

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 201 / KATEWADI (AG)
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583		.1646		.1463	1.0486	
2	.6401		.1829		.1463	1.0814	
3	.6226		.2012		.1646	1.1305	
4	.6226		.2012		.1829	1.1797	
5	.7545		.2561		.2012	1.2452	
6	1.0059		.2926		.2561	1.3435	
7	1.4754		.3292		.3292	1.4255	
8	1.6787		.2743		.2743	1.7204	
9	.2103	1.5074	1.6356	1.6032	1.6575	.168	.2229
10	.2012	1.6385	1.9109	1.7652	1.7072	.1478	.1543
11	.1494	1.9006	1.9271	1.8896	1.757	.1307	.1372
12	.1307	1.9826	2.0081	1.8896	1.8299	.128	.1029
13	.1132	2.0481	1.9109	1.9062	1.7814	.0905	.0876
14	.0943	2.0809	1.8299	1.7166	1.7901	.0914	.0701
15	.0943	1.8515	1.7166	1.7072	1.7736	.0914	.0895
16	.1086	1.8233	1.6356	1.5912	1.6907	.0934	.0876
17	.1448	.12	.12	.1402	.12	.1307	.0895
18	.181	.1433	.1372	.1715	.1372		.1294
19	.1991	.1928	.2103	.197	.2058		.1867
20	.181	.1844	.1886	.1928	.1886		.2054
21	.1629	.1372	.1715	.1753	.1715		.2075
22	.1867		.1646	.1829	.1646	.1829	.1867
23	.168		.1463	.1829	.7865	.7865	.8356
24	.6081		.1463		.1463	.9831	.8097
Max	1.6787	2.0809	2.0081	1.9062	1.8299	1.7204	.8356
Min	.0943	.12	.12	.1402	.12	.0905	.0701
Avg	.4299	1.2008	.7401	1.0208	.7337	.6600	.2252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 202 / 11 kKV KATEWADI (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077		.3772		.415	.3772	
2	.2743		.3772		.415	.3961	
3	.2715		.3841		.4527	.3961	
4	.2896		.415		.4904	.3932	
5	.3881		.439		.5281	.4424	
6	.6161		.4904		.6036	.547	
7	.6036		.5658		.6602	.679	
8	.6413		.6602		.6224	.6979	
9	.5658	.5281	.5228	.5788	.5228	.5914	.5228
10	.4481	.3772	.3734	.3921	.4108	.5041	.4294
11	.3395	.3395	.3174	.3734	.3547	.3881	.3921
12	.298	.3395	.2614	.2801	.2896	.3292	.3174
13	.2481	.3018	.2427	.2987	.2172	.3258	.2378
14	.1677	.2829	.2427	.2801	.2353	.2715	.1698
15	.2172	.2829	.2614	.2801	.2353	.2865	.2427
16	.2614	.2715	.2801	.2987	.2561	.2658	.1663
17	.2987	.3582	.2587	.3121	.3174	.3292	.2427
18	.4481	.3475	.3547	.3841	.3921		.3511
19	.5228	.5415	.5175	.4904	.5788		.4527
20	.4854	.4527	.4904	.4904	.5228		.4527
21	.4481	.4294	.4481	.4294	.4668		.4904
22	.4066		.3961	.415	.415	.4715	.4066
23			.415	.415	.3772	.3961	.3772
24	.3142		.415		.415	.3772	
Max	.6413	.5415	.6602	.5788	.6602	.6979	.5228
Min	.1677	.2715	.2427	.2801	.2172	.2658	.1663
Avg	.3853	.3733	.3961	.3812	.4248	.4233	.3501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 205 / 11 KV INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.221		.3429		.3429	.3429	
2	.2241		.3601		.3429	.3429	
3	.2286		.3601		.3429	.3601	
4	.2096		.3601		.3601	.3601	
5	.2431		.3772		.3601	.3772	
6	.1829		.3772		.3772	.4115	
7	.1943		.3772		.3772	.4287	
8	.1928		.3772		.3944	.4115	
9	.1829	.3258	.3944	.4115	.3772	.4031	.3601
10	.204	.3429	.3944	.4287	.3944	.4298	.3944
11	.2305	.3429	.3601	.3944	.3944	.3982	.4458
12	.1715	.3429	.3944	.431	.3647	.4024	.4115
13	.0438	.3429	.3944	.4144	.3978	.4108	.3812
14	.0953	.3429	.3944	.4527	.4144	.2477	.2949
15	.208	.3772	.3772	.4748	.421	.2721	.3258
16	.3601	.3605	.4115	.4144	.426	.2934	.3601
17	.3601	.197	.3647	.4024	.4287	.3144	.3201
18	.3601	.2195	.4024	.4144	.3978		.2858
19	.3601	.3605	.4527	.4239	.4287		.2809
20	.3601	.3932	.431	.3856	.4115		.3441
21	.3401	.3768	.3978	.3944	.4115		.2599
22			.3944	.3772	.4115		.2286
23			.3429	.3772	.3772		.3429
24	.2362		.3429		.3429	.3944	
Max	.3601	.3932	.4527	.4748	.4287	.4298	.4458
Min	.0438	.197	.3429	.3772	.3429	.2477	.2286
Avg	.2368	.3327	.3826	.4131	.3874	.3667	.3357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 206 / 11 KV GAWARKHOPAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3749		.0366		.0366	.6882	
2	.3658				.0366	.7045	
3	.3715		.0549		.0366	.7209	
4	.3913		.0549		.0549	.7209	
5	.4268		.0549		.0549	.7537	
6	.4938		.0549		.0549	.7537	
7	.4999		.0549		.0549	.7865	
8	.4999		.0549		.0549	.8192	
9	.0924	.5898	.8097	.9069	.8421	.0739	.0343
10	.0747	.7537	1.1336	1.1271	1.0202	.0747	.0343
11	.0554	.9831	1.166	1.2266	1.0364	.0554	.0343
12	.0566	.9831	1.166	1.2631	1.1142	.0373	.0343
13	.0566	.9831	1.1012	1.3426		.037	.0328
14	.0566	1.0486	1.004	1.2125	1.004	.0377	.0328
15	.037	.9503	.8745	1.0608	1.0364	.0377	.0347
16	.0343	.9175	.9393	1.0277	1.004	.0377	.0335
17	.0514	.0343	.0492	.0335	.0343	.056	.0566
18	.0514	.0514	.0492	.0335	.0343		.0754
19	.0514	.0503	.0503	.0332	.0514		.0754
20	.0514	.0497	.0497	.0332	.0514		.0754
21	.0514	.0332	.0492	.0497	.0514		.0747
22			.0366	.0549	.0549	.0549	.0747
23			.0366	.0549	.6554	.7209	.439
24	.3567		.0366		.0366	.6882	
Max	.4999	1.0486	1.166	1.3426	1.1142	.8192	.439
Min	.0343	.0332	.0366	.0332	.0343	.037	.0328
Avg	.2046	.5714	.3877	.6307	.3657	.3930	.0761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 201 / 11 KV DHUMALWADI SINGLE SINGLE PHASING
PH. Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	1.7695	1.6766	1.6385	1.6712	.6859	.7095
2	.6516	1.6385	1.6004	1.6385	1.6712	.6516	.7095
3	.6859	1.6575	1.6004	1.6057	1.8023	.6687	.7095
4	1.0288	1.8023	1.6766	1.6057	1.9334	.6859	.7842
5	1.3375	2.13	1.829	1.9662	2.0165	1.1488	1.1576
6	1.406	2.5149	2.0729	2.2939	2.2245	1.5261	1.531
7	1.6118	2.6749	2.4996	2.6216	2.6086	1.6632	1.8107
8	1.4575	2.7854	2.8045	3.0178	2.9329	1.4746	1.4091
9	2.5149	1.1203		1.2323	1.2254	3.0521	3.0803
10	3.0483	.7468		.7842	.5138	3.6866	3.5719
11	2.8182	.5316	.6859	.5144	.3086	3.8923	3.5665
12	3.0521	.4801	.5144	.463	.2743	3.6008	3.3836
13	3.2579	.4801	.4801	.463	.5144	2.774	
14	3.2579	.463	.4801	.4938	.4572	3.3265	3.0178
15	3.1893	.4287	.4801	.4938	.5144	3.3436	3.0483
16	2.8178	.4801	.5601	.5487	.6001	3.3608	2.7282
17	.7468	.6344	.7095	.695	.6859	.6161	.6344
18	1.0829	.9602	.8962	.9694	.9774	.9709	.8916
19	1.2323	1.3203	1.5089	1.4937	1.3032	1.5466	1.2689
20	1.4712	1.2689	1.5466	1.4998	1.286	1.5844	1.2346
21	1.3817	1.1488	1.5089	1.2254	1.1317	1.2449	1.1145
22	.9709	.8573	.9335	.9877	.8916	1.0456	.8916
23	1.8351	1.7528	1.8023	1.6964	.703	.811	.7373
24	.6859	1.7695	1.7528	1.7368	1.6804	.6859	.7468
Max	3.2579	2.7854	2.8045	3.0178	2.9329	3.8923	3.5719
Min	.6516	.4287	.4801	.463	.2743	.6161	.6344
Avg	1.7595	1.3090	1.3463	1.3202	1.247	1.8353	1.6842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 202 / 11 KV DHAKALE SINGLE PH. SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.3361	.2743	.3361	.2439	1.1145	.9335
2	.6097	.3361	.2743	.3361		1.1317	.9335
3	.6097	.3734	.3086	.3361	.3361	1.1145	.9335
4	.6859	.3734	.3086	.3734	.4024	1.166	1.0456
5	.6859	.5228	.4287	.4481	.4755	1.2346	1.2323
6	.7621	.6722	.6344	.6722	.695	1.2689	1.3203
7	1.0669	.8962	.7888	.8962	.823	1.6975	1.4563
8	1.4022	.7468	.6516	.8215	.7316	1.9033	1.8023
9	.0463	1.4746		1.704	1.7204	.5144	.5601
10	.3086	1.9006		1.9006	1.8023	.5487	.3734
11	.2987	1.89	2.2634	2.1262	1.8176	.2241	.2401
12	.1886	2.0119		2.2805	1.448	.2241	.2058
13	.2058	2.1033	2.1434	2.2291	1.5851	.2241	.2229
14	.1372	1.9357	2.1262	2.0005	1.3413	.2058	.2058
15	.1543	2.0119	2.1262	1.9109	2.1262	.1372	.2058
16	.2241	1.9052	1.9376	1.8351	1.9204	.2401	.2058
17	.2614	.2058	.2801	.2926	.2572	.2641	.2401
18	.3734	.3429	.3734	.4207	.3772	.4527	.3772
19	.5228	.583	.6036	.5975	.6516	.6413	.5487
20	.6722	.5487	.679	.6584	.6001	.6722	.4801
21	.6722	.3429	.6413	.5487	.5658	.6348	.4801
22	.5041	.3944	.4481	.4251	.463	.4108	.3772
23	.3361	.3086	.3734	.3361	1.0802	.9175	.7468
24	.6859	.3361	.2743	.3734	.3361	1.1488	.8848
Max	1.4022	2.1033	2.2634	2.2805	2.1262	1.9033	1.8023
Min	.0463	.2058	.2743	.2926	.2439	.1372	.2058
Avg	.5035	.9397	.8543	.9941	.9478	.7538	.6672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 203 / 11 KV MIDC FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2263	.1715	.1886	.3395	.2572	.1509
2	.2229	.2263	.2401	.1886	.3395	.2572	.2263
3	.2229	.2263	.2401	.1509	.3018	.2572	.2263
4	.2401	.2452	.2229	.1509	.3395	.2572	.2263
5	.2401	.2452	.2743	.1509	.415	.2572	.1886
6	.2401	.2452	.2743	.1509	.4715	.3086	.1886
7	.2229	.2641	.2915	.2641	.3961	.2743	.2641
8	.2401	.2829	.2743	.3018	.2641	.4801	.6036
9	.2401	.3772		.3395	.2641	.5487	.5658
10	.2134	.4527		.3772	.5093	.7202	.5658
11	.6979	.4115	.3395	.6706	.4287	.7545	.463
12	.463	.4268	.3086	.4572	.4115	.679	.4287
13	.1372	.2915	.4801	.1677	.1219	.1509	.1543
14	.1372	.2401	.3963	.415	.381	.3258	.2572
15	.1543	.5144	.381	.7167	.4458	.5316	.3772
16	.6036	.4458	.2743	.6036	.4115	.2058	.2915
17	.4715	.3944	.3772	.6036	.3772	.6602	.4115
18	.1886	.1372	.3772	.5847	.4115	.4904	.3772
19	.2641	.1372	.415	.5658	.2401	.3584	.4115
20	.3018	.2743	.3018	.4904	.2229	.3018	.3601
21	.2829	.2915	.3018	.3772	.2401	.2263	.3258
22	.2829	.2401	.2641	.3018	.1372	.1132	.1543
23	.2263	.12	.2641	.415	.2572		.3772
24	.2401	.2263	.12	.2263	.3772	.2743	.1132
Max	.6979	.5144	.4801	.7167	.5093	.7545	.6036
Min	.1372	.12	.12	.1509	.1219	.1132	.1132
Avg	.2823	.2893	.2995	.3691	.3377	.3778	.3212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 204 / 11 KV PANDHRE SINGLE PH. SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	.5281	.3429	.4527	.3734	1.5432	1.4746
2	1.2193	.4904	.3429	.4527	.3734	1.5432	1.4746
3	1.2193	.4904	.3429	.4527	.4108	1.5432	1.4746
4	1.2498	.6413	.4287	.5658	.4854	1.5432	1.6244
5	1.2955	.9054	.5487	.7167	.7842	1.8004	1.7814
6	1.3717	1.1317	.9088	.9808	1.0269	1.9033	1.9662
7	1.6004	1.2071	1.1145	1.1694	1.2323	2.2805	2.1628
8	1.829	1.2071	1.0288	1.1317		2.4006	2.2834
9	.7888	2.2611			2.5126	.7716	.9431
10	.6173	2.9492		2.9797	2.9287	.5487	.679
11	.6413	2.5911	3.1207	2.9569	3.1722	.4801	.4801
12	.5316	2.9264	3.0864	2.8807	2.8197	.3772	.463
13	.463	3.0178	3.1036	2.8349	2.6978	.3429	.4287
14	.4287	2.8959	2.5911	2.7846	2.713	.3429	.3944
15	.4115	2.8197	2.5453	2.9165	2.915	.3772	.3772
16	.5281	2.6368		2.834	2.692	.3944	.3772
17	.6348	.5658	.5281	.5788	.4973	.5847	.4801
18	.7095	.6516	.7545	.7095	.703	.7922	.6173
19	.8676	.9945	.9808	.8215	1.0288	1.0185	.9602
20	1.0562	.9774	1.0185	1.0456	.9259	1.0562	.8916
21	1.0374	.8402	.9808	.8962	.8573	.9431	.8573
22	.679	.6516	.7356	.6348	.6859	.7167	.6173
23	.5281	.4287	.4904	.4481	1.6975	1.6057	1.2498
24	1.2955	.5281	.3601	.4904	.4108	1.5432	1.5074
Max	1.829	3.0178	3.1207	2.9797	3.1722	2.4006	2.2834
Min	.4115	.4287	.3429	.4481	.3734	.3429	.3772
Avg	.9285	1.4307	1.2073	1.3798	1.4758	1.1022	1.0652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 207 / GAVTHANPANDARE SANGAVI NON SHEDDABLE WATER SUPPLY AND
PANIPUR Feeder KV- 11 / OUTGOING UTILITY

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0152	.0305	.0575
2					.0152	.0343	.0369
3					.0152	.0305	.0152
4					.0305	.0305	.0152
5	.0171				.0865	.0846	.0758
6	.0297	.0575		.0408	.0952	.1623	.0621
7	.1154	.1097	.1101	.1036	.1086	.1806	.0686
8	.1147	.1109	.1166	.1067	.107	.1604	.0152
9	.1154	.1158	.0697	.109	.1143	.1528	.0652
10	.104	.115	.0671	.1059	.112	.1532	.0644
11	.1032	.1021	.1021	.107	.1261	.128	.1116
12	.1101	.1135	.0869	.1059	.1154	.1223	.1196
13	.112	.1204	.0918	.1074	.1173	.1406	.1463
14	.112	.1166	.1013	.0945	.0964	.1128	.12
15	.0865	.1215	.1131	.0613	.1055	.1059	.0869
16	.0971	.0892	.0987	.0305	.1314	.096	.088
17	.0579	.0632	.077	.0209	.1272	.1002	.088
18	.0152		.0762	.0152	.0838	.0926	.0846
19	.0152		.0019	.0189	.0194	.0529	.0099
20	.0152			.0152	.0171	.0583	.0171
21	.0152			.0152	.0152	.0205	
22				.0152	.0152	.0438	
23				.0152	.0305	.0522	
24					.0152	.072	.0152
Max	.1154	.1215	.1166	.109	.1314	.1806	.1463
Min	.0152	.0575	.0019	.0152	.0152	.0205	.0099
Avg	.0727	.1030	.0856	.0605	.0715	.0924	.0649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN

Feeder No / Name : 201 / 11 KV KARAHATI SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.2829	.3658	.3018	.2829	.4904	.6036
2	.5658	.2829	.3772	.3018	.2829	.4904	.5658
3	.6036	.2829	.3395	.3395	.2829	.5093	.5658
4	.6584	.3395	.3658	.4527	.3772	.5281	.5281
5	.695	.5281	.4755	.5281	.4904	.5847	.6602
6	.9431	.7545	.695	.679	.679	.7545	.7922
7	1.2826	.8299	.8413	.9431	.9054	1.2071	1.226
8	1.4335	.8488	.823	.9054	.8488	1.3957	1.6221
9	.6602	1.094		1.1317	1.2071	.6413	.6602
10	.4715	1.5089		1.4146	1.358	.4527	.5093
11	.415	1.7353	1.2071	1.2637	1.5466	.3584	.415
12	.3395	1.6975	1.0185	1.4335	1.4335	.2561	.415
13	.2829	1.6975	1.094	1.4146	1.4146	.2195	.2641
14	.2263	1.5466	1.2826	1.4146	1.5089	.2263	.2641
15	.2829	1.4335	1.358	1.3769	1.4712	.2641	.2641
16	.3018	1.5089	1.4146	1.358	1.4712	.2641	.2829
17	.3018	.3658	.3395	.3584	.3395	.3395	.3772
18	.4904	.4527	.4715	.4904	.5281	.3206	.5658
19	.7922	.6036	.8299	.8299	.8299	.5487	.7922
20	.7922	.6979	.7545	.811	.7545	.7545	.679
21	.679	.5658	.6036	.679	.7167	.6602	.6413
22	.4338	.4715	.4904	.5281	.5281	.4904	.4715
23	.3584		.3961	.415	.4904	.5281	.5658
24	.5487	.3018	.3772	.3395	.3018	.5093	.5658
Max	1.4335	1.7353	1.4146	1.4335	1.5466	1.3957	1.6221
Min	.2263	.2829	.3395	.3018	.2829	.2195	.2641
Avg	.5885	.8622	.7237	.8213	.8354	.5331	.5957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN

Feeder No / Name : 202 / 11 KV DEULGAON SINGLE SINGLE PHASING
PHASING Feeder KV- 11 /
OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2263	.3018	.2641	.2641	.2829	.2641
2	.2561	.2263	.3018	.2263	.2641	.2641	.2829
3	.2926	.2075	.2743	.2263	.3018	.2641	.3018
4	.3395	.2452	.3292	.3395	.3395	.3018	.3395
5	.3658	.3395	.3772	.3961	.3395	.415	.4715
6	.547	.3395	.4024	.4715	.3961	.547	.679
7	.679	.7733	.7167	.7733	.7545	.7922	.7356
8	.6036	.9054	.9431	1.0751	1.0374	.6602	.6979
9	.4715	.4527		.3772	.4527	.5658	.4904
10	.679	.3018		.3206	.3018	.7733	.6413
11	.6602	.1886	.1886	.2452	.2075	.6979	.7167
12	.7167	.0943	.132	.1698	.1698	.6219	.6413
13	.7167	.0943	.132	.1698	.1509	.5658	.5658
14	.3395	.0566	.1132	.1509	.1509	.5658	.4527
15	.5658	.0943	.132	.1698	.1509	.6224	.4527
16	.5658	.1132	.132	.1698	.1509	.5658	.547
17	.2452	.1509	.1698	.2452	.2075	.2012	.2452
18	.3018	.3018	.2829	.3584	.415	.3206	.3395
19	.5658	.3772	.5658	.6036	.6036	.4527	.547
20	.5093	.4715	.5281	.547	.5281	.5093	.5093
21	.4527	.3772	.4527	.4338	.4904	.4527	.4338
22	.3206	.3018	.3395	.3395	.3961	.3772	.3772
23	.2452		.2263	.2641	.3206	.3206	.3395
24	.2561	.2263	.3018	.2641	.2641	.3018	.3018
Max	.7167	.9054	.9431	1.0751	1.0374	.7922	.7356
Min	.2452	.0566	.1132	.1509	.1509	.2012	.2452
Avg	.4563	.2985	.3338	.3584	.3607	.4768	.4739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN

Feeder No / Name : 204 / 11 KV SYNBACHIWADI SINGLE SINGLE PHASING
PHAS Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4549	.3795	.3229	.4549	.1698	.2641	.2829
2	.4549	.3795	.32	.4549	.1698	.2641	.2829
3	.4927	.4172	.3418	.5689	.1886	.2452	.2641
4	.5304	.5311	.4511	.6066	.2263	.2829	.3018
5	.682	.6451	.4934	.7205	.3018	.3018	.3772
6	1.1736	.8344	.7213	.9107	.415	.4715	.6036
7	2.0462	1.1574	.9869	1.119	.5281	.8299	.9997
8	2.2748	1.0624	1.0254	1.0624	.4527	1.094	1.1883
9	1.3121	1.4019	.6097	1.2699	.547	.3395	.3395
10	.6262	2.2009	.9145	1.7059	.7545	.2829	.3395
11	.4934	2.2755	1.9715	1.5739	.8299	.2075	.2075
12	.4557	2.0854	1.8953	1.5731	.8488	.1829	.1886
13	.3795	2.1993	1.8583	1.6871	.9054	.132	.1509
14	.3418	2.1239	1.5928	1.7059	.8299	.1132	.132
15	.2656	1.9338	1.4788	1.6305	.7733	.0943	.1132
16	.3033	1.7444	1.46	1.4788	.7545	.0943	.132
17	.3984	.913	.7417	.7983	.1698	.1097	.1698
18	.55	.4557	.5311	.55	.2452	.1886	.2263
19	.9296	.7164	.7967	.8156	.415	.2263	.3395
20	.8919	.741	.8344	.8919	.3395	.2452	.3018
21	.759	.5273	.7967	.759	.3018	.2452	.2452
22	.6073	.513	.6828	.6451	.2452	.1886	.2075
23	.4746	.3048	.5689	.5123	.2641	.2263	.2641
24	.4549	.3984	.3991	.5311	.1698	.2452	.2452
Max	2.2748	2.2755	1.9715	1.7059	.9054	1.094	1.1883
Min	.2656	.3048	.32	.4549	.1698	.0943	.1132
Avg	.7230	1.0809	.9081	1.0011	.4519	.2865	.3293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN

Feeder No / Name : 205 / 11 KV SONPIRWADI SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.5304	.682	.796	.415	.2641	.3018
2	.5304	.5304	.7468	.8337	.4527	.2641	.3206
3	.6066	.6443	.7205	.8714	.4527	.3018	.3395
4	.6443	.7771	.796	.9853	.5281	.3961	.4527
5	1.0059	1.1748	.9476	1.0993	.5658	.547	.5658
6	1.4724	1.5354	1.2321	1.3461	.679	.7545	.8865
7	1.9142	1.7437	1.8656	1.9142	.9808	.9619	1.0374
8	1.8961	1.8199	2.6158	2.5404	1.226	.9054	.9808
9	1.6871	1.8945	1.0669	1.7648	.6602	.9431	.9619
10	2.3314	2.1986	.5335	1.1001	.5093	1.1317	1.094
11	2.0854	2.4447	.7205	.7394	.3018	1.2071	1.094
12	2.142	2.351	.4549	.4172	.2641	1.1694	1.1317
13	2.1231	2.2748	.2286	.3222	.2075	1.1694	1.1317
14	2.0666	2.1993	.341	.2844	.2263	1.0059	.9054
15	1.9338	2.01	.3787	.3222	.1886	.9145	.9431
16	1.9904	1.8961	.3787	.3976	.1886	.9431	1.0185
17	1.0073	1.0631	.5492	.4927	.3018	.2561	.3584
18	.7009	.9091	.891	.8525	.547	.4715	.5093
19	1.592	1.4034	1.5166	1.5166	.8299	.6413	.8488
20	1.555	1.4788	1.4977	1.5166	.7545	.7545	.7733
21	1.2895	1.1755	1.214	1.3657	.5847	.5847	.6413
22	.9862	.8596	1.0616	1.0616	.4715	.5093	.4715
23	.7016	.381	.7205	.8337	.3395	.3395	.3584
24	.5974	.6639	.7582	.796	.415	.2829	.3018
Max	2.3314	2.4447	2.6158	2.5404	1.226	1.2071	1.1317
Min	.5304	.381	.2286	.2844	.1886	.2561	.3018
Avg	1.3913	1.4150	.9133	1.0071	.5038	.6966	.7262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN

Feeder No / Name : 206 / 11 KV JALGAON (KP) SINGLE SINGLE PHASING
PHAS Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5115	.4361	.4481	.4927	.4549	.7205	.7205
2	.5115	.4361	.3787	.4927	.4927	.682	.7205
3	.4927	.4549	.4361	.3787	.5304	.7394	.7394
4	.6443	.4549	.4927	.5304	.5304	.7771	.796
5	.7575	.4927	.4927	.5681	.5681	.9476	1.0993
6	.8748	.5492	.5877	.6632	.7009	1.1371	1.3264
7	1.4215	1.023	.9673	1.1937	1.1559	1.6675	1.6297
8	1.4788	1.3264	1.555	1.5354	1.4215	1.6493	1.7255
9	1.1001	1.2699	.6097	1.3649	1.3649	1.1959	1.2525
10	.9853	.9485	.5335	1.1001	1.1567	.9287	1.0616
11	.6828	.7205	.7205	.6639	.7205	.9287	.9476
12	.3048	.3991	.5689	.4165	.5689	.8722	.8525
13	.8337	.4927	.4549	.4927	.5877	.8722	.9287
14	.9287	.4549	.3599	.4927	.4927	.7468	.6828
15	.9476	.4738	.4549	.4927	.4738	.6443	.796
16	.891	.4927	.4738	.4927	.5115	.7205	.891
17	.6639	.6443	.4361	.6443	.6443	.6066	.796
18	.8714	.9327	.8525	.9665	.9476	.796	1.1371
19	1.2699	1.2712	1.3838	1.4026	1.4026	1.2517	1.4026
20	1.251	1.4223	1.3461	1.3838	1.3461	1.3083	1.3461
21	1.1755	1.0822	1.1378	1.1378	1.1755	1.2321	1.251
22	1.0428	.9287	.9862	.9107	1.0428	1.0428	1.1755
23	.6073	.381	.6451	.6073	.8533	.891	1.0239
24	.5115	.4549	.4549	.4927	.6073	.7771	.8722
Max	1.4788	1.4223	1.555	1.5354	1.4215	1.6675	1.7255
Min	.3048	.381	.3599	.3787	.4549	.6066	.6828
Avg	.8650	.7309	.6990	.7882	.8230	.9640	1.0489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 201 / 11 KV KARKHANA SINGLE SINGLE PHASING
 PHASING Feeder KV- 11 /
 OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.785	.5224	.5123	.2614	.2303	.5304	.6413
2	.8617	.5936	.586	.2801	.2126	.5304	.6413
3	.9684	.6878	.7535	.2801	.2303	.4915	.6413
4	1.0326	.9183	.8879	.2829	.2658	.5735	.6602
5	1.1451	1.0195	.9918	.4435	.3898	.5898	.7468
6	1.1965	1.0928	.9911	.5544	.6024	.6478	.763
7	1.0546	1.0669	1.049	.7865	.7087	.8421	.8139
8	1.0831	1.7402	1.4994	.695	.567	.7773	.8916
9	.8734	1.911	1.0059	.8859	.8002	.5068	.543
10	.6097	2.0527	1.0136	.9259	.8848	.439	.3841
11	.6325	2.0439	2.1325	.8855	.8848	.3584	.3658
12	.6325	2.0527	2.0591	.8539	.9175	.2829	.2896
13	.6144	2.0767	2.1429	.8381	.9116	.2829	.2534
14	.6676	1.9988	2.0999	.8855	.8848	.2452	.2534
15	.8063	2.0081	1.9883	.9172	.9012	.2263	.2534
16	1.1012	1.6945	1.7184	.8855	.9069	.2641	.2195
17	1.1889	1.0203	1.0458	.3189	.3258	.3206	.3258
18	1.1889	1.0581	1.0979	.3898	.394	.4715	.3982
19	1.2289	1.0677	1.1416	.5316	.5373	.5658	.543
20	1.1088	.8872	.88	.4784	.543	.5281	.4706
21	1.0288	.7857	.7869	.443	.4706	.5658	.4572
22	.9587	.626	.6401	.3544	.3982	.415	.4024
23	.8565	.5197	.5457	.2658	.5636	.6413	.5636
24	1.0707	.5102	.4665	.2614	.2303	.5304	.6036
Max	1.2289	2.0767	2.1429	.9259	.9175	.8421	.8916
Min	.6097	.5102	.4665	.2614	.2126	.2263	.2195
Avg	.9456	1.2481	1.1682	.5710	.5734	.4845	.5053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 202 / 11 KV SHARADANAGAR SINGLE SINGLE PHASING
PHAS Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2635	1.9097	1.9547	.9593	.8697	.2957	.3077
2	1.2026	1.748	1.7784	.9568	.8381	.2587	.3109
3	.9478	1.4203	1.6564	.9465	.8697	.2743	.3109
4	1.044	1.514	1.7185	.9568	.9014	.4024	.3292
5	1.2544	1.7216	1.8187	.9816	.9488	.4572	.5068
6	1.419	1.5784	1.9158	1.0631	.9804	.6154	.6697
7	1.3861	1.5641	1.7276	1.2039	1.1069	.8869	.8326
8	2.5292	1.7768	1.7147	1.2763	1.2651	.9774	.9231
9	2.9885	1.0772	.3887	.6653	.7265	1.2289	1.4091
10	3.0159	.9203	.3734	.5487	.4784	1.4251	1.3763
11	2.9226	.8164	.8017	.4252	.4298	1.3735	1.3435
12	3.1169	.8013	.8519	.3898	.394	1.5415	
13	3.1718	.8547	.8116	.3189	.4024	1.379	1.3279
14	2.9674	.9031	.8617	.3898	.362	1.4243	1.4419
15	2.8818	1.0327	.9543	.3366	.4344	1.4243	1.3765
16	2.6177	1.9393	1.897	.3898	.4525	1.3056	1.4091
17	1.4068	1.9113	1.9784	.4252	.4344	.5281	.439
18	1.3855	1.2574	1.9204	.567	.5373	.5658	.5068
19	1.3013	1.9833	2.0538	.7265	.7522	.7282	.6878
20	1.1412	1.707	1.1584	.691	.724	.7468	.6516
21	.983	1.5981	1.8117	.6556	.6335	.6979	.5853
22	.8322	1.512	1.6747	.5316	.5792	.5847	.5487
23	1.1565	1.8938	2.0165	.9922	.3982	.415	.4024
24	.6419	1.789	2.0767	.8886	.8697	.3258	.3395
Max	3.1718	1.9833	2.0767	1.2763	1.2651	1.5415	1.4419
Min	.6419	.8013	.3734	.3189	.362	.2587	.3077
Avg	1.8157	1.4679	1.4965	.7203	.6829	.8276	.7842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 203 / 11 KV YELEWASTI SINGLE SINGLE PHASING
PHASING Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5241	.9233	.9815	.4294	.4252	.8288	.9602
2	1.6994	1.0784	1.129	.4294	.3898	.8288	
3	1.9637	1.2994	1.3549	.415	.4252	.852	.9448
4	2.0641	1.7654	1.6057	.415	.6733	.9503	.9503
5	2.1672	2.0567	1.8261	.7602	.9568	1.0364	1.0814
6	2.1452	2.0538	2.1044	.9816	1.0985	1.166	1.1498
7	2.1659	1.9262	1.8728	1.1568	1.3112	1.4403	1.1498
8	2.0966	3.2289	3.0742	1.1603	1.2757	1.4899	1.5708
9	1.3931	3.3436	1.7985	1.4575	1.3599	.9412	1.0242
10	1.154	3.4309	1.8366	1.6244	1.5181	.7682	.8688
11	.9999	3.4221	3.4454	1.5339	1.6194	.4668	.5973
12	1.0684	3.711	3.6057	1.6129	1.6057		.5792
13	1.105	3.6477	3.597	1.4864	1.5746	.6099	.5068
14	1.1873	3.4614	3.5406	1.3599	1.5074	.4854	.439
15	1.3885	3.4408	3.3531	1.3599	1.4255	.3395	.4344
16	2.2847	2.9279	3.0266	1.3441	1.3279	1.3056	
17	2.4101	2.0275	1.9357	.4607	.5068		.5068
18	2.292	2.1083	1.9982	.7796	.6335		.6516
19	2.2729	1.9932	2.0515	1.0277	.9593		.9412
20	1.9414	1.7162	1.6227	.9922	.9313	1.0288	.9412
21	1.8823	1.4575	1.4013	.9214	.8145	.8916	.8048
22	1.8457	1.2041	1.2465	.6733	.7602	.7712	.7316
23	1.6497	.9888	.9824	.4784	.9282	.9835	.9614
24	2.1491	.8715	.9231	1.5339	.4252	.8951	.9389
Max	2.4101	3.711	3.6057	1.6244	1.6194	1.4899	1.5708
Min	.9999	.8715	.9231	.415	.3898	.3395	.4344
Avg	1.7854	2.2535	2.0964	1.0164	1.0189	.9040	.8516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 204 / 11 KV 22 PHATA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1709	1.5444	1.4992	.7602	.6325	.181	.1886
2	1.0909	1.3831	1.2765	.7701	.6009	.1829	.1886
3	.5929	.9297	.95	.7865	.6325	.1646	.1698
4	.6571	1.0665	1.0425	.7865	.6642	.3109	.2075
5	.7278	1.211	1.1471	.8916	.7274	.362	.3395
6	.7751	1.3146	1.2388	.9892	.7907	.4344	.4904
7	.7689	1.3774	1.3338	1.1633	.9488	.5068	.547
8	1.8538	1.3988	1.3045	1.2163	.9962	.4887	.4904
9	2.6966	.5259	.1638	.3696	.3439	1.0159	1.1498
10	2.6349	.3383	.1524	.2452	.2743	1.2631	1.166
11	2.7035	.3106	.404	.1772	.1991	1.358	1.1469
12	2.6338	.3157	.3734	.1772	.1629	1.2795	1.1012
13	2.7236	.3145	.3704	.1595	.1629	1.2174	1.166
14	2.6445	.3273	.1494	.124	.1463	1.1517	1.2452
15	2.6959	.4631	.2231	.1417	.1448	1.1145	1.1336
16	2.3243	1.6276	1.5682	.1949	.1612	1.1163	1.1012
17	.7629	1.6287	1.6606	.2126	.2534	.2829	.2195
18	.8093	1.5701	1.6176	.3012	.3077	.3206	.2715
19	.7183	1.4466	1.5013	.3898	.3582	.3772	.362
20	.5921	1.2563	1.3075	.3721	.3258	.3584	.3077
21	.4991	1.1738	1.2049	.2835	.2715	.2641	.2743
22	.4321	1.0724	1.0951	.2303	.2353	.2641	.2195
23	.8421	1.5221	1.5642	.6483	.1991	.1886	.1829
24	.3399	1.5554	1.5488	.7602	.6325	.181	.1829
Max	2.7236	1.6287	1.6606	1.2163	.9962	1.358	1.2452
Min	.3399	.3106	.1494	.124	.1448	.1646	.1698
Avg	1.4038	1.0697	1.0290	.5063	.4238	.5994	.5772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 205 / 11 KV KHANDAJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9099	1.8739	1.898	1.3032	1.1544	.2195	.2075
2	.8587	1.8156	1.7748	1.2887	1.1227	.2195	.1886
3	.3715	1.2898	1.3569	1.2616	1.1544	.1829	.1886
4	.4405	1.5341	1.4419	1.3203	1.186	.4066	.2195
5	.6874	1.619	1.528	1.3765	1.2967	.5121	.4572
6	.8097	1.691	1.7696	1.4864	1.4232	.5853	.6036
7	.8088	1.8564	1.8362	1.6716	1.5813	.6516	.679
8	1.5516	2.0157	1.9018	1.7185	1.6129	.6154	.6036
9	3.1503	.4698	.0724	.3734	.4252	1.704	2.13
10	3.1531	.3167	.0724	.2641	.2926	2.1052	2.0081
11	3.0712	.2065	.218	.1949	.2534	2.0424	2.2672
12	3.3059	.1888	.218	.1595	.1772	1.9845	2.1376
13	3.357	.2002	.212		.1433	1.8724	2.17
14	2.9245	.2307	.2713	.124	.1433	2.0729	2.0243
15	2.9878	.3208	.3247	.124	.1629	2.1091	1.9433
16	2.835	1.1679	1.4784	.1772	.181	1.9766	1.8785
17	.599	1.3201	1.3405	.2126	.2195	.2829	.2926
18	.7187	1.2791	1.3717	.3366	.3292	.3772	.362
19	.775	1.3066	1.3771	.5493	.4706	.5281	.4706
20	.6257	1.1658	1.2604	.4607	.4298	.4527	.4344
21	.5144	1.0631	1.1462	.3898	.3982	.4024	.3658
22	.4214	.9909	1.0296	.3544	.3658	.3018	.2926
23	1.3671	1.8789	1.9296	1.1702	.2896	.2641	.2561
24	.3414	1.9376	1.9056	1.3032	1.1544	.2561	.2263
Max	3.357	2.0157	1.9296	1.7185	1.6129	2.1091	2.2672
Min	.3414	.1888	.0724	.124	.1433	.1829	.1886
Avg	1.5244	1.1558	1.1556	.7661	.6653	.9219	.9336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.

Feeder No / Name : 201 / 11 KV PARWADI SINGLE SINGLE PHASING
 PHASING Feeder KV- 11 /
 OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.5801		.5992	.6464	.1886	.1698
2	.1698	.5801		.6062	.6464	.1886	.1698
3	.1698	.5801		.6062	.6464	.1886	.1886
4	.2075	.6299		.664	.6796	.2263	.2263
5	.3395	.7625		.7209	.9116	.4338	.2829
6	.547	.9282		.9175	1.0111	.5093	.5281
7	.7545	1.1768		1.2289	1.3592	.7167	.6602
8	.679	1.2431		1.2452	1.442	.679	.6224
9	1.2163	.4715		.4096	.4715	1.1603	1.2631
10	1.3443	.3018	.2987	.3174	.3206	1.4586	1.3923
11	1.4413	.132	.1494	.2054	.2263		1.4413
12	1.4413	.0943	.1307	.1132	.1132	1.2955	1.3283
13	1.0526	.132	.0934	.0943	.0943	1.3441	1.3117
14	1.2146	.0943	.112	.1132	.0943	1.3927	1.065
15	1.2793	.0943	.112	.112	.1132	1.3603	1.1843
16	1.1984	.1132	.1132	.132	.132	1.1822	1.2125
17	.132	.0943	.1698	.1698	.1886	.132	.2614
18	.2263	.2641	.2452	.3772	.3395	.415	.3696
19	.5658	.5658	.5281	.547	.6036	.4715	.4805
20	.5093	.4715	.415	.5093	.5093	.5281	.3547
21	.3772	.2829	.3395	.3921	.3584	.3584	.2801
22	.2452	.2452	.2452	.2641	.2829		.2263
23	.5636	.5636	.5243	.6154	.2263	.1886	.1867
24	.1886	.5801	.6203	.6081	.663	.1886	.1698
Max	1.4413	1.2431	.6203	1.2452	1.442	1.4586	1.4413
Min	.132	.0943	.0934	.0943	.0943	.132	.1698
Avg	.6680	.4576	.2731	.4820	.5033	.6639	.6407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.

Feeder No / Name : 202 / 11 KV KATPHAL SINGLE SINGLE PHASING

PHASIN Feeder KV- 11 /
OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7253	.3584		.3361	.3206	.7956	.8259
2	.7253	.3584		.3361	.3206	.7956	.8259
3	.7499	.3772		.3547	.3206	.7956	.8421
4	.7748	.3961		.4294	.3584	.8288	.8583
5	.9602	.5658		.5975	.5847	.9614	.9231
6	1.1523	.7922		.8215	.8865	1.1437	1.2146
7	1.5043	.9619		1.094	1.0374	1.4752	1.6518
8	1.7764	.9997		.9431	.9808	1.7404	1.587
9	.7842	1.6221		1.5181	1.4419	.6979	.7712
10	.5788	2.0405	1.8515	1.7341	1.6549	.6413	.6348
11	.4904	2.2024	1.9826	1.8976	1.7695	.5093	.6348
12	.3395	2.1214	1.8185	1.8185	1.6221	.415	.5041
13	.3018	2.1052	1.6091	1.7185	1.704	.3584	.4481
14	.3018	1.9433	1.6604	1.7869	1.1469	.3395	.3395
15	.3018	1.8623	1.7284	1.7711	1.3763	.3018	.3361
16	.2829	1.7652	1.6129	1.2483	1.4091		.4066
17	.3584	.3961	.3605	.3353	.4527		.4938
18	.4527	.6036	.5304	.5359	.6413	.679	.5729
19	.8299	.8299	.8589	.8865	.8676	.7167	.6584
20	.7545	.7545	.6535	.7167	.811	.7733	.5914
21	.6413	.5847	.5544	.6224	.6413	.679	.4805
22	.4715	.4715	.4668	.4527	.547		.4066
23	.3772	.3395	.3361	.3772	.7969	.7935	.6483
24	.7499	.3584	.3395	.3361	.3395	.8122	.8259
Max	1.7764	2.2024	1.9826	1.8976	1.7695	1.7404	1.6518
Min	.2829	.3395	.3361	.3353	.3206	.3018	.3361
Avg	.6827	1.0338	1.0909	.9445	.9180	.7740	.7284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.

Feeder No / Name : 203 / 11 KV SHIRSUPHAL SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1698		.2075	.2641	.1457	.1619
2	.128	.1698		.2075	.2641	.1457	.1619
3	.1296	.1886		.2075	.2641	.1457	.1619
4	.1457	.2263		.2829	.2829	.1781	.1943
5	.2267	.3961		.3772	.3584	.2591	.2429
6	.3277	.4904		.5281		.3077	.3401
7	.4475	.5093		.5658		.4372	.5182
8	.5506	.547		.3961		.583	.6478
9	.3395	.5898		.6602		.4904	.4715
10	.3206	.6962	.6882	.7449	.5304	.3584	.5093
11	.2641	.7293	.6882	.7865	.6464	.2641	.2829
12	.2641	.7293	.6562	.7935	.6133	.1509	
13	.2641	.5304	.7468	.8402	.5636	.1886	.2075
14	.2452	.7127	.6535	.7209	.3647	.1886	.2263
15	.2263	.6962	.502	.6554	.3647	.2075	.2452
16	.1698	.663	.5243	.421	.3812	.1698	.2829
17	.2075	.132	.1494	.2427	.2263	.2263	.2801
18	.2263	.3018	.2987	.3584	.3772	.3206	.2957
19	.4338	.4527	.4481	.4294	.4904	.4715	.3921
20	.3772	.3395	.3772	.4108	.547	.4904	.3142
21	.2452	.2829	.2829	.3921	.3395	.3206	.3174
22	.2263	.2263	.2241	.3174	.3018		.2801
23	.1886	.2075	.2054	.2614	.1526	.1943	.213
24	.128	.1698	.2075	.2075	.2641	.1457	.1619
Max	.5506	.7293	.7468	.8402	.6464	.583	.6478
Min	.128	.132	.1494	.2075	.1526	.1457	.1619
Avg	.2588	.4232	.4435	.4590	.3798	.2778	.3004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.

Feeder No / Name : 204 / 11 KV NIMBODI SINGLE SINGLE PHASING
 PHASING Feeder KV- 11 /
 OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3081	1.9212	1.044	1.8519	.8951	.2641	.2452
2	1.2624	1.7307	.9526	1.7071	.8951	.2641	.2452
3	.7173	1.2748	.4191	1.2498	.8951	.2641	.2829
4	.824	1.4451	.5258	1.488	.9448	.3018	.3206
5	1.0439	1.6042	.5868	1.7509	1.0608	.5658	.3772
6	1.338	1.8442	.5792	1.6975	1.1603	.7356	.7733
7	1.207	1.8503	.2972	1.7728	1.5083	.9242	.8299
8	2.7388	1.8709	.2058	1.8175	1.6409	.7922	.7167
9	3.7848	.7563	.5038	.662	.547	1.5181	1.6244
10	4.0238	.4995	.4885	.4999	.4338	1.8976	1.5083
11	4.4751	.4129	.3841	.4281	.3018	1.7078	2.304
12	4.5138	.3033	.3883	.3791	.2075	1.6604	2.1464
13	4.4568	.4325	.3772	.4325	.1509	1.8976	2.1464
14	4.179	.471	.5186	.5087	.1698	1.9608	1.6907
15	4.1153	.688	.6524	.6611	.1698	1.8976	1.8515
16	3.2807	2.0176	2.29	2.0629	.2263	.1698	1.8652
17	1.1027	2.1391	2.4249	2.1047	.2263	.3395	.2614
18	1.2002	2.0041	2.0728	1.9547	.4715	.3395	.4108
19	1.3344	1.8755	1.9753	1.8955	.6224	.415	.5228
20	.993	1.6556	1.6407	1.6296	.547	.5281	.4805
21	.8033	1.4209	1.4769	1.5003	.4715	.4527	.4294
22	.5761	1.3226	1.3567	1.3606	.3395	.3395	.3206
23	1.13	1.9708	1.8995	1.8069	.2641	.2452	.2641
24	.5232	1.9149	1.9199	1.8404	.9116	.2641	.2452
Max	4.5138	2.1391	2.4249	2.1047	1.6409	1.9608	2.304
Min	.5232	.3033	.2058	.3791	.1509	.1698	.2452
Avg	2.1222	1.3928	1.0408	1.3776	.6276	.8227	.9109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 201 / 11 KV KAMBALESHWAR SINGLE SINGLE PHASING
PHAS Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.218	1.3344	.7293	1.2715	1.2849	.2755	.2454
2	.2225	1.3062	.7285	1.27	1.2803	.3067	.2965
3	.2435	1.2735	.7263	1.2799	1.2834	.3555	.341
4	.2915	1.371	.7156	1.2566	1.3085	.4142	.4577
5	.3822	1.5005	.7529	1.3961	1.4045	.5247	.61
6	.5023	1.6328	.8695	1.56	1.5356	.6203	.7918
7	.5986	1.2058	.948	1.7315	1.6279	.7653	.8402
8	.5898	1.275	1.0303	1.8412	1.6045	.7867	.7773
9	2.0385	1.1469	.8467	1.078	.9294	1.5017	2.2649
10	2.0801	.471	.2606	.4104	.4436	2.4112	2.6056
11	2.292	.2991	.3254	.3521	.3311	2.6361	2.7184
12	2.2329	.2648	.2755	.2625	.216	2.1772	2.7626
13	2.4752	.2264	.1014	.2564	.1855	2.2984	2.4722
14	2.348	.197		.2187	.1954	2.1841	2.3182
15	2.2774	.1909	.2279	.1992	.17	2.0896	2.3709
16	2.0629	.2203	.2248	.2264	.2134	2.0241	2.3472
17	.9953	.2465	.2724	.3121	.3227	.8212	.9606
18	.4746	.2993	.4096	.3822	.4344	.3495	.442
19	.7278	.6401	.6672	.6085	.7156	.6341	.6508
20	.6378	.3612	.6497	.6957	.7015	.62	.6492
21	.6149	.5828	.5628	.6249	.6691	.5625	.5571
22	.5182	.4786	.442	.4721	.4706	.4637	.4359
23	.913	1.3506	1.3062	1.2677	.3292	.3475	.3029
24	.7987	1.3855	1.3382	1.2567	.7179	.2507	.2649
Max	2.4752	1.6328	1.3382	1.8412	1.6279	2.6361	2.7626
Min	.218	.1909	.1014	.1992	.17	.2507	.2454
Avg	1.1057	.8025	.6266	.8429	.7656	1.0592	1.1868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 202 / 11 KV SHIRWALI SINGLE SINGLE PHASING
PHASING Feeder KV- 11 /
OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.2896		.2263	.2058	.7207	.5228
2	.5658	.3048		.2263	.2058	.7733	.5228
3	.5658	.2987		.2614	.2058	.8029	.5601
4	.6001	.1905		.3361	.3086	.8402	.6036
5	.6516	.3429		.4481	.3772	.8686	.6348
6	.7373	.3734		.5601		.8871	.7468
7	.8059	.4115		.6535	.5658	.9522	.8488
8	.8573	.4115		.6161	.5487	1.0082	.9054
9	.4904	1.1065		.9724	1.0288	.4904	.5281
10	.3734	1.1883		1.0974	1.1506	.4481	.3887
11	.1867	1.1203	1.1233	1.1145	1.1883	.3584	.3772
12	.1307	1.094	1.0395	1.0974	1.1763	.2987	.2641
13	.2263	1.1694	1.0288	1.0288	1.0317	.2241	.2641
14	.2263	1.1317	.9945	1.046	1.0374	.2263	.1886
15	.2241	1.1883		1.0288	1.0185	.2328	.2263
16	.2286	1.1128	.9602	.9945	1.0269	.3018	.2452
17	.3048	.3206	.3395	.2058	.3174	.3772	.3018
18	.1753	.4338	.4527	.4115	.4251	.4481	.415
19	.4115	.6036	.5847	.5144	.5975	.6036	.547
20	.5144	.5281	.5281	.4801	.5601	.5658	.5041
21	.3772	.3772	.4527	.4115	.5041	.4854	.4527
22	.3681	.2987	.3584	.3086	.3961	.4294	.3772
23	.3429	.2263	.2263	.2401	.7095	.5658	.4458
24	.5658	.3086	.1886	.2263	.2058	.7095	.5228
Max	.8573	1.1883	1.1233	1.1145	1.1883	1.0082	.9054
Min	.1307	.1905	.1886	.2058	.2058	.2241	.1886
Avg	.4373	.6180	.6367	.6044	.6431	.5674	.4747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 203 / 11 KV BARAVNAGAR SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501	.2964	.1791	.3597	.3479	.7171	.7445
2	.841	.2911	.1821	.3712	.3666	.7173	.7361
3	.8417	.3368	.202	.4192	.4329	.7265	.8078
4	.8898	.4206	.2477	.5509	.586	.7657	.897
5	.9683	.6835	.4009	.8139	.8296	.8623	1.0463
6	1.1214	1.0227	.5677	1.1222	1.0521	.9968	1.2388
7	1.496	1.0326	.6516	1.2483	1.1744	1.3738	1.5372
8	1.9346	.6287	.7133	1.342	1.4186	1.8136	1.957
9	1.4015	1.6149	.8985	1.4052	1.0421	1.3573	1.4327
10	.8581	1.9629	1.0174	1.6103	1.6103	.8691	1.0421
11	1.2224	2.1491	2.1658	1.7265	1.6287	.7545	.5479
12	.474	2.1251	2.0359	1.712	1.5265	.5296	.4507
13	.3879	2.0211	1.7875	1.5885	1.4926	.3468	.2911
14	.3628	1.9688	1.5596	1.5013	1.5394	.311	.2524
15	.3414	1.9123	1.5024	1.448	1.4586	.285	.1357
16	.3886	1.8876	1.4762	1.4521	1.4549	.3692	.2603
17	.6211	.8358	.8894	.8696	.7819	.5217	.4163
18	.7871	.78	.8139	.8398	.9012	.7102	.6607
19	.8802	1.0341	1.094	1.1081	.9928	1.1305	.9297
20	.8364	.9214	1.057	1.0623	.8991	.6842	.8954
21	.6973	.7802	.8474	.8577	.8547	.8776	.7361
22	.5472	.6331	.6146	.6592	.6704	.764	.6211
23	.9183	.405	.423	.4451	.7114	.8658	.8501
24	.5857	.3723	.346	.3742	.5437	.7674	.8215
Max	1.9346	2.1491	2.1658	1.7265	1.6287	1.8136	1.957
Min	.3414	.2911	.1791	.3597	.3479	.285	.1357
Avg	.8439	1.0882	.9030	1.0370	1.0132	.7965	.8045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 205 / 11 KV PONDKULE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.1715		.1132	.1029	.5041	.4338
2	.3429	.1524		.1132	.1029	.5415	.4338
3	.3429	.1143		.132	.1029	.5847	.4294
4	.3772	.1905		.1509	.1029	.5847	.4668
5	.4115	.2286		.1886	.1372	.6161	.5544
6	.463	.2667		.2427	.2058	.6413	.6224
7	.5487	.2987		.2801	.2401	.6979	.6979
8	.6173	.3018		.2801	.2743	.811	.8299
9	.2829	.6173		.7377	.7545	.2263	.2401
10	.1886	.811		.8383	1.1128	.1509	.197
11	.1905	.8775	.9054	.823	.9619	.1267	.1698
12	.1307	.8299	.8551	.823	.9242	.1254	.1132
13	.1143	.9149	.7712	.823	.9054	.1109	.1132
14	.1143	.9054	.823	.7888	.8676	.0857	.0943
15	.1143	.9619	.8573	.823	.8488	.112	.0943
16	.1143	.8676	.8402	.8573	.8676	.132	.132
17	.1143	.1132	.132	.1372	.1509	.112	.1132
18	.1372	.1509	.1698	.1715	.1509	.1307	.168
19	.2715	.2614	.2829	.2401	.2641	.2614	.2263
20	.2534	.2263	.2641	.2572	.3772	.2263	.2075
21	.2172	.2075	.2263	.2058	.2241	.1886	.1886
22	.1715	.1509	.1698	.1372	.1509	.1494	.1509
23	.1715	.1132	.1132	.1029	.4904	.4481	.3978
24	.1698		.1132	.1132	.1029	.4715	.4207
Max	.6173	.9619	.9054	.8573	1.1128	.811	.8299
Min	.1143	.1132	.1132	.1029	.1029	.0857	.0943
Avg	.2584	.4232	.4660	.3908	.4343	.3350	.3123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 206 / 11 KV PATILWASTI SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3466	1.4648	.7377	1.1945	1.3306	.4047	.394
2	.3656	1.4979	.7552	1.2143	1.3527	.4493	.4172
3	.4134	1.5334	.7659	1.222	1.4053	.5525	.5705
4	.5264	1.603	.8284	1.2608	1.4747	.7011	.7556
5	.7209	1.7489	.9419	1.3599	1.6019	.8682	.9408
6	.8718	1.8922	.9976	1.5607	1.8251	.977	1.1065
7	.9713	1.9006	1.0334	1.637	1.8652	1.0513	1.1698
8	1.5673	.8128	.4313	1.2094	1.2632	1.4693	1.6224
9	2.0618	.5986	.2599	.4756	.5997	1.928	2.3823
10	2.1513	.45	.202	.2088	.4725	2.13	2.5415
11	2.2752	.2767	.329	.3483	.3803	2.3149	2.3838
12	1.9105	.2264	.2858	.2972	.3184	2.4295	2.3205
13	2.2032	.2819	.2645	.2729	.2553	2.4131	2.3198
14	2.194	.2668	.2492	.2713	.2545	2.3789	2.3022
15	2.1266	.3016	.3513	.3094	.333	2.1277	2.117
16	1.2079	.3702	.418	.3445	.3354	1.1557	1.3074
17	.5464	.462	.5122	.49	.5342	.506	.494
18	.7571	.6546	.6775	.6889	.7172	.6981	.6189
19	.7667	.7507	.775	.7087	.8047	.8128	.6893
20	.6393	.6933	.727	.7377	.7491	.7613	.6538
21	.5799	.6546	.591	.6363	.6691	.6794	.5624
22	.9526	.961	.8867	.9336	.4664	.5319	.4424
23	1.4526	1.4167	1.2407	1.2689	.4169	.3856	.3704
24	.8711	1.496	1.2986	1.2501	.82	.3818	.3814
Max	2.2752	1.9006	1.2986	1.637	1.8652	2.4295	2.5415
Min	.3466	.2264	.202	.2088	.2545	.3818	.3704
Avg	1.1866	.9298	.6483	.8292	.8436	1.1712	1.2027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 207 / 11 KV SANGAVI SINGLE SINGLE PHASING
 PHASING Feeder KV- 11 /
 OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.3772		.2534	.3429	.2801	.2263
2	.2241	.4115		.2534	.3429	.2801	.2641
3	.2614	.4557		.2896	.3258	.3174	.3395
4	.2987	.4458		.3439	.3086	.4024	.3982
5	.3734	.4801		.4163	.4115	.5228	.547
6	.5228	.5487		.4801	.5144	.7095	.7468
7	.6535	.6001		.5658	.4973	.7947	.811
8	.7842	.583		.4973	.4801	.6584	.7545
9	.583	.4801		.5658	.4458	.5914	.679
10	.6859	.4668		.4527	.5415	.5729	.6722
11	.6173	.3475	.3772	.3429	.3292	.5087	.5487
12	.4115	.2561	.2641	.2743	.2987	.5281	.463
13	.5487	.2743	.2641	.2401	.2378	.4904	.463
14	.4801	.2263	.2641	.2229	.2641	.4706	.463
15	.5144	.2378	.2075	.2058	.2614	.4904	.463
16	.5144	.2801	.3018	.2572	.3142	.4715	.4287
17	.381	.3921	.2641	.2743	.3292	.3155	.3018
18	.4801	.5093	.4904	.4287	.5228	.4481	.4481
19	.4115	.6767	.6413	.5658	.6036	.5975	.5658
20	.3856	.6036	.6036	.5316	.5975	.547	.5281
21	.362	.5415	.5281	.4801	.5487	.4715	.4527
22	.3258	.3584	.415	.3429	.3734	.3961	.3584
23	.3429	.3292	.2715	.3772	.2801	.2452	.2263
24	.2241	.3429	.3584	.2534	.3772	.2427	.2241
Max	.7842	.6767	.6413	.5658	.6036	.7947	.811
Min	.2241	.2263	.2075	.2058	.2378	.2427	.2241
Avg	.4421	.4260	.3751	.3715	.3979	.4730	.4739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 201 / 11 KV SALOBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	1.1995	2.0508	1.8595	1.9406	.0328	.037
2	.0366	1.1908	1.9746	1.7989	1.9398	.0328	.0647
3	.0366	1.0745	1.9441	1.8058	1.8999	.0328	.0796
4	.0366	1.1184	1.9106	1.7787	1.845	1.3435	.0754
5	.0606	1.19	1.8431	1.7409	1.7962	.0328	.0947
6	.0396	1.3651	1.7903	1.6316	1.8039	.0328	.1069
7	.0366	1.7233	1.8686	1.7875	1.8656	.0328	.1077
8	.0362	2.0028	1.9845	2.0153	2.1388	.0328	.1134
9	1.8141	.9375	.9168	.9943	.9762	2.4554	2.2073
10	2.1529	.0884	.0316	.1281	.0316	2.7583	2.4049
11	2.3609	.0762	.0316	.1151	.0316	2.8006	2.4318
12	2.2085	.0689	.0316	.1034	.0316	2.945	2.2773
13	2.162	.0811	.0316	.1061	.0316	2.8722	2.134
14	2.1397	.0785	.0316	.0988	.0316	2.6117	1.968
15	2.0413	.0762	.0316	.0958	.0316	2.3914	1.9327
16	2.0018	.0735	.0316	.0988	.0316	2.2222	1.8382
17	.8612	.08	.0316	.1053	.0316	1.0227	.8089
18	.1338	.1046	.0316	.1042	.0316	.0396	.095
19	.1625	.1091	.0316	.1099	.0316	.0373	.1023
20	.1486	.1277	.0316	.1334	.0316	.0373	.1057
21	.1251	.1103	.0316	.1368	.0316	.037	.1095
22	.1251	.108	.0316	.1202		.037	.1091
23	1.2769	1.2586	1.992	2.0445	.0316	.037	.0872
24	.8292	1.5915	2.0645	1.9006	.0316	.0316	.0804
Max	2.3609	2.0028	2.0645	2.0445	2.1388	2.945	2.4318
Min	.0362	.0689	.0316	.0958	.0316	.0316	.037
Avg	.8693	.6598	.8646	.8672	.7238	.9962	.8072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 202 / 11 KV YAMAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0367	.245	.1806	.2405	.2544	1.7832	2.441
2	2.0264	.2271	.1776	.2351	.2513	1.7353	2.4105
3	2.0256	.2263	.1768	.2489	.2567	1.773	2.4029
4	1.9814	.245	.2075	.261	.2828	1.8716	2.3892
5	1.9547	.2843	.2288	.3041	.3118	2.053	2.4616
6	1.0372	.3505	.3018	.3654	.3823	2.6258	2.5058
7	2.2085	.4153	.3816	.3722	.4044	2.8814	2.8345
8	2.47	.4245	.4029	.3707	.4305	3.1028	3.1664
9	1.1915	2.9878	3.5311	3.3954	3.1577	1.3253	1.3869
10	.282	3.5814	3.8504	3.7561	3.6927	.344	.3227
11	.2385	3.9761	4.0276	3.9522	3.8687	.291	.2435
12	.1916	3.9137	3.9709	3.8805	3.8257	.2065	.1816
13	.1863	3.9053	2.1254	3.7937	3.6218	.2184	.1555
14	.1653	3.8219	3.7532	3.6408	3.714	.2011	.131
15	.1547	3.8687	3.6984	3.6206	3.5841	.2339	.0739
16	.197	3.7536	3.6748	3.5541	3.5799	.2355	.1785
17	.2157	1.5415	1.4209	1.3013	1.2555	.2435	.2468
18	.2256	.2782	.2229	.213	.2496	.298	.279
19	.3528	.2965	.3278	.3179	.2881	.3852	.3156
20	.3543	.3425	.3907	.3839	.3482	.3453	.3547
21	.338	.3202	.3884	.3738	.3551	.3451	.3585
22	.3296	.2957	.337	.3355	.3235	.3147	.3095
23	.285	.2582	.3018	.2858	2.4516	2.5393	2.5446
24	1.0513	.2343	.2119	.2536	1.4219	2.4463	2.4898
Max	2.47	3.9761	4.0276	3.9522	3.8687	3.1028	3.1664
Min	.1547	.2263	.1768	.213	.2496	.2011	.0739
Avg	.8958	1.4914	1.4288	1.4773	1.5963	1.1583	1.2577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 203 / 11 KV NAGESHWAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8421	1.0078	.9891	.9808	1.0387	.9461	.98
2	.8291	.9594	.9484	.9046	.9839	.9122	.9206
3	.7937	.953	.9431	.9008	.9892	.9915	.9168
4	.7876	.9937	.9914	.9655	1.0532	1.0807	.9785
5	1.041	1.1294	1.1423	1.1622	1.2277	1.2818	1.3108
6	.5944	1.6293	1.6994	1.6339	1.6781	1.5706	1.7841
7	1.7981	2.2543	2.3167	2.3289	2.215	2.0446	2.1376
8	2.1064	2.3388	2.3929	2.3739	2.4184	2.3959	2.3674
9	2.0793	2.0035	1.9646	2.1293	2.1845	2.1689	2.1704
10	1.9761	1.7322	1.6201	1.8613	1.6682	1.8858	1.853
11	1.7886	1.6994	1.5973	1.8122	1.563	1.589	1.6644
12	1.5645	1.5973	1.467	1.5569	1.3813	1.5257	1.4384
13	1.3691	.6722	1.3771	1.3588	1.2537	1.3462	1.3131
14	1.1968	1.0387	1.4213	1.3489	1.2692	1.2555	1.2079
15	1.2608	1.435	1.3817	1.3261	1.2132	1.2026	1.1755
16	1.2623	1.4837	1.3741	1.3512	1.1618	1.179	1.2178
17	1.2643	1.4632	1.3672	1.5303	1.1652	1.4602	1.1504
18	1.3642	1.5646	1.4632	1.5367	1.5528	1.4922	1.3889
19	1.7745	1.8587	1.8663	1.9208	1.8153	1.8328	1.7752
20	.9755	1.8282	1.7749	1.8679	1.7292	1.789	1.7543
21	1.6225	1.7795	1.6926	1.7505	1.6316	1.7352	1.6591
22	1.5112	1.6499	1.4899	1.5127	1.4754	1.5673	1.549
23	1.2613	1.3604	1.2758	1.2304	1.2338	1.3085	1.2818
24	.9633	1.0883	1.0349	1.0326	1.1195	1.0055	1.0448
Max	2.1064	2.3388	2.3929	2.3739	2.4184	2.3959	2.3674
Min	.5944	.6722	.9431	.9008	.9839	.9122	.9168
Avg	1.3344	1.4800	1.4830	1.5157	1.4592	1.4820	1.4600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 204 / 11 KV NANDAN EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.2054	.3772	.3395	.4527	.3921	.2829
2	.3361	.1867	.3584	.3395	.415	.3921	.3395
3	.3734	.2054	.3395	.3018	.415	.3734	.3395
4	.3734	.1867	.3395	.3018	.4338	.3734	.3395
5	.3326	.2054	.415	.3772	.4527	.4294	.3772
6		.2241	.4527	.4338	.4527	.4668	.3961
7	.2987	.2241	.4338	.4338	.3961	.4294	.3881
8	.4755	.2241	.4715	.4527	.4527	.4481	.4435
9	.2427	.2614	.2641	.2641	.2452	.2614	.4805
10	.2241	.415	.4338	.3584	.3174	.3361	.3395
11	.3174	.3206	.3395	.3206	.2801	.3361	.2829
12	.2801	.3018	.3018	.2829	.2801	.2614	.3206
13	.2614	.2641	.4715	.2452	.2614	.2427	.2452
14	.2801	.2641	.4904	.2641	.4481	.5041	.3174
15	.2614	.2641	.4904	.2641	.4854	.5544	.2427
16	.2614	.2829	.5281	.2641	.3734	.5544	.2075
17	.2614	.3018	.547	.5281	.3921	.5544	.3018
18	.2614	.3395	.547	.415	.4294	.5544	.3961
19	.2614	.3395	.5281	.5281	.5041	.5175	.3018
20	.2614	.3584	.5281	.5281	.5975	.5175	.2829
21	.2427	.547	.5281	.4527	.0754	.4435	.3395
22	.2241	.5281	.4527	.3772	.4668	.4435	.5093
23	.2241	.5093	.5281	.4715	.4294	.4435	.4904
24	.3361	.2241	.4338	.3395	.4668	.3734	.2829
Max	.4755	.547	.547	.5281	.5975	.5544	.5093
Min	.2241	.1867	.2641	.2452	.0754	.2427	.2075
Avg	.2925	.2993	.4417	.3702	.3968	.4251	.3436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 205 / 11 KV NIAM EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0754	.0754	.0566	.0566	.0566	.056
2	.0566	.0754	.0754	.0566	.0566	.0566	.056
3	.0566	.0754	.0754	.0566	.0566	.0754	.056
4	.0532	.0754	.0754	.0566	.0566	.0754	.056
5	.0537	.0754	.0754	.0754	.0566	.0754	.0747
6		.0754	.0566	.0754	.0566	.0754	.0934
7	.0566	.0566	.0566	.0566	.0566	.0566	.0754
8	.0554	.0566	.0566	.0566	.0566	.0754	.0943
9	.0914	.0943	.0754	.1132	.0754	.0943	.0754
10	.1132	.1509	.1886	.1509	.1132	.1494	.132
11	.132	.1698	.1698	.1509	.1698	.112	.132
12	.132	.1698	.1698	.1509	.132	.1307	.132
13	.132	.1698	.1509	.1698	.132	.1494	.1132
14	.132	.1698	.1509	.1886	.1509	.1307	.1132
15	.132	.1698	.1886	.1698	.1509	.1478	.132
16	.132	.1698	.1509	.1509	.1698	.1294	.1132
17	.132	.1132	.1132	.0943	.132	.0934	.0754
18	.0754	.0943	.0943	.0754	.0943	.0934	.0754
19	.1132	.1132	.1132	.0943	.0943	.0934	.0754
20	.0754	.1132	.0943	.0943	.0943	.0934	.0943
21	.0754	.0754	.0754	.0754		.0747	.0754
22	.0754	.0754	.0754	.0754	.0754	.0747	.0754
23	.0754	.0754	.0566	.0566	.0566	.056	.0943
24	.0566	.0754	.0566	.0566	.0566	.0566	.0566
Max	.132	.1698	.1886	.1886	.1698	.1494	.132
Min	.0532	.0566	.0566	.0566	.0566	.056	.056
Avg	.0897	.1069	.1029	.0982	.0935	.0928	.0886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 201 / 11 KV SHIRSUPHAL SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.1734	.1715	.2229	.2058	.2915	.2294
2	.2279	.2481	.1696	.2229	.2401	.3258	.2374
3	.2454	.3086	.1677	.2401	.2743	.3429	.2294
4	.2629	.394	.2012	.2743	.3086	.3772	.2713
5	.3086	.3814	.3018	.3086	.4115	.4801	.3052
6	.3768	.4458	.4915	.3772		.5144	.4239
7	.6443	.5721	.4752	.4458	.4458	.6516	.4588
8		.5434	.4588	.4115	.5144	.703	.6783
9	.3856	.664		.583	.6173	.3725	.3563
10	.2835	.6478	.583	.6001	.6173	.3277	.2622
11	.208	.6478	.6173	.6173	.6344	.2429	.1638
12	.1734	.6154	.6516	.6001	.6344	.1802	
13	.1753	.6226	.6173	.6173	.5487	.1638	
14	.1772	.583	.583	.583	.5487	.1619	.2012
15	.1734	.583	.5487	.5658	.583	.1638	.2294
16	.1753	.583	.5144	.5144	.5658	.1638	.2458
17	.2058	.1475	.1715	.1715	.1715	.2035	.2204
18	.3641	.3086	.2229	.2743	.3086	.3429	.3052
19	.4607	.4024	.4115	.4287	.4458	.4239	.4239
20	.4115	.463	.4801	.4801	.5144	.3887	.4207
21	.333	.3353	.3772	.4115	.4458	.3391	.3898
22	.2774	.2743	.2058	.2401	.2572	.2883	.3898
23	.2103	.2012	.2058	.2058	.2401	.2401	.2401
24	.7712	.1753	.1715	.2058	.6173	.2229	.2294
Max	.7712	.664	.6516	.6173	.6344	.703	.6783
Min	.1734	.1475	.1677	.1715	.1715	.1619	.1638
Avg	.3076	.4300	.3826	.4001	.4413	.3297	.3142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 202 / 11 KV GADIKHEL SINGLE SINGLE PHASING
 PHASING Feeder KV- 11 /
 OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.4207	.3277	.3772	.2743	.1715	.2683
2	.2572	.4161	.3277	.3429	.2572	.2058	.2713
3	.2683	.4961	.3113	.3772	.2915	.2401	.2713
4	.3052	.4908	.373	.4115	.3258	.3258	.3018
5	.3391	.5731	.4239	.4458	.3429	.3429	.3391
6	.4191	.5548	.4915	.4801		.3772	.3688
7	.57	.6068	.5571	.4458	.4458	.4458	.4024
8	.4557	.4607	.4588	.3258	.1715	.4115	.4527
9	.2481	.2683		.2572	.2743	.1802	.3018
10	.1991	.2429	.2915	.3429	.3086	.1638	.2515
11	.1543	.2429	.3258	.3429	.3086	.1311	.1943
12	.1612	.2429	.3601	.3601	.3258	.0983	.1509
13	.1629	.2622	.3429	.3086	.2743	.081	.1311
14	.1417	.2949	.3258	.3086	.2572	.0819	
15	.1387	.2846	.3086	.2915	.2401	.0819	
16	.1227	.3163	.2743	.2743	.2229	.0655	
17	.1772	.1174	.1543	.1543	.1543	.1357	.1174
18	.3086	.3353	.1715	.3429	.3772	.3052	.3086
19	.5138	.503	.5144	.4801	.5144	.463	.39
20	.5028	.4801	.5487	.5658	.5144	.4409	.4961
21	.4784	.4458	.4801	.583	.5144	.407	.5258
22	.4382	.4458	.4458	.4115	.3772	.39	.4207
23	.4115	.407	.4287	.3429	.1543	.2572	.2572
24	.2572	.4252	.3429	.3772	.2743	.1715	.2515
Max	.57	.6068	.5571	.583	.5144	.463	.5258
Min	.1227	.1174	.1543	.1543	.1543	.0655	.1174
Avg	.3037	.3889	.3733	.3729	.3131	.2490	.3082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 203 / 11 KV ATOLEWASTI SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.1227	.0983			.1886	.1715
2	.1311	.1448	.0983			.2401	.1715
3	.1341	.1417	.1311			.2743	.1677
4	.1311	.1402	.1341			.2743	.1715
5	.1638	.1907	.1677			.3086	.2035
6	.2035	.197	.1619			.3429	.2401
7	.3239	.1578	.1802			.3772	.3018
8	.3944	.1433	.1311			.3429	.39
9	.1402	.3561				.1475	.1677
10	.1402	.3563	.3086			.1311	.1638
11	.1063	.3725	.3258			.1311	.1311
12	.12	.4049	.3601			.0983	.0983
13	.124	.3932	.3772			.0819	.0983
14	.1075	.3795	.3429		.2401	.0819	.0819
15	.1052	.3563	.3258		.2572	.0819	.0819
16	.1075	.3239	.2915		.1886	.0819	.0819
17	.1254	.1174	.0857			.1017	.0983
18	.1612	.1372	.0857		.1372	.1357	.1341
19	.1734	.1715	.1372		.2058	.1638	.1865
20	.1791	.1372	.12		.1715	.1696	.1753
21	.1387	.1227	.12		.1715	.1696	.1753
22	.1417	.1187	.1372		.1543	.1677	.1753
23	.1254	.1029	.12		.1715	.1677	.1715
24	.1341	.1254	.1052	.0857		.1715	.1677
Max	.3944	.4049	.3772	.0857	.2572	.3772	.39
Min	.1052	.1029	.0857	.0857	.1372	.0819	.0819
Avg	.1560	.2172	.1889	.0857	.1886	.1847	.1669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 204 / 11 KV PATILWASTI SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5533	.1364	.1204	.1048	.1227	.6032	.426
2	.5575	.136	.1223	.1048	.1398	.6264	.4199
3	.5342	.1896	.125	.1235	.1616	.6264	.426
4	.5525	.1968	.1608	.1413	.1833	.6668	.4336
5	.5654	.2592	.2016	.1654	.202	.6885	.4709
6	.6123	.2795	.2393	.1878	.0381	.7019	.5091
7	.7011	.3275	.3216	.1962	.2328	.7975	.5129
8	.7594	.2751	.2568	.2134	.2142	.78	.6051
9	.2835	.9027	.2202	1.0704	1.1115	.2744	.2858
10	.1791	1.086	1.1804	1.1835	1.2224	.1273	.1295
11	.1738	.6573	1.3108	1.214	1.2643	.1197	.0884
12	.1551	1.227	1.3893	1.262	1.2978	.1174	.0541
13	.1547	1.2643	1.3908	1.3092	1.3062	.0979	.0496
14	.1178	1.2429	1.3728	1.278	1.3016	.0792	.0458
15	.1105	1.2429	1.3458	1.2429	1.1926	.0807	.0473
16	.1065	.2804	1.3077	1.2246	1.1492	.0769	.048
17	.0507	.3338	.3143	.3174	.2942	.0785	.1174
18	.202	.1578	.0785	.1413	.1345	.1204	.1524
19	.253	.2028	.0983	.1886	.1848	.1623	.1639
20	.2195	.1737	.0686	.1692	.1684	.1257	.1311
21	.1882	.1715	.1147	.1669	.149	.128	.1311
22	.186	.1349	.1273	.1303	.1101	.1032	.1105
23	.1399	.125	.1063	.1242	.5479	.4206	.426
24	.4454	.1322	.1215	.1055	.1916	.5616	.4328
Max	.7594	1.2643	1.3908	1.3092	1.3062	.7975	.6051
Min	.0507	.125	.0686	.1048	.0381	.0769	.0458
Avg	.3251	.4640	.5040	.5152	.5384	.3402	.2591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 205 / 11 KV TILEKARWASTI SINGLE SINGLE PHASING
PHAS Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0869	1.7032	1.4876	1.3748	1.4419	.0998	.144
2	.0869	1.7307	1.4159	1.4018	1.4907	.0991	.1425
3	.0884	1.755	1.39	1.4358	1.4808	.0922	.1592
4	.0907	1.7501	1.3878	1.4613	1.4015	.0869	.1592
5	.0938	1.7671	1.3939	1.4746	1.496	.096	.1631
6	.1036	1.8153	1.4228	1.5268	.727	.1036	.1749
7	.1075	1.9587	1.5554	1.595	1.6026	.1059	.1981
8	.1086	1.9589	1.6271	1.659	1.7405	.1044	.2065
9	2.4143	1.0775	.7918	.8139	.9419	1.8465	2.2409
10	2.7235	.1028	.0838	.109	.1578	2.3868	2.7542
11	2.8483	.1101	.1357	.1265	.144	2.6787	2.9142
12	2.7983	.1017	.1265	.1212	.1296	2.8532	2.9878
13	2.7207	.0991	.112	.128	.1341	2.8555	2.7214
14	2.737	.0938	.1036	.112	.1235	2.7511	2.7275
15	2.7673	.0873	.0815	.1075	.1219	2.8501	2.6558
16	2.7614	.0896	.0473	.1158	.1639	2.7816	2.6475
17	1.4739	.0884	.0404	.1166	.1334	1.3828	1.3443
18	.0945	.0876	.08	.1517	.1166	.0594	.157
19	.1132	.1048	.1105	.1707	.1235	.1715	.1905
20	.1143	.1093	.0678	.1753	.1174	.163	.1936
21	.1071	.0949	.096	.1265	.1059	.1569	.1669
22	.1052	.0869	.0876	.1143	.1059	.1463	.1592
23	1.5721	1.5154	1.3207	1.5043	.1021	.1463	.1402
24	.993	1.5333	1.4267	1.4846	.8543	.1113	.1357
Max	2.8483	1.9589	1.6271	1.659	1.7405	2.8555	2.9878
Min	.0869	.0869	.0404	.1075	.1021	.0594	.1357
Avg	1.1296	.8259	.6830	.7253	.6232	1.0054	1.0618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 206 / 11KV GARMALA SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /
OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.2259	.2073		.2305	.2447	.205
2	.1623	.2637	.2066		.2447	.2462	.202
3	.1677	.2606	.2119		.2477	.2813	.2043
4	.1973	.2976	.2515		.2873	.3177	.2108
5	.2485	.3476	.2591		.3345	.3673	.2553
6	.2698	.3544	.2774		.0693	.3951	.3354
7	.3056	.4412	.3395		.4435	.4206	.4115
8	.2995	.4595	.3936		.4211	.4549	.4671
9	.4388	.3955	.0823		.405	.3902	.4088
10	.487	.2088	.218		.3418	.4542	.4435
11	.5167	.1996	.2027		.279	.5136	.4542
12	.4763	.1623	.1989		.2416	.1158	.4557
13	.4496	.1532	.1608		.2073	.4847	.4382
14	.3875	.1486	.1444		.205	.4412	.4062
15	.3698	.1509	.1025		.1817	.4077	.4008
16	.3732	.1353	.0549		.1303	.397	.4149
17	.2389	.1585	.1174		.1543	.1893	.1916
18	.3468	.2401			.2035	.2339	.2447
19	.4009	.368		.6307	.2645	.3703	.3635
20	.3834	.3285		.4961	.3011	.3216	.3353
21	.301	.2842		.551	.266	.2953	.2957
22	.2833	.253		.4062	.2584	.282	.2843
23	.226	.2111		.221	.2313	.2454	.2092
24	.2012	.2089	.1677	.0472	.2088	.2081	.2005
Max	.5167	.4595	.3936	.6307	.4435	.5136	.4671
Min	.1578	.1353	.0549	.0472	.0693	.1158	.1916
Avg	.3204	.2607	.1998	.3920	.2566	.3366	.3266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 201 / 11 KV KARKHEL SINGLE SINGLE PHASING
 PHASING Feeder KV- 11 /
 OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3086		.2286	.2286	.3086	.3086
2	.2915	.3086		.2286	.2286	.3086	.2915
3	.2915	.3086		.2439	.2439	.3086	.2915
4	.3772	.2915		.3048	.3048	.3772	.3772
5	.6516	.3086		.4115	.3963	.6859	.6687
6	.8745	.6001		.5639	.4877	1.0288	.9431
7	1.0117	1.0974	.6706	.6706	.7011	1.0802	1.0802
8	.9945	.9945		.7621	.8078	.8745	1.0802
9	.7316	.6859		.6859	.7202	.6554	.6401
10	.823	.6859	.3258	.3772	.3429	.7011	.6401
11	.884	.6554	.1543	.3086	.2915	.6859	.6401
12	.7926	.6249	.0857	.2401	.2743	.6401	.6097
13	.6249	.5792	.1372	.2058	.2572	.6554	.5792
14	.5335	.5639	.1715	.1715	.2229	.6706	.5639
15	.5182	.5792	.1715	.2058	.2229	.6554	.5792
16	.4877	.5639	.1715	.2915	.2229	.5335	.3334
17	.3944	.3601	.2058	.3258	.3086	.2743	.3429
18	.5487	.5487	.5144	.6344	.6001	.5658	.5487
19	.7888	.8402	.823	.8573	.8059	.8059	.7373
20	.7545	.8059	.7888	.8402	.7716	.7716	.7202
21	.6001	.583	.5658	.583	.6344	.6001	.6001
22	.3772	.4801	.4801	.4458	.463	.4458	.4115
23	.3258	.2439	.2439	.2439	.3601	.3429	.3772
24	.3086			.2439	.2439	.3086	.3086
Max	1.0117	1.0974	.823	.8573	.8078	1.0802	1.0802
Min	.2915	.2439	.0857	.1715	.2229	.2743	.2915
Avg	.5949	.5660	.3673	.4198	.4226	.5952	.5697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 202 / 11 KV KHARADWADI SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3086		.2134	.1981	.2915	.2743
2	.2572	.2743		.2134	.1829	.2915	.2743
3	.2572	.2743		.2134	.1829	.2915	.2743
4	.3429	.2572		.2591	.2591	.3429	.3429
5	.583	.4801		.3963	.3353	.6001	.5487
6	.7716	.7716		.5487	.442	.8745	.7716
7	.9431	.9774	.7011	.7011	.5639	.9259	.9088
8	.9431	.9259		.7773	.7468	.7545	.9088
9	.6097	.6554		.6344	.5316	.6249	.6859
10	.6859	.6554	.3429	.463	.2915	.7164	.7621
11	.7316	.6249	.2572	.2915	.2572	.7316	.7316
12	.6859	.6097	.2401	.2229	.2401	.7621	.5487
13	.6401	.5792	.2401	.2058	.2401	.7468	.503
14	.5792	.5639	.2401	.1886	.2401	.7164	.4877
15	.5487	.5944	.2401	.1886	.2401	.6859	.4877
16	.5487	.5335	.2401	.1886	.2572	.5639	.5639
17	.3086	.2743	.2743	.2915	.2915	.3429	.3429
18	.5144	.5144	.4801	.6173	.583	.583	.5144
19	.7716	.7373	.7545	.8573	.7888	.7202	.6173
20	.6859	.703	.7202	.823	.7545	.6859	.583
21	.5487	.5487	.5487	.5144	.6344	.5658	.5144
22	.3601	.4458	.4458	.3601	.4458	.3772	.3601
23	.3086	.2134	.2286	.1829	.3429	.3086	.3086
24	.3086			.2134	.1981	.2915	.2915
Max	.9431	.9774	.7545	.8573	.7888	.9259	.9088
Min	.2572	.2134	.2286	.1829	.1829	.2915	.2743
Avg	.5497	.5445	.3969	.3986	.3853	.5748	.5253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 203 / 11 KV UNDAWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0914		.0914	.0914	.1067	.1067
2	.0762	.0914		.0914	.0914	.1067	.1067
3	.0762	.0914		.1067	.0914	.1067	.1067
4	.1372	.0914		.1219	.1372	.1219	.1372
5	.1829	.1372		.1677	.1981	.1829	.2134
6	.2591	.2286		.2591	.2743	.2896	.3048
7	.3201	.3201	.3201	.2896	.3201	.3353	.2896
8	.2743	.2591		.2286	.2591	.2743	.2743
9	.2439	.1981		.1829	.2286	.2286	.2286
10	.1829	.1677	.1677	.1372	.1524	.1981	.1981
11	.1524	.1219	.1067	.1067	.1067	.1524	.1677
12	.0914	.0762	.0762	.0762	.0762	.1067	.1067
13	.0762	.0762	.0762	.061	.0762	.0914	.0914
14	.0762	.0762	.0762	.061	.061	.0914	.0762
15	.0762	.061	.0762	.061	.061	.0914	.0762
16	.0762	.0762	.0762	.061	.061	.0914	.0914
17	.1219	.0914	.0914	.0914	.0914	.1067	.1219
18	.1524	.1524	.1524	.1524	.1677	.1981	.1524
19	.2134	.2286	.2286	.2591	.2591	.2743	.2286
20	.2134	.2134	.2134	.2439	.2439	.2591	.2134
21	.1829	.1981	.1981	.2134	.2134	.2134	.1829
22	.1219	.1524	.1524	.1524	.1677	.1677	.1524
23	.1067	.1219	.1219	.1219	.1372	.1372	.1219
24	.0914			.0914	.1067	.1067	.1067
Max	.3201	.3201	.3201	.2896	.3201	.3353	.3048
Min	.0762	.061	.0762	.061	.061	.0914	.0762
Avg	.1492	.1444	.1422	.1429	.1531	.1683	.1607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 204 / 11 KV SONWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857		.0857	.1524	.1524	.1219
2	.0686	.0857		.0857	.1372	.1524	.1219
3	.0686	.0857		.0857	.1372	.1524	.1372
4	.1029	.0857		.1029	.1524	.1524	.1524
5	.1543	.1029		.1543	.1677	.2134	.1829
6	.1715	.1886		.2229	.1981	.2896	.2286
7	.2058	.2401	.2572	.2401	.2896	.3658	.3963
8	.2229	.2058		.2058	.4268	.4572	.4877
9	.381	.381		.3506	.1543	.1715	.1886
10	.5182	.4877	.3353	.381	.1029	.1029	.1372
11	.3334	.4877	.3506	.3963	.0686	.0857	.1029
12	.7926	.3963	.3506	.442	.0686	.0857	.1029
13	.6249	.3963	.3353	.4572	.0686	.0686	.0857
14	.503	.4115	.3353	.442	.0514	.0514	.0686
15	.2858	.3963	.3506		.0514	.0514	.0686
16	.4572	.3506	.3658	.381	.0514	.0514	.0686
17	.12	.1029	.0857	.12	.0857	.0857	.1029
18		.1372	.1372	.1543	.1372	.12	.12
19	.1886	.1886	.1886	.2058	.2058	.2058	.1886
20	.1886	.1715	.1715	.1886	.1886	.1886	.1886
21	.1372	.1715	.1372	.1715	.1715	.1715	.1715
22	.1372	.1372	.12	.1372	.1543	.1543	.1543
23	.12	.12	.1029	.1372	.1524	.1372	.1372
24	.12			.0857	.1524	.1524	.1219
Max	.7926	.4877	.3658	.4572	.4268	.4572	.4877
Min	.0686	.0857	.0857	.0857	.0514	.0514	.0686
Avg	.2603	.2355	.2416	.2275	.1469	.1592	.1599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 205 / 11 KV SABALEWADI SINGLE SEPARATED AG FEEDERS HAVING SPECIAL
PHASIN Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3201		.3667	.2915	.2572	.3258
2	.2743	.3048		.3658	.2915	.2572	.3258
3	.2915	.2896		.381	.2915	.2572	.3429
4	.3258	.2896		.4268	.3258	.2915	.3772
5	.3429	.3506		.5487	.3601	.3086	.4115
6	.3944	.6249		.7926	.4115	.3772	.4458
7	.4801	.9755	.9602	.8993	.4801	.3601	.4973
8	.4115	.9907		.9907	.3944	.3086	.4458
9	.8078	.2572		.2743	.6859	.2134	.8078
10	1.1126	.2058	.2401	.2058	1.1584	.2896	1.1888
11	1.2193	.1715	.1886	.1715	1.2193	1.0364	1.1736
12	1.2498	.1372	.1715	.1543	1.2651	1.1279	.9145
13	1.2193	.1372	.1715	.1372	1.2193	1.1431	.945
14	1.1431	.1372	.1715	.1372	1.1888	1.1431	.884
15	1.0669	.1543	.1715	.1372	1.1584	1.1126	.8383
16	.9755	.1715	.1715	.1372	1.1279	.9602	.8078
17	.1543	.1543	.1715	.1886	.1715	.12	.1543
18	.2915	.2915	.3086	.2915	.2743	.2229	.2058
19	.3772	.463	.4458	.4287	.3944	.4458	.4115
20	.4115	.4458	.4458	.4287	.3429	.4287	.3944
21	.3429	.4115	.4115	.4115	.3086	.4287	.3944
22	.2915	.3944	.3772	.3601	.2915	.3601	.3429
23	.381	.3658	.4268	.3258	.2915	.3429	.3258
24	.381			.3963	.3086	.2743	.3258
Max	1.2498	.9907	.9602	.9907	1.2651	1.1431	1.1888
Min	.1543	.1372	.1715	.1372	.1715	.12	.1543
Avg	.5925	.3497	.3222	.3732	.5939	.5028	.5536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 206 / 11 KV JARADWADI
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0857		.0686	.1829	.1829	.2134
2	.0686	.0857		.0686	.1829	.1829	.1981
3	.0686	.0857		.0686	.1829	.2134	.1981
4	.0857	.12		.0857	.2134	.2439	.2439
5	.1029	.1543		.1029	.2743	.3048	.3048
6	.1543	.1715		.1543	.3353	.4268	.381
7	.1886	.1715	.1715	.1715	.4877	.5182	.5335
8	.1543	.1543		.1372	.6859	.6401	.7011
9	.5639	.4877		.503	.1372	.12	.12
10	.884	.7621	.6097	.7164	.12	.12	.1029
11	.945	.7468	.6401	.7164	.12	.12	.1029
12	.9602	.7316	.6706	.7011	.12	.12	.0686
13	.9145	.7011	.6859	.7316	.1029	.1029	.0686
14	.884	.6706	.7011	.7621	.1029	.1029	.0686
15	.8383	.7011	.6859	.7316	.1029	.1029	.0686
16	.823	.7164	.6859	.5487	.1029	.1372	.0857
17	.1543	.12	.1029	.12	.1029	.1543	.1029
18	.1543	.1372	.12	.1372	.12	.1715	.1029
19	.1543	.1543	.1543	.1715	.1543	.1715	.12
20	.1372	.1543	.1543	.1543	.1543	.1543	.12
21	.12	.1372	.12	.1372	.12	.12	.0857
22	.1029	.12	.1029	.1029	.1029	.1029	.0857
23	.0857	.1029	.0857	.1981	.1981	.2286	
24	.0857			.0857	.1029	.1981	.2134
Max	.9602	.7621	.7011	.7621	.6859	.6401	.7011
Min	.0686	.0857	.0857	.0686	.1029	.1029	.0686
Avg	.3625	.3249	.3794	.3073	.1879	.2058	.1865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214500 / 33/11 KV MEKHALI

Feeder No / Name : 201 / 11 KV MEKHALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	11-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3734	.5975	.5144	.3601
2	.3429	.4108	.5975	.5144	.4115
3	.3772	.4854	.6348	.5487	.4458
4	.4115	.5228	.7095	.5487	.5144
5	.0514	.6722	.7468	.5487	.6516
6	.6516	.8029	.7842	.5658	.8573
7	.7202	.8589	.8402	.583	.8402
8	.6001	.7282	.6535	.6001	.6687
9	.5316	.5041	.7468	.5144	.6001
10	.4458	.4108		.463	.5316
11	.3772	.3921		.4458	.4458
12	.3086	.3734	.3929	.3944	.3944
13		.3547	.3921	.3772	.3601
14	.3772	.3734	.3734	.3772	.2915
15	.3601	.3921	.3921	.3601	.3086
16		.3921	.4294	.3944	
17		.4294	.4668	.3601	.3944
18		.5415	.5415	.4801	.4973
19		.7468	.8775	.7716	.6859
20		.6535	.8775	.7373	.7202
21		.5975	.6348	.6859	.6859
22		.5788	.5975	.583	.5316
23			.5601	.4115	.5144
24	.3601	.3921	.5975	.5144	.3772
Max	.7202	.8589	.8775	.7716	.8573
Min	.0514	.3547	.3734	.3601	.2915
Avg	.4172	.5212	.6111	.5123	.5256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214500 / 33/11 KV MEKHALI

Feeder No / Name : 202 / 11 KV GHADAGEWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	11-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.0934	.168		.0857
2	.8059	.0934	.168		.1029
3	.823	.1307	.1867		.1029
4	.8573	.1307	.1867		.1372
5	.8916	.1494	.2054		.1886
6	.8916	.168	.2054		.2058
7	.9259	.1867	.2054		.2229
8	1.0117	.168	.2241		.1886
9	.1715	1.307	2.0165		.1543
10	.12	1.4937	2.3712		.12
11	.12	1.7737	2.5766		.0857
12	.12	1.9418	2.6139		.0857
13	.0857	2.0351	2.4272		.0857
14	.0857	2.1472	2.3152	.0686	.0857
15	.0857	2.1845	2.5766	.0686	.1029
16		2.1285	2.2965	.0857	.1029
17		.0934	.112	.1029	.0857
18		.1307	.1494	.12	.12
19		.2054	.168	.1543	.1372
20		.1494	.168	.1372	.1372
21		.1307	.1494	.12	.12
22		.112	.1307	.1372	.12
23			.1494	.1029	.9431
24	.8402	.0934	.168		.0857
Max	1.0117	2.1845	2.6139	.1543	.9431
Min	.0857	.0934	.112	.0686	.0857
Avg	.5401	.7412	.9141	.1097	.1586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214500 / 33/11 KV MEKHALI

Feeder No / Name : 203 / 11 KV SONGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	11-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	1.3443	1.4937	.2915	.1886
2	.1886	1.3443	1.4937	.2915	.2401
3	.2058	1.3817	1.5497		.2743
4	.2058	1.4003	1.5684	.3086	.2915
5	.2401	1.475	1.643	.3086	.3601
6	.2743	1.5684	1.6804	.3086	.3944
7	.3086	1.7177	1.6804	.3258	.3944
8	.2743	1.9231	1.587	.3258	.3601
9	1.8861	.3361	.1867	2.0576	1.6804
10	2.2977	.1307		2.0919	2.1434
11	2.3663	.1307		2.1948	2.1434
12	2.4006	.112	.1307	2.332	2.0062
13	2.1948	.1307	.1307	2.1776	2.0576
14	2.1262	.1307	.1307	2.2462	2.1091
15	2.0405	.112	.1307	2.2119	2.0576
16		.1307		2.1948	1.9376
17		.168	.1867	.1886	.1543
18		.2427	.2427	.2401	.2058
19		.2614	.3361	.3086	.2915
20		.2241	.3361	.3086	.2915
21		.2801	.2987	.2743	.2743
22		.2801	.2614	.2743	.2572
23			.3361	.2229	.2229
24	.1886	1.307	1.4937	.2915	.2058
Max	2.4006	1.9231	1.6804	2.332	2.1434
Min	.1886	.112	.1307	.1886	.1543
Avg	1.0867	.7014	.8046	.9468	.8559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214500 / 33/11 KV MEKHALI

Feeder No / Name : 204 / 11 KV NIRAWAGAJ GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	11-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2427	.3734	.2915	.2401
2		.2241	.3734	.2915	.2401
3	.2743	.2987	.4108	.3086	.2743
4	.3086	.3361	.4294	.3086	.3086
5	.3429	.3734	.4481	.3258	.3772
6	.4115	.4481	.4481	.3258	.463
7	.463	.4854	.4668	.3429	.4973
8	.3429	.3921	.4854	.3429	.4115
9	.2743	.3174	.3361	.2572	.3258
10	.2401	.1867	.2241	.1886	.2915
11	.2229	.1307	.2054	.1886	.2229
12	.1886		.1494	.1886	.1543
13	.1543	.112	.1494	.1715	.1372
14	.1715	.1307	.1867	.1543	.1372
15	.1715	.1307	.168	.1715	.1372
16		.1494	.1867	.1886	.1543
17		.168	.2054	.2229	.1543
18		.2801	.2427	.2743	.2401
19		.3921	.4108	.3772	.3772
20		.3734	.4108	.3601	.3429
21		.2801	.3361	.3429	.3258
22		.2614	.2987	.2743	.2743
23				.2229	.2743
24		.2614	.3734	.2915	.2058
Max	.463	.4854	.4854	.3772	.4973
Min	.1543	.112	.1494	.1543	.1372
Avg	.2743	.2716	.3182	.2672	.2736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214500 / 33/11 KV MEKHALI

Feeder No / Name : 205 / 11 KV ZARGADWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	11-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	1.251	2.4272	.3944	.3086
2	.2743	1.3443	2.4272	.3944	.3429
3	.3429	1.307	2.4832	.4115	.3429
4	.3772	1.3817	2.5393	.4115	.3772
5	.4115	1.419	2.5019	.4287	.4115
6	.4801	1.7177	2.5766	.4458	.5658
7	.5658	2.1285	2.6139	.4801	.6173
8	.5487	2.5953	2.6139	.5144	.583
9	2.1605	.4294	.3734	2.4006	2.2805
10	2.8464	.2987	.3734		2.7949
11	2.8635	.2614	.2987	2.6578	3.0007
12	2.8978	.2241	.2054	2.7949	2.9321
13	2.6749	.2054	.1867	2.6749	2.9835
14	2.7263	.168	.2054	3.2407	2.7778
15	2.7263	.168	.168	3.0864	2.5377
16		.2054	.1867	2.7263	
17		.2241		.2229	.2229
18		.3174	.2614	.3086	.2743
19		.4668	.4854	.463	.4458
20		.4108	.4854	.4801	.3772
21		.3921	.3921	.4115	.3601
22		.3734	.4108	.3772	.3601
23			1.4003	.3258	.3258
24	.2915	1.2323	2.4272	.3944	.3086
Max	2.8978	2.5953	2.6139	3.2407	3.0007
Min	.2572	.168	.168	.2229	.2229
Avg	1.4028	.8053	1.2193	1.1324	1.1101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 201 / Paras -MIDC-

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.1905	.1905	.2096	.2096	.1524	.2667
2	.2667	.1715	.1905	.1905	.2096	.1715	.2477
3	.2667	.1524	.1715	.1905	.2286	.1905	.2286
4	.2667	.1905	.1715	.1905	.2096	.1524	.2286
5	.2477	.2286	.1715	.2096	.2286	.1334	.2286
6	.2667	.2477	.1905	.2096	.2096	.1524	.2286
7	.2477	.2667	.2286	.2096	.2096	.1334	.2477
8	.2477	.2477		.2477	.2858	.1905	.3048
9	.2286	.2286		.2667	.3429	.3048	.381
10	.3429	.3048		.3429	.2667	.3048	.381
11	.362	.3429		.381	.2477	.3429	.381
12	.3239	.3048	.3429	.381	.2096	.3429	.381
13	.2477	.3048	.3429	.381	.2096	.381	.3429
14	.2858	.3239	.3239	.4191	.1905	.4191	.3429
15	.3239	.3239	.3239	.381	.1715	.4763	.381
16	.3048	.3429	.3048	.3429	.1905	.4763	.381
17	.2667	.3429	.2858	.3429	.1715	.4572	.381
18	.2477	.3429	.2667	.2667	.1715	.381	.3429
19	.2286	.3048	.2477	.3048	.1905	.381	.3239
20	.2477	.2286	.2286	.2286	.1524	.2858	.2858
21	.2667	.2286	.2286	.2477	.1905	.2858	.2858
22	.2286	.2096	.2096	.2286	.1715	.2667	.3048
23	.2096	.2096	.2096	.2096	.1524	.2667	.2858
24	.3048	.2286	.1905	.2096	.2096	.1334	.2667
Max	.362	.3429	.3429	.4191	.3429	.4763	.381
Min	.2096	.1524	.1715	.1905	.1524	.1334	.2286
Avg	.2715	.2612	.2410	.2747	.2096	.2826	.3096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 202 / Naka footwear

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.7621		.9907	.724	.724	.9145
2	.9717	.743		.9526	.6668	.6668	.9145
3	.9907	.8002		.9145	.5906	.724	.8573
4	1.0098	.8573		.9335	.5716	.7621	.8573
5	1.0098	.9145		.9526	.5525	.8573	.8192
6	1.0098	.8954		.9717	.5716	.9335	.8192
7	.9907	.8573		.9907	.5716	.724	.8383
8	.8764	.8573		1.0669	.5906	1.2765	.8383
9	.8002	.8383		1.1812	.6287	1.0669	.9145
10	.9526	.9907		1.5242	.8573	1.1431	.9526
11	1.0098	1.2193		1.7528	1.105	1.2574	.9907
12	1.0479	1.0669	1.5242	1.2955	1.105	1.4861	1.0288
13	.8764	1.1431	1.5432	1.2193	1.105	1.5623	1.0479
14	.9526	1.2193	1.4861	1.1431	1.0479	1.6385	1.0288
15	.9526	1.2193	1.448	1.105	1.0098	1.6194	1.0098
16	.9145	1.2193	1.3717	1.0669	.9907	1.6004	.9907
17	.8192	1.2193	1.3336	.9907	1.0098	1.5623	.9907
18	.8573	1.1431	1.2955	1.1241	.7811	1.5242	.9526
19	.8764	1.105	1.2384	1.1622	1.1241	1.448	.9526
20	.9145	1.0669	1.1812	1.1812	.9907	1.2193	.9145
21	.8383	1.1431	1.1622	1.0479	.7811	1.1812	.9145
22	.7621	.9907	1.1431	.9526	.6668	1.1431	.8383
23	.7621	.9526	1.105	.8573	.724	.9907	.8383
24	.9526	.7811		1.0479	.8002	.7621	.9526
Max	1.0479	1.2193	1.5432	1.7528	1.1241	1.6385	1.0479
Min	.7621	.743	1.105	.8573	.5525	.6668	.8192
Avg	.9209	1.0002	1.3194	1.1010	.8153	1.1614	.9240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 203 / Ganesh Mandir

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	.7621	.9145	1.0479	.9907	.9145	.9145
2	1.0288	.743	.9145	.9907	.9526	.8573	.9145
3	.9907	.8002	.9145	.9907	.9526	.7621	.8954
4	.9526	.8192	.9526	1.0479	1.0479	.8573	.8954
5	1.0098	.8383	1.0479	1.086	1.1431	1.0098	.9526
6	1.1241	1.2765	1.3336	1.2955	1.3336	1.1241	1.1431
7	1.1812	1.6194	1.6766	1.7528	1.7147	1.6575	1.448
8	1.4289	2.21		2.0957	2.0957	2.1338	1.829
9	1.6766	1.448		1.5623	1.5242	1.5623	1.6766
10	1.4289	1.3336		1.2955	1.3336	1.448	1.3717
11	1.2574	1.1431		1.1431	1.2384	1.3336	1.2003
12	1.1431	.9907	1.1431	1.0669	1.105	1.1431	1.0479
13	1.086	.9145	.9526	.9526	1.0479	1.0669	1.0288
14	.8573	.8383	.8573	.8383	.9717	.9907	.9907
15	.8573	.9145	.7811	.8573	.8764	.9145	.9907
16	.9717	.9145	.8192	.9145	.9526	.8573	.9907
17	1.0479	1.0669	.9145	.9907	1.086	.9526	1.2955
18	1.1812	1.2193	.9335	1.2003	1.2765	1.2193	1.4098
19	1.5242	1.3336	1.2384	1.6194	1.5623	1.4861	1.4861
20	1.6575	1.5242	1.4098	1.5813	1.5623	1.4289	1.3717
21	1.3717	1.3717	1.2955	1.448	1.4289	1.3336	1.2574
22	1.2193	1.2193	1.1812	1.3336	1.2003	1.0669	1.0669
23	1.105	1.1431	1.1431	1.2384	1.105	.9145	.9145
24	1.0098	.7811	.9145	1.0479	1.0479	.9526	.9145
Max	1.6766	2.21	1.6766	2.0957	2.0957	2.1338	1.829
Min	.8573	.743	.7811	.8383	.8764	.7621	.8954
Avg	1.1733	1.1344	1.0669	1.2249	1.2312	1.1661	1.1669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 204 / RUI HOSPITAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.349	.3444	.1608	.3483	.3486	.3517	.3799
2	.2995	.2995	.1509	.3376	.3429	.322	.3505
3	.2999	.3345	.1486	.3152	.3212	.3532	.3475
4	.2866	.3174	.1494	.3159	.3372	.3905	.3285
5	.2983	.3467	.1585	.3444	.3643	.3616	.3464
6	.3086	.3932	.2065	.4016	.4344	.4036	.3746
7	.3242	.3917	.2542	.4767	.5034	.5331	.4256
8	.3525	.5308	.3033	.5369	.5738	.5807	.4348
9	.3898	.551	.3292	.5224	.5681	.634	.5464
10	.431	.583	.3323	.6614	.6261	.6813	.5369
11	.3989	.6169	.5643	.5635	.6096	.6702	.5037
12	.3406	.5353	.5323	.541	.5792	.5887	.4831
13	.2927	.4405	.4873	.4755	.5388	.5628	.4538
14	.2329	.351	.4192	.4065	.4557	.5631	.4138
15	.25	.4253	.4233	.5437	.493	.5685	.4252
16	.2469	.4409	.4577	.6371	.5117	.506	.426
17	.3376	.4481	.4736	.5681	.5075	.5205	.466
18	.4279	.5262	.511	.5571	.5193	.5361	.5621
19	.4455	.5277	.543	.6466	.6543	.6032	.6093
20	.4264	.5155	.5278	.6835	.6405	.5948	.5765
21	.4527	.4995	.506	.5856	.5921	.5788	.5734
22	.4603	.4957	.4976	.5376	.5781	.5799	.5635
23	.4092	.4401	.4443	.4732	.4728	.4436	.5102
24	.4027	.3571	.1859	.4108	.4192	.3886	.4253
Max	.4603	.6169	.5643	.6835	.6543	.6813	.6093
Min	.2329	.2995	.1486	.3152	.3212	.322	.3285
Avg	.3527	.4463	.3653	.4954	.4997	.5132	.4610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 205 / Kalyani Corner

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.381	.5716	.4572	.4954	.4572	.4954
2	.4763	.362		.4191	.5335	.5335	.4954
3	.4191	.4382		.381	.5144	.5716	.4572
4	.4001	.4763		.3429	.5335	.5335	.4382
5	.4001	.4382		.3239	.5144	.5716	.4382
6	.4191	.4191		.3048	.5525	.6478	.4191
7	.381	.4001		.3239	.5144	.4763	.4191
8	.381	.6097		.6097	.5906	.6287	.724
9	.381	.5716		.7811	.7621	.6668	.6859
10	.3429	.6859		.7621	.7811	.724	.6478
11	.381	.8383		.9526	.7811	.6859	.6668
12	.362	.8764	.743	.9145	.7621	.6478	.6859
13	.381	.8002	.7621	.8764	.7811	.5716	.6478
14	.4382	.8383	.743	.8383	.743	.5335	.6097
15	.4191	.9145	.7621	.7621	.7621	.4954	.5716
16	.4572	.5716	.724	.5716	.743	.4382	.4763
17	.4191	.4572	.6097	.724	.4954	.4572	.4763
18	.381	.4954	.5144	.5335	.4382	.4763	.4763
19	.4001	.4572	.5335	.5906	.5525	.4763	.4954
20	.4382	.4954	.5525	.5335	.6287	.4954	.4954
21	.381	.4954	.5335	.5525	.5716	.4572	.4763
22	.362	.6478	1.105	.5335	.5525	.5716	.6097
23	.381	.6097	.5525	.5144	.4763	.5716	.6097
24	.5335	.4001	.5716	.5144	.4763	.4191	.5335
Max	.5335	.9145	1.105	.9526	.7811	.724	.724
Min	.3429	.362	.5144	.3048	.4382	.4191	.4191
Avg	.4096	.5700	.6628	.5882	.6065	.5462	.5438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214477 / 33/11 kV Textile park

Feeder No / Name : 201 / Geeta textile

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.12	.1372	.12	.1402	.1402	.12
2	.1372	.1174	.1372	.12	.1402	.1402	.12
3	.1372	.1147	.1372	.12	.1402	.1402	.12
4	.1372	.1147	.1372	.12	.1402	.1402	.12
5	.1372	.1147	.1372	.12	.1402	.1402	.1372
6	.1372	.1187	.1372	.1372	.1402	.1402	.1372
7	.1372	.1174	.1372	.1372	.1227	.1402	.1372
8	.1372	.1372	.12	.1372	.1227	.1402	.1372
9	.463	.3429		.4287	.1753	.4115	.1543
10	.3944	.5144		.4115	.1753	.3944	.1886
11	.4115	.4801	.4115	.4801	.2103	.4115	.2058
12	.4287	.4458	.4115	.4458	.1753	.4287	.2401
13	.3772	.4801	.4287	.4458	.1753	.4287	.2743
14	.3772	.4287	.4458	.4115	.1753	.4801	.2401
15	.4115	.4287	.4694	.3772	.1402	.4973	.2058
16	.4207	.4458	.4527	.3429	.1227	.5144	.2058
17	.4801	.5144	.4801	.4031		.4458	.1526
18	.218	.2572	.2743	.2279		.2743	.1174
19	.1844	.1886	.2229	.1753	.1227	.1715	.1526
20	.1147	.1372	.1886	.1402	.1227	.1543	.1341
21	.116	.1372	.12	.1402	.1402	.1372	.1372
22	.1147	.1372	.12	.1402	.1402	.12	.1341
23	.1174	.1372	.12	.1402	.1402	.12	.1311
24	.1372	.1147	.1372	.12	.1402	.1402	.12
Max	.4801	.5144	.4801	.4801	.2103	.5144	.2743
Min	.1147	.1147	.12	.12	.1227	.12	.1174
Avg	.2443	.2560	.2438	.2434	.1474	.2605	.1593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214477 / 33/11 kV Textile park

Feeder No / Name : 202 / Cotton King

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1286	.1448	.1429	.1429	.1337	.1486	.1429
2	.1286	.1486	.1429	.1429	.1337	.1486	.1429
3	.1286	.1448	.1429	.1429	.1337	.1486	.1429
4	.1429	.1448	.1429	.1429	.1337	.1486	.1429
5	.1429	.1448	.1572	.1429	.1486	.1486	.1429
6	.1572	.1486	.1572	.1715	.1635	.1486	.1572
7	.1572	.1638	.1572	.1715	.1635	.1486	.1715
8	.1572	.1783	.1572	.1715	.1635	.1486	.1715
9	.1715	.176		.1429	.1486	.176	.1572
10	.2054	.2054		.2	.1486	.176	.176
11	.2054	.176	.2054	.2	.1635	.176	.1614
12	.2054	.176	.2347	.1715	.1635	.1467	.176
13	.1467	.1467	.2347	.1715	.1486	.1467	.176
14	.176	.1429	.2286	.2	.1337	.1467	.176
15	.176	.1715	.2	.2286	.1337	.1467	.2054
16	.176	.1715	.2	.2572	.1486	.1467	.2054
17	.1738	.1429	.1715	.208	.1486	.1429	.2317
18	.1429	.1429	.1429	.1783	.1486	.1429	.1448
19	.1448	.1429	.1429	.1783	.1486	.1572	.1429
20	.141	.5716	.1429	.1486	.1486	.1429	.1448
21	.1429	.1429	.1429	.1337	.1486	.1429	.1448
22	.1448	.1429	.1429	.1486	.1486	.1286	.1429
23		.1429	.1429	.1337	.1486	.1286	.1448
24	.1286	.1448	.1429	.1429	.1337	.1486	.1429
Max	.2054	.5716	.2347	.2572	.1635	.176	.2317
Min	.1286	.1429	.1429	.1337	.1337	.1286	.1429
Avg	.1576	.1733	.1671	.1697	.1474	.1494	.1620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214477 / 33/11 kV Textile park

Feeder No / Name : 204 / 11 KV RUI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1791	.1646	.1829	.1829	.2012	.1829
2	.1829	.181	.1646	.1829	.1829	.2012	.1829
3	.1829	.1791	.1829	.1829	.1829	.2012	.1829
4	.2012	.2149	.1829	.2195	.2012	.2743	.2012
5	.2378	.2328	.2195	.2743	.2561	.3658	.2561
6	.3109	.394	.3658	.3841	.3658	.4024	.3841
7	.439	.5973	.5853	.567	.5487	.6219	.5121
8	.567	.6447	.0389	.6401	.6584	.695	.6036
9	.5487	.4572		.0274	.5304	.4938	.4938
10	.4572	.3475		.4207	.5304	.4024	.4755
11	.4024	.3658	.3292	.3658	.3475	.3658	.3658
12	.362	.3258	.2896	.3292	.2926	.3292	.3658
13	.2926	.2926	.2378	.2743	.2561	.3109	.2561
14	.2561	.2378	.2561	.2926	.2378	.3109	.2561
15	.2561	.2561	.2561	.2926	.2195	.3292	.2378
16	.2926	.2561	.2378	.2743	.2561	.2926	.2353
17	.3761	.3475	.3109	.3475	.3109	.3292	.2507
18	.3801	.3841	.439	.3841	.439	.4207	.3258
19	.4656	.4572	.4755	.4755	.5121	.4572	.3761
20	.4344	.4755	.4572	.4024	.4938	.4024	.3582
21	.3761	.3841	.3841	.3841	.439	.3658	.3224
22	.2865	.3475	.3109	.3109	.3292	.3109	.2896
23	.2353	.2195	.2195	.2012	.2195	.2378	.2149
24	.1829	.1791	.1646	.1829	.1829	.2012	.1829
Max	.567	.6447	.5853	.6401	.6584	.695	.6036
Min	.1829	.1791	.0389	.0274	.1829	.2012	.1829
Avg	.3296	.3315	.2851	.3166	.3407	.3551	.3130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214478 / 33/11 kV MIDC Baramati - II

Feeder No / Name : 201 / Airport

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9624	2.0576	2.2481	1.9052	1.9052	1.5242	2.0005
2	1.9624	1.9814	2.191	1.8861	1.8671	1.5242	1.9624
3	1.9433	2.0195	2.1529	1.8671	1.8671	1.4861	1.9052
4	1.9052	2.0576	2.1338	1.8861	1.7718	1.4861	1.9052
5	1.8671	1.8671	2.1338	1.848	1.7909	1.4861	1.8671
6	1.7718	1.829	2.1338	1.8671	1.8099	1.5242	1.8671
7	1.6575	1.6956	1.829	1.6194	1.467	1.5242	1.6575
8	1.8099	1.5813	1.7909	1.5623	1.4098	1.6385	1.6194
9	2.2481	1.9433		1.9624	1.3908	2.0767	1.848
10	2.4006	2.1529		2.2291	1.6766	2.191	1.8861
11	2.4577	2.0957		2.3815	1.8671	2.2862	2.0195
12	2.3243	2.1529	2.191	1.9814	1.5623	2.3053	2.0576
13	2.2481	2.1719	2.0386	2.0005	1.5242	2.21	1.829
14	2.1338	2.0957	2.2291	2.0957	1.5242	2.1338	1.829
15	2.0957	2.2481	2.2481	2.1529	1.5242	2.2481	1.9814
16	2.0576	2.3815	2.3243	2.2291	1.5242	2.0386	2.0005
17	1.6956	2.1148	2.191	1.9624	1.4861	1.9433	1.9624
18	1.7528	2.1148	1.9052	1.6956	1.4861	1.8861	1.848
19	1.9243	2.0767	1.9433	1.7909	1.467	1.9814	2.1338
20	1.8671	1.9052	1.8671	1.9052	1.448	1.9624	2.0386
21	1.829	1.8099	1.8099	1.848	1.448	1.9433	2.0195
22	1.829	1.9052	1.7147	1.7718	1.4861	1.9052	2.0386
23	2.1338	2.2481	1.9052	1.8671	1.5242	1.9433	2.21
24	1.9814	2.0957	2.2672	1.9243	1.9052	1.5813	2.0005
Max	2.4577	2.3815	2.3243	2.3815	1.9052	2.3053	2.21
Min	1.6575	1.5813	1.7147	1.5623	1.3908	1.4861	1.6194
Avg	1.9941	2.0251	2.0594	1.9266	1.6139	1.8679	1.9370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214478 / 33/11 kV MIDC Baramati - II

Feeder No / Name : 202 / Water Supply MIDC
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0856	1.1775	1.2426	1.1321	1.297	.4287	.9415
2	1.1546	1.1565	1.2053	1.1161	1.2052	.4187	1.0273
3	1.1035	1.1404	1.1291	1.0795	1.1671	.413	.9724
4	1.1542	1.2487	1.1702	1.1938	1.1378	.4508	.9868
5	1.1675	1.2258	1.2354	1.2323	1.2719	.5331	1.0421
6	1.1176	1.2537	1.1999	1.1881	1.299	.5212	1.1747
7	1.3523	1.278	1.1112	1.0582	1.4095	.6938	1.1996
8	1.2293	1.273	1.1923	1.4499	.8871	.9355	1.3367
9	1.4621	1.3832	.7244	1.4521	.6519	1.4354	1.3958
10	1.6206	1.5142	.7381	1.8953	.5471	2.0896	1.6323
11	1.8861	1.4857	1.3607	1.8168	.6116	2.1167	1.8331
12	1.848	1.5977	1.4746	1.6328	.6062	1.7711	1.4415
13	1.837	1.3946	1.5897	1.4205	.4477	1.4841	1.297
14	1.8225	1.4297	1.6358	1.336	.5384	1.773	1.4769
15	1.741	1.3565	1.7794	1.5299	.5475	1.8804	1.9288
16	1.7501	1.4282	1.8313	1.7356	.5281	2.0294	1.9025
17	1.5508	.8989	1.6899	1.542	.6611	1.8758	1.8976
18	1.0974	1.3089	1.6129	1.4651	.647	1.4948	1.7265
19	1.1504	1.4197	1.6008	1.3184	.6767	1.3413	1.7047
20	1.0536	1.2909	1.246	1.2087	.6108	1.1336	1.3839
21	1.15	1.2129	1.1272	1.1451	.5738	1.0204	.998
22	1.1397	1.2719	1.1695	.8771	.5391	1.0551	.8657
23	1.0929	1.2418	1.3081	1.0585	.5064	1.1439	1.1176
24	1.2098	1.1919	1.182	1.1253	.9019	.7312	1.1077
Max	1.8861	1.5977	1.8313	1.8953	1.4095	2.1167	1.9288
Min	1.0536	.8989	.7244	.8771	.4477	.413	.8657
Avg	1.3657	1.2992	1.3149	1.3337	.8029	1.1988	1.3496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 201 / Shriramnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.743	.5837	.6058	.2667	.3048	.583
2	.2858	.5624	.567	.5723	.2477	.2667	.5457
3	.2667	.5532	.5182	.5662	.2477	.2667	.5212
4	.2858	.5532	.2873	.5647	.2477	.2286	.522
5	.3048	.631	.3147	.6303	.2858	.3429	.5799
6	.3429	.8246	.4306	.8124	.381	.4191	.7514
7	.4382	1.1355	.5693	1.2185	.6097	.6097	.945
8	.6287	1.3832	.8002	1.4632	.6668	.6859	1.3169
9	.6287	1.2628	1.3733	1.2742	.5525	.6478	1.3291
10	.5335	1.1942	1.1226	1.0441	.5335	.4954	1.2567
11	.4954	.999	1.0336	.9716	.4954	.5144	1.0692
12	.4382	.967	.9928	.9365	.4191	.4763	.9069
13	.4191	.9091	.9092	.8794	.4572	.4191	.8581
14	.381	.8611	.8444	.836	.4191	.4191	.836
15	.362	.8428	.7849	.8047	.4191	.362	.7903
16	.362	.8954	.8771	.8253	.4191	.4191	.7735
17	.4001	.9572	.8764	.9313	.4191	.9877	.8161
18	.4763	1.1272	1.0708	1.0982	.5335	1.0814	.9824
19	.5906	1.4068	1.3916	1.3466	.6859	1.3946	1.2368
20	.5906	1.3482	1.3412	1.3017	.6478	1.2614	1.2003
21	.5335	1.2803	1.2133	.5525	.5716	1.1714	.5335
22	.4572	1.163	1.0211	.4572	.4954	1.031	.4763
23	.3239	.8657	.8253	.362	.381	.8467	.362
24	.3048	.6417	.6523	.3048	.2858	.6706	.2858
Max	.6287	1.4068	1.3916	1.4632	.6859	1.3946	1.3291
Min	.2667	.5532	.2873	.3048	.2477	.2286	.2858
Avg	.4223	.9628	.8500	.8483	.4453	.6384	.8116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 202 / Desai Estate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	.9991	.4954	.4954	.4954	.4572	.4763
2	.9976	.9656	.4954	.4763	.4763	.4572	.4572
3	.9945	.9259	.4572	.4763	.4572	.4572	.4382
4	1.0083	.9312		.4954	.4572	.4191	.4382
5	1.0708	1.0227		.5716	.4954	.4954	.4763
6	1.2361	1.4495		.724	.7049	.724	.6097
7	1.4677	1.8503		.9526	.8954	.9526	.7049
8	1.9083	2.0912		1.0098	1.0669	1.0669	.8764
9	1.9776	1.9852	1.0288	.9717	.9526	1.0288	.9145
10	1.9013	1.8191	.8488	.8764	.8764	.8383	.8954
11	1.6987	.8383	.7621	.7811	.724	.7811	.724
12	1.592	.8002	.724	.7621	.7621	.7621	.7049
13	1.4541	.7621	.7167	.7049	.724	.724	.6859
14	1.2765	.6859	.6478	.6097	.6097	.6287	.6478
15	1.1622	.6478	.6668	.6478	.6478	.724	.6287
16	1.1569	.6859	.6478	.6287	.6478	.6859	.5906
17	1.2201	.7621	.6478	.6859	.6478	.6859	.6097
18	1.4037	.8383	.8002	.7811	.8002	.8002	.7621
19	1.9631	1.0288	1.0288	1.0288	1.0098	1.0288	.9526
20	1.9112	.9907	.9717	.9717	.9526	.9717	.9145
21	1.816	.9526	.8954	.8954	.9526	.8764	.8383
22	1.6171	.9145	.7621	.7621	.8002	.7811	.724
23	1.3412	.6478	.6097	.5906	.6097	.6287	.6287
24	1.1584	.5144	.5335	.5093	.4954	.4954	.5144
Max	1.9776	2.0912	1.0288	1.0288	1.0669	1.0669	.9526
Min	.9945	.5144	.4572	.4763	.4572	.4191	.4382
Avg	1.4326	1.0462	.7232	.7254	.7192	.7279	.6756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 203 / Ashoknagar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2829	.2667	.2829	.2829	.3048	.2829
2	.3018	.2641	.2667	.2641	.2641	.2667	.2641
3	.2829	.2641	.2667	.2641	.2452	.2667	.2452
4	.2829	.2829		.2641	.2452	.2286	.2452
5	.3018	.3206		.3018	.2641	.3048	.2829
6	.3395	.3584		.3772	.3772	.4191	.3395
7	.3961	.5281		.4715	.415	.4954	.3584
8	.5093	.5281		.5658	.6036	.6036	.4715
9	.6224	.547	.5658	.5281	.5658	.5716	.5144
10	.547	.5716	.4904	.5093	.5335	.5281	.5281
11	.5847	.4954	.4904	.4904	.5335	.4904	.5281
12	.4338	.5335	.4904	.4904	.4572	.5093	.4904
13	.4527	.5335	.4904	.415	.4954	.4904	.4527
14	.3961	.4954	.4715	.4527	.4191	.4904	.4715
15	.3772	.4954	.4338	.415	.4191	.4338	.4338
16	.3961	.5335	.415	.4338	.4572	.4715	.2641
17	.3772	.5335	.4715	.4715	.4954	.4338	.415
18	.4715	.6097	.5281	.547	.5335	.5281	.547
19	.6602	.724	.679	.7167	.724	.7167	.6413
20	.6224	.6859	.6602	.6413	.6859	.6413	.6224
21	.5658	.6097	.5847	.6036	.6097	.5847	.5658
22	.5093	.4954	.5093	.4904	.5335	.4904	.4715
23	.3584	.4191	.3772	.3772	.381	.3961	.3772
24	.3206	.3018	.3048	.3018	.3018	.3048	.3018
Max	.6602	.724	.679	.7167	.724	.7167	.6413
Min	.2829	.2641	.2667	.2641	.2452	.2286	.2452
Avg	.4338	.4756	.4612	.4448	.4518	.4571	.4215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 204 / T.C. College

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.679	.7167	.6413	.6224	.6413	.679
2	.6224	.6602	.679	.6224	.6036	.6413	.6413
3	.6224	.6413	.679	.6036	.5847	.6036	.6413
4	.6602	.6413		.6413	.5847	.5658	.6602
5	.811	.7356		.7922	.6224	.6413	.7167
6	1.0374	1.1506		1.1506	1.1694	1.2449	1.0562
7	1.2826	1.5089		1.6221	1.6032	1.5466	1.226
8	1.358	1.5278		1.6409	1.6409	1.7353	1.4146
9	1.4901	1.4523	1.5089	1.5278	1.5089	1.5844	1.4901
10	1.4523	1.4712	1.4523	1.4335	1.4712	1.5844	1.5089
11	1.4523	1.358	1.3014	1.3203	1.3203	1.3769	1.4523
12	1.2637	1.3203	1.3392	1.226	1.2449	1.2449	1.2637
13	1.2071	1.2826	1.2449	1.2449	1.1694	1.1883	1.1883
14	1.1317	1.2449	1.1317	1.1694	1.1317	1.1128	1.1694
15	1.0751	1.2071	1.1506	1.1506	1.1694	1.1128	1.1317
16	1.094	1.2449	1.1317	1.1694	1.1317	1.1883	1.0562
17	1.1694	1.2826	1.2071	1.2449	1.1317	1.226	1.1128
18	1.3957	1.5089	1.4712	1.4335	1.4712	1.5089	1.4146
19	1.6787	1.8861	1.8861	1.8861	1.8296	1.8861	1.7918
20	1.6598	1.773	1.6787	1.7918	1.773	1.7541	1.6598
21	1.4335	1.5089	1.4523	1.4901	1.5466	1.4901	1.3203
22	1.226	1.2826	1.2637	1.1694	1.2449	1.2826	1.1883
23	.8488	.9808	.9242	.8865	.9431	.9808	.9431
24	.7167	.7167	.7545	.6979	1.2449	.6413	.6979
Max	1.6787	1.8861	1.8861	1.8861	1.8296	1.8861	1.7918
Min	.6224	.6413	.679	.6036	.5847	.5658	.6413
Avg	1.1395	1.2111	1.2091	1.1899	1.1985	1.1993	1.1427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 205 / Khandobanagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.548	1.46	1.5836	1.567	1.5164	1.3676	1.5176
2	1.5253	1.4114	1.5372	1.5571	1.4398	1.3295	1.4175
3	1.4971	1.388	1.4902	1.5161	1.4179	1.2826	1.4025
4	1.5221	1.3653	.7948	1.5442	1.4278	1.2715	1.42
5	1.6876	1.557	.9153	1.7547	1.5485	1.4731	1.5672
6	2.1223	2.2668	1.1835	2.3291	2.3483	2.3461	2.114
7	2.4241	2.6852	1.5501	2.8397	2.8149	2.8647	2.5227
8	2.884	3.0879	1.7383	3.2322	3.3116	3.261	2.7715
9	1.8383	2.9974	3.2986	3.0782	3.2785	3.2102	3.0398
10	1.9767	2.918	3.0556	3.0376	3.0723	3.0054	3.0407
11	2.256	3.0155	2.9584	2.9612	3.0358	2.9455	2.8909
12	2.7765	2.9443	2.8607	2.9327	2.7739	2.6918	2.5172
13	2.7168	2.559	2.6582	2.5882	2.6284	2.5191	2.3049
14	2.3598	2.4127	2.6122	2.4546	2.1628	2.372	2.1862
15	2.2809	2.4821	2.4678	2.5794	2.0332	2.3722	2.1832
16	2.383	2.5214	2.5261	2.6196	2.164	2.4145	2.1335
17	2.42	2.5637	2.7008	2.7978	2.2885	2.4489	2.1626
18	2.7559	3.0014	2.9961	2.9548	2.756	2.7265	2.5562
19	3.2992	3.7007	3.6359	3.7036	3.4411	3.331	3.0193
20	3.1164	3.4823	3.3084	3.4699	3.2655	3.1861	2.7766
21	2.9008	3.1257	2.9936	3.1446	3.0019	2.9311	2.5862
22	2.5019	2.5998	2.673	2.7528	2.606	2.6137	2.3929
23	1.9654	2.2096	2.1965	2.2003	1.997	2.1514	2.0641
24	1.6367	1.6821	1.8137	1.7465	1.6207	1.608	1.6301
Max	3.2992	3.7007	3.6359	3.7036	3.4411	3.331	3.0407
Min	1.4971	1.3653	.7948	1.5161	1.4179	1.2715	1.4025
Avg	2.2665	2.4766	2.3145	2.5567	2.4146	2.4051	2.2591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 206 / Avchat Estate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6413	.679	.6224	.6036	.679	.6979
2	.5658	.6224	.679	.5847	.5847	.679	.679
3	.5658	.6224	.6413	.547	.5658	.6036	.6413
4	.6036	.6413		.5658	.547	.5658	.6413
5	.7167	.7356		.7167	.5847	.6348	.679
6	.8865	.9431		.9619	.9808	1.0185	.8865
7	.9619	1.0562		1.0562	1.094	1.1694	.9808
8	1.0562	1.226		1.1506	1.1883	1.2449	1.0562
9	1.1128	1.1317	1.2071	1.094	1.1317	1.2071	1.1317
10	1.1317	1.2071	1.2637	1.2071	1.2071	1.2826	1.2449
11	1.094	1.2449	1.226	1.1694	1.2071	1.3203	1.2637
12	1.0751	1.2449	1.2071	1.1883	1.1317	1.2071	1.2449
13	1.0562	1.1694	1.1694	1.1317	1.1694	1.2449	1.094
14	.9808	1.2071	1.1506	1.1317	1.1317	1.1128	1.0751
15	.9431	1.3203	1.0562	1.094	1.094	1.094	1.0374
16	.9054	1.3203	1.094	1.1128	1.1317	1.1128	.9619
17	.9431	1.2826	1.1506	1.1694	1.1694	1.1883	1.094
18	1.2071	1.5466	1.4335	1.4146	1.3203	1.358	1.3203
19	1.4712	1.7353	1.7353	1.9239	1.6787	1.6975	1.6598
20	1.3203	1.6221	1.6221	1.5655	1.6221	1.6221	1.5089
21	1.1883	1.3203	1.2826	1.2826	1.358	1.358	1.2449
22	1.0185	1.094	1.0751	1.0562	1.1317	1.094	1.094
23	.7545	.9054	.8488	.811	.8676	.8865	.9054
24	.679	.6602	.7167	.679	.6602	.7167	.7167
Max	1.4712	1.7353	1.7353	1.9239	1.6787	1.6975	1.6598
Min	.5658	.6224	.6413	.547	.547	.5658	.6413
Avg	.9517	1.1042	1.1178	1.0515	1.0484	1.0874	1.0358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 212004 / Switching Station Indapur

Feeder No / Name : 205 / 11 KV Kandalgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.4115		.2915	.6173	.2572	.3258
2	.2915	.4801		.2743	.6024	.2401	.3429
3	.2401	.5316		.2572	.6588	.2401	.4287
4	.3086	.583		.2401	.6783	.2743	.4801
5	.3258	.6687		.3601	.703	.3944	.583
6	.583	.703		.4801	.7888	.4973	.6344
7	.7373	.7545		.6001	.8589	.6516	.6687
8	.8059	.703		.7888	.823	.7373	.7202
9	.7373	.6687		.6001	.583	.703	.6859
10	.583	.583		.6687	.5316	.5487	
11	.4973		.4458	.4908	.4973	.4458	.5487
12	.4458		.5201	.4031	.4287	.4801	.3772
13	.3944	.5895	.5144	.4973	.463	.4287	.3601
14	.3772	.5144	.4287	.5375	.4458		.3429
15	.3601		.4588	.5138	.6001		.3086
16	.3429	.6379	.4973	.5316	.583		.2743
17	.3944	.4458	.5144		.5144		.3258
18	.463	.5548	.6001	.3601	.463		.4458
19	.6344	.5658	.6516	.4607	.583	.6687	.4973
20	.5316	.5375	.5316	.5258	.6516	.5316	.5316
21	.4801	.5138	.4287	.5895	.5144	.5316	.4973
22	.4287	.4973	.3944	.5487	.3944	.463	.4801
23	.3944	.5375	.3601	.5959	.3601	.3944	.463
24	.3601	.3601	.5487	.3258	.5658	.3086	.5658
Max	.8059	.7545	.6516	.7888	.8589	.7373	.7202
Min	.2401	.3601	.3601	.2401	.3601	.2401	.2743
Avg	.4594	.5639	.4925	.4757	.5796	.4630	.4734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 212004 / Switching Station Indapur

Feeder No / Name : 206 / Kalthan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543		1.5947	1.0974	1.3546	.1715
2	.0857	.1372		1.6289	1.1831	1.3889	.2229
3	.0857	.1715		1.5432	1.2003	1.3375	.2743
4	.1029	.2401		1.3717	1.2689	1.286	.3086
5	.1543	.2915		1.286	1.3032	1.4403	.3601
6	.2058	.3601		1.5261	1.3717	1.5261	.3944
7	.3086	.3944		1.6118	1.406	1.6118	.4287
8	.3944	.3601		1.5604	1.6461	1.5089	.3944
9	1.7318	.3086		.3258	.2743	1.5947	1.869
10	1.8347	.2058		.1715	.2572	1.7318	
11	1.8004	.1949		.1886	.2743	1.7147	2.1091
12	1.8347	.2103	.1715	.2229	.2743	1.7318	2.0576
13	1.8176	.181	.1928	.1886	.2915	1.7147	1.9033
14	1.7318	.1543	.1715	.1715	.2743		1.8004
15	1.6804	.1753	.2204	.2058	.2572		1.869
16	1.5604	.2279	.2572	.2572	.2743		1.8861
17	.0857	.2401	.2743	.2743	.2915		.2572
18	.1543	.333	.3086	.3258	.3086		.3086
19	.2229	.3429	.3601	.3086	.3944	1.6975	.3601
20	.2572	.3366	.3258	.3258	.4801	1.6118	.3258
21	.2743	.3429	.2915	.2915	.3772	1.5432	.3086
22	.2401	.3721	.2572	.2743	.2229	.2229	.2743
23	.2058	.9816	1.406	.9259	1.2174	.2229	.2401
24	.1543	.1715	1.0631	1.4746	1.0288	1.2689	.1886
Max	1.8347	.9816	1.406	1.6289	1.6461	1.7318	2.1091
Min	.0857	.1372	.1715	.1715	.2229	.2229	.1715
Avg	.7109	.287	.4077	.7523	.7073	1.3952	.7962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 201 / Sarate

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.6602	.8488			1.2346	1.2041
2	1.1431	.6602	.8488			1.2346	1.2041
3	1.1431	.6602	.8488			1.2346	1.2041
4	1.3108	.8859	.9431		1.226	1.4232	1.3927
5	1.5089	1.387			1.5604	1.6385	1.5746
6	1.8442	1.8004			1.6956	2.0805	2.0805
7	2.392	1.7804			1.8861	2.4272	2.4806
8	2.572	1.8004			1.6956	2.6578	2.572
9	1.3413	2.2119			2.0957		
10	1.0174	2.2119			2.0957		
11		2.1348					
12	.7545	2.1091	1.8576		2.1195		
13	.7545	2.1091	1.7528		2.0957	.7545	
14	.6602		1.6004		2.0719	.6602	.9054
15	.724		1.7185		1.989	.6602	.6602
16	.6706	1.9566	1.6871		1.9662	.7545	.6535
17	.9431	.9431		.8488	.8488	.7545	.7545
18	1.226	1.226			1.4146		1.0374
19	1.4918	1.6975					
20	1.3413	1.4146					1.226
21	1.2136	1.1317				1.226	1.1317
22	.9431	1.0374			1.0374	1.0374	.9431
23	.7545	.8488			1.2346	1.2041	1.1431
24	1.1431	.7545	.8488		.8488	1.2346	1.2041
Max	2.572	2.2119	1.8576	.8488	2.1195	2.6578	2.572
Min	.6602	.6602	.8488	.8488	.8488	.6602	.6535
Avg	1.2190	1.4283	1.2955	.8488	1.6401	1.3069	1.2984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 202 / Ganeshwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1677		1.7966	1.5604
2		.1715	.1677		1.7966	1.5604
3		.1734	.2629		1.7966	1.5604
4		.1791	.2629	.2572	1.7966	1.6004
5		.2772	.3696	.3582	1.8976	1.7747
6		.3696	.3696	.3696	2.0805	1.8747
7	1.6604	.3658	.3696	.3696	2.3205	2.0557
8	1.9766	.3696	.3696	.362	2.4806	2.372
9	.2715	2.2377		2.834	.2772	.2772
10	.2686	2.672		2.5692	.2686	.1848
11		2.5911		2.7664	.1715	.1791
12	.1638	2.672		2.9007	.1677	.16
13	.1562		2.6558	2.9007	.1619	.1467
14			2.6558	2.934	.1619	.1448
15				2.8178	.1619	.1429
16		2.7206		2.5911	.1524	.1238
17	.1638			.1581	.1638	.1562
18	.2572	.2515		.1619	.181	.1562
19	.2715	.2715		.2743	.2715	.2715
20	.2715	.2658		.1791	.2686	.2686
21	.2686	.2658		.2686	.2629	.1772
22	.1772	.1734		.2686	.2629	.1734
23	.1715	.1677		1.7966	1.5604	1.6556
24		.1715	.1677	.1638	1.7966	1.5604
Max	1.9766	2.7206	2.6558	2.934	2.4806	2.372
Min	.1562	.1677	.1677	.1581	.1524	.1238
Avg	.4676	.8269	.7108	1.3001	.9274	.8390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 203 / Wadapuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.3937	1.6556		.7621	.724
2	.8573	1.4118	1.6556		.7621	.724
3	.8573	1.448	1.6556		.7621	.724
4	1.0059	1.5623	1.7966	2.0062	.8592	.9831
5	1.2431	1.7814	2.0805	2.0805	1.0402	1.1603
6	1.5432	2.4034	2.652	2.3472	1.5089	1.4251
7	1.7004	3.1131	3.3532	3.2322		1.6956
8	1.6289	3.3979		3.2388	1.6956	1.6108
9	2.9959	1.2289		1.326	3.0664	3.2693
10	3.1131	.9012		.9326	3.2322	
11	3.1855	.8002		.7373	3.3532	3.0407
12	3.0045	.5868		.6401	3.476	3.1626
13	2.9683			.6401	3.1626	2.8597
14	2.8959		.7545	.5601	3.0836	2.7092
15	2.8959			.5401	2.8959	2.6339
16	2.8197	.6602		.5335	2.8197	2.5673
17	.7545			.6516	.5068	.5135
18	.8916	.9907		.9145	.8097	.9431
19	1.2955	1.2955		1.3108	1.0526	1.1203
20	1.326	1.1069		1.3108	1.0279	1.1069
21	1.0898	.9145		1.1336	.9145	.9259
22	.7621	.7526		.8488	.8278	.8278
23	1.448	1.6556		.7621	.724	.7335
24	.8573	1.3937	1.6556	1.6347	.7621	.724
Max	3.1855	3.3979	3.3532	3.2388	3.476	3.2693
Min	.7545	.5868	.7545	.5335	.5068	.5135
Avg	1.7499	1.4399	1.9177	1.3039	1.7002	1.5732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 204 / Bhandgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8747	1.7966			
2		1.8747	1.7966			
3		1.8976	1.7966			
4		1.989	1.9204	1.7966		
5		2.1795	2.13	1.9204		
6		2.5149	2.5149	2.3739		
7		2.8178		2.572		
8		3.0521		2.8178		
9	3.2322					
10	3.6046					
11	3.5608					
12	3.5637				3.8152	
13	3.4408					
14	3.4008					
15	3.3198					
16	3.2388			.3048		
17					.2829	.2829
19	.4858					
23	1.9766	1.7966				
24	.4715	1.8747	1.7966	1.6975		
Max	3.6046	3.0521	2.5149	2.8178	3.8152	.2829
Min	.4715	1.7966	1.7966	.3048	.2829	.2829
Avg	2.7541	2.1872	1.9645	1.9261	2.0491	.2829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 205 / Bhandgaon 2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1336	1.1203			
2		1.1469	1.1203			
3		1.1469	1.1203			
4		1.3413	1.2289	.9602		
5		1.5261	1.326	1.0059		
6		1.7147	1.6289	1.1869		
7		1.9719	1.9071			
8		2.0576	2.1672			
9	2.0576				1.8204	2.0348
10	2.2043				2.1672	2.2891
11	2.2291				2.1434	2.2891
12	2.1795				2.2043	2.1195
13	2.1548				2.0957	1.6956
14	2.0243				1.989	1.7804
15	1.8747				1.9062	1.7804
16	1.7528				1.9281	1.6804
23	1.1336	1.1203				
24		1.1336	1.1203	.8697		
Max	2.2291	2.0576	2.1672	1.1869	2.2043	2.2891
Min	1.1336	1.1203	1.1203	.8697	1.8204	1.6804
Avg	1.9567	1.4293	1.4155	1.0057	2.0318	1.9587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 206 / Ganeshwadi 2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0145	.3048	.3715		.6344	.4877
2	1.0145	.3086	.3048		.6344	.4877
3	1.0145	.3201	.3048		.6344	.4877
4	1.1431	.3239	.4049	.301	.6344	.5563
5	1.1431	.3277	.4049	.3048	.6344	.6344
6	1.2346	.4096	.4287	.3048	.743	.6944
7	1.2498	.4096	.4334	.3544	.8592	.7811
8	1.406	.3353		.4191	1.0155	.9031
9	.3315	1.4842		1.186	.3658	.3506
10	.2572	1.9662		1.3413	.3467	.2743
11		2.13		1.3108	.2629	.2515
12	.1715	2.13		1.2651	.1772	.1562
13	.1715		2.0309	1.2955	.1391	.12
14			2.0309	1.3413	.1391	.1296
15				1.326	.1429	.1334
16		2.1052		1.2193	.1448	.1829
17	.3277			.2372	.3315	.2201
18	.4096	.4049		.3429	.3315	.2858
19	.3239	.4049		.362	.3315	.3315
20	.3315	.3125		.3506	.2372	.3277
21	.3315	.3125		.3429	.3048	.3086
22	.3201	.3163		.3277	.3048	.3125
23	.3048	.3715		.6344	.4877	.5744
24	1.0145	.3048	.3715	.2972	.6344	.4877
Max	1.406	2.13	2.0309	1.3413	1.0155	.9031
Min	.1715	.3048	.3048	.2372	.1391	.12
Avg	.6758	.7491	.7086	.7078	.4363	.3950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 207 / Lakhewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5119	.2572	.2724	.1029	.1174	1.555	1.5468
2	1.5196	.2644	.2709	.1029	.1181	1.5436	1.5521
3	1.5142	.272	.2686	.109	.1219	1.5428	1.5552
4	1.5598	.2858	.3784	.1181	.3681	1.5375	1.5964
5	1.6858	.4946	.4012	.1463	.4321	1.6576	1.7726
6	1.8633	.6604	.6695	.202	.4843	1.7988	1.96
7	2.1165	.6873	.7177	.2629	.7076	2.0315	2.2241
8	2.3922	.602	.2583	.2622	.6264	2.3522	2.513
9	1.1677	1.8439	.458	.5159	1.9002	1.3245	1.3611
10	.3349	2.5408	1.0608	.9907	2.3981	.47	.4887
11	.1044	2.5618	1.0494	1.0189	2.6894	.3273	.4371
12	.1677	2.526	.8916	1.0402	2.6448	.293	.3144
13	.2164	.9717	2.2846	1.0021	2.6225	.1795	.2705
14	.1071	.98	2.2937	.9953	2.524	.2298	.2598
15	.1494	.9854	.9267	1.0265	2.5522	.2514	.2565
16	.2076	1.0242	.9701	1.0151	2.5359	.2556	.2469
17	.2839	1.0189	.9694	.929	1.1466	.2713	.2774
18	.3683	.3589	.1242	.1212	.3951	.2999	.3795
19	.5449	.5296	.1997	.189	.5555	.5373	.4275
20	.5853	.4559	.2065	.2058	.5731	.459	.446
21	.4643	.4243	.1661	.1738	.5502	.4176	.4454
22	.3052	.3973	.1364	.1456	.3189	.3094	.3094
23	.261	.2838	.1113	.1105	1.3071	1.2633	1.2892
24	.9853	.2758	.2541	.1135	.78	1.5916	1.4972
Max	2.3922	2.5618	2.2937	1.0402	2.6894	2.3522	2.513
Min	.1044	.2572	.1113	.1029	.1174	.1795	.2469
Avg	.8507	.8626	.6392	.4541	1.1862	.9375	.9761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214409 / 33 KV PIMPRI BK

Feeder No / Name : 201 / Narsingpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0762	.3277
2		.0762	
3		.0762	
4		.0762	.3277
5		.0762	
6		.0762	
7		.0762	.4096
8		.0762	.5735
9	.0819	1.065	.0819
10	.0762	1.4746	.0819
11	.0762		.0819
12	.0762		.0819
13	.081	1.7204	.0819
14	.081	1.8023	.0819
15	.0791	1.8023	.0819
16	.0819		.0819
17	.0819		.0819
18	.0819	.0819	.0819
19	.0819		.0819
20	.0762		.0819
21	.0762	.0819	.0819
22	.0762	.0819	.0819
23	.0762	.3163	1.065
24	.6554	.0762	.3277
Max	.6554	1.8023	1.065
Min	.0762	.0762	.0819
Avg	.1150	.5062	.2089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214409 / 33 KV PIMPRI BK

Feeder No / Name : 202 / Ozare -Pimpri Bk-

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3521	.7126	.4146	.996	.7811	3.3679	3.5002
2	3.3051	.7873	.4512	.9	.8101	3.3862	3.4895
3	3.3703	.9166	.5091	1.0859	.8909	3.4075	3.5322
4	3.4283	1.1267	.6371	1.1103	1.3057	3.5048	3.5719
5	3.5219	1.422	.8703	1.4693	1.6543	3.7089	3.6647
6	3.7586	1.7677	1.0852	1.6705	1.8637	3.9083	4.0771
7	4.1651	1.7951	1.0425	1.6735	1.8522	4.2982	4.6209
8	4.2292	1.7524	.9556	1.0075	1.7901	4.5462	4.6452
9	1.6048	5.0122	5.7187	5.4009	5.1429	1.6659	1.5383
10	1.0582	3.1901	5.7994	5.6852	5.4036	1.3336	1.4358
11	.816	3.3349	5.836	2.9645	5.4401	.5213	1.2712
12	.5756	3.344	5.5327	2.9706	5.495	.3749	1.0883
13	.4538	3.3105	5.5099	2.9096	5.5072	.5396	.8783
14	.4172	3.0986	5.3636	2.5301	5.554	.407	.7884
15	.4111	3.1139	5.5106	2.8319	5.0746	.4999	
16	.5908	5.6516	5.4633	2.8487	4.7047	.2606	.6432
17	.8117	.4557	.7784	.2256	.74	.4039	1.0502
18	1.3003	1.227	1.0189	1.3119	1.1024	1.1188	1.2818
19	1.5865	1.3903	1.4754	1.5119	1.343	.7072	1.3443
20	1.4523	1.2805	1.3748	1.4586	1.2973	.6417	1.2696
21	1.1007	.9531	.5563	1.2066	1.0688	1.0426	1.1904
22	.848	.8657	1.0928	.9549	.9196	.8946	1.0974
23	.6836	.8321	1.0182	.7224	3.2827	3.4819	3.3619
24	1.9136	.7263	.3704	.8924	2.2306	3.4334	3.5459
Max	4.2292	5.6516	5.836	5.6852	5.554	4.5462	4.6452
Min	.4111	.4557	.3704	.2256	.74	.2606	.6432
Avg	1.8648	2.0028	2.4327	1.9308	2.7189	1.9773	2.2994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214409 / 33 KV PIMPRI BK

Feeder No / Name : 203 / LIS -Shriram Lift-

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	1.7911	.5792	1.4522	.0943	.5647	
2	.0953	1.7911	.586	1.4568	.0953	.5655	
3	.0953	1.7934	.5952	1.4568	.0953	.564	.0857
4	.0953	1.7888	.5891	1.5364	.0953	.5754	
5	.0953	1.7926	.5891	1.5333	.0953	.5853	.0857
6	.0953	1.9048	.6219	1.5569	.0953	.6831	
7	.0953	2.0323	.6447	1.5501	.0953	.6876	
8	.426	2.0681	.6714	.602	.1675	.6792	.1924
9	2.7556	.0857		.0857	.7356	.0857	.8047
10	2.9083			.0953	.976	.0857	.9241
11	3.0091				.9851		1.0143
12	3.0037				.9775		1.0273
13	2.9862				.9691	.0857	1.0334
14	3.0456				.9882	.0857	1.0288
15	3.0091		.0819		.9981	.0857	1.0326
16	2.9885		.0819	.1661	.9745		1.0296
17	.0886		.0819	.5509	.0886	.1852	.0819
18	.0886	.0857	.0819	.5616	.0886	.2092	.0819
19	.0886	.0886	.0819	.583	.0886		.0819
20	.0886	.0886	.0819	.5487	.0886		.0082
21	.0886	.0886	.0819	.5471	.0886	.0857	.0819
22	.0886	.3197	.2564	.5487	.18	.0857	.0819
23	1.9231	1.595	1.4468	.0943	.564	.0857	.0819
24	.7835	1.8202	.5502	.9012	.3046	.3582	.0857
Max	3.0456	2.0681	1.4468	1.5569	.9981	.6876	1.0334
Min	.0886	.0857	.0819	.0857	.0886	.0857	.0082
Avg	1.1682	1.1959	.4280	.8330	.4137	.3338	.4655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214409 / 33 KV PIMPRI BK

Feeder No / Name : 204 / Girvi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	1.1469		.852	.8402	.3277	
2	.362	1.1469		.8684	.823	.3277	.4915
3	.4525	1.1469		.9012	.823	.3277	
4	.6335	1.1469		.9503	.823	.4915	
5	.724	1.1469		.9831	.905	.6554	.7373
6	.905	1.3108		.9831	1.086	.8192	
7	.8145	1.4746		.9831	1.3575	.8192	.8192
8	.8145	1.7204			1.5947	.8192	.8192
9	1.5565	.6706		.5935	.4915	1.3927	1.7204
10	1.6385			.4239	.3277	1.8023	2.3758
11					.2458		2.2119
12					.1638		2.2119
13					.1638	1.7204	2.0481
14					.1638	1.7204	1.8023
15			.3277		.1638	1.7204	1.6385
16			.2458		.1638		1.6385
17			.3277	.3429	.3277		.2458
18		.4915	.4096	.5144	.4096	.4096	.3277
19		.5735		.6201	.4915		.5243
20		.5735	.4915	.7087	.4915		.4096
21	1.2289	.4096	.4915	.6335	.4096	.3277	.4096
22	1.3108	.4096	.4915	.4525	.4096	.3277	.4096
23	1.3108	.7373	.8192	.7373	.3277	.3277	.4096
24	.362	1.2289		.8192	.8488	.3277	.3277
Max	1.6385	1.7204	.8192	.9831	1.5947	1.8023	2.3758
Min	.362	.4096	.2458	.3429	.1638	.3277	.2458
Avg	.8911	.9584	.4506	.7275	.5772	.8147	1.0789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON

Feeder No / Name : 201 / Bhat Nimgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8383	.6783	.5144	.5335		
2		.8383	.6783	.5144	.5335		
3		.8383		.5144	.5335		
4		.0838		.6001	.5335		
5		.8383		.6001	.5335		
6		.8383		.6001	.5335		
7		.9724		.6859	.5335		
8		.9724		.7716	.5935		
9						.5087	1.1401
10	.8383					.8383	1.2003
11	1.0059					1.0059	1.1145
12	1.0059					1.0059	1.0288
13	1.0059					.9389	1.1145
14	1.073					.9389	1.1145
15	1.0898					.9724	1.0288
16	1.1065						1.0288
23	.9054	.503		.4572			
24		.8383	.5087	.6001	.5335		
Max	1.1065	.9724	.6783	.7716	.5935	1.0059	1.2003
Min	.8383	.0838	.5087	.4572	.5335	.5087	1.0288
Avg	1.0038	.7561	.6218	.5858	.5402	.887	1.0963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON

Feeder No / Name : 202 / Babhulgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	.0838	.1696	.1715	.1524	1.3413	1.3413
2	1.829	.0838	.1696	.1715		1.3413	1.3413
3	1.829	.0838	.1696	.1715	.1524	1.3413	1.3413
4	1.829	.0838		.1715	.1524	1.3413	1.3413
5	1.9052	.0838		.1715	.1524	1.3413	1.3413
6	1.9814	.0838		.1715	.2286	1.4754	1.4754
7	1.9814	.0838		.1715	.3048	1.5261	1.4754
8	2.1338	.0838		.1715	.3391	1.5261	1.4251
9		2.0348		2.1434	1.6956	.1696	.0838
10		2.0348	2.572	1.9814	.0848	.1677	.1715
11		2.2043	2.7435	2.1338	1.6956	.0838	.1715
12		2.2043	2.6578		1.6956	.0838	.1715
13	.1006	2.2043	2.4006	2.1338	1.6956	.0838	.1715
14	.1006	2.2043	2.4006	1.9814	1.6956	.0838	.1715
15	.1006	2.2043	2.2291	1.9052	1.6956	.0838	.1715
16	.1006	2.2043	2.0576	1.9052	1.6956		.1715
17	.0838	.0848	.1715	.2286	.0848		.1715
18	.0838	.1696	.1715	.2286	.0848	.0838	.1715
19	.0838	.1696	.1715	.1524	.0848	.0838	.1715
20	.0838	.0848	.1715		.1696	.0838	.1715
21	.0838	.0848	.1715	.1524	.0848	.0838	.1715
22	.0838		.1715	.1524		.0838	.1715
23	.0838	.0848	.1715	.1524		1.0059	
24	1.829	.0838	.1696	.1715	.1524	1.3413	1.3413
Max	2.1338	2.2043	2.7435	2.1434	1.6956	1.5261	1.4754
Min	.0838	.0838	.1696	.1524	.0848	.0838	.0838
Avg	.9068	.8143	1.0522	.7634	.6713	.6708	.6407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON

Feeder No / Name : 203 / Rakhunde Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.9297	.924	1.1145	.8383	.0848	.1448
2	.2438	.9297	.924	1.2003	.8383	.0848	.16
3	.2743	.945	.0914	1.2155	.8383	1.5261	.1752
4	.2896	.9755	.1372	1.2669	.9145	.0848	.1752
5	.3658	1.0075	.1524	1.2669	1.0288	.0848	.1752
6	.3963	1.1431	.1524	1.2669	.9145	.0848	.1905
7	.3658	1.3108	.1372	1.3527	1.0669	.0848	.2057
8	.3658	1.4296	.1219	1.3222	1.1869	.0848	.2744
9	.1219	.1752	.1067	.2934	.0848	.0848	1.5851
10	1.6324	.1762	.2782	.2591	.0848	1.3748	1.5337
11	1.547	.1762	.2782	.2591	.0848	1.4419	1.5337
12	1.547	.1915	.2934	.2591	.0848	1.4754	1.4327
13	1.4282	.2067	.2934	.2743	.0848	1.4754	1.3717
14	1.4114	.1372	.3392	.3087	.0848	1.5089	1.4575
15	1.3108	.2067	.3392	.2896	.0848	1.5089	1.4575
16	1.1736	.0848	.1715	.1715	.0848		1.3717
17	.0838	.0848	.1715	.1524	.0848		.1715
18	.0838	.0848	.1715	.1524	.0848	.0838	.1715
19	.0838	.0848	.1715	.1524	.0848	.0838	.1715
20	.0838	.1	.1715	.1524	.0848	.0838	.1715
21	.2057	.2067	.2934	.2896	.0848	.0838	.1715
22	.1905	.1067	.2934	.2743		.0838	.1715
23	.7804	.6001	1.1355	.2438		.0838	
24	.2286	.9145	.8544	1.105	.8383	.0848	.0838
Max	1.6324	1.4296	1.1355	1.3527	1.1869	1.5261	1.5851
Min	.0838	.0848	.0914	.1524	.0848	.0838	.0838
Avg	.5961	.5087	.3335	.6101	.4349	.5262	.6242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214426 / 33/11KV KATI S/STN

Feeder No / Name : 201 / kati

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5344	1.2631	1.1012	1.1984	.4696	.4858	.4534
2	.4858	1.2955	1.1012	1.1984	.4696	.5668	.4534
3	.4858	1.4413	1.1336	1.2146	.4696	.664	.4858
4	.5668	1.5223	1.3603	1.2955	.5668	.7935	.5668
5	.8097	1.6194	1.4899	1.3603	.6802	.9069	.8097
6	.9717	1.7814	1.5223	1.668	.9393	.9717	1.1336
7	1.247	2.5587	2.2834	2.251	1.085	1.1498	1.1822
8	1.1174	2.9797		2.7368	1.1174	1.1336	1.166
9	2.1376	.8745		.7935	2.332	2.1538	2.332
10	2.4939	.6226		.6154	2.6235	2.8502	2.672
11	2.4615	.4588	.4372	.4858		2.7161	2.4615
12	2.672	.3605	.421	.4049	2.7206	2.649	2.4453
13	2.6397	.3605	.3239		2.5587	2.5987	2.4129
14	2.5425	.3441	.3239	.3401	2.4939		2.2186
15	2.4615		.3239	.3563	2.332	2.5484	
16	2.5263		.3725	.3563	2.1214	2.146	1.8623
17	.5506	.4424		.4534	.421	.4534	.4696
18		.7865	.7449	.6154	.7287	.7449	.6154
19	1.085	1.0322	.9393	.8421	.9555	.9069	.7449
20	.9231	.8097	.8583	.7287	.8259		.6802
21	.664	.6478	.6478	.6316	.6964	.664	.2915
22	.5992	.5344	.6478	.4858	.5992	.5344	.5182
23	1.247	1.0364	1.166	.4696	.4534	.4534	.4696
24	.5344	1.247	1.1336	1.1984	.4696	.4372	.4534
Max	2.672	2.9797	2.2834	2.7368	2.7206	2.8502	2.672
Min	.4858	.3441	.3239	.3401	.421	.4372	.2915
Avg	1.3807	1.0918	.9166	.9435	1.2230	1.2968	1.1695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214426 / 33/11KV KATI S/STN

Feeder No / Name : 202 / Reda

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9221	.2622	.2458	.2429	.8097	.9831	.9221
2	.9221	.3277	.2622	.2429	.8097	1.0486	.9221
3	.9221	.426	.2949	.3239	.8421	1.1305	.9892
4	1.0059	.4915	.4588	.3887	.8907	1.2125	1.0898
5	1.2742	.5571	.4915	.4696	.9878	1.3599	1.3245
6	1.5089	.6062	.6062	.583	1.1984	1.4582	1.5424
7	2.079	.6718		.7611	1.6194	1.8351	1.9448
8	2.2801	.6718		.7125	2.0405	2.1956	2.0424
9	.6062	.9831		1.7436	.5571	.6062	
10	.3932	2.1628		1.9616	.3441	.4858	.5668
11	.2949	2.1125	1.8138	1.7436		.3725	.4696
12	.2294	2.0287	1.3765	1.6263	.213	.2753	.3725
13	.1638		1.6032		.1966	.2105	.3077
14	.1966		1.587	1.5257	.1638		.2105
15	.2458		1.4723	1.4922	.1638	.1781	.1619
16	.2785		1.411	1.4413	.2294	.2267	.1781
17	.2622		.1943	.2267	.1966	.2429	.2267
18	.4752	.4359	.421	.3887	.4096	.4696	.4372
19	.639	.5868	.5668	.6154	.6062	.583	.583
20	.5243	.4915	.4858	.4858	.5243		.4858
21	.426	.4096	.3563	.4372	.4588	.421	.3725
22	.3113	.2949	.3077	.2915	.3441	.3077	.3239
23	.2785	.2458	.2591	.8097	.9667	.8718	.8907
24	.9054	.2622	.2294	.2429	.8097	.9831	.9221
Max	2.2801	2.1628	1.8138	1.9616	2.0405	2.1956	2.0424
Min	.1638	.2458	.1943	.2267	.1638	.1781	.1619
Avg	.7144	.7383	.7222	.8155	.6688	.7935	.7516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214426 / 33/11KV KATI S/STN

Feeder No / Name : 203 / Shetphal Haveli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3261	1.1431	1.7475	.3963	.6477	.7347	.8078
2	1.2041	1.3488	1.6206	.3963	.7011	1.0107	.8688
3	.9707	1.699	1.3641	.4496	.8002	.9397	.9145
4	1.3403	3.2327	1.8061	.5716	1.0227	1.2498	1.1583
5	1.6385	3.0759	2.1201	.8307	1.3664	1.4952	1.5298
6	1.6632	2.6886	2.1159	.8154	1.4632	1.531	1.643
7	1.4636	2.8395	.5792	.5944	1.2262	1.3439	1.3779
8	2.5606	3.0301	.4039	.3963	2.4752	2.771	2.5492
9	3.504	1.574	.3582	.3658	3.6113	3.3284	3.456
10	3.8862	1.4106	.3429	.3353	3.7559	3.6115	3.3715
11	3.8405	1.2452	.3201	.3201	2.0729	3.5328	3.3837
12	3.9695	1.2069	.3125	.3582	3.9371	3.6951	1.7375
13	3.9163	.3277	.3201	.3429	3.9447	3.5808	3.3531
14	3.8563	.4725	.4115	.4725	3.8695	1.9509	3.5056
15	3.7398	.6325	.6097	.6173	3.7258	3.5254	3.4294
16	2.899	2.2329	2.2405	2.2253	2.9987	2.889	3.0483
17	1.3077	2.2253	2.4006	2.3243	1.1111	1.1983	1.3077
18	1.5562	2.2603	1.7833	1.7528	1.299	1.424	1.4883
19	1.6832	2.0294	1.3717	1.3641	1.3641	1.4965	1.6156
20	1.3401	1.8034	1.1812	1.1507	1.2458	.5563	1.3001
21	1.0516	1.5641	1.0822	1.0059	.9137	.9879	1.0593
22	.8524	1.4129	1.044	1.2613	.7697	.844	.9126
23	1.1913	1.7756	1.7238	1.2535	.6741	.7518	.7834
24	.823	1.6842	1.8465	.945	.6935	.5975	.8108
Max	3.9695	3.2327	2.4006	2.3243	3.9447	3.6951	3.5056
Min	.823	.3277	.3125	.3201	.6477	.5563	.7834
Avg	2.1493	1.7881	1.2128	.8561	1.9037	1.8769	1.8922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214426 / 33/11KV KATI S/STN

Feeder No / Name : 204 / 11 kv Pandharwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7255	1.6023	.4586	.4496	.8993	1.0059	.9983
2	.794	1.7589	.5159	.2667	.6554	.7859	.7392
3	.8703	1.6247	.6477	.3506	.724	.9593	.8421
4	1.0059	.8459	.7872	.3963	.8897	1.1264	.9297
5	1.1691	.9824	.9586	.4039	.9918	1.1915	1.0154
6	1.1446	.9869	.9305	.3429	.9831	1.2305	1.1394
7	1.3939	.8893	.3048	.2439	1.3188	1.3469	1.3603
8	1.6461	.7202	1.1126	1.1965	1.2391	1.2917	1.5146
9	.5602	1.3077	1.0974	1.1812	.5533	.517	.5094
10	.4626	1.6356	1.1888	1.1355	.4154	.4938	.4534
11	.3852	1.3931	2.2939	1.2117	.1981	.4972	.5179
12	.314	1.3584	1.2879	1.2574	.4435	.5401	.5611
13	.4298	1.4175	1.2346	1.3717	.4115	.535	.5011
14	.4582	1.5394	1.2803	1.2803	.4329	.5129	.4934
15	.5396	1.326	1.2117	1.044	.5761	.5487	.5696
16	1.7059	.4801	.5182	.5182	1.4923	1.4022	1.6949
17	1.6242	.5716	.5716	.5563	1.4384	1.5775	1.5796
18	1.432	.8882	.5258	.5487	1.3005	1.3603	1.2656
19	1.2984	.8001	.4039	.3963	1.1555	1.1747	1.3718
20	1.0547	.6741	.3125	.2896	.9345	.6478	.8737
21	.9465	.6249	.2667	.2362	.8124	.8566	.7864
22	.8634	.5039	.2362	.4041	.7559	.7553	.7762
23	.7977	.4397	.4229	.5487	.8901	1.0144	.9757
24	1.0534	.4014	.4814	.2058	.8078	1.028	.9861
Max	1.7059	1.7589	2.2939	1.3717	1.4923	1.5775	1.6949
Min	.314	.4014	.2362	.2058	.1981	.4938	.4534
Avg	.9448	1.0322	.7937	.6598	.8466	.9333	.9356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN

Feeder No / Name : 205 / Chandgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8442	3.6427	3.3989	3.2731	2.3738	1.0441	.8744
2	1.6994	3.4446	3.2312	3.1969	2.3776	1.9967	1.225
3	1.0669	3.0692	2.7073	2.7549	2.4996	2.1205	1.3946
4	1.1888	3.2294	2.8445	2.9473	2.5872	2.0766	1.5166
5	1.5241	3.3074	2.9568	3.2579	2.8578	2.2158	1.7318
6	1.8138	3.3913	3.1017	3.6942	3.0674	2.0728	2.1585
7	1.7337	4.0085	3.4141	3.0864	3.3493	1.5946	2.4367
8	2.0919	4.1534	3.6075	3.5342	3.5246	1.286	2.2825
9	3.033	1.5184	.442	1.6995	1.73	2.7378	1.0898
10	3.3532	1.3813	.442	1.488	1.5889	3.0026	3.9476
11	3.4751	1.2704	.4496	1.3527	.5411	2.6749	4.0878
12	3.4172	1.2864	1.065	1.3145	1.3298	2.6978	3.9399
13	3.3455	.4877	1.1107	1.326	1.0554	2.6216	4.2524
14	3.5065	1.2117	1.1717	1.3565	1.0993	2.5378	3.9445
15	3.1931	1.3108	.6783	1.486	1.4784	2.5454	3.7799
16	2.8959	2.7987	2.3282	2.6044	2.4101	.7392	2.4082
17	.6401	2.9568	1.9052	1.7071	2.4577	.8154	2.6444
18	1.4041	2.873	2.4863	1.6385	2.3987	2.6939	2.191
19	1.5851	2.7054	2.3891	2.7397	2.2786	2.7282	2.3948
20	1.4556	2.479	2.2996	2.492	2.1414	2.6368	2.2558
21	1.2937	2.3129	2.231	2.2176	2.0176	2.5911	1.8995
22	1.1545	2.1597	1.9205	2.0081	1.8937	2.8731	1.5958
23	2.6826	3.477	3.2922	3.1245	1.7775	1.0936	.8596
24	.7392	3.8276	3.4782	3.2693	2.9835	1.0974	.9507
Max	3.5065	4.1534	3.6075	3.6942	3.5246	3.0026	4.2524
Min	.6401	.4877	.442	1.3145	.5411	.7392	.8596
Avg	2.0891	2.5960	2.2063	2.3987	2.1591	2.1039	2.3276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S

Feeder No / Name : 201 / kalthan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3563	.2452	.2075	.2263	.2515	.4191	.3768
2	.3768	.2829	.2075	.2641	.2218	.4191	.3768
3	.3725	.2829	.2614	.3206	.2229	.4191	.4096
4	.3932	.3395	.3174	.3395	.2587	.4694	.4424
5	.3978	.3772	.4108	.3584	.2641	.4694	.4807
6	.431	.5281	.5041	.3361	.3361	.503	.5079
7		.3395	.5175	.3361	.3547	.5868	.6226
8	.4973	.2829	.4435	.2829	.2561	.6706	.7045
9	.2926	.5868		.8097	.8192	.3395	.3174
10	.2263	.7773		.9724	.8383	.2427	.2452
11	.1698	.8907	.8745	.8848	.8886	.1867	.1886
12	.1509	.8745	.9393	.8288	.8383	.1509	
13	.1509	.8745	.9231	.8383	.8383	.1132	.1132
14	.1509	.8421	.9069	.8288	.788	.1132	.1132
15	.1509	.8421	.8745	.779	.788	.132	.1132
16	.1509	.8259	.8583	.7712	.7712	.1132	.132
17	.2263	.1494		.1174	.1132	.168	.1698
18	.3018	.1867	.4108	.2743	.2641	.2801	.2263
19	.3772	.3881	.3921	.362	.3961	.3734	.3772
20	.3961	.4108	.3921	.362	.3772	.3734	.3961
21	.3395	.3734	.3395	.2957	.3395	.3361	.2829
22	.2641	.2987	.2641	.2561	.2641	.2801	.2829
23	.2452	.2241	.2263	.2452	.4191	.3563	.4252
24	.3563	.2452	.2054	.2075	.2075	.4191	.3768
Max	.4973	.8907	.9393	.9724	.8886	.6706	.7045
Min	.1509	.1494	.2054	.1174	.1132	.1132	.1132
Avg	.2945	.4779	.4989	.4707	.4632	.3306	.3340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S

Feeder No / Name : 202 / kalashi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9479	.5006	.5026	.4927	1.4784	2.1658	1.8288
2	.9936	.5997	.594	.6752	1.3489	2.0851	1.8288
3	1.0486	.6828	.6691	.7133	.7514	1.6126	1.303
4	1.1103	.8344	.8345	.7891	.8772	1.7071	1.3413
5	1.2031	1.0086	.996	.8833	.9934	1.8381	1.4525
6	1.2681	1.0387	.8082	.9377	.9488	1.8183	1.4658
7	.4115	.9694	.6024	.8496	.7769	1.829	1.5805
8	1.4418	2.1056	2.2365	2.2843	2.0835	1.8274	1.611
9	.7468	2.6353	1.6994	3.1901	3.0552	.9694	.6592
10	.7278	2.8492	1.6461	3.4599	3.1733	.7712	.5613
11	.7278	2.8806	3.163	3.5121	3.1291	.7506	.5881
12	.7278	2.9368	3.2937	***	3.1337	.7354	.3658
13	.7582	2.9368	3.1907	3.5467	3.1535	.7053	.6512
14	.743	2.9149	3.1361	3.4979	3.1839	.7209	.5797
15	.7887	2.7759	3.0606	3.4126	3.1839	.9038	.6447
16	1.5737	2.3853	2.894	3.1337	2.9096	1.9928	1.7686
17	1.5737	.833	.8048	.8703	.9716	1.9797	1.848
18	1.406	.9713	.5639	.9511	1.0166	1.9265	1.7193
19	1.3631	1.0387	1.0079	.9312	1.0311	1.9035	1.6535
20	1.1774	.8368	.935	.8353	.9091	1.8197	1.5813
21	1.2083	.7158	.7842	.7385	.7652	1.7581	1.5244
22	1.1401	.6516	.6562	.6554	.6439	1.6903	1.5468
23	1.0951	.5308	.5348	.5873	1.2498	2.0929	1.9079
24	1.5733	.4778	.5384	.4967	.508	2.2847	2.0129
Max	1.5737	2.9368	3.2937	20.0999	3.1839	2.2847	2.0129
Min	.4115	.4778	.5026	.4927	.508	.7053	.3658
Avg	1.0732	1.5046	1.4647	2.3977	1.7198	1.5787	1.3344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S

Feeder No / Name : 203 / karewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.9556	.9282	.8421	.8916	.415	.4108
2	.4252	.9724	.9282	.8583	.8478	.415	.4108
3	1.1919	.9724	.9282	.8745	.9425	.4338	.4251
4	.4887	1.0059	.9614	.8745	.8648	.4715	.462
5	.5611	1.0059	1.004	.9231	.8718	.4904	.5228
6	.5914	1.0898	1.085	.9922	1.1041	.4904	.5788
7		1.2574	1.2955	1.1385	1.3352	.5281	.6535
8	.3696	1.3916	1.3603	1.4548	1.2763	.547	.5544
9	1.442	.3772		.3734	.3881	1.3077	1.6712
10	1.5089	.3292		.4527	.2829	1.6356	1.8185
11	1.576	.2195		.2427	.2452	1.7004	1.8027
12	1.5927	.2012		.1663	.2263	1.7004	
13	1.5089	.168		.2054	.2263	1.7204	1.5497
14	1.5089	.168		.2054	.2263	1.6876	1.5223
15	1.4083	.168	.2452	.1663	.2075	1.5384	1.4737
16	1.3748	.168	.2829	.1867	.2641	1.4746	1.4575
17	.2829	.2614		.1848	.2452	.2801	
18	.3961	.3734	.4294	.3292		.3174	.3018
19	.4715	.3921	.3921	.4066	.4715	.3881	.415
20	.3961	.4108	.3734	.362	.4715	.3547	.3772
21	.415	.3921	.3961	.3921	.415	.3921	.415
22	.415	.3921	.3734	.4024	.415	.4294	.3961
23	.9556	.8951	.8097	.7935	.3772	.3921	.3772
24	.3696	.9556	.9282	.8421	.8029	.415	.4108
Max	1.5927	1.3916	1.3603	1.4548	1.3352	1.7204	1.8185
Min	.2829	.168	.2452	.1663	.2075	.2801	.3018
Avg	.8537	.6051	.7483	.5696	.5826	.8136	.8185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S

Feeder No / Name : 204 / 11Kv Gangawalan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8459	1.3763	1.1934	1.0974	.7179	.3639	.3679
2	.7665	1.3001	1.1858	1.0517	.8341	.3715	.3984
3	.5123	.8657	.9496	.8017	.8763	.4702	.4423
4	.6249	.9877	1.0517	.9598	.8907	.5914	.5552
5	.7926	1.166	1.1454	1.0768	2.1376	.6824	.6832
6	.9877	1.1583	1.0826	1.19	1.3127	.7579	.7648
7	.442	1.4022	1.0612	1.1957	1.2887	.7872	.793
8	1.7803	1.4754	1.4279	1.3572	1.2254	1.8998	1.8054
9	2.6978	.8109	.3277	.7655	.6363	2.4676	2.4993
10	2.841	.6687	.3353	.6977	.6287	2.689	2.6414
11	2.9996	.6417	.6788	.6169	.6363	2.7533	2.625
12	2.9675	.6904	.7053	.7125	.6138	2.7324	1.2803
13	3.0103	.6714	.6562	.6867	.6147	2.7915	2.6718
14	2.9736	.631	.6559	.6615	.607	2.748	2.8109
15	2.8684	.7779	.7626	.7255	.6604	2.6216	2.6901
16	2.5423	1.651	1.5135	1.547	1.3539	2.1612	2.4196
17	.5106	1.6281	1.5857	1.5013	1.3611	.788	.7293
18	.9633	1.432	.9983	1.3641	1.2688	.7949	.8385
19	.9132	1.3805	1.3245	1.2643	1.1614	.743	.7735
20	.682	1.136	1.1694	1.0079	.9572	.57	.6407
21	.538	.9539	1.0598	.9042	.8283	.4397	.5344
22	.4397	.901	.9692	.7914	.8207	.3791	.4397
23	.7651	1.3641	1.2289	1.0273	.7754	.3414	.398
24	.3932	1.2742	1.3687	1.1033	1.1088	.3715	.3509
Max	3.0103	1.651	1.5857	1.547	2.1376	2.7915	2.8109
Min	.3932	.631	.3277	.6169	.607	.3414	.3509
Avg	1.4524	1.0977	1.0182	1.0045	.9715	1.3049	1.2564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 201 / Sarati

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.7811	.945	.8573	.8215	.16	.0953
2	.1143	.7907	.945	.9145	.7613	.16	.0953
3	.1372	.8642	.9755	.9145	.7819	.16	.0953
4	.16	.9374	1.0059	.9145	.945	.16	.0953
5	.2766	1.0753	1.0669	1.0059	1.0059	.1867	.16
6	.285	1.1584	1.1279	1.1584	1.1736	.2743	.2401
7	.282	1.3748	1.2803	1.4575	1.3283	.3353	.3227
8	.282	1.5043		1.2811	1.4899	.3048	.3227
9	1.4723	.2397		.2267	.2675	1.4091	1.6385
10	1.6842	.1783	.1303	.1189	.1334	1.704	1.8399
11	1.749	.1372	.1048	.1115	.1334	1.8947	2.1548
12	1.9433	.1372	.0953	.0943	.1067	2.0957	1.9271
13		.1143	.0953	.0943	.1067	1.9559	1.8461
14	1.8027	.1105	.0859	.0943	.1334	1.989	1.7924
15	1.7284	.1257	.0819	.096	.1334	1.989	1.7604
16	1.6129	.1048	.109	.0916	.1334	1.8027	1.692
17	.08	.1067	.2572	.1147	.1486	.0842	
18		.1334	.1715	.1951	.1829	.1143	
19	.2195	.1829	.2353	.2235	.2401	.1524	.1646
20	.1677	.1715	.2229	.1943	.2134	.1143	.1829
21	.1257	.1715	.2229	.1115	.1867	.0953	.16
22	.1943	.1707	.1981	.1139	.16	.1067	.16
23	.7529	.8688	.8383	.8036	.1143	.1143	.0914
24	.1372	.7727	.945	.8288	.8109	.1143	.0953
Max	1.9433	1.5043	1.2803	1.4575	1.4899	2.0957	2.1548
Min	.08	.1048	.0819	.0916	.1067	.0842	.0914
Avg	.6964	.5088	.5064	.5007	.4797	.7282	.7696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 202 / Boratwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7042	.3887	.3521	.3563	.4858	.6478	.6478
2	.7042	.3887	.3521	.3563	.4534	.6478	.6478
3	.7042	.3887	.3521	.3563	.4534	.6478	.6478
4	.7042	.3887	.3521	.3563	.4534	.7287	.7287
5	.7362	.421	.3841	.3563	.4534	.8097	.8097
6	.8002	.421	.3841	.3887	.5182	.8745	.9393
7	.8962	.3887	.3887	.421	.4534	.9393	1.0526
8	1.0242	.3563		.4049	.4534	.9717	1.2955
9	.2881	.9393		.9717	.9717	.3563	.421
10	.2591	1.2308		1.1012	1.004	.2881	.3201
11	.1619	1.1984	1.3123	1.1012	1.0364	.2241	.2881
12	.1619	1.166	1.2803	1.1336	1.0688	.192	.192
13	.1619	1.0688	1.2003	1.1012	1.0364	.192	.192
14	.1619	1.1203	1.1203	1.1012	1.004	.128	.16
15	.1619		1.1523	1.0688	.9717		.128
16	.1619	1.0883	1.0883	1.0364	.8962	.192	.16
17	.2267	.192	.16	.2267	.192	.192	
18		.2881	.2915	.3563	.3563	.2561	.2881
19	.4534	.4161	.4049	.421	.3887	.3841	.3201
20	.4858	.3841	.4049	.421	.3887	.3841	.3521
21	.4534	.4161	.3239	.421	.421	.3201	.3086
22	.4534	.4161	.3239	.421	.4049	.4161	.2778
23	.421	.3201	.3239	.4858	.583	.6478	.4858
24	.7362	.421	.3521	.3563	.4534	.6478	.2241
Max	1.0242	1.2308	1.3123	1.1336	1.0688	.9717	1.2955
Min	.1619	.192	.16	.2267	.192	.128	.128
Avg	.4792	.6003	.5859	.6134	.6209	.4821	.4733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 203 / 11 kV Nirnimgaon Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1898	.6325	.7907	.8223	.7274	.2372	.2214
2	.1898	.6009	.7907	.8223	.7274	.2372	.2214
3	.1898	.6642	.7907	.8539	.759	.2372	.2214
4	.2214	.8539	.8539	.8855	.8223	.253	.2846
5	.1581	.8855	.9488	1.012	.9172	.2846	.3163
6	.3795	.9804	1.0753	1.1385	1.0437	.3479	.3795
7	.4111	1.3599	1.4232	1.4864	1.2651	.3953	.4111
8	.4111	1.4864		1.7394	1.4864	.3795	.4111
9	1.4232	.3479		.3163	.3163	1.4232	1.5813
10	1.7394	.1265		.2214	.1581	1.7078	1.866
11	1.866	.0949		.0949	.1581	1.7711	1.8343
12	1.9608	.0633	.0949	.0949	.1265	1.6129	1.5813
13	1.9608	.0633	.064	.0949	.0633	1.8027	1.6446
14	1.9608	.0633	.064	.0949	.0633	1.8343	1.5181
15	1.7394	.0633	.096	.1265	.0633	1.7078	1.5181
16	1.6762	.0949	.128	.1265		1.6129	1.3916
17	.2214		.16	.1898		.1265	.1581
18			.2561	.3479	.2846	.1581	.2214
19	.2214		.3841	.4111	.3163	.3795	.3479
20	.3479	.3163	.3201	.3795	.3163	.3163	.3163
21	.3163	.253	.2401	.2846	.2846	.3163	.253
22	.253	.2214	.2401	.253	.253	.253	.2214
23	.6325	.7907	.7907	.759	.2214	.2214	.2214
24	.1898	.6325	.7907	.8223	.759	.2372	.2214
Max	1.9608	1.4864	1.4232	1.7394	1.4864	1.8343	1.866
Min	.1581	.0633	.064	.0949	.0633	.1265	.1581
Avg	.8113	.5045	.5151	.5574	.5060	.7439	.7235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 204 / 11 kV Gondi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5775	.5658	.6036	.6602	.5658	1.7147	1.5384
2	1.5775	.5281	.6036	.6602	.5658	1.7147	1.5384
3	1.5775	.6036	.6413	.6602	.6036	1.8004	1.5384
4	1.6118	.7167	.679	.6602	.7167	1.8861	1.5384
5	1.6804	.7545	.7545	.7545	.7167	1.9719	1.8004
6	1.7833	.9431	.8299	.8488	.8676	2.1434	2.0576
7	2.0576	1.094	1.0562	1.0374	1.0562	2.2634	2.2539
8	2.3663	1.1694		1.1317	1.1883	2.4006	2.7046
9	1.0082	2.2131		2.5206	2.7915	1.1317	1.0082
10	.7922	2.6353	2.6749		2.5034	.9431	.8488
11	.5658	2.9729	2.8995		2.4691	.6908	.6722
12	.4904	3.1367	2.8807	2.5819	2.4348	.5975	.5658
13		2.5526	2.7435	2.5484	2.572	.5601	.4527
14	.4527	2.6113	2.5149	2.5149	2.7949	.4668	.4904
15	.4527	2.4926	2.3807	2.4813	2.572	.3734	.3395
16	.4904	2.5095	2.4646	2.431	2.332	.4715	.3772
17	.6036	.6413	.679	.6036	.6602		
18		.9054	.8488	.7922	.9431	.7167	.7167
19	1.094	.9808	.9054	.9431	1.0562	.9997	.9431
20	.9054	.9054	.8488	.9054	.9431	.9431	.9054
21	.7167	.679	.7545	.7545	.7922	.7545	.8488
22	.679	.6413	.6602	.7167	.7545	.7167	.8488
23	.5658	.6036	.5658	.6602	1.8861	1.4575	1.5384
24	1.5432	.5658	.6036	.6036	.6036	1.7147	1.5384
Max	2.3663	3.1367	2.8995	2.5819	2.7949	2.4006	2.7046
Min	.4527	.5281	.5658	.6036	.5658	.3734	.3395
Avg	1.1178	1.3926	1.3451	1.2487	1.4329	1.2362	1.1767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 205 / 11 kV Sarati AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1132	.1132	.132	.112	.1029	.1509
2	.1052	.0943	.1132	.132	.0934	.1715	.1509
3	.1402	.1509	.132	.132	.112	.1372	.1509
4	.1753	.1698	.1698	.1509	.1867	.1715	.1509
5	.2058	.2263	.2075	.1886	.2614	.2229	.1448
6	.2572	.2641	.2641	.2641	.2829	.2401	.181
7	.2572	.1886	.2641	.2641	.2641	.2572	.1928
8	.2401	.1886		.2452	.2641	.2401	.1886
9	.2054	.132		.1886	.1715	.2263	.1448
10	.1698	.1214	.1372	.104	.1029	.2054	.1867
11	.1132	.1227	.0867	.0867	.0857	.1494	.0905
12	.0943	.1063	.0686	.0693	.0686	.112	.1063
13	.0943	.0867	.0514	.0693	.0686	.0934	.0895
14	.0754	.052	.0343	.0693	.0678	.0924	.0895
15	.0943	.0716	.0514	.0693	.0686	.1109	.0732
16	.1132	.0739	.0724	.0693	.0701	.1463	.1097
17	.132	.0716	.0905	.104	.0934	.1663	.0914
18		.1612	.1791	.156	.1509	.1867	.0895
19	.2641	.2149	.197	.1907	.1886	.1886	.1791
20	.2075	.1791	.1753	.1734	.1886	.1886	.1791
21	.1886	.1612	.1715	.1387	.1698	.1886	.1886
22	.1886	.1433	.1372	.1387	.1698	.1886	.1509
23	.1132	.168	.1307	.1494	.1509	.1886	.1067
24	.1052	.1132	.132	.1307	.112	.1029	.1886
Max	.2641	.2641	.2641	.2641	.2829	.2572	.1928
Min	.0754	.052	.0343	.0693	.0678	.0924	.0732
Avg	.1585	.1406	.1354	.1423	.1460	.1699	.1406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 206 / 11 kV Bhagatwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0625	.535	.5937	.5312	.5944	.0625	.08
2	.0625	.535	.5937	.5312	.5647	.0625	.08
3	.0625	.5944	.5937	.5312	.5944	.0781	.08
4	.0937	.7133	.6562	.5624	.6241	.0937	.08
5	.1562	.7727	.7186	.6249	.6241	.1562	.1334
6	.25	.8916	.8124	.6874	.7133	.2187	.2134
7	.2187	.9511	.9686	.8124	.8322	.2812	.2667
8	.2187	1.0105		.9374	.9511	.2343	.1867
9	.9998	.1886		.1562	.1886	.9259	.8002
10	1.1561	.0377	.0625	.0943	.0754	1.0185	.9877
11	1.1561	.0328	.0625	.0754	.0754	1.0494	1.0494
12	1.1439	.0312	.0312		.0377	.8951	.9877
13	1.1138	.0312	.0312		.0377	.9568	.9877
14	1.0974	.0312	.0312	.0566	.0377	.8951	.9686
15	1.1248	.0312	.0312	.0566	.0312	.9568	.8749
16	1.0623	.0312	.0312	.0566	.0617	.9568	.8436
17	.1132	.0625	.0312	.0754	.0617	.0617	.0625
18		.125	.1562	.2263	.0937	.0926	.0926
19	.2641	.1875	.1875	.2263	.1562	.1852	.1852
20	.2263	.1562	.1562	.2263	.1562	.1852	.1543
21	.1509	.125	.1562	.1509	.1562	.1543	.1543
22	.1132	.0937	.125	.1509	.0937	.0926	.1235
23	.5647	.5693	.5312	.602	.0625	.0926	.0533
24	.0625	.4904	.5693	.5312	.602	.0625	.0926
Max	1.1561	1.0105	.9686	.9374	.9511	1.0494	1.0494
Min	.0625	.0312	.0312	.0566	.0312	.0617	.0533
Avg	.4989	.3428	.3241	.3592	.3094	.4070	.3974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 201 / Palasdeo

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.1715	.1067	.1219	.1543	.823	
2	.5658	.1715	.1067	.1219	.1543	.823	
3	.5658	.1886	.1372	.1219	.1715	.8059	
4	.6001	.1886	.1524	.1524	.1715	.8573	
5	.7373	.2572	.2915	.2439	.3086	.8383	
6	.8059	.3429	.3258	.2743	.3944	.9755	
7	.8916	.4115	.4115	.3353	.4287	1.1431	
8	.9602	.3601			.4115	1.0822	
9	.2401	1.0212		1.2193	1.1126	.3086	.3048
10	.2058	1.3108		1.2498	1.2803	.2134	.2134
11	.1715	1.4632	1.3108	1.3717	1.2651	.1524	.1829
12	.1715	1.4632	1.2803	1.4022	1.2498	.1219	.1524
13		1.3717	1.2193	1.326	1.2041	.1219	.1524
14	.12	1.2498	1.1888	1.2955	1.3108	.0686	.1067
15	.1543	1.2651	1.1584	1.1736	1.2498	.0762	.0914
16	.1886	1.1584	1.1279	1.1888	1.1584	.1219	.1219
17	.1372	.1981		.1886	.2401	.2134	.1829
18	.2743	.2134	.2286	.2401	.2915	.2439	.1829
19	.3086	.3086	.2591	.3086	.2915	.2743	.2134
20	.2915	.2591	.2743	.2572	.2915	.2743	.2134
21	.2743	.2439	.2134	.2229	.2915	.2439	.1981
22	.2401	.2134		.2058	.2572	.2286	.1829
23	.1543	.1067	.1524	.1372	.8402	.7316	.5792
24	.583	.1543	.1067	.1524	.1372	.823	
Max	.9602	1.4632	1.3108	1.4022	1.3108	1.1431	.5792
Min	.12	.1067	.1067	.1219	.1372	.0686	.0914
Avg	.4011	.5872	.5290	.5788	.6111	.4819	.2052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 202 / Rui

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.4801	.5144	.4458	.5316	.4801	
2	.6859	.4973	.5144	.3429	.5316	.4801	
3	.6859	.4973	.5144	.3086	.5487	.4801	
4	.703	.5144	.5144	.2915	.5487	.5487	
5	.8059	.703	.8745	.3429	.8059	.7545	
6	.9755	.8916	.9088	.6516	.9602	.9145	
7	1.4403	.9431	1.0117		1.046	1.2803	
8	1.6461	.823	.8573		.9602	1.9204	
9	.6859	1.5546		1.5089	1.1431	.6859	.6859
10	.5487	1.7833		1.4632	1.4175	.6173	.6173
11	.4458	1.7833	1.9204	1.4632	1.2955	.583	.5144
12	.3258	1.7528	1.7833	1.4937	1.2193	.4458	
13		1.7528	1.6118	1.4327	1.2498	.3086	.2915
14	.2915	1.448	1.5432	1.3413	1.1584	.2743	.2743
15	.3086	1.6309	1.4403	1.2346	1.0974	.3086	.2401
16	.3086	1.326	1.3717	1.1431	1.0059	.3429	.3086
17	.4115	.3086		.3086	.4115	.4801	.4115
18	.6859	.5487	.5144	.5487	.5487	.6173	.5658
19	.9431	.8402	.8916	.8573	.9431	.7202	.6859
20	.7545	.6859	.9602	.7888	.7545	.7545	.6859
21	.6516	.5487	.7888	.6001	.6859	.6516	.583
22	.5316	.5316	.5487	.5487	.5144	.5487	.5144
23	.463	.463	.4801	.5144	.4801	.6859	.6687
24	.6859	.4801	.463	.4801	.5144	.4801	
Max	1.6461	1.7833	1.9204	1.5089	1.4175	1.9204	.6859
Min	.2915	.3086	.463	.2915	.4115	.2743	.2401
Avg	.6813	.9495	.9537	.8232	.8489	.6401	.5034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 203 / Nhavi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7621	.9145	.823	.9088	.6516	
2	.6516	.7621	.9145	.7926	.9259	.6344	
3	.6344	.7773	.9145		.9259	.6344	
4	.6344	.7926	1.0669	.9755	.9431	.6687	
5	.7545	.9602	1.1431	1.1279	.945	.9259	
6	1.046	1.0364	1.1584	1.3108	1.0059	1.046	
7	1.046	1.6309	1.7071	2.0729	1.4175	1.046	
8	1.0631	2.1033			1.9814	.9297	
9	1.6309	.823		.7468	.8402	1.6309	2.0576
10	2.0576	.5487		.6173	.5487	1.9662	
11	2.0881	.463	.4268	.4458	.3772	2.0119	2.21
12	2.0424	.3944	.3658	.4115	.3429	2.0729	1.9357
13		.3601	.2743	.3772	.3258	2.1643	1.6309
14	1.8595	.3429	.2743	.3772	.3601	2.1948	1.6309
15	1.9357	.3772		.3772	.3429	2.0729	1.7223
16	1.6766	.4115		.4115	.3086	1.8442	1.6461
17	.4973	.5144		.3429	.4458	.4268	.4801
18	.7716	.7373	.5792	.5658	.7202	.4877	.5658
19	.8916	.9602	.8535	.8402	.8573	.5792	.7545
20	.823	.7545	.8535	.8059	.8059	.6706	.7545
21	.7716	.7545	.7316	.7373	.8059	.7011	.7202
22	.7202	.6859	.6097		.7202	.4572	.703
23	.8402	.884	.7926	.8916	.6687	.5792	.6687
24	.6516	.7468	.8993	.823	.8916	.6516	
Max	2.0881	2.1033	1.7071	2.0729	1.9814	2.1948	2.21
Min	.4973	.3429	.2743	.3429	.3086	.4268	.4801
Avg	1.1191	.7743	.8044	.7559	.7673	1.1270	1.2486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 204 / Kalewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2946	1.174	.9938	1.1538	1.1016	.3159	.1509
2	.1269	1.1706	.9938	1.1233	1.1176	.3186	.1558
3	.2961	1.1835	.998	1.1142	1.1214	.3193	.1566
4	.2984	1.1827	1.0322	1.238	1.1511	.3216	.1578
5	.3483	1.2155	1.0406	1.3009	1.1511	.3372	.157
6	.3609	1.2509	1.0799	1.4053	1.1683	.3402	.1513
7	.33	1.467	1.2567	1.6335	1.2654	.4085	.173
8	.3471	1.568	1.5154	.6264	1.2582	.3712	.1772
9	1.7901	.1794		.1535	.1501	1.6602	2.0816
10	2.162	.3045		.2008	.2141	2.1406	2.5789
11	2.2668	.3475		.2241	.2545	2.3236	2.559
12	2.2515	.415		.2122	.2587	2.7157	2.3606
13	2.106	.381		.2194	.3338	2.7908	2.4661
14	2.2946	.3056	.0065	.264	.3681	2.7702	2.4558
15	2.3027	.3353	.2454	.437	.3902	2.7569	2.5358
16	2.2554	.3639	.3738	.4611	.4329	2.7267	2.4917
17	.2294	.4192	.1505	.4226	.4409	.2823	.3506
18	.306	.4215	.3391	.4435	.3788	.3559	.3368
19	.2908	.4169	.343	.4618	.41	.4123	.3883
20	.2671	.4165	.3323	.429	.4157	.4976	.394
21	.2408	.3266	.2347	.4207	.3746	.5258	.3825
22	.2194	.3132	.1878	.3871	.3673	.4431	.2976
23	1.1519	.9191	1.1263	1.1195	.3121	.3586	.253
24	.6683	1.0539	1.0699	1.137	.8013	.3323	.1014
Max	2.3027	1.568	1.5154	1.6335	1.2654	2.7908	2.5789
Min	.1269	.1794	.0065	.1535	.1501	.2823	.1014
Avg	.9669	.7138	.7010	.6912	.6349	1.0760	.9714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 205 / 11 KV Irrigation

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.0857	.0857	.1029	.1029	.6859	
2	.6687	.1029	.0762	.1029	.12	.6687	
3	.6687	.1029	.0762	.1029	.12	.6687	
4	.6516	.12	.0914	.1029	.1372	.6859	
5	.6859	.1372	.1372	.1372	.1372	.7716	
6	.7716	.1543	.1524	.1372	.1543	.7926	
7	.8402	.1543	.1886	.1372	.2058	.9145	
8	.9088	.1543	.1372		.1543	.9602	
9	.12	.945		1.3717	1.1888	.1372	.0914
10	.12	1.1888		1.4022	1.3413	.0857	.0914
11	.0514	1.2041	1.6118	1.4632	1.2803	.1029	
12	.0514	1.2193	1.6461	1.387	1.2193	.0857	.1067
13		1.1279	1.5775	1.387	1.2346	.0686	.1067
14	.0686	1.2041	1.5432	1.3717	1.326	.0686	.0914
15	.0686	1.326	1.5432	1.387	1.3413	.0686	.061
16	.0857	1.2651	1.5089	1.326	1.2193	.0686	.0762
17	.12	.1067		.0857	.1715	.1029	.1543
18	.1372	.1372	.1372	.0857	.1543	.1029	.1067
19	.1715	.1524	.1372	.1372	.1372	.1372	.1067
20	.1543	.1372	.1715	.1372	.1715	.1715	.1524
21	.12	.1372	.1715	.1372	.1715	.1715	.1067
22	.12	.1524	.1372	.1372	.1543	.1372	.1372
23	.0857	.0857	.1029	.1029	.6859	.7316	.6706
24	.6687	.0857	.0857	.1029	.1029	.6859	
Max	.9088	1.326	1.6461	1.4632	1.3413	.9602	.6706
Min	.0514	.0857	.0762	.0857	.1029	.0686	.061
Avg	.3481	.4786	.5390	.5585	.5430	.3781	.1471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 401 / 33 KV VALMONT

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543		.1029	.1029	.1543	.1543	
2	.1543		.2058	.1029	.1543	.1543	
3	.1543		.2058	.1543	.2058	.1543	
4	.1543		.2058	.1543	.1543	.1543	
5	.1543		.2572	.2058	.2572	.1543	
6	.1543		.2058	.2058	.1543	.1543	
7	.1029		.1029	.1543	.1029	.1543	
8		.2058	.1543		.1543	.1543	
9	.1029	.3086		.1543	.2058	.1543	.1029
10		.3086		.3086	.2572	.3601	.4115
11		.3601	.2058	.1543	.3086	.3086	.3086
12		.2572	.1543	.2058		.4115	.3086
13		.2058	.1543	.3086	.1543	.4115	.2572
14		.2058	.1543	.1543		.463	.2058
15		.2058	.2058	.1543		.4115	.2058
16		.3601		.2572	.1543	.4115	.2572
17		.2572		.3086	.2058	.2572	.1029
18		.2058	.1543	.2572	.1543	.2572	.2058
19		.2572	.2058	.3086	.3086	.2572	.2058
20		.2058	.1543	.2572	.1543	.1543	.2058
21		.2572	.2058	.2058	.3086	.1543	.2058
22		.2572	.2058	.2572	.2058	.1543	.2572
23		.2058	.1543	.2058	.1543	.1543	.2058
24	.1543		.2572	.1543	.2058	.1543	
Max	.1543	.3601	.2572	.3086	.3086	.463	.4115
Min	.1029	.2058	.1029	.1029	.1029	.1543	.1029
Avg	.1429	.254	.1826	.2058	.1960	.2379	.2298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN

Feeder No / Name : 201 / Shirsodi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4725	.1159	.061	.1159	.7678	1.2895	1.2345
2	.5029	.1463	.0762	.1311	.3562	.82	.884
3	.5029	.1463	.0762	.1311	.1886	.7286	.8291
4	.5182	.1463	.0914	.1463	.1886	.7986	.8261
5	.5334	.1616	.0914	.1463	.2038	.8535	.9968
6	.5354	.1921	.1067	.1646	.2038	.9328	1.1218
7	.5525	.1951	.0914	.1342	.2058	.9877	.9693
8	.7678	1.0487	1.0212	1.0944	1.1088	1.0487	1.2651
9	.3753	1.5455	1.0364	1.8777	1.9433	.3749	.7682
10	.3582	1.6766	1.0517	2.0748	2.1277	.3932	.8154
11	.4023	1.0059	1.0364	2.1739	2.1948	.3627	.6157
12	.4146	1.0059	2.0576	2.1033	2.207	.3506	.3963
13	.3414	.9755	2.0699	2.2024	2.1856	.3993	.791
14	.3505	.884	2.0911	2.1224	2.1368	.4176	.6431
15	.3505	.7164	1.9601	1.9529	2.0911	.3384	.695
16	.8261	.1524	1.1584	1.0936	1.0883	1.0212	1.233
17	.631	.0762	.1646	.1448	.2194	1.0029	.9983
18	.5944	.0762	.1859	.1791	.2073	.9236	1.0349
19	.5944	.061	.1342	.1619	.2073	.9053	1.0699
20	.5944	.0762	.1342	.1619	.2073	.8413	.9694
21	.5762	.061	.061	.1467	.2042	.8413	.8855
22	.5609	.061	.061	.1467	.2042	.8413	.8352
23	.5974	.061	.1159	.1124	.6463	1.2651	1.2224
24	.8649	.1342	.061	.1159	.1124	1.3499	1.326
Max	.8649	1.6766	2.0911	2.2024	2.207	1.3499	1.326
Min	.3414	.061	.061	.1124	.1124	.3384	.3963
Avg	.5341	.4467	.6248	.7848	.8836	.7953	.9344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN

Feeder No / Name : 202 / padasthal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.7316		.7133	.6344	1.1888	1.2437
2	.9945	.7316		.695	.6687	1.2071	1.262
3	.9945	.695		.695	.6516	1.262	1.2803
4	1.0117	.7133		.7316	.6344	1.3169	1.3717
5	1.0631	.7682		.7865	.7545		1.4449
6	1.2517	.823		.823	.9259	1.5181	1.5364
7	1.4746	.9145		.8596	.8916	1.7375	1.6827
8	1.4746	.9694		.8413	.8916	1.9022	1.7558
9	.7888	1.5912		1.957	1.6975	.9511	.9694
10	.8402			1.9669	2.0668	.9328	1.0288
11	.7133		2.1765	2.0576	2.0485	.8779	.9774
12	.7133		2.0485	2.0576	2.0119	.823	.9088
13	.6036		1.9936	1.9719	1.957	.7499	.5316
14	.5304		1.9204	1.9547	1.7741	.7316	.6173
15	.567		1.9387	1.8898	1.8107	.7499	.7202
16	.6036		1.8656	1.7833	1.701	.7682	.9335
17	.6767		.5853	.5144	.5853	.7865	.8916
18	.8413		.823	.703	.7888	.9328	.9602
19	.8413		.8779	.8402	.9328	.9145	1.0288
20	.8596		.7682	.7888	.8962	.8962	.9774
21	.8048			.6859	.8048	.8413	.9259
22	.7682			.6344	.7682	.823	.8402
23	.7316		.7316	.6173	1.0974	1.0974	1.0974
24	.9945	.7133		.7499	.6516	1.2308	1.1888
Max	1.4746	1.5912	2.1765	2.0576	2.0668	1.9022	1.7558
Min	.5304	.695	.5853	.5144	.5853	.7316	.5316
Avg	.8822	.8651	1.4299	1.1383	1.1519	1.0539	1.0906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN

Feeder No / Name : 203 / 11kv Ajoti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	1.0974		1.1523	.823	.4572	.5304
2	.4115	1.0974		1.1157	.8573	.439	.5487
3	.4115	1.0608		1.134	.8573	.4024	.6219
4	.4115	1.134		1.1888	.8402	.4207	.6767
5	.3772	1.2437		1.262	.9088	.4755	.695
6	.4458	1.4083		1.3169	1.0117	.5121	.7316
7	.5144	1.6278		1.4449	1.1488	.5121	.7316
8	.4973	1.7924		1.6278	1.3717	.4755	.6584
9	1.7318	.5121		.5121	.4458	1.4083	2.0119
10		.3944		.3944	.4207	1.8839	2.1605
11	2.0851		.3292	.3601	.3658		2.1948
12	2.268		.3109	.3429	.3292	2.0302	1.8004
13	2.1582		.2926	.2915	.3109	1.9753	1.8176
14	2.0668		.2926	.2915	.2926	1.9387	1.8519
15	2.0119		.2926	.3086	.2926	1.829	1.9204
16	1.8839		.3292	.3601	.3109	1.7375	1.8861
17	.3292		.3475	.4115	.3475	.2743	.3601
18	.439		.5121	.4801	.4207	.439	.4458
19	.4572		.5487	.5658	.4755	.4755	.5144
20	.4938		.4207	.5144	.5121	.5121	.4801
21	.4572			.4801	.439	.4938	.4801
22	.4207			.463	.4572	.4755	.4458
23	.8779		1.134	.8059	.4207	.4755	.4287
24	.3772	1.0791		1.1888	.8402	.4755	.4938
Max	2.268	1.7924	1.134	1.6278	1.3717	2.0302	2.1948
Min	.3292	.3944	.2926	.2915	.2926	.2743	.3601
Avg	.9357	1.1316	.4373	.7506	.6042	.8747	1.0203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN

Feeder No / Name : 204 / 11kv Malwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5772	1.2117	.3429	.951	.6173	.2439	.2256
2	.5391	1.1111	.2591	.8611	.6249	.2073	.2439
3	.1733	.7849	.0762	.727	.6173	.2149	.2622
4	.181	.8475	.0838	.7788	.6668	.2149	.2439
5	.1966	.9358	.0991	.8886	.7258	.2591	.2515
6	.2408	1.1446	.0991	1.0319	.8364	.2957	.2881
7	.2545	1.265	.0838	1.1644	.9335	.3429	.2805
8	.9054	1.3596	.0686	1.2773	1.1355	1.0242	.9282
9	2.2085	.1844	.061	.2743	.2706	1.8183	.7087
10	2.3072	.0381	.0686	.2884	.2957	2.05	2.3152
11	2.617	.0381	.1859	.28	.2667	2.2222	2.2816
12	2.6109	.0457	.189	.2629	.3186	2.4066	2.3472
13	2.524	.0457	.1996	.2877	.2896	2.3381	2.1262
14	2.3472	.0686	.2225	.2877	.2606	2.271	2.1582
15	2.3182	.0838	.1935	.2877	.2789	2.1994	2.1612
16	1.8382	.6859	.8063	.783	.7026	1.8046	1.7299
17	.1799	.6783	.8246	.783	.7026	.2728	.2317
18	.2164	.5563	.7331	.7487	.6249	.2576	.2317
19	.2011	.4801	.6188	.6211	.5456	.2499	.2241
20	.2118	.4572	.5517	.5602	.4816	.2271	.192
21	.1676	.4344	.4268	.5182	.4588	.2118	.1768
22	.16	.4496	.4191	.4801	.4588	.2042	.1692
23	.9389	.4572	1.1355	.8326	.4511	.1966	.1616
24	.181	1.3351	.3887	1.0379	.8307	.2515	.2256
Max	2.617	1.3596	1.1355	1.2773	1.1355	2.4066	2.3472
Min	.16	.0381	.061	.2629	.2606	.1966	.1616
Avg	1.0040	.6124	.3391	.6672	.5581	.9077	.8402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 201 / Kandalgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.373	.3048	.3429	.2439	.0724	.061
2	.061	.4024	.3048	.3391	.3048	.0716	.061
3	.061	.3932	.3048	.3353	.3048	.0716	.061
4	.0914	.3932	.3437	.3315	.3353	.0709	.0762
5	.0937	.4534	.3749	.3315	.3658	.0886	.0972
6	.0972	.4801	.3887	.3605	.3658	.0876	.0995
7	.0972	.506	.4858	.3563	.1006	.0905	
8	.0972	.5693	.5182	.4481	.0671	.0716	
9	.6802	.0914		.0914	.0732	.4801	.6802
10	.759	.0838		.0762	.1097	.4344	.7186
11	.8124	.081		.1067	.1267	.5068	.7621
12	.8322	.064		.1067	.1254	.6203	.7621
13	.8223	.1235		.1524	.128	.6706	.6687
14	.7811	.1219		.1524	.1086	.6706	.6321
15	.7499	.1219	.0732	.1829	.1086	.7011	.6401
16	.7274	.1219	.1086	.1829	.1448		.6481
17	.1097	.1158	.1097	.1829	.1848		.1097
18	.1097	.1143	.1097	.1692	.1478	.0556	.1086
19	.1097	.1158	.0905	.1158	.1097	.0914	.1097
20	.1086	.0869	.0924	.088	.1097	.0914	.0914
21	.0914	.0892	.2926	.0869	.1097	.0903	.0905
22	.0905	.061	.0914	.0914	.1097	.0846	.0739
23	.3772	.3048	.3429	.2439	.0905	.061	.0732
24	.061	.3772	.3048	.3429	.2439	.0724	.061
Max	.8322	.5693	.5182	.4481	.3658	.7011	.7621
Min	.061	.061	.0732	.0762	.0671	.0556	.061
Avg	.3284	.2352	.2579	.2174	.1716	.2389	.3039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 202 / Mahadev Nagar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6477	.7735	.7316	.8154	.2743	.541	.4725
2	.6477	.7887	.7163	.823	.3125	.5687	.4877
3	.5029	.6659	.5868	.7135	.602	.5687	.4877
4	.5258	.6792	.6021	.6992	.6173	.6554	.564
5	.6173	.7174	.7659	.7373	.6325	.6859	.5716
6	.644	.7621	.7631	.7983	.7163	.6896	.5525
7	.5754	.7087	.664	.7468	.5944	.6402	.1981
8	.7659	.8002	.6839	.8535	.5372	.2715	.6554
9	1.3337	.3839	.1677	.4449	.4068	1.4556	1.2908
10	1.4404	.3496	.1524	.3277	.4039	1.486	1.5394
11	1.4555	.2762		.2515	.3277	1.5927	1.5794
12	1.4784	.2896		.2515	.3353	1.6079	1.5937
13	1.4784	.2915		.2667	.3296	1.6233	1.7147
14	1.4708	.3048		.2972	.3829	1.6461	1.6766
15	1.3755	.3734	.2743	.3277	.381	1.5471	1.7689
16	1.2555	.8497	.9221	.964	.8612	.6554	1.5547
17	.6401	.884	1.0698	.965	.9755	.3125	.5963
18	.6553	.8316	.8869	.8535	.9373	.6669	.6344
19	.663	.8078	.803	.8383	.8564	.6935	.7069
20	.5868	.7468	.7344	.7964	.8136	.6782	.6307
21	.5486	.6497	.7163	.7545	.7878	.6401	.5973
22	.5287	.6477	.7087	.7392	.7755	.5011	.5744
23	.583	.7239	.7659	.7316	.7669	.5106	.5535
24	.4648	.7506	.7392	.7659	.7925	.5563	.5029
Max	1.4784	.884	1.0698	.965	.9755	1.6461	1.7689
Min	.4648	.2762	.1524	.2515	.2743	.2715	.1981
Avg	.8702	.6274	.6727	.6568	.6009	.8664	.8960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 203 / Hingangaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.2149	.1981	.2328	.1829	.7716	.6249
2	.6097	.2172	.1981	.2507	.2134	.7716	.6249
3	.6401	.2865	.2439	.2481		.7926	.6401
4	.6401	.2865	.25	.2896	.2439	.7926	.6401
5	.6874	.3467	.2812	.3258	.3048	.823	.6874
6	.7125	.3601	.2915	.3506	.3048	.8436	.7293
7	.8097	.3641	.2753	.3467	.8551	.8905	
8	.8907	.3086		.3121	.9496	.953	
9	.2591	.9172		1.1469	1.2266	.3121	.4049
10	.2427	1.1984		1.1584	1.2308	.2317	.3467
11	.2149	1.2955	1.3279	1.1584	1.2163	.2294	.3294
12	.2149	1.2803	1.3123	1.2193	1.2163	.1692	.2279
13		1.2654	1.2651	1.2193	1.1984	.1524	.2427
14	.2149	1.2498	1.2146	1.2193	1.1523	.1219	.2454
15	.2172	1.2193	1.2308	1.1584	1.1203	.1829	.2454
16	.2328	1.2186	1.1984	1.0151	1.1012		.2481
17	.2328	.1738	.1791	.1692	.1772		.2658
18	.2303	.2143	.2507	.2115	.2481	.1947	.3012
19	.3224	.2606	.2896	.2606	.3224	.2743	.3189
20	.3045	.2675	.3045	.2494	.3012	.3048	.2865
21	.2865	.2378	.2686	.2462	.2865	.2559	.2481
22	.2658	.2134	.2686	.2439	.2534	.2317	.2149
23	.2328	.2134	.2481	.2134	.7253	.6249	.5304
24	.6097	.2172	.1981	.2328	.1829	.7716	.6249
Max	.8907	1.2955	1.3279	1.2193	1.2308	.953	.7293
Min	.2149	.1738	.1791	.1692	.1772	.1219	.2149
Avg	.4209	.5761	.5378	.5616	.6528	.4862	.4104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 204 / 11 Kv Sardewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.621	.5411	.6344	1.5851	2.1414	1.9738
2	1.1127	.7393	.6096	.7059	.8154	1.7471	1.448
3	1.0974	.7088	.602	.6725	.663	1.5261	1.3584
4	1.1584	.6973	.6782	.7697	.762	1.587	1.4365
5	1.2079	.6858	.6859	.7964	.7239	1.6232	1.4556
6	1.3203	.6858	.6516	.8269	.8154	1.6994	1.488
7	1.4165	.6706	.6211	.7088	1.6765	1.2346	.3353
8	1.4594	2.2186	2.3587	2.4043	3.276	1.2346	.3201
9	.8345	2.9569	2.111	3.6036	3.5989	.6783	.6745
10	.9317	3.538	2.1491	3.6199	3.6656	.6249	.7468
11	.9488	3.6923	4.0123	3.6428	3.7256	.602	.8555
12	.9488	3.6999	3.9971	3.7342	3.6799	.6173	.7849
13	.9869	3.6094	4.0352	3.7342	3.8199	.5715	.7811
14	.9869	3.5361	4.0123	3.7342	3.8199	.4953	.7506
15	.9126	3.2313	3.7208	3.4294	3.6808	.5106	.7812
16	1.669	2.0348	2.3929	1.9967	2.3787	1.5318	1.5775
17	1.6975	.5754	.6039	.5697	.724	1.4708	1.5661
18	1.5756	.6364	.6821	.6402	.7507	1.7033	1.4556
19	1.5299	.6478	.6897	.6706	.7735	1.7146	1.4785
20	1.5404	.6478	.6973	.6821	.7735	1.7985	1.4899
21	1.4442	.6401	.6821	.663	.7811	1.7223	1.4823
22	1.4327	.6401	.6554	.5868	.7697	1.6918	1.4746
23	1.3984	.5563	.5582	.5715	1.4632	2.3015	1.9834
24	1.7147	.6631	.5029	.6068	.602	2.4386	1.9814
Max	1.7147	3.6999	4.0352	3.7342	3.8199	2.4386	1.9834
Min	.8345	.5563	.5029	.5697	.602	.4953	.3201
Avg	1.2628	1.5972	1.5938	1.6669	1.8885	1.3861	1.2367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214466 / 33/11 KV BIJEWADI

Feeder No / Name : 201 / Bijewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	2.0195	1.5013	1.4327	1.0784	.458	.2953
2	.905	2.0042	1.4632	1.4023	1.0784	.3086	.3029
3	.2877	1.4022	.8535	.7088	1.086	.3163	.3029
4	.2877	1.4022	1.0307	.7164	1.0784	.3163	.3029
5	.2877	1.4022	1.2041	.7316	1.3336	.3239	.2953
6	.382	1.4022	1.5089	.9069	1.326	.3163	.2572
7	.3515	1.7223	1.6023	1.1355	1.608	.2781	.2572
8	1.1793	1.6995	1.9661	1.4022	1.608	1.5508	1.3146
9	2.6749	.2496	.0686	.2553	.2781	2.9645	2.774
10	3.0864	.2496	.0686	.2591	.2781	3.2465	2.774
11	3.3493	.2305	.0762	.2591	.2629	3.437	3.155
12	3.3474	.1905	.2477	.2477	.2648	3.4522	3.1322
13	3.3722	.0762	.2477	.2477	.2705	3.5589	3.4217
14	3.1931	.2363	.2477	.2496	.2705	3.5513	3.4293
15	3.1017	.2667	.2782	.2724	.2877	3.4217	2.8235
16	2.4997	1.1603	1.1774	1.1355	1.0593	3.0026	1.1126
17	.341	1.1622	1.105	1.2326	1.2384	.3258	.362
18	.3639	1.0498	1.1317	1.126	1.1412	.3258	.3563
19	.3486	.9888	1.0402	1.0345	1.0498	.3182	.3334
20	.3182	.9583	.9812	1.0116	1.0326	.3105	.3239
21	.3182	.9431	.9412	1.004	1.025	.3029	.3086
22	.3182	.9431	.9202	.9964	1.0345	.3029	.3086
23	1.4174	1.5013	1.3261	1.7719	1.0193	.2953	.3105
24	.3105	2.05	1.4632	1.4023	1.8024	.2953	.3105
Max	3.3722	2.05	1.9661	1.7719	1.8024	3.5589	3.4293
Min	.2877	.0762	.0686	.2477	.2629	.2781	.2572
Avg	1.3744	1.0546	.9355	.8726	.9380	1.3742	1.1902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214466 / 33/11 KV BIJEWADI

Feeder No / Name : 202 / Gaagargaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7983	.1248	.14	.1172	.7954	1.6308	1.3279
2	.7983	.1362	.1362	.1248	.6582	1.5851	1.2517
3	.8078	.1362	.14	.1515	.1286	1.0936	.844
4	.8078	.1362	.1438	.1476	.1286	1.0974	.8402
5	.8154	.1362	.1438	.1476	.1286	1.0974	1.0022
6	.8478	.1286	.1381	.1429	.1239	1.1812	1.006
7	.7888	.1172	.1124	.1391	.1239	1.2765	1.0327
8	.7888	.8449	.8745	.8593	.9126	1.2879	1.0517
9	.1172	1.4594	.7888	.7697	1.8861	.1553	.1447
10	.121	1.707	.7849	1.848	1.9509	.1515	.1506
11	.1362	1.81	.7697	1.848	2.0614	.1277	.1286
12	.1362	1.8804	1.6994	1.8061	2.0119	.1277	.1286
13	.1362	1.89	1.6956	1.7871	2.0004	.1286	.1515
14	.1172	1.827	1.6689	1.9547	2.0004	.1248	.1353
15	.1172	1.7223	1.6156	1.9395	1.9585	.121	.1248
16	.6278	1.547	1.4784	1.7604	.522	.8107	.7602
17	.6239	.1286	.1324	.1438	.1324	.7992	.7573
18	.6163	.1286	.2229	.1438	.1286	.7878	.704
19	.6049	.1248	.1286	.1438	.1239	.7878	.6735
20	.5973	.1239	.1286	.1476	.1248	.7916	.6506
21	.5973	.1239	.1324	.1476	.1248	.7992	.6506
22	.5973	.1248	.1286	.1438	.121	.803	.6659
23	.5973	.121	.1248	.1438	1.0936	1.5184	1.4746
24	1.2631	.121	.1248	.14	.1172	1.7756	1.3698
Max	1.2631	1.89	1.6994	1.9547	2.0614	1.7756	1.4746
Min	.1172	.1172	.1124	.1172	.1172	.121	.1248
Avg	.5608	.6917	.5606	.6957	.8066	.8358	.7095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214466 / 33/11 KV BIJEWADI

Feeder No / Name : 203 / Bijawadi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5077	.3944	.3906	.5087	.4058	.3867	.3944
2	.542	.4439	.4934	.4744	.5468	.421	.4325
3	.6258	.5125	.6077	.5716	.6535	.6001	.5011
4	.6792	.6001	.6497	.602	.703	.6649	.5315
5	.7887	.8354	.6973	.702	.7973	.7668	.6563
6	.7192	.9068	.8536	.8459	.9487	.8497	.8144
7	.4715	.8487	.8211	.9431	.9488	.9354	.8878
8	.5658	.8564	.985	1.0498	.9031	.9164	.964
9	.7725	.7468	.3125	1.4022	.7077	.7049	.865
10	.6935	.3925	.301	.7278	.6973	.6134	.663
11	.5839	.6659	.3125	.724	.724	.6973	.4668
12	.6068	.3848	.5297	.684	.6906	.6287	.4039
13	.5011	.3734	.5659	.4877	.6058	.7401	.6592
14	.5811	.3772	.6611	.6601	.6516	.6458	.7068
15	.6992	.4249	.7354	.6725	.7716	.6687	.8154
16	.602	.7659	.8497	.6687	.6897	.7716	.9107
17	.5944	.843	.9888	.905	.9678	.8211	.9726
18	.5982	.9183	.9564	.863	1.0593	.7525	.9526
19	.9221	.8716	1.0021	.7211	1.0269	.8306	.9736
20	.8344	.7954	.8068	.7163	.8154	.7163	.7945
21	.6678	.6401	.4553	.5496	.7582	.5572	.6287
22	.5277	.523	.5115	.3982	.603	.4172	.5039
23	.5087	.4096	.3944	.3906	.5049	.3982	.481
24	.5954	.4058	.3867	.3829	.5087	.3944	.3791
Max	.9221	.9183	1.0021	1.4022	1.0593	.9354	.9736
Min	.4715	.3734	.301	.3829	.4058	.3867	.3791
Avg	.6329	.6224	.6362	.6938	.7371	.6625	.6816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 201 / 11kv Pitkeshwer

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4191		.3521		.5716	.4915
2		.4572		.3441		.5716	.4973
3		.4763		.3521		.5716	.503
4		.4763		.3647		.6668	.5304
5		.5525		.4641		.7049	.6962
6		.6859		.6539		.8573	.8122
7	1.2717	.7049		.639		1.6385	1.1768
8	1.543	.724		.5868			1.4083
9	.4239			1.0978		.6097	.4641
10	.4191	1.3592		1.1869	1.6766	.4359	.4144
11	.3429	1.3426	1.2929	1.2548	1.6194		.5087
12	.3239	1.3923	1.3757	1.3226	1.2574		.3561
13	.3048	1.2266	1.3413	1.3735	1.2003		.2035
14	.3048	1.3094	1.2597			.285	.2035
15	.3239	1.2929	1.2146	.7291	.9526	.3149	.2035
16	.2477	1.2929	1.1797			.3481	.2204
17	.3048	.2883	.2949		.381	.3856	.2713
18		.4239	.4424			.4359	.407
19		.4578	.4641			.4527	.4917
20		.407	.4807			.4641	.4527
21		.4409	.4588			.4359	.431
22		.407	.431			.4191	.431
23		.3222	.3647		.5716	.5087	.5304
24	.4917	.4191	.3052	.3481	.4382	.4915	.5087
Max	1.543	1.3923	1.3757	1.3735	1.6766	1.6385	1.4083
Min	.2477	.2883	.2949	.3441	.381	.285	.2035
Avg	.5252	.7338	.7790	.7380	1.0121	.5585	.5089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 202 / Vyahali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9526		.7969		1.2003	1.065
2		1.0098		.788			1.0898
3		1.0479		.7701		1.2003	1.065
4		1.1431		.8192		1.3336	1.1271
5		1.4289		1.2944		1.6385	1.6244
6		1.829		1.491		2.0957	2.2611
7	3.3065	1.7147		1.6095		3.4484	3.7555
8	4.1034	1.3336		1.5746		3.8104	4.1126
9	1.2209			3.0312		1.3336	1.2597
10		3.6466			.9145	.9892	1.0442
11	.8954	3.1161	3.315		3.3341	.6464	.9492
12	.8573	2.7349	3.195		3.4294	.663	.8417
13	.8002	3.083	2.934		3.4294	.6796	.5373
14	.7621	2.8344	2.652		2.8959	.5967	.591
15	.7621	2.9007	2.556		2.6863	.4973	.5194
16		3.083	2.3537		2.7625	.3315	.5552
17	.7811	.7343	.6036		.7621	.7125	.7343
18		.9313	.9667			.6706	.9492
19		1.5939	1.1797			1.0774	1.3073
20		1.379	1.3108			.9892	1.1999
21		1.1641	1.0774			.9892	1.0745
22		1.0208	.8848		1.1431	.9116	.9492
23		.8775	.7865		1.2384	1.1401	1.1437
24	1.1361	.9526	.7956	.788	.9145	1.0322	1.065
Max	4.1034	3.6466	3.315	3.0312	3.4294	3.8104	4.1126
Min	.7621	.7343	.6036	.7701	.7621	.3315	.5194
Avg	1.4625	1.7614	1.7579	1.2963	2.1373	1.2168	1.2842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 203 / 11KV INDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.5525	.1638	.4656	.2096	.6449	.6226
2	.1867	.5715	.1829	.4961	.2096	.624	.5921
3	.2096	.5868	.2096	.5197	.2324	.6316	.5929
4	.2324	.6401	.2286	.5639	.2439	.6192	.6318
5	.2515	.7316	.2591	.676	.2667	.6889	.8087
6	.2667	.8459	.2477	.7794	.2629	.7692	.9098
7	1.3834	.8269	.1638	1.0852	.1715	1.0576	1.3168
8	1.5072	1.2003	.522	.6135	.3887	1.5272	1.3653
9	.5314	1.9738	.6059	1.7696	.4915	.563	.4641
10	.4763	2.0043	.5754	1.2717	1.5623	.4648	.3885
11	.4916	2.0347	1.6629	1.9704	1.589		.3496
12	.4534	2.0385	1.7303	1.8537	1.7299		.2932
13	.4344	1.9772	1.6653	1.9525	1.5584	.0076	.1448
14	.4115	1.9593	1.6309	.724	1.6957	.3334	.3635
15	.4801	1.9033	1.6206	1.6409	1.669	.4207	.3716
16	1.1393	1.6238	1.3028	.5411	1.2841	1.0643	.9558
17	1.1507	.5274	.5167	.282	.644	.984	.9309
18	.4306	.6816	.6047	.3086	.301	.6874	.8687
19	.3048	.7546	.5982	.2782	.2591	.6325	.763
20	.2439	.6356	.6098	.2286	.2172	.6174	.606
21	.2134	.575	.5335	.1943	.1981	.5653	.5462
22	.202	.5296	.5054	.1829	.1867	.5615	.5016
23	.2058	.4636	.4609	.1753	.644	.6036	.5769
24	.5449	.5487	.4805	.4592	.1562	.6069	.6005
Max	1.5072	2.0385	1.7303	1.9704	1.7299	1.5272	1.3653
Min	.1753	.4636	.1638	.1753	.1562	.0076	.1448
Avg	.4970	1.0911	.7117	.7930	.6738	.6670	.6485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 204 / 11KV Varkute(kh)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2384		1.1584		.9831	1.1022
2		1.2384		1.2452		.9945	1.0774
3		1.2384		1.2452		1.0277	1.0774
4		1.2384		1.291		1.0774	1.1233
5		1.6194		1.4582		1.2597	1.1797
6		1.9814		1.9989		1.3599	1.4752
7	1.3565	2.8006		2.934		1.4754	1.4586
8	1.2039	3.8866		3.408		1.4922	
9	2.6452	1.2193		1.1142		2.8675	2.8837
10	3.5818	.5935		1.0343	1.1431	3.4591	3.1184
11	3.3532	.5935	.7712	.9326	.9907		3.2047
12	2.2862	.5765	.6371	.7461	.9145		2.652
13	2.9531	.6443		.9156	.8002		2.0388
14	2.7625	.6274		1.1022	.7621	2.4531	2.1365
15	2.8197	.6104		.4239	.6668	2.5987	2.3739
16	2.2862		.9614		.6287	3.1659	2.3205
17	.8192		.9221		.6859	2.8669	.6516
18		.9835	1.0395			1.6575	.823
19		1.2548	1.1271			1.3413	1.1831
20		1.2378	1.2597			1.1523	1.17
21		1.1869	1.2407			1.1437	1.17
22		1.1963	1.166		1.2955	1.1271	1.1963
23		1.2887	1.2742		1.2384	1.0774	1.0852
24	1.0174	.7969	1.283	1.2742	1.2955	1.0277	2.3205
Max	3.5818	3.8866	1.283	3.408	1.2955	3.4591	3.2047
Min	.8192	.5765	.6371	.4239	.6287	.9831	.6516
Avg	2.2571	1.2751	1.062	1.3926	.9474	1.6956	1.6879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 205 / Nimgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905		.1802		.1905	.1802
2		.1905		.1823		.1905	.1802
3		.1905		.1823		.1905	.1823
4		.2286		.2012		.2477	.1966
5		.2858		.3277		.2858	.2949
6		.4382		.4641		.4572	.4862
7	.6104	.6668		.6104		.6668	.6133
8	.6274	.7049		.6539		.6668	.6062
9	.5935					.5716	.503
10	.4954	.4031		.4917	.4191	.4807	.3932
11	.4572	.3506	.3315	.4239	.381	.3481	.4382
12	.4191	.3149	.2818		.362	.3481	.394
13	.3429	.298	.3315		.3429	.2652	.298
14	.3048	.2454	.3856		.2858	.2347	.2804
15	.3048	.2629	.3605		.2667	.2683	.2454
16	.3239	.3681	.3441		.3429	.3185	.2454
17	.381	.298	.3315		.362	.3113	.2454
18		.3681	.3277			.4024	.3681
19		.4908	.3481			.4191	.3856
20		.4382	.3812			.4409	.3641
21		.3506	.3315			.3353	.3506
22		.2865	.2429		.2858	.2515	.2774
23		.2328	.1823		.2096	.2012	.2149
24	.1865	.1905	.1928	.4239	.2096	.1638	.1823
Max	.6274	.7049	.3856	.6539	.4191	.6668	.6133
Min	.1865	.1905	.1823	.1802	.2096	.1638	.1802
Avg	.4206	.3389	.3124	.3765	.3152	.3440	.3302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 206 / 11 KV Gotondi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4289		1.3413		.6097	.5079
2		1.4289		1.3108		.6097	.502
3		1.4289		1.3108		.6097	.5079
4		1.4289		1.3435		.6668	.5407
5		1.6194		1.643		.743	.8048
6		2.0195		2.0348		.8954	.9054
7	.9326	2.9531		2.8656		.9526	.9556
8	.8309	3.2388		2.8837		.8764	.5138
9	2.34	.7621		.5992		2.4768	2.5587
10	3.0102	.4578			.5335	2.652	2.7362
11	3.1626	.3391	.3647		.4191	2.5857	2.9843
12	3.1626	.3391	.3978		.362	2.8502	2.7469
13	3.0483	.3222	.3688		.381	2.6189	1.9112
14	2.7625	.2374	.3521		.4191		2.2786
15	2.7625	.3052	.3932		.381	2.3472	2.3061
16	2.572	.407	.4694		.3239	2.4366	2.2043
17	.4954	.4409	.5407		.5144	2.2043	.4287
18		.6516	.663			.547	.5375
19		.7888	.7373			.6371	.7712
20		.7291	.8215			.8122	.7122
21		.6613	.6554			.7042	.6613
22		.5784	.6036		.6668	.5596	.5426
23		1.3056	1.3245		.6287	.4877	.5426
24	.4917	1.4289	1.3226	1.3108	1.448	.5243	.5138
Max	3.1626	3.2388	1.3245	2.8837	1.448	2.8502	2.9843
Min	.4917	.2374	.3521	.5992	.3239	.4877	.4287
Avg	2.1309	1.0542	.6439	1.6644	.5525	1.3220	1.2364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 207 / 11 Kv Sonai

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0076		.0067		.0076	.0061
2		.0076		.0061			.0066
3		.0076		.0066		.0076	.0068
4		.0076		.0061		.0076	.0061
5		.0076		.0061		.0076	.0062
6		.0076		.0061			.0066
7	.0136	.0076		.0061		.0076	.0067
8	.0068	.0076		.0122		.0076	.0061
9	.0068			.0262		.0152	.0259
10	.16	.1696			.0114	.0244	.0975
11	.1715	.1683	.0332		.0953	.0197	.1734
12	.1143	.0351	.0328		.0305	.0183	.1803
13	.1334	.0351	.1524		.0152	.0244	.1472
14	.1905	.0701	.1638		.0152	.0265	.1683
15	.1715	.0882	.1677		.0152	.0597	.2033
16	.1334	.2103	.1844		.0229	.0604	.2103
17	.1334	.1542	.1677		.1143	.1677	.1893
18		.1542	.1311			.1677	.1402
19		.2173	.1326			.218	.2244
20		.1402	.1219			.2321	.1907
21		.1648	.1389			.2204	.1803
22		.021	.1389		.2058	.1509	.1734
23		.0208	.1543		.2286	.1219	.0358
24	.0068	.0076	.007		.0076	.0131	.0061
Max	.1905	.2173	.1844	.0262	.2286	.2321	.2244
Min	.0068	.0076	.007	.0061	.0076	.0076	.0061
Avg	.1035	.0747	.1233	.0091	.0693	.0721	.0999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 401 / 33 KV Sonai

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2574		1.3763	1.2963
2				1.17		1.094	1.3117
3				1.1305		.9945	1.278
4				1.0814		.9945	1.0974
5				1.278		.8951	1.2071
6						.9054	1.5912
7	1.2717			1.0562		.9448	1.6907
8	.8648			1.5238		.9665	1.5592
9	1.17			1.861		1.5415	1.7295
10	1.6004	1.9404			1.6004	1.7901	1.6712
11	1.4289	2.1068	2.0885		1.0288	1.4083	1.7741
12	1.5432	1.0534	2.0119		.9145	1.1934	1.6632
13	1.6004	.499	1.7204		1.086	1.2071	1.1088
14	1.2574	.8402	1.3763		1.7718	1.1934	1.0534
15	1.4289	1.0642	1.2929		2.0005	.8951	1.296
16	.9717	1.5123	1.2431		.9145	.7459	1.386
17	.9717	1.3443	1.1568		1.4861	.6882	1.8296
18		1.386	1.5912			.4024	1.2752
19		1.4563	1.4918			1.0059	1.7187
20		1.5524	1.5238			1.3426	1.6632
21		1.386	1.4083			1.5592	1.6078
22		1.5123	1.4586			1.7901	1.6078
23		1.4415	1.5238		1.6004	1.406	1.6078
24	1.5261		1.2752	1.2289		1.3763	1.4255
Max	1.6004	2.1068	2.0885	1.861	2.0005	1.7901	1.8296
Min	.8648	.499	1.1568	1.0562	.9145	.4024	1.0534
Avg	1.3029	1.3639	1.5116	1.2875	1.3781	1.1549	1.4771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214502 / 33/11 KV Wadapuri

Feeder No / Name : 201 / 11 KV Vitthalwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	.298	.3506		.3506	1.5415	1.5775
2	1.6289	.2865	.3506		.3721	1.5203	1.595
3	1.7177	.2926	.3641		.394	1.5364	1.6301
4	1.749	.4344	.4508		.4382	1.6126	1.6804
5	1.861	.5609	.5316		.5258	1.6617	1.7404
6	2.0287	.7545	.7209		.7343	1.8884	1.9498
7	2.4646	.8589	.7773		.7888	2.2885	2.4453
8	2.8837	.7442	.6882		.7888	2.6235	2.753
9	.583	2.4143			2.5316	.6274	.6316
10	.427	2.9007			2.9005	.4744	.5801
11	.3361	3.6222	2.8502		3.0011	.3637	.4191
12	.3086	3.2278			2.8334	.2591	.4115
13	.3005	3.195			2.8166	.2429	.3189
14	.25	3.1623			2.6322	.2294	.2865
15	.2743	3.1417			2.649	.2105	.2715
16	.2675	3.0121			2.4577	.2105	.3366
17	.3018	.2915			.3511	.3292	.3506
18	.5138	.5487			.543	.5249	.3898
19	.7164	.7059			.7392	.695	.4207
20	.6908	.6516			.6348	.6036	.3988
21	.5601	.4207			.5121	.4525	.3772
22	.4481	.3658		.4207	.3475	.3258	.3772
23	.3391	.3429		.3772	1.5947	1.4918	1.5089
24	1.6632	.3086	.333		.3506	1.5775	1.491
Max	2.8837	3.6222	2.8502	.4207	3.0011	2.6235	2.753
Min	.25	.2865	.333	.3772	.3475	.2105	.2715
Avg	.9983	1.3559	.7417	.3990	1.3037	.9705	.9976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214502 / 33/11 KV Wadapuri

Feeder No / Name : 202 / 11 KV Gokhali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.9114	1.0341	.9116	.8939	.2481	.298
2	.2915	.8954	1.0517	.9503	.8859	.2172	.298
3	.333	.9145	1.0402	.9945	.9671	.2195	.333
4	.3772	1.0136	1.1096	1.0898	.964	.2454	.3601
5	.4191	1.0692	1.166	1.1736	1.0166	.3052	.431
6	.5197	1.3203	1.2742	1.1768	1.1999	.4321	.4752
7	.5533	1.8054	1.6518	1.7295	1.6632	.5121	.5344
8	.5365	2.0199	2.0005	2.0405	1.8519	.5182	.4696
9	1.6804	.3856		.3856	.3018	1.5091	1.6032
10	1.7711	.2818		.2401	.2347	1.8976	1.7404
11	1.8244	.2155	.2347	.2012	.1677	1.9766	1.9784
12	1.6975	.1475	.2058	.1715	.1677	1.8947	2.0233
13	1.9134	.1475	.2103	.1543	.1509	1.9433	2.0376
14	1.7966	.1311	.1791	.1543	.1174	2.0481	1.97
15	1.5546	.1296	.1595	.1715	.1341	1.8947	1.9185
16	1.5009	.1457	.1753	.2229	.1311	1.8138	1.825
17	.1844	.2058	.2058	.2058	.2033	.2378	.2103
18	.3898	.3658	.208	.3353	.4344	.362	.2658
19	.5194	.543	.2835	.4359	.5175	.4755	.298
20	.5041	.4706	.3155	.4287	.4668	.4207	.3121
21	.4294	.4207	.3294	.3772	.4024	.3439	.3429
22	.3921	.3658	.3429	.3506	.3475	.3077	.3772
23	.9156	.9602	.8718	.8745	.3189	.2743	.3353
24	.3086	.9259	1.0341	.852	.9114	.2629	.2774
Max	1.9134	2.0199	2.0005	2.0405	1.8519	2.0481	2.0376
Min	.1844	.1296	.1595	.1543	.1174	.2172	.2103
Avg	.8627	.6580	.6856	.6512	.6021	.8484	.8631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214502 / 33/11 KV Wadapuri

Feeder No / Name : 203 / 11 KV Wadapuri GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0701	.0701	.0829	.0701	.0709	.0701
2	.0686	.0537	.0701	.0819	.0709	.0543	.0876
3	.1052	.0549	.0867	.0995	.0895	.0549	.0876
4	.12	.0905	.104	.1341	.1227	.0876	.12
5	.1509	.1402	.1543	.1677	.1578	.1357	.1492
6	.218	.2229	.218	.1989	.2328	.208	.213
7						.16	.1943
8						.1296	.1619
9							.1457
10	.1423	.116		.1543	.1509	.1265	.1492
11	.144	.0995	.0838	.1509	.1006	.1107	.1341
12	.0772	.0983	.1029	.12	.0838	.081	.1029
13	.0791	.0983	.0876	.0686	.1006	.081	.0886
14	.0625	.0819	.0895	.0686	.0838	.0655	.0716
15	.0762	.0648	.0709	.0686	.1006	.0648	.0543
16	.0892	.081	.1052	.0857	.1475	.0648	.0886
17	.0838	.1029	.0857	.1372	.1109	.1097	.0701
18	.1417	.128	.0867	.1006	.0905	.1267	.0886
19	.1612	.1448	.0886	.1677	.1294	.1646	.0876
20	.1307	.1629	.0876	.1372	.1867	.1463	.0867
21	.112	.128	.0867	.12	.1463	.1267	.1029
22	.112	.0914	.0857	.1052	.1097	.0905	.1029
23	.0678	.0686	.0838	.0857	.0886	.0857	.0838
24	.0857	.0686	.0701	.0819	.0701	.0701	.0693
Max	.218	.2229	.218	.1989	.2328	.208	.213
Min	.0625	.0537	.0701	.0686	.0701	.0543	.0543
Avg	.1094	.1032	.0959	.1151	.1164	.1050	.1088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214502 / 33/11 KV Wadapuri

Feeder No / Name : 204 / 11 kV Pingalewasti Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.1227	.1578		.1402	.3189	.3506
2	.4115	.1075	.1578		.1417	.3077	.3506
3	.4382	.1097	.1734		.1612	.3109	.4031
4	.5144	.1629	.208		.2454	.3506	.4458
5	.57	.2454	.2572		.298	.4748	.5304
6	.7377	.4287	.3856		.4477	.6081	.6882
7	.9556	.5434	.4696		.5487	.8322	.8907
8	1.2071	2.4097	.4161		.4458	.9069	1.1174
9	.3258	.8886			.7545	.373	.3563
10	.1739	.8619			.788	.2688	.2652
11	.144	.9116			.6539	.1739	.2347
12	.1235	.852			.6874	.1296	.1886
13	.1107	.7865			.7209	.1296	.1772
14	.0937	.7537			.6371	.1311	.1433
15	.0914	.7287			.6371	.1457	.1267
16		.7125			.6062	.1781	.1595
17	.2012	.1543			.1294	.2378	.1753
18	.3012	.2743			.2715	.2896	.1772
19	.3761	.4525			.3511	.4572	.1753
20	.3361	.3258			.3361	.3475	.1734
21	.2427	.2378			.2378	.2896	.1886
22	.1867	.1829		.1753	.1829	.2172	.1886
23	.1526	.1372		.1543	.3012	.3258	.3185
24	.3601	.1372	.1402		.1578	.3155	.3294
Max	1.2071	2.4097	.4696	.1753	.788	.9069	1.1174
Min	.0914	.1075	.1402	.1543	.1294	.1296	.1267
Avg	.3666	.5220	.2629	.1648	.4117	.3383	.3398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214502 / 33/11 KV Wadapuri

Feeder No / Name : 206 / 11 kV Ramwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.8413	.964		.9816	.3544	.4382
2	.3944	.8596	.9816		.9922	.3258	.4733
3	.4382	.8962	.9991		1.0387	.3109	.5083
4	.5144	1.0136	1.0402		1.0867	.4031	.583
5	.57	1.0517	1.1145		1.2269	.5426	.663
6	.9556	1.406	1.5089		1.4506	.9282	.9503
7	.9892	1.9281	1.9109		1.749	1.1203	1.0526
8	1.0059		2.2085		2.1776	1.166	1.0202
9	1.8861	.9724			1.0395	1.7635	1.8461
10	2.0557	.6962			.6706	2.0241	2.1548
11	2.2085	.4641			.57	2.2138	2.1795
12	1.9136	.3605			.4694	2.17	2.0233
13	1.8027	.3277				2.1052	1.8427
14	1.6872	.2949			.4024	2.0645	1.8983
15	1.6461	.2753			.4359	1.9433	1.8823
16	1.3375	.3563			.4588	1.8138	1.7718
17	.57	.4801			.5175	.5121	.4557
18	.8859	.8413			.7964	.6878	.4961
19	1.0029	.9774			.961	.9511	.4557
20	.8962	.7964			.8962	.8413	.4854
21	.6348	.7682			.695	.6516	.4458
22	.5228	.5853		.5083	.5121	.5792	.4801
23	.8478	.9088		.9774	.3898	.4115	.4024
24	.3772	.8573	.9465		.9991	.3506	.4161
Max	2.2085	1.9281	2.2085	.9774	2.1776	2.2138	2.1795
Min	.3601	.2753	.9465	.5083	.3898	.3109	.4024
Avg	1.0626	.7808	1.2971	.7429	.8920	1.0931	1.0385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214504 / 33/11 kV Agoti

Feeder No / Name : 201 / 11 kV Chitalkarwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.0191	.0171	.0191	.0191	.2858	
2	.1905	.0191	.0171	.0191	.0191	.2858	.1715
3	.1905	.0191	.0171	.0191	.0191	.2858	.1715
4	.1905	.0191	.0171	.0191	.0191	.2858	.1715
5	.1905	.0191	.0171	.0381	.0191	.2858	.2058
6	.1905	.0191	.0343	.0381	.0191	.2858	.2058
7	.1905	.0381		.0381	.0381	.2858	.3429
8	.2286	.0381		.0381	.0381	.2858	.3429
9	.0381	.3239		.5716	.5716	.0191	.0343
10	.0191	.2572		.6097	.5716	.0191	.0343
11	.0191	.3772		.6668	.6668	.0171	.0343
12	.0191	.3772	.5716	.6859	.6668		.0343
13	.0191	.4115	.5716	.6859	.6668	.0343	.0343
14	.0191	.4287	.5716	.6287	.6097	.0343	.0343
15	.0191	.4801	.4763	.6668	.5716	.0343	.0343
16	.0191	.4801	.4763	.6668	.5716		.0343
17	.0191	.0171	.0191	.0191	.0191		.0171
18	.0191	.0343	.0191	.0191	.0191	.0514	.0343
19	.0191	.0343	.0381	.0191	.0191	.0171	.0343
20	.0381		.0381	.0191	.0191	.0343	.0343
21	.0191	.0343	.0381	.0191	.0191		.0343
22	.0191	.0343	.0191	.0191	.0191	.0343	.0343
23	.0191	.0343	.0191	.0191	.2858	.1715	.1715
24	.1905	.0191	.0171	.0191	.0191	.2858	.1715
Max	.2286	.4801	.5716	.6859	.6668	.2858	.3429
Min	.0191	.0171	.0171	.0191	.0191	.0171	.0171
Avg	.0865	.1537	.1576	.2318	.2295	.1520	.1051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214504 / 33/11 kV Agoti

Feeder No / Name : 202 / 11 kV Laxmi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	.2477	.3429	.2858	.381	1.5242	1.286
2	1.6194	.2858	.3429	.2858	.381	1.5242	1.286
3	1.6194	.2858	.4287	.2858	.381	1.5242	1.286
4	1.6194	.381	.4287	.2858	.4763	1.5242	1.3717
5	1.6194	.4763	.5487	.4763	.5716	1.7147	1.6289
6	1.6194	.6097	.6516	.5716	.6668	2.0957	1.6289
7	1.8861	.6859	.6516	.6668	.724	2.0957	2.1434
8	2.0957	.7049		.5716	.724	2.191	2.1434
9	.381	2.0005		2.191	2.4958	.5716	.5487
10	.4191	2.3663		2.572	2.7625	.4763	.5144
11	.3239	2.4006		2.6673	2.8387	.4287	.5144
12	.2096	2.4006	2.7625	2.4768	2.7625	.2572	.5144
13	.2667	2.4006	2.5149	2.4768	2.6673	.2572	
14	.2286	2.4006	2.4768	2.3624	2.6673	.2572	.3429
15	.2286	2.4006	2.2862	2.4768	2.572	.2572	.2572
16	.2667	2.4006	2.191	2.4768	2.2862		.2572
17	.3239	.3429	.2858		.381		.3429
18	.4763		.381	.5335	.4763	.4287	.4287
19	.5716	.5487	.5716	.6668	.4763	.5144	.4287
20	.4763	.5487	.5716	.6097	.5716	.5144	.4287
21	.362	.4287	.4763	.4572	.5716	.4287	.3086
22	.3048	.4287	.2858	.4001	.381	.4287	.3086
23	.2477	.3429	.2858	.3239	1.5242	1.286	1.2003
24	1.4289	.5144	.3429	.2858	.3429	1.5242	1.286
Max	2.0957	2.4006	2.7625	2.6673	2.8387	2.191	2.1434
Min	.2096	.2477	.2858	.2858	.3429	.2572	.2572
Avg	.8422	1.1132	.9414	1.1481	1.2535	.9920	.8894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214504 / 33/11 kV Agoti

Feeder No / Name : 203 / 11 kV Talemala Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.7621	.6001	.6668	.6668	.1905	.1715
2	.1905	.7621	.6001	.6668	.6668	.1905	.1715
3	.1905	.7621	.6001	.6668	.6668	.1905	.1715
4	.1905	.8573	.6001	.6668	.6668	.1905	.1715
5	.1905	.9526	.6859	.7621	.7621	.2858	.1715
6	.1905	1.0479	.8573	.7621	.8573	.2858	.2058
7	.1905	1.1812	.8573	.9526	.9526	.2858	.2058
8	.1905	1.2193		.9526	1.086	.2286	.2058
9	1.4289	.2096		.1905	.1905	1.1431	1.286
10	1.5432	.1543		.1905	.1905	1.4289	1.286
11	1.5623	.1029		.1905	.1524	1.286	1.2003
12	1.4861	.1029	.1334	.1143	.1524	1.2003	1.2003
13	1.448	.1029	.0953	.1143	.1143	1.2003	1.2003
14	1.448	.0857	.0953	.1143	.1143	1.2003	1.2003
15	1.4861	.0857	.0953	.1143	.1143	1.2003	1.2003
16	1.4289	.0857	.0953	.1334	.1143		1.2003
17	.1905	.0857	.0953	.1524	.1905		.2058
18	.2096		.1905	.2286	.2477	.2058	.2058
19	.2667	.2058	.2286	.2477	.2477		.2058
20	.2286	.2058	.2858	.2286	.1905		.1886
21	.1905	.2058	.2858	.2286	.1905	.1715	.1715
22	.1905	.2058	.1905	.1905	.1905	.1715	.1715
23	.7621	.6001	.6668	.6287	.1905	.1372	.1715
24	.1905	.7811	.6001	.6668	.6287	.1905	.1715
Max	1.5623	1.2193	.8573	.9526	1.086	1.4289	1.286
Min	.1905	.0857	.0953	.1143	.1143	.1372	.1715
Avg	.6494	.4680	.3929	.4096	.3977	.5692	.5309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION

Feeder No / Name : 201 / 11 KV REDANI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.6668	.6535	.6001	.6535	1.1022	.8173
2	.9907	.6602	.6535	.6135	.7545	1.1736	.8173
3	1.1069	.6668	.7468	.6859	.7621	1.1603	.9202
4	1.1336	.7545	.8402	.7011	.7545	1.3108	.9431
5	1.2146	.8059	.8402	.763	.8402	1.4575	1.0059
6	1.5384	.8954	.9431	.964	1.0829	1.7814	1.1831
7	1.8623	1.0269	1.1431	1.0288	1.1431	1.9204	1.5775
8	2.3482	1.0974		1.0288	.9526	2.3148	1.7747
9	.9526	1.8842		1.5118	1.8623	.9526	.9145
10	.6668	2.4006		2.2119	2.2939	.763	.8573
11	.5716	2.4291	2.1091	2.1548	2.2939	.5144	.7621
12	.381	2.4577	1.9805	2.13	1.6575	.4287	.4763
13	.2858		1.9319	2.1795	1.9662	.3429	.381
14	.2858		1.9566	2.2377	1.989	.3429	.2143
15	.2858		1.8814	2.13	1.9433	.2572	.2858
16	.2858		1.7309	2.0348	1.9433	.2572	.3506
17	.381		.2629		.4049	.4382	.3658
18	.6668	.6401	.6001	.6668	.5935	.6135	.543
19	.9335	.8402	.763	.9335	.8192	.7888	.7392
20	.8402	.9431		.8573	.9335	.823	.8316
21	.7606	.7468		.8402	.8145	.7716	.6097
22	.7545	.6535		.7468	.7468	.7011	.7621
23	.6535	.7468		.6535	1.0174	.8545	.9831
24	.9659	.6668	.6268	.6135	.6535	1.1145	.8545
Max	2.3482	2.4577	2.1091	2.2377	2.2939	2.3148	1.7747
Min	.2858	.6401	.2629	.6001	.4049	.2572	.2143
Avg	.8690	1.1044	1.1567	1.2299	1.2032	.9244	.7904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION

Feeder No / Name : 202 / 11 KV BORATWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	1.1022	.9012		1.0059	.1524	.1715
2	.2858	1.0898	.9945		.9945	.1543	.1715
3	.2858	1.1469	1.1469		1.065	.2286	.1753
4	.381	1.2289	1.2146		1.0526	.2286	.2572
5	.381	1.2955	1.3108		1.1203	.3163	.3429
6	.4763	1.3603	1.5432		1.186	.4239	.3506
7	.4763	1.5203	1.5203		1.2193	.4668	.4287
8	.4763	1.6404			1.4232	.4191	.4287
9	1.6004	.2743			.2	1.2955	1.3146
10	1.829	.1638			.1296	1.3003	1.9662
11	2.13	.0791	.0714		.1143	1.446	2.2377
12	2.1091		.0638		.0857	1.4175	1.8023
13	2.1348		.0381		.0667	1.5089	1.9662
14	2.0805				.0667	1.3717	1.7966
15	2.0481				.0762	1.4175	1.8404
16	1.8842			.0819	.0648	1.3832	1.7966
17	.1905				.0648	.1829	.1276
18	.2801	.1696			.1524	.2572	.1486
19	.3772	.1638			.2286	.3429	.2229
20	.2829	.2572			.2286	.3506	.2229
21	.2801	.2658			.2286	.3429	.1524
22	.2858	.1715			.2286	.2743	.1524
23	1.0288	.8173		.1334	.1429	.2572	.1696
24	.2858	1.0277	.8383		1.0174	.1486	.1829
Max	2.1348	1.6404	1.5432	.1334	1.4232	1.5089	2.2377
Min	.1905	.0791	.0381	.0819	.0648	.1486	.1276
Avg	.9115	.7652	.8766	.1077	.5068	.6536	.7678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION

Feeder No / Name : 203 / 11 KV REDANI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1867	.1829	.1867	.1829	.1753
2	.1867	.2801	.1886	.1886	.2772		.1715
3	.2801	.2829	.1867	.1829	.3734	.2801	.1715
4	.2829	.2829	.2772	.2829	.3734	.2772	.2658
5	.3772	.3734	.3734	.3506	.3772	.3696	.3506
6	.3772	.462	.3734	.3772	.4668	.4668	.3582
7	.3772	.3734	.4715	.3772	.3734	.4715	.3544
8	.2715	.2801		.3772	.3734	.4715	.3658
9	.181	.2715		.2629	.2515	.3772	.2829
10	.181	.1658		.1867	.1715	.3772	.2829
11	.1829	.1638	.1848	.1886	.1867	.3734	.1886
12	.2772			.2801	.1886	.2829	
13	.2743			.2801	.1791	.1867	
14	.2801			.1867	.1867	.1886	.1829
15	.1867		.2601	.1867	.1829	.1886	.1867
16	.1867		.1867	.1715	.2429	.1886	.2743
17	.1848		.2629		.2801	.2829	.181
18	.3772	.2801	.1867	.2772	.3658	.2829	.3658
19	.4715	.4668	.3772	.4668	.4668	.3772	.3772
20	.3696	.3734		.4668	.4668	.3772	.3772
21	.2829	.2772		.3734	.3734	.3658	.2801
22	.1867	.2801		.2829	.2772	.2829	.2801
23	.2829	.1886		.2801	.2801	.2829	.1886
24	.1886	.1886	.1867	.1715	.2715	.1867	.1772
Max	.4715	.4668	.4715	.4668	.4668	.4715	.3772
Min	.181	.1638	.1848	.1715	.1715	.1829	.1715
Avg	.2681	.2877	.2645	.2775	.2989	.3096	.2654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 301 / BHIGWAN

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8714	.2321		.1829	.2401	4.593	4.513
2	3.7494	.2321		.1829	.2134	4.593	4.4201
3	3.6275	.2321		.1829	.2401	4.6235	4.3419
4	3.5361	.2321		.1829	.2401	4.7615	4.2809
5	3.597	.2321		.2134	.2401	4.9497	4.5481
6	3.719	.2652	.6401	.2439	.2743	5.1631	5.237
7	4.4201	.8444	.6706	.6706	.983	6.2925	6.1607
8	5.487	1.0631	.7316	.884	1.1393	7.2176	7.3282
9	5.8527	4.6372	3.0483	4.9993	5.269	5.234	5.4992
10	.2931	8.2361	6.7063	8.943	9.1556	.8626	.7925
11	.2652	8.9057	9.9985	9.7798	2.8178	.2622	.4877
12	.2321	6.7978	10.0595	9.6723	9.8727	.2294	
13	.2321	7.8608	8.8707	9.555	9.9946	.192	
14	.2321	10.612	9.5717	6.6758	9.5412	.2012	.1829
15	.2321	10.0123	9.3584	3.754	8.6823	.1898	.1829
16	.2321	9.9318	9.1145	9.0208	8.2781	.192	.2134
17	.2321	7.2314	6.432	5.5404	5.6886	.2561	.3658
18	.2931	.2248	.1829	.8573	.2984	.2866	.2439
19	.9107	.8383	.7621	1.1088	1.0021	.346	.2744
20	.8418	1.0182	.884	1.0669	.9663	.3181	.3353
21	.3235	.8947	.4573	.5754	.9027	.2294	.6097
22	.2321	.192	.5792	.2401	.6589	.2294	.2134
23	.2321	.2214	.2134	.2058	3.2903	2.9279	3.1093
24	1.4746	.2321		.2134	3.4713	4.5626	4.5435
Max	5.8527	10.612	10.0595	9.7798	9.9946	7.2176	7.3282
Min	.2321	.192	.1829	.1829	.2134	.1898	.1829
Avg	1.8383	3.3825	4.3490	3.1230	3.4775	2.4464	2.6311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 302 / 22 kv KHANOTA BHIGWAN SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.1331	2.1871	1.6156	2.1948	2.271	11.1439	10.8559
2	7.0416	2.2176	1.6156	2.1948	2.271	11.0219	10.7339
3	6.9197	2.2786	1.6766	2.2862	2.332	11.0219	
4	7.0111	2.5892	1.8595	2.4386	1.9281	11.3778	
5	7.316	3.0193	2.1643	2.8655	3.1245	11.9029	
6	7.6818	3.5421	2.6216	3.5665	3.7914	12.6109	
7	8.5048	3.786	2.8045	3.9628	4.1343	13.3913	
8	9.2669	3.4439	2.8349	3.8409	3.8942	14.1061	
9	10.2043	7.3008	3.3227	8.4133	8.5924	10.6912	.5376
10	2.3994	15.6166	11.9189	15.9077	10.8215	2.3373	.7316
11	1.9376	17.0767	17.8326	14.2829		1.9422	2.1643
12	1.4194	12.6505	12.9249	17.2253	11.4007	1.7909	1.9509
13	1.2951	10.6615	17.2534	10.3643	10.9683	1.422	1.7375
14	1.2951	18.7281	17.4364	17.5515	16.7272	1.3382	1.3413
15	1.2951	18.3967	17.4364	17.2093	16.7577	1.2681	1.3413
16	1.3256	18.2404	16.4609	16.8884	14.7752	1.4251	1.0059
17	1.4544	12.8944	11.8884	12.018	12.0896	1.6705	1.8595
18	2.2481	.7754	1.9814	2.2557	2.0042	1.922	2.0729
19	3.0826	3.3207	2.9874	3.1017	3.0864	2.9386	2.8654
20	3.2632	3.4179	3.2312	3.3455	3.2015	3.184	3.1093
21	2.955	3.2434	3.1093	3.2503	3.1359	3.091	2.8959
22	2.7382	3.0182	2.8654	2.9568	2.979	2.8395	2.774
23	2.5529	2.6456	2.5606	2.6102	7.8258	6.3588	7.5293
24	4.3286	2.2786	1.6156	2.2253	8.0552	10.9	11.1302
Max	10.2043	18.7281	17.8326	17.5515	16.7577	14.1061	11.1302
Min	1.2951	.7754	1.6156	2.1948	1.9281	1.2681	.5376
Avg	4.3612	7.2221	6.7508	7.2065	6.7899	6.3207	3.7020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 303 / Bhigawan GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0594	1.1176	.2103	1.0548	1.1287	1.0604	1.0296
2	.0594	1.116	.2119	1.0532	1.1256	1.0573	1.025
3	.0594	1.1145	.2119	1.038	1.1165	1.0573	1.0296
4	.0655	1.6335	.2119	1.1614	1.3398	1.504	1.2117
5	.0732	1.9783	.2256	1.6323	1.5547	1.8473	1.5074
6	.0945	2.3354	.2667	2.4905	2.1826	2.2721	2.1559
7	.125	2.766	.3673	2.5941	2.7846	2.6753	2.7351
8	.125	3.1188	.503	2.652	2.8067	2.7908	2.6742
9	2.2375	2.4935	.4999	2.111	2.2984	2.4174	2.2542
10	2.2958	1.6941	.0945	1.3931	1.8099	2.2558	2.2207
11	2.1124	1.5706	1.1187	1.342	1.3032	2.0888	2.0195
12	1.943	.0564	1.1309	1.3405	1.3337	1.9521	1.7361
13	1.8359	1.3923	1.1218	1.0784	1.0445	1.9654	1.6308
14	1.5749	1.1488	.9968	.0564	.966	1.7207	1.4678
15	1.6671	1.1518	1.0243	1.1911	1.3325	1.5798	1.4358
16	1.6102	1.1797	1.0577	1.0647	1.2872	1.6995	1.4997
17	1.7737	1.5981	1.2925	1.4014	1.5569	1.8694	1.5577
18	1.5718	1.7295	1.544	1.7071	1.8362	1.7413	1.3718
19	1.9795	2.1376	1.9128	1.9639	2.2043	2.0942	1.6979
20	1.9132	1.9479	1.7375	1.8092	2.1011	1.9452	1.4601
21	1.6317	1.6892	1.4267	1.5066	1.8302	.1768	1.265
22	1.3637	1.3626	1.169	.0838	1.4499	1.3748	1.1019
23	1.1198	1.0803	1.0212	1.1127	1.1466	1.033	.916
24	1.0951	1.1343	1.1751	1.0562	.9488	1.0619	1.025
Max	2.2958	3.1188	1.9128	2.652	2.8067	2.7908	2.7351
Min	.0594	.0564	.0945	.0564	.9488	.1768	.916
Avg	1.1828	1.6061	.8555	1.4123	1.6037	1.7184	1.5845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 306 / 22 KV KUMBHARGAON AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.6292		1.829	1.7101	.2667	.192
2		2.6292		1.829	1.6712	.2667	.192
3		2.6292		1.829	1.6712	.2667	.192
4		2.6673		1.829	1.7368	.2667	.2241
5		2.7054		1.89	1.8351	.3048	.2214
6		2.7054		2.0729	1.9662	.3429	.2561
7		3.1626		2.3472	2.13	.3429	.2267
8		3.2769		2.2862	2.4249	.3429	.2561
9	3.5391	.3048		.2134	.2401	3.0483	3.1687
10	4.6487	.1898		.2058	.2667	3.5105	3.5665
11	4.5725	.1898	.2134	.2058	.2667	3.6808	3.7494
12	4.6487		.1829	.2058		3.7449	3.4141
13	4.8773	.1898	.1829	.2058		3.6923	3.3532
14	4.5344	.192	.1829			3.7685	3.2617
15	4.3439	.1943	.1829	.2058	.2667	3.8729	3.3836
16	4.039	.1898	.1829	.2058	.2667	3.5719	3.3532
17	.2667	.1898	.1843	.2058	.2667	.1943	.2439
18	.2667	.2241	.2134	.2058	.3048	.2241	.3048
19	.3048	.2241	.2439	.2401	.3048	.2241	.3048
20	.3048	.2214	.2439	.2058	.3048	.2267	.3048
21	.2667	.2214	.2134	.2058	.2667	.1943	.3048
22	.2667	.1898	.2134	.2058	.2667	.1943	.2743
23	2.6292	1.7924	1.89	1.7833	.2667	.1898	.2439
24	.2058	2.6292		1.89	1.6712	.2667	.192
Max	4.8773	3.2769	1.89	2.3472	2.4249	3.8729	3.7494
Min	.2058	.1898	.1829	.2058	.2401	.1898	.192
Avg	2.4822	1.2847	.3331	.9697	.9574	1.3752	1.2993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 201 / TAWASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3031	1.1035	.4725	.4725	1.9814	1.185	1.4442
2	1.3074	1.1915	.6325	.6325	2.0995	1.1279	1.3565
3	1.5832	1.387	.8383	.8383	2.2367	1.2384	1.5546
4	1.7471	1.5166	.9069	.9374	2.2405	1.4708	1.9186
5	1.8437	1.6121	1.0364	.9983	2.5682	1.7338	2.0442
6	1.8625	1.6385	.9755	.9526	2.4844	1.9547	2.0443
7	1.7071	1.4784	.6325	.6249	2.2805	1.8347	1.7852
8	1.6457	***	1.6004	1.3489	2.3929	1.4174	1.7109
9	1.0507	1.8519	1.6461	1.3032	2.4006	1.0784	1.0936
10	.9581	1.9509	1.6537	1.6385	2.4539	.8706	.9087
11	.7103	1.9814	1.768	1.7071	2.353	.7983	.8065
12	.8398	2.05	1.7909	1.8138	2.0805	.7335	.7434
13	.8671	3.7609	1.8519	1.8214	1.928	.7716	.7559
14	1.0544	3.5341	1.7604	1.5699	1.8614	.884	.9541
15	1.1382	3.2808	1.547	1.4327	1.7871	1.0193	1.1294
16	1.8164	2.8902	1.0212	1.0822	2.4349	1.3145	1.579
17	1.8782	1.6346	1.2727	1.2803	1.7413	1.7623	1.8974
18	1.877	1.688	1.2879	1.2955	2.0062	2.0252	1.9826
19	1.864	1.77	1.0288	1.0364	1.991	2.0157	1.9799
20	1.5165	1.5916	.724	.7392	1.6499	1.5604	1.744
21	1.3877	1.3986	.5868	.5716	1.3089	1.3032	1.509
22	1.2819	1.2549	.503	.4954	1.1221	1.1412	1.3239
23	1.3516	1.2056	.4572	.4725	1.0726	1.1889	1.448
24	1.3162	1.2605	.964	.9793	.8611	1.0021	1.5108
Max	1.8782	104.8074	1.8519	1.8214	2.5682	2.0252	2.0443
Min	.7103	1.1035	.4572	.4725	.8611	.7335	.7434
Avg	1.4128	6.1600	1.1233	1.0852	1.9724	1.3097	1.4677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 202 / SAPKALWADI (THORATWADI SINGLE PHASING
OLD) Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6375	.4084	.1296	.1143	.1543	.1543	.3086
2	.6097	.4694	.1753	.1677	.1715	.1543	.3086
3	.6287	.5755	.2591	.2667	.2058	.1715	.3086
4	.6726	.5898	.2896	.3048	.2743	.2743	.4458
5	.7159	.663	.3277	.3429	.3086	.3429	.4801
6	.7329	.6878	.3506	.3429	.3429	.3944	.5316
7	.7316	.622	.2439	.2439	.3772	.463	.5658
8	.8216	1.2572	.6706	.5335	.3772	.4115	.6859
9	.5175	1.3546	.7087	.6859	.463	.3429	.3601
10	.4088	1.5299	.7316	.6935	.5487	.2572	.2572
11	.3681	1.5603	.7621	.724	.6001	.1886	.1698
12	.3481	1.5928	.7926	.7087	.6344	.12	.132
13	.3661	1.5527	.823	.7545	.6859	.0857	.1132
14	.439	1.4041	.8154	.7011	.6173	.0857	.1132
15	.4702	1.387	.7392	.663	.583	.0857	.1132
16	.836	1.307	.442	.4496	.4115	.1029	.1132
17	.8781	.7449	.4725	.4725	.2058	.1543	.1698
18	.7554	.6763	.4268	.4572	.2401	.2229	.2263
19	.7318	.682	.3201	.3658	.3429	.3086	.3018
20	.6295	.6371	.2134	.2439	.2915	.2743	.3018
21	.5689	.55	.1905	.1753	.2572	.2401	.2452
22	.5348	.5047	.1524	.1524	.2229	.2058	.2075
23	.612	.4858	.1219	.1372	.2229	.2401	.3224
24	.612	.6196	.2762	.2934	.1543	.1715	.2915
Max	.8781	1.5928	.823	.7545	.6859	.463	.6859
Min	.3481	.4084	.1219	.1143	.1543	.0857	.1132
Avg	.6095	.9109	.4348	.4164	.3622	.2272	.2947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 203 / 11 kV Jamb

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4652	.6562	.3125	.2896	.4115	.4458	.2743
2	.541	.671	.2858	.2477	.4801		
3	.7039	.6287	.2172	.2362	.583	.5144	.2743
4	.8401	.78	.2743	.2896	.6859	.5487	.3601
5	.967	.9084	.3048	.2743	.7545	.6516	.4287
6	1.0253	1.0139	.2858	.282	.823	.7202	.463
7	.9373	1.038	.1829	.1791	.8573	.7888	.5316
8	1.4586	.8764	.1181	.1067	.9945	.9602	.6859
9	1.4049	1.0021	.0686	.0686	.4801	1.0631	1.1831
10	1.9577	.6687	.0648	.0648	.4801	1.286	1.4232
11	1.9349	.5011	.0686	.061	.2572	1.3717	.9496
12	2.0111	.4229	.08	.0648	.2058	1.4403	
13	1.9822	.4	.0953	.1105	.1715	1.4575	1.2209
14	1.9517	.4801	.1448	.1296	.1715	1.406	1.2071
15	1.9033	.6592	.2134	.1829	.1715	1.3717	1.2071
16	1.7166	.6935	.6097	.5525	.2058	1.3717	1.2071
17	.7857	1.0917	.6401	.6097	.2572	.3601	.2427
18	.9472	1.2517	.5982	.4877	.4115	.3601	.415
19	.9879	.9653	.4534	.3887	.5658	.5144	.5847
20	.7868	.7754	.4001	.3086	.5144	.4801	.4904
21	.6127	.6089	.3696	.2934	.4287	.4115	.415
22	.454	.4691	.3582	.282	.3429	.3429	.3395
23	.4275	.6127	.3582	.2896	.4115	.3086	.3018
24	.4275	.4199	.9755	.8421	.4115	.4115	.2743
Max	2.0111	1.2517	.9755	.8421	.9945	1.4575	1.4232
Min	.4275	.4	.0648	.061	.1715	.3086	.2427
Avg	1.1346	.7331	.3117	.2767	.4615	.8081	.6582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 204 / 11 KV UDMAI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.072	.0532	.0419	.0381	.0343	.0171	.0343
2	.072	.0532	.0381	.0381	.0343	.0171	.0343
3	.1025	.057	.0381	.0419	.0343	.0343	.0343
4	.1063	.1063		.0724	.0343	.0514	.0343
5	.1101	.1063		.0762	.0343	.0343	.0343
6	.1025	.0834	.0457	.0686	.0343	.0343	.0171
7	.0796	.0684	.0381	.0495	.0343	.0343	.0343
8	.0682	.0834	.0495	.0457	.0343	.0343	.0343
9	.0682	.0762	.0381	.0305	.0343	.0343	.0171
10	.0682	.0686	.0191	.0381	.0514	.0514	.0343
11	.0678	.0724		.0381	.0514	.0343	.0566
12	.0716	.0686		.0419	.0343	.0343	.0377
13	.0716	.0724		.0381	.0343	.0343	.0377
14	.0837	.0991	.061	.0533	.0343	.0343	.0377
15	.0875	.0991	.0724	.0686	.0171	.0343	.0377
16	.083	.0686	.0343	.0648		.0343	.0377
17	.0532	.0686	.0305	.0495	.0343	.0343	.0377
18	.072	.0686	.0343	.0381	.0343	.0343	.0377
19	.0909	.0686	.0343	.0419	.0343	.0343	.0566
20	.0909	.0909	.0343	.0419	.0514	.0343	.0566
21	.0909	.0909	.0343	.0381	.0514	.0514	.0566
22	.072	.0909	.0343	.0419	.0343	.0343	.0377
23	.072	.072	.0343	.0419	.0343	.0343	.0377
24	.072	.072	.0686	.0762	.0343	.0171	.0343
Max	.1101	.1063	.0724	.0762	.0514	.0514	.0566
Min	.0532	.0532	.0191	.0305	.0171	.0171	.0171
Avg	.0804	.0774	.0411	.0489	.0365	.0343	.0379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 205 / KURAWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.44	1.6845	.9069	1.9852	.7545	.8916	.583
2	1.6068	1.7147	.8764	1.9151	.8573	.9259	.583
3	1.7513	1.6834	.8916	2.5581	.9259	1.0631	.6516
4	1.9182	1.9464	.9678	2.2101	1.0631	1.166	.8402
5	2.1167	2.2025	1.0974	2.4329	1.2003	1.2003	.9602
6	2.1609	2.2805	1.0517	2.4615	1.3375	1.286	1.1488
7	1.8023	2.1175	.7164	2.178	1.4575	1.3546	1.2689
8	2.8115	1.8267	.602	2.05	1.5089	1.4918	1.1317
9	3.5473	1.4323	.4649	.9716	.6859	1.6804	1.7661
10	3.7052	1.0736	.381	1.0041	.6516	1.749	2.1776
11	3.8591	.8783	.4039	.9572	.583	1.8004	1.1271
12	4.0725	.7925	.4344	.9062	.5144	1.8519	1.704
13	4.103	.801	.5182	.5563	.4287	1.8861	1.704
14	4.0627	1.0555	.663	1.0608	.3772	1.8861	1.7238
15	3.7235	1.4049	.884	1.2079	.3429	1.8861	1.6907
16	3.1703	1.5203	1.6004	1.7348	.4801	1.8004	1.7101
17	1.7998	2.054	1.8747	2.1593	.6344	.583	.5041
18	2.0561	2.2959	1.7299	2.2405	.5658	.7373	.7167
19	2.204	2.4301	1.4175	2.4007	1.1317	1.0802	1.0374
20	1.9303	2.1148	1.1355	2.0401	.9945	.9602	.9431
21	1.6354	1.7995	.9831	1.7973	.8573	.8402	.8299
22	1.4592	1.4929	.945	1.5497	.7373	.6859	.7545
23	1.387	1.5203	.9374	.8688	.823	.6516	.679
24	1.3718	1.3416	1.8709	1.9041	.6859	.9602	.6001
Max	4.103	2.4301	1.8747	2.5581	1.5089	1.8861	2.1776
Min	1.3718	.7925	.381	.5563	.3429	.583	.5041
Avg	2.4873	1.6443	.9731	1.7146	.8166	1.2674	1.1182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 206 / 11KV THORATWADI (NEW) SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6058	.7213	.381	.3353	.4115	.3772	.2743
2	.7347	.7362	.3658	.3201	.4801	.3772	.3086
3	.9019	.7739	.4191	.4039	.5487	.4458	.3086
4	1.0158	.9408	.5411	.5182	.6173	.4801	.4458
5	1.1523	1.1149	.5868	.5868	.6859	.5487	.5487
6	1.2022	1.1828	.5868	.5868	.7202	.583	.6516
7	.9854	1.1054	.4344	.4344	.7545	.6344	.7545
8	1.6019	.912	.2439	.2896	.9431	.7888	.6516
9	2.0195	.6764	.1905	.1829	.4287	.9602	.8916
10	2.3209	.4534	.1524	.1372	.2915	1.0802	1.166
11	2.364	.3601	.1524	.1753	.2401	1.2346	1.166
12	2.5263	.2972	.1905	.1829	.2229	1.3375	1.1869
13	2.572	.3658	.2134	.2591	.1372	1.4746	1.073
14	2.4531	.4401	.3048	.3048	.1543	1.3889	1.0395
15	2.303	.6402	.4725	.4725	.1715	1.2346	1.0059
16	1.7413	.7926	.9755	.9526	.2058	1.166	.9665
17	1.0422	1.0402	1.2193	1.1965	.3086	.3086	.2614
18	1.1999	1.1507	.9755	.9221	.4115	.3601	.4527
19	1.1907	1.1507	.7697	.7316	.5144	.5144	.6036
20	.8642	.9549	.5563	.4801	.4458	.4115	.5281
21	.6744	.6857	.4496	.3582	.3601	.3429	.3772
22	.5457	.5304	.4268	.3506	.3086	.2743	.3206
23	.4927	.73	.4344	.3582	.3086	.2743	.3018
24	.5228	.4927	.964	.9145	.4115	.3429	.2572
Max	2.572	1.1828	1.2193	1.1965	.9431	1.4746	1.1869
Min	.4927	.2972	.1524	.1372	.1372	.2743	.2572
Avg	1.3764	.7604	.5003	.4773	.4201	.7059	.6476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 201 / bhawaninagar SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0193	.7392	.7811	.3429	.415	1.1174	1.1336
2	1.1289	.7849	.8573	.3429	.3961	1.1498	1.166
3	1.2375	.823	.9104	.3772	.415	1.1984	1.166
4	1.4108	1.0059	1.0776	.4115	.4527	1.2955	1.2308
5	1.4727	1.1088	1.2557	.5144	.547	1.3927	1.2955
6	1.4432	1.1965	1.3272	.6516	.6602	1.4413	1.3603
7	1.307	1.0822	1.1319	.6344	.7167	1.5061	1.5384
8	1.3603	2.4253	1.4861	.6516	.7167	1.6842	1.7004
9	.7773	1.8823	.9907	1.7166	1.8461	.6602	.5487
10	.221	3.3074	2.1643	1.9919	2.0081		.4715
11	.5944	3.2303	2.271	2.1052	1.9433	.3086	.3772
12	.4972	3.2322	4.1077	1.9595	1.9109	.2743	.2641
13	.4078	3.1665	4.1895	2.0081		.2229	.1886
14	.663	3.296	4.2943	1.9595	1.8785	.2058	.2075
15	.7792	3.1436	3.9819	1.7976	1.8138	.1715	.1886
16	1.5547	2.4216	2.9702	1.8461	1.6842	.2229	.2263
17	1.4594	1.0563	.9907	.2829	.3018	.2572	.3018
18	1.5165	1.2597	1.1222	.4338	.5281	.3772	.4527
19	1.3832	1.2357	1.2117	.7167	.5658	.5487	.6036
20	1.3032	1.0801	1.0117	.6036	.6036	.5658	.5093
21	1.206	.9172	.884	.5281	.547	.4801	.4527
22	1.1298	.8414	.8097		.4527	.4115	.4527
23	1.0783	.7771	.7506		1.004	1.1336	1.1336
24	1.0783	.381	.7087		1.0688	1.1336	
Max	1.5547	3.3074	4.2943	2.1052	2.0081	1.6842	1.7004
Min	.221	.381	.7087	.2829	.3018	.1715	.1886
Avg	1.0845	1.6831	1.7203	1.0417	.9772	.7721	.7378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 202 / Shindewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	11-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.421	.3429	
2	.5182	.3772	
3	.5506	.4115	
4	.6154	.4801	
5	.6478	.5144	
6	.7125	.583	
7	.8745	.7202	
8	1.1336	.7202	.6859
9	.6173		
10		.8421	
11	.3258	.8421	
12	.2058	.8421	
13	.1715	.8421	
14	.1715	.8421	
15	.1372	.7773	
16	.1886	.7773	
17	.2743	.2641	
18	.5487	.415	
19	.5487	.7167	
20	.5487	.6413	
21	.463		
22	.3772		
23	.3772		
24	.3429		
Max	1.1336	.8421	.6859
Min	.1372	.2641	.6859
Avg	.4683	.6290	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 203 / Kazad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	1.427	1.6508	.6478	.7611	.4534	.5487
2	1.1202	1.2289	1.5622	.6478	.8097	.4287	.5487
3	1.185	1.3517	1.6175	.6802	.8097	.3944	.5487
4	1.2879	1.4737	1.9119	.7449	.8421	.3258	.583
5	1.4784	1.627	2.0318	.8421	.8745	.3086	.7202
6	1.507	1.5213	1.9928	1.0364	.9555	.3429	.9602
7	1.6461	1.4671	1.7909	.4458	1.2308	.6173	1.1145
8	2.1129	1.5013	.2972	1.3927	1.4413	1.0974	1.0631
9	2.1072	.2743	.2515		.7167	1.2955	1.4251
10	1.1965	.9004	.2439				1.4899
11	2.271	.7724	.2743		.679	1.5546	1.6194
12	2.2872	.6066	.5791		.3772	1.5546	1.5546
13	2.3091	.7366	.7087			1.4575	1.3603
14	2.3681	.893	.8516		.3206	1.3765	1.2793
15	2.3224	1.1405	1.0517		.3018	1.2955	1.2955
16	2.0653	1.6282	2.1947		.3772	1.4575	1.1984
17	1.6499	1.7217	2.1528		.5281	.3772	.3961
18	1.8443	1.5783	1.9357		.7167	.6344	.5506
19	1.7223	1.6129	2.0881		1.0185	.8916	.9242
20	1.6537	1.3855	1.7356			.9431	.8676
21	1.368	1.2113	1.4727		.7733	.823	.8865
22	1.2613	1.166	1.2993	.7733	.4527	.7202	.7922
23	1.145	1.1003	1.4632	.7611	.6036	.6173	.7167
24	1.1374	.3963	1.5204	.7611	.5658	.5487	
Max	2.3681	1.7217	2.1947	1.3927	1.4413	1.5546	1.6194
Min	.8954	.2743	.2439	.4458	.3018	.3086	.3961
Avg	1.6642	1.1968	1.3616	.7939	.7217	.8485	.9758

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 204 / WADACHA MALA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3887	.421	.421	.2915	.3429	.3429
2		.421	.421	.4534	.2915	.3086	.3772
3	.2743	.421	.4534	.4858	.3239	.2915	.4115
4	.3086	.4534	.4858	.4858	.3887	.2572	.4458
5	.4115	.4858	.5182	.5487	.4858	.3429	.5144
6	.5316	.5182	.5506	.5506	.7611	.4458	.6173
7	.6516	.6802	.8259	.8097	.8745	.5144	.6687
8	.6001	1.0202		.9878	.8745	.6344	.5658
9	.7935			.4904	.5093	.5992	.7287
10		.2829		.3395	.3395		
11	.7773	.2263		.2263	.1943	.9555	.7611
12	.7611	.1509	.1886	.1886	.2075	.9393	.7449
13	.7449	.1698	.1715	.2075		1.004	.583
14	.7125	.1509	.1543	.1698	.1698	.9069	.7287
15	.7125	.1509	.1543	.1886	.1509	.8421	.7287
16	.7287	.1509	.1886	.1886	.2075	.8745	.7611
17	.2572	.1509	.2058	.2075	.2641	.2058	.2263
18	.4287	.3584	.4115	.3018	.3206	.3086	.3772
19	.4458	.6413	.5487	.5847	.4338	.5316	.6036
20	.5658	.5847	.5144	.6036	.5658	.5144	.547
21	.5144	.5658	.4801	.547	.5281	.5144	.4904
22	.4801	.5281	.4287	.4904	.4904	.4287	.4527
23	.3887	.4049	4.2591	.2915	.4527	.3772	.415
24	.3887		.421	.2915	.415	.3429	
Max	.7935	1.0202	4.2591	.9878	.8745	1.004	.7611
Min	.2572	.1509	.1543	.1698	.1509	.2058	.2263
Avg	.5466	.4048	.5901	.4192	.4148	.5427	.5496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 205 / LAKADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.2743	.3018	.2743	.3395	.6478	.6802
2	.6964	.3086	.3018	.2743	.3395	.6964	.6802
3	.7611	.3086	.3395	.3086	.3584	.7287	.7449
4	.8259	.3429	.3395	.3086	.3772	.8097	.8421
5	.9717	.3429	.415	.3429	.3772	.9393	.9069
6	1.0364	.3944	.4527	.3429	.415	1.1174	1.004
7	1.1984	.4458	.5281			1.2631	1.2146
8		.4458		.4287	.4527	1.3279	1.4575
9	.4115			1.2631	1.3279	.4115	.4115
10		1.7328			1.4899		
11		1.9109		2.0559	1.6194	.2743	.3584
12	.2229	2.0405	1.6518	1.5384	1.5708	.1886	.2641
13	.2058	1.7166	1.7004	1.6032		.1543	.1886
14	.1372	1.6356	1.6518	1.4737	1.4737	.12	.1886
15	.1543	1.668	1.3927	1.3765	1.3765	.1029	.132
16	.1543	1.4899	1.1984	1.2955	1.247	.1715	.2263
17	.1543	.1509	.1372	.2075	.1619	.1886	.2641
18	.3772	.3206	.2743	.3395	.3018	.2915	.3772
19	.3772	.4527	.3944	.4527	.3395	.3429	.4527
20	.3429	.415	.3429	.3772	.3395	.3429	.415
21	.3086	.3772	.3086	.415	.3018	.3086	.3772
22	.2743	.3395	.2743	.3395	.583	.2743	.3772
23	.2743	.3018	.2743	.3395		.6478	.7773
24	.2743		.2743	.3395	.6154	.6478	
Max	1.1984	2.0405	1.7004	2.0559	1.6194	1.3279	1.4575
Min	.1372	.1509	.1372	.2075	.1619	.1029	.132
Avg	.4670	.7916	.6277	.7135	.7337	.5216	.5609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 201 / NIMSAKHAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1545	.8459	.3125	.6335	.905	.9955
2	1.2174	.8288	.4039	.6401	.905	.9955
3	1.2651	.9355	.4801	.8145	.985	1.0498
4	1.4593	1.3241	.583	.9955	.964	1.0745
5	1.6308	1.608	.6668	1.267	1.0745	1.0745
6	1.949	1.7528	.6706	1.3432	1.4022	1.5061
7	2.5511	1.5661	.4268	1.5384	2.1434	2.2148
8	2.9703	3.1055	.964	1.3575	2.4539	2.6292
9	1.1393	1.2231	1.1431	1.8861	.7716	1.0974
10	1.004	3.8637	1.1698	2.4006	.7716	.9088
11	.8802	3.7666	1.2574	2.2291	.6859	.823
12	.9336	3.7038	1.3336		.6173	.6001
13	.8573	3.8104	1.3756	1.8861	.6001	.4287
14	.7659	3.8524	1.3489	1.8861	.5144	.3429
15	.9068	3.4674	1.326	1.7147	.5144	.3429
16	1.9738	3.0597	1.0631	1.7147	.4287	.4287
17	1.4518	1.3527	.8345	.7716	.3429	.3658
18	1.8975	1.6023	.8535	.6859	.9259	.5487
19	1.5851	1.5871	.6859	.9431	1.0631	.9145
20	1.488	1.3298	.4877	1.0117	.9431	1.0974
21	1.3565	1.2536	.3849	.9431	.8916	.9145
22	.8783	.3201	.3467	.8573	.7716	.4525
23	.9793	1.0022	.3277	.8573	.9877	.905
24	1.3013	.8269	.9278	2.0576	.823	1.0059
Max	2.9703	3.8637	1.3756	2.4006	2.4539	2.6292
Min	.7659	.3201	.3125	.6335	.3429	.3429
Avg	1.3998	1.9995	.8072	1.3232	.9369	.9465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 203 / 11 KV KHOROCHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3546	1.6004	.8459	.6135	.3658	.3734
2	1.2193	1.385	.7392	.6859	.443	.3696
3	.9449	1.0707	.5944	.7716	.4572	.4572
4	1.0917	1.4194	.7316	.8215	.543	.5487
5	1.3603	1.6575	.9069	.9835	.6268	.6401
6	1.4384	1.7776	.8535	1.1469	.6201	.724
7	1.2194	1.9547	.5411	1.3927	.8859	.724
8	2.5205	.9984	.3887	1.7004	.6335	.6401
9	3.5475	.2896	.2896	.5487	.8573	1.9547
10	3.6751	.5944	.3048	.5144	1.7147	2.4006
11	4.1457	.6325	.3201	.3429	2.0576	2.9835
12	4.199	.6401	.3429		2.0576	2.572
13	4.1647	.6477	.3658	.3429	2.4863	2.0748
14	4.0314	.8611	.4725	.2572	2.4006	2.452
15	3.818	1.0593	.663	.2572	2.4863	2.6406
16	3.2731	2.3472	1.9738	.3429	2.3148	2.572
17	1.0136	2.431	2.111	.3429	.6001	.4477
18	1.4175	2.2786	1.6994	.4801	.6859	.6401
19	1.4251	1.9205	1.387	.7716	.7716	.8145
20	1.3965	1.5737	1.1584	.6001	.6001	.823
21	1.0555	1.3584	1.0822	.5144	.5144	.724
22	.9393	1.3661	.9831	.4287	.4287	.5487
23	1.1736	1.709	.945	.3429	.3658	.5601
24	.9012	1.7166	1.6004	.3086	.3429	.3658
Max	4.199	2.431	2.111	1.7004	2.4863	2.9835
Min	.9012	.2896	.2896	.2572	.3429	.3658
Avg	2.1386	1.3871	.8875	.6309	1.0525	1.2105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 204 / MODERN ENGINEERING WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0274	.0293	.0293
2	.0274	.029	.0293
3	.0274	.029	.029
4	.0274	.0287	.029
5	.0277	.0287	.029
6	.0274	.0283	.0293
7	.0271	.0283	.0293
8	.0268	.028	.029
9	.0274	.0274	.0274
10	.0274	.0274	.0274
11	.0274	.0274	.0274
12		.0274	.0274
13		.0274	.0274
14	.0274	.0274	.0274
15	.0274	.0274	.0274
16	.0274	.0274	.0274
17	.0274	.0274	.0293
18	.0274	.0274	.0293
19	.0274	.0274	.0293
20	.0274	.0274	.029
21	.0274	.0274	.029
22	.0274	.0274	.0287
23	.0274	.0299	.029
24	.0274	.0274	.0293
Max	.0277	.0299	.0293
Min	.0268	.0274	.0274
Avg	.0274	.0279	.0286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 205 / SARAFWADI- 2

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.4973		.5144	.7602	.7682
2	.703	.4973		.6001	.8059	.7973
3	.6859	.4973		.703	.8063	.8507
4	.7716	.4801		.763	.8413	.8596
5	.8402	.6344		.8573	.8573	.8954
6	1.0631	.823		.9326	1.0631	1.0631
7	1.406	.9945		1.0898	1.406	1.5432
8		1.3546		1.0288	1.7147	1.6766
9	.8745			1.1488	.9602	.7716
10	.6173	1.6804		1.4232	.6516	.6859
11	.3944	1.749		1.5432	.463	.5144
12	.3258	1.5775			.3258	.3429
13	.2572	1.5775		1.3375	.2915	.2743
14	.2572	1.5775		1.3717	.2572	.2572
15	.2572	1.5089		1.2346	.2401	.2572
16	.3429	1.4575		1.2689	.4801	.3258
17		.3944		.6173	.4801	.4572
18	.6173	.7373		.6173	.7716	.7164
19	.8402	.9088		.9602	.8573	.823
20	.6687	.7716		.8573	.8059	.7522
21	.5487	.6859		.7888	.7373	.6584
22	.5487	.5487		.6001	.6344	.543
23	.4801			.6859	.7522	.7059
24	.703	.4801	.4973	1.406	.6859	.7442
Max	1.406	1.749	.4973	1.5432	1.7147	1.6766
Min	.2572	.3944	.4973	.5144	.2401	.2572
Avg	.6329	.9743	.4973	.9717	.7354	.7202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 206 / KHOROCHI- 2

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6516		.7973	.7602	.724
2	.6344	.6859		.823	.8238	.8048
3	.6344	.6859		.9088	.8589	.8596
4	.8059	.7716		.9774	.9391	.9774
5	.8916	.9431		1.0059	1.0288	1.1222
6	1.2003	1.0631		1.0898	1.3321	1.4842
7	1.4575	1.0631		1.3413	1.5089	1.5592
8	1.3889	.9774		1.4746	1.5432	1.4022
9	1.5089			1.2174	1.3717	1.6975
10	1.7833	.7373		.7716	1.8176	1.8861
11	1.9033	.4973		.5487	2.0233	2.0748
12	1.9547			.4458	1.9547	2.1262
13	1.6804	.4287		.3944	1.8519	1.6975
14	1.6289	.4287		.4115	1.8861	1.5947
15	1.6289	.4287		.3944	2.1948	1.9204
16	1.5947	.463		.4801	1.9719	1.869
17		.583		.6859	.5316	.567
18	.6173	.9088		.8059	.9259	.985
19	1.3889	1.3546		1.406	1.2517	1.1145
20	1.2346	1.1488		1.1831	1.0802	1.0402
21	.823	.9259		1.0802	.9602	.964
22	.6859	.9088		.8059	.7545	.7087
23	.6859	.8916		.6173	.7133	.6878
24	.703	.6687	.8402	.7545	.6516	.7164
Max	1.9547	1.3546	.8402	1.4746	2.1948	2.1262
Min	.6173	.4287	.8402	.3944	.5316	.567
Avg	1.1951	.7825	.8402	.8509	1.2807	1.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 201 / PILEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1677	.1802	.213	.1638	.1677	.1802
2	.1677	.1829	.1966	.213	.1638	.1829	
3	.0183	.1981	.213	.2294	.1966	.1981	.2294
4	.1981	.2134	.2458	.2294	.213	.2134	.2622
5	.2134	.2439	.2622	.2622	.2458	.2439	.2785
6	.3048	.3353	.3441	.3605	.3277	.3506	.3277
7	.3658	.4115	.3932	.4424	.426	.4115	.426
8	1.1888	.2949		.3932	.3768	.9297	1.3272
9	1.5089	.3441		.3441	.3048	1.5238	1.704
10	1.6613	.2622		.2622	.1677	1.6221	1.6549
11	1.7375	.1802		.1311	.1677	1.6712	1.7204
12	1.6918	.1802		.1147	.1219	1.7204	1.5729
13	1.6309	.181		.1311	.1219	1.704	1.4419
14	1.5851	.1311	.1475	.213	.1372	1.6549	1.3599
15	1.3717	.1311	.1475	.213	.1372	1.6057	1.2452
16	.1524	2.0317	1.8515	1.8187	1.6766		.1638
17		1.8679	1.9662	1.8679	1.6004	.1638	.1638
18	.2286	1.6221	1.704	1.8023	1.5394	.2622	.1966
19	.3353	1.4582	1.4091	1.491	1.1279	.3441	.2949
20	.2743	1.3435	1.278	1.2616	.9907	.3113	.2785
21	.2286	1.2289	.9831	1.0978	.8688	.2622	.2294
22	.2286	.9831	.9339	.9503	.7011	.2294	.213
23	.1829	.9012	.8192	.9175	.6706	.1966	.1802
24	.1802	.1677	.1802	.1966	.1638	.1677	.1802
Max	1.7375	2.0317	1.9662	1.8679	1.6766	1.7204	1.7204
Min	.0183	.1311	.1475	.1147	.1219	.1638	.1638
Avg	.6792	.6276	.7364	.6315	.5255	.7016	.6796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 202 / AKOLE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.2439	.5182	.4696	.4641	.1372	.1646
2	.1372	.2591	.5243	.4858	.4588	.1524	.1848
3	.1372	.2743	.5668	.5079	.4915	.1677	.2195
4	.1524	.2896	.6316	.502	.5571	.1829	.2378
5	.1677	.4115	.6882	.5571	.6226	.1829	.2743
6	.1981	.5792	.9393	.8745	.8356	.1981	.2957
7	.2439	.7011	1.004	.9448	.9012	.2134	.3361
8	.2439	.2957		.2374	.2507	.2286	.2987
9	.1829	.2402		.1928	.1524	.2561	.2801
10	.1677	.1867	.1886	.1578	.1067	.2218	.2241
11	.1372	.1294	.12	.1267	.1067	.1463	.1867
12	.1067	.1307	.1029	.112	.0762	.1463	.168
13		.0914	.0857	.0943	.061	.128	.1494
14	.0762	.0914	.0857	.0943	.0457	.128	.1294
15	.0914	.0914	.0848	.0943	.061	.128	.1307
16	1.326	.1097	.0848	.0943	.061		1.1822
17		.128	.1029	.1132	.12	1.5402	1.186
18	1.2803	.2033	.1475	.1848	.1372	1.247	1.1043
19	.9602	.2378	.2058	.2279	.1981	.9878	.7202
20	.7164	.2561	.1886	.2172	.1981	.9069	.5921
21	.5182	.2195	.1696	.1829	.1829	.639	.4961
22	.3353	.1829	.1543	.1848	.1524	.5506	.4641
23	.2439	.1494	.1543	.1646	.1372	.4915	.4024
24	.1578	.1494	.502	.4915	.4588	.1372	.1646
Max	1.326	.7011	1.004	.9448	.9012	1.5402	1.186
Min	.0762	.0914	.0848	.0943	.0457	.128	.1294
Avg	.3508	.2355	.3295	.3047	.2849	.3964	.3997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 203 / KALAS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7322	.7134	.7576	.7896	.7674	1.589	1.8111
2	1.8076	.7503	.7863	.7952	.7948	1.5615	1.8814
3	1.8907	.7742	.8501	.8566	.8517	1.6484	1.9627
4	2.0827	.8039	.8939	.8702	.9282	1.7551	2.13
5	2.3967	.8611	.9496	.9473	.9835	1.8663	2.3769
6	3.088	.871	1.0048	1.0912	1.0105	2.4181	2.9477
7	3.9895	1.2056	1.166	1.2494	1.2818	3.171	3.7745
8	2.6978	2.3228	1.858	2.1272	2.1243	2.6208	2.6536
9	.7632	4.2668	4.2208	3.9057	3.4857	.7004	.7354
10	.5872	4.8498	4.2498	2.3609	3.931	.2801	.6943
11	.487	4.8278	4.254	3.9277	3.1268	.2054	.4207
12	.3962	2.5133	4.2124	3.8835	3.4743	.1646	.4077
13	.3315	4.619	4.1929	3.7601	3.7236	.4214	.5776
14	.3521	4.4437	3.863	3.7204	3.6503	.3795	.5506
15	.359	4.0284	3.5894	3.498	3.1748	.3639	.5072
16	.3506	2.0043	1.7962	1.7985	1.7665	.3307	.5339
17	.2538	.3525	.4414	.4199	.3948	.3605	.6173
18	.5038	.5601	.592	.6455	.5061	.7118	.6786
19	.8497	.7735	.9099	.9415	.8375	.5967	.8574
20	.8093	.8752	.9181	.916	.8017	.9995	.8227
21	.7529	.8466	.9187	.8608	.7713	.9267	.8143
22	.7697	.8573	.8647	.8593	.7713	.9195	.8311
23	.6729	.7606	.8238	.7697	1.2773	1.4731	1.2955
24	1.2293	.7423	.7522	.7571	1.0646	1.1279	1.755
Max	3.9895	4.8498	4.254	3.9277	3.931	3.171	3.7745
Min	.2538	.3525	.4414	.4199	.3948	.1646	.4077
Avg	1.2147	1.9010	1.8694	1.7396	1.7292	1.1080	1.3182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 204 / KALAS GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3086	.3018	.3142	.3018	.3086	.3206
2	.3086	.3258	.3206	.3734	.3395	.3258	.3206
3	.3429	.3429	.3395	.3881	.3772	.3429	.3395
4	.3353	.3601	.3961	.4251	.415	.3772	.415
5	.4287	.4287	.4668	.4854	.4904	.4458	.5281
6	.5144	.583	.5847	.6348	.5847	.5335	.5658
7	.6173	.423	.6602	.6722	.6602	.6687	.6979
8	.6001	.5658		.6161	.5847	.6516	.6224
9	.5144	.4338	.3547	.4527	.0446	.5658	.4527
10	.3601	.3658	.3475	.3206	.4108		.4338
11	.2915	.2641	.2614	.2641	.3086	.3018	.3206
12	.2572	.2075	.1867	.2075	.1372	.2452	.2263
13	.2229	.1886	.1494	.1698	.1886	.1886	.1698
14	.1715	.1509	.1267	.1698	.1715	.1509	.1698
15	.1886	.1698	.1109	.2075	.1543	.1307	.1509
16	.2058	.2075	.1867	.2263	.2058		.168
17		.2641	.2054	.2263	.2401	.2263	.1886
18	.4115	.3584	.2587	.3772	.2915	.3584	.3018
19	.4973	.5093	.4435	.5281	.5144	.5281	.4338
20	.4801	.4715	.462	.4715	.463	.4904	.3961
21	.3506	.3961	.4251	.415	.4115	.4338	.3584
22	.3429	.3584	.3734	.3584	.3772	.5281	.3584
23	.3086	.3018	.3174	.3018	.3086	.3206	.3206
24	.3206	.3086	.3018	.2987	.3018	.3086	.3206
Max	.6173	.583	.6602	.6722	.6602	.6687	.6979
Min	.1715	.1509	.1109	.1698	.0446	.1307	.1509
Avg	.3636	.3456	.3296	.3710	.3451	.3832	.3575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 205 / AKOLE- 2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.8573	.9831	.9945	.9393	.1829	.2241
2	.1829	.7773	.9717	.9995	.9282	.2229	.2378
3	.2229	.7926	.9995	1.0442	.9282	.2134	.2402
4	.2401	.8078	1.0322	1.0978	.9442	.2286	.2801
5	.2743	.8535	1.0364	1.1305	.9602	.2591	.3142
6	.3048	1.0631	1.3927	1.2955	1.0562	.3429	.3734
7	.4115	1.3108	1.704	1.704	1.5364	.3658	.4854
8	.3429	1.7166		1.9662	1.7604	.4115	.4481
9	1.6766	.2743	.2172	.2881	.3429	1.7368	1.9006
10	2.2119	.2378	.2058	.2241	.2572	1.9433	2.0485
11	2.2805	.1829	.1867	.181	.2058	1.9757	1.9204
12	1.9357	.168	.1372	.1402	.1219	1.9271	1.8884
13	2.0919	.1463	.12	.128	.1372	1.8679	1.6964
14	1.7985	.1463	.1017	.125	.1372	1.7859	1.4685
15	1.869	.1463	.1029	.128	.1219	1.704	1.3763
16	1.6461	.1463	.1187	.1296	.1524		1.3123
17		.2195	.2058	.1677	.2058	.2614	.1619
18	.1715	.3109	.2402	.2865	.2439	.3109	.2294
19	.3429	.3658	.3258	.3582	.3048	.3475	.3292
20	.2743	.3547	.3113	.3658	.2743	.3658	.2865
21	.2439	.3109	.3052	.3018	.2439	.3292	.2835
22	.2439	.2926	.2883	.2641	.2401	.2926	.2347
23	.7926	.9831	.9175	.873	.2058	.2427	.1966
24	.2149	.7621	.9717	.9614	.9393	.1829	.2195
Max	2.2805	1.7166	1.704	1.9662	1.7604	1.9757	2.0485
Min	.1715	.1463	.1017	.125	.1219	.1829	.1619
Avg	.8687	.5511	.5598	.6314	.5495	.7609	.7565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 206 / BORI (BIRANGUDWADI)

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5944	.3506	.3768	.4096	.426	.6001	.852
2	.6097	.3658	.3932	.426	.426	.5487	.8381
3	.6706	.381	.4096	.4588	.4588	.5792	.9012
4	.7926	.381	.4424	.4752	.4915	.5792	.9995
5	.945	.4115	.5079	.4915	.5243	.7926	1.1142
6	1.3413	.4268	.5079		.5243	1.166	1.3272
7	1.9509	.442	.5079	.5407	.5571	1.4784	2.0645
8	.3658	1.1469		1.4091	1.2944	.4268	.5079
9	.3201	2.2939	1.8351	1.8187	1.6613		.4588
10	.2743	2.3594	1.8842	1.9498	1.8515		.3441
11	.2134	2.1956	1.8351	1.704	1.6004		.3277
12	.1981	2.13	1.8515	1.6057	1.4937		.3441
13	.1829	2.0317	1.7859	1.5074	1.387	.2294	.2949
14	.1829	1.9662	1.5565	1.5893	1.326	.213	.3605
15	.1829	1.5402	1.4255	1.4746	1.286	.2056	.3113
16	.1981	.1475	.1802	.1802	.1677		.3277
17		.1802	.2294	.2294	.1829	.2785	.3768
18	.2743	.3441	.2949	.3277	.2401	.4096	.4096
19	.2439	.3932	.4915	.4752	.4268	.4752	.4424
20	.3506	.4424	.4752	.4915	.4268	.5243	.4424
21	.3506	.4588	.4588	.4915	.3963	.5079	.4424
22	.3658	.4424	.4424	.4588	.3963	.5079	.4588
23	.3506	.3932	.426	.426	.3506	.4428	.4588
24	.639	.3506	.3768	.3932	.426	.5335	.852
Max	1.9509	2.3594	1.8842	1.9498	1.8515	1.4784	2.0645
Min	.1829	.1475	.1802	.1802	.1677	.2056	.2949
Avg	.5043	.8990	.8128	.8406	.7634	.5526	.6357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 201 / 11 KV Dhekalwadi
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4161		.431	.3978	.9015	.9015
2		.5028		.4641	.3978	.9015	1.0402
3		.5028		.4973	.4973	1.0402	1.1443
4		.5721		.5636	.6133	1.2309	1.2309
5		.6588		.5967	.6962	1.3696	1.4217
6	1.326	.7975	.8322	.6962	.779	1.5083	1.6644
7	1.6741	.8842	.8669	.7459	.8288	1.6297	1.8724
8	1.7238	.7975		.7459	.7459	1.8378	1.9765
9	.6935	1.6409		1.6991	1.6297	.663	.663
10	.5201	2.0388		1.9938	1.6817	.5201	.5304
11	.4334	2.0553	1.9938	1.9765	1.8031	.3814	.4475
12	.1734	2.0056	1.9071	1.9591	1.7684	.4801	.3481
13	.3814	1.8896	1.8204	1.7857	1.6817	.2427	
14	.2601	1.8233	1.7511	1.7164	1.647	.2427	
15	.2601	1.6907	1.6644	1.6817	1.5604	.2601	.2486
16	.3294	1.6907	1.6991	1.6297	1.5083	.2947	.2818
17	.4681	.3814	.3641	.3641	.3647	.3641	.3481
18	.5548	.4854	.3315	.503	.5138	.3641	.4475
19	.6588	.6762	.6588	.6539	.663	.6415	.5967
20	.6068	.6241	.6241	.5967	.6464	.6068	.5967
21	.5028	.5895	.5967	.5304	.6133	.6068	.547
22	.5028	.5375	.4973	.4973	.5138	.5375	.4973
23	.4508	.4508	.4144	.431	.8495	.8619	.8842
24		.4161	.4161	.3978	.5138	.9015	.8669
Max	1.7238	2.0553	1.9938	1.9938	1.8031	1.8378	1.9765
Min	.1734	.3814	.3315	.3641	.3647	.2427	.2486
Avg	.6400	1.0053	1.0274	.9649	.9548	.7662	.8434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 202 / KRUSHNA MANDIR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754		.1132	.0754	.0754	.0754
2		.0754		.1132	.0754	.0754	.0943
3		.0943		.1509		.0943	.132
4		.132		.1509	.0943	.1698	.1698
5		.1698		.1886	.1132	.2263	.2263
6	.2263	.2263	.2263	.2263	.132	.2641	.2641
7	.2263	.2641	.2641	.2641	.1886	.3018	.3018
8	.2075	.2452		.2641	.1698	.2829	.2452
9	.1886	.1886		.2075	.132	.2353	.2263
10	.132	.1698		.1509	.132	.1509	.1698
11	.1698	.132	.1132	.132		.1132	.132
12	.0943	.0943	.0566	.0943	.132	.0754	.1132
13	.0943	.0566	.0566	.0566	.1132	.0754	
14	.0754	.0566	.0566	.0566	.0943	.0943	
15	.0943	.0754	.0566	.0566	.0943	.0754	.0943
16	.0943	.132	.0754	.0754	.0943	.0754	.0943
17		.132	.1132	.0754	.1132	.1132	.0943
18	.1509	.1698	.1132	.1132	.1698	.1132	.132
19	.1886	.1886	.2075	.2075	.2452	.1698	.1698
20	.1886	.1509	.1698	.1886	.2263	.1698	.1698
21	.132	.1509	.1509	.1509	.2075	.1886	.1509
22	.1132	.132	.1132	.1132	.1509	.1132	.132
23	.0754	.0754	.0754	.0754	.0943	.0754	.0943
24		.0754	.0754	.0754	.0754	.0754	
Max	.2263	.2641	.2641	.2641	.2452	.3018	.3018
Min	.0754	.0566	.0566	.0566	.0754	.0754	.0754
Avg	.1442	.1360	.1203	.1375	.1329	.1418	.1563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 203 / BELWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5304		.6241	.6859	.1981	.2629
2		.5304			.7888	.1981	.2804
3		.547			1.0402	.2439	.3155
4		.547			1.3176	.3048	.3506
5		.547			1.387	.3353	.3856
6	.3856	.7459	.8383		1.439	.3658	.4557
7	.4382	1.2929	1.3108		1.491	.381	.4908
8	.4207	1.6741			1.647	.381	.4382
9	1.4175	.3121			.3048	1.4899	1.7071
10	1.9559	.1928			.2286	1.6461	2.2436
11	1.9559	.1402	.1372		.1677	1.9662	2.2786
12	2.0388	.1227	.1372		.1219	1.8442	
13	2.0719	.1402	.1372		.1219	2.0119	
14	1.9725	.1052	.1219		.1067	2.1033	
15	1.9227	.1052	.1219		.1067	1.9509	2.0508
16	1.6244	.1227	.1067		.1219	1.8442	2.191
17	.208	.1928	.1677		.1524	.2103	.1524
18	.2774	.1578	.1677	.2286	.2515	.2804	.2286
19	.3641	.3856	.3201	.3048	.3201	.3988	.3048
20	.3641	.3506	.3048	.2743	.3048	.333	.2896
21	.3121	.3155	.2896	.2591	.2896	.333	.2743
22	.2947	.2804	.2591	.2439	.2591	.298	.2591
23	.5138	.5182	.5959	.6762	.2286	.2629	.2134
24		.5304	.5335	.5959	.6859	.1981	
Max	2.0719	1.6741	1.3108	.6762	1.647	2.1033	2.2786
Min	.208	.1052	.1067	.2286	.1067	.1981	.1524
Avg	1.0299	.4328	.3469	.4009	.5654	.8158	.7587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 205 / 11 KV Sansar Gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572		.543	.4344	.3982	.362
2		.4755		.5973	.4344	.3982	.4344
3		.5853		.724	.4706	.362	.5068
4		.695		.7964	.5792	.5068	.6154
5		.7865		.8869	.6697	.5792	.6878
6	1.0317	1.0791	.9774	.9774	.7783	.6516	.8145
7	1.1041	1.0791	1.0136	1.086	.8507	.8688	.8688
8	1.0679	.9877		.9955	.724	.8869	.7421
9	.5068	.7865		.8688	.7421	.6516	.6335
10	.6219	.5973		.7421	.7783	.5611	.6154
11	.4938	.5068	.3801	.1991	.4344	.4887	.4706
12	.2743	.3258	.2715	.1448	.3439	.362	.3982
13	.3658	.3077	.2715	.0724	.3077	.2715	
14	.3109	.3077	.2534	.1086	.1991	.2353	
15	.3292	.2172	.2353	.0543	.2534	.2172	.2534
16	.3475	.3801	.3077	.3801	.2534	.2172	.1991
17	.4024	.4706	.4706	.4525	.362	.3801	.3077
18	.4755	.6697	.4525	.4525	.5611	.5249	.5249
19	.8596	1.0136	.8145	.4344	.8145	.6335	.6516
20	.7499	.8507	.7602	.4344	.7059	.5973	.6335
21	.7133	.7059	.7421	.4163	.6516	.5611	.543
22	.567	.5973	.6154	.4163	.4887	.4525	.362
23	.4938	.4344	.5068	.2715	.3982	.3258	.3258
24		.4572	.4163	.4525	.4344	.3982	.3077
Max	1.1041	1.0791	1.0136	1.086	.8507	.8869	.8688
Min	.2743	.2172	.2353	.0543	.1991	.2172	.1991
Avg	.5953	.6156	.5306	.5211	.5279	.4804	.5117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 206 / Chatrapati Karkhana

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801		.4268	.3658	1.0288	.9145
2		.4801		.4572	.3658	1.0288	.9755
3		.4973		.5487	.5639	1.2689	1.0669
4		.5487		.6097	.7164	1.4918	1.1584
5		.7888		.6859	.823	1.5432	1.2803
6	1.1736	1.0117	1.0802	.945	1.0364	1.5947	1.4022
7	1.5699	1.1488	1.1488	1.0974	1.1126	1.6289	1.5242
8	1.7223	1.1317		1.0059	.7316	1.9033	1.6309
9	.9431	1.587		1.749	1.046	.8078	.9259
10	.7202	1.7071		1.9376	1.2689	.7202	.7011
11	.5144	1.6918	1.8861	1.9719	1.4232	.5144	.6554
12	.5144	1.7528	1.869	1.7985	1.8519		.5944
13	.5144	1.7985	1.8176	1.8347	1.8004	.4973	
14	.463	1.7985	1.8004	1.8004	1.7661	.4287	
15	.4973	1.768	1.7661	1.7857	1.6632	.4801	.442
16	.4973	1.6156	1.6804	1.6461	1.4403	.4973	.4572
17	.6173	.6001	.5487	.5944	.5335	.7202	.4877
18	.7545	.823	.5487	.6401	.7468	.7888	.5944
19	.9259	.9431	.8535	.8383	.8688	.8916	.7164
20	.9088	.9088	.7773	.7011	.8078	.8573	.7468
21	.7716	.7888	.7011	.6097	.7621	.823	.6859
22	.6516	.7373	.5944	.5487	.6401	.703	.6249
23	.4801	.4801	.4115	.4115	.8688	.8993	.823
24		.4801	.4458	.3963	.3658	1.0288	
Max	1.7223	1.7985	1.8861	1.9719	1.8519	1.9033	1.6309
Min	.463	.4801	.4115	.3963	.3658	.4287	.442
Avg	.7911	1.0653	1.1206	1.0434	.9821	.9629	.8766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 201 / PIMPAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	1.3765	1.4413		1.2308	.2858	.2401
2	.3048	1.4089	1.4575		1.2631	.2858	.2204
3	.3429	1.4413	1.5384		1.2955	.3048	.2204
4	.3429	1.4737	1.6194		1.3279		.2401
5	.381	1.5223	1.6518		1.3441	.3429	.3086
6	.4001	1.5546	1.7166		1.3603	.381	.3944
7	.4763	1.8138	1.8623		1.587	.4954	.463
8	.4954	2.0243	1.9919		1.6842	.4954	.4458
9	1.7604	.3429	.3429				
10	2.1052	.2713	.2477				
11	2.1862	.2374	.2286				
12	2.3205	.2058	.1905				
13	2.3482	.2096	.2096				
14	2.3205	.1715	.2096				
15	2.3158	.1715	.1905				
16	2.2186	.1715	.2667				
17	.1905	.2667	.2858		.2477	.2096	.1905
18	.2667	.3429	.381		.3429	.3048	.2667
19	.4191	.4382	.4001		.4763	.4191	.381
20	.381	.381	.4191		.4572	.4191	.3429
21	.3429	.362	.381		.4191	.4001	.362
22	.3239	.3239	.362		.3429	.3429	.3048
23	1.2803	1.3603	1.0526		.3048	.3048	.2858
24	.2667	1.2651	1.3927	1.1336	1.1984	.2858	.2858
Max	2.3482	2.0243	1.9919	1.1336	1.6842	.4954	.463
Min	.1905	.1715	.1905	1.1336	.2477	.2096	.1905
Avg	1.0024	.7974	.8267	1.1336	.9301	.3518	.3095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 202 / Lamjewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.0572	.0762		.0762	.2591	.2881
2	.2915	.0572	.0762		.0762	.2753	.2753
3	.2429	.0762	.0953		.0762	.3077	.2721
4	.3239	.0953	.0953		.0953		.2915
5	.3401	.1143	.1143		.1143	.3239	.3041
6	.3725	.1334	.1334		.1524	.3401	.3401
7	.502	.1715	.1905		.1715	.421	.5182
8	.5506	.2286	.2096		.1905	.5668	.6316
9	.1187	.5344	.503				
10	.1029	.6722	.5335				
11	.0686	.5921	.5487				
12	.0686	.6316	.5792				
13	.0857	.664	.5944				
14	.0857		.583				
15	.0686	.5992	.5506				
16	.0686	.5668	.5344				
17	.0953	.0762	.0762		.0762	.0762	.0762
18	.0762	.1143	.1143		.0953	.1143	.0762
19	.1334	.1334	.1334		.1524	.1524	.1143
20	.1334	.1334	.1524		.1524	.1524	.1143
21	.1143	.1143	.1334			.1143	.0953
22	.0953	.0953	.0953		.0953	.0953	.0572
23	.0762	.0762	.0762		.2429	.2743	.2591
24	.2429	.0572	.0762	.0572	.0762	.2591	.2896
Max	.5506	.6722	.5944	.0572	.2429	.5668	.6316
Min	.0686	.0572	.0762	.0572	.0762	.0762	.0572
Avg	.1882	.2606	.2615	.0572	.1229	.2488	.2502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 203 / Shetfalgade

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6316	.1334	.1143	.1143	.1143	.5344	.5182
2	.6478	.1524	.1143	.1143	.1143	.5344	.502
3	.6802	.1715	.1334	.1143	.1334	.5506	.502
4	.6964	.1905	.1524	.1334	.1715		.5121
5	.7125	.1905	.1715	.1524	.1905	.5506	.6154
6	.7287	.2096	.2667	.1905	.2096	.5668	.6882
7	.8583	.2858	.3239	.3048	.3048	.8259	.8802
8	1.1498	.2858	.2858	.3239	.3239	1.0364	1.1203
9	.2401	1.0364	.945	1.1012			
10	.1543	1.3283	1.1584	1.247			
11	.1526	1.4575	1.1736	1.1984			
12	.1357	1.3923	1.1279				
13	.0857	1.4251	1.1431				
14	.0857	1.2498	1.2146				
15	.1029	1.3279	1.2308				
16	.1029	1.2793	1.1822				
17	.1524	.1524	.1334		.1143	.1334	.0953
18	.1524	.2096	.1715		.1524	.1905	.1715
19	.2286	.2667	.2667		.2477	.2286	.2096
20	.2286	.2286	.362		.1905	.2286	.2286
21	.2096	.1905	.2286		.1524	.1715	.1715
22	.1905	.1715	.1524		.1334	.1524	.1334
23	.1334	.1143	.1334		.4877	.4877	.4877
24	.6154	.1334	.1143	.1143	.1143	.5344	.503
Max	1.1498	1.4575	1.2308	1.247	.4877	1.0364	1.1203
Min	.0857	.1143	.1143	.1143	.1143	.1334	.0953
Avg	.3782	.5660	.5125	.4257	.1972	.4484	.4587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 204 / SHETPHALGADE GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.1334	.132	.1524	.1524	.132
2	.1524	.1524	.1524	.132	.1524	.1715	.1132
3	.1524	.1524	.1715	.132	.1905	.3429	.1132
4	.1715	.1905	.1905	.1698	.2858		.1886
5	.2667	.3239	.381	.1886	.381	.381	.2987
6	.381	.4191	.4572	.3961	.4382	.4001	.4572
7	.4763	.4954	.5144	.5093	.4954	.5144	.5304
8	.5335	.4763	.4572	.4715	.4572	.5144	.4755
9	.3439	.3292	.3239	.3206			
10	.2534	.2353	.2477	.2263			
11	.2195	.181	.1905	.1698			
12	.112	.1463	.1334				
13	.1267	.132	.1334				
14	.128	.132	.1334				
15	.128	.1132	.1334				
16	.1267	.132	.1524				
17	.1524	.2075	.2096		.1698	.1886	.1543
18	.2667	.2829	.2477		.3206	.3018	.2229
19	.381	.415	.3048		.3772	.3584	.3018
20	.3239	.3206	.362		.3086	.3206	.2829
21	.2667	.2641	.2858		.3018	.2641	.2263
22	.2286	.2263	.1905		.2075	.1698	.1698
23	.1524	.132	.1715		.1372	.12	.12
24	.1524	.1334	.132	.1334	.1334	.1372	.12
Max	.5335	.4954	.5144	.5093	.4954	.5144	.5304
Min	.112	.1132	.132	.132	.1334	.12	.1132
Avg	.2354	.2386	.2421	.2485	.2818	.2891	.2442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 205 / Mhasobachi wadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8259	.4191	.4572	.4382	.4954	.7935	.8907
2	.8421	.4954	.5335	.4572	.5525	.8097	.8482
3	.8421	.5335	.6097	.4763	.6668	.8421	.8745
4	.8583	.6668	.6478	.6668	.7621		.8802
5	.8745	.7621	.7049	.8002	.8192	.8583	.9555
6	.8907	.9145	.8573	.9145	.8192	.8907	1.0082
7	1.2146	1.0669	.9907	1.1241	1.086	1.1012	1.3603
8	1.4737	1.0479	.9145	1.0098	1.0098	1.3927	1.5708
9	.6516	1.3117	1.3717	1.2955			
10	.5426	1.5043	1.4175	1.4327			
11	.4287	1.5524	1.448	1.4175			
12	.3391	1.6842	1.5242	1.4327			
13	.3429	1.5708	1.5546	1.4175			
14	.2743	1.491		1.4327			
15	.2572	1.4413		1.387			
16	.2915	1.4575		1.2955			
17	.381	.362	.3239		.4001	.5144	.4001
18	.5525	.6478	.6287	.6478	.6478	.6668	.5906
19	.8192	.8954		.8573	.8764	.8764	.7049
20	.8002	.7621	.8002	.8573	.8002	.8192	.8002
21	.6287	.6478	.6668	.8002	.7049	.6478	.5906
22	.5335	.5335	.5716	.6668	.5716	.5335	.5335
23	.4191	.4001	.4763	.4763	.7316	.823	.8535
24	.8259	.381	.381	.4191	.4572	.7773	.8383
Max	1.4737	1.6842	1.5546	1.4327	1.086	1.3927	1.5708
Min	.2572	.362	.3239	.4191	.4001	.5144	.4001
Avg	.6629	.9395	.8440	.9445	.7126	.8231	.8563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 206 / NIRGUDE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.5506	.6478	.6154	.6154	.1524	.12
2	.1524	.583	.6478	.6154	.6478	.1524	.1017
3	.1524	.6154	.7773	.6154	.6802	.1905	.1017
4	.1905	.6478	.8097	.6478	.7287		.12
5	.2286	.6964	.8421	.6964	.7449	.2286	.1715
6	.2667	.7935	.8907	.7935	.7935	.2858	.2374
7	.362	1.0202	1.4098	1.1498	1.0364	.4001	.3561
8	.4191	1.2631	1.4089	1.4413	1.2308	.362	.3222
9	1.2803	.2572	.3048				
10	1.5546	.1734	.2096				
11	1.5364	.156	.2096	.1905			
12	1.5384	.1886	.2667	.1905			
13	1.5203	.2667	.2667	.1715			
14	1.5546	.1905	.2286	.1905			
15	1.4737	.1715	.2096	.1905			
16	1.2963	.1715	.2286	.1905			
17	.2858	.2286	.2286	.1905	.2667	.2096	.2096
18	.2858	.2858	.3048	.2667	.2667	.2096	.2667
19	.3239	.362	.2286	.3048	.2858	.2667	.2858
20	.2858	.3048	.2667	.2477	.2858	.2858	.3048
21	.2286	.2286	.2477	.2667	.2858	.2286	.2477
22	.2096	.2096	.2286	.2286	.2477	.2667	.2477
23	.4572	.6478	.5668	.6154	.1524	.1334	.1524
24	.1524	.4877	.6316	.6154	.583	.1524	.1334
Max	1.5546	1.2631	1.4098	1.4413	1.2308	.4001	.3561
Min	.1524	.156	.2096	.1715	.1524	.1334	.1017
Avg	.6628	.4375	.5026	.4743	.5532	.2350	.2112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 218030 / 220/33 KV SUB-STATION

BHIGWAN

Feeder No / Name : 401 / BHIGWAN

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	9.4559	8.9461		6.8359	7.1502	9.1038	5.5927
16	7.1416	9.6079	8.69	8.9878	7.4954	7.6338	6.8501
24	5.8785	4.8788		4.8234	4.4753	5.6927	5.5504
Max	9.4559	9.6079	8.69	8.9878	7.4954	9.1038	6.8501
Min	5.8785	4.8788	8.69	4.8234	4.4753	5.6927	5.5504
Avg	7.492	7.8109	8.69	6.8824	6.3736	7.4768	5.9977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 218030 / 220/33 KV SUB-STATION

BHIGWAN

Feeder No / Name : 402 / WATER WORKS

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2829	.2829	.2778	.2829	.3064	.2681	.2778
16	.2778	.6173	.547	.5973	.5373	.4515	.2829
24	.2829	.2778		.2778	.2681	.2681	.2778
Max	.2829	.6173	.547	.5973	.5373	.4515	.2829
Min	.2778	.2778	.2778	.2778	.2681	.2681	.2778
Avg	.2812	.3927	.4124	.386	.3706	.3292	.2795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 201 / 11 KV CHAKEN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8968	3.469	1.8831	1.7977	1.9806	1.6491	1.8884
2	1.9128	3.3943	1.9067	1.7429	1.9776	1.6743	1.8869
3	1.8656	3.4446	1.8785	1.7017	1.9509	1.6857	1.8587
4	1.8801	3.424	1.8922	1.7253	1.9319	1.6179	1.7947
5	1.8801	3.4324	1.8747	1.7635	1.9829	1.6309	1.8305
6	1.9578	3.5871	2.0591	1.8938	2.0058	1.7383	1.9448
7	1.9204	3.5901	2.0226	1.9311	1.9753	1.7886	1.9494
8	1.8747	3.773	1.9951	2.0035	1.845	1.7764	1.9966
9	2.0782	3.7692	2.0256	2.1407	1.6545	1.9547	1.9883
10	4.3065	4.3301	2.2588	2.2237	3.5627	2.2489	3.9476
11	4.1229	4.3743	4.3219	4.4635	3.4628	2.2763	4.1773
12	3.8866	4.2707	4.2543	4.5526	3.4689	2.1902	3.959
13	3.5346	3.9605	4.1217	4.3858	3.264	2.1437	3.5357
14	3.5147	4.1016	4.1518	4.4582	3.3493	2.037	3.4644
15	3.9095	4.3343	4.4216	4.5252	3.4438	2.1567	3.802
16	4.084	4.4254	4.4143	4.6472	3.4568	2.1498	4.06
17	4.1244	4.289	4.4479	4.4872	3.4636	2.1247	4.1054
18	4.055	3.1047	4.4208	4.6319	3.4042	2.2001	4.2239
19	4.1183	4.249	3.4196	4.8087	3.6115	2.2451	4.3312
20	3.9841	4.1286	4.4147	4.5047	3.5894	2.2398	4.1652
21	3.9072	4.0924	3.7966	4.3659	3.3935	2.2016	3.9289
22	3.6656	3.8347	3.5963	4.0253	3.2526	1.9082	3.8264
23	3.4392	1.9441	3.4995	3.8173	3.2572	1.8991	3.8074
24	3.4431	1.9022	1.8221	3.6649	3.2022	1.893	1.8907
Max	4.3065	4.4254	4.4479	4.8087	3.6115	2.2763	4.3312
Min	1.8656	1.9022	1.8221	1.7017	1.6545	1.6179	1.7947
Avg	3.1401	3.7177	3.1208	3.3443	2.8536	1.9763	3.0985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 202 / 11 KV TASC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.97	3.8394	1.9471	1.9441	2.053	1.7284	1.2163
2	2.0835	3.7472	2.0081	1.8198	1.8313	1.6911	1.2422
3	2.0241	3.8035	1.9006	1.8381	1.7993	1.6674	1.2224
4	1.9105	3.8699	1.8084	1.9913	1.7726	1.6903	1.2765
5	1.9608	3.8912	1.8107	2.063	1.7467	1.6171	1.249
6	2.0454	4.0269	1.9692	2.0218	1.717	1.6743	1.3016
7	2.0485	4.0984	1.9174	1.8404	1.8755	1.6057	1.3306
8	2.1262	4.1671	1.973	1.8938	1.8298	1.6057	1.3413
9	2.303	4.055	2.1544	2.1483	1.7856	1.733	1.3977
10	4.7439	3.9769	2.1834	4.3995	3.7571	1.8054	2.8765
11	4.6258	3.9758	4.1788	4.0725	3.5917	1.7924	2.7999
12	4.6822	4.3686	4.3594	4.3256	3.3326	1.8061	2.2397
13	4.4886	3.8375	4.0638	4.065	3.6512	1.7871	1.9193
14	4.3423	3.7548	4.1125	4.1084	3.5071	1.6491	2.0043
15	4.3682	3.8801	4.1908	4.1381	3.6321	1.704	2.2478
16	4.5496	4.2013	4.3655	4.4894	3.6054	1.6324	2.6338
17	4.5351	3.8325	4.2699	4.824	3.5337	1.5828	2.5766
18	4.007	2.6913	4.0805	4.6464	3.472	1.5447	2.5019
19	4.0726	3.9712	4.111	4.3865	3.466	1.5767	2.5
20	4.0223	3.7776	2.1323	4.321	3.3029	1.4434	2.4005
21	4.0992	3.6964	3.882	4.0261	3.3455	1.2125	2.4165
22	3.8439	3.8082	3.9521	4.1838	3.4446	1.2254	2.3884
23	3.9171	2.0607	3.7144	3.9537	3.4233	1.2643	2.4044
24	3.9103	1.9273	1.9342	3.7479	3.3692	1.23	1.2216
Max	4.7439	4.3686	4.3655	4.824	3.7571	1.8061	2.8765
Min	1.9105	1.9273	1.8084	1.8198	1.717	1.2125	1.2163
Avg	3.4450	3.7191	3.0425	3.3854	2.8686	1.5946	1.9462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 203 / 11 KV ICL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4937					
2		1.7924					
3		1.8671					
4		1.7924					
5		1.8671					
6		1.8298					
7		2.0165					
8		2.1658					
9		2.6886					
10	2.5766	2.5766			2.2405	3.2114	1.6991
11	2.5393	2.6886	1.8099		2.2405	3.0247	2.4459
12	2.4272	2.726	1.6289		1.8671	2.8753	2.0911
13	2.3152	2.5579	1.5927		1.7177	2.7633	1.9231
14	2.3525	2.2965	1.6289		1.7551	2.6326	1.4937
15	2.3899	2.4459	1.7372		1.7924	2.5206	1.9978
16	2.3525	2.5766	1.8099		1.6804	3.0247	2.2032
17	2.3899	1.531	1.587		1.5684	2.9874	1.8671
18	2.0911	2.1285			1.6804	3.006	1.363
19	2.3525	2.3339	1.5384		1.7551	2.6139	1.3817
20	2.4646	2.2779	1.7737		1.7924	2.2405	1.531
21	2.3899	2.2965	1.5775		1.9418	2.1285	1.6244
22	1.8298	1.9418	1.576		2.1658	2.2032	1.6991
23	1.2696		1.5927		2.1658	2.2405	1.7737
24	1.307			1.6108	2.1658		
Max	2.5766	2.726	1.8099	1.6108	2.2405	3.2114	2.4459
Min	1.2696	1.4937	1.5384	1.6108	1.5684	2.1285	1.363
Avg	2.2032	2.1769	1.6544	1.6108	1.9019	2.6766	1.7924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 204 / 11 KV VINAMAX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.056					
2		.056					
3		.056					
4		.056					
5		.056					
6		.0373					
7		.0373					
8		.0373					
9		.0373					
10	.0373	.0373			.0373	.0373	.0373
11	.0373	.0373	.0366		.0373	.0373	.0373
12	.0373	.0373	.0366		.0373	.0373	.0373
13	.0373	.0373	.0343		.0373	.0373	.0373
14	.0373	.0373	.0343		.0373	.0373	.0373
15	.0373	.0373	.0362		.0373	.0373	.0373
16	.0373	.0373	.0362		.0373	.0373	.0373
17	.0373	.0373	.0362		.0373	.0373	.0373
18	.0373	.056	.0362		.0373	.0373	.0373
19	.056	.056			.056	.056	.056
20	.056	.056	.0549		.056	.056	.056
21	.056	.056	.0537		.056	.056	.056
22	.056	.056	.0543		.056	.056	.056
23	.056		.0543		.056	.056	.056
24	.056			.0514	.056		
Max	.056	.056	.0549	.0514	.056	.056	.056
Min	.0373	.0373	.0343	.0514	.0373	.0373	.0373
Avg	.0448	.0458	.0420	.0514	.0448	.0440	.0440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 205 / 11 KV KHADI CRUSHER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4108				
2		.4108				
3		.4108				
4		.4108				
5		.4294				
6		.4481				
7		.5228				
8		.9149				
9		1.4937				
10	1.0082	1.531	1.0242		.5228	1.1576
11	.8589	1.8298	1.1765		.5228	1.531
12	.9335	1.5203	1.3575		.5228	1.2696
13	1.0456	1.0829	1.448		.5228	.9335
14	1.1203	1.0642	1.7194		.4108	1.1949
15	1.1949	1.3817	1.8099		.4108	1.587
16	1.2696	1.5684	1.8099		.4108	1.419
17	1.2696	.8962			.4108	1.0269
18	.8589	.5228			.4294	.6908
19	.5228	.5601	.5249		.4481	.5415
20	.4481	.5228	.5304		.4481	.4294
21	.4481	.5041	.4163		.4108	.4294
22	.4481	.4481	.3982		.4108	.4294
23	.4481		.4163		.4108	.4294
24	.4294			.3944	.4108	
Max	1.2696	1.8298	1.8099	.3944	.5228	1.587
Min	.4294	.4108	.3982	.3944	.4108	.4294
Avg	.8203	.8584	1.0526	.3944	.4469	.9335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 206 / 11 KV PANDHAREWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	1.5147	.6516	.7019		.7922	.8711
2	.6767	1.5067	.6527	.6882		.7922	.8722
3	.679	1.5554	.6653	.6824		.8025	.8882
4	.7099	1.5512	.7133	.7019		.8185	.9625
5	.8471	1.7166	.8505	.8391		.9671	1.118
6	1.0162	2.1407	1.078	1.0597		1.2071	1.4278
7	1.3923	2.6482	1.3455	1.3249		1.4826	1.7901
8	1.7101	2.8589	1.6015	1.5466		1.7193	1.8701
9	1.8141	3.0064	1.7055	1.6004			.1692
10	3.4941	2.8298	1.6507	3.0539	.0137		
11	3.2579	2.9866	3.3424	1.717	2.9287		
12	3.2419	2.6683	3.3459	1.7673	3.2267		
13	3.2797	2.9685	3.3024	1.7718	3.1341		
14	3.2141	2.924	3.1219	1.5066	3.2686		
15	2.9919	2.807	3.0425	1.5272	3.3997	3.7025	3.4931
16	2.9256	2.7456	1.7021	1.6358	3.4869	4.2638	4.0492
17	2.7526	2.9184	3.1076	1.5901	3.4934	4.5022	4.1036
18	2.62	2.0969	2.9595	1.4975	3.2861	4.3181	3.9918
19	2.5209	2.5749	2.8026	.0949	2.9149	3.515	3.4397
20	2.2958	2.1895	2.1365		2.5252	3.0575	2.9512
21	2.031	2.0256	1.946		2.356	2.5944	2.5749
22	1.7833	1.7528	1.5924		2.0096	2.3324	2.3246
23	1.597	.7647	1.5866		1.781	2.164	2.0956
24	1.5238	.695	.7362	.823	1.709	2.6348	.9934
Max	3.4941	3.0064	3.3459	3.0539	3.4934	4.5022	4.1036
Min	.6767	.695	.6516	.0949	.0137	.7922	.1692
Avg	2.0446	2.2269	1.9016	1.3065	2.6356	2.3148	2.1045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214428 / 33/11 KV PATAS

Feeder No / Name : 201 / 11 KV Patas Gaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8855	1.201	1.2376	1.2269	1.1858	1.2574	1.3032
2	.881	1.1934	1.1782	1.1904	1.134	1.2468	1.2605
3	.9084	1.2071	1.1736	1.2407	1.1706	1.2559	1.2605
4	1.0471	1.3154	1.2711	1.3413	1.2864	1.3077	1.3016
5	1.3428	1.4754	1.4495	1.483	1.5333	1.5409	1.5257
6	1.8945	1.858	1.9067	1.9418	1.9646	2.0073	2.0363
7	2.3457	2.5118	2.524	2.6048	2.5697	2.6962	2.8532
8	2.3884	2.7267	2.6292	2.7328	2.838	2.9035	2.9935
9	2.905	1.7436	1.6385	1.7314	1.8564	1.9143	1.9585
10	3.2404	1.3077	1.3489	1.4708	1.5242	1.4678	1.5988
11	3.3608	1.1599	1.1706	1.2041	1.3214	1.2955	1.4068
12	2.998	.9831	1.073	1.1157	1.1355	1.169	1.2117
13	2.87	.9313	.9938	1.044	1.1035	1.0776	1.0639
14	2.8654	.9114	.9054	.9435	.9938	.9602	.913
15	2.7145	.9313	.8612	1.0273	.945	1.0273	.9877
16	2.6094	.9739	.9816	1.0456	1.0684	1.0761	.9998
17	1.1675	1.0715	1.1949	1.1126	1.1873	1.1446	1.1111
18	1.5364	1.3702	1.4556	1.4281	1.4922	1.5485	1.387
19	1.8153	1.8503	1.922	1.8991	1.9052	1.8092	1.765
20	1.7802	1.8823	1.89	1.8839	1.864	1.8564	1.7894
21	1.643	1.7787	1.8351	1.7421	1.8138	1.736	1.7299
22	1.4525	1.5211	1.5303	1.5013	1.5745	1.5104	1.4861
23	1.2742	1.3214	1.3001	1.2635	1.3291	1.4053	1.3474
24	1.23	1.2833	1.2742	1.2452	1.2879	1.3794	1.3474
Max	3.3608	2.7267	2.6292	2.7328	2.838	2.9035	2.9935
Min	.881	.9114	.8612	.9435	.945	.9602	.913
Avg	1.9648	1.4379	1.4477	1.4758	1.5035	1.5247	1.5266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214428 / 33/11 KV PATAS

Feeder No / Name : 204 / 11 KV Kusegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0867	.5769	.6036	.6226	.631	.6203	.6211
2	1.054	.5998	.612	.631	.6501	.6668	.6318
3	1.0555	.6424	.6714	.6729	.7011	.708	.7004
4	1.1401	.7941	.7781	.8032	.8307	.788	.8345
5	1.454	1.0494	1.0715	1.1241	1.1355	1.1233	1.0989
6	2.0195	1.5379	1.5272	1.5493	1.5325	1.531	1.5508
7	2.9561	1.8412	1.7993	1.8313	1.8	1.8061	1.7977
8	3.3371	1.6606	1.7132	1.752	1.7642	1.7779	1.7802
9	1.9768	2.9127	2.7724	2.7702	2.7747	2.3548	2.7564
10	1.025	3.7106	3.2922	3.3943	2.9706	2.7885	3.2708
11	.8048	3.7197	3.3029	3.28	3.0552	2.7145	3.312
12	.6043	3.4888	3.1413	3.2556	2.963	2.6444	2.9462
13	.5228	1.4137	2.979	3.1565	2.9279	2.6208	2.5789
14	.5182	3.4088	2.8235	2.9675	2.7686	2.271	2.1757
15	.5982	3.3638	1.9464	2.7115	2.6208	2.2939	2.3373
16	.6706	3.3425	2.6779	2.7084	2.5415	2.4417	2.1856
17	.6348	1.4297	1.419	1.2902	.98	1.1995	1.0684
18	.9244	.9976	.9648	.9556	1.0265	1.0052	.929
19	1.3397	1.4319	1.4434	1.3999	1.4662	1.4045	1.2833
20	1.339	1.3801	1.4205	1.4586	1.4731	1.4159	1.2597
21	1.1919	1.246	1.2094	1.2811	1.3405	1.2651	1.1751
22	.932	1.0296	1.0037	1.0509	1.0501	1.0319	.9854
23	.6821	.7179	.7308	.7255	.7301	.7461	.7552
24	.5799	.6173	.6409	.6341	.6059	.628	.6462
Max	3.3371	3.7197	3.3029	3.3943	3.0552	2.7885	3.312
Min	.5182	.5769	.6036	.6226	.6059	.6203	.6211
Avg	1.1853	1.7880	1.6894	1.7511	1.6808	1.5770	1.6117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 201 / 11 KV H.Berdi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2682	1.6324	.791	1.355	1.2399	1.1286	1.0288
2	.2728	1.6141	.7865	1.3374	1.2384	1.1325	1.0243
3		1.7238	.7529	1.3374	1.2399	1.1813	1.0182
4		1.7817	.756	1.3748	1.2239	1.1889	1.0334
5		1.8519	.823	1.4548	1.3104	1.2483	1.089
6		1.9533	.9846	1.6766	1.4693	1.3931	1.2293
7		2.0759	1.1385	1.8172	1.5901	1.541	1.5607
8	1.6751	1.9799	1.169	1.9536	1.7314	1.5348	1.6713
9	3.6489						
10	3.8607						
11	3.8531						
12	3.8492						
13	3.7738						
14	3.7433	.0945	.1357	.1844	.2073	.0061	.0869
15	3.6602	.3642	.3673	.4145	.3521	.3338	.3315
16	3.4355	.3856	.4588	.4527	.3993	.4283	.3978
17	.4237	.5091	.5807	.5396	.5708	.4649	.4024
18	.4687	.5914	.6706	.5838	.5746	.4832	.4504
19	.541	.6676	.7087	.631	.4511	.5213	.4184
20	.49	.6142	.6996	.6538	.41	.4832	.413
21	.4603	.5243	.6737	.57	.4008	.4512	.4054
22	1.054	.945	.9953	.7956	.8345	.7316	.8116
23	1.6004	1.6689	1.3325	1.2338	1.0821	1.0273	1.073
24	.9526	1.5608	.6859	1.3169	1.2049	1.0334	1.1035
Max	3.8607	2.0759	1.3325	1.9536	1.7314	1.541	1.6713
Min	.2682	.0945	.1357	.1844	.2073	.0061	.0869
Avg	2.0017	1.1862	.7637	1.0359	.9227	.8586	.8184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 202 / 11 KV Wadgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2354	.2073	.0854	.2408	.1851	.2538	.2019
2	1.2643	.2096	.0884	.2446	.1768	.2454	.2042
3	1.2727	.1021	.0434	.1364	.0884	.0343	.0914
4	1.2979	.0975		.1303			
5	1.336	.0899		.1318			
6	1.3299	.016		.1326			
7	1.4106			.1387			
8	1.4807			.112			
9	.2309	2.54	1.7017	3.8485	3.5734	3.8896	4.4276
10		3.0651	1.9532	4.1365	3.9194	4.2681	4.8019
11		3.3223	3.7769	4.2897	4.2913	4.3598	4.8591
12		3.7879	3.8115	4.3431	4.5397	4.4434	4.7684
13		3.8131	4.0687	4.1876	4.7561	2.3464	4.8171
14		3.7975	3.9624	4.0257	4.8674	2.1994	4.8087
15	.058	3.7998	3.9236	3.7007	4.5389	2.2596	4.2714
16	.077	3.8214	3.9167	3.6786	4.68	4.292	4.1434
17	.1601	.9046	1.3139	.676	.5297	.9183	.426
18	.1814	.2149	.2537	.1029	.1951	.1798	.1418
19	.1951	.2256	.3094	.1746	.2454	.1935	.1699
20	.221	.1996	.3826	.2202	.279	.2034	.1906
21	.2294	.2164	.2904	.2293	.2744	.2042	.2309
22	.2165	.2248	.2697	.2476	.2736	.2164	.253
23	.2081	.2118	.2431	.2057	.3155	.2118	.2576
24	.6646	.1966	.1341	.1973	.2446	.2202	.2156
Max	1.4807	3.8214	4.0687	4.3431	4.8674	4.4434	4.8591
Min	.058	.016	.0434	.1029	.0884	.0343	.0914
Avg	.6879	1.4120	1.6068	1.4805	1.9986	1.6284	2.0674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 203 / 11 KV Pedgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.1143		.1463	.1646	.1524	.1829
2	1.0288	.1334		.1463	.1646	.1524	.1829
3	1.1431					.1524	
4	1.1812						
5	1.2955						
6	1.4098						
7	1.448						
8	1.467						
9		1.7147		2.1262	2.2862	1.9719	2.4006
10		1.7833		2.2634	2.553	2.1948	2.5149
11		1.9547	2.2462	2.2977	2.6292	2.1262	2.553
12		2.0919	2.2291	2.2977	2.5911	2.1091	2.4768
13		2.1948	2.2291	2.2634	2.4577	2.1262	
14		1.7833	2.2291	2.332	2.5149	2.1605	2.6292
15	.1143	2.1605	2.1434	2.0919	2.4387	2.1948	2.2481
16	.1334	2.1948	2.0233		2.4768	2.1262	2.191
17	.1524	.1097	.0914	.0914	.0762	.0732	.1143
18	.1905	.1463	.0914	.128	.1143	.1097	.1524
19	.2286	.1829	.2012	.1829	.1524	.1829	.1905
20	.1905	.1829	.2012	.1829	.2096	.1829	.2286
21	.1905	.1829	.2012	.1829	.2096	.2012	.2286
22	.1524	.1463	.1829	.1646	.2096	.1829	.2096
23	.1524	.1463	.1646	.1646	.2096	.1829	.1905
24	.8383	.1143		.1463	.1646	.1905	.1829
Max	1.467	2.1948	2.2462	2.332	2.6292	2.1948	2.6292
Min	.1143	.1097	.0914	.0914	.0762	.0732	.1143
Avg	.6795	.9632	1.0949	1.0123	1.2013	.9881	1.1104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 204 / 11 KV D. Raje AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1699	1.7978	1.7924	1.7726	1.4373	1.6286	1.6187
2	.1707	1.8328	1.8129	1.7444	1.467	1.7071	1.5951
3		1.8252	1.6393	1.7611	1.5082	1.6819	1.4762
4		1.9471	.9145	1.8119	1.5204	1.6918	1.5059
5		2.0279	.9496	1.898	1.5867	1.7558	1.5806
6		2.111	1.0593	2.0474	1.7565	1.8625	1.7189
7		2.4562	1.3077	2.2839	2.1224	2.095	2.1823
8		2.6269	1.4098	2.4405	2.5202	2.5049	2.4006
9	3.4195						
10	3.7174						
11	3.7372						
12	3.7944						
13	3.7799						
14	3.6877		.0023		.0023		
15	3.6626	.0732	.1204	.1083	.1303	.0801	.077
16	3.6534	.1486	.0823	.1639	.1029	.1349	.17
17	.1654	.2461	.2156	.1996	.1745	.157	.2271
18	.2149	.253	.2728	.2454	.24	.2545	.3033
19	.3041	.2926	.3124	.2751	.2858	.3269	.359
20	.2553	.2476	.3056	.2621	.1433	.2667	.3132
21	.2324	.2271	.3041	.2583	.2507	.2393	.3444
22	.2469	.2286	.2027	.2324	.3185	.237	.3224
23	1.7383	1.8427	1.7886	1.4434	1.5463	1.5814	1.4625
24	1.1919	1.6713	1.8129	1.6049	1.637	1.5524	1.5097
Max	3.7944	2.6269	1.8129	2.4405	2.5202	2.5049	2.4006
Min	.1654	.0732	.0023	.1083	.0023	.0801	.077
Avg	1.8968	1.2142	.8582	1.1418	.9869	1.0977	1.0648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 207 / 11 KV VITTHAL NAGAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.8573		.5784	.5258	.6097	
2	.0572	.8573		.5434	.5258	.6478	
3		.8573		.5784	.5258	.6478	.6478
4		.8954		.5959	.5258	.4191	.6478
5		.9145		.6661	.5258	.6668	.6668
6		.9526		.6661	.5609	.6859	.6859
7		.9717		.7011	.6173	.6287	.724
8		1.0098		.7011	.7316	.743	.7621
9	1.5242						
10	1.6004						
11	1.6004						
12	1.6385						
13	1.6194						
14	1.5813						
15	1.6004	.0366	.0366	.037	.0572	.0366	.0381
16	1.6385	.0366	.0366	.037	.0572	.0366	.0572
17	.0572	.0732	.0366	.0732	.0762	.0732	.0572
18	.0762	.0732	.0366	.0732	.0762	.0732	.0572
19	.0762	.0732	.0732	.0732	.0762	.0914	.0762
20	.0762	.0732	.0732	.0914	.0762	.0914	.1143
21	.0762	.0732	.0732	.0914	.0762	.0914	.1143
22	.0572	.0732	.0732	.0732	.0953	.0914	.0953
23	.7621	.6447	.6001	.5487	.5335	.5959	.4191
24	.0572	.8192		.6135	.5258	.5525	
Max	1.6385	1.0098	.6001	.7011	.7316	.743	.7621
Min	.0572	.0366	.0366	.037	.0572	.0366	.0381
Avg	.7864	.5162	.1155	.3746	.3438	.3768	.3442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 208 / 11KV DEULGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954			.3881	.3326	.381	.3429
2	.4191	.3429		.3696	.3696	.381	.381
3	.381	.3429		.3696	.4066	.4001	.4572
4	.4572	.381		.5544	.5544	.4191	.5716
5	.5335	.5335		.6838	.7392	.5335	.7621
6	.724	.6478		.8316	.9877	.724	1.105
7	1.0288	.9526		.9979	1.0059	1.0669	1.1431
8	.9526	.8871		.924	.8779	1.0098	.9907
9	.724	.6283		.6653	.7621	.7316	.8764
10	.5906	.5175		.4435	.6097	.5853	.743
11	.4954	.2587	.462	.3696	.5716	.4435	.4572
12	.4191	.2587	.3881	.2614	.3429	.2772	.3429
13	.2667	.2587	.2614	.2241	.2096	.2427	.3048
14	.2286	.2033	.2427		.1905	.2241	.2286
15	.2667	.0183	.2054	.1867	.2286	.2054	.2667
16	.3048	.1848	.2427	.2614	.2667	.2241	.2667
17	.381	.3142	.3174	.3696	.3239	.2614	.3429
18	.6478	.5544	.5729	.5175	.6097	.4805	.6478
19	.8002	.7865	.7392	.7865	.7621	.8048	.743
20	.8002	.7392	.7207	.7316	.8002	.8413	.8002
21	.6668	.5544	.6653	.6219	.6859	.6653	.8192
22	.5335	.4435	.5544	.4755	.5144	.5175	.7621
23	.4191	.3696	.4435	.3696	.4572	.4066	.6478
24	.6097	.6283		.3881	.3326	.4191	.3429
Max	1.0288	.9526	.7392	.9979	1.0059	1.0669	1.1431
Min	.2286	.0183	.2054	.1867	.1905	.2054	.2286
Avg	.5477	.4698	.4474	.5127	.5392	.5102	.5977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214523 / 33/11 KV RAWANGAON

SUBSTATION

Feeder No / Name : 201 / 11 KV KHADKI AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0973	.1337	.128	.1219	.1505	.1524	.1296
2	2.1834	.1337	.128	.1389	.1505	.1562	.1311
3	2.2447	.1337	.1296	.1389		.1581	.1384
4	2.3746	.1372	.1296	.144	.1714	.1615	.1219
5	2.5972	.1817	.1423	.1726	.1905	.3124	.2564
6	2.8212	.3319	.3237	.3219	.3326	.3848	.3448
7	3.4015	.3298	.3448	.3319	.4054	.4009	.3814
8	4.1012	.3155	.1936	.3079	.3978	.4047	.3768
9	.3359	3.5753	2.7907		3.8774	3.5619	3.6189
10	.2819	5.3833	5.4068	3.0759	3.3513	4.7256	4.4419
11	.128	5.7507	5.6737	5.3696	5.0458	4.994	4.6953
12	.1311	5.8478	2.7297	5.6588	5.169	5.3041	4.67
13	.1311	5.0889	5.6851	3.1306	5.5312	4.9665	4.7592
14	.1341	5.7735	5.8421	3.5147	4.9123	5.1718	4.2886
15	.1341	5.7796	5.359	2.5362	5.0069	5.1875	3.7098
16	.1341	5.3759	5.2012	4.6993	4.8319	4.6503	3.2906
17	.128	.132	.2637	.1505	.1593	.1219	.1174
18	.253	.2446	.236	.1898	.2671	.2014	.2957
19	.3321	.3033	.3094	.3711	.3551	.3233	.3151
20	.3181	.3103	.2957	.368	.3353	.3081	.3096
21	.3147	.2019	.282	.3087	.322	.1924	.2332
22	.1635	.137	.1174	.3056	.3071	.1296	.1235
23	.1635	.1326	.1204	.1505	.1505	.128	.1235
24	.7804	.1486	.1204	2.1376	.1505	.1505	.1235
Max	4.1012	5.8478	5.8421	5.6588	5.5312	5.3041	4.7592
Min	.128	.132	.1174	.1219	.1505	.1219	.1174
Avg	1.0702	1.9118	1.7480	1.4628	1.8075	1.7603	1.5415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214523 / 33/11 KV RAWANGAON

SUBSTATION

Feeder No / Name : 202 / 11 KV RAWANGAON GAVTHAN

GAOTHAN FEEDER

FEEDE Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2597	1.2754	1.2113	1.1873	1.2468	1.2712	1.219
2	1.3131	1.342	1.2196	1.2536	1.275	1.2979	1.2708
3	1.4273	1.5425	1.2768	1.3392	1.3207	1.3512	1.3098
4	1.6804	1.7886	1.5147	1.5426	1.6328	1.6251	1.5483
5	2.0484	2.3751	2.0766	1.8294	2.1784	2.2626	1.9501
6	2.4776	2.9298	2.8208	2.6753	2.9658	3.1546	2.6802
7	3.0079	3.1873	3.5589	3.4326	3.4023	3.2893	3.3272
8	3.2629	3.2198	1.7787	3.0925	3.4614	3.1169	3.3249
9	2.9816	2.8936	1.4922	2.6878	2.7961	2.6524	3.2087
10	2.13	2.0803	2.2566	2.0645	2.3403	2.2144	2.7341
11	1.5863	1.5112	1.3906	1.4445	1.765	1.8069	2.207
12	1.1805	1.1702	.5182	1.3188	1.2239	1.4396	1.7642
13	1.1156	1.0334		1.033	1.0867	1.1708	1.319
14	.9629	.927		.9481	.9557	.9669	1.1183
15	.9183	.9202	1.0225	.9107	.9259	.9499	1.2056
16	.7788	.9244	1.1953	.8204	1.0181	1.0258	1.3054
17	1.5028	1.1043	1.4472	1.2517	1.0951	1.3378	1.4411
18	1.9212	1.8115	1.8175	1.7787	1.7696	1.7863	1.6776
19	2.6585	2.5244	2.6894	2.633	2.7984	2.3247	2.1361
20	2.502	2.3312	2.513	2.6119	1.8507	2.5019	2.2203
21	2.1308	2.0184	2.093	2.1757	2.2954	2.1993	1.933
22	1.7367	1.6371	1.6754	1.8842	1.9155	1.768	1.6317
23	1.4183	1.3936	1.3946	1.4361	1.4575	1.4952	1.424
24	1.2232	1.2326	1.2178	.6569	1.2864	1.275	1.2765
Max	3.2629	3.2198	3.5589	3.4326	3.4614	3.2893	3.3272
Min	.7788	.9202	.5182	.6569	.9259	.9499	1.1183
Avg	1.8010	1.7989	1.7355	1.7504	1.8360	1.8452	1.8847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214523 / 33/11 KV RAWANGAON

SUBSTATION

Feeder No / Name : 203 / 11 KV NANDADEVI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7327	.4652	.4241	.4664	.4526	.474	.4062
2	1.7996	.4698	.4279	.4935	.4572	.4801	.4016
3	1.8534	.511	.4127	.525	.477	.4808	.4093
4	1.9532	.5489	.4431	.5441	.493	.5058	.4542
5	2.0507	.5845	.5023	.582	.5583	.5331	.5049
6	2.1917	.6588	.6037	.6209	.6506	.6097	.5875
7	2.3887	.6272	.7128	.6809	.7293	.6905	.6348
8	2.7517	.5621	.3147	.6481	.6218	.6603	.6035
9	.5232	2.4756	1.528		3.2549	3.3928	3.8952
10	.4176	2.8075	3.3385	2.5495	4.0375	4.1644	4.2101
11	.2774	2.9599	3.3264	3.9408	3.972	4.0773	4.1438
12	.2561	3.2244	3.4335	4.1571	.016	4.1081	3.8986
13	.2655	3.3077	3.5303	4.3988	3.8746	4.105	3.8293
14	.2538	3.4148	3.448	2.3838	4.2105	4.1518	3.706
15	.2576	3.3833	3.6099	3.7875	4.1297	3.9293	3.549
16	.253	3.2289	3.3017	3.7883	3.8488	3.6725	3.2838
17	.3086	.4017	.3033	.3086	.2942	.346	.4626
18	.4241	.4056	.3704	.3757	.4115	.439	.3506
19	.5537	.5637	.5152	.559	.5515	.5007	.4215
20	.4835	.5357	.4889	.5628	.5575	.5491	.4734
21	.442	.4626	.4482	.4474	.5209	.4946	.4688
22	.445	.4459	.4348	.4805	.5224	.4535	.4726
23	.4421	.4443	.4291	.4459	.4828	.4352	.4832
24	.9928	.4553	.4672	2.1968	.4703	.4397	.4847
Max	2.7517	3.4148	3.6099	4.3988	4.2105	4.1644	4.2101
Min	.253	.4017	.3033	.3086	.016	.346	.3506
Avg	.9716	1.3727	1.3673	1.5193	1.4831	1.6539	1.5890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214523 / 33/11 KV RAWANGAON

SUBSTATION

Feeder No / Name : 204 / 11 KV RAWANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8036	3.2884	3.7747	3.9395	3.4845	3.6877	3.6138
2	.8057	3.3821	3.7136	3.9925	3.8083	3.7232	3.6134
3	.821	3.3779	3.6582	4.0329	3.5665	3.7254	3.6854
4	.8616	3.368	3.7107	4.0589	3.8456	3.7841	3.6503
5	.889	3.4194	3.7712	4.1534	3.7266	3.8592	4.092
6	.936	3.5722	4.2372	4.3264	3.9727	4.0756	4.3058
7	.9436	4.0344	4.5732	4.6106	4.6257	4.6057	4.6978
8	.9057	4.6369	2.8913	4.8033	4.9937	4.9093	4.8076
9	5.2824	.7514	.378	.7804	.7384	.8105	.8444
10	6.0487	.5744	.5163	.5994	.2896	.6889	.7232
11	6.0536	.3338	.3232	.3932	.3894	.5191	.6379
12	6.1348	.2842	.3072	.357	.3609	.4657	.5175
13	6.1926	.3018	.2711	.2957	.3551	.4237	.4408
14	5.6089	.2827	.2628	.1509	.3525	.3715	.4306
15	5.3342	.2795	.2149	.1845	.2988	.3365	.4119
16	5.0625	.2999	.3182	.3133	.3483	.357	.3841
17	.4515	.4039	.4674	.3765	.4313	.4459	.5438
18	.6394	.5909	.5673	.5685	.5436	.6204	.6485
19	.884	.8676	.8338	.9307	.9621	.8615	.809
20	.8508	.8691	.9103	.9446	.9614	.8939	.8623
21	.8223	.8595	.879	.8219	.9229	.8653	.8733
22	.8368	.8623	.9145	.8539	.9385	.8783	.8909
23	3.2114	3.7429	3.5947	3.4641	3.6504	3.5932	3.5041
24	2.2306	3.5197	3.7163	2.1217	3.6935	3.5429	3.6794
Max	6.1926	4.6369	4.5732	4.8033	4.9937	4.9093	4.8076
Min	.4515	.2795	.2149	.1509	.2896	.3365	.3841
Avg	2.6088	1.8293	1.8669	1.9614	1.9692	2.0019	2.0278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 302 / 22 KV DAUND

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	09-JAN-17
HR	Load (MW)
1	1.5242
2	1.5242
3	1.5242
4	1.5242
5	1.5242
6	3.0483
7	4.5725
8	5.3346
9	5.3346
10	4.5725
11	3.8104
12	3.8104
13	3.0483
14	3.0483
15	3.0483
16	2.2862
Max	5.3346
Min	1.5242
Avg	3.0960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 201 / 11 kv kedgaon feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8775		.5144	.6859	.7716	.8775
2	2.3491	.8688		.6001	.6859	.6097	.8869
3	2.2977	.9231		.6859	.6859	.5144	.9231
4	2.3148	.8859		.7716	.7373	.6001	.9774
5	2.3834	.9774		.8916	.823	.7716	.9774
6	2.3491	.9774		1.0631	.9945	.9945	1.0498
7	2.4691	1.086		1.1488	1.1145	1.2003	1.1016
8		1.1041		1.0974	.9945	1.2003	1.0924
9		2.4348		2.1538	1.9966	2.2186	2.1948
10		2.4234	1.7328	2.2558	2.2996	2.4006	2.1214
11		2.5758	2.5911	2.332	2.3967	2.4691	2.2186
12		2.4996	2.0405	1.89	2.3482	2.452	2.3158
13	.9774	2.4387	2.2672	1.9509	2.2348	2.4006	2.4291
14	.905	2.332	2.4291	2.0424	2.3158	2.4006	2.0081
15	.8505	2.4387	2.4291	2.0424	2.3158	2.3148	2.0081
16	.8688	2.4996	2.2996	1.9204	1.9109	2.2977	2.0891
17	.8869	.6687	.823	.6859	.6344	.8775	.7716
18	.9671	.823	.7716	.8402	.8573	.8954	.823
19	1.0631	1.2003	.8916	1.0288	.9431	1.0208	.8573
20	1.0924	1.0974	1.0631	1.046	1.0288	1.0498	.9431
21	1.086	1.0288	.9602	.8573	.9774	1.0498	.9431
22	1.0498	.8059	.8573	.7716	.8916	.9877	.8916
23	.8688	.703	.6859	.6859	.8573	.8859	.8573
24	1.6804	.8326		.6859	.703	.8059	.8688
Max	2.4691	2.5758	2.5911	2.332	2.3967	2.4691	2.4291
Min	.8505	.6687	.6859	.5144	.6344	.5144	.7716
Avg	1.4700	1.4376	1.5602	1.2484	1.3097	1.3829	1.3428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 203 / 11 Kv Handalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5073	1.8681	1.2498	1.7947	1.7375	1.688	1.6861
2	2.7054	2.011	1.2803	1.6537	1.9357	1.6689	1.8046
3	2.6711	2.1053	1.387	1.8556	2.0919	1.7947	1.893
4	2.955	2.1468	1.4632	1.9585	2.1415	1.9395	1.9197
5	3.0902	2.2152	1.5089	2.231	2.2101	1.9204	1.9719
6	3.1245	2.3244	1.448	2.4386	2.2787	2.0881	1.9833
7	2.8121	2.0195	1.0669	1.4974	2.0062	2.2729	1.7061
8	1.1126	4.4458	3.0636	3.9533	3.919	3.8181	3.6679
9	1.0822	5.0526	3.2007	4.6315	4.4666	4.4067	4.6658
10	1.1126	5.1516	4.4553	4.862	4.8421	4.9306	4.7059
11	1.1279	5.487	4.9878	4.8773	4.8745	5.1955	4.883
12	1.0669	5.1821	4.5982	3.1093	4.2296	5.0164	5.0736
13	.6154	5.2736	5.1669	5.0755	4.9926	4.9276	5.1164
14	.5316	5.1212	5.2479	5.0145	5.0069	5.144	4.905
15	1.8576	4.8773	5.1259	4.984	4.8678	4.8983	4.6287
16	1.8176	3.7494	4.2086	3.8104	3.9961	3.597	3.9495
17	3.7049	2.2387	2.3205	2.3929	2.4292	2.4911	2.3072
18	3.4134	2.4234	2.191	1.9509	2.4216	2.3568	2.2977
19	3.0598	2.3511	2.109	2.3701	2.4387	2.3247	2.2157
20	2.9063	2.1186	2.0843	2.13	2.2653	2.0786	2.2101
21	2.7826	1.9299	1.9452	1.9738	2.0729	1.9502	2.1433
22	2.7245	1.8347	1.8214	1.8347	1.9433	1.9052	1.9033
23	2.6883	1.7357	1.7185	1.7566	1.8176	1.8414	1.8709
24	3.3075	1.789	1.2193	1.6575	1.8461	1.7985	1.8871
Max	3.7049	5.487	5.2479	5.0755	5.0069	5.1955	5.1164
Min	.5316	1.7357	1.0669	1.4974	1.7375	1.6689	1.6861
Avg	2.2824	3.1438	2.7028	2.9089	3.0346	3.0022	2.9748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 204 / 11 KV KADETHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0679	1.6118		1.1336	1.0974	1.2955	1.4403
2	.9568	1.6118		1.166	1.1126	1.1984	1.5261
3	1.0454	1.7147		1.2146	1.1431	1.1336	1.4403
4	1.1584	1.7833		1.2955	1.2193	1.2955	1.543
5	1.2226	2.0576		1.3603	1.3413	1.4413	1.6118
6	1.1462	2.0233		1.6356	1.5089	1.6194	1.7364
7	1.267	2.0576		1.749	1.7375	1.8138	1.869
8		2.0748		1.8623	1.829	1.8138	1.8519
9		.7865		.9088	.8745	.823	.9313
10		.7888	.7202	.8059	.7716	.8507	.8745
11		.6554	.6859	.6859		.8596	.8059
12		.6401	.5487	.6687	.703	.7343	.7545
13	2.8978	.6001	.6516	.5201	.7373	.7522	.6516
14	2.8121	.5658	.7202	.6516	.6516	.724	.6516
15	2.6406	.6344	.7202	.6859	.6001	.7602	.6516
16	2.5206	.6001	.6516	.6516	.6859	.7442	.6687
17	.6878	.6001	.6687	.6859	.6859	.7964	.7202
18	.7796	.7202	.8059	.8745	.8916	.8326	.7716
19	1.0454	1.0288	.8916	1.1317	1.0288	.8869	.8573
20	.9774	.9602	.9602	1.0117	1.1317	.8688	.9602
21	.9412	.8573	.8916	.9431	1.0288	.8869	.8916
22	.905	.7202	.823	.8745	.823	.8507	.7545
23	1.5432	1.1431	1.1336	1.0822	1.2955	1.1831	1.0688
24	.9774	1.6461		1.2308	1.0974	1.2955	1.2003
Max	2.8978	2.0748	1.1336	1.8623	1.829	1.8138	1.869
Min	.6878	.5658	.5487	.5201	.6001	.724	.6516
Avg	1.3996	1.1618	.7766	1.0346	1.0433	1.0609	1.0930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 205 / Dairy Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1696	.0762	.1219	.1295	.1219	.1848
2	.2153	.1696	.0914	.1219	.1162	.1067	.1848
3	.2307	.1848	.0762	.0914	.1162	.0914	.1486
4	.2347	.1463	.0762	.1067	.1295	.1219	.1515
5	.2334	.1848	.0914	.1371	.1524	.1067	.1153
6	.1977	.1877	.061	.1524	.1219	.122	.1319
7	.2153	.2058	.0762	.1981	.1524	.1828	.0983
8	.1067	.2029	.061	.1371	.1372	.12	.1319
9	.0914	.2002	.061	.1524	.1162	.1067	.1153
10	.0914	.1486	.1524	.1581	.1676	.163	.1676
11	.1524	.1981	.1981	.2133	.1828	.2331	.1677
12	.1524	.2438	.2743	.2438	.2743	.3315	.3048
13	.1448	.1639	.2744	.1981	.2439	.2972	.2286
14	.1417	.1714	.2744	.1429	.1676	.25	.1676
15	.1238	.1277	.1372	.1429	.1524	.1543	.1676
16	.1543	.1314	.1372	.1277	.1371	.152	.1372
17	.2154	.1448	.1676	.1771	.1676	.1638	.1524
18	.2	.1447	.1676	.1581	.1219	.1623	.1371
19	.1819	.1447	.1676	.0762	.1372	.1471	.1372
20	.1989	.1447	.1676	.1448	.1219	.1486	.1676
21	.1989	.1676	.1829	.1562	.1524	.1696	.1828
22	.2	.1524	.1676	.141	.1676	.1667	.1524
23	.1809	.1677	.1524	.1429	.1372	.1471	.1219
24	.1848	.1972	.061	.1372	.1334	.122	.1638
Max	.2347	.2438	.2744	.2438	.2743	.3315	.3048
Min	.0914	.1277	.061	.0762	.1162	.0914	.0983
Avg	.1724	.1709	.1397	.1491	.1515	.1620	.1591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 206 / 22 FATA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	.6697		.6859	.5144	.5144	.7059
2	1.6461	.6805		.5144	.5144	.5658	.7059
3	1.8861	.7059		.5487	.5487	.6859	.6485
4	1.7833	.7421		.6516	.6173	.8059	.724
5	2.0233	.7964		.9431	.823	.8573	.7964
6	2.3034	.8326		1.2517	.9945	1.0631	.7964
7	2.1262	.8869		1.3546	1.0631	1.3717	.8507
8		.905		1.2003	.9259	1.0669	.8869
9		1.9719		2.2348	1.8595	2.2672	1.9033
10		1.9814	2.0729	1.9509	2.672	2.4691	1.9433
11		2.1338	2.3805	1.9204	2.753	2.5892	2.1862
12		2.0729	2.5911	1.9509	2.6397	2.5549	2.4939
13	.7964	1.9509	2.5587	1.9509	2.6235	2.5377	2.4082
14	.724	1.89	2.5263	1.9814	2.5101	2.4348	2.3967
15	.6154	1.9204	2.4291	1.8595	2.4453	2.4006	2.3158
16	.6516	1.8595	2.332	1.9052	2.5425	2.3491	2.2862
17	.724	.4801	.4458	.4287	.583	.567	.6859
18	.7442	.6516	.7202	.6859	.7716	.6556	.703
19	.7964	.8573	.9259	.823	.8573	.7087	.7545
20	.7522	.7888	1.0288	.7373	1.0288	.724	.9602
21	.7343	.6859	.8573	.6859	.9602	.7265	.9945
22	.7421	.6516	.7888	.6516	.7545	.7059	.8573
23	.6878	.5144	.7545	.5316	.6859	.6878	.7716
24	1.6118	.6516		.7202	.5487	.6001	.6878
Max	2.3034	2.1338	2.5911	2.2348	2.753	2.5892	2.4939
Min	.6154	.4801	.4458	.4287	.5144	.5144	.6485
Avg	1.2130	1.1367	1.6009	1.1737	1.3432	1.3296	1.2693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 207 / 11kv Vrundavan City

Feeder KV- 11 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	12-JAN-17	13-JAN-17
HR	Load (MW)	Load (MW)
9		1.2498
24	.0286	
Max	.0286	1.2498
Min	.0286	1.2498
Avg	.0286	1.2498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN

Feeder No / Name : 201 / 11 kv Grant Apparel

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291	1.9052	1.9624	1.9052	2.1529	1.6194	2.3624
2	2.1719	1.848	2.0195	1.848	2.0767	1.5051	2.3053
3	2.1719	1.848	2.0005	1.7337	2.0386	1.448	2.21
4	2.2291	1.829	1.8671	1.6956	2.0005	1.4861	2.1338
5	2.2481	1.8671	1.8861	1.8861	2.0005	1.4861	2.4006
6	2.2672	1.8099	2.3434	2.0005	1.7909	1.5432	2.4006
7	2.2862	1.7909	2.3243	2.0386	1.5432	2.0957	2.553
8	2.7625	2.5463	2.8578	2.6292	1.6194	2.7244	2.8197
9	2.7054	3.0556		2.7054	1.7718	2.6673	3.0744
10	2.5579	3.0434		2.915	1.848	2.6101	
11	2.4579	3.006		3.0102	1.8861	3.0807	2.9613
12	2.1658	2.2634	2.6101	2.4577	1.7718	2.4577	1.9993
13	2.1845	2.9531	3.1436	2.7816	1.9052	2.8006	2.6863
14	2.2257	2.7816	3.2388	2.4006	1.9243	2.8292	3.0293
15	2.2068	2.7435	3.3532	2.6863	1.9624	2.584	2.7435
16	1.9805	2.6101	2.8959	3.0102	1.9433	2.572	2.6673
17	1.8861	2.5911	2.7244	2.5339	1.7147	2.5911	2.5339
18	1.8107	2.3624	2.4577	2.3624	1.5432	2.6101	2.3624
19	1.8107	2.4387	2.5149	2.8006	1.467	2.7435	2.3434
20	1.7147	1.6766	2.0195	2.0005	1.3336	2.0005	1.9243
21	1.9243	2.3243	2.4577	2.553	1.5813	2.3243	2.4196
22	2.1338	2.3434	2.4577	2.2291	1.7718	2.6101	2.5911
23	2.2862	2.8387	2.5911	2.5149	1.848	2.6482	2.6863
24	2.2291	2.0767	2.5339	1.8347	2.2672	1.6766	2.4768
Max	2.7625	3.0556	3.3532	3.0102	2.2672	3.0807	3.0744
Min	1.7147	1.6766	1.8671	1.6956	1.3336	1.448	1.9243
Avg	2.1936	2.3564	2.4886	2.3555	1.8234	2.2798	2.5080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN

Feeder No / Name : 202 / sahajpur GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2061	.1818	.1753	.1765	.1627	.1765	.1776
2	.2088	.1898	.178	.1776	.181	.1784	.1784
3	.216	.1959	.2073	.1902	.2103	.1917	.2309
4	.2534	.2641	.2469	.2607	.2332	.24	.264
5	.3555	.3567	.3609	.3586	.3647	.37	.3437
6	.4321	.4367	.4717	.4755	.4843	.4683	.4805
7	.5388	.5414	.5372	.5418	.5433	.5369	.5083
8	.5243	.469	.2149	.4516	.4687	.4744	.5034
9	.3715	.3262	.1513	.3472	.3536	.3525	.5035
10	.2797	.2801	.1246	.2066	.3014	.3334	.358
11	.1964	.2255	.093	.1596	.2614	.2541	.229
12	.1601	.1857	.1455	.1471	.2237	.2324	.2313
13	.1471	.1665		.1486	.2176	.2328	
14	.152	.1616		.1239	.2298	.2256	
15	.1562	.1833	.1616	.1109	.224	.2054	.2538
16	.155	.1741	.1566	.117	.2229	.258	.2233
17	.1535	.1768	.1623		.2301	.2778	.2679
18	.2136	.2736	.2412	.1216	.2828	.3609	.2801
19	.3131	.3414	.3079	.3609	.3829	.3586	.3387
20	.2778	.309	.3025	.3376	.333	.3334	.2888
21	.2698	.271	.2706	.3025	.271	.2564	.234
22	.2427	.2088	.2378	.2511	.2324	.2408	.226
23	.194	.1902	.1898	.1986	.1967	.1936	.184
24	.1997	.1772	.1787	.181	.1589	.1799	.1875
Max	.5388	.5414	.5372	.5418	.5433	.5369	.5083
Min	.1471	.1616	.093	.1109	.1589	.1765	.1776
Avg	.2591	.2619	.2325	.2499	.2821	.2888	.2951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN

Feeder No / Name : 203 / 11 Kv Khamgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8517	2.7922	2.8319	2.8761	2.992	2.992	2.7465
2	2.9249	2.8829	2.8975	2.8974	2.9943	2.995	2.9965
3	2.9798	2.9813	3.091	3.1124	3.0788	3.1604	3.0423
4	3.28	3.2495	3.232	3.248	3.3051	3.3989	3.1619
5	3.4454	3.6419	3.4766	3.4561	3.5642	3.6443	3.5002
6	3.8393	3.9895	3.8065	3.8515	3.8721	4.0657	3.8477
7	4.2196	4.2912	3.9582	4.0283	4.0085	4.337	4.0215
8	3.8515	4.1357	1.9563	3.8256	3.9735	4.0748	4.1937
9	3.6435	4.013	1.7878	3.6465	3.9049	3.9537	4.216
10	2.3727	3.7871	1.9761	3.9361	3.8005	3.9469	4.4366
11	3.1962	3.7283	2.0553	3.9735	4.1206	4.0436	4.5489
12	3.5642	3.9017	2.1033	4.0504	4.1686	4.0581	4.4568
13	3.5707	2.0546		4.1259	3.8485	4.0009	4.4201
14	3.7214			4.1099	4.0695	3.9672	3.6496
15	3.5938		3.7898	4.1877	4.2334	3.8266	3.8881
16	3.5046	3.1184	4.3309	4.0749	4.2372	3.991	2.4173
17	3.5909	3.9011	4.3888	3.8965	4.1945	3.8622	2.5209
18	3.6902	1.3169	4.4985	3.9224	3.9225	3.7494	2.4516
19	3.6496	2.806	4.3888	4.0299	3.9651	3.818	2.0355
20	3.7129	3.8119	3.9796	3.7997	3.8934	3.7403	.881
21	3.4552	3.4042	3.6663	3.6747	3.7913	3.4629	3.6397
22	3.2358	3.1429	3.261	3.2708	3.4431	3.1908	3.3676
23	2.8852	2.9515	2.9889	3.0987	3.1215	2.9492	3.2198
24	2.8746	2.8143	2.857	2.947	2.9874	2.912	2.9653
Max	4.2196	4.2912	4.4985	4.1877	4.2372	4.337	4.5489
Min	2.3727	1.3169	1.7878	2.8761	2.9874	2.912	.881
Avg	3.4022	3.3053	3.2419	3.6683	3.7288	3.6725	3.3594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 202 / 11 KV RAHU AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)
1		.5144
2		.5487
3		.5609
4		.5548
5		.6135
6		.6836
7		.7282
8		.6661
9		2.8121
10		2.8807
11		2.8807
12		2.8292
13		2.8121
14		2.7778
15		2.7092
16		2.6406
17		.3429
18		.4458
19	.5487	.5316
20	.5316	.4877
21	.5548	.5335
22	.5959	.583
23	.5028	.5316
24		.5144
Max	.5959	2.8807
Min	.5028	.3429
Avg	.5468	1.2993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 203 / 11 KV MADHAV NAGAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5243	1.4403	1.2308		1.3523
2	.5304	1.3904	1.2452		1.3032
3	.5138	1.4403	1.2929		1.2971
4	.5365	1.5257	1.3748		1.3321
5	.583	1.6126	1.4413		1.387
6	.5506	1.701	1.4403		1.4899
7	.6062	1.7164	1.4089		1.5769
8	.5636	1.749			1.7002
9	2.0405	.421			.463
10	2.1605	.3113			.3506
11	2.191	.2249			.3201
12	2.2712	.2347		.2572	.3086
13	2.1948				.2286
14	2.1262	.1715		.2279	.1981
15	2.0567	.1943		.208	.2134
16	1.8515	.1966		.2427	.2286
17	.1715	.2321		.298	.2915
18	.2427	.4191		.4161	.3601
19	.5434	.5256		.5316	.5144
20	.5548	.5304		.5144	.5487
21	.5721	.5197		.5721	.5316
22	.5658	.5256		.5609	.5316
23	.5434	1.286		1.387	1.2517
24	.4858	.5201	1.2717		1.3032
Max	2.2712	1.749	1.4413	1.387	1.7002
Min	.1715	.1715	1.2308	.208	.1981
Avg	1.0408	.8212	1.3382	.4742	.7951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 205 / 11 KV TELE WADI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9662	.4801	.5668	.4115	.5144	.5182	.4801
2	2.0719	.4748		.4801	.5201	.6226	.4801
3	2.0957	.5144	.663	.442		.6299	.5201
4	2.1026	.5548	.6706	.4877	.5959	.6036	.6588
5	2.3834	.7802	.6613	.6097	.7282	.6783	.8573
6	2.5101	.8939	.8916	.7926	.8589	.8402	.9015
7	2.7035		.9878	.884	.929	.9717	1.0692
8	2.967			.9431	.8669	.9339	.964
9	.463	1.6032	3.5151	3.5837	3.1579	3.3648	3.2236
10	.2915	1.8351	3.3265	3.7275	3.4244	3.3913	3.2236
11	.2279		3.6351	3.751	3.4642	3.3779	3.2579
12	.1907	3.2693	3.5665	3.8315	3.4705	3.3436	3.2579
13		3.4252	3.5665		3.2895	3.1893	3.2579
14		3.6523	3.6351		3.3436	3.3288	3.275
15		3.4332	3.6008		3.1903	3.3808	3.2579
16		3.5063	3.5665				3.2922
17	.3258	.3149	.3658		.4144		.4458
18	.4508	.4862	.4572		.5365	.5609	.6173
19	.8413	.8309	.7468		.78	.7716	.6859
20	.7975	.6962	.6706	.6859	.7122	.7202	.6516
21	.6588	.6874	.5792		.6516	.6068	.6173
22	.5658	.6613	.583		.5801	.5784	.583
23	2.0858	.5487	.463		.5138	.5201	.5144
24	1.9109	2.0631	.5426	.4801	.4917	.5138	.4973
Max	2.967	3.6523	3.6351	3.8315	3.4705	3.3913	3.2922
Min	.1907	.3149	.3658	.4115	.4144	.5138	.4458
Avg	1.3805	1.4625	1.6937	1.5079	1.5016	1.5203	1.5246

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 206 / 11 kv SOMESHWAR FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9498	.9259	.0084		1.6118
2	1.9725	.9156	.8848		1.6461
3	1.9784	.9431	.9945		1.6804
4	2.0687	.9362	1.0395		1.7337
5	2.1605	1.0341	1.0513		1.7465
6	2.0567	1.134	1.1145		1.9105
7	2.1464	1.2136	1.085		2.0978
8	2.2211	1.2689			2.3838
9	1.5775	2.4615			3.0864
10	1.7318	2.5232			3.4122
11	1.7878	2.6023			3.3265
12	1.8204	2.6825		3.1207	3.2579
13	1.749	2.7469		3.2074	3.2579
14	1.7147	2.8807		3.2427	3.2407
15	1.6518	2.6397		3.2065	
16	1.5565	2.6216		3.1036	3.2579
17	.1715	.1658		.2103	.2058
18	.2254	.218		.2915	.2743
19	.2279	.2713		.3601	.3601
20	.2254	.0024		.3258	.3429
21	.2254	.2347		.3121	.3086
22	.2401	.2374		.3155	.3258
23	2.0508	.9088		1.5604	1.6289
24	1.8947	1.9938	.9326		1.6118
Max	2.2211	2.8807	1.1145	3.2427	3.4122
Min	.1715	.0024	.0084	.2103	.2058
Avg	1.4752	1.3984	.8888	1.6047	1.8569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 207 / 11 Kv Walaki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	3.0693	2.6558		
2	.4144		2.6871		2.2291
3	.4359	3.1207	2.7018		
4	.4239	3.2247	2.7664		2.2805
5	.5316	3.3128	2.7978		
6	.5506	3.3665	2.915		2.3148
7	.6226	3.4501	2.8178		2.5833
8	.5304	3.6008			2.7343
9	3.7723	.5344			.4572
10	3.9952	.2458			.3658
11	4.1015	.2652			.0857
12	4.2476	.2347			.0762
13	4.2181	.2035		3.1207	.2286
14	4.3038	.2058		3.0167	.2286
15	4.0486	.2105		3.1207	.2286
16	3.9979	.2294			.2572
17	.4287	.2652		.6173	.2591
18	.4854	.4191			.3963
19	.5959	.5256		.5316	.4572
20	.5721	.5138		.5144	.5144
21	.5028	.503		.4681	.5144
22	.4801	.4748		.4908	.4973
23	.4382	2.7778		2.1152	2.1434
24	.3887	.4161	2.7469		2.2462
Max	4.3038	3.6008	2.915	3.1207	2.7343
Min	.3887	.2035	2.6558	.4681	.0762
Avg	1.6873	1.3552	2.7611	1.5551	1.0047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 208 / 11 Kv Bafna Express

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.0343	.0324	.0343	.0343	.0324	.0347
2	.0332	.0339	.0164	.0343	.0347	.0328	.0343
3	.0335	.0343	.0332	.0343	.0351	.0332	.0343
4	.0339	.0347	.0335	.0343	.0347	.0335	.0347
5	.0343	.0351	.0339	.0343	.0347	.0339	.0175
6	.0324	.0354	.0343	.0343	.0351	.0343	.0175
7	.0328	.0347	.0324	.0343	.0351	.0324	.0351
8	.0166	.0343		.0343	.0347	.0328	.0351
9	.0343	.0324	.0343	.0343	.0324	.0332	.0343
10	.0343	.0328	.0343	.0347	.0328	.0509	.0514
11	.0351	.0497	.0686	.0526	.0497	.0343	.0514
12	.0347	.0503	.0343		.0503		.0343
13		.0339	.0343		.0339		.0514
14	.0343	.0514	.0343		.0343		.0514
15	.0324	.0324	.0343		.0324		.0343
16	.0328	.0328	.0343		.0328		.0343
17	.0343	.0332	.0343		.0166	.0343	.0343
18	.0347	.0335	.0343		.0335	.0343	.0343
19	.0351	.0339	.0343		.017	.0343	.0343
20		.0332	.0343	.0343	.017	.0343	.0343
21	.0347	.0335	.0343		.0343	.0347	.0343
22	.0343	.0339	.0343		.0166	.0175	.0343
23	.0351	.0343	.0343		.0332	.0347	.0343
24	.0324	.0347	.0339	.0343	.0339	.0332	.0343
Max	.0351	.0514	.0686	.0526	.0503	.0509	.0514
Min	.0164	.0324	.0164	.0343	.0166	.0175	.0175
Avg	.0323	.0359	.0347	.0357	.0325	.0337	.0359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 209 / 11 Kv RAHU GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.4515	.4791			.2743
2	.2984	.2286	.4897			.3052
3	.285	.5182	.5243			.3467
4	.3052	.5788	.599			.3988
5	.3772	.6631	.6558			.4031
6	.3887	.8419	.8154			.4115
7	.4588	1.0036	.9554			.4557
8	.4144	.9469	.4954			.4382
9	.3944	.8202	.5659			.3601
10	.3258	.6836	.4801			.3258
11	.3155	.5458	.3582			.2743
12	.2947	.5563	.3353	.2254	.2058	.2401
13	.2572	.5685			.1907	.2058
14	.2401	.503			.2103	.1715
15	.2267	.4696			.2254	.1715
16	.1638	.4569			.2279	.2229
17	.2572	.5395				.2058
18	.2601	.5808			.2572	.2743
19	.3506	.671			.2915	.3086
20	.2774	.6324			.3086	.3086
21	.2427	.5472			.2601	.2915
22	.2229	.5194			.2454	.2743
23	.2454	.4725			.2254	.2401
24	.2753	.449	.2204			.2401
Max	.4588	1.0036	.9554	.2254	.3086	.4557
Min	.1638	.2286	.2204	.2254	.1907	.1715
Avg	.2973	.5937	.5365	.2254	.2408	.2979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 211 / WALKI G F S S

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0159	.8916	.9069	.9602	1.0288	.9069	1.0117
2	1.0277	.8478	.9175	.9602	1.0402	.852	1.0852
3	1.0898	.8916	.9614	1.0117	1.1919	.8619	1.0631
4	1.0852	1.0402	1.1568	1.0974	1.2094	1.0059	1.1919
5	1.2346	1.3146	1.2209	1.3375	1.4217	1.2717	1.2136
6	1.4089	1.5592	1.4403	1.5432	1.4899	1.3717	1.5089
7	1.491	1.5257	1.4575	1.6804	1.6126	1.6194	1.6118
8	1.4752	1.4918		1.4575	1.4737	1.3763	1.595
9	1.3717	1.1012	1.3375	1.1831	1.1498	1.21	1.3717
10	1.046	.9175	1.0631	.9362	1.0159	.9496	1.0749
11	1.6126	.8288	.5944	.8764	.8619	.9431	.9602
12		.8718	.8573	.7282	.8048	.8573	.9774
13		.763	.7373		.8309	.7716	.8573
14	.7716	.8402	.7716		.8059	.104	.7545
15	.7449	.7935			.7449	.8059	.7716
16	.7373	.7373			.8192	.8149	.823
17	.8916	.8619	.8059		.8785	.8238	.823
18	.9709	1.0395	1.0288		1.0059	1.1043	1.0974
19	1.3672	1.3395	1.2689		1.3395	1.335	1.3032
20	1.2483	1.1603	1.2346	1.166	1.2209	1.3375	1.2689
21	1.1789	1.0898	1.2003		1.2346	1.2483	1.2003
22	1.0802	1.0682	1.0631		1.1271	1.1568	1.1317
23	.9816	.8916	.9774		.9614	1.0576	.9602
24	.9393	1.1012	.852	.9431	.9665	.9614	.9774
Max	1.6126	1.5592	1.4575	1.6804	1.6126	1.6194	1.6118
Min	.7373	.7373	.5944	.7282	.7449	.104	.7545
Avg	1.1259	1.0403	1.0406	1.1344	1.0932	1.0311	1.1097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 201 / 11 Kv Pargaon Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.2915	.2743	.2572	.2401	.2915	.2743
2	.7716	.2743	.2572	.2401	.2572	.2743	.2915
3	.7545	.2572	.3429	.2743	.285	.3086	.3222
4	.8573	.3429	.4287	.3429	.3521	.3944	.3688
5	.8916	.5144	.5144	.4287	.4287	.4801	.4458
6	.9774	.5487	.6001	.5658	.5487	.6001	.5487
7	1.046	.5658	.6516	.6344	.583	.6516	.6516
8	1.0974	.5316	.4973	.5658	.5658	.6344	.5868
9	.4973	1.406	1.6289	2.1434	2.2291	2.0748	2.1948
10	.3429	1.6804	1.7661	2.2462	2.1091	2.1605	2.4177
11	.2572	1.9376	1.8861	2.1434	2.1434	2.4006	2.2805
12	.3258	2.0119	1.5604	2.3148	.703	2.332	2.2977
13	.3086	1.8347	1.8861	2.2634	2.2291	2.2805	2.2462
14	.3601	1.8347	2.0576	2.2291	2.2805	2.0576	2.1776
15	.3258	1.8176	2.0233	2.1776	1.989	2.1434	2.2634
16	.3086	1.8347	1.9719	2.2462	2.0405	2.1776	2.3491
17	.3086	.3429	.3429	.3429	.3258	.3258	.3429
18	.4115	.4115	.3772	.3772	.4115	.3601	.3772
19	.4973	.4458	.4115	.3772	.463	.463	.4801
20	.3944	.4287	.4115	.3772	.4801	.4115	.4458
21	.4115	.3772	.3944	.3601	.3601	.3944	.3944
22	.3772	.3258	.3258	.2743	.3772	.3601	.3944
23	.3258	.2743	.2743	.2401	.3086	.3086	.3601
24	.7545	.2915	.2915	.2743	.2401	.2915	.2743
Max	1.0974	2.0119	2.0576	2.3148	2.2805	2.4006	2.4177
Min	.2572	.2572	.2572	.2401	.2401	.2743	.2743
Avg	.5566	.8576	.8823	.9874	.9146	1.0074	1.0327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 202 / 11 KV SHINDEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.3944	.3086	.3258	.3258	.3353	.3258
2	.7202	.4287	.2743	.3086	.3353	.3185	.3258
3	.7545	.3429	.3429	.3429	.3856	.3601	.3601
4	.7888	.4287	.4287	.4287	.4458	.4287	.4115
5	.8402	.5144	.5144	.5144	.5144	.5144	.4801
6	.8916	.6001	.6344	.5658	.6001	.6274	.5658
7	1.0802	.6687	.6516	.703	.6173	.7545	.6539
8	1.3889	.5658	.4458	.5316	.5658	.5658	.57
9	.3944	1.1488	1.3375	1.4232	1.3889	1.286	1.3717
10	.3772	1.4746	1.4403	1.5947	1.4918	1.4918	1.5089
11	.3086	1.5261	1.3717	1.1831	1.4918	1.4918	1.6289
12	.2401	1.5775	1.3032	1.5775	1.5261	1.5089	1.5604
13	.2401	1.6118	1.5089	1.5947	1.4918	1.5604	1.5947
14	.2058	1.6118	1.4575	1.6118	1.5261	1.6118	1.5261
15	.2743	1.6289	1.4918	1.5775	1.5089	1.6118	1.4918
16	.2743	1.6289	1.5089	1.6118	1.6118	1.5604	1.5775
17	.2915	.2572	.2229	.2743	.3086	.2915	.2915
18	.4287	.4458	.3772	.3086	.3944	.3429	.4115
19	.6001	.5144	.4115	.4458	.5316	.4973	.5316
20	.5144	.463	.4973	.4973	.463	.463	.463
21	.4973	.4458	.4801	.5144	.4115	.463	.463
22	.463	.3944	.4287	.3944	.4115	.4115	.3772
23	.3772	.3429	.3944	.3601	.3429	.3601	.3258
24	.5144	.3944	.3258	.3258	.3429	.3258	.3429
Max	1.3889	1.6289	1.5089	1.6118	1.6118	1.6118	1.6289
Min	.2058	.2572	.2229	.2743	.3086	.2915	.2915
Avg	.5466	.8088	.7566	.7923	.7931	.7993	.7983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 203 / 11 Kv Nangaon Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	1.382	1.1163	1.1871	1.0454	1.0099	1.0277
2	.3898	1.3289	1.1871	1.1163	1.0517	.9922	.9922
3	.3721	1.2757	1.2403	1.2226	1.0867	1.0277	1.0166
4	.567	1.4175	1.2934	1.2934	1.1694	1.0985	1.0692
5	.6024	1.5592	1.3643	1.3289	1.258	1.1694	1.1517
6	.6379	1.6478	1.4175	1.3998	1.4022	1.2757	1.2403
7	.6556	1.9136	1.8604	1.6832	1.6655	1.5238	1.4706
8	.6379	2.0908	1.8427	2.0376	1.8427	1.8959	1.8427
9	2.7641	.5316	.5493	.7265	.7442	.7087	.6687
10	3.083	.567	.7087	.7619	.6733	.691	.583
11	3.3842	.5847	.7265	.7087	.6733	.7087	.6024
12	3.0653	.5316	.567	.7619	.6379	.7087	.6024
13	3.1361	.4961	.6379	.8328	.6201	.2303	.2572
14	2.8704	.5316	.6201	.8859	.6201	.6201	.3189
15	2.9944	.5493	.6201	.7796	.6733	.6201	.1949
16	2.7286	.567	.6024	.7796	.7087	.5847	.2835
17	.4252	.4607	.6733	.7973	.6201	.5493	.3544
18	.4784	.4607	.6379	.6201	.6024	.6024	.4075
19	.5316	.4784	.6379	.5316	.5847	.6024	.5316
20	.4784	.567	.6201	.4961	.567	.5138	.5138
21	.4075	.5138	.4961	.4784	.5138	.4784	.4607
22	.3721	.443	.4607	.4607	.4252	.4207	.4382
23	1.4175	1.1517	1.134	1.0631	.9568	.9991	.9816
24	.3544	1.382	1.134	1.1517	1.0808	1.0277	1.0631
Max	3.3842	2.0908	1.8604	2.0376	1.8427	1.8959	1.8427
Min	.3544	.443	.4607	.4607	.4252	.2303	.1949
Avg	1.3628	.9347	.9228	.9627	.8843	.8358	.7530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 204 / 11 Kv HATAWALAN GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0242	1.0608	1.0242	1.0059	.9694	.9328	.9412
2	1.0242	1.0974	1.0059	.9328	.9412	.9694	.9231
3	1.1888	1.0059	1.0974	.9145	1.0136	1.1157	.9877
4	1.2986	1.3717	1.2254	.9877	1.1403	1.3352	1.1523
5	1.4632	1.829	1.3717	1.0974	1.39	1.4998	1.4118
6	1.7558	1.7924	1.7558	1.7741	1.7924	1.7193	1.7013
7	2.0485	1.7375	1.8839	1.7375	1.9185	1.957	1.9004
8	1.9936	1.9022		1.8656	1.8839	1.957	1.9185
9		1.7193	1.6827	1.39	1.4815	1.8839	1.7558
10		1.4998	1.1888	1.2071	1.1523	1.3717	1.6461
11		1.262	1.2254	1.0608	1.134	1.1157	1.3535
12	1.2986	.9877		1.2071	1.0059	1.0791	1.1706
13	1.2071	.8779		.9511	.8048	.8413	1.0059
14	1.1157	.9145		.9328	.7682	.695	.8413
15	1.0425	.9877		.9328	.9328	.9694	.9511
16	1.1888	1.0608	1.1157	1.1706	.8779	1.0242	.9511
17	1.2071	1.1706	1.1706	1.0059	.9145	1.0608	1.0608
18	1.3352	1.3169	1.3169	1.2437	1.0791	1.1706	1.2986
19	1.6644	1.4266	1.3717	1.39	1.6095	1.5912	1.4998
20	1.5729	1.4266	1.2986	1.4449	1.6095	1.4449	1.4998
21	1.4998	1.4083	1.2986	1.0791	1.39	1.3535	1.2803
22	1.2437	1.0631	1.2254	1.0974	1.1888	1.1584	1.0974
23	1.0608	.9877	1.0425	1.0608	1.0136	1.086	1.0059
24	1.0059	.9511	1.0425	.9694	.9877	.9511	1.0136
Max	2.0485	1.9022	1.8839	1.8656	1.9185	1.957	1.9185
Min	1.0059	.8779	1.0059	.9145	.7682	.695	.8413
Avg	1.3447	1.2857	1.2812	1.1858	1.2083	1.2618	1.2653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 205 / 11 Kv Khutbav GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.5487	.7316	.695	.6154	.567	.6767
2	.823	.5853	.7316	.6584	.6468	.5853	.6335
3	.8596	.5304	.7133	.6767	.6838	.6219	.6516
4	.9145	.6767	.7499	.7133	.7316	.695	.7059
5	.9877	.7682	.8596	.7865	.8048	.7865	.823
6	1.0425	.9145	.9694	.9511	.8869	.9145	.9328
7	1.1523	1.0608	1.0425	1.0242	1.0317	.9511	1.0317
8	1.0974	1.0791		1.134	1.1706	1.0608	1.267
9	.8413	.9694	.7682	.9877	.9877	1.0791	.9511
10	1.0242	.8779	.7316	1.0242	1.0608	1.0242	.9145
11	.9145	.7133		.9328	.9877	.9694	.9511
12	.8048	.8413		.7499	.8596	.7682	.823
13	.6584	.8779		.7499	.8048	.9328	.8048
14	.5304	.8413		.6401	.8596	.7133	.7499
15	.5853	.823	.5853	.823	.8048	.6401	.7316
16	.6584	.823	.6767	.8048	.8779	.8413	.7316
17	.6036	.7316	.7682	.7316	.8413	.7682	.7133
18	.7682	.8413	.8048	.8048	.9694	.9145	.8596
19	.9694	.9694	.823	.8413	.9511	1.0425	.9877
20	.9328	1.134	.8413	.8962	1.0059	1.1523	1.0059
21	.8962	.8779	.8413	.9877	.823	.9511	1.0059
22	.823	.8048	.7865	.8779	.6767	.9412	.8688
23	.8413	.7499	.8779	.7682	.6697	.823	.8507
24	.695	.5487	.7499	.7133	.6516	.6219	.7499
Max	1.1523	1.134	1.0425	1.134	1.1706	1.1523	1.267
Min	.5304	.5304	.5853	.6401	.6154	.567	.6335
Avg	.8390	.8162	.7922	.8322	.8501	.8486	.8509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 206 / 11 Kv Delwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.0857	.0514	.0514	.0343	.0343	.0514
2	.5144	.0857	.0514	.0514	.0332	.0343	.0343
3	.4801	.0686	.0514	.0514	.0497	.0343	.0514
4	.5144	.0686	.0514	.0686	.0509	.0514	.0671
5	.5316	.1029	.0686	.0686	.0514	.0514	.0671
6	.5487	.1029	.0686	.0686	.0686	.0686	.0686
7	.6001	.1029	.0686	.0857	.0503	.0686	.0686
8	.6516	.1029	.0686	.0514	.0686	.0686	.0686
9	.0514	1.166	1.5604	1.6461	1.6118	1.8519	1.869
10	.0343	1.4403	1.7661	1.8347	1.749	1.9204	1.9376
11	.0343	1.5604	1.7661	1.8176	1.8519	1.9376	1.9719
12	.0171	1.5947	1.6118	1.8861	1.869	1.8861	1.8861
13	.0514	1.6118	1.7661	1.8861	1.8861	1.8519	1.8347
14	.0514	1.6461	1.7661	1.869	1.9033	1.9376	1.406
15	.0514	1.6804	1.749	1.869	1.8861	1.9204	1.6118
16	.0514	1.6975	1.749	1.8519	1.8861	1.9033	1.6289
17	.0514	.0686	.0686	.0343	.0171	.0343	.0343
18	.0686	.0514	.0514	.0343	.0514	.0514	.0514
19	.1029	.0514	.0514	.0514	.0514	.0514	.0857
20	.0857	.0514	.0343	.0514	.0514	.0514	.0514
21	.0857	.0514	.0514	.0514	.0686	.0514	.0514
22	.1029	.0686	.0514	.0686	.0686	.0514	.0514
23	.0857	.0514	.0514	.0514	.0514	.0514	.0686
24	.5658	.0857	.0514	.0514	.0343	.0343	.0514
Max	.6516	1.6975	1.7661	1.8861	1.9033	1.9376	1.9719
Min	.0171	.0514	.0343	.0343	.0171	.0343	.0343
Avg	.2450	.5666	.6094	.6480	.6435	.6666	.6279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 207 / 11kv Hatawalan AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6041	3.3619	2.9036	2.7921	2.763	2.3594	2.2112
2	2.2891	3.155	2.6915	2.6601	2.6029	2.2502	2.0904
3	1.2997	2.4794	2.1948	2.0959	2.112	2.0507	1.857
4	1.2934	2.4794	2.224	2.0364	2.1073	2.0456	1.8924
5	1.3466	2.6034	2.2188	2.0187	2.1049	2.0696	1.9279
6	1.3706	2.6629	2.2074	2.0314	2.1273	2.0936	1.9644
7	1.3311	2.8526	2.3034	2.0325	2.1818	2.2834	2.0454
8	3.4916	2.8412	2.5806	2.145	2.2525	2.3542	2.2321
9	5.8568	1.3769	1.1152	1.3363	1.3603	1.4163	1.5569
10	6.17	1.3123	1.3654	1.3426	1.3603	1.1294	1.5507
11	6.27	.6744	1.3415	1.2643	1.2831	.6201	1.486
12	6.6667	1.2945	1.306	1.3415	1.2602		1.5038
13	6.2483	1.2945	1.3758	1.3477	1.254	.2401	1.5038
14	6.2763	1.306	1.3403	1.4226	1.3288	.6744	1.5089
15	6.1619	1.3581	1.3924	1.3631	1.334	1.4112	1.5432
16	4.92	2.9356	2.6623	2.2205	2.3742	2.4462	2.304
17	1.3163	2.9304	2.5366	2.1456	2.3348	2.4005	2.2342
18	1.3403	2.8224	2.3714	2.0261	2.2319	2.2417	2.0868
19	1.3643	2.7372	2.2519	2.0336	2.2279	2.1617	2.0245
20	1.3529	2.6343	2.2126	1.9942	2.1656	2.1679	1.9445
21	1.3238	2.5937	2.229	1.9484	2.1542	2.1451	1.9102
22	1.3238	2.6343	2.1999	1.9141	2.1428	2.1805	1.9279
23	2.4994	3.4014	2.9138	2.8223	2.7778	2.4514	2.2177
24	1.3123	3.7506	2.9898	2.8046	2.7807	2.6932	2.2634
Max	6.6667	3.7506	2.9898	2.8223	2.7807	2.6932	2.304
Min	1.2934	.6744	1.1152	1.2643	1.254	.2401	1.486
Avg	3.1429	2.3955	2.122	1.9642	2.0259	1.9081	1.9078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 401 / 33kv visaka

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8318	.4017	.447	.6847	.6111	.5545	.8657
2	.6168	.4187	.43	.6734	.6337	.5772	.6451
3	.447	.464	.481	.7526	.5941	.5998	.5998
4	.6903	.4527	.5262	.7186	.5545	.5489	.6337
5	.6677	.8205	.5715	.7073	.7752	.6394	.7073
6	.7243	.8601	.7413	.7016	.8714	.7865	.6055
7	.447	.4697	.7299	.5772	.5149	.4527	.6734
8	.7865	.6394	.7186	.7186	.8488	.6507	.5941
9	.4979	.9563	.7639	.9336	.7413	.8771	.6564
10	.5036	.6677	.5262	.9223	.7243	.4697	.8884
11	.8148	.3951	.1811	.7299	.249	.5602	.8601
12	.4697	.7572	.1698	.911	.481	.5602	.7243
13	.7299	.9054	.1811	.8488	.6734	.5828	.5262
14	.4753	.8148	.2094	.8431	.6677	.6564	
15	.8374	.7469	.2546	.5545	.7922	.6337	.662
16	.9959	.4527	.9733	.5885	.4866	.713	.6281
17	.8657	.8205	.696	.7299	.6337	.7978	.7469
18	.5828	.7695	.7469	.7582	.6224	.6507	.7526
19	.8657	.6734	.5998	.6903	.662	.4866	.4527
20	.7016	.4866	.5093	.4979	.6507	.6564	.4244
21	.8601	.6847	.6168	.7413	.6564	.6168	.4187
22	.4866	.7922	.8657	.696	.4131	.4244	.4583
23	.7243	.5489	.5319	.6564	.4923	.8714	.4414
24	.9223	.4187	.464	.696	.5885	.6507	.713
Max	.9959	.9563	.9733	.9336	.8714	.8771	.8884
Min	.447	.3951	.1698	.4979	.249	.4244	.4187
Avg	.6894	.6424	.5390	.7222	.6224	.6257	.6382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 201 / 11 Kv Warwand Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6201		.5609	.5609	.6556	.6379	.5959
2	.7087		.6135	.5784	.7087	.6379	.7011
3	.7973		.7888	.6135	.7362	.6379	.7888
4	.8764		.9259	.7716	.7712	.6379	1.0517
5	.964		1.0288	.9259	.8063	.691	1.1145
6	1.0517		1.3032	1.1145	.8589	1.0454	1.2003
7	1.2136			1.4575	1.0402	1.5592	1.4403
8		1.0576		1.2346	1.2136	1.258	1.2003
9		.9015		1.0288	1.0867	.8573	1.0631
10		.8573		.8573	.7202	.6859	.8573
11		.7888		.7545	.6516	.6001	.8573
12	.5144	.6859		.703	.5434	.583	.7545
13	.5144	.7202		.6516	.5316	.6859	.6344
14	.4458	.6516		.6173	.5138	.6859	.5658
15	.6687	.6173	.6001	.6173	.4961	.6001	.5658
16	.6173	.5959	.5316	.6068	.4961	.5144	.5658
17	.6588	.5609	.5609	.5895	.5493	.6859	.5258
18	.5959	.7011	.6485	.7888	.6201	.7202	.6485
19	.6661		.9114	.9114	.8505	.823	.8059
20	.7537	.8063	.8764	.8939	.8859	.7888	.8063
21	.8764	.8764	.7888	.8764	.8328	.8059	.7888
22	.7362	.7888	.7362	.8764	.7973	.9465	.7362
23	.6661	.6135	.6135	.7087	.6379	.7011	
24	.567		.5609		.6024	.6556	.6135
Max	1.2136	1.0576	1.3032	1.4575	1.2136	1.5592	1.4403
Min	.4458	.5609	.5316	.5609	.4961	.5144	.5258
Avg	.7256	.7482	.7531	.8147	.7336	.7685	.8210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 202 / 11 Kv Fargade Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0183	.8383	1.3793	1.5775	1.7217	1.5603	1.5623
2	1.0538	.8078	1.4221	1.5699	1.7318	1.5527	1.5623
3	1.1044	.8002	1.4594	1.5699	1.7242	1.5775	1.5798
4	1.1454	.8002	1.4845	1.5775	1.7474	1.6004	1.6202
5	1.1934	.8535	1.5547	1.608	1.7779	1.6632	1.7262
6	1.2894	.9297	1.7699	1.8995	1.9097	1.8671	1.8937
7	1.3215	1.0974	1.0059	1.9852	2.1147	2.1129	2.1815
8	.2896	2.2824	1.2346	2.4425	2.4897	2.5587	2.431
9	.2591	.589	.5182	.6516	.7804	.8364	.9698
10		.3601	.1829	.4096	.4159	.4916	.5315
11		.282	.1448	1.4956	.3658	.362	.4344
12	1.3489	.2419	.282	1.566	.2835	.3639	.4096
13	3.2388	.2172	.2419	1.5261	.2804	.2896	.3296
14	3.4522	.2267	.2248	1.5089	.2393	.28	.2896
15	3.4484	.2096	.2419	1.4915	.2469	.3067	.2419
16	3.3684	.1219	.2496	1.5166	.2652	.3067	.2572
17	2.9569	.1448	.2926	.2315	.2804	.3735	.3178
18	2.6765	.1677	.3811	.3424	.3551	.5087	.4161
19	.6051	.4801	.6257	.4989	.4771	.6515	.5563
20	.5547	.5754	.6157	.6584	.6096	.6333	.5449
21	.5121	.5571	.5677	.6203	.5868	.5677	.5197
22	.4893	.5243	.5274	.5975	.5533	.5876	.5045
23	1.5394	1.3116	1.6065	.9623	.951	1.3946	.7849
24	1.6002	.8535	1.6095	.8612	1.7065	1.6137	1.4365
Max	3.4522	2.2824	1.7699	2.4425	2.4897	2.5587	2.431
Min	.2591	.1219	.1448	.2315	.2393	.28	.2419
Avg	1.5666	.6364	.8176	1.2154	.9839	1.0025	.9626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 203 / 11 Kv Punarvasan

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063		.1753	.1052	.124	.128	.1753
2	.1417		.1753	.1227	.1595	.128	.1753
3	.1595		.1928	.1227	.1578	.128	.1753
4	.1928		.1928	.1402	.1753	.128	.1928
5	.4801		.2058	.1578	.1928	.1463	.1928
6	.2103		.2058	.1886	.208	.1829	.2103
7	.208			.2229	.1907	.2195	.2058
8		.208		.2058	.1907	.2012	.1886
9		.7802		.7716	1.0985	.8573	.9602
10		1.0288		1.2517	1.2048	1.1831	1.3546
11		1.046			1.2003	1.2003	1.4403
12		1.0974	1.2689		1.2346	1.3375	1.3203
13	.0686	1.1317	1.2174		1.2003	1.2346	1.3032
14	.0686	1.2003	1.2346		1.1831	1.2003	1.286
15	.0693	1.1831	1.2346		1.0974	1.2003	1.2689
16	.0693	1.046	1.2174		1.0631	1.1831	1.2346
17	.0867	.0857	.0701		.0732	.1715	.0876
18	.1052		.1052		.1463	.1886	.1227
19	.1227	.1227	.1753		.1646	.1715	.1543
20	.1227	.1543	.1578	.1578	.1829	.1753	.1578
21	.1402	.1753	.1402	.1578	.1646	.1578	.1402
22	.1402	.1753	.1227	.1402	.1463	.1753	.1227
23	.1052	.1753	.1227	.124		.1753	
24	.1063		.0709		.124	.128	.1753
Max	.4801	1.2003	1.2689	1.2517	1.2346	1.3375	1.4403
Min	.0686	.0857	.0701	.1052	.0732	.128	.0876
Avg	.1423	.6407	.4361	.2764	.5079	.5001	.5498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 204 / 11 NARAYAN BET GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7087		.631	.631	.7796	.7265	.6135
2	.7973		.7011	.6485	.8505	.7265	.7011
3	.8859		.7888	.6661	.9114	.7442	.7888
4	.964		.9465	.7362	.9816	.8048	.9465
5	1.0517		1.0288	.8402	1.0867	.7973	1.0517
6	1.262		1.2174	1.0288	1.2136	1.0277	1.0867
7	1.4373			1.286	1.2309	1.3466	1.3032
8		1.2136		1.2174	1.2483	1.2757	1.2689
9		1.1269		1.0802	1.0985	1.2003	1.2174
10		1.0288		.9602	.9922	1.0288	1.2003
11		.9431	.8745	1.0117	.8916	.9259	1.1145
12		.8573	.8573	.8573	.8505	.823	.8745
13	.8059	.7202	.7716	.7888	.8505	.7716	.8059
14	.9945	.7545	.6344	.7545	.8682	.7202	.7545
15	.9259	.7362	.6859	.703	.815	.7545	.7545
16	.8402	.8764	.7545	.7108	.7796	.7202	.7716
17	.9536	.8939	.8238	.7888	.815	.9259	.8059
18	1.0402		.9114	1.0056	.8505	1.0288	.9774
19	1.0166	1.0517	1.2094	1.2656	.9568	1.166	1.0974
20	.9816	1.1744	1.1393		.9568	.8764	1.0341
21	.9816	1.0517	.964	.9991	.8859	.8238	.9114
22	.8764	.9465	.8589	.7888	.815	.8764	.8764
23	.7712	.7888	.7011	.7973	.7265	.6135	
24	.6733		.631		.7087	.7265	.5258
Max	1.4373	1.2136	1.2174	1.286	1.2483	1.3466	1.3032
Min	.6733	.7202	.631	.631	.7087	.6135	.5258
Avg	.9457	.9443	.8565	.8894	.9235	.8930	.934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 205 / 11 KV Deulgaon Gada Ag SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4773	.3201	.6028	.6508	.6745	.6798	.6028
2	1.4188	.3353	.6181	.6508	.7074	.6798	.6028
3	1.3908	.3353	.6707	.6683	.6882	.6798	.6531
4	1.422	.3506	.6859	.6683	.7209	.6981	.6531
5	1.5767	.3658	.6954	.6836	.7209	.6981	.6782
6	1.7139	.3963	.7907	.7411	.7819	.8475	.7582
7	2.0622	.4572	.4572	.8859	.8039	.881	.8192
8	1.9357	.8581	.4115	.8173	.7409	.88	.7849
9	.061	4.2105	1.7223	3.1283	3.5665	3.3989	2.7968
10		6.2224	2.9569	5.5537	4.9402	4.5705	4.5229
11		6.4739	3.0026	5.9671	5.0316	4.6735	4.9383
12		6.5767	6.1138	5.6051	5.0926	4.6106	4.6296
13	.4306	6.6473	5.7918	5.2736	4.321	4.5153	4.1723
14	.5144	6.5005	5.7804	4.9116	3.4122	4.4505	3.9342
15	.4497	6.4434	5.6108	4.8583	3.5056	4.2485	3.7399
16	.4172	5.0717	4.9364	4.4113	3.0979	4.0695	3.6123
17	.5018	3.1001	2.793	2.4092	2.1461	2.2386	2.0287
18	.6333	.3353	.5876	.6515	.5883	.5963	.6531
19	.775	.7012	.8954	.8256	.8017	.743	.8299
20	.8428	.8627	.8932	.8124	.8749	.7796	.8451
21	.8451	.8475	.8276	.7796	.823	.7796	.7971
22	.4115	.7469	.7796	.7491	.7926	.3963	.7971
23	.7164	.6486	.7316	.7164	.7255	.3506	.3963
24	.6213	.3201	.6661	.3201	.705	.634	.631
Max	2.0622	6.6473	6.1138	5.9671	5.0926	4.6735	4.9383
Min	.061	.3201	.4115	.3201	.5883	.3506	.3963
Avg	.9627	2.4636	2.0426	2.1975	1.9276	1.9625	1.8699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 206 / KHOR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.684	.503	1.1371	1.4003	1.3996	1.3641	1.3451
2	.7725	.5335	1.1218	1.387	1.435	1.3337	1.3146
3	.8611	.5639	1.1812	1.4194	1.4289	1.3355	1.3565
4	.9565	.6097	1.2041	1.5489	1.416	1.3375	1.4575
5	1.1621	.6706	1.2784	1.6785	1.4487	1.3984	1.6041
6	1.3854	.8078	1.7318	2.069	1.6667	1.8938	1.9204
7	1.6571	1.0212	1.1584	2.5892	2.2243	2.5472	2.6102
8	.3048	2.8023	1.6156	3.8961	2.9715	3.719	3.5818
9		1.153	1.5394	1.6766	1.4784	1.8595	1.9662
10		.3029	.1524				
11		.1924	.1067				
12		.1771	.1448				
13	4.4544	.2114	.0762				
14	4.8411	.2114					
15	4.5973	.1943					
16	3.9857	.1771					
17	3.195	.16					
18	1.7357	.1372					
19	1.2744	.3582					
20	.4763	.4519					
21	.3734	.3582					
22	.3277	.343					
23	.8192	.7012	1.0364	.9554	.9221	.8916	.3353
24	.9814	.7011	1.4	.6859	1.4453	1.3337	1.2163
Max	4.8411	2.8023	1.7318	3.8961	2.9715	3.719	3.5818
Min	.3048	.1372	.0762	.6859	.9221	.8916	.3353
Avg	1.7423	.5559	.9923	1.7551	1.6215	1.7285	1.7007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 401 / 33kv mahananda express

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532		.0526	.0526	.0532	.0549	.0526
2	.0532		.0526	.0526	.0532	.0549	.0526
3	.0532		.0526	.0526	.0532	.0549	.0526
4	.0526		.0526	.0526	.0526	.0549	.0526
5			.0514	.0526	.0526	.0549	.0526
6			.0514	.0514	.0526	.0549	.0526
7				.0514		.0549	.0514
8		.052		.0514		.0549	.0514
9		.052		.0514			.0514
10		.0514		.0514			.0514
11		.0514		.0514			.0514
12		.0514		.0514			.0514
13		.2058		.0514			.0514
14		.0514		.0514			.0514
15		.0514		.0514			.0514
16		.0514		.0514			.0514
17		.0514		.052		.0514	.0514
18				.052	.0549	.0514	.0514
19		.0526		.052		.0514	.0514
20		.0526	.0526	.0526		.0526	.0526
21		.0514	.0526	.0526	.0549	.0514	.0526
22	.0526	.0526	.0526	.0526	.0549	.0526	.0526
23	.0526	.0526	.0526	.0532	.0549	.0526	
24	.0532		.0526		.0532	.0549	.0526
Max	.0532	.2058	.0526	.0532	.0549	.0549	.0526
Min	.0526	.0514	.0514	.0514	.0526	.0514	.0514
Avg	.0529	.0621	.0524	.0520	.0537	.0536	.0519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214499 / 33/11 KV DAHITANE S/STN.

Feeder No / Name : 201 / 11 KV DEVKARWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	9.4365	9.648	9.6137	9.648	9.6876	9.571
2	***	9.4434	9.6423	9.5824	9.648	9.7215	9.6038
3	***	9.5013	9.6754	9.6137	9.648	9.715	9.7021
4	***	9.5138	***	9.6571	***	***	9.7021
5	***	***	***	***	***	***	***
6	***	***	***	***	***	***	***
7	***	***	***	***	***	***	***
8	***	***	***	***	***	***	***
9	***	***	***	***	***	***	***
10	9.4498	***	***	***	***	***	***
11	6.3046	***	***	***	***	***	***
12	3.2312	***	***	***	***	***	***
13	3.2083	***	***	***	***	***	***
14	3.2141	***	***	***	***	***	***
15	3.2198	***	***	***	***	***	***
16	3.2312	***	***	***	***	***	***
17	6.4853	***	***	***	***	***	***
18	6.5653	6.4361	3.3295	3.3398	6.5554	6.6796	6.4243
19	***	***	9.4803	9.6251	***	9.6632	9.145
20	***	***	***	***	***	***	9.145
21	***	***	***	***	***	***	9.5382
22	***	***	9.5611	9.6251	9.5771	9.6308	9.5382
23	***	9.6308	9.5413	9.6091	9.6091	9.5984	9.145
24	***	9.6365	9.5718	9.6091	9.145	9.6754	9.566
Max	47.5767	63.7842	64.0147	63.5483	63.6825	63.6794	63.5521
Min	3.2083	6.4361	3.3295	3.3398	6.5554	6.6796	6.4243
Avg	21.8402	29.3158	29.3113	29.2733	29.6355	29.4145	28.2979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214499 / 33/11 KV DAHITANE S/STN.

Feeder No / Name : 202 / 11 KV DAHITANE GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	.4409	***
2	.0492	***	***	***	***	.4409	***
3	.3481	***	.5304	***	.3353	.4862	***
4	.3978	.4191	.547	.4321	1.7772	.4752	.4096
5	.4527	.4359	.5868	.4641	.5121	.5365	.4807
6	.503	.4752	.6203	.5121	.5898	.5304	.5636
7	.5365	.5533	.6154	.5182	.6554	.5487	.639
8		.3887		.3353	.5304	.4748	.639
9	.2591	.3018		.3353	.3281	.4287	.2949
10	.2286	.2347		.2526	.2515	.3429	.2652
11	.208	***		***	***	.285	.2321
12	***	***	***	***	***	***	
13	***	***	***	***	***	***	***
14	***	***	***	***	***	***	***
15	***	***	***	***	***	***	***
16	***	***	***	***	***	***	***
17	***	***	***	***	***	***	***
18	***	***	***	***	***	***	***
19	.4062	.4321	.2591	.3681	.4359	.4049	***
20	.3858	.3479	.2743	.3681	.3841	.0648	
21	.3637	.3437	.2526	.3563	.2968	.3077	.2785
22	.3163	.2846	.2824	.3201	.2623	.3018	.2622
23	.2968	.2753	.3048	.2984	.3315	.2458	
24	***	***	***	***		***	***
Max	152.8481	152.7723	154.2393	152.8066	152.7601	152.8138	152.842
Min	.0492	.2347	.2526	.2526	.2515	.0648	.2321
Avg	51.6671	68.5748	70.9016	62.2264	58.3640	44.7943	71.0732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214499 / 33/11 KV DAHITANE S/STN.

Feeder No / Name : 203 / 11 KV DAHITANE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	1.3927	1.8442	1.406	1.7939	1.5939	1.6221
2	.0492	1.5415		1.4998	1.8143	1.6278	1.6385
3	.0497	1.6032	1.8233	1.531	1.7939	1.6263	1.6876
4	.0497	1.861	1.8564	1.6004	1.7772	1.5893	1.7204
5	.0503	1.9113	1.8778	1.6964	1.6804	1.643	1.8067
6	.0503	1.917	1.8778	1.7284	1.7204	1.6575	1.8233
7	.0503	1.9951	1.7976	1.7814	1.7204	1.6975	1.6221
8	.0463	1.9271		1.8138	1.757	1.6617	1.6221
9	2.2558						.0328
10	2.3929						.0332
11	2.4817						.0332
12	2.5453	.0305			.0497		
13	2.6566				.0503		
14	2.7515					.0335	.0335
15	2.8464					.0335	.0343
16	2.4691				.032		.0347
17	.0648	.0579	.0625	.0663	.0486	.0486	.0328
18	.0937	.0077	.0625	.081	.0492	.0486	.0328
19	.125	.0926	.061	.064	.0503	.0648	
20	.1543	.0791	.061	.08	.064	.0648	
21	.1581	.0937	.0594	.081	.0625	.0671	.0328
22	.1423	.0949	.0594	.08	.0617	.0671	.0328
23	.1094	1.7814	1.1584	1.7901	1.4586	1.6221	
24	.0492	1.8187	1.1888	1.7901		1.5581	1.6385
Max	2.8464	1.9951	1.8778	1.8138	1.8143	1.6975	1.8233
Min	.0463	.0077	.0594	.064	.032	.0335	.0328
Avg	.9038	1.0709	.9850	1.0681	.8880	.9281	.8165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 301 / DSM Express

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	.0754	***	***	15.4638	21.0254	***
2	24.9185	.0754	20.4912	19.6236	23.0088	24.2273	***
3	23.9198	.0377	***	***	23.6172	24.7977	16.0037
4	23.1292	.0754	.9054	***	17.2927	23.3132	***
5	23.1604	.0754	.8676	24.196	24.5698	23.8836	***
6	22.8944	2.3616	3.267	***	24.5695	18.9319	***
7	21.2163	1.1804	2.0104	***	24.1118	***	***
8	.8372	5.524	6.1653	***	19.313	***	17.2611
9	13.6032	7.7325	7.4684	19.1663	16.1892	22.6338	.4191
10	11.773	9.6384	9.4498	12.8029	13.9038	16.8378	.2278
11	15.9595	10.5891	10.2119	8.9163	9.7523	8.6824	10.0556
12	17.4833	10.4016	10.5903	7.1997	7.5804	10.1357	13.903
13	4.3053	8.0757	7.8494	6.3634	7.0103	9.4117	14.779
14	16.7219	9.1831	9.1831	6.0966	2.934	11.8884	14.5885
15	15.085	11.8122	11.8122	11.0121		12.0638	10.6269
16	11.9616	12.3042	11.9647	14.3652	2.7808	12.9173	9.143
17	6.3242	15.5781	14.9368	21.1096	13.6344	22.7862	4.1525
18	.0754	22.7862	22.7862	16.2323	***	***	.1132
19	.1132	24.6072	23.815	18.9377	***	***	.0754
20	.0754	20.3396	19.5474	***	21.6366	***	.0754
21	.0377	21.262	21.262	***	***	***	.1132
22	.0754	23.5784	22.7862	***	***	***	.0754
23	.0754	***	***	***	20.7602	***	.1132
24	.8676	***	***	***	18.3227	***	
Max	26.1059	26.4053	27.1205	27.7778	28.8379	28.7247	28.6923
Min	.0377	.0377	.8676	6.0966	2.7808	8.6824	.0754
Avg	11.6966	11.2095	14.2649	19.7324	18.0325	20.9744	12.0311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 302 / Pepsico Express

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***	***
2	***	***	***	***	***	***	***
3	***	***	***	***	***	***	***
4	***	***	***	***	***	***	***
5	***	***	***	***	***	***	***
6	***	***	***	***	***	***	***
7	***	***		***	***	***	***
8	***	***		***	***	***	***
9	***	***	***	***	***	***	***
10	***	***	***	***	***	***	***
11	***	***	***	***	***	***	***
12	***	***	***	***	***	***	***
13	***	***	***	***	***	***	***
14	***	***	***	***	***	***	***
15	***	***	***	***		***	***
16	***	***	***	***	***	***	***
17	***	***	***	***	***	***	***
18	***	***	***	***	***	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	***	***	***	***	***	***	***
23	***	***	***	***	***	***	***
24	***	***	***	***	***	***	***
Max	47.3465	51.1181	48.7563	44.5276	47.9165	46.6774	47.63
Min	38.7757	42.4304	34.9033	31.5882	35.9149	38.7137	35.3864
Avg	43.2208	45.6884	43.6323	38.0439	44.2312	43.0696	41.2235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 303 / G &F Block MIDC

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.7716	4.4582	5.7537		5.144	3.4675	
2	5.6962	4.3439	5.5632		4.8773	3.4294	
3	5.4698	4.5344	6.211		4.9535	3.8104	
4	6.1111	4.763	6.4015		4.763	3.8866	
5	5.5251	4.5344	5.6394		4.9154	4.1914	
6	6.211	4.4201	5.3727		5.0297	3.9628	
7	5.9061	5.7156	5.6394		4.382	4.6106	
8	6.0966	6.4015	6.1347		3.3913		
9		6.9349			3.3913		
10	6.5261	7.6589			3.5437	4.1914	6.7063
11	5.9823	7.6208			3.4675	5.6394	6.3253
12	5.9823	7.7351			3.7723	6.4777	6.973
13	5.487	7.0492			3.2769		4.8392
14	5.144	6.6682					6.8587
15	5.3346						6.0966
16	5.7156	7.5446					6.2491
17	5.7537	5.7537			3.0483		6.0204
18	4.4582	7.0492			3.315		5.5632
19	4.9535	6.3253			3.2769		4.6487
20	4.5725	6.1347			3.0864		5.1821
21	4.2295	5.5632			3.3913		5.5632
22	4.8773	5.3727			3.0102		5.0297
23	4.5344	6.211		5.2584	3.0483		5.1059
24	5.8848	4.6868	6.7825	5.9442	5.2965	3.0864	
Max	6.5261	7.7351	6.7825	5.9442	5.2965	6.4777	6.973
Min	4.2295	4.3439	5.3727	5.2584	3.0102	3.0864	4.6487
Avg	5.4880	5.9774	5.9442	5.6013	3.9229	4.2503	5.7972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 304 / Wheels India EXPS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1683	.4512	1.0002		1.2125	1.0014	
2	1.2795	.4793	1.0574		1.2689	1.1126	
3	1.1405	.4793	1.2003		1.0997	1.1405	
4	1.363	.4512	1.2574		1.1279	1.2239	
5	1.0014	.423	1.1431		.9869	1.1126	
6	.884	.4793	.9431		.9305	1.057	
7	.8623	.4512	1.0574		1.1279	1.1961	
8	.4451	1.3146	1.5146		1.1279		
9	.4729	1.1145			1.2125		
10	.4172	1.5242			1.5718		1.438
11	.4793	1.4575			1.1431		1.1961
12	.5075	1.0574			1.1717		.9736
13	.4572	1.4003			1.8861		1.3908
14	.4512						1.2239
15	.4512						1.5021
16	.5075	1.1717			1.2003		1.0292
17	.4512	1.6004			1.2574		1.363
18	.4512				1.5718		1.3073
19	.4512	1.6289			1.3908		1.6411
20	.4512	1.0002			1.057		1.057
21	.4512				1.2239		1.2239
22	.4793	1.2574			1.057		1.3352
23	.423	1.3432		1.5508	1.1961		1.1683
24	1.3908	1.2003	1.2003	1.438	1.3253	1.3073	
Max	1.3908	1.6289	1.5146	1.5508	1.8861	1.3073	1.6411
Min	.4172	.423	.9431	1.438	.9305	1.0014	.9736
Avg	.6849	1.0143	1.1526	1.4944	1.2340	1.1439	1.2750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 305 / 22 KV POLYONE

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.0377	.1886		.1886	.2263	
2	.1829	.0377	.1509		.1509	.1886	
3	.1886	.0377	.1886		.1886	.2263	
4	.1886	.0377	.1509		.1886	.1509	
5	.1886	.0377	.1509		.1886	.1886	
6	.2263	.0377	.1509		.1886	.1509	
7	.2263	.0377	.1509		.1509	.2263	
8		.1886	.1132		.1886		
9		.1509			.1886		
10		.1886			.2641		.1509
11	.0377	.2263			.2641		.1886
12	.0377	.1886			1.5466		.1886
13	.0377	.1886			.2263		.1886
14	.0377						.1886
15	.0377						.1886
16	.0377	.1509			.1886		.2641
17	.0377	.1509			.1509		.1509
18	.0377				.1509		.1509
19	.0377	.1886			.1886		.1509
20	.0377	.1509			.1886		.1509
21	.0377				.1886		.1509
22	.0377	.1509			.1509		.1509
23	.0377	.1886		.1886	.1886		.1509
24	.1509	.1509	.1886	.2263	.1886	.1132	
Max	.2263	.2263	.1886	.2263	1.5466	.2263	.2641
Min	.0377	.0377	.1132	.1886	.1509	.1132	.1509
Avg	.0949	.1264	.1593	.2075	.2503	.1839	.1725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II

Feeder No / Name : 301 / Classic auto tube NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634	1.8861		1.5089	2.2405	2.2405	2.2634
2	1.8861	1.8861		1.5089	1.5089	2.2405	1.8861
3	2.2634	1.8861		1.8861	2.5873	1.8671	1.5089
4	1.8861	1.8861		1.3146	2.2405	1.8671	1.8861
5	1.8861	1.8861		1.8861	1.8861	1.8671	1.5089
6	2.2634	1.8861		2.2634	1.8861	1.1203	1.5089
7	1.8861	1.5089		1.5089	1.1431	1.1203	1.8861
8	1.8861				1.9052	1.4937	2.2634
9	1.8861	1.1203		1.1088	1.1431	1.8671	1.8861
10	1.8861	1.4784		.7621	.7468	1.4937	1.1203
11	2.2634	.7392	1.8861	.7621	.7468	1.5089	1.5089
12	1.8861	1.4784	.3772	.381	.7468		1.8861
13	1.8861	1.1088	1.1317	.7621	.7392	1.1317	.7545
14	1.5089	1.848	1.1317	1.5242	.3734	1.5089	2.6406
15	.7545	.3696	.3772	.381	.3734	.7545	.3772
16	1.5089	1.1088	1.5089	1.5242	1.4937	1.5089	2.2634
17	2.2634	.7392	1.5089	1.9052	1.8671	2.2634	2.6406
18	2.2634	1.848		2.6673	1.8671	1.8861	2.6406
19	3.0178	2.5873		2.2862	1.8671	1.8861	1.8861
20	1.8861	1.848		1.9052	1.8671	1.8861	1.5089
21	1.8861	1.848		2.2862	2.2405	1.5089	2.6406
22		1.848		1.9052	2.6139	2.2634	2.2634
23		1.1088		.7316	2.2405	1.8861	1.1203
24		1.8861	2.2177	1.5089	2.2634	1.8671	1.5089
Max	3.0178	2.5873	2.2177	2.6673	2.6139	2.2634	2.6406
Min	.7545	.3696	.3772	.381	.3734	.7545	.3772
Avg	1.9580	1.5561	1.2674	1.4904	1.6078	1.6973	1.8066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II

Feeder No / Name : 302 / Jabil Circuit

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.1203	1.3717	1.4937	1.1431	1.5242	1.1317
2	.7468	1.1203	1.3717	1.1317	1.1431	1.5242	1.5089
3	1.1317	1.1317	1.2193	1.1203	1.5242	1.1431	1.5089
4	.7468	1.1203	1.2193	1.4937	1.5242	1.5242	1.5089
5	.7468	1.1203		1.1203	1.1431	1.1431	.7545
6	.3734			1.4937	1.1431	.7621	.7545
7	.1867	1.1203		1.4937	1.1431	1.1431	.7545
8	.3734				1.1431	1.1431	.7545
9	.3734	1.1431		1.1431	1.1431	1.1431	.7545
10	.3734	.7621		1.1431	1.1431	1.1431	1.1431
11	.1867	.7621	1.5089	1.1431	1.1431	1.4937	1.1431
12	.1867	.7621	1.1203	.7621	1.1431		1.1431
13	.1867	.7621	1.1203	1.1431	1.1431	1.5089	.7621
14	.7468	1.1431		1.1431	.7621	1.1317	1.1431
15	.7468			1.1431	1.5242	.7621	.7621
16	.7468	1.1431		1.5242	1.1431	1.1317	.7621
17	.7468	1.5242	1.4937	1.5242	1.5242	1.5242	1.1431
18	.7468	1.5242		1.5242	1.5242	1.5089	1.1431
19	1.1203	1.5242		1.5242	1.9052	1.1317	1.1431
20	1.1317	1.5242		1.5242	1.9052	1.5089	1.1431
21	1.1203	1.5242		1.5242	1.9052	1.1317	1.1431
22		1.1431		1.1431	1.1431	.7545	1.1431
23		.7621		1.1431	1.5242	1.1317	1.1431
24		1.1317	1.1431	1.1317	1.1431	1.1431	1.1317
Max	1.1317	1.5242	1.5089	1.5242	1.9052	1.5242	1.5089
Min	.1867	.7621	1.1203	.7621	.7621	.7545	.7545
Avg	.6590	1.1366	1.2854	1.2840	1.3178	1.2198	1.0593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214333 / 33/11 kv Pabal

Feeder No / Name : 201 / 11 kv Pabal

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1835	.5563	.5411	1.307		
2		1.1835	.5487	.5411	1.307		
3		1.1835	.5487	.5411	1.3443		
4		1.2734	.5716	.5411	1.3817		
5		1.3939	1.2784	.5944	1.5123	1.1389	
6		1.6126	.7316	.7087	1.6804		
7		1.8854	1.9379	.8993	2.2218		
8		.9983	1.9555	.9831	2.2032	2.4646	
9		1.0212	1.166	1.2803	.7095		
10	.6348	2.7511	2.6444	2.2779		.6024	
11	.5228	5.4793	2.6216		.5228	.5493	.5415
12	.5041	2.7282	2.4539	2.1472			.5228
13	.5041	4.9825	2.3701	2.2592			.5041
14	.4854	2.6216	2.3472	1.0642	.4668		.4854
15	.4668	2.5987	2.3853	1.4937			.4854
16	.4854	4.7081	2.3701	1.8484			.4854
17	.5041	2.8029	2.3167	.5041	.4481		.4481
18	.6161	.503	.5106	.5601			.5788
19	.7282	1.504	.724	.8589	.8215		.7655
20	.8029	.823	.8535	.8029			.8215
21	.7095	.8307	.8459	.7468			.7468
22	.6161	1.4384	.7545	.5975	.6535		.5788
23	.7095	.663	.6325	1.3443			1.1949
24	.7087	3.1261	1.105	2.5393	.4108	.9335	.6161
Max	.8029	5.4793	2.6444	2.5393	2.2218	2.4646	1.1949
Min	.4668	.503	.5106	.5041	.4108	.5493	.4481
Avg	.5999	2.0540	1.4263	1.1163	1.1327	1.1377	.6268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214333 / 33/11 kv Pabal

Feeder No / Name : 202 / 11 kv Dhamari
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1576			1.3443		
2		1.1576			1.3443		
3		1.1576			1.3443		
4		1.531			1.531		
5		1.7177	1.251		1.9231	.5975	
6		1.8671			2.1285		
7		1.8484	1.8858		3.006		
8			1.7924		3.1927	3.8089	
9					1.419		
10	1.251			3.3794		1.134	
11	1.0269	3.5475			.9335	.9036	1.0269
12	.8029			3.1367			.9896
13	.8029	3.3981		3.0807			.9522
14	.7095			2.838	.8215		
15	.7468			2.2405			
16	.7282	2.894		1.7737			.7282
17	.8589	.6908		.7655	.6908		.7468
18	1.1203			.8775			1.0829
19	1.4937	1.6804		1.7177	1.5497		1.6057
20	1.6804			1.5497			1.643
21	1.419			1.307			1.4563
22	1.1949	1.0829		1.0829	1.1016		1.0456
23	.9709			1.2883			1.4003
24	1.5364	2.8006	.8859	3.062	.5975	1.4632	1.2696
Max	1.6804	3.5475	1.8858	3.3794	3.1927	3.8089	1.643
Min	.7095	.6908	.8859	.7655	.5975	.5975	.7282
Avg	1.0895	1.8951	1.4538	2.0071	1.5285	1.5814	1.1623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214333 / 33/11 kv Pabal

Feeder No / Name : 203 / 11 kv Kendur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		4.1876	2.1491	1.9814	.6535		
2		4.1571	2.1186	1.9509	.6535		
3		4.1419	1.9814	1.8595	.6535		
4		4.2048	1.9814	1.89	.7842		
5		4.4353	4.0687	2.0729	1.0456	.9522	
6		4.9725	2.5453	2.4691	1.1763		
7		6.8092	6.0303	3.094	1.4003		
8		4.039	7.3304	3.719	1.307	1.2696	
9		3.4294	3.6885	3.5056	3.6595		
10	3.5475	.9602	.9907	.8775		4.2701	
11	4.5557	1.3969	.7468		3.9209	4.5176	4.201
12	4.2383	.5487	.5944	.5788			4.1076
13	4.3877	.8036	.5182	.5601			4.0703
14	4.5184	.4268	.5792	.5228	3.0807		3.6408
15	4.0703	.4877	.5487	.5228			3.8836
16	4.1076	.061	.5639	.5228			3.1927
17	.4668	.061	.5944	.6348	.5228		.4481
18	.7468	.7316	.6706	.7282			.7842
19	1.0456	2.2618	1.1431	1.1949	1.1949		1.2323
20	1.1763	1.2041	1.2193	1.1389			1.1949
21	.9896	1.1736	1.1126	.9335			1.1203
22	.8029	1.9106	.945	.8402	.8962		.7282
23	1.8298	1.7375	1.4784	.6535			.6908
24	3.3288	3.4561	3.6023	.8775	3.4728	.7682	3.4355
Max	4.5557	6.8092	7.3304	3.719	3.9209	4.5176	4.201
Min	.4668	.061	.5182	.5228	.5228	.7682	.4481
Avg	2.6541	2.3999	1.9667	1.4404	1.6281	2.3555	2.3379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214333 / 33/11 kv Pabal

Feeder No / Name : 204 / 11kv Pabal Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8154			.3734		
2		.8078			.3734		
3		.8078			.3734		
4		1.0212			.4481		
5		1.2993	.4668		.5601		
6		1.5917			.7468		
7		1.9581	.9335		.8402		
8		1.0707	.8215		.8589	.9149	
9		1.0593			.7468		
10	.7095	.9031		.7095			
11	.4854	1.4045			.6722	.7655	.7468
12	.4668	.6821		.5975			.6535
13	.5228	1.174		.4854			.5415
14	.4854	.5716		.4294	.3547		.4668
15	.5415	.5601		.4668			.4668
16	.5228	1.1325		.5228			.5415
17	.4854	1.2875		.5415	.3921		.5975
18	.6348	.7125		.5601			.6535
19	.8029	1.5089		.8215	.7842		.6908
20	.8029	.8726		.7095			.7468
21	.6348	.8307		.6722			.6722
22	.5228	1.1709		.5601	.6348		.4668
23	.4294	.5144		.4108			.4294
24	.8048	.9713	.439	.5975	.3361	.439	.7842
Max	.8048	1.9581	.9335	.8215	.8589	.9149	.7842
Min	.4294	.5144	.439	.4108	.3361	.439	.4294
Avg	.5901	1.0303	.6652	.5775	.5663	.7065	.6042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214451 / 33 KV NHAVARA

Feeder No / Name : 201 / 11 KV Uralgaon
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-JAN-17	10-JAN-17
HR	Load (MW)	Load (MW)
1	1.733	1.9601
2	1.7574	1.9799
3	1.7726	1.9555
4	1.8061	1.9646
5	1.8686	2.0195
6	1.954	2.1719
7	2.1506	2.3487
8	2.4463	2.7161
9	2.7039	2.5956
10	.7133	.7362
11	.5563	.6158
12	.3917	.4359
13	.3628	.4085
14	.3765	.3917
15	.3201	.3917
16	.3033	.3551
17	.3506	.3673
18	.4191	.4313
19	.7164	.6813
20	.9023	.8962
21	.849	
22	.7484	
23	.7834	
24	1.9418	
Max	2.7039	2.7161
Min	.3033	.3551
Avg	1.1636	1.2711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214514 / 33/22 kV PIMPALE JAGTAP Sub
StFeeder No / Name : 301 / 22 KV Pimpale Jagtap AG
Feeder KV- 22 / OUTGOING

SHEDDABLE RURAL

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9008	.8764	.8825	1.7848	1.7009	1.7612	1.7818
2	.9175	.881	.8886	1.7772	1.6156	1.7924	1.7681
3	.9419	.9267	.9221	1.9223	2.4783	2.3289	1.8016
4	1.0517	.977	.9907	2.1917	2.62	2.6863	1.8885
5	1.2605	1.1706	1.2102	2.5396	2.8006	2.8243	2.532
6	1.5943	1.5653	1.6065	3.307	3.264	3.1733	3.1615
7	1.9143	1.8701	1.8991	3.959	3.5192	3.5985	3.6953
8	1.9387	1.8686	1.8305	3.7704	3.6024	3.6107	3.6249
9	2.681	5.8566	2.9203	5.8155	5.1075	5.4382	5.8719
10	3.6382	3.4492	3.4797	6.6568	6.2003	6.432	6.3512
11	7.1872	7.0729	3.5223	6.6613	3.3318	6.6575	6.1576
12	3.6549	7.0119	6.7672	6.97	4.9154	6.4898	6.2094
13	3.6245	6.7596	6.467	6.5432	4.9398	6.0463	6.0113
14	3.6046	6.6461	6.4137	6.0128	4.862	5.9548	5.8893
15	3.3745	6.4685	6.054	6.0753	4.8422	5.8467	5.8162
16	3.2907	6.3214	6.4602	5.5365	4.638	5.8772	5.6699
17	2.8212	3.7914	3.5528	3.1749	3.0109	3.7014	3.3364
18	.8002	1.6491	1.5512	1.3599	.5548	1.7977	1.8251
19	1.3291	2.7389	2.9488	2.8342	2.9729	2.9767	2.7298
20	1.4952	3.0011	3.1147	3.0826	3.0072	2.9919	2.8167
21	1.4906	2.7983	2.9283	2.9889	2.8776	2.8913	2.7672
22	1.3641	2.4028	2.5362	2.9062	2.7374	2.4524	2.4287
23	1.0745	2.0279	2.0675	2.0298	2.2284	2.0424	2.0043
24	.9297	1.829	.9282	1.8713	1.6781	1.9418	1.853
Max	7.1872	7.0729	6.7672	6.97	6.2003	6.6575	6.3512
Min	.8002	.8764	.8825	1.3599	.5548	1.7612	1.7681
Avg	2.2033	3.3317	2.9976	3.8238	3.3127	3.8047	3.6663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214514 / 33/22 kV PIMPALE JAGTAP Sub
StFeeder No / Name : 303 / 22 KV Industrial
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3123	1.2391	1.5699	1.9273	2.9493	2.3015	3.2808
2	1.3824	1.2391	1.5516	1.8012	2.8883	2.4318	3.1855
3	1.3413	1.2849	1.6903	1.7951	2.835	2.3396	3.1661
4	1.4007	1.2849	1.7711	1.7559	3.0285	2.367	3.0925
5	1.4571	1.358	1.9372	1.7714	2.6155	2.4562	3.4492
6	1.4708	1.3763	1.9418	1.7943	2.3967	2.6505	3.6675
7	1.4967	1.8915	2.5072	2.0812	2.3495	4.5359	4.3118
8	1.5897	1.9692	2.3243	1.7657	2.3793	4.4414	4.3145
9	2.1323	3.2739	2.6261	2.1784	2.0934	3.7373	4.5489
10	2.1506	2.0439	2.3091	4.1396	2.1857	4.4407	4.6075
11	3.1649	3.533	2.2451	3.8295	2.1902	4.0627	4.6761
12	2.1186	3.2872	5.0251	3.5818	2.0538	4.2928	4.6768
13	1.8397	3.5887	4.3614	4.1327	2.0744	3.9057	3.7883
14	2.0683	3.6599	5.2355	3.7159	2.0965	4.007	4.1031
15	1.6095	3.4126	4.4101	3.3592	1.7536	4.1251	3.962
16	1.422	3.1626	3.3856	2.4669	1.8496	3.2122	4.0314
17	1.3291	3.413	3.035	2.5758	2.072	3.4499	3.8478
18	1.3077	3.5052	3.2991	3.285	2.2146	3.2069	3.9857
19	1.3672	3.7475	3.4805	3.3863	2.383	3.3761	4.4956
20	1.3093	3.6515	3.3375	3.2628	2.3495	3.5787	3.6237
21	1.2346	3.4587	3.0418	3.0266	2.2497	3.0758	3.4133
22	1.1782	3.5491	3.1256	2.7743	2.2756	3.2435	4.3378
23	1.1706	3.5395	2.7218	2.9679	2.1354	3.4149	3.4492
24	1.2026	3.1184	1.5867	3.0724	2.2619	2.8761	2.694
Max	3.1649	3.7475	5.2355	4.1396	3.0285	4.5359	4.6768
Min	1.1706	1.2391	1.5516	1.7559	1.7536	2.3015	2.694
Avg	1.5857	2.7328	2.8550	2.7686	2.3200	3.3971	3.8629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 201 / 11 KV WAGHESHWAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1187			.1255	
2		.1187			.1255	
3		.1221			.1255	
4		.1221			.1289	
5		.1221			.1323	
6		.1221			.1357	
7		.1166			.1357	
8		.1085			.1153	
9	2.713			3.2895		1.5261
10	2.9504		3.658	3.3234		3.242
11	2.9843		3.7151	3.4252		3.0521
12	2.9843		3.7913	3.4591		2.9911
13	3.0521		3.7913	.2849		2.9843
14	3.2013		3.7151	2.9843		2.9843
15	3.2217		3.7342	3.12		2.9843
16	3.2013		3.7151	3.12		2.9843
17	.0543		.08	.0678		.0814
18	.0678		.1067	.0823		.095
19	.095		.1372	.1097		.1153
20	.1085		.1524	.1303		.1221
21	.1255		.1524	.1303		.1255
22	.1357		.1448	.1289		.1221
23	.1153		.1296	.1289		.1269
24	.1486	.1153			.1289	
Max	3.2217	.1221	3.7913	3.4591	.1357	3.242
Min	.0543	.1085	.08	.0678	.1153	.0814
Avg	1.5724	.1185	1.9302	1.5856	.1281	1.5691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 202 / 11 KV SIDDHESHWAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6802			.5603	
2		.6931			.5603	
3		.6964			.583	
4		.7125			.5895	
5		.7773			.6478	
6		.8907			.8421	
7		1.2308			1.2308	
8		1.3441			1.4154	
9	.1522			.1652		.1619
10	.1328		.1638	.1587		.1393
11	.1296		.16	.1328		.1296
12	.1166		.1296	.1004		.1134
13	.1166		.1105	.0972		.1036
14	.1134		.0876	.0972		.068
15	.1134		.0953	.0842		.081
16	.1069		.1296	.0972		.0874
17	.1522		.1638	.1101		.1522
18	.1846		.221	.1166		.1781
19	.2429		.2362	.204		.2008
20	.2623		.2439	.1781		.1943
21	.2008		.1981	.1425		.1814
22	.1555		.1638	.1328		.1619
23	.664		.8345	.5182		.583
24		.6802			.5506	
Max	.664	1.3441	.8345	.5182	1.4154	.583
Min	.1069	.6802	.0876	.0842	.5506	.068
Avg	.1896	.8561	.2098	.1557	.7755	.1691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 203 / Junamala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3927			1.3992	
2		1.4251			1.3992	
3		1.4251			1.4251	
4		1.4575			1.4316	
5		1.5223			1.4899	
6		1.749			1.6194	
7		2.1376			2.0729	
8		2.332			2.2348	
9	1.8461			.2591		.3401
10	.1619		.2439	.2397		.2656
11	.149		.2134	.1943		.2591
12	.136			.1555		.2267
13	.1296		.1524	.1425		.1846
14	.1166		.1524	.149		.136
15	.1296		.16	.1231		.149
16	.136		.1524	.1425		
17	.2138		.1981	.2008		.1943
18	.2656		.3429	.298		.2591
19	.3368		.3963	.3433		.2785
20	.3142		.423	.3563		.298
21	.2915		.3887	.2915		.3174
22	.2785		.3658	.285		.298
23	1.3927		1.7756	1.3603		1.3927
24		1.3927			1.3927	.2785
Max	1.8461	2.332	1.7756	1.3603	2.2348	1.3927
Min	.1166	1.3927	.1524	.1231	1.3927	.136
Avg	.3932	1.6482	.3819	.3027	1.6072	.3252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 301 / Mandavgaon

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9433		1.9052	1.6194	
2				1.9052	1.6194	
3		1.9433		1.9052	1.6194	
4		1.9433		1.9052	1.6194	
5		1.9433		1.9052	1.6194	
6		2.1052		2.0957	1.6194	
7		2.1052		2.2862	1.8023	
8		2.1052		2.2862	1.9433	
9	.2591			.2622		.2622
10	.2267		.2286	.2294		.2622
11	.1943		.2286	.1966		.2294
12	.1943		.1905	.1966		.1966
13	.1943		.1905	.1966		
14	.1943		.1905	.1966		
15	.1943		.1905	.1966		.1943
16	.1943		.1905	.1966		.1966
17	.2267		.2286	.1966		
18	.2591		.2286	.2622		.2294
19	.2591		.3048	.2622		.2622
20	.2622		.381	.2622		.2622
21	.2622		.381	.2622		.2622
22	.2622		.3048	.2622		.2622
23	1.9433		1.9052	1.6385		1.6194
24		1.9433		1.9052	1.6194	
Max	1.9433	2.1052	1.9052	2.2862	1.9433	1.6194
Min	.1943	1.9433	.1905	.1966	1.6194	.1943
Avg	.3418	2.0040	.3674	.9549	1.6757	.3532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 302 / Babhulsar

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3315			.3315	
2		.3315			.3315	
3		.3315			.3315	
4		.3315			.3315	
5		.3978			.3315	
6		.4641			.3978	
7		.5304			.5304	
8		.5304			.5304	
9	.1326			.1326		.1326
10	.0995		.1524	.0995		.0995
11	.0995		.1143	.0995		.0995
12	.0995		.1524	.0995		.0995
13	.0995		.1143	.0995		.0995
14	.0995		.1143	.0995		.0995
15	.0995		.1143	.0995		.0995
16	.0995		.1143	.0995		.0995
17	.0995		.1524	.0995		.0995
18	.1326		.1524	.0995		.0995
19	.1326		.1524	.1326		.1326
20	.1326		.1524	.1326		.1326
21	.1326		.1524	.1326		.1326
22	.1326		.1524	.1326		.1326
23			.381	.3315		.3315
24		.3315		.381	.3315	
Max	.1326	.5304	.381	.381	.5304	.3315
Min	.0995	.3315	.1143	.0995	.3315	.0995
Avg	.1137	.3978	.1551	.1419	.3831	.126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 303 / Inamgaon

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2622		.2286	.2622
2		.2622		.2286	.2622
3		.2622		.2286	.2622
4		.1638		.2286	.2622
5		.2622		.2286	.2622
6		.2949		.3048	.2949
7		.2949		.3048	.2949
8		.2949		.3048	.2622
9	4.2105			4.2105	4.2105
10	4.5344		4.7249	4.2105	4.2105
11	4.5344		4.9535	4.2105	
12	4.5344		4.9535	4.2105	4.2105
13	4.5344		4.9535	4.2105	4.2105
14	4.2105		4.9535		4.2105
15	4.5344		4.5725	3.5627	4.2105
16	4.5344		4.5725	3.5627	3.8866
17	.2591			.2591	.2591
18	.2591				.2591
19	.2591		.3048	.2622	.2622
20	.2622		.381	.2622	.2652
21	.2622		.381		.2622
22	.2622		.3048	.2622	.2622
23	.2622		.3048	.2622	.2622
24		.2622		.3048	.2622
Max	4.5344	.2949	4.9535	4.2105	4.2105
Min	.2591	.1638	.3048	.2286	.2591
Avg	2.4969	.2622	2.9467	1.5166	1.4525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 304 / GFSS Mandavgan Farata

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.414		.4534	.4066	
2		.4435		.4344	.414	
3		.4509		.4344	.4214	
4		.5027		.442	.4435	
5		.5618		.4496	.5248	
6		.7392		.5563	.5988	
7		.7901		.8154	.8168	
8		.7389		.7697	.7466	
9	.6062			.6431		.6468
10	.4509		.6173	.5692		.6796
11	.4214		.503	.4879		.5396
12	.3955		.4458	.367		.4768
13	.3068		.3963			.4066
14	.3585		.362	.4177		.3918
15	.3622		.4572	.3326		.414
16	.3733		.5411	.3918		.4509
17	.5064		.6173	.4609		.463
18	.6062		.6706	.5655		.4805
19	.7133		.8497	.7244		.5766
20	.6871		.8078	.6722		.6801
21	.6049		.7087	.5825		.5988
22	.4817		.5563	.4481		.4805
23	.4066		.4649	.414		.4509
24		.4066		.4534	.4066	
Max	.7133	.7901	.8497	.8154	.8168	.6801
Min	.3068	.4066	.362	.3326	.4066	.3918
Avg	.4854	.5609	.5713	.5168	.5310	.5158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 305 / Gfss Inamgaon - Babulsar

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0306		.9907	.9858	
2		1.0456		.9907	.9858	
3		1.0456		.9907	1.0082	
4		1.0605		.9983	1.0082	
5		1.1277			1.0232	
6		1.3966			1.2248	
7		1.643			1.5833	
8		1.5908			1.5011	
9	1.0605			1.2024		1.4937
10	.9037		1.0822	1.0605		1.1277
11	.8215		.9983	.9709		.8953
12	.8215		.8688	.9858		.8962
13			.7697	.9858		.8962
14			.6249			.8439
15	.8365		.6173	1.0456		.8215
16	.8962		.5868	1.0605		.8962
17	.9858			1.1203		.9709
18	1.1352			1.2222		1.1352
19	1.292		1.4556	1.358		1.2024
20	1.358		1.387	1.2826		1.2696
21	1.1392		1.3032	1.1203		1.2099
22	1.0713		1.1584	1.0605		1.0979
23	1.0456		.9983	.9709		1.0456
24		1.0157		.9907	.9709	
Max	1.358	1.643	1.4556	1.358	1.5833	1.4937
Min	.8215	1.0157	.5868	.9709	.9709	.8215
Avg	1.0282	1.2173	.9875	1.0741	1.1435	1.0535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33 KV NHAVERA

Feeder No / Name : 202 / 11 KV Ambale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.4542	.4268	.4119	.3761	.4656	.4298
2	.4656	.4527	.4268	.394	.4119	.5014	.4835
3	.4835	.4877	.4443	.4298	.5014	.5194	
4	.6447	.5235	.5007	.5731	.6447	.5731	.6626
5	.7522	.6577	.6005	.6626	.823	.6626	.7701
6	.8775	.8932	.8276	.8954	.8916	.8596	.9671
7	1.0208	1.07	1.07	1.0566	.9945		.8775
8	***	1.1439	1.1096	1.0029	.9134		.9671
9	1.0387	1.2544	.5777	1.0208	.9259		1.0208
10	.583	1.3024	1.0738	.8954	.8954		.9313
11		1.7927	1.608	2.3819	.6984	.9492	1.0029
12		1.4601	.7324	.5731	.5731	.5731	.8059
13		1.2731		.7522	.5194	.7522	.6984
14		1.1595		.6984	.4854	.7282	.6089
15		1.0703	.367	.7164	.4656	.7468	.3045
16		.8234	1.1466	.8059	.5014	.8059	.7343
17		.8874	1.142		.591	.7522	.591
18		1.0277	1.2856		.7522	1.0642	.7164
19		1.7501	1.7089	1.1104	.9134	1.1694	.788
20		1.7905	1.7303	.9313	.8954	.9808	.8059
21		1.555	.6268	.6984	.6805	.7356	.6626
22		1.2913	.5373	.591	.591	.6224	.6805
23		1.0779	.4298	.5373	.5373	.5373	.5373
24	.4656	.49		.4298	.4298	.4835	.4835
Max	10.0827	1.7927	1.7303	2.3819	.9945	1.1694	1.0208
Min	.4298	.4527	.367	.394	.3761	.4656	.3045
Avg	1.5313	1.0704	.8749	.7986	.6672	.7241	.7187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33 KV NHAVERA

Feeder No / Name : 203 / 11 KV Kolape Wasti Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5402	.301	.5494	.2507	.197	.2328	.2149
2	1.576	.301	.5704	.2328	.2686	.2507	.2507
3	1.6476	.3185	.3094	.2507	.3361	.2686	.3224
4	1.7909	.3323	.6749	.3582	.3582	.3224	.394
5	1.9521	.3818	.8028	.394	.4656	.3582	.4477
6	2.0953	.4633	1.0174	.4835	.5014	.4656	.4835
7	2.4893	.5891	.5937	.5041	.5316		.5194
8	2.7042	.6135	1.0536	.4835	.4835		.5014
9	.4119	.9404	.8467	2.2923	2.2565		2.2207
10	.2507	2.9134	2.7496	2.5431	2.3663		2.5072
11		5.932	5.7346	2.3819	2.561	2.3819	2.3998
12		6.2247	5.4778	2.4535	2.5252	2.4535	2.2923
13		6.0852	5.2899	2.5431		2.6513	2.3282
14		5.8654	5.4587	2.4535	2.3998	2.5579	2.2207
15		5.6089	5.463	2.3282	2.561	2.4272	2.2923
16		5.0941	5.4325		2.5252		.2328
17		2.8988	2.9831				
18		.6282	.6105	.3403	.2507	.3403	.3403
19		.8825	.8847	.4298	.4119	.4527	.3582
20		.9252	.9777	.4119	.4119	.4338	.3761
21		.8495	.394	.3403	.394	.3584	.3582
22		.7327	.3045	.2686	.2865	.2829	.2865
23		.6119	.2865	.2507	.2686	.2507	.2686
24	1.5939	.2995	.2507	.2686	.2507	.2507	.2328
Max	2.7042	6.2247	5.7346	2.5431	2.561	2.6513	2.5072
Min	.2507	.2995	.2507	.2328	.197	.2328	.2149
Avg	1.6411	2.0747	2.0298	1.0120	1.0278	.9300	.9499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33 KV NHAVERA

Feeder No / Name : 301 / Nhavara

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854			.2987	.2987	.2987	.2987
2	.3734			.2987	.3734	.2987	.2987
3	.4481			.2987	.4481	.2987	.3361
4	.4854			.3361	.4854	.2987	.4108
5	.4854			.3361	.5228	.3734	.4854
6	.5228			.4854	.5975	.5601	.5601
7	.7095			.7468	.7842		.7095
8	.7468			.7842	.8589		.8589
9	.6722			.6348	.7095		.6722
10	.5975			.8962	.6348		.6722
11		.5228	.4854	.5228	.4854	.5601	.5228
12		.4108	.4481	.4481	.8962	.5228	.4854
13		.4108	.4481	.4481	.8962	.4481	
14		.4108	.4108	.3734	.9335	.3734	.3734
15		.4108	.4108	.4481	1.0082	.4481	.2987
16		.4108	.4481	.4481	1.0829	.4108	.4108
17		.5228	.4481	.4854	.4108	.4854	.4481
18		.4854	.5228	.5228	.6722	.5228	.5228
19		.6348	.6348	.5601	.6722	.6413	.5601
20		.6036	.4854	.5601	.5975	.5658	.4108
21		.4904	.4481	.5228	.5228	.4904	.4108
22		.415	.3734	.3734	.4108	.415	.3734
23		.3734	.2987	.2987	.3734	.3361	.3361
24	.5601			.5228	.2987	.6413	.2987
Max	.7468	.6348	.6348	.8962	1.0829	.6413	.8589
Min	.3734	.3734	.2987	.2987	.2987	.2987	.2987
Avg	.5533	.4694	.4510	.4854	.6239	.4495	.4676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33 KV NHAVERA

Feeder No / Name : 302 / Nimbone

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7342			.3734	.3734	.3734	.3734
2	3.8089			.3361	.4481	.4108	.4108
3	3.9582			.3734	.4854	.4854	.4854
4	4.1823				.5228	.4854	.5601
5	4.4063			.5228	.5975	.5975	.6348
6	4.481			.7095	.6722	.7095	.7095
7	5.2279			.7842	.8962		.7842
8	5.7507			.8589	.7842		.8589
9	.6722			5.3772	5.3772		5.5266
10	.5601			6.0867	6.0494		5.9
11		6.0867	6.4975	6.3108	6.1241	6.4228	6.2734
12		6.7215	6.4602	6.5722	6.4602	6.2361	6.0867
13		6.5348	6.5348	6.8709	6.4975	5.9747	6.1988
14		6.5348	6.7962	6.6469	6.6095	6.2734	6.2734
15		6.4228	6.7589	6.4975	6.8709	6.2734	5.9457
16		6.2734	6.5348	6.0867	6.4602	5.9	5.9747
17		.3772	.4108	1.5043	.3734	.415	.4108
18		.3772	.5601	2.0416	.3734	.4108	.7095
19		.6036	.7095	.7095	.5601	.7545	.7095
20		.5658	.6348	.7095	.6722	.679	.6722
21		.5281	.5601	.5975	.5975	.6036	.6348
22		.4527	.5228	.5228	.5228	.5281	.5601
23		.4108	.4481	.4854	.4854	.4854	.4854
24	3.8836			.4108	.4481	.4481	.4481
Max	5.7507	6.7215	6.7962	6.8709	6.8709	6.4228	6.2734
Min	.5601	.3772	.4108	.3361	.3734	.3734	.3734
Avg	3.6969	3.2223	3.3407	2.6691	2.4692	2.2233	2.4011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33 KV NHAVERA

Feeder No / Name : 303 / 22 KV Alegaon AG feeder

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734			4.0703	3.8836	4.1076	4.1076
2	.4108			3.8462	4.0329	4.257	4.2196
3	.4481			3.8836	4.1823	4.257	4.257
4					4.481	4.369	4.369
5				4.4063	4.7051	4.5184	4.5931
6				4.7051	4.7798	4.9665	4.8171
7	.9335			5.3026	5.2279		5.3772
8	.8215			5.4146	5.676		5.9
9	5.5639			.6722	.6348		.7842
10	6.0867			.4854	.4854		.7095
11		.3361	.3734	.4108	.4108	.5228	.5975
12		.3361	.3361	.2987	.2614	.4481	.5228
13			.3361		.2614	.3734	.4108
14			.2987	.2614	.2614	.3734	.4854
15			.2614	.3734	.2987	.3734	.3734
16			.2987	.5373	.4108	.4108	.4108
17		.3361	.3361	.0358	.4481	.415	.4108
18		.4108	.2987	.3734	.5601	.5601	.6722
19		.8215	.8215	.7842	.7842	.8299	.7095
20		.7167	.7468	.7095	.7468	.7167	.7468
21		.7167	.6722	.5975	.6348	.679	
22		.6036	.5975	.6348	.5601	.6036	.5601
23		3.8462	4.0329	4.0703	3.9209	3.9582	3.9956
24	.4481			4.1823	3.9956	4.0329	4.0329
Max	6.0867	3.8462	4.0329	5.4146	5.676	4.9665	5.9
Min	.3734	.3361	.2614	.0358	.2614	.3734	.3734
Avg	1.8858	.9026	.7239	2.0934	2.1518	2.0386	2.3071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33 KV NHAVERA

Feeder No / Name : 304 / GFSS Alegaon Paga

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	11-JAN-17
HR	Load (MW)
20	1.2696
Max	1.2696
Min	1.2696
Avg	1.2696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33 KV NHAVERA

Feeder No / Name : 305 / 22 Kv Mallikarjun GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722			.7842	.6722	.7468	.7842
2	.8589			.8589	.8589	.8962	.8962
3	.9335			.9335	.9335	.9709	1.0082
4	1.1203			1.0829	1.0829	1.0082	1.1203
5	1.1949			1.1576	1.1576	1.1949	1.2323
6	1.2696			1.2696	1.2696	1.1949	1.419
7	1.3817			1.2696	1.3817		1.4937
8	1.307			1.2323	1.419		1.2696
9	.112			1.2323	1.0829		1.3817
10	1.3443			1.0829	.8962		1.2696
11		.8589	.5601	.7468	.8215	.8589	1.1203
12		.7842		.6355	.8215	.7842	.8215
13		.7842		.7842	.8215	.7095	.8962
14		.7095		.7095	.8589	.7842	
15		.7468	.5975	.6722	.7842	.8215	.7842
16		.7468	.7468	.7095	.7842	.8962	.7468
17		.7842	.8215	.6722	.6722	.8215	.6348
18		.9709	.9709	.8962	.9335	1.0829	1.2323
19		1.3443	1.1949	1.307	1.307	1.3203	.5228
20		1.2449			1.1576	1.2449	.7468
21		1.0185	1.0456	1.0829	.9709	1.094	.8215
22		.8676	.9709	.9335	.9335	.9808	.7468
23		.8215	.8215	.8589	.8215	.9335	.8215
24	.8215			.8215	.7202	.7842	.8589
Max	1.3817	1.3443	1.1949	1.307	1.419	1.3203	1.4937
Min	.112	.7095	.5601	.6355	.6722	.7095	.5228
Avg	1.0014	.8986	.8589	.9449	.9651	.9564	.9839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 301 / TAKALI HAJI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	1.9589	1.8671	1.848	1.8671	1.7741	2.2546
2	.4108	1.9959		1.922	2.0328	1.848	2.2177
3	.4481	2.0328		2.0328	2.0328	1.885	2.2177
4	.4481	2.0328		2.1068	2.4025	1.9589	2.3285
5	.5175	2.2177		2.2546	2.7435	2.0328	2.4394
6	.583	2.5133		2.4764	2.9264	2.7721	2.7721
7	.7392	3.2156		3.2156	2.9264	2.9569	3.4004
8	.8131	3.2922		3.6214	3.658	3.4751	3.5848
9	4.0238	.7392		.8048	.7392	.9709	.7762
10	4.3439	.6348		.6653	.6348	.6283	.7023
11	4.2353	.6348		.5601	.5175	.5914	.6283
12	4.0181	.5853		.5175	.4108	.5228	.5544
13	4.2798	.3658	.4805	.4066	.3326	.4854	.4435
14	3.9872	.4805	.4805	.4435	.3326	.4108	.3696
15	3.914	.3326	.4805	.3734	.2957	.4108	.3696
16	3.8409	.5175	.4805	.2987	.3696	.4108	.4066
17	.3361	.5175	.5228	.4108	.3734	.5228	.4108
18	.4108		.5975	.4854	.5601	.5975	.5975
19	.7095	.6348	.8962	.8215	.7095	.7842	.7468
20	.6722	.7095	.7095	.6722	.6722	.6722	.7095
21	.5601	.5975	.5975	.5975	.5601	.5975	.6348
22	.4481	.5228	.4854	.5228	.4481	.5601	.5228
23	2.1068	1.8671	1.7551	2.0538	1.7741	2.2405	
24	.4854	2.0698	1.8671	1.885	1.8671	1.848	2.3285
Max	4.3439	3.2922	1.8671	3.6214	3.658	3.4751	3.5848
Min	.3361	.3326	.4805	.2987	.2957	.4108	.3696
Avg	1.7794	1.3247	.8631	1.2915	1.2995	1.2899	1.3659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 302 / Kavathe

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.6653	.9335	1.1576	1.307	1.1088	1.1088
2	.5601	.7392		1.1949	1.4784	1.1827	1.0719
3	.6348	.8131		1.2696	1.4784	1.2567	1.0719
4	.7095	.8871		1.307	1.829	1.2936	1.1827
5	.8215	.961		1.3817	2.1948	1.3306	1.2567
6	.8962	1.1088		1.7551	2.1948	1.9589	1.922
7	.961	2.2546		2.9127	2.7435	2.8166	3.2526
8	1.0349	2.8532		3.6222	1.0082	3.2922	3.7677
9	2.5873	.8871		.9335	1.0082	1.0456	1.0719
10	3.1459	.6722		.8131	1.0456	.8871	1.0719
11	3.4019	.5975		.8215	.8501	.8131	.9979
12	3.9095	.5175	.7023	.7468		.7522	.8501
13	3.658	.6653	.6653	.7468		.7762	.8131
14	3.5482	.6653	.7023	.7468	.7392	.8215	.7762
15	3.3653	.6653	.7392	.7842	.8215	.7842	.7392
16	3.1459	.6283	.7392		.7842	.8215	.5914
17	.5228	.5975	.7095	.8215	.7468	.6722	.7842
18	.5601	.6722	.7842	.8589	.7842	.8962	.7842
19	.8962	.7468	1.0082	1.0456	.8962	1.0082	.9709
20	.8215	.8215	.8589	.9335	.8589	1.0829	1.0456
21	.6722	.7468	.6722	.8215	.7095	.7842	.8962
22	.5975	.5228	.5601	.5975	.5975	.6348	.5601
23	.7392	.9335	1.0829	1.1576	.9979	1.0829	
24	.4854	.7023	.9335	1.1949	1.1576	1.1088	1.1088
Max	3.9095	2.8532	1.0829	3.6222	2.7435	3.2922	3.7677
Min	.4854	.5175	.5601	.5975	.5975	.6348	.5601
Avg	1.5914	.8885	.7922	1.2011	1.1923	1.1755	1.2042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 303 / Shastabad

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	.5544	.6348	.5601	.6722	.5601	.5601
2	1.8671	.5544		.6348	.7095	.6348	.6348
3	2.2405	.6283		.7095	.7468	.7468	.6722
4	2.4025	.8501		.7762	.8215	.8871	.7762
5	3.1417	.961		.8871	.9511	.961	.8871
6	3.5113	1.1088		1.2567	1.1706	1.2197	1.1827
7	3.8809	1.4415		1.4784	1.2803	1.4415	1.4415
8	3.6961	1.0719		1.3306	1.4266	1.2567	1.3169
9	.7316	2.6981		3.3265	3.1417	2.846	2.846
10	.7392	3.2526		4.0238	3.5475	3.4019	3.4743
11	.8131	2.9264		4.1076	3.4019	3.2895	3.4004
12	.6283	2.7435	3.8775	4.0657	3.4374	3.1047	3.5113
13	.4805	4.3896	3.9506	3.8809	3.1417	2.8829	3.3265
14	.5544	4.2067	3.8409	3.5113	2.9569	2.7351	3.5113
15	.5121	4.2067	3.4743	3.3608	2.7721	2.8829	2.7721
16	.4805	3.658	3.3634	3.1417	2.6612	2.6612	2.5873
17	.5914	.5601	.4481	.6283	.4854	.5601	.6348
18	.7842	.8589	.6722	.7392	.7842	.8589	.7842
19	1.1949	1.0082	1.1949	1.2696	1.1949	1.1949	1.1203
20	1.0829	1.1203	1.1203	1.3817	1.1203	1.1576	1.1949
21	.9709	.9335		.9808	.9709	1.0082	1.1203
22	.7468	1.0456	.7842	.7842	.7468	.8589	.7842
23	.5975	.5975	.6722	.6722	.6348	.6348	
24	1.6804	.5914	.6348	.5975	.5975	.5601	.5601
Max	3.8809	4.3896	3.9506	4.1076	3.5475	3.4019	3.5113
Min	.4805	.5544	.4481	.5601	.4854	.5601	.5601
Avg	1.4587	1.7486	1.8976	1.8377	1.6406	1.5977	1.7000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 304 / 22 KV Kawathe Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4066	.4108	.3734	.4481	.3734	.4854
2	.4108	.4435		.4854	.4805	.4854	.4854
3	.5228	.4805		.4854	.6722	.5601	.4854
4	.5914	.5544		.5228	.7392	.6348	.7392
5	.6722	.7762		.6348	.9709	.7392	.7468
6		.9979		.9335	1.0349	.924	.961
7		1.1827		1.1949	1.1458	1.1827	1.2567
8		1.1458		1.1576	1.1827	1.2567	1.1827
9		.9979		1.0829	.961	1.1203	1.2567
10	.8589	.7762		.8962	.8962	.961	.9979
11	.7468	.4481		.6653	.7023	.7468	.8215
12	.4805	.3734	.4066	.5601		.5228	.7468
13	.4108	.439		.5601		.5228	.6722
14	.3326	.4024		.4481	.4435	.4481	.5228
15		.2987	.4435	.4854	.4066	.4066	.3696
16	.3696	.4066	.4854		.4108	.4066	.3696
17	.3734	.4108	.4108	.5975	.4108	.5228	.3734
18	.4854	.5975	.5228	.6722	.5601	.7095	.5975
19	.9335	.8215	.9979	1.1203	.9335	1.0082	.8962
20	.9335	.9709	.9335	1.0456	.9335	1.0082	1.0082
21	.7842	.7095	.7468	.8215	.7842	.7095	1.1317
22	.5601	.5228	.5228	.5601	.5601	.5228	.5281
23	.4066	.4108	.4108	.3734	.4108	.4481	
24	.3734	.4066	.4108	.3734	.4108	.3734	.4854
Max	.9335	1.1827	.9979	1.1949	1.1827	1.2567	1.2567
Min	.3326	.2987	.4066	.3734	.4066	.3734	.3696
Avg	.5589	.6242	.5585	.6978	.7045	.6914	.7444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 305 / 22 kv industrial feeder

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.037	.0373			.0373		.1867
8	.1478			.2241	.112	.112	.2241
9	.0373	.037	.1109	.1494	.0739		.1478
10		.0373		.1478	.1867	.0739	.0373
11		.0373		.1494	.1109	.112	.2218
12	.0739			.1848	.1109	.2241	.2218
13	.037			.2218	.0373	.0373	.1478
14	.112	.0373		.1867	.1109	.1494	.1867
15	.112	.0373		.1867	.1109	.1494	.112
16	.0747	.1494		.1494	.037	.1494	.2218
17	.0747	.0747		.1494	.1867	.0373	
18	.0373	.0373		.112	.2241	.0373	.112
19				.0373			
21		.0373					
Max	.1478	.1494	.1109	.2241	.2241	.2241	.2241
Min	.037	.037	.1109	.0373	.037	.0373	.0373
Avg	.0744	.0522	.1109	.1582	.1116	.1082	.1654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 306 / 22 kv Amdabad

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.1494	.1867	.1867	.2241	.1867	.2241
2	.9335	.1494		.181	.1867	.1867	.2241
3	1.0456	.1867		.2241	.1867	.2241	.2241
4	1.1203	.1867		.2241	.2241	.2241	.2241
5	1.2936	.2241		.2614	.2561	.2614	.2614
6	1.4784	.2614		.2987	.2957	.2614	.2614
7	1.6632	.2987		.2987	.2926	.2987	.2987
8	1.6632	.2614		.2987	.2926	.2987	.3361
9	.2987	1.5154		1.7551	1.6804	1.643	1.6263
10	.2957	2.1068		2.1285	1.8671	1.8111	1.922
11	.2587	1.9022		2.2405	1.885	1.848	1.885
12	.2218	1.829	2.1068	2.2405	1.8111	1.8671	1.922
13	.1848	2.1948	1.9959	2.2405	1.8111	1.848	2.0328
14	.1867	2.1948		2.1658	1.7741	1.8111	1.848
15	.1867	2.2314		2.0538	1.7741	1.7372	1.7177
16	.1867	2.0851	2.1068	1.8671	1.7741	1.7741	1.7002
17	.1867	.1494	.2241	.2241	.1494	.1867	.1494
18	.1867	.1867	.2241	.2241	.2241	.2241	.2241
19	.2614	.2241	.1867	.3018	.2614	.2614	.2614
20	.2241		.2987	.3018	.2241	.2987	.2614
21	.2241	.2614	.2614	.2641	.2241	.2614	.2614
22	.1867	.2241	.2241	.2614	.2241	.2614	.2614
23	.1494	.1867	.2241	.2614	.2241	.2241	
24	.8215	.1867	.1867	.2241	.2241	.2241	.2241
Max	1.6632	2.2314	2.1068	2.2405	1.885	1.8671	2.0328
Min	.1494	.1494	.1867	.181	.1494	.1867	.1494
Avg	.5867	.8346	.6855	.8637	.7538	.7593	.7979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 307 / 22 kv Malthan Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.112	.112	.112	.112	.1494	.112
2	.112	.1494		.112	.1867	.1494	.112
3	.1494	.1494		.1494	.2218	.1867	.112
4	.1494	.1867		.1494	.2241	.2241	.1494
5	.1848	.2241		.1494	.2614	.2241	.1494
6	.2587	.2614		.2614	.2987	.2614	.2587
7	.2987	.3361		.2987	.3361	.3361	.2987
8	.3361	.2614		.2987	.2987	.3734	.3361
9	.2957	.2587		.2587	.2218	.2614	.2987
10	.2587	.1848		.2218	.2614	.2218	.2587
11	.1848	.1829		.2241	.1848	.1867	.2218
12	.1848	.1829		.1848	.1478	.1867	.2218
13	.1848	.1829		.1848	.1478	.1478	.1848
14	.1494	.112		.1867	.1478	.0747	.1478
15	.1494	.112	.1478	.1848	.1109	.112	.1109
16	.112	.1494	.1867	.1494	.1848	.112	.1109
17	.1494	.1494	.1867	.2241	.1867	.112	.1867
18	.1494	.2241	.2241	.2241	.1867	.2241	.1867
19	.2614	.2614	.2987	.2987	.2987	.2987	.2614
20	.2614	.2614	.2614	.2987	.2614	.2987	.2987
21	.2241	.2241	.2241	.2641	.2614	.2614	.2987
22	.1867	.1867	.1867	.1867	.1867	.2241	.1867
23	.1494	.1494	.112	.0747	.1494	.112	
24	.112	.112	.112	.112	.112	.1494	.112
Max	.3361	.3361	.2987	.2987	.3361	.3734	.3361
Min	.112	.112	.112	.0747	.1109	.0747	.1109
Avg	.1923	.1923	.1866	.2004	.2079	.2037	.2006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214461 / 33 KV TAKALI HAJI

Feeder No / Name : 201 / Malwadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	09-JAN-17
HR	Load (MW)
12	.8726
Max	.8726
Min	.8726
Avg	.8726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214461 / 33 KV TAKALI HAJI

Feeder No / Name : 202 / 11 kv Shingawadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.2169	.2191	.2587	.298	.2419	.2384
2	.5316	.2188	.221	.2615	.2905	.2534	.2587
3	.6268	.2358	.2439	.2579	.3093	.2776	
4	.6268	.2565	.2591	.2751	.332	.3041	.2758
5	.6335	.2735	.2763	.2926	.3546	.3402	.3294
6	.6401	.2942	.301	.2926	.3923	.3804	.3658
7	.924	.3301	.3125	.4287	.4263	.4066	.414
8	1.1203	.3546	.3582	.3286	.3489	.4029	.3804
9	.3678			1.1317	1.1317	1.1203	1.1317
10	.4131	1.6194		1.5089	1.3203	1.2136	1.226
11	.4055	1.6194	1.4335	1.6032	1.4146	1.3203	1.3203
12	.3923	1.6194	1.5242	1.5089	1.4712	1.4146	1.4146
13	.4131	1.6194	1.5242	1.6194	1.4146	1.3203	1.3203
14	.4451	1.6194	1.5242	1.6194	1.4146	1.3336	1.3203
15	.464	1.6194	1.5242	1.6194	1.3203	1.3336	1.3203
16	.464	1.6194	1.4289	1.5242	1.3203	1.226	1.3203
17	.4508	.4344	.2565	.3144	.2905	.2689	.3056
18	.3885	.3144	.2987	.4014	.3885	.2513	.2905
19	.3885	.3353	.3992	.3844	.4263	.3365	.3282
20	.3753	.3544	.3118	.3402	.4187	.3621	.3131
21	.3489	.2858	.2906	.3294	.332	.3137	.332
22	.3131	.282	.2693	.3152	.332	.333	.3659
23	.2565	.2343	.2559	.2764	.298	.241	.3093
24	.6135	.2169	.2191	.2445		.2358	.2219
Max	1.1203	1.6194	1.5242	1.6194	1.4712	1.4146	1.4146
Min	.2565	.2169	.2191	.2445	.2905	.2358	.2219
Avg	.5054	.6945	.6114	.7140	.6976	.6347	.6566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214461 / 33 KV TAKALI HAJI

Feeder No / Name : 204 / 11 kv Temkarwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1393	.4055	.4306	.4066	.4829	.4334	.3121
2	1.2269	.4244	.4839	.4288	.5809	.5346	.3541
3	1.2403	.4432	.5106	.5086	.7582	.5723	.4394
4	1.3432	.5187	.5449	.5792	.7695	.6376	.505
5	1.448	.6903	.5868	.591	.7997	.7023	.5502
6	1.4632	.6903	.6973	.6371	.8639	.7312	.6072
7	1.848	.7846	.7773	.7974	.9167		.717
8	2.1472	.7262	.8993	.8871	.9468	.8701	.834
9	.7262	2.4768		2.452	2.0748	2.3339	2.3577
10	.6941	2.572		2.572	2.2634	2.6406	2.3577
11	.7073	2.7625	2.6673	2.572	2.0748	2.5463	2.452
12	.6696	2.7625	2.7625	2.3815	2.452	2.5463	2.3577
13	.5809	2.9531	2.7625	2.4768	2.452	2.452	2.1691
14	.596	2.8578	2.6673	2.572	2.452	2.3577	2.2634
15	.5753	2.7625	2.5463	2.572	2.2634	2.3815	2.0748
16	.5772	2.6673	2.5463	2.4768	1.9805	2.3577	2.0748
17	.5376	.4725	.4332	.4877	.4451	.4332	.4225
18	.5583	.5487	.5248	.5432	.5734	.4953	.4678
19	.7262	.5773	.6658	.6572	.6451	.6209	.5734
20	.5828	.5868	.6232	.6246	.6526	.5751	.4678
21	.5451	.5182	.5316	.5487	.4753	.4705	.4187
22		.4954	.4394	.4778	.4753	.3982	.3923
23	.4263	.3467	.4066	.4406	.464	.326	.3508
24	1.1269	.3697		.3953	.4376	.3866	.3086
Max	2.1472	2.9531	2.7625	2.572	2.452	2.6406	2.452
Min	.4263	.3467	.4066	.3953	.4376	.326	.3086
Avg	.9342	1.2672	1.1670	1.2119	1.1792	1.2088	1.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214461 / 33 KV TAKALI HAJI

Feeder No / Name : 205 / Sablewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4943	.7545	.6668	.6135	.6602	.6135	
2	.5386	.7545	.7621	.7087	.7545	.7087	.7011
3	.5767	.7545	.7621	.7973	.8488	.8059	.7973
4	.6299	.9431	.8573	.8954	.9431	.905	.8954
5	.6621	.9431	.9526	1.0059	1.0374	1.0974	.9955
6	.717	1.1317	1.1431	1.0974	1.1317	1.2012	1.0974
7	.7356	1.3203	1.5242	1.386	1.4146	1.307	1.386
8	.6871	1.5089	1.7147	1.6804	1.6975	1.587	1.6461
9	1.5089	.5716		.7828	.8148	.7879	.928
10	1.6975	.5182		.7207	.6564	.7545	.9204
11	1.8861	.4877	.6783	.6805	.5809	.7545	.8827
12	1.7918	.4763	.6401	.6661	.6639	.7205	.7997
13	1.6975	.4649	.6249	.7658	.6111		.6828
14	1.6975	.4725	.6097	.7207	.6111		.6187
15	1.5089	.4763	.596	.7669	.6073		.5734
16	1.5089	.4801	.5228	.6859	.6149		.5508
17	.4678	.4954	.5853	.6358	.5508	.7545	.5734
18	.5017	.5868	.5414	.6895	.5734	.8365	.5583
19	.596	.6059	.5864	.7229	.6337	.7692	.6488
20	.5074	.6097	.5014	.6766	.63	.7243	.5885
21	.4829	.5373	.5032	.6275	.5055	.5825	.5206
22		.5487	.5103	.5599	.6602	.5719	.5508
23	.7545	.6668	.6135	.6068	.6602	.6201	.6602
24	.4542	.7545	.6668	.6068	.6602	.6068	.6001
Max	1.8861	1.5089	1.7147	1.6804	1.6975	1.587	1.6461
Min	.4542	.4649	.5014	.5599	.5055	.5719	.5206
Avg	.9610	.7026	.7529	.7958	.7718	.8354	.7903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214461 / 33 KV TAKALI HAJI

Feeder No / Name : 206 / Takali Haji

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5749	1.4146	1.3336	1.2269	1.3203	1.3146	1.4899
2	.6024	1.4146	1.3336	1.3289	1.4146	1.3289	1.5947
3	.659	1.5089	1.5242	1.4327	1.5089	1.3432	1.6118
4	.7602	1.6975	1.7147	1.5384	1.6032	1.448	1.7194
5	.8816	1.8861	1.9052	1.7375	1.7918	1.4632	1.829
6	.9364	2.0748	2.191	2.0328	2.0748	1.4632	2.1033
7	1.1901	2.452	2.6673	2.5206	2.5463	1.5708	2.7721
8	1.1501	2.9235	3.0483	3.2065	3.2065	1.587	3.2007
9	2.8292	1.1812		1.391	1.3052	.8775	1.2222
10	2.9235	1.1774		1.1873	1.2788	.7243	1.2713
11	3.4894	.9412	.945	1.1203	1.1053	.6639	1.2713
12	3.678	.8726	.8993	1.0574	1.0977	.6488	1.1392
13	3.5837	.7621	.884	.964	1.0525		.7846
14	3.5837	.7678	.8612	.9869	.9695		.8714
15	3.2065	.8154	.8383	.945	.8639		.8978
16	3.1121	.8192	.9297	.9259	.4564		.9129
17	.6903	.8192	.941	.8582	.4225	.9054	.7281
18	.8412	.8421	.754	1.028	.6149	1.0904	1.0147
19	1.1996	1.0059	1.2145	1.1774	.7582	1.2123	1.177
20	.8789	1.0288	1.0316	1.0381	.7582	1.1128	.8224
21	.7846	.8726	.9249	1.0312	.5885	.8365	.8205
22		.724	.8221	.724	.5394	.695	.7431
23	1.4146	1.3336	1.2269	1.2536	1.4146	1.5061	1.226
24	.5687	1.4146	1.3336	1.2136	1.3203	1.3003	1.4737
Max	3.678	2.9235	3.0483	3.2065	3.2065	1.587	3.2007
Min	.5687	.724	.754	.724	.4225	.6488	.7281
Avg	1.7191	1.2812	1.3329	1.3303	1.2505	1.1546	1.3624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214470 / 33/11KV JAM BUT

Feeder No / Name : 201 / 11 kv jambut

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.2149	.2686		.2149	.2172	.2507
2	.2328	.2353	.2686		.2149	.2353	.2507
3	.2328	.2353	.2686		.2686	.2353	.2507
4	.2865	.2715	.2686		.2865	.2534	.2507
5	.3155	.3258	.362		.3224	.3292	.2865
6	.3429	.4721	.4163		.4298	.4024	.439
7	.4801	.5121	.5487		.5083	.4938	.4961
8	.5487	.5853	.5487		.5959	.6219	.5658
9	.4409	.4854	.4656		.5959	.6068	.4973
10	.4163	.5028	.5201		.6241	.5721	.5087
11	.3045		.4854		.5487	.5548	.5596
12	.2835	.5087	.5316	.5601	.4973	.5765	.4641
13	.2328	.5365	.5487	.5441		.5256	.547
14	.2686	.5487	.5426	.5197	.4973	.503	.4973
15	.2303	.5658	.5087	.5487	.4801	.4694	.4475
16	.2126	.503	.5087	.5304		.4694	.4475
17	.2667	.3258	.2858	.2957	.3429	.1829	.2858
18	.2667	.3658	.3429	.462	.4763	.381	.4001
19	.5144	.4481	.4954	.5415	.5716	.5175	.4954
20	.4763	.4904	.4954	.4066	.4954	.4435	.4572
21	.4572	.3961		.4066	.4572	.4207	.4191
22	.3239	.3881		.3696	.3429	.3292	.3239
23	.2328	.3292		.2172	.2328	.2587	.2629
24	.2427	.2149	.3224		.2172	.2149	.2587
Max	.5487	.5853	.5487	.5601	.6241	.6219	.5658
Min	.2126	.2149	.2686	.2172	.2149	.1829	.2507
Avg	.3268	.4114	.4287	.4502	.4191	.4089	.4026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214470 / 33/11KV JAMBUT

Feeder No / Name : 202 / 11 kv fakte

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	1.3432	1.0745		.985	1.4118	1.3969
2	.3582	1.3756	1.0745		.985	1.4118	1.3969
3	.3582	1.3756	1.0745		1.1104	1.448	1.4327
4	.4298	1.3756	1.1641		1.5402	1.4842	1.4685
5	.4557	1.4118	1.3394		1.6118	1.5729	1.4685
6	.5487	1.5565	1.5565		1.7909	1.8839	1.8107
7	.583	1.829	1.6461		2.1209	2.2314	2.0199
8	.6173	2.1582	2.0119		2.489	2.524	2.3834
9	2.1365	.5028	.4835		.5258	.5895	.463
10	2.8054	.3467	.3814		.4161	.4161	.4917
11	3.1878	.3086	.2254		.2915	.3772	.3391
12	3.0653	.3052	.2572	.3041		.2883	.2652
13	2.955	.2683	.2058	1.5043		.2374	.2984
14	3.1341	.2743	.2035	.285	.1715	.2347	.2321
15	2.9235	.2401	.2374	.2915	.1543	.218	.2321
16	2.7286	.2515	.2204	.2652		.218	.2984
17	.3048	.2715	.2667	.3326	.3429	.2561	.381
18	.4763	.3658	.3048	.5544	.4763	.4382	.4763
19	.6478	.5228	.3239	.7095	.724	.4805	.5144
20	.6478	.6413	.6478	.5914	.6668	.5914	.6097
21	.5716	.5658		.5914	.6478	.5487	.5716
22	.4954	.5544		.4805	.4954	.5121	.4954
23	1.3073	1.0974		.9955	1.3253	1.2012	1.4022
24	.3734	1.3432	1.0745		.9955	1.379	1.4415
Max	3.1878	2.1582	2.0119	1.5043	2.489	2.524	2.3834
Min	.3048	.2401	.2035	.2652	.1543	.218	.2321
Avg	1.3112	.8452	.7511	.5755	.9460	.9148	.9121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214470 / 33/11KV JAMBUT

Feeder No / Name : 203 / 11 kv wadner

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.4119			.4298	.4163	.394
2	.8059	.4163			.4298	.4163	.394
3	.8059	.4706			.4656	.4344	.4656
4	.8596	.4706			.5014	.4525	.5014
5	.9114	.543			.5194	.5121	.5373
6	.9945	.6335			.5731	.6219	.695
7		.8048			.631	.7682	.6733
8	1.7147	.8048			.7011	.7316	.6344
9	.5426	1.9418			1.8755	1.9071	1.7147
10	.543	2.1845	2.2712		2.2539	2.2192	2.0687
11	.4298	2.2119	2.3926		2.1262	1.9204	2.1534
12	.3898	2.2891	2.0919	1.5364	2.1605	1.9839	2.0388
13	.394	2.2801	2.1948	2.0325		2.0008	1.8233
14	.3224	2.2977	2.1195	2.0622	2.0748	1.8778	1.8067
15	.3189	2.2119	2.1365	2.2291	2.0919	1.8442	1.7238
16	.3012	1.9784	2.0348	1.9559		1.7772	1.6907
17	.3239	.2172	.3429	.2957	.4001	.3292	.3429
18	.4572	.439	.4001	.5175	.5335	.4382	.4572
19	.6859	.5228	.3429	.6348	.724	.5175	.6478
20	.6478	.6036	.6859	.7023	.724	.6099	.6287
21	.5716	.5281		.7023	.6097	.4938	.5716
22	.4954	.5175		.4805	.5144	.439	.4763
23	.4298	.4024		.4344	.4298	.4066	.4207
24	.8402	.4298	.394		.4344	.4298	.4066
Max	1.7147	2.2977	2.3926	2.2291	2.2539	2.2192	2.1534
Min	.3012	.2172	.3429	.2957	.4001	.3292	.3429
Avg	.6344	1.0671	1.4506	1.1320	.9638	.9812	.9695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214470 / 33/11KV JAMBUT

Feeder No / Name : 204 / 11 KV Gajare Mala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5801	.1989			.1658	.1658	.1753
2	.5801	.213			.1658	.1658	.1658
3	.5801	.213			.2321	.1966	.1966
4	.7459	.2458			.2652	.1966	.2321
5	.8192	.2622			.3149	.2949	.2486
6	.8684	.3315			.3239	.3932	.3605
7	1.1142	.4641			.3887	.4973	.3932
8	1.1498	.4641			.4321	.4641	.4096
9	.3887	1.4089			1.3763	1.6244	1.3599
10	.3149	1.5581			1.6004	1.7532	1.6907
11	.2321	1.4737	1.5581		1.6385	1.7072	1.7072
12	.1989	1.5684	1.6078	1.0822	1.6221	1.7857	1.3757
13	.1823	1.2452	1.6244	1.2498	1.6078	1.5912	1.3426
14	.2155	1.4251	1.6244	1.5623	1.5746	1.5746	1.326
15	.1989	1.4883	1.6575	1.5223	1.6244	1.5402	1.4255
16	.1989	1.587	1.4586	1.5546		1.5074	1.4255
17	.2321	.1658	.116	.1526	.1989	.1526	.1492
18	.1966	.2401	.1492	.2622	.2984	.3121	.2321
19	.4144	.3086	.3978	.3481	.4641	.4481	.3481
20	.4144	.4508	.3812	.407	.431	.3921	.3647
21	.2984	.3086		.3222	.3315	.3326	.2652
22	.2321	.2984		.1966	.2155	.2402	.1658
23	.1989	.2486		.1638	.1658	.181	.1658
24	.5868	.1989			.1677	.1658	.181
Max	1.1498	1.587	1.6575	1.5623	1.6385	1.7857	1.7072
Min	.1823	.1658	.116	.1526	.1658	.1526	.1492
Avg	.4559	.6820	1.0575	.7353	.6785	.7368	.6544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata

Feeder No / Name : 201 / 11 kv Shirasgaon Kata
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.2987		.3361	
2		.2743	.2829		.3174	
3		.3086	.2801		.3361	
4		.3429	.3018		.3547	
5		.3772	.3361		.3734	
6		.5144	.4435		.4805	
7		.6173	.6653		.6722	
8		.5144	.5914		.5975	
9		3.5322	3.5951		3.3208	
10	.2743	3.7635		3.8668	3.7651	
11	.2401	3.9533		4.2105		
12	.1886	4.2429		4.1457		
13	.1715	4.2854		3.9676		4.5344
14	.1715	4.3583		4.0482		
15	.1543	4.3562		4.161		
16	.1543	4.5344				
17	.1886	.1867				
18	.3086	.0213		.3174		
19	.4801	.5228		.4805		
20	.4458	.4668		.4481		
21	.4115	.3361		.3547		
22	.2915	.3174		.3361		
23	.2743	.3174		.3361		
24		.2572	.2987		.3361	
Max	.4801	4.5344	3.5951	4.2105	3.7651	4.5344
Min	.1543	.0213	.2801	.3174	.3174	4.5344
Avg	.2682	1.6108	.7094	2.2227	.9900	4.5344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata

Feeder No / Name : 202 / 11 kv Pimpalsuti

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4575	1.3916		1.5424	
2		1.4746	1.5249		1.5746	
3		1.4918	1.6244		1.6741	
4		1.5432	1.6244		1.7736	
5		1.5432	1.6385		1.7204	
6		1.5432	1.8275		1.8399	
7		1.989	2.17		1.8023	
8		2.4348	2.42		1.917	
9		.3258	.4108		.4668	
10	2.572	.2241		.1867	.3734	
11		.1494		.1494		
12				.1494		
13				.1307		.2591
14	2.4691			.1307		
15	2.6063			.1494		
16	2.572			.168		
17	.2058			.1867		
18	.3258	.3921		.3174		
19	.4287	.4854		.4481		
20		.3921		.4481		
21	.3772	.3734		.3734		
22	.3429	.3361		.3547		
23	1.4746	1.2071		1.153		
24		1.4575	1.3413		1.2574	
Max	2.6063	2.4348	2.42	1.153	1.917	.2591
Min	.2058	.1494	.4108	.1307	.3734	.2591
Avg	1.3374	1.0456	1.5973	.3104	1.4493	.2591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata

Feeder No / Name : 203 / 11 kv Shirasgaon Kata Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029	.1132		.1109	
2		.12	.0934		.112	
3		.12	.0934		.0934	
4		.1372	.112		.112	
5		.1715	.112		.1494	
6		.0857	.128		.1829	
7		.1029	.1463		.0914	
8		.0686			.0739	
9		.0514	.0924		.0739	
10	.1372	.112		.1109	.2195	
11	.1029	.112		.0934		
12	.0686	.056		.0924		
13	.0514	.0747		.056		.081
14	.0514	.0549		.0747		
15	.0857	.056		.056		
16	.1029	.056		.0747		
17		.0924		.1109		
18	.1372	.1109		.1494		
19	.1543	.2033		.2033		
20	.1372	.168		.1848		
21	.1372	.128		.1463		
22	.12	.1307		.112		
23	.1029	.1109		.112		
24		.1029	.112		.1109	
Max	.1543	.2033	.1463	.2033	.2195	.081
Min	.0514	.0514	.0924	.056	.0739	.081
Avg	.1068	.1054	.1114	.1126	.1209	.081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata

Feeder No / Name : 204 / 11 kv Chinchani

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8861	1.8399		2.0222	
2		1.8861	1.8067		2.1216	
3		1.9719	1.9448		2.1136	
4		2.0233	1.9989		2.2119	
5		2.0576	1.9989		2.1538	
6		2.0919	2.1382		2.2672	
7		2.332	2.2874		2.0972	
8		1.6918	2.6825		2.42	
9		.2572	.3206		.3584	
10	3.0864	.2263		.2241	.2829	
11	3.0864	.1867		.2054		
12	3.0521	.1478		.1494		
13	3.0521	.1109		.1075		.2328
14	3.0521	.0914		.0924		
15	3.0178	.1097		.0914		
16	2.9492	.1075		.1109		
17	.1543	.1612		.1494		
18	.2572	.1829		.2241		
19	.3258	.3734		.3547		
20	.3086	.3361		.4108		
21	.2743	.2614		.3361		
22	.2401	.2218		.2427		
23	1.8519	1.8564		1.7772		
24		1.9719	1.8313		2.0454	
Max	3.0864	2.332	2.6825	1.7772	2.42	.2328
Min	.1543	.0914	.3206	.0914	.2829	.2328
Avg	1.7649	.9393	1.8849	.3197	1.8267	.2328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata

Feeder No / Name : 205 / 11 kv Nirvee

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086	.3395		.3734	
2		.3086	.3395		.3395	
3		.3429	.3206		.3584	
4		.3772	.3395		.3395	
5		.4115	.3772		.3772	
6		.5487	.4904		.5281	
7		.6173	.6979		.7545	
8		.5487	.679		.679	
9		2.5377	2.3045		2.1506	
10	.2743	2.8988		2.5749	2.915	
11	.2401	3.1093		2.5263		
12	.1543	2.8837		2.9797		
13	.1372	3.2065		2.8166		3.4294
14	.1372	3.0727		3.0445		
15	.1543	3.0567		2.9797		
16	.1715	3.1047		3.0087		
17	.2058	.2103		.2012		
18	.3086	.3326		.2926		
19	.4801	.5228		.5281		
20	.4801	.4854		.4904		
21	.4287	.3734		.4108		
22	.3429	.3361		.3734		
23	.3086	.3361		.3734		
24		.3086	.3361		.3734	
Max	.4801	3.2065	2.3045	3.0445	2.915	3.4294
Min	.1372	.2103	.3206	.2012	.3395	3.4294
Avg	.2731	1.2600	.6224	1.6143	.8353	3.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata

Feeder No / Name : 206 / 11 kv Zapfa

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029	.1132		.1132	
2		.12	.1132		.0943	
3		.1372	.132		.0943	
4		.1372	.112		1.4523	
5		.1543	.1478		.168	
6		.1886	.1829		.1829	
7		.1886	.1991		.1991	
8		.1886	.2103		.2058	
9		.1715	.197		.197	
10	.1886	.2033		.168	.1848	
11	.1715	.2033		.168		
12	.1715	.1848		.1848		
13	.1715	.2012		.1867		.1991
14	.1715	.2195		.1848		
15	.1715	.2172		.2033		
16	.1715	.2172		.2012		
17	.2229	.2401		.2033		
18	.2229	.2279		.2103		
19	.2058	.2149		.2241		
20	.1886	.2126		.2195		
21	.1715	.1848		.1463		
22	.1029	.1109		.0549		
23	.1029	.1132		.112		
24		.1029	.112		.1132	
Max	.2229	.2401	.2103	.2241	1.4523	.1991
Min	.1029	.1029	.112	.0549	.0943	.1991
Avg	.1739	.1768	.1520	.1762	.2732	.1991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214522 / 33/11 KV Nimone Sub station

Feeder No / Name : 201 / 11 KV NIMONE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / INCOMING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1132		.1132		.1132	.1132
2	.1494	.1509		.1509		.132	.1509
3	.1867	.1886		.1886		.1698	.1886
4	.2614	.2452		.2263		.2452	.2263
5	.2987	.3395		.2641		.3018	.2641
6	.3174	.3395		.3018		.3206	.3018
7	.4108	.3961		.3772		.3584	.3772
8	.3734	.3772		.3395		.3584	.3772
9	.415	.415		.3961	.3961		1.0608
10	.3961	.3772		.3584	.3584		.3018
11	.3018	.2641		.2263	.2452		.2641
12	.1509	.1886		.1132	.1132		.2829
13	.132	.1039		.1132	.1132		.2263
14	.1132	.112	.112		.1132		.1509
15	.1132	.0934	.0934		.132		.1698
16	.1132	.112	.112		.0943		.1886
17	.132	.112	.112		.1132		.1886
18	.1886	.1867	.1867	.1509	.1509		.2263
19	.3018	.2241	.2241	.2641	.2829		.2829
20	.2452	.2614	.2614	.2263	.2452		.2641
21	.1886	.2241	.2241	.1886	.1509		.2263
22	.1698	.1494	.1494	.1509	.132		.1698
23	.1509	.112			.132		.1509
24	.112	.1132	.1132			.1132	.1132
Max	.415	.415	.2614	.3961	.3961	.3584	1.0608
Min	.112	.0934	.0934	.1132	.0943	.1132	.1132
Avg	.2223	.2166	.1588	.2305	.1848	.2347	.2611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214522 / 33/11 KV Nimone Sub station

Feeder No / Name : 206 / 11 KV Pimpachiwadi

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4717	2.9321	1.0402	2.8365	.9541	2.7092	2.8456
2	.4747	2.9889	1.054	2.8639	.9694	2.7427	2.886
3	.596	3.0396	1.0562	2.8967	1.0029	2.8079	2.9142
4	.5922	3.1016	1.0639	2.9599	1.0166	2.8216	3.0834
5	.6485	3.1714	1.0875	3.0217	1.0661	2.8646	3.1871
6	.772	3.2623	1.1507	3.0979	1.1439	2.9691	3.3326
7	.9061	3.6961	1.2605	3.5719	1.2925	3.2697	3.6626
8	.9237	4.0068	1.4167	4.4856	1.5158	3.8641	4.1945
9	3.9363	1.7829	1.4883	1.865	1.9976	1.3573	1.8572
10	4.4467	.6173	.2484	.6847	.6778	.2606	.7518
11	4.8453	.5247	.1783	.4183	.5285	.2058	.6341
12	4.5305		.1357	.3574	.3847	.1532	.5982
13	4.2006	.121	.1097	.1189	.298	.1021	.4763
14	4.2737	.2858		.0008	.2907	.0983	.2904
15	4.1447	.3144			.2628	.0861	.2945
16	4.2987	.3338		.2526	.2628	.0914	.3376
17	1.7143	.3514		.349	.3524	.1158	.349
18	.4721	.5167	.1463	.5041	.4881	.1448	.4881
19	.8712	.8909	.2789	.7964	.8514	.2637	.7373
20	.8005	.8391	.2949	.8554	.7844	.2721	.657
21	.6646	.6965	.253	.7095	.6642	.2301	.5814
22	.5643	.5411	.2119	.6421	.5619	.1913	.5262
23	2.7393	2.8166	.9724	.9114	2.5139	.993	2.6791
24	1.3527	2.8125	2.8105	.9511	.9709	2.6582	1.5101
Max	4.8453	4.0068	2.8105	4.4856	2.5139	3.8641	4.1945
Min	.4717	.121	.1097	.0008	.2628	.0861	.2904
Avg	2.0517	1.7236	.8129	1.5283	.8688	1.3030	1.6198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 305 / MALLIKARJUN

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1707	.1722		.189	.1768
2			.1707	.1646		.1783	.1814
3		.0533	.1722	.1738		.1692	.1875
4		.1692	.1738	.1936	.157	.1905	.189
5		.2042	.1981	.2088	.1768	.2149	.218
6		.2469	.2484	.2423	.2332	.2545	.2774
7		.2926	.3277	.3262	.3734	.3643	.3948
8		.3719	.4252	.3841	.4161	.4664	.5075
9	.2911	.3917	.4222	.3902	.3338	.4618	.5045
10	.5045						
11	.5456						
12	.5456						
13	.4908						
14	.5106						
15	.5091						
16	.4984						
17	.4481						
23	.0808	.1646	.1631		.1783	.1402	.1814
24		.1692	.1707		.1829	.16	.189
Max	.5456	.3917	.4252	.3902	.4161	.4664	.5075
Min	.0808	.0533	.1631	.1646	.157	.1402	.1768
Avg	.4425	.2293	.2403	.2506	.2564	.2536	.2734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 402 / Takli haji

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17
HR	Load (MW)
24	7.7161
Max	7.7161
Min	7.7161
Avg	7.7161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 214484 / 33 KV NIGUDGHAR

Feeder No / Name : 201 / 11 KV SHIRWALI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.0274	.0533	.0225	.0343	.0566	.0532
2	.0362	.0271	.0511	.0221	.0347	.0566	.0351
3	.0351	.0271	.0511	.0221	.0351	.0566	.0358
4	.0354	.0274	.0511	.0221	.0347	.0566	.0351
5	.0354	.0282		.0221	.0343	.0566	.0351
6	.0343	.0343	.0638	.0229	.0343	.0497	.0514
7	.0503	.0509	.0886	.0434	.0572	.0566	.0693
8	.0709	.0497	.0949	.0463	.0648	.0943	.0838
9	.0486	.0509	.0914	.0474	.0469	.0686	.0671
10	.0497	.0332	.0587	.0271	.0671	.0693	
11	.0497	.0366	.0366	.0255	.064	.0394	.0537
12	.0486	.0309	.0332	.0248	.0556		.0734
13	.0469	.0301	.032	.036	.061	.0383	.0714
14	.0412	.0347	.0314	.0372	.0486		.0549
15	.0412	.0434	.0236	.024	.0301	.0251	.0781
16	.0417	.0412	.0229	.0248	.0452		.0857
17	.0417	.0412	.0221	.0383	.0594	.0372	
18	.064	.0812	.0383	.0474	.0686	.0655	.096
19	.1097	.1265	.08	.1227	.132	.1227	.1478
20	.1097	.1235	.081	.1227	.132	.1052	.1646
21	.0914	.108	.081	.0972	.1132	.1063	.1372
22	.0655	.0812	.0423	.0848	.0739	.0709	.1029
23	.0316	.0572	.0244	.0701	.0497	.0526	.08
24	.0362	.0267	.0476	.0343	.052	.0429	.0532
Max	.1097	.1265	.0949	.1227	.132	.1227	.1646
Min	.0316	.0267	.0221	.0221	.0301	.0251	.0351
Avg	.0521	.0508	.0522	.0453	.0595	.0632	.0757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 214484 / 33 KV NIGUDGHAR

Feeder No / Name : 202 / 11 KV WAGHJAI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0671	.0857	.0617	.0876	.0943	.0905
2	.0709	.0655	.0857	.0617	.0876	.0943	.0886
3	.0716	.064	.0857	.061	.0867	.0943	.0905
4	.0709	.0617	.0857	.0625	.0867	.0943	.0886
5	.0709	.0617	.0857	.064	.0857	.0943	.0905
6	.0876	.0762	.0995	.1063	.0857	.132	.0857
7	.1402	.1402	.1433	.1326	.1387	.1509	.1227
8	.1772	.1844	.1526	.1638	.1844	.1867	.2149
9	.1509	.1802	.1526	.192	.1063	.1509	.2149
10	.1753	.1543	.1355	.1581	.1402	.1509	
11	.1543	.1492	.132	.116	.1063		.1595
12	.1475	.1326	.1113	.1677	.1006	.1475	.1865
13	.1107	.1296	.088		.1006		.1677
14	.128	.116	.0766		.1006	.1475	.156
15	.0937	.1143	.0743		.1387		.1402
16	.0743	.1189	.0667	.1355	.1326	.1326	.1526
17	.1423	.1143	.0724	.1524	.12	.1475	.1865
18	.1389	.1581	.1014		.1402		.1417
19	.2103	.2561	.2012		.2427	.2481	.2452
20	.197	.2507	.2058		.2263	.2534	.2452
21	.1791	.2353	.1907	.2172	.1886	.1949	.2075
22	.1448	.1595	.1341	.1448	.1509	.1791	.1494
23	.0886	.0972	.081	.0886		.1227	.1109
24	.0924	.0693	.088	.1581	.0886	.0943	.1063
Max	.2103	.2561	.2058	.2172	.2427	.2534	.2452
Min	.0709	.0617	.0667	.061	.0857	.0943	.0857
Avg	.1245	.1315	.1140	.1247	.1272	.1455	.1497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 214484 / 33 KV NIGUDGHAR

Feeder No / Name : 203 / 11 KV Raireshwar

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0296	1.033	.9869	.9518	.983	1.0585	1.0075
2	1.1681	1.1206	1.2269	1.1271	1.2222	1.2338	1.1942
3	1.3498	1.315	1.467	1.3405	1.4108	1.3633	1.3701
4	1.5067	1.4826	1.5699	1.4853	1.5623	1.5881	1.4762
5	1.5899	1.5207	1.6575	1.6529	1.5937	1.6796	1.5371
6	1.6468	1.5337	1.6369	1.7066	1.6634	1.656	1.5249
7	1.7213	1.7219	1.8138	2.0184	1.7558	1.9029	1.7127
8	1.83	1.6217	1.1387	2.0401	1.7669	1.9715	1.6718
9	2.0309	1.7002	.4338	2.1433	1.8854	1.9966	1.91
10	2.1849	1.7855	.5929	2.2402	2.1567	2.0557	1.1698
11	2.2329	1.9214	.7051	2.2615	2.3205	2.1719	2.3808
12	2.2079	1.8808	.7754	2.1548	2.3891	1.2498	2.3338
13	2.2024	1.9528	.8184	1.1698	2.2748	2.3068	2.3205
14	2.0462	1.7673	.5538	1.0669	2.1548	1.0745	2.0881
15	1.9887	1.77	.4458	1.0212	2.0385	1.8294	1.9547
16	1.7749	1.5617	.4496	2.0671	1.7591	.8078	1.656
17	1.728	1.624	1.4984	1.9982	1.6819	1.85	1.6891
18	1.5927	1.579	1.5821	.6668	1.6741	1.6728	1.5546
19	1.5613	1.5366	1.6381	.4801	.4877	1.5432	1.4883
20	1.4548	1.4766	1.5203	.4382	1.5356	1.5211	1.4502
21	1.3603	1.267	1.3988	1.3613	1.3807	1.2883	1.2841
22	1.1705	1.0791	1.2094	1.1079	1.1927	1.1698	1.1774
23	1.0222	1.0141	1.0012	.98	.9815	1.025	.9993
24	.9753	.9431	.985	.8794	.9993	.9599	.89
Max	2.2329	1.9528	1.8138	2.2615	2.3891	2.3068	2.3808
Min	.9753	.9431	.4338	.4382	.4877	.8078	.89
Avg	1.6407	1.5087	1.1294	1.4316	1.6196	1.5407	1.5767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 214484 / 33 KV NIGUDGHAR

Feeder No / Name : 205 / Pombardi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2488	.1943				.3054	.2988
2	.2374	.1974				.2707	.2881
3	.2252	.1867				.2692	.2751
4	.2123	.1867				.2678	.2728
5	.2138	.1837				.2625	.2789
6	.2146	.1642				.2751	.2851
7	.2164	.1694				.2998	.2896
8	.223	.2667				.3149	.3141
9	.0983	.3395	.3765	.2881		.1783	.1738
10		.4702	.5845	.4916			
11		.474	.6621	.5071			
12		.4641	.6489	.6287			
13		.5304	.6379	.6352			
14		.5442	.6009	.6403			
15		.5615	.5426	.5853			
16		.5958	.5647	.5723			
17		.3185	.3071	.3041			
23	.1147				.2667	.2523	.2667
24	.2176	.0724			.1783	.2936	.2843
Max	.2488	.5958	.6621	.6403	.2667	.3149	.3141
Min	.0983	.0724	.3071	.2881	.1783	.1783	.1738
Avg	.2020	.3289	.5472	.5170	.2225	.2718	.2752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION

Feeder No / Name : 301 / 22KV JEJURI(U) FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.5975	.7095	.6859		.5487	.5601
2	.6653	.5975	.7095	.7087		.5544	.5601
3	.6653	.5975	.7468	.7392		.5544	.6722
4	.7316	.5975	.7468	.7316		.5544	.6722
5	.7392	.6722	.7468	.924		.7468	.7468
6	.924	.9335	.8215	1.0974	.9709	.924	.8589
7	1.1088	1.1203	1.1576	1.1203	1.1203	1.1203	1.0082
8	1.1088	1.307	1.2323	.7468	1.307	1.1203	1.4937
9	1.1949	1.1203		1.1949	1.267	1.1949	1.1949
10	1.1949	1.0829		1.1949	1.0745	1.1203	1.1949
11	1.1949	1.0456			.8764	.9709	1.1203
12		1.0456			.9602	1.0829	1.0669
13	1.0456	.8962			.8383	.9709	
14	1.0456	.8962			.8573	.9335	
15	1.0456	.8589				.9335	
16	1.1203	.8589	.9259		.8383	.8962	
17	1.0456	.9335	.9568			1.0082	
18	1.1203	1.1576	1.0402			1.0082	
19	1.0456	1.1949				1.2323	
20	1.1203	1.1949			1.1088	1.1949	
21	1.1203	1.1203	1.1088			1.1203	
22	1.0456	.9709	.924		.924	.9335	
23	.7468	.7468	.7392			.7842	
24	.6653	.6722	.7095	.6859	.6722	1.1203	.5601
Max	1.1949	1.307	1.2323	1.1949	1.307	1.2323	1.4937
Min	.6653	.5975	.7095	.6859	.6722	.5487	.5601
Avg	.9722	.9258	.8850	.8936	.9858	.9428	.9007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION

Feeder No / Name : 303 / 22KV MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3472	2.4006	2.713	2.0119		.9145	2.3739
2	2.3472	2.4006	2.5434	1.989		1.0212	2.3739
3	2.2939	2.4006	2.5434	1.989		.9145	2.3739
4	2.3205	2.4006	2.5434	1.989		.884	2.3739
5	2.3205	2.4006	2.713	2.1548		.9145	2.3739
6	2.2939	2.572	2.713	2.2939	1.7147	1.0212	2.3739
7	2.1872	2.4006	2.3739	2.4863	2.0576	1.0802	2.2043
8	1.669	2.4006	2.2043	2.3472	1.5432	1.467	2.3739
9	2.572	3.2217		3.2579	.6554	2.2043	2.7435
10	3.2579	3.3913		3.0864	.7468	3.0521	3.4294
11	3.6008	3.5608			.8135	3.5608	3.2579
12		3.3913			.9907	3.2217	3.4294
13	2.915	3.3913			.7735	2.3739	
14	3.2579	3.7304			.6001		
15	3.4294	3.8999	3.9609			3.3913	
16	3.6008	3.7304	4.1495		.8078	3.5608	
17	3.0864	3.7304	3.5475			3.3913	
18	2.915	3.3913	3.1741			3.2217	
19	2.915	3.0521	2.8349			3.2217	
20	2.7435	2.3739			.7164	2.5434	
21	2.7435	2.713	2.572			2.3739	
22	2.572	2.8826	2.3472		.9145	2.5434	
23	2.4006	2.713	2.3472			2.5434	
24	2.3472	2.4006	2.713	2.1795	1.7147	.9297	2.3739
Max	3.6008	3.8999	4.1495	3.2579	2.0576	3.5608	3.4294
Min	1.669	2.3739	2.2043	1.989	.6001	.884	2.2043
Avg	2.7016	2.9563	2.8232	2.3441	1.0807	2.1892	2.6197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION

Feeder No / Name : 304 / 22 KV KOLVIHIRE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4744	.5087	2.0348	1.5432		1.8976	1.1869
2	.4744	.5087	2.0348	1.5623		1.8976	1.1869
3	.4744	.5087	2.0348	1.5623		1.9204	1.1869
4	.4858	.5087	2.2043	1.5813		1.8976	1.3565
5	.4915	.6783	2.3739	1.6004		1.9204	1.5261
6	.6554	1.0174	2.5434	1.6975	2.5434	1.8976	1.5261
7	.8192	1.0174	3.7304	1.9433	3.0521	2.0557	1.6956
8	.9945	1.2003	4.0695	3.0521	3.7304	2.2138	1.6956
9	2.3739	1.0174		.6783	.5087	2.713	2.3739
10	3.2217	.6783		.6783	.6783	2.3472	3.0521
11	3.0521	.6783			.6401	5.0869	2.5434
12		.6783			.4801	5.426	2.5434
13	3.3913	.6783			.3125	5.7651	
14	3.0521	.5087			.1677		
15	3.0521	.5087				4.5782	
16	2.5434	.5087			.16	4.5782	
17	.8478	.5087					
18	.8478	.8478	.3391			1.0174	
19	.8478	1.1869				1.6956	
20	1.0174	1.1869			1.1069	1.5261	
21	1.0174	1.0174	.6325			1.6956	
22	1.0174	.8478	.6325		.7907	1.6956	
23	.5087	2.2043	1.6956			1.3565	
24	.4744	.5087	2.0348	1.6956	1.6956	.3163	1.1869
Max	3.3913	2.2043	4.0695	3.0521	3.7304	5.7651	3.0521
Min	.4744	.5087	.3391	.6783	.16	.3163	1.1869
Avg	1.3972	.8131	2.0277	1.5995	1.2205	2.5227	1.7739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION

Feeder No / Name : 305 / 22KV NAZARE GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8197	3.0864	3.3532	3.5818	3.5818	1.9433	3.8104
2	2.4387	3.1245	2.9721	2.8578	3.2388	2.4386	4.001
3	2.2101	3.1626	2.7816	2.6292	3.0102	2.5529	4.1534
4	2.4387	2.5148	2.7816	2.5149	1.9433	2.6672	3.9628
5	3.3913	2.9341	2.8959	3.2008	2.6292	3.5056	4.2296
6	4.6106	4.5725	3.9629	4.3058	4.1915	4.6106	5.3727
7	5.6775	5.868	4.9535	5.2584	5.5632	5.7156	5.1441
8	6.2491	5.7918	4.9535	4.9154	4.9536	5.7156	5.3727
9	6.6682	5.7537	3.5437	5.0678	4.42	4.9536	5.4108
10	7.7351	6.0966	4.1533	6.211	3.5436	5.5251	5.6013
11	5.7156	5.7918	3.9628	6.973	3.3151	5.6775	5.7918
12	5.4108	5.4108	4.3439	6.8206	3.4675	5.7918	5.2584
13	5.9442	4.9916	3.8485	6.4396	3.3913	5.4108	4.2676
14	5.2965	4.3439	3.7723	4.6106	3.2007	4.6106	3.658
15	5.2965	4.0391	4.1914	4.9916	2.9721	5.4489	2.9721
16	5.2965	4.8011	4.6868	4.5344	3.4674	5.487	2.934
17	5.9442	4.9154	4.8011	4.6487	2.2481	4.4201	3.8104
18	5.4489	4.8773	4.9535	3.8104	3.0864	4.0009	3.5437
19	7.3921	6.5158	5.5251	5.8299	4.9154	6.9349	4.5725
20	7.4303	6.592	5.9823	6.1728	6.2872	6.8206	4.8392
21	7.1635	6.211	6.7063	5.5251	5.0297	6.4015	4.6487
22	6.211	5.5251	5.2584	4.6487	4.763	5.7918	3.8866
23	5.2203	5.4108	5.0679	4.8392	3.1245	5.3346	3.2769
24	4.4582	4.2296	4.4582	4.8392	3.3913	4.0009	3.7723
Max	7.7351	6.592	6.7063	6.973	6.2872	6.9349	5.7918
Min	2.2101	2.5148	2.7816	2.5149	1.9433	1.9433	2.934
Avg	5.2695	4.8567	4.3296	4.8011	3.7390	4.8233	4.3455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION

Feeder No / Name : 306 / 22KV WALHA GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.4572	.381		.381	.381
2	.381	.381	.4572	.381		.381	.381
3	.381	.381	.5335	.381		.381	.4572
4	.381	.381	.5335	.381		.5716	.6097
5	.5716	.5335	.6097	.5716		.6859	.6097
6	.724	.6478	.724	.7621	.7621	.7621	.6859
7	.8383	.8764	.9145	.8383	.8383	.8764	.8383
8	.8764	.8383	.8764	.8002	.8383	.8764	.8764
9	.8383	.7621		.7621	.8002	.8764	.8002
10	.7621			.6859	.6859	.724	.6859
11	.724	.5716			.6097	.6097	.6097
12		.4572		.5716	.381	.6478	.6097
13	.5716	.4954		.5716	.4954	.5716	
14	.6097	.5335		.4954	.5716	.5716	
15	.6097	.5335		.5335		.5335	
16	.6097	.5335		.5335	.4954	.5335	
17	.6097	.6097	.5716	.6097		.6478	
18	.6097	.8002	.6097	.6859		.6097	
19	.6859	.9145		.8764		.9145	
20	.6859	.8764			.8002	.8383	
21	.5335	.7621	.8002			.724	
22	.5335	.6478	.5716		.5716	.5716	
23	.4572	.4954	.4954			.4572	
24	.4191	.4572	.4572	.4572	.4572	.381	.381
Max	.8764	.9145	.9145	.8764	.8383	.9145	.8764
Min	.381	.381	.4572	.381	.381	.381	.381
Avg	.5997	.6030	.6151	.5936	.6390	.6303	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION

Feeder No / Name : 307 / 22KV WALHA AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5434	2.0348	.2858	.1105			2.8826
2	2.572	2.0348	.2858				2.8826
3	2.5434	2.0348	.2858				2.8826
4	2.5434	2.0348	.2858				2.8826
5	2.572	2.3739	.381				2.8826
6	2.6292	2.5434	.381		.2858		2.8826
7	3.7209	3.0521	.381	.1372	.2858	.1524	3.5608
8	4.1152	3.3913	.2858	.1315	.2858	.1143	3.7304
9	.2858	1.1203		4.0695	3.9438	.2058	.2858
10	.2858			4.9173	4.9611	.1067	.2858
11	.1905	4.4086			4.7478	.1143	.1905
12		4.7478			4.1438	.1448	.1905
13	.1905	4.7478			4.3591	.1448	
14	.1905	4.7478			4.3591		
15	.1905	3.3913				.1448	
16	.1905	4.5782			4.3096	.1486	
17	.1905	.2858				.1448	
18	.1905	.2858	.213			.1829	
19	.2858	.381				.3048	
20	.2858	.381			.2058	.2896	
21	.2858	.381	.1829			.3048	
22	.9526	.2858	.1181		.1334	.3048	
23	2.0348	.2858	.1143			2.713	
24	2.5434	2.0348	.2858	.128	.1905	.1372	2.8826
Max	4.1152	4.7478	.381	4.9173	4.9611	2.713	3.7304
Min	.1905	.2858	.1143	.1105	.1334	.1067	.1905
Avg	1.3710	2.2419	.2682	1.5823	2.4778	.3328	2.1863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 201 / 11KV KALDARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953		.3429	.4151	.0747	.0953
2	.0381	.0953		.3429	.4002		.0934
3	.0953	.0953		.3258	.4002		.0934
4	.0953	.1334		.3258	.3695	.0747	.1294
5	.1905	.1905		.3467			.1867
6	.2286	.2286		.3944	.3695		.2241
7	.2614	.2286		.583	.4618		.2614
8	.2614	.2286		.6443	.4926	1.3565	.1867
9	1.4922	.1334		.132	.123		1.2209
10	1.56	.1307		.1143	.0943	1.6448	1.6278
11	2.035	.0747	.0754	.1143	.0754	1.7635	
12	1.6144	.0754	.0754	.1143	.0566	1.6956	1.5394
13	1.601	.0747	.0754	.0762	.4843	1.5424	1.5067
14	1.5337	.056	.0754	.0572	.6401	1.7635	1.4914
15	1.503	.056	.0754	.0762	.6859	1.3748	1.4778
16	1.3633	.056		.0953	.6642	1.4754	1.4895
17	.0953	.0934	.0754	.0953	.0754	.112	.1208
18	.1524	.1307	.1132	.0953		.1494	.1905
19	.1715	.2614	.2263	.2286		.0187	
20	.2071	.2641	.2263	.2286			.2096
21	.1715	.2452	.1886	.1715		.2054	.1715
22	.1715	.1494	.1311	.1524		.1494	.1524
23	.1143	.3932	.3239	.4618	.0934	.112	.1143
24	.1143		.3978	.4151		.0747	.0934
Max	2.035	.3932	.3978	.6443	.6859	1.7635	1.6278
Min	.0381	.056	.0754	.0572	.0566	.0187	.0934
Avg	.6319	.1517	.1584	.2473	.3471	.7993	.5762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 202 / 11 KV PARINCHE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9656	.861		.0754	.0762		1.1271
2	.9666			.0754	.0762		1.1401
3	.9494	.0084		.0754	.0762		1.1401
4	.8313	.8313		.0754	.0762	.112	1.1271
5	.7995	.8005		.0943	.0953		1.1401
6	.7697	.7697		.132	.1143		1.1401
7	1.2452	.9994		.1509	.1143	.1867	1.5089
8	1.5074	1.3069		.1132	.1143		1.6907
9	.112	1.8473		1.5581	1.8473	.112	.1494
10	.0934	2.079		1.7857	2.1795	.112	.1307
11	.0953	2.13	2.2119	1.8296	1.9841	.1307	.0133
12	.0762	2.1548	2.1136	1.7681	1.6549	.0934	.0076
13	.0762	2.13	1.8564	1.5375	.0747		.0572
14	.0572	1.9989	1.8187		.0754		.0572
15	.0762	1.989	1.7859	1.3837	.0754		.0762
16	.0859	1.7901	1.5708	1.3393	.0754	.0934	.0076
17	.0953	.0747	.0566	.0762	.1509	.0914	.0762
18	.1143	.0934	.0754			.1307	.1143
19	.1207	.0934	.1509	.1334		.1867	
20	.1524	.1307	.1698	.1524		.1867	
21	.1524	.112	.132	.1524		.1494	
22	.1143	.0934	.1132	.1143		.168	
23	.8764	.0747	.0754	.0762	.1307	1.1401	1.0468
24	.8302		.0747	.0953		.112	.984
Max	1.5074	2.1548	2.2119	1.8296	2.1795	1.1401	1.6907
Min	.0572	.0084	.0566	.0754	.0747	.0914	.0076
Avg	.4651	1.0168	.8718	.5816	.4995	.2003	.6367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 203 / 11KV VEER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7389	.7389		.0754	.0762		.7956
2	.7072	.7081		.0754	.0762		.7956
3	.6893	.6919		.0754			.7956
4	.6927	.6902		.0754			.7956
5	.8104	.0745		.0943	.0762		.8048
6	.7389	.7389		.132	.0762		.8215
7	.7625	.8467		.1509	.0572		.8619
8	.8785	1.0314		.0943	.0381		.9831
9	.056			1.2452	1.3837		.0187
10	.0373	1.5927		1.4452	1.5592		.0187
11	.0381	1.6741	1.933	1.5375	1.5074		.0019
12	.0572	1.8233	1.861	1.5067	1.4255	.0187	.0191
13	.0762	1.8023	1.8275		.0377		.0191
14	.0762	1.7204	1.8275	1.4606	.0566	.0187	
15	.0572	1.5893	1.7695			.0373	.0191
16	.0572	1.5238	1.5623		.0566	.0373	.0191
17	.0572	.0747	.0754	.0762	.0566	.0373	.0191
18	.0572	.056	.0754			.056	.0191
19	.1143	.112	.1132	.1334		.056	.0191
20	.1334	.112	.132	.1334		.1307	.0191
21	.1143	.112	.1132	.0572		.112	.0191
22	.0953	.0934	.0934	.0762		.0747	.0191
23	.738	.0924	.0934		.0934	.7956	
24	.6927		.0924	.0762		.0747	.8122
Max	.8785	1.8233	1.933	1.5375	1.5592	.7956	.9831
Min	.0373	.056	.0754	.0572	.0377	.0187	.0019
Avg	.3532	.8136	.8264	.4485	.4385	.1208	.3498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 204 / 11KV VEER GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2005	.0771	.1143	.224	.1143	.2057	.224
2	.2005	.1625	.0762	.2229	.0762	.2048	.224
3	.2006	.1625	.1143	.224	.2005	.1143	.2229
4	.2179	.2179	.1143	.224	.2697	.2048	.2987
5	.3248	.325	.1905	.3187	.1524	.317	.4847
6	.6119	.6496	.3048	.6595	.4918	.5974	.7918
7	.868	.7676	.4572	.8485	.7516	.9062	.8866
8	.8306	.7122	.4572	.4572	.7676	.8306	.8119
9	.7552	.567	.4191	.7171	.6569	.6992	.6797
10	.6416	.4496	.3048	.5112	.5609	.5609	.5791
11	.4736	.4458	.4862	.4557	.4298	.4679	.4904
12	.4178	.3715	.3875	.3793	.3568	.3734	.4176
13	.3625	.3715	.3677	.3453	.3551	.3551	.401
14	.3457	.2778	.2941	.29	.3353	.3551	.3453
15	.3283	.2957	.2751	.3072	.3136	.3551	.2903
16	.2905	.3153	.2941	.3072	.3119	.3368	.3078
17	.3078	.3534	.2957	.3078	.2926	.2987	.3072
18	.3802	.3734	.3534	.3623	.1524	.4298	.3048
19	.4465	.7171	.6618	.6363	.3048	.6976	.4763
20	.6566	.6992	.6919	.7122	.3429	.6797	.5334
21	.5155	.5266	.6172	.6039	.3429	.6416	.4763
22	.3699	.4515	.4477	.4947	.2667	.4534	.381
23	.256	.3018	.2621	.3113	.3002	.3199	.1905
24	.2005	.1143	.2252	.2178	.1143	.2057	.2096
Max	.868	.7676	.6919	.8485	.7676	.9062	.8866
Min	.2005	.0771	.0762	.2178	.0762	.1143	.1905
Avg	.4251	.4044	.3422	.4224	.3442	.4421	.4306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 205 / 11KV KALDARI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0865	.0862		.0747		.0924	.0863
2	.069	.069		.0754			.0732
3	.0519	.0517		.0754	.0073		.0732
4	.0398	.0518		.0747	.069	.0924	.0914
5	.0863	.0862		.112	.1036		.1478
6	.2069	.2067		.2241	.1726		.2614
7	.2987	.2069		.2641	.2069		.2987
8	.2241	.2064			.1897		.2614
9	.2149	.1886		.1949	.1552	.168	.2561
10	.2012	.1463			.1417	.1463	.2195
11	.1539	.0895	.0848		.124	.1086	.172
12	.1373	.0716	.0857	.1036	.0876	.0886	.1376
13	.1207	.0886	.0876	.0054	.0886	.0876	.1207
14	.1203	.0526	.0895	.0516	.0724	.0876	.086
15	.1207	.0526	.0886	.069	.0905	.0886	.086
16	.1204	.0716	.0716	.086		.0914	.1032
17	.155	.0905	.1107	.172	.1063	.1086	.1207
18	.1897	.1267	.1595	.1718		.1646	.1584
19	.2064	.2957	.2614	.2237		.2614	
20	.2067	.2801	.2614	.2409		.2241	.2411
21	.1724	.2241	.1677	.1375		.2054	.172
22	.1552	.1478	.1341	.2589		.168	.1376
23	.1208	.1109	.0747	.1202	.1463	.1109	.1032
24	.0865		.0732	.1547			.0924
Max	.2987	.2957	.2614	.2641	.2069	.2614	.2987
Min	.0398	.0517	.0716	.0054	.0073	.0876	.0732
Avg	.1477	.1305	.1250	.1376	.1174	.1350	.1522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 206 / 11KV PARINCHE GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1379	.1381		.1494	.1552	.1097	.1478
2	.1207	.1206		.1494	.1379		.1463
3	.128	.1206		.1494	.1379		.1463
4	.1381	.1378		.1494	.1379	.1097	.1848
5	.1724	.172		.168	.2241		.2241
6	.2762	.2759		.3361	.2241	.3921	.3361
7	.3734			.3961	.3448		.3326
8	.3734	.3621		.3361	.2931		.3361
9	.2926	.2414		.2865	.2244	.2987	.2926
10	.2658	.2149		.2064	.2629	.2126	.2195
11	.2414	.2126	.181	.1892	.2058	.181	.206
12	.2069	.2126	.1829	.1897	.1715	.2172	.2064
13	.2069	.1802	.1949	.2071	.1715	.197	.1897
14	.2064	.2058	.1991	.2067	.1595	.1772	.1892
15	.1892	.2035	.2058	.2064	.1402	.1928	.2062
16	.1897	.2103	.2229	.2234	.1753	.2454	.2064
17	.2232	.2279	.2279	.2234	.1943	.2507	.2234
18	.3097	.2658	.2686	.2578		.2926	.2581
19	.3441	.3475	.3982	.2589		.4108	.2921
20	.3613	.3734	.394	.2414		.3547	.31
21	.31	.3361	.3109	.2417		.2987	.2581
22	.2074	.2402	.2378	.2589		.2402	.2067
23	.172	.1829	.1663	.2069	.1294	.1663	
24	.1376		.1478	.1552		.1097	.1376
Max	.3734	.3734	.3982	.3961	.3448	.4108	.3361
Min	.1207	.1206	.1478	.1494	.1294	.1097	.1376
Avg	.2327	.2265	.2384	.2247	.1939	.2346	.2285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 207 / 11KV KAMBALWADI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2107	.287	.0854	.2961	.0879	.1616	.1646
2	.1816	.2858	.0827	.2957	.0956	.1616	.1635
3	.0913	.2343	.0819	.294	.2168	.1616	.1635
4	.0929	.2343	.0819	.2953	.2351	.1616	.1638
5	.1898	.287	.0823	.2953	.2343	.1719	.1638
6	.29	.2896	.0838	.298	.2892	.2961	.1653
7	.3193	.2908	.0846	.2984	.2354	.3152	.1997
8	.3006	.2892	.0846	.2976	.1592	.2968	.3209
9	.3182	.29	.0842	.2424	.0892	.2978	.2999
10	.3174	.2458	.0861	.1768	.1672	.2968	.319
11	.2216	.1688	.1684	.1607	.0914	.3193	.2908
12	.1581	.1463	.1684	.16	.1653	.1699	.2923
13	.1358	.1593	.1661	.1588	.1642	.2961	.2866
14	.2335	.1585	.1653	.1415	.106	.165	.1194
15	.285	.1593	.1661	.0869	.2126	.1778	.1362
16	.2333	.1654	.1657	.1002	.1835	.0267	.1011
17	.1456	.1639	.1592	.1585	.0519	.045	.0745
18	.1391	.1372	.1573	.1577	.0263	.0819	.1339
19	.1412	.1635	.1669	.1053	.0598	.0747	.1531
20	.1415	.1631	.2991	.0436	.0903	.1654	.1916
21	.1588	.1627	.2972	.0436	.0888	.1642	.237
22	.1585	.1627	.2976	.0436	.088	.1642	.2358
23	.0892	.1634	.2972	.0436	.1623	.1646	.1033
24	.2419	.0892	.2412	.0436	.0876	.165	.16
Max	.3193	.2908	.2991	.2984	.2892	.3193	.3209
Min	.0892	.0892	.0819	.0436	.0263	.0267	.0745
Avg	.1998	.2040	.1564	.1766	.1412	.1875	.1933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 208 / Penjalwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.097	.0969	.7506	.8726	.9962	.1044	.0848
2	.1031	.1039	.7194	.865	.9133	.1082	.0861
3	.0964	.1054	.6752	.8337	.8902	.1105	.0933
4	.0956	.0986	.6318	.8078	.4915	.1143	.0899
5	.1292	.1072	.6417	.8147	.9096	.112	.1046
6	.1034	.1156	.6668	.8691	.9294	.1134	.1086
7	.1236	.1179	.8253	1.1004	1.014	.1219	.1265
8	.1231	.1168	.9526	1.2936	1.0472	.1494	.1137
9	1.7541	.0856	.8962	.7703	.5841	1.6842	1.9761
10	2.7452	.0701	.0472	.0717	.0533	2.7244	2.9071
11	2.9852	.0724	.0585	.0702	.0648	2.6562	2.9488
12	2.9481	.0755	.0585	.0756	.0694	2.915	3.0229
13	1.7661	.0762	.0694	.0741	1.0785	3.03	2.8878
14	2.8542	.0831	.0758	.0854	2.2302	3.0161	2.862
15	2.7152	.0815	.0709	.1525	2.7558	2.8647	2.7454
16	2.518	.077	.0577	.1183	2.7246	2.7755	2.7157
17	1.2919	.1082	.1028	.1022	1.4639	1.5058	1.321
18	.1669	.1311	.1166	.1178	.0968	.0991	.0989
19	.1428	.1395	.1091	.077	.0793	.1044	.1125
20	.1198	.1421	.1189	.0732	.0732	.1057	.1331
21	.1458	.1495	.1166	.0739	.0861	.1129	.1267
22	.142	.1516	.1151	.0854	.0869	.104	.1237
23	.1377	1.2307	.7785	.3871	.0876	.1075	.1173
24	.0895	.7651	1.1393	1.137	.0777	.0556	.0793
Max	2.9852	1.2307	1.1393	1.2936	2.7558	3.03	3.0229
Min	.0895	.0701	.0472	.0702	.0533	.0556	.0793
Avg	.9747	.1792	.4081	.4554	.7835	1.0331	1.0411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION

Feeder No / Name : 201 / 11KV PANDESHWAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4218	.4416	.4058	.3852	.4096	.4024	.3921
2	.4553	.4287	.4344	.4039	.4043	.3915	.4361
3	.5089	.4759	.4767	.4466	.4398	.3984	.4822
4	.6049	.58	.6092	.5774	.5232	.5102	.5632
5	.761	.8078	.7807	.7594	.7415	.6965	.7623
6	1.1694	1.1899	1.2414	1.1328	1.1363	1.1553	1.1845
7	1.2575	1.3264	1.3131	1.2227	1.315	1.3012	1.2437
8	1.1195	1.1908	1.1629	1.1772	1.2239	1.225	1.177
9	.9385	.8871	.8596	.9469	.9456	.9816	1.0391
10	.6195	.6474	.5838	.6228	.727	.6527	.8821
11	.4908	.4466	.4251	.4642	.4656	.4485	.6874
12	.3967	.3963	.3807	.3925	.445	.3507	.5018
13	.3608	.3568	.3566	.3974	.394	.3225	.4313
14	.3326	.3292	.3391	.3578	.3791	.3193	.3414
15	.3258	.3471	.3394	.3288	.3387	.3189	.3509
16	.3681	.3951	.3631	.3994	.3655	.3818	.4066
17	.4058	.458	.4937	.5593	.4411	.4835	.4866
18	.6165	.7027	.6432	.8726	.6574	.6768	.7099
19	1.1382	1.2041	1.1081	1.2472	1.0838	1.0694	1.0361
20	1.107	1.2272	1.053	1.198	1.0536	1.0654	.9937
21	.9576	1.0286	.8787	.9888	.5258	.9328	.8581
22	.7914	.7956	.6842	.7674	.7041	.7173	.6973
23	.5777	.5098	.4809	.5106	.4931	.5024	.5331
24	.451	.4264	.4032	.4096	.418	.4085	.4424
Max	1.2575	1.3264	1.3131	1.2472	1.315	1.3012	1.2437
Min	.3258	.3292	.3391	.3288	.3387	.3189	.3414
Avg	.6740	.6916	.6590	.6904	.6513	.6547	.6933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION

Feeder No / Name : 202 / 11KV PANDESHWAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2709	.132	.3185	.3185	.3563	.2494	.132
2	.2702	.132	.3567	.3521	.3887	.2526	.1307
3	.3077	.132	.3715	.3864	.4049	.2709	.1494
4	.3345	.1698	.3814	.3913	.4534	1.2193	.1886
5	.4131	.2263	.4365	.381	.4999	.3048	.2241
6	.524	.3395	.4999	.3749	.578	.3395	.3018
7	.6196	.3772	.68	.5243	.5937	.4218	.3206
8	.6432	.3584	.7209	.6081	.7343	.4902	.3395
9	1.195	.2641	.2241	.1509	.2452	.5335	.578
10	1.3215	.168	.1848	.132	.1867	.5487	.5468
11	1.3344	.132	.1294	.132	.1294	.5117	.503
12	1.3227	.112	.1294	.1132	.1294	.5135	.4725
13	1.3626	.1294	.128	.1132	.128	.535	.4877
14	1.3211	.1109	.128	.1132	.1097	.5719	.4999
15	1.2386	.1307	.1294	.1132	.1097	.5428	.4999
16	1.2079	.1097	.1494	.1132	.128	.5281	.4843
17	.7526	.1267	.1494	.132	.1254	.1075	.1132
18	.2263	.2241	.1663	.2263	.168	.1663	.2263
19	.3206	.3206	.2957	.3206	.2829	.2829	.2829
20	.3018	.2829	.2614	.2641	.2829	.2452	.2452
21	.2641	.2263	.2241	.2263	.1886	.2241	.2075
22	.1886	.1698	.168	.1509	.168	.1867	.1698
23	.1509	.362	.333	.3563	.2462	.1494	.132
24	.132	.132	.3243	.3102	.3563	.2462	.132
Max	1.3626	.3772	.7209	.6081	.7343	1.2193	.578
Min	.132	.1097	.128	.1132	.1097	.1075	.1132
Avg	.6677	.2029	.2871	.2627	.2914	.3934	.3070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION

Feeder No / Name : 203 / 11KV KOTHALE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7667	.7285	3.9049	3.7982	3.7594	3.2236	.8337
2	.809	.7316	3.7611	3.6925	3.69	3.219	.8299
3	.8208	.7518	3.7563	3.7014	3.69	3.199	.8503
4	.8577	.7918	3.7424	3.7073	3.7274	3.2083	.8372
5	.9071	.8383	3.7509	3.5955	3.7708	3.2438	.918
6	1.009	.9213	3.9814	3.6195	3.9948	3.4126	1.0753
7	1.1528	1.0227	4.5625	4.1522	4.3073	3.6545	1.1386
8	1.1454	.9929	4.9821	5.0983	4.8346	3.9554	1.1439
9	3.2103	.9007	3.0156	3.04	2.9622	4.1186	3.3219
10	4.0576	.8688	.6729	.7609	.6806	4.4977	3.9036
11	4.5572	.847	.6973	.7579	.6984	4.575	4.4898
12	4.5519	.8261	.6897	.7583	.3353	4.6837	4.8028
13	4.6769	.792	.7215	.8303	.5487	5.1616	4.6044
14	4.699	.7579	.7352	.8067	.634	4.9264	4.5359
15	4.6685	.7339	.7045	.7468	.6767	4.4719	4.382
16	4.635	.7103	.6969	.7995	.7133	4.3015	4.3763
17	2.7096	.728	.7382	.8025	.7278	2.5453	2.3534
18	.6641	.8033	.7491	.892	.6996	.5718	.7072
19	.8413	.932	.97	.9518	.8284	.849	.9705
20	.881	.9515	.985	.8962	.8534	.8964	1.0182
21	.8482	.8749	.9022	.8498	.8562	.9305	1.0242
22	.8051	.836	.8088	.791	.8517	.9192	1.0101
23	.7621	3.5345	3.2693	3.3459	2.6078	.8745	.9716
24	.7493	2.559	3.8573	3.9091	3.6709	1.7339	.8393
Max	4.699	3.5345	4.9821	5.0983	4.8346	5.1616	4.8028
Min	.6641	.7103	.6729	.7468	.3353	.5718	.7072
Avg	2.1161	1.0181	2.1940	2.1793	2.0883	3.0489	2.1224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION

Feeder No / Name : 204 / 11KV NAZARE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.2801	.8977	.8977	.945	.8069	.3142
2	.3292	.2987	.9633	.9267	.945	.7335	.2957
3	.3511	.2987	.9808	.9808	.9755	.724	.3292
4	.3734	.3361	1.034	.9389	.9659	.695	.3361
5	.3961	.3734	1.078	.9214	1.0105	.6716	.3734
6	.4294	.4108	1.0974	.8949	1.07	.6573	.3921
7	.4481	.4481	1.2191	1.0974	1.1145	.7145	.3921
8	.4066	.3921	1.2037	1.2041	1.1149	.8145	.3511
9	.9536	.3361	.2715	.3361	.2587	.9587	.9362
10	1.1443	.2896	.2957	.3361	.2772	1.0997	1.0105
11	1.1888	.2686	.2987	.3361	.2957	1.1591	1.0974
12	1.2651	.2896	.2987	.3361	.3326	1.0709	1.1126
13	1.2498	.2835	.2987	.3361	.2957	1.0433	1.1294
14	1.1888	.2686	.2987	.3361	.2772	1.1149	1.1149
15	1.1431	.2715	.3361	.3174	.2772	1.1439	1.1003
16	1.1248	.2804	.362	.3174	.2772	.9334	1.0709
17	.2054	.3045	.362	.3361	.3077	.2896	.2353
18	.2614	.3189	.3801	.3921	.3142	.2534	.3292
19	.3174	.4251	.4525	.4668	.3142	.2987	.4108
20	.3361	.4435	.439	.4294	.2987	.3511	.4108
21	.3361	.3921	.4024	.3921	.2772	.3174	.4294
22	.2987	.3547	.3696	.3361	.2561	.2957	.4108
23	.2801	.9934	.9808	.9145	.8471	.2926	.3921
24	.3326	.2801	.9659	.9783	.945	.8322	.2743
Max	1.2651	.9934	1.2191	1.2041	1.1149	1.1591	1.1294
Min	.2054	.2686	.2715	.3174	.2561	.2534	.2353
Avg	.6114	.3599	.6369	.6149	.5830	.7197	.5937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION

Feeder No / Name : 301 / 22 KV NIRA U GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.775	.8151	.4085	.4066	.3734	.7621
2	.4108	.7666	.8075	.3887	.4108	.3734	.8291
3	.439	.7995	.8429	.3917	.439	.4108	.8337
4	.5175	1.0128	1.0783	.4298	.4435	.4481	.8954
5	.5975	1.1881	1.2956	.5502	.4854	.5975	1.195
6	.6653	1.6171	1.5844	.756	.4854	.7842	1.4967
7	.8501	2.0942	2.1594	1.0959	.7545	1.0829	1.8709
8	1.0082	2.1018	1.1523	1.1523	.8962	1.0456	2.1491
9	.8589	1.8725	1.0181	1.038	.7392	.7712	2.0004
10	.8962	1.6019	.8185	.852	.7095	.7468	1.6713
11	.6722	1.4624	.7804	.7667	.5975	.7468	1.6164
12	.6348	1.339	1.2719	.7057	.5975	.6722	1.4731
13	.6348	1.2575	1.2041	.7164	.6348	.6348	1.2887
14	.5975	1.2437	1.1423	.66	.5975	.4854	1.2026
15	.5601	1.1789	1.1195	.6142	.6283	.5601	1.1889
16	.5601	1.1709	.631		.5975	.6348	1.1904
17	.5975	1.23	.6356		.5975	.7095	1.2891
18	.6348	1.2498	.6706		.6348	.7468	1.3352
19	.9054	1.829	.9114		.8962	1.6987	1.6255
20	.8589	1.7276	.9633		.8962	1.6499	1.6743
21	.7545	1.6064	.8947		.7842	1.656	1.5607
22	1.3283	1.448	.7849	.6283	.6348	1.3877	1.3664
23	1.0638	1.2201	.631	.4854	.5228	1.1134	1.1012
24	.9206	.8867	.9099		.4108	.8696	.8848
Max	1.3283	2.1018	2.1594	1.1523	.8962	1.6987	2.1491
Min	.4024	.7666	.631	.3887	.4066	.3734	.7621
Avg	.7237	1.3616	1.0051	.6847	.6167	.8417	1.3542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION

Feeder No / Name : 302 / 22 KV PIMPRA GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.708	.7827	.3734	.3292	.3361	.7537
2	.3361	.6999	.7766	.3643	.3361	.3361	.7537
3	.3734	.7407	.8139	.3749	.3734	.3361	.7941
4	.4481	.836	.9404	.4085	.4066	.4108	.9099
5	.5544	1.0082	1.2841	.5228	.4805	.5975	1.1728
6	.6653	1.4632	1.5317	.6706	.5544	.7468	1.5783
7	.8215	1.621	1.6994	.8169		.7468	1.6796
8	.7922	1.6423	1.7185	.8002	.8215	.7842	1.6347
9	.7468	1.5127	.8078	.7941	.6283	.7468	1.4868
10	.6722	1.2094	.7087	.6706	.7095	.4854	1.2414
11	.5601	1.1355	.7575	.5456	.5601	.4481	1.1865
12	.5975	1.2239	1.1645	.5075	.4481	.4481	.9301
13	.5601	1.2551	.5975	.5091	.5601	.5601	.9556
14	.5228	1.2422	.4481	.5167	.5975	.5068	.8711
15	.5601	1.2514		.5106	.4481	.6653	.8741
16	.5601	1.2529	.6554		.5601	.5601	.9914
17	.5601	1.198	.7011		.4854	.5601	.9084
18	.5228	1.2002	.5761		.5601	1.2376	.5658
19	.7468	1.7444	.852		.7842	1.5493	.5975
20	.8215	1.7021	.8276		.7095	1.4373	.5975
21	.6348	1.4968	.7362		.6348	1.3542	.5228
22	1.3924	1.2521	.6127	.5175	.5228	1.1721	.4481
23	.8459	.9937	.4893	.4805	.4481	1.0014	.3734
24	.7167	.8002	.7537		.3361	.7796	.3734
Max	1.3924	1.7444	1.7185	.8169	.8215	1.5493	1.6796
Min	.3326	.6999	.4481	.3643	.3292	.3361	.3734
Avg	.6393	1.2162	.8798	.5520	.5345	.7419	.9250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION

Feeder No / Name : 303 / 22KV NIRA (U) AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.4091	.3052		.3018	.3353	1.5074
2	1.5089	1.3923	.3052		.3052	.3353	1.5074
3	1.4586	1.3923	.2984		.3353	.3353	1.5074
4	1.5249	1.4582	.2984		.3315	.3353	1.5729
5	1.5249	1.4582	.3353		.3353	.3688	1.6057
6	1.5939	.5304	.373		.3277	.3688	1.6712
7	1.9113	1.7635	.407		.431	.4024	1.9662
8	2.1795	1.9334	.3688		.3353	.4024	2.2283
9	.3018	2.1795			1.9559	.3647	.3315
10		2.6825				.3315	.2984
11	.3018	2.5484			2.0885	.2683	.3353
12		2.4813	2.1795		2.42	.2122	.2984
13		2.4813	2.3137		2.4531	.2683	.218
14		2.2801	2.2466		2.2874	.2984	.1956
15		2.1795	2.1795		2.0553	.2984	.1856
16	.2683	2.146	2.1795		2.1216	.3315	.1989
17	.2683	.2683			.2683	.2984	.1923
18	.3353				.3647	.2984	.3315
19	.4409	.3688			.4359	.4694	.4024
20	.4359	.407			.4359	.3688	.4024
21	.3978	.4024			.4359	.4024	.3688
22	.3647	.373		.4359	.4359	.3353	.3688
23	1.3592	.3353		.373	.4024	1.4419	1.5074
24	1.4746	1.3592	.3018		.3315	.3688	1.6095
Max	2.1795	2.6825	2.3137	.4359	2.4531	1.4419	2.2283
Min	.2683	.2683	.2984	.373	.2683	.2122	.1856
Avg	1.0075	1.4709	1.0066	.4045	.9215	.3850	.8671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 301 / 22 KV PURANDAR AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963	.4207	.0754	.1006	.1132	.1132	.4534
2	.3353	.3506	.0754	.0983	.1132	.1132	.4534
3	.3479	.3506	.0754	.1296	.1509	.1509	.4588
4	.3795	.4115	.1132	.1311	.1509		.4858
5	.4481	.4115	.1132	.1638	.1494		.4915
6	.5121	.4458	.1886	.1638	.1886	.1848	.4915
7	.6081	.4458	.1848	.1696	.1886	.2218	.6478
8	.7125	.5765		.1696	.1494	.181	.8048
9	.1478	.5053		.5792	.5365	.1677	.1463
10	.1494	.5487		.6516	.6036	.1619	.1848
11	.1478	.5792		.6706		.1029	.1867
12	.112	.6097	.7209	.6962		.1715	.1867
13	.1494	.6642	.6478	.663		.1638	.1867
14	.1494	.6009	.5243	.5571		.1677	.1494
15	.1494	.3795	.6154	.6226		.1524	.1494
16	.1478	.5506	.5693	.6962		.1638	.1494
17	.1848		.1715	.1848		.1943	.1867
18	.1867	.1886		.1867		.1966	.1494
19	.1494	.181	.1966	.1867	.1509	.1943	.1867
20	.1867	.1448	.1638	.1886	.1886	.1619	.1867
21	.1867	.1509	.1638	.1886		.1638	.1886
22	.1886	.1509	.1619	.1509	.1509	.1677	.1886
23	.3582		.1696	.1509		.6554	.6089
24	.4572	.4298	.1132	.6962	.1132	.1509	.583
Max	.7125	.6642	.7209	.6962	.6036	.6554	.8048
Min	.112	.1448	.0754	.0983	.1132	.1029	.1463
Avg	.2830	.4135	.2655	.3415	.2106	.1864	.3294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 302 / 22 KV SHIVARI AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.9403	6.6278	1.899	2.2076	2.1156	1.8129	4.8463
2	5.5945	6.4044	1.9432	2.1926	2.161	1.7523	4.6191
3	5.2177	6.3586	1.9406	2.383	2.7101	1.7683	4.3899
4	5.487	6.2586	2.0479	2.5092	2.7336	1.8567	4.4027
5	6.4074	6.2277	2.1977	2.6542	3.0186	2.2741	4.4188
6	7.2293	6.5183	2.7526	3.2811	3.359	2.5173	4.7416
7	8.3565	7.3204	3.1898	3.5139	3.3829	2.6711	5.8628
8	10.3231	8.393	2.5043	3.5532	3.471	2.8673	6.4962
9	8.4621	8.8775	2.0506	4.7972	5.1558	2.4764	5.6789
10	2.9236	9.5129	4.7252	9.9721	6.8165	2.1079	2.056
11	2.6184	9.4893	4.6883	10.2205	7.0234	1.7453	1.8692
12	2.2033	7.9274	1.5183	10.3956	.3599	1.5722	1.7449
13	2.2619	9.0573	1.8767	9.8874	.3515	1.6139	1.7183
14	2.2403	8.8033	6.7641	6.4099	.1169	1.5592	1.3658
15	2.3807	6.5047	10.251	1.7852	.6645	.9894	1.2688
16	2.4694	5.9263	10.7573	6.936	.5521	1.0152	1.2246
17	2.3527	6.0055	8.0628	7.5799	.0965	1.5196	1.4482
18	2.6821	2.5552	2.9188	2.8853	.0957	1.8255	1.7746
19	2.961	2.8423	3.3877	2.9936	2.0876	1.9023	1.8926
20	3.1643	2.9785	2.7521	3.2225	2.4088	2.1318	2.3616
21	3.104	2.9192	3.4716	3.1579	1.7602	1.9977	2.4421
22	2.8455	2.8302	3.1136	2.9387	2.1213	2.0359	2.4207
23	3.819	2.0966	2.9041	2.6405	1.6061	2.8818	2.8796
24	6.5402	3.4868	2.3357	1.9989	2.1771	4.1871	4.6019
Max	10.3231	9.5129	10.7573	10.3956	7.0234	4.1871	6.4962
Min	2.2033	2.0966	1.5183	1.7852	.0957	.9894	1.2246
Avg	4.4827	6.0801	3.7522	4.5882	2.3477	2.0451	3.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 303 / 22 KV KHALAD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4891	1.6111	8.7121	8.6344	7.5141	2.1278	1.7497
2	1.5196	1.6415	8.1756	8.0704	7.1712	2.1582	1.7517
3	1.5501	1.6415	7.9927	7.9637	7.0493	2.1887	1.7673
4	1.6949	1.8229	7.9622	8.1962	6.8853	2.2192	1.8054
5	4.2882	1.794	8.5871	8.8249	7.2397	2.4311	1.9075
6	2.0302	2.0607	9.2669	9.2669	7.8685	2.492	2.0668
7	2.0607	2.3014	11.5912	11.4159	9.0058	2.492	1.9143
8	1.9997	2.1521	10.3948	13.7479	10.7362	2.7954	2.018
9	11.4922	1.7894	7.8342	7.694	11.4008	12.7058	11.5227
10	14.8423	1.576	1.3717	1.5455	9.2669	16.3352	15.6608
11	15.9732	1.5806	1.0669	1.3931	9.5412	17.3031	15.9427
12	15.9046	1.5455	.4572	1.4845		17.4573	15.5102
13	15.0053	1.4282	1.7832	1.4799		17.6402	14.7767
14	14.3481	.8535	.945	1.5714		17.4135	14.3386
15	13.9347	1.2193	1.4174	1.4236		15.8512	14.0166
16	13.8242	.9755	1.3565	1.3321		12.8753	13.4096
17	7.729	1.9753	1.8252	1.6065		6.2186	7.5721
18	1.8778	2.3091	1.8861	1.9692	.3353	2.1338	2.3014
19	2.0668	2.2938	2.21	2.1217	1.5546	2.271	2.1887
20	2.271	2.0973	2.3015	2.3624	2.1278	2.332	2.0973
21	2.0973	2.2787	2.271	2.2497	1.6461	2.3015	2.3701
22	2.0668	2.5225	2.2862	2.4311	2.2497	2.2557	2.3396
23	1.8854	6.5234	8.6039	7.657	1.5546	1.9852	1.9159
24	1.6111	7.1285	8.9926	7.9142	3.7914	1.8534	1.4647
Max	15.9732	7.1285	11.5912	13.7479	11.4008	17.6402	15.9427
Min	1.4891	.8535	.4572	1.3321	.3353	1.8534	1.4647
Avg	6.3984	2.2134	4.9705	5.0982	5.9410	6.9932	6.3504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 304 / 22 KV SASWAD U NO 1

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.679	.6722	.6722	.679	.6722	.7316
2	.6348	.679	.6722	.6722	.679		.6584
3	.7095	.679	.6722	.6584	.679	.6722	.6584
4	.7468	.7545	.7762	.7316	.7545	.7468	.7468
5	.8131	.7545	.8501	.9145	.7922	1.0974	.9335
6	1.2197	1.358	1.3535	1.2803	1.3203	1.5238	1.1706
7	1.5203	1.8861	1.5775	1.6461	1.7353	1.7833	1.5729
8	1.4746	1.5844		1.6461	1.6221	1.4746	1.6461
9	1.5089	1.2803		1.2449	1.2071	1.4632	1.5089
10	1.2696	1.134		1.1576		1.2803	1.3443
11	1.1949	1.0608		1.0829		1.0974	1.1203
12	1.1203	1.0608	1.0242	1.0082		1.0136	1.0829
13	.9709	.961	.9774	.9709		.9774	.9709
14	.8962		1.0974	.9335		.9145	.8589
15	.8962		.905	.8962		.9145	.8962
16	.9335		.905	.9335		1.0242	.9709
17	1.0082		.9877	.9709		1.0974	1.0082
18	1.1949	1.3169	1.2803	1.2323		1.2803	1.1576
19	1.773	1.595	1.6461	1.6804		1.6461	1.5684
20	1.6975	1.5604		1.7353	1.6118	1.5729	1.5844
21	1.5089	1.4175	1.4632	1.5466		1.4632	1.4712
22	1.3203	1.2437	1.2803	1.2449	.9511	1.307	1.3203
23	.9431		.9145	.9054		.9145	.9808
24	.7095	.7545	.7468	.6584	.7167	.7392	.8215
Max	1.773	1.8861	1.6461	1.7353	1.7353	1.7833	1.6461
Min	.6348	.679	.6722	.6584	.679	.6722	.6584
Avg	1.1140	1.1452	1.0422	1.1010	1.0623	1.1598	1.116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 305 / 22 KV DIWA GOATHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.1132	.0754	.0732	.1132		.0754
2	.0754	.1132	.0754	.0747	.1132		.0754
3	.1132	.1509	.1132	.0732	.1132		.0747
4	.1132	.1509	.1132	.0747	.1509		.112
5	.1848	.1509		.1463	.1886		.1494
6	.2218	.2641		.2561	.3018		.2241
7	.2957	.3395		.2926	.3772		.2987
8		.3018		.2561	.3395	.3696	.2926
9	.3018	.2587		.2641	.2587	.2926	.2641
10	.2641	.1867		.2641		.2561	.2641
11	.1867	.1509	.0732	.2241		.2195	.2241
12	.1867	.1132	.1463	.1867		.1463	.1867
13	.1867	.1132	.1463	.1494		.1463	.1867
14	.1494		.0732	.1494		.1097	.1867
15	.1494		.0732	.1494		.1097	.1867
16	.1867		.0732	.1494		.1097	.1867
17	.1867		.1097	.1494		.1463	.1867
18	.2241	.1867	.1829	.1867		.1829	.2263
19	.3395	.2926	.2926	.3395		.2926	.3018
20	.3018	.2957	.2926	.3018	.2957	.2641	.3018
21	.2641	.2218	.2195	.2641		.2263	.2641
22	.2263	.2241	.1829	.2263	.1132	.1886	.2263
23	.1886		.1494	.1886		.1097	.1886
24	.1132	.1132	.0754	.0732	.1509	.1132	.112
Max	.3395	.3395	.2926	.3395	.3772	.3696	.3018
Min	.0754	.1132	.0732	.0732	.1132	.1097	.0747
Avg	.1972	.1969	.1371	.1880	.2097	.1931	.1998

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 306 / 22 KV KHALAD GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1509	.1132	.1494	.1509		.1494
2	.1509	.1509	.1132	.1463	.1509		.1494
3	.1509	.1509	.1132	.1494	.1509		.1463
4	.1886	.1886	.1886	.1463	.1886		.1867
5	.2587	.2641	.2218	.1829	.3018		.2241
6	.3696	.5281	.4066	.3658	.4527		.2987
7	.439	.6036	.5121	.5121	.5658		.439
8	.4805	.5281	.4066	.439	.4904	.4108	.5487
9	.4527	.2987		.4527	.2987	.4024	.415
10	.3772	.2241		.3361		.2561	.3395
11	.2987	.1509	.1829	.2614		.0732	.2987
12	.2987	.1509	.181	.2241		.1463	.2241
13	.2614	.1132	.181	.2614		.1463	.1867
14	.2614		.1448	.2614		.1463	.1494
15	.2241		.1448	.1867		.1463	.2241
16	.2614		.1829	.2614		.1829	.1867
17	.2987		.2926	.2614			.1867
18	.4108		.2926	.2987		.2926	.2614
19	.679		.5487	.5601		.5487	.5281
20	.6036		.5121	.5658	.5544	.5487	.4904
21	.4904		.3658	.4904		.415	.4527
22	.3395		.2561	.3772	.1886	.2641	.3772
23	.2263		.1829	.2263		.1829	.2263
24	.1886	.1509	.1509	.1494	.1886	.1509	.1463
Max	.679	.6036	.5487	.5658	.5658	.5487	.5487
Min	.1509	.1132	.1132	.1463	.1509	.0732	.1463
Avg	.3291	.2610	.2588	.3027	.3069	.2696	.2848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 307 / 22 KV SASWAD AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.6554	.4915	.5609	.0754	.0732
2	.0377	.0754	.5967	.503	.5487		.0373
3	.0377	.0754	.5967	.4858	.5144		.0373
4	.0754	.0754	.5967	.4915	.5144		.0732
5		.1132	.5898	.5898	.4801		.112
6	.1132	.1509	.6478	.583	.5144		.1494
7	.1494	.1494	.9069	.8192	.6859		.1463
8	.1494	.1494		.9175	.7042	.1509	.1448
9	1.0288	.1132		.0732	.8421	1.1469	1.0288
10	1.1934	.0754		.0747		1.3108	1.2003
11	1.3108	.0754	.0724	.0739		1.3108	1.1736
12	1.2308	.0754	.0724	.0747		1.4746	1.2742
13	1.166	.0754	.0732	.0739		1.3763	1.1934
14	1.0562		.0724	.0739		1.2955	1.1797
15	1.0883		.0724	.0747		1.1336	1.1336
16	1.0753		.1097	.0747		1.2452	1.1336
17	.0732		.1086	.112		.1097	.0732
18	.112	.0754	.1097	.2614		.1097	.112
19	.1494	.1132	.1097	.1494		.1086	.1494
20	.1132	.1132	.1097	.112	.1509	.1097	.1509
21	.1132	.1132	.1097	.1132		.439	.1509
22	.112	.1132	.1097	.1132	.0754	.4024	.1509
23	.0754		.4915	.631		.1097	.1132
24	.0754	.0754	.7125	.5243	.631	.0754	.0732
Max	1.3108	.1509	.9069	.9175	.8421	1.4746	1.2742
Min	.0377	.0754	.0724	.0732	.0754	.0754	.0373
Avg	.4614	.0991	.3297	.3121	.5185	.6658	.4610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 308 / 22 KV PURANDAR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	09-JAN-17
HR	Load (MW)
5	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 309 / 22 KV SHIVARI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3395	.3361	.2987	.3395		.2987
2	.3361	.3395	.2987	.2987	.3395		.2987
3	.3361	.3018	.2987	.2926	.3395		.2987
4	.3361	.3018	.3326	.3292	.3772		.3292
5	.3361	.3395	.3696	.3658	.415		.4024
6	.4435	.4904	.4805	.4755	.4904		.5121
7	.4435	.4904	.4435	.5121	.5281		.5121
8	.4066	.5281		.4024	.3772	.3326	.439
9	.5281	.4805		.5228	.2957	.3658	.5281
10	.6348	.5544		.6722		.5853	.5601
11	.6722	.5544	.5121	.6348		.5487	.5601
12	.6348	.4108	.543	.5601		.5121	.4854
13	.4854	.4435	.5121	.4854		.5068	.4854
14	.5601		.5121	.5601		.5121	.4854
15	.5601		.5121	.5975		.5121	.5228
16	.5601		.439	.4481		.5121	.4854
17	.4854		.5121	.5228		.5121	.4854
18	.4481	.3734	.439	.4854		.5121	.4481
19	.5658	.5175		.4854		.5121	.5281
20	.4527	.4066	.5121	.4904	.4066	.1097	.5281
21	.4527	.4108	.439	.4527			.4904
22	.415	.3696	.439	.3772	.2987		.415
23	.415		.3658	.415		.4024	.415
24	.3395	.3772	.3734	.3292	.3772	.2263	.3658
Max	.6722	.5544	.543	.6722	.5281	.5853	.5601
Min	.3361	.3018	.2987	.2926	.2957	.1097	.2987
Avg	.4660	.4226	.4335	.4589	.3821	.4442	.4533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 310 / 22 KV SASWAD NO 2

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3395	.3018	.2987	.3018	.3018	.3018
2	.3018	.3018	.3018	.2926	.3018	.3395	.2987
3	.3018	.3018	.3395	.2926	.3018	.3395	.2926
4	.3395	.3018	.3772	.2926	.3395	.4904	.3696
5	.3772	.3772	.4108	.3658	.3772	.6722	.4481
6	.415	.679	.8501	.5487	.7922	.8501	.6348
7	.8871	1.0562	1.134	1.0974	1.1694	1.0974	.9877
8	.9511	1.0562		.9774	1.0185	.9979	1.0974
9	.9054	.7762		.8676	.7762	.8215	.9808
10	.7842	.5975		.6348		.7316	.7468
11	.6348	.5601		.5228		.5853	.6722
12	.5601	.5228	.5487	.5228		.5792	.5601
13	.5228	.5601	.4706	.5228		.4706	.4854
14	.4481		.4024	.4854		.439	.4481
15	.4481		.4344	.4854		.439	.4854
16	.4481		.5121	.5228		.4706	.4854
17	.5228		.5487	.6348		.5853	.5228
18	.6348	.6722	.5487	.6348		.6219	.6348
19	.8299	.8871	.7316	.8589		.7316	.7545
20	.7167	.7762	.7316	.7545	.7762	.7316	.679
21	.679	.7762	.7316	.7167		.7468	.7167
22	.6036	.6722	.5853	.6036	.4527	.5601	.6413
23	.4904		.439	.415		.439	.3772
24	.3395	.3395	.3018	.3292	.3395	.3018	.3734
Max	.9511	1.0562	1.134	1.0974	1.1694	1.0974	1.0974
Min	.3018	.3018	.3018	.2926	.3018	.3018	.2926
Avg	.5602	.6081	.5351	.5699	.5789	.5977	.5831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 311 / 22 KV CHAMBALI AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9816	.2263	.2926	.3018		1.0059
2	.9488	.9114	.2263	.2926	.2263		.9069
3	.9488	.8916	.2263	.2987	.2263		.8535
4	.9488	.8916	.3018	.2926	.3018		.9831
5	1.012	.9602	.3018	.3658	.3772		1.1469
6	1.1523	1.0288	.5281	.5487	.5281		1.3413
7	1.6644	1.3565	.6036	.5853	.6722		1.9662
8	.2218	1.6575	.6036	.5792	.5975	.6722	2.2939
9	.439	1.4548		1.5604	1.4251	.5487	.5121
10	.4435	1.4815		1.7436		.5487	.5228
11	.4481	1.5813	1.6385	1.757		.5487	.4481
12	.4435	1.5813	1.704	1.6385		.4344	.4481
13	.3696	1.4723	1.6385	1.5546		.439	.4481
14	.3734		1.1336	1.5364		.4344	.2987
15	.3696		1.6385	1.5364		.362	.2987
16	.3696		1.4746	1.5402		.3658	.3734
17	.3734		.3658	.3658		.3658	.3734
18	.4481	.3772	.3658	.3734		.439	.4481
19	.5228	.5228	.5487	.5228		.6584	.5228
20	.5228	.4481	.5487	.5228	.6722	.5487	.5281
21	.5281	.3734	.439	.5281		.4527	.4481
22	.4481	.3772	.3658	.4481	.3018	.4527	.3772
23	1.0517		.3658	.3018		1.3763	1.1218
24	1.0974	.9602	.2263	.2926	.3018	.3018	1.1469
Max	1.6644	1.6575	1.704	1.757	1.4251	1.3763	2.2939
Min	.2218	.3734	.2263	.2926	.2263	.3018	.2987
Avg	.6692	1.0163	.7032	.8116	.4943	.5264	.7839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 201 / 11 KV BABAWADI

SINGLE PHASING

SINGLEPHASING Feeder KV- 11 /
OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.065	4.7634	4.3613	4.4092	4.5782	4.4445	4.5096
2	4.1301	4.6899	4.4475	4.4136	4.5794	4.5079	4.5942
3	4.1354	4.6182	4.4866	4.5486	4.6392	4.5803	4.7188
4	4.3351	4.6894	4.5039	4.8072	4.9367	4.7264	4.8954
5	4.6442	4.7308	4.6578	5.0766	5.2813	4.9733	5.2321
6	5.048	5.0621	5.2774	5.5746	5.6878	5.471	5.5895
7	5.4649	5.8421	6.0875	6.3824	6.5474	6.4647	6.1615
8	6.0172	6.6928	7.2106	7.1403	6.8881	6.6248	6.5867
9	1.675	1.3598	1.1675	1.2285	1.5335	1.7429	1.7227
10	1.2761	1.2264	.7606	1.2854	1.2958	1.2181	1.6145
11	1.0387	.9017	1.1843	1.2094	1.0646	.9989	.7331
12	.8993	.0488	1.0237	.3597	.9541	.8819	1.2688
13	.8437	.8789	.9011	.9438	.832	.9339	1.0829
14	.8367	.8128	1.0774	.7863	.6937	.8316	1.0158
15	.8927	.8875	.8324	.8357	.8326		.8473
16	1.0478	.9176	.9729	.8651	.944	.4908	.8939
17	.4908		1.1066	.8427	1.0171	.9511	1.0311
18	1.4868	1.2087	1.5314	1.259	1.4578	1.3962	1.2941
19	1.6186	1.5272	2.071	1.8145	1.8983	1.7882	1.6083
20	1.6476	1.8467	1.8763	1.9948	1.7334	1.901	1.6461
21	1.6096	1.6777	1.6362	1.6986	1.6015	1.5194	1.3828
22	1.2525	1.5924	1.2834	1.427	1.1824	1.2651	1.2776
23	4.7885	4.1716	4.3696	4.5161	4.3232	4.4693	.9587
24	4.4105	4.3479	4.3667	2.5545	4.4357	4.3988	1.2395
Max	6.0172	6.6928	7.2106	7.1403	6.8881	6.6248	6.5867
Min	.4908	.0488	.7606	.3597	.6937	.4908	.7331
Avg	2.6523	2.8041	2.7997	2.7489	2.8724	2.8948	2.5794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 202 / 11 KV MALSHIRAS

SINGLE PHASING

SINGLEPHASING Feeder KV- 11 /
OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.8061	.8488	1.0642	1.0306	.9511	1.0031
2	1.0551	.7956	.8638	1.1804	1.0805	.9526	1.0469
3	1.1249	.8514	.9724	1.2681	1.1303	1.0101	1.109
4	1.2688	.9387	1.2529	1.4097	1.2917	1.2011	1.1995
5	1.448	1.1893	1.4693	1.6762	1.515	1.504	1.3816
6	1.7404	1.7404	1.995	1.9589	1.7974	2.0001	1.6675
7	2.0534	1.9913	2.0302	2.174	2.1762	2.2698	1.8888
8	1.9083	1.9083	1.7318	1.8934	1.8222	2.0424	1.9897
9	4.2417	4.0501	2.0972	4.165	3.7514	3.7856	4.3149
10	4.6944	4.4189	2.4554	4.6735	4.3568	4.0155	4.8497
11	4.9871	4.389	4.6982	4.5794	4.3659	4.123	4.8672
12	4.6398	4.2013	3.9407	4.2932	4.0809	4.0722	4.6186
13	4.6956	4.1777	4.1407	4.4711	3.8714	4.1017	4.478
14	4.6518	4.1373	4.2044	4.3431	3.7956	4.0815	4.1585
15	4.7325	4.0485	4.2601	4.2566	3.9686		3.9262
16	4.7805	3.5864	4.3649	4.2677	4.224	1.7878	3.9963
17	1.8951	1.2113	1.9329	1.6167	1.6078	2.5177	1.8963
18	.8604	.9347	1.1608	1.0896	1.161	1.0582	.6813
19	1.6815	1.7444	1.8454	1.7831	1.8835	1.5593	1.7871
20	1.6412	1.631	1.8463	1.9985	1.8675	1.7557	1.7299
21	1.4681	1.4612	1.6871	1.7404	1.6903	1.5851	1.6286
22	1.2481	1.2677	1.3931	1.5392	1.4498	1.3403	1.3062
23	.9339	1.0003	1.0626	1.1384	1.1007	1.0595	2.4375
24	.9315	.8825	1.0372	.5304	1.0275	.9899	1.7975
Max	4.9871	4.4189	4.6982	4.6735	4.3659	4.123	4.8672
Min	.8604	.7956	.8488	.5304	1.0275	.9511	.6813
Avg	2.4865	2.2235	2.2205	2.4630	2.3353	2.1637	2.4900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 203 / 11 KV RISEPISE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7867	1.4795	1.4286	1.6588	1.6934	1.3084	1.9814
2	1.9769	1.3861	1.4106	1.9556	2.0148	1.6964	1.7411
3	2.1391	1.4633	1.4998	2.12	2.2625	1.9129	1.9145
4	2.4424	1.5371	2.1666	2.3707	2.4393	2.1165	2.0666
5	2.7031	2.2076	2.3239	2.5015	2.6185	2.3008	2.4338
6	2.6241	2.2845	2.3107	2.5054	2.6196	1.8657	2.3556
7	2.684	2.9585	2.3713	2.5453	2.6383	2.9439	2.5694
8	3.819	3.5285	2.9607	3.2398	3.7052	3.2792	4.132
9	4.5211	3.4249	2.2116	4.121	4.2821	2.3876	4.4704
10	5.2885	4.7283	3.0864	4.3966	4.523	4.4338	4.9762
11	5.7797	4.8073	4.6495	4.3636	4.6537	4.4326	4.9474
12	5.8246	4.6731	4.4423	.1219	4.7248	4.7124	5.1513
13	5.8565	4.6865	4.614	4.2642	4.7368	4.6708	5.2977
14	5.4153	4.7542	4.5648	4.6727	4.6777	4.7382	5.3346
15	5.5571	3.1482	4.1638	4.4132	4.2364	1.7375	4.8965
16	3.8706	.6806	4.5271	3.98	3.9414	2.3854	3.6375
17	2.3598	1.8375	2.4019	2.2863	2.0538	3.0182	2.1887
18	2.3716	.676	2.204	2.36	2.0632	1.9182	2.2394
19	2.5963	.9725	2.4945	2.5396	2.3419	1.3428	2.476
20	2.4676	2.2944	2.3741	2.5204	2.1643	2.3939	2.1955
21	2.0515	2.1156	2.2887	2.1662	1.9323	2.2062	2.0302
22	1.8688	2.269	2.1839	1.9948	1.767	1.9699	1.7356
23	1.5244	1.7724	1.7818	1.5874	1.5636	1.7725	1.8926
24	1.7374	1.4274	1.6339	.884	1.4908	1.4373	1.9963
Max	5.8565	4.8073	4.6495	4.6727	4.7368	4.7382	5.3346
Min	1.5244	.676	1.4106	.1219	1.4908	1.3084	1.7356
Avg	3.3028	2.5464	2.7539	2.7320	2.9644	2.6242	3.1108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 204 / 11 KV BHULESHWAR 3 PHASE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8023	1.989	1.9662	1.8947	1.917	1.7124	1.6324
2	1.989	2.079	1.9685	1.9595	1.9662	1.8067	1.6804
3	2.1548	2.1293	2.0885	2.0153	2.0719	1.9271	1.7284
4	2.2634	2.1548	2.1628	2.0405	2.2377	1.9919	1.8947
5	2.4417	2.2131	2.2119	2.2119	2.3868	2.1548	2.0405
6	2.7469	2.3061	2.5943	2.536	2.5652	2.2298	2.2119
7	3.0013	3.0521	3.0178	2.8487	3.0011	2.7831	2.3594
8	2.8841	3.1493	3.2358	3.0011	3.3196	3.0178	2.6235
9	.9335	.8299		.9242	.9431	.9054	1.0456
10	.7842	.7356		.811	.9808	.9808	.8962
11	.6535	.6979	.5658	.7733	.7842	1.0185	.8402
12	.7095	.679	.4338	.7545	.7545	.679	.8775
13	.8962	.679	.679	.679	.7545	.7733	.7842
14	.6722	.7167	.5658		.7922	.6722	.7468
15	.7468	.6348		.679	.7356		.7545
16	.7842	.679		.7545	.7922		.8488
17	.7947	.7468	.6413	.7922	.811	.7095	.8962
18	.8326	.8589	.8145	1.0185	.8488	.7922	1.0164
19	1.2437	1.1203	1.3443	1.1883	1.1088	1.1883	1.2136
20	1.2803	1.1949	1.307	1.3443	1.1273	1.3443	1.2323
21	1.2012	.8962	1.1763	1.1949	1.0082	1.307	1.1576
22	.924	.7682	1.086	1.1763	.9335	1.1949	1.0269
23	1.9334	2.0317	1.917	1.917	1.749	1.5893	.8962
24	1.7695	1.9826	1.8842		1.8842	1.7166	1.6004
Max	3.0013	3.1493	3.2358	3.0011	3.3196	3.0178	2.6235
Min	.6535	.6348	.4338	.679	.7356	.6722	.7468
Avg	1.4768	1.4302	1.5830	1.4779	1.4781	1.4770	1.3335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 205 / 11 kv RAJURI SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.6838	.5228	.7356	.7922	.6036	.5847
2	.8865	.6838	.4908	.7733	.8299	.5601	.6224
3	.9149	.7095	.6036	.7922	.8488	.6224	.679
4	.9335	.7842	.7842	.8488	.9431	.695	.7545
5	.9979	.9425	.9694	1.0185	1.0185	.8962	.8488
6	1.1523	1.1088	1.226	1.1763	1.1883	1.0425	1.0185
7	1.3169	1.2437	1.3957	1.358	1.358	1.2437	1.1883
8	1.2071	1.1088	1.0608	1.2071	1.1883	1.2178	1.358
9	1.8023	1.406		1.3077	1.4243	1.6409	1.8778
10	1.9062	1.4582		1.5089	1.5769	1.4918	2.0719
11	1.989	2.3205	1.5074	1.6221	1.5384	1.643	1.989
12	1.8842	1.757	1.4746		1.7772	1.4746	1.9062
13	1.8842	1.6095	1.3272	1.1797	1.7204	1.6095	1.9448
14	1.9062	1.6617	1.3272	1.3599	1.6244	1.6598	1.9393
15	1.6766	1.5729	1.2955	1.3592	1.5384		1.6766
16	1.6575	1.4563	1.2955	1.358	1.4752		1.6575
17	.5853	.8962	.5975	.4854	.4108	.5788	.3696
18	.8501	.5658	.7545	.7545	.7095	1.0082	.7468
19	1.2567	1.094	1.2071	1.0185	1.094	1.0082	1.1949
20	1.262	1.1506	1.1763	1.3443	1.2071	1.307	1.1203
21	1.0059	.8299	1.1643	1.1763	1.0562	1.1763	.9808
22	.9145	.7167	.9496	.7956	.9431	1.0562	.924
23	.8596	.6224	.7545	.8488	.591	.679	.823
24	.8488	.547	.7167		.7545	.6036	.5658
Max	1.989	2.3205	1.5074	1.6221	1.7772	1.6598	2.0719
Min	.5853	.547	.4908	.4854	.4108	.5601	.3696
Avg	1.2728	1.1221	1.0273	1.0922	1.1504	1.0826	1.2018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 201 / 11 KV Vadhane AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0334	3.6992	2.3007	3.9213	3.9514	1.0387	1.1206
2	1.0296	3.6412	2.2314	3.8112	3.8851	1.0448	1.0761
3	1.0608	3.5742	2.1514	3.7128	3.8516	1.0776	1.0749
4	1.1988	3.6656	2.1856	3.7197	3.8638	1.1378	1.0921
5	1.4426	3.8935	2.2352	3.783	4.2547	1.3957	1.2811
6	1.7992	4.4917	2.5461	4.1579	4.7912	1.8358	1.7657
7	2.0347	3.3615	3.1931	5.4161	5.5282	1.9707	2.1141
8	1.9021	5.2355	3.3486	6.1305	6.0372	1.9692	2.0546
9	3.7944	1.3504	1.0319	1.6614	1.9029	4.8042	6.6065
10	4.2745	.9122	.5335	1.2361	1.3352	6.2285	7.4158
11	3.9743	.6264	.4923	.6378	.7804	6.459	7.1391
12	3.6123	.5228		.4466	.6067	6.2636	6.0166
13	3.6854			.4611	.8184	6.4922	5.8315
14	3.8988			.6234	.9076	6.5836	5.7422
15	4.1327			.6752	.8878	6.4579	5.5449
16	3.7472			.7712	.9175	6.0936	5.4984
17	1.0844			.967	.9998	1.1808	1.1195
18	1.2037	.3079	.1608	1.3817	1.3939	1.049	1.233
19	1.6438	1.2544	1.4601	1.6919	1.6477	1.5744	1.6416
20	1.5448	1.2193	1.4712	1.6286	1.4975	1.5512	1.6675
21	1.4609	1.2863	1.3633	1.5844	1.5082	1.4788	1.5234
22	1.1972	1.2132	1.4907	1.3352	1.326	1.4747	1.3946
23	3.5193	2.2443	3.8417	3.805	1.1507	1.2071	1.2216
24	2.761	3.8896	2.4798	3.7852	2.1742	1.1454	1.121
Max	4.2745	5.2355	3.8417	6.1305	6.0372	6.5836	7.4158
Min	1.0296	.3079	.1608	.4466	.6067	1.0387	1.0749
Avg	2.3765	2.4415	1.9176	2.3893	2.3341	2.9798	3.0124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 202 / 11 KV Supa Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6496	.6169	.3406	.6966	.6153	.6165	.6531
2	.6386	.6073	.3418	.6771	.6142	.6146	.6085
3	.6439	.6344	.3601	.6413	.6165	.6287	.6268
4	.7281	.3757	.3841	.6786	.674	.7213	.7347
5	1.0258	1.0517	.5167	.8425	.9644	1.049	.9404
6	1.4849	1.5585	.8124	1.1797	1.5779	1.5771	1.3984
7	1.9307	1.9013	1.0841	1.7646	1.9989	2.0263	1.9414
8	1.9113	1.9901	1.1168	1.9658	1.9863	2.0073	1.9563
9	1.6415	1.7066	.9831	1.6682	1.7467	1.3786	1.7947
10	1.2003	1.0852	.6542	1.0955	1.225	1.182	1.3474
11	.791	.8284	.4565	.8116	.868	.8821	.8931
12	.6573	.7335	.6733	.6623	.7693	.7445	.7374
13	.6508	.3288	.5327	.6611	.6074	.6359	.7277
14	.618	.2427	.4911	.6405	.6029	.5674	.6234
15	.5651	.6554	.7411	.6073	.5613	.543	.5963
16	.5937	.655	.7689	.6287	.5918	.6336	.6226
17	.6234	.5951	.9183	.6435	.703	.6698	.6607
18	.8767	.6249	1.0365	.8661	.9591	.8814	.8646
19	1.6366	1.1454	1.4537	1.6042	1.6834	1.5116	1.5375
20	1.5836	1.4011	1.4926	1.6	1.6217	1.475	1.4148
21	1.3176	1.1957	1.2959	1.4472	1.4605	1.3264	1.3005
22	.9781	1.0048	1.0166	1.15	1.1298	1.0745	.9991
23	.7651	.479	.8128	.8024	.8306	.8341	.7727
24	.6512	.6664	.3628	.7705	.6294	.6493	.7122
Max	1.9307	1.9901	1.4926	1.9658	1.9989	2.0263	1.9563
Min	.5651	.2427	.3406	.6073	.5613	.543	.5963
Avg	1.0068	.9202	.7769	1.0044	1.0432	1.0096	1.0193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 203 / 11 KV Baburdi Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.1715	.1524	.1457	.1715	.3353	.8421
2	.4877	.1715	.1524	.1457	.1715	.3353	.9069
3	.4877	.1715	.1524	.1619	.1715	.3353	.9393
4	.5335	.1886	.1829	.1457	.2058	.381	1.004
5	.6097	.2229	.1829	.1296	.2572	.4268	1.0364
6	.7316	.3086	.2134	.1457	.3086	.4877	1.2308
7	1.2803	.3429	.2134	.1619	.3429	.8535	1.3279
8		.2743	.2622	.2915	.2915	1.1584	1.3108
9	.2572	1.5242	1.2803		.2058	.1296	.2401
10	.2058	1.7071	1.4327		.7316	.1219	.2058
11	.1543	1.6766	1.5424		1.4022	.1219	.1543
12	.1372	1.7071	1.6095	1.4022	1.6461		.1372
13	.1372		1.4899	1.4022	1.6461		.1372
14	.12		1.6095	1.2955	1.6461		.1372
15	.12	2.4082	1.5089	1.1584	1.6461		.1372
16	.12	1.829	1.6095	1.1584	1.6461		.1372
17	.12	.2134	.1781	.2058	.12	.1524	.1543
18	.1715	.2286	.1943	.2058	.1715	.1829	.1886
19	.3086	.2439	.1619	.2058	.3258	.2439	.2058
20	.2401	.2439	.1457	.2229	.3086	.1457	.2401
21	.2229	.1829	.1619	.2401	.2572	.1619	.2058
22	.1886	.1219	.1943	.1715	.2401	.1943	.1886
23	.1715		.2915	.1715	.3353	.5182	.3658
24	.5487	.1715		.16	.1715	.3353	.6802
Max	1.2803	2.4082	1.6095	1.4022	1.6461	1.1584	1.3279
Min	.12	.1219	.1457	.1296	.12	.1219	.1372
Avg	.3409	.6719	.6488	.4442	.6009	.3485	.5047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 204 / 11 KV Chandugadewadi Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1524		.1524	.12	.1372	.2267
2	.2058	.1524	.1067	.1524	.12	.1372	.2267
3	.2058	.1524	.0914	.1372	.12	.1372	.3887
4	.2229	.1524	.0914	.1372	.1543	.1715	.3239
5	.2134	.1543	.0914	.1524	.1886	.2058	.2915
6	.2439	.2058	.1524	.1524	.2572	.2058	.3563
7	.3429	.2572	.1829	.1829	.2743	.3429	.3887
8	.4268	.2058	.1829	.1829	.2229	.4115	.4268
9	.1715	.3963	.3353	.4268	.4115	.1219	.2058
10	.12	.4268	.3658	.4877	.4115	.1219	.1715
11	.1029	.3963	.3658	.4572	.3658	.0914	.1029
12	.0857	.3658	.3353	.4115	.381	.0914	.0686
13	.0857		.3048	.4115	.4115	.0762	.0686
14	.0857		.4725	.381	.4268	.0914	.0857
15	.0857	.3658	.4572	.4115	.4268	.061	.0857
16	.0857	.3658	.4268	.3658	.4268	.0819	.0686
17	.1029	.1829	.1067	.1029	.0857	.0914	.0686
18	.1543	.2134	.1341	.1029	.1886	.1829	.1372
19	.2058	.1829	.1829	.1715	.2058	.2439	.2058
20	.2058		.1829	.2058	.2058	.2267	.2058
21	.1886		.1524	.2058	.1886	.1943	
22	.1372		.1829	.1886	.1543	.1943	.1372
23	.1372		.1524	.12	.1372	.3086	.12
24	.4268	.1372	.1067	.1524	.12	.1372	.3772
Max	.4268	.4268	.4725	.4877	.4268	.4115	.4268
Min	.0857	.1372	.0914	.1029	.0857	.061	.0686
Avg	.1854	.2481	.2245	.2439	.2502	.1694	.2060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 205 / 11 KV Supa Ag Feeder
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.4115	.4572	.6154	.7316	.2058	.1943
2	.2229	.4458	.5792	.6802	.7468	.2058	.1619
3	.2229	.4458	.6401	.7125	.7621	.2058	.1619
4	.2572	.4572	.7125	.7773	.823	.2401	.1943
5	.3086	.6859	.6706	.9717	.9145	.2743	.2267
6	.4115	1.0974	1.0669	1.3279	1.1888	.4115	.3563
7	.5487	1.3717	1.4022	1.5546	1.6461	.4115	.3887
8	.5487	1.5851	1.7071	1.9757	1.6613	.4115	.1829
9	1.8442	.1829	.1829	.3086	.2743	1.9814	1.6766
10	2.3015	.2134	.2439	.2572	.2572	2.0119	2.0424
11	2.3167	.1219	.1524	.1372	.0857	1.9814	1.9814
12	2.3472	.1372	.1829	.1372	.1372	2.0119	1.9204
13	2.3167		.1829	.1372	.1372	2.0729	1.89
14			.1829	.1372	.1372	2.0119	1.8595
15	2.1795	.1372	.1829	.1372	.1372	1.9814	1.829
16	2.1338		.2286	.1372	.1372	2.0729	1.7985
17	.1715		.2134	.1715	.2229	.3048	.1543
18	.3086	.3048	.2439	.2401	.2915	.3353	.2743
19	.4115	.3658	.1067	.3086	.4115	.3658	.3429
20	.2743	.1829	.1067	.4115	.4115	.2591	.3258
21	.2743	.2134	.1219	.3086	.3429	.2267	.2401
22	.2572	.2439	.1296	.2743	.2743	.2591	.2229
23	.3658		.3887	.7316	.2401	.1829	.2058
24	.2229	.3658	.4268	.4534	.7316	.2229	.1943
Max	2.3472	1.5851	1.7071	1.9757	1.6613	2.0729	2.0424
Min	.1715	.1219	.1067	.1372	.0857	.1829	.1543
Avg	.8900	.4721	.4380	.5377	.5293	.8604	.7844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 206 / 11 KV Baburdi Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0914	.0972	.0953	.0953	.081
2	.0953	.0953	.0914	.081	.0953	.0953	.081
3	.0953	.0953	.0914	.081	.0953	.0953	.081
4	.1143	.1143	.0762	.081	.1029	.12	.1134
5	.1543	.1715	.0762	.081	.1543	.1543	.1134
6	.2401	.2743	.1134	.0648	.2401	.2401	.0972
7	.2401	.2743	.1372	.0972	.3086	.3258	.0972
8	.2743	.2401	.2439	.0972	.2058	.2743	.061
9	.1886	.1829	.1524	.1029	.2058	.1067	.1372
10	.12	.1829	.0914	.1029	.0857	.1296	.1372
11	.0857	.0914	.061	.0514		.1067	.1029
12	.0686	.0914	.0457	.0514	.0857		.0857
13	.0686		.0457	.0514	.0686		.0857
14	.0514		.0305	.0514	.0514		.0857
15	.0514	.061	.0305	.0514	.0514		.0857
16	.0514	.0457	.0305	.0514	.0514		.0857
17	.0686	.061	.0305	.0686	.0857	.1524	.1029
18	.1372	.1524	.0305	.1029	.1029	.1829	.1372
19	.2401	.1829	.0457	.2401	.2401	.2134	.2401
20	.2058	.1524	.061	.2058	.2229	.1943	.2058
21	.2058	.1372	.0762	.2058	.1886	.1457	.1715
22	.1029	.1219	.1524	.1029	.1029	.1296	.1372
23	.0857		.061	.1029	.0953	.1067	.1029
24	.0953	.0953	.1067	.0972	.0953	.0953	.0972
Max	.2743	.2743	.2439	.2401	.3086	.3258	.2401
Min	.0514	.0457	.0305	.0514	.0514	.0953	.061
Avg	.1307	.1390	.0822	.0967	.1318	.1560	.1136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 207 / 11 KV Dandwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.274	.4107	.3909	.3636	.3948	2.3488	2.5168
2	2.2733	.4138	.394	.3826	.4016	2.3145	2.5671
3	2.2741	.4123	.3917	.3966	.3994	2.2977	2.6177
4	2.3228	.4287	.3864	.4366	.4348	2.3007	2.676
5	2.3716	.4881	.4123	.4603	.4873	2.3739	2.8487
6	2.5674	.6085	.4519	.5651	.6089	2.6132	3.1512
7	3.1458	.7773	.5342	.6897	.7587	3.0491	3.4823
8	3.5338	.751	.7697	.7268	.7506	3.4545	3.9034
9	2.2272	4.1244	4.2425	3.6412	3.8424	2.1285	2.5244
10	.5045	4.6937	4.4704	4.7706	4.5709	.5213	.5712
11	.4012	4.7508	4.6494	4.7585	4.4132	.394	.4359
12	.3803	4.6487	4.7455	4.6449	4.4018	.3864	.4005
13	.3502	2.6978	4.7325	4.5755	4.4315	.4245	.3913
14	.3448		4.3614	4.4361	4.5146	.3825	.3357
15	.2736	4.7256	4.1907	4.3386	4.5496	.3766	.37
16	.298	4.6959	4.2433	4.2883	4.5908	.4039	.3933
17	.3468	2.6535	2.5027	2.3556	2.4166	.3833	.2911
18	.5067	.4778	.3673	.362	.1695	.3978	.3791
19	.6611	.6653	.458	.6203	.684	.4984	.5776
20	.6196	.6919	.5175	.7	.6706	.5357	.6139
21	.4995	.583	.538	.5872	.5701	.482	.5472
22	.4603	.5083	.5106	.5335	.4878	.5117	.4957
23	.4226	.2667	.458	.4927	2.2466	2.0614	1.976
24	1.2597	.429	.4321	.3529	1.5547	2.2946	2.2344
Max	3.5338	4.7508	4.7455	4.7706	4.5908	3.4545	3.9034
Min	.2736	.2667	.3673	.3529	.1695	.3766	.2911
Avg	1.2633	1.7784	1.8813	1.8950	2.0146	1.3723	1.5125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 201 / 11 KV Murti single
 phasing Feeder KV- 11 /
 OUTGOING

SINGLE PHASING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4488	.6981	1.3226	1.4578	.2995	.455	.4268
2	.4534	.7186	1.2891	1.4594	.3102	.4595	.4291
3	.4793	1.3066	1.2361	1.4586	.3231	.4782	.4496
4	.5746	1.4027	1.2662	1.5059	.3872	.5777	.5548
5	.7895	1.8147	1.6568	1.9378	.4786	.7742	.7262
6	1.044	2.1998	2.2542	2.5069	.6592	1.0555	.9458
7	1.0913	2.8149	3.0331	3.2199	1.7253	1.1058	.9884
8	1.0356	3.1138	3.1115	3.1382	2.7244	.9876	1.0578
9	2.8052	.5476	.2987	.5522	1.9654	2.4379	2.8235
10	3.2629	.2522	.1898	.292	.346	3.1291	3.0376
11	3.3591	.2812	.294	.2241	.3018	3.2808	2.9972
12	3.564	.224	.2101	.2096	.2305	3.3257	2.6659
13	3.1838	.2058	.1949	.2302	.2347	3.3135	2.616
14	3.0823	.2038	.2002	.234	.2374	3.3463	2.4638
15	2.8529	.2425	.226	.2264	.2835	3.2068	2.4455
16	2.5979	.2488	.245	.2804	.3117	2.979	2.4644
17	.2938	.2845	.3064	.3109	.3929	.3513	.421
18	.5443	.6112	.5405	.5967	.6935	.6645	.6055
19	.8046	.9031	.8555	.8558	.9244	.8954	.8593
20	.7895	.892	.8441	.8748	.9396	.8802	.804
21	.6855	.7643	.7643	.7415	.8939	.7629	.7304
22	.6512	.6683	.7043	.5944	.5235	.6195	.6188
23	1.1667	1.3062	1.4159	.3071	.5342	.4999	.527
24	.8832	1.3379	1.2834	.8276	.4069	.4771	.4808
Max	3.564	3.1138	3.1115	3.2199	2.7244	3.3463	3.0376
Min	.2938	.2038	.1898	.2096	.2305	.3513	.421
Avg	1.5185	.9601	.9893	1.0018	.6720	1.5026	1.3391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 202 / 11 KV Jogwadi single SINGLE PHASING
Phasing Feeder KV- 11 /
OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1562		.132	.1132	.1052	.12	.1562
2	.1562		.132	.1132	.1052	.1372	.16
3	.1875	.132	.1307	.1132	.1075	.1429	.16
4	.2187	.132	.1509	.1132	.1402	.1524	.1875
5	.2812	.2641	.2987	.2263	.2103	.2027	.2134
6	.3658	.3395	.3734	.3206	.3506	.2743	.2812
7	.3658	.415	.439	.415	.3429	.3772	.3749
8	.4999	.2829	.3734	.3584	.3086	.4816	.4572
9	.2263	.431		.3481	.25	.2896	.2652
10	.1886	.4586		.3978	.3125	.1829	.2263
11	.1509	.4938	.4807	.4801	.3858	.1791	.1886
12	.1132	.6325	.5138	.4481	.4161	.1433	.1886
13	.132	.5117	.4475	.4481	.4161	.1254	.132
14	.1132	.4458	.4144	.3749	.3963	.1075	.1132
15	.1132	.4058	.4144	.3437	.362	.1075	.1132
16	.1132	.4054	.3647	.3749	.3475	.1433	.0943
17	.1509	.1646	.132	.1402	.1646	.1433	.1698
18	.2452	.2353	.2263	.2103	.2614	.2454	.2452
19	.3206	.2987	.3018	.2804	.3361	.2743	.2829
20	.3206	.2987	.3395	.2561	.2801	.2401	.2641
21	.3018	.2614	.2829	.2103	.2614	.2058	.2263
22	.1886	.2054	.1698	.1402	.1867	.1402	.1886
23	.1698	.1494	.132	.1254	.1334	.1562	.1698
24	.1524	.132	.1307	.1132	.1052	.1524	.1562
Max	.4999	.6325	.5138	.4801	.4161	.4816	.4572
Min	.1132	.132	.1307	.1132	.1052	.1075	.0943
Avg	.2180	.3225	.2900	.2694	.2619	.1969	.2089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 203 / 11 KV Morgaon single
Phasing Feeder KV- 11 /
OUTGOING

SINGLE PHASING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4405	.1692	.3283	.2844	.288	.3696	.4337
2	.4306	.1699	.3382	.2844	.2949	.3204	.4344
3	.4192	.3443	.3262	.2882	.2941	.3254	.4351
4	.4732	.3542	.3788	.3035	.3414	.3757	.4892
5	.6523	.5579	.5967	.4165	.4946	.5273	.567
6	.9541	.7099	.7285	.6208	.6538	.7764	.7659
7	1.3337	.797	.8052	.7463	.5586	1.0886	1.1439
8	1.6095	.7228	.6341	.7333	.6912	1.2773	1.5455
9	.5689	1.3066	.6851	1.0446	1.0795	.4824	.5171
10	.4073	1.5638	.8162	1.2871	1.2277	.3894	.3664
11	.3364	1.5996	1.4693	1.3008	1.0997	.3399	.3338
12	.2577	1.5265	1.4207	1.2795	1.0304	.3094	.2837
13	.2336	1.5707	1.3739	1.2406	.9297	.2889	.4233
14	.2162	1.4693	1.2378	1.0989	.9816	.2965	.2783
15	.4076	1.3901	1.1806	1.06	.9541	.2896	.2791
16	.3329	1.2552	1.1153	.9694	.8527	.2439	.3502
17	.289	.2507	.3084	.3506	.5125	.3147	.3382
18	.3431	.4862	.3091	.442	.4535	.4732	.4514
19	.6247	.7255	.6901	.6714	.6226	.6752	.7234
20	.6216	.8383	.6165	.6081	.5792	.5983	.6907
21	.5354	.5297	.5461	.4885	.4954	.5083	.59
22	.4127	.4308	.4127	.3773	.3978	.4077	.4679
23	.3662	.3239	.3359	.2965	.3426	.4481	.4632
24	.3567	.3276	.298	.2783	.3383	.4222	.4634
Max	1.6095	1.5996	1.4693	1.3008	1.2277	1.2773	1.5455
Min	.2162	.1692	.298	.2783	.288	.2439	.2783
Avg	.5260	.8092	.7063	.6863	.6464	.4812	.5348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 204 / 11 KV Tardoli single
phasing Feeder KV- 11 /
OUTGOING SINGLE PHASING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3125		.2263	.2263	.2103	.3048	.3125
2	.3125		.2263	.2263	.2103	.2896	.3201
3	.3125	.2263	.2172	.2263	.2103	.3086	.3125
4	.3437	.2263	.2561	.2263	.2454	.3201	.3437
5	.4268	.3395	.3734	.3772	.3856	.5468	.5624
6	.6401	.4715	.5601	.5281	.5609	.6405	.6706
7	.7773	.679	.7133	.7167	.5959	.7499	.884
8	.9907	.5658	.5792	.5658	.5258	.8535	.9602
9	.3772	.6796		.6796	.5213	.4344	.431
10	.3206	.8749		.8122	.5952	.3077	.3395
11	.2829	.823	.8288	.7811	.7316	.2328	.2829
12	.1886	.9374	.7956		.695	.197	.2452
13	.1698	.9568		.7042	.6535	.3582	.2263
14	.1698	.7773	.7459	.7042	.6622	.2149	.2452
15	.1886	.724	.7127	.6722	.6401	.2103	.2452
16	.1886	.823	.7127	.7042	.5944	.208	.2263
17	.2263	.1848	.1698	.16	.2801	.3681	.2641
18	.3206	.2561	.3018	.2812	.3547	.4207	.3961
19	.5281	.547	.5658	.5258	.5415	.6135	.6036
20	.5281	.5228	.5281	.4374	.5601	.5487	.5093
21	.4715	.4481	.4527	.4382	.5228	.5258	.415
22	.3395	.3174	.3206	.2865	.3361	.3772	.3206
23	.2829	.2427	.2829	.2328	.2782	.3437	.3315
24	.3125	.2263	.2241	.2263	.2103	.3185	.3437
Max	.9907	.9568	.8288	.8122	.7316	.8535	.9602
Min	.1698	.1848	.1698	.16	.2103	.197	.2263
Avg	.3755	.5386	.4664	.4669	.4634	.4039	.4080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 205 / 11 KV Modhave single
phasing Feeder KV- 11 /
OUTGOING SINGLE PHASING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804		.3812	.2652	.2454	.2241	.2507
2	.2804		.2155	.2652	.2187	***	.2507
3	.2804	.2155	.2134	.2652	.2187	***	.2241
4	.3155	.2155	.2378	.2652	.25	.2614	.25
5	.3506	.3647	.3572	.4973	.2743	.2987	.3155
6	.4801	.4475	.5761	.663	.3749	.5068	.5258
7	.6516	.5801	.664	.8288	.578	.6219	.6485
8	.5316	.663	.7253	.8122	.6401	.5973	.5434
9	.4641	.2641		.3961	.4119	.4784	.5967
10	.5801	.2743		.2829	.2686	.6093	.5967
11	.5801	.2534	.2075	.2454	.2534	.7186	.5138
12	.5636	.2172	.1886	***	.2353	.7186	.5138
13	.4973	***	***	.2103	***	.6249	.4144
14	.4641	***	.2829	***	.2195	.6081	.3315
15	.431	***	.2829	.2279	.2353	.5601	.8288
16	.3315	.2614	***	.2507	.2534	.4641	.3315
17	.2829	.2587	.2829	.2454	.2427	.2454	.2641
18	.3961	.3174	.3772	.3856	.4572	.4298	.3584
19	.6602	.6908	.6224	.591	.6348	.591	.5658
20	.6602	.7095	.5658	.6089	.6979	.5487	.5093
21	.5658	.5788	.5093	.4908	.5041	.463	.415
22	.415	.4108		.333	.3734	.3681	.3206
23	.2321	.2408	.2321	.2507	.2614	.2804	.2452
24	.2804	.2155	.2134	.2652	.2187	.2614	.2507
Max	.6602	152.6355	152.416	152.6309	152.6355	152.6423	.8288
Min	.2321	.2155	.1886	.2103	.2187	.2241	.2241
Avg	.4406	21.1378	11.2419	13.0793	6.6960	13.1568	.4194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 206 / 11KV Ambi Single Phasing SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3437		.2452	.2263	.2103	.3048	.3201
2	.3353		.2452	.2263	.2149	.2667	.2881
3	.3437	.2452	.2172	.2263	.2103	.2743	.2881
4	.3749	.2452	.2587	.2263	.2103	.3429	.3201
5	.4374	.3395	.2987	.3395	.2804	.3041	.3749
6	.4877	.4527	.4706	.4338	.3856	.3506	.4374
7	.5944	.547	.5853	.5093	.4733	.381	.5335
8	.5944	.4715	.4835	.5281	.3429	.5068	.6097
9	.415	.6464		.5138	.5624	.3658	.1989
10	.3206	.7373		.5801	.5468	.3258	.3018
11	.2829	.7011		.5761	.5335	.2507	.2263
12	.2075	.639	.4973	.5761	.6344	.2149	***
13	.2075	.5681		.5441	.4489	.1791	***
14	***	.6554	.5967	.5121	.4344	.1791	***
15	***	.5716	.5636	.4961	.4999	***	***
16	***	.5357	.5636	.5441	.5243	***	***
17	***	.1867	.2075	.1753	.181	***	***
18	.2829	.2896	.3206	.2804	.3547	.3155	.2075
19	.5281	.5175	.5658	.5373	.5228	.5014	.4338
20	.5281	.5415	.5093	.4298	.5601	.4207	.3772
21	.4527	.4108	.4527	.3856	.4294	.394	.3395
22	.3395	.2987	.3018	.3045	.3395	.298	.2829
23	.2829	.2402	.2641	.2328	.2435	.3125	.3315
24	.3437	.2452	.2195	.2263	.2149	.3048	.3125
Max	152.6046	.7373	.5967	.5801	.6344	152.6439	152.6612
Min	.2075	.1867	.2075	.1753	.181	.1791	.1989
Avg	25.7519	.4585	.3933	.4013	.3899	16.1825	38.4096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 201 / 11 KV Waki single Phasing SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.5228	.5415	.4805	***	***	***
2	.5228	.5228	.5359	.4805	***	***	***
3	.5228	.5228	.5415	.4805	***	***	***
4	.5228	.5228	.5975	.499	***	***	.1829
5	.5601	.5601	.6348	.5359	.2614	***	.2591
6	.6722	.6535	.6838	.6283	.4294	.3077	.3658
7	.9055	.9055	.9425	.924	.5228	.421	.4268
8	.9979	.9709		1.0164	.4668	.421	.3658
9	.3326	.2957		.3734	.8907	.8097	.7926
10	.2267	.2429		.2105	1.0526	.8421	.9555
11	.2105	.2105	.1619	.1619	.9878	.9231	.9393
12	.1619	.1619	***	***	.9717	.9231	.8421
13	***	***	***	***	.9393	.8745	.8421
14	***	***	***	***	.9069	.8583	.8421
15	***	***	***	***	.8907	.8745	.8097
16	***	***	***	***	.8583	.8421	.7935
17	.2105	***	***	***	.2267	.1619	.1619
18	.2987	.3174	.2591	.3174	.2987	.2591	.2439
19	.4481	.4854	.4066	.4294	.4481	.4049	.3201
20	.4108	.4481	.4066	.4294	.4481	.3353	.2896
21	.3696	.3696	.3696	.4108	.3856	.2743	.2591
22	.2772	.2427	.2587	.2957	.2804	.2134	.1981
23	.5175	.5228	.4805	.2241	.181	.1524	.3201
24	.5175	.5228	.5359	***	***	***	.1524
Max	152.5941	152.6008	152.6103	152.8965	152.6401	152.7025	152.5989
Min	.1619	.1619	.1619	.1619	.181	.1524	.1524
Avg	25.8131	32.1614	43.9440	44.8429	32.2770	38.5709	19.5041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 202 / 11 KV Hol single Phasing SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.3315	.2652	.2652	.5914	.3887	.4268
2	.2652	.3315	.2652	.2652	.5914	.3887	.4572
3	.2652	.3315	.2652	.2652	.5304	.4805	.4572
4	.2984	.3315	.2984	.2984	.5304	.4268	.442
5	.3315	.3315	.3978	.3315	.5967	.4641	.4877
6	.4641	.4641	.4641	.4641	.663	.4641	.5487
7	.5304	.5967	.5967	.5967	.7293	.4641	.6706
8	.5304	.8619		.5304		.3315	.7926
9	.5175	.8619		.7956	.2321	.4641	.4268
10	1.2597	1.0608		.9945	.3201	.3315	.3315
11	1.2597	1.1271	1.1271		.2652	.2652	.2652
12	1.326	1.0608	1.1271			.1326	.1989
13	1.2597	1.0608	1.0608	.9945		.1326	.1989
14	1.2597	.8619	1.0608	1.0608		.1326	.1326
15	1.1271	.8619	.9945	1.0608		.1326	.1326
16	1.1271	.9282	.9282	.9945	.3315	.1326	.1326
17	.1326	.1989	.1989	.1326	.3315	.1989	.1989
18	.2652	.3315	.1989	.1989	.3978	.2652	.1829
19	.4973	.5304	.4641	.5304	.5304	.4641	.3658
20	.4641	.4973	.4641	.4973	.5304	.4268	.3658
21	.431	.3978	.431	.4641	.5601	.3048	.3658
22	.3978	.3315	.3978	.3315	.5258	.3048	.3048
23	.3315	.2652	.2652	.5304	.5068	.4268	.2439
24	.2652	.3315	.2652	.2652	.4877	.3658	.4268
Max	1.326	1.1271	1.1271	1.0608	.7293	.4805	.7926
Min	.1326	.1989	.1989	.1326	.2321	.1326	.1326
Avg	.6197	.5953	.5493	.5394	.4869	.3287	.3565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 203 / 11 KV SASTEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.7392	.8871	.8589	.0554	.0514	.0457
2	.6722	.7392	.8686	.8589	.0554	.056	***
3	.6722	.7392	.8775	.8589	.0554	.056	***
4	.6722	.7577	.8686	.8962	.0554	.0747	***
5	.7282	.7947	.8775	.9149	***	***	***
6	.8589	.8686	.8775	.9335	***	***	***
7	1.0903	1.0829	1.2323	1.1763	***	***	***
8	1.3491	1.2382		1.4784	***	***	***
9	.0924	.0747		.0747	1.2963	1.4198	1.4327
10	***	***		.0309	1.5123	1.6204	1.6821
11	***	***	.0463	.0497	1.6204	1.5586	1.5895
12	***	***	***	.0497	1.6821	1.5741	1.4198
13	***	***	***	***	1.713	1.3735	1.3117
14	***	***	***	***	1.6667	.1389	1.2809
15	***	.037	***	.0617	1.5741	1.25	1.142
16	***	***	***	***	1.4969	1.2191	1.1111
17	***	***	***	***	.0617	.0617	.0617
18	.0739	***	***	***	***	.0617	***
19		***	***	***	***	***	***
20	***	***	***	***	***	***	.061
21	***	***	***	***	***	***	***
22	***	***	***	***	***	***	***
23	.7392	.8589	.8589	.0554	.0549	.0457	.5182
24	.6653	.7392	.8871	.8589	.0554	.056	.0457
Max	76.316	76.3014	76.3014	76.3014	76.3014	76.2697	76.2994
Min	.0739	.037	.0463	.0309	.0549	.0457	.0457
Avg	36.8431	38.5004	40.353	28.9884	29.1510	25.8655	35.4448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 204 / 11KV Chopadaj

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	.7392	.7392	.6642	.1848	.181	.1524
2	.7762	.7392	.7392	.6642	.1848	.1715	.1524
3	.7762	.7392	.7392	.6642	.1848	.1753	.1829
4	.7762	.7392	.8131	.6958	.1848	.1372	.1829
5	.8131	.7392	.8871	.7907	.2218	.1265	.3048
6	.924	.7762	1.0349	.8539	.3696	.1265	.4877
7	1.1088	1.0719	1.1827	.9488	.5544	.3163	.4268
8	1.2567	1.1458		1.0753	.6283	.4744	.4572
9	.5175	.5175		.4111	.9172	.9172	.9755
10	.2846	.3163		.2846	1.1984	1.0437	1.0753
11	.253	.1898	.1581	.1581	1.1385	1.012	1.2018
12	.2214	.1898	.1581	.1265	1.1069	1.2018	1.1702
13	.1898	.1581	.1581	.0949	1.0753	1.2651	1.1385
14	.1581	.1478	.1581	.1265	1.1385	1.1385	1.0437
15	.1898	.1478	.1265	.1265	1.0437	1.1385	1.1069
16	.1898	.1848	.1581	.1898	.9488	1.1069	1.1069
17	.1898	.1478	.1898	.2214	.2214	.2214	.1581
18	.2587	.3734	.253	.253	.3326	.3479	.2591
19	.5175	.5175	.4111	.3795	.4805	.4111	.3658
20	.4066	.4805	.3479	.3795	.4805	.3963	.3048
21	.5175	.4066	.3163	.3479	.4481	.3658	.2743
22	.2957	.2957	.2846	.2957	.3982	.2743	.2286
23	.7023	.7392	.6642	.1848	.2896	.1524	.5487
24	.7762	.7392	.7392	.6642	.1715	.1867	.1524
Max	1.2567	1.1458	1.1827	1.0753	1.1984	1.2651	1.2018
Min	.1581	.1478	.1265	.0949	.1715	.1265	.1524
Avg	.5365	.5101	.4885	.4417	.5793	.5370	.5607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 205 / 11 KV LOKHANDWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2427	.2587	.2896	.9335	.7011	.6401
2	.2427	.2427	.2614	.2743	.9335	.7316	.6401
3	.2427	.2427	.2614	.2926	.9335	.724	.6706
4	.2987	.2427	.2987	.2984	.9335	.8916	.6859
5	.4108	.3921	.3734	.4287	1.0456	.9717	.7468
6	.5228	.4854	.4854	.5487	1.251	1.0364	.945
7	.6161	.6535	.5975	.6154	1.4784	1.2308	1.2041
8	.5041	.4854		.543	1.6617	1.4089	1.3413
9	1.251	1.5123		1.5023	.3401	.362	.3658
10	1.5223	1.5546		1.5729	.2534	.2534	.2378
11	1.587	1.4737	1.4251	1.4251	.1619	.1991	.2195
12	1.668	1.4089	1.4074	1.4089	.0732	.1991	.1494
13	1.6194	1.4737	1.4737	1.2631	.1296	.168	.0747
14	1.5223	1.4937	1.3603	1.1984	.1463	.0747	.1463
15	1.3603	1.5497	1.4413	1.3765	.1509	.0747	.0724
16	1.1883	1.531	1.2631	1.247	.0747	.1646	.0724
17	.0732	.0747	.0648	.1781	.2195	.2054	.2054
18	.2241	.3142	.2534	.2534	.3547	.2987	.2591
19	.5228	.4668	.5121	.5316	.5975	.5068	.3506
20	.4481	.4481	.421	.439	.4668	.4115	.3201
21	.3696	.3511	.3982	.3801	.443	.3353	.2896
22	.2957	.2957	.3224	.3547	.3772	.2743	.2439
23	.2614	.2614	.2896	.9149	.8686	.6249	.2286
24	.2801	.2614	.2587	.2896	.7621	.7011	.6401
Max	1.668	1.5546	1.4737	1.5729	1.6617	1.4089	1.3413
Min	.0732	.0747	.0648	.1781	.0732	.0747	.0724
Avg	.7197	.7274	.6394	.7344	.6079	.5229	.4479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 206 / 11 KV Korhale KH single SINGLE PHASING
Phasin Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5138	.5138	.4475	.5138	1.326	1.1004	1.1888
2	.5138	.5138	.4475	.5138	1.326	1.2193	1.2193
3	.5138	.5138	.4475	.5138	1.326	1.166	1.2498
4	.5967	.5967	.5801	.5967	1.3592	1.3375	1.2498
5	.7293	.7459	.7625	.9282	1.4586	1.4918	1.3717
6	.8619	.9614	.8951	.9282	1.476	1.4918	1.4175
7	.9945	1.0608	.9922	1.0442	1.7404	1.6575	1.4327
8	.9448	.9448		.9116	1.7901	1.6741	1.5242
9	1.7072	2.0553		1.7238	.7459	.8619	.7164
10	1.989	2.2542		1.873	.5636	.6133	.663
11	2.0553	2.1051	2.0885	1.6078	.431	.4641	.4475
12	2.0222	2.1051	2.0885	1.8399	.3481	.3481	.3812
13	2.1879	2.0885	2.0553	1.8233	.3647	.3149	.3149
14	2.0553		1.9393	1.7901	.3149	.3149	.3481
15	1.9227		1.8896	1.8233	.3149	.3315	.3149
16	1.9393		1.873	1.8233	.3647	.3812	.3647
17	.4807		.4475	.5304	.4475	.4144	.4641
18	.6133		.663	.7655	.6962	.6464	.5792
19	.9945		.8453	1.0269	.779	.8453	.7316
20	.7956	.8453	.7459	.8619		.7164	.6401
21	.6962	.7293	.6962	.663	.8402	.6249	.5639
22	.5967	.6722	.6133	.5636	.6535	.5639	.503
23	.5138	.4641	.5138	1.3094	1.419	1.1888	.4572
24	.5138	.5138	.4475	.5138	1.326	1.1584	1.1888
Max	2.1879	2.2542	2.0885	1.873	1.7901	1.6741	1.5242
Min	.4807	.4641	.4475	.5138	.3149	.3149	.3149
Avg	1.1147	1.0936	1.0228	1.1037	.9309	.8720	.8055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 201 / 11 KV Karkhana Single
phasing Feeder KV- 11 /
OUTGOING SINGLE PHASING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6882	.3277	.2949	.2949	.3605	.5571	.5735
2	.6882	.3277	.2949	.2949	.3605	.5571	.5735
3	.6882	.3277	.2949	.2949	.3605	.5571	.5735
4	.7373	.3277	.2949	.2949	.3605	.6226	.6226
5	.8192	.426	.4915	.4096	.3932	.6882	.7209
6	.9339	.7209	.6554	.5571	.7865	.7865	.852
7	1.1142	.7209	.7865	.7209	.7865	.9831	1.0159
8	1.1142	.6554	.7537	.6554	.7209	1.1142	.9831
9	.3932	.6554	1.3108	1.1797	1.1469	.3768	.3932
10	.3277	1.1797	.4481	1.1797	1.1797	.3932	.3932
11	.3277	1.3108	1.2452	1.1797	1.1469	.3605	.3932
12	.1966		1.2452	1.1797	1.1142	.3277	.3932
13	.1638	1.1797	1.2452	1.1469	1.1142	.3277	.3932
14		1.1797	1.1797	1.1469	1.0486	.3932	.3932
15	.2949	1.1797	1.1797	1.1142	1.0486	.3932	.3932
16	.3932	1.1797	1.1469	1.0486	1.0486	.4588	.2458
17	.5243		.3932	.3277	.4588	.5898	.2949
18	.6554		.7209	.3932	.3932	.6554	.6226
19	.7537		.7209	.4915	.4588	.7209	.7209
20	.6554		.6882	.6554	.7209	.6554	.6882
21	.7537		.639	.5243	.5735	.5898	.6226
22	.4915		.3932	.4588	.4915	.4268	.4915
23	.3277	.3277	.3277	.3932	.5571	.5735	.6226
24	.6882	.3277	.2949	.2949	.3605	.5571	.5735
Max	1.1142	1.3108	1.3108	1.1797	1.1797	1.1142	1.0159
Min	.1638	.3277	.2949	.2949	.3605	.3277	.2458
Avg	.5970	.7267	.7102	.6765	.7080	.5694	.5646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 202 / Malashi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8123	1.1119	1.1865	1.3017	.7751	.4275	.4397
2	.8108	1.121	1.2056	1.2803	.8074	.442	.4504
3	.8253	1.1447	1.2399	1.2986	.8497	.5037	.4969
4	.9526	1.2201	1.3523	1.358	.932	.6467	.5487
5	1.1763	1.5249	1.5493	1.5256	1.0288	.7262	.6668
6	1.2757	1.6392	1.7856	1.669	1.1096	.7926	.7202
7	1.3008	1.826	1.8039	1.6507	1.2331	1.0112	1.0875
8	.5144	1.1408	1.0738	1.1104	1.8496	1.5516	1.592
9	1.0822	.4115	.3901	.4633	1.2223	2.1674	2.2276
10	1.1591	.4332	.3642	.4374	1.3092	2.1026	2.2919
11	1.1622	.4092	.3962	.3932	1.3283	2.0812	2.1761
12	1.1706	.413	.429	.3475	1.2029	2.0393	2.2531
13	1.153	.3731	.429	.3818	1.2559	1.9494	2.1613
14	1.1408	.3883	.4283	.3802	1.2411	1.9974	2.0835
15	1.1218	.4104	.4671	.4359	1.2475	1.9547	1.9631
16	1.1279	.4747	.5052	.4602	.5129	1.1896	1.2429
17	.4976	.3612	.6112	.5319	.5296	.567	.5739
18	.5822	.3963	.6608	.6471	.6646	.6729	.6646
19	.6523	.4054	.5407	.6608	.6821	.8345	.695
20	.5571	.378	.6364	.6256	.6135	.692	.6821
21	.6501	.5274	.8078	.5913	.5361	.6287	.7407
22	.8238	.676	.9038	.4786	.4386	.487	.8631
23	1.0898	1.2018	1.2719	.7971	.4023	.4527	.8086
24	.8093	1.1302	1.2689	.769	.804	.3894	.8162
Max	1.3008	1.826	1.8039	1.669	1.8496	2.1674	2.2919
Min	.4976	.3612	.3642	.3475	.4023	.3894	.4397
Avg	.9353	.7966	.8878	.8165	.9407	1.0961	1.1769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 203 / 11 KV Murum Single phasing SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	1.1142	1.0059	.9389	.9831	.2515	.2622
2	.3018	1.1142	1.0059	.9389	.9831	.2515	.2622
3	.3018	1.1142	1.0059	.9389	.9831	.2515	.2622
4	.4024	1.1142	1.0059	.9724	.9831	.4191	.3018
5	.503	1.2125	1.0898	1.0395	1.0486	.503	.4359
6	.6036	1.3108	1.2071	1.073	1.1797	.6706	.57
7	.6706	1.4419	1.4754	1.3413	1.1797	.7377	.6706
8	.6706	1.5074	1.3413	1.2071	1.1797	.6036	.6371
9	1.7695	1.6876	.2515	.2622	.3605	1.5074	1.5424
10	1.6385	.3018	.2458	.2622	.3932	1.5074	1.7604
11	1.8023	.2347	.2294	.1966	.4024	1.5729	1.7604
12	1.8023	.2012	.2294	.1966	.4024	1.6385	1.7101
13	1.7695	.2347	.2294	.2294	.4024	1.6385	1.7101
14	1.7695	.2683	.2294	.2294	.2347	1.7695	1.6766
15	1.704	.2683	.2294	.2622	.2683	1.6385	1.643
16	1.704	.285	.2622	.2949	.285	1.6385	1.5424
17	.2949		.2949	.3277	.285	.3277	.3018
18	.3932		.2683	.3932	.4024	.3605	.3856
19	.4915		.3353	.4588	.4359	.3932	.4359
20	.4588		.4527	.5243	.503	.3605	.4694
21	.3932		.4527	.4915	.4191	.3277	.4359
22	.3605		.3353	.3605	.3353	.3277	.3353
23	1.1142		.9389	.9831	.2515	.2949	.2683
24	.3018	1.1142	1.0059	.9389	.9831	.2515	.2622
Max	1.8023	1.6876	1.4754	1.3413	1.1797	1.7695	1.7604
Min	.2949	.2012	.2294	.1966	.2347	.2515	.2622
Avg	.8968	.8544	.6303	.6192	.6202	.8018	.8184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 204 / 11 KV Shinde Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.945	.8878	.7559	.7933	.6615	.8878	.8703
2	.6988	.8878	.7559	.6802	.6615	.7933	.8703
3	.6988	.8878	.8131	.683	.7186	.8505	.8703
4	.6988	.8878	.8131	.6802	.6615	.7945	.8703
5	.8131	.8878	.6988	.6802	.6615	.7945	.9077
6	.8703	.945	.6988	.6802	.6615	.6802	.945
7	.8878	.945	.7746	.7559	.6615	.7373	.945
8	.945	1.0581	.8493	.9317	.6802	.8866	1.0581
9	.8993	1.0208	.9065	.9637	.7559	1.0384	1.0208
10	1.0395	1.0208	1.0197	1.0208	.9321	1.1328	1.2483
11	1.0768	1.0208	1.1351	1.1351	1.0197	1.2856	1.3043
12	1.3043	1.2471	1.078	1.1351	1.134	1.2856	1.3043
13	1.323	1.2471	1.078	1.1911	1.2284	1.2856	1.3043
14	1.2754	1.323	1.1141	1.2471	1.2284	1.2471	1.3603
15	1.2856	1.323	1.2658	1.2471	1.1911	1.2471	1.3603
16	1.3427	1.3988	1.2658	1.2471	1.2471	1.2284	1.4746
17	1.2856	.8002	1.2658	1.169	1.2098	1.1911	1.4758
18	1.1538	.8002	1.0197	1.1911	.743	1.1164	1.3043
19	1.0395	.6859	.8703	1.078	1.0395	.8665	1.3043
20	1.0208	.6287	.7559	.9263	1.0021	.8993	1.3043
21	.9157	.6287	.7373	.8505	.945	.9637	1.3043
22	.5716	.5716	.7548	.8505	.9263	.945	1.2471
23	.945	.5716	.8691	.7945	.9263	.8703	1.2471
24	.945	.945	.8703	.7735	.833	.945	1.0417
Max	1.3427	1.3988	1.2658	1.2471	1.2471	1.2856	1.4758
Min	.5716	.5716	.6988	.6802	.6615	.6802	.8703
Avg	.9992	.9425	.9236	.9461	.9054	.9989	1.1643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 205 / 11KV Wayalpatta single SINGLE PHASING
phasing Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7507	.3497	.3703	.4713	.3726	.9309	.9469
2	.7594	.3593	.3856	.4786	.3898	.9324	.9484
3	.7743	.3753	.408	.5068	.4115	.9435	.9602
4	.8242	.3966	.5141	.527	.4263	.9633	1.0749
5	.9259	.5213	.6531	.6226	.5518	1.0825	1.2189
6	1.0787	.8093	.7857	.6878	.8238	1.2501	1.3725
7	1.2034	.897	.9236	.7811	.905	1.5257	1.6149
8	1.4121	.8642	.8288	.8154	.8036	1.811	1.8278
9	.9301	.9233	1.89	1.9132	1.7607	1.2217	1.2791
10	.4919	1.5002	2.1567	2.2032	1.5916	.6307	.567
11	.4481	1.6053	2.2889	2.1681	1.7227	.511	.4812
12	.3845	1.6728	2.3137	2.0291	1.7452	.3753	.4569
13	.3456	1.9647	2.3102	1.9521	1.6027	.381	.3939
14	.3444	2.0339	2.2817	1.9685	1.9867	.3829	.3753
15	.3482	1.9487	2.2436	1.9475	1.9246	.3566	.3402
16	.3864	1.9437	2.1647	1.9094	1.805	.3699	.4005
17	.4454	1.2052	1.3294	1.2929	1.1294	.4313	.4237
18	.5582	.5532	.3787	.5621	.5917	.5057	.5083
19	.711	.6714	.6207	.7102	.6432	.7145	.623
20	.6714	.6927	.6352	.7297	.6523	.7087	.639
21	.5956	.5708	.5762	.6489	.5853	.6614	.551
22	.663	.4641	.5087	.5384	.5376	.3542	.4751
23	.3951	.4111	.4897	.4252	.8916	.8992	.8676
24	.5411	.3703	.3425	.493	1.4205	.9324	.8977
Max	1.4121	2.0339	2.3137	2.2032	1.9867	1.811	1.8278
Min	.3444	.3497	.3425	.4252	.3726	.3542	.3402
Avg	.6662	.9627	1.1417	1.0993	1.0531	.7865	.8018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 206 / Someshwar Engineering

College Feeder KV- 11 /

OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0165	.0144	.0185	.0154	.0185	.0165	.0185
2	.0165	.0229	.0185	.0154	.0165	.0165	.0185
3	.0165	.0134	.0185	.0154	.0165	.0165	.0185
4	.0165	.0134	.0185	.0154	.0165	.0165	.0185
5	.0165	.0134	.0185	.0154	.0262	.0154	.0185
6	.0165	.0134	.0185	.0154	.0144	.0154	.0185
7	.0165	.0134	.0185	.0165	.0229	.0134	.0175
8	.0154	.0154	.0185	.0216	.0134	.0165	.0175
9	.0144	.0154	.0185	.1852	.0175	.0185	.0175
10	.0229	.0185	.0195	.0185	.0185	.0216	.0185
11	.0123	.0216	.0195	.0185	.0185	.1852	.0185
12	.0197	.0206	.0195	.0185	.0185	.0185	.0185
13	.0165	.0185	.0195	.0185	.0175	.0185	.0185
14	.0165	.0175	.0195	.0185	.0195	.0185	.0185
15	.0165	.0165	.0195	.2058	.0165	.0175	.0175
16	.0165	.0165	.0165	.0154	.0165	.0165	.0175
17	.0262	.0144	.0165	.0154	.0165	.0195	.0165
18	.0165	.0165	.0165	.0165	.0165	.0195	.0165
19	.0175	.0165	.0185	.0195	.0185	.0195	.0185
20	.1852	.0175	.0185	.0195	.0185	.0185	.0185
21	.0185	.0175	.0185	.0195	.0185	.0185	.0185
22	.0175	.0185	.0195	.0195	.0175	.0195	.0185
23	.0144	.0185	.0185	.0195	.0165	.0185	.0165
24	.0165	.0144	.0185	.0165	.0185	.0165	.0185
Max	.1852	.0229	.0195	.2058	.0262	.1852	.0185
Min	.0123	.0134	.0165	.0154	.0134	.0134	.0165
Avg	.0241	.0166	.0185	.0323	.0179	.0246	.0180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 201 / 11 KV Chilaimala Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7419	.0671	.1268	.0793	.8017	.8664	.7583
2	.73	.0461	.1282	.0823	.7941	.8322	.7209
3	.7209	.0491	.1191	.0846	.791	.8307	.711
4	.7125	.0506	.1486	.0846	.7819	.8383	.7225
5	.7415	.0506	.1532	.1002	.7667	.83	.7423
6	.7453	.0686	.1494	.1047	.7445	.8048	.7392
7	.8245	.1296	.1608	.1169	.9077	.9404	.799
8	.8833	.1771	.1749	.1223	1.0623	1.038	.9815
9	.5767	.8413	.7133	1.3954	.6104	.6417	.5845
10	.1177	1.0997	1.3801	1.6331	.1418	.1139	.1402
11	.125	1.2026	1.4159	1.6453	.1501	.122	.1177
12	.1131	1.4396	1.4837	1.3977	.1585	.1418	.1108
13	.1108	1.5387	1.4823	1.5173	.1768	.1494	.112
14	.1009	1.545	1.2293	1.5752	.1722	.1494	.109
15	.0747	1.4655	1.2285	1.5295	.1593	.1493	.1166
16	.0671	1.47	1.2574	1.2543	.1593	.141	.1181
17	.0724	.8151	.7141	.8375	.1502	.1402	.1502
18	.077	.1737	.1311	.1395	.1463	.1303	.1441
19	.1303	.1715	.1486	.122	.1501	.1227	.1357
20	.1341	.1855	.1403	.1067	.1517	.1124	.1224
21	.1147	.1825	.138	.0968	.1509	.0892	.1006
22	.1002	.1912	.1059	.0937	.1471	.0838	.0823
23	.0926	.1707	.0861	.7407	.8817	.7263	.7666
24	.3681	.1082	.1136	.4778	.8634	.8086	.8169
Max	.8833	1.545	1.4837	1.6453	1.0623	1.038	.9815
Min	.0671	.0461	.0861	.0793	.1418	.0838	.0823
Avg	.3531	.5517	.5387	.6391	.4592	.4501	.4126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 202 / 11 KV Wadgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2058	.2054	.2054	.2572	.2218	.2218
2	.1829	.2058	.2012	.2054	.2572	.2241	.2241
3	.2033	.2058	.2195	.2263	.2572	.2241	.2534
4	.2241	.2401	.2614	.2829	.2743	.2614	.3258
5	.2987	.3086	.3326	.3584	.3086	.3547	.394
6	.462	.4287	.4854	.4904	.4458	.4854	.4525
7	.5487	.5487	.5194	.5975	.4801	.5788	.5611
8	.5975	.5658	.5788	.6348	.5316	.5975	.5914
9	.5415	.4973		.5175	.5144	.499	.5228
10	.4287	.4066	.3511	.3429	.362	.3982	.4298
11	.3601	.3292	.2481	.3086	.2743	.3361	.3403
12	.2915	.3012	.2572	.3086	.2572	.2715	.2947
13	.3258	.2481	.2229	.3086	.2515	.2987	.2743
14	.3086	.1991	.2401	.3086	.2515	.2896	.2572
15	.2743	.208	.1886	.2572	.2515		.2229
16	.2743	.2401	.1677	.2743	.2429	.2715	.2401
17	.2743	.3258	.3018	.3601	.2572	.3361	.2401
18	.3601	.4108	.3429	.3772	.3681	.4024	.3544
19	.4801	.4938	.4938	.463	.4805	.5041	.4251
20	.463	.4668	.462	.4287	.4755	.4668	.4294
21	.4115	.4066	.4066	.3944	.4207	.4066	.3921
22	.3429	.3326	.3326	.3086	.3326		.3292
23	.2743	.2427	.2402	.2572	.2378	.2401	.2561
24	.2054	.2058	.2033	.2241	.2572	.2195	.2172
Max	.5975	.5658	.5788	.6348	.5316	.5975	.5914
Min	.1829	.1991	.1677	.2054	.2378	.2195	.2172
Avg	.3475	.3343	.3158	.3517	.3353	.3585	.3437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 203 / 11 KV CHOUDHARWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4634	.4954	.4763	.4672	.5232	.5229	.5723
2	.4657	.5	.4655	.4885	.5224	.5231	.5407
3	.5182	.5144	.4923	.5068	.5376	.5338	.5837
4	.6333	.5692	.567	.6078	.6195	.6459	.708
5	.8771	.775	.8155	.839	.844	.8696	.9477
6	1.1035	1.1032	1.1645	1.1195	1.0715	1.2414	1.3309
7	1.3558	1.3314	1.3456	1.3576	1.3009	1.5161	1.4174
8	1.3489	1.3032	1.278	1.3298	1.3169	1.3653	1.2963
9	.9934	1.0125	.6036	.9991	1.0643	1.0265	1.0198
10	.7808	.7156	.6866	.7076	.841	.7968	.8236
11	.5994	.5951	.4916	.6256	.679	.6721	.6857
12	.5061	.4033	.4576	.5457	.6013	.5746	.5757
13	.4748	.4656	.5137	.5122	.57	.5525	.4901
14	.516	.4878	.4794	.516	.497	.6206	.5091
15	.4386	.5228	.5224	.594	.5262	.5601	.5076
16	.4138	.5282	.5037	.5776	.5367	.5689	.5155
17	.5582	.5624	.6764	.777	.6912	.6771	.5929
18	.6957	.7857	.7102	.7613	.8569	.7743	.7438
19	.9584	1.1103	1.03	1.0547	1.1469	1.0601	.9442
20	1.0361	1.0261	1.0109	1.0551	1.1527	1.0639	.9442
21	.9728	.9111	.9107	.9114	1.0783	.9952	.8917
22	.7895	.7956	.8009	.7742	.8443	.8644	.7247
23	.6828	.5902	.6215	.6245	.6592	.6775	.6032
24	.4908	.5471	.5183	.5018	.5575	.5521	.554
Max	1.3558	1.3314	1.3456	1.3576	1.3169	1.5161	1.4174
Min	.4138	.4033	.4576	.4672	.497	.5229	.4901
Avg	.7364	.7355	.7143	.7606	.7933	.8023	.7718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 204 / 11 KV Wadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9266	.3582	.2896	.3033	1.4327	1.6331	1.4579
2	1.329	.2896	.2972	.3033	1.4327	1.6019	1.5394
3	.8504	.2896	.3033	.3033	1.4327	1.6019	1.5394
4	.9106	.2896	.3765	.341	1.4327	1.4495	1.5669
5	.9815	.3582	.3696	.341	1.4327	1.512	1.5166
6	.9754	.5106	.3696	.3787	1.7071	1.7052	1.5166
7	1.1995	.5791	.3787	.4165	1.89	1.8648	1.4998
8	1.448	.5791	.3765	.3787	2.1033	2.05	1.6918
9	.913	1.1583	.6097	1.5356	1.3908	1.291	1.0654
10	.3239	2.4082	2.4988	2.9645	.3002	.3033	.3002
11	.3239	2.8959	2.6672	3.0331	.3002	.3018	.3002
12	.2896	2.7115	2.652	2.8655	.2972	.3018	.3002
13	.2896	2.1018	2.7576	2.4387	.2256	.3033	.2987
14	.3239	2.591	2.726	2.6826	.1463	.1524	.3018
15	.3582	2.7588	2.5735	2.5301	.2972	.1524	
16	.3582	2.6749	2.5735	2.5301	.2957		.1478
17	.3582	1.5165	1.515	1.5432	.3296	.1509	.3391
18	.3582	.2972	.3018	.3239	.3719	.3033	.3391
19	.5791	.3787	.3018	.3582	.4085	.2957	.3765
20	.5791	.3787	.3391	.4267	.3673	.3765	.3765
21	.5791	.3787	.3391	.3582	.3696	.3765	.3765
22	.5449	.3765	.3391	.3239	.3696	.3765	.3353
23	.3582	.3765	.341	1.0364	1.073	1.1697	.7925
24	.6112	.3582	.3018	.9507	1.7375	1.512	1.4495
Max	1.448	2.8959	2.7576	3.0331	2.1033	2.05	1.6918
Min	.2896	.2896	.2896	.3033	.1463	.1509	.1478
Avg	.6571	1.1090	1.0666	1.1945	.8810	.9037	.8447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 205 / 11 KV MUDHALE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383		.679	.583	.7202	.7888	.964
2			.6348	.583	.7202	.7888	1.0059
3	.9326		.679	.6173	.7545	.823	1.0288
4	.9221		.8962	.6859	.7545	.8573	1.2003
5	1.0631		.9709	.8402	.823	.9088	1.2003
6	1.1012	.9259	1.1203	1.046	1.046	1.046	1.262
7	1.5775	1.1145	1.1883	1.1488	1.4403	1.6632	1.5604
8	1.7204	.9945	1.0751	1.0288	1.6289	1.8176	1.7661
9	.7545	1.3717		1.4575	.703	.9145	.7545
10	.4973	2.0237	1.6804	1.6461	.4382	.5335	.6287
11	.3944	2.1434	1.7147	1.7833	.381	.415	.4763
12	.3086	1.989	1.6804	1.8861	.3239	.2987	.3239
13		1.781	1.6804	1.7661	.3048	.2987	.3048
14	.3258	1.7394	1.749	1.5775	.3048	.3018	.3048
15	.3086	1.5242	1.6804	1.5432	.3239	.3018	.3239
16	.3429	1.7147	1.5089	1.3889	.381	.2829	.3048
17	.3429	.2641	.3258	.3601	.4382	.415	.381
18	.6344	.6036	.583	.5658	.7049	.6722	.6859
19	.9431	.9619	.9774	.9431	1.0669	.9808	.9526
20		1.0562	.9431	.9774	1.0669	1.094	.9717
21	.9259	.9431	.8916	.9088	.9907	.9431	.9145
22	.7888	.8488	.8059	.823	.8764	.8676	.8002
23	.7202	.6979	.6859	.7202	.823	.9088	.8413
24	.8478		.679	.6173	.7202	.823	.9431
Max	1.7204	2.1434	1.749	1.8861	1.6289	1.8176	1.7661
Min	.3086	.2641	.3258	.3601	.3048	.2829	.3048
Avg	.7757	1.2610	1.0795	1.0624	.7390	.7810	.8292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 206 / 11 KV DAREKAR MALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8953	.0808	.0804	.08	1.7665	1.6971	1.5425
2	.8677	.0846	.0804	.08	1.8442	1.672	1.507
3	.8246	.0846	.0834	.0831	1.6957	1.6628	1.3939
4	.8512	.1025	.0838	.0869	1.8076	1.6842	1.4244
5	.8794	.1063	.1296	.104	1.6758	1.6834	1.387
6	.9472	.1311	.1371	.1047	1.688	1.7242	1.3051
7	1.0524	.1425	.1516	.1296	1.8305	1.6865	1.3253
8	1.1325	.1486	.1351	.1672	1.7993	1.6735	1.3786
9	.7402	1.5676	1.0982	2.1247	.9816	.9564	.7371
10	.1108	1.906	2.5408	2.5156	.0758	.1328	.1138
11	.0846	2.4844	2.5233	2.6002	.0766	.0987	.0827
12	.0663	2.5318	2.4227	2.5171	.0773	.1025	.0758
13	.0655	2.5107	2.3213	2.4554	.0674	.0811	.0819
14	.0648	2.5556	2.3122	2.303	.0319	.1109	.0667
15	.0663	2.3967	2.2306	2.3906	.0537	.0993	.0598
16	.0633	2.338	2.1201	2.4181	.0674	.0903	.0598
17	.0686	1.2041	1.1569	1.2125	.0667	.1196	.0655
18	.0948	.1054	.1131	.1017	.1065	.1417	.0789
19	.1558	.1819	.1395	.1177	.1303	.1646	.1101
20	.1509	.148	.1143	.1235	.1463	.148	.116
21	.1448	.0994	.1101	.1143	.1282	.1275	.1092
22	.1162	.0868	.1108	.0633	.1214	.1176	.0796
23	.1055	.088	.1032	1.621	1.6592	1.5487	1.2018
24	.419	.077	.0842	1.0075	1.7063	1.6453	1.4144
Max	1.1325	2.5556	2.5408	2.6002	1.8442	1.7242	1.5425
Min	.0633	.077	.0804	.0633	.0319	.0811	.0598
Avg	.4153	.8818	.8493	1.0217	.8168	.7987	.6549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 201 / 11 KV Late Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.0762	.1029	.0857	.6097	.5068	.5144
2	.5487	.0762	.1029	.0857	.6097	.5068	.5144
3	.5487	.0914	.1029	.0857	.5944	.5068	.5144
4	.5487	.0914	.1029	.1029	.6097	.5213	.5144
5	.5639	.1067	.1029	.12	.6097	.5502	.583
6	.6249	.1219	.1029	.1372	.6554	.6287	.6516
7	.7773	.1219	.12	.1509	.8383	.8025	.7716
8	.9755	.1067	.1029	.132	.7926	.8278	.9088
9	.0762	1.166		1.0669	.0686	.0934	.1109
10	.0457	1.5604		1.2803	.0686	.0857	.0747
11	.0457	1.6804	1.4022	1.2955	.0514	.0514	.0739
12	.0305	1.7661	1.4022	1.2498	.0514	.0343	.0549
13	.0457	1.6461	1.387	1.3565	.0514	.0343	.0532
14	.0457	1.4746	1.2803	1.2193	.0554	.0343	.0526
15	.0305	1.5261	1.2498	1.2193	.0554	.0343	.0543
16	.0457	1.4575	1.0974	1.1279	.0566	.0343	.0537
17	.061	.0686	.0514		.056	.0514	.0701
18	.0762	.1029	.0686	.0762	.0754	.0857	.1109
19	.0914	.12	.1029	.0914	.1132	.12	.112
20	.0914	.12	.1509	.1067	.132	.12	.1307
21	.0914	.1029	.132	.1067	.132	.12	.132
22	.0914	.0857	.1132	.1067	.132	.1029	.1307
23	.0914	.1029	.0943	.5944	.5068	.5144	.5281
24	.5639	.0762	.1029	.0857	.5944	.8278	.5144
Max	.9755	1.7661	1.4022	1.3565	.8383	.8278	.9088
Min	.0305	.0686	.0514	.0762	.0514	.0343	.0526
Avg	.2775	.5770	.4307	.5167	.3133	.2998	.3012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 202 / 11 KV Korhale Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	.7926		.884	***	***	***
2	***	.7926		.884	***	***	***
3	***	.7926		.884	***	***	***
4	***	.7926		.884	***	***	***
5	***	.7926		.884	***	***	***
6	***	.884		.9145	***	***	***
7	***	.9755		1.0212	***	***	***
8	***	1.1279		1.1126	***	***	***
9	1.0669	.1543		.1219	1.0364	1.2193	1.1888
10	1.2955	***	***	***	1.4175	1.5089	1.387
11	1.4022	***	***	***	1.4784	1.5775	1.3565
12	1.3717	***	***	***	1.4632	1.6461	1.3643
13	1.4022	***	***	***	1.3496	1.6461	1.3466
14	1.3717	***	***	***	1.3226	1.5089	1.2308
15	1.3717	***	***	***	1.2631	1.4746	1.1149
16	1.2193	***	***	***	1.2037	1.5775	.9002
17	.0914	***	***	***	.0709	.1029	.0943
18	***	***	***	***	***	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	***	***	***	***	***	***	***
23	.7926	1.0631	.8993	***	***	***	***
24	.1698	.7926		***	***	***	***
Max	114.5383	114.5178	114.5572	114.5254	114.5572	114.5383	114.5572
Min	.0914	.1543	.8993	.1219	.0709	.1029	.0943
Avg	51.3763	33.7787	60.0578	41.6991	57.7144	53.0218	57.6895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 203 / 11KV Kurnewadi single SINGLE PHASING
Phasing Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.5182	.5487	.5792	.3353	.415	.3772
2	.3772	.5487	.5487	.5792	.3353	.415	.3772
3	.4338	.5487	.5487	.5944	.3658	.4527	.3772
4	.5093	.5792	.5487	.6401	.3963	.5281	.4458
5	.679	.7011	.8573	.7164	.5487	.7167	.5487
6	.8865	.884	1.0288	.8688	.7011	.9431	.8916
7	.8573	.9755	1.2003	1.1142	.823	1.0562	.9602
8	.823	1.1279	1.3375	1.1728	.7316	.9431	.8916
9	1.0669	.4801		.4572	.9755	.9783	1.1873
10	1.1584	.3086		.2439	1.2193	1.3717	1.3748
11	1.2498	***	***	***	1.3413	1.406	1.3748
12	1.1584	***	***	***	1.3226	1.4403	1.278
13	1.2193	***	***	***	1.291	1.4746	1.2289
14	1.1584	***	***	***	1.278	1.3375	1.1873
15	1.1584	***	***	***	1.278	1.3032	1.0709
16	1.0059	***	***	***	1.247	1.3032	.9717
17	.2896	***	***		.4207	.3772	.3258
18	.4725	.5487	.5144	.4877	.5975	.4458	.4938
19	.6097	.7545	.7202	.7164	.8589	.7202	.7545
20	.6401	.7202	.7842	.6859	.8676	.6859	.7922
21	.5792	.6173	.7167	.5487	.7545	.6859	.679
22	.4268	.5487	.547	.442	.5658	.5487	.547
23	.5182	.5487	.5792	.3353	.4527	.5144	.4338
24	.3772	.5182	.5487	.5792	.3353	.415	.4115
Max	1.2498	152.7932	152.7589	152.6561	1.3413	1.4746	1.3748
Min	.2896	.3086	.5144	.2439	.3353	.3772	.3258
Avg	.7513	37.0331	36.9497	31.9953	.7935	.8532	.7909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 204 / MATKARWASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.179	1.832	1.0143	1.8299	.1677	.1738	.0686
2	.1821	1.835	.9945	1.8284	.1669	.1768	.0686
3	.1874	1.8099	1.0052	1.8641	.1867	.1844	.0686
4	.2078	1.8373	1.0044	1.883	.192	.2009	.0686
5	.2374	1.8801	1.0761	1.9323	.2164	.2332	.0686
6	.3064	1.9776	1.1325	2.0935	.2316	.5289	.1334
7	.2965	2.031	1.2109	2.2832	.272	.3117	.141
8	.301	2.4714	1.3618	2.5088	.2476	.291	.1433
9	2.4463	1.1221	1.0098	1.1904	2.1933	2.6898	.6371
10	2.9096	.2	.0838	.1555	2.899	3.1664	.8055
11	3.2144	.1555	.0701	.154	3.2206	3.248	2.8662
12	3.248	.0686	.0581	.1387	2.3198	3.2857	2.8418
13	3.2282	.0694	.1231	.1433	1.2273	3.3547	2.8311
14	3.1161	.0686	.1002	.1585	2.7999	3.1131	1.6347
15	3.0461	.1501	.0705	.1326	3.2777	2.8853	2.3438
16	2.8654	.1037	.0486	.1433	3.2991	2.9454	2.3236
17	1.2255	.0968	.1677	.1578	1.4716	1.022	1.0274
18	.1418	.2058	.2027	.1707	.173	.0732	.192
19	.2096	.2317	.2423	.2171	.2423	.0694	.2105
20	.2096	.2218	.2004	.2065	.2412	.0686	.2133
21	.1966	.2187	.2278	.1943	.2496	.0686	.208
22	.192	.1806	.2172	.2035	.2095	.0686	.2088
23	1.7825	1.9109	1.7897	.1768	.1867	.0686	.1821
24	1.0928	1.8343	1.038	.8834	.157	.0747	.1738
Max	3.248	2.4714	1.7897	2.5088	3.2991	3.3547	2.8662
Min	.1418	.0686	.0486	.1326	.157	.0686	.0686
Avg	1.2926	.9380	.6021	.8604	1.0770	1.1793	.8109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JAN-17 and 14-JAN-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 205 / 11 KV BAJARANGWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JAN-17	09-JAN-17	10-JAN-17	11-JAN-17	12-JAN-17	13-JAN-17	14-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4572		.4572	.4115	.499	.4458
2	.4854	.4572		.4572	.3963	.499	.4458
3	.5228	.4877		.4938	.4268	.5544	.4458
4	.5601	.4877		.5729	.4268	.6468	.5144
5	.6908	.6097		.7095	.5944	.7392	.6859
6	.8962	.7926		.9149	.7316	.9055	.8402
7	.8916	.8535		1.0082	.8383	.9979	.8573
8	.8745	.7468		.8871	.7011	.9795	.8916
9	.6401	.7373		.5792	.6859	.7602	.7602
10	.5487	.5658		.4877	.4801	.6001	.5973
11	.4572	.5144	.4973	.4725	.463	.5144	.5792
12	.442	.4973	.4641	.442	.4161	.4287	.4887
13	.3963	.4458	.3906	.4115	.4001	.4287	.421
14	.3658	.4287	.4049	.381	.421	.3944	.3812
15	.442	.4287	.4049	.381	.421	.4115	.3647
16	.4268	.4973	.421	.4268	.4372	.4801	.3605
17	.4725	.5316	.4858	.4725	.5304	.5487	.4144
18	.5182	.583	.6274	.5487	.724	.6173	.5548
19	.5792	.7545	.7964	.6554	.8326	.7202	.695
20	.6097	.6859	.7421	.5944	.7783	.6859	.6653
21	.5792	.6173	.695	.5944	.7059	.6516	.5914
22	.4877	.583	.6348	.4725	.6154	.5316	.5304
23	.442	.4801	.5068	.3963	.5249	.4801	.4572
24	.4854	.4572		.4525	.3963	.499	.4458
Max	.8962	.8535	.7964	1.0082	.8383	.9979	.8916
Min	.3658	.4287	.3906	.381	.3963	.3944	.3605
Avg	.5542	.5708	.5439	.5529	.5566	.6072	.5597