

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 201 / KATEWADI (AG)
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	1.89	1.9433	1.8671	.1524	.1829
2	.1905	1.5089	1.6842	1.4556	.1981	.1981
3	.1905	.2058	.1829	.1981	.1981	.2058
4	.2134	.2134	.1981	.2286	.2286	.2439
5	.2439	.2362	.2286	.2362	.2286	.2439
6	.2286	.1981	.1905	.221	.2058	.1981
7	.1372	.1524	.1372	.0914	.1448	.1448
8	.8078	2.3472	.1219	.1372	.1372	2.9188
9	3.216	2.6139	.0991	.1067	.1219	2.9492
10	3.1169	2.8349	.0991	.0991	.1143	2.8883
11		2.7816	.1067	.1067	.1143	3.0102
12	.4877	2.8502	.1143	.1067	.1296	3.0788
13	3.094	3.1703	.1296	.1219	.1372	3.1779
14	3.1474	3.1626	.16	.1372	.1829	3.0255
15	3.0864	3.0026	.1905	.1905	.1905	2.7206
16	1.9357	1.9204	2.7968	2.6673	2.6368	2.05
17	.3048	.3048	2.7892	2.7054	2.6444	.2743
18	.3048	.3048	2.5149	2.4691	2.3472	.3048
19	.2439	.2515	2.1491	2.1491	2.05	.2591
20	.1905	.2134	1.9509	1.9966	1.9052	.2134
21	.1753	.1905	1.8976	1.989	1.9128	.1981
22	.16	.1829	1.9281	1.9738	1.8976	.1829
23	.16	.1677	1.8976	1.9585	1.8823	.1677
24	.16	.1677	1.89	1.9585	1.8823	.16
Max	3.216	3.1703	2.7968	2.7054	2.6444	3.1779
Min	.1372	.1524	.0991	.0914	.1143	.1448
Avg	.9552	1.2863	1.0583	1.0488	.9018	1.2082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 202 / 11 kKV KATEWADI (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.3544	.3582	.3734	.362	.3734
2	.4496	.442	.4344	.4344	.423	.4382
3	.4992	.5068	.4801	.4954	.4611	.4877
4	.5563	.5487	.5144	.5563	.5411	.522
5	.5601	.5487	.522	.5677	.5601	.5487
6	.4344	.4534	.4344	.4649	.4534	.4534
7	.362	.3506	.3353	.3849	.3772	.3849
8	.3467	.3467	.3506	.3582	.4001	.3734
9	.3277	.3048	.3125	.3086	.3315	.3353
10	.2515	.3201	.3201	.301	.3353	.301
11	.2743	.3048	.3048	.3048	.3429	.2629
12	.3239	.3315	.3163	.3239	.3467	.3086
13	.3429	.3849	.3696	.3506	.3658	.3506
14	.381	.4611	.4268	.4191	.3887	.4382
15	.4725	.4992	.5487	.522	.5296	.4649
16	.5944	.5906	.5716	.6173	.6211	.6211
17	.663	.6973	.6897	.663	.7164	.7011
18	.663	.6897	.6668	.7202	.6859	.7049
19	.5601	.5906	.5601	.6478	.5868	.6059
20	.4611	.4611	.442	.4687	.503	.4954
21	.381	.4115	.3849	.3734	.3849	.4039
22	.3391	.3658	.3429	.3391	.3582	.3544
23	.3201	.3506	.3239	.3239	.3429	.3429
24	.3277	.3658	.3239	.3353	.3467	.3429
Max	.663	.6973	.6897	.7202	.7164	.7049
Min	.2515	.3048	.3048	.301	.3315	.2629
Avg	.4283	.4450	.4306	.4439	.4485	.4423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 205 / 11 KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4611	.4725	.4572	.381	.423	.4801
2	.4611	.4306	.4496	.4001	.4306	.4839
3	.4344	.423	.4496	.4001	.4306	.4191
4	.442	.4649	.4763	.4191	.4572	.4687
5	.4572	.4725	.4915	.4268	.4687	.5106
6	.5106	.4954	.4687	.4382	.4687	.5258
7	.4954	.5601	.4268	.442	.4572	.5754
8	.602	.5601	.4649	.4534	.4649	.6097
9	.5754	.522	.5373	.4496	.4458	.5335
10	.4954	.5639	.5068	.3963	.4344	.4344
11	.5296	.4572	.5106	.3239	.4458	.4077
12	.5068	.4992	.5754	.2782	.4611	.4268
13	.5068	.4725	.5296	.4344	.4534	.4153
14	.4725	.3696	.5182	.4344	.4268	.3963
15	.4458	.4077	.4496	.4153	.4001	.4839
16	.4382	.423	.3849	.4153	.4039	.4992
17	.4915	.4572	.4153	.442	.4344	.4382
18	.4534	.4191	.4001	.442	.423	.4115
19	.4344	.4077	.3391	.4306	.3887	.3925
20	.442	.4191	.3506	.4268	.3925	.4115
21	.4153	.4191	.3658	.4306	.381	.4191
22	.4001	.4306	.3925	.423	.381	.4306
23	.4001	.423	.4115	.4306	.3734	.442
24	.4077	.4344	.442	.442	.3734	.4153
Max	.602	.5639	.5754	.4534	.4687	.6097
Min	.4001	.3696	.3391	.2782	.3734	.3925
Avg	.4700	.4585	.4506	.4157	.4258	.4596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 206 / 11 KV GAWARKHOPAD AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	1.5699	1.3565	1.387	.0381	.0381
2	.0457	1.0974	1.1431	1.0822	.0533	.0457
3	.0457	.0457	.0457	.0457	.0533	.0457
4	.0457	.0381	.0381	.0457	.0457	.0381
5	.0457	.0381	.0381	.0381	.0457	.0457
6	.0381	.0381	.0381	.0381	.0381	.0305
7	1.4861	1.6232	.0305	.0381	.0381	.0305
8	1.4861	1.6537	.0229	.0305	.0381	1.7833
9		1.7223	.0229	.0229	.0305	1.8671
10	.1905	1.8061	.0229	.0305	.0305	1.8747
11	1.8823	1.7528	.0305	.0229	.0305	1.8976
12	1.7375	1.0212	.0229	.0229	.0229	1.9204
13	.0991		.0229	.0229	.0229	1.8595
14	1.9052		.0229	.0229	.0305	1.7833
15	1.8061	1.6918	.0305	.0305	.0229	1.669
16	1.0517	1.2422	1.7071	1.6004	1.5013	1.1355
17	.0533	.0457	1.768	1.608	1.6004	.0457
18	.0457	.0457	1.6613	1.547	1.5394	.0457
19	.0457	.0457	1.608	1.4327	1.4556	.0457
20	.0457	.0381	1.5699	1.3946	1.4022	.0457
21	.0457	.0457	1.5623	1.3641	1.387	.0457
22	.0457	.0381	1.5775	1.3717	1.3794	.0457
23	.0381	.0381	1.6004	1.3489	1.3794	.0457
24	.0381	.0381	1.6232	1.3489	1.3946	.0381
Max	1.9052	1.8061	1.768	1.608	1.6004	1.9204
Min	.0381	.0381	.0229	.0229	.0229	.0305
Avg	.5331	.7125	.7319	.6624	.5659	.6843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 201 / 11 KV DHUMALWADI SINGLE SINGLE PHASING
PH. Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4234	1.0669	1.0517	1.1126	2.4234	2.6673
2	1.3565	1.2651	1.2651	1.2955	1.2498	1.3413
3	1.4022	1.4327	1.4632	1.5089	1.4175	1.4175
4	1.5546	1.6004	1.5851	1.6004	1.5546	1.6004
5	1.6004	1.6156	1.6004	1.6156	1.5699	1.6461
6	1.0212	1.0974	1.0059	1.2651	1.0364	.381
7	.8078	.7621	.8383	.8688	.8688	.8993
8	.7468	.7773	4.4201	4.2067	3.9476	.7164
9	.7164	.7468	4.4963	4.4201	3.9018	.6554
10	.7316	.7011	4.3134	4.4048	4.1	.6554
11	.7621	.6859	4.3743	4.4353	4.2981	.6401
12		.6706	4.2524	4.4505	4.5268	.6401
13	.6706	.6554	4.5877	4.5572	4.603	.6401
14	.884	.8383	4.7554	3.5818	4.4201	.7011
15	1.1736	1.1431	4.2372	3.4446	4.2067	1.0212
16	3.8561	3.5665	1.7223	1.8442	1.6766	3.8104
17	3.8104	3.4751	1.8138	1.8595	1.7985	3.719
18	3.0331	3.0026	1.8138	1.8595	1.768	3.0636
19	2.6368	2.6368	1.5242	1.5242	1.5242	2.6825
20	2.3929	2.3929	1.2346	1.1736	1.2041	2.4539
21	2.271	2.3015	1.0669	1.0059	1.0517	2.3624
22	2.2405	2.3015	.9907	.9755	1.0059	2.3777
23	2.2558	2.3167	.9907	.9602	.9907	2.3777
24	2.271	2.3777	.9907	.9755	1.0059	2.3929
Max	3.8561	3.5665	4.7554	4.5572	4.603	3.8104
Min	.6706	.6554	.8383	.8688	.8688	.381
Avg	1.7660	1.6429	2.3498	2.2894	2.3396	1.7026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 202 / 11 KV DHAKALE SINGLE PH. SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4649	1.6613	1.6994	1.7223	.3887	.4039
2	.5563	1.4556	1.5546	1.5775	.4954	.5182
3	.6859	.663	.5944	.5868	.5563	.5639
4	.7011	.7164	.663	.6325	.6249	.6478
5	.7087	.8002	.7011	.6783	.663	.6706
6	.5487	.1372	.4801	.5639	.503	.503
7	.3125	.2667	.3277	.2972	.2972	.282
8	2.2558	2.2634	.282	.282	.2667	1.4708
9	2.4006	2.4463	.282	.2743	.2591	1.5089
10	2.5225	2.4615	.2972	.2743	.2667	1.0822
11	2.6978	2.4691	.3048	.2591	.2591	1.3032
12	2.7816	2.4996	.1981	.2591	.1981	1.1507
13	2.5987	2.5225	.2896	.2591	.1905	1.2346
14	2.6368	2.4158	.3658	.2667	.3277	2.4539
15	2.5072	2.3091	.4268	.4115	.4877	2.5606
16	2.0652	2.0119	2.0957	2.5835	2.5987	1.9814
17	.8535	.9069	2.6139	2.6978	2.7359	.8383
18	.8459	.884	2.3548	2.3396	2.3015	.9221
19	.6325	.724	1.89	1.8595	1.7452	.6783
20	.4801	.5411	1.7528	1.7071	1.6918	.4649
21	.4268	.4649	1.6994	1.6309	1.6309	.4191
22	.4115	.442	1.6994	1.6613	1.6385	.3963
23	.4039	.4344	1.6918	1.6994	1.669	.4039
24	.4039	.4344	1.6842	1.6842	1.6994	.3887
Max	2.7816	2.5225	2.6139	2.6978	2.7359	2.5606
Min	.3125	.1372	.1981	.2591	.1905	.282
Avg	1.2876	1.3305	1.0812	1.0920	.9790	.9520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 204 / 11 KV PANDHRE SINGLE PH. SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1948	2.3624	2.4539		
2		1.5242	1.6004	1.6918		
8	3.5056	3.1398				4.039
9	3.7494	3.1398				4.0238
10	3.7952	3.6427				2.774
11	3.9781	3.7342				4.1152
12	4.1762	3.8714				3.7647
13	4.2219	3.9628				3.9628
14	3.9018	3.9323				3.7799
15	3.6123	3.5665				3.8866
16	.0305	2.0881	3.216	3.3684	3.155	1.6766
17			3.2007	3.4751	2.4387	
18			2.7435	3.1398	2.1338	
19			2.271	2.6216	1.9052	
20			2.1795	2.3472	1.7528	
21			2.1186	2.3015	2.3472	
22			2.1338	2.2862	2.332	
23			2.1491	2.3015	2.3777	
24			2.1795	2.332	2.3929	
Max	4.2219	3.9628	3.216	3.4751	3.155	4.1152
Min	.0305	1.5242	1.6004	1.6918	1.7528	1.6766
Avg	3.4412	3.1633	2.3777	2.5745	2.3150	3.5581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN

Feeder No / Name : 206 / 11 KV JALGAON (KP) SINGLE SINGLE PHASING
PHAS Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1524	.3048	.381	.381	.2286
2	.1524	.1524	.381	.381	.381	.2286
3	.1524	.1524	.381	.381	.381	.2286
4	.2286	.2286	.381	.381	.381	.2286
5	.2286	.2286	.4572	.4572	.4572	.3048
6	.381	.381	.6097	.6859	.6097	.381
7	.6859	.6859	.8383	.8383	.8383	.6097
8	.8383	.8383	.8383	.8383	.8383	.7621
9	.7621	.6859	.6097	.5335	.6859	.5335
10	.381	.381	.5335	.4572	.4572	.4572
11	.2286	.2286	.4572	.381	.4572	.2286
12		.2286	.381	.381	.4572	.2286
13		.2286	.5335	.3048	.4572	.1524
14	.2286	.2286	.5335	.381	.381	.1524
15	.2286	.2286	.4572	.381	.4572	.1524
16	.2286	.2286	.4572	.381	.381	.2286
17	.2286	.2286	.4572	.381	.381	.2286
18	.2286	.3048	.2286	.2286	.2286	.3048
19	.4572	.4572	.381	.4572	.4572	.4572
20	.6859	.6859	.6859	.6859	.6859	.6859
21	.6097	.6859	.6097	.6859	.6859	.6097
22	.5335	.5335	.5335	.5335	.6097	.5335
23	.381	.4572	.4572	.5335	.4572	.4572
24	.2286	.381	.381	.381	.2286	.2286
Max	.8383	.8383	.8383	.8383	.8383	.7621
Min	.1524	.1524	.2286	.2286	.2286	.1524
Avg	.3776	.3747	.4953	.4763	.4890	.3588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 201 / 11 KV KARKHANA SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.9145	1.0745	1.0212	.5563	.6097
2	.7773	.8459	.9526	.9678	.7316	.7849
3	.8764	.8383	.8916	.884	.8764	.8993
4	.9374	.884	.9526	.945	.945	.9602
5	.9755	.9221	.9755	.9602	.9602	.9678
6	.7773	.7849	.7926	.8459	.7926	.663
7	.5716	.6097	.6173	.6325	.6783	.5106
8	1.7985	1.6156	.602	.5944	.5944	1.7985
9	1.8214	1.6537	.5563	.5639	.503	1.8519
10	1.8061	1.6994	.5106	.5563	.4877	1.7833
11	1.7375	1.7375	.5563	.5944	.4801	1.8519
12	1.8595	1.7985	.663	.3201	.5258	1.9052
13	1.8519	1.89	.1905	.282	.5106	1.9433
14	1.8138	1.89	.4191	.5411	.5868	1.8595
15	1.7909	1.7985	.7011	.7468	.7621	1.7833
16	1.3489	1.4175	1.7452	1.8061	1.7147	1.3184
17	1.2193	1.2269	1.7299	1.8138	1.7071	1.2498
18	1.2193	1.2727	1.4632	1.5318	1.4632	1.2346
19	1.0059	1.0364	1.2117	1.2574	1.2269	1.0136
20	.6783	.7087	1.0364	1.0898	1.0974	.7087
21	.5487	.5868	.9602	1.0212	1.0059	.5487
22	.5106	.5487	.9374	1.0288	.9907	.5258
23	.4954	.5563	.9221	1.0212	.9907	.5182
24	.5182	.5487	.9069	1.0136	1.0059	.5182
Max	1.8595	1.89	1.7452	1.8138	1.7147	1.9433
Min	.4954	.5487	.1905	.282	.4801	.5106
Avg	1.1482	1.1577	.8904	.9183	.8831	1.1587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 202 / 11 KV SHARADANAGAR SINGLE SINGLE PHASING
PHAS Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0364	.4572	.4649	.4649	.9145	.945
2	.9983	.602	.6097	.5716	.8916	.8688
3	.7011	.6783	.6859	.6859	.6706	.6783
4	.7468	.7011	.7011	.7392	.7392	.7316
5	.7849	.7545	.7164	.7545	.7621	.7849
6	.6706	.6554	.5792	.6173	.6706	.6859
7	.4191	.4572	.5258	.4954	.5258	.5258
8	.4344	.4572	1.7452	1.6232	1.5699	.4572
9	.4801	.4496	1.7528	1.6232	1.5623	.4572
10	.503	.4725	1.7147	1.6156	1.5546	.4496
11	.4801	.4496	1.6766	1.5165	1.608	.4115
12	.442	.4115	1.7147	1.7223	1.608	.4039
13	.3887	.4268	1.8061	1.8061	1.6004	.4191
14	.4496	.4877	1.7071	1.7528	1.6232	.4572
15	.5106	.5487	1.5546	1.7452	1.5242	.4725
16	1.3413	1.4327	1.2269	1.3336	1.1507	1.3336
17	1.3794	1.4251	.8993	.8078	.8002	1.326
18	1.1279	1.3032	.7849	.7697	.7697	1.166
19	.945	1.0898	.5487	.6249	.5411	.9526
20	.8307	.9983	.4344	.442	.4268	.8688
21	.8154	.9678	.4039	.4115	.3887	.8993
22	.8154	.9602	.3963	.3963	.3963	.8916
23	.8535	.9907	.4039	.4039	.4039	.8916
24	.8688	1.0136	.4191	.4191	.4115	.8916
Max	1.3794	1.4327	1.8061	1.8061	1.6232	1.3336
Min	.3887	.4115	.3963	.3963	.3887	.4039
Avg	.7510	.7579	.9780	.9726	.9631	.7487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 203 / 11 KV YELEWASTI SINGLE SINGLE PHASING
PHASING Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4039	.7697	.7926	.7849	.4191	.4344
2	.5258	.6706	.6478	.6859	.5335	.5716
3	.5792	.6249	.6097	.6249	.6401	.6401
4	.6249	.6554	.6706	.6478	.6859	.6554
5	.6783	.6859	.6935	.6859	.7011	.7011
6	.5182	.5716	.5868	.5792	.5792	.5716
7	.381	.4877	.4801	.4801	.4801	.442
8	1.166	1.105	.4191	.4191	.4268	1.044
9	1.166	1.1279	.3582	.3582	.381	1.0593
10	1.0136	1.1584	.3201	.3582	.3963	1.0212
11	.9678	1.166	.3658	.3353	.3887	1.044
12	.4268	1.2193	.3734	.3429	.381	1.1355
13	.9983	1.2117	.3506	.3429	.4496	1.2193
14	.724	1.1736	.4344	.3963	.442	1.2269
15	1.0288	1.1279	.5563	.4649	.6173	1.1736
16	.7697	.8154	1.166	1.0898	1.0974	.8459
17	.7697	.7926	1.1584	1.0898	.9907	.8612
18	.7621	.8078	1.0822	.9907	.9602	.8078
19	.6173	.6554	.8688	.8154	.8688	.663
20	.4649	.4725	.7773	.7697	.7545	.503
21	.381	.4191	.7697	.7392	.7545	.4039
22	.3582	.3963	.7621	.7316	.7545	.3963
23	.3582	.381	.7545	.724	.7545	.3887
24	.3658	.381	.7697	.724	.7773	.3887
Max	1.166	1.2193	1.166	1.0898	1.0974	1.2269
Min	.3582	.381	.3201	.3353	.381	.3887
Avg	.6687	.7865	.6570	.6325	.6348	.7583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 204 / 11 KV 22 PHATA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8421	.2324	.2324	.221	.8878	.8116
2	.6935	.2705	.2705	.2553	.8078	.2667
3	.2858	.3086	.2934	.2972	.301	.3125
4	.3391	.3506	.3353	.3544	.3429	.3506
5	.3887	.3772	.3429	.3658	.3734	.3658
6	.3353	.3277	.2934	.3315	.3125	.3315
7	.2782	.2934	.2248	.2439	.2705	.2858
8	.2362	.2324	1.3527	1.2841	1.2574	.2286
9	.2134	.1981	1.3336	1.307	1.2993	.1867
10	.1905	.1829	1.3451	1.3032	1.3375	.16
11		.1715	1.3794	1.3298	1.3908	.1334
12		.1791	1.3641	1.3756	1.4784	.1677
13		.1791	1.4213	1.3794	1.4937	.1943
14	.2096	.2401	1.4632	1.387	1.5623	.2591
15	.1943	.3086	1.2955	1.5013	1.5508	.301
16	1.3565	1.2765	1.0974	1.1774	1.2536	1.3984
17	1.3451	1.307	.5525	.5487	.5487	1.4289
18	1.2117	1.2231	.5601	.5449	.5373	1.3222
19	1.0174	1.086	.4534	.4306	.4458	1.0822
20	.8612	.8993	.3239	.2858	.301	.9145
21	.8154	.823	.2705	.2439	.2515	.8878
22	.8078	.8002	.2362	.2172	.2248	.8688
23	.804	.8154	.2286	.2058	.2172	.8688
24	.8116	.8307	.2248	.2058	.2134	.865
Max	1.3565	1.307	1.4632	1.5013	1.5623	1.4289
Min	.1905	.1715	.2248	.2058	.2134	.1334
Avg	.6304	.5381	.7040	.6999	.7775	.5830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 205 / 11 KV KHANDAJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.1448	.1448	.1372	.644	.5754
2	.5677	.1677	.16	.1638	.6325	.5449
3	.1981	.1905	.1905	.1867	.1867	.1867
4	.221	.2324	.2172	.221	.2286	.2248
5	.282	.2667	.2401	.2515	.2515	.2515
6	.2362	.2248	.1791	.2134	.2172	.2058
7	.1486	.1486	.1334	.1372	.1638	.1372
8	.1257	.1105	1.0288	1.0098	.9221	.0991
9	.1181	.1029	1.0822	1.0555	1.0593	.08
10	.1143	.0914	1.0974	1.025	1.0555	.0686
11		.0914	1.0936	1.0707	1.0707	.0762
12		.0914	1.1546	1.0898	1.1393	.0762
13		.0991	1.1317	1.1279	1.1812	.08
14	.1372	.1181	1.1012	1.1126	1.1279	.1143
15	.1753	.1677	.9983	1.0555	.9983	.1562
16	.8688	.7735	.8269	.9069	.8345	.8459
17	.9335	.8612	.3163	.3201	.3086	.9678
18	.8383	.8078	.3353	.3277	.3163	.9069
19	.7125	.6859	.2705	.2934	.282	.7621
20	.6249	.583	.1943	.221	.2058	.6821
21	.5868	.5563	.16	.1638	.1638	.6516
22	.5563	.5716	.1486	.1524	.1448	.644
23	.5563	.5639	.141	.1448	.141	.644
24	.5525	.5716	.1372	.1448	.1372	.644
Max	.9335	.8612	1.1546	1.1279	1.1812	.9678
Min	.1143	.0914	.1334	.1372	.1372	.0686
Avg	.4346	.3426	.5201	.5222	.5589	.4011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.

Feeder No / Name : 204 / 11 KV NIMBODI SINGLE SINGLE PHASING
 PHASING Feeder KV- 11 /
 OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	.2972	.3201	.3277	1.0212	1.2574
2	1.1355	.3582	.4039	.4039	.9831	1.1812
3	.5411	.4572	.5258	.5106	.5487	.503
4	.6249	.6478	.602	.6401	.6401	.6249
5	.6783	.724	.6478	.7164	.7316	.7011
6	.5411	.5487	.5335	.5792	.5639	.5487
7	.3658	.3277	.3506	.381	.3963	.4039
8	.2896	.3048	1.6766	1.6842	1.6385	.3048
9	.2667	.2362	1.7833	1.7147	1.6994	.2515
10	.2667	.1829	1.8595	1.7071	1.8595	.2134
11	.2591	.1753	1.9052	1.768	2.0119	.221
12		.2134	1.9814	1.8976	2.1033	.2515
13		.2667	1.9281	1.9814	2.0881	.3125
14	.3582	.3429	1.9509	1.9204	2.0424	.442
15	.5563	.503	1.9662	1.9128	1.8976	.5868
16	1.6994	1.7452	1.3336	1.5927	1.5927	1.7756
17	1.8519	1.829	.9145	.9374	.8916	1.9738
18	1.5546	1.5394	.9374	.9602	.8993	1.6613
19	1.2574	1.2117	.6859	.7164	.6859	1.2498
20	1.1355	1.166	.5106	.5335	.4649	1.0822
21	.9907	1.044	.3429	.3734	.3734	.9907
22	.9297	1.0288	.2972	.3125	.3125	.9831
23	.9221	1.044	.2896	.3048	.3125	.9983
24	1.0288	1.044	.2896	.3048	.3201	1.0136
Max	1.8519	1.829	1.9814	1.9814	2.1033	1.9738
Min	.2591	.1753	.2896	.3048	.3125	.2134
Avg	.8345	.7183	1.0015	1.0075	1.0866	.8138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 201 / 11 KV KAMBALESHWAR SINGLE SINGLE PHASING
PHAS Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6112	.5769	.1867	.1989	.1844	.775
2	.6203	.57	.1844	.1974	.1859	.7567
3	.6234	.57	.1875	.1981	.1852	.743
4	.6158	.5777	.2004	.2096	.2012	.7125
5	.6333	.6203	.2469	.2644	.2431	.7316
6	.727	.7057	.3521	.3887	.3688	.8642
7	.8612	.8612	.4466	.4595	.4672	1.0189
8	.8932	.9252	.4306	.4329	.4169	1.0418
9	.7385	.6828	.9511	1.1119	1.0623	.8764
10	.2294	.2599	1.2696	1.3161	1.31	.2522
11	.1524	.1951	1.3923	1.3862	1.3405	.1608
12	.141	.1844	1.3748	1.4045	1.3565	.1631
13	.0754	.1638	1.4137	1.2064	1.2986	.1585
14	.1166	.1623	1.3771	1.2696	1.2529	.1471
15	.1242	.1456	1.3077	1.2414	1.2452	.1181
16	.1585	.1417	1.2894	1.2247	1.2033	.112
17	.1806	.1677	1.121	1.028	.9137	.0564
18	.1905	.2347	.1677	.1837	.2187	.2225
19	.3445	.3262	.301	.317	.3155	.3406
20	.3574	.3696	.3628	.3688	.3917	.3727
21	.3368	.3452	.3742	.365	.378	.3582
22	.2881	.3094	.3163	.3102	.3155	.2972
23	.599	.2469	.2423	.2538	.7682	.7171
24	.5891	.1936	.1997	.189	.7827	.7324
Max	.8932	.9252	1.4137	1.4045	1.3565	1.0418
Min	.0754	.1417	.1677	.1837	.1844	.0564
Avg	.4253	.3973	.6540	.6469	.6836	.4887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 203 / 11 KV BARAVNAGAR SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.2096	.4854	.487	.4976	.2027
2	.2134	.208	.4656	.4702	.4915	.2027
3	.2141	.2172	.4763	.4763	.4877	.2263
4	.266	.2667	.4915	.5083	.5365	.2629
5	.3894	.3925	.5799	.5761	.5952	.3871
6	.5571	.5799	.7232	.7446	.7049	.5403
7	.6531	.6638	1.0113	1.0715	1.0067	.6661
8	.647	.6508	1.1713	1.2109	1.1081	.6325
9	.9335	1.073	.9419	1.0113	1.0059	.9168
10	1.1492	1.246	.3894	.3353	.3948	1.1355
11	1.2102	1.2894	.3056	.2911	.3132	1.1949
12		1.169	.2301	.1943	.2103	1.0639
13	1.134	1.1264	.1913	.1776	.1981	1.1035
14	1.1721	1.0921	.1684	.1776	.1867	1.0052
15	1.1927	1.0143	.1471	.1699	.176	.9343
16	1.1736	.9739	.1791	.2225	.1959	.9374
17	.8695	.7331	.2187	.2492	.2591	.66
18	.3445	.3391	.269	.3193	.3384	.3132
19	.4877	.4595	.4009	.5007	.5083	.487
20	.5647	.5091	.4931	.5144	.5479	.5571
21	.4603	.4336	.4847	.4115	.4252	.4108
22	.3765	.3643	.3727	.3269	.3567	.3635
23	.2949	.5167	.5396	.5175	.2843	.2949
24	.2225	.5205	.5228	.5335	.2271	.2119
Max	1.2102	1.2894	1.1713	1.2109	1.1081	1.1949
Min	.2103	.208	.1471	.1699	.176	.2027
Avg	.6407	.6687	.4691	.4791	.4607	.6129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 206 / 11 KV PATILWASTI SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6051	.6798	.2309	.2362	.2073	.6333
2	.615	.6005	.2439	.2477	.2279	.6516
3	.6341	.6013	.2599	.2736	.266	.6767
4	.7057	.6615	.346	.3734	.3506	.7385
5	.8269	.7468	.4603	.4824	.4542	.8078
6	.9381	.8238	.5114	.5289	.4702	.9381
7	.932	.8276	.4839	.4832	.4702	.932
8	.3673	.3064	.9076	1.0753	1.0669	.413
9	.2225	.2103	1.0844	1.1805	1.0883	.2515
10	.2103	.208	1.169	1.291	1.2239	.2126
11	.1006	.1776	1.0943	1.2582	1.2231	.1806
12		.1646	1.0014	1.1965	1.0242	.16
13	.003	.1547	1.0517	1.1469	1.0181	.1616
14	.2164	.1684	1.0593	1.0265	1.0326	.1699
15	.2164	.2218		.9648	1.0303	.1829
16	.234	.2263	.1318	.317	.2576	.2164
17	.3224	.2637	.2644	.2675	.2797	.301
18	.3917	.3978	.3528	.4031	.4169	.3887
19	.3841	.3864	.3871	.3955	.3986	.3833
20	.365	.3635	.3742	.3597	.3483	.3315
21	.3018	.3216	.3399	.3467	.3071	.3025
22	.7019	.25	.2553	.253	.6943	.7125
23	.6897	.2263	.234	.2172	.6257	.7026
24	.676	.218	.2279	.2065	.6203	.7057
Max	.9381	.8276	1.169	1.291	1.2239	.9381
Min	.003	.1547	.1318	.2065	.2073	.16
Avg	.4635	.3836	.5422	.6055	.6293	.4648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 201 / 11 KV SALOBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1561	1.2216	.0492	.085		1.1957
2	1.1542	1.2216	.048	.0869		1.1854
3	1.1492	1.2178	.0507	.0899		1.1831
4	1.1023	1.2052	.0503	.0899		1.15
5	1.0357	1.2125	.0518	.0895		1.1325
6	1.049	1.2167	.0663	.0899	.0324	1.1614
7	1.1492	1.2906	.0812	.101	.0556	1.2548
8	1.233	1.3314	.085	.0934	.0735	1.358
9	1.0399	1.0764	1.4262	1.5059	1.5531	1.1759
10	.0465	.0594	1.704	1.7116	1.7379	.0271
11	.029	.0442	1.7539	1.808	1.7055	.0267
12	.0019	.0545	1.8355	1.8061	1.7482	.045
13	.0476	.0533	1.8164	1.7882	1.7429	.0251
14	.037	.056	1.7715	1.7345	1.7025	.0423
15	.0457	.0556	1.8012	1.6922	1.6636	.0446
16	.0358	.0518	1.7543	1.6427	1.611	.0118
17	.0541	.0522	1.3904	1.2997	1.1797	.0385
18	.0495		.0553		.0682	.048
19	.0553	.0488	.072		.0735	.0663
20	.0648	.0553	.0838	.0004	.0739	.0869
21	.0602	.0583	.0827	.0011	.0754	.0774
22	.0545	.053	.0831		.0747	.0682
23	1.2395	.0507	.0854		1.2163	1.2433
24	1.2239	.0514	.0869		1.2098	1.2868
Max	1.2395	1.3314	1.8355	1.808	1.7482	1.358
Min	.0019	.0442	.048	.0004	.0324	.0118
Avg	.5464	.5104	.6785	.8272	.9262	.5806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 202 / 11 KV YAMAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1539	.1448	1.6629	1.5867	1.7246	.1578
2	.144	.1517	1.643	1.5592	1.5897	.1562
3	.1547	.1524	1.643	1.5554	1.6042	.1608
4	.157	.1593	1.6217	1.5447	1.6194	.1745
5	.1631	.1829	1.6316	1.595	1.6232	.1852
6	.1928	.2141	1.6804	1.6248	1.6583	.208
7	.2378	.25	1.816	1.7467	1.7688	.2408
8	.221	.221	1.9486	1.8816	1.8176	.2301
9	2.0492	1.9723	1.3192	1.2178	1.249	1.8968
10	2.2779	2.1811	.1593	.157	.1699	2.2779
11	2.3304	2.2946	.1501	.1478	.1661	2.3167
12	1.8366	2.3632	.1425	.1608	.1692	2.2756
13	2.0675	2.4326	.1425	.1593	.1616	2.2611
14	2.2314	2.4006	.1448	.1699	.1623	2.268
15	2.2794	2.2779	.1334	.1715	.157	2.2573
16	2.3076	2.2641	.1303	.1616	.1578	2.2375
17	1.5135	1.5775	.144	.1219	.1478	1.48
18	.1379	.1402	.141	.1837	.16	.1623
19	.2111	.2012	.1928	.2149	.2035	.1913
20	.2172	.2256	.205	.2301	.234	.2119
21	.218	.2225	.189	.2355	.2324	.2126
22	.2027	.2202	.1974	.1951	.2202	.2042
23	.1852	1.6865	1.6339	1.7535	.1943	.1859
24	.1532	1.6667	1.6148	1.7345	.1684	.1631
Max	2.3304	2.4326	1.9486	1.8816	1.8176	2.3167
Min	.1379	.1402	.1303	.1219	.1478	.1562
Avg	.9018	1.0668	.8453	.8379	.7233	.9215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 203 / 11 KV NAGESHWAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.6546	.6805	.711	.644	.6638
2	.6211	.6424	.6531	.6805	.6226	.6394
3	.615	.6401	.6523	.6798	.6295	.6356
4	.6211	.6562	.6539	.6783	.6485	.6386
5	.6767	.7103	.7103	.7369	.7004	.7034
6	.8665	.948	.9305	.9785	.865	.9953
7	1.166	1.1515	1.153	1.1385	1.0501	1.1477
8	1.1888	1.2071	1.1667	1.1218	1.1264	1.182
9	1.0616	1.0814	1.1027	1.0021	1.0791	1.0844
10	.9831	.9092	.9503	.9877	1.0006	.9404
11	.884	.8436	.9282	.868	.9488	.8817
12	.6371	.8429	.8299	.8718	.833	.8429
13	.8627	.823	.7407	.8063	.7682	.8238
14	.8657	.8238	.6973	.7918	.7141	.8162
15	.9183	.8512	.74	.6859	.7278	.8977
16	.9046	.865	.7263	.8284	.7331	.8612
17	.8947	.8954	.8246	.7979	.7301	.8825
18	.836	.7964	.7926	.8048	.3955	.8512
19	.9907	.9366	.9663	.9633	1.0082	.9953
20	1.0578	.996	1.012	1.0288	1.0669	1.0661
21	.9953	.9678	.9998	.9694	.9777	1.0067
22	.9907	.9351	.9617	.9457	.929	.9762
23	.8604	.8375	.8695	.8398	.8284	.8558
24	.7247	.7438	.7773	.6874	.7156	.7278
Max	1.1888	1.2071	1.1667	1.1385	1.1264	1.182
Min	.615	.6401	.6523	.6783	.3955	.6356
Avg	.8691	.8650	.8550	.8585	.8226	.8798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 204 / 11 KV PATILWASTI SINGLE SINGLE PHASING
PHASIN Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.029	.3018	.33	.3292	.0427
2	.0328	.0297	.301	.3239	.3307	.0434
3	.0335	.0335	.2995	.3269	.3285	.0465
4	.0373	.0419	.3079	.3262	.3292	.0511
5	.045	.0465	.3064	.3307	.33	.0587
6	.0518	.0556	.3094	.3368	.3406	.0671
7	.0671	.0709	.3414	.3711	.3757	.0823
8	.061	.0686	.3788	.397	.4024	.0785
9	.2835	.2743	.3506	.3711	.3917	.3635
10	.394	.4222	.0221	.0495	.045	.4832
11	.4161	.4321	.0145	.0358	.0396	.5037
12	.4298	.4176	.0107	.0274	.0312	.4908
13	.4169	.4169	.0251	.0251	.029	.4976
14	.4009	.4115	.029	.0213	.0305	.4748
15	.3925	.4153	.0274	.0236	.016	.455
16	.3993	.41	.0213	.0236	.0358	.4618
17	.3719	.3635	.0183	.0259	.0366	.4321
18	.0183	.0251	.0213	.0274	.0358	.0229
19	.0404	.0312	.0404	.048	.0427	.0457
20	.048	.0412	.0518	.0572	.0663	.0556
21	.0427	.0389	.048	.0526	.0633	.0503
22	.0396	.0351	.045	.0472	.0488	.0434
23	.0335	.2477	.2934	.3025	.045	.0366
24	.0297	.301	.3346	.3307	.0404	.0312
Max	.4298	.4321	.3788	.397	.4024	.5037
Min	.0183	.0251	.0107	.0213	.016	.0229
Avg	.1716	.1941	.1625	.1755	.1568	.2049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 205 / 11 KV TILEKARWASTI SINGLE SINGLE PHASING
PHAS Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1096	1.0753	.0617	.0884	.08	1.3977
2	1.0806	1.0349	.0617	.0884	.0793	1.374
3	1.0501	1.0166	.0617	.0876	.0793	1.3489
4	1.0555	1.0288	.0648	.0884	.0823	1.2978
5	1.0517	1.0448	.0625	.1044	.0945	1.3382
6	1.1385	1.1134	.077	.1036	.1044	1.3999
7	1.1591	1.2148	.0846	.1257	.1082	1.5379
8	1.3108	1.3062	.0937	.1082	.0975	1.6255
9	1.2475	1.246	1.3306	1.5173	1.5173	1.5371
10	.0953	.0709	1.736	1.8473	1.6819	.0899
11	.1052	.0587	2.018	2.0378	1.9349	.0899
12		.0549	2.1559	2.1399	2.0995	.0899
13		.0831	1.9197	1.9692	2.1033	.0831
14	.0602	.0815	1.9334	2.0409	2.0195	.0716
15	.0556	.0861	1.8755	1.8267	2.0972	.0701
16	.061	.0922	2.0424	1.7955	1.8709	.0823
17	.0762	.0998	1.8488	1.7741	1.643	.0846
18	.1021	.0937	.0953	.1067	.1227	.0724
19	.1151	.0046	.1158	.1341	.0922	.0793
20	.1273	.0335	.1372	.1471	.1326	.0747
21	.1288	.0671	.1341	.1372	.0991	.064
22	.0983	.0739	.125	.1318	.0754	.0503
23	1.0296	.0655	.1181	.0937	1.3474	1.355
24	1.0921	.0625	.1105	.0831	1.3954	1.4266
Max	1.3108	1.3062	2.1559	2.1399	2.1033	1.6255
Min	.0556	.0046	.0617	.0831	.0754	.0503
Avg	.6068	.4629	.761	.7740	.8732	.6934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 206 / 11KV GARMALA SINGLE SINGLE PHASING
 PHASING Feeder KV- 11 /
 OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0831	.0351	.0358	.0328	.0663
2	.0686	.0808	.0351	.0389	.0335	.0671
3	.0671	.08	.0366	.0396	.0351	.0678
4	.0655	.0815	.0389	.0427	.0373	.077
5	.0823	.0861	.0442	.0541	.0518	.0968
6	.1059	.109	.064	.0716	.0709	.109
7	.1425	.1517	.0815	.0831	.0777	.1448
8	.141	.1555	.0777	.0762	.08	.1578
9	.0922	.1235	.1067	.1014	.1113	.1296
10	.0343	.0305	.1417	.1296	.144	.0472
11	.0297	.0282	.1463	.1273	.128	.0381
12		.029	.1303	.1166	.1029	.0343
13		.0267	.1143	.1181	.0937	.0297
14	.0198	.0251	.1135	.1181	.1227	.0236
15	.0305	.0251	.1204	.1143	.1067	.029
16	.0297	.0305	.1166	.1196	.0998	.0274
17	.032	.0335	.1113	.1036	.0892	.0282
18	.0373	.0328	.0396	.032	.0351	.032
19	.0579	.0541	.0526	.0472	.0511	.0556
20	.0671	.0541	.0617	.0633	.0594	.0678
21	.0572	.0541	.0594	.0572	.0564	.0587
22	.0541	.0503	.0511	.0488	.0541	.0533
23	.0724	.045	.0419	.0404	.0693	.0732
24	.0808	.0366	.0366	.032	.0732	.0815
Max	.1425	.1555	.1463	.1296	.144	.1578
Min	.0198	.0251	.0351	.032	.0328	.0236
Avg	.0654	.0628	.0774	.0755	.0757	.0665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 201 / Paras -MIDC-

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.2934	.3315	.3772	.4077	.4725
2	.3429	.3125	.3467	.3734	.3925	.4458
3	.3544	.3163	.3429	.4115	.3925	.4382
4	.3582	.3125	.362	.3849	.381	.4458
5	.4268	.3086	.4077	.4496	.4839	.4839
6	.4534	.3201	.3582	.5335	.4992	.5182
7	.5106	.2782	.4077	.6211	.5106	.5754
8	.5258	.2858	.4268	.6592	.583	.663
9	.5068	.2858	.4458	.6363	.4954	.6211
10	.4915	.3125	.4534	.5792	.5487	.6668
11	.4992	.2972	.4039	.5144	.4801	.583
12	.442	.3277	.4611	.5525	.5182	.5335
13	.4611	.3277	.5068	.5716	.5335	.6249
14	.4725	.301	.4992	.5525	.5258	.5754
15	.423	.2743	.4496	.4725	.5144	.5677
16	.3277	.2477	.3963	.3506	.3887	.4458
17	.2896	.2896	.3277	.3429	.3544	.4153
18	.2591	.301	.301	.3315	.3277	.4001
19	.2591	.3125	.2896	.3391	.3429	.4039
20	.2743	.3277	.2896	.3277	.3772	.3963
21	.2629	.3201	.2972	.3353	.3849	.3963
22	.2667	.3125	.2858	.3353	.3658	.4077
23	.2858	.3048	.2858	.3315	.3849	.4001
24	.2743	.3277	.2972	.3201	.3925	.3963
Max	.5258	.3277	.5068	.6592	.583	.6668
Min	.2591	.2477	.2858	.3201	.3277	.3963
Avg	.3795	.3041	.3739	.4460	.4411	.4949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 204 / RUI HOSPITAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2423	.2313	.2404	.2298	.213	
2	.2206	.2122	.2218	.2191	.205	
3	.2138	.2069	.2168	.2111	.205	
4	.2111	.2088	.2172	.2092	.2042	
5	.2195	.2191	.2282	.2187	.2115	
6	.2503	.2625	.2751	.2583	.2233	
7	.2667	.2877	.2721	.2637	.2149	
8	.3045	.3045	.274	.2877	.2153	
9	.3022	.3361	.2976	.2919		
10	.3669	.3647	.3125	.2926		.3483
11	.3418	.3666	.2755	.3098		.3445
12	.3456	.3429	.2717	.3254		.3166
13	.3288	.322	.2389	.2873		.2884
14	.2957	.3022	.2462	.2717		.2732
15	.33	.3563	.2591	.3174		.3288
16	.3205	.3525	.2408	.3109		.3414
17	.3227	.3315	.234	.2869		.3166
18	.2995	.3155	.2362	.2439		.2683
19	.3365	.3323	.2824	.2683		.2995
20	.3368	.3567	.298	.2759		.2804
21	.3224	.3426	.3056	.2641		.2743
22	.3254	.3342	.3125	.2675		.2652
23	.2869	.29	.2774	.2488		.2606
24	.2587	.2633	.2522	.2362		.2256
Max	.3669	.3666	.3125	.3254	.2233	.3483
Min	.2111	.2069	.2168	.2092	.2042	.2256
Avg	.2937	.3018	.2619	.2665	.2115	.2954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214478 / 33/11 kV MIDC Baramati - II

Feeder No / Name : 202 / Water Supply MIDC
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7308	.5826	.2759	.6462	.6329	.4828
2	.6802	.5807	.2785	.6283	.6165	.5975
3	.7004	.583	.277	.5148	.583	.6028
4	.6969	.5834	.2782	.5784	.5662	.5677
5	.6874	.5811	.2797	.6085	.5925	.5914
6	.6741	.5853	.2843	.6131	.5967	.5937
7	.5453	.4839	.3045	.5506	.6596	.6238
8	.6184	.3921	.2782	.6299	.631	.6481
9	.7598	.2789	.5525	.703	.7506	.7788
10	.8192	.3037	.6958	.8798	.9175	.9701
11	.9099	.3258	.7541	1.0094	1.182	.9137
12	.8577	.3182	.7533	1.0494	1.2201	.8097
13	.8543	.2743	.7164	.9762	.9979	.7971
14	.9709	.2854	.8265	1.0894	.9968	.8364
15	1.0475	.2884	.7994	1.1294	1.1309	.9812
16	.9903	.3422	.932	1.0566	1.0307	.8829
17	.9473	.325	1.0319	.9377	1.0139	.8711
18	.8653	.2622	.9621	.865	.988	.9385
19	.7099	.2462	.7701	.7381	.7491	.767
20	.6283	.2462	.6493	.6973	.647	.6847
21	.5548	.2473	.5376	.554	.6032	.6055
22	.5681	.2763	.5403	.5651	.5445	.5689
23	.5617	.261	.5167	.6382	.5392	.5521
24	.5742	.2568	.5342	.6272	.5487	.5239
Max	1.0475	.5853	1.0319	1.1294	1.2201	.9812
Min	.5453	.2462	.2759	.5148	.5392	.4828
Avg	.7480	.3713	.5762	.7619	.7808	.7162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 201 / Shriramnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5129	.503	.5197	.5235	.5152	.4984
2	.4771	.4809	.5037	.5014	.4908	.4694
3	.4649	.4748	.4847	.4816	.474	.4633
4	.4618	.4588	.4801	.474	.4611	.4527
5	.471	.4748	.4847	.4832	.4603	.4702
6	.5441	.5464	.5571	.5548	.5182	.5639
7	.6973	.7202	.6554	.6783	.6173	.7026
8	.7636	.7941	.7118	.7278	.6889	.7651
9	.7049	.7407	.7385	.727	.695	.6889
10	.6401	.6866	.695	.6508	.6958	.6379
11	.6409	.6363	.6523	.5914	.5982	.6508
12	.6219	.6295	.6188	.5578	.5578	.6234
13	.5898	.6196	.5891	.5502	.5418	.5982
14	.6127	.6081	.5754	.5396	.5251	.5876
15	.6051	.6059	.5799	.5258	.506	.5807
16	.6318	.612	.5784	.5464	.5106	.6158
17	.6478	.6615	.599	.5617	.5296	.66
18	.6798	.6562	.5898	.5769	.5396	.6699
19	.7941	.7758	.7171	.7354	.6851	.7735
20	.8375	.8063	.7827	.7895	.7788	.8497
21	.8101	.7933	.7613	.7636	.7689	.8154
22	.7415	.7301	.7209	.7156	.6996	.7225
23	.6676	.6775	.6592	.6783	.6409	.6752
24	.5784	.5944	.586	.5784	.5464	.5784
Max	.8375	.8063	.7827	.7895	.7788	.8497
Min	.4618	.4588	.4801	.474	.4603	.4527
Avg	.6332	.6370	.6184	.6047	.5852	.6297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 202 / Desai Estate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7575	.7727	.7834	.7903	.7857	.7689
2	.7186	.7194	.7461	.7606	.7453	.7301
3	.7034	.7103	.7285	.74	.7225	.724
4	.6943	.6973	.7087	.7255	.7072	.7057
5	.708	.7179	.7339	.7537	.711	.7148
6	.8276	.8657	.8467	.8711	.7948	.8246
7	.9617	1.0227	.9076	.9922	.8657	.9777
8	1.0761	1.0783	1.0143	.9976	1.0197	1.0921
9	1.0037	.9892	1.0021	.9663	.9633	.993
10	.916	.9389	.9747	.9511	.9435	.9099
11	.8642	.8612	.9107	.8627	.8436	.9031
12	.7819	.8581	.8535	.7834	.8101	.8474
13	.7598	.8154	.8116	.8375	.7773	.8375
14	.7758	.8467	.8223	.8185	.7857	.8497
15	.7918	.8101	.7796	.8009	.772	.7849
16	.8055	.8169	.7956	.8421	.7705	.8032
17	.8055	.8269	.8147	.8291	.7651	.7948
18	.8505	.8055	.8276	.8055	.7545	.8345
19	.977	.9252	.9785	.9701	.9031	1.0189
20	1.1279	1.1401	1.1416	1.1629	1.0761	1.1881
21	1.1096	1.1294	1.0783	1.1492	1.0883	1.1363
22	1.0372	1.0524	1.0425	1.0654	1.0456	1.0722
23	.9694	.9983	.9831	.9915	.9808	1.0219
24	.849	.8756	.884	.8787	.8604	.8833
Max	1.1279	1.1401	1.1416	1.1629	1.0883	1.1881
Min	.6943	.6973	.7087	.7255	.7072	.7057
Avg	.8697	.8864	.8821	.8894	.8538	.8924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048]

BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 203 / Ashoknagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.4344	.4527	.4374	.4527	.4291
2	.41	.4115	.4222	.4176	.4176	.4016
3	.3978	.4039	.4031	.4009	.4184	.3925
4	.3902	.4062	.4039	.3978	.413	.3833
5	.4054	.4222	.4024	.3993	.4039	.3993
6	.4626	.4816	.4778	.4656	.4557	.4733
7	.5487	.5495	.5167	.5091	.458	.5464
8	.599	.618	.5601	.5601	.535	.586
9	.5624	.57	.5403	.57	.5296	.5578
10	.5784	.6013	.5716	.5182	.5304	.538
11	.5601	.6417	.5479	.5571	.5075	.6043
12	.5853	.66	.5144	.5586	.5152	.615
13	.5868	.6386	.5441	.5746	.5235	.6333
14	.5662	.6409	.5182	.5441	.5007	.6417
15	.6028	.612	.5121	.5274	.4938	.6417
16	.6424	.66	.5418	.5525	.487	.6584
17	.6516	.7232	.599	.551	.5418	.6516
18	.6097	.6447	.5655	.5586	.5296	.6043
19	.7369	.7811	.7346	.756	.6988	.8238
20	.8063	.7903	.775	.8208	.7293	.8421
21	.7735	.7659	.7103	.7613	.6912	.8055
22	.6866	.6577	.631	.6767	.6089	.679
23	.5746	.5891	.5731	.5716	.5418	.5838
24	.4862	.4931	.4931	.5114	.4588	.4755
Max	.8063	.7903	.775	.8208	.7293	.8421
Min	.3902	.4039	.4024	.3978	.4039	.3833
Avg	.5688	.5915	.5421	.5499	.5184	.5820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 204 / T.C. College

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9496	.9579	.9648	.9884	.9549	.9404
2	.8977	.9099	.9229	.9381	.9023	.8833
3	.8825	.884	.8985	.9099	.8825	.8878
4	.9869	.9678	.9701	1.0082	.961	.9427
5	1.0113	1.0166	1.0593	1.038	1.0014	1.0265
6	1.1858	1.2384	1.2254	1.2353	1.1401	1.1812
7	1.4632	1.499	1.3496	1.448	1.323	1.4982
8	1.5752	1.6004	1.56	1.4815	1.4213	1.5371
9	1.4525	1.4518	1.5409	1.419	1.4198	1.4319
10	1.4518	1.4236	1.5371	1.4083	1.3405	1.3824
11	1.4251	1.406	1.5051	1.3778	1.3626	1.3283
12	1.2765	1.3702	1.3824	1.342	1.3291	1.2742
13	1.3001	1.3634	1.3077	1.3466	1.2254	1.2841
14	1.278	1.3291	1.3009	1.2856	1.1683	1.3062
15	1.2833	1.3375	1.2971	1.3207	1.1363	1.3047
16	1.3756	1.3405	1.3618	1.3999	1.1104	1.3169
17	1.3679	1.3641	1.342	1.3565	1.1538	1.3893
18	1.4335	1.3824	1.358	1.4426	1.1606	1.3603
19	1.6354	1.6156	1.5493	1.685	1.4259	1.6438
20	1.864	1.8686	1.8732	1.8915	1.6865	1.8945
21	1.8099	1.768	1.8153	1.8122	1.6354	1.8572
22	1.448	1.5516	1.4236	1.39	1.3908	1.5318
23	1.326	1.3908	1.3367	1.2833	1.2529	1.358
24	1.1142	1.1203	1.1332	1.1073	1.057	1.0898
Max	1.864	1.8686	1.8732	1.8915	1.6865	1.8945
Min	.8825	.884	.8985	.9099	.8825	.8833
Avg	1.3248	1.3399	1.3340	1.3298	1.2267	1.3188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 205 / Khandobanagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0768	1.1233	1.1073	1.1279	1.1667	1.0288
2	1.0402	1.0875	1.054	1.0844	1.1172	.9983
3	1.0357	1.0623	1.0311	1.0753	1.0806	.9922
4	1.0227	1.0623	1.0319	1.0646	1.073	.9884
5	1.0799	1.1416	1.1111	1.1187	1.134	1.0486
6	1.3176	1.403	1.3504	1.3664	1.2864	1.2925
7	1.5516	1.5981	1.5051	1.5745	1.4548	1.5409
8	1.7063	1.7581	1.7025	1.6751	1.6309	1.7421
9	1.6156	1.6697	1.6202	1.6484	1.6895	1.6735
10	1.5219	1.5516	1.5851	1.6537	1.5752	1.5554
11	1.5424	1.5417	1.4007	1.5813	1.5463	1.6164
12	1.4601	1.4876	1.4701	1.5188	1.5188	1.4982
13	1.2978	1.4586	1.4548	1.4586	1.5112	1.4487
14	1.2902	1.3535	1.4198	1.3062	1.3291	1.4098
15	1.4083	1.4472	1.4281	1.483	1.438	1.4952
16	1.5447	1.4746	1.4784	1.5074	1.3809	1.4967
17	1.5379	1.4998	1.5158	1.5737	1.3999	1.4693
18	1.6392	1.592	1.5836	1.672	1.3992	1.5996
19	1.9715	1.8983	1.9799	1.9936	1.7688	1.9334
20	2.0416	1.9806	1.986	2.0957	1.8991	2.0469
21	1.8374	1.8031	1.7878	1.8991	1.7467	1.8054
22	1.6758	1.6644	1.6819	1.7474	1.5478	1.64
23	1.5066	1.5272	1.5127	1.5028	1.3702	1.451
24	1.275	1.2727	1.2955	1.2948	1.1309	1.1919
Max	2.0416	1.9806	1.986	2.0957	1.8991	2.0469
Min	1.0227	1.0623	1.0311	1.0646	1.073	.9884
Avg	1.4582	1.4775	1.4622	1.5010	1.4248	1.4568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 206 / Avchat Estate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1035	1.1035	1.1218	1.1492	1.0989	1.0471
2	1.038	1.0425	1.0639	1.0547	1.0364	.9907
3	1.0075	1.0212	1.044	1.0288	1.0014	.9785
4	.9861	.9968	1.0166	1.0136	.9968	.9556
5	1.0136	1.0181	1.0578	1.0517	1.0075	.977
6	1.2041	1.2376	1.2391	1.2087	1.1523	1.1751
7	1.3626	1.3717	1.358	1.3672	1.2803	1.358
8	1.3794	1.4053	1.3199	1.3367	1.2422	1.4038
9	1.3184	1.3413	1.3336	1.3062	1.2757	1.3474
10	1.3977	1.4693	1.4601	1.3916	1.3032	1.39
11	1.5242	1.5714	1.5638	1.512	1.3702	1.512
12	1.5607	1.5546	1.544	1.4906	1.3885	1.5516
13	1.5851	1.5912	1.5364	1.544	1.4038	1.5379
14	1.6019	1.6126	1.4891	1.5165	1.3824	1.5699
15	1.5745	1.5653	1.4891	1.5135	1.3016	1.5333
16	1.5867	1.6095	1.5623	1.4937	1.2772	1.5546
17	1.6766	1.6537	1.6141	1.5516	1.3123	1.6049
18	1.7086	1.6994	1.6476	1.6065	1.3519	1.6796
19	2.0988	2.0668	2.0393	2.0485	1.6446	2.0668
20	2.1994	2.2024	2.178	2.2116	1.8138	2.21
21	2.053	2.021	2.0149	2.0287	1.7055	2.0424
22	1.7406	1.7071	1.7116	1.6888	1.5699	1.6751
23	1.4861	1.4784	1.4845	1.483	1.4129	1.4342
24	1.259	1.262	1.3077	1.2666	1.1965	1.2407
Max	2.1994	2.2024	2.178	2.2116	1.8138	2.21
Min	.9861	.9968	1.0166	1.0136	.9968	.9556
Avg	1.4778	1.4834	1.4666	1.4527	1.3136	1.4515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 207 / Lakhewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0922	.112	.7072	.7285	.7659	.1357
2	.0922	.1052	.7072	.7446	.7674	.1395
3	.0975	.1075	.7293	.7545	.7712	.144
4	.1036	.1151	.7263	.7522	.7872	.1486
5	.1181	.1509	.7438	.7735	.8451	.192
6	.1951	.1959	.807	.8124	.8718	.2149
7	.2286	.2362	.913	.9595	.9549	.2507
8	.2385	.2218	1.0258	1.0639	1.0616	.2462
9	.4824	.5769	1.0075	1.0722	1.0517	.6028
10	.9823	.9732	.1311	.1654	.1463	.9777
11	1.0212	.9922	.1113	.1288	.1357	.9793
12	1.0501	1.0059	.0998	.1227	.1204	1.0219
13	.9419	1.0105	.08	.1204	.1189	1.0372
14	.9328	.9503	.0892	.1174	.1181	1.0265
15	1.0189	.9457	.0914	.1135	.1067	1.0166
16	1.0654	.961	.0236	.1151	.112	.9732
17	1.0501	.9717	.1128	.128	.1174	.9556
18	.1097	.1097	.1097	.1334	.1311	.1158
19	.1654	.1517	.141	.1768	.1539	.1638
20	.2042	.1959	.1821	.2096	.1898	.2096
21	.1753	.173	.189	.2004	.1783	.1951
22	.1585	.1494	.1547	.1768	.1517	.1593
23	.125	.5068	.4999	.4915	.1341	.1334
24	.1166	.711	.711	.74	.1341	.1242
Max	1.0654	1.0105	1.0258	1.0722	1.0616	1.0372
Min	.0922	.1052	.0236	.1135	.1067	.1158
Avg	.4486	.4846	.4206	.4500	.4136	.4652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214409 / 33 KV PIMPRI BK

Feeder No / Name : 202 / Ozare -Pimpri Bk-

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4496	2.553	2.7572	2.6551	.4207
2	.4603	.5167	2.5499	2.7831	2.6368	.4618
3	.4908	.567	2.5987	2.7938	2.5895	.5517
4	.6036	.6874	2.6033	2.8243	2.5804	.6341
5	.8291	.8688	2.6932	2.9325	2.6993	.8627
6	.9252	.8581	2.9172	3.1337	2.8304	.9633
7	.9633	.8657	3.1611	3.3882	3.1916	.9907
8	.9374	.9435	3.2648	3.4598	3.1291	.8261
9		3.3897	.6188	.6691	.6508	3.4492
10		3.5696	.5213	.5289		3.8546
11	2.3076	3.6976	.3673	.4024	.4862	3.9552
12	3.2251	2.9935	.3033	.3902	.4222	3.7906
13	3.2129	3.1763	.3307	.2225	.3399	3.629
14	3.2038	3.1367	.3094	.1463	.2896	3.4934
15	3.3562	3.2266	.2881	.2972	.3246	3.4751
16	3.3333	3.0498	.3841	.4039	.41	3.4476
17	2.998	.3125	.3993	.4801	.4237	.4405
18	.5929	.5304	.4999	.567	.5487	.6234
19	.8733	.8048	.7849	.7179	.7377	.8124
20	.8017	.8154	.7346	.6584	.7987	.7712
21	.6417	.6752	.6142	.5304	.602	.628
22	.5335	.5365	.5975	.5228	.5335	.5014
23	.4451	2.5636	2.7511	2.6307	.4313	.4191
24	.4313	2.588	2.7603	2.6612	.4085	.4191
Max	3.3562	3.6976	3.2648	3.4598	3.1916	3.9552
Min	.4191	.3125	.2881	.1463	.2896	.4191
Avg	1.4357	1.7010	1.4419	1.4959	1.2922	1.6425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214409 / 33 KV PIMPRI BK

Feeder No / Name : 203 / LIS -Shriram Lift-
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	24-FEB-17	25-FEB-17
HR	Load (MW)	Load (MW)
8		.0023
9		.0488
16	.0091	
Max	.0091	.0488
Min	.0091	.0023
Avg	.0091	.0256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON

Feeder No / Name : 203 / Rakhunde Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1067	.1219	.1067	.1219	.1219
2	.1067	.1067	.1372	.1219	.1219	.1372
3	.1067	.1219	.1524	.1372	.1372	.1524
4	.1067	.1372	.1829	.1677	.1677	.1677
5	.1219	.1524	.1981	.1981	.1677	.1829
6	.1524	.1524	.0914	.1524	.1677	.1677
7	.1372	.0914	.1372	.1524	.1372	.1677
8	.1372		.1219	.1372	.1219	.1524
9	.1372	.0914	.1372	.1219	.1067	.1524
10	.1067	.1067	.1372	.1524	.1067	.1219
11	.1067	.0762	.0914	.1524	.1372	.1219
12	.1219	.1067	.0914	.1677	.1372	.1524
13	.1219	.1372	.1677	.1677	.1677	.1524
14	.1219	.1372	.1829	.1677	.1981	.1677
15	.1219	.1067	.1829	.1829	.1981	.1372
19				.0305		
20				.1372		
21	.1067	.1067	.1372	.1372	.1524	.1524
22	.1067	.1067	.1372	.1219	.1372	.1524
23	.0914	.0914	.1219	.1219	.1219	.1372
24	.0762	.0914	.1067	.1219	.1067	.1067
Max	.1524	.1524	.1981	.1981	.1981	.1829
Min	.0762	.0762	.0914	.0305	.1067	.1067
Avg	.1147	.1126	.1388	.1408	.1428	.1476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214426 / 33/11KV KATI S/STN

Feeder No / Name : 203 / Shetphal Haveli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4725	.4725	.4801	.4649	1.3565	1.4022
2	.5258	.5487	.5487	.5411	1.1507	1.326
3	.6173	.6249	.6173	.6249	.5868	.6173
4	.7621	.8154	.7621	.8002	.7164	.8154
5	.945	.9145	.8993	.8993	.8535	.945
6	.8154	.7926	.7545	.7621	.7164	.8535
7	.5716	.5106	.4801	.5487	.4954	.6325
8	.4725	2.1033	2.0881	2.2177	2.2024	.4801
9	.442	2.2786	2.0805	2.3472	2.3472	.4268
10	.3353	2.2481	2.1414	1.9814	2.2329	.3658
11	.3353	2.3396	2.1414	2.2634	2.3091	.3506
12		2.4158	2.21	2.4844	2.4539	.0991
13	.3734	2.3853	2.4539	2.5453	2.5758	
14	.3963	2.6216	2.5606	2.4768	2.492	
15	.6554	2.4463	2.5758	2.3853	2.4768	.5639
16	2.4158	1.6461	1.9128	1.8138	1.7909	2.5987
17	2.4844	.9983	.9907	1.0212	.9526	2.8349
18	2.0805	.9221	.9755	1.0136	.9374	2.4006
19	1.5394	.8535	.8688	.9297	.8612	1.7604
20	1.2574	.663	.6783	.7087	.663	1.4861
21	1.1736	.5258	.5411	.602	.5487	1.3489
22	1.1812	.4649	.4877	.5335	.4649	1.3336
23	1.2117	.4572	.4801	.4877	.442	1.326
24	1.2269	.4649	.4801	.4801	.4496	1.3565
Max	2.4844	2.6216	2.5758	2.5453	2.5758	2.8349
Min	.3353	.4572	.4801	.4649	.442	.0991
Avg	.9692	1.2714	1.2587	1.2889	1.3365	1.1511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214426 / 33/11KV KATI S/STN

Feeder No / Name : 204 / 11 kv Pandharwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.7468	.8612	.8383	.2134	.2667
2	.2896	.3658	.3048	.3353	.282	.3201
3	.3658	.3734	.3353	.3277	.3658	.4039
4	.4725	.4649	.3963	.4344	.4725	.4725
5	.4725	.4725	.4268	.4877	.4954	.4954
6	.3429	.3353	.2972	.3734	.3506	.3201
7	.2591	.2896	.2439	.3125	.2743	.2515
8	1.3413	.2362	.2134	.282	.2515	1.2955
9	1.3489	.1981	.2058	.1829	.2286	1.3032
10	1.4556	.1981	.2134	.1677	.2439	1.4708
11	1.5165	.2134	.221	.1448	.2286	1.6994
12	1.5851	.2439	.2362	.1829	.2362	1.7071
13	1.669	.1981	.2591	.2286	.2439	1.608
14	1.608	.3048	.3048	.2667	.282	1.7071
15	1.4403	.3277	.4268	.3582	.3658	1.547
16	.4496	1.5699	1.8747	1.3946	1.829	.5639
17	.5335	1.7223	1.8823	1.9204	1.6004	.5868
18	.5487	1.4327	1.3565	1.547	1.3717	.5335
19	.4115	1.0288	.9602	1.0898	1.0288	.4268
20	.282	.7697	.8535	.9069	.8459	.282
21	.2362	.6173	.8002	.7926	.7621	.2439
22	.2286	.6173	.7849	.7926	.8078	.2286
23	.2286	.6173	.7926	.8154	.8459	.2134
24	.2058	.6783	.7926	.8459	.8307	.2058
Max	1.669	1.7223	1.8823	1.9204	1.829	1.7071
Min	.2058	.1981	.2058	.1448	.2134	.2058
Avg	.7487	.5843	.6268	.6262	.6024	.7564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN

Feeder No / Name : 201 / Loni

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5394	.7011	.6249	.6554	1.6156	1.6613
2	1.5242	.8078	.7773	.8078	1.5699	1.6309
3	.9755	.945	.823	.945	.8993	.9145
4	1.1584	1.1126	1.0059	1.1279	1.0364	1.1431
5	1.326	1.1888	1.1279	1.2498	1.1584	1.2651
6	1.2498	1.1736	1.0669	3.2617	1.0822	.5639
7	1.1126	.8688	.8535	3.3989	2.2253	.9755
8	1.0364	.7468	2.1948	3.1093	2.5149	.9145
9	.884	.7011	2.8045		2.2558	.823
10	.8535	.7011	2.7282		2.6978	.7926
11	.7773	.7773	2.8045		2.6978	
12		.7773	2.8959		2.9569	
13		.884	2.9721		3.1398	
14	.3353	.945	2.7892		3.3227	
15	.9907	1.0212	2.0424	.3506	3.3074	.7468
16	1.89	2.0119	2.2253	2.6368	2.6673	2.2558
17	2.2558	2.5758	1.2651	1.326	1.3565	2.6825
18	1.9966	2.3472	1.2651	1.2498	1.2193	2.5301
19	1.6766	1.9204	1.1431	1.0822	1.1279	2.1186
20	1.5242	1.6461	.9297	.8383	.8688	1.8595
21	1.4175	1.5242	.8383	.7316	.7926	1.6613
22	1.4022	1.448	.7468	.6554	.6859	1.6156
23	1.4175	1.4632	.7011	.6401	.6554	1.5851
24	1.4632	1.5089	.6859	.6097	.6554	1.6004
Max	2.2558	2.5758	2.9721	3.3989	3.3227	2.6825
Min	.3353	.7011	.6249	.3506	.6554	.5639
Avg	1.3094	1.2416	1.5546	1.3709	1.7712	1.4670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN

Feeder No / Name : 203 / AGOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3567	.3521	1.5836	1.6491	.9922	.4176
2	.3719	.3658	1.5668	1.6644	1.6156	.4298
3	.4039	.3841	1.5775	1.7436	1.7894	.4283
4	.4512	.4633	1.6842	1.7802	1.9067	.4725
5	.5274	.5609	1.8168	2.021	2.0729	.602
6	.631	.695	2.1247	2.3503	2.553	.7225
7	.6828	.8368	2.8608	2.8608	3.2343	.7865
8	.6554	.8032	2.8974	3.0529	2.9279	.7331
9	2.8121	2.7923	.57	.4938	.7727	3.2419
10	3.2449	2.7892	.4923	.5472	.5472	3.5269
11	3.1824	2.9538	.4679	.4923	.4512	3.533
12	3.0437	2.7481	.4207	.4268	.2561	3.4141
13	2.8227	2.4752	.3795	.4527		3.2846
14	2.4981	2.2908	.4451	.4039		3.0849
15	2.3701	2.2542	.4496	.442	.4374	2.7191
16	2.3289	2.2375	.4466	.4588	.4725	2.7511
17	.4268	.5685	.3948	.0594	.5396	.4862
18	.4679	.4451	.4679		.5716	.5914
19	.6645	.6935	.6981	.6828	.7392	.5167
20	.6676	.6401	.6676	.7545	.724	.7301
21	.5167	.5091	.5517	.599	.6264	.5761
22	.4572	.4542	.4908	.5335	.5365	.5197
23	.3841	1.547	1.6888	.4268	.4039	.4115
24	.3765	1.611	1.7147	.4009	.4009	.3826
Max	3.2449	2.9538	2.8974	3.0529	3.2343	3.533
Min	.3567	.3521	.3795	.0594	.2561	.3826
Avg	1.2644	1.3113	1.1024	1.0564	1.1169	1.4318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN

Feeder No / Name : 205 / Chandgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7926	.1829	.1905	.1905	1.105	.9602
2	.7316	.1753	.1829	.2286	.9374	.884
3	.2286	.1905	.1829	.2362	.2134	.16
4	.2515	.2286	.1905	.2515	.2515	.1905
5	.2667	.2515	.1905	.2515	.2896	.2591
6	.2743	.2439	.16		.2743	.2515
7	.2591	.2134	.1677		.2515	.2515
8	.2591	.1829	1.044	1.0898	1.166	.221
9	.2362	.1753	1.2269	1.1584	1.1736	.2134
10	.2286	.1753	1.2117	1.1965	1.1431	.1753
11	.1448	.1905	1.1965	1.1965	1.1584	
12		.2058	1.2498	1.2422	1.2422	
13		.2058	1.2346	1.2269	1.2803	
14	.1448	.2134	1.1736	1.166	1.3489	
15	.1753	.221	1.1279	1.105	1.2803	.2134
16	.9069	.8459	.7773	.9374	.8535	1.1279
17	.9374	.884	.1829	.1829	.1981	1.166
18	.8612	.8535	.1981	.2134	.2134	1.1355
19	.8154	.8154	.2058	.2134	.1981	1.0822
20	.7849	.7849	.1981	.1981	.1981	1.0822
21	.8078	.7773	.1905	.1905	.1981	1.0898
22	.8078	.7773	.1829	.1829	.1981	1.0898
23	.8078	.7849	.1753	.1905	.1981	1.0974
24	.8078	.7926	.1753	.1905	.1905	1.0898
Max	.9374	.884	1.2498	1.2422	1.3489	1.166
Min	.1448	.1753	.16	.1829	.1905	.16
Avg	.5241	.4322	.5423	.5927	.6484	.6870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S

Feeder No / Name : 204 / 11Kv Gangawalan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.2743	.2515	.3125	1.3413	1.1126
2	.8078	.3277	.282	.3734	1.4708	1.0364
3	.4191	.4344	.3506	.4191	1.5546	.3887
4	.4725	.4649	.4268	.4649	1.7071	.4877
5	.3963	.5716	.5563	.442	1.9052	.602
6	.5944	.2667	.5411		1.9357	.6249
7	.5639	.4039	.503		2.0652	.5639
8	.4649	.4039	1.4708		2.111	.4954
9	.4572	.3658	1.8823		2.1795	.4268
10	.3201	.3734	1.8519		2.1948	.3048
11		.3658	1.8595		2.2177	
12		.3506	1.5089		2.3167	
13		.3201	2.0652		2.2558	
14	.4039	.4268	1.9738		2.3015	
15	.3353	.5563	1.9433	1.0745	2.2786	.3201
16	1.2269	1.2727	1.5013	1.5927	1.9128	1.5927
17	1.4327	1.3794	.5487	.5411	.6325	1.8595
18	1.2574	1.1888	.5487	.5487	.5716	1.5851
19	1.0212	1.0212	.4115	.442	.4496	1.4022
20	.9831	.9297	.282	.3201	.3506	1.3641
21	.9297	.8916	.2591	.2667	.3277	1.2803
22	.9374	.8993	.2439	.2591	.3048	1.2803
23	.9221	.8916	.2362	.2515	.2972	1.2803
24	.9221	.8688	.2515	.2439	.3048	1.2955
Max	1.4327	1.3794	2.0652	1.5927	2.3167	1.8595
Min	.3201	.2667	.2362	.2439	.2972	.3048
Avg	.7494	.6354	.9062	.5035	1.4578	.9652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 204 / Kalewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8063	.8699	.1421	.1989	.2092	.9457
2	.8086	.8638	.144	.2027	.2111	.9408
3	.8044	.8505	.1448	.2035	.216	.9351
4	.8009	.852	.144	.2039	.2157	.9404
5	.791	.8577	.1463	.2069	.2176	.945
6	.7941	.892	.1497	.2092	.2096	.9553
7	.8806	.9838	.1486	.2141	.21	1.0364
8	.9027	.9998	.1509	.0918	.0248	1.044
9	.069	.2263	1.11	1.2121	1.1911	.1017
10	.0834	.2648	1.238	1.2696	1.1069	.117
11		.1433	1.2948	1.2597	1.2361	.1848
12		.1478	1.3108	1.2845	1.3203	.1871
13		.1604	1.3032	1.2864	1.1976	.189
14		.1658	1.2906	1.2189	1.2399	.1909
15	.117	.1825	1.3001	1.2197	1.2273	.1951
16	.2229	.1997	1.2578	1.2266	1.1927	.1947
17	.25	.2134	.1132	.1738	.1879	.2301
18	.2603	.2404	.2488	.2549	.2332	.245
19	.2587	.2237	.2462	.2686	.1604	.277
20	.2686	.2241	.2362	.2759	.2069	.2751
21	.2538	.2061	.226	.2724	.2229	.2641
22	.2153	.1962	.2282	.2583	.2481	.2157
23	.8589	.1558	.2031	.2382	.9522	.8905
24	.8722	.1421	.1962	.2248	.9576	.9065
Max	.9027	.9998	1.3108	1.2864	1.3203	1.044
Min	.069	.1421	.1132	.0918	.0248	.1017
Avg	.5159	.4276	.5406	.5615	.5998	.5170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN

Feeder No / Name : 201 / Shirsodi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	1.1736	1.0212	1.0364	.1981	.3048
2	.1067	.3048	.3506	.3506	.3201	.1067
3	.0914	.0914	.1067	.3506	.3048	.0914
4	.0914	.0914	.1219	.3658	.2286	.0152
5	.0914	.0914	.1067	.3658	.2286	.0152
6	.0762	.0914	.0762	.3658	.2134	.1067
7	.0152	.0914	.061	.1829	.0457	.1067
8	1.2955	1.326	.0762	.0762		1.448
9	1.2955	1.326	.0152	.0457		1.448
10	1.2803	1.326	.0305	.061		1.448
11	1.2651	1.326	.0305	.0762		1.4784
12	1.3108	1.3413	.0305	.0914		1.4784
13	1.2955	1.326	.0152	.0762	.0152	1.4632
14	1.2955	1.3108	.0152	.0305	.0305	1.4022
15	1.2498	1.2955	.0305	.0457	.0305	1.2498
16	.0914	.1829	1.326	1.2498	1.1584	.3048
17	.1067	.0762	1.2955	1.2346	1.2193	.2743
18	.1067	.0762	1.2498	1.1126	1.0517	.2896
19	.1067	.0762	1.2193	1.0517	1.0059	.2591
20	.0914	.0762	1.1888	1.0517	1.0059	.2591
21	.1067	.0762	1.1888	1.0212	.9755	.2591
22	.1067	.061	1.1888	1.0212	.9907	.2439
23	.0914	.061	1.1888	1.0364	1.0059	.2439
24	.0914	.061	1.1736	1.0364	1.0212	.2439
Max	1.3108	1.3413	1.326	1.2498	1.2193	1.4784
Min	.0152	.061	.0152	.0305	.0152	.0152
Avg	.4884	.5525	.5461	.5557	.5816	.6059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN

Feeder No / Name : 204 / 11kv Malwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.0533	.0533	.061	.6783	.6249
2	.5182	.0533	.061	.0838	.7087	.5563
3	.061	.0533	.0533	.0838	.7392	.0991
4	.0762	.061	.0762	.0838	.8078	.1296
5	.0914	.0838	.0762	.061	.8459	.1372
6	.0991	.0762	.0762		.884	
7	.1143	.0762	.061		.9374	.1067
8	.1067	.0686	.8612		.9831	.0457
9	.0991	.0533	1.0059		1.0593	
10	.0762	.0533	1.0517		1.0974	
11		.061	1.0898		1.1431	
12		.061	1.1279		1.1812	
13		.0686	1.1126		1.1965	
14	.1143	.0838	1.0517		1.1736	
15	.1219	.0991	.9983	.1981	1.1507	.0838
16	.7926	.823	.6554	.6706	.8535	.9678
17	.8002	.8688	.0991	.1143	.1524	1.0212
18	.7011	.7697	.1067	.1143	.1524	.8993
19	.6249	.6478	.0914	.1067	.1219	.7697
20	.5868	.5944	.0838	.0686	.0914	.7087
21	.5487	.5639	.0762	.061	.0762	.6859
22	.5411	.5639	.0686	.0533	.0686	.6706
23	.5411	.5716	.061	.0533	.061	.663
24	.5411	.5792	.0533	.0533	.061	.6783
Max	.8002	.8688	1.1279	.6706	1.1965	1.0212
Min	.061	.0533	.0533	.0533	.061	.0457
Avg	.3683	.2912	.4188	.1245	.6760	.5205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 202 / Mahadev Nagar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.663	.2591	.2591	.9069	.6249	.7468
2	.6706	.2667	.2972	1.0669	.6325	.7392
3	.3125	.2667	.282	1.1279	.2972	.2896
4	.2972	.2743	.2972	1.2346	.2972	.2743
5	.3429	.3125	.2972	1.2879	.3353	.3277
6	.3125	.2439	.2515	1.4022	.2743	.3048
7	.1981	.16	.1753	1.4327	.1829	.2058
8	.1905	.1448	.9069	1.3413	.8154	.1829
9	.1448	.16	1.1507		.9526	.1677
10	.1372	.1296	1.1279		1.044	.1677
11		.1524	1.1431		1.0974	
12		.1753	.8078		1.0974	
13		.16	1.0059		1.0745	
14	.16	.1905	1.1431		1.0898	
15	.221	.1829	1.2346	.5182	1.1203	.16
16	.884	.8078	.9831	1.0822	.9983	.884
17	1.0288	.9755	.3429	.381	.3734	1.0517
18	.8383	.7926	.3582	.3887	.3734	.8764
19	.8383	.7621	.3506	.3887	.3658	.7697
20	.7773	.724	.3353	.3353	.3277	.6783
21	.6706	.6935	.2972	.2896	.2896	.6401
22	.663	.7392	.2743	.282	.2667	.6401
23	.6401	.7087	.2743	.2667	.2515	.6097
24	.6325	.663	.2591	.2591	.602	.5563
Max	1.0288	.9755	1.2346	1.4327	1.1203	1.0517
Min	.1372	.1296	.1753	.2591	.1829	.16
Avg	.5059	.4144	.5773	.7773	.6160	.5136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 204 / 11 Kv Sardewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7087	1.8595	1.7604	.5411	.8916	.7468
2	.7621	.6935	.7849	.7087	.9069	.7392
3	.7468	.2439	.4954	.7087	.9831	.8764
4	.7621	.2515	.5563	.6935	.9983	.9374
5	.7926	.2667	.5868	.7773	.9678	.9374
6	.724	.2515	.6173	.7849	.9678	.7926
7	1.8976	.2134	.5335	.8459	.7849	.3734
8	2.7435	2.5606	.5258	.8535	.6935	2.7816
9	2.8197	2.5606	.5487	.7621	.5563	2.7664
10	2.774	2.5835	.602	.7621	.0991	2.7664
11	2.713	2.6444	.6173	.7621		2.7968
12	1.5851	2.6749	.5868	.6859		2.7968
13	2.8273	2.6825	.5411	.5944	.5868	2.774
14	2.873	2.7054	.4344	.5716	.6401	2.7816
15	2.7206	2.5911	.4115	.5792	.5792	2.5835
16	.7773	.8916	2.2405	2.1338	2.0576	.7773
17	.4344	.4115	2.2253	2.1262	2.0729	.5639
18	.6249	.7545	2.111	1.8671	1.89	.5792
19	.6401	.7926	2.0043	1.7909	1.768	.5487
20	.6325	.7697	1.8976	1.768	1.7071	.4801
21	.6325	.7621	1.9052	1.7528	1.6537	.4725
22	.6249	.7468	1.8976	1.8214	1.6004	.4649
23	.6097	.7316	1.89	1.8138	1.5927	.4496
24	.6097	.724	1.8671	1.8061	.9831	.8688
Max	2.873	2.7054	2.2405	2.1338	2.0729	2.7968
Min	.4344	.2134	.4115	.5411	.0991	.3734
Avg	1.3765	1.3070	1.1517	1.1463	1.1355	1.3606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214466 / 33/11 KV BIJEWADI

Feeder No / Name : 201 / Bijewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2041	.3125	.2286	.1143	1.326	1.3946
2	1.1736	.3201	.2743	.1372	1.2498	1.2574
3	.1219	.3353	.2439	.1372	1.1279	.2972
4	.1219	.3353	.2515		.2743	.3353
5	.1372	.3125	.2591		.2743	.3506
6	.1219	.2667	.2134		.2362	.3277
7	.1067	.2362	.1524		.1753	.2972
8	.1219	.2362	1.4784		1.7147	.282
9	.1067	.2439	1.7604		1.7756	.282
10	.1219	.2286	1.7452		1.6994	.2896
11	.1143	.2134	1.7299		1.7833	.282
12		.1981	1.7833		1.8061	.2058
13		.1981	1.7452		1.8366	.1677
14	.0914	.1829	1.6461		1.7909	.2286
15	.0991	.0914	1.1279	.5944	1.768	.1981
16	1.3489	1.3946	1.1736	1.3717	1.6537	1.3717
17	1.448	1.4861	.3506	.2743	.1372	1.6766
18	1.4022	1.4403	.3506	.2896	.1448	1.5851
19	1.3184	1.2346	.3429	.2743	.1372	1.4327
20	1.2346	1.1965	.3277	.2515	.1296	1.3565
21	1.1888	1.166	.3125	.2439	.1219	1.3184
22	1.1812	1.166	.3125	.2362	.1219	1.3108
23	1.1965	1.166	.3125	.2362	.1219	1.3184
24	1.2041	1.1812	.3125	.2362	.1219	1.3336
Max	1.448	1.4861	1.7833	1.3717	1.8366	1.6766
Min	.0914	.0914	.1524	.1143	.1219	.1677
Avg	.6893	.6309	.7681	.3382	.8970	.7875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 301 / BHIGWAN

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.4446	3.8409	4.2067	
2			3.3227	3.719	4.0238	
3			3.2312	3.597	3.8714	
4			3.2312	3.5361	3.9018	
5			3.2007	3.597	3.9018	
6	.2134	.2439	3.597	3.9323	4.2676	.1829
7	.7316	.7621	4.542	5.1821	5.2126	.7316
8	.884	.7621	5.5175	6.0357	5.8223	.8535
9	3.0788	2.9264	5.3041	5.7004	5.6089	1.1279
10	6.7673	6.7368	.6401	.7011	.4572	6.7673
11	6.8892	6.8587	.6401	.2134	.4268	7.4074
12		5.6394	.5792		.4572	7.4684
13		4.7554	.2134			7.4684
14	5.3346	5.9747				7.255
15	6.9197	6.1576				6.4624
16	6.5539	5.4565				7.194
17	5.9137	5.0907	.4268			7.0111
18		.0914	.6706		.1829	
19	.6706	.5792	.6706	.7011	.6706	.3963
20	.823	.7316	.6401	.7926	.823	.7621
21	.823	.6706	.5792	.7011	.8535	.7011
22	.5182	.2439	.5487	.5792	.7316	.1829
23	.6401	1.5851	2.0729	2.0119	.3353	
24		3.5056	3.9018	4.2981		
Max	6.9197	6.8587	5.5175	6.0357	5.8223	7.4684
Min	.2134	.0914	.2134	.2134	.1829	.1829
Avg	3.1174	3.0932	2.2369	2.8905	2.5419	3.8733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 302 / 22 kv KHANOTA BHIGWAN SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7071	1.768	11.5836	11.6751	11.4922	1.8595
2	1.7071	1.7985	11.3398	11.2178	11.2483	1.8595
3	1.7375	1.829	11.2788	11.1569	11.0959	1.89
4	1.829	1.9509	11.0349	11.0654	11.0044	2.0424
5	2.1033	2.1948	11.3093	11.2178	11.4312	2.3167
6	2.5606	2.4996	12.1323	12.0409	12.3152	2.7435
7	2.7435	2.8349	13.1992	13.2907	13.5041	2.9874
8	2.4996	2.6825	14.6015	14.2966	14.6929	2.6216
9	6.1881	6.3405	14.2966	13.4431	14.2966	4.7249
10	15.6379	16.1256	1.6461	1.5851	1.768	15.1197
11	16.0037	15.7598	1.2193	.8535	1.3108	15.3026
12	16.3085	11.1264	1.0364	.9755	1.1279	15.2721
13	2.1338	9.6632	.9755	.9145	1.0364	15.9732
14	15.5159	15.5464	1.0669		1.0364	15.9427
15	15.9732	15.1502	.9755	.2134	1.1279	15.6684
16	15.6074	13.4431	1.0059	1.1584	1.1584	16.0342
17	12.742	14.2052	1.2803	1.4022	1.3717	15.4855
18	1.3413	1.4022	1.3413	1.5851	1.5851	1.5851
19	1.768	1.7985	1.5242	1.89	1.9509	1.6766
20	2.4691	2.3472	2.2862	2.3472	2.3777	2.3777
21	2.4387	2.3777	2.2558	2.3472	2.3472	2.4387
22	2.2558	2.3167	2.2253	2.1948	2.2253	2.3167
23	2.1033	5.365	6.1271	5.1821	2.2253	2.3472
24	1.7985	11.858	11.9799	11.4007	1.8595	1.6766
Max	16.3085	16.1256	14.6015	14.2966	14.6929	16.0342
Min	1.3413	1.4022	.9755	.2134	1.0364	1.5851
Avg	6.1322	6.7660	6.1551	6.2371	5.6496	6.7609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 303 / Bhigawan GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2606	.2865	.0808	.0854	.0777	.2515
2	.2622	.2743	.0808	.0838	.0762	.2484
3	.2591	.2759	.0823	.0823	.0777	.2484
4	.2652	.2804	.0854	.0854	.0808	.2393
5	.2774	.2926	.0884	.0945	.0899	.2469
6	.3048	.3185	.1021	.1052	.1128	.2743
7	.3795	.4268	.1341	.1357	.1326	.346
8	.2698	.506	.128	.0945	.1204	.442
9	.2256	.2362	.2393	.2119	.192	.1981
10	.0823	.0869	.282	.3871	.4344	.096
11	.0823	.0823	.5121	.0762	.4725	.0869
12	.0777	.0762	.5091	.3353	.4496	.0686
13	.0823	.0518	.4893	.474	.4298	.0686
14	.0869	.064	.4588	.4557	.3978	.0625
15	.0823	.0594	.4207	.1509	.3673	.0686
16	.0793	.0533	.3963	.4085	.349	.0671
17	.0854	.061	.2286	.2408	.1616	.0823
18	.0914	.0671	.0671	.0747	.0686	.0808
19	.0899	.1006	.0838	.0701	.0777	.0777
20	.1143	.1204	.1219	.1174	.1021	.0914
21	.1052	.1052	.1189	.0991	.0899	.0884
22	.093	.096	.1082	.0884	.0884	.0854
23	.1738	.0884	.093	.0808	.1555	.1265
24	.3003	.0808	.0854	.0747	.2469	.2469
Max	.3795	.506	.5121	.474	.4725	.442
Min	.0777	.0518	.0671	.0701	.0686	.0625
Avg	.1721	.1704	.2082	.1714	.2021	.1622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 201 / TAWASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6249	1.0822	.9831	1.0136	.602
2	.724	.7468	.9831	.9983	.9755	.7392
3	.8383	.884	.8916	.8688	.8993	.8307
4	1.0059	.9526	.9602	.9526	1.0059	.9755
5	1.0288	1.0059	.9602	1.044	1.044	1.044
6	.8002	.8002	.7316	.8078	.8078	.8383
7	.4877	.602	.5487	.5944	.5563	.5716
8	1.448	1.5242	.5258	.5182	.5106	1.387
9	1.7147	1.6537	.4191	.4344	.4572	1.5089
10	1.6461	1.608	.4115	.4191	.4115	1.5089
11	1.2346	1.7604	.3887	.4191	.4268	1.6156
12	1.5013	1.7375	.3887	.4496	.4344	1.6613
13	1.8061	1.6842	.3887	.2972	.4877	1.829
14	1.7452	1.829	.4801	.3887	.5868	1.8519
15	1.7452	1.8671	.6097	.4954	.381	1.8519
16	1.1736	1.5165	.9678	.9221	1.8061	1.7756
17	1.2879	1.2117	1.2346	1.9433	2.0043	1.7071
18	1.387	1.2879	1.2269	1.7985	1.6461	1.3717
19	1.1736	1.0517	1.0593	1.326	1.2422	1.166
20	.9526	.8307	.8459	1.1279	1.0745	1.0517
21	.7926	.6935	.7011	1.044	.9678	1.0059
22	.7164	.6249	.6249	1.0364	.9221	.9907
23	.6859	.6173	.5944	1.0364	.9221	.9831
24	.6783	.5944	.5944	1.0593	.9221	.9907
Max	1.8061	1.8671	1.2346	1.9433	2.0043	1.8519
Min	.4877	.5944	.3887	.2972	.381	.5716
Avg	1.1327	1.1545	.7341	.8735	.8961	1.2441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 202 / SAPKALWADI (THORATWADI SINGLE PHASING
OLD) Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1829	.4954	.4801	.4649	.1677
2	.221	.2439	.4268	.4344	.4268	.2286
3	.2896	.2743	.282	.2667	.3048	.2743
4	.2896	.2972	.2972	.3353	.3277	.3125
5	.3429	.3125	.3201	.3506	.3582	.3277
6	.2743	.2972	.2591	.2667	.282	.2591
7	.2058	.2058	.1677	.1981	.221	.2058
8	.5944	.6097	.1829	.1677	.1753	.5487
9	.602	.6401	.1677	.1219	.1372	.5639
10	.5487	.6554	.1372	.1219	.1372	.5411
11	.4268	.6249	.1524	.1067	.1143	.5411
12	.6097	.6706	.16	.1372	.1219	.5639
13	.6706	.7087	.1677	.16	.1524	.5944
14	.6935	.7392	.1677	.2058	.1981	.6859
15	.6935	.7697	.2058	.2591	.2591	.6706
16	.4801	.5792	.3277	.6097	.7392	.7316
17	.442	.4725	.4191	.8002	.8459	.6859
18	.4801	.4649	.4496	.7087	.6706	.602
19	.4039	.3734	.4039	.5944	.602	.5411
20	.2743	.2515	.2743	.503	.5182	.4801
21	.2134	.2058	.2058	.4649	.4725	.4572
22	.1753	.1829	.1829	.4572	.4649	.4496
23	.1753	.1677	.1753	.4572	.4649	.4572
24	.1677	.1677	.1829	.4725	.4877	.4649
Max	.6935	.7697	.4954	.8002	.8459	.7316
Min	.1677	.1677	.1372	.1067	.1143	.1677
Avg	.3941	.4207	.2588	.3617	.3728	.4731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 203 / 11 kV Jamb SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.5449	.1715	.1715	.1753	.5982
2	.4611	.4915	.1943	.1981	.2096	.5106
3	.2782	.2401	.2629	.2477	.2553	.2667
4	.301	.282	.2858	.3048	.2896	.2896
5	.3163	.301	.2972	.3315	.3125	.3125
6	.2629	.2477	.2248	.2667	.2477	.2401
7	.1562	.1486	.1562	.1677	.16	.1791
8	.1334	.1257	.7583	.8154	.8307	.1181
9	.0953	.1067	.743	.8497	.8421	.0914
10	.0838	.1029	.7621	.8345	.865	.0914
11	.0838	.0953	.823	.8459	.9183	.0838
12	.0038	.08	.9145	.8802	.9412	.0838
13	.0876	.0953	.9145	.9107	.9602	.0838
14	.1219	.1219	.9221	.8993	.8993	.1219
15	.1943	.1905	.884	.8802	.5106	.1791
16	.7354	.7849	.8802	.5868	.3125	.3163
17	.8421	.865	.7849	.3963	.4001	.4191
18	.7583	.7735	.6897	.4382	.4306	.4306
19	.6516	.6135	.6363	.3772	.3582	.3696
20	.5944	.5182	.5716	.2515	.2743	.282
21	.5487	.4954	.5373	.2058	.202	.2058
22	.5411	.4839	.5258	.1829	.1715	.1753
23	.5258	.4763	.5335	.1715	.1715	.1677
24	.5258	.4801	.5449	.1715	.1638	.1715
Max	.8421	.865	.9221	.9107	.9602	.5982
Min	.0038	.08	.1562	.1677	.16	.0838
Avg	.3663	.3610	.5841	.4744	.4542	.2412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 204 / 11 KV UDMAI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0381	.0381	.0305	.0381	.0381
2	.0305	.0343	.0305	.0343	.0495	.0267
3	.0648	.0648	.0648	.0686	.0686	.0724
4	.0686	.0686	.0686	.0686	.0686	.0724
5	.0724	.0686	.0648	.0648	.0648	.0724
6	.0495	.0343	.0419	.0419	.0419	.0457
7	.0343	.0343	.0305	.0343	.0381	.0419
8	.0343	.0267	.0267	.0305	.0267	.0305
9	.0267	.0305	.0343	.0343	.0305	.0343
10	.0267	.0343	.0343	.0343	.0343	.0305
11	.0038	.0343	.0343	.0343	.0343	.0305
12		.0381	.0343	.0343	.0343	.0305
13		.0381	.0305	.0381	.0381	.0267
14	.0648	.0686	.0686	.0648	.0762	.0572
15	.0686	.0686	.0686	.0457	.0229	.0686
16	.0686	.0686	.0762	.0533	.0724	.0648
17	.0381	.0343	.0533	.0495	.0495	.0419
18	.0343	.0305	.0229	.0381	.0381	.0343
19	.0305	.0305	.0343	.0343	.0305	.0343
20	.0343	.0305	.0343	.0343	.0305	.0343
21	.0343	.0305	.0343	.0343	.0305	.0381
22	.0381	.0305	.0381	.0343	.0305	.0343
23	.0381	.0305	.0381	.0343	.0305	.0381
24	.0381	.0305	.0381	.0381	.0305	.0343
Max	.0724	.0686	.0762	.0686	.0762	.0724
Min	.0038	.0267	.0229	.0305	.0229	.0267
Avg	.0423	.0416	.0434	.0421	.0421	.0430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 205 / KURAWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.3032	.7468	.7545	.7773	1.1888
2	1.2879	1.2955	.8612	.8459	.8612	1.1584
3	.9678	.8993	.9221	.9297	.9069	.8916
4	1.044	1.0517	1.0745	1.0669	1.0212	.9907
5	1.1279	1.1507	1.1279	1.166	1.1584	1.1355
6	.9526	.9755	.9145	1.0136	.9983	.9602
7	.6173	.724	.5716	.7011	.5868	.7392
8	.5335	.6097	1.5242	1.5242	1.4556	.6554
9	.4877	.5411	1.7833	1.6842	1.5699	.5487
10	.4344	.5182	1.8519	1.6842	1.547	.4877
11	.3963	.4877	1.8976	1.7375	1.6004	.4725
12	.4039	.4725	1.9433	1.9509	1.7147	.4801
13	.4572	.503	1.8976	2.1414	1.89	.5563
14	.663	.5335	1.89	2.1872	1.9814	.6706
15	.8078	.8002	1.829	2.1033	1.547	.884
16	1.7909	1.9281	1.989	1.7528	1.5927	1.2193
17	2.3015	2.2024	1.829	1.3489	1.3184	1.4022
18	2.1872	2.1567	1.6461	1.4327	1.4098	1.4556
19	1.829	1.8442	1.5242	1.2955	1.2879	1.3184
20	1.4784	1.4861	1.326	1.0212	1.0364	1.0288
21	1.3717	1.3184	1.2955	.8307	.8916	.8688
22	1.3413	1.2651	1.2346	.7773	.7926	.7773
23	1.3108	1.2651	1.2422	.7392	.7392	.7621
24	1.3108	1.2955	1.2574	.724	.724	.7468
Max	2.3015	2.2024	1.989	2.1872	1.9814	1.4556
Min	.3963	.4725	.5716	.7011	.5868	.4725
Avg	1.1006	1.1095	1.4241	1.3089	1.2254	.8916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 206 / 11KV THORATWADI (NEW) SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4115	.2896	.2972	.2972	.5563
2	.4191	.3734	.3353	.3506	.3277	.4954
3	.4877	.4572	.4191	.4344	.4344	.4572
4	.5563	.5258	.503	.4801	.5258	.5411
5	.6249	.602	.5639	.5944	.5944	.6554
6	.5639	.5182	.4877	.5258	.5182	.5563
7	.4039	.3963	.3125	.3658	.3658	.4115
8	.4039	.3506	.7164	.6173	.6097	.3125
9	.2439	.2667	.9602	.8764	.8535	.221
10	.2439	.2134	.9221	.8154	.8993	.1905
11	.2362	.221	1.0898	.9602	.945	.1981
12		.2362	1.1279	1.0517	1.0288	.2134
13		.2362	1.2346	1.1279	1.1431	.2058
14	.2667	.2286	1.2193	1.2346	1.3032	.2515
15	.4268	.4268	.8154	1.3184	.3734	.381
16	1.1126	.9374	1.1965	1.105	.8993	.5792
17	1.5546	1.5089	1.1203	.6935	.7468	.7468
18	1.3032	1.2727	.7011	.8154	.7926	.7849
19	.8993	.8154	.6325	.6935	.663	.7316
20	.6935	.5639	.5182	.4496	.4572	.503
21	.5487	.4801	.4496	.3429	.3201	.3734
22	.4954	.4572	.442	.3048	.2896	.3125
23	.4725	.4496	.4268	.2896	.282	.2896
24	.5258	.4649	.4191	.282	.282	.2972
Max	1.5546	1.5089	1.2346	1.3184	1.3032	.7849
Min	.2362	.2134	.2896	.282	.282	.1905
Avg	.5882	.5173	.7043	.6678	.6230	.4277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 201 / bhawaninagar SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.442	1.8671	2.2177	2.1414	.4191	.4344
2	.4877	1.6994	1.9509	1.7452	.4877	.4725
3	.4877	.4801	.4877	.5106	.4954	.4877
4	.6249	.5639	.5944	.602	.6173	.6249
5	.6859	.6401	.6325	.663	.6478	.6783
6	.4954	.503	.4649	.4572	.5258	.4954
7	.3201	.3353	.2972	.3125	.3887	.2896
8	2.6292	2.3015	.282	.2439	.2972	2.7054
9	2.6901	2.5987	.2439	.2591	.2667	2.8578
10	2.8959	2.6901	.2591	.2362	.2591	2.873
11	2.8883	2.774	.282	.2362	.2667	2.9645
12	2.8578	2.7435	.2972	.2515	.2743	2.995
13	2.8197	2.7664	.3048	.2743	.3353	3.0026
14	2.8959	2.7587	.381	.3582	.3734	3.1398
15	2.9797	2.7282	.5106	.4801	.4725	3.0255
16	2.1414	1.7375	2.1186	2.8349	2.6139	2.0271
17	.7087	.7621	2.7435	2.713	2.5682	.7392
18	.7087	.7468	2.4387	2.6749	2.5149	.6859
19	.6249	.6401	2.2329	2.3624	2.1338	.6249
20	.5335	.5258	2.0576	2.1948	1.9966	.5487
21	.4801	.4801	1.8747	2.111	1.9738	.4725
22	.4649	.442	1.8595	2.1414	1.9814	.442
23	.4496	.4344	1.8442	2.1795	2.0576	.4191
24	.442	.4344	1.8366	2.2177	2.1186	.4191
Max	2.9797	2.774	2.7435	2.8349	2.6139	3.1398
Min	.3201	.3353	.2439	.2362	.2591	.2896
Avg	1.3648	1.4022	1.1755	1.2584	1.0869	1.3927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 203 / Kazad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2422	.663	.6554	.663	1.2422	1.3946
2	1.044	.7697	.7468	.7164	.8764	.9297
3	.8154	.823	.7697	.7621	.8078	.8535
4	.9831	.9907	.9526	.9602	.9678	1.0364
5	1.0822	1.044	.9678	1.0364	.9831	1.0745
6	.6554	.7011	.5868	.6706	.6325	.6935
7	.381	.4039	.3658	.442	.4115	.5106
8	.2896	.3506	1.8366	1.3794	1.669	.381
9	.3277	.3048	1.8138	1.4022	1.7147	.3429
10	.3277	.2896	1.8976	1.4632	1.6766	.3506
11	.2972	.3125	1.829	1.6156	1.8747	.4039
12		.2972	2.0271	1.8366	1.9052	
13	.0457	.3353	2.332	2.1033	2.1414	
14	.5487	.5258	2.332	2.111	2.21	.5487
15	.7926	.7392	2.1567	1.768	2.0271	.7849
16	2.2329	1.9814	1.1431	1.1126	1.1584	2.3015
17	2.3015	2.0881	1.1736	1.2193	1.166	2.3777
18	1.9204	1.6842	1.1736	1.2041	1.1507	1.8747
19	1.669	1.2803	1.0136	1.0288	1.0745	1.4022
20	1.5318	1.1126	.8307	.8383	.8688	1.2879
21	1.4251	1.0517	.7392	.724	.7392	1.2727
22	1.4251	1.0364	.6935	.6783	.6706	1.2269
23	1.4175	1.0364	.6783	.6706	.6401	1.2117
24	1.448	1.0059	.6554	.6478	.6325	1.2269
Max	2.3015	2.0881	2.332	2.111	2.21	2.3777
Min	.0457	.2896	.3658	.442	.4115	.3429
Avg	1.0523	.8678	1.2238	1.1272	1.2184	1.0676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 201 / NIMSAKHAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.7506	.8421	.8154	.3544	.3544
2	.4611	.7278	.7545	.7392	.4306	.442
3	.5335	.5258	.5449	.4915	.503	.5258
4	.6173	.6325	.6097	.6097	.5639	.602
5	.7278	.6935	.6668	.7125	.6973	.6706
6	.6135	.5677	.3849	.5716	.6135	.5677
7	.3849	.3734	.4001	.3506	.3887	.3163
8	1.1927	1.2574	.3582	.2782	.1296	1.1965
9	1.3603	1.3679	.301	.2667	.2858	1.3375
10	1.3451	1.2308	.2896	.2743	.2858	1.3603
11	1.3756	1.4403	.3048	.282	.3163	1.4022
12	1.3946	1.4937	.3353	.3125	.301	1.467
13	1.4327	1.5242	.3887	.3582	.3734	1.4746
14	1.4365	.7049	.4801	.4153	.4191	1.4822
15	1.4022	1.4556	.5258	.522	.5525	1.3375
16	1.1622	1.1431	1.4975	1.4708	1.4937	1.2003
17	.8192	.8764	1.6918	1.7375	1.7414	.8192
18	.8459	.8573	1.3375	1.4975	1.4594	.804
19	.7164	.7202	1.0479	1.1774	1.0326	.724
20	.5335	.5258	.8612	.9297	.8916	.5182
21	.4115	.4115	.804	.8154	.7888	.3963
22	.381	.3849	.7773	.8154	.7773	.3658
23	.381	.3772	.7773	.823	.7849	.3467
24	.3772	.3696	.7773	.8269	.8116	.3506
Max	1.4365	1.5242	1.6918	1.7375	1.7414	1.4822
Min	.3772	.3696	.2896	.2667	.1296	.3163
Avg	.8453	.8505	.6983	.7122	.6665	.8359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 203 / 11 KV KHOROCHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3184	.5487	.5106	.4954	1.4937	1.5165
2	1.1203	.5944	.5487	.5563	1.3032	1.4022
3	.6478	.6401	.6097	.5868	.6173	.6478
4	.7849	.7849	.7849	.8307	.8307	.8612
5	.8078	.8916	.8688	.945	.8916	.9526
6	.6478	.7773	.6859	.7621	.724	.823
7	.4496	.5563	.4801	.4877	.4954	.5868
8	.4344	.4725	2.4158	1.7375	2.0348	.5716
9	.3734	.4191	2.6368	2.4691	2.4996	.5182
10	.2972	.2896	2.6444	2.5225	2.6368	.2058
11		.2972	2.7435	2.713	2.7359	
12		.3125	2.7054	2.7892	2.8045	
13		.3429	2.6749	2.2862	2.5835	
14	.3963	.381	2.4387	2.4234	2.873	
15	.6173	.6478	2.3472	2.3548	2.7664	.6935
16	2.05	2.2481	1.5318	1.7452	1.8976	2.5149
17	2.2481	2.2939	.8078	.9755	1.0669	2.6216
18	1.9357	2.05	.9221	.9983	1.0822	2.2634
19	1.5013	1.6309	.823	.9221	.823	1.8138
20	1.3413	1.4251	.7164	.7011	.6706	1.6232
21	1.2803	1.3413	.6249	.5944	.5639	1.4937
22	1.2574	1.2955	.5868	.5487	.5258	1.4632
23	1.2422	1.2803	.5639	.5411	.5182	1.4784
24	1.2498	1.3032	.5487	.5106	.5106	1.4784
Max	2.2481	2.2939	2.7435	2.7892	2.873	2.6216
Min	.2972	.2896	.4801	.4877	.4954	.2058
Avg	1.0477	.9510	1.3425	1.3124	1.4562	1.2765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 203 / KALAS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5319	.4687	1.0456	1.1759	1.3253	.5456
2	.5487	.4862	1.0471	1.1782	1.1469	.5738
3	.57	.5068	1.086	1.1934	1.1866	.5891
4	.5959	.5335	1.1637	1.2841	1.2803	.615
5	.6097	.5495	1.3039	1.5737	1.6545	.6417
6	.5944	.5357	1.6651	2.0957	2.2169	.6447
7	.7926	.7926	2.0462	2.4204	2.5553	.8337
8	1.9806	2.2291	.4565	.4824	.4466	2.4684
9	2.3663	2.4341	.4344	.4291	.3993	2.6795
10	2.4272	2.4036		.3757	.3422	2.8746
11	2.2954	2.3022	.2713	.2812	.2934	2.7755
12	2.2306	1.9395	.2789	.2797	.2561	2.7145
13	2.2458	1.9143	.2865	.3109	.2698	2.6391
14	2.1346	1.9113	.2187	.3277	.3109	2.4714
15	1.9837	1.9128	.2393	.3254	.3155	2.319
16	.1882	.1814	.2522	.2812	.3025	.2294
17	.1959	.1959	.2683	.25	.3125	.2766
18	.2317	.2538	.3307	.3185	.3132	.3399
19	.4085	.3909	.4092	.3757	.4801	.4649
20	.4649	.4519	.4832	.442	.5129	.4908
21	.4626	.4214	.4969	.4313	.5182	.4885
22	.5327	.4633	.5495	.4832	.5777	.5632
23	.5213	.599	.6607	.6638	.5312	.5365
24	.4641	1.0532	1.1637	1.31	.5274	.4961
Max	2.4272	2.4341	2.0462	2.4204	2.5553	2.8746
Min	.1882	.1814	.2187	.25	.2561	.2294
Avg	1.0574	1.0388	.7025	.7621	.7531	1.2196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 202 / 11 KV TASC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.207	2.3221	1.8099	2.0927	2.0515	2.1193
2	2.226	2.3122	1.7947	1.9578	1.9845	2.0889
3	2.2824	2.1369	1.8092	1.9585	2.0058	2.0759
4	2.3236	2.1033	1.7238	1.909	2.0683	2.069
5	2.284	2.2184	1.6705	1.9631	1.9403	2.1018
6	2.223	2.1582	1.784	2.098	1.8801	2.1117
7	2.2901	1.9799	1.7406	2.0584	1.8229	2.0767
8	2.3022	1.7825	1.7977	1.9822	1.8724	2.0721
9	2.351	1.7574	2.0027	2.1026	1.9944	2.1552
10	2.4661	1.816	2.1102	2.0591	2.0569	2.2184
11	2.5934	1.8686	2.0203	2.2634	2.2001	1.9563
12	2.4768	1.6065	2.2093	2.2649	2.2222	2.1795
13	2.4547	1.2254	2.1293	2.1376	2.1971	2.1399
14	2.4981	1.3466	2.066	2.1856	1.8625	2.0073
15	2.5309	1.3237	2.1262	2.2619	2.0553	2.1384
16	2.3495		2.2558	2.348	2.178	2.082
17	2.4326	.8505	2.1529	2.271	2.1376	2.0005
18	2.2878	.9335	2.1826	2.1399	2.0409	2.0706
19	2.3503	1.7078	2.2436	2.2817	2.1788	2.1224
20	2.3647	1.7322	2.0454	2.146	2.1262	2.0812
21	2.1773	1.7772	1.9456	2.0584	2.0889	1.9677
22	2.3739	1.8054	1.9464	2.1186	2.0553	1.8465
23	2.4448	1.8282	2.1795	2.146	2.066	1.9143
24	2.3579	1.8176	2.1895	2.1254	2.1986	2.0256
Max	2.5934	2.3221	2.2558	2.348	2.2222	2.2184
Min	2.1773	.8505	1.6705	1.909	1.8229	1.8465
Avg	2.3603	1.7570	1.9973	2.1221	2.0535	2.0676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214428 / 33/11 KV PATAS

Feeder No / Name : 201 / 11 KV Patas Gaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17
HR	Load (MW)	Load (MW)
1	2.5133	2.5377
2	2.4463	2.5042
3	2.4737	2.4463
4	2.5438	2.5941
5	2.8227	2.9188
6	3.3227	3.5101
7	4.2798	4.2006
8	4.3149	4.2234
9	1.9906	1.7863
10	1.8214	1.4815
11	1.3992	1.3885
12	1.2666	1.2894
13	.5914	1.2894
14	1.454	1.2818
15	.5517	1.3291
16		1.3885
17		1.3489
18	2.0927	1.5592
19	2.4813	1.9646
20	2.4524	2.0957
21	2.2878	2.0485
22	2.0774	1.9799
23	2.6353	2.838
24	2.5941	2.8014
Max	4.3149	4.2234
Min	.5517	1.2818
Avg	2.2915	2.2002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214428 / 33/11 KV PATAS

Feeder No / Name : 204 / 11 KV Kusegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17
HR	Load (MW)	Load (MW)
1	.7247	.7247
2	.7453	.7529
3	.8009	.788
4	.916	.8833
5	1.2483	1.201
6	1.6629	1.7162
7	1.7398	1.8846
8	1.6773	1.6972
9	1.6202	2.8342
10	3.0453	2.8799
11	3.1809	2.5621
12	2.9774	2.4859
13	.5792	2.5705
14	2.6726	2.4463
15	2.5293	2.505
16	2.7633	2.5232
17	1.1454	1.2833
18	.8032	.8215
19	1.3496	1.3359
20	1.5767	1.4228
21	1.4198	1.3832
22	1.1927	1.1576
23	.8695	.9122
24	.7377	.8139
Max	3.1809	2.8799
Min	.5792	.7247
Avg	1.5824	1.6494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214523 / 33/11 KV RAWANGAON

SUBSTATION

Feeder No / Name : 201 / 11 KV KHADKI AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.157	.1631	.0701	.157		1.2163
2	.1341	.16	.0472	.1585		1.2285
3	.1509	.064	.1036	.1585		1.2117
4	.1494	.096	.1296	.1616		1.2239
5	.1707	.0732	.1555	.1692	.1265	1.2285
6	.1814	.1707	.189	.1951	.1829	1.3992
7	.1905	.1936	.2134	.2088	.192	1.957
8	.2027	.189	.2195	.2058	.1966	2.1994
9	2.2161	2.2573	1.986	1.9814	2.207	1.7132
10	2.6048	2.7267	2.2116	2.2542	2.5682	
11	2.6856	2.8243	2.0942	2.2314	2.4798	
12	2.6612	2.7618	2.5835	2.3609	2.4097	
13	2.5606	2.5484	2.5423	2.3457	2.367	
14	2.4691	2.3213	2.5179	2.3061	2.3	
15	2.3076	2.1049	2.2878	2.0957	2.2253	
16	2.1628	1.9784	1.9997	2.0409	2.2161	
17	1.8168	1.3184	1.5181	1.4571	1.7345	.0107
18	.003	.003	.0076	.0122		.0533
19	.2103	.2195	.2027	.1936	.1539	.2027
20	.2271	.2256	.2134	.2088	.1768	.2134
21	.1951	.1981	.1859	.1844	.1494	.1905
22	.2012	.1875	.1814	.1707	.0854	.1768
23	.1936	.1814	.1707		1.2056	1.387
24	.1829	.16	.16		1.233	1.4784
Max	2.6856	2.8243	2.5835	2.3609	2.5682	2.1994
Min	.003	.003	.0076	.0122	.0854	.0107
Avg	1.0014	.9636	.9163	.9663	1.2742	1.0053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214523 / 33/11 KV RAWANGAON

SUBSTATION

Feeder No / Name : 204 / 11 KV RAWANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1699	.1616	.1608	.1646	.1646	1.1553
2	.1738	.1616	.1638	.1692	.1638	1.1004
3	.1738	.1661	.1638	.1692	.1616	1.1294
4	.1753	.1738	.1684	.1753	.1684	1.1248
5	.1715	.1753	.1707	.1837	.1776	1.1706
6	.1677	.1844	.1852	.1867	.1859	1.2033
7	.1875	.1974	.1928	.202	.205	1.3283
8	.1875	.1943	.1882	.1951	.1722	1.4182
9	1.374	1.326	1.1591	1.451	1.3672	1.2262
10	1.5516	1.5021	1.5424	1.6103	1.4838	.0983
11	1.624	1.5638	1.3123	1.624	1.5912	.0373
12	1.6286	1.6148	1.4098	1.5912	1.5867	
13	1.5409	1.6148	1.6613	1.5661	1.6621	
14	1.5112	1.5775	1.6933	1.5203	1.6438	
15	1.4662	1.5021	1.6217	1.5104	1.5447	
16	1.4213	1.3717	1.454	1.5112	1.4655	
17	1.2452	1.0898	1.233	1.1302	1.2795	.0511
18	.0914	.1029	.0968	.0678	.0838	.013
19	.1349	.1448	.0922	.1524	.1387	.1478
20	.1707	.16	.1753	.1821	.1646	.2157
21	.1539	.1646	.1555	.1608	.1555	.1882
22	.1509	.1631	.1631	.1524	.1402	.1715
23	.1562	.1707	.1669	.1593	1.0943	1.2681
24	.1608	.1585	.1608	.1616	1.153	1.3435
Max	1.6286	1.6148	1.6933	1.624	1.6621	1.4182
Min	.0914	.1029	.0922	.0678	.0838	.013
Avg	.6579	.6517	.6455	.6665	.7481	.7574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 203 / 11 Kv Handalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.4327	1.4327	1.3413	2.774	2.9569
2	1.5546	1.4937	1.5851	1.4937	2.8959	2.4691
3	1.6156	1.5089	1.6309	1.5546	1.5851	1.4632
4	1.7223	1.5242	1.6309	1.5699	1.6156	1.6156
5	1.7375	1.6156	1.6766	1.4937	1.7071	1.6766
6	1.448	1.2498	1.4175	1.2803	1.4175	1.4327
7	3.9781	1.0974	1.1736	1.0974	1.2346	.823
8	4.3439	3.4598	4.039	3.216	3.3532	1.1279
9	4.3286	.5639	3.9323	3.7952	3.719	1.0669
10	3.7799	4.0085	3.8409	3.9171	3.6427	1.0517
11	4.0238	4.0543	4.1914	4.1457	4.1305	1.0822
12	1.3108	4.1914	4.2372	4.1152	4.1305	1.1584
13		4.1457	4.5572	4.2676	4.3743	1.1584
14		3.5361	4.6334	4.2067	4.5115	1.2498
15		3.9476	4.3439	4.0238	4.3286	1.3108
16	1.4175	3.1703	3.2007	3.155	3.3989	3.7494
17	1.768	1.9814	1.9509	2.0271	1.9814	4.4963
18	1.8595	2.0271	1.9357	2.0576	1.9509	4.039
19	1.7375	1.8138	1.8138	1.829	1.7375	3.2007
20	1.5699	1.7071	1.5699	1.7071	1.5699	3.0026
21	1.4175	1.6156	1.5242	1.6613	1.4327	2.8654
22	1.326	1.5242	1.387	1.4632	1.3565	2.774
23	1.2955	1.4175	1.3717	1.4632	1.326	2.7282
24	1.326	1.4937	1.4327	1.4327	1.3413	2.7435
Max	4.3439	4.1914	4.6334	4.2676	4.5115	4.4963
Min	1.2955	.5639	1.1736	1.0974	1.2346	.823
Avg	2.1469	2.2742	2.5212	2.4298	2.5631	2.1351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 205 / Dairy Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0457	.0457	.0457	.061	.0305
2	.0457	.0457	.0457	.0457	.061	.0457
3	.0457	.0305	.0457	.0457	.061	.0457
4	.0457	.0457	.0457	.0457	.061	.0457
5	.0457	.0457	.0305	.0305	.0762	.0305
6	.061	.0305	.0457	.061	.0762	.0457
7	.061	.0457	.061	.0762	.0762	.0457
8	.061	.0457	.0457	.0914	.0762	.061
9	.0762	.061	.0762	.0762	.0914	.0762
10	.061	.0457	.0762	.061	.1067	.0762
11	.061	.061	.0762	.0762	.0914	.0762
12	.0762	.061	.061	.0762	.0914	.0914
13		.1067	.1372	.1372	.1524	.1372
14		.1219	.1372	.1524	.1372	.1219
15		.061	.061	.0762	.0457	.1067
16	.0305	.0152	.0457	.0305	.0457	.0762
17	.0305	.0457	.0457	.0457	.0457	.0457
18	.0457	.0457	.0457	.0457	.0457	.061
19	.0457	.0457	.0305	.0457	.0457	.0457
20	.0457	.0457	.0457	.0457	.0457	.0457
21	.0457	.0457	.0457	.0457	.0457	.061
22	.0457	.0457	.0457	.0457	.0305	.0457
23	.0305	.0457	.0457	.0457	.0457	.061
24	.0457	.0457	.0457	.0457	.0457	.0762
Max	.0762	.1219	.1372	.1524	.1524	.1372
Min	.0305	.0152	.0305	.0305	.0305	.0305
Avg	.0501	.0514	.0578	.0622	.0692	.0648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN

Feeder No / Name : 202 / sahajpur GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1391	.1166	.1166	.1162	.1097	.112
2	.1444	.1166	.125	.12	.1113	.1101
3	.1486	.1242	.1276	.1349	.1174	.1116
4	.1661	.1528	.1402	.1467	.1334	.1337
5	.2343	.2256	.1928	.2023	.1802	.1993
6	.301	.2854	.25	.2686	.2576	.2671
7	.2751	.2888	.2789	.277	.2839	.2587
8	.2587	.253	.2477	.2301	.2595	.2134
9	.1882	.1741	.2393	.1619	.2092	.1208
10	.1745	.1597	.2054	.1326	.1303	.0945
11	.1261	.1425	.1558	.1143	.1029	.0869
12	.0945	.1383	.1417	.1155	.0964	.0751
13		.1517	.1158	.12	.0975	.0747
14		.1585	.1128	.0972	.1002	.1052
15		.1379	.1235	.1185	.0918	.1036
16		.1669	.1513	.1395	.0876	.1372
17	.1604	.1943	.1757	.1402	.0907	.141
18	.1768	.1856	.1943	.1581	.1052	.1581
19	.2263	.2218	.2103	.205	.157	.208
20	.2275	.1962	.2119	.21	.1619	.1909
21	.1673	.1642	.1547	.1661	.152	.1547
22	.1452	.1616	.1536	.1501	.1425	.1475
23	.1296	.1414	.1372	.1242	.12	.1261
24	.1189	.1212	.1166	.109	.1162	.112
Max	.301	.2888	.2789	.277	.2839	.2671
Min	.0945	.1166	.1128	.0972	.0876	.0747
Avg	.1801	.1741	.1699	.1566	.1423	.1434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN

Feeder No / Name : 203 / 11 Kv Khamgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7901	1.9281	1.8084	1.768	1.8359	1.7703
2	1.7246	1.9296	1.7955	1.7452	1.874	1.7391
3	1.7566	1.9959	1.8549	1.7947	1.89	1.7619
4	1.8359	2.0325	1.8983	1.8717	1.9913	1.8412
5	1.9845	2.2199	2.0561	1.9555	2.1475	2.0073
6	2.2177	2.4013	2.2977	2.2298	2.3556	2.2276
7	2.319	2.5423	2.4044	2.383	2.4623	2.3144
8	2.3045	2.5492	2.4554	2.3807	2.5034	2.3274
9	2.2451	2.652	2.3122	2.3122	2.4265	2.3525
10	2.1925	2.5796	2.2024	2.3739	2.383	2.284
11	2.2321	2.553	2.4181	2.4745	2.2954	2.335
12	1.7414	2.4249	2.4707	2.4135	2.239	2.351
13		2.4143	2.4028	2.4333	2.1773	2.2961
14		2.4516	2.3868	2.4204	2.1689	2.316
15	.6706	2.412	2.4486	2.4752	2.1353	2.2977
16	2.3083	2.2878	2.4821	2.2901	2.1506	2.3297
17	2.3533	2.38	2.4989	2.4752	2.1056	2.2763
18	2.4417	2.3487	1.1614	2.3998	2.1026	2.3663
19	2.4783	2.143	2.287	2.4051	2.1346	2.3876
20	2.4493	2.2321	2.3457	2.3884	2.1978	2.4425
21	2.3525	2.1475	2.2939	2.2832	2.0782	2.2626
22	2.2184	2.05	2.1613	2.1353	2.0203	2.0782
23	2.0439	1.9502	2.0241	1.9403	1.8656	1.9342
24	1.9631	1.8328	1.7635	1.8519	1.7795	1.8031
Max	2.4783	2.652	2.4989	2.4752	2.5034	2.4425
Min	.6706	1.8328	1.1614	1.7452	1.7795	1.7391
Avg	2.0738	2.2691	2.1763	2.2167	2.1383	2.1709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 207 / 11kv Hatawalan AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.492	2.4234	2.4006	2.6063	.6859	.7316
2	2.1376	2.069	1.909	2.1262	.7087	.743
3	.7316	.7202	.6973	.7545	.7316	.7316
4	.7316	.7202	.6973	.7545	.7202	.7202
5	.7087	.743	.6973	.7316	.7202	.7202
6	.6973	.6973	.6859	.7202	.6744	.6973
7	.6744	.6744	.6744	.6516	.6973	.663
8	.6859	.7087	.6744	.663	.6859	2.9835
9	.6744	.6973	.663	.6859	.6859	3.2579
10	.7087	.6973	.7087	.6973	.6744	3.1779
11	.6859	.6859	.6973		.6859	3.5437
12	.0343	.6859	.3658		.7087	3.5322
13	.6859	.6859	.663		.7087	3.578
14	.6744	.7202	.4572		.7202	3.4751
15	.7202	.743	.7202		.7545	3.1779
16	2.6177	3.0979	2.5835		2.5949	2.4577
17	2.6863	3.0178	2.6978		2.8121	.7316
18	2.4234	2.9378	2.572	2.5377	2.6406	.7316
19	2.1605	2.6292	2.4806	2.5149	2.492	.7202
20	2.1033	2.5149	2.3891	2.3777	2.412	.6973
21	2.0576	2.4577	2.3548	2.3205	2.3891	.6744
22	2.069	2.4806	2.3663	2.3205	2.3891	.6744
23	2.0805	2.5034	2.3777	2.3663	2.5377	.6859
24	2.0919	2.5034	2.3777	2.3663	2.5835	.6744
Max	2.6863	3.0979	2.6978	2.6063	2.8121	3.578
Min	.0343	.6744	.3658	.6516	.6744	.663
Avg	1.3889	1.5756	1.4546	1.5997	1.3922	1.6575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUNG DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 202 / 11 Kv Fargade Mala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.4937	1.4175	1.4708	1.5013	.2667
2	1.2498	1.4403	1.3794	1.4556	1.4556	.2667
3	1.2651	1.4022	1.3794	1.4327	1.448	.2743
4	1.2879	1.4327	1.4022	1.4632	1.4708	.2896
5	1.3946	1.4937	1.5089	1.547	1.5546	.3201
6	1.608	1.6994	1.6385	1.6918	1.7909	.3658
7	1.7833	1.8366	2.05	1.89	2.0119	.3734
8	1.8823	1.9509	2.1186		1.9738	.3353
9		.6554	.8002		.663	2.05
10	.221	.221	.2439		.2286	2.2329
11	.2058	.1981	.2058	.2286	.1981	2.3472
12	.1981	.1905	.1753	.2134	.1905	2.2405
13		.1829	.1677	.2134	.1905	2.0957
14	.1753	.1143	.1753	.1981	.1829	2.0729
15	.1677	.1296	.1905	.2058	.1829	2.0576
16	.1905	.0991	.16	.2134	.2134	2.0957
17	.2134		.1905	.2286	.2286	.5563
18	.2058	.2286	.2439	.2591	.221	.221
19	.3353	.3201	.3506	.3429	.3048	.3506
20	.3734	.3658	.381	.381	.3582	.381
21	.3353	.3201	.3506	.3429	.3125	.3506
22	.3201	.3048	.3277	.3201	.282	.3353
23	1.387	1.4022	1.4403	1.4708	.2591	.282
24	1.5242	1.4403	1.5242	1.5546	.2591	.2743
Max	1.8823	1.9509	2.1186	1.89	2.0119	2.3472
Min	.1677	.0991	.16	.1981	.1829	.221
Avg	.8002	.8227	.8259	.8154	.7284	.9348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 206 / KHOR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.945	.7926	.884	.8993	.0914
2	.8078	.945	.7011	.8383	.823	.0914
3	.823	.884	.6859	.8078	.7621	.1067
4	.823	.8688	.6706	.7926	.7621	.1067
5	.9145	.8993	.7011	.8535	.884	.1372
6	1.0822	1.0822	.9145	1.0212	1.0059	.1981
7	1.4022	1.5699	1.2346	1.4784	1.3717	.2134
8	1.9204	2.0729	1.9357	2.0424	1.8747	.2286
9	1.9204	1.6004	1.768	1.6918	1.6004	1.0059
10	.0914	.1372	.1067	.1219	.1219	1.6461
11	.0762	.0914	.0762	.0914	.0914	1.7375
12		.0457	.061	.0762	.0914	1.6766
13	.0762	.0457	.0457	.0305	.0457	1.4784
14	.0457	.0457	.0762	.0457		1.5546
15	.1677	.0457	.0762	.061	.061	1.4937
16	.1677	.3963	.061	.0762	.061	1.448
17	.0762	.0457	.061	.0762	.0762	1.326
18	.1067	.061	.0914	.0914	.0762	.0762
19	.1372	.1219	.1067	.1372	.1219	.1372
20	.2134	.1677	.1981	.2134	.1981	.2134
21	.1981	.1372	.1677	.1829	.1524	.1829
22	.1677	.1219	.1372	.1524	.1067	.1677
23	.503	.4572	.5792	.6249	.1067	.1372
24	.9145	.823	.945	.945	.0914	.1219
Max	1.9204	2.0729	1.9357	2.0424	1.8747	1.7375
Min	.0457	.0457	.0457	.0305	.0457	.0762
Avg	.5858	.5671	.5081	.5557	.4950	.6490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214499 / 33/11 KV DAHITANE S/STN.

Feeder No / Name : 202 / 11 KV DAHITANE GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	***	***	***		***	
12	***	***	***	***	***	***
13		***	***	***	***	***
14		***	***	***	***	***
15		***	***	***	***	***
16	***	***	***	***	***	***
17	***	***	***	***	***	***
18	***	***		***	***	***
19		***		***		
24			***			***
Max	152.416	152.416	152.416	152.416	152.416	152.416
Min	114.312	114.312	114.312	114.312	114.312	114.312
Avg	144.7952	127.0133	133.364	119.075	138.127	142.89

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 301 / DSM Express

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.7063	17.223	***	***	***	3.1626
2	7.7732	16.3085	24.6914	***	***	2.6673
3	7.8113	9.5641	***	***	***	4.2295
4	6.4777	17.4516	***	***	***	5.8299
5	7.5827	***	***	***	***	5.2584
6	5.6013	***	***	***	***	5.5632
7	4.7249	***	23.9293	***	***	6.4396
8	5.487	***	22.5195	***	3.8485	8.8401
9	11.3169	***	18.5566	20.2713	5.868	14.4033
10	7.316	21.605	4.8773	19.4711	8.421	10.25
11	8.1924	15.7751	9.7927	15.4321	10.5167	13.2221
12	10.6691	16.5371	11.3931	14.1747	13.565	12.2695
13	8.3829	14.9368	10.9358	13.9461	15.394	5.144
14	8.3829	14.9368	10.5548	14.1366	15.013	5.7156
15	1.4861	13.1459	12.1171	16.2704	13.7174	4.8392
16	4.2676	8.4972	15.3178	19.5092	9.9451	18.1756
17	12.3457	13.2983	19.5855	24.539	4.8011	23.2815
18	17.9089	22.8243	20.1951	***	2.4768	23.5483
19	***	***	21.6431	***	7.9637	24.1579
20	***	21.1858	***	***	8.1543	***
21	***	***	***	***	8.0399	***
22	***	***	***	***	6.7444	***
23	***	***	***	***	5.4489	***
24	19.0901	***	***	***	4.039	***
Max	35.8559	34.3317	32.8456	33.0743	31.0929	29.5306
Min	1.4861	8.4972	4.8773	13.9461	2.4768	2.6673
Avg	13.9096	21.2335	21.3557	26.7188	14.8526	14.2620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 302 / Pepsico Express

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.2872	***	***	***	***	***
2	6.4777	***	***	***	***	***
3	6.6301	***	***	***	***	***
4	7.0873	***	***	***	***	***
5	7.2398	***	***	***	***	***
6	14.7081	***	***	***	***	***
7	17.8708	***	***	***	***	***
8	***	***	***	***	***	***
9	***	***	***	***	***	***
10	***	***	***	***	***	***
11	***	***	***	***	***	***
12	***	***	***	***	***	***
13	***	***	***	***	***	***
14	***	***	***	***	***	***
15	***	***	***	***	***	***
16	***	***	***	***	***	***
17	***	***	***	***	***	***
18	***	***	***	***	***	***
19	***	***	***	***	***	***
20	***	***	***	***	***	***
21	***	***	***	***	***	***
22	***	***	***	***	***	***
23	***	***	***	***	***	***
24	***	***	***	***	***	***
Max	48.1635	47.8205	48.0491	47.5538	46.0296	44.6198
Min	6.2872	42.7146	26.1774	34.7127	37.3419	37.4562
Avg	34.2364	45.3279	37.6102	42.2812	41.2762	41.2651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 305 / 22 KV POLYONE

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0945	.5365	.5693	.5502	.5251	.5479
2	.096	.5777	.5617	.5464	.5647	.5716
3	.0914	.5929	.57	.4763	.5312	.5799
4	.093	.5136	.5418	.5136	.5975	.5929
5	.0922	.5624	.5075	.5114	.663	.6196
6	.234	.554	.6226	.5769	.663	.6165
7	.3277	.5883	.6569	.5959	.7346	.6478
8	.3086	.5213	.5022	.5784	.6493	.6691
9	.3605	.5411	.5563	.5418	.6135	.6584
10	.5411	.6386	.5761	.663	.5563	.6988
11	.4999	.5784	.6516	.6272	.5716	.8238
12	.5296	.5723	.6981	.6234	.6501	.6554
13	.5388	.6341	.6005	.6379	.6501	.6714
14	.5761	.6386	.6371	.5632	.66	.5738
15	.5784	.6622	.6958	.6051	.6927	.6699
16	.6142	.6493	.6363	.57	.6173	.7133
17	.5769	.535	.5601	.5639	.5639	.5967
18	.4778	.5304	.5007	.5533	.5883	.5716
19	.57	.535	.4664	.551	.6257	.6226
20	.5655	.5601	.5197	.5952	.5304	.6142
21	.5114	.5441	.5213	.5975	.5144	.5876
22	.4923	.5441	.5213	.554	.4778	.5548
23	.5274	.6188	.5777	.5799	.5213	.4801
24	.5022	.5662	.5685	.4725	.5296	.4954
Max	.6142	.6622	.6981	.663	.7346	.8238
Min	.0914	.5136	.4664	.4725	.4778	.4801
Avg	.4083	.5748	.5758	.5687	.5955	.6180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214451 / 33 KV NHAVARA

Feeder No / Name : 201 / 11 KV Uralgaon
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0666	3.7113	2.8807	3.8516	3.376	.6447
2	3.0437	3.5467	3.3272	3.7266	3.3913	.6478
3	3.0316	3.5635	3.2907	3.5421	3.3242	.6706
4	3.0331	3.5559	3.1596	3.3303	3.0437	.7316
5	3.1809	3.1565	3.248	3.2891	.4496	.7804
6	3.2206	1.8549	3.5635	2.7679	2.6551	.9145
7	2.1232	1.8458	2.7313	3.0483	1.6903	.9267
9						2.9553
10						3.4202
11						2.3762
12						3.7113
13						3.6626
14						3.7494
15	.3445	.3673	.4359		.3597	3.7113
16	.4481	.4115	.5304		.3963	3.7266
17	.4496	.4252	.57	.2164	.4512	2.8639
18	.4771	.5639	.5838	.5335	.4603	.5152
19	.5883	.7667	.8337	.7697	.7697	.8048
20	.8703	.8581	.9069	.9023	.8901	.9587
21	.8261	.759	.8672	.8779	.8764	.9175
22	.7514	.7667	.8383	.7727	.791	.8169
23	2.8669	2.5225	3.3775	2.9706	.7225	.7179
24	3.5924	2.902	3.7449	3.4126	.6493	.6783
Max	3.5924	3.7113	3.7449	3.8516	3.3913	3.7494
Min	.3445	.3673	.4359	.2164	.3597	.5152
Avg	1.8773	1.8575	2.0523	2.2674	1.4292	1.7784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214514 / 33/22 kV PIMPALE JAGTAP Sub
StFeeder No / Name : 301 / 22 KV Pimpale Jagtap AG
Feeder KV- 22 / OUTGOING

SHEDDABLE RURAL

DATE	22-FEB-17	23-FEB-17	24-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9998	.9343	1.0044
2	.9907	.916	.9785
3	1.0151	.9175	1.0059
4	1.0745	1.0029	1.0501
5	1.2666	1.1858	1.2574
6	1.6613	1.5668	1.5348
7	1.8564	1.7253	1.7528
8	1.8107	1.6811	1.7314
9	3.2861	3.4979	3.6458
10	4.4246	4.2478	4.606
11	4.3393	4.1274	4.6334
12	4.3012	4.0558	4.4673
13	1.1675	3.408	4.5024
14	4.0695	1.4891	4.2158
15	4.1518		4.0847
16	4.1427	1.4937	3.9963
17	3.2724	1.4922	3.8074
18	.7651	.4496	.7758
19	1.1629	.3384	1.1248
20	1.5196	1.4449	1.4891
21	1.5043	1.4845	1.4967
22	1.3596	1.3565	1.4815
23	1.1507	1.23	1.2666
24	.9785	1.0654	1.0974
Max	4.4246	4.2478	4.6334
Min	.7651	.3384	.7758
Avg	2.1780	1.7874	2.3753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214514 / 33/22 kV PIMPALE JAGTAP Sub
StFeeder No / Name : 303 / 22 KV Industrial
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.291	1.6903	.9556	1.6278	1.259	1.0471
2	1.2544	1.7452	.9023	1.4114	1.2483	.9983
3	1.2544	1.4556	.9236	1.2483	1.2056	1.0288
4	1.2879	1.6019	.9419	1.2163	1.1355	1.0181
5	1.3077	1.3748	.9877	1.2391	1.1568	1.0242
6	1.3138	1.3474	1.0532	1.2285	1.1157	1.1507
7	1.8595	1.0883	1.5623	1.4769	1.2681	1.5745
8	2.1186		1.576	1.5501	1.39	1.6674
9	2.4112	.9556	1.5973	1.704	1.387	2.3945
10	2.3975	1.0837	1.9677		1.4998	2.143
11	2.2283	1.0319	2.0866	1.9555	1.387	2.3198
12	2.3762	.9648	1.8793	1.9997	1.3809	2.0409
13	2.2131	1.0181	1.9753	1.9662	1.3855	1.8488
14	2.4234	1.0395	1.7345	1.9555	1.2635	1.8671
15	1.8793	.977	1.5485	1.512	1.1309	1.5348
16	1.7924	1.2452	1.3748	1.5333	1.1355	1.4159
17	1.733	1.1888	1.5181	1.6903	1.0456	1.4419
18	1.7848	1.1401	1.6339	1.6507	1.0105	1.7406
19	1.7909	1.3275	1.6842	1.6613	1.1355	1.7711
20	1.8412	1.2361	1.5882	1.64	1.134	1.7452
21	1.8549	1.2757	1.6522	1.6583	1.1233	1.6994
22	1.8397	1.2833	1.608	1.6324	1.0669	1.6811
23	1.7406	1.259	1.5318	1.4891	1.0608	1.6217
24	1.643	1.0608	1.4525	1.1599	1.0242	1.8412
Max	2.4234	1.7452	2.0866	1.9997	1.4998	2.3945
Min	1.2544	.9556	.9023	1.1599	1.0105	.9983
Avg	1.8182	1.2344	1.4890	1.5742	1.2062	1.6090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 201 / 11 KV WAGHESHWAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1661	.16	.1661	.1616	.157	3.7601
2	.1692	.1616	.1677	.1646	.16	3.7525
3	.1799	.1631	.1768	.1646	.1707	3.6915
4	.1799	.1692	.1799	.1738	.1753	3.6946
5	.189	.1799	.189	.1844	.1905	3.6961
6	.1829	.1814	.192	.1799	.1905	3.8333
7	.1814	.1707	.1814	.1631	.1738	3.9445
8	.1509	.1494	.1357	.0518	.1509	3.9125
9	3.1946	4.1442	3.815	4.0192	4.2616	3.8363
10	3.7555	1.5226	4.2326	4.1076	4.478	
11	4.1655	1.6232	4.3606	4.2646	3.8653	
12	3.693	4.2204	4.039	3.9963	4.1457	
13		4.3073	4.0375	3.7814	4.3423	
14	2.809	4.2936	4.1747	3.5924	4.4216	
18		.003	.0229			
19	.0549	.093	.1128	.003		.0518
20	.1707	.1783	.1433	.0808		.1722
21	.061	.1677	.1783	.1113	.0244	.1692
22	.1661	.1814	.1875	.1799	.1616	.1799
23	.1677	.1768	.16	.1707	3.9034	3.9598
24	.1585	.1677	.157	.1555	3.8668	3.8592
Max	4.1655	4.3073	4.3606	4.2646	4.478	3.9598
Min	.0549	.003	.0229	.003	.0244	.0518
Avg	1.0419	1.0674	1.2862	1.2853	1.9355	2.8342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 202 / 11 KV SIDDHESHWAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9326	2.1735	2.2062	2.3152	2.1475	.1196
2	1.9418	2.21	2.2268	2.3129	2.1674	.1235
3	1.9509	2.2001	2.2634	2.3175	2.1613	.1273
4	1.9974	2.2085	2.3259	2.2901	2.1628	.1524
5	2.063	2.2641	2.367	2.3213	2.2687	.1669
6	2.1849	2.4615	2.5362	2.3868	2.367	.2088
7	2.5842	2.7176	2.931	2.7679	2.7305	.2774
8	2.8288	2.6665	2.9973	2.8784	2.8753	.2949
9	2.7534	2.3251	2.6719	2.3365	2.5972	2.3945
10	.1631	.1905	.1677	.1875	.1875	2.4272
11	.1334	.1494	.1654	.1547	.1692	
12	.1387	.1494	.1638	.1372	.157	
13		.1593	.141	.1212	.1486	
14	.1006	.1433	.1433	.1212	.1181	
15	.0953	.1296	.1326	.0968	.125	2.0546
16	.1044	.1036	.1059	.1143	.0808	3.0559
17	.1585	.1303	.1341	.1417	.1425	3.0712
18	.1814	.1814	.1951	.141	.189	
19	.2157	.2164	.2164	.1524	.2286	.2469
20	.2683	.2324	.2614	.1791	.2553	.2743
21	.2545	.2324	.2454	.1882	.2286	.2469
22	.221	.2088	.221	.1638	.2058	.2195
23	1.9182	2.0378	2.1346	2.095	.1814	.1997
24	2.0972	2.1773	2.3274	2.1247	.1425	.176
Max	2.8288	2.7176	2.9973	2.8784	2.8753	3.0712
Min	.0953	.1036	.1059	.0968	.0808	.1196
Avg	1.1429	1.1529	1.2200	1.1686	1.0016	.8336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 203 / Junamala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1225	1.2765	1.2932	1.3077	1.3047	.1593
2	1.1317	1.2788	1.2948	1.3001	1.3039	.1684
3	1.1393	1.2772	1.2986	1.2894	1.3077	.1768
4	1.1515	1.2475	1.3176	1.2894	1.3253	.1943
5	1.1728	1.2681	1.3649	1.3039	1.3649	.218
6	1.2651	1.3527	1.4411	1.4571	1.3999	.2629
7	1.3748	1.5676	1.6469	1.5874	1.6697	.2949
8	1.4982	1.592	1.6834	1.6446	1.6911	.2888
9	1.4601	1.2765	1.3306	1.4243	1.4716	1.4929
10	.0998	.202	.2042	.2187	.2195	1.5036
11		.1578	.1677	.1646	.189	
12		.1425	.1524	.125	.1631	
13		.1235	.1341	.1311	.1311	
14	.0998	.1235	.1257	.1341	.1204	1.406
15	.112	.1174	.1204	.1379	.1235	1.5714
16	.109	.1151	.1174	.1456	.1174	
17	.125	.1265	.1235	.1699	.1357	
18	.1578	.1501	.1448	.1738	.144	.0998
19	.208	.1997	.1943	.173	.1547	.2111
20	.2431	.2157	.221	.2004	.1997	.2263
21	.2103	.2035	.208	.2004	.221	.2172
22	.1837	.189	.2004	.1959	.2073	.2164
23	1.2148	1.2498	1.246	1.2536	.1867	.1905
24	1.2635	1.2872	1.2925	1.3176	.1699	.1669
Max	1.4982	1.592	1.6834	1.6446	1.6911	1.5714
Min	.0998	.1151	.1174	.125	.1174	.0998
Avg	.7306	.6975	.7218	.7227	.6384	.4771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33 KV NHAVERA

Feeder No / Name : 202 / 11 KV Ambale Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7644	.7407	.6577	.6706	.7148	.6798
2	.8109	.7644	.7087	.7064	.7545	.6546
3	.8307	.7682	.7415	.7125	.7263	.6737
4	.8954	.8497	.8086	.7545	.7552	.7232
5	.9892	.9938	.8962	.8924	.8779	.868
6	1.102	1.1241	1.1073	1.0921	1.0204	1.0585
7	1.2963	1.2475	1.2719	1.1485	1.1195	1.1576
8	1.1652	1.0684	1.1858	.9922	1.0684	1.0402
9	1.2346	1.0501	1.1995	1.0433	1.1789	1.2163
10	1.057	.9313	1.0524	.9755	1.025	.6661
11	.9244	.8139	.9816	.8253	.8886	.9785
12	.6783	.7476	.865	.7918	.8726	.8131
13	.554	.6569	.8215	.7385	.7903	.7545
14	.7415	.6866	.7804	.1707	.5235	.7971
15	.7461	.7141	.7682	.6691	.7819	.7819
16	.6874	.7369	.7987	.8063	.8147	.7933
17	.8124	.7659	.8063	.8398	.833	.8467
18	.9107	.7895	.8291	.82	.849	.9153
19	.8634	.8543	.8703	.9732	.8451	.9404
20	1.0212	.9892	.9625	1.0684	.9922	1.0753
21	1.0044	.9739	.9945	1.0052	.9015	1.0738
22	.9526	.9145	.932	.9427	.8703	.9747
23	.8154	.7537	.7644	.7872	.7941	.8238
24	.791	.6866	.7103	.7529	.6699	.7644
Max	1.2963	1.2475	1.2719	1.1485	1.1789	1.2163
Min	.554	.6569	.6577	.1707	.5235	.6546
Avg	.9020	.8592	.8964	.8408	.8612	.8780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33 KV NHAVARA

Feeder No / Name : 203 / 11 KV Kolape Wasti Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2865	.2843	.3231	.3224	.3125	1.9524
2	.2911	.2881	.3368	.3323	.3216	2.0066
3	.3224	.3109	.3498	.3506	.346	2.0614
4	.3742	.3681	.3841	.3902	.4054	2.1239
5	.4725	.4626	.4694	.4839	.5075	2.2901
6	.5274	.5594	.1242	.5235	.5708	2.4737
7	.3528	.5319		.4793	.3765	2.0218
9	2.6558	2.3792	2.8365	2.2253	2.6779	
10	3.043	3.03	2.9287	2.6642	2.899	
11	3.1421	3.0643	3.0369	2.7023	3.0544	
12	3.1634	2.8083	3.0735	2.8159	3.0651	
13	.2507	2.806	3.0163	2.8631	2.979	
14	2.6673	2.5972	3.0338	2.825	2.9881	
15	1.986	2.3647	3.0087	2.5438	2.6406	.2644
16	2.7282	2.4196	2.9142	2.7008	2.7481	.2736
17	1.8503	.9054	1.6926	1.7589	1.8008	.1814
18	.2347	.2804	.2241	.2119	.2774	.3681
19	.3795	.4298	.3932	.3818	.4031	.5121
20	.4778	.4877	.4504	.458	.4656	.5784
21	.4466	.4512	.4664	.4733	.4512	.5365
22	.3765	.4085	.4291	.4085	.4031	.4534
23	.3231	.3483	.3635	.3467	1.8511	2.2405
24	.2881	.3216	.3216	.314	1.8945	2.3381
Max	3.1634	3.0643	3.0735	2.8631	3.0651	2.4737
Min	.2347	.2804	.1242	.2119	.2774	.1814
Avg	1.1583	1.2134	1.3717	1.2424	1.4539	1.3339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214470 / 33/11KV JAMBUT

Feeder No / Name : 202 / 11 kv fakte

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.332	2.3929	2.7587	2.4844	.3353	.4115
2	2.21	2.0576	2.4082	2.3167	.4268	.503
3	.5639	.5792	.5639	.5792	.4877	.6249
4	.6249	.6401	.5792	.6554	.5487	.6401
5	.6706	.6554	.6554	.6706	.6554	.7164
6	.5487	.5792	.5335	.5639	.5335	.5792
7	.3963	.381	.381	.4115	.3506	.4268
8	.3506	.3963	.3201	.4268	.3658	2.8045
9	.3353	.3506	.3048	.3506	.3963	3.719
10	.3353	.3201	.2896	.3048	.4268	3.9628
11	.1981	.3048	.2896	.3048	.3963	4.0543
12	.0762	.3048	.2286	.2896	.3963	3.9018
13	.2896	.3353	.3658	.3048	.3201	3.9476
14	.3048	.3353	.4115	.4115	.381	3.8104
15	.4877	.5487	.5335	.5639	.4725	3.5665
16	2.4082	2.2862	2.6673	2.5911	2.6216	2.774
17	3.2769	3.4903	3.597	3.5513	3.5665	.6097
18	3.094	3.3684	3.1398	3.5056	3.2769	.6401
19	2.5149	2.6978	2.8349	3.094	2.8197	.5335
20	2.332	2.4082	2.3472	2.8959	2.6216	.4572
21	2.21	2.3167	2.2558	2.8349	2.5301	.3963
22	2.2253	2.3472	2.2405	2.8197	2.5453	.3658
23	2.2253	2.3777	2.1795	2.8654	2.5453	.3353
24	2.21	2.3929	2.3167	2.8959	2.5149	.3353
Max	3.2769	3.4903	3.597	3.5513	3.5665	4.0543
Min	.0762	.3048	.2286	.2896	.3201	.3353
Avg	1.3425	1.4111	1.4251	1.5705	1.3140	1.6715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214522 / 33/11 KV Nimone Sub station

Feeder No / Name : 206 / 11 KV Pimpachiwadi

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3611	1.435	1.5623	1.5996	1.544	.1753
2	1.3489	1.4319	1.5402	1.5562	1.5905	.1768
3	1.3634	1.422	1.4914	1.5539	1.5668	.1859
4	1.3618	1.4419	1.5127	1.5684	1.5097	.192
5	1.4053	1.5196	1.5867	1.6065	1.5737	.2141
6	1.5059	1.611	1.6377	1.6446	1.6354	.2644
7	1.6789	1.7345	1.6903	1.6888	1.7642	.3178
8	1.8191	1.8427	1.6972	1.8526	1.8823	.317
9	1.7642	1.7513	.3536	1.672	1.752	1.448
10	.2301	.2096	.0838	.2401	.25	1.7231
11	.1562	.1638		.1707	.1951	1.8823
12	.1204	.1311	.253	.1387	.1341	1.9372
13	.0488	.1128	.1395	.1364	.1113	1.9578
14	.1113	.0907	.1196	.1242	.0975	1.8961
15	.1265	.1044	.1128	.109	.0975	1.874
16	.1341	.0937	.1105	.0968	.0975	1.7878
17	.1349	.0953	.109	.1014	.1181	1.6011
18	.1486	.1143	.1227	.1341	.1372	.1372
19	.2248	.2248	.2012	.2195	.2362	.2279
20	.3216	.3155	.282	.3208	.3239	.3224
21	.2987	.2797	.2599	.2896	.2911	.2812
22	.2324	.2355	.2111	.2263	.2271	.2294
23	1.2971	1.3435	1.3817	1.467	.205	.2065
24	1.3999	1.547	1.6027	1.5501	.1882	.1852
Max	1.8191	1.8427	1.6972	1.8526	1.8823	1.9578
Min	.0488	.0907	.0838	.0968	.0975	.1372
Avg	.7748	.8022	.7853	.8361	.7304	.8142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 305 / MALLIKARJUN

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3567	.3704	.3612	.2911	.2911	
2	.346	.3582	.3597	.2896	.282	
3	.3384	.3688	.3628	.3003	.2865	
4	.3475	.3841	.3704	.2972	.3048	
5	.3673	.4115	.3887	.3231	.3125	
6	.4435	.4984	.4618	.4039	.378	
7	.5517	.6097	.5898	.5152	.4877	.1707
8	.5853	.6859	.6401	.6158	.5975	.0914
9	.5868	.6783	.5731	.6142	.5777	.3856
10		.1021		.0076		.5959
11						.6295
12						.6341
13						.6341
14						.6112
15						.599
16						.5853
17						.5685
19	.003	.0396				
20	.0198	.1722		.1219	.1052	.0244
21	.0015			.0015	.0213	.003
22				.0229		
23	.2957	.3094	.2058	.2652		
24	.3765	.3734	.2804	.285		
Max	.5868	.6859	.6401	.6158	.5975	.6341
Min	.0015	.0396	.2058	.0015	.0213	.003
Avg	.3300	.383	.4176	.2903	.3313	.4256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 214484 / 33 KV NIGUDGHAR

Feeder No / Name : 203 / 11 KV Raireshwar

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6973	.7659	.804	.6211	.8345	.804
2	.9183	.9678	1.0898	1.0212	1.0212	1.0021
3	1.0631	1.1546	1.3336	1.2117	1.185	1.1431
4	1.5242	1.3184	1.448	1.3146	1.2879	1.2917
5	1.5851	1.3679	1.5394	1.1546	1.2727	1.2727
6	1.5242	1.3565	1.3641	1.2879	.9145	1.1355
7	1.5508	1.4708	1.4022	1.3717	1.1698	1.0517
8	1.4632	1.3641	1.3603	1.3603	1.1584	1.0326
9	1.4251	1.2879	1.3108	1.2498	1.1203	.9945
10	1.5661	1.2117	1.3603	.5982	1.246	.9183
11	1.6804	1.3451	1.448	1.2841	1.3756	1.0936
12	1.7718	1.5165	1.5089	1.307	1.406	1.2231
13	1.8633	1.5242	1.4441	1.246	1.3413	1.2689
14	1.7337	1.5203	1.4937	1.5089	.9983	1.4289
15	1.4632	1.4518	1.4594	1.3641	1.5318	1.3108
16	1.1622	1.0631	1.1736	1.1164	1.2993	1.1584
17	.9526	.9717	.964	.9793	1.1012	1.0974
18	.7545	.7811	.7278	.8383	.804	.8383
19	.6287	.644	.6287	.6859	.6211	.6783
20	.5677	.5754	.5716	.6173	.5563	.6173
21	.5677	.5563	.5868	.6173	.5716	.6097
22	.5868	.5525	.5792	.6287	.5754	.644
23	.5868	.5639	.5716	.644	.583	.6744
24	.6059	.5982	.6592	.6821	.6059	.7202
Max	1.8633	1.5242	1.5394	1.5089	1.5318	1.4289
Min	.5677	.5525	.5716	.5982	.5563	.6097
Avg	1.1768	1.0804	1.1179	1.0296	1.0242	1.0004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 214484 / 33 KV NIGUDGHAR

Feeder No / Name : 205 / Pombardi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0023	.0023	.0023	.0023
2			.0023	.0023	.0023	.0023
3			.0023	.0023	.0023	.0023
4			.0023	.0023	.0023	.0023
5			.0023	.0023	.0023	.0023
6			.0023	.0023	.0023	.0023
7			.0023	.0023	.0023	.0023
8			.0023	.0023	.0023	.0023
9	.0015		.0015	.0015	.0015	.0023
10	.0015				.0008	.0023
11	.0015					.0015
12	.0015					.0015
13	.0015					.0023
14	.0015					.0023
15	.0015					.0015
16	.0015					.0015
17	.0015					.0015
23		.0015	.0015	.0015		
24		.0023	.0015	.0015	.0015	
Max	.0015	.0023	.0023	.0023	.0023	.0023
Min	.0015	.0015	.0015	.0015	.0008	.0015
Avg	.0015	.0019	.0021	.0021	.0020	.0021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION

Feeder No / Name : 305 / 22KV NAZARE GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5911	4.0771	2.5911	3.0102	2.6673	2.7054
2	2.3243	3.8866	2.5149	2.8578	2.4768	2.7054
3	2.2481	2.7054	2.4387	2.6673	2.2862	2.5911
4	2.4006	2.9721	2.0957	2.7435	2.2862	2.6673
5	2.4768	2.934	2.6673	2.7054	2.3624	2.6673
6	3.4675	3.8485	3.658	3.6199	3.5818	3.7342
7	4.2676	4.3058	4.1914	4.3439	4.3058	4.3439
8	4.1152	4.3439	4.1914	4.4201	4.2676	4.4582
9	3.7723	3.8104	4.0771	4.2676	4.1533	4.763
10	4.8011	3.1245	4.763	5.2202	5.3727	5.4489
11	4.6487	2.9721	5.2584	5.3727	5.5632	5.4489
12	4.9154	2.4006	4.9535	5.144	5.4489	4.9916
13	4.7249	2.0195	4.382	5.1821	4.9916	4.6868
14	3.5056	1.829	4.2295	4.4201	4.4201	4.1533
15	4.1533	2.2862	4.8011	4.9154	4.9916	4.8011
16	4.2676	2.8959	4.6487	5.3346	4.8773	5.2202
17	4.4582	2.3624	4.763	5.4489	4.4582	5.4108
18	4.0771	3.5056	4.2676	5.1059	3.8485	4.6868
19	5.2202	4.039	4.5344	5.7918	4.1533	4.6868
20	6.8206	4.8773	4.9916	6.592	4.8011	5.3346
21	5.6013	4.8011	4.3439	5.2584	4.1152	5.1821
22	5.144	4.6868	4.1914	4.3058	4.1152	4.2676
23	4.9535	3.0102	3.9247	3.315	3.2769	3.0102
24	4.4201	2.7054	3.5056	2.8197	3.0864	2.3243
Max	6.8206	4.8773	5.2584	6.592	5.5632	5.4489
Min	2.2481	1.829	2.0957	2.6673	2.2862	2.3243
Avg	4.1406	3.3500	3.9993	4.3693	3.9962	4.1787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 207 / 11KV KAMBALWADI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.1642	.1638	.1673	.1661	.0846
2	.1661	.1638	.1638	.1345	.1673	.0838
3	.1661	.1638	.1638	.1635	.1673	.0831
4	.1658	.1638	.1646	.1631	.1669	.0884
5	.1642	.1642	.1646	.1635	.1669	.1661
6	.0522	.1654	.1665	.085	.1692	.1684
7	.1661	.1688	.1688	.1738	.1749	.1696
8	.165	.1654	.1677	.1718	.1722	.1715
9	.1642	.128	.1665	.1707	.1696	.1703
10	.1715	.1688	.1665	.1139	.1684	.1722
11	.1524	.1677	.168	.0907	.1669	.1715
12	.1688	.1688	.1684	.0899	.1711	.1707
13	.1654	.1661	.1677	.0892	.1696	.1341
14	.1658	.1677	.1658	.1562	.1669	.1658
15	.1677	.168	.168	.168	.1677	.1665
16	.1684	.1402	.1718	.168	.1677	.1677
17	.1673	.1658	.1696	.1661	.1669	.168
18	.1623	.1635	.1635	.1646	.1635	.1638
19	.1635	.1642	.1646	.1658	.1638	.1646
20	.1661	.1669	.168	.1684	.0838	.1673
21	.1658	.1665	.1669	.1677	.0834	.1665
22	.165	.165	.1658	.1654	.0834	.1658
23	.1661	.1638	.1661	.1669	.085	.1665
24	.1658	.1638	.1692	.1688	.0857	.1684
Max	.1715	.1688	.1718	.1738	.1749	.1722
Min	.0522	.128	.1635	.085	.0834	.0831
Avg	.1607	.1631	.1667	.1501	.1506	.1527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 208 / Penjalwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0936	1.0547		.0549	.0503	.0549
2	1.07	.9976		.0602	.0518	.064
3	1.0181	.977		.0655	.0541	.0648
4	.9823	.9084		.0663	.0579	.0686
5	.9968	.8878		.0655	.0594	.0625
6	1.0219	.961		.061	.0587	.0625
7	1.2239	1.1104		.0617	.0602	.0754
8	1.3626	1.2315		.0648	.061	.0693
9	1.3352	1.1393		1.2742	1.0928	.0671
10	.0511	1.4975		1.9082	1.9273	.0526
11	.0488	1.5752	1.6682	1.9745	1.9311	.048
12	.0457	1.5341	2.0812	1.8541	1.9806	.0427
13	.0587	1.4601	2.0165	1.7764	2.005	.0495
14	.0587	.0503	1.8694	1.7048	1.9166	.0564
15	.0511	.0549	1.8557	1.7002	1.8237	.0572
16	.0457	.0602	1.8397	1.7154	1.7147	.0533
17	.0823	.0854	1.2422	1.6171	1.6065	.077
18	.0945	.093	.0983	.08	.096	.0869
19	.0869	.0457	.093	.0815	.093	.0854
20	.0732		.0747	.0671	.08	.0831
21	.0762		.0823	.0785	.0892	.0884
22	.0815		.0854	.08	.0869	.093
23	.6607		.0892	.0823	.0854	.897
24	1.0814		.0503	.0488	.0488	1.3291
Max	1.3626	1.5752	2.0812	1.9745	2.005	1.3291
Min	.0457	.0457	.0503	.0488	.0488	.0427
Avg	.5292	.8276	.9390	.6893	.7096	.1537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION

Feeder No / Name : 201 / 11KV PANDESHWAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2301	.2355	.2279	.2561	.234	.2241
2	.2233	.2401	.221	.2522	.2187	.2233
3	.2301	.25	.221	.2568	.2279	.2248
4	.2309	.2614	.2736	.298	.2507	.2698
5	.3285	.3406	.365	.3925	.3307	.3384
6	.5197	.535	.5014	.5929	.5449	.5335
7	.6188	.6325	.6005	.6783	.6485	.6241
8	.6142	.583	.583	.6013	.6432	.602
9	.4687	.4542	.4717	.4672	.487	.5022
10	.3056	.3338	.3361	.3246	.3254	.3483
11	.2355	.2629	.2591	.2484	.2637	.2362
12	.2172	.2035	.2301	.2271	.2172	.2035
13	.1821	.1951	.2408	.234	.2088	.2111
14	.1654	.2058	.2324	.2271	.1943	.1799
15	.1814	.2103	.2042	.2233	.1814	.1776
16	.1738	.208	.2103	.2187	.192	.1898
17	.2111	.2385	.2553	.2157	.2263	.2141
18	.2888	.2812	.269	.2599	.3071	.2705
19	.4024	.4077	.423	.4085	.4115	.4009
20	.5792	.5373	.5799	.5723	.57	.5708
21	.5601	.5136	.5228	.5357	.5243	.5487
22	.4565	.4405	.4412	.426	.4169	.439
23	.3597	.3445	.365	.3208	.314	.3155
24	.2561	.2583	.2751	.2362	.2317	.2385
Max	.6188	.6325	.6005	.6783	.6485	.6241
Min	.1654	.1951	.2042	.2157	.1814	.1776
Avg	.3350	.3406	.3462	.3531	.3404	.3369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION

Feeder No / Name : 301 / 22 KV NIRA U GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5975	.6447	.6462	.6615	.6417
2	.538	.5639	.6234	.6127	.6417	.6173
3	.5365	.5441	.602	.5838	.5898	.6097
4	.5441	.5502	.6066	.6066	.5914	.5944
5	.6112	.6112	.6676	.6783	.663	.724
6	.8002	.7712	.7788	.8703	.7849	.8535
7	1.0151	1.0044	1.0395	1.1401	1.0242	1.1279
8	1.0486	1.012	1.1218	1.1248	1.1081	1.1325
9	.9755	.8688	1.0258	.9252	.9953	.9145
10	.8291	.8657	.8871	.8733	.9145	.8474
11	.8063	.8169	.8794	.724	.8169	.7926
12	.8002	.82	.8154	.7194	.7743	.7697
13	.7941	.8109	.8261	.7788	.8261	.7849
14	.7529	.759	.7743	.7727	.8063	.7727
15	.788	.724	.7667	.7499	.7179	.7545
16	.7727	.7575	.7697	.756	.7164	.8048
17	.7636	.7788	.7346	.7468	.7011	.7941
18	.7346	.7514	.7606	.7133	.7011	.7621
19	.8261	.9648	.9496	.9358	.9297	.9572
20	.9511	1.012	.9938	.9907	1.0212	1.0136
21	.9206	.9663	.9633	.9983	.98	.9831
22	.8474	.8901	.916	.9252	.9206	.9404
23	.7956	.8017	.8276	.8398	.8337	.8596
24	.6691	.7133	.7209	.7026	.727	.7042
Max	1.0486	1.012	1.1218	1.1401	1.1081	1.1325
Min	.5365	.5441	.602	.5838	.5898	.5944
Avg	.7799	.7898	.8206	.8089	.8103	.8232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION

Feeder No / Name : 302 / 22 KV PIMPRA GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4329	.4527	.4359	.4603	.4664	.4252
2	.4237	.4344	.4237	.4405	.4496	.41
3	.4176	.4359	.4207	.4329	.442	.4176
4	.439	.4557	.4557	.4542	.4435	.4374
5	.535	.5411	.5517	.5426	.5213	.5213
6	.6752	.7042	.6859	.7118	.6889	.7194
7	.7362	.8032	.8017	.8566	.8109	.7865
8		.8078	.8474	.8017	.8932	.8551
9		.7011	.7682	.7453	.759	.695
10	.2362	.5685	.2271	.6889	.66	.6112
11	.6325	.5944	.6295	.695	.6813	.6219
12	.6371	.6173	.6249	.7148	.5822	.6005
13	.5868	.6539	.6935	.7545	.7499	.6859
14	.5472	.6142	.6203	.6584	.7316	.4161
15	.535	.631	.6066	.6478	.6219	.6127
16	.5441	.6554	.6234	.7331	.6142	.6219
17	.5335	.6051	.6127	.8063	.5898	.6432
18	.5365	.6158	.6859	.6737	.6097	.5868
19	.6904	.7133	.6981	.6325	.7057	.7468
20	.8398	.8703	.8444	.8916	.8429	.852
21	.8032	.8154	.8063	.8383	.7651	.8109
22	.6737	.6783	.6859	.7285	.6889	.7026
23	.5914	.5838	.5975	.6081	.5761	.5929
24	.4984	.474	.4999	.506	.4603	.4512
Max	.8398	.8703	.8474	.8916	.8932	.8551
Min	.2362	.4344	.2271	.4329	.442	.41
Avg	.5702	.6261	.6186	.6676	.6398	.6177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 302 / 22 KV SHIVARI AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6929	1.4707	1.4263	3.0208	3.1279	2.4447
2	1.6782	1.4704	1.4427	2.9332	2.8878	2.3046
3	1.7386	1.47	1.4606	2.8411	2.7796	2.2449
4	1.6723	1.4859	1.4764	2.9041	2.7616	2.3498
5	1.4637	1.5651	1.7092	2.8488	2.8444	2.4158
6	1.9431	1.774	1.8392	3.1552	3.0108	2.5791
7	2.424	1.9309	2.0224	3.9202	3.3404	3.022
8	2.6167	1.9457	2.0801	5.0975	4.576	3.6173
9	2.4194	1.9725	1.8889	5.0269	3.6621	3.7471
10	6.057	3.6976	1.4748	1.127	1.5642	3.4209
11	6.0018	3.8806	1.379	1.0642	1.2997	3.8007
12	5.9249	3.754	1.3012	.9703	1.2674	3.8125
13	5.3488	3.6374	1.2808	.904	1.216	3.6588
14	5.5362	3.3176	1.1716	1.252	1.2082	3.4443
15	5.0704	2.8363	1.2557	1.1968	1.1952	3.4512
16	4.9023	3.3246	1.2859	1.2394	1.2377	3.362
17	3.3112	3.5434	1.3152	1.2553	1.2718	3.4073
18	1.5292	1.4112	1.5159	1.3072	1.3503	1.5057
19	1.5719	1.6686	1.4851	1.4745	1.1474	1.6858
20	1.634	1.8194	1.868	1.795	1.391	1.9891
21	1.7234	1.8002	1.7423	1.7568	1.437	2.0039
22	1.6773	1.6445	1.7969	1.7228	1.343	1.9227
23	1.5568	1.5625	1.8124	1.6284	1.3226	1.8547
24	1.3969	1.4558	3.3656	3.2161	2.6299	1.624
Max	6.057	3.8806	3.3656	5.0975	4.576	3.8125
Min	1.3969	1.4112	1.1716	.904	1.1474	1.5057
Avg	2.9538	2.2683	1.6415	2.2357	2.078	2.7362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 303 / 22 KV KHALAD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.5784	5.5175	1.0364	.8535	.8535	1.0974
2	5.365	5.3041	1.0364	.884	.884	1.1279
3	5.2126	5.1821	1.0669	.9145	.884	1.1279
4	5.2431	5.1212	1.0974	.9145	.945	1.1584
5	5.426	5.3346	1.1888	1.0059	.9755	1.2193
6	6.31	5.8528	1.3413	1.2498	1.1584	1.4327
7	8.7182	7.2855	1.4327	1.4022	1.2803	1.4022
8	10.4557	8.6572	1.4327	1.3413	1.2803	1.3717
9	7.2855	9.6327	8.0476	8.8401	8.4134	1.0669
10	.945	10.0899	10.0595	11.2788	11.0349	.823
11	.884	10.5472	10.5167	11.0349	11.5531	.884
12	.8535	10.2119	7.5294	10.6386	11.8275	.823
13	.945	9.5108	10.4862	10.2728	11.8275	.8535
14	1.1279	9.2364	10.3033	9.8766	10.974	.7926
15	.8535	9.2669	10.3643	9.5108	10.6691	.884
16	.7926	9.2974	8.9925	9.7851	11.2788	1.0059
17	1.1888		7.5903	7.194	7.7427	1.0974
18	1.1888	.6706	1.0974	1.2193	1.1279	1.0974
19	1.2193	1.4632	1.0669	1.4327	1.1888	1.2498
20	1.3108	1.4022	1.2193	1.2803	1.2803	1.3108
21	1.3108	1.2803	1.2498	1.1584	1.1888	1.4327
22	1.3413	1.2193	1.1584	1.1584	1.0669	1.1888
23	5.487	1.0974	1.0669	1.0669	.9755	6.3405
24	5.7004	1.0059	.8535	.8535	1.0669	6.5844
Max	10.4557	10.5472	10.5167	11.2788	11.8275	6.5844
Min	.7926	.6706	.8535	.8535	.8535	.7926
Avg	3.5310	5.8342	4.2181	4.3820	4.6449	1.5572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 201 / 11 KV BABAWADI

SINGLE PHASING

SINGLEPHASING Feeder KV- 11 /
OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8031	1.9616	1.8717	1.9677	.1814	.192
2	1.7787	1.8534	1.8732	1.9723	.192	.1799
3	1.7787	1.7939	1.8046	1.9814	.1905	.1997
4	1.8061	1.7985	1.7863	1.9464	.2088	.2256
5	1.9143	1.858	1.8732	2.0378	.2667	.2835
6	2.079	2.0317	2.0942	2.0515	.3856	.3734
7	2.3228	2.4356	2.4783	2.3122	.4313	.4161
8	2.3228	2.5438	2.5332	2.5758	.3948	.3429
9	.378	.5517	.8048	.4298	2.6322	2.7282
10	.3429	.1997	.2301	.3536	2.8365	2.9645
11	.317	.1936	.1951	.3826	2.9965	2.9432
12	.3125	.2149	.1859	.3338	3.1245	3.0666
13	.3216	.1997	.1036	.3582	3.059	3.0666
14	.317	.1997	.1814	.3749	2.9752	2.902
15	.346	.1997	.1738	.2942	2.9066	2.9797
16	.3536	.2073	.1875	.2241	2.9553	2.8608
17	.317	.2317	.1905	.1997	.7545	.2362
18	.3368	.2149	.1875	.1951	.2484	.2256
19	.3749	.3551	.3475	.3734	.3582	.3506
20	.41	.3826	.3445	.3932	.3506	.3902
21	.3688	.3658	.3262	.3597	.349	.346
22	.3368	.3201	.314	.2957	.3079	.3292
23	1.8473	1.9067	1.8976	.2362	.2073	.2469
24	1.9662	1.9174	1.9753	.2088	.2042	.2195
Max	2.3228	2.5438	2.5332	2.5758	3.1245	3.0666
Min	.3125	.1936	.1036	.1951	.1814	.1799
Avg	1.0188	.9974	.9983	.9108	1.1882	1.1695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 202 / 11 KV MALSHIRAS

SINGLE PHASING

SINGLEPHASING Feeder KV- 11 /
OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5213	.4832	.4862	.474	1.1645	1.4297
2	.5243	.4938	.4816	.474	1.1325	1.4129
3	.535	.535	.5075	.4847	1.134	1.3519
4	.5853	.5639	.5716	.5487	1.1203	1.3382
5	.7209	.7057	.6828	.6798	1.1949	1.4403
6	.9374	.8596	.8703	.8932	1.3626	1.736
7	1.0059	.9389	.9846	.9846	1.9479	2.2055
8	.724	.8596	.8916	.8657	2.3	2.4752
9	1.9753	2.021	1.6796	1.9692	1.4068	1.4312
10	2.2298	1.768	1.9524	2.1125	.3506	.3414
11	2.2558	1.8488	1.9906	2.2405	.2713	.3033
12	2.0348	1.8198	2.1232	2.2558	.2713	.2926
13	2.0134	1.7467	2.2497	2.2268	.2637	.2865
14	2.1445	1.6918	2.1994	2.2055	.3003	.2683
15	2.2192	1.704	2.1293	2.3122	.3125	.2865
16	2.3243	1.6248	2.2451	2.332	.3018	.3185
17	1.2696	.9236	1.3214	1.3733	.3079	.2957
18	.5289	.3521	.4283	.282	.3567	.3353
19	.8459	.6935	.7255	.8215	.5411	.5746
20	1.0334	.852	.8733	.9343	.6859	.695
21	.9419	.8612	.8642	.8947	.5898	.6737
22	.7971	.7331	.7682	.7346	.5517	.5731
23	.6219	.6295	.5975	1.1187	1.3519	1.2818
24	.4908	.4984	.4847	1.1782	1.4175	1.3885
Max	2.3243	2.021	2.2497	2.332	2.3	2.4752
Min	.4908	.3521	.4283	.282	.2637	.2683
Avg	1.2200	1.0503	1.1712	1.2665	.8599	.9473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 203 / 11 KV RISEPISE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8124	.3673	.4329	.314	.7346	.7514
2	.8109	.3795	.41	.3185	.7072	.7179
3	.8139	.378	.4146	.3353	.6935	.7209
4	.8413	.3902	.4298	.3673	.7194	.7606
5	1.0121	.4954	.5136	.4938	.8733	.8932
6	1.3519	.6767	.7194	.6904	1.1538	1.1782
7	1.7345	.7621	.8078	.7392	1.5135	1.6232
8	1.6339	.7072	.6661	.6097	1.5409	1.6796
9	2.0622	1.1401	.9678	1.1126	.5792	.5959
10	2.4783	1.2574	1.2132	1.2102	.3003	.3155
11	2.617	1.2361	1.3321	1.2361	.3216	.2881
12	2.5499	1.3382	1.294	1.3047	.3185	.3018
13	2.4996	1.2544	1.4342	1.3352	.3079	.285
14	2.3563	1.323	1.291	1.3717	.3125	.2362
15	2.2604	1.3062	1.3992	1.3794	.2972	.2393
16	2.1918	1.2879	1.3565	1.3931	.3262	.3003
17	1.2803	.4298	.4527	.5487	.2957	.3353
18	.6981	.3551	.3658	.4572	.3125	.378
19	1.1599	.5731	.5822	.7545	.5014	.5898
20	1.5272	.6478	.6615	.7926	.5959	.66
21	1.5196	.6539	.6295	.6188	.5731	.6523
22	1.4037	.5838	.5502	.6158	.5335	.5548
23	1.0715	.4755	.3597	.7545	.7285	.727
24	.7575	.4405	.3125	.7392	.7392	.7407
Max	2.617	1.3382	1.4342	1.3931	1.5409	1.6796
Min	.6981	.3551	.3125	.314	.2957	.2362
Avg	1.5602	.7691	.7748	.8122	.6241	.6469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 201 / 11 KV Vadhane AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2887	1.4487	.4755	.4656	.4397	1.0181
2	1.2353	1.3748	.474	.4687	.4481	1.0242
3	1.2247	1.3542	.4976	.4641	.4679	1.0654
4	1.2407	1.3557	.5136	.5274	.5129	1.1081
5	1.3999	1.4853	.6401	.6676	.676	1.2437
6	1.7467	1.8359	.8787	.9069	.8589	1.6209
7	2.2382	2.3518	.9175	.9122	.8871	2.069
8	2.428	2.4798	.7872	.7948	.8124	2.1178
9	.7682	.6859	1.4701	1.5988	1.6552	.7941
10	.4016	.4062	2.1978	1.8587	1.7764	.333
11	.3925	.4176	2.0904	1.7955	1.8557	.3376
12	.4001	.3643	1.9745	1.8671	1.8823	.3414
13	.2774	.3544	1.9563	1.8633	1.8846	.3437
14	.2759	.3925	1.9494	1.8648	1.8244	.3704
15	.3254	.3864	1.7718	1.8092	1.7246	.397
16	.365	.4092	1.9464	1.8435	1.7863	.4123
17	.2332	.3216	.57	.426	.4763	.4283
18	.4169	.3681	.3323	.333	.2294	.3719
19	.6523	.6912	.6097	.5274	.6546	.692
20	.7278	.7933	.7026	.6645	.7308	.7324
21	.7064	.7194	.6775	.6516	.6904	.676
22	.6562	.6501	.6325	.5868	.6013	.583
23	1.5226	.5578	.519	.487	1.0006	1.2795
24	1.4914	.4923	.4679	.455	1.012	1.2856
Max	2.428	2.4798	2.1978	1.8671	1.8846	2.1178
Min	.2332	.3216	.3323	.333	.2294	.333
Avg	.9340	.9040	1.0439	.9933	1.0370	.8602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 202 / 11 KV Supa Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4626	.4862	.4877	.4954	.4363	.4062
2	.4534	.4832	.4816	.4809	.4336	.4127
3	.4611	.4858	.4908	.49	.4363	.4344
4	.4999	.5396	.5064	.5175	.4698	.4538
5	.652	.695	.636	.6725	.5811	.6123
6	.9217	.9659	.9282	.9797	.884	.9271
7	1.1477	1.161	1.086	1.1599	1.1138	1.1309
8	1.0208	1.1142	1.1587	1.1427	1.0631	1.1485
9	.8299	.9187	.964	.905	.953	.913
10	.6329	.575	.6474	.5639	.6291	.7053
11	.4416	.4531	.482	.4683	.4809	.4443
12	.4054	.4184	.4199	.4188	.397	.3768
13	.4203	.4096	.4275	.3654	.3768	.3662
14	.3868	.3894	.4271	.3765	.4233	.3955
15	.4012	.4005	.4062	.3883	.3909	.3753
16	.4214	.3727	.3951	.3944	.4283	.3704
17	.4241	.3601	.4111	.4012	.4565	.3974
18	.4805	.4096	.4226	.423	.4538	.4222
19	.6668	.5948	.5891	.4508	.6954	.6062
20	1.0006	.94	.9438	.9694	.9915	.9484
21	.9503	.9126	.9092	.8977	.9004	.9073
22	.8181	.775	.8036	.7468	.7727	.7419
23	.6683	.6767	.6832	.5727	.5876	.5803
24	.5464	.5296	.5357	.4607	.4546	.4504
Max	1.1477	1.161	1.1587	1.1599	1.1138	1.1485
Min	.3868	.3601	.3951	.3654	.3768	.3662
Avg	.6297	.6278	.6351	.6142	.6171	.6053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 207 / 11 KV Dandwadi Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2119	1.0098	1.2521	1.3253	.2591
2	.2096	.2103	1.0067	1.2056	1.2917	.2622
3	.2119	.2149	1.0357	1.1393	1.2353	.2637
4	.2111	.2195	1.0959	1.1454	1.2239	.269
5	.2362	.2583	1.0883	1.2094	1.2193	.3041
6	.3231	.3307	1.2178	1.3093	1.3275	.3688
7	.3902	.4092	1.5059	1.6674	1.6392	.4405
8	.4092	.4252	1.845	1.9479	1.9875	.4504
9	1.7825	1.7139	1.7894	1.8961	2.0127	1.7901
10	2.1163	1.9784	.2141	.2248	.2545	2.1353
11	2.0942	1.7985	.1859	.1936	.2378	2.0904
12	1.9867	1.8305	.202	.2027	.2431	2.0386
13	1.925	1.7977	.1936	.218	.253	1.8077
14	1.8503	1.7825	.2111	.2073	.2324	1.922
15	1.8572	1.7528	.1981	.2134	.2271	1.9349
16	1.8701	1.845	.1814	.2225	.2423	1.9143
17	1.8122	1.6469	.1791	.2515	.1638	1.7657
18	.1509	.1616	.2271	.2378	.2241	.1486
19	.2667	.2629	.2446	.333	.3307	.2812
20	.3376	.3353	.3048	.3803	.3673	.3368
21	.3429	.333	.2964	.3765	.3231	.3422
22	.314	.2888	.2888	.3292	.2911	.3224
23	.2705	1.038	1.2498	1.2605	.2888	.2789
24	.2126	1.0509	1.3253	1.3603	.2614	.2431
Max	2.1163	1.9784	1.845	1.9479	2.0127	2.1353
Min	.1509	.1616	.1791	.1936	.1638	.1486
Avg	.8913	.9124	.7124	.7827	.7168	.9154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 201 / 11 KV Murti single
 phasing Feeder KV- 11 /
 OUTGOING

SINGLE PHASING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6485	.6226	.2911	.2911	.3125	.5114
2	.6074	.615	.2964	.2995	.3231	.5373
3	.612	.6287	.3033	.3064	.3376	.5319
4	.6661	.6661	.3567	.3643	.3544	.5761
5	.7651	.8101	.4649	.5045	.4824	.6889
6	.9976	1.0242	.5647	.5647	.5838	.9023
7	1.4861	1.4495	.5571	.5258	.5746	1.3115
8	1.4845	1.3435	.4672	.4801	.4336	1.3588
9	.2241	.2362	1.1325	1.0814	1.0311	.3018
10	.1494	.1608	1.2186	1.0722	1.0044	.1646
11	.1075	.1524	1.2574	1.0631	1.012	.128
12	.1036	.1578	1.2925	1.1279	1.0608	.1379
13	.1204	.1478	1.2292	1.1782	1.1065	.1425
14	.1174	.1501	1.1576	.977	1.0989	.1486
15	.1578	.1517	1.1187	.9092	.9998	.1631
16	.1425	.1585	1.1667	.9145	.9175	.1677
17	.1776	.1768	.1699	.1753	.1974	.1791
18	.2606	.2309	.2324	.2827	.2888	.2683
19	.4611	.4862	.4473	.5075	.4504	.4816
20	.4641	.4702	.4687	.5022	.4641	.5022
21	.4351	.4344	.4237	.4405	.4298	.4412
22	.3666	.381	.3673	.3986	.3727	.3536
23	.6882	.3178	.3102	.3285	.5114	.6249
24	.6523	.2888	.2896	.3094	.4976	.6089
Max	1.4861	1.4495	1.2925	1.1782	1.1065	1.3588
Min	.1036	.1478	.1699	.1753	.1974	.128
Avg	.4957	.4692	.6493	.6085	.6186	.4680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 202 / 11 KV Jogwadi single SINGLE PHASING
 Phasing Feeder KV- 11 /
 OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5426	.535	.5319	.5289
2	.5053	.4908	.4786	.4923
3	.4672	.4748	.4611	.4847
4	.5754	.5716	.5677	.567
5	.5274	.5235	.5106	.5152
6	.4748	.4755	.4664	.4862
7	.4435	.4595	.4534	.4801
8	.4999	.4961	.4984	.5784
9	.3513	.3285	.3528	.4329
10	.1334	.1608	.2012	.1799
11	.3025	.426	.4999	.1562
12	.426	.6546	.7293	.2766
13	.4557	.5335	.5045	.3147
14	.5136	.3917	.442	.2774
15	.3864	.538	.4108	.2606
16	.3757	.5624	.2964	.2119
17	.1585	.3475	.2187	.2248
18	.4679	.3681	.3871	.5175
19	.6851	.6158	.5091	.7232
20	.759	.6813	.6996	.7933
21	.7019	.6447	.5464	.7674
22	.6843	.6653	.6958	.7217
23	.5815	.5716	.6333	.6379
24	.4893	.4915	.5243	.5075
Max	.759	.6813	.7293	.7933
Min	.1334	.1608	.2012	.1562
Avg	.4795	.5003	.4841	.4640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 203 / 11 KV Morgaon single

SINGLE PHASING

Phasing Feeder KV- 11 /
OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1638	.1745	.1852	.1981	.202
2	.1478	.1631	.1715	.1692	.1821	.2103
3	.1555	.1738	.1768	.1722	.1776	.2119
4	.1692	.2035	.1905	.1699	.1898	.2256
5	.2446	.2614	.2241	.2446	.2233	.2926
6	.3544	.4176	.3231	.4001	.3178	.4047
7	.3917	.4344	.5502	.628	.5906	.4405
8	.3193	.3285	.6112	.6744	.6737	.3696
9	.3658	.4443	.237	.2301	.2492	.4961
10	.4115	.4298	.1814	.1913	.2042	.5129
11	.4222	.4237	.141	.1578	.1661	.4969
12	.3948	.4199	.1196	.0762	.1715	.4595
13	.3643	.3856	.1402		.1745	.442
14	.3788	.3589	.1402	.1372	.1684	.3704
15	.4321	.381	.1364	.1776	.1631	.3376
16	.4405	.3993	.1494	.173	.1578	.3719
17	.1677	.1417	.1463	.1463	.1699	.1448
18	.192	.2157	.2103	.221	.1799	.1707
19	.3102	.3475	.3544	.362	.3567	.3734
20	.3445	.3612	.3757	.3079	.3795	.3932
21	.3307	.301	.3643	.3307	.349	.3384
22	.2431	.266	.3079	.2972	.2858	.2865
23	.1844	.1753	.1997	.2248	.2172	.2225
24	.1677	.1783	.1905	.2218	.2027	.2035
Max	.4405	.4443	.6112	.6744	.6737	.5129
Min	.1478	.1417	.1196	.0762	.1578	.1448
Avg	.2952	.3073	.2423	.2565	.2562	.3324

Feederwise Load Information for All Feeders

Feeder No / Name : 205 / 11 KV Modhave single SINGLE PHASING
phasing Feeder KV- 11 /
OUTGOING

DATE	22-FEB-17	23-FEB-17
HR	Load (MW)	Load (MW)
1	***	***
2	***	
3	***	***
4		***
Max	152.416	152.416
Min	152.416	152.416
Avg	152.416	152.416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 206 / 11KV Ambi Single Phasing SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11			***	***		
12			***	***		
13			***	***		
14			***	***	***	
15			***	***	***	
16			***	***	***	
17			***	***	***	
18	***	***	***	***		***
Max	152.416	76.208	152.416	152.416	152.416	152.416
Min	152.416	76.208	76.208	76.208	152.416	152.416
Avg	152.416	76.208	133.364	142.89	152.416	152.416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 201 / 11 KV Waki single Phasing SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
12	***		
13	***		
14	***	***	***
15	***	***	
16	***		
17	***		
Max	152.416	152.416	152.416
Min	152.416	152.416	152.416
Avg	152.416	152.416	152.416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 203 / 11 KV SASTEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				***		
4				***		
5				***		
6		***	***	***		
7		***	***	***		
8		***	***	***		
10					***	***
11	***				***	***
12	***				***	***
13	***				***	
14	***				***	
15	***				***	***
16	***				***	***
17	***				***	***
18	***	***	***	***	***	***
19	***	***	***	***	***	***
20	***	***	***	***	***	***
21		***	***	***	***	***
22		***	***	***	***	***
23			***			
Max	76.208	76.208	76.208	76.208	76.208	76.208
Min	76.208	76.208	76.208	76.208	76.208	76.208
Avg	76.208	76.208	76.208	76.208	76.208	76.208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 202 / Malashi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6683	.2667	.266	.2629	.6645	.6363
2	.6744	.2804	.266	.2759	.6843	.6394
3	.7049	.2919	.2911	.3079	.6943	.6546
4	.8573	.3727	.3597	.3795	.7644	.7781
5	.964	.4039	.4268	.4268	.945	.9595
6	1.1073	.4588	.4252	.4138	1.0364	1.044
7	1.0433	.6394	.5876	.6409	.9884	.98
8	.2698	1.0212	1.0799	1.1241	.3025	.2797
9	.2705	1.0547	1.1164	1.1317	.2492	.2248
10	.2507	1.0913	1.1218	1.1629	.3452	.2134
11	.2797	1.1164	1.1134	1.0974	.3117	.2195
12	.2698	1.1568	1.1065	1.0982	.2812	.2568
13	.2378	1.1004	.9541	1.0463	.2774	.2576
14	.2515	1.1012	.5251	1.0448	.2309	.2545
15	.2713	1.1469	1.1599	1.0402	.2553	.2835
16	.2858	.2812	.3056	.2705	.2919	.2896
17	.3041	.3193	.3254	.3102	.2835	.2972
18	.394	.3673	.397	.3719	.3742	.365
19	.3932	.3788	.3955	.3765	.3757	.3757
20	.3688	.365	.3932	.3353	.3513	.3513
21	.3307	.3445	.3582	.4191	.4832	.4108
22	.2393	.2408	.2705	.6401	.6638	.6066
23	.2591	.2416	.2637	.6394	.6485	.6112
24	.2583	.2583	.2644	.6493	.6379	.6417
Max	1.1073	1.1568	1.1599	1.1629	1.0364	1.044
Min	.2378	.2408	.2637	.2629	.2309	.2134
Avg	.4564	.5958	.5739	.6444	.5059	.4846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 205 / 11KV Wayalpatta single SINGLE PHASING
phasing Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2035	.6596	.7526	.5396	.2408
2	.2362	.2065	.6718	.759	.5445	.242
3	.2538	.2164	.6843	.7724	.5575	.2637
4	.2648	.2431	.7164	.7781	.5853	.2782
5	.3125	.2934	.7423	.8124	.6379	.3147
6	.3666	.3818	.8432	.892	.7415	.3547
7	.4607	.4443	1.0402	1.0322	.8349	.4241
8	.4763	.4599	1.2018	1.145	.9076	.4241
9	.9496	1.0555	1.0997	1.1187	.9088	.6775
10	1.185	1.2917	.2503	.2583	.3414	.9918
11	1.23	1.3051	.2023	.2061	.2465	1.0059
12	1.2955	1.2799	.1753	.1696	.2454	1.2559
13	1.2845	1.0814	.176	.1665	.2492	1.2696
14	1.1888	1.1366	.1974	.1959	.2263	1.3013
15	1.1469	1.1229	.1566	.1844	.229	1.2868
16	1.1485	1.1496	.1646	.1856	.2122	1.2681
17	1.0883	1.0997	.1917	.2039	.2336	1.1888
18	.274	.1955	.1962	.2004	.253	.2004
19	.3292	.2717	.2511	.2542	.3464	.2667
20	.3871	.3064	.2884	.314	.373	.3045
21	.3536	.2721	.2789	.293	.338	.2808
22	.2949	.242	.2561	.2606	.3147	.2374
23	.253	.6158	.6603	.5049	.2747	.1955
24	.2023	.6653	.7533	.543	.2328	.1585
Max	1.2955	1.3051	1.2018	1.145	.9088	1.3013
Min	.2023	.1955	.1566	.1665	.2122	.1585
Avg	.6336	.6475	.4941	.5001	.4322	.6013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 201 / 11 KV Chilaimala Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.4961	.711	.6546	.7141	.0655
2	.0305	.4969	.7049	.6539	.6935	.0663
3	.0312	.4984	.6935	.6584	.6943	.0671
4	.0305	.4976	.6927	.6341	.6836	.0655
5	.032	.4923	.7034	.6333	.6836	.0693
6	.0381	.4976	.6836	.6615	.6889	.0678
7	.0526	.599	.7491	.7133	.6927	.0846
8	.0678	.6325	.7743	.7468	.6691	.0953
9	.6539	.6424	.7804	.7164	.5548	.6889
10	.8429	.0594	.0884	.0869	.0838	.823
11	.8833	.0777	.0876	.0846	.064	.8848
12	.9008	.0709	.0831	.0754	.0838	.9335
13	.8939	.0709	.0762	.0739	.0861	.9617
14	.849	.0785	.0793	.0998	.1014	.9496
15	.8192	.096	.0922	.096	.0998	.8177
16	.8055	.0968	.0937	.0747	.0854	.9503
17	.7636	.0884	.0968	.0831	.0808	.8589
18	.0648	.0884	.096	.0991	.0945	.0831
19	.077	.1006	.0975	.112	.0998	.0876
20	.0861	.1059	.1082	.0991	.1052	.0831
21	.0823	.0869	.0953	.0838	.0815	.0777
22	.0777	.0663	.0739	.0678	.0793	.0701
23	.3711	.5396	.5456	.6379	.0747	.0663
24	.5144	.7118	.6661	.7293	.0648	.0541
Max	.9008	.7118	.7804	.7468	.7141	.9617
Min	.0305	.0594	.0739	.0678	.064	.0541
Avg	.3749	.2996	.3697	.3573	.3066	.3738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 203 / 11 KV CHOUDHARWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315	.3391	.3673	.3544	.3353	.298
2	.3231	.3346	.3589	.3406	.3216	.2934
3	.3208	.3399	.3658	.3422	.3285	.2972
4	.3521	.3757	.4077	.3772	.3658	.3368
5	.4588	.4847	.5022	.4733	.5091	.4748
6	.5967	.6569	.6241	.6501	.647	.5731
7	.695	.7255	.724	.7415	.692	.6965
8	.6798	.6958	.6775	.6973	.6965	.6821
9	.554	.5677	.5594	.5213	.6112	.519
10	.3948	.4626	.4428	.4108	.4344	.3635
11	.3391	.3635	.3628	.4054	.3643	.2873
12	.2858	.3429	.3772	.3963	.2736	.2766
13	.2919	.3429	.3902	.3925	.2751	.2865
14	.33	.3734	.3978	.4047	.2698	.2789
15	.3048	.349	.33	.3605	.2736	.2804
16	.3315	.407	.3346	.3262	.2705	.2926
17	.3696	.4687	.3788	.3978	.3307	.3429
18	.4252	.4893	.4039	.4237	.3467	.3727
19	.4595	.5014	.4512	.4763	.4435	.4961
20	.5761	.6249	.5632	.5632	.5426	.5998
21	.5456	.5967	.5479	.5578	.5144	.5662
22	.5053	.535	.5159	.5129	.4885	.4938
23	.4344	.4542	.4519	.4367	.3871	.3925
24	.3544	.3871	.3742	.3506	.3117	.3292
Max	.695	.7255	.724	.7415	.6965	.6965
Min	.2858	.3346	.33	.3262	.2698	.2766
Avg	.4275	.4674	.4546	.4547	.4181	.4096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 206 / 11 KV DAREKAR MALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503	1.0258	1.1302	1.1347	1.0524	.0488
2	.0503	1.0334	1.1088	1.121	1.0555	.048
3	.0488	1.0303	1.0341	1.1225	1.0486	.048
4	.0488	1.0296	1.0204	1.121	1.0387	.0472
5	.048	1.0288	1.0395	1.1218	1.0105	.048
6	.0556	1.038	1.0517	1.1149	1.0288	.0495
7	.0549	1.0456	1.1088	1.1454	1.1004	.0549
8	.0389	1.1081	1.1782	1.259	1.1812	.0823
9	1.1218	1.1347	1.1789	1.2513	.9777	.913
10	1.3466	.0427	.0389	.0602	.0412	1.1744
11	1.3771	.0221	.0358	.0419	.0427	1.355
12	1.4182	.0267	.0358	.0381	.032	1.3169
13	1.3664	.0221	.0389	.0213	.0282	1.3024
14	1.3245	.0236	.0312	.0183	.0251	1.3207
15	1.3146	.032	.029	.0244	.0244	1.3169
16	1.2978	.0221	.016	.0198	.0259	1.3047
17	1.1797	.0244	.0396	.0244	.0343	1.3184
18	.0305	.0328	.0427	.032	.0351	.0457
19	.061	.0633	.0518	.0594	.064	.0572
20	.0648	.0701	.0709	.0549	.0648	.0724
21	.0754	.064	.0724	.0587	.0541	.0625
22	.0602	.0572	.0587	.0518	.0533	.0488
23	.7316	.8573	.9168	.8985	.0533	.048
24	.9511	1.1241	1.1645	1.073	.0503	.0556
Max	1.4182	1.1347	1.1789	1.259	1.1812	1.355
Min	.0305	.0221	.016	.0183	.0244	.0457
Avg	.5882	.4983	.5206	.5362	.4218	.5058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 201 / 11 KV Late Ag SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***					***
2	***					***
3	***					***
4	***					***
5	***					***
6	***					***
7	***					***
8	***					***
10		***	***	***	***	
11		***		***	***	
18			***			***
19	***	***	***	***	***	***
20	***	***	***	***	***	***
21	***	***	***	***	***	***
22	***	***	***	***	***	***
23					***	***
24					***	***
Max	76.208	38.104	38.104	38.104	38.104	76.208
Min	38.104	38.104	38.104	38.104	38.104	38.104
Avg	44.4547	38.104	38.104	38.104	38.104	43.1845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 202 / 11 KV Korhale Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		***	***	***	***	
2		***	***	***	***	
3		***	***	***	***	
4		***	***	***	***	
5		***	***	***	***	
6		***	***	***	***	
7		***	***	***	***	
8		***	***	***	***	
10	***					***
11	***					***
12	***					***
13	***					***
14	***					***
15	***					***
16	***					***
17	***					***
18	***		***	***	***	***
19	***	***	***	***	***	***
20	***	***	***	***	***	***
21	***	***	***	***	***	***
22	***	***	***	***	***	***
23	***	***	***	***		
24	***	***	***	***		
Max	114.312	114.312	114.312	114.312	114.312	76.208
Min	38.104	76.208	38.104	38.104	38.104	38.104
Avg	63.5067	89.8166	83.8288	86.3691	90.8634	52.7594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 203 / 11KV Kurnewadi single SINGLE PHASING
Phasing Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)
11	***	
12	***	***
13	***	***
14	***	***
15	***	***
16	***	***
Max	152.416	152.416
Min	114.312	114.312
Avg	139.7147	137.1744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 204 / MATKARWASTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082		.0831	.1006	.0975	1.1317
2	.9076	.0617	.0854	.1014	.0991	1.1302
3	.9145	.0823	.0907	.1029	.1021	1.1264
4	.9358	.0861	.1036	.1113	.1135	1.1203
5	.9968	.0907	.1059	.1227	.1189	1.1347
6	1.0288	.1135	.1196	.1539	.1478	1.2651
7	1.217	.1105	.1296	.1547	.1562	1.3786
8	1.4419	.1181	.1372	.1478	.1478	1.5455
9	1.1843	1.5036	1.7185	1.7947	1.5394	1.307
10	.0876	1.7101	2.0111	2.0469	1.8374	.1113
11	.0777	1.9189	2.0035	2.1681	1.8633	.0937
12	.0213	1.9433	2.0355	2.2359	1.8808	.0991
13	.0823	2.0241	1.954	2.1933	1.848	.0953
14	.0457	1.7802	1.9494	1.9761	1.9258	.0945
15	.0145	1.8602	1.8419	1.7924	1.8732	.0899
16		1.8282	1.7414	1.6065	1.8252	.0617
17	.077	1.2856	1.3489	1.169	1.3908	.0892
18	.0945	.0709	.048	.0953	.1105	.1257
19	.0815	.1029	.109	.1105	.1273	.1242
20	.1158	.1067	.1196	.1158	.1357	.1326
21	.1036	.0922	.1097	.112	.125	.1219
22	.0854	.0861	.1036	.1006	.1105	.112
23	.0579	.0846	.1006	.0991	1.0631	1.2612
24		.0831	.0975	.0968	1.1264	1.3352
Max	1.4419	2.0241	2.0355	2.2359	1.9258	1.5455
Min	.0145	.0617	.048	.0953	.0975	.0617
Avg	.4809	.7454	.7561	.7795	.8236	.6286