

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 201 / 11 KV SAKALPAPER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0924 | | | | | | .0924 |
| 2 | | .0914 | | .0924 | .0914 | | |
| 3 | .0924 | | | | | | .0739 |
| 4 | | .0924 | .1109 | .0924 | .1097 | .112 | |
| 5 | .0924 | | | | | | .0739 |
| 6 | | .1097 | | .0924 | .1097 | | |
| 7 | | | | | | | .0739 |
| 8 | .1109 | .1109 | | .0924 | .1097 | .112 | .0924 |
| 10 | .1097 | | .1294 | .128 | | | .128 |
| 11 | | | | | .1307 | .1294 | |
| 12 | .1097 | | .1307 | .1463 | | | .2012 |
| 13 | | .1294 | | | | | |
| 14 | .1294 | | .1494 | .128 | | .168 | .1646 |
| 15 | | .1478 | | | .168 | | |
| 16 | .1294 | | .1478 | .1463 | | .1478 | .1663 |
| 17 | | | | | .1494 | .1663 | |
| 18 | .1463 | | .1848 | .1829 | | | .1848 |
| 19 | | | | | .1494 | .1294 | |
| 20 | .128 | | .1294 | .1663 | | | .1478 |
| 21 | | .1494 | .1109 | | .1294 | | |
| 22 | .1294 | | .1109 | .1463 | | .1109 | .1478 |
| 24 | .0924 | .0924 | .1109 | .0924 | .1109 | | .0924 |
| Max | .1463 | .1494 | .1848 | .1829 | .168 | .168 | .2012 |
| Min | .0924 | .0914 | .1109 | .0924 | .0914 | .1109 | .0739 |
| Avg | .1135 | .1154 | .1315 | .1255 | .1258 | .1345 | .1261 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 202 / 11 KV KUKERAJA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5544 | | | | | | .6099 |
| 2 | | .5487 | | .5175 | .5121 | | |
| 3 | .5175 | | | | | | .5544 |
| 4 | | .5175 | .6468 | .4805 | .5121 | .7207 | |
| 5 | .5544 | | | | | | .5544 |
| 6 | | .6036 | | .5175 | .6099 | | |
| 7 | | | | | | | .6099 |
| 8 | .6653 | .6584 | | .6099 | .7023 | .7207 | .7023 |
| 10 | .6468 | | 1.251 | 1.262 | | | 1.3169 |
| 11 | | | | | 1.363 | 1.3306 | |
| 12 | .6838 | | 1.2883 | 1.2382 | | | 1.2803 |
| 13 | | 1.2883 | | | | | |
| 14 | .695 | | 1.4003 | 1.2936 | | 1.386 | 1.2986 |
| 15 | | 1.3443 | | | 1.3306 | | |
| 16 | .695 | | 1.386 | 1.39 | | 1.3676 | 1.2437 |
| 17 | | | | | 1.2936 | 1.2936 | |
| 18 | .6838 | | 1.1088 | 1.134 | | | 1.0164 |
| 19 | | | | | .9425 | .924 | |
| 20 | .7023 | | 1.0349 | .8596 | | | .8048 |
| 21 | | .8215 | .6838 | | .7947 | | |
| 22 | .6401 | | .6838 | .7133 | | .7207 | .7133 |
| 24 | .5914 | .6283 | .6099 | .6468 | .6468 | | .6653 |
| Max | .7023 | 1.3443 | 1.4003 | 1.39 | 1.363 | 1.386 | 1.3169 |
| Min | .5175 | .5175 | .6099 | .4805 | .5121 | .7207 | .5544 |
| Avg | .6358 | .8013 | 1.0094 | .8886 | .8708 | 1.0580 | .8746 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 203 / 11 KV GAUTAM COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7392 | | | | | | .7762 |
| 2 | | .7316 | | .7023 | .695 | | |
| 3 | .7023 | | | | | | .7392 |
| 4 | | .6584 | 1.0269 | .6838 | .7762 | .7023 | |
| 5 | .7392 | | | | | | .7207 |
| 6 | | .7865 | | .7762 | .7947 | | |
| 7 | | | | | | | .7947 |
| 8 | .7207 | 1.2197 | | 1.0534 | 1.0242 | 1.1576 | .8131 |
| 10 | .8962 | | 1.7187 | 1.7193 | | | 1.3717 |
| 11 | | | | | 1.8665 | 1.8484 | |
| 12 | .9511 | | 1.8298 | 1.7924 | | | 1.39 |
| 13 | | 1.6448 | | | | | |
| 14 | .8962 | | 1.8298 | 1.8473 | | 1.848 | 1.3717 |
| 15 | | 1.8296 | | | 1.8671 | | |
| 16 | .823 | | 1.7741 | | | 1.9035 | 1.2803 |
| 17 | | | | | 1.8484 | 1.7372 | |
| 18 | .8779 | | 1.6448 | 1.6461 | | | 1.2752 |
| 19 | | | | | 1.2936 | 1.2936 | |
| 20 | .9055 | | 1.1088 | 1.1088 | | | 1.0242 |
| 21 | | 1.0164 | | | 1.0534 | | |
| 22 | .9055 | | .9055 | 1.0349 | | .9795 | .9145 |
| 24 | .7762 | .7865 | .8029 | .7947 | .8131 | | .8316 |
| Max | .9511 | 1.8296 | 1.8298 | 1.8473 | 1.8671 | 1.9035 | 1.39 |
| Min | .7023 | .6584 | .8029 | .6838 | .695 | .7023 | .7207 |
| Avg | .8278 | 1.0842 | 1.4046 | 1.1963 | 1.2032 | 1.4338 | 1.0233 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 205 / 11 KV ARENJA TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3696 | | | | | | .4066 |
| 2 | | .3292 | | .3696 | .439 | | |
| 3 | .2957 | | | | | | .3881 |
| 4 | | .3326 | .5041 | .4251 | .3658 | .4066 | |
| 5 | .1478 | | | | | | .4066 |
| 6 | | .4024 | | .4805 | .4572 | | |
| 7 | | | | | | | .4435 |
| 8 | .3696 | .6036 | | .6099 | .5304 | .5975 | .4251 |
| 10 | .4755 | | .9522 | .823 | | | .7682 |
| 11 | | | | | .9055 | .924 | |
| 12 | .439 | | .9149 | .8779 | | | .7865 |
| 13 | | .9149 | | | | | |
| 14 | .4207 | | .9709 | .9055 | | .9055 | .7316 |
| 15 | | .9522 | | | .9522 | | |
| 16 | .3841 | | .924 | .9145 | | .9795 | .7682 |
| 17 | | | | | 1.0082 | .9795 | |
| 18 | .4572 | | .8686 | .8413 | | | .7207 |
| 19 | | | | | .7207 | .7207 | |
| 20 | .4938 | | | .6584 | | | .5914 |
| 21 | | .6283 | | | .6468 | | |
| 22 | .499 | | .5601 | .5544 | | .5359 | .5175 |
| 24 | .4066 | .4435 | .4668 | .462 | .4805 | | .4435 |
| Max | .499 | .9522 | .9709 | .9145 | 1.0082 | .9795 | .7865 |
| Min | .1478 | .3292 | .4668 | .3696 | .3658 | .4066 | .3881 |
| Avg | .3966 | .5758 | .7702 | .6602 | .6506 | .7562 | .5690 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 206 / 11 KV CHANDRAMUKHI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3326 | | | | | | .3696 |
| 2 | | .3475 | | .2957 | .3326 | | |
| 3 | .0293 | | | | | | .2772 |
| 4 | | .3258 | .4066 | .2957 | .3142 | .3361 | |
| 5 | .2957 | | | | | | .2957 |
| 6 | | .3326 | | .3142 | .3326 | | |
| 7 | | | | | | | .3142 |
| 8 | .3142 | .3881 | | .3696 | .3881 | .4251 | .3511 |
| 10 | .3658 | | 1.4937 | 1.3535 | | | 1.2803 |
| 11 | | | | | 1.7177 | 1.6263 | |
| 12 | .462 | | 1.5684 | 1.5729 | | | 1.5181 |
| 14 | .499 | | 1.5497 | 1.5364 | | 1.5893 | 1.4083 |
| 15 | | 1.7372 | | | 1.6448 | | |
| 16 | .4435 | | 1.5524 | 1.701 | | 1.6817 | 1.2986 |
| 17 | | | | | 1.5893 | 1.7002 | |
| 18 | .4163 | | 1.3121 | 1.3169 | | | .961 |
| 19 | | | | | 1.0456 | .961 | |
| 20 | .4805 | | .7023 | .7133 | | | .6767 |
| 21 | | .6099 | | | .6161 | | |
| 22 | .4251 | | .4435 | .5121 | | .5175 | .5304 |
| 24 | .3881 | .3841 | .3696 | .3881 | .4066 | | .4066 |
| Max | .499 | 1.7372 | 1.5684 | 1.701 | 1.7177 | 1.7002 | 1.5181 |
| Min | .0293 | .3258 | .3696 | .2957 | .3142 | .3361 | .2772 |
| Avg | .3710 | .5893 | 1.0443 | .8641 | .8388 | 1.1047 | .7452 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 207 / 11 KV CIDCO PUMP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3326 | | | | | | .4066 |
| 2 | | .4024 | | .4066 | .4024 | | |
| 3 | .3142 | | | | | | .4805 |
| 4 | | .3292 | .6653 | .4435 | .439 | .4435 | |
| 5 | .3696 | | | | | | .5914 |
| 6 | | .5175 | | .5544 | .6219 | | |
| 7 | | | | | | | .5914 |
| 8 | .5544 | .6468 | | .6099 | .6401 | .5975 | .6283 |
| 10 | .5359 | | .5041 | .4066 | | | .462 |
| 11 | | | | | .3921 | .462 | |
| 12 | .4805 | | .3361 | .4066 | | | .3658 |
| 14 | .3475 | | .2957 | .3511 | | .3142 | .3511 |
| 15 | | .3511 | | | .3142 | | |
| 16 | .3511 | | .3142 | .3292 | | .3326 | .3511 |
| 17 | | | | | .3547 | .3511 | |
| 18 | .462 | | .3696 | .3841 | | | .4251 |
| 19 | | | | | .5175 | .499 | |
| 20 | .5359 | | .4805 | .5121 | | | .4938 |
| 21 | | .5228 | | | .499 | | |
| 22 | .4572 | | .4435 | .4572 | | .4805 | .4572 |
| 24 | .3696 | .4024 | .3696 | .4066 | .3881 | | .462 |
| Max | .5544 | .6468 | .6653 | .6099 | .6401 | .5975 | .6283 |
| Min | .3142 | .3292 | .2957 | .3292 | .3142 | .3142 | .3511 |
| Avg | .4259 | .4532 | .4198 | .4390 | .4569 | .4351 | .4666 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 208 / 11 KV INFOTECH PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7392 | | | | | | .8501 |
| 2 | | .695 | | .8501 | .8131 | | |
| 3 | .6653 | | | | | | .7392 |
| 4 | | .6767 | .9896 | .7762 | .7762 | .7842 | |
| 5 | .6468 | | | | | | .7577 |
| 6 | | .6468 | | .7762 | .7392 | | |
| 7 | | | | | | | .7392 |
| 8 | .7207 | .8501 | | .8501 | .7947 | .961 | .7762 |
| 10 | .7499 | | 1.4003 | 1.39 | | | 1.0791 |
| 11 | | | | | 1.4003 | 1.4003 | |
| 12 | .8779 | | 1.4377 | 1.423 | | | 1.2803 |
| 14 | .8779 | | 1.475 | 1.423 | | 1.4784 | 1.2197 |
| 15 | | 1.475 | | | 1.46 | | |
| 16 | .8871 | | 1.423 | 1.4266 | | 1.4415 | 1.2254 |
| 17 | | | | | 1.423 | 1.3676 | |
| 18 | .8871 | | 1.3491 | 1.2986 | | | 1.0349 |
| 19 | | | | | 1.1389 | 1.1458 | |
| 20 | .8131 | | 1.0164 | 1.0903 | | | .8413 |
| 21 | | .9979 | | | 1.0269 | | |
| 22 | .8131 | | .924 | .961 | | .9425 | .7762 |
| 24 | .7577 | .8131 | .8962 | .9055 | .8871 | | .9055 |
| Max | .8871 | 1.475 | 1.475 | 1.4266 | 1.46 | 1.4784 | 1.2803 |
| Min | .6468 | .6468 | .8962 | .7762 | .7392 | .7842 | .7392 |
| Avg | .7863 | .8792 | 1.2124 | 1.0976 | 1.0459 | 1.1902 | .9404 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 209 / 11 KV RBI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1848 | | | | | | .1848 |
| 2 | | .1646 | | .1848 | .1829 | | |
| 3 | .1478 | | | | | | .1848 |
| 4 | | .1646 | .1867 | .1848 | .2012 | .2054 | |
| 5 | .1848 | | | | | | .2033 |
| 6 | | .2378 | | .1848 | .2218 | | |
| 7 | | | | | | | .1663 |
| 8 | .1478 | .2012 | | .1848 | .2402 | .2033 | .2033 |
| 10 | .1829 | | .1867 | .2012 | | | .2218 |
| 11 | | | | | .2054 | .2033 | |
| 12 | .1848 | | .1867 | .1829 | | | .1829 |
| 14 | .1663 | | .1867 | .1646 | | .1848 | .2012 |
| 15 | | .168 | | | .1848 | | |
| 16 | .1646 | | .1663 | .1829 | | .1848 | .1848 |
| 17 | | | | | .2033 | .2033 | |
| 18 | .2033 | | .2218 | .1848 | | | .1848 |
| 19 | | | | | .2987 | .2218 | |
| 20 | .2587 | | .2772 | .2772 | | | .2587 |
| 21 | | .2801 | | | .2987 | | |
| 22 | .2715 | | .2587 | .2772 | | .2402 | .2743 |
| 24 | .2054 | .2033 | .2241 | .2218 | .2218 | | .2218 |
| Max | .2715 | .2801 | .2772 | .2772 | .2987 | .2402 | .2743 |
| Min | .1478 | .1646 | .1663 | .1646 | .1829 | .1848 | .1663 |
| Avg | .1919 | .2028 | .2105 | .2027 | .2259 | .2059 | .2056 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 210 / 11 KV MTNL / DIWALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7023 | | | | | | .7762 |
| 2 | | .7207 | | .7392 | .7499 | | |
| 3 | .6468 | | | | | | .7577 |
| 4 | | .695 | .924 | .7577 | .7682 | .8029 | |
| 5 | .7023 | | | | | | .7762 |
| 6 | | .7947 | | .8316 | .8413 | | |
| 7 | | | | | | | .8131 |
| 8 | .8316 | .9511 | | .961 | .9328 | .9795 | .8871 |
| 10 | .8131 | | 1.6991 | 1.7741 | | | 1.6095 |
| 11 | | | | | 1.9404 | 1.8296 | |
| 12 | .823 | | 1.9044 | 1.6461 | | | 1.5912 |
| 14 | .8413 | | 1.8298 | 1.6827 | | 1.9404 | 1.7002 |
| 15 | | 1.9589 | | | 1.9605 | | |
| 16 | .7577 | | 1.848 | 1.8656 | | 1.885 | 1.4415 |
| 17 | | | | | 1.9231 | 1.7926 | |
| 18 | .8501 | | 1.46 | 1.3717 | | | 1.2567 |
| 19 | | | | | 1.1389 | 1.0903 | |
| 20 | .8131 | | .9979 | .9511 | | | .9425 |
| 21 | | .9335 | | | .9335 | | |
| 22 | .823 | | .7947 | .8501 | | .8501 | .8131 |
| 24 | .7207 | .8131 | .8131 | .7947 | .8131 | | .8131 |
| Max | .8501 | 1.9589 | 1.9044 | 1.8656 | 1.9605 | 1.9404 | 1.7002 |
| Min | .6468 | .695 | .7947 | .7392 | .7499 | .8029 | .7577 |
| Avg | .7771 | .981 | 1.3634 | 1.1855 | 1.2002 | 1.3963 | 1.0906 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 212 / 11 KV MAYURESH COSMOSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0739 | | | | | | .0739 |
| 2 | | .0732 | | .0739 | .0914 | | |
| 3 | .0739 | | | | | | .0739 |
| 4 | | .0914 | .0934 | .0739 | .0732 | .0924 | |
| 5 | .0924 | | | | | | .0739 |
| 6 | | .0914 | | .0924 | .0914 | | |
| 7 | | | | | | | .0739 |
| 8 | .0924 | .0914 | | .112 | .0924 | .0934 | .0924 |
| 10 | .0732 | | .2241 | .2195 | | | .1829 |
| 11 | | | | | .2614 | .2587 | |
| 12 | .0914 | | .2427 | .2378 | | | .2195 |
| 14 | .1097 | | .2427 | | | .1867 | .2378 |
| 15 | | .2614 | | | .2587 | | |
| 16 | .0914 | | .2402 | .2561 | | .2801 | .2195 |
| 17 | | | | | .2772 | .2587 | |
| 18 | .1097 | | .2218 | .2378 | | | .1848 |
| 19 | | | | | .168 | .1294 | |
| 20 | .0914 | | .1109 | .132 | | | .0914 |
| 21 | | .1294 | | | .0924 | | |
| 22 | .0924 | | .0924 | .0914 | | .0739 | .1097 |
| 24 | .0739 | .0924 | .0934 | .0739 | .0739 | | .0739 |
| Max | .1097 | .2614 | .2427 | .2561 | .2772 | .2801 | .2378 |
| Min | .0732 | .0732 | .0924 | .0739 | .0732 | .0739 | .0739 |
| Avg | .0888 | .1187 | .1735 | .1455 | .148 | .1717 | .1313 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 403 / 33 KV NMMC

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3306 | | | | | | 1.8107 |
| 2 | | 1.2449 | | 1.6975 | 1.8107 | | |
| 3 | 1.4712 | | | | | | 1.7541 |
| 4 | | 1.2449 | 1.7541 | 1.4415 | 1.1883 | 1.3146 | |
| 5 | 1.7741 | | | | | | 1.4415 |
| 6 | | .6224 | | 1.2197 | 1.2449 | | |
| 7 | | | | | | | 1.7541 |
| 8 | 1.358 | .6224 | | 1.358 | 1.3014 | 1.2449 | 1.7741 |
| 10 | .7922 | | 1.7541 | .9054 | | | 1.8107 |
| 11 | | | | | .8573 | 1.8107 | |
| 12 | 1.8673 | | 1.7364 | 1.358 | | | 1.8107 |
| 14 | 1.8296 | | 1.7924 | 1.8107 | | 1.7187 | 1.8107 |
| 15 | | 1.2574 | | | 1.829 | | |
| 16 | 1.7541 | | 1.8107 | 1.8107 | | 1.7741 | 1.8107 |
| 17 | | | | | .8573 | .9054 | |
| 18 | 1.7541 | | 1.7741 | .8488 | | | .7922 |
| 19 | | | | | .7922 | .8488 | |
| 20 | .8488 | | 1.2752 | .8488 | | | .8488 |
| 21 | | .8573 | | | .8573 | | |
| 22 | .8488 | | 1.2449 | .8488 | | 1.8107 | 1.4146 |
| 24 | 1.3306 | 1.358 | 1.7718 | 1.8107 | 1.4146 | | 1.7541 |
| Max | 1.8673 | 1.358 | 1.8107 | 1.8107 | 1.829 | 1.8107 | 1.8107 |
| Min | .7922 | .6224 | 1.2449 | .8488 | .7922 | .8488 | .7922 |
| Avg | 1.4133 | 1.0296 | 1.6571 | 1.3299 | 1.2153 | 1.4285 | 1.5836 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 201 / 11 KV Sector 8-A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .8962 | | | .9335 | | |
| 3 | | .7468 | | | .8215 | | .8215 |
| 4 | | | | .8589 | | | |
| 5 | | .8589 | | | .9335 | | |
| 6 | .8215 | 1.0082 | | | 1.0642 | 1.1389 | .9709 |
| 7 | | 1.251 | 1.2136 | 1.1763 | 1.1576 | 1.2696 | 1.0456 |
| 8 | 1.0829 | | 1.251 | 1.307 | | 1.3256 | 1.2136 |
| 9 | 1.2696 | 1.307 | 1.4937 | 1.307 | 1.2696 | 1.307 | 1.3817 |
| 10 | 1.3817 | 1.1763 | 1.1203 | 1.1576 | 1.2136 | 1.2696 | 1.3817 |
| 11 | 1.2696 | 1.1763 | 1.0829 | 1.0829 | 1.1389 | 1.1576 | |
| 12 | 1.1203 | .5415 | .9709 | .9522 | .8916 | 1.0082 | 1.0642 |
| 13 | .9896 | .9709 | .9335 | | .8962 | .9335 | .9896 |
| 14 | | | .8962 | .8402 | | | .9149 |
| 15 | .8402 | .8029 | .8215 | .8215 | | | |
| 16 | .7842 | .8215 | .7468 | | | .8215 | .8215 |
| 17 | .9335 | | .7842 | | .8215 | .8215 | .8589 |
| 18 | 1.0456 | .8962 | .8962 | | .8962 | .8589 | .8962 |
| 19 | 1.2323 | 1.251 | 1.2323 | 1.2883 | 1.251 | 1.2696 | |
| 20 | | .0187 | 1.2696 | 1.2696 | 1.3443 | 1.307 | 1.363 |
| 21 | | 1.3443 | 1.2696 | 1.3256 | 1.3443 | 1.307 | 1.2883 |
| 22 | 1.2136 | 1.2136 | | | 1.251 | | 1.2323 |
| 23 | | | .9896 | | 1.1016 | | |
| 24 | 1.0829 | | .9149 | 1.2696 | 1.0456 | 1.3256 | 1.307 |
| Max | 1.3817 | 1.3443 | 1.4937 | 1.3256 | 1.3443 | 1.3256 | 1.3817 |
| Min | .7842 | .0187 | .7468 | .8215 | .8215 | .8215 | .8215 |
| Avg | 1.0763 | .9577 | 1.0522 | 1.1274 | 1.0764 | 1.1414 | 1.0969 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 202 / 11 KV BELAPUR BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 21-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 19 | 1.307 |
| Max | 1.307 |
| Min | 1.307 |
| Avg | 1.307 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 203 / 11 KV CBD SEC 8 B

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4481 | | | .4854 | | |
| 3 | | .4108 | | | .4108 | | .3547 |
| 4 | | | | .4294 | | | |
| 5 | | .4108 | | | .4481 | | |
| 6 | .0747 | .4668 | | | .5041 | .5415 | .4854 |
| 7 | | .6161 | .6348 | .6722 | .6348 | .6535 | .5975 |
| 8 | .5788 | | .7282 | .7468 | | .6722 | .6348 |
| 9 | .6908 | .7282 | .6722 | .7468 | .6722 | .6908 | .6722 |
| 10 | .5975 | .6535 | .5975 | .6161 | .6722 | .6535 | .6908 |
| 11 | .7095 | .5041 | .5975 | .6161 | .6161 | .5975 | |
| 12 | .6161 | .5415 | .5975 | .5975 | .5601 | .5601 | .5788 |
| 13 | .6348 | .5415 | .5228 | | .5228 | .5228 | .5601 |
| 14 | | | .5228 | .4854 | | | .5415 |
| 15 | .4294 | .4294 | .4108 | | | | |
| 16 | .3921 | .4294 | .3734 | | | .4481 | .4294 |
| 17 | .3734 | | .4481 | | .5041 | .4294 | .5228 |
| 18 | .5788 | .5415 | .5601 | | .5975 | .5601 | .4668 |
| 19 | .6722 | .6908 | .7095 | .5601 | .6348 | .7468 | .7095 |
| 20 | | .7095 | .6722 | .6722 | .7282 | .6535 | .6722 |
| 21 | | .6722 | .6722 | .6722 | .6722 | .5975 | .6161 |
| 22 | .6535 | .5975 | | | .6348 | | .6348 |
| 23 | | | .4668 | | .4854 | | |
| 24 | .3921 | | .3921 | .4481 | .4481 | | .4854 |
| Max | .7095 | .7282 | .7282 | .7468 | .7282 | .7468 | .7095 |
| Min | .0747 | .4108 | .3734 | .4294 | .4108 | .4294 | .3547 |
| Avg | .5281 | .5525 | .5634 | .6052 | .5684 | .5948 | .5678 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 204 / 11 KV S/STN T/F SECT-06

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0747 | | | .0934 | | |
| 3 | | .0747 | | | .0747 | | .0747 |
| 4 | | | | .0747 | | | |
| 5 | | .0747 | | | .0747 | | |
| 6 | .0747 | .0934 | | | .0934 | .1307 | .0934 |
| 7 | | .0934 | .112 | .112 | .0934 | .1307 | .112 |
| 8 | .112 | | .112 | .112 | | .112 | .112 |
| 9 | .1494 | .112 | .1307 | .112 | .0934 | .1307 | .1494 |
| 10 | .112 | .0934 | .112 | .0934 | .112 | .112 | .112 |
| 11 | .0934 | | .0747 | .0934 | .0934 | .0934 | |
| 12 | .0747 | .0934 | .0934 | .0934 | .0747 | .0747 | .0934 |
| 13 | .0747 | .0934 | .0747 | | .0747 | .0934 | .0934 |
| 14 | | | .0934 | .0747 | | | .0934 |
| 15 | .0747 | .0747 | .056 | | | | |
| 16 | .0747 | .056 | .0934 | | | .0934 | .0747 |
| 17 | .0747 | | .0934 | | .0934 | .0747 | .0747 |
| 18 | .0747 | .0934 | .0934 | | .0747 | .0747 | .0747 |
| 19 | | .112 | .112 | .112 | .0934 | .112 | |
| 20 | | .112 | .112 | .0934 | .0934 | .112 | .0934 |
| 21 | | .112 | .112 | .112 | .112 | .112 | .112 |
| 22 | .0934 | .112 | | | .112 | | .0934 |
| 23 | | | .112 | | .112 | | |
| 24 | .0934 | | .0934 | .112 | .0934 | | .0934 |
| Max | .1494 | .112 | .1307 | .112 | .112 | .1307 | .1494 |
| Min | .0747 | .056 | .056 | .0747 | .0747 | .0747 | .0747 |
| Avg | .0905 | .0922 | .0989 | .0996 | .0923 | .1040 | .0969 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 206 / 11 KV KENDRIYA SADAN SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2801 | | | .2801 | | |
| 3 | | .2614 | | | .2427 | | .2614 |
| 4 | | | | .2614 | | | |
| 5 | | .2427 | | | .2427 | | |
| 6 | .2054 | .2614 | | | .2801 | .2801 | .2614 |
| 7 | | .3174 | .2987 | .3174 | .3174 | .5788 | .2987 |
| 8 | .3174 | | .4108 | .3361 | | .3734 | .2987 |
| 9 | .2801 | .3547 | .3734 | .3734 | .3734 | .3734 | .3361 |
| 10 | .3361 | .4294 | .3734 | .3921 | .4108 | .4108 | .3921 |
| 11 | .3547 | | .3734 | .3734 | .4481 | .4108 | |
| 12 | .3547 | .4668 | .3734 | .4108 | .4294 | .3734 | .4294 |
| 13 | .3361 | .4108 | .4108 | | .3921 | .3734 | .4108 |
| 14 | | | .3547 | .3174 | | | .4108 |
| 15 | | .3921 | .3361 | | | | |
| 16 | | .3547 | .3547 | | | .3547 | .3547 |
| 17 | .2801 | | .029 | | .3921 | .3547 | .3361 |
| 18 | .3547 | .4108 | .4108 | | .4108 | .4108 | .4108 |
| 19 | | .5041 | .4854 | .4668 | .5228 | .5041 | |
| 20 | | .4854 | .4854 | .3734 | .5041 | .5041 | .4854 |
| 21 | | .5228 | .4481 | .4294 | .4668 | .4481 | .4481 |
| 22 | .3734 | .4108 | | | .4294 | | .4108 |
| 23 | | | .2987 | | .3361 | | |
| 24 | .2801 | | .2801 | .2987 | .2987 | | .2801 |
| Max | .3734 | .5228 | .4854 | .4668 | .5228 | .5788 | .4854 |
| Min | .2054 | .2427 | .029 | .2614 | .2427 | .2801 | .2614 |
| Avg | .3157 | .3816 | .3586 | .3625 | .3765 | .4108 | .3641 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 207 / 11 KV SECTOR-09 NEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4481 | | | .4481 | | |
| 3 | | .4108 | | | .4108 | | .4108 |
| 4 | | | | .4294 | | | |
| 5 | | .4108 | | | .4668 | | |
| 6 | .4108 | .4854 | | | .5041 | .5228 | .4854 |
| 7 | | .5228 | .6348 | .6722 | .6161 | .5788 | .5228 |
| 8 | .5788 | | .6908 | .6348 | | .6722 | .5975 |
| 9 | .6908 | .6722 | .7468 | .6722 | .6722 | .7468 | .7468 |
| 10 | .6722 | .5041 | .5975 | .5601 | .5601 | .5975 | .6535 |
| 11 | .5601 | | .4481 | .5228 | .4854 | .4854 | |
| 12 | .5041 | .4668 | .4108 | | | .5041 | .4668 |
| 13 | .4294 | .4668 | .4108 | | .4481 | .4481 | .4668 |
| 14 | | | .3734 | .4108 | | | .4294 |
| 15 | .2801 | .3547 | .3734 | | | | |
| 16 | | .3361 | .3361 | | | .3361 | .3734 |
| 17 | .3547 | | .3361 | | .3734 | .3547 | .3921 |
| 18 | .4108 | .4668 | .3785 | | .4294 | .3734 | .4294 |
| 19 | | .6348 | .6535 | .6161 | .6348 | .6348 | |
| 20 | | .6722 | .6535 | .6535 | .6722 | .5975 | .5975 |
| 21 | | .6348 | .6535 | .6348 | .6535 | .6535 | .6161 |
| 22 | .5975 | .5788 | | | .6161 | | .5788 |
| 23 | | | .5041 | | .5601 | | |
| 24 | .2987 | | .4668 | .4668 | .5041 | | .4668 |
| Max | .6908 | .6722 | .7468 | .6722 | .6722 | .7468 | .7468 |
| Min | .2801 | .3361 | .3361 | .4108 | .3734 | .3361 | .3734 |
| Avg | .4823 | .5041 | .5099 | .5703 | .5327 | .5361 | .5146 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 208 / 11 KV RBI SEC 10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3734 | | | .3734 | | |
| 3 | | .3734 | | | .3361 | | .3361 |
| 4 | | | | .3361 | | | |
| 5 | | .3734 | | | .3361 | | |
| 6 | .3547 | .3734 | | | .3734 | .3734 | .3734 |
| 7 | | .4108 | .3921 | .4108 | .3921 | .3921 | .3734 |
| 8 | .3547 | | .5041 | .4108 | | .4668 | .3734 |
| 9 | .3547 | .5228 | .5601 | .5601 | .7095 | .6535 | .4668 |
| 10 | .3734 | 1.0829 | .9709 | 1.0829 | 1.1203 | 1.0642 | .5228 |
| 11 | .3734 | | 1.0642 | 1.1203 | 1.2136 | 1.251 | |
| 12 | .3921 | 1.2883 | 1.1576 | | | 1.2308 | .8029 |
| 13 | .3921 | 1.2696 | 1.1949 | | 1.2323 | 1.2136 | .7468 |
| 14 | | | 1.1203 | 1.1389 | | | .7655 |
| 15 | .3734 | 1.3256 | 1.2136 | | | | |
| 16 | | 1.3443 | 1.2136 | | | 1.307 | .8215 |
| 17 | .3547 | | 1.307 | | 1.251 | 1.2696 | .8215 |
| 18 | .4108 | 1.0456 | .9335 | | 1.1576 | .9709 | .5415 |
| 19 | | .7655 | .7468 | .7468 | .7468 | .7468 | |
| 20 | | .4294 | .5041 | .4668 | .4668 | .4854 | .4294 |
| 21 | | .4294 | .4481 | .4294 | .4481 | .4108 | .4108 |
| 22 | .3734 | .4108 | | | .4108 | | .4108 |
| 23 | | | .3734 | | .4108 | | |
| 24 | .3547 | | .3921 | .3734 | .3734 | | .3734 |
| Max | .4108 | 1.3443 | 1.307 | 1.1389 | 1.251 | 1.307 | .8215 |
| Min | .3547 | .3734 | .3734 | .3361 | .3361 | .3734 | .3361 |
| Avg | .3718 | .7387 | .8292 | .6433 | .6678 | .8454 | .5356 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 210 / 11 KV RBI (NEW)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3547 | | | .3734 | | |
| 3 | | .3547 | | | .3734 | | .3361 |
| 4 | | | | .3361 | | | |
| 5 | | .3734 | | | .3734 | | |
| 6 | .3734 | .4294 | | | .3734 | .3361 | .3547 |
| 7 | | .3734 | .4294 | .3547 | .3734 | .3921 | .3361 |
| 8 | .3734 | | .3734 | .3547 | | .3921 | .3734 |
| 9 | .3547 | .4108 | .3734 | .3734 | .4481 | .4108 | .3734 |
| 10 | .3361 | .5228 | .5601 | .5601 | .5601 | .5975 | .4108 |
| 11 | .3361 | | .5228 | .5601 | .4668 | .5975 | |
| 12 | .3361 | .6348 | .5415 | | | .4668 | .4294 |
| 13 | .3361 | .6161 | .6722 | | .5415 | .5041 | .4294 |
| 14 | | | .5041 | .4854 | | | .3734 |
| 15 | .3361 | .5228 | .5975 | | | | |
| 16 | | .5601 | .5975 | | | .4854 | .4668 |
| 17 | .3361 | | .5601 | | .5415 | .4668 | .4294 |
| 18 | .3361 | .4294 | .4481 | | .4481 | .4294 | .4108 |
| 19 | | .4108 | .3734 | .4108 | .4294 | .3734 | |
| 20 | | .3547 | .3547 | .3734 | .3921 | .3734 | .4108 |
| 21 | | .3547 | .3734 | .3734 | .3734 | .3547 | .4108 |
| 22 | .3361 | .3547 | | | .3734 | | .3547 |
| 23 | | | .3734 | | .3361 | | |
| 24 | .3361 | | .3174 | .3441 | .3361 | | .4108 |
| Max | .3734 | .6348 | .6722 | .5601 | .5601 | .5975 | .4668 |
| Min | .3361 | .3547 | .3174 | .3361 | .3361 | .3361 | .3361 |
| Avg | .3439 | .4411 | .4690 | .4115 | .4184 | .4414 | .3944 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 201 / 11KV PHANASPADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6287 | | | | .6478 | .6036 | |
| 2 | | .6097 | | .5544 | .8764 | | .6283 |
| 3 | .5601 | .5716 | | | .724 | .5487 | |
| 4 | | .5716 | .7095 | .5975 | .8383 | | .6722 |
| 5 | .6722 | .6478 | | | .8764 | .7207 | |
| 6 | | .8192 | | .7762 | .9526 | | .8215 |
| 7 | .7095 | .9145 | .8131 | | .9717 | .924 | |
| 8 | | .9717 | .9145 | .924 | .9526 | .9511 | .8589 |
| 9 | .8962 | .9335 | .8779 | | .9717 | .9145 | .9149 |
| 10 | .8962 | | | .7023 | .8002 | .9412 | .7947 |
| 11 | .4572 | | .6908 | .6859 | .6401 | .6584 | .6653 |
| 12 | .8002 | | .5601 | .6287 | .5853 | .6535 | |
| 13 | .7621 | | .6348 | .6097 | .5611 | .6535 | .6099 |
| 14 | .6859 | | .5544 | .5716 | .543 | .5788 | .5914 |
| 15 | .5906 | | .4805 | .5144 | .5068 | .5041 | |
| 16 | .5906 | | .5175 | .4954 | .543 | .5415 | .5487 |
| 17 | .6287 | .5853 | .6468 | .6287 | | .5975 | |
| 18 | .8383 | .6767 | .7392 | | .724 | .7095 | .6697 |
| 19 | 1.0098 | .6219 | .8131 | .8954 | .8688 | .8589 | .8507 |
| 20 | .9717 | | .9055 | .9526 | .8507 | .8962 | |
| 21 | .9145 | .8962 | .9425 | .9717 | .8869 | .9149 | .8326 |
| 22 | .8764 | .7783 | .8501 | .8383 | | | |
| 23 | .8002 | | .7023 | .8192 | .7316 | | |
| 24 | .7049 | | .7095 | .7049 | .6401 | .9145 | .6838 |
| Max | 1.0098 | .9717 | .9425 | .9717 | .9717 | .9511 | .9149 |
| Min | .4572 | .5716 | .4805 | .4954 | .5068 | .5041 | .5487 |
| Avg | .7497 | .7383 | .7257 | .7151 | .7588 | .7413 | .7245 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 202 / 11KV PUJIT PLAZA SECTOR-11 SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .362 | | | | .362 | .3292 | |
| 2 | | .3048 | | .3326 | .5144 | | .3326 |
| 3 | .3142 | .3048 | | | .4001 | .3439 | |
| 4 | | .3429 | .3696 | .3696 | .4954 | | .3696 |
| 5 | .3696 | .4191 | | | .5716 | .5083 | |
| 6 | | .5144 | | .5121 | .5144 | | .5175 |
| 7 | .5544 | .5525 | .5975 | | .7049 | | |
| 8 | | .6478 | .7207 | .6401 | .6859 | .7762 | .7023 |
| 9 | .6468 | .6478 | .6401 | | .7049 | .6584 | .6099 |
| 10 | .5544 | | | .5121 | .6668 | .7682 | .5359 |
| 11 | .4572 | | .5228 | .4001 | .4656 | .4938 | .5304 |
| 12 | .4382 | | .4481 | .4382 | .4477 | .4755 | |
| 13 | .4382 | | .4668 | .4763 | .4656 | .4572 | .4572 |
| 14 | .381 | | .4435 | .4382 | .4119 | .4207 | .439 |
| 15 | .3239 | | .4251 | .4572 | .4298 | .4572 | |
| 16 | .3429 | | .462 | .4382 | .4835 | .4755 | .4525 |
| 17 | .4001 | | .5304 | .5525 | | .5121 | |
| 18 | .5525 | .6584 | .567 | | .5373 | .5487 | .4755 |
| 19 | .6287 | .6584 | .567 | .6859 | .5973 | .6584 | .6219 |
| 20 | .5716 | | .5853 | .6097 | .543 | .6036 | |
| 21 | .5906 | .5487 | .567 | .5906 | .5304 | .5304 | .5316 |
| 22 | .5716 | .5359 | .4938 | .5525 | | | |
| 23 | .4572 | | .439 | .4572 | .439 | | |
| 24 | .4001 | | .4108 | .4191 | | .3696 | .3881 |
| Max | .6468 | .6584 | .7207 | .6859 | .7049 | .7762 | .7023 |
| Min | .3142 | .3048 | .3696 | .3326 | .362 | .3292 | .3326 |
| Avg | .4678 | .5113 | .5143 | .4935 | .5225 | .5215 | .4974 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 203 / 11KV BELAPUR DTC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5906 | | | | .5716 | .5487 | |
| 2 | | .5335 | | .5415 | .724 | | .5544 |
| 3 | .415 | .4954 | | | .6097 | .4706 | |
| 4 | | .4763 | .5373 | .4854 | .743 | | .5281 |
| 5 | .4481 | .4763 | | | .724 | .7023 | |
| 6 | | .7621 | | .6722 | .8192 | | .7167 |
| 7 | .6722 | .8383 | .7316 | | .8383 | | |
| 8 | | .8192 | .8596 | .7842 | .8764 | .8413 | .8488 |
| 9 | .8299 | .7811 | .7316 | | .8192 | .7023 | .7545 |
| 10 | .7733 | | | .6161 | .6478 | .8501 | .7095 |
| 11 | .7049 | | .5415 | .5144 | .4557 | .5228 | .5601 |
| 12 | .6478 | | .5041 | .5144 | .9816 | .4904 | |
| 13 | .5716 | | .4668 | .4954 | .3856 | .4904 | .4294 |
| 14 | .5525 | | .4481 | .4382 | .3506 | .4668 | .4108 |
| 15 | .4954 | | .4294 | .4572 | .3856 | .4668 | |
| 16 | .4954 | | .4294 | .4572 | .4031 | .4294 | .3881 |
| 17 | .5335 | | .5228 | .5144 | | .4668 | |
| 18 | .6478 | .567 | .6348 | | | .6161 | .567 |
| 19 | .8383 | .6733 | .7095 | .7811 | .691 | .7282 | .6767 |
| 20 | .7811 | | .7655 | .8192 | .691 | .7842 | |
| 21 | .8192 | .6626 | .7842 | .8192 | .7164 | .7655 | .6401 |
| 22 | .7621 | .6447 | .7655 | .7621 | | | |
| 23 | .6859 | | .6535 | .6859 | .6335 | | |
| 24 | .6287 | | .567 | .6097 | .6097 | .5853 | .6099 |
| Max | .8383 | .8383 | .8596 | .8192 | .9816 | .8501 | .8488 |
| Min | .415 | .4763 | .4294 | .4382 | .3506 | .4294 | .3881 |
| Avg | .6447 | .6442 | .6157 | .6093 | .6513 | .6071 | .5996 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 204 / 11KV S/STN TRANSFORMER

SHEDDABLE URBAN

R.M.U S Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0762 | | | | .0762 | .0572 | |
| 2 | | .0572 | | .0572 | .0762 | | .0572 |
| 3 | .0381 | .0572 | | | .0572 | .0762 | |
| 4 | | .0572 | .0572 | .0572 | .0572 | | .0572 |
| 5 | .0381 | .0572 | | | .0762 | .0572 | |
| 6 | | .0762 | | .0381 | .0762 | | .0572 |
| 7 | .0381 | .0762 | .0572 | | .0762 | | |
| 8 | | .0762 | .0572 | .0381 | .0572 | .0572 | .0381 |
| 9 | .0572 | .0762 | .0381 | | .0762 | .0572 | .0572 |
| 10 | .0572 | | | .0762 | .0762 | .0572 | .0572 |
| 11 | .0762 | | .0572 | .0762 | .0572 | .0572 | .0572 |
| 12 | .0762 | | .0572 | .0762 | .0572 | .0572 | |
| 13 | .0762 | | .0572 | .0762 | .0381 | .0572 | .0572 |
| 14 | .0762 | | .0572 | .0572 | .0572 | .0762 | .0381 |
| 15 | .0762 | | .0572 | .0762 | .0762 | .0572 | |
| 16 | .0762 | | .0762 | .0572 | .0762 | .0572 | |
| 17 | .0762 | | .0572 | .0762 | | .0572 | |
| 18 | .0762 | .0762 | .0572 | | | .0572 | .9922 |
| 19 | .0762 | .0572 | .0572 | .0762 | .0762 | .0762 | .0762 |
| 20 | .0762 | | .0572 | .0762 | .0762 | .0381 | |
| 21 | .0762 | .0572 | .0572 | .0762 | .0762 | .0762 | |
| 22 | .0762 | .0572 | .0381 | .0762 | | | |
| 23 | .0762 | | .0381 | .0762 | .0572 | | |
| 24 | .0762 | | .0762 | .0572 | | .0572 | .0762 |
| Max | .0762 | .0762 | .0762 | .0762 | .0762 | .0762 | .9922 |
| Min | .0381 | .0572 | .0381 | .0381 | .0381 | .0381 | .0381 |
| Avg | .0686 | .0651 | .0561 | .0667 | .0676 | .0604 | .1351 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 205 / 11KV SAI VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9145 | | | | .8954 | .7602 | |
| 2 | | .8002 | | .788 | .8764 | | .7888 |
| 3 | .6859 | .724 | | | .8573 | .6984 | |
| 4 | | .724 | .7712 | .7701 | .8954 | | .7716 |
| 5 | .7202 | .7621 | | | .8192 | .8059 | |
| 6 | | .9335 | | | .8764 | | .8573 |
| 7 | .8139 | .9335 | .8059 | | .9526 | .8059 | |
| 8 | | .9717 | .8842 | .9214 | 1.0098 | .8871 | .9088 |
| 9 | .9156 | 1.0669 | .9568 | | 1.0479 | .929 | .9602 |
| 10 | .8065 | | | 1.1104 | 1.2193 | 1.0277 | 1.0631 |
| 11 | .8954 | | 1.1462 | 1.2193 | 1.1393 | 1.2048 | 1.046 |
| 12 | .9717 | | 1.1641 | 1.1622 | 1.0867 | 1.2403 | |
| 13 | 1.0098 | | 1.1641 | 1.2193 | 1.1568 | 1.1871 | 1.1789 |
| 14 | .9907 | | 1.1641 | 1.2384 | 1.1789 | 1.1871 | 1.1218 |
| 15 | 1.0288 | | 1.1999 | 1.3717 | 1.1488 | 1.258 | |
| 16 | .9907 | | 1.1568 | 1.3717 | 1.1317 | 1.2403 | 1.0867 |
| 17 | 1.0288 | | 1.1919 | 1.3527 | | 1.2403 | |
| 18 | 1.1241 | 1.2894 | 1.1393 | | | 1.2403 | 1.0387 |
| 19 | 1.2384 | 1.1946 | 1.1568 | 1.2955 | 1.1145 | 1.2715 | 1.1462 |
| 20 | 1.2384 | | 1.1744 | 1.2765 | 1.1443 | 1.2357 | |
| 21 | 1.3146 | 1.1222 | 1.1393 | 1.2193 | 1.0867 | 1.1641 | |
| 22 | 1.2955 | 1.0029 | 1.0867 | 1.2193 | | | |
| 23 | 1.1431 | | .9568 | 1.1241 | .8859 | | |
| 24 | .9907 | | .9134 | 1.0479 | 1.0479 | .8413 | 1.1283 |
| Max | 1.3146 | 1.2894 | 1.1999 | 1.3717 | 1.2193 | 1.2715 | 1.1789 |
| Min | .6859 | .724 | .7712 | .7701 | .8192 | .6984 | .7716 |
| Avg | 1.0059 | .9604 | 1.0651 | 1.1593 | 1.0272 | 1.0645 | 1.0074 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 206 / 11KV CHROMA SECTOR-15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4572 | | | | .4382 | .4207 | |
| 2 | | .4191 | | | .3239 | | .3582 |
| 3 | .3258 | .3429 | | | .2858 | .362 | |
| 4 | | .3429 | .3814 | .3856 | .2477 | | .2804 |
| 5 | .3353 | .381 | | | .4191 | .4207 | |
| 6 | | .4191 | | | .4572 | | .3506 |
| 7 | .3605 | .5144 | .4784 | | .4954 | .4207 | |
| 8 | | .4763 | .4607 | .443 | .5335 | .4382 | .4733 |
| 9 | .4096 | .4954 | .5316 | | .5906 | .567 | .4733 |
| 10 | .426 | | | .591 | .6097 | .5552 | .5609 |
| 11 | .6478 | | .695 | .6287 | .7265 | .6626 | .5959 |
| 12 | .6478 | | .7865 | .7621 | .7087 | .7973 | |
| 13 | .6287 | | .7316 | .8192 | .6733 | .7619 | .6556 |
| 14 | .6478 | | .724 | .7621 | .7537 | .7619 | .6661 |
| 15 | .6478 | | .7783 | .7621 | .7186 | .7442 | |
| 16 | .6097 | | .7087 | .7811 | .7186 | .7087 | .6556 |
| 17 | .6478 | | .7265 | .7811 | | .7087 | |
| 18 | .5906 | .5441 | .7087 | | | .7442 | .6485 |
| 19 | .6668 | .6081 | .7087 | .7811 | | .7164 | .5784 |
| 20 | .6859 | | .691 | .7049 | .6626 | .6626 | |
| 21 | .7811 | .5636 | .6379 | .743 | .6447 | .6805 | |
| 22 | .6097 | .5138 | .5847 | .7049 | | | |
| 23 | .6097 | | .5316 | .6287 | .5249 | | |
| 24 | .5716 | | .4973 | .5144 | .6379 | .4572 | .6201 |
| Max | .7811 | .6081 | .7865 | .8192 | .7537 | .7973 | .6661 |
| Min | .3258 | .3429 | .3814 | .3856 | .2477 | .362 | .2804 |
| Avg | .5654 | .4684 | .6313 | .6746 | .5585 | .6100 | .5321 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 207 / 11KV OLD R.M.U SECTOR-15 SHEDDABLE URBAN
S/Stn Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0953 | | | | .0762 | .0739 | |
| 2 | | .0762 | | | .0762 | | .0686 |
| 3 | .0648 | .0762 | | | .0762 | .0732 | |
| 4 | | .0762 | .052 | .0724 | .0953 | | .061 |
| 5 | .0633 | .0572 | | | .0953 | .0554 | |
| 6 | | .0953 | | | .0762 | | .0572 |
| 7 | .0633 | .0762 | .0526 | | .0953 | .0554 | |
| 8 | | .0762 | .0693 | .0732 | .0953 | .0549 | .0556 |
| 9 | .0625 | .0762 | .0686 | | .0762 | .0739 | .1113 |
| 10 | .0625 | | | .1991 | .0762 | .181 | .1551 |
| 11 | .0572 | | .1829 | .1524 | .2075 | .1848 | .1269 |
| 12 | .0762 | | .128 | .1334 | .1132 | .1494 | |
| 13 | .0762 | | .1829 | .1143 | .2075 | .1867 | .132 |
| 14 | .0762 | | .1052 | .1715 | .1867 | .1867 | .0892 |
| 15 | .0953 | | .1753 | .1905 | .0934 | .1867 | |
| 16 | .0953 | | .1086 | .1334 | .1109 | .1867 | .1337 |
| 17 | .0953 | | | .2096 | | .181 | |
| 18 | .0953 | .0983 | .1109 | | | .1448 | .061 |
| 19 | .0953 | .0819 | | .0953 | | .1629 | .064 |
| 20 | .0953 | | .0732 | .0953 | .0732 | .0905 | |
| 21 | .0953 | .0663 | | .0762 | .0554 | .0905 | |
| 22 | .0762 | .0663 | .0732 | .0953 | | | |
| 23 | .0762 | | .0732 | .0953 | .056 | | |
| 24 | .0953 | | .0686 | .0953 | .0732 | .056 | .0655 |
| Max | .0953 | .0983 | .1829 | .2096 | .2075 | .1867 | .1551 |
| Min | .0572 | .0572 | .052 | .0724 | .0554 | .0549 | .0556 |
| Avg | .0806 | .0769 | .1016 | .1252 | .1008 | .1250 | .0909 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 208 / 11KV GREAT EASTERN SUMMIT SHEDDABLE URBAN
SECT Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0479 | | | | 1.0479 | .9156 | |
| 2 | | .9907 | | | 1.1241 | | .8907 |
| 3 | .7316 | .9526 | | | 1.086 | .8383 | |
| 4 | | | .7625 | .7621 | 1.1431 | | .8535 |
| 5 | .7621 | .9145 | | | 1.0479 | .8619 | |
| 6 | | 1.086 | | | 1.0288 | | .884 |
| 7 | .743 | 1.105 | .9054 | | 1.1241 | .9496 | |
| 8 | | 1.105 | .8619 | .9922 | 1.2193 | 1.0513 | .7895 |
| 9 | .8573 | 1.2193 | 1.0486 | | 1.3336 | 1.073 | .86 |
| 10 | .8859 | | | 1.1203 | 1.4289 | 1.2597 | 1.0105 |
| 11 | 1.1431 | | 1.2742 | 1.448 | 1.2239 | 1.326 | 1.0084 |
| 12 | 1.1241 | | 1.4083 | 1.3908 | 1.2266 | 1.3923 | |
| 13 | 1.2003 | | 1.2742 | 1.467 | | 1.326 | 1.1126 |
| 14 | 1.2193 | | 1.2125 | 1.3146 | 1.1469 | 1.2763 | 1.0185 |
| 15 | 1.105 | | 1.278 | 1.448 | 1.2125 | 1.2929 | |
| 16 | 1.105 | | 1.3117 | 1.3908 | 1.3108 | 1.326 | .9686 |
| 17 | 1.086 | | 1.247 | 1.4289 | | 1.326 | |
| 18 | 1.2003 | 1.1797 | 1.2955 | | | 1.326 | |
| 19 | 1.2574 | 1.1797 | 1.2146 | 1.5051 | | 1.326 | 1.0883 |
| 20 | 1.2574 | | 1.1336 | | 1.1568 | 1.21 | |
| 21 | 1.2193 | 1.0774 | 1.1336 | 1.2955 | 1.0898 | 1.094 | |
| 22 | 1.1812 | 1.0395 | .9717 | 1.1812 | | | |
| 23 | 1.1431 | | .9231 | 1.2193 | .9496 | | |
| 24 | 1.0288 | | .9496 | 1.105 | 1.2763 | .9431 | 1.0159 |
| Max | 1.2574 | 1.2193 | 1.4083 | 1.5051 | 1.4289 | 1.3923 | 1.1126 |
| Min | .7316 | .9145 | .7625 | .7621 | .9496 | .8383 | .7895 |
| Avg | 1.0649 | 1.0772 | 1.1226 | 1.2713 | 1.1672 | 1.1639 | .9584 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 401 / 33KV SBI - 2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3475 | .5144 | .4372 | .4321 | .5658 | .583 | .3841 |
| 2 | .3475 | .5144 | | .4321 | .5144 | .5344 | .3795 |
| 3 | .3475 | .5144 | | .4167 | .5144 | .5344 | .3658 |
| 4 | .3475 | .5144 | .3795 | .4115 | .5144 | .5533 | .3612 |
| 5 | .3384 | .5144 | .3795 | .3704 | .5144 | .4801 | .3475 |
| 6 | .3338 | .5144 | .3841 | .3658 | .5658 | .4801 | .3658 |
| 7 | .3475 | .5144 | .3401 | .3795 | .5658 | .427 | .4115 |
| 8 | .3567 | .5144 | .3932 | .4218 | .6173 | .4321 | .463 |
| 9 | .3567 | .6173 | .3601 | .5898 | | .4858 | .5898 |
| 10 | .427 | .9774 | .7716 | .7122 | .639 | .7122 | .7282 |
| 11 | .463 | 1.1203 | .7802 | .9259 | .6962 | .4024 | .9774 |
| 12 | .463 | 1.1643 | .7888 | .9259 | .7545 | .7522 | 1.0288 |
| 13 | .5658 | 1.2197 | .7973 | .823 | .8139 | .7682 | .9259 |
| 14 | .5658 | 1.1088 | .8059 | .9259 | .8745 | .7682 | .9259 |
| 15 | .5658 | 1.0425 | .823 | .9774 | .8842 | .7682 | 1.1317 |
| 16 | .5658 | .9774 | .7522 | .9774 | .9465 | | .9774 |
| 17 | .5658 | .9134 | .7522 | .8745 | 1.0208 | .7059 | .9259 |
| 18 | .5658 | .8505 | .691 | .7716 | .9774 | .7522 | .6173 |
| 19 | .5144 | .7888 | .631 | .7202 | .9036 | .5847 | .6173 |
| 20 | .5144 | .7282 | .503 | .6173 | .763 | .5144 | .5658 |
| 21 | .5144 | .6173 | .5087 | .5658 | .7545 | .4527 | .5658 |
| 22 | .5144 | .6104 | .4475 | .5658 | | .4527 | .5658 |
| 23 | .5144 | | .4424 | .5658 | .6464 | | |
| 24 | .3475 | .5144 | .5721 | .4424 | .5658 | .5967 | .3932 |
| Max | .5658 | 1.2197 | .823 | .9774 | 1.0208 | .7682 | 1.1317 |
| Min | .3338 | .5144 | .3401 | .3658 | .5144 | .4024 | .3475 |
| Avg | .4496 | .7550 | .5791 | .6338 | .7097 | .5791 | .6354 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 402 / 33KV IDBI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 5 | .4572 | |
| 9 | | .6173 |
| Max | .4572 | .6173 |
| Min | .4572 | .6173 |
| Avg | .4572 | .6173 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 201 / 11 KV Sector-19 Ulwe

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 | 20-JAN-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11 | .8002 | | | |
| 12 | | .7621 | .7811 | |
| 13 | | | .6668 | .6859 |
| 15 | | .6859 | | |
| Max | .8002 | .7621 | .7811 | .6859 |
| Min | .8002 | .6859 | .6668 | .6859 |
| Avg | .8002 | .724 | .7240 | .6859 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 202 / 11 KV Sector-21 Ulwe
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 17-JAN-17 | 19-JAN-17 | 20-JAN-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 12 | .3429 | .3429 | |
| 13 | | .2858 | .3429 |
| 15 | .2858 | | |
| Max | .3429 | .3429 | .3429 |
| Min | .2858 | .2858 | .3429 |
| Avg | .3144 | .3144 | .3429 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 203 / 11 KV Unnati Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 | 20-JAN-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11 | .5144 | | | |
| 12 | | .362 | .362 | |
| 13 | | | .381 | .362 |
| 15 | | .381 | | |
| Max | .5144 | .381 | .381 | .362 |
| Min | .5144 | .362 | .362 | .362 |
| Avg | .5144 | .3715 | .3715 | .362 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 204 / 11 KV Sector-5 Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 | 20-JAN-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11 | .381 | | | |
| 12 | | .3429 | .4382 | |
| 13 | | | .3429 | .381 |
| 15 | | .3239 | | |
| Max | .381 | .3429 | .4382 | .381 |
| Min | .381 | .3239 | .3429 | .381 |
| Avg | .381 | .3334 | .3906 | .381 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 205 / 11 KV Sector-20 Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 | 20-JAN-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11 | .1334 | | | |
| 12 | | .0953 | .0762 | |
| 13 | | | | .0953 |
| 15 | | .0953 | | |
| Max | .1334 | .0953 | .0762 | .0953 |
| Min | .1334 | .0953 | .0762 | .0953 |
| Avg | .1334 | .0953 | .0762 | .0953 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284062 / 33/11 KV SECTOR-23 ULWE

Feeder No / Name : 208 / 11 KV Wahal Sec-23

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 | 20-JAN-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 11 | .8383 | | | |
| 12 | | .8954 | .8002 | |
| 13 | | | .7621 | .6859 |
| 15 | | .8954 | | |
| Max | .8383 | .8954 | .8002 | .6859 |
| Min | .8383 | .8954 | .7621 | .6859 |
| Avg | .8383 | .8954 | .7812 | .6859 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 305 / 22 KV URAN PHATA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 20-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 1.6461 |
| 2 | 1.6461 |
| 3 | 1.5546 |
| 4 | 1.5546 |
| 5 | 1.5546 |
| 6 | 1.5546 |
| 7 | 1.5242 |
| 8 | 1.5546 |
| 9 | 1.5851 |
| 10 | 1.7071 |
| 11 | 1.7071 |
| 12 | 1.6766 |
| 13 | 1.7071 |
| 14 | 1.7071 |
| 15 | 1.7071 |
| 16 | 1.7071 |
| 17 | 1.7071 |
| 18 | 1.6766 |
| 19 | 1.6766 |
| 20 | 1.7071 |
| 21 | 1.6461 |
| 22 | 1.6461 |
| 23 | 1.6156 |
| 24 | 1.5851 |
| Max | 1.7071 |
| Min | 1.5242 |
| Avg | 1.6398 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 201 / 11KV AIR INDIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5041 | .463 | .4801 | .5041 | .5144 | .5144 | .5601 |
| 2 | .4668 | .4458 | .463 | .4477 | .463 | .4801 | .5228 |
| 3 | .4668 | .4115 | .4458 | .4481 | .4287 | .4801 | .4668 |
| 4 | .4481 | .4115 | .4801 | .5041 | .4287 | .5144 | .5228 |
| 5 | .4108 | .4801 | .5487 | .5228 | .463 | .583 | .5601 |
| 6 | .4481 | .5487 | .6859 | .6722 | .583 | .6344 | .6161 |
| 7 | .5041 | .7716 | .7888 | .8962 | .8573 | .823 | .6722 |
| 8 | | .8059 | .8573 | .9149 | .7888 | .8402 | .7282 |
| 9 | .7655 | .703 | .7202 | .8059 | .7202 | .7888 | .8215 |
| 10 | .9259 | .7373 | .7842 | .7716 | .703 | .8402 | .8402 |
| 11 | .8059 | .703 | .7655 | .7545 | .7545 | .7842 | .7373 |
| 12 | .8573 | .6687 | .7282 | .6344 | .6173 | .4108 | .6687 |
| 13 | .7545 | | .6161 | .5658 | .2229 | .7468 | .6173 |
| 14 | .6173 | .6173 | | .5144 | .5316 | .6348 | .583 |
| 15 | .6344 | .5144 | | .5487 | .5316 | | .583 |
| 16 | .583 | .5658 | | .4973 | .5316 | .5601 | .5487 |
| 17 | .6344 | .5658 | .6348 | .6001 | .6001 | | .6001 |
| 18 | .6516 | .6173 | | .6687 | .6173 | .8215 | .7545 |
| 19 | .7888 | .7373 | .8215 | .7373 | .703 | .7655 | .7716 |
| 20 | .6687 | .7373 | .7842 | .7545 | .6859 | .7655 | .7202 |
| 21 | .6859 | .7202 | | .7545 | .7545 | .7655 | .6687 |
| 22 | .6687 | .6687 | | .6687 | | | .6687 |
| 23 | .6344 | .6344 | .6447 | .6001 | | | .6344 |
| 24 | .5601 | .6344 | .7842 | .5975 | .5316 | .9088 | .6348 |
| Max | .9259 | .8059 | .8573 | .9149 | .8573 | .9088 | .8402 |
| Min | .4108 | .4115 | .4458 | .4477 | .2229 | .4108 | .4668 |
| Avg | .6298 | .6158 | .6685 | .6410 | .5924 | .6831 | .6459 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 202 / 11KV JAWAHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1494 | .1372 | .1543 | .1307 | .1029 | .1543 | .168 |
| 2 | .1307 | .1372 | .1543 | .1307 | .1029 | .1543 | .1494 |
| 3 | .1307 | .12 | .1543 | .1307 | .1029 | .1543 | .1494 |
| 4 | .1307 | .12 | .1715 | .1307 | .1029 | .1543 | .1494 |
| 5 | .1307 | .12 | .1715 | .1494 | .1372 | .1543 | .168 |
| 6 | .1494 | .1372 | .1715 | .168 | .1372 | .1543 | .168 |
| 7 | .1494 | .1886 | .1886 | .1867 | .1715 | .1715 | .1867 |
| 8 | .1494 | .1715 | .2058 | .1867 | .1715 | .2058 | .2054 |
| 9 | .1867 | .1715 | .1715 | .1886 | .1886 | .2401 | .1867 |
| 10 | .1886 | .2058 | .2241 | .2572 | .2401 | .2614 | .2401 |
| 11 | .2572 | | .2054 | .2572 | .2229 | | .2915 |
| 12 | .2572 | | .2054 | .1715 | .2229 | 1.8298 | .2229 |
| 13 | .1715 | | .1867 | .2401 | .1543 | .2054 | .1886 |
| 14 | .2058 | .1543 | | .1886 | .1715 | .1867 | .1886 |
| 15 | .2229 | .1543 | .1494 | .1715 | .2229 | .2054 | .1886 |
| 16 | .1715 | | | .1715 | .2229 | .2614 | .2572 |
| 17 | .2743 | .12 | .2241 | .2572 | .2572 | | .2229 |
| 18 | .2743 | .1543 | | .1886 | .1886 | .2801 | .2401 |
| 19 | .3258 | .1886 | .2054 | .2058 | .2229 | .2987 | .2915 |
| 20 | .3086 | .1886 | .2241 | .2229 | .2058 | .2987 | .3086 |
| 21 | .2229 | .1715 | | .2058 | .2229 | .2427 | .2572 |
| 22 | .1886 | .1886 | | .1715 | | | .1886 |
| 23 | .1715 | .1543 | .168 | .1543 | | | .1543 |
| 24 | .168 | .1543 | .1543 | .1494 | .1372 | .1543 | .168 |
| Max | .3258 | .2058 | .2241 | .2572 | .2572 | 1.8298 | .3086 |
| Min | .1307 | .12 | .1494 | .1307 | .1029 | .1543 | .1494 |
| Avg | .1965 | .1569 | .1837 | .1840 | .1777 | .2884 | .2058 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 203 / 11KV BANK OF INDIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9522 | .9774 | .6859 | .7621 | .9259 | .9945 | 1.0082 |
| 2 | .8775 | .823 | .6516 | .8962 | .8745 | .9602 | .9709 |
| 3 | .9335 | .7888 | .7202 | .8402 | .823 | .9259 | 1.0269 |
| 4 | .8962 | .7545 | .823 | .8775 | .7888 | .9602 | 1.1203 |
| 5 | .9709 | .8916 | .9259 | .9335 | .8745 | 1.0288 | 1.1576 |
| 6 | 1.0456 | .9602 | 1.0288 | 1.0269 | 1.0631 | 1.1145 | 1.2323 |
| 7 | 1.307 | .9774 | 1.1831 | 1.251 | 1.406 | 1.2003 | 1.5497 |
| 8 | 1.419 | 1.0288 | 1.5775 | 1.6244 | 1.5947 | .6516 | 1.643 |
| 9 | 1.2696 | 1.2003 | 1.4232 | 1.4746 | 1.3717 | 1.6804 | 1.531 |
| 10 | 1.0974 | 1.3889 | 1.587 | 1.4575 | 1.6461 | | 1.4575 |
| 11 | 1.166 | | 1.6244 | 1.6289 | 1.4918 | 1.7551 | 1.4403 |
| 12 | 1.286 | | 1.6244 | 1.286 | 1.2346 | 1.8298 | 1.5775 |
| 13 | 1.1488 | | 1.5497 | 1.3032 | 1.1317 | 1.7551 | .1886 |
| 14 | .9259 | 1.5604 | | 1.3032 | 1.286 | 1.7177 | 1.2003 |
| 15 | 1.0974 | 1.6975 | 1.6617 | 1.5947 | 1.4918 | 1.8484 | 1.4918 |
| 16 | 1.3375 | | | 1.4232 | 1.4918 | 1.8484 | 1.4575 |
| 17 | 1.166 | 1.5089 | 1.587 | 1.3546 | 1.6118 | | 1.5947 |
| 18 | 1.406 | 1.1831 | | 1.3717 | 1.3717 | 1.643 | 1.5089 |
| 19 | 1.5947 | 1.4746 | 1.4377 | 1.3889 | 1.5775 | 1.7737 | 1.7318 |
| 20 | 1.5775 | 1.3203 | 1.166 | 1.0974 | 1.3546 | 1.307 | 1.6289 |
| 21 | 1.1831 | 1.0974 | | .8745 | 1.3203 | 1.3256 | 1.2174 |
| 22 | 1.2174 | .9431 | | 1.046 | | | 1.1145 |
| 23 | .9602 | 1.1317 | 1.0829 | 1.0288 | | | 1.1145 |
| 24 | 1.1389 | 1.0117 | .7373 | .9896 | .9259 | 1.046 | 1.0456 |
| Max | 1.5947 | 1.6975 | 1.6617 | 1.6289 | 1.6461 | 1.8484 | 1.7318 |
| Min | .8775 | .7545 | .6516 | .7621 | .7888 | .6516 | .1886 |
| Avg | 1.1656 | 1.1360 | 1.2146 | 1.2014 | 1.2572 | 1.3683 | 1.2921 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 205 / 11KV ARMY NIWAS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1494 | .1372 | .1543 | .1494 | .1372 | .1543 | .168 |
| 2 | .1307 | .1372 | .1543 | .1494 | .12 | .1543 | .168 |
| 3 | .1307 | .1372 | .1543 | .1494 | .12 | .1543 | .1494 |
| 4 | .1307 | .1372 | .1543 | .168 | .12 | .1543 | .1494 |
| 5 | .1494 | .1372 | .1715 | .168 | .1372 | .1543 | .1494 |
| 6 | .1867 | .1715 | .2058 | .1867 | .1543 | .1543 | .1494 |
| 7 | .2054 | .2401 | .2915 | .2987 | .3258 | .2743 | .2241 |
| 8 | .2241 | .3601 | .3086 | .3174 | .3258 | .3601 | .2987 |
| 9 | .2427 | .2058 | .2743 | .1886 | .2572 | .2743 | .2987 |
| 10 | .2572 | .2229 | .2987 | .2401 | .2572 | | .2401 |
| 11 | .2743 | | .1867 | .2058 | .2058 | .2054 | .2572 |
| 12 | .2915 | | .1494 | .2229 | .2401 | .2987 | .2572 |
| 13 | .2743 | | .168 | .1372 | .2229 | .2054 | .2401 |
| 14 | .1372 | .1886 | | .1543 | .1715 | .1494 | .1886 |
| 15 | .1543 | .1715 | .168 | .1372 | .1543 | .168 | .1543 |
| 16 | .1543 | | | .1372 | .1543 | .168 | .1372 |
| 17 | .1543 | .1543 | .168 | .1543 | .1543 | | .1715 |
| 18 | .2229 | .1543 | | .2058 | .2058 | .2241 | .2401 |
| 19 | .2401 | .2743 | .2614 | .2401 | .2401 | .2614 | .2572 |
| 20 | .2401 | .2058 | .3174 | .2229 | .2058 | .2614 | .2401 |
| 21 | .2229 | .2058 | | .2401 | .2229 | .2614 | .2229 |
| 22 | .2058 | .2229 | | .2229 | | | .2058 |
| 23 | .1886 | .1715 | .2054 | .1543 | | | .2058 |
| 24 | .1494 | .1372 | .1543 | .1494 | .1372 | .1543 | .168 |
| Max | .2915 | .3601 | .3174 | .3174 | .3258 | .3601 | .2987 |
| Min | .1307 | .1372 | .1494 | .1372 | .12 | .1494 | .1372 |
| Avg | .1965 | .1886 | .2077 | .1917 | .1941 | .2096 | .2059 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 206 / 11 KV LENYADRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2614 | .2572 | .2401 | .2801 | .2401 | .2401 | .2801 |
| 2 | .2614 | .2229 | .2229 | .2427 | .2058 | .2229 | .2427 |
| 3 | .2241 | .2229 | .2572 | .2427 | .2058 | .2058 | .2241 |
| 4 | .2241 | .2229 | .3086 | .2801 | .2058 | .2401 | .2241 |
| 5 | .2241 | .2401 | .3429 | .2987 | .2401 | .2743 | .2614 |
| 6 | .2614 | .2743 | .3601 | .3174 | .2743 | .3086 | .2801 |
| 7 | .2801 | .3601 | .3772 | .4294 | .3772 | .3944 | .3361 |
| 8 | .2987 | .4115 | .4287 | .4668 | .4115 | .4458 | .3361 |
| 9 | .4108 | .4287 | .3944 | .4115 | .4801 | .3772 | .4108 |
| 10 | .3944 | .3944 | .4481 | .3772 | .3772 | | .4115 |
| 11 | .3601 | | .3734 | .3601 | .2915 | .3547 | .3944 |
| 12 | .3601 | | .3361 | .2743 | .2915 | .3361 | .3086 |
| 13 | .3772 | | .3174 | .2743 | .2915 | 1.4377 | .3086 |
| 14 | .3258 | .2743 | | .2572 | .1829 | .2987 | .2915 |
| 15 | .2743 | .2743 | .2614 | .2572 | .2743 | .2801 | .2743 |
| 16 | .2915 | | | .2401 | .2743 | .2801 | .2743 |
| 17 | .2915 | .2915 | .2987 | .2743 | .2743 | | .2915 |
| 18 | .3258 | .3429 | | .2915 | .3258 | .3361 | .3258 |
| 19 | .4115 | .3429 | .3547 | .3086 | .4115 | .3734 | .3944 |
| 20 | .3944 | .3944 | .3921 | .3944 | .3944 | .3921 | .4115 |
| 21 | .3944 | .4287 | | .3944 | .3944 | .3921 | .4115 |
| 22 | .3944 | .3258 | | .3429 | | | .3429 |
| 23 | .3086 | .3086 | .3174 | .3258 | | | .3086 |
| 24 | .2987 | .2572 | .2743 | .2801 | .2743 | .2743 | .3174 |
| Max | .4115 | .4287 | .4481 | .4668 | .4801 | 1.4377 | .4115 |
| Min | .2241 | .2229 | .2229 | .2401 | .1829 | .2058 | .2241 |
| Avg | .3187 | .3138 | .3319 | .3176 | .3045 | .3732 | .3193 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 207 / 11KV BHIMA SHANKAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3734 | .3772 | .3772 | .3921 | .3944 | .3772 | .4108 |
| 2 | .3547 | .3601 | .3429 | .3734 | .3601 | .3429 | .3734 |
| 3 | .3734 | .3429 | .3429 | .3734 | .3601 | .3429 | .3734 |
| 4 | .3361 | .3429 | .4115 | .4481 | .3772 | .4115 | .4108 |
| 5 | .3734 | .3601 | .4801 | .5228 | .4115 | .4801 | .4481 |
| 6 | .3734 | .4115 | .5144 | .5975 | .463 | .5144 | .4481 |
| 7 | .3921 | .5658 | .6001 | .6161 | .583 | .6001 | .5041 |
| 8 | .4854 | .6687 | .6859 | .7655 | .7888 | .6859 | .6535 |
| 9 | .6161 | .5316 | .6687 | .6344 | .6516 | .6687 | .6722 |
| 10 | .6344 | | .5788 | .5316 | | | .5658 |
| 11 | .6001 | | .5041 | .5144 | .5144 | .5041 | .5658 |
| 12 | .5316 | | .5041 | .4458 | .4458 | .5041 | .4973 |
| 13 | .5316 | | .4668 | .4287 | .3944 | .4481 | .4458 |
| 14 | .4801 | .4287 | | .3772 | .3258 | .4481 | .4287 |
| 15 | .4287 | .3429 | .3361 | .3258 | .3429 | .3547 | .4115 |
| 16 | .3772 | | | .3258 | .3429 | | .3772 |
| 17 | .4115 | .3944 | .3921 | .3772 | .3772 | | .4458 |
| 18 | .5487 | .463 | | .4973 | .4973 | .5041 | .5144 |
| 19 | .5658 | 2.2634 | .5788 | .5487 | .5487 | .5788 | .5316 |
| 20 | .5658 | .5658 | .6161 | .5658 | .5658 | .5415 | .5658 |
| 21 | .5658 | .583 | | .583 | .6173 | .5975 | .583 |
| 22 | .5487 | .5487 | | .5658 | | | .5487 |
| 23 | .5144 | .5316 | .5601 | .4973 | | | .5316 |
| 24 | .4668 | .4287 | .4115 | .4668 | .4115 | .4115 | .4481 |
| Max | .6344 | 2.2634 | .6859 | .7655 | .7888 | .6859 | .6722 |
| Min | .3361 | .3429 | .3361 | .3258 | .3258 | .3429 | .3734 |
| Avg | .4771 | .5532 | .4933 | .4906 | .4654 | .4903 | .4898 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 209 / 11 KV STN TRF

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2987 | .2572 | .2572 | .2801 | .2572 | .2572 | .2801 |
| 2 | .2801 | .2572 | .2401 | .2614 | .2401 | .2401 | .2614 |
| 3 | .2614 | .2401 | .2401 | .2427 | .2058 | .2058 | .2241 |
| 4 | .2427 | .2401 | .2743 | .2427 | .2058 | .2401 | .2241 |
| 5 | .2241 | .2743 | .3086 | .2801 | .2058 | .2915 | .2801 |
| 6 | .2801 | .2915 | .3429 | .3921 | .2915 | .3258 | .3734 |
| 7 | .3547 | .4115 | .4458 | .4108 | .4115 | .4115 | .3734 |
| 8 | .4481 | .5487 | .5316 | .5601 | .5658 | .5658 | .5601 |
| 9 | .3921 | .5487 | .5658 | .4458 | .5487 | .5487 | .5975 |
| 10 | .5316 | .3944 | .4108 | .4115 | .4115 | .4668 | .4115 |
| 11 | .5316 | | .4294 | .3601 | .3601 | .3734 | .4287 |
| 12 | .3601 | | .3361 | .3429 | .3429 | .4108 | .3601 |
| 13 | .3601 | | .3361 | .3258 | .2915 | .1867 | .3086 |
| 14 | .3772 | .2915 | | .2743 | .2743 | .3174 | .2915 |
| 15 | .3086 | .3086 | .5415 | .2743 | .2743 | .2614 | .2743 |
| 16 | .2743 | | .2614 | .2572 | .2743 | .2614 | .2915 |
| 17 | .2743 | .2572 | .2801 | .2572 | .2915 | | .2743 |
| 18 | .3772 | .3086 | | .2915 | .3086 | .3547 | .3086 |
| 19 | .4287 | .4458 | .4481 | .4458 | .5144 | .4668 | .4801 |
| 20 | .463 | .4287 | .4854 | .4287 | .5316 | .4668 | .3944 |
| 21 | .4458 | .463 | | .4287 | .5144 | .5415 | .463 |
| 22 | .3772 | .4287 | | .3944 | | | .3944 |
| 23 | .3429 | .3429 | .3921 | .3258 | | | .3258 |
| 24 | .2987 | .2915 | .2915 | .3174 | .2915 | .2915 | .3174 |
| Max | .5316 | .5487 | .5658 | .5601 | .5658 | .5658 | .5975 |
| Min | .2241 | .2401 | .2401 | .2427 | .2058 | .1867 | .2241 |
| Avg | .3556 | .3515 | .3709 | .3438 | .3461 | .3565 | .3541 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 202 / 11KV APPEJAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4931 | .4786 | .8886 | .9434 | .9472 | .9105 | .4809 |
| 2 | .4504 | .4473 | .8658 | .9227 | .8604 | .8507 | .4595 |
| 3 | .4405 | .4275 | .8261 | .8833 | .8147 | .8253 | .4512 |
| 4 | .4336 | .4245 | .7937 | .8198 | .7923 | .8931 | .4451 |
| 5 | .4351 | .4351 | .4519 | .8841 | .8301 | .9434 | .4443 |
| 6 | .4816 | .5167 | .5548 | 1.1071 | 1.0391 | 1.1035 | .519 |
| 7 | .5144 | .5609 | 1.3164 | 1.2049 | 1.2441 | 1.206 | .5845 |
| 8 | .5838 | .6104 | 1.2923 | 1.3468 | 1.2997 | 1.343 | 1.2799 |
| 9 | .5563 | .6356 | 1.2255 | 1.2392 | 1.2157 | 1.2311 | 1.2711 |
| 10 | .618 | 1.2833 | 1.2441 | .6638 | 1.241 | 1.3226 | 1.3234 |
| 11 | .6333 | .6752 | 1.2875 | .6592 | 1.2803 | 1.0707 | 1.3333 |
| 12 | .6234 | 1.3111 | 1.2194 | .6546 | 1.2468 | 1.398 | 1.3058 |
| 13 | .6386 | 1.2631 | 1.2072 | .6554 | 1.2462 | 1.3319 | 1.2309 |
| 14 | .631 | 1.2425 | 1.1877 | .6546 | 1.19 | 1.2905 | 1.2428 |
| 15 | .5769 | .6135 | 1.1313 | .6287 | 1.1661 | 1.1694 | 1.1611 |
| 16 | .5586 | .5929 | 1.0444 | .5754 | 1.1249 | 1.0728 | 1.1287 |
| 17 | .583 | .5777 | 1.1551 | .583 | 1.177 | 1.2049 | 1.1066 |
| 18 | .7019 | .6584 | 1.3603 | .7186 | 1.3039 | 1.3359 | 1.3279 |
| 19 | .8421 | .8413 | 1.6606 | 1.7116 | 1.7314 | 1.6114 | 1.6274 |
| 20 | .8474 | 1.6507 | 1.6712 | 1.7116 | 1.7146 | 1.637 | 1.6034 |
| 21 | .8162 | .8025 | 1.5859 | 1.5943 | 1.5653 | .8192 | 1.5501 |
| 22 | .7621 | .7735 | 1.4289 | 1.3919 | 1.463 | .7651 | 1.422 |
| 23 | .615 | .5982 | 1.2041 | 1.178 | 1.1923 | .6508 | 1.1428 |
| 24 | .5327 | .5258 | 1.0259 | 1.0173 | 1.034 | .9922 | .5594 |
| Max | .8474 | 1.6507 | 1.6712 | 1.7116 | 1.7314 | 1.637 | 1.6274 |
| Min | .4336 | .4245 | .4519 | .5754 | .7923 | .6508 | .4443 |
| Avg | .5987 | .7478 | 1.1512 | .9896 | 1.1967 | 1.1241 | 1.0417 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 203 / 11KV CIDCO OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3993 | .4214 | .4146 | .7215 | .7537 | .7705 | .4237 |
| 2 | .3742 | .394 | .3742 | .7099 | .7145 | .7259 | .394 |
| 3 | .3719 | .3849 | .365 | .6832 | .689 | .6825 | .3841 |
| 4 | .3727 | .3887 | .6791 | .6775 | .7031 | .6966 | .3818 |
| 5 | .3818 | .4009 | .3795 | .7209 | .7688 | .7891 | .3864 |
| 6 | .407 | .4893 | .4641 | .8333 | .8842 | .8962 | .4397 |
| 7 | .4077 | .5373 | .9427 | .9534 | 1.0031 | .9692 | .4542 |
| 8 | .4854 | .5693 | 1.1081 | 1.147 | 1.0702 | 1.0972 | 1.0944 |
| 9 | .5365 | .618 | 1.1387 | 1.1187 | 1.0972 | 1.0905 | 1.1225 |
| 10 | .5197 | 1.028 | .9532 | .4885 | 1.0288 | 1.0539 | 1.0894 |
| 11 | .5114 | .5152 | .964 | .4527 | .9048 | .9881 | .996 |
| 12 | .4931 | .9571 | .9145 | .4664 | .9046 | .9379 | .9853 |
| 13 | .4824 | 1.0494 | .8939 | .4618 | .8052 | .9292 | .9621 |
| 14 | .4633 | .9362 | .8535 | .4512 | .8855 | .867 | .8684 |
| 15 | .3955 | .4412 | .7743 | .3993 | .7962 | .8093 | .8536 |
| 16 | .3887 | .4473 | .4123 | .41 | .8112 | .8333 | .7924 |
| 17 | .4031 | .4603 | .8219 | .455 | .9045 | .8404 | .8152 |
| 18 | .5106 | .5228 | .9376 | .4976 | .9396 | .9406 | 1.017 |
| 19 | .6272 | .6562 | 1.1965 | 1.2216 | 1.1887 | 1.1782 | 1.2323 |
| 20 | .6135 | 1.2576 | 1.2049 | 1.2227 | 1.2117 | 1.1245 | 1.2637 |
| 21 | .5746 | .615 | 1.1298 | 1.1637 | 1.1296 | .5868 | 1.1714 |
| 22 | .5609 | .5479 | 1.0897 | 1.0648 | 1.0416 | .5769 | 1.0591 |
| 23 | .519 | .5159 | .9739 | .9815 | .982 | .535 | .9895 |
| 24 | .4694 | .4557 | .8526 | .8556 | .8512 | .8492 | .4786 |
| Max | .6272 | 1.2576 | 1.2049 | 1.2227 | 1.2117 | 1.1782 | 1.2637 |
| Min | .3719 | .3849 | .365 | .3993 | .689 | .535 | .3818 |
| Avg | .4695 | .6087 | .8266 | .7566 | .9195 | .8653 | .8190 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 204 / 11KV STEP GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3033 | .314 | .3163 | .6223 | .6028 | .5908 | .3376 |
| 2 | .285 | .2987 | .2964 | .5807 | .5634 | .546 | .3079 |
| 3 | .2728 | .2858 | .2919 | .5574 | .5361 | .5241 | .2964 |
| 4 | .2675 | .2835 | .5601 | .5324 | .5308 | .5739 | .2949 |
| 5 | .2751 | .2957 | .2995 | .5875 | .5876 | .5923 | .3033 |
| 6 | .3155 | .4161 | .4214 | .7598 | .7362 | .743 | .3719 |
| 7 | .3521 | .4313 | .8848 | .8734 | .8612 | .8131 | .426 |
| 8 | .4077 | .4672 | .9581 | .933 | .9671 | .9434 | .84 |
| 9 | .407 | .4146 | .8349 | .8131 | .8478 | .8859 | .7918 |
| 10 | .4214 | .7316 | .7369 | .4153 | .7621 | .7895 | .7634 |
| 11 | .4382 | .4039 | .7255 | .3688 | .7346 | .7468 | .7895 |
| 12 | .4176 | .7087 | .696 | .3506 | .6637 | .8855 | .7209 |
| 13 | .378 | .6859 | .6573 | .3391 | .6908 | .6733 | .6621 |
| 14 | .3567 | .6249 | .6028 | .3102 | .6096 | .6142 | .634 |
| 15 | .33 | .2888 | .5596 | .2926 | .5628 | .5876 | .6081 |
| 16 | .3079 | .2881 | .5104 | .2751 | .5422 | .5501 | .5518 |
| 17 | .2987 | .3041 | .5456 | .2858 | .5677 | .5531 | .6182 |
| 18 | .3788 | .3864 | .7038 | .3589 | .6962 | .6916 | .726 |
| 19 | .4649 | .4702 | .873 | .8295 | .8813 | .8335 | .8909 |
| 20 | .4603 | .9323 | .8954 | .8985 | .8642 | .8516 | .9046 |
| 21 | .4252 | .4656 | .9095 | .892 | .913 | .4405 | .8436 |
| 22 | .4222 | .4367 | .8101 | .8074 | .8322 | .4199 | .7705 |
| 23 | .4024 | .4138 | .7808 | .7583 | .7455 | .3986 | .7463 |
| 24 | .3513 | .3567 | .6733 | .6908 | .6897 | .6638 | .3856 |
| Max | .4649 | .9323 | .9581 | .933 | .9671 | .9434 | .9046 |
| Min | .2675 | .2835 | .2919 | .2751 | .5308 | .3986 | .2949 |
| Avg | .3642 | .4460 | .6476 | .5889 | .7079 | .6630 | .6077 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 205 / 11KV JUINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8726 | .8954 | .8924 | 1.6835 | 1.6911 | 1.7517 | .9297 |
| 2 | .8131 | .8429 | .8421 | 1.6067 | 1.5821 | 1.684 | .8665 |
| 3 | .7903 | .8208 | .8246 | 1.565 | 1.4654 | 1.608 | .849 |
| 4 | .7766 | .8185 | 1.5546 | 1.4776 | 1.5264 | 1.5257 | .8383 |
| 5 | .7819 | .8497 | .836 | 1.6059 | 1.7688 | 1.7406 | .8749 |
| 6 | .8322 | 1.1142 | 1.0966 | 2.1376 | 2.2618 | 2.2823 | 1.0029 |
| 7 | 1.0105 | 1.371 | 2.7384 | 2.7256 | 2.7668 | 2.6652 | 1.2353 |
| 8 | 1.5104 | 1.6491 | 3.4162 | 3.2693 | 3.28 | 3.2518 | 3.104 |
| 9 | 1.5646 | 1.5966 | 2.9703 | 3.0801 | 3.0927 | 2.9295 | 3.0315 |
| 10 | 1.5181 | 2.353 | 2.3929 | 1.3405 | 2.2566 | 2.3423 | 2.5804 |
| 11 | 1.3169 | 1.086 | 1.9853 | 1.0501 | 1.9771 | 2.074 | 2.1544 |
| 12 | 1.1218 | 1.7576 | 1.7615 | .9099 | 1.7657 | 1.809 | 1.9308 |
| 13 | .9938 | 1.6114 | 1.6233 | .8368 | 1.5951 | 1.6179 | 1.7802 |
| 14 | .8497 | 1.5404 | 1.5935 | .8177 | 1.5495 | 1.5493 | 1.6956 |
| 15 | .7903 | .7712 | 1.398 | .7537 | 1.515 | 1.499 | 1.5726 |
| 16 | .7087 | .7659 | 1.2839 | .7583 | 1.4914 | 1.4487 | 1.5497 |
| 17 | .7644 | .7857 | 1.3546 | .8032 | 1.5394 | 1.3811 | 1.6568 |
| 18 | .9297 | .8886 | 1.6533 | .8284 | 1.7284 | 1.6476 | 1.7642 |
| 19 | 1.2551 | 1.2285 | 2.3171 | 2.4078 | 2.4376 | 2.3796 | 2.4597 |
| 20 | 1.4228 | 2.8079 | 2.7751 | 2.7999 | 2.7313 | 2.4814 | 2.7706 |
| 21 | 1.438 | 1.4518 | 2.6913 | 2.6916 | 2.7542 | 1.3679 | 2.7476 |
| 22 | 1.3839 | 1.3626 | 2.5587 | 2.505 | 2.5724 | 1.3428 | 2.5498 |
| 23 | 1.2262 | 1.1949 | 2.2775 | 2.2626 | 2.316 | 1.2254 | 2.3411 |
| 24 | 1.0166 | 1.0303 | 1.8869 | 1.8831 | 1.9273 | 1.9454 | 1.0905 |
| Max | 1.5646 | 2.8079 | 3.4162 | 3.2693 | 3.28 | 3.2518 | 3.104 |
| Min | .7087 | .7659 | .8246 | .7537 | 1.4654 | 1.2254 | .8383 |
| Avg | 1.0703 | 1.2748 | 1.8635 | 1.7417 | 2.0663 | 1.8979 | 1.8073 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 206 / 11KV TRUPTI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4938 | .5342 | .5327 | .9903 | .9957 | .9825 | .535 |
| 2 | .4626 | .4969 | .4938 | .9365 | .9083 | .9098 | .4961 |
| 3 | .4405 | .4862 | .4801 | .9114 | .8499 | .876 | .4824 |
| 4 | .4367 | .4755 | .9206 | .868 | .8631 | .8383 | .4771 |
| 5 | .4329 | .5022 | .5053 | .9282 | .9989 | .9396 | .4877 |
| 6 | .4877 | .6584 | .6447 | 1.1271 | 1.2986 | 1.315 | .5898 |
| 7 | .5891 | .7781 | 1.5356 | 1.4994 | 1.5382 | 1.5063 | .7255 |
| 8 | .7842 | .8406 | 1.6506 | 1.6743 | 1.5928 | 1.6896 | 1.6384 |
| 9 | .7423 | .7339 | 1.4701 | 1.3721 | 1.4163 | 1.4278 | 1.4049 |
| 10 | .6767 | 1.1623 | 1.1363 | .5914 | 1.081 | 1.1749 | 1.2075 |
| 11 | .6165 | .5891 | 1.0128 | .5205 | 1.1039 | 1.0884 | 1.2264 |
| 12 | .6097 | 1.0929 | 1.0158 | .5175 | 1.0036 | 1.0539 | 1.1797 |
| 13 | .567 | 1.028 | 1.0077 | .5235 | .9853 | 1.0501 | 1.1428 |
| 14 | .551 | .9945 | .9785 | .503 | 1.0059 | .9534 | 1.0471 |
| 15 | .5098 | .487 | .8932 | .4412 | .9228 | .9023 | .9663 |
| 16 | .4595 | .4694 | .8916 | .4489 | .894 | .8429 | .9609 |
| 17 | .4992 | .5144 | 1.0075 | .4969 | .9402 | .9084 | 1.0479 |
| 18 | .6112 | .6074 | 1.1473 | .5807 | 1.1186 | 1.0631 | 1.2056 |
| 19 | .82 | .823 | 1.5331 | 1.6111 | 1.5583 | 1.5276 | 1.6229 |
| 20 | .8314 | 1.6675 | 1.6385 | 1.6975 | 1.644 | 1.5385 | 1.617 |
| 21 | .8009 | .8337 | 1.5303 | 1.5892 | 1.2643 | .788 | 1.5379 |
| 22 | .7598 | .7438 | 1.4441 | 1.4205 | 1.4242 | .7499 | 1.4319 |
| 23 | .679 | .6683 | 1.275 | 1.2613 | 1.2651 | .6645 | 1.3055 |
| 24 | .5944 | .6013 | 1.1204 | 1.1219 | 1.1104 | 1.1378 | .6341 |
| Max | .8314 | 1.6675 | 1.6506 | 1.6975 | 1.644 | 1.6896 | 1.6384 |
| Min | .4329 | .4694 | .4801 | .4412 | .8499 | .6645 | .4771 |
| Avg | .6023 | .7412 | 1.0777 | .9847 | 1.1576 | 1.0804 | 1.0404 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 207 / 11KV AUGUSTEEN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .8993 | .8692 | .4066 | |
| 2 | | | .8311 | .8055 | .3696 | |
| 3 | | | .7712 | .7456 | .3361 | |
| 4 | | .3547 | .6919 | .7583 | .2987 | |
| 5 | | | .7041 | .7792 | .3547 | |
| 6 | | | .8239 | .8604 | .5175 | |
| 7 | | .5228 | 1.1656 | 1.1747 | .5359 | |
| 8 | | .7468 | 1.3679 | 1.4525 | .7392 | .7207 |
| 9 | | .6722 | 1.3089 | 1.2685 | .5544 | .5788 |
| 10 | .499 | .5788 | .6752 | 1.1828 | .5544 | .6161 |
| 11 | | .5041 | .5281 | 1.083 | .5175 | .5729 |
| 12 | .5544 | .4805 | .5235 | 1.1021 | .5175 | .5544 |
| 13 | .5175 | .5544 | .5175 | 1.0769 | .499 | .5544 |
| 14 | .4805 | .499 | .5022 | 1.0178 | .499 | .4805 |
| 15 | | .4435 | .4915 | .9503 | .4805 | .462 |
| 16 | | .4066 | .4542 | .9282 | .4251 | .462 |
| 17 | | .462 | .4527 | 1.0183 | .499 | .499 |
| 18 | | .5788 | .5411 | 1.1018 | .5975 | .5914 |
| 19 | | .8962 | 1.5547 | 1.6192 | .924 | .9055 |
| 20 | .7316 | .7392 | 1.721 | 1.7301 | .924 | .7577 |
| 21 | | .6653 | 1.5905 | 1.6659 | | .6099 |
| 22 | | .6161 | 1.2978 | .6653 | | .6099 |
| 23 | | .5041 | 1.1537 | .5544 | | .5359 |
| 24 | | .4481 | 1.0064 | .4108 | .4251 | |
| Max | .7316 | .8962 | 1.721 | 1.7301 | .924 | .9055 |
| Min | .4805 | .3547 | .4527 | .4108 | .2987 | .462 |
| Avg | .5566 | .5617 | .8989 | 1.0342 | .5226 | .5944 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 208 / 11KV RAILWAY COMPLEX
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .33 | .3429 | .3315 | .6414 | .6203 | .6628 | .3429 |
| 2 | .3033 | .3125 | .3125 | .602 | .5838 | .6082 | .3185 |
| 3 | .2957 | .3102 | .2957 | .5694 | .5654 | .5824 | .3064 |
| 4 | .2812 | .301 | .583 | .6021 | .5739 | .617 | .3003 |
| 5 | .3025 | .3155 | .3353 | .7185 | .6303 | .6725 | .3193 |
| 6 | .3086 | .3871 | .3772 | .7884 | .7773 | .8059 | .3262 |
| 7 | .3315 | .455 | .953 | .8682 | .9249 | .9252 | .3963 |
| 8 | .3544 | .4725 | .8642 | .8946 | .8328 | .9015 | .8621 |
| 9 | .4039 | .5053 | .9663 | .9404 | .9569 | .9236 | .9757 |
| 10 | .4976 | 1.2411 | 1.1122 | .5335 | 1.1479 | 1.1776 | 1.1774 |
| 11 | .5411 | .6241 | 1.2001 | .5693 | 1.1103 | 1.299 | 1.2117 |
| 12 | .5731 | 1.2364 | 1.2041 | .6059 | 1.169 | 1.3642 | 1.262 |
| 13 | .5761 | 1.2125 | 1.2521 | .6211 | 1.3016 | 1.3004 | 1.3324 |
| 14 | .5479 | 1.1767 | 1.1503 | .5617 | 1.165 | 1.2702 | 1.3278 |
| 15 | .5235 | .5677 | 1.1155 | .5799 | 1.2189 | 1.243 | 1.1831 |
| 16 | .471 | .5853 | 1.1358 | .5883 | 1.2049 | 1.2625 | 1.2293 |
| 17 | .4809 | .5693 | 1.1822 | .5746 | 1.1393 | 1.2064 | 1.2833 |
| 18 | .5319 | .6577 | 1.273 | .647 | 1.3319 | 1.3925 | 1.3449 |
| 19 | .5883 | .743 | 1.4538 | 1.5043 | 1.4716 | 1.5049 | 1.4975 |
| 20 | .5868 | 1.3472 | 1.3666 | 1.4194 | 1.3756 | 1.4167 | 1.3778 |
| 21 | .5639 | .6447 | 1.1881 | 1.2491 | 1.2384 | .6394 | 1.1897 |
| 22 | .5129 | .5601 | 1.0471 | 1.0136 | 1.0538 | .5479 | 1.0753 |
| 23 | .4725 | .4893 | .8532 | .8648 | .8954 | .4877 | .9503 |
| 24 | .4108 | .3993 | .7449 | .7819 | .7434 | .9985 | .4321 |
| Max | .5883 | 1.3472 | 1.4538 | 1.5043 | 1.4716 | 1.5049 | 1.4975 |
| Min | .2812 | .301 | .2957 | .5335 | .5654 | .4877 | .3003 |
| Avg | .4496 | .6440 | .9291 | .7808 | 1.0014 | .9921 | .9176 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 201 / 11KV NRI COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8316 | .823 | .924 | .9145 | .823 | .8779 | .961 |
| 2 | .0739 | .7316 | .8501 | .8596 | .7316 | .823 | .8871 |
| 3 | .7392 | .8413 | .7762 | .8779 | .8048 | .8596 | .7762 |
| 4 | .8131 | .9145 | .8871 | .9328 | .9145 | .9511 | .8316 |
| 5 | .8871 | 1.0242 | .9979 | 1.0059 | 1.0608 | 1.0059 | .9335 |
| 6 | .924 | 1.1157 | 1.1827 | 1.1157 | 1.1888 | 1.0974 | |
| 7 | .9145 | | 1.4266 | 1.4083 | | 1.4266 | 1.1706 |
| 8 | | 1.3717 | | 1.3717 | 1.2803 | 1.3352 | |
| 9 | 1.386 | | 1.4632 | 1.5364 | | 1.4083 | |
| 10 | 1.4415 | 1.2803 | .1372 | 1.4815 | 1.39 | 1.3717 | 1.5912 |
| 11 | | | 1.2437 | | 1.2437 | 1.3491 | |
| 12 | 1.4998 | 1.1523 | 1.134 | 1.2254 | 1.134 | 1.1827 | 1.2437 |
| 13 | 1.2986 | 1.0456 | 1.0059 | 1.0974 | 1.0608 | 1.1458 | 1.1888 |
| 14 | | | 1.0242 | | .9694 | 1.0164 | |
| 15 | 1.0608 | 1.0269 | | 1.0242 | 1.0608 | 1.1088 | 1.1888 |
| 16 | | | | | 1.0425 | | |
| 17 | .9511 | | .9328 | .9145 | .9145 | .9328 | 1.0059 |
| 18 | 1.0242 | .924 | .9328 | | .8779 | .8962 | .9511 |
| 19 | 1.3352 | .1349 | 1.3717 | 1.2803 | 1.2437 | 1.3169 | 1.3169 |
| 20 | | 1.2803 | 1.3352 | 1.3352 | 1.3717 | 1.4415 | |
| 21 | 1.3717 | 1.4266 | 1.2986 | 1.4266 | 1.4266 | 1.4415 | 1.4266 |
| 22 | | 1.2986 | 1.1888 | 1.3352 | 1.4266 | .1312 | 1.3352 |
| 23 | 1.0974 | 1.0974 | 1.1157 | | 1.1157 | | |
| 24 | 1.0608 | .9145 | .9694 | .9511 | .9145 | .9145 | .1072 |
| Max | 1.4998 | 1.4266 | 1.4632 | 1.5364 | 1.4266 | 1.4415 | 1.5912 |
| Min | .0739 | .1349 | .1372 | .8596 | .7316 | .1312 | .1072 |
| Avg | 1.0395 | 1.0224 | 1.0570 | 1.1629 | 1.0907 | 1.0925 | 1.0572 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 203 / 11KV BPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8775 | .9145 | .924 | .9145 | .9145 | .9145 | 1.0829 |
| 2 | .8131 | .8413 | .8871 | .8596 | .823 | .8779 | .961 |
| 3 | .0747 | .9511 | .8131 | .9511 | .9145 | .9694 | .8131 |
| 4 | .8215 | 1.0974 | .924 | .9511 | 1.0242 | 1.1157 | .8501 |
| 5 | .8962 | 1.2437 | 1.1458 | 1.1157 | 1.1888 | 1.1888 | .9709 |
| 6 | .961 | 1.3717 | 1.386 | 1.2437 | 1.39 | 1.2986 | |
| 7 | .9979 | | 1.46 | 1.3352 | | 1.5181 | 1.4266 |
| 8 | | 1.4632 | | | 1.4998 | .9511 | |
| 9 | 1.4998 | | 1.6095 | 1.5729 | | 1.4815 | |
| 10 | 1.5181 | 1.5546 | 1.3717 | 1.3717 | 1.4632 | 1.4632 | 1.4632 |
| 11 | | | 1.2986 | | 1.4266 | 1.423 | |
| 12 | 1.3352 | 1.1888 | 1.3535 | 1.1888 | 1.1706 | 1.3535 | 1.2803 |
| 13 | 1.4632 | 1.0456 | 1.2254 | 1.0242 | 1.2071 | 1.1523 | 1.2437 |
| 14 | | | 1.2071 | | 1.1888 | 1.2254 | |
| 15 | 1.0059 | 1.1949 | | 1.0608 | 1.0425 | .9877 | 1.1888 |
| 16 | | | | | .9511 | | |
| 17 | 1.3717 | | 1.0974 | 1.2803 | 1.0608 | 1.1088 | 1.2803 |
| 18 | 1.6461 | 1.3121 | 1.2803 | | 1.4266 | 1.2936 | 1.4632 |
| 19 | 1.5181 | 1.6632 | 1.4266 | 1.6461 | 1.5364 | 1.5893 | 1.5912 |
| 20 | | 1.6644 | 1.3717 | 1.6095 | 1.6095 | 1.4266 | |
| 21 | 1.4998 | 1.6095 | 1.4266 | 1.4266 | 1.4815 | 1.4998 | 1.4998 |
| 22 | | 1.4083 | 1.3535 | 1.3717 | 1.4266 | 1.3717 | 1.5181 |
| 23 | 1.0974 | 1.2254 | 1.134 | | 1.1888 | | |
| 24 | 1.0608 | 1.0059 | .9694 | .9511 | .9694 | .9511 | 1.1458 |
| Max | 1.6461 | 1.6644 | 1.6095 | 1.6461 | 1.6095 | 1.5893 | 1.5912 |
| Min | .0747 | .8413 | .8131 | .8596 | .823 | .8779 | .8131 |
| Avg | 1.1366 | 1.2642 | 1.2222 | 1.2153 | 1.2229 | 1.2346 | 1.2362 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 204 / 11KV SWP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3547 | .4668 | .3734 | .3734 | .4108 | .3921 | .3361 |
| 2 | .3361 | .4668 | .4108 | .3361 | .3734 | .3734 | .3361 |
| 3 | .3174 | .4294 | .4481 | .3174 | .3361 | .3361 | .3734 |
| 4 | .3361 | .3734 | .4108 | .3734 | .4108 | .3921 | .4108 |
| 5 | .3734 | .3734 | .3734 | .3921 | .4668 | .3734 | .4481 |
| 6 | .3921 | .3361 | .3547 | .4294 | .5041 | .3547 | |
| 7 | .5041 | | .3547 | .4294 | | .4854 | .4854 |
| 8 | | .4294 | | .3174 | .4294 | .4481 | |
| 9 | .4251 | | .5175 | .5601 | | .4481 | |
| 10 | .499 | .3734 | .4251 | .4294 | .4668 | .4294 | .3881 |
| 11 | | | .5359 | | .4668 | .4668 | |
| 12 | .3142 | .5853 | .499 | .4668 | .3921 | .4854 | .3734 |
| 13 | .4294 | .5175 | .3696 | .4481 | .3547 | .4668 | .4481 |
| 14 | | | .3361 | | .3734 | .2987 | |
| 15 | .4108 | .4435 | | .5601 | .3734 | .4668 | .4108 |
| 16 | | | | | .3547 | | |
| 17 | .3734 | | .3696 | .4668 | .4481 | .3174 | .4668 |
| 18 | .2801 | .3921 | .462 | | .4481 | .3361 | .3921 |
| 19 | .4668 | .3174 | .4435 | .3734 | .4294 | .3881 | .3547 |
| 20 | | .3142 | .4066 | .4854 | .3361 | .4435 | |
| 21 | .2801 | .3921 | .4435 | .4294 | .4294 | .2957 | .3734 |
| 22 | | .3696 | .4251 | .3734 | .3361 | .3511 | .4294 |
| 23 | .4668 | .4108 | .462 | | .6161 | | |
| 24 | .3361 | .4294 | .3547 | .3921 | .4481 | .4294 | .3734 |
| Max | .5041 | .5853 | .5359 | .5601 | .6161 | .4854 | .4854 |
| Min | .2801 | .3142 | .3361 | .3174 | .3361 | .2957 | .3361 |
| Avg | .3831 | .4123 | .4179 | .4186 | .4184 | .3990 | .4000 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 205 / 11KV DELHI PUBLIC SCHOOL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0572 | .0381 | .0572 | .0572 | .0381 | .0572 | .0381 |
| 2 | .0381 | .0381 | .0572 | .0572 | .0381 | .0381 | .0381 |
| 3 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| 4 | .0572 | .0572 | .0572 | .0381 | .0381 | .0381 | .0572 |
| 5 | .0572 | .0572 | .0572 | .0572 | .0381 | .0572 | .0762 |
| 6 | .0762 | .0762 | .0762 | .0572 | .0381 | .0572 | |
| 7 | .0572 | | .0762 | .0572 | | .0572 | .0762 |
| 8 | | .0953 | | .0762 | .1143 | .0953 | |
| 9 | .0572 | | .1143 | .1143 | | .1143 | |
| 10 | .0572 | .1143 | .0953 | .0953 | .1143 | .1334 | .1143 |
| 11 | | | .1143 | | .1143 | .1143 | |
| 12 | .0572 | .1143 | .0762 | .0953 | .0953 | .1143 | .0762 |
| 13 | .0572 | .0953 | .0572 | .0953 | .1143 | .1334 | .0572 |
| 14 | | | .0762 | | .0762 | .1143 | |
| 15 | .0762 | .0762 | | .0762 | .0572 | .0762 | .0762 |
| 16 | | | | | .0572 | | |
| 17 | .0572 | | .0572 | .0572 | .0762 | .0572 | .0572 |
| 18 | .0953 | .0762 | .0762 | | .0572 | .0572 | .0572 |
| 19 | .0572 | .0572 | .0572 | .0572 | .0572 | .0572 | .0572 |
| 20 | | .0762 | .0572 | .0572 | .0762 | .0572 | |
| 21 | .0572 | .0572 | | .0572 | .0572 | .0572 | .0572 |
| 22 | | .0572 | .0572 | .0762 | .0762 | .0381 | .0572 |
| 23 | .0381 | .0572 | .0572 | | .0572 | | |
| 24 | .0572 | .0572 | .0572 | .0762 | .0381 | .0762 | .0572 |
| Max | .0953 | .1143 | .1143 | .1143 | .1143 | .1334 | .1143 |
| Min | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 | .0381 |
| Avg | .0582 | .0688 | .0686 | .0682 | .0667 | .0745 | .0619 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 206 / 11KV NEELKANTH TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8775 | .8413 | .9335 | .8596 | .9145 | .9328 | .9709 |
| 2 | .8131 | .8779 | .8962 | .8413 | .8413 | .9145 | .8962 |
| 3 | .7392 | .9145 | .8589 | .9145 | .9145 | 1.0059 | .8215 |
| 4 | .7392 | 1.0242 | .9335 | 1.0608 | 1.0242 | 1.1523 | .8775 |
| 5 | .8686 | 1.1888 | 1.0829 | 1.1888 | 1.1888 | 1.2437 | .961 |
| 6 | .9877 | 1.3169 | 1.419 | 1.2803 | 1.3352 | 1.3352 | |
| 7 | 1.0242 | | 1.46 | 1.4266 | | 1.4632 | 1.3169 |
| 8 | | 1.4998 | | 1.5181 | 1.5729 | 1.5181 | |
| 9 | 1.2382 | | 1.4784 | 1.4266 | | 1.1458 | |
| 10 | 1.4415 | 1.3717 | 1.386 | 1.4266 | 1.39 | 1.3717 | 1.5181 |
| 11 | | | 1.3352 | | 1.3717 | 1.3817 | |
| 12 | 1.39 | 1.2382 | 1.2254 | 1.2437 | 1.2437 | 1.386 | 1.39 |
| 13 | 1.2071 | 1.2437 | 1.1523 | 1.2437 | 1.2254 | 1.2936 | 1.2437 |
| 14 | | | 1.0974 | | 1.1888 | 1.2382 | |
| 15 | 1.0974 | 1.0791 | | 1.0059 | 1.0608 | 1.1088 | 1.1706 |
| 16 | | | | | 1.0608 | | |
| 17 | 1.2437 | | 1.2437 | 1.1888 | 1.2437 | 1.1643 | 1.2803 |
| 18 | 1.4083 | 1.3306 | 1.4083 | | 1.39 | 1.3491 | 1.4083 |
| 19 | 1.5181 | 1.4784 | 1.4266 | 1.4632 | 1.4632 | 1.4266 | 1.4815 |
| 20 | | 1.4784 | 1.3717 | 1.4632 | 1.39 | 1.3352 | |
| 21 | 1.3717 | 1.386 | 1.3717 | 1.39 | 1.3169 | 1.3352 | 1.3535 |
| 22 | | 1.2803 | 1.2437 | 1.2437 | 1.3352 | 1.3169 | 1.2437 |
| 23 | 1.0974 | 1.1523 | 1.134 | | 1.1888 | | |
| 24 | .924 | 1.4784 | .9877 | .9145 | .9511 | .9877 | 1.1203 |
| Max | 1.5181 | 1.4998 | 1.4784 | 1.5181 | 1.5729 | 1.5181 | 1.5181 |
| Min | .7392 | .8413 | .8589 | .8413 | .8413 | .9145 | .8215 |
| Avg | 1.1104 | 1.2323 | 1.2117 | 1.2158 | 1.2096 | 1.2458 | 1.1909 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 207 / 11KV KOKAN RAILWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6348 | .6099 | .6161 | .6653 | .6099 | .6838 | .7095 |
| 2 | .5975 | .6468 | .5601 | .6468 | .5544 | .6653 | .5975 |
| 3 | .5601 | .7023 | .5415 | .7023 | .6468 | .7392 | .5601 |
| 4 | .5041 | .8316 | .6161 | .8316 | .7392 | .8316 | .5228 |
| 5 | .5601 | .924 | .8775 | .9425 | .924 | .9425 | .5975 |
| 6 | .5975 | 1.0349 | 1.1643 | 1.0349 | 1.1088 | 1.0719 | |
| 7 | .6838 | | 1.0719 | 1.0903 | | 1.0534 | 1.0719 |
| 8 | | 1.2197 | | 1.2012 | 1.2936 | 1.2567 | |
| 9 | 1.0719 | | 1.2012 | 1.1643 | | 1.1458 | |
| 10 | 1.1827 | 1.0164 | 1.0349 | 1.0164 | 1.0534 | 1.0164 | 1.1088 |
| 11 | | | .8501 | | .8501 | .9145 | |
| 12 | .924 | .8131 | .7392 | .8131 | .8316 | .8048 | .8871 |
| 13 | .8871 | .6584 | .6838 | .6468 | .7023 | .695 | .7947 |
| 14 | | | .6283 | | .6099 | .6401 | |
| 15 | .6468 | .6036 | | .5914 | .5544 | .6099 | .6283 |
| 16 | | | | | .5544 | | |
| 17 | .7392 | | .6283 | .6653 | .6283 | .6653 | .7392 |
| 18 | .924 | .8131 | .8501 | | .8501 | .8131 | .8686 |
| 19 | 1.0534 | 1.1088 | .9979 | 1.0534 | 1.0349 | 1.0164 | 1.1088 |
| 20 | | 1.1088 | 1.0164 | 1.0719 | 1.0719 | 1.0059 | |
| 21 | 1.0349 | 1.0349 | 1.0164 | 1.0164 | 1.0719 | 1.0059 | 1.0164 |
| 22 | | 1.0059 | .961 | .9979 | 1.0164 | .9511 | .961 |
| 23 | .7392 | .7865 | .8316 | | .8501 | | |
| 24 | .7392 | 1.1088 | .6584 | .7023 | .6653 | .7023 | .7682 |
| Max | 1.1827 | 1.2197 | 1.2012 | 1.2012 | 1.2936 | 1.2567 | 1.1088 |
| Min | .5041 | .6036 | .5415 | .5914 | .5544 | .6099 | .5228 |
| Avg | .7822 | .8904 | .8355 | .8871 | .8283 | .8741 | .8088 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 208 / 11kV KENDRIYA VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5601 | .4294 | .4668 | | .4805 | .5041 | .5093 |
| 2 | .5041 | .4668 | .4668 | | .4066 | .4668 | .4108 |
| 3 | .4481 | .5228 | .4294 | | .462 | .5041 | .4108 |
| 4 | .4108 | .5601 | .5228 | | .5544 | .5788 | .0448 |
| 5 | .4668 | .6161 | .6161 | | .6653 | .6535 | .4481 |
| 6 | .5041 | .6535 | .7095 | | .7392 | .7468 | |
| 7 | .4854 | | .7023 | | | .7095 | .6535 |
| 8 | | .8589 | | .7095 | .7392 | .7762 | |
| 9 | .7762 | | .7762 | .7095 | | .7392 | |
| 10 | .8316 | .9335 | .8871 | .7947 | .924 | .8316 | 1.0164 |
| 11 | | | .8686 | | .8316 | .8596 | |
| 12 | .8589 | .8131 | .7392 | .8131 | .8501 | .8131 | .924 |
| 13 | .8962 | .7842 | .7023 | .7392 | .7392 | .8316 | .8501 |
| 14 | | | .7392 | | .7947 | .7468 | |
| 15 | .7468 | .7282 | | .7392 | .7023 | .7095 | .7392 |
| 16 | | | | | .7023 | | |
| 17 | .8402 | | .7392 | .8131 | .7392 | .7282 | .7762 |
| 18 | .9335 | .8779 | .8871 | | .8501 | .8871 | .8686 |
| 19 | 1.0082 | .9694 | 1.0164 | .961 | 1.0349 | .961 | 1.0164 |
| 20 | | .9896 | .9425 | .961 | .9795 | .8871 | |
| 21 | .9335 | .9145 | .924 | .924 | .8871 | .8871 | .924 |
| 22 | | .7392 | .6838 | .7947 | .8686 | .7499 | .7392 |
| 23 | .5601 | .6099 | .5975 | | .6468 | | |
| 24 | .5544 | .9694 | .4938 | .5041 | .8871 | .5228 | .5601 |
| Max | 1.0082 | .9896 | 1.0164 | .961 | 1.0349 | .961 | 1.0164 |
| Min | .4108 | .4294 | .4294 | .5041 | .4066 | .4668 | .0448 |
| Avg | .6844 | .7465 | .7100 | .7886 | .7493 | .7316 | .6807 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 209 / 11KV SEAWOODS PH-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6516 | .6036 | .6687 | 1.4017 | .5533 | .5596 | .6516 |
| 2 | .6173 | .5533 | .6516 | 1.3358 | .503 | .5426 | .6001 |
| 3 | .5487 | .6371 | .6687 | 1.3572 | .5365 | .5935 | .3944 |
| 4 | .5487 | .7042 | .6001 | 1.3679 | .6036 | .6274 | .703 |
| 5 | .6274 | .7712 | .6859 | 1.414 | .6706 | .6613 | .7202 |
| 6 | .6952 | .8383 | .7545 | 1.4282 | .7545 | .7122 | |
| 7 | .6443 | | .8309 | 1.6931 | | .8048 | .7461 |
| 8 | | .8718 | | 1.752 | .8383 | .7545 | |
| 9 | .8139 | | .7969 | 1.7326 | | .7545 | |
| 10 | .7461 | .7712 | .78 | 1.608 | .7545 | .7377 | .8048 |
| 11 | | | .6783 | .8779 | .6874 | .7461 | |
| 12 | .8383 | .6613 | .6783 | 1.4007 | .6539 | .7122 | .7545 |
| 13 | .7712 | .6173 | .6371 | 1.3855 | .57 | .6952 | .7209 |
| 14 | | | .6036 | .7057 | .5868 | .6613 | |
| 15 | .6203 | .5426 | | 1.2757 | .5533 | .5935 | .503 |
| 16 | | | | .6432 | .6203 | | |
| 17 | .8048 | .6104 | .6874 | 1.4236 | .7042 | .7291 | .7209 |
| 18 | .8383 | .7291 | .7209 | .8444 | .7209 | .7377 | .7209 |
| 19 | .8048 | .788 | .7209 | 1.6629 | .7545 | .7377 | .8048 |
| 20 | | .8048 | .7712 | 1.6598 | .7712 | .7461 | |
| 21 | .7545 | .7712 | .7545 | 1.7269 | .7545 | .7888 | .7712 |
| 22 | | .7969 | .7209 | 1.7193 | .7545 | .78 | .788 |
| 23 | .6706 | .7461 | .6783 | .8993 | .6783 | | |
| 24 | .6516 | .788 | .6783 | 1.4612 | .6036 | .5935 | .7202 |
| Max | .8383 | .8718 | .8309 | 1.752 | .8383 | .8048 | .8048 |
| Min | .5487 | .5426 | .6001 | .6432 | .503 | .5426 | .3944 |
| Avg | .7026 | .7161 | .7032 | 1.3657 | .6649 | .6941 | .6953 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 304 / 22KV NERUL II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .3048 | .4268 |
| 2 | .2134 | .6097 |
| 3 | .1219 | .4268 |
| 4 | .1219 | .5182 |
| 5 | | .3048 |
| 6 | | .3048 |
| 7 | .1524 | .3048 |
| 8 | .3048 | .3048 |
| 9 | .3353 | .2134 |
| 10 | .5792 | .5182 |
| 11 | .6401 | .2134 |
| 12 | .6097 | .2439 |
| 13 | .6706 | .6097 |
| 14 | .6401 | .5487 |
| 15 | .6706 | .5182 |
| 16 | .6706 | .5792 |
| 17 | .7011 | .5792 |
| 18 | .7011 | .3048 |
| 19 | .5792 | .4268 |
| 20 | .6097 | .2743 |
| 21 | .5182 | .3963 |
| 22 | .5792 | .3963 |
| 23 | .3048 | .6097 |
| 24 | .4572 | |
| Max | .7011 | .6097 |
| Min | .1219 | .2134 |
| Avg | .4766 | .4188 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 402 / 33KV NRI S/STN

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 20-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 1.9204 |
| 2 | 1.8519 |
| 3 | 1.8519 |
| 4 | 1.8519 |
| 5 | 1.7833 |
| 6 | 1.8519 |
| 7 | 2.4006 |
| 8 | 2.8121 |
| 9 | 2.5377 |
| 10 | 2.4691 |
| 11 | 2.5377 |
| 12 | 2.4006 |
| 13 | 2.2634 |
| 14 | 2.2634 |
| 15 | 1.989 |
| 16 | 1.8519 |
| 17 | 1.9204 |
| 18 | 2.2634 |
| 19 | 2.332 |
| 20 | 2.4006 |
| 21 | 2.4006 |
| 22 | 2.4006 |
| 23 | 2.332 |
| 24 | 2.1948 |
| Max | 2.8121 |
| Min | 1.7833 |
| Avg | 2.2034 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642] BU 4642

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 405 / 33KV RAILWAY II NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 17-JAN-17 | 18-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 7.476 | 7.4074 |
| 2 | 6.4472 | 6.3786 |
| 3 | 6.0357 | 5.8985 |
| 4 | 5.8985 | 5.7613 |
| 5 | 5.7613 | 5.6927 |
| 6 | 6.3786 | 6.31 |
| 7 | 8.9163 | 8.7792 |
| 8 | 9.808 | 10.0823 |
| 9 | 10.4253 | 10.3567 |
| 10 | 9.8766 | 9.9451 |
| 11 | 10.0823 | 9.808 |
| 12 | 9.808 | 9.6022 |
| 13 | 9.5336 | 9.465 |
| 14 | 9.1221 | 9.1907 |
| 15 | 8.5048 | 8.7106 |
| 16 | 8.1619 | 8.0933 |
| 17 | 8.5048 | 8.5048 |
| 18 | 9.1221 | 9.1907 |
| 19 | 10.1509 | 10.4938 |
| 20 | 11.3169 | 11.1111 |
| 21 | 11.1111 | 10.974 |
| 22 | 10.8368 | 10.7682 |
| 23 | 9.9451 | 9.8766 |
| 24 | 8.642 | 8.8477 |
| Max | 11.3169 | 11.1111 |
| Min | 5.7613 | 5.6927 |
| Avg | 8.8277 | 8.8020 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 407 / 33KV SECTOR 11

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 20-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 6.5158 |
| 2 | 5.9671 |
| 3 | 5.487 |
| 4 | 5.2812 |
| 5 | 5.0755 |
| 6 | 5.8299 |
| 7 | 7.4074 |
| 8 | 9.3964 |
| 9 | 9.9451 |
| 10 | 9.8766 |
| 11 | 9.7394 |
| 12 | 9.6708 |
| 13 | 9.808 |
| 14 | 9.0535 |
| 15 | 8.5048 |
| 16 | 8.5734 |
| 17 | 8.5734 |
| 18 | 8.3676 |
| 19 | 9.0535 |
| 20 | 9.808 |
| 21 | 9.3964 |
| 22 | 9.1221 |
| 23 | 7.8875 |
| 24 | 7.0645 |
| Max | 9.9451 |
| Min | 5.0755 |
| Avg | 8.1419 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 408 / 33KV NERUL SUB DIVISION

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 20-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 15.9808 |
| 2 | 14.1976 |
| 3 | 13.3745 |
| 4 | 13.0316 |
| 5 | 12.8944 |
| 6 | 13.8546 |
| 7 | 19.6845 |
| 8 | 22.2223 |
| 9 | 24.0741 |
| 10 | 21.7421 |
| 11 | 19.2044 |
| 12 | 18.2442 |
| 13 | 17.284 |
| 14 | 16.8725 |
| 15 | 16.4609 |
| 16 | 15.2949 |
| 17 | 15.0206 |
| 18 | 15.5007 |
| 19 | 19.1358 |
| 20 | 24.0741 |
| 21 | 23.9369 |
| 22 | 21.8107 |
| 23 | 21.0563 |
| 24 | 18.7929 |
| Max | 24.0741 |
| Min | 12.8944 |
| Avg | 18.0727 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 409 / 33KV SBI S/S

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 20-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 9.808 |
| 2 | 9.1564 |
| 3 | 8.882 |
| 4 | 8.7792 |
| 5 | 8.7449 |
| 6 | 9.1221 |
| 7 | 11.6598 |
| 8 | 12.2428 |
| 9 | 13.5803 |
| 10 | 14.6434 |
| 11 | 15.3635 |
| 12 | 15.0892 |
| 13 | 14.1976 |
| 14 | 14.0604 |
| 15 | 13.203 |
| 16 | 13.2373 |
| 17 | 13.2716 |
| 18 | 12.8258 |
| 19 | 13.1002 |
| 20 | 14.1633 |
| 21 | 13.8203 |
| 22 | 12.8944 |
| 23 | 12.1056 |
| 24 | 11.1454 |
| Max | 15.3635 |
| Min | 8.7449 |
| Avg | 12.2957 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 201 / 11KV NERUL GAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3413 | 1.4662 | 1.4358 | 1.4373 | 1.3946 | 1.3687 | 1.5181 |
| 2 | 1.2803 | 1.4038 | 1.3611 | 1.3504 | 1.3093 | 1.2925 | 1.4403 |
| 3 | 1.2437 | 1.326 | 1.3413 | 1.3184 | 1.2849 | 1.259 | 1.4129 |
| 4 | 1.2285 | 1.3245 | 1.3169 | 1.3047 | 1.3214 | 1.2544 | 1.39 |
| 5 | 1.2209 | 1.4693 | 1.4586 | 1.4251 | 1.419 | 1.3778 | 1.4906 |
| 6 | 1.8275 | 2.2832 | 2.3167 | 2.2893 | 2.3045 | 2.2161 | 2.1719 |
| 7 | 2.0622 | 2.6231 | 2.6795 | 2.5514 | 2.5956 | 2.6185 | 2.4981 |
| 8 | 2.1491 | 2.6398 | 2.6703 | 2.6246 | 2.6551 | 2.7054 | 2.5667 |
| 9 | 1.9875 | 2.1414 | 2.143 | 2.0972 | 2.0744 | 2.2085 | 2.0698 |
| 10 | 1.8945 | 1.9235 | 1.8351 | 1.8397 | 1.8793 | 2.0088 | 1.925 |
| 11 | 1.8519 | 1.7924 | 1.733 | 1.6491 | 1.7055 | 1.7863 | 1.8 |
| 12 | 1.6659 | 1.7375 | 1.6187 | 1.512 | 1.6049 | 1.6674 | 1.6903 |
| 13 | 1.6644 | 1.6552 | 1.6537 | 1.3519 | 1.5745 | 1.7071 | 1.736 |
| 14 | 1.5867 | 1.5714 | 1.4982 | 1.4434 | 1.5943 | 1.669 | 1.6659 |
| 15 | 1.3885 | 1.5364 | 1.387 | 1.3626 | 1.4815 | 1.5074 | 1.5379 |
| 16 | 1.4083 | 1.544 | 1.4845 | 1.448 | 1.5196 | 1.5059 | 1.5668 |
| 17 | 1.5592 | 1.6217 | 1.6415 | 1.5821 | 1.6324 | 1.5806 | 1.7116 |
| 18 | 1.9555 | 2.0363 | 2.0241 | 1.9311 | 2.0348 | 1.9464 | 2.0073 |
| 19 | 2.5469 | 2.6612 | 2.6231 | 2.6139 | 2.681 | 2.5621 | 2.681 |
| 20 | 2.4371 | 2.6033 | 2.4829 | 2.4859 | 2.6017 | 2.431 | 2.5575 |
| 21 | 2.0576 | 2.1186 | 2.1475 | 2.1003 | 2.1536 | 2.0454 | 2.1597 |
| 22 | 2.0454 | 2.0317 | 2.0668 | 2.0424 | 1.9784 | 2.1125 | 2.0317 |
| 23 | 1.8061 | 1.8823 | 1.701 | 1.8381 | 1.7863 | 1.8854 | 1.8961 |
| 24 | 1.5927 | 1.6019 | 1.6065 | 1.5668 | 1.5455 | 1.6674 | 1.6796 |
| Max | 2.5469 | 2.6612 | 2.6795 | 2.6246 | 2.681 | 2.7054 | 2.681 |
| Min | 1.2209 | 1.3245 | 1.3169 | 1.3047 | 1.2849 | 1.2544 | 1.39 |
| Avg | 1.7417 | 1.8748 | 1.8428 | 1.7986 | 1.8388 | 1.8493 | 1.8835 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 201 / 11KV SAMNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4115 | .3772 | .5144 | .3772 | .3944 | .3601 | .3944 |
| 2 | .3772 | .4115 | .5144 | .3429 | .4287 | .3601 | .463 |
| 3 | .3429 | .3772 | .4801 | .3429 | .3944 | .3429 | .4287 |
| 4 | .3429 | .3772 | .463 | .3258 | .4115 | .3429 | .3944 |
| 5 | .3258 | .3944 | .4287 | .3258 | .4287 | .3258 | .4287 |
| 6 | .3086 | .463 | .4287 | .3086 | .4287 | .3772 | .5144 |
| 7 | .3429 | .4973 | .463 | .3429 | .463 | .4458 | .583 |
| 8 | .4115 | .4973 | .463 | .4287 | .4458 | .4801 | .6344 |
| 9 | .4973 | .4801 | .4801 | .5316 | .4973 | .463 | .5658 |
| 10 | .6001 | .5316 | .5658 | .5658 | .5487 | .5658 | .583 |
| 11 | .583 | .4801 | .5144 | .5144 | .5316 | .583 | .6859 |
| 12 | .4801 | .4458 | .463 | .5144 | .5144 | .5144 | .703 |
| 13 | .4801 | .3944 | .4287 | .463 | .463 | .5487 | .6516 |
| 14 | .463 | .3772 | .4458 | .3944 | .3944 | .0429 | .6173 |
| 15 | .4287 | .4115 | .4458 | .4287 | .3944 | .3944 | .583 |
| 16 | .3601 | .4115 | .463 | .3944 | .4801 | .463 | .5144 |
| 17 | .4287 | .4115 | .4973 | .4458 | .5658 | .4801 | .4287 |
| 18 | .463 | .5144 | .4973 | .5487 | .6001 | .4801 | .4458 |
| 19 | .5658 | .583 | .5144 | .5658 | .5316 | .4973 | .5144 |
| 20 | .4973 | .5316 | .5487 | .5658 | .583 | .5144 | .5487 |
| 21 | .5487 | .5316 | .5658 | .6173 | .5316 | .5487 | .5658 |
| 22 | .4801 | .4801 | .583 | .5658 | .5144 | .4801 | .5144 |
| 23 | .4458 | .4458 | .4973 | .4801 | .4801 | | .463 |
| 24 | .4287 | .3944 | .463 | .3944 | .4801 | .463 | .4801 |
| Max | .6001 | .583 | .583 | .6173 | .6001 | .583 | .703 |
| Min | .3086 | .3772 | .4287 | .3086 | .3944 | .0429 | .3944 |
| Avg | .4422 | .4508 | .4887 | .4494 | .4794 | .4380 | .5294 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 202 / 11 KV MITTAL TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1029 | .0857 | .0857 | .12 | .1029 | .1029 | .1029 |
| 2 | .1029 | .0857 | .0857 | .1029 | .1029 | .1029 | .1029 |
| 3 | .1029 | .0686 | .0857 | .1029 | .0857 | .0857 | .0857 |
| 4 | .0857 | .0857 | .0857 | .1029 | .0857 | .0857 | .0857 |
| 5 | .0857 | .0857 | .0857 | .1029 | .1029 | .0857 | .0857 |
| 6 | .0857 | .12 | .1029 | .1029 | .12 | .1029 | .1029 |
| 7 | .1029 | .1715 | .12 | .12 | .1543 | .12 | .12 |
| 8 | .1372 | .1372 | .12 | .1372 | .1372 | .1372 | .1372 |
| 9 | .1372 | .1372 | .12 | .12 | .1372 | .1029 | .1372 |
| 10 | .1372 | .1372 | .12 | .12 | .1543 | .12 | .12 |
| 11 | .1029 | .1372 | .1372 | .12 | .12 | .1372 | .1372 |
| 12 | .1029 | .1372 | .1372 | .1372 | .1029 | .12 | .1372 |
| 13 | .1029 | .12 | .12 | .1029 | .1029 | .1372 | .1372 |
| 14 | .0857 | .12 | .12 | .0857 | .1029 | .1029 | .1543 |
| 15 | .0857 | .12 | .12 | .12 | .1029 | .1372 | .1543 |
| 16 | .0857 | .12 | .1372 | .12 | .1029 | .12 | .1543 |
| 17 | .1029 | .12 | .1372 | .1029 | .1029 | .12 | .1543 |
| 18 | .1029 | .1372 | .1372 | .1029 | .12 | .1029 | .1372 |
| 19 | .1029 | .1372 | .1372 | .12 | .1372 | .1372 | .1543 |
| 20 | .12 | .1372 | .1372 | .1372 | .1372 | .1372 | .1715 |
| 21 | .12 | .12 | .1372 | .12 | .12 | .1372 | .1543 |
| 22 | .12 | .12 | .1543 | .12 | .12 | .12 | .1372 |
| 23 | .1029 | .1029 | .1372 | .1029 | .1029 | | .12 |
| 24 | .12 | .0857 | .1029 | .1372 | .1029 | .1029 | .1029 |
| Max | .1372 | .1715 | .1543 | .1372 | .1543 | .1372 | .1715 |
| Min | .0857 | .0686 | .0857 | .0857 | .0857 | .0857 | .0857 |
| Avg | .1057 | .1179 | .1193 | .1150 | .1150 | .1156 | .1286 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 203 / 11 KV IPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2058 | .1715 | .1886 | .2229 | .1715 | .1886 | .1886 |
| 2 | .1886 | .1715 | .1715 | .2058 | .1715 | .1886 | .1886 |
| 3 | .1886 | .1543 | .1715 | .2058 | .1543 | .1715 | .1715 |
| 4 | .1715 | .1543 | .1715 | .1886 | .1543 | .1715 | .1715 |
| 5 | .1715 | .1715 | .1715 | .1715 | .1886 | .1715 | .1715 |
| 6 | .1886 | .1715 | .1886 | .1715 | .2058 | .1886 | .2058 |
| 7 | .1886 | .2058 | .2229 | .2401 | .2229 | .2229 | .2058 |
| 8 | .2058 | .2229 | .2572 | .2743 | .2229 | .2229 | .1886 |
| 9 | .2229 | .2572 | .3086 | .3086 | .2572 | .2915 | .2572 |
| 10 | .2572 | .3429 | .3429 | .3258 | .3772 | .3772 | .3772 |
| 11 | .2743 | .3429 | .3429 | .4458 | .3944 | .4115 | .3601 |
| 12 | .2572 | .3772 | .3601 | .3429 | .3944 | .3601 | .3429 |
| 13 | .2401 | .3772 | .3772 | .3601 | .3944 | .3944 | .3601 |
| 14 | .3086 | .3601 | .3772 | .3429 | .3944 | .3772 | .3772 |
| 15 | .2229 | .3944 | .3772 | .3944 | .3429 | .3601 | .3772 |
| 16 | .2229 | .3601 | .3601 | .4115 | .3772 | .3601 | .3601 |
| 17 | .2401 | .3601 | .3944 | .3772 | .3772 | .463 | .3944 |
| 18 | .2915 | .3944 | .4115 | .3258 | .3429 | .3772 | .4115 |
| 19 | .2743 | .4287 | .4287 | .3772 | .3944 | .4287 | .4115 |
| 20 | .2572 | .3429 | .4115 | .3601 | .3429 | .3601 | .3944 |
| 21 | .3086 | .3429 | .3772 | .3258 | .3429 | .3429 | .3772 |
| 22 | .2915 | .3086 | .3429 | .2915 | .3086 | .3086 | .3429 |
| 23 | .2572 | .2572 | .3258 | .2743 | .2401 | | .2915 |
| 24 | .2229 | .2058 | .2058 | .2401 | .2058 | .2229 | .2401 |
| Max | .3086 | .4287 | .4287 | .4458 | .3944 | .463 | .4115 |
| Min | .1715 | .1543 | .1715 | .1715 | .1543 | .1715 | .1715 |
| Avg | .2358 | .2865 | .3036 | .2994 | .2908 | .3027 | .2986 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 208 / 11 KV PUDHARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .12 | .0857 | .0686 | .1029 | .0857 | .0857 | .1029 |
| 2 | .1029 | .1029 | .0686 | .1029 | .0857 | .0857 | .0857 |
| 3 | .1029 | .0857 | .0686 | .0857 | .0686 | .0686 | .0686 |
| 4 | .0857 | .0686 | .0686 | .0857 | .0686 | .0686 | .0686 |
| 5 | .0857 | .0686 | .0686 | .0857 | .0857 | .0686 | .1029 |
| 6 | .0857 | .0857 | .0857 | .0857 | .1029 | .0857 | .0857 |
| 7 | .1029 | .12 | .1029 | .1029 | .12 | .1029 | .0857 |
| 8 | .1029 | .12 | .1372 | .1543 | .1029 | .1029 | .1029 |
| 9 | .1029 | .1715 | .2401 | .2229 | .2743 | .1886 | .1886 |
| 10 | .1543 | .2915 | .2743 | .2743 | | .2915 | .2401 |
| 11 | .12 | .2915 | .2743 | .2743 | .2743 | .3086 | .2572 |
| 12 | .12 | .2915 | .2915 | .2915 | .2915 | .3258 | .2743 |
| 13 | .0857 | .2915 | .3258 | .2401 | .3086 | .2915 | .2915 |
| 14 | .1029 | .3429 | .3258 | .2743 | .2915 | .2743 | .2915 |
| 15 | .0857 | .2915 | .3258 | .3086 | .3258 | .3086 | .2743 |
| 16 | .12 | .3086 | .3258 | .3258 | .3429 | .2915 | .2743 |
| 17 | .0686 | .3086 | .3086 | .2915 | .3086 | .3086 | .2572 |
| 18 | .12 | .2915 | .2915 | .2572 | .2915 | .2915 | .3258 |
| 19 | .12 | .2572 | .2229 | .2401 | .2401 | .2572 | .2572 |
| 20 | .12 | .1715 | .2058 | .1715 | .1886 | .1886 | .2401 |
| 21 | .1029 | .1715 | .1715 | .1372 | .1372 | .1715 | .2058 |
| 22 | .0857 | .1372 | .1543 | .12 | .12 | .1715 | .1715 |
| 23 | .0857 | .1372 | .1372 | .1029 | .1029 | | .1543 |
| 24 | .1372 | .0857 | .0857 | .1029 | .0857 | .0857 | .12 |
| Max | .1543 | .3429 | .3258 | .3258 | .3429 | .3258 | .3258 |
| Min | .0686 | .0686 | .0686 | .0857 | .0686 | .0686 | .0686 |
| Avg | .1050 | .1908 | .1929 | .1850 | .1871 | .1923 | .1886 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 209 / 11 KV MILLENIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0572 | .0514 | .0762 | .0572 | .0514 | .0762 | .0514 |
| 2 | .0572 | .0686 | .0762 | .0572 | .0514 | .0572 | .0686 |
| 3 | .0572 | .0686 | .0572 | .0572 | .0686 | .0572 | .0514 |
| 4 | .0572 | .0514 | .0572 | .0572 | .0514 | .0572 | .0514 |
| 5 | .0572 | .0514 | .0572 | .0572 | .0514 | .0762 | .0686 |
| 6 | .0572 | .0514 | .0762 | .0572 | .0514 | .0686 | .0514 |
| 7 | .0572 | .0514 | .0762 | .0572 | .0686 | .0686 | .0514 |
| 8 | .0762 | .0514 | .0762 | .0572 | .0514 | .0762 | .0514 |
| 9 | .0762 | .0686 | .0762 | .0762 | | .0686 | .0514 |
| 10 | .0762 | .0514 | .0762 | .0762 | | .0762 | .0514 |
| 11 | .0514 | .0762 | .0762 | .0514 | .0762 | .0514 | .0762 |
| 12 | .0514 | .0762 | .0762 | .0514 | .0686 | .0514 | .0762 |
| 13 | .0857 | .0762 | .0762 | .0514 | .0762 | .0514 | |
| 14 | .0514 | .0762 | .0762 | .0514 | .0762 | .0514 | |
| 15 | .0514 | .0514 | .0762 | .0514 | .0762 | .0514 | |
| 16 | .0514 | .0572 | .0762 | .0514 | .0762 | .0514 | |
| 17 | .0514 | .0762 | .0762 | .0514 | .0762 | .0514 | .0762 |
| 18 | .0514 | .0686 | .0762 | .0514 | .0762 | .0514 | .0762 |
| 19 | .0514 | .0762 | .0762 | .0686 | .0762 | .0514 | .0762 |
| 20 | .0514 | .0686 | .0762 | .0514 | .0762 | .0514 | .0762 |
| 21 | .0514 | .0762 | .0762 | .0686 | .0762 | .0514 | .0762 |
| 22 | .0514 | .0762 | .0762 | .0514 | .0762 | .0514 | .0762 |
| 23 | .0514 | .0686 | .0762 | .0514 | .0572 | | .0686 |
| 24 | .0762 | .0514 | .0762 | .0762 | .0514 | .0762 | .0514 |
| Max | .0857 | .0762 | .0762 | .0762 | .0762 | .0762 | .0762 |
| Min | .0514 | .0514 | .0572 | .0514 | .0514 | .0514 | .0514 |
| Avg | .0587 | .0642 | .0738 | .0579 | .0664 | .0598 | .0639 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 201 / 11 KV VASHI RLY I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | | .0754 | | .0754 | | |
| 2 | .0686 | | .0754 | | .0754 | | .0754 |
| 3 | .0686 | | .0754 | | .0754 | | |
| 4 | .0686 | | .0754 | | .0754 | | .0754 |
| 5 | .0686 | | .0754 | | .0754 | | |
| 6 | .0686 | | .0754 | | .0754 | | .0754 |
| 7 | | .0754 | | | | .0754 | |
| 18 | | | | | | | .0754 |
| 19 | | .0754 | .0754 | .0754 | | .2263 | .0754 |
| 20 | | .0754 | | | | | |
| 21 | | .0754 | | .0754 | | .0754 | .0754 |
| 22 | | .0754 | .0754 | .0754 | | .0754 | .0762 |
| 23 | | .0754 | | .0754 | .0754 | | |
| 24 | | .0754 | .0754 | .0754 | .0754 | .0754 | .0762 |
| Max | .0686 | .0754 | .0754 | .0754 | .0754 | .2263 | .0762 |
| Min | .0686 | .0754 | .0754 | .0754 | .0754 | .0754 | .0754 |
| Avg | .0686 | .0754 | .0754 | .0754 | .0754 | .1056 | .0756 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 202 / 11 KV SHAH GROUP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1543 | | .1886 | | .1886 | | |
| 2 | .1543 | | .1886 | | .1886 | | .1698 |
| 3 | .1543 | | .1698 | | .1698 | | |
| 4 | .1543 | | .1886 | | .1886 | | .1886 |
| 5 | .1715 | | .2263 | | .2263 | | |
| 6 | .1886 | | .2452 | | .2452 | | .2829 |
| 7 | .2058 | .2829 | .2829 | | .2641 | .2829 | .2829 |
| 8 | .2058 | .3018 | .3206 | .2829 | .3018 | .3395 | .2641 |
| 9 | .2401 | .3018 | .3395 | .3018 | .2829 | .3395 | .3018 |
| 10 | .2572 | .2263 | .3018 | .2641 | .2641 | .2829 | .2641 |
| 11 | | .2075 | | .2452 | .2452 | .2263 | .2829 |
| 12 | | .2075 | .2263 | .2075 | | .2075 | .2452 |
| 13 | | | .2075 | | .1886 | | .2641 |
| 14 | | .1698 | | .1886 | .1698 | .1698 | .2075 |
| 15 | .1905 | .1698 | | .1698 | | .1886 | .1698 |
| 16 | | .1886 | | .1698 | | .1698 | |
| 17 | | .1698 | | .1886 | | .1886 | .2263 |
| 18 | | .2452 | | .2263 | | .2263 | .2263 |
| 19 | | .2452 | .2452 | .2641 | | .2263 | .2263 |
| 20 | | .2263 | | | | | |
| 21 | | .2263 | | .2641 | | .2263 | .2263 |
| 22 | | .2075 | .2263 | .2263 | | .2452 | .2096 |
| 23 | | .2075 | | .2075 | .1886 | | |
| 24 | .1543 | .1886 | .2075 | .1886 | .1698 | .1698 | .1886 |
| Max | .2572 | .3018 | .3395 | .3018 | .3018 | .3395 | .3018 |
| Min | .1543 | .1698 | .1698 | .1698 | .1698 | .1698 | .1698 |
| Avg | .1859 | .2219 | .2376 | .2263 | .2188 | .2326 | .2348 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 203 / 11 KV ASSAM BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | | .0754 | | .0754 | | |
| 2 | .0686 | | .0754 | | .0754 | | .0754 |
| 3 | .0686 | | .0754 | | .0754 | | |
| 4 | .0686 | | .0754 | | .0754 | | .0754 |
| 5 | .0686 | | .0754 | | .0754 | | |
| 6 | .0686 | | .0754 | | .0754 | | .0754 |
| 7 | .0686 | .0754 | .0754 | | .0754 | .0754 | .0754 |
| 8 | .0686 | .0754 | .0754 | .0754 | .0754 | .0754 | .0754 |
| 9 | .0686 | .0754 | .0754 | .0754 | .0754 | .0754 | .0754 |
| 10 | .0686 | .0754 | .0754 | .0754 | .0754 | .0754 | .0754 |
| 11 | | .0754 | | .0754 | .0754 | .0754 | .0762 |
| 12 | | .0754 | | | | .0754 | .0754 |
| 13 | | .0754 | .0754 | | .0754 | | .0754 |
| 14 | | .0754 | | .0754 | .0754 | .0754 | .0754 |
| 15 | .0754 | .0754 | | .0754 | | .0754 | .0754 |
| 16 | | .0754 | | .0754 | | .0754 | |
| 17 | | .0754 | | .0754 | | .0754 | .0762 |
| 18 | | .0754 | | .0754 | | .0754 | .811 |
| 19 | | .0754 | .0754 | .0754 | | .0754 | .0754 |
| 20 | | .0754 | | | | | |
| 21 | | .0754 | | .0754 | | .0754 | .0754 |
| 22 | | .0754 | .0754 | .0754 | | .0754 | .0754 |
| 23 | | .0754 | | .0754 | .0754 | | |
| 24 | .0686 | .0754 | .0754 | .0754 | .0754 | .0754 | .0754 |
| Max | .0754 | .0754 | .0754 | .0754 | .0754 | .0754 | .811 |
| Min | .0686 | .0754 | .0754 | .0754 | .0754 | .0754 | .0754 |
| Avg | .0692 | .0754 | .0754 | .0754 | .0754 | .0754 | .1164 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 204 / 11 KV REAL TRADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6553 | .3894 | .7582 | .4054 | .7781 | .3948 | .4382 |
| 2 | .6401 | .3612 | .7255 | .3582 | .7051 | .3056 | .6922 |
| 3 | .732 | .4313 | .7509 | .4275 | .7282 | .397 | .3567 |
| 4 | .6398 | .4138 | .6801 | .3521 | .6481 | .3208 | .6756 |
| 5 | .5845 | .3117 | .6611 | .3117 | .6542 | .2934 | .301 |
| 6 | .6904 | .4321 | .7785 | .3155 | .8154 | .3056 | .6851 |
| 7 | .6683 | .732 | .7433 | .4915 | .7947 | .8021 | .8061 |
| 8 | .7041 | .8792 | .7379 | .8795 | .8818 | .7872 | .8494 |
| 9 | .8001 | 1.2029 | .9958 | 1.2129 | 1.0981 | 1.0529 | .9775 |
| 10 | .9012 | 1.4525 | 1.6653 | 1.2907 | 1.2898 | 1.2364 | 1.1141 |
| 11 | .6112 | 1.7206 | .8078 | 1.6247 | 1.6318 | 1.5552 | 1.584 |
| 12 | .7316 | 1.8176 | .8627 | .8238 | .836 | 1.7211 | 1.6434 |
| 13 | .7727 | 1.7231 | 1.6457 | .8208 | 1.7206 | .8688 | 1.726 |
| 14 | .7324 | 1.6523 | .8276 | 1.7765 | 1.6455 | 1.5547 | 1.6792 |
| 15 | 1.3938 | 1.7084 | .9008 | 1.7496 | .8711 | 1.6002 | 1.762 |
| 16 | .7339 | 1.8024 | .9069 | 1.6301 | .8863 | 1.8058 | .9922 |
| 17 | .7727 | 1.7452 | 1.0067 | 1.7298 | .9076 | 1.76 | 1.7713 |
| 18 | .7407 | 1.8768 | .9229 | 1.7653 | .9724 | 1.6146 | 1.6874 |
| 19 | .8238 | 1.8453 | 2.0228 | 1.8649 | 1.0951 | 2.0471 | 1.7488 |
| 20 | .8017 | 1.9265 | .9046 | .9838 | .9587 | .9313 | .8284 |
| 21 | .7758 | 1.6939 | .7636 | 1.5402 | .8192 | 1.5829 | 1.4891 |
| 22 | .6447 | 1.1833 | 1.1449 | 1.2273 | .5883 | 1.2819 | 1.1655 |
| 23 | .4893 | .9534 | .4969 | .9928 | 1.1062 | .5533 | .471 |
| 24 | .7655 | .8662 | .8707 | .8819 | .8783 | .905 | .8402 |
| Max | 1.3938 | 1.9265 | 2.0228 | 1.8649 | 1.7206 | 2.0471 | 1.7713 |
| Min | .4893 | .3117 | .4969 | .3117 | .5883 | .2934 | .301 |
| Avg | .7419 | 1.2134 | .9409 | 1.0607 | .9713 | 1.0699 | 1.0952 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 205 / 11 KV VASHI RLY -2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .285 | .1471 | .2776 | .1448 | .2783 | .1463 | .1463 |
| 2 | .2843 | .1471 | .276 | .144 | .2783 | .1463 | .2776 |
| 3 | .2828 | .144 | .2595 | .1456 | .2603 | .1448 | .1448 |
| 4 | .2656 | .1448 | .261 | .1463 | .261 | .1463 | .2565 |
| 5 | .2671 | .1456 | .2783 | .1463 | .2791 | .1463 | .144 |
| 6 | .2686 | .1471 | .2806 | .1494 | .3018 | .1501 | .2965 |
| 7 | .2881 | .3102 | .3064 | .1547 | .3041 | .2875 | .3026 |
| 8 | .2866 | .3003 | .3048 | .2814 | .3071 | .3041 | .301 |
| 9 | .2797 | .3155 | .3231 | .3208 | .3186 | .322 | .3094 |
| 10 | .2835 | .3847 | .3852 | .3763 | .3898 | .3641 | .3657 |
| 11 | .1608 | .4648 | .2187 | .4549 | .4618 | .4504 | .3997 |
| 12 | .1616 | .4633 | .2042 | .2073 | .2256 | .4805 | .3913 |
| 13 | .1547 | .4338 | .5327 | .2004 | .4331 | .2126 | .374 |
| 14 | .1616 | .4255 | .2362 | .4641 | .437 | .4936 | .4069 |
| 15 | .3079 | .4633 | .2309 | .4559 | .2492 | .4709 | .4404 |
| 16 | .1562 | .4725 | .2218 | .4595 | .2401 | .4488 | .2012 |
| 17 | .1562 | .4875 | .2149 | .4572 | .2484 | .4458 | .4244 |
| 18 | .1501 | .4997 | .2164 | .499 | .2408 | .4959 | .4186 |
| 19 | .1608 | .5209 | .43 | .4694 | .2492 | .4831 | .3982 |
| 20 | .1738 | .3913 | .192 | .1943 | .2058 | .2004 | .1959 |
| 21 | .1562 | .3639 | .1738 | .3745 | .1783 | .3662 | .3436 |
| 22 | .1509 | .3413 | .3397 | .3497 | .1593 | .3186 | .342 |
| 23 | .1486 | .3186 | .1631 | .301 | .3352 | .1669 | .1509 |
| 24 | .2843 | .2972 | .298 | .298 | .2987 | .3018 | .298 |
| Max | .3079 | .5209 | .5327 | .499 | .4618 | .4959 | .4404 |
| Min | .1486 | .144 | .1631 | .144 | .1593 | .1448 | .144 |
| Avg | .2198 | .3388 | .2760 | .2998 | .2892 | .3122 | .3054 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 206 / 11 KV CIDCO WATER PUMP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6108 | .3193 | .6474 | .2987 | .6937 | .3643 | .3658 |
| 2 | .5951 | .3025 | .6199 | .2797 | .6306 | .349 | .6968 |
| 3 | .5616 | .2888 | .5988 | .2782 | .5883 | .3292 | .3323 |
| 4 | .5707 | .2782 | .5784 | .2751 | .5883 | .3079 | .6573 |
| 5 | .5593 | .2652 | .5777 | .2736 | .6071 | .3056 | .3056 |
| 6 | .604 | .2911 | .6104 | .3201 | .659 | .349 | .6996 |
| 7 | .6706 | .667 | .6605 | .3597 | .7144 | .7803 | .7954 |
| 8 | .6794 | .7181 | .7242 | .7152 | .7387 | .8372 | .7902 |
| 9 | .716 | .6638 | .7228 | .7945 | .8006 | .8773 | .8514 |
| 10 | .6782 | .8869 | .9722 | .9198 | 1.0002 | .9862 | 1.0631 |
| 11 | .41 | 1.2952 | .6051 | 1.1511 | 1.3527 | 1.3035 | 1.2981 |
| 12 | .4199 | 1.3786 | .6211 | .6211 | .6859 | 1.3763 | 1.3883 |
| 13 | .4755 | 1.3827 | 1.227 | .6401 | .6973 | .7034 | 1.4152 |
| 14 | .4496 | 1.4331 | .6691 | 1.3051 | 1.3203 | 1.371 | 1.3702 |
| 15 | .8825 | 1.4676 | .6973 | 1.3999 | .7293 | 1.4475 | 1.5272 |
| 16 | .458 | 1.5242 | .7103 | 1.4295 | .7049 | 1.4165 | .6973 |
| 17 | .4306 | 1.4043 | .6645 | 1.3613 | .6615 | 1.3771 | 1.3074 |
| 18 | .4031 | 1.2704 | .6173 | 1.358 | .6219 | 1.3096 | 1.2052 |
| 19 | .4191 | 1.0898 | 1.1045 | 1.1701 | .599 | 1.1968 | 1.076 |
| 20 | .426 | .9465 | .522 | .4992 | .5388 | .5335 | .5373 |
| 21 | .4245 | .8461 | .4626 | .9493 | .4976 | 1.0326 | .9465 |
| 22 | .4184 | .7909 | .8329 | .9501 | .4778 | .9562 | .9644 |
| 23 | .413 | .7114 | .4252 | .9501 | .8958 | .4839 | .4809 |
| 24 | .6543 | .6801 | .7228 | .7594 | .8032 | .8555 | .8448 |
| Max | .8825 | 1.5242 | 1.227 | 1.4295 | 1.3527 | 1.4475 | 1.5272 |
| Min | .4031 | .2652 | .4252 | .2736 | .4778 | .3056 | .3056 |
| Avg | .5388 | .8709 | .6914 | .7941 | .7336 | .8687 | .9007 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 208 / 11 KV LIFE STYLE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | | .0754 | | | | |
| 2 | .0686 | | .0754 | | | | |
| 3 | | | .0754 | | | | |
| 18 | | .6036 | | | | | |
| 19 | | .0754 | | | | .0754 | |
| 20 | | .0754 | | | | | |
| 21 | | .0754 | | .0754 | | .0754 | |
| 22 | | .0754 | | .0754 | | .0754 | |
| 23 | | .0754 | | .0754 | | | |
| 24 | .0686 | | .0754 | | .0754 | | .0754 |
| Max | .0686 | .6036 | .0754 | .0754 | .0754 | .0754 | .0754 |
| Min | .0686 | .0754 | .0754 | .0754 | .0754 | .0754 | .0754 |
| Avg | .0686 | .1634 | .0754 | .0754 | .0754 | .0754 | .0754 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 402 / 33 KV BSEL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2058 | | .2263 | | .2263 | | |
| 2 | .2058 | | .2263 | | .2263 | | .2263 |
| 3 | | | .2263 | | .2263 | | |
| 4 | .2058 | | .2263 | | .2263 | | .2263 |
| 5 | .2058 | | .2263 | | .2263 | | |
| 6 | .2058 | | .2263 | | .2263 | | .2263 |
| 7 | .2058 | .2263 | .2263 | | .2263 | .2263 | .2263 |
| 8 | .2058 | .2263 | .2263 | .2263 | .2263 | .2263 | .2263 |
| 9 | .2058 | .2263 | .2263 | .2263 | .2263 | .2263 | .2263 |
| 10 | .2058 | .4527 | .4527 | .4527 | .4527 | .4527 | .2263 |
| 11 | | .679 | | .679 | .679 | .679 | .4481 |
| 12 | | .679 | .679 | | | .679 | .4481 |
| 13 | | .679 | .679 | | .679 | | .4527 |
| 14 | | .679 | | .679 | .679 | .679 | .4527 |
| 15 | .2263 | .679 | | .679 | | .679 | .4527 |
| 16 | | .679 | | .679 | | .679 | |
| 17 | | .679 | | .679 | | .679 | .4527 |
| 18 | | .679 | | .679 | | .679 | .2263 |
| 19 | | .4527 | .4572 | .4527 | | .4527 | .2263 |
| 20 | | .2263 | | | | | |
| 21 | | .2263 | | .2263 | | .2263 | .2263 |
| 22 | | .2263 | .2263 | .2263 | | .2263 | .2263 |
| 23 | | .2263 | | .2263 | .2263 | | |
| 24 | .2058 | .2263 | .679 | .4527 | .679 | | .2263 |
| Max | .2263 | .679 | .679 | .679 | .679 | .679 | .4527 |
| Min | .2058 | .2263 | .2263 | .2263 | .2263 | .2263 | .2263 |
| Avg | .2077 | .4527 | .3473 | .4688 | .3621 | .4850 | .3013 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 403 / 33 KV VISHWAROOP

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9259 | | 1.1317 | | 1.1317 | | |
| 2 | .823 | | 1.1317 | | 1.1317 | | 1.0185 |
| 3 | .823 | | 1.0185 | | 1.0185 | | |
| 4 | .823 | | 1.0185 | | 1.0185 | | .9054 |
| 5 | .072 | | .9054 | | .9054 | | |
| 6 | .7202 | | .9054 | | 1.0185 | | 1.0185 |
| 7 | .823 | 1.0185 | .9054 | | 1.0185 | 1.0185 | .9054 |
| 8 | .823 | 1.1317 | 1.1317 | 1.358 | 1.2449 | 1.1317 | 1.0185 |
| 9 | .9259 | 1.5844 | 1.2449 | 1.358 | 1.5844 | 1.2449 | 1.0185 |
| 10 | .9259 | 1.6975 | 1.5844 | 1.6975 | 1.8107 | 1.5844 | 1.1317 |
| 11 | | 1.8107 | | 1.5844 | 1.9239 | 1.6975 | 1.2449 |
| 12 | | 1.6975 | 1.8107 | | | 1.6975 | 1.2449 |
| 13 | | 1.6975 | 1.6626 | | 1.9239 | | 1.358 |
| 14 | | 1.6975 | | 1.6975 | 1.8107 | 1.5844 | 1.358 |
| 15 | 1.0185 | 1.6975 | | 1.9239 | | 1.8107 | 1.2449 |
| 16 | | 1.6975 | | 1.9239 | | 1.8107 | |
| 17 | | 1.6975 | | 1.9239 | | 1.6975 | 1.2449 |
| 18 | | 1.8107 | | 1.8107 | | 1.8107 | 1.2449 |
| 19 | | 1.8107 | 1.8107 | 1.6975 | | 1.6975 | 1.358 |
| 20 | | 1.5844 | | | | | |
| 21 | | 1.4712 | | 1.4712 | | 1.4712 | 1.1317 |
| 22 | | 1.358 | 1.358 | 1.358 | | 1.358 | 1.0185 |
| 23 | | 1.358 | | 1.358 | 1.3508 | | |
| 24 | .9259 | .9054 | 1.8107 | 1.1317 | 1.358 | | 1.1317 |
| Max | 1.0185 | 1.8107 | 1.8107 | 1.9239 | 1.9239 | 1.8107 | 1.358 |
| Min | .072 | .9054 | .9054 | 1.1317 | .9054 | 1.0185 | .9054 |
| Avg | .8024 | 1.5403 | 1.2954 | 1.5924 | 1.3500 | 1.5439 | 1.1443 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 404 / 33 KV SEC 30 SANPADA FRM NON SHEDDABLE EXPRESS HV FEEDERS

VASHI Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8745 | .7202 | .8745 | .823 | .7716 | .7716 | .823 |
| 2 | .823 | .823 | .8745 | .7716 | .7716 | .7202 | .8745 |
| 3 | .7716 | .7202 | .823 | .7202 | .7202 | .7202 | .7716 |
| 4 | .7716 | .7202 | .823 | .7202 | .7716 | .7202 | .7716 |
| 5 | .6687 | .7716 | .7716 | .6687 | .823 | .6687 | .823 |
| 6 | .6687 | .8745 | .8745 | .6687 | .8745 | .823 | .9259 |
| 7 | .7716 | .9774 | .9259 | .823 | .9774 | .9259 | 1.0288 |
| 8 | .9259 | 1.0288 | 1.0288 | .9774 | .9259 | .9774 | 1.0802 |
| 9 | 1.0288 | 1.0802 | 1.1831 | 1.0802 | 1.0802 | 1.0802 | 1.1831 |
| 10 | 1.1831 | 1.3375 | 1.3375 | 1.3375 | 1.3889 | 1.3889 | 1.3375 |
| 11 | .9259 | 1.286 | 1.286 | 1.3375 | 1.3889 | 1.4403 | 1.4918 |
| 12 | .9774 | 1.286 | 1.286 | 1.286 | 1.3375 | 1.3375 | 1.4918 |
| 13 | .9259 | 1.2346 | 1.286 | 1.1831 | 1.286 | 1.3889 | 1.4403 |
| 14 | .9774 | 1.2346 | 1.3375 | 1.1317 | 1.2346 | 1.1831 | 1.4918 |
| 15 | .823 | 1.2346 | 1.3375 | 1.286 | 1.1831 | 1.1831 | 1.3889 |
| 16 | .823 | 1.2346 | 1.3375 | 1.2346 | 1.3375 | 1.286 | 1.3375 |
| 17 | .8745 | 1.2346 | | 1.2346 | 1.3889 | 1.2346 | 1.286 |
| 18 | .6516 | 1.3375 | 1.4403 | 1.286 | 1.3889 | 1.2346 | 1.286 |
| 19 | 1.0802 | 1.4403 | 1.3375 | 1.3375 | 1.3375 | 1.3375 | 1.3889 |
| 20 | .9774 | 1.2346 | 1.3375 | 1.286 | 1.286 | 1.2346 | 1.3889 |
| 21 | 1.0802 | 1.2346 | 1.286 | 1.2346 | 1.1831 | 1.2346 | 1.3375 |
| 22 | 1.0288 | 1.0802 | 1.286 | 1.0802 | 1.1317 | 1.0802 | 1.1831 |
| 23 | .8745 | .9774 | 1.1317 | .9774 | .9774 | | 1.0288 |
| 24 | .9259 | .7716 | 1.3889 | .9259 | .8745 | .9259 | .9774 |
| Max | 1.1831 | 1.4403 | 1.4403 | 1.3375 | 1.3889 | 1.4403 | 1.4918 |
| Min | .6516 | .7202 | .7716 | .6687 | .7202 | .6687 | .7716 |
| Avg | .8931 | 1.0781 | 1.1563 | 1.0588 | 1.1017 | 1.0825 | 1.1724 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 201 / 11 KV NMMC WATER PUMP SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .7207 | | | .7207 | .7392 | |
| 2 | | .6838 | | | | | .7095 |
| 3 | | .6283 | | | .6838 | | |
| 4 | | .6468 | | | | | .7655 |
| 5 | | .7577 | | | .8871 | | |
| 6 | | 1.0903 | | | | | 1.1203 |
| 7 | | 1.1458 | | | 1.0349 | | |
| 8 | | 1.1827 | | .8871 | 1.1088 | | 1.1389 |
| 9 | | | 1.2012 | .961 | | 1.1458 | 1.1203 |
| 10 | | | 1.1088 | .8686 | .9795 | 1.0082 | 1.0269 |
| 11 | 1.0349 | | .9795 | .9425 | .961 | .9522 | .9896 |
| 12 | .9425 | | .8962 | .7762 | 1.0164 | | .924 |
| 13 | .8316 | | .8413 | .7207 | .8316 | .8215 | .7392 |
| 14 | .7207 | | .7682 | .6468 | .8501 | .8962 | .7023 |
| 15 | .6653 | | .6767 | .7207 | | .7095 | .6468 |
| 16 | .6468 | | .695 | .7577 | | .6722 | .6767 |
| 17 | .924 | | | .7947 | | .6908 | .8962 |
| 18 | 1.0534 | | | 1.1458 | | .8962 | 1.2803 |
| 19 | 1.423 | | | 1.4045 | | 1.0642 | 1.3352 |
| 20 | 1.386 | | | 1.3306 | | 1.3256 | 1.3169 |
| 21 | 1.2936 | | | 1.3306 | | 1.3256 | |
| 22 | 1.0534 | | | 1.0534 | | 1.1949 | |
| 23 | .9425 | | | .9055 | | | |
| 24 | .7682 | .7762 | | .7762 | .7947 | .7762 | .7095 |
| Max | 1.423 | 1.1827 | 1.2012 | 1.4045 | 1.1088 | 1.3256 | 1.3352 |
| Min | .6468 | .6283 | .6767 | .6468 | .6838 | .6722 | .6468 |
| Avg | .9776 | .8480 | .8959 | .9425 | .8971 | .9479 | .9469 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 202 / 11 KV TEJASWINI HOSTEL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.2071 | | | | 1.1694 | |
| 2 | | 1.1506 | | | 1.1128 | | 1.1317 |
| 3 | | 1.1128 | | | | | |
| 4 | | 1.094 | | | 1.094 | | 1.1128 |
| 5 | | 1.1128 | | | | | |
| 6 | | 1.1317 | | | 1.1317 | | 1.1694 |
| 7 | | 1.226 | | | | | |
| 8 | | 1.2637 | | 1.4712 | 1.3769 | | 1.3203 |
| 9 | | | 1.4523 | 1.4335 | | 1.4146 | 1.4146 |
| 10 | | | 1.4146 | 1.358 | 1.4712 | 1.3957 | 1.5089 |
| 11 | 1.3203 | | 1.3957 | 1.3392 | 1.1506 | 1.4712 | 1.5123 |
| 12 | 1.3769 | | 1.3443 | 1.358 | 1.3769 | | 1.531 |
| 13 | 1.3203 | | 1.3256 | 1.4146 | 1.3203 | 1.4335 | 1.4937 |
| 14 | 1.3014 | | 1.3256 | 1.4712 | 1.3769 | 1.3957 | 1.4377 |
| 15 | 1.2826 | | 1.2883 | 1.358 | | 1.3392 | 1.475 |
| 16 | 1.2637 | | 1.4415 | 1.3392 | | 1.3769 | 1.5154 |
| 17 | 1.2826 | | | 1.4901 | | 1.3769 | 1.4784 |
| 18 | 1.4712 | | | 1.7353 | | 1.7353 | 1.848 |
| 19 | 1.7918 | | | 1.9616 | | 1.8484 | 1.9035 |
| 20 | 1.773 | | | 1.8861 | | 1.7541 | 1.7551 |
| 21 | 1.6975 | | | 1.7164 | | 1.6975 | |
| 22 | 1.5089 | | | 1.5844 | | 1.5466 | |
| 23 | 1.4146 | | | 1.3203 | | | |
| 24 | 1.1506 | 1.2449 | | 1.1883 | 1.226 | 1.2071 | 1.2637 |
| Max | 1.7918 | 1.2637 | 1.4523 | 1.9616 | 1.4712 | 1.8484 | 1.9035 |
| Min | 1.1506 | 1.094 | 1.2883 | 1.1883 | 1.094 | 1.1694 | 1.1128 |
| Avg | 1.4254 | 1.1715 | 1.3735 | 1.4956 | 1.2637 | 1.4775 | 1.4630 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 203 / 11 KV SANPADA INDL SEC 6 SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1143 | | | | .1334 | |
| 2 | | .1143 | | | .1143 | | .1334 |
| 3 | | .0953 | | | | | |
| 4 | | .0953 | | | .1143 | | .1334 |
| 5 | | .1143 | | | | | |
| 6 | | .1334 | | | .1334 | | .1334 |
| 7 | | .1334 | | | | | |
| 8 | | .1334 | | .1524 | .1524 | | .1334 |
| 9 | | | .1715 | .1524 | | .1524 | .1334 |
| 10 | | | .1715 | .1524 | .1715 | .1715 | .1524 |
| 11 | .1334 | | .1715 | .1524 | .1715 | .1524 | .1524 |
| 12 | .1334 | | .1715 | .1715 | .1715 | .1905 | .1715 |
| 13 | .1334 | | .1715 | .1715 | .1715 | .1905 | .1715 |
| 14 | .1334 | | .1715 | .1715 | .1524 | .1715 | .1715 |
| 15 | .1334 | | .1715 | .1905 | | .2096 | .1524 |
| 16 | .1334 | | .1905 | .1715 | | .1715 | .1524 |
| 17 | .1334 | | | .2096 | | .2096 | .1715 |
| 18 | .1143 | | | .1905 | | .1715 | .1715 |
| 19 | .1334 | | | .1715 | | .1524 | .1905 |
| 20 | .1334 | | | .1715 | | .1524 | .1715 |
| 21 | .1334 | | | .1524 | | .1334 | |
| 22 | .1334 | | | .1524 | | .1334 | |
| 23 | .1143 | | | .1524 | | | |
| 24 | .1334 | .1143 | | .1334 | .1334 | .1334 | .1334 |
| Max | .1334 | .1334 | .1905 | .2096 | .1715 | .2096 | .1905 |
| Min | .1143 | .0953 | .1715 | .1334 | .1143 | .1334 | .1334 |
| Avg | .1307 | .1164 | .1739 | .1659 | .1486 | .1643 | .1547 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 204 / 11 KV SEC 6 SUBSTATION SHEDDABLE URBAN

TRANSFO Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3921 | | | | .4108 | |
| 2 | | .3547 | | | .3361 | | .3361 |
| 3 | | .3174 | | | | | |
| 4 | | .2987 | | | .2801 | | .3361 |
| 5 | | .3361 | | | | | |
| 6 | | .3547 | | | .3361 | | .3547 |
| 7 | | .4294 | | | | | |
| 8 | | .5041 | | .4294 | .4854 | | .4481 |
| 9 | | | .5228 | .4668 | | .4668 | .4854 |
| 10 | | | .4294 | .4294 | .4108 | .4481 | .5228 |
| 11 | .5041 | | .3547 | .3921 | .4294 | .4294 | .4668 |
| 12 | .4294 | | .3361 | .3772 | .3734 | .4294 | .4294 |
| 13 | .3921 | | .3361 | .3734 | .3734 | .3921 | .3921 |
| 14 | .3734 | | .3174 | .3584 | .3361 | .3547 | .3734 |
| 15 | .3734 | | .3361 | .3174 | | .3361 | .3547 |
| 16 | .3361 | | .3174 | .3174 | | .3361 | .3734 |
| 17 | .2987 | | | .3547 | | .3174 | .3174 |
| 18 | .3921 | | | .4108 | | .3921 | .4668 |
| 19 | .4854 | | | .4854 | | .5041 | .5228 |
| 20 | .4481 | | | .4668 | | .5601 | .4481 |
| 21 | .4668 | | | .4854 | | .5601 | |
| 22 | .4481 | | | .4854 | | .5601 | |
| 23 | .4481 | | | .5415 | | | |
| 24 | .3734 | .4294 | | .4854 | .3921 | .5041 | .3734 |
| Max | .5041 | .5041 | .5228 | .5415 | .4854 | .5601 | .5228 |
| Min | .2987 | .2987 | .3174 | .3174 | .2801 | .3174 | .3174 |
| Avg | .4121 | .3796 | .3688 | .4222 | .3753 | .4376 | .4119 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 205 / 11 KV SAIKRIPA SEC 10 SHEDDABLE URBAN
SANPADA Feeder KV- 11 /
OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3048 | | | | .3048 | |
| 2 | | .2667 | | | .2477 | | .2667 |
| 3 | | .2477 | | | | | |
| 4 | | .2477 | | | .2286 | | .3048 |
| 5 | | .2858 | | | | | |
| 6 | | .3429 | | | .3239 | | .4191 |
| 7 | | .4001 | | | | | |
| 8 | | .4572 | | .4763 | .4954 | | .4001 |
| 9 | | | .4763 | .4382 | | .4382 | .4382 |
| 10 | | | .4382 | .381 | .381 | .4382 | .4191 |
| 11 | .362 | | .3429 | .3429 | .3429 | .3429 | .3429 |
| 12 | .2858 | | .3018 | .3239 | .3239 | .362 | .3018 |
| 13 | .2667 | | .2829 | .3239 | .3239 | .3239 | .3206 |
| 14 | .2477 | | .2641 | .3239 | .3048 | .2667 | .3018 |
| 15 | .2286 | | .2452 | .2667 | | .3048 | .2829 |
| 16 | .2096 | | .2241 | .2477 | | .2477 | .2427 |
| 17 | .2286 | | | .2477 | | .2667 | .2241 |
| 18 | .2477 | | | .3429 | | .2477 | .3734 |
| 19 | .381 | | | .4382 | | .4001 | .4108 |
| 20 | .4382 | | | .4001 | | .4191 | .415 |
| 21 | .4001 | | | .4001 | | .381 | |
| 22 | .4001 | | | .3429 | | .4001 | |
| 23 | .381 | | | .3429 | | | |
| 24 | .2858 | .3239 | | .2667 | .3048 | .3239 | .3429 |
| Max | .4382 | .4572 | .4763 | .4763 | .4954 | .4382 | .4382 |
| Min | .2096 | .2477 | .2241 | .2477 | .2286 | .2477 | .2241 |
| Avg | .3116 | .3196 | .3219 | .3474 | .3277 | .3417 | .3416 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 206 / 11 KV SAMTA SEC 4/7 SHEDDABLE URBAN
 SANPADA Feeder KV- 11 /
 OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6722 | | | | .6722 | |
| 2 | | .6161 | | | .6161 | | .6161 |
| 3 | | .5788 | | | | | |
| 4 | | .5975 | | | .6161 | | .7282 |
| 5 | | .6722 | | | | | |
| 6 | | .8215 | | | .7655 | | 1.0642 |
| 7 | | .9149 | | | | | |
| 8 | | 1.0642 | | 1.1203 | 1.0829 | | 1.0642 |
| 9 | | | 1.1576 | 1.0642 | | 1.0456 | 1.1016 |
| 10 | | | 1.0269 | .9896 | .9896 | .9709 | 1.0269 |
| 11 | .9709 | | .8215 | .8962 | .8962 | 1.0456 | .9896 |
| 12 | .8589 | | .7762 | .8215 | .8029 | 1.3769 | .924 |
| 13 | .7468 | | .7392 | .7842 | .7655 | .7468 | .8871 |
| 14 | .6722 | | .7023 | .7468 | .8029 | .8029 | .8131 |
| 15 | .6535 | | .7392 | .7842 | | .6535 | .7947 |
| 16 | .7095 | | .7499 | .6348 | | .7468 | .7682 |
| 17 | .5788 | | | .8029 | | .7842 | .7865 |
| 18 | .9149 | | | .9522 | | .9149 | .8962 |
| 19 | 1.0829 | | | 1.1389 | | 1.1016 | 1.0059 |
| 20 | 1.1389 | | | 1.1949 | | 1.2323 | 1.0903 |
| 21 | 1.1016 | | | 1.1389 | | 1.1949 | |
| 22 | .9709 | | | 1.0082 | | 1.0642 | |
| 23 | .8402 | | | .8029 | | | |
| 24 | .6722 | .7095 | | .6722 | .7095 | .6908 | .7655 |
| Max | 1.1389 | 1.0642 | 1.1576 | 1.1949 | 1.0829 | 1.3769 | 1.1016 |
| Min | .5788 | .5788 | .7023 | .6348 | .6161 | .6535 | .6161 |
| Avg | .8509 | .7385 | .8391 | .9149 | .8047 | .9403 | .9013 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 208 / 11 KV LAXMI SEC10 SANPADA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.251 | | | | 1.2323 | |
| 2 | | 1.2136 | | | 1.1576 | | 1.1763 |
| 3 | | 1.1389 | | | | | |
| 4 | | 1.1763 | | | 1.1763 | | 1.1949 |
| 5 | | 1.2883 | | | | | |
| 6 | | 1.475 | | | 1.475 | | 1.531 |
| 7 | | 1.587 | | | | | |
| 8 | | 1.7364 | | 1.4563 | 1.8671 | | 1.8298 |
| 9 | | | 1.8111 | 1.4003 | | 1.531 | 1.7364 |
| 10 | | | 1.475 | 1.3256 | 1.475 | 1.2883 | 1.531 |
| 11 | 1.419 | | 1.1949 | 1.1576 | 1.2136 | 1.251 | 1.3443 |
| 12 | 1.2696 | | 1.1203 | 1.0642 | 1.1203 | 1.1763 | 1.2136 |
| 13 | 1.1949 | | 1.0456 | 1.0082 | | 1.1203 | 1.1949 |
| 14 | 1.1203 | | .9896 | .9522 | .9709 | 1.0642 | 1.1763 |
| 15 | 1.0456 | | .9522 | .9709 | | 1.0082 | 1.1389 |
| 16 | 1.0269 | | 1.0082 | .9709 | | 1.0642 | 1.1203 |
| 17 | 1.1949 | | | 1.0456 | | | 1.251 |
| 18 | 1.2883 | | | 1.2883 | | 1.2696 | 1.4003 |
| 19 | 1.7177 | | | 1.6617 | | 1.5497 | 1.6244 |
| 20 | 1.6617 | | | 1.7364 | | 1.6804 | 1.7177 |
| 21 | 1.6804 | | | 1.6804 | | 1.643 | |
| 22 | 1.6244 | | | 1.6244 | | 1.587 | |
| 23 | 1.4937 | | | 1.4563 | | | |
| 24 | 1.251 | 1.307 | | 1.2323 | 1.2883 | 1.2696 | 1.1763 |
| Max | 1.7177 | 1.7364 | 1.8111 | 1.7364 | 1.8671 | 1.6804 | 1.8298 |
| Min | 1.0269 | 1.1389 | .9522 | .9522 | .9709 | 1.0082 | 1.1203 |
| Avg | 1.3563 | 1.3526 | 1.1996 | 1.2960 | 1.3049 | 1.3157 | 1.3740 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 201 / 11 KV SUN HOME

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6722 | .7356 | .8215 | .7468 | .7095 | .9149 | .7655 |
| 2 | .6908 | .7095 | .7468 | .7468 | .7655 | .7282 | .7842 |
| 3 | .6722 | .7095 | .7207 | .7842 | .7167 | .6908 | .8215 |
| 4 | .7095 | .6908 | .6908 | .8215 | .6908 | .7282 | .8589 |
| 5 | .7282 | .7095 | .7282 | .8962 | .6908 | 1.0082 | .9149 |
| 6 | .7282 | 1.094 | .8676 | .9709 | 1.0642 | 1.1389 | 1.0269 |
| 7 | .8962 | 1.1317 | 1.2696 | 1.251 | 1.1883 | 1.1949 | 1.2323 |
| 8 | 1.0269 | 1.2826 | 1.4003 | 1.3817 | 1.3957 | 1.4003 | 1.2883 |
| 9 | 1.4377 | 1.1694 | 1.4377 | 1.2883 | 1.3957 | 1.2323 | 1.251 |
| 10 | 1.4563 | .9709 | 1.1203 | 1.1203 | 1.0642 | 1.1016 | 1.1763 |
| 11 | 1.2136 | .9896 | .9335 | .9709 | 1.0269 | .9335 | .9896 |
| 12 | 1.0456 | .8029 | .8402 | .8215 | .7842 | .8962 | .8775 |
| 13 | .8589 | .6722 | .7655 | .7356 | .7095 | .7095 | .7655 |
| 14 | .8029 | .6908 | .6908 | .6535 | .679 | .6908 | .7282 |
| 15 | .7842 | .6161 | .6535 | .6535 | .6908 | .6722 | .6908 |
| 16 | .7655 | .6161 | .679 | .6722 | .7282 | .5975 | .7095 |
| 17 | .7842 | .7655 | .679 | .6722 | .7468 | .6908 | .7842 |
| 18 | .8775 | .8215 | .7842 | .7733 | .8215 | .8029 | .8589 |
| 19 | 1.1203 | 1.0642 | .9997 | 1.0562 | 1.0456 | 1.0269 | 1.1016 |
| 20 | 1.1128 | 1.1576 | 1.1128 | 1.1128 | 1.2136 | 1.0829 | 1.1016 |
| 21 | 1.2449 | 1.3256 | 1.1763 | 1.1883 | 1.1949 | 1.1203 | 1.1389 |
| 22 | 1.1128 | 1.2323 | 1.0642 | 1.1317 | 1.1763 | 1.1016 | 1.1317 |
| 23 | 1.0185 | .9896 | .9335 | .9808 | .9896 | | 1.1016 |
| 24 | .8215 | .8488 | .8402 | .8215 | .8488 | .8215 | .8402 |
| Max | 1.4563 | 1.3256 | 1.4377 | 1.3817 | 1.3957 | 1.4003 | 1.2883 |
| Min | .6722 | .6161 | .6535 | .6535 | .679 | .5975 | .6908 |
| Avg | .9409 | .9082 | .9148 | .9272 | .9307 | .9254 | .9558 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 204 / Spare (11 KV Sec 30 Nerul link Feeder KV- 11 / OUTGOING SHEDDABLE URBAN

| DATE | 18-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 9 | .056 |
| Max | .056 |
| Min | .056 |
| Avg | .056 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 205 / 11 KV SUBSTATION

SHEDDABLE URBAN

TRANSFORMER S Feeder KV- 11 /
OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .056 | .0377 | .0566 | .056 | .0373 | .0566 | .0747 |
| 2 | .056 | .0373 | .056 | .056 | .056 | .0566 | .056 |
| 3 | .056 | .0373 | .056 | .056 | .056 | .056 | .056 |
| 4 | .056 | .0373 | .0566 | .056 | .0373 | .0566 | .056 |
| 5 | .056 | .0373 | .056 | .056 | .056 | .0566 | .056 |
| 6 | .056 | .0566 | .0566 | .056 | .0373 | .0566 | .056 |
| 7 | .056 | .0051 | .0566 | .056 | .0566 | .0566 | .056 |
| 8 | .056 | .0566 | .0566 | .056 | .0566 | .0566 | .0747 |
| 9 | .056 | .0566 | .0566 | .0747 | .0754 | .0566 | .0747 |
| 10 | .056 | .056 | .056 | .056 | .0566 | .0566 | .056 |
| 11 | .056 | .056 | .056 | .056 | .0566 | .056 | .0566 |
| 12 | .056 | .056 | .056 | .056 | .0566 | .0046 | .0566 |
| 13 | .056 | .0566 | .056 | .056 | .0566 | .0747 | .0566 |
| 14 | .056 | .0566 | .6908 | .0566 | .0566 | .0747 | .0566 |
| 15 | .056 | .056 | .0747 | .056 | .0566 | | .0566 |
| 16 | .056 | .0566 | .056 | .0566 | .0566 | .0747 | .0566 |
| 17 | .0373 | .0566 | | .056 | .0566 | .0747 | .0566 |
| 18 | .0373 | .0566 | .056 | .056 | .0566 | .056 | .0566 |
| 19 | | .0566 | .0566 | .056 | .0566 | .0747 | .0566 |
| 20 | .0373 | .0566 | .0566 | .0377 | .0566 | .0747 | .0566 |
| 21 | .0377 | .0566 | .056 | .0377 | .0566 | .056 | .0566 |
| 22 | .0377 | .056 | .056 | .0377 | .0566 | .0747 | .0566 |
| 23 | .0566 | .0566 | .056 | .0377 | .0566 | | .0566 |
| 24 | .056 | .0566 | .0566 | .056 | .0377 | .0566 | .0747 |
| Max | .0566 | .0566 | .6908 | .0747 | .0754 | .0747 | .0747 |
| Min | .0373 | .0051 | .056 | .0377 | .0373 | .0046 | .056 |
| Avg | .0520 | .0503 | .0846 | .0538 | .0541 | .0599 | .0594 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 206 / 11 KV KUKSHET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7468 | .8865 | .9149 | .8589 | .8029 | .8962 | |
| 2 | .7842 | .7842 | .9054 | .8775 | .7922 | .8215 | .9335 |
| 3 | .7655 | .7842 | .8775 | .8589 | .7468 | .7842 | .9335 |
| 4 | .7842 | .7655 | .7842 | .9335 | .7468 | .7842 | .9896 |
| 5 | .8215 | .7842 | .7842 | .9709 | .7655 | .9149 | 1.0269 |
| 6 | .8589 | .9997 | .9335 | 1.0082 | .9808 | 1.1203 | 1.1203 |
| 7 | .9522 | 1.1883 | 1.2323 | 1.251 | 1.1317 | 1.1576 | 1.1389 |
| 8 | 1.1576 | 1.2637 | 1.2883 | 1.251 | 1.2449 | 1.358 | 1.2136 |
| 9 | 1.1763 | 1.1694 | 1.226 | 1.1576 | 1.2071 | 1.1128 | 1.2136 |
| 10 | 1.1576 | .9709 | .9522 | .9149 | .9997 | 1.0082 | .9896 |
| 11 | .9709 | .7842 | .8589 | .8865 | .8402 | .9149 | .9896 |
| 12 | .9149 | .8589 | .8215 | .811 | .8402 | .7842 | .9054 |
| 13 | .8215 | .7545 | .8215 | .7655 | .8402 | .7655 | .8676 |
| 14 | .7095 | .6979 | .6908 | .6908 | .7733 | .7095 | .7922 |
| 15 | .7842 | .7282 | .6908 | .7095 | .7545 | .7282 | .7468 |
| 16 | .6908 | .6722 | .6979 | .7095 | .7468 | .6722 | .7095 |
| 17 | .6908 | .6908 | .6602 | .6908 | .7095 | .6722 | .7545 |
| 18 | .8962 | .8589 | .9149 | .8215 | .8589 | .8589 | .8775 |
| 19 | 1.2136 | 1.1576 | 1.1128 | 1.1694 | 1.2136 | 1.1016 | 1.2696 |
| 20 | 1.2826 | 1.2136 | 1.2449 | 1.2637 | 1.2696 | 1.251 | 1.3203 |
| 21 | 1.226 | 1.2323 | 1.1576 | 1.226 | 1.251 | 1.2323 | 1.2637 |
| 22 | 1.1317 | 1.1576 | 1.1763 | 1.226 | 1.2136 | 1.2136 | 1.1883 |
| 23 | 1.0751 | 1.0269 | 1.0456 | 1.0185 | 1.1389 | | 1.1016 |
| 24 | .9335 | .9619 | .9335 | .9149 | .9431 | .9709 | .9709 |
| Max | 1.2826 | 1.2637 | 1.2883 | 1.2637 | 1.2696 | 1.358 | 1.3203 |
| Min | .6908 | .6722 | .6602 | .6908 | .7095 | .6722 | .7095 |
| Avg | .9394 | .9330 | .9469 | .9578 | .9505 | .9493 | 1.0138 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 207 / 11 KV AGRI KOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3361 | .3361 | .3174 | .3734 | .3395 | .3547 | .3361 |
| 2 | .3174 | .3018 | .3174 | .3921 | .3361 | .3361 | .3174 |
| 3 | .3174 | .2987 | .2987 | .3734 | .3361 | .3206 | .2987 |
| 4 | | .2987 | .2987 | .3921 | .3174 | .3174 | .3174 |
| 5 | .3547 | .3174 | .2987 | .4108 | .3174 | .3772 | .3547 |
| 6 | .3921 | .4715 | .3547 | .4294 | .4527 | .4294 | .4294 |
| 7 | .4108 | .5658 | .5975 | .5601 | .5658 | .5658 | .5601 |
| 8 | .4294 | .6161 | .6036 | .5415 | .6036 | .5847 | .5788 |
| 9 | .5601 | .7167 | .5788 | .5228 | .6036 | .5281 | .5415 |
| 10 | .5975 | .6348 | .5041 | .4854 | .4904 | .5359 | .5601 |
| 11 | .4668 | .4854 | .4854 | .3734 | .4108 | .4108 | .4668 |
| 12 | .5041 | .4854 | .4668 | .3734 | .4108 | .3547 | .4527 |
| 13 | .4108 | .4108 | .4294 | .3772 | .3772 | .4108 | .4294 |
| 14 | .4294 | .5041 | .4108 | .3395 | .3174 | .3547 | .3734 |
| 15 | .3361 | .4108 | .3734 | .3018 | .2829 | .3361 | .3734 |
| 16 | .3547 | .3734 | .3734 | .2987 | .3206 | .4668 | .3734 |
| 17 | .3921 | .3734 | .1191 | .3734 | .3547 | .5228 | .4108 |
| 18 | .4481 | .4481 | .5281 | .4294 | .4481 | .5601 | .4854 |
| 19 | .547 | .5415 | .5281 | .5041 | .4854 | .5415 | .4715 |
| 20 | .4715 | .5601 | .5281 | .547 | .4854 | .5228 | .4854 |
| 21 | .4715 | .5788 | .5415 | .5093 | .4294 | .5415 | .4527 |
| 22 | .4338 | 1.1576 | .5041 | .4527 | .4668 | .4481 | .4668 |
| 23 | .415 | .415 | .4668 | .4527 | .4294 | | .4481 |
| 24 | .3921 | .3772 | .3361 | .4108 | .3772 | .3734 | .3734 |
| Max | .5975 | 1.1576 | .6036 | .5601 | .6036 | .5847 | .5788 |
| Min | .3174 | .2987 | .1191 | .2987 | .2829 | .3174 | .2987 |
| Avg | .4256 | .4866 | .4275 | .4260 | .4149 | .4432 | .4316 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 401 / 33 KV SEC 30 NERUL S/STN SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7202 | | | .631 | | | |
| 2 | .5658 | | | | .6687 | | |
| 4 | .5658 | | | | .7202 | | |
| 6 | .7716 | .8505 | | | .8745 | | .7362 |
| 8 | .823 | 1.1163 | | | 1.0288 | | 1.1043 |
| 9 | .9774 | | | | 1.0288 | | |
| 10 | 4.5182 | | | .9259 | | .9991 | |
| 11 | | | | .9774 | | | 1.1043 |
| 12 | 1.0099 | | .9465 | .9259 | | .9465 | .9991 |
| 13 | | | | .8745 | | | .9991 |
| 14 | .9036 | .8413 | .8413 | .823 | | .7888 | .9465 |
| 15 | | | | .7716 | | | .9465 |
| 16 | .7442 | | .7888 | .7202 | | .7362 | |
| 17 | | | .8413 | .8745 | | | .9465 |
| 18 | 1.0631 | | .9991 | .9259 | | 1.0517 | .9991 |
| 19 | | | 1.2094 | 1.2346 | | | 1.2094 |
| 20 | 1.1694 | | | 1.1831 | | 1.1568 | 1.262 |
| 21 | | | | 1.1831 | | | |
| 22 | 1.0631 | | .9991 | 1.0802 | | 1.0517 | |
| 24 | .691 | | .7282 | .631 | .6687 | .6241 | |
| Max | 4.5182 | 1.1163 | 1.2094 | 1.2346 | 1.0288 | 1.1568 | 1.262 |
| Min | .5658 | .8413 | .7282 | .631 | .6687 | .6241 | .7362 |
| Avg | 1.1133 | .9360 | .9192 | .9175 | .8316 | .9194 | 1.023 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 201 / 11 KV SEC 24, SEC 30 STN SHEDDABLE URBAN

NERU Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9259 | | | 1.0082 | | | |
| 2 | .8059 | | | | 1.1831 | | |
| 3 | | | | .9335 | | | |
| 4 | .8059 | | | | 1.1488 | | |
| 5 | | | | 1.0456 | | | |
| 6 | .8916 | 1.3306 | | | 1.1488 | | 1.4563 |
| 8 | 1.2003 | 1.5708 | | 1.643 | 1.3546 | | 1.5123 |
| 9 | 1.3889 | | | 1.5123 | 1.3203 | | |
| 10 | 1.5708 | | 1.2883 | 1.1488 | | 1.2696 | |
| 11 | | | 1.1016 | | | | 1.1949 |
| 12 | 1.2012 | | .9522 | .8745 | | .9522 | 1.0642 |
| 13 | | | | .8573 | | | 1.1016 |
| 14 | 1.0903 | .8775 | .8589 | .8745 | | .9522 | .9522 |
| 15 | | | | .7716 | | | .9335 |
| 16 | .9055 | | .7655 | .7202 | | .8215 | .8589 |
| 17 | | | .8029 | .7716 | | | .9335 |
| 18 | 1.0719 | | .9709 | .8402 | | 1.0642 | 1.0082 |
| 19 | | | 1.3443 | 1.2174 | | | 1.363 |
| 20 | 1.4045 | | 1.4003 | 1.2689 | | 1.3443 | 1.4003 |
| 21 | | | 1.4003 | 1.286 | | | 1.4003 |
| 22 | 1.3306 | | 1.3817 | 1.2689 | | 1.363 | 1.4377 |
| 23 | | | | | | | 1.3256 |
| 24 | 1.0534 | | 1.0642 | 1.0082 | 1.2003 | 1.0642 | |
| Max | 1.5708 | 1.5708 | 1.4003 | 1.643 | 1.3546 | 1.363 | 1.5123 |
| Min | .8059 | .8775 | .7655 | .7202 | 1.1488 | .8215 | .8589 |
| Avg | 1.1176 | 1.2596 | 1.1109 | 1.0584 | 1.2260 | 1.1039 | 1.1962 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 202 / 11 KV METRO,SEC 30 STN SHEDDABLE URBAN

NERUL Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .12 | | | .112 | | | |
| 2 | .1029 | | | | .1029 | | |
| 3 | | | | .112 | | | |
| 4 | .1029 | | | | .1029 | | |
| 5 | | | | .112 | | | |
| 6 | .12 | .1294 | | | .12 | | .0934 |
| 8 | .12 | .1478 | | .1307 | .12 | | .1307 |
| 9 | .12 | | | .1307 | .1372 | | |
| 10 | .1294 | | .1307 | .12 | | .1307 | |
| 11 | | | .112 | .12 | | | .1307 |
| 12 | .1478 | | .0934 | .12 | | .112 | .1307 |
| 13 | | | | .1029 | | | .112 |
| 14 | .1109 | .1307 | .112 | .12 | | .112 | .1307 |
| 15 | | | | .12 | | | .1307 |
| 16 | .1109 | | .112 | .12 | | .112 | .112 |
| 17 | | | .112 | .1029 | | | .1307 |
| 18 | .1109 | | .112 | .12 | | .1307 | .112 |
| 19 | | | .1307 | .12 | | | .1307 |
| 20 | .1294 | | .112 | .12 | | .1494 | .1307 |
| 21 | | | .112 | .1372 | | | .1307 |
| 22 | .1109 | | .1307 | .12 | | .112 | .1307 |
| 23 | | | | | | | .1307 |
| 24 | .1109 | | .1307 | .112 | .12 | .112 | |
| Max | .1478 | .1478 | .1307 | .1372 | .1372 | .1494 | .1307 |
| Min | .1029 | .1294 | .0934 | .1029 | .1029 | .112 | .0934 |
| Avg | .1176 | .1360 | .1167 | .1185 | .1172 | .1214 | .1245 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 204 / 11 KV NERUL GYMKHANA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | | | .0747 | | | |
| 2 | .0686 | | | | .12 | | |
| 3 | | | | .0747 | | | |
| 4 | .0686 | | | | .1029 | | |
| 5 | | | | .0747 | | | |
| 6 | .0686 | .0739 | | | .0686 | | .0934 |
| 8 | .0686 | .0739 | | .0747 | .0686 | | .0934 |
| 9 | .0686 | | | .0747 | .0686 | | |
| 10 | .0924 | | .0747 | .0686 | | .0934 | |
| 11 | | | .0934 | .0686 | | | .0747 |
| 12 | .0739 | | .0934 | .0686 | | .0747 | .0934 |
| 13 | | | | .0686 | | | .0747 |
| 14 | .0739 | .056 | .0747 | .0686 | | .056 | .0747 |
| 15 | | | | .0514 | | | .0747 |
| 16 | .0739 | | .0747 | .0686 | | .0747 | |
| 17 | | | | .0514 | | | .056 |
| 18 | .0739 | | .0747 | .0686 | | .0747 | .0934 |
| 19 | | | .112 | .0686 | | | .0934 |
| 20 | .1109 | | .112 | .0686 | | .0934 | .0934 |
| 21 | | | | .0686 | | | .112 |
| 22 | .0924 | | .0747 | .0686 | | .0747 | .0747 |
| 23 | | | | | | | .0747 |
| 24 | .0739 | | .056 | .0747 | .12 | .0554 | |
| Max | .1109 | .0739 | .112 | .0747 | .12 | .0934 | .112 |
| Min | .0686 | .056 | .056 | .0514 | .0686 | .0554 | .056 |
| Avg | .0769 | .0679 | .0840 | .0687 | .0915 | .0746 | .0840 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 205 / 11 KV SEC 14 S/S NERUL SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

| DATE | 15-JAN-17 | 18-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 9 | .0171 | |
| 24 | | .0171 |
| Max | .0171 | .0171 |
| Min | .0171 | .0171 |
| Avg | .0171 | .0171 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 206 / 11 KV SEC-50 NRI SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 18-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 9 | .0171 | |
| 10 | | .0171 |
| 24 | | .0171 |
| Max | .0171 | .0171 |
| Min | .0171 | .0171 |
| Avg | .0171 | .0171 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 208 / 11 KV HAWARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2058 | | | .2241 | | | |
| 2 | .1715 | | | | .2229 | | |
| 3 | | | | .2012 | | | |
| 4 | .1886 | | | | .024 | | |
| 5 | | | | .2614 | | | |
| 6 | .2572 | .3439 | | | .2743 | | .2561 |
| 8 | .2915 | .4163 | | .4207 | .4115 | | .4572 |
| 9 | .4115 | | | .439 | .3944 | | |
| 10 | .4344 | | .3174 | .2401 | | .3292 | |
| 11 | | | .3109 | .1886 | | | .3109 |
| 12 | .3258 | | .2378 | .1886 | | .2378 | .3174 |
| 13 | | | | .2058 | | | .2743 |
| 14 | .2353 | .2054 | .1829 | .1886 | | .1829 | .2427 |
| 15 | | | | .1715 | | | .2195 |
| 16 | .1991 | | .1646 | .1715 | | .1829 | |
| 17 | | | .1829 | .1543 | | | .2012 |
| 18 | .2353 | | .2378 | .1886 | | .2561 | .2195 |
| 19 | | | .2926 | .2743 | | | .2926 |
| 20 | .2896 | | .3292 | .2743 | | .2926 | .2926 |
| 21 | | | .3109 | .3258 | | | .3174 |
| 22 | .2896 | | .2987 | .2915 | | .2926 | .2926 |
| 23 | | | | | | | .2743 |
| 24 | .2715 | | .2054 | .2195 | .2058 | .2033 | |
| Max | .4344 | .4163 | .3292 | .439 | .4115 | .3292 | .4572 |
| Min | .1715 | .2054 | .1646 | .1543 | .024 | .1829 | .2012 |
| Avg | .2719 | .3219 | .2559 | .2437 | .2555 | .2472 | .2835 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 201 / 11 KV RAGHULEELA NEW

SHEDDABLE URBAN

FEEDER Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .2801 | | | | |
| 3 | | | | .2801 | .3174 | .3734 | .2801 |
| 4 | | | .2641 | | | | |
| 5 | | | | | .2801 | | |
| 6 | | | .2427 | .3734 | | .2614 | .2427 |
| 7 | | | | | .2427 | | |
| 8 | .2427 | | | .5041 | .2241 | .2427 | .2614 |
| 9 | .3547 | | .3361 | .6722 | .3734 | .3734 | .4108 |
| 10 | 1.0082 | | .3921 | .7095 | .3921 | .3921 | .5093 |
| 11 | 1.3443 | 1.363 | 1.475 | 1.5497 | 1.1576 | 1.1949 | 1.773 |
| 12 | 1.4937 | 1.7177 | 1.7551 | 1.7177 | 1.7924 | 1.7177 | 1.8296 |
| 13 | | 1.7177 | 1.7737 | 1.8671 | 1.8111 | 1.7924 | 1.7918 |
| 14 | 2.0725 | 1.7364 | 1.7924 | 1.9044 | 1.7737 | 1.8111 | |
| 15 | 2.0351 | 1.7551 | 1.6804 | 1.6991 | 1.6617 | 1.7737 | |
| 16 | | 1.7924 | 1.6057 | | 1.5684 | 1.5497 | 1.9616 |
| 17 | | 1.8111 | 1.4377 | 1.6804 | 1.4377 | 1.475 | 1.9993 |
| 18 | | 1.7551 | 1.4377 | 1.8671 | 1.6244 | | 1.9805 |
| 19 | | 1.8298 | | 1.8671 | 1.7924 | 1.8298 | |
| 20 | | | 1.5089 | 2.0911 | 2.0538 | 1.9605 | |
| 21 | | 1.6804 | 1.4937 | 1.531 | 1.475 | | |
| 22 | | | .5601 | .9335 | .9335 | .8962 | |
| 23 | | .3734 | .4854 | .6722 | .7095 | | |
| 24 | | | .2801 | .3174 | .3734 | 1.587 | 1.9616 |
| Max | 2.0725 | 1.8298 | 1.7924 | 2.0911 | 2.0538 | 1.9605 | 1.9993 |
| Min | .2427 | .3734 | .2427 | .2801 | .2241 | .2427 | .2427 |
| Avg | 1.2216 | 1.5938 | 1.0445 | 1.2354 | 1.0997 | 1.2019 | 1.2501 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 203 / 11 KV VASHI RLY 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .1307 | | | | |
| 3 | | | | | .112 | .1307 | |
| 4 | | | .1132 | | | | |
| 5 | | | | | .112 | | |
| 6 | | | .132 | .1307 | | .1307 | .112 |
| 7 | | | | | .1307 | | |
| 8 | .0934 | | | .112 | .112 | .1307 | .1307 |
| 9 | .112 | | .2427 | .2427 | .2054 | .1867 | .1494 |
| 10 | .112 | | .2427 | .2427 | .2241 | .2801 | .1132 |
| 11 | .1307 | .2614 | .2427 | .2614 | .2427 | .2427 | .1509 |
| 12 | .1494 | .2614 | .2241 | .2614 | .2427 | .2241 | .1132 |
| 13 | | .2427 | .2241 | | .2614 | .2427 | .1698 |
| 14 | .1307 | .2054 | .2427 | .2241 | .2427 | .2427 | |
| 15 | .112 | .2427 | .2614 | .2241 | .2427 | .2427 | |
| 16 | | .2427 | .2427 | | .2801 | .2801 | |
| 17 | | | .2614 | .2427 | .2241 | .2614 | .132 |
| 18 | | .2427 | .2427 | .2427 | .2614 | .2801 | .1132 |
| 19 | | .2801 | .2614 | .2614 | .2054 | .2614 | |
| 20 | | | .1867 | .2241 | .1867 | 2.3712 | |
| 21 | | .1867 | .1867 | .2054 | .1867 | | |
| 22 | | | .1494 | .168 | | | |
| 23 | | .1494 | .1494 | .168 | .1494 | | |
| 24 | | | .1867 | .1307 | .1307 | .1494 | .1698 |
| Max | .1494 | .2801 | .2614 | .2614 | .2801 | 2.3712 | .1698 |
| Min | .0934 | .1494 | .1132 | .112 | .112 | .1307 | .112 |
| Avg | .1200 | .2315 | .2065 | .2089 | .1975 | .3536 | .1354 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 204 / 11 KV MICROTECH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .3361 | | | | |
| 3 | | | | | .3361 | .3174 | .3547 |
| 4 | | | .3018 | | | | |
| 5 | | | | | .2987 | | |
| 6 | | | .2641 | .2614 | | .2801 | .2987 |
| 7 | | | | | .3174 | | |
| 8 | .2427 | | | .3734 | .3361 | .3547 | .2614 |
| 9 | .2241 | | .4481 | .4668 | .5041 | .5041 | .2801 |
| 10 | .2987 | | .6413 | .6413 | .6535 | .6535 | .3961 |
| 11 | .3174 | .8402 | .7922 | .8488 | .7842 | .7842 | .5281 |
| 12 | .4481 | .9149 | .8676 | .8488 | .9522 | .9896 | .6036 |
| 13 | | 1.0082 | .9431 | | .8962 | .9522 | .6036 |
| 14 | .5415 | 1.0082 | 1.0374 | .811 | .9335 | .9149 | |
| 15 | .5415 | 1.0456 | 1.0562 | .9431 | .9522 | .9896 | .6224 |
| 16 | | .9149 | .9054 | | .9335 | .8402 | |
| 17 | | | .811 | .7733 | .8775 | .8775 | .4715 |
| 18 | | | .7356 | .7842 | .7468 | .8029 | .415 |
| 19 | | .8215 | .7655 | .7468 | .8215 | .7842 | |
| 20 | | | .7468 | .7095 | .6722 | .7468 | |
| 21 | | .6722 | .6348 | .6535 | .6722 | | |
| 22 | | | .5975 | .5601 | | .6348 | |
| 23 | | .4668 | .4481 | .4854 | .5041 | | |
| 24 | | | .3734 | .3258 | .3921 | .3734 | .4108 |
| Max | .5415 | 1.0456 | 1.0562 | .9431 | .9522 | .9896 | .6224 |
| Min | .2241 | .4668 | .2641 | .2614 | .2987 | .2801 | .2614 |
| Avg | .3734 | .8547 | .6687 | .6396 | .6623 | .6941 | .4372 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 205 / 11 kV SUBSTATION

SHEDDABLE URBAN

TRANSFORMER Feeder KV- 11 /
OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .0377 | | | | |
| 3 | | | | | .056 | | .056 |
| 4 | | | .0377 | | | | |
| 6 | | | .0566 | .056 | | | |
| 7 | | | | | .056 | | |
| 8 | .0566 | | | .056 | | .056 | |
| 9 | .0566 | | .056 | .056 | .056 | .056 | .056 |
| 10 | .0572 | | .0566 | .0754 | .0566 | .0754 | .0754 |
| 11 | .0572 | | .0754 | .0566 | .0566 | .0754 | .0754 |
| 12 | .0572 | .0566 | .0566 | .0754 | .0566 | .0566 | .0754 |
| 13 | | | .0566 | | .0566 | .0566 | .0754 |
| 14 | | | .0566 | .0754 | .0566 | .0754 | |
| 15 | | | .0754 | .0566 | .0566 | .0754 | .0754 |
| 16 | | | .0566 | | .0754 | .0754 | |
| 17 | | | .0754 | .0566 | .0566 | .0754 | .0566 |
| 18 | | .056 | .0754 | .0747 | .0566 | .056 | .0566 |
| 19 | | .056 | .056 | .056 | .056 | .056 | |
| 20 | | | .056 | .056 | | .056 | |
| 21 | | .056 | .056 | .056 | .056 | | |
| 22 | | | .056 | .056 | | | |
| 23 | | .056 | .056 | | | | |
| 24 | | | .056 | .056 | .056 | .056 | .0566 |
| Max | .0572 | .0566 | .0754 | .0754 | .0754 | .0754 | .0754 |
| Min | .0566 | .056 | .0377 | .056 | .056 | .056 | .056 |
| Avg | .0570 | .0561 | .0583 | .0612 | .0576 | .0644 | .0659 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 206 / 11 KV MAITHILLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | 1.4003 | | | | |
| 3 | | | | 1.4377 | 1.4563 | 1.419 | 1.4003 |
| 4 | | | 1.4146 | | | | |
| 5 | | | | | 1.419 | | |
| 6 | | | 1.4335 | 1.419 | | 1.4003 | 1.419 |
| 7 | | | | | 1.419 | | |
| 8 | 1.4377 | | | 1.419 | 1.4377 | 1.4003 | 1.4377 |
| 9 | 1.4377 | | 1.6804 | | 1.6804 | 1.7737 | 1.4563 |
| 10 | | | 1.8861 | 1.8484 | 1.9239 | 1.8484 | 1.8111 |
| 11 | | | 1.9427 | 1.9418 | 1.9993 | 1.9616 | 1.9418 |
| 12 | | 2.0725 | 2.037 | 1.9418 | 1.9993 | 2.037 | 1.9605 |
| 13 | | 2.1285 | | | 2.0182 | 2.0182 | 1.7364 |
| 14 | | 2.1285 | 2.0559 | 2.0165 | 2.0748 | 2.1313 | |
| 15 | | 2.0911 | 2.0748 | 2.0538 | 2.0936 | 2.1502 | 1.9231 |
| 16 | | 2.0911 | 2.1313 | | 2.1125 | 2.1313 | |
| 17 | | | 2.1691 | 2.1285 | 2.1313 | 2.1691 | 1.8484 |
| 18 | | 2.0538 | 1.9616 | 1.9791 | 2.0559 | 1.9231 | 1.7551 |
| 19 | | 1.7737 | 1.7924 | 1.7737 | 1.8111 | 1.8484 | |
| 20 | | | 1.643 | 1.6804 | 1.6617 | 1.6804 | |
| 21 | | 1.7924 | 1.6057 | 1.6057 | 1.6057 | | |
| 22 | | | 1.531 | 1.531 | 1.5123 | 1.531 | |
| 23 | | 1.4937 | 1.5123 | 1.4937 | 1.4937 | | |
| 24 | | | 1.5123 | 1.4937 | 1.475 | 1.475 | 1.419 |
| Max | 1.4377 | 2.1285 | 2.1691 | 2.1285 | 2.1313 | 2.1691 | 1.9605 |
| Min | 1.4377 | 1.4937 | 1.4003 | 1.419 | 1.419 | 1.4003 | 1.4003 |
| Avg | 1.4377 | 1.9584 | 1.7658 | 1.7352 | 1.7690 | 1.8175 | 1.6757 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 207 / 11 KV FISH MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .4668 | | | | |
| 3 | | | | .5228 | .4481 | .4481 | .4481 |
| 4 | | | .5281 | | | | |
| 5 | | | | | .5041 | | |
| 6 | | | .6036 | .6348 | | .5415 | .5041 |
| 7 | | | | | .5975 | | |
| 8 | .5975 | | | .6348 | .6908 | .7095 | .6161 |
| 9 | .6535 | | .6161 | .5975 | .6348 | .6908 | .7095 |
| 10 | | | .5093 | .4854 | .5415 | .5658 | .5788 |
| 11 | | .5228 | .4527 | .5415 | .4854 | .4527 | .5601 |
| 12 | | .4668 | .4527 | .4481 | .3921 | .4904 | .4668 |
| 13 | | .4481 | | | .3734 | .4715 | .5041 |
| 14 | | .4108 | .3772 | .3921 | .4108 | .4338 | |
| 15 | | .3734 | .3961 | .3547 | .4108 | .4338 | .3734 |
| 16 | | .3921 | .3772 | | .4108 | .4527 | |
| 17 | | | .415 | .3921 | .4481 | .415 | .4294 |
| 18 | | .5601 | .547 | .5415 | .5601 | .5601 | .5228 |
| 19 | | .7095 | .6535 | .6722 | .7095 | .6535 | |
| 20 | | | .6344 | .7282 | .7468 | .7468 | |
| 21 | | .6908 | .7095 | .6722 | .7095 | | |
| 22 | | | .6535 | | .6722 | .6348 | |
| 23 | | .5788 | .5601 | .5788 | .5788 | | |
| 24 | | | .6535 | .4668 | .4854 | | .4854 |
| Max | .6535 | .7095 | .7095 | .7282 | .7468 | .7468 | .7095 |
| Min | .5975 | .3734 | .3772 | .3547 | .3734 | .415 | .3734 |
| Avg | .6255 | .5153 | .5337 | .5415 | .5405 | .5438 | .5166 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 208 / 11 KV ORISSA BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .1307 | | | | |
| 3 | | | | .112 | .1307 | .1307 | .112 |
| 4 | | | .132 | | | | |
| 5 | | | | | .1307 | | |
| 6 | | | .1509 | .1307 | | .1494 | .1307 |
| 7 | | | | | .1494 | | |
| 8 | .112 | | | .1494 | .1494 | .168 | .1307 |
| 9 | .1307 | | .2241 | | .2241 | .2241 | .168 |
| 10 | | | .415 | .3547 | .415 | .3395 | .2801 |
| 11 | | .4854 | .3584 | .4668 | .4904 | .3961 | .2987 |
| 12 | | .4108 | .3772 | .4108 | .4715 | .4338 | .2987 |
| 13 | | .4294 | | | .415 | .3961 | .3734 |
| 14 | | .4108 | .4338 | .4481 | .415 | .4527 | |
| 15 | | .4668 | .4338 | .4854 | .5093 | .4904 | .2801 |
| 16 | | .5228 | .4527 | | .4527 | .4527 | |
| 17 | | | .4338 | .0934 | .415 | .4715 | .2801 |
| 18 | | .4668 | .4338 | .2801 | .4527 | .4481 | .2427 |
| 19 | | .4294 | .3547 | .3361 | .3734 | .4481 | |
| 20 | | | .2241 | .2614 | .2801 | .2801 | |
| 21 | | .2054 | .1867 | .1867 | .1867 | | |
| 22 | | | .2241 | .2054 | .1867 | .2054 | |
| 23 | | .1867 | .168 | .0747 | | | |
| 24 | | | .1867 | .1494 | .168 | .168 | .1307 |
| Max | .1307 | .5228 | .4527 | .4854 | .5093 | .4904 | .3734 |
| Min | .112 | .1867 | .1307 | .0747 | .1307 | .1307 | .112 |
| Avg | .1214 | .4014 | .2956 | .2591 | .3166 | .3326 | .2272 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/sFeeder No / Name : 209 / 11 KV CIDCO BUSINESS
CENTER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2 | | | .0377 | | | | |
| 3 | | | | .0381 | .056 | .056 | .0373 |
| 4 | | | .0377 | .0023 | | | |
| 5 | | | | | .056 | | |
| 6 | | | .0377 | .056 | | .056 | .056 |
| 7 | | | | | .112 | | |
| 8 | .056 | | | .2987 | .2801 | .2987 | .2241 |
| 9 | .2614 | | .0566 | .2705 | .6272 | .2614 | .2987 |
| 10 | | | .0373 | .5155 | .6211 | .2452 | .2829 |
| 11 | | .0373 | .0373 | .5216 | .5693 | .2641 | .2452 |
| 12 | | .0373 | .0373 | .4984 | .5632 | .2641 | .2452 |
| 13 | | .0373 | | .2606 | .5556 | .2641 | .3206 |
| 14 | | .0373 | .0373 | .5746 | .5674 | .2641 | |
| 15 | | .0373 | .056 | .6134 | .5563 | .2829 | .3206 |
| 16 | | .0373 | .0373 | .3224 | .5403 | .2829 | |
| 17 | | | .056 | .6127 | .5929 | .2641 | .3206 |
| 18 | | .112 | .056 | .618 | .2987 | .2987 | .3395 |
| 19 | | .112 | .0747 | .6017 | .2801 | .2241 | |
| 20 | | | .0747 | .5792 | .1494 | .2241 | |
| 21 | | .1307 | .0747 | .3704 | .112 | | |
| 22 | | | .0747 | .1357 | .112 | .112 | |
| 23 | | .0747 | .0747 | .1014 | .112 | | |
| 24 | | | .056 | .2644 | .056 | .0747 | .0747 |
| Max | .2614 | .1307 | .0747 | .618 | .6272 | .2987 | .3395 |
| Min | .056 | .0373 | .0373 | .0023 | .056 | .056 | .0373 |
| Avg | .1587 | .0653 | .0530 | .3628 | .3409 | .2198 | .2305 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 201 / 11 KV RELIANCE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | .298 | | | | | | |
| 7 | | | .4801 | | | .583 | |
| 8 | .3582 | | .5144 | | | .5144 | .394 |
| 9 | .4755 | | .5658 | | | | |
| 10 | | | | | | .6767 | .7023 |
| 11 | | | .7392 | .8131 | .7202 | | .788 |
| 12 | | .7888 | | | .4572 | .6154 | .7133 |
| 13 | .5601 | .7888 | | .7392 | .7202 | .6878 | .7716 |
| 14 | | | .6722 | | .6516 | | .7545 |
| 15 | .5228 | .6173 | | .7762 | | .6447 | |
| 16 | | .6859 | .7095 | | .6516 | | |
| 17 | | .6516 | | .6722 | .7202 | | |
| 18 | | | .7762 | | .6516 | .6556 | .6859 |
| 19 | | | | | .6859 | .6626 | .6859 |
| 20 | .6348 | .6859 | | | | | .6173 |
| 21 | | | | | .583 | .5316 | |
| 22 | .5228 | .6001 | | | | | |
| 23 | .4481 | .4458 | | | .3772 | | |
| 24 | .3856 | | .4115 | .4108 | .4108 | .3429 | .3856 |
| Max | .6348 | .7888 | .7762 | .8131 | .7202 | .6878 | .788 |
| Min | .298 | .4458 | .4115 | .4108 | .3772 | .3429 | .3856 |
| Avg | .4673 | .6580 | .6086 | .6823 | .6027 | .5915 | .6498 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 202 / 11 KV SAI PRIDE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | .6661 | | | | | | |
| 7 | | | .7926 | | | .9145 | |
| 8 | .6001 | | .9145 | | | .9297 | .7049 |
| 9 | .9175 | | .7621 | | | | |
| 10 | | | | | | .8259 | .9175 |
| 11 | | | .9145 | .8779 | .823 | | .9667 |
| 12 | | | | | .6706 | .8097 | .664 |
| 13 | 1.0242 | .6706 | | .7392 | .6401 | .7449 | .7164 |
| 14 | | | .7023 | | .6401 | | .7373 |
| 15 | .8501 | .5792 | | .7023 | | .6062 | |
| 16 | | | .7392 | | | | |
| 17 | | .6097 | | .8131 | .7011 | | |
| 18 | | | .9877 | | .823 | .8145 | .8535 |
| 19 | | | | | .823 | .7282 | .8535 |
| 20 | 1.0608 | .8383 | | | | | .8535 |
| 21 | | | | | .8535 | .8025 | |
| 22 | 1.0974 | .8535 | | | | | |
| 23 | .9511 | .884 | | | .7316 | | |
| 24 | .6398 | .8383 | .6706 | .8131 | .7392 | .6706 | .6259 |
| Max | 1.0974 | .884 | .9877 | .8779 | .8535 | .9297 | .9667 |
| Min | .6001 | .5792 | .6706 | .7023 | .6401 | .6062 | .6259 |
| Avg | .8675 | .7534 | .8104 | .7891 | .7445 | .7847 | .7893 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 203 / 11 KV SEWERAGE TREATMENT

SHEDDABLE URBAN

PLANT Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | .2641 | | | | | | |
| 7 | | | .4115 | | | .3772 | |
| 8 | .3511 | | .6344 | | | .5316 | .5914 |
| 9 | .5544 | | .8573 | | | | |
| 10 | | | | | | | .7762 |
| 11 | | | .8501 | .6722 | .823 | | .7655 |
| 12 | | | | | 1.0631 | .8686 | .6838 |
| 13 | .6348 | .8916 | | .8131 | 1.0974 | .7922 | .703 |
| 14 | | | 1.0242 | | .9259 | | .4973 |
| 15 | .5601 | .7202 | | .9145 | | .7545 | |
| 16 | | | 1.0242 | | | | |
| 17 | | .823 | | | .8573 | | |
| 18 | | | .7392 | | .6859 | .5847 | .5487 |
| 19 | | | | | .5487 | .4904 | .4458 |
| 20 | .3772 | .4287 | | | | | .4801 |
| 21 | | | | | .3429 | .2829 | |
| 22 | .3361 | .3601 | | | | | |
| 23 | .3772 | .3429 | | | .2401 | | |
| 24 | .3395 | | .3086 | .3018 | .3395 | .9979 | .415 |
| Max | .6348 | .8916 | 1.0242 | .9145 | 1.0974 | .9979 | .7762 |
| Min | .2641 | .3429 | .3086 | .3018 | .2401 | .2829 | .415 |
| Avg | .4216 | .5944 | .7312 | .6754 | .6924 | .6311 | .5907 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 204 / 11 KV PAN INDIA VASHI
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | .3563 | | | | | | |
| 7 | | | .3772 | | | .4458 | |
| 8 | .2572 | | .4287 | | | .4287 | .2787 |
| 9 | .4108 | | .5144 | | | | |
| 10 | | | | | | .5601 | .4973 |
| 11 | | | .8131 | .7095 | .7888 | | .4694 |
| 12 | | | | | .7545 | .6464 | .57 |
| 13 | .4527 | .7202 | | .7316 | | .6588 | .6344 |
| 14 | | | .7762 | | .7202 | | .6173 |
| 15 | .4481 | .7888 | | .7682 | | .7888 | |
| 16 | | | .8501 | | | | |
| 17 | | .7888 | | .8131 | .7545 | | |
| 18 | | | .7095 | | .7202 | .6081 | .5144 |
| 19 | | | | | .6516 | .5441 | .4801 |
| 20 | .4108 | .5316 | | | | | .4458 |
| 21 | | | | | .5487 | .4904 | |
| 22 | .4108 | .463 | | | | | |
| 23 | .415 | .4115 | | | .2972 | | |
| 24 | .2961 | | .4458 | .4481 | .7545 | .4458 | .3102 |
| Max | .4527 | .7888 | .8501 | .8131 | .7888 | .7888 | .6344 |
| Min | .2572 | .4115 | .3772 | .4481 | .2972 | .4287 | .2787 |
| Avg | .3842 | .6173 | .6144 | .6941 | .6656 | .5617 | .4818 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 205 / 11 KV KESHAV KUNJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | .6706 | | | | | | |
| 7 | | | .8916 | | | .9602 | |
| 8 | .7253 | | .7716 | | | .9431 | .7011 |
| 9 | .8573 | | .9945 | | | | |
| 10 | | | | | | .9259 | .9602 |
| 11 | | | 1.0974 | 1.0242 | .9945 | | 1.0749 |
| 12 | | | | | .9259 | .9602 | 1.0056 |
| 13 | .9511 | .9945 | | .9511 | | .9496 | 1.046 |
| 14 | | | .9145 | | .9259 | | 1.0288 |
| 15 | .9511 | .8573 | | .8779 | | .78 | |
| 16 | | | .9145 | | | | |
| 17 | | .8573 | | .8779 | .8916 | | |
| 18 | | | .9511 | | .8916 | .8785 | .8916 |
| 19 | | | | | .9602 | .9326 | .9259 |
| 20 | .9511 | .8573 | | | | | .9259 |
| 21 | | | | | .9602 | .9556 | |
| 22 | .9511 | .9431 | | | | | |
| 23 | .8413 | .823 | | | .823 | | |
| 24 | .6706 | | .7545 | .7682 | .9259 | .7202 | .7011 |
| Max | .9511 | .9945 | 1.0974 | 1.0242 | .9945 | .9602 | 1.0749 |
| Min | .6706 | .823 | .7545 | .7682 | .823 | .7202 | .7011 |
| Avg | .8411 | .8888 | .9112 | .8999 | .9221 | .9006 | .9261 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada

s/stn

Feeder No / Name : 206 / 11 KV LADIES HOSTELL,SEC

SHEDDABLE URBAN

10,SA Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7 | | | .6173 | | | .7545 | |
| 8 | .7922 | | .8573 | | | .8573 | .8215 |
| 9 | .6413 | | .6516 | | | | |
| 10 | | | | | | .6602 | .5975 |
| 11 | | | .5601 | .5601 | .5144 | | .7468 |
| 12 | | | | | .583 | .5041 | .6348 |
| 13 | .5975 | .4458 | | .4108 | | .4904 | .4973 |
| 14 | | | .5228 | | .5144 | | .4458 |
| 15 | .4481 | .4801 | | .4108 | | .5658 | |
| 16 | | | .4481 | | | | |
| 17 | | .4801 | | .5228 | .4458 | | |
| 18 | | | .7762 | | .6859 | .5975 | .6859 |
| 19 | | | | | .7545 | .7842 | .7545 |
| 20 | .8131 | .7888 | | | | | .7888 |
| 21 | | | | | .7888 | .7842 | |
| 22 | .5975 | .7373 | | | | | |
| 23 | .5601 | .5487 | | | | | |
| 24 | .462 | | .4458 | .4854 | .6173 | .4801 | .5041 |
| Max | .8131 | .7888 | .8573 | .5601 | .7888 | .8573 | .8215 |
| Min | .4481 | .4458 | .4458 | .4108 | .4458 | .4801 | .4458 |
| Avg | .6140 | .5801 | .6099 | .4780 | .6130 | .6478 | .6477 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 207 / Sector 11 sanpada Bhoomi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | .2778 | | | | | | |
| 7 | | | .4458 | | | .4115 | |
| 8 | .3429 | | .4458 | | | .4458 | .4024 |
| 9 | .4938 | | .4801 | | | | |
| 10 | | | | | | .6154 | .5487 |
| 11 | | | .6348 | .6722 | .6173 | | .7023 |
| 12 | | | | | .5487 | .5304 | .5853 |
| 13 | .4854 | .5487 | | .5601 | | .4344 | .6001 |
| 14 | | | .5228 | | .5487 | | .5658 |
| 15 | .415 | .5487 | | .4854 | | .5373 | |
| 16 | | | .5228 | | | | |
| 17 | | .4801 | | .5601 | .5144 | | |
| 18 | | | .5601 | | .5144 | .4119 | .4458 |
| 19 | | | | | .5144 | .5068 | .4801 |
| 20 | .4108 | .5144 | | | | | .4801 |
| 21 | | | | | .4458 | .3898 | |
| 22 | .4481 | .4287 | | | | | |
| 23 | .4108 | .4115 | | | | | |
| 24 | .3018 | | .3772 | .415 | .3772 | .3772 | .3647 |
| Max | .4938 | .5487 | .6348 | .6722 | .6173 | .6154 | .7023 |
| Min | .2778 | .4115 | .3772 | .415 | .3772 | .3772 | .3647 |
| Avg | .3985 | .4887 | .4987 | .5386 | .5101 | .4661 | .5175 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 209 / Cidco Exhibition

Centre, Vashi Feeder KV- 11 /
OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | .112 | | | | | | |
| 7 | | | .1372 | | | .2915 | |
| 8 | .0934 | | .1372 | | | .823 | .3361 |
| 9 | .0934 | | .1372 | | | | |
| 10 | | | | | | .8865 | .8589 |
| 11 | | | .0943 | .9145 | .7716 | | .9522 |
| 12 | | | | | .823 | .9522 | .9709 |
| 13 | .1132 | .0514 | | .9511 | | .8962 | .8745 |
| 14 | | | .0943 | | .7888 | | .8745 |
| 15 | .0566 | .0514 | | .9511 | | .8775 | |
| 16 | | | .0754 | | | | |
| 17 | | .1372 | | .7577 | | | |
| 18 | | | .1132 | | .8402 | 1.0374 | .4287 |
| 19 | | | | | .8573 | 1.0269 | .5316 |
| 20 | .132 | .1372 | | | | | .4973 |
| 21 | | | | | .3429 | .6535 | |
| 22 | .1132 | .1372 | | | | | |
| 23 | .1132 | .1372 | | | | | |
| 24 | .132 | | .1372 | .2641 | .3258 | .3258 | .3361 |
| Max | .132 | .1372 | .1372 | .9511 | .8573 | 1.0374 | .9709 |
| Min | .0566 | .0514 | .0754 | .2641 | .3258 | .2915 | .3361 |
| Avg | .1066 | .1086 | .1158 | .7677 | .6785 | .7771 | .6661 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 302 / 22KV TURBHE NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 22 / OUTGOING UTILITY

| DATE | 18-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | .7926 |
| 2 | .7621 |
| 3 | .7621 |
| 4 | .7926 |
| 5 | .7926 |
| 6 | .7621 |
| 7 | 1.0059 |
| 8 | 1.0364 |
| 9 | 1.0669 |
| 10 | .823 |
| 11 | .7011 |
| 12 | .5792 |
| 13 | .6097 |
| 14 | .6706 |
| 15 | .2439 |
| 16 | .061 |
| 17 | .3048 |
| 18 | .6097 |
| 19 | .7011 |
| 20 | .9145 |
| 21 | 1.0974 |
| 22 | 1.0669 |
| 23 | .945 |
| 24 | .884 |
| Max | 1.0974 |
| Min | .061 |
| Avg | .7494 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 303 / 22 KV NERUL I

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 18-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 3.5361 |
| 2 | 3.4751 |
| 3 | 3.4141 |
| 4 | 3.1703 |
| 5 | 3.2007 |
| 6 | 3.0483 |
| 7 | 3.1703 |
| 8 | 2.8045 |
| 9 | 2.8045 |
| 10 | 3.2922 |
| 11 | 3.9018 |
| 12 | 4.6944 |
| 13 | 4.9383 |
| 14 | 4.6944 |
| 15 | 4.5725 |
| 16 | 4.7554 |
| 17 | 4.6639 |
| 18 | 4.603 |
| 19 | 4.0847 |
| 20 | 3.5665 |
| 21 | 2.8959 |
| 22 | 2.9569 |
| 23 | 2.652 |
| 24 | 2.8349 |
| Max | 4.9383 |
| Min | 2.652 |
| Avg | 3.6554 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 308 / 22 KV L P NAKA

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 20-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 5.365 |
| 2 | 5.3041 |
| 3 | 5.1821 |
| 4 | 5.0602 |
| 5 | 4.9992 |
| 6 | 5.1212 |
| 7 | 5.2431 |
| 8 | 5.2431 |
| 9 | 5.487 |
| 10 | 5.9137 |
| 11 | 6.3405 |
| 12 | 6.4624 |
| 13 | 6.7673 |
| 14 | 6.7673 |
| 15 | 6.9502 |
| 16 | 7.194 |
| 17 | 7.1331 |
| 18 | 6.5844 |
| 19 | 6.2186 |
| 20 | 5.8528 |
| 21 | 5.6089 |
| 22 | 5.6089 |
| 23 | 5.487 |
| 24 | 5.6699 |
| Max | 7.194 |
| Min | 4.9992 |
| Avg | 5.8985 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288057 / 220/33/22KV NERUL S/Stn

Feeder No / Name : 309 / 22 KV SHIRAWANE

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7316 | .7316 |
| 2 | .7011 | .7011 |
| 3 | .6706 | .6706 |
| 4 | .6706 | .6706 |
| 5 | .6706 | .6706 |
| 6 | .6706 | .6706 |
| 7 | .7011 | .7316 |
| 8 | .823 | .7926 |
| 9 | 1.3717 | 1.4022 |
| 10 | 1.5851 | 1.6461 |
| 11 | 1.5242 | 1.6766 |
| 12 | 1.5546 | 1.7071 |
| 13 | 1.5851 | 1.7375 |
| 14 | 1.5546 | 1.7985 |
| 15 | 1.5851 | 1.5546 |
| 16 | 1.5851 | 1.5242 |
| 17 | 1.4022 | 1.3717 |
| 18 | 1.0364 | |
| 19 | .945 | .9145 |
| 20 | .9755 | .945 |
| 21 | .884 | .8535 |
| 22 | .8535 | |
| 23 | .823 | |
| 24 | .7926 | |
| Max | 1.5851 | 1.7985 |
| Min | .6706 | .6706 |
| Avg | 1.0707 | 1.1385 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 401 / 33 KV IC-1 SEC 6 SANPADA NON SHEDDABLE EXPRESS HV FEEDERS
 SS Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 17-JAN-17 | 18-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 9.465 | 9.1907 |
| 2 | 8.5734 | 8.2991 |
| 3 | 8.1619 | 7.9561 |
| 4 | 8.1619 | 7.8189 |
| 5 | 8.2991 | 8.1619 |
| 6 | 9.3279 | 9.1907 |
| 7 | 11.7284 | 11.4541 |
| 8 | 13.9232 | 13.8546 |
| 9 | 14.6777 | 14.5405 |
| 10 | 13.8546 | 13.5803 |
| 11 | 11.2483 | 11.5226 |
| 12 | 10.0823 | 9.7394 |
| 13 | 9.1221 | 8.9849 |
| 14 | 8.4362 | 8.2991 |
| 15 | 7.8189 | 7.8875 |
| 16 | 7.476 | 7.5446 |
| 17 | 7.5446 | 7.5446 |
| 18 | 8.2991 | 8.2991 |
| 19 | 11.5912 | |
| 20 | 13.1687 | |
| 21 | 13.9918 | |
| 22 | 13.6489 | |
| 23 | 12.6886 | |
| 24 | 10.974 | |
| Max | 14.6777 | 14.5405 |
| Min | 7.476 | 7.5446 |
| Avg | 10.5110 | 9.6594 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 402 / 33KV INCOMER to NRI SS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 17-JAN-17 | 18-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 13.8546 | 15.5007 |
| 2 | 12.5515 | 13.786 |
| 3 | 11.8656 | 12.8944 |
| 4 | 11.6598 | 12.2771 |
| 5 | 11.4541 | 12.1399 |
| 6 | 13.0316 | 13.9232 |
| 7 | 18.9987 | 20.7819 |
| 8 | 20.9877 | 23.0453 |
| 9 | 21.605 | 24.0741 |
| 10 | 21.6736 | 24.0741 |
| 11 | 20.3018 | 23.4568 |
| 12 | 19.9589 | 22.0851 |
| 13 | 18.5871 | 20.8505 |
| 14 | 17.8327 | 18.7929 |
| 15 | 18.45 | 18.3814 |
| 16 | 14.6091 | 17.0782 |
| 17 | 17.8327 | 17.4211 |
| 18 | 19.9589 | 18.0384 |
| 19 | 22.3594 | |
| 20 | 23.4568 | |
| 21 | 23.1139 | |
| 22 | 23.3196 | |
| 23 | 21.6736 | |
| 24 | 19.6159 | |
| Max | 23.4568 | 24.0741 |
| Min | 11.4541 | 12.1399 |
| Avg | 18.2814 | 18.2556 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 403 / 33 KV IC-1 SEC 30

RAGHULEELA Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 17-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 6.7215 |
| 2 | 6.4472 |
| 3 | 6.31 |
| 4 | 6.2414 |
| 5 | 6.2414 |
| 6 | 6.31 |
| 7 | 6.7901 |
| 8 | 6.9959 |
| 9 | 7.2017 |
| 10 | 8.4362 |
| 11 | 8.7792 |
| 12 | 8.9849 |
| 13 | 9.1221 |
| 14 | 9.1907 |
| 15 | 8.9849 |
| 16 | 9.1221 |
| 17 | 9.2593 |
| 18 | 9.2593 |
| 19 | 9.1907 |
| 20 | 8.9163 |
| 21 | 8.5734 |
| 22 | 7.9561 |
| 23 | 7.4074 |
| 24 | 6.9273 |
| Max | 9.2593 |
| Min | 6.2414 |
| Avg | 7.8904 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 404 / 33 KV IC-1 SEC 20 SANPADA NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 17-JAN-17 | 18-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 6.2414 | 6.0357 |
| 2 | 5.8299 | 5.6927 |
| 3 | 5.5556 | 5.487 |
| 4 | 5.4184 | 5.3498 |
| 5 | 5.4184 | 5.2126 |
| 6 | 5.9671 | 5.5556 |
| 7 | 6.2414 | 6.5158 |
| 8 | 7.8875 | 7.8875 |
| 9 | 8.8477 | 8.5048 |
| 10 | 10.0137 | 9.3964 |
| 11 | 10.631 | 10.0823 |
| 12 | 10.3567 | 10.5624 |
| 13 | 10.1509 | 10.2195 |
| 14 | 10.2195 | 10.1509 |
| 15 | 9.9451 | 10.1509 |
| 16 | 9.8766 | 10.0823 |
| 17 | 9.465 | 10.2195 |
| 18 | 9.2593 | 10.0137 |
| 19 | 9.9451 | |
| 20 | 9.6022 | |
| 21 | 8.2305 | |
| 22 | 7.8875 | |
| 23 | 7.476 | |
| 24 | 6.7215 | |
| Max | 10.631 | 10.5624 |
| Min | 5.4184 | 5.2126 |
| Avg | 8.2162 | 8.1733 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 408 / 33 KV IC-2 SEC 30

RAGHULEELA Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 2.5377 | 2.8121 |
| 2 | 2.1262 | 2.2634 |
| 3 | 1.989 | 2.0576 |
| 4 | 1.989 | 1.989 |
| 5 | 1.9204 | 1.989 |
| 6 | 1.9204 | 1.9204 |
| 7 | 2.1262 | 1.9204 |
| 8 | 2.9492 | 1.9204 |
| 9 | 3.6351 | 2.5377 |
| 10 | 4.321 | 3.4294 |
| 11 | 5.0755 | 4.5953 |
| 12 | 8.7792 | 7.6132 |
| 13 | 9.0535 | 9.1221 |
| 14 | 9.3964 | 9.1221 |
| 15 | 9.1907 | 9.2593 |
| 16 | 8.9849 | 9.0535 |
| 17 | 8.8477 | 8.5734 |
| 18 | 8.4362 | 7.9561 |
| 19 | 8.9849 | 8.2991 |
| 20 | 9.1907 | 8.8477 |
| 21 | 9.2593 | 9.1221 |
| 22 | 7.476 | |
| 23 | 5.7613 | |
| 24 | 4.1838 | |
| Max | 9.3964 | 9.2593 |
| Min | 1.9204 | 1.9204 |
| Avg | 5.7556 | 5.4478 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 415 / 33 KV IC VASHI RLY S/STN

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | 11.2483 | 12.0713 | 11.797 |
| 2 | 10.5624 | 11.0425 | 10.631 |
| 3 | 10.4253 | 10.631 | 10.4253 |
| 4 | 10.2881 | 10.2881 | 10.3567 |
| 5 | 9.6022 | 9.808 | 9.7394 |
| 6 | 9.2593 | 9.3964 | 9.2593 |
| 7 | 10.4938 | 10.6996 | 10.9054 |
| 8 | 11.5226 | 12.1399 | 12.0028 |
| 9 | 12.6886 | 13.5803 | 13.2373 |
| 10 | 15.7065 | 16.2552 | 15.7065 |
| 11 | 18.2442 | 19.4788 | 18.7929 |
| 12 | 18.8615 | 20.3018 | 19.6845 |
| 13 | 18.7243 | 20.2332 | 19.7531 |
| 14 | 18.3128 | 19.8903 | 19.2044 |
| 15 | 19.1358 | 19.4788 | 18.6557 |
| 16 | 20.096 | | 19.4102 |
| 17 | 19.9589 | | 19.4788 |
| 18 | 19.7531 | | 19.2044 |
| 19 | 19.9589 | | 19.8903 |
| 20 | 19.273 | | 18.9301 |
| 21 | 17.0782 | | 16.8039 |
| 22 | 15.7065 | | 15.7065 |
| 23 | 14.129 | | 13.9918 |
| 24 | 13.0316 | | 12.8944 |
| Max | 20.096 | 20.3018 | 19.8903 |
| Min | 9.2593 | 9.3964 | 9.2593 |
| Avg | 15.1692 | 14.3530 | 15.2692 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 416 / 33 KV IC-2 SEC 6 SANPADA NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | 7.476 | 7.4074 | 7.476 |
| 2 | 6.7215 | 6.653 | 6.7215 |
| 3 | 6.5844 | 6.5158 | 6.5844 |
| 4 | 6.7215 | 6.5844 | 6.7215 |
| 5 | 6.7901 | 6.653 | 6.7901 |
| 6 | 7.1331 | 6.9959 | 6.8587 |
| 7 | 8.7106 | 8.3676 | 8.5048 |
| 8 | 9.5336 | 9.3964 | 9.465 |
| 9 | 10.0137 | 9.7394 | 10.0137 |
| 10 | 9.9451 | 9.6708 | 9.8766 |
| 11 | 9.2593 | 8.9849 | 9.3279 |
| 12 | 8.642 | 8.8477 | 8.7106 |
| 13 | 8.642 | 8.2991 | 8.9163 |
| 14 | 8.0933 | 7.6818 | 8.2305 |
| 15 | 7.8189 | 7.8189 | 8.0247 |
| 16 | 7.6818 | 7.9561 | 8.0933 |
| 17 | 7.8875 | 7.9561 | 8.2305 |
| 18 | 8.0247 | 8.9163 | 8.5048 |
| 19 | 11.4541 | 11.1797 | 11.4541 |
| 20 | 11.797 | 11.797 | 12.0713 |
| 21 | 11.3855 | 11.4541 | 11.7284 |
| 22 | 10.9054 | 10.974 | |
| 23 | 9.6708 | 9.808 | |
| 24 | 8.7106 | 8.7792 | |
| Max | 11.797 | 11.797 | 12.0713 |
| Min | 6.5844 | 6.5158 | 6.5844 |
| Avg | 8.7334 | 8.6849 | 8.6812 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 202 / 11 KV B G SHIRKE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.044 | 1.0677 | 1.0189 | 1.0189 | 1.0113 | 1.0258 | 1.0913 |
| 2 | 1.0646 | 1.1203 | 1.0219 | 1.0418 | 1.0486 | 1.0395 | 1.1187 |
| 3 | 1.0905 | 1.1317 | 1.0631 | 1.0761 | 1.0806 | 1.0753 | 1.1652 |
| 4 | 1.1134 | 1.1294 | 1.0738 | 1.0814 | 1.0951 | 1.1096 | 1.1507 |
| 5 | 1.1157 | 1.1302 | 1.0639 | 1.0829 | 1.0951 | 1.0707 | 1.1142 |
| 6 | 1.1546 | 1.2056 | 1.1187 | 1.1248 | 1.2193 | 1.2003 | 1.1789 |
| 7 | 1.1507 | 1.1789 | 1.1309 | 1.1385 | 1.1988 | 1.2209 | 1.1431 |
| 8 | 1.2048 | 1.1309 | 2.0576 | 1.1774 | 1.2132 | 1.2513 | 1.1934 |
| 9 | 1.2262 | 1.1401 | 2.0858 | 1.0517 | 1.1629 | 1.2315 | 1.1561 |
| 10 | 1.1751 | 1.0296 | .9915 | .9534 | 1.041 | 1.1119 | .9899 |
| 11 | 1.0334 | .996 | .9343 | .9496 | .9214 | 1.0174 | .9724 |
| 12 | .9473 | .9076 | .8863 | .8855 | .8878 | .9953 | .9793 |
| 13 | .9861 | 1.0532 | .9869 | .9396 | .8924 | 1.0402 | 1.0433 |
| 14 | .9328 | 1.0128 | .8886 | .8985 | .836 | 1.009 | .929 |
| 15 | .8436 | .7918 | .7834 | .7529 | .7865 | .9617 | .7834 |
| 16 | .8261 | .8032 | .7674 | .7537 | .7674 | .9457 | .7667 |
| 17 | .8901 | .8429 | .852 | .8764 | .8947 | .9907 | .8627 |
| 18 | 1.0273 | .9633 | .9899 | .964 | .9808 | 1.0197 | .9671 |
| 19 | 1.1439 | 1.9052 | 1.1043 | 1.1126 | 1.1164 | 1.0677 | 1.1111 |
| 20 | 1.1378 | 1.1256 | 1.1164 | 1.1759 | 1.1416 | 1.1492 | 1.169 |
| 21 | 1.169 | 2.1132 | 1.1286 | 1.2216 | 1.1866 | 1.1393 | 1.1988 |
| 22 | 1.1797 | 1.1401 | 1.1172 | 1.1744 | 1.15 | 1.1622 | 1.1477 |
| 23 | 1.0959 | 1.7543 | 1.0418 | 1.0966 | 1.0692 | 1.0814 | 1.0715 |
| 24 | 1.012 | .9755 | 1.0357 | 1.0189 | .9846 | 1.0555 | 1.0113 |
| Max | 1.2262 | 2.1132 | 2.0858 | 1.2216 | 1.2193 | 1.2513 | 1.1988 |
| Min | .8261 | .7918 | .7674 | .7529 | .7674 | .9457 | .7667 |
| Avg | 1.0652 | 1.1520 | 1.0941 | 1.0236 | 1.0326 | 1.0822 | 1.0548 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 203 / 11 KV V M JOG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 | 20-JAN-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | 1.2148 | 1.2094 |
| 2 | | | 1.134 | 1.1553 |
| 3 | | | 1.1286 | 1.1302 |
| 4 | | | 1.1081 | 1.1264 |
| 5 | | | 1.1515 | 1.1736 |
| 6 | | | 1.5127 | 1.5303 |
| 7 | | | 1.7711 | 1.7711 |
| 8 | | 1.6126 | 1.9044 | 1.9006 |
| 9 | | 1.5074 | 1.8275 | 1.9006 |
| 10 | | | 1.5539 | 1.6583 |
| 11 | | | 1.2917 | 1.3527 |
| 12 | | | 1.166 | 1.233 |
| 13 | | | 1.0738 | 1.1027 |
| 14 | | | 1.0654 | 1.0844 |
| 15 | | | .9663 | .9869 |
| 16 | | | .9496 | .9282 |
| 17 | | | 1.0555 | .9854 |
| 18 | | | 1.2521 | 1.1553 |
| 19 | 1.5249 | | 1.6354 | 1.5005 |
| 20 | | | 1.7101 | 1.6316 |
| 21 | 1.5249 | | 1.7002 | 1.6392 |
| 22 | | | 1.6148 | 1.5966 |
| 23 | 1.3496 | | 1.5851 | 1.528 |
| 24 | | | 1.406 | |
| Max | 1.5249 | 1.6126 | 1.9044 | 1.9006 |
| Min | 1.3496 | 1.5074 | .9496 | .9282 |
| Avg | 1.4665 | 1.56 | 1.3658 | 1.3600 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 204 / 11 KV Herambha

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 8 | | .8131 |
| 9 | | .7947 |
| 23 | .7577 | |
| 24 | .7762 | |
| Max | .7762 | .8131 |
| Min | .7577 | .7947 |
| Avg | .7670 | .8039 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 205 / 11 KV SEC 14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 8 | | 2.0165 |
| 9 | | 1.8298 |
| 19 | 1.9605 | |
| 21 | 1.9791 | |
| 23 | 1.643 | |
| Max | 1.9791 | 2.0165 |
| Min | 1.643 | 1.8298 |
| Avg | 1.8609 | 1.9232 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 206 / 11 KV STP 12 FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 16-JAN-17 | 17-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 8 | | .3511 |
| 9 | | .4251 |
| 23 | .1294 | |
| 24 | .3696 | |
| Max | .3696 | .4251 |
| Min | .1294 | .3511 |
| Avg | .2495 | .3881 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 207 / SEC-9/E FEEDER NO-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 8 | | .0747 |
| 9 | | .1251 |
| 19 | .0952 | |
| 21 | .1624 | |
| 23 | .1027 | |
| Max | .1624 | .1251 |
| Min | .0952 | .0747 |
| Avg | .1201 | .0999 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 208 / SEC-9/E FEEDER NO-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 8 | | .0698 |
| 9 | | .0453 |
| 19 | .0943 | |
| 21 | .0868 | |
| 23 | .0604 | |
| Max | .0943 | .0698 |
| Min | .0604 | .0453 |
| Avg | .0805 | .0576 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223032 / 22/11 KV Kalmboli Steel

Market

Feeder No / Name : 201 / 11 KV STEEL CHAMBER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2591 | .2687 | .2778 | .2637 | .2621 | .2702 | .2718 |
| 2 | .2694 | .2704 | .282 | .2679 | .274 | .2637 | .2677 |
| 3 | .269 | .2742 | .2808 | .272 | .2759 | .2793 | .265 |
| 4 | .2728 | .2713 | .28 | .2757 | .2843 | .2721 | .2602 |
| 5 | .2652 | .2852 | .2668 | .2614 | .2717 | .2671 | .2655 |
| 6 | .2629 | .2618 | .2633 | .2549 | .2598 | .2591 | .2476 |
| 7 | .2629 | .2398 | .2352 | .2389 | .2439 | .2469 | .2324 |
| 8 | .2597 | .2581 | .2016 | .222 | .2137 | .229 | .1147 |
| 9 | .3015 | .4278 | .3128 | .2955 | .3216 | .3174 | .2804 |
| 10 | .3323 | .5437 | .4862 | .5403 | .5368 | .4956 | .5541 |
| 11 | .192 | .6771 | .5841 | .6505 | .6506 | .3178 | .7202 |
| 12 | .3515 | .65 | .5855 | .6642 | .6935 | .6545 | .7411 |
| 13 | .3147 | .7617 | .6044 | .6665 | .7198 | .6311 | .6759 |
| 14 | .165 | .6237 | .5948 | .6462 | .6146 | .5774 | .5986 |
| 15 | .2671 | .658 | .5963 | .5746 | .6222 | .3273 | .671 |
| 16 | .3486 | .6813 | .5705 | .6607 | .6365 | .6221 | .6413 |
| 17 | .4015 | .7209 | .6028 | .6717 | .6316 | .5857 | .6546 |
| 18 | .3357 | .7076 | .6512 | .6302 | .6085 | .6531 | .66 |
| 19 | .3208 | .6736 | .57 | .6439 | .5723 | .5961 | .5704 |
| 20 | .3097 | .4588 | .4432 | .4954 | .4573 | .4475 | .4515 |
| 21 | .3135 | .386 | .3704 | .3776 | .3568 | .3698 | .3589 |
| 22 | .3022 | .3129 | .3102 | .325 | .3147 | .3078 | .2911 |
| 23 | .1379 | .2938 | .266 | .2938 | .2675 | .1467 | .2366 |
| 24 | .2522 | .2726 | .2732 | .2557 | .2675 | .2595 | .2556 |
| Max | .4015 | .7617 | .6512 | .6717 | .7198 | .6545 | .7411 |
| Min | .1379 | .2398 | .2016 | .222 | .2137 | .1467 | .1147 |
| Avg | .2820 | .4575 | .4129 | .4353 | .4316 | .3915 | .4286 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 201 / 11 KV C.E. FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2193 | 1.2136 | 2.6886 | 2.6063 | 1.2696 | 1.3717 | 1.3717 |
| 2 | 1.2193 | 1.1203 | 2.7557 | 2.3853 | 1.1763 | 1.2193 | 1.2193 |
| 3 | 1.0669 | 1.2136 | 2.7191 | 2.3167 | 1.2136 | 1.2193 | 1.2193 |
| 4 | 1.0669 | 1.4937 | 2.7557 | 2.3167 | 1.307 | 1.2193 | 1.2193 |
| 5 | 2.1643 | 1.8671 | 2.902 | 2.5568 | 1.587 | 1.2193 | 1.2193 |
| 6 | 2.3167 | 2.0538 | 3.3532 | 2.9835 | 1.6804 | 1.5242 | 3.0331 |
| 7 | 2.6749 | 2.0538 | 4.103 | 4.0199 | 2.4272 | 1.9814 | 3.5094 |
| 8 | 3.4408 | 2.2405 | 4.6273 | 4.2409 | 1.9044 | 2.2862 | 3.9857 |
| 9 | 3.6961 | 1.9418 | 4.2101 | 3.8828 | 1.8671 | 2.2862 | 3.9171 |
| 10 | 3.8858 | 1.829 | 3.6618 | 3.5467 | | 3.6275 | 1.9814 |
| 11 | 3.8485 | 1.5364 | 1.6766 | 3.155 | | 3.2693 | 1.829 |
| 12 | 3.5094 | 1.2803 | 2.8274 | 2.8685 | 1.531 | 3.0141 | 3.3974 |
| 13 | 3.2076 | 1.3535 | 2.5377 | 2.8501 | 1.531 | 1.3717 | 3.0552 |
| 14 | 2.9432 | 2.8715 | 2.351 | 1.2936 | 1.5684 | 1.3717 | 2.9722 |
| 15 | 2.6787 | 2.7557 | 1.2193 | 1.1827 | 2.828 | 1.3717 | 2.3822 |
| 16 | 2.6653 | 2.7191 | .8155 | 1.1458 | 2.6383 | 1.2193 | 2.601 |
| 17 | 2.8654 | 2.7191 | .1524 | 1.3443 | 2.5636 | 2.4196 | 2.7907 |
| 18 | 3.2419 | 3.024 | 2.953 | 1.6804 | 3.354 | 1.5242 | 3.2419 |
| 19 | 3.9232 | 3.4751 | 4.2066 | 1.885 | 3.8485 | 3.7647 | 3.8485 |
| 20 | 3.8858 | 3.7738 | 2.1338 | 1.9418 | 3.9232 | 3.7647 | 3.9232 |
| 21 | 3.8485 | 3.7738 | 1.9814 | 1.9044 | 1.9814 | 1.9814 | 3.8485 |
| 22 | 1.8671 | 3.8104 | 1.9814 | 1.8671 | 1.9814 | 1.9814 | 3.8858 |
| 23 | 1.587 | 3.4019 | 3.3379 | 1.531 | 1.829 | 3.3722 | 3.3974 |
| 24 | 1.166 | 2.8312 | 2.7938 | 1.2689 | 2.8548 | 2.9836 | 2.9798 |
| Max | 3.9232 | 3.8104 | 4.6273 | 4.2409 | 3.9232 | 3.7647 | 3.9857 |
| Min | 1.0669 | 1.1203 | .1524 | 1.1458 | 1.1763 | 1.2193 | 1.2193 |
| Avg | 2.6662 | 2.3480 | 2.6977 | 2.3656 | 2.1302 | 2.1402 | 2.7845 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 202 / 11 KV N.T.F.C. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1867 | .3429 | .1029 | .1867 | | .1524 |
| 2 | | .1867 | .3048 | .1029 | .1867 | | .1524 |
| 3 | | .1867 | .2286 | .1029 | .1867 | | .1524 |
| 4 | | .1867 | .2286 | .0686 | .1867 | | .1524 |
| 5 | .1715 | .1867 | .3048 | .0686 | .1867 | | .1524 |
| 6 | .1715 | .1867 | .2667 | .0686 | .1867 | | .3582 |
| 7 | .1715 | .2241 | .381 | .0686 | .2614 | | .3582 |
| 8 | .1715 | .2614 | .3048 | .2058 | .2614 | | .3239 |
| 9 | .1715 | .2614 | .1509 | .2401 | .2614 | | .3925 |
| 10 | .2241 | .2667 | .1715 | | | .2401 | .1524 |
| 11 | .2241 | .2667 | .1524 | .2614 | | .2401 | .1524 |
| 12 | .2241 | .4191 | .1372 | | .2641 | .2401 | .4165 |
| 13 | .2241 | .4191 | .1372 | .2614 | .2667 | | .381 |
| 14 | .2241 | .4191 | .1372 | .2587 | .2667 | | .381 |
| 15 | .2241 | .4191 | | .2614 | .2286 | | .3429 |
| 16 | .2241 | .4191 | .1029 | .2614 | .2286 | | .3429 |
| 17 | .2241 | .4191 | | .2614 | .2286 | .3582 | .3429 |
| 18 | .2241 | .4191 | .1029 | .2587 | .2286 | .1524 | .381 |
| 19 | .2241 | .4191 | .1029 | .2241 | .2667 | .3582 | .381 |
| 20 | .2241 | .381 | | .2218 | .2667 | .3582 | .381 |
| 21 | .2241 | .381 | | .2241 | | .1524 | .4191 |
| 22 | .2241 | .381 | | .2241 | | .1524 | .4191 |
| 23 | .2241 | .381 | .1029 | .2241 | | .3239 | .381 |
| 24 | .2058 | .3391 | .1886 | .1029 | .1867 | .3765 | .3239 |
| Max | .2241 | .4191 | .381 | .2614 | .2667 | .3765 | .4191 |
| Min | .1715 | .1867 | .1029 | .0686 | .1867 | .1524 | .1524 |
| Avg | .2100 | .3174 | .2026 | .1852 | .2282 | .2684 | .3080 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 203 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0187 | .0191 | .0171 | .0187 | | |
| 2 | | .0187 | .0191 | .0171 | .0187 | | |
| 3 | | .0187 | .0191 | .0171 | .0187 | | |
| 4 | | .0187 | .0191 | .0171 | .0187 | | |
| 5 | .0171 | .0187 | .0191 | .0171 | .0187 | | |
| 6 | .0171 | .0187 | .0191 | .0171 | .0187 | | .0171 |
| 7 | .0171 | .0187 | .0191 | .0171 | .0187 | | .0171 |
| 8 | .0171 | .0187 | .0191 | .0171 | .0187 | | .0171 |
| 9 | .0171 | | .0191 | .0171 | .0187 | | .0171 |
| 10 | .0187 | .0191 | .0171 | | | .0171 | |
| 11 | .0187 | .0191 | | .0187 | | .0171 | |
| 12 | .0187 | .0191 | .0171 | | .0187 | .0171 | .0191 |
| 13 | .0187 | .0191 | .0171 | .0187 | .0191 | | .0191 |
| 14 | .0187 | .0191 | .0171 | .0187 | .0191 | | .0191 |
| 15 | .0187 | .0191 | | .0187 | .0191 | | .0191 |
| 16 | .0187 | .0191 | .0171 | .0187 | .0191 | | .0191 |
| 17 | .0187 | .0191 | | .0187 | .0191 | .0171 | .0191 |
| 18 | .0187 | .0191 | .0171 | .0187 | .0191 | | .0191 |
| 19 | .0187 | .0191 | .0171 | .0187 | .0191 | .0171 | .0191 |
| 20 | .0187 | .0191 | | .0187 | .0191 | .0171 | .0191 |
| 21 | .0187 | .0191 | | .0187 | | | .0191 |
| 22 | .0187 | .0191 | | .0185 | | | .0191 |
| 23 | .0187 | .0191 | .0171 | .0187 | | .0171 | .0191 |
| 24 | .0171 | .0187 | .0191 | .0171 | .0187 | .0191 | .0171 |
| Max | .0187 | .0191 | .0191 | .0187 | .0191 | .0191 | .0191 |
| Min | .0171 | .0187 | .0171 | .0171 | .0187 | .0171 | .0171 |
| Avg | .0182 | .0189 | .0182 | .0180 | .0189 | .0174 | .0185 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 204 / 11 KV MHATMA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.307 | 2.7557 | 1.2346 | 1.4003 | | 1.5242 |
| 2 | | 1.307 | 2.6459 | 1.2346 | 1.307 | | 1.2193 |
| 3 | | 1.2136 | 2.6459 | 1.166 | 1.307 | | 1.2193 |
| 4 | | 1.2936 | 2.7191 | 1.166 | 1.4937 | | 1.2193 |
| 5 | 1.0974 | 1.6804 | 2.8654 | 1.5089 | 1.6804 | | 1.2193 |
| 6 | 1.2346 | 2.0538 | 3.3532 | 1.6804 | 1.8671 | | 3.1017 |
| 7 | 1.3032 | 2.2405 | 4.1091 | 1.9204 | 2.4272 | | 3.4065 |
| 8 | 1.7147 | 2.2405 | 4.1823 | 1.9204 | 2.5206 | | 3.9857 |
| 9 | 1.8519 | 2.2405 | 4.1503 | 1.989 | 2.2405 | 2.1338 | 3.9857 |
| 10 | 2.2177 | 2.0851 | 3.4751 | 1.8671 | | 3.8485 | 2.1338 |
| 11 | 1.9605 | 1.829 | 1.829 | 1.5708 | | 3.4065 | 1.829 |
| 12 | 1.6632 | 1.5364 | 2.8274 | 1.4784 | 1.7558 | 2.8959 | 3.5643 |
| 13 | 1.4937 | 1.4998 | 2.6596 | 1.4937 | 1.4563 | 1.5242 | 3.0606 |
| 14 | 1.4003 | 1.5364 | 2.3853 | 1.2136 | 1.3443 | 1.2193 | 3.1337 |
| 15 | 1.2012 | 1.5729 | 1.2193 | 1.1203 | 1.3817 | 1.2193 | 2.7191 |
| 16 | 1.1203 | 2.7922 | 1.0974 | 1.2012 | 1.419 | 1.2193 | 2.6825 |
| 17 | 1.4003 | 2.7191 | | 1.4045 | 1.419 | 2.4539 | 2.6825 |
| 18 | 1.848 | 3.0606 | 1.4403 | 1.5708 | 1.8671 | 1.2193 | 3.3166 |
| 19 | 2.2405 | 4.2189 | 1.8519 | 2.2177 | 1.9418 | 3.6123 | 4.2189 |
| 20 | 2.3339 | 4.3286 | | 2.2177 | 2.0911 | 3.9171 | 4.3286 |
| 21 | 2.2405 | 4.2554 | | 2.2177 | | 2.1338 | 4.2554 |
| 22 | 1.9404 | 4.1091 | | 2.0538 | | 2.1338 | 4.1823 |
| 23 | 1.7737 | 3.4385 | 1.5089 | 1.6804 | | 3.3379 | 3.658 |
| 24 | 1.2346 | 2.9102 | 1.5089 | 1.2346 | 1.4784 | 3.3379 | 3.2007 |
| Max | 2.3339 | 4.3286 | 4.1823 | 2.2177 | 2.5206 | 3.9171 | 4.3286 |
| Min | 1.0974 | 1.2136 | 1.0974 | 1.1203 | 1.307 | 1.2193 | 1.2193 |
| Avg | 1.6635 | 2.3945 | 2.5615 | 1.5984 | 1.7052 | 2.4758 | 2.9103 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 205 / 11Kv Pump P2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.307 | 2.7236 | 2.4539 | 1.4003 | | 1.5242 |
| 2 | | 1.307 | 2.8669 | 2.4539 | 1.307 | | 1.2193 |
| 3 | | 1.2012 | 3.0102 | 2.4539 | 1.307 | | 1.2193 |
| 4 | | 1.307 | 3.0818 | 2.3853 | 1.4937 | | 1.2193 |
| 5 | 1.0974 | 1.6804 | 3.3325 | 2.7282 | 1.7177 | | 1.2193 |
| 6 | 1.2346 | 2.2405 | 3.7449 | 3.2046 | 1.9044 | | 3.1703 |
| 7 | 1.3032 | 2.2177 | 4.462 | 4.0542 | 2.2405 | | 3.4065 |
| 8 | 1.6461 | 2.5206 | 4.4978 | 4.3972 | 2.4272 | | 4.0542 |
| 9 | 2.0576 | 2.5206 | 4.7398 | 2.4387 | 2.3339 | | 4.3286 |
| 10 | 2.3101 | 2.1491 | 4.0542 | 4.281 | | 1.9204 | 2.1338 |
| 11 | 2.0328 | 1.7909 | 2.1338 | 4.0009 | | 1.6461 | 2.1338 |
| 12 | 1.8671 | 3.5483 | 1.5089 | 3.6027 | 1.7558 | 1.3717 | 3.3654 |
| 13 | 1.4937 | 3.0285 | | 3.095 | 1.5364 | | 3.1337 |
| 14 | 1.4784 | 2.9927 | 1.2346 | 2.6196 | 1.4266 | | 3.024 |
| 15 | 1.4003 | 3.0644 | 1.2193 | 1.2936 | 1.2803 | | 2.9874 |
| 16 | 1.307 | 2.7953 | 2.3853 | 1.2012 | 1.2803 | | 2.6825 |
| 17 | 1.386 | 2.7236 | 1.2193 | 1.39 | 1.2437 | 2.5225 | 1.39 |
| 18 | 1.6804 | 2.7236 | 2.591 | 1.7556 | 1.829 | 1.5242 | 1.829 |
| 19 | 2.2405 | 3.6915 | 3.6809 | 2.2177 | 1.9022 | 3.6809 | 2.0485 |
| 20 | 2.2032 | 4.2112 | 2.1338 | 2.2177 | 2.1216 | 3.6809 | 2.1216 |
| 21 | 2.1472 | 4.1754 | 1.829 | 2.2405 | | 1.829 | 2.0851 |
| 22 | 1.9404 | 3.9963 | 1.829 | 2.1807 | | 1.829 | 1.9753 |
| 23 | 1.6804 | 3.4766 | 3.4065 | 1.5223 | | 3.4065 | 1.7924 |
| 24 | 1.2346 | 2.9245 | 2.9577 | 1.3032 | 1.4003 | 3.0331 | 1.3717 |
| Max | 2.3101 | 4.2112 | 4.7398 | 4.3972 | 2.4272 | 3.6809 | 4.3286 |
| Min | 1.0974 | 1.2012 | 1.2193 | 1.2012 | 1.2437 | 1.3717 | 1.2193 |
| Avg | 1.6871 | 2.6497 | 2.8106 | 2.5622 | 1.6794 | 2.4040 | 2.3098 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 206 / HORIZON SCHOOL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0183 | .0179 | .0171 | .0185 | | |
| 2 | | .0175 | .0179 | .0171 | .0185 | | |
| 3 | | .0175 | .0179 | .0171 | .0185 | | |
| 4 | | .0175 | .0179 | .0171 | .0187 | | |
| 5 | .0171 | .0181 | .0179 | .0171 | .0183 | | |
| 6 | .0171 | .0181 | .0179 | .0171 | .0181 | | .0171 |
| 7 | .0171 | .0171 | .0179 | .0171 | .0181 | | .0171 |
| 8 | .0171 | .0171 | .0179 | .0171 | .0183 | | .0171 |
| 9 | .0171 | .0175 | .0189 | .0171 | .0177 | | .0171 |
| 10 | .0171 | .0179 | .0171 | | | .0171 | |
| 11 | .0171 | .0179 | | .0171 | | .0171 | |
| 12 | .0171 | .0179 | .0171 | | .0183 | .0171 | .0183 |
| 13 | .0171 | .0179 | .0171 | .0171 | .0183 | | .0366 |
| 14 | .0171 | .0179 | .0171 | .0171 | .0183 | | .0183 |
| 15 | .0171 | .0179 | | .0175 | .0183 | | .0183 |
| 16 | .0171 | .0179 | .0171 | .0171 | .0183 | | .0183 |
| 17 | .0171 | .0179 | | .0185 | .0183 | .0171 | .0183 |
| 18 | .0181 | .0122 | .0171 | .0187 | .0183 | | .0183 |
| 19 | .0185 | .0179 | .0171 | .0185 | .0183 | .0171 | .0183 |
| 20 | .0181 | .0179 | | .0185 | .0183 | .0171 | .0183 |
| 21 | .0181 | .0179 | | .0187 | | | .0183 |
| 22 | .0181 | .0179 | | .0187 | | | .0183 |
| 23 | .0183 | .0179 | .0171 | .0181 | | .0171 | .0183 |
| 24 | .0171 | .0183 | .0183 | .0171 | .0187 | .0187 | .0171 |
| Max | .0185 | .0183 | .0189 | .0187 | .0187 | .0187 | .0366 |
| Min | .0171 | .0122 | .0171 | .0171 | .0177 | .0171 | .0171 |
| Avg | .0174 | .0176 | .0176 | .0176 | .0183 | .0173 | .0190 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 207 / 11 kv khandeshwar railway NON SHEDDABLE EHV INDUSTRIAL FEEDERS
 stn Feeder KV- 11 / OUTGOING (NON CONTINOUS PROCESS)(NO
 STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0305 | .0251 | .0305 | .0305 | | |
| 2 | | .0305 | .0251 | .0305 | .0305 | | |
| 3 | | .0305 | .0251 | .061 | .0305 | | |
| 4 | | .0305 | .0251 | .061 | .0305 | | |
| 5 | .0305 | .0305 | .0251 | .0305 | .0305 | | |
| 6 | .0305 | .0305 | .0251 | .0305 | .0305 | | .0305 |
| 7 | .0305 | .0267 | .0251 | .0305 | .0305 | | .0343 |
| 8 | .0305 | .0305 | .0251 | .0305 | .0305 | | .0305 |
| 9 | .0305 | .0114 | .0114 | .0305 | .0305 | | .0343 |
| 10 | .0114 | .0251 | .0305 | | | .0305 | |
| 11 | .0076 | .0251 | | .0038 | | .0305 | |
| 12 | .0076 | .0251 | .0305 | | .0072 | .0305 | .0133 |
| 13 | .0076 | .0251 | .0305 | .0038 | .0095 | | .0229 |
| 14 | .0076 | .0251 | .0305 | .0076 | .0095 | | .0229 |
| 15 | .0076 | .0251 | | .0076 | .0095 | | .0229 |
| 16 | .0076 | .0251 | .0305 | .0114 | .0095 | | .0229 |
| 17 | .0114 | .0251 | | .0076 | .0095 | .0305 | .0229 |
| 18 | .0305 | .0251 | .0305 | .0305 | .0095 | | .0229 |
| 19 | .0305 | .0251 | .0305 | .0305 | .0095 | .0305 | .0229 |
| 20 | .0305 | .0251 | | .0305 | .0095 | .0305 | .0229 |
| 21 | .0305 | .0251 | | .0305 | | | .0229 |
| 22 | .0305 | .0251 | | .0305 | | | .0229 |
| 23 | .0305 | .0251 | .0305 | .0305 | | .0305 | .0229 |
| 24 | .061 | .0305 | .0339 | .0305 | .0305 | .0328 | .0343 |
| Max | .061 | .0305 | .0339 | .061 | .0305 | .0328 | .0343 |
| Min | .0076 | .0114 | .0114 | .0038 | .0072 | .0305 | .0133 |
| Avg | .0232 | .0264 | .0272 | .0269 | .0204 | .0308 | .0252 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 208 / MGM (EXPRESS)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3734 | .4036 | .2915 | .3734 | | |
| 2 | | .3361 | .4319 | .2812 | .3734 | | |
| 3 | | .3361 | .4414 | .2743 | .3547 | | |
| 4 | | .3361 | .464 | .2881 | .3734 | | |
| 5 | .2778 | .3547 | .4885 | .3292 | .3921 | | |
| 6 | .3429 | .3361 | .5055 | .3858 | .4481 | | .3772 |
| 7 | .3138 | .3547 | .5093 | .439 | .4294 | | .4218 |
| 8 | .3601 | .5601 | .5432 | .4973 | .4108 | | .5058 |
| 9 | .3429 | .7282 | .7054 | .631 | .7095 | | .5727 |
| 10 | .4481 | .7658 | .7082 | .7095 | | .6979 | |
| 11 | .5041 | .8035 | | .8402 | | .7545 | |
| 12 | .4854 | .8921 | .739 | | .8318 | .7545 | .7337 |
| 13 | .4294 | .8092 | .7202 | .7095 | .7658 | | .7092 |
| 14 | .4108 | .7281 | 7.4074 | .8029 | .7281 | | .5923 |
| 15 | .4108 | .6205 | | .7392 | .7016 | | .5828 |
| 16 | .4108 | .6715 | .6602 | .7023 | .6658 | | .5357 |
| 17 | .3921 | .5923 | | .6535 | .5734 | .5453 | .4904 |
| 18 | .3921 | .564 | .4698 | .4481 | .5357 | | .4829 |
| 19 | .3734 | .5206 | .4458 | .5415 | .4829 | .4287 | .4338 |
| 20 | .4294 | .5055 | | .4805 | .4546 | .463 | .415 |
| 21 | .4294 | .4866 | | .4481 | | | .4112 |
| 22 | .4481 | .4319 | | .4668 | | | .4225 |
| 23 | .3921 | .4131 | .3429 | .4294 | | .3344 | .4131 |
| 24 | .3258 | .4294 | .3678 | .2932 | .3921 | .415 | .3344 |
| Max | .5041 | .8921 | 7.4074 | .8402 | .8318 | .7545 | .7337 |
| Min | .2778 | .3361 | .3429 | .2743 | .3547 | .3344 | .3344 |
| Avg | .3960 | .5396 | .9086 | .5079 | .5261 | .5492 | .4961 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 201 / 11 KV STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0549 | .0566 | .0514 | .0532 | .0514 | .0566 |
| 2 | | .0549 | .0566 | .0514 | .0532 | .0514 | .0566 |
| 3 | | .0549 | .0566 | .0514 | .0532 | | .0566 |
| 4 | | .0549 | .0566 | .0514 | .0532 | .0514 | .0566 |
| 5 | | .0549 | .0566 | .0514 | .0532 | | .0566 |
| 6 | | .0549 | .0754 | .0514 | .0532 | .0686 | .0754 |
| 7 | | .0549 | .0754 | | .0532 | | .0566 |
| 8 | .0514 | .0549 | .0566 | .0686 | .0514 | .0686 | .0566 |
| 9 | | .0754 | | .0549 | .0514 | .0566 | .0543 |
| 10 | | .0566 | .0686 | .0549 | .0686 | .0566 | .0543 |
| 11 | | .0754 | .0514 | .0549 | .0686 | .0566 | .0543 |
| 12 | | .0754 | .0514 | .0549 | .0514 | .0754 | .0543 |
| 13 | | .0566 | | .0549 | .0514 | .0754 | .0543 |
| 14 | | .0566 | .0514 | .0549 | .0686 | .0566 | .0543 |
| 15 | | .0566 | .0514 | .0549 | .0514 | .0566 | .0543 |
| 16 | .0566 | .0754 | .0514 | .0549 | .0514 | .0566 | .0543 |
| 17 | | .0566 | .0514 | .0537 | .0514 | .0754 | .0532 |
| 18 | | .0566 | .0514 | .0537 | .0686 | .0566 | .0532 |
| 19 | | .0566 | .0514 | .0537 | .0686 | .0566 | .0532 |
| 20 | | .0754 | .0514 | .0537 | .0686 | .0566 | .0532 |
| 21 | | .0754 | | .0543 | .0686 | .0566 | .0532 |
| 22 | | .0566 | .0514 | .0543 | .0514 | .0754 | .0532 |
| 23 | | .0754 | .0514 | | .0514 | .0754 | .0532 |
| 24 | | .0754 | .0514 | | .0514 | | .0754 |
| Max | .0566 | .0754 | .0754 | .0686 | .0686 | .0754 | .0754 |
| Min | .0514 | .0549 | .0514 | .0514 | .0514 | .0514 | .0532 |
| Avg | .054 | .0623 | .0560 | .0543 | .0569 | .0617 | .0564 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 203 / 11 KV JUI GAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.8861 | 1.6461 | 1.7918 | 1.4575 | 1.6301 | 1.6289 | 1.8484 |
| 2 | 1.6975 | 1.6461 | 1.7541 | 1.4232 | 1.5061 | 1.5947 | 1.8107 |
| 3 | 1.5089 | 1.5729 | 1.6975 | 1.3889 | 1.4529 | 1.5947 | 1.7541 |
| 4 | 1.6975 | 1.5912 | 1.6975 | 1.3717 | 1.4175 | 1.5947 | 1.7353 |
| 5 | | 1.6827 | 1.773 | 1.4746 | 1.4175 | 1.8861 | 1.773 |
| 6 | 1.8861 | 2.1948 | 2.0182 | 1.9547 | 1.9845 | 2.1605 | 1.9805 |
| 7 | 2.2634 | 2.5972 | 2.584 | | 2.4274 | 2.4006 | 2.2634 |
| 8 | 2.2291 | 2.9081 | 2.9613 | 2.6235 | 2.692 | 2.6063 | 2.7349 |
| 9 | 2.0576 | 2.7349 | 2.4006 | 2.7252 | 2.4246 | 2.8481 | 2.6606 |
| 10 | 1.989 | 2.584 | 2.1776 | 2.4508 | 2.5034 | 2.6595 | 2.4253 |
| 11 | 1.7147 | 1.9805 | | 2.2862 | 2.2119 | 2.3954 | 2.3529 |
| 12 | 1.8861 | 1.8296 | 1.7147 | 2.2314 | 2.1262 | 2.3011 | 2.2081 |
| 13 | 1.869 | 2.0559 | 1.6804 | 2.2497 | 1.9033 | 2.1879 | 2.0633 |
| 14 | | 1.9805 | 1.5947 | 2.0485 | 1.6289 | 1.8296 | 1.9366 |
| 15 | 1.8861 | 1.6409 | 1.8004 | 2.0119 | 1.7661 | 1.9993 | 1.828 |
| 16 | 1.8519 | 1.9993 | 1.7661 | 1.9936 | 1.6804 | 1.5844 | 1.8099 |
| 17 | 2.0748 | 2.0182 | 1.7147 | 1.97 | 1.6632 | 1.8484 | 1.7718 |
| 18 | 2.452 | 2.037 | 1.8861 | 1.8267 | 1.8519 | 2.0748 | 2.0199 |
| 19 | 2.6406 | 2.6406 | 2.3491 | 2.561 | 2.4691 | 2.5274 | 2.6046 |
| 20 | 2.6406 | 2.7349 | 2.5206 | 2.6505 | 2.3148 | 2.6783 | 2.6578 |
| 21 | 2.9664 | 2.5274 | | 2.6425 | 2.4863 | 2.7915 | 2.6932 |
| 22 | .2092 | 2.4897 | 2.2634 | 2.4615 | 2.3834 | 2.3577 | 2.4806 |
| 23 | | 2.3954 | 2.0919 | 2.1719 | 1.9376 | 2.2068 | 1.8959 |
| 24 | 2.0748 | 2.7349 | 1.5089 | | 1.749 | | 1.9239 |
| Max | 2.9664 | 2.9081 | 2.9613 | 2.7252 | 2.692 | 2.8481 | 2.7349 |
| Min | .2092 | 1.5729 | 1.5089 | 1.3717 | 1.4175 | 1.5844 | 1.7353 |
| Avg | 1.9753 | 2.1760 | 1.9885 | 2.0898 | 1.9845 | 2.1633 | 2.1347 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 204 / 11 KV SURAJ PARK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.8292 | 1.9387 | 2.1125 | 1.6461 | 1.7187 | 1.8004 | 2.0936 |
| 2 | 2.6406 | 1.8656 | 2.0559 | 1.5947 | 1.6478 | 1.7661 | 2.0182 |
| 3 | 2.452 | 1.8473 | 1.9805 | 1.5432 | 1.5947 | 1.7318 | 1.9616 |
| 4 | 2.2634 | 1.8473 | 1.905 | 1.5432 | 1.5769 | 1.749 | 1.9427 |
| 5 | 2.2257 | 1.8656 | 1.9993 | 1.6118 | 1.5769 | 1.8176 | 2.037 |
| 6 | 2.6029 | 2.4874 | 2.32 | 2.1091 | 2.1439 | 2.2119 | 2.2445 |
| 7 | 3.0178 | 3.3288 | 2.7915 | | 2.6932 | 3.1207 | 2.6406 |
| 8 | 3.263 | | 3.7534 | 3.275 | 3.4122 | 3.2579 | 3.5082 |
| 9 | 2.915 | 3.2253 | 3.0864 | 3.3288 | 3.0864 | 3.1687 | 3.1493 |
| 10 | 2.7435 | 2.8481 | 2.4863 | 3.091 | 2.6406 | 2.8481 | 2.8778 |
| 11 | 2.572 | 2.4331 | 2.3663 | 2.4874 | 2.2805 | 2.8104 | 2.7149 |
| 12 | 2.4006 | 2.2822 | 2.4177 | 2.1765 | 2.1948 | 2.6029 | 2.5701 |
| 13 | 2.452 | 2.32 | 2.1948 | 2.1399 | 2.1434 | 2.3577 | 2.4072 |
| 14 | 2.2291 | 2.1691 | 2.0576 | 2.0119 | 1.9719 | 2.2257 | 2.1538 |
| 15 | 1.8347 | 2.1502 | 1.8176 | 1.9936 | 1.9204 | 2.0748 | 2.0633 |
| 16 | 1.9376 | 2.0559 | 1.8176 | 1.9936 | 1.8004 | 1.9993 | 2.0814 |
| 17 | 2.452 | 2.1879 | 1.9033 | 1.9879 | 1.9204 | 2.0559 | 2.0199 |
| 18 | 2.572 | 2.4709 | 2.0576 | 2.1491 | 2.2462 | 2.2445 | 2.3034 |
| 19 | 2.8292 | 2.8858 | 2.5549 | 2.8654 | 2.6235 | 2.8481 | 2.8349 |
| 20 | 3.0178 | 3.131 | 2.7778 | 2.8086 | 2.7606 | 3.0367 | 2.8881 |
| 21 | 2.572 | 3.1876 | | 2.8959 | 2.8464 | 3.0556 | 2.9058 |
| 22 | | 2.8669 | 2.6063 | 2.7511 | 2.6406 | 2.8669 | 2.6932 |
| 23 | 2.1091 | 2.452 | 2.1948 | 2.3348 | 2.1605 | 2.5463 | 2.268 |
| 24 | 3.0178 | 3.2253 | 1.9204 | | 1.9033 | | 2.1879 |
| Max | 3.263 | 3.3288 | 3.7534 | 3.3288 | 3.4122 | 3.2579 | 3.5082 |
| Min | 1.8347 | 1.8473 | 1.8176 | 1.5432 | 1.5769 | 1.7318 | 1.9427 |
| Avg | 2.563 | 2.4814 | 2.3121 | 2.2881 | 2.2293 | 2.4433 | 2.4402 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 205 / 11 KV AWAS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.4006 | 1.9204 | 1.9616 | 1.5775 | 1.701 | 1.7833 | 2.0559 |
| 2 | 2.3663 | 1.8473 | 1.905 | 1.5432 | 1.6301 | 1.7318 | 1.9805 |
| 3 | 2.6406 | 1.829 | 1.8861 | 1.4918 | 1.5947 | 1.6975 | 1.9427 |
| 4 | 2.0576 | 1.8473 | 1.7918 | 1.4575 | 1.5415 | 1.749 | 1.8861 |
| 5 | | 1.8473 | 1.9239 | 1.4918 | 1.5415 | 1.989 | 1.9616 |
| 6 | 2.2291 | 2.3594 | 2.3011 | 2.1091 | 2.1262 | 2.2805 | 2.1502 |
| 7 | 2.4863 | 3.1459 | 3.0556 | | 2.8704 | 3.0521 | 2.5652 |
| 8 | 2.6063 | 3.3288 | 3.4894 | 3.0178 | 3.1722 | 3.0521 | 3.1876 |
| 9 | 2.4006 | 3.0933 | 2.8635 | 2.963 | 2.8635 | 3.0556 | 3.1674 |
| 10 | 2.452 | 2.8104 | 2.4006 | 2.8166 | 2.572 | 2.6595 | 2.6968 |
| 11 | 2.0576 | 2.5463 | 2.2291 | 2.2862 | 2.2462 | 2.5652 | 2.3891 |
| 12 | 1.8861 | 1.4028 | 2.0576 | 2.0485 | 2.0576 | 2.32 | 2.3348 |
| 13 | 1.9376 | 2.2445 | 1.8861 | 1.9753 | 1.989 | 2.1691 | 2.2443 |
| 14 | 1.9376 | 1.9616 | 1.8176 | 1.957 | 1.8347 | 1.9616 | 2.2624 |
| 15 | 1.8176 | 1.9239 | 1.6461 | 1.9753 | 1.7833 | 1.8107 | 2.2443 |
| 16 | 1.8347 | 1.905 | 1.7661 | 1.9753 | 1.8176 | 1.9239 | 2.2443 |
| 17 | 2.2634 | 2.0748 | 1.8519 | 1.97 | 1.9547 | 2.0748 | 2.2148 |
| 18 | 2.6406 | 2.584 | 2.0576 | 2.4535 | 2.0748 | 2.5463 | 2.6046 |
| 19 | 3.0178 | 3.3385 | 2.9321 | 3.152 | 3.0178 | 3.2253 | 3.207 |
| 20 | 3.3951 | 3.5082 | 3.0007 | 3.1878 | 3.0864 | 3.3196 | 3.2602 |
| 21 | 2.915 | 3.3951 | | 3.1131 | 3.0178 | 3.1876 | 3.2956 |
| 22 | 2.6406 | 3.0556 | 2.7778 | 2.7873 | 2.5377 | 2.8669 | 2.8349 |
| 23 | 2.1776 | 2.4331 | 2.1434 | 2.2805 | 2.1434 | 2.3954 | 2.3565 |
| 24 | 2.572 | 3.0933 | 1.9033 | 3.1131 | 1.9376 | | 2.1502 |
| Max | 3.3951 | 3.5082 | 3.4894 | 3.1878 | 3.1722 | 3.3196 | 3.2956 |
| Min | 1.8176 | 1.4028 | 1.6461 | 1.4575 | 1.5415 | 1.6975 | 1.8861 |
| Avg | 2.3797 | 2.4790 | 2.2456 | 2.2932 | 2.2130 | 2.4094 | 2.4682 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 206 / 11 KV KAMOTHE VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.7147 | 1.4998 | 1.5844 | 1.286 | 1.3466 | 1.4918 | 1.5655 |
| 2 | 1.5432 | 1.39 | 1.5466 | 1.2003 | 1.2757 | 1.4403 | 1.5278 |
| 3 | 1.3717 | 1.3535 | 1.5089 | 1.166 | 1.2934 | 1.4575 | 1.4901 |
| 4 | 1.3717 | 1.3535 | 1.5089 | 1.1317 | 1.2757 | 1.4403 | 1.4712 |
| 5 | 1.286 | 1.4083 | 1.5466 | 1.1488 | 1.2403 | 1.5261 | 1.5089 |
| 6 | 1.7147 | 1.9022 | 1.6409 | 1.5775 | 1.6655 | 1.6804 | 1.6032 |
| 7 | 1.8176 | 2.2131 | 2.1691 | | 1.9313 | 2.1262 | 1.9427 |
| 8 | 1.8519 | 2.268 | 2.3954 | 2.1434 | 1.9719 | 2.2291 | 2.4143 |
| 9 | 1.7147 | 2.2257 | | 2.1765 | 2.0919 | 2.2257 | 2.1176 |
| 10 | 1.6975 | 1.9616 | 1.5947 | 2.0119 | 1.7147 | 1.9239 | 2.009 |
| 11 | 1.3717 | 1.6975 | 1.4232 | 1.4998 | 1.3375 | 1.7164 | 1.9728 |
| 12 | 1.3717 | 1.5278 | 1.3717 | 1.4632 | 1.3717 | 1.6032 | 1.6651 |
| 13 | 1.3032 | 1.5089 | | 1.39 | 1.3546 | 1.5089 | 1.5565 |
| 14 | 1.2517 | 1.3769 | 1.2003 | 1.3169 | 1.2517 | 1.3203 | 1.4842 |
| 15 | 1.2346 | 1.2637 | 1.2517 | 1.262 | 1.1488 | 1.3014 | 1.448 |
| 16 | 1.2689 | 1.3203 | 1.2689 | 1.2254 | 1.2174 | 1.3392 | 1.448 |
| 17 | 1.5089 | 1.3957 | 1.3717 | 1.2536 | 1.3203 | 1.3769 | 1.4352 |
| 18 | 1.6975 | 1.7353 | 1.5432 | 1.5223 | 1.3717 | 1.7353 | 1.6832 |
| 19 | 2.0748 | 2.3388 | 2.1091 | 2.3282 | 2.1776 | 2.2257 | 2.3388 |
| 20 | 2.3765 | 2.4143 | 2.1262 | 2.2565 | 2.2119 | 2.32 | 2.3034 |
| 21 | 2.2634 | 2.4143 | | 2.1719 | 2.1776 | 2.3577 | 2.3388 |
| 22 | | 2.2445 | 2.0405 | 2.0452 | 1.9719 | 2.2068 | 2.1085 |
| 23 | 1.6461 | 1.9427 | 1.6632 | 1.7918 | 1.6975 | 1.905 | 1.7364 |
| 24 | 1.7147 | 2.2257 | 1.5432 | | 1.5089 | | 1.6032 |
| Max | 2.3765 | 2.4143 | 2.3954 | 2.3282 | 2.2119 | 2.3577 | 2.4143 |
| Min | 1.2346 | 1.2637 | 1.2003 | 1.1317 | 1.1488 | 1.3014 | 1.4352 |
| Avg | 1.6160 | 1.7909 | 1.6385 | 1.6077 | 1.5803 | 1.7590 | 1.7822 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 208 / 11 KV O/G SPARE-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0732 | .0754 | .0686 | .0532 | .0686 | .0754 |
| 2 | | .0732 | .0754 | | .0532 | .0686 | .0754 |
| 3 | | .0732 | .0754 | .0686 | .0532 | | .0754 |
| 4 | | .0732 | .0754 | .0686 | .0532 | .0686 | .0754 |
| 5 | | .0732 | .0754 | .0686 | .0532 | | .0754 |
| 6 | | .0732 | .0754 | | .0532 | .0857 | .0754 |
| 7 | | .0732 | | | .0532 | | .0754 |
| 8 | | .0732 | .0754 | .0686 | .0514 | .0686 | .0754 |
| 9 | .1372 | .0943 | | .128 | .0514 | .0754 | .0724 |
| 10 | .1509 | .0754 | .12 | .128 | .12 | .132 | .1267 |
| 11 | .1509 | .0943 | .12 | .128 | .12 | .132 | .1267 |
| 12 | .1372 | .0943 | .12 | .128 | .12 | .1509 | .1267 |
| 13 | .1509 | .1132 | .12 | .128 | .12 | .0566 | .1267 |
| 14 | .1509 | .132 | .12 | .128 | .12 | .132 | .1267 |
| 15 | .1509 | .132 | .1372 | .128 | .1372 | .132 | .1448 |
| 16 | .1509 | .132 | .12 | .128 | .1372 | .1509 | .1448 |
| 17 | .1509 | .1509 | .1372 | .1254 | .0514 | .1509 | .1417 |
| 18 | .1509 | .1509 | .1372 | .1254 | .0686 | .1509 | .1417 |
| 19 | .1509 | .1509 | .1372 | .1254 | .1543 | .1509 | .1417 |
| 20 | .1509 | .1509 | .1543 | .1433 | .1543 | .1698 | .1595 |
| 21 | .1509 | .1509 | | .1448 | .1543 | .1698 | .1595 |
| 22 | | .1509 | .12 | .1448 | .0514 | .0754 | .1595 |
| 23 | .0514 | .0566 | .0514 | .0543 | .0686 | .0754 | .0709 |
| 24 | | .0943 | .0514 | | .0686 | | .0754 |
| Max | .1509 | .1509 | .1543 | .1448 | .1543 | .1698 | .1595 |
| Min | .0514 | .0566 | .0514 | .0543 | .0514 | .0566 | .0709 |
| Avg | .1418 | .1046 | .1035 | .1115 | .0884 | .1133 | .1104 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 302 / 22 KV Venkatesh Feeder

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3032 | .9877 | 1.0562 | 1.0288 | .9568 | .9602 | 1.0562 |
| 2 | 1.2346 | 1.0242 | 1.0562 | 1.0288 | .9568 | .9602 | .9808 |
| 3 | 1.1317 | 1.0242 | .9808 | 1.0288 | .9214 | .9602 | .9808 |
| 4 | 1.0288 | 1.0608 | .9431 | 1.0288 | .8859 | .9602 | .9054 |
| 5 | 1.2346 | 1.0608 | 1.0185 | 1.0288 | .8859 | 1.0288 | 1.0185 |
| 6 | 1.3717 | 1.1706 | 1.1694 | 1.0631 | 1.134 | 1.0974 | 1.1317 |
| 7 | 1.4403 | 1.5364 | 1.5089 | | 1.4175 | 1.4746 | 1.358 |
| 8 | 1.4746 | 1.6095 | 1.8107 | 1.4403 | 1.3717 | 1.7147 | 1.6598 |
| 9 | 1.3032 | 1.5089 | 1.5844 | 1.3169 | 1.2346 | 1.5089 | 1.267 |
| 10 | 1.3032 | 1.2826 | 1.2449 | 1.1706 | 1.2689 | 1.2826 | 1.267 |
| 11 | 1.358 | 1.1317 | 1.3203 | 1.1706 | 1.1317 | 1.2826 | 1.2308 |
| 12 | 1.358 | 1.094 | 1.0974 | 1.134 | 1.1317 | 1.2071 | 1.1584 |
| 13 | 1.2449 | 1.0562 | 1.0288 | 1.0608 | 1.1317 | 1.094 | 1.1584 |
| 14 | 1.2071 | 1.1317 | 1.0288 | 1.0242 | .8916 | 1.094 | 1.086 |
| 15 | 1.2071 | 1.0562 | .8916 | 1.0242 | .9259 | 1.0185 | 1.0498 |
| 16 | 1.094 | .9808 | .8916 | .9877 | .8573 | 1.0185 | 1.0136 |
| 17 | 1.2071 | 1.1317 | .9945 | 1.0387 | .9602 | 1.0562 | 1.0277 |
| 18 | | 1.2449 | 1.0288 | 1.1462 | 1.0974 | 1.1317 | 1.0985 |
| 19 | 1.4335 | 1.4712 | 1.3032 | 1.576 | 1.3032 | 1.358 | 1.4175 |
| 20 | 1.5089 | 1.5844 | 1.3717 | 1.5043 | 1.406 | 1.5466 | 1.4883 |
| 21 | 1.5089 | 1.5466 | | 1.5203 | 1.3717 | 1.4712 | 1.4883 |
| 22 | 1.3957 | 1.4335 | 1.3032 | 1.3394 | 1.2689 | 1.4335 | 1.3466 |
| 23 | 1.2449 | 1.2826 | 1.1317 | 1.1584 | 1.0974 | 1.1317 | 1.2048 |
| 24 | 1.3717 | 1.1317 | 1.0974 | | .9945 | | 1.1317 |
| Max | 1.5089 | 1.6095 | 1.8107 | 1.576 | 1.4175 | 1.7147 | 1.6598 |
| Min | 1.0288 | .9808 | .8916 | .9877 | .8573 | .9602 | .9054 |
| Avg | 1.3029 | 1.2310 | 1.1679 | 1.1736 | 1.1084 | 1.2083 | 1.1886 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 303 / 22 KV JAWAHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1317 | 1.6461 | 1.8107 | 1.2346 | 1.4883 | 1.7147 | 1.6598 |
| 2 | 1.0974 | 1.5364 | 1.7353 | 1.2003 | 1.4883 | 1.6461 | 1.5844 |
| 3 | 1.0288 | 1.5364 | 1.7353 | 1.2003 | 1.4529 | 1.5775 | 1.5089 |
| 4 | .9602 | 1.5729 | 1.6598 | 1.2003 | 1.4529 | 1.5775 | 1.5089 |
| 5 | .9945 | 1.5364 | 1.6975 | 1.2003 | 1.5592 | 1.5432 | 1.5844 |
| 6 | 1.2003 | 1.6095 | 1.773 | 1.2689 | | 1.6118 | 1.7353 |
| 7 | 1.3717 | 1.7193 | 1.6221 | | 1.6655 | 1.619 | 1.773 |
| 8 | 1.5089 | 1.9022 | 1.5466 | 1.7924 | 1.6804 | 1.6461 | 2.037 |
| 9 | 1.8861 | 2.4897 | 1.5775 | 2.8898 | 2.6406 | 2.3011 | 2.2081 |
| 10 | 1.9616 | 2.5652 | 1.5775 | 2.8532 | 2.6749 | 2.7538 | 2.3891 |
| 11 | 2.1125 | 3.0556 | | 2.7801 | 2.9835 | 2.7915 | 2.3529 |
| 12 | 2.2634 | 3.0556 | | 2.7435 | 2.7435 | 3.0933 | 2.3167 |
| 13 | 2.2634 | 2.4143 | 1.5775 | 2.7801 | 2.332 | 2.6029 | 2.3167 |
| 14 | 2.3765 | 2.6783 | 1.6461 | 2.7069 | 3.0178 | 2.8292 | 2.3529 |
| 15 | 2.4143 | 2.8669 | | 2.9995 | 2.7435 | 2.9801 | 2.2443 |
| 16 | 2.4897 | 2.9801 | 1.5432 | 3.0361 | 3.0178 | 3.0933 | 2.3167 |
| 17 | 2.2634 | 2.6783 | 1.4403 | 2.8654 | 2.4691 | 2.8669 | 2.268 |
| 18 | 2.2634 | 2.6783 | 1.3717 | 2.6505 | 2.4006 | 2.9047 | 2.268 |
| 19 | 2.1879 | 2.5274 | 1.3032 | 2.1132 | 2.2977 | 2.7915 | 1.949 |
| 20 | 1.9993 | 2.037 | 1.3375 | 1.9342 | 1.9204 | 2.1125 | 1.9136 |
| 21 | | 1.9616 | | 1.8823 | 1.749 | 2.0748 | 1.8427 |
| 22 | 1.8861 | 1.9239 | 1.3375 | 1.7737 | 1.8519 | 1.9239 | 1.8073 |
| 23 | 1.8107 | 1.8861 | 1.3032 | 1.5203 | 1.7147 | 1.7353 | 1.382 |
| 24 | 1.2003 | 1.8107 | 1.2346 | | 1.7833 | | 1.7353 |
| Max | 2.4897 | 3.0556 | 1.8107 | 3.0361 | 3.0178 | 3.0933 | 2.3891 |
| Min | .9602 | 1.5364 | 1.2346 | 1.2003 | 1.4529 | 1.5432 | 1.382 |
| Avg | 1.7684 | 2.1945 | 1.5415 | 2.1194 | 2.1360 | 2.2518 | 1.9606 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 203 / 11 KV MURBI SECTOR-19

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3048 | | .3048 | .3048 | | .3048 | .3048 |
| 2 | | | .3048 | .3048 | | .3048 | .3048 |
| 3 | .4115 | | .9907 | .7163 | | .8192 | .7163 |
| 4 | | .4287 | .3048 | .3048 | .4287 | .3048 | .3048 |
| 5 | | | .3048 | .3048 | | .3048 | .3048 |
| 6 | | | .3048 | .3048 | | .3048 | .3048 |
| 7 | .5487 | | 1.7718 | 1.9433 | .8573 | 1.6004 | 1.3642 |
| 8 | | | .9145 | .9145 | | .9145 | .6097 |
| 9 | .8916 | | 1.9433 | 1.7375 | | 1.7718 | 1.8061 |
| 10 | | .9431 | .9145 | .9145 | | .9145 | .9145 |
| 11 | | .9145 | .9145 | .9145 | | .9145 | .9145 |
| 12 | | .6097 | .6097 | .6097 | | 1.6004 | .6097 |
| 13 | | .6097 | .6097 | 1.1241 | | .6097 | 1.6004 |
| 14 | | .6097 | .6097 | | | .6097 | |
| 15 | | 1.2956 | 1.227 | | .6097 | 1.227 | |
| 16 | .5144 | .6097 | .6097 | .5144 | .6097 | .6097 | |
| 17 | | .6097 | 1.227 | | .6097 | 1.1584 | .6859 |
| 18 | | .6097 | .6097 | | .6097 | .6097 | |
| 19 | | .6097 | .6097 | | 1.467 | .6097 | |
| 20 | | 1.467 | 1.4327 | .8573 | .6097 | 1.3642 | |
| 21 | .7716 | .6097 | .6097 | | .6097 | .6097 | .6097 |
| 22 | | .6097 | .6097 | | .6097 | .6097 | 1.2956 |
| 23 | | 1.2956 | 1.1584 | | 1.2956 | .6097 | .6097 |
| 24 | .4801 | 1.2956 | 1.2956 | .4801 | 1.1241 | 1.2956 | 1.2956 |
| Max | .8916 | 1.467 | 1.9433 | 1.9433 | 1.467 | 1.7718 | 1.8061 |
| Min | .3048 | .4287 | .3048 | .3048 | .4287 | .3048 | .3048 |
| Avg | .5604 | .8205 | .8413 | .7656 | .7867 | .8326 | .8087 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 204 / 11 KV VIGNHAR SECTOR-12

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 |
|------------|---------------|---------------|---------------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 3 | .8573 | | .8573 |
| 4 | | .8573 | |
| 7 | 1.0288 | | 1.286 |
| 9 | 1.3717 | | 1.5432 |
| 10 | | 1.3717 | |
| 12 | | | 1.2003 |
| 15 | | 1.2003 | .9945 |
| 16 | 1.0288 | | |
| 20 | | 1.7147 | |
| 21 | 1.6289 | | |
| 23 | | 1.3717 | |
| 24 | .9431 | 1.2003 | 1.0288 |
| Max | 1.6289 | 1.7147 | 1.5432 |
| Min | .8573 | .8573 | .8573 |
| Avg | 1.1431 | 1.286 | 1.1517 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 206 / 11 KV AWHO SECTOR-14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3 | 1.2003 | | 1.286 | 1.2003 | | 1.2003 | 1.2003 |
| 4 | | 1.2003 | | | 1.2003 | | |
| 7 | 1.4575 | | 1.8004 | 2.1434 | 2.1434 | 1.8004 | 1.8861 |
| 9 | 1.4575 | | 2.1434 | 2.4006 | | 2.1434 | 2.0576 |
| 10 | | 2.0576 | | | | | |
| 12 | | | 2.2291 | | | 2.4006 | |
| 13 | | | | 1.8004 | | | 1.9719 |
| 15 | | 1.8861 | 2.0576 | | | 1.8861 | |
| 16 | 1.9719 | | | 1.8861 | | | |
| 17 | | | 1.9719 | | | 1.8861 | 2.2291 |
| 19 | | | | | 2.572 | | |
| 20 | | 2.3148 | 2.572 | 2.4006 | | 2.4006 | |
| 21 | 2.1434 | | | | | | |
| 22 | | | | | | | 2.0576 |
| 23 | | 1.8861 | 1.5432 | | 1.9719 | | |
| 24 | 1.286 | 1.9719 | 1.4575 | 1.3717 | 1.3717 | 1.4575 | 1.5432 |
| Max | 2.1434 | 2.3148 | 2.572 | 2.4006 | 2.572 | 2.4006 | 2.2291 |
| Min | 1.2003 | 1.2003 | 1.286 | 1.2003 | 1.2003 | 1.2003 | 1.2003 |
| Avg | 1.5861 | 1.8861 | 1.8957 | 1.8862 | 1.8519 | 1.8969 | 1.8494 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 207 / VISHWAJYOTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3 | .5144 | | .4287 | .5144 | | .4287 | .4287 |
| 4 | | .5144 | | | .5144 | | |
| 7 | .6859 | | .6859 | .8573 | .8573 | .6859 | .7716 |
| 9 | .7716 | | .8573 | .7716 | | .8573 | .7716 |
| 10 | | .7716 | | | | | |
| 12 | | | .6859 | | | .6859 | |
| 13 | | | | .6001 | | | .6859 |
| 15 | | .6859 | .6001 | | | .5144 | |
| 16 | .5144 | | | .5144 | | | |
| 17 | | | .6859 | | | .6859 | .6859 |
| 19 | | | | | .8573 | | |
| 20 | | .7716 | .8573 | .7716 | | .8573 | |
| 21 | .6859 | | | | | | |
| 22 | | | | | | | .6859 |
| 23 | | .6859 | .6001 | | .6859 | | |
| 24 | .4801 | .6859 | .6001 | .5144 | .6001 | .6001 | .5144 |
| Max | .7716 | .7716 | .8573 | .8573 | .8573 | .8573 | .7716 |
| Min | .4801 | .5144 | .4287 | .5144 | .5144 | .4287 | .4287 |
| Avg | .6087 | .6859 | .6668 | .6491 | .703 | .6644 | .6491 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 208 / 11 KV JALVAYU SECTOR-20

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3 | .6859 | | .6859 | .6859 | | .6859 | .6859 |
| 4 | | .6859 | | | .6859 | | |
| 7 | .8573 | | 1.0288 | 1.3717 | 1.2003 | 1.0288 | 1.0288 |
| 9 | 1.2003 | | 1.2003 | 1.2003 | | 1.286 | 1.2003 |
| 10 | | 1.1145 | | | | | |
| 12 | | | 1.0288 | | | 1.0288 | |
| 13 | | | | .8573 | | | 1.2003 |
| 15 | | .9431 | .7716 | | | .8573 | |
| 16 | .9431 | | | .8573 | | | |
| 17 | | | .9945 | | | .9431 | 1.0288 |
| 19 | | | | | 1.2003 | | |
| 20 | | 1.3717 | 1.2003 | 1.286 | | 1.2003 | |
| 21 | 1.2003 | | | | | | |
| 22 | | | | | | | 1.2003 |
| 23 | | 1.0288 | .9431 | | 1.0288 | | |
| 24 | .7716 | 1.0288 | .6001 | .7716 | .7716 | .8573 | .8573 |
| Max | 1.2003 | 1.3717 | 1.2003 | 1.3717 | 1.2003 | 1.286 | 1.2003 |
| Min | .6859 | .6859 | .6001 | .6859 | .6859 | .6859 | .6859 |
| Avg | .9431 | 1.0288 | .9393 | 1.0043 | .9774 | .9859 | 1.0288 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 209 / 11 kV \sector 18

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3 | .5144 | | .4287 | .5144 | | .5144 | .4287 |
| 4 | | .5144 | | | .5144 | | |
| 7 | .6001 | | .7716 | .7716 | .9431 | .7716 | .7716 |
| 9 | .7716 | | .9431 | .9431 | | .9431 | .7716 |
| 10 | | .7716 | | | | | |
| 12 | | | .6859 | | | .6859 | |
| 13 | | | | .6001 | | | .6859 |
| 15 | | .6859 | .5144 | | | .5144 | |
| 16 | .5144 | | | .5144 | | | |
| 17 | | | .6001 | | | .5144 | .6001 |
| 20 | | .8573 | .7716 | .7716 | | .7716 | |
| 21 | .6859 | | | | | | |
| 22 | | | | | | | .6859 |
| 23 | | .6859 | .6859 | | .6859 | | |
| 24 | .5144 | .6859 | .6001 | .5144 | .6001 | .6001 | .5144 |
| Max | .7716 | .8573 | .9431 | .9431 | .9431 | .9431 | .7716 |
| Min | .5144 | .5144 | .4287 | .5144 | .5144 | .5144 | .4287 |
| Avg | .6001 | .7002 | .6668 | .6614 | .6859 | .6644 | .6369 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 210 / 11 kV \ Vastuvihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3 | .2229 | | .1715 | .1715 | | .1715 | .1886 |
| 4 | | .1715 | | | .1715 | | |
| 7 | .2229 | | .1715 | .2743 | .2572 | .1715 | .2743 |
| 9 | .2401 | | .2572 | .2572 | | .2572 | .2572 |
| 10 | | .1715 | | | | | |
| 12 | | | .1886 | | | .1715 | |
| 13 | | | | .1715 | | | .1715 |
| 15 | | .1715 | .1372 | | | .12 | |
| 16 | .1715 | | | .1715 | | | |
| 17 | | | .2058 | | | | .1715 |
| 19 | | | | | .2572 | | |
| 20 | | .2572 | .2401 | .1715 | | .2401 | |
| 21 | .2572 | | | | | | |
| 22 | | | | | | | .2572 |
| 23 | | .2572 | .2401 | | .3429 | | |
| 24 | .2058 | .1715 | .2572 | .2058 | .1715 | .2572 | .2229 |
| Max | .2572 | .2572 | .2572 | .2743 | .3429 | .2572 | .2743 |
| Min | .1715 | .1715 | .1372 | .1715 | .1715 | .12 | .1715 |
| Avg | .2201 | .2001 | .2077 | .2033 | .2401 | .1984 | .2205 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 212 / Sector-30 Owe village

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 3 | .2572 | | .1715 | .5144 | | .4287 | .6859 |
| 4 | | .1715 | | | .4287 | | |
| 7 | .2229 | | .1715 | .3086 | .3429 | .2572 | .3429 |
| 9 | .1543 | | .1715 | .1543 | | .3429 | .3429 |
| 10 | | .5144 | | | | | |
| 12 | | | .6859 | | | .6859 | |
| 13 | | | | .3429 | | | .5144 |
| 15 | | .6001 | .6859 | | | .5144 | |
| 16 | .1715 | | | .3429 | | | |
| 17 | | | .5144 | | | .5144 | .4287 |
| 19 | | | | | .8573 | | |
| 20 | | .7716 | .8573 | .6859 | | 1.0288 | |
| 21 | .2572 | | | | | | |
| 22 | | | | | | | .9431 |
| 23 | | .6859 | .6859 | | .7716 | | |
| 24 | .6516 | .6859 | | .6859 | .6001 | .7716 | .8573 |
| Max | .6516 | .7716 | .8573 | .6859 | .8573 | 1.0288 | .9431 |
| Min | .1543 | .1715 | .1715 | .1543 | .3429 | .2572 | .3429 |
| Avg | .2858 | .5716 | .4930 | .4336 | .6001 | .5680 | .5879 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 241 / 11kV incomer-

SHEDDABLE URBAN

1(10/12.5MVATr Feeder KV- 11

/ INCOMING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6004 | 1.6575 | 1.6575 | .5335 | .5525 | .5716 | .5906 |
| 2 | 1.467 | 1.5242 | 1.5432 | .5144 | .5144 | .5144 | .5525 |
| 3 | 1.4289 | 1.4861 | 1.4861 | .4954 | .4954 | .5144 | .5525 |
| 4 | 1.3908 | 1.467 | 1.467 | .4954 | .4954 | .4954 | .5335 |
| 5 | 1.3908 | 1.5242 | 1.5051 | .5144 | .4954 | .5144 | .5335 |
| 6 | 1.5051 | 1.9243 | 1.9243 | .6478 | .6859 | .6859 | .6287 |
| 7 | 1.6956 | 2.5911 | 2.5911 | 1.0479 | 1.0479 | 1.0288 | .8192 |
| 8 | 2.1148 | 2.8006 | 2.8006 | 1.086 | 1.105 | 1.086 | .9145 |
| 9 | 2.5149 | 2.7435 | 2.7244 | 1.086 | 1.0288 | 1.086 | 1.0479 |
| 10 | 2.7435 | 2.572 | 2.5911 | .9717 | .9526 | 1.0479 | 1.105 |
| 11 | 2.7435 | 2.5339 | 2.4577 | .9717 | .9335 | .9526 | 1.0098 |
| 12 | 2.5911 | 2.3243 | 2.3053 | .8383 | .8573 | .9145 | .9526 |
| 13 | 2.3815 | 2.1719 | 2.0767 | .8002 | .8002 | .8192 | .8954 |
| 14 | 2.2291 | 2.0195 | 1.9624 | .7621 | .7621 | .743 | .8002 |
| 15 | 2.0386 | 1.8671 | 1.7718 | .6668 | .6859 | .6668 | .724 |
| 16 | 1.8671 | 1.7528 | 1.6956 | .6287 | .6478 | .6478 | .7049 |
| 17 | 1.9433 | 1.9052 | .6668 | .6859 | .6859 | .6478 | .724 |
| 18 | 2.21 | 2.191 | .7621 | .743 | .7811 | .7811 | .8192 |
| 19 | 2.7816 | 2.7625 | .8764 | .8954 | .9335 | .8764 | .9526 |
| 20 | 2.7625 | 2.8197 | .9145 | .9145 | .9335 | .8954 | .9526 |
| 21 | 2.7435 | 2.7625 | .8954 | .8954 | .8954 | .8383 | .9335 |
| 22 | 2.6101 | 2.6673 | .8383 | .8573 | .8764 | .8383 | .8764 |
| 23 | 2.2291 | 2.2672 | .743 | .743 | .7621 | .7621 | .7811 |
| 24 | 1.9433 | 1.9243 | .6287 | .6287 | .6668 | .6859 | .6859 |
| Max | 2.7816 | 2.8197 | 2.8006 | 1.086 | 1.105 | 1.086 | 1.105 |
| Min | 1.3908 | 1.467 | .6287 | .4954 | .4954 | .4954 | .5335 |
| Avg | 2.1219 | 2.1775 | 1.6202 | .7676 | .7748 | .7756 | .7954 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 202 / 11 KV CIDCO S/STN SEC-10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .7468 | | | .7842 | |
| 2 | | | .7095 | | | .7468 | |
| 3 | | | .7095 | | | .7095 | .6722 |
| 4 | | | .7468 | | | .7095 | |
| 5 | | | .7842 | | | .6908 | |
| 6 | | .8215 | 1.0082 | | .7095 | .7655 | |
| 7 | | | 1.1203 | | | 1.2323 | |
| 8 | .7468 | | 1.1203 | 1.0456 | | 1.251 | .9522 |
| 9 | .9149 | | .9896 | | .9896 | 1.0456 | 1.1203 |
| 10 | .9335 | .9335 | | .9709 | .9709 | | 1.0829 |
| 11 | .9335 | .8962 | .8029 | .8962 | .9335 | .8775 | 1.0269 |
| 12 | .9335 | .8402 | .7842 | .8402 | .8402 | | .9896 |
| 13 | .9522 | .7468 | | .7842 | .7842 | .8402 | .9522 |
| 14 | .9335 | .7095 | .7282 | .7655 | .7468 | | .8029 |
| 15 | .9335 | .7095 | | | .7095 | .7655 | .8402 |
| 16 | .8962 | .8215 | | | .7282 | | .8029 |
| 17 | .8589 | .8775 | .9149 | .7468 | .7842 | .7655 | 1.0642 |
| 18 | .9709 | .8029 | | .9709 | .9335 | | .9709 |
| 19 | 1.0456 | 1.0456 | 1.0269 | | 1.0082 | 1.0829 | 1.1016 |
| 20 | 1.0082 | 1.0082 | | .9709 | 1.0456 | | 1.0829 |
| 21 | .9709 | 1.0082 | 1.0456 | | 1.0082 | | .9896 |
| 22 | .9522 | .8962 | | .9335 | .9522 | .9149 | .9522 |
| 23 | | .7842 | | | .8589 | | .8962 |
| 24 | .7282 | .8402 | .7468 | .7468 | .7842 | .8215 | .7655 |
| Max | 1.0456 | 1.0456 | 1.1203 | 1.0456 | 1.0456 | 1.251 | 1.1203 |
| Min | .7282 | .7095 | .7095 | .7468 | .7095 | .6908 | .6722 |
| Avg | .9195 | .8589 | .8740 | .8792 | .8698 | .8752 | .9481 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 203 / 11KV CIDCO Sec-2 Kharghar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | 1.5684 | | | 1.5684 | |
| 2 | | | 1.531 | | | 1.4937 | |
| 3 | | | 1.531 | | | 1.419 | 1.4937 |
| 4 | | | 1.4937 | | | 1.3817 | |
| 5 | | | 1.6057 | | | 1.3817 | |
| 6 | | 1.8671 | 1.6804 | | 2.0538 | 1.6057 | |
| 7 | | | 1.9605 | | | 1.9044 | |
| 8 | 1.587 | | 1.7737 | 1.8111 | | 1.8298 | 1.6804 |
| 9 | 1.7737 | | 2.0538 | | 2.0351 | 2.0538 | 2.1658 |
| 10 | 1.8298 | 2.5393 | | 2.1472 | 2.5393 | | 2.7633 |
| 11 | 2.0538 | 2.6886 | 2.4272 | 2.5206 | 2.8193 | 2.7633 | 3.0434 |
| 12 | 2.3339 | 2.782 | 2.782 | 2.7073 | 2.894 | | 3.062 |
| 13 | 2.5579 | 2.7073 | | 2.3525 | 2.782 | 2.6513 | 3.006 |
| 14 | 2.5019 | 2.5953 | 2.5206 | 2.3339 | 2.6139 | | 2.838 |
| 15 | 2.4272 | 2.4646 | | | 2.4459 | 2.2592 | 2.8193 |
| 16 | 2.3339 | 2.3339 | | | 2.2592 | | 2.5579 |
| 17 | 2.2405 | 2.4272 | 2.4086 | 2.3339 | 2.5019 | 2.4832 | 2.5766 |
| 18 | 2.7633 | 2.4832 | | 2.7073 | 2.5579 | | 2.9313 |
| 19 | 3.0434 | 3.0994 | 3.0247 | | 3.062 | 3.0807 | 3.1741 |
| 20 | 3.0247 | 2.8193 | | 2.894 | 3.0247 | | 3.062 |
| 21 | 2.9687 | 2.8753 | 2.6513 | | 2.8753 | | 2.8753 |
| 22 | 2.5766 | 2.4646 | | 2.8006 | 2.4272 | 2.3152 | 2.5393 |
| 23 | | 1.9978 | | | 2.0538 | | 2.1658 |
| 24 | 1.7551 | 2.4272 | 1.6244 | 1.7364 | 2.6139 | 1.9044 | 1.6804 |
| Max | 3.0434 | 3.0994 | 3.0247 | 2.894 | 3.062 | 3.0807 | 3.1741 |
| Min | 1.587 | 1.8671 | 1.4937 | 1.7364 | 2.0351 | 1.3817 | 1.4937 |
| Avg | 2.3607 | 2.5358 | 2.0398 | 2.3950 | 2.5623 | 2.0060 | 2.5797 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 204 / 11 KV Prajapati S/stn Sec- SHEDDABLE URBAN
2 kh Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .8215 | | | .8215 | |
| 2 | | | .7842 | | | .7842 | |
| 3 | | | .7842 | | | .7842 | .7468 |
| 4 | | | .7842 | | | .7468 | |
| 5 | | | .8589 | | | .7468 | |
| 6 | | .9335 | 1.1576 | | 1.1016 | .8775 | |
| 7 | | | 1.307 | | | 1.3443 | |
| 8 | .9709 | | 1.307 | 1.251 | | 1.2136 | .0934 |
| 9 | 1.2136 | | 1.251 | | 1.2883 | 1.3443 | .0934 |
| 10 | 1.1949 | 1.1576 | | 1.2136 | 1.1203 | | .112 |
| 11 | 1.1576 | 1.1576 | 1.1576 | 1.1203 | 1.0642 | 1.1389 | .112 |
| 12 | 1.1203 | .9896 | 1.0082 | .9896 | 1.0082 | | .112 |
| 13 | 1.0082 | .9522 | | .9149 | .9335 | .9149 | .1307 |
| 14 | .9709 | .8962 | .8775 | .8775 | .8589 | | .112 |
| 15 | .9335 | .8402 | | | .7842 | .8029 | .112 |
| 16 | .8962 | .7842 | | | .8029 | | .0934 |
| 17 | .8962 | .8029 | .8775 | .8402 | .8775 | .7655 | .0934 |
| 18 | 1.0829 | .8402 | | .9335 | .9149 | | .1307 |
| 19 | 1.1949 | 1.1949 | 1.1203 | | 1.1576 | 1.1949 | .1307 |
| 20 | 1.1576 | 1.1949 | | 1.1576 | 1.1763 | | .1307 |
| 21 | 1.1576 | 1.1763 | 1.2136 | | 1.1203 | | .1494 |
| 22 | 1.0642 | 1.1016 | | 1.1576 | 1.0829 | 1.0829 | .112 |
| 23 | | .9896 | | | .9709 | | .112 |
| 24 | .8029 | .9522 | .8402 | .7842 | 1.0456 | .8215 | .8589 |
| Max | 1.2136 | 1.1949 | 1.307 | 1.251 | 1.2883 | 1.3443 | .8589 |
| Min | .8029 | .7842 | .7842 | .7842 | .7842 | .7468 | .0934 |
| Avg | 1.0514 | .9977 | 1.0094 | 1.0218 | 1.0181 | .9615 | .1909 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 205 / 11 KV Railway station

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .1307 | | | .1307 | |
| 2 | | | .112 | | | .112 | |
| 3 | | | .112 | | | .112 | .112 |
| 4 | | | .112 | | | .1307 | |
| 5 | | | .1307 | | | .168 | |
| 6 | | .0934 | .112 | | .0747 | .168 | |
| 7 | | | .1307 | | | .1494 | |
| 8 | .0747 | | .056 | .056 | | .0747 | .056 |
| 9 | .0747 | | .1307 | | .0934 | .0934 | .0747 |
| 10 | .0747 | .112 | | .0747 | .0934 | | .0934 |
| 11 | .112 | .1307 | .0747 | .0747 | .0747 | .0747 | .0934 |
| 12 | .112 | .0934 | .0934 | .0747 | .0934 | | .0934 |
| 13 | .112 | .0934 | | .0934 | .0747 | .0934 | .0934 |
| 14 | .112 | .0934 | .112 | .0934 | .0747 | | .0934 |
| 15 | .0934 | .1307 | | | .0747 | .0934 | .056 |
| 16 | .0934 | .0934 | | | .0747 | | .0934 |
| 17 | .0934 | .0934 | .0747 | .0934 | .0747 | .0934 | .0747 |
| 18 | .1494 | .112 | | .112 | .112 | | .0934 |
| 19 | .2054 | .168 | .1867 | | .1867 | .1867 | .168 |
| 20 | .2054 | .2241 | | .2054 | .1867 | | .168 |
| 21 | .2054 | .2054 | .2241 | | .2054 | | .168 |
| 22 | .2054 | .1867 | | .2054 | .2054 | .2054 | .168 |
| 23 | | .1867 | | | .1867 | | .168 |
| 24 | .2054 | .168 | .168 | .168 | .168 | .168 | .1867 |
| Max | .2054 | .2241 | .2241 | .2054 | .2054 | .2054 | .1867 |
| Min | .0747 | .0934 | .056 | .056 | .0747 | .0747 | .056 |
| Avg | .1330 | .1365 | .1225 | .1137 | .1208 | .1284 | .1141 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 206 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | | .0187 | | .0187 |
| 9 | | | | .0187 |
| 10 | .0187 | | .0187 | |
| 11 | .0187 | | .0187 | |
| 12 | .0187 | | .0187 | |
| 13 | .0187 | | .0187 | |
| 14 | .0187 | | .0187 | |
| 15 | .0187 | | | |
| 16 | .0187 | | | |
| 17 | .0187 | | .0187 | |
| 18 | .0187 | | .0187 | |
| 19 | .0187 | | | |
| 20 | .0187 | | .0187 | |
| 21 | .0187 | | | |
| 22 | .0187 | | .0187 | |
| 24 | | .0187 | | .0187 |
| Max | .0187 | .0187 | .0187 | .0187 |
| Min | .0187 | .0187 | .0187 | .0187 |
| Avg | .0187 | .0187 | .0187 | .0187 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 207 / 11 KV Glow Max

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .056 | | | .056 | |
| 2 | | | .0187 | | | .0187 | |
| 3 | | | .0187 | | | .0187 | .0187 |
| 4 | | | .0187 | | | .0187 | |
| 5 | | | .0187 | | | .0187 | |
| 6 | | .056 | .0187 | | .056 | .0187 | |
| 7 | | | .0187 | | | .0187 | |
| 8 | .0187 | | .0187 | .0187 | | .0187 | .0187 |
| 9 | .1494 | | .112 | | .1494 | .112 | .0373 |
| 10 | .168 | .168 | | .1494 | .1867 | | .1867 |
| 11 | .1867 | .2054 | .2054 | .1867 | .2054 | .2054 | .2241 |
| 12 | .2054 | .2054 | .2054 | .2054 | .2054 | | .2054 |
| 13 | .2054 | .2241 | | .1867 | .2054 | .2054 | .1867 |
| 14 | .2241 | .2054 | .1494 | .1867 | .1867 | | .2054 |
| 15 | .2427 | .2054 | | | .1867 | .2054 | .2241 |
| 16 | .2614 | .2054 | | | .2054 | | .2427 |
| 17 | .2801 | .2054 | .2427 | .1867 | .1867 | .2054 | .2241 |
| 18 | .2427 | .2054 | | .2054 | .1867 | | .2054 |
| 19 | .2427 | .2241 | .1494 | | .2241 | .2054 | .2241 |
| 20 | .2427 | .2241 | | .1867 | .1867 | | .2241 |
| 21 | .2241 | .1867 | .168 | | .2054 | | .2054 |
| 22 | .2241 | .1494 | | .1867 | .168 | .168 | .1867 |
| 23 | | .1307 | | | .168 | | .1867 |
| 24 | .168 | .1494 | .168 | .1307 | .112 | .1307 | .112 |
| Max | .2801 | .2241 | .2427 | .2054 | .2241 | .2054 | .2427 |
| Min | .0187 | .056 | .0187 | .0187 | .056 | .0187 | .0187 |
| Avg | .2054 | .1844 | .0992 | .1663 | .1779 | .1015 | .1732 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 208 / 11 KV Balaji Angan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | 1.0082 | | | 1.1203 | |
| 2 | | | .9335 | | | 1.0456 | |
| 3 | | | .8962 | | | 1.0456 | .9709 |
| 4 | | | .8962 | | | 1.0082 | |
| 5 | | | .9335 | | | 1.0082 | |
| 6 | | 1.587 | 1.2696 | | | 1.1203 | |
| 7 | | | 1.5684 | | | 1.6617 | |
| 8 | 1.2883 | | 1.7364 | 1.7924 | | 1.7737 | 1.475 |
| 9 | 1.475 | | 2.1658 | | 2.2405 | 2.0911 | 1.9605 |
| 10 | 1.475 | 2.3339 | | 1.9418 | 2.2405 | | 2.1285 |
| 11 | 1.4937 | 2.1845 | 2.0725 | 1.9044 | 2.2592 | 2.0725 | 2.0911 |
| 12 | 1.531 | 2.0351 | 1.9418 | 1.9044 | 1.9605 | | 1.9978 |
| 13 | 1.475 | 1.9044 | | 1.7551 | 1.9044 | 1.8111 | 1.8858 |
| 14 | 1.4003 | 1.7737 | 1.7364 | 1.7924 | 1.9418 | | 1.643 |
| 15 | 1.307 | 1.8298 | | | 1.9231 | 1.7737 | 1.6991 |
| 16 | 1.2323 | 1.6804 | | | 1.8111 | | 1.6244 |
| 17 | 1.2136 | 1.6057 | 1.6617 | 1.7299 | 1.6617 | 1.531 | 1.4003 |
| 18 | 1.4003 | 1.587 | | 1.6057 | 1.475 | | 1.4003 |
| 19 | 1.6057 | 1.8111 | 1.7551 | | 1.7177 | 1.7551 | 1.7924 |
| 20 | 1.5497 | 1.6991 | | 1.6804 | 1.7551 | | 1.7551 |
| 21 | 1.4937 | 1.6804 | 1.6804 | | 1.6804 | | 1.6057 |
| 22 | 1.475 | 1.5123 | | 1.531 | 1.587 | 1.587 | 1.5123 |
| 23 | | 1.3443 | | | 1.2883 | | 1.363 |
| 24 | .9896 | 1.307 | 1.1203 | 1.0456 | 1.3817 | 1.1949 | 1.1203 |
| Max | 1.6057 | 2.3339 | 2.1658 | 1.9418 | 2.2592 | 2.0911 | 2.1285 |
| Min | .9896 | 1.307 | .8962 | 1.0456 | 1.2883 | 1.0082 | .9709 |
| Avg | 1.4003 | 1.7422 | 1.461 | 1.6985 | 1.8018 | 1.475 | 1.6348 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 209 / 11kV NIFT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6 | | .0187 | | .0187 |
| 9 | | | | .0187 |
| 10 | .0187 | | .0187 | |
| 11 | .0187 | | .0187 | |
| 12 | .0187 | | .0187 | |
| 13 | .0187 | | .0187 | |
| 14 | .0187 | | .0187 | |
| 15 | .0187 | | | |
| 16 | .0187 | | | |
| 17 | .0187 | | .0187 | |
| 18 | .0187 | | .0187 | |
| 19 | .0187 | | | |
| 20 | .8962 | | .0187 | |
| 21 | .0187 | | | |
| 22 | .0187 | | .0187 | |
| 24 | | .0187 | | .0187 |
| Max | .8962 | .0187 | .0187 | .0187 |
| Min | .0187 | .0187 | .0187 | .0187 |
| Avg | .0862 | .0187 | .0187 | .0187 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 210 / 11kV outgoing feeder 10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .6161 | | | .6348 | |
| 2 | | | .5975 | | | .6161 | |
| 3 | | | .5975 | | | .5788 | .5601 |
| 4 | | | .5975 | | | .5975 | |
| 5 | | | .6722 | | | .5788 | |
| 6 | | .7468 | .8215 | | .6722 | .7282 | |
| 7 | | | .9522 | | | .9335 | |
| 8 | .7842 | | .9709 | .9335 | | 1.0829 | .8589 |
| 9 | .8215 | | .9522 | | .8029 | .8402 | .8215 |
| 10 | .8402 | .7468 | | .7842 | .8215 | | .9335 |
| 11 | .8402 | .7468 | .7655 | .7468 | .8029 | .8029 | .8775 |
| 12 | .8402 | .7468 | .7842 | .6722 | .6908 | | .8402 |
| 13 | .8402 | .7095 | | .6535 | .6535 | .7655 | .7095 |
| 14 | .8215 | .6348 | .6161 | .6348 | .6535 | | .7095 |
| 15 | .7842 | .5415 | | | .5975 | .5601 | .6722 |
| 16 | .7468 | .6348 | | | .6908 | | .6535 |
| 17 | .7095 | .6161 | .6161 | .6161 | .6348 | .6535 | .6722 |
| 18 | .8029 | .8029 | | .7468 | .6722 | | .7468 |
| 19 | .9335 | .8402 | .9149 | | .8215 | .8402 | .8962 |
| 20 | | .8589 | | .8589 | .8962 | | .8775 |
| 21 | .8775 | .8589 | .8589 | | .8962 | | .8402 |
| 22 | .8029 | .8402 | | .7468 | .8029 | .7842 | .8589 |
| 23 | | .7095 | | | .7095 | | .7468 |
| 24 | .5975 | .7095 | .6348 | .6348 | .6535 | .6722 | .6535 |
| Max | .9335 | .8589 | .9709 | .9335 | .8962 | 1.0829 | .9335 |
| Min | .5975 | .5415 | .5975 | .6161 | .5975 | .5601 | .5601 |
| Avg | .8029 | .734 | .7480 | .7299 | .7337 | .7293 | .7738 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 211 / 11 KV S N Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .5601 | | | .5975 | |
| 2 | | | .5601 | | | .5601 | |
| 3 | | | .5601 | | | .5415 | .5228 |
| 4 | | | .5975 | | | | |
| 5 | | | .6348 | | | .5228 | |
| 6 | | .7468 | .8215 | | .8962 | .6535 | |
| 7 | | | .8962 | | | .8962 | |
| 8 | .7468 | | 1.0642 | 1.1203 | | 1.1016 | .6161 |
| 9 | .8589 | | 1.0829 | | 1.0829 | 1.0456 | 1.1203 |
| 10 | .8215 | .8589 | | 1.0082 | .9709 | | .9896 |
| 11 | .7842 | .7468 | .8962 | .9335 | .9149 | .8775 | .9709 |
| 12 | .7095 | .7468 | .8029 | .7842 | .8589 | | .8775 |
| 13 | .6535 | .7842 | | .8589 | .7842 | .8589 | .8029 |
| 14 | .6348 | .6908 | .6722 | .8215 | .8029 | | .7468 |
| 15 | .5975 | .7095 | | | .7282 | .6908 | .7282 |
| 16 | .5975 | .6348 | | | .8215 | | .7095 |
| 17 | .6161 | .6348 | .5788 | .6908 | .7282 | .6722 | .7282 |
| 18 | .7655 | .7282 | | .7095 | .8215 | | .7282 |
| 19 | .8402 | .8029 | .8589 | | .9896 | .8589 | .8589 |
| 20 | .8215 | .8962 | | .8589 | .8962 | | .8589 |
| 21 | .7655 | .9149 | .8402 | | .8775 | | .7655 |
| 22 | .7842 | .7655 | | .8589 | .8029 | .7655 | .8029 |
| 23 | | .7282 | | | .7655 | | .8775 |
| 24 | .5415 | | .5975 | .5975 | .7842 | .7095 | .5975 |
| Max | .8589 | .9149 | 1.0829 | 1.1203 | 1.0829 | 1.1016 | 1.1203 |
| Min | .5415 | .6348 | .5601 | .5975 | .7282 | .5228 | .5228 |
| Avg | .7212 | .7593 | .7515 | .8402 | .8545 | .7568 | .7946 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 213 / 11kV BPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .0187 | | | .0187 | |
| 2 | | | .0187 | | | .0187 | |
| 3 | | | .0187 | | | .0187 | .0187 |
| 4 | | | .0187 | | | .0187 | |
| 5 | | | .0187 | | | .0187 | |
| 6 | | .0187 | .0187 | | .0187 | .0187 | |
| 7 | | | .0187 | | | .0187 | |
| 8 | .0187 | | .112 | .2225 | .1105 | .245 | .0373 |
| 9 | .0373 | | .1307 | .1181 | .2751 | .3025 | .0747 |
| 10 | .0373 | .1494 | | .2679 | .298 | .1638 | .056 |
| 11 | .0373 | .1867 | .1494 | .298 | .3209 | .3022 | .0373 |
| 12 | .0373 | .1867 | .1494 | .3056 | .2869 | .1677 | .056 |
| 13 | .0373 | .1867 | | .3171 | .3544 | .3772 | .056 |
| 14 | .0373 | .1867 | .168 | .3132 | .3433 | .1905 | .0747 |
| 15 | .0373 | .2054 | | .1753 | .3772 | .3696 | .056 |
| 16 | .0373 | .2054 | | .1829 | .381 | | .0747 |
| 17 | .0373 | .168 | .1494 | .3209 | .3285 | .168 | .056 |
| 18 | .0373 | .1307 | | *** | .2869 | | .056 |
| 19 | .0187 | .0747 | .056 | .1067 | .1703 | .0747 | .0373 |
| 20 | .0373 | .056 | | .0411 | .056 | | .0373 |
| 21 | .0373 | .0373 | .0373 | | .0411 | | .0373 |
| 22 | .0373 | .0373 | | .0373 | .0373 | .0187 | .0373 |
| 23 | | .0187 | | | .0373 | | .0373 |
| 24 | .0373 | .0187 | .0187 | .0373 | .0187 | .0187 | .0373 |
| Max | .0373 | .2054 | .168 | 178.4155 | .381 | .3772 | .0747 |
| Min | .0187 | .0187 | .0187 | .0373 | .0187 | .0187 | .0187 |
| Avg | .0350 | .1167 | .0689 | 12.0773 | .2079 | .1331 | .0487 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 201 / plot no 51 sec-30 feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 11 | | | 1.5432 |
| 16 | | 1.2174 | |
| 24 | 1.406 | | |
| Max | 1.406 | 1.2174 | 1.5432 |
| Min | 1.406 | 1.2174 | 1.5432 |
| Avg | 1.406 | 1.2174 | 1.5432 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 202 / mass housing s/s no-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 204 / sec-34A feeder prop.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 11 | | | .5639 |
| 16 | | .4287 | |
| 24 | .463 | | |
| Max | .463 | .4287 | .5639 |
| Min | .463 | .4287 | .5639 |
| Avg | .463 | .4287 | .5639 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 205 / pl no.42 & 43, sec-35D SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 206 / PLOT NO 53 & 54 STATUS SHEDDABLE URBAN
VIHAR S Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 11 | | | .4115 |
| 16 | | .3048 | |
| 24 | .3086 | | |
| Max | .3086 | .3048 | .4115 |
| Min | .3086 | .3048 | .4115 |
| Avg | .3086 | .3048 | .4115 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 207 / MASS HOUSING S/S NO.3 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 16 | | .0457 |
| 24 | .0514 | |
| Max | .0514 | .0457 |
| Min | .0514 | .0457 |
| Avg | .0514 | .0457 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 210 / MASS HOUSING S/S NO.4 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 16 | | .0457 |
| 24 | .0686 | |
| Max | .0686 | .0457 |
| Min | .0686 | .0457 |
| Avg | .0686 | .0457 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 211 / MASS HOUSING S/S NO.2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 24 | .0343 |
| Max | .0343 |
| Min | .0343 |
| Avg | .0343 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 212 / arihant abhilasha pl no-10 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 | 17-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 16 | | .703 |
| 24 | .8402 | |
| Max | .8402 | .703 |
| Min | .8402 | .703 |
| Avg | .8402 | .703 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 405 / 33KV SECTOR-19

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

| DATE | 15-JAN-17 | 16-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 17.284 | 16.941 |
| 2 | 15.3635 | 15.8436 |
| 3 | 14.8148 | 15.3635 |
| 4 | 14.4719 | 15.0206 |
| 5 | 14.1976 | 15.3635 |
| 6 | 14.8148 | 18.3814 |
| 7 | 17.1468 | 25.3087 |
| 8 | 20.5076 | 28.0522 |
| 9 | 23.7312 | 26.5432 |
| 10 | 26.749 | 25.7888 |
| 11 | 27.6406 | 25.7888 |
| 12 | 27.0919 | 25.3773 |
| 13 | 26.2003 | 24.2799 |
| 14 | 24.0055 | 21.8793 |
| 15 | 21.1934 | 20.0275 |
| 16 | 19.4788 | 19.9589 |
| 17 | 20.9191 | 21.3992 |
| 18 | 23.3196 | 22.9081 |
| 19 | 28.6009 | 27.7778 |
| 20 | 28.6694 | 29.2181 |
| 21 | 26.8862 | 28.8752 |
| 22 | 26.6118 | 27.7092 |
| 23 | 22.9767 | 24.76 |
| 24 | 19.5474 | 20.9877 |
| Max | 28.6694 | 29.2181 |
| Min | 14.1976 | 15.0206 |
| Avg | 21.7593 | 22.6481 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 304 / 22KV GAVAN

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 10.1814 | 6.8892 | 12.1323 | 13.5955 | 13.0468 | 11.858 | 12.4676 |
| 2 | 9.6327 | 6.6149 | 11.6141 | 13.4431 | 11.6141 | 12.3152 | 12.7115 |
| 3 | 10.5167 | 6.6758 | 11.1569 | 12.6505 | 11.3702 | 11.5226 | 10.5777 |
| 4 | 10.4557 | 6.7673 | 11.7665 | 11.3093 | 10.2424 | 11.9494 | 8.9011 |
| 5 | 11.0349 | 7.6513 | 12.0104 | 12.1933 | 9.6632 | 11.6141 | 9.907 |
| 6 | 10.2728 | 10.2424 | 11.5836 | 12.0104 | 11.736 | 11.6446 | 10.3948 |
| 7 | 8.9621 | 10.1204 | 10.3643 | 9.968 | 10.2424 | 9.4803 | 9.9375 |
| 8 | 8.6877 | 9.2364 | 12.0713 | 11.6751 | 12.681 | 10.3338 | 8.8096 |
| 9 | 7.7122 | 12.3762 | 12.0409 | 13.9003 | 15.0282 | 13.1078 | 10.1814 |
| 10 | 7.4074 | 12.4676 | 14.1137 | 14.1137 | 12.9249 | 13.5345 | 12.8029 |
| 11 | 5.5479 | 15.4855 | 15.9732 | 14.2966 | 14.7234 | 10.7301 | 12.8944 |
| 12 | 4.8468 | 15.5769 | | 14.7844 | 13.565 | 14.4186 | 12.1018 |
| 13 | 5.7918 | | | 13.4431 | 13.0163 | 9.3888 | 12.1018 |
| 14 | 5.5784 | | | 10.029 | 10.3033 | 7.6513 | 11.2788 |
| 15 | 6.9502 | | | 13.5041 | 14.3271 | 15.455 | 14.2357 |
| 16 | 5.9747 | | | 17.4974 | 13.8394 | 15.8513 | 10.3338 |
| 17 | 6.8587 | .1524 | 14.6624 | 15.6684 | 14.7539 | 15.1197 | 15.6988 |
| 18 | 7.0721 | 17.0706 | 18.107 | 13.1383 | 15.1197 | 14.6319 | 15.8513 |
| 19 | 7.6208 | 16.7048 | 17.2535 | 12.8334 | 12.6505 | 13.8089 | 13.0163 |
| 20 | 7.5294 | 13.8699 | 15.6379 | 11.736 | 10.1509 | 11.5836 | 12.4371 |
| 21 | 7.4074 | 15.2111 | 14.2966 | 10.7911 | 12.2847 | 11.6751 | 13.3212 |
| 22 | 7.1026 | 12.7725 | 12.62 | 11.797 | 10.4862 | 11.4007 | 13.9308 |
| 23 | 6.8892 | 14.4795 | 13.1992 | 11.0959 | 10.2424 | 10.9435 | 13.4736 |
| 24 | 6.8587 | 14.4795 | 14.6015 | 12.4676 | 11.8275 | 14.3271 | 12.4981 |
| Max | 11.0349 | 17.0706 | 18.107 | 17.4974 | 15.1197 | 15.8513 | 15.8513 |
| Min | 4.8468 | .1524 | 10.3643 | 9.968 | 9.6632 | 7.6513 | 8.8096 |
| Avg | 7.7872 | 11.2422 | 13.4319 | 12.8309 | 12.3266 | 12.2644 | 12.0777 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 309 / 22kv omayya
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.5301 | 2.5301 | 2.5911 |
| 2 | 2.5301 | 2.5149 | 2.5606 |
| 3 | 2.5149 | 2.5149 | |
| 4 | 2.5149 | 2.4996 | |
| 5 | 2.5453 | 2.5149 | |
| 6 | 2.5301 | 2.5301 | |
| 7 | 2.5758 | 2.5911 | |
| 8 | 2.6063 | 2.6063 | |
| 9 | 2.6368 | 2.6063 | |
| 10 | 2.9874 | 3.0178 | |
| 11 | 3.0178 | 3.0483 | |
| 12 | 3.0483 | 3.0483 | |
| 13 | 2.9874 | 3.0178 | |
| 14 | 2.5758 | 2.5911 | |
| 15 | 2.5911 | 2.5911 | |
| 16 | 2.5911 | 3.0178 | |
| 17 | 2.5911 | 3.0178 | |
| 18 | 2.5911 | 3.0026 | |
| 19 | 2.6063 | 3.0331 | |
| 20 | 2.5911 | 2.7282 | |
| 21 | 2.5758 | 2.652 | |
| 22 | 2.5758 | 2.5911 | |
| 23 | 2.5301 | 2.6063 | |
| 24 | 2.6063 | 2.6063 | |
| Max | 3.0483 | 3.0483 | 2.5911 |
| Min | 2.5149 | 2.4996 | 2.5606 |
| Avg | 2.6438 | 2.7282 | 2.5759 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 311 / 22KV Bombay Bear

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 17-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 2.3777 |
| 2 | 2.3472 |
| 3 | 2.4082 |
| 4 | 2.3396 |
| 5 | 2.3396 |
| 6 | 2.332 |
| 7 | 2.4539 |
| 8 | 2.4768 |
| 9 | 2.492 |
| 10 | 2.6063 |
| 11 | 2.5072 |
| 12 | 2.7054 |
| 13 | 2.6597 |
| 14 | 2.5682 |
| 15 | 2.6063 |
| 16 | 2.6368 |
| 17 | 2.5911 |
| 18 | 2.652 |
| 19 | 2.6673 |
| 20 | 2.5377 |
| 21 | 2.6216 |
| 22 | 2.4996 |
| 23 | 2.431 |
| 24 | 2.3396 |
| Max | 2.7054 |
| Min | 2.332 |
| Avg | 2.5082 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 310 / 22 KV PANVEL-III

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.7984 | 2.3167 | 2.2436 | 2.1704 | 2.2954 | 2.2862 | 2.3137 |
| 2 | 2.5149 | 2.1948 | 2.1735 | 2.0851 | 2.2253 | 2.1856 | 2.2314 |
| 3 | 2.4143 | 2.21 | 2.082 | 2.0393 | 2.2558 | 2.1795 | 2.1856 |
| 4 | 2.3929 | 2.1369 | 2.1094 | 2.0393 | 2.2131 | 2.1552 | 2.1643 |
| 5 | 2.46 | 2.2893 | 2.1795 | 2.1125 | 2.3045 | 2.2466 | 2.2192 |
| 6 | 2.5636 | 2.8136 | 2.5911 | 2.5972 | 2.6886 | 2.6337 | 2.4722 |
| 7 | 2.6185 | 3.0026 | 2.7343 | 2.7831 | 2.841 | 2.8471 | 2.5453 |
| 8 | 3.0453 | 3.0758 | 2.8288 | 3.1428 | 3.0879 | 3.091 | 2.838 |
| 9 | 4.0726 | 3.3745 | 2.8837 | 3.3806 | 3.3532 | 3.3227 | 3.53 |
| 10 | 4.6152 | 4.0085 | 3.1062 | 3.5239 | 3.9049 | 3.6123 | 3.7921 |
| 11 | 5.4778 | 4.1274 | 3.1916 | 3.7007 | 4.0512 | 3.9781 | 3.9293 |
| 12 | 5.5022 | 4.0787 | | 3.7311 | 3.8927 | 3.783 | 3.9842 |
| 13 | 4.3743 | 3.6671 | | 3.5239 | 3.5086 | 3.2861 | 3.7647 |
| 14 | 3.3745 | 3.3867 | | 3.6123 | 3.3135 | 3.2891 | 4.0055 |
| 15 | 3.53 | 3.7799 | 2.1917 | 3.8653 | 3.6824 | 3.3653 | 3.9354 |
| 16 | 3.4111 | 3.6854 | 3.2739 | 3.725 | 3.7952 | 3.3653 | 3.9811 |
| 17 | 3.533 | 3.6885 | 3.1703 | 3.7342 | 3.597 | 3.2678 | 3.722 |
| 18 | 3.5452 | 3.722 | 3.3196 | 3.8439 | 3.7281 | 3.4873 | 3.8287 |
| 19 | 3.9262 | 4.1213 | 3.5879 | 4.1274 | 4.1366 | 3.9659 | 4.1762 |
| 20 | 3.5391 | 3.6671 | 3.4111 | 3.6153 | 3.6946 | 3.7403 | 3.9628 |
| 21 | 3.3958 | 3.3166 | 3.1337 | 3.472 | 3.3532 | 3.2495 | 3.5635 |
| 22 | 3.2465 | 3.0117 | 2.7923 | 3.0849 | 3.1763 | 3.1703 | 3.4202 |
| 23 | 2.8624 | 2.8776 | 2.6703 | 2.9782 | 3.0727 | 2.8014 | 3.0422 |
| 24 | 2.5057 | 2.4387 | 2.3685 | 2.4752 | 2.5545 | 2.6856 | 2.8197 |
| Max | 5.5022 | 4.1274 | 3.5879 | 4.1274 | 4.1366 | 3.9781 | 4.1762 |
| Min | 2.3929 | 2.1369 | 2.082 | 2.0393 | 2.2131 | 2.1552 | 2.1643 |
| Avg | 3.4050 | 3.2080 | 2.7640 | 3.1402 | 3.1969 | 3.0831 | 3.2678 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 206 / 11kv sect-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 18 | 1.1462 |
| 19 | 1.2536 |
| 24 | 1.1706 |
| Max | 1.2536 |
| Min | 1.1462 |
| Avg | 1.1901 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 207 / 11KV SECT-5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 17 | 1.829 |
| 18 | 1.97 |
| 19 | 2.0953 |
| 24 | 2.0237 |
| Max | 2.0953 |
| Min | 1.829 |
| Avg | 1.9795 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 208 / 11kv mpk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 17 | .8871 |
| 18 | 1.1088 |
| 19 | 1.2752 |
| 24 | 1.0534 |
| Max | 1.2752 |
| Min | .8871 |
| Avg | 1.0811 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 209 / 11 KV ESRGSR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 18 | .4435 |
| 19 | .4805 |
| 24 | .3658 |
| Max | .4805 |
| Min | .3658 |
| Avg | .4299 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 201 / 11KV KALPATARU KRISHNA-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1097 | .0939 | .1061 | .1259 | .0619 | .1 | .1221 |
| 2 | .0581 | .0596 | .0604 | .0377 | .0574 | .0642 | .0688 |
| 3 | .0566 | .0574 | .0574 | .0377 | .0566 | .0566 | .0407 |
| 4 | .0566 | .0566 | .0754 | .0566 | .0566 | .0566 | .0407 |
| 5 | .0566 | .0943 | .1262 | .0566 | .0581 | .0754 | .0566 |
| 6 | .0665 | .1978 | .2074 | .188 | .2146 | .2039 | .1554 |
| 7 | .1577 | .3062 | .2949 | .3161 | .3094 | .3237 | .257 |
| 8 | .2654 | .3786 | .3702 | .4066 | .3862 | .3786 | .3578 |
| 9 | .3125 | .3756 | .3544 | .3513 | .3719 | .3589 | .4073 |
| 10 | .3187 | .237 | .2991 | .2778 | .2885 | .2882 | .3262 |
| 11 | .2981 | .2246 | .2292 | .2277 | .2322 | .2776 | .2936 |
| 12 | .2928 | .1851 | .1935 | .2132 | .1836 | .2527 | .2623 |
| 13 | .2511 | .1519 | .1821 | .2056 | .1714 | .201 | .2351 |
| 14 | .2185 | .1298 | .1684 | .176 | .1625 | .1729 | .1964 |
| 15 | .2109 | .1061 | .16 | .1166 | .1435 | .1577 | .1572 |
| 16 | .1964 | .0718 | .1394 | .1287 | .1442 | .1181 | .1473 |
| 17 | .1804 | .068 | .1371 | .1463 | .1298 | .1614 | .1661 |
| 18 | .1941 | .1242 | .1896 | .2153 | .1911 | .1979 | .1783 |
| 19 | .2359 | .2086 | .2185 | .2593 | .2458 | .2405 | .2593 |
| 20 | .2593 | .2101 | .2458 | .2745 | .2473 | .2496 | .2677 |
| 21 | .2489 | .2208 | .2661 | .2843 | .2511 | .1357 | .233 |
| 22 | .2117 | .2147 | .2254 | .2178 | .2103 | .2231 | .2223 |
| 23 | .179 | .1821 | .1752 | .1691 | .1557 | .1806 | .1859 |
| 24 | .1653 | .1638 | .1397 | .1298 | .1592 | .1435 | .1661 |
| Max | .3187 | .3786 | .3702 | .4066 | .3862 | .3786 | .4073 |
| Min | .0566 | .0566 | .0574 | .0377 | .0566 | .0566 | .0407 |
| Avg | .1917 | .1716 | .1926 | .1924 | .1870 | .1924 | .2001 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 202 / 11KV KALPATARU NARMADA-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0566 | .0566 | .0566 | .0566 | .0566 | .0377 | .0566 |
| 2 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 |
| 3 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 |
| 4 | .0377 | .0377 | .0377 | .0566 | .0377 | .0566 | .0377 |
| 5 | .0377 | .0566 | .0566 | .0566 | .0566 | .0566 | .0566 |
| 6 | .0566 | .0754 | .0566 | .1132 | .0754 | .0754 | .0754 |
| 7 | .0566 | .0943 | .0754 | .1132 | .1132 | .0943 | .0943 |
| 8 | .0943 | .0943 | .0943 | .0943 | .1132 | .0754 | .1132 |
| 9 | .0943 | .0943 | .0943 | .0943 | .132 | .0943 | .1132 |
| 10 | .0943 | .1132 | .1132 | .0943 | .132 | .1132 | .0943 |
| 11 | .1132 | .0943 | .0943 | .0943 | .1132 | .0943 | .0754 |
| 12 | .0943 | .0943 | .0566 | .0754 | .0566 | .0943 | .0754 |
| 13 | .0943 | .0566 | .0566 | .0754 | | .0754 | .0754 |
| 14 | .0754 | .0377 | .0566 | .0754 | .0566 | .0754 | .0943 |
| 15 | .0754 | .0566 | .0566 | .0566 | .0566 | .0566 | .0701 |
| 16 | .0566 | .0754 | .0566 | .0754 | .0566 | .0754 | .0566 |
| 17 | .0754 | .0943 | .0754 | .0943 | .0566 | .0943 | .0754 |
| 18 | .0943 | .0943 | .0566 | .0943 | .0754 | .0943 | .0754 |
| 19 | .0943 | .0754 | .0754 | .0943 | .0754 | .0754 | .132 |
| 20 | .0754 | .0754 | .0754 | .0943 | .0754 | .0754 | .0754 |
| 21 | .0754 | .0566 | .0754 | .0754 | .0754 | .0754 | .0566 |
| 22 | .0754 | .0754 | .0754 | .0754 | .0754 | .0754 | .0754 |
| 23 | .0754 | .0566 | .0566 | .0566 | .0754 | .0754 | .0754 |
| 24 | .0566 | .0566 | .0566 | | .0566 | .0566 | .0754 |
| Max | .1132 | .1132 | .1132 | .1132 | .132 | .1132 | .132 |
| Min | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 | .0377 |
| Avg | .0723 | .0707 | .0660 | .0779 | .0738 | .0739 | .0752 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 203 / 11 KV KALPATARU KAVERI-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0526 | .0716 | .0526 | .0526 | .0526 | .0526 | .0526 |
| 2 | .0351 | .0526 | .0526 | .0351 | .0351 | .0351 | .0526 |
| 3 | .0351 | .0534 | .0526 | .0351 | .0351 | .0351 | .0351 |
| 4 | .0351 | .0526 | .0701 | .0526 | .0526 | .0526 | .0351 |
| 5 | .058 | .0701 | .1067 | .0526 | .0526 | .0701 | .0526 |
| 6 | .0617 | .1341 | .1898 | .1052 | .0701 | .0876 | .0701 |
| 7 | .1692 | .2713 | .317 | .0876 | .1052 | .1052 | .0876 |
| 8 | .173 | .2203 | .2202 | .0876 | .1052 | .1052 | .1052 |
| 9 | .2469 | .2317 | .2865 | .0876 | .1227 | .0876 | .1052 |
| 10 | .2957 | .1791 | .208 | .0876 | .1052 | .1052 | .1052 |
| 11 | .2576 | .2187 | .1912 | .0876 | .0876 | .1052 | .1227 |
| 12 | .282 | .2416 | .1052 | .1052 | .0876 | .0876 | .1227 |
| 13 | .2264 | .2073 | .0754 | .0876 | | .0876 | .1052 |
| 14 | .2072 | .1501 | .0701 | .0876 | .0876 | .0701 | .0701 |
| 15 | .1905 | .1699 | .0876 | .0701 | .0701 | .0701 | .0701 |
| 16 | .1745 | .1547 | .0701 | .0876 | .0701 | .0701 | .0701 |
| 17 | .2111 | .1707 | .0701 | .1052 | .0701 | .0943 | .0701 |
| 18 | .1646 | .0976 | .0701 | .0876 | .0701 | .0876 | .0876 |
| 19 | .1882 | .1387 | .0701 | .0876 | .0876 | .0943 | .0876 |
| 20 | .1928 | .1699 | .0701 | .0876 | .0701 | .1052 | .0701 |
| 21 | .2088 | .1905 | .0701 | .0876 | .0701 | .0876 | .0876 |
| 22 | .1951 | .1692 | .0701 | .0754 | .0701 | .0876 | .0701 |
| 23 | .1501 | .1798 | .0526 | .0701 | .0701 | .0701 | .0701 |
| 24 | .0853 | .1463 | .0526 | | .1052 | .0526 | .0701 |
| Max | .2957 | .2713 | .317 | .1052 | .1227 | .1052 | .1227 |
| Min | .0351 | .0526 | .0526 | .0351 | .0351 | .0351 | .0351 |
| Avg | .1624 | .1559 | .1117 | .0787 | .0762 | .0794 | .0781 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 204 / 11 KV KALPATARU SUBSTATION SHEDDABLE URBAN
TRA Feeder KV- 11 / OUTGOING

| DATE | 18-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 2 | .0244 |
| Max | .0244 |
| Min | .0244 |
| Avg | .0244 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 205 / 11 KV KALPATARU INCOMING-1 SHEDDABLE RURAL
Feeder KV- 11 / INCOMING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1768 | .1875 | .1844 | .1844 | .1829 | .1859 | .2012 |
| 2 | .1646 | .1722 | .1722 | .1661 | .1738 | .1814 | .1799 |
| 3 | .1524 | .1661 | .1661 | .16 | .1661 | .1677 | .1722 |
| 4 | .1189 | .1646 | .1646 | .1555 | .1616 | .1616 | .1722 |
| 5 | .1326 | .1677 | .1753 | .1661 | .1722 | .1768 | .1616 |
| 6 | .1859 | .2378 | .2698 | .2835 | .2576 | .2622 | .2286 |
| 7 | .221 | .381 | .3902 | .3841 | .4207 | .3688 | .3109 |
| 8 | .3506 | .4268 | .439 | .442 | .442 | .4298 | .3734 |
| 9 | .4146 | .4618 | .4649 | .4603 | .4649 | .471 | .4466 |
| 10 | .4313 | .3597 | .4054 | .3765 | .381 | .378 | .3963 |
| 11 | .4085 | .3749 | .3475 | .3307 | .3932 | .3841 | .3902 |
| 12 | .4191 | .3048 | .3094 | .3246 | .2926 | .3323 | .3597 |
| 13 | .3353 | .3064 | .285 | .2926 | .2896 | .3125 | .3292 |
| 14 | .3506 | .2271 | .25 | .2896 | .2743 | .2545 | .2957 |
| 15 | .282 | .2195 | .2301 | .2317 | .2271 | .2271 | .2713 |
| 16 | .2393 | .2088 | .2286 | .2027 | .221 | .2073 | .2225 |
| 17 | .2743 | .2286 | .2759 | .2256 | .2515 | .2545 | .2561 |
| 18 | .2606 | .2347 | .2423 | .2743 | .2561 | .2881 | .282 |
| 19 | .3185 | .2881 | .2865 | .3048 | .3064 | .3064 | .346 |
| 20 | .3185 | .2865 | .3079 | .3262 | .3185 | .317 | .3262 |
| 21 | .317 | .3094 | .317 | .3231 | .3079 | .3246 | .3201 |
| 22 | .3048 | .2926 | .2987 | .2865 | .2957 | .3109 | .285 |
| 23 | .2576 | .2698 | .253 | .253 | .253 | .2561 | .2667 |
| 24 | .2195 | .2225 | .2134 | .2058 | .218 | .2195 | .2347 |
| Max | .4313 | .4618 | .4649 | .4603 | .4649 | .471 | .4466 |
| Min | .1189 | .1646 | .1646 | .1555 | .1616 | .1616 | .1616 |
| Avg | .2773 | .2708 | .2782 | .2771 | .2803 | .2824 | .2845 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 303 / 22KV O/g 2(Panvel 2)

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.268 | 2.1948 | 2.0485 | 2.268 | 2.3777 | 2.268 | 2.1948 |
| 2 | 2.0851 | 2.0485 | 1.9022 | 1.9387 | 2.1948 | 2.1948 | 1.9753 |
| 3 | 1.8656 | 1.9753 | 1.9022 | 1.829 | 1.829 | 2.1216 | 2.0485 |
| 4 | 1.8656 | 1.9022 | 2.1582 | 2.0851 | 1.829 | 2.1948 | 2.0485 |
| 5 | 2.0119 | 2.1948 | 2.5606 | 2.3777 | 2.3777 | 2.5606 | 2.1948 |
| 6 | 2.1948 | 2.7435 | 2.8898 | 2.6703 | 2.9264 | 2.9995 | 2.3777 |
| 7 | 2.4143 | 3.6214 | 3.0361 | 3.1824 | 3.1824 | 3.1824 | 2.7435 |
| 8 | 3.0727 | 3.5482 | 3.3653 | 3.3653 | 3.5117 | 3.5482 | 3.3288 |
| 9 | 3.4385 | 3.6946 | 3.6946 | 3.5482 | 3.658 | 3.5482 | 3.6946 |
| 10 | 3.5848 | 3.7677 | 3.5848 | 3.8775 | 3.7677 | 3.9506 | 3.8775 |
| 11 | 3.658 | 3.8775 | 3.8409 | 3.658 | 3.914 | 4.1335 | 4.0238 |
| 12 | 3.6946 | 3.6214 | 3.5848 | 3.6214 | 3.658 | 4.0238 | 4.2798 |
| 13 | 3.4751 | 3.7677 | 3.5482 | 3.4751 | | 3.8775 | 4.0238 |
| 14 | 3.2922 | 3.5117 | 3.4385 | 3.3653 | 3.4385 | 3.658 | 3.9506 |
| 15 | 3.0727 | 3.3653 | 3.3288 | 3.5848 | 3.4751 | 3.5848 | 3.8043 |
| 16 | 2.9264 | 3.4385 | 3.4019 | 3.658 | 3.5482 | 4.0238 | 3.914 |
| 17 | 3.2922 | 3.5117 | 3.4751 | 3.8775 | 3.5848 | 4.3896 | 3.9872 |
| 18 | 3.5482 | 3.9872 | 3.8775 | 4.4627 | 3.8775 | 4.6091 | 4.0604 |
| 19 | 4.1701 | 4.6822 | 4.5725 | 4.9017 | 4.792 | 4.7554 | 4.9017 |
| 20 | 4.1335 | 4.4993 | 4.1335 | 4.3896 | 4.5359 | 4.7554 | 4.7554 |
| 21 | 3.7677 | 4.0969 | 3.9506 | 4.1701 | 4.1335 | 3.658 | 4.2433 |
| 22 | 3.1459 | 3.3653 | 3.3288 | 3.4751 | 3.5848 | 3.3653 | 3.3288 |
| 23 | 2.9264 | 2.8898 | 2.8532 | 2.7069 | 2.963 | 2.9995 | 2.963 |
| 24 | 2.4874 | 2.3411 | 2.4143 | | 3.7677 | 2.4508 | 2.5606 |
| Max | 4.1701 | 4.6822 | 4.5725 | 4.9017 | 4.792 | 4.7554 | 4.9017 |
| Min | 1.8656 | 1.9022 | 1.9022 | 1.829 | 1.829 | 2.1216 | 1.9753 |
| Avg | 3.0163 | 3.2769 | 3.2038 | 3.3256 | 3.3447 | 3.4522 | 3.3867 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 301 / 22Kv ONGC Express
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1888 | 1.2498 | 1.2498 |
| 2 | 1.1279 | 1.1888 | 1.1584 |
| 3 | 1.1584 | 1.1584 | 1.1584 |
| 4 | 1.1584 | 1.1888 | 1.1888 |
| 5 | 1.1584 | 1.1584 | 1.1888 |
| 6 | 1.2193 | 1.2193 | 1.3717 |
| 7 | 1.6156 | 1.5546 | 1.5851 |
| 8 | 1.4937 | 1.6156 | 1.5242 |
| 9 | 1.7375 | 1.7071 | 1.7375 |
| 10 | 2.5606 | 2.5606 | 2.8654 |
| 11 | 2.7435 | 2.713 | 2.9874 |
| 12 | 2.8654 | 2.8045 | 3.0483 |
| 13 | 2.5911 | 2.6825 | 2.9874 |
| 14 | 2.5301 | 2.5301 | 2.3777 |
| 15 | 2.4996 | 2.4691 | 2.3167 |
| 16 | 2.4691 | 2.8349 | |
| 17 | 2.7435 | 2.652 | |
| 18 | 1.6766 | 1.7985 | |
| 19 | 1.7985 | 1.8595 | |
| 20 | 1.768 | 1.829 | |
| 21 | 1.4022 | 1.3717 | |
| 22 | 1.3413 | 1.3413 | |
| 23 | 1.3108 | 1.2803 | |
| 24 | 1.2498 | 1.2193 | |
| Max | 2.8654 | 2.8349 | 3.0483 |
| Min | 1.1279 | 1.1584 | 1.1584 |
| Avg | 1.8087 | 1.8328 | 1.9164 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 304 / 22 KV NEW PANVEL

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | | 1.2193 |
| 2 | | 1.2193 |
| 3 | | .6097 |
| 4 | | .6097 |
| 5 | | .6097 |
| 6 | | .6097 |
| 7 | | 1.2193 |
| 8 | | 1.2193 |
| 9 | | 1.2193 |
| 10 | | 1.2193 |
| 11 | | 1.829 |
| 12 | 1.2193 | 1.829 |
| 13 | 1.2193 | 1.829 |
| 14 | 1.2193 | .6097 |
| 15 | 1.829 | 1.2193 |
| 16 | 1.2193 | 1.2193 |
| 17 | 1.829 | 1.829 |
| 18 | 1.829 | 1.829 |
| 19 | 1.2193 | 1.2193 |
| 20 | .6097 | .6097 |
| 21 | 1.2193 | .6097 |
| 22 | 1.2193 | .6097 |
| 23 | 1.2193 | 1.2193 |
| 24 | 1.2193 | 1.2193 |
| Max | 1.829 | 1.829 |
| Min | .6097 | .6097 |
| Avg | 1.3131 | 1.1431 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 405 / 33KV KALPATARU INCOMING-1 NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.6337 | 2.6337 | 10.0823 | 10.2469 | 10.5624 | 10.6584 | 10.631 |
| 2 | 2.4691 | 2.4691 | 9.4925 | 9.3004 | 9.6434 | 9.7393 | 9.6845 |
| 3 | 2.1948 | 2.4143 | 9.1495 | 8.9163 | 9.0535 | 9.3964 | 9.3416 |
| 4 | 2.1948 | 2.3594 | 9.2319 | 9.0535 | 8.9163 | 9.5336 | 9.3278 |
| 5 | 3.0178 | 2.6337 | 9.9589 | 9.6708 | 9.7394 | 10.0823 | 9.6708 |
| 6 | 2.524 | 3.1824 | 12.1673 | 11.9204 | 12.0301 | 12.2085 | 11.6324 |
| 7 | 2.7435 | 3.8958 | 14.3211 | 14.5542 | 14.5679 | 14.4993 | 13.059 |
| 8 | 3.3471 | 3.7311 | 15.2812 | 15.5419 | 15.8986 | 15.8573 | 15.0343 |
| 9 | 3.786 | 4.0055 | 16.3375 | 16.1454 | 16.5844 | 16.1454 | 16.7078 |
| 10 | 3.9506 | 3.9506 | 16.3101 | 16.6804 | 16.6255 | 17.5309 | 17.476 |
| 11 | 3.9506 | 4.1152 | 16.845 | 16.5981 | 17.4623 | 18.3128 | 18.8752 |
| 12 | 3.9506 | 3.786 | 16.214 | 16.3787 | 16.5844 | 17.9972 | 18.6969 |
| 13 | 3.6214 | 4.0055 | 15.5281 | 15.5556 | 16.8724 | 17.0234 | 18.4637 |
| 14 | 3.6214 | 3.786 | 15.0069 | 15.0891 | 16.1317 | 16.3238 | 17.1606 |
| 15 | 3.3471 | 3.5665 | 14.2799 | 14.4307 | 15.0343 | 15.5693 | 16.3649 |
| 16 | 3.2922 | 3.6763 | 14.1975 | 10.7682 | 15.1578 | 15.9396 | 16.2003 |
| 17 | 3.6214 | 3.786 | 15.0618 | 17.9972 | 15.5556 | 16.9273 | 16.7765 |
| 18 | 3.786 | 4.1152 | 16.3237 | 17.7641 | 16.9822 | 17.8601 | 16.3016 |
| 19 | 4.3896 | 4.8285 | 19.808 | 20.8367 | 20.5624 | 20.5624 | 21.1523 |
| 20 | 4.3896 | 4.6639 | 19.4651 | 20.1235 | 20.2606 | 20.5076 | 20.8505 |
| 21 | 4.0055 | 4.2798 | 18.2305 | 18.7517 | 19.0946 | 18.9301 | 19.3965 |
| 22 | 3.4568 | 3.6214 | 15.9671 | 16.0357 | 16.4747 | 16.7079 | 16.4472 |
| 23 | 3.2922 | 3.1276 | 13.3471 | 13.5665 | 13.7997 | 14.0604 | 13.9918 |
| 24 | 2.8532 | 2.7435 | 11.4678 | 8.9163 | 13.2373 | 12.0028 | 12.3731 |
| Max | 4.3896 | 4.8285 | 19.808 | 20.8367 | 20.5624 | 20.5624 | 21.1523 |
| Min | 2.1948 | 2.3594 | 9.1495 | 8.9163 | 8.9163 | 9.3964 | 9.3278 |
| Avg | 3.3516 | 3.5574 | 14.3365 | 14.3684 | 14.8680 | 15.1823 | 15.2340 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 302 / 22 KV Dronagiri

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | | | | | 1.9596 | |
| 12 | .9818 | | | | | 1.8766 |
| 13 | | | | | | 1.6139 |
| 14 | | | | | | 1.8016 |
| 16 | .4518 | | | | | 1.8016 |
| 18 | 1.0562 | | | | | |
| 22 | | 1.764 | | | | 1.6514 |
| 24 | | 1.3553 | 1.5764 | 2.2144 | | |
| Max | 1.0562 | 1.764 | 1.5764 | 2.2144 | 1.9596 | 1.8766 |
| Min | .4518 | 1.3553 | 1.5764 | 2.2144 | 1.9596 | 1.6139 |
| Avg | .8299 | 1.5597 | 1.5764 | 2.2144 | 1.9596 | 1.7490 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 303 / 22 KV Chirner

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10 | | | | | 3.8477 | |
| 12 | 3.6214 | | | | | 4.6446 |
| 13 | | | | | | 4.116 |
| 14 | | | | | | 4.0404 |
| 16 | 2.8669 | | | | | 5.06 |
| 18 | 3.0556 | | | | | |
| 22 | | 4.8663 | | | | 4.5313 |
| 24 | 2.8669 | 3.1687 | 4.0741 | 4.6824 | | |
| Max | 3.6214 | 4.8663 | 4.0741 | 4.6824 | 3.8477 | 5.06 |
| Min | 2.8669 | 3.1687 | 4.0741 | 4.6824 | 3.8477 | 4.0404 |
| Avg | 3.1027 | 4.0175 | 4.0741 | 4.6824 | 3.8477 | 4.4785 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 304 / 22 KV Industrial

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 19-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12 | 1.1706 | | | | 1.2826 |
| 13 | | | | | 1.9616 |
| 14 | | | | | 1.2826 |
| 16 | 1.1706 | | | | 1.6221 |
| 18 | 1.3972 | | | | |
| 22 | | 1.6992 | | | 1.773 |
| 24 | | 1.1328 | 1.3216 | 1.3957 | |
| Max | 1.3972 | 1.6992 | 1.3216 | 1.3957 | 1.9616 |
| Min | 1.1706 | 1.1328 | 1.3216 | 1.3957 | 1.2826 |
| Avg | 1.2461 | 1.416 | 1.3216 | 1.3957 | 1.5844 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 201 / 11 KV Sector - 14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | 2.0957 | | | |
| 2 | | | | 1.9624 | | | |
| 3 | | | | 1.9433 | | | |
| 4 | | | | 1.9243 | | | |
| 5 | | | | 2.191 | | | |
| 6 | | 3.1245 | | 2.6673 | | | |
| 7 | | 3.1055 | | 3.0293 | | | |
| 8 | 2.4196 | 3.0102 | | 2.9531 | | | |
| 9 | 2.7054 | | | 2.8578 | | | |
| 10 | | 2.7625 | | 2.5149 | | | |
| 11 | 2.7244 | | | 2.4387 | | | |
| 12 | 2.7816 | 2.6673 | | 2.2862 | | | |
| 13 | | 2.4387 | | 2.3053 | | | |
| 14 | | 2.3815 | | 2.0957 | | | |
| 15 | | | | 2.0005 | | | |
| 16 | 2.3243 | 2.2481 | | | | | |
| 17 | 2.1529 | 2.21 | 1.9052 | | | | |
| 18 | 2.191 | 2.4958 | | | | | |
| 19 | 3.4675 | 3.3341 | 2.6673 | | | | |
| 20 | 3.4865 | 3.5437 | | | | | |
| 21 | 3.3341 | 3.4294 | 3.4103 | | | | |
| 22 | 3.0674 | | 3.1817 | | | | |
| 24 | | 2.4006 | 3.4103 | 2.3243 | 2.2862 | 2.4006 | 2.4577 |
| Max | 3.4865 | 3.5437 | 3.4103 | 3.0293 | 2.2862 | 2.4006 | 2.4577 |
| Min | 2.1529 | 2.21 | 1.9052 | 1.9243 | 2.2862 | 2.4006 | 2.4577 |
| Avg | 2.7868 | 2.7966 | 2.9150 | 2.3494 | 2.2862 | 2.4006 | 2.4577 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 202 / 11 KV Sector - 7

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | 1.3527 | | | |
| 2 | | | | 1.2384 | | | |
| 3 | | | | 1.1622 | | | |
| 4 | | | | 1.1431 | | | |
| 5 | | | | 1.5051 | | | |
| 6 | | 1.7337 | | 1.7528 | | | |
| 7 | | 1.7147 | | 1.8671 | | | |
| 8 | 1.8861 | 2.1148 | | 2.0386 | | | |
| 9 | 2.0767 | | | 2.0386 | | | |
| 10 | | 2.1148 | | 2.0005 | | | |
| 11 | 2.21 | | | 1.9243 | | | |
| 12 | 2.2291 | 2.1338 | | 1.7147 | | | |
| 13 | | 1.9052 | | 1.7909 | | | |
| 14 | | 1.8671 | | 1.6575 | | | |
| 15 | | | | 1.3717 | | | |
| 16 | 1.7147 | 1.7528 | | | | | |
| 17 | 1.4861 | 1.5051 | 1.4098 | | | | |
| 18 | 1.5242 | 1.8099 | | | | | |
| 19 | 2.2672 | 2.2481 | 2.191 | | | | |
| 20 | 2.3815 | 2.3434 | | | | | |
| 21 | 2.21 | 2.3434 | 2.3815 | | | | |
| 22 | 2.0195 | | 2.3624 | | | | |
| 24 | | 1.5051 | | 1.4289 | 1.3336 | 1.4861 | 1.467 |
| Max | 2.3815 | 2.3434 | 2.3815 | 2.0386 | 1.3336 | 1.4861 | 1.467 |
| Min | 1.4861 | 1.5051 | 1.4098 | 1.1431 | 1.3336 | 1.4861 | 1.467 |
| Avg | 2.0005 | 1.9351 | 2.0862 | 1.6242 | 1.3336 | 1.4861 | 1.467 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 204 / 11 KV Sector -15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .0953 | | | |
| 2 | | | | .0953 | | | |
| 3 | | | | .0953 | | | |
| 4 | | | | .0953 | | | |
| 5 | | | | .1143 | | | |
| 6 | | .1334 | | .1143 | | | |
| 7 | | .1334 | | .1143 | | | |
| 8 | .0953 | .1334 | | .1143 | | | |
| 9 | .0953 | | | .0953 | | | |
| 10 | | .1143 | | .0953 | | | |
| 11 | .1143 | | | .0953 | | | |
| 12 | .1143 | .0953 | | .0953 | | | |
| 13 | | .0953 | | .0953 | | | |
| 14 | | .0953 | | .0953 | | | |
| 15 | | | | .0953 | | | |
| 16 | .0953 | .0953 | | | | | |
| 17 | .0953 | .0953 | .0953 | | | | |
| 18 | .0953 | .0953 | | | | | |
| 19 | .0953 | .1143 | .0953 | | | | |
| 20 | .0953 | | | | | | |
| 21 | .1334 | .1143 | .1334 | | | | |
| 22 | .1143 | | .1334 | | | | |
| 24 | | .1143 | | .0953 | .1143 | .1143 | .1143 |
| Max | .1334 | .1334 | .1334 | .1143 | .1143 | .1143 | .1143 |
| Min | .0953 | .0953 | .0953 | .0953 | .1143 | .1143 | .1143 |
| Avg | .1039 | .1099 | .1144 | .1001 | .1143 | .1143 | .1143 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 205 / 11 KV Railway

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .0953 | | | |
| 2 | | | | .0953 | | | |
| 3 | | | | .0953 | | | |
| 4 | | | | .0953 | | | |
| 5 | | | | .0953 | | | |
| 6 | | .0953 | | .0953 | | | |
| 7 | | .1143 | | .0953 | | | |
| 8 | .0953 | .1334 | | .1334 | | | |
| 9 | .0953 | | | .1334 | | | |
| 10 | | .1143 | | .1334 | | | |
| 11 | .0953 | | | .1143 | | | |
| 12 | .0953 | .0953 | | .1334 | | | |
| 13 | | .0953 | | .1334 | | | |
| 14 | | .0953 | | .1334 | | | |
| 15 | | | | .1143 | | | |
| 16 | .0953 | .0953 | | | | | |
| 17 | .0953 | .0953 | .0953 | | | | |
| 18 | .0953 | .1143 | | | | | |
| 19 | .1334 | .1334 | .0953 | | | | |
| 20 | .1143 | .1143 | | | | | |
| 21 | .1143 | .0953 | .1143 | | | | |
| 22 | .1524 | | .1143 | | | | |
| 24 | | .0953 | | .0953 | .0953 | .1334 | .0953 |
| Max | .1524 | .1334 | .1143 | .1334 | .0953 | .1334 | .0953 |
| Min | .0953 | .0953 | .0953 | .0953 | .0953 | .1334 | .0953 |
| Avg | .1074 | .1062 | .1048 | .1120 | .0953 | .1334 | .0953 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 206 / 11 KV Ajanta Sector -13

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .0953 | | | |
| 2 | | | | .0953 | | | |
| 3 | | | | .0953 | | | |
| 4 | | | | .0953 | | | |
| 5 | | | | .0953 | | | |
| 6 | | .0953 | | .0953 | | | |
| 7 | | .0953 | | | | | |
| 8 | .0953 | .0953 | | .0953 | | | |
| 9 | .0953 | | | .0953 | | | |
| 10 | | .0953 | | .0953 | | | |
| 11 | .0953 | | | .0953 | | | |
| 12 | .0953 | .0953 | | .0953 | | | |
| 13 | | .0953 | | .0953 | | | |
| 14 | | .0953 | | .0953 | | | |
| 15 | | | | .0953 | | | |
| 16 | .0953 | .0953 | | | | | |
| 17 | .0953 | .0953 | .0953 | | | | |
| 18 | .0953 | .0953 | | | | | |
| 19 | .0953 | .0953 | .0953 | | | | |
| 20 | .0953 | .0953 | | | | | |
| 21 | .0953 | .0953 | .0953 | | | | |
| 22 | .0953 | | .0953 | | | | |
| 24 | | .0953 | | .0953 | .0953 | .0953 | .0953 |
| Max | .0953 | .0953 | .0953 | .0953 | .0953 | .0953 | .0953 |
| Min | .0953 | .0953 | .0953 | .0953 | .0953 | .0953 | .0953 |
| Avg | .0953 | .0953 | .0953 | .0953 | .0953 | .0953 | .0953 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 207 / 11 KV Sector - 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | 1.7528 | | | |
| 2 | | | | 1.7718 | | | |
| 3 | | | | 1.6194 | | | |
| 4 | | | | 1.5051 | | | |
| 5 | | | | 1.9052 | | | |
| 6 | | 2.4577 | | 2.4768 | | | |
| 7 | | 2.4768 | | 2.7054 | | | |
| 8 | 2.3434 | 2.8197 | | 2.6673 | | | |
| 9 | 2.2862 | | | 2.5149 | | | |
| 10 | | 2.4196 | | 2.2862 | | | |
| 11 | 2.4196 | | | 2.0386 | | | |
| 12 | 2.4387 | 2.3243 | | 1.9052 | | | |
| 13 | | 2.1338 | | 1.8099 | | | |
| 14 | | 2.0957 | | 1.7718 | | | |
| 15 | | | | 1.6385 | | | |
| 16 | 1.7528 | 2.0005 | | | | | |
| 17 | 1.6575 | 1.6766 | 1.6004 | | | | |
| 18 | 1.6766 | 1.9052 | | | | | |
| 19 | 2.4768 | 2.3243 | 1.7147 | | | | |
| 20 | 2.6101 | 2.6673 | | | | | |
| 21 | 2.4958 | 2.6482 | 2.6101 | | | | |
| 22 | 2.2862 | | 2.5911 | | | | |
| 24 | | 1.7909 | | 1.7909 | 1.8099 | 1.8671 | 1.8861 |
| Max | 2.6101 | 2.8197 | 2.6101 | 2.7054 | 1.8099 | 1.8671 | 1.8861 |
| Min | 1.6575 | 1.6766 | 1.6004 | 1.5051 | 1.8099 | 1.8671 | 1.8861 |
| Avg | 2.2222 | 2.2672 | 2.1291 | 2.0100 | 1.8099 | 1.8671 | 1.8861 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 208 / 11 KV Sector-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .5525 | | | |
| 2 | | | | .5144 | | | |
| 3 | | | | .5335 | | | |
| 4 | | | | .5335 | | | |
| 5 | | | | .6668 | | | |
| 6 | | .7811 | | .6668 | | | |
| 7 | | .8002 | | .8764 | | | |
| 8 | .8002 | 1.1812 | | .9335 | | | |
| 9 | .9335 | 1.1431 | | 1.0669 | | | |
| 10 | | .9335 | | 1.0288 | | | |
| 11 | .8764 | | | .9335 | | | |
| 12 | .9145 | .8383 | | .8002 | | | |
| 13 | | .8764 | | .7621 | | | |
| 14 | | .8002 | | | | | |
| 15 | | | | .6859 | | | |
| 16 | .6097 | .724 | | | | | |
| 17 | .5716 | .5716 | .6668 | | | | |
| 18 | .6287 | .6668 | | | | | |
| 19 | 1.0479 | .7811 | .8764 | | | | |
| 20 | .9145 | .9145 | | | | | |
| 21 | .9526 | .8002 | .9335 | | | | |
| 22 | .9526 | | .1143 | | | | |
| 24 | | .6668 | | .5716 | .5716 | .6287 | .6287 |
| Max | 1.0479 | 1.1812 | .9335 | 1.0669 | .5716 | .6287 | .6287 |
| Min | .5716 | .5716 | .1143 | .5144 | .5716 | .6287 | .6287 |
| Avg | .8366 | .8319 | .6478 | .7418 | .5716 | .6287 | .6287 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 301 / 22KV Diva Gaon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .6097 | | | |
| 2 | | | | .5716 | | | |
| 3 | | | | .5335 | | | |
| 4 | | | | .6859 | | | |
| 5 | | | | .6859 | | | |
| 6 | | .7621 | | .7621 | | | |
| 7 | | .8383 | | .8764 | | | |
| 8 | .7621 | .9145 | | .8002 | | | |
| 9 | .8383 | | | .7621 | | | |
| 10 | | | | .724 | | | |
| 11 | .7621 | | | .6859 | | | |
| 12 | .724 | .6478 | | .6859 | | | |
| 13 | | .6859 | | .6097 | | | |
| 14 | | .6097 | | .5716 | | | |
| 15 | | | | .5716 | | | |
| 16 | .6478 | .5716 | | | | | |
| 17 | .6478 | .6097 | .6097 | | | | |
| 18 | .724 | .6859 | | | | | |
| 19 | 1.0288 | .9145 | .9526 | | | | |
| 20 | .9907 | .9907 | | | | | |
| 21 | .9526 | .9907 | .9526 | | | | |
| 22 | .8764 | | .8764 | | | | |
| 24 | | .6478 | | .6478 | .6478 | .6859 | .6859 |
| Max | 1.0288 | .9907 | .9526 | .8764 | .6478 | .6859 | .6859 |
| Min | .6478 | .5716 | .6097 | .5335 | .6478 | .6859 | .6859 |
| Avg | .8141 | .7592 | .8478 | .6740 | .6478 | .6859 | .6859 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 301 / 22 KV KALWA - I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.8807 | 3.2922 | 2.7435 | 2.8807 | 3.3608 | 2.915 | 3.0178 |
| 2 | 2.7435 | 3.1207 | 2.6063 | 2.7435 | 3.2236 | 2.8464 | 2.9492 |
| 3 | 2.8464 | 3.1207 | 2.5034 | 2.8807 | 3.1893 | | 2.8464 |
| 4 | 2.8121 | 3.0521 | 2.6063 | 3.2922 | 2.8121 | 2.6749 | 2.7435 |
| 5 | 2.8807 | 3.155 | 2.7435 | 3.4294 | 2.7435 | 2.9492 | 2.915 |
| 6 | 2.9492 | 2.9835 | 3.7723 | 3.4979 | 2.915 | 3.2579 | 3.3608 |
| 7 | 3.0178 | 2.9492 | 3.7723 | 3.6351 | 3.0521 | 3.7037 | 3.6351 |
| 8 | 3.5665 | 3.2579 | 3.9781 | 3.8066 | 3.0521 | 3.7037 | 3.8066 |
| 9 | 3.9095 | 3.4294 | 3.5322 | 3.4294 | 3.2236 | 3.3608 | 3.6008 |
| 10 | 3.8409 | 3.1893 | 3.2236 | 3.1893 | 3.2922 | 2.8807 | 3.2922 |
| 11 | 3.5322 | 2.8464 | 2.8121 | 2.8121 | 2.915 | 2.7435 | 3.0178 |
| 12 | 3.4637 | 2.7435 | 2.5034 | 2.5034 | 2.7435 | | 2.8464 |
| 13 | 3.0521 | 2.4691 | 2.4348 | 2.3663 | 2.6063 | | 2.6063 |
| 14 | 3.1207 | 2.5034 | 2.2634 | 2.2634 | 2.5377 | | 2.5377 |
| 15 | 2.6749 | 2.3663 | 2.2977 | 2.2977 | 2.4691 | | 5.1097 |
| 16 | 2.7092 | 2.332 | 2.2634 | 2.1948 | 2.4006 | 4.5268 | 5.3841 |
| 17 | 2.572 | 2.5377 | 2.2977 | 2.2291 | 2.572 | 4.2867 | 5.1097 |
| 18 | 3.0178 | 2.8464 | 2.8121 | 2.7778 | 2.8464 | 4.904 | 5.7613 |
| 19 | 4.1495 | 3.3265 | 3.7723 | 3.738 | 4.1495 | 3.6351 | 6.5158 |
| 20 | 4.1152 | 3.9438 | 3.9095 | 4.0466 | 4.1152 | 3.8409 | 6.2071 |
| 21 | 4.0466 | 4.0809 | 3.9438 | 3.9438 | 4.1495 | 3.8066 | 6.1386 |
| 22 | 3.9095 | 3.7723 | 3.8409 | 3.4979 | 3.8752 | 3.8409 | 6.1043 |
| 23 | 3.738 | 3.4637 | 3.4294 | 3.4294 | 3.6008 | 3.5665 | 5.6927 |
| 24 | 2.915 | 3.4294 | 2.8464 | 3.9438 | 3.4294 | 3.0521 | 3.0864 |
| Max | 4.1495 | 4.0809 | 3.9781 | 4.0466 | 4.1495 | 4.904 | 6.5158 |
| Min | 2.572 | 2.332 | 2.2634 | 2.1948 | 2.4006 | 2.6749 | 2.5377 |
| Avg | 3.2693 | 3.0921 | 3.0379 | 3.1179 | 3.1364 | 3.4998 | 4.0952 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 302 / 22 KV Airoli - I

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6461 | 1.4746 | 1.9547 | 1.6461 | 2.3663 | 2.0576 | 1.7833 |
| 2 | 1.7147 | 1.3375 | 2.1262 | 1.8176 | 2.0919 | 2.1262 | 1.7147 |
| 3 | 1.6118 | 1.2689 | 1.5775 | 1.6118 | 1.989 | 1.7147 | 1.6461 |
| 4 | 1.3717 | 1.406 | 1.3375 | 1.3717 | 1.9547 | 1.5775 | 1.4746 |
| 5 | 1.3032 | 1.6118 | 1.2689 | 1.2003 | 1.7833 | 1.4746 | 1.2346 |
| 6 | 1.0974 | 1.6804 | 1.2346 | 1.166 | 1.7147 | 1.3717 | 1.0974 |
| 7 | 1.0631 | 1.7833 | 1.3717 | 1.5432 | 1.6118 | 1.3032 | 1.3717 |
| 8 | 1.0631 | 1.9547 | 1.6118 | 1.7147 | 1.5775 | 1.989 | 1.2689 |
| 9 | 1.1317 | 1.989 | 1.7833 | 1.8519 | 1.7147 | | 1.4403 |
| 10 | 1.0631 | 2.0233 | 2.0576 | 1.8861 | 2.0233 | 1.989 | 1.6461 |
| 11 | 1.0974 | 2.1605 | 2.1605 | 1.989 | 2.0576 | 1.8861 | 1.6461 |
| 12 | 1.2003 | 2.1262 | 2.0576 | 2.0576 | 2.1262 | | 1.5775 |
| 13 | 1.2689 | 2.2977 | 2.1262 | 2.1605 | 2.1262 | | 1.6804 |
| 14 | 1.3717 | 2.332 | 2.1605 | 2.1605 | 2.1605 | | 1.8176 |
| 15 | 1.2003 | 2.3663 | 2.2291 | 2.2291 | 2.2634 | | 2.0233 |
| 16 | 1.2346 | 2.4006 | 2.4006 | 2.2634 | 2.1948 | 2.2977 | 2.1262 |
| 17 | 1.406 | 2.5377 | 2.332 | 2.2977 | 2.2977 | 2.332 | 1.8176 |
| 18 | 1.4403 | 2.6406 | 2.572 | 2.572 | 2.4348 | 2.8121 | 2.0233 |
| 19 | 1.5089 | 2.572 | 2.5034 | 2.5377 | 2.6063 | 2.7778 | 2.2634 |
| 20 | 1.406 | 2.5034 | 2.332 | 2.4691 | 2.4006 | 2.4691 | 2.0919 |
| 21 | 1.4746 | 2.332 | 2.0576 | 2.3663 | 2.332 | 1.8176 | 1.8519 |
| 22 | 1.406 | 1.8176 | 1.7833 | 1.9547 | 2.1262 | 1.6461 | 1.5089 |
| 23 | 1.4403 | 1.749 | 1.6118 | 1.7833 | 1.6118 | 1.5089 | 1.4403 |
| 24 | 1.4403 | 1.406 | 1.749 | 1.7147 | 1.7147 | 1.8861 | 1.5775 |
| Max | 1.7147 | 2.6406 | 2.572 | 2.572 | 2.6063 | 2.8121 | 2.2634 |
| Min | 1.0631 | 1.2689 | 1.2346 | 1.166 | 1.5775 | 1.3032 | 1.0974 |
| Avg | 1.3317 | 1.9905 | 1.9333 | 1.9319 | 2.0533 | 1.9493 | 1.6718 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 303 / 22 KV Airoli - II

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6859 | .9259 | .6516 | .6859 | .823 | .7202 | .823 |
| 2 | .6859 | .9259 | .6173 | .6859 | .7545 | .6859 | .7545 |
| 3 | .6173 | .8573 | .6173 | .6173 | .6859 | .6516 | .6859 |
| 4 | .6173 | .8573 | .6516 | .6173 | .8916 | .6173 | .6859 |
| 5 | .6859 | .8916 | .7202 | .7202 | .823 | .6516 | .7545 |
| 6 | .6859 | .7545 | .7888 | .7888 | .8573 | .6859 | .823 |
| 7 | .6859 | .8573 | .8573 | .823 | .823 | .823 | .8573 |
| 8 | .823 | .823 | .9259 | .8916 | .823 | .9259 | .8573 |
| 9 | .823 | .823 | .8916 | .823 | .823 | .8573 | .823 |
| 10 | .9602 | .7888 | .823 | .823 | .8916 | .8573 | .8573 |
| 11 | .9602 | .7202 | 1.1317 | .7545 | .823 | .8916 | .823 |
| 12 | .6516 | .6859 | .7202 | .6859 | .6859 | .823 | .7202 |
| 13 | .7202 | .6516 | .6516 | .6859 | .6516 | .823 | .6859 |
| 14 | .7545 | .6516 | .6173 | .6173 | .6173 | .6173 | .6516 |
| 15 | .823 | .6173 | .5487 | .6173 | .6173 | .6516 | .6516 |
| 16 | .583 | .583 | .5487 | .6173 | .6173 | .583 | .6173 |
| 17 | .6516 | .6516 | .6516 | .583 | .6859 | .5487 | .6516 |
| 18 | .7545 | .7545 | .6859 | .6859 | .7202 | .6516 | .7545 |
| 19 | .9259 | .8573 | .9602 | .9602 | .9602 | .8573 | .9602 |
| 20 | .9602 | .9602 | .9602 | 1.3032 | 1.0288 | .8573 | .8916 |
| 21 | 1.0288 | .8916 | .9259 | 1.2003 | .9945 | .8916 | .9602 |
| 22 | | .9259 | .9259 | 1.166 | .9602 | .9259 | .9602 |
| 23 | .9602 | .8573 | .823 | .8573 | .9259 | .8916 | .9259 |
| 24 | .7202 | .8916 | .6859 | .7545 | .8916 | .7888 | .823 |
| Max | 1.0288 | .9602 | 1.1317 | 1.3032 | 1.0288 | .9259 | .9602 |
| Min | .583 | .583 | .5487 | .583 | .6173 | .5487 | .6173 |
| Avg | .7724 | .8002 | .7659 | .7902 | .8073 | .7616 | .7916 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 304 / 22 KV Rabale MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 3.2922 | 2.8807 | 2.7435 | 2.915 | 2.7092 | 2.8464 | 2.572 |
| 2 | 3.1893 | 2.9835 | 3.0178 | 2.8464 | 2.7778 | 2.7435 | 2.6063 |
| 3 | 3.0864 | 3.0864 | 2.6063 | 2.7435 | 2.572 | 2.7778 | 2.5377 |
| 4 | 3.0178 | 3.2579 | 2.572 | 2.8464 | 2.6749 | 2.8121 | 2.4006 |
| 5 | 3.0178 | 3.2579 | 2.6406 | 2.7778 | 3.4294 | 2.7435 | 2.6063 |
| 6 | 3.0864 | 3.3951 | 2.7435 | 2.915 | 3.4294 | 2.8464 | 2.7092 |
| 7 | 2.9835 | 3.3608 | 2.8464 | 2.8807 | 4.0124 | 2.8121 | 2.8464 |
| 8 | 2.4691 | 3.5322 | 3.3608 | 3.155 | 4.4239 | 2.7778 | 2.8464 |
| 9 | 2.8464 | 3.6351 | 3.7037 | 3.6008 | 4.4925 | 2.6749 | 3.155 |
| 10 | 3.4294 | 4.2524 | 4.321 | 4.2867 | 4.5953 | 2.6749 | 4.0124 |
| 11 | 3.4637 | 4.6982 | 4.6296 | 4.3896 | 4.561 | 2.4348 | 4.4925 |
| 12 | 3.738 | 3.8752 | 4.7325 | 4.6296 | 4.6296 | | 4.6639 |
| 13 | 3.8752 | 3.4979 | 3.7037 | 4.4582 | 3.5322 | | 3.6008 |
| 14 | 4.0124 | 4.0809 | 4.561 | 4.3553 | 4.5268 | | 3.9438 |
| 15 | 3.7037 | 4.4582 | 4.8354 | 4.3896 | 4.5953 | | 4.4925 |
| 16 | 3.4294 | 4.6982 | 4.6639 | 4.4582 | 4.6639 | 2.572 | 4.8697 |
| 17 | 3.6008 | 4.4582 | 4.8697 | 4.5268 | 4.4239 | 2.6406 | 4.4239 |
| 18 | 3.4637 | 4.2181 | 4.2181 | 4.1152 | 4.0466 | 2.6749 | 4.0124 |
| 19 | 3.3265 | 3.9438 | 4.1152 | 3.738 | 3.8409 | 2.6063 | 3.4637 |
| 20 | 3.1207 | 3.738 | 3.6008 | 3.2579 | 3.4979 | 2.7435 | 3.3951 |
| 21 | 3.0178 | 3.5322 | 3.3265 | 3.1207 | 3.3608 | 2.7778 | 3.2236 |
| 22 | 3.155 | 2.8807 | 3.0178 | 2.8807 | 3.1893 | 2.8121 | 3.2922 |
| 23 | 2.9492 | 2.9492 | 2.9492 | 2.6406 | 3.0178 | 2.7435 | 3.0864 |
| 24 | 3.3608 | 2.7778 | 2.8464 | 2.9835 | 2.7435 | 2.9492 | 2.7092 |
| Max | 4.0124 | 4.6982 | 4.8697 | 4.6296 | 4.6639 | 2.9492 | 4.8697 |
| Min | 2.4691 | 2.7778 | 2.572 | 2.6406 | 2.572 | 2.4348 | 2.4006 |
| Avg | 3.2765 | 3.6437 | 3.6094 | 3.5380 | 3.7394 | 2.7332 | 3.4151 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 305 / 22 KV Ghansoli

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 4.2867 | 4.9726 | 4.4582 | .4458 | 4.8011 | 4.561 | 4.8011 |
| 2 | 4.1838 | 5.2469 | 4.2867 | 4.3896 | 4.6982 | 4.4239 | 4.7325 |
| 3 | 4.1152 | 5.3841 | 4.1152 | 4.2867 | 4.5268 | 4.2524 | 4.6296 |
| 4 | 4.3896 | 5.487 | 4.4239 | 4.4582 | 4.5268 | 4.2867 | 4.5268 |
| 5 | 4.9726 | 5.5556 | 5.3498 | 4.8697 | 4.8697 | 5.4184 | 5.0755 |
| 6 | 5.4184 | 5.5899 | 6.4815 | 6.4129 | 6.4129 | 6.4129 | 6.07 |
| 7 | 5.5556 | 5.6584 | 7.0302 | 6.7901 | 6.07 | 7.0302 | 6.653 |
| 8 | 6.6873 | 5.6242 | 7.2702 | 7.476 | 5.6584 | 7.0302 | 6.5844 |
| 9 | 6.9616 | 5.6927 | 6.2757 | 6.31 | 5.727 | 6.4129 | 5.7613 |
| 10 | 6.6873 | 5.144 | 5.4184 | 5.3498 | 5.6242 | 5.4184 | 5.5556 |
| 11 | 5.1097 | 4.3896 | 4.6296 | 4.6296 | 5.0755 | 5.0412 | 4.904 |
| 12 | 4.1838 | 4.321 | 4.3553 | 4.2524 | 4.5268 | 4.8011 | |
| 13 | 4.1495 | 4.2524 | 3.9781 | 4.0466 | 4.2181 | 4.3896 | |
| 14 | 4.0124 | 4.1152 | 3.9438 | 3.8409 | 4.0466 | 3.8409 | |
| 15 | 3.738 | 3.8409 | 3.7723 | 3.9095 | 4.0809 | 3.8409 | |
| 16 | 3.8752 | 3.7723 | 3.8066 | 4.0124 | 4.1152 | 3.738 | 4.8354 |
| 17 | 4.4239 | 4.1495 | 4.1495 | 4.1152 | 4.3896 | 3.9438 | 5.0069 |
| 18 | 4.7668 | 5.2126 | 4.8011 | 4.8011 | 4.6639 | | 4.7668 |
| 19 | 6.4815 | 6.1386 | 6.31 | 6.1386 | 6.8587 | | 6.7215 |
| 20 | 6.4129 | 6.7901 | 6.7901 | 6.1728 | 6.9273 | 4.904 | 6.2071 |
| 21 | 6.31 | 7.1674 | 6.5158 | 6.4815 | 6.7901 | 4.8011 | 6.1386 |
| 22 | 6.0357 | 6.07 | 6.1043 | 6.07 | 5.9328 | 6.2757 | 6.3443 |
| 23 | 5.4527 | 5.4184 | 5.3498 | 5.2469 | 5.487 | 5.8299 | 5.6242 |
| 24 | 4.321 | 4.8011 | 4.561 | 4.5268 | 5.144 | 4.7325 | 4.8697 |
| Max | 6.9616 | 7.1674 | 7.2702 | 7.476 | 6.9273 | 7.0302 | 6.7215 |
| Min | 3.738 | 3.7723 | 3.7723 | .4458 | 4.0466 | 3.738 | 4.5268 |
| Avg | 5.1055 | 5.1998 | 5.1740 | 4.9597 | 5.2155 | 5.0630 | 5.4904 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 306 / 22 KV Railway -II

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 2 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 3 | .4801 | .5144 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 4 | .4801 | .7888 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 5 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 6 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 7 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 8 | .4801 | .4801 | .4801 | .4801 | .583 | .4801 | .4801 |
| 9 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 10 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 11 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 12 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 13 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 14 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 15 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 16 | .5144 | .4801 | .4801 | .4801 | .583 | .4801 | .4801 |
| 17 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 18 | .5144 | .4801 | .4801 | .4801 | .4801 | .4801 | .5144 |
| 19 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .5144 |
| 20 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 21 | .4801 | .4801 | .4801 | .5144 | .4801 | .4801 | .5144 |
| 22 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| 23 | .4801 | .4801 | .4801 | .5144 | .4801 | .4801 | .4801 |
| 24 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| Max | .5144 | .7888 | .4801 | .5144 | .583 | .4801 | .5144 |
| Min | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 | .4801 |
| Avg | .4830 | .4944 | .4801 | .4830 | .4887 | .4801 | .4844 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 309 / 22 KV Railway -I

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2346 | 1.3375 | 1.3032 | 1.2346 | 1.3375 | 1.2689 | 1.3717 |
| 2 | 1.2003 | 1.2003 | 1.2003 | 1.166 | 1.2689 | 1.1317 | 1.3032 |
| 3 | 1.2689 | 1.2689 | 1.166 | 1.0288 | 1.3032 | 1.0631 | 1.4403 |
| 4 | 1.3032 | 1.1317 | 1.2346 | 1.3032 | 1.2346 | 1.1317 | 1.4746 |
| 5 | 1.3717 | 1.2346 | 1.3717 | 1.5089 | 1.4403 | 1.3375 | 1.5775 |
| 6 | 1.5089 | 1.3375 | 3.0178 | 1.7833 | 1.5089 | 1.6461 | 1.7147 |
| 7 | 1.5775 | 1.406 | 1.8519 | 1.9204 | 1.5089 | 1.8861 | 1.9547 |
| 8 | 1.7833 | 1.4746 | 1.7833 | 1.989 | 1.406 | 1.7833 | 1.7833 |
| 9 | 2.0233 | 1.5089 | 1.6461 | 1.7147 | 1.4746 | 1.7147 | 1.6461 |
| 10 | 1.6804 | 1.4403 | 1.5432 | 1.5432 | 1.5089 | 1.4746 | 1.5775 |
| 11 | 1.6461 | 1.3375 | 1.4403 | 1.4746 | 1.4403 | 1.3717 | 1.5775 |
| 12 | 1.6804 | 1.3717 | 1.4403 | 1.4403 | 1.5089 | | 1.5432 |
| 13 | 1.7147 | 1.406 | 1.4746 | .3772 | 1.4403 | | 1.5089 |
| 14 | 1.749 | 1.3717 | 1.406 | 1.2346 | 1.8176 | | 1.4746 |
| 15 | 1.6804 | 1.2003 | 1.3375 | 1.2689 | 1.2003 | | 1.406 |
| 16 | 1.7147 | 1.166 | 1.2003 | 1.2346 | 1.2003 | 1.6461 | 1.3717 |
| 17 | 1.7833 | 1.406 | 1.3717 | 1.3032 | 1.2003 | 1.5775 | 1.5089 |
| 18 | 1.8519 | 1.5775 | 1.5775 | 1.4403 | 1.4403 | 1.4746 | 1.749 |
| 19 | 1.7833 | 1.7147 | 1.8861 | 1.6804 | 1.8176 | 1.6461 | 1.8519 |
| 20 | 1.6804 | 1.8519 | 1.989 | 1.8176 | 1.9204 | 1.9547 | 1.7833 |
| 21 | 1.7147 | 1.7833 | 2.0576 | 1.749 | 1.8176 | 1.7833 | 1.749 |
| 22 | 1.749 | 1.7147 | 1.8176 | 1.6118 | 1.7147 | 1.6461 | 1.8861 |
| 23 | 1.6461 | 1.6804 | 1.5432 | 1.5775 | 1.5775 | 1.6804 | 1.5432 |
| 24 | 1.3032 | 1.5432 | 1.406 | 1.3032 | 1.3717 | 1.3717 | 1.5089 |
| Max | 2.0233 | 1.8519 | 3.0178 | 1.989 | 1.9204 | 1.9547 | 1.9547 |
| Min | 1.2003 | 1.1317 | 1.166 | .3772 | 1.2003 | 1.0631 | 1.3032 |
| Avg | 1.6104 | 1.4361 | 1.5861 | 1.4461 | 1.4775 | 1.5295 | 1.5961 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 311 / 22 KV Cidco II

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .823 | 1.0288 | 1.2346 | .7545 | 1.0288 | 1.0288 | 1.0288 |
| 2 | .7545 | .8916 | 1.1317 | .6859 | .9602 | .9259 | 1.0631 |
| 3 | .8573 | .9602 | 1.0288 | .6859 | .8916 | .7888 | .9602 |
| 4 | .823 | .8573 | .9602 | .823 | .823 | .7202 | .8916 |
| 5 | .9602 | .9945 | .8573 | 1.0288 | 1.0288 | .9259 | 1.166 |
| 6 | 1.0288 | 1.0974 | 1.2346 | 1.2346 | 1.0631 | 1.1317 | 1.3717 |
| 7 | 1.166 | 1.2003 | 1.4746 | 1.0631 | .9945 | 1.3032 | 1.2689 |
| 8 | 1.0288 | 1.2689 | 1.3717 | 1.3717 | 1.166 | 1.2689 | 1.3717 |
| 9 | 1.166 | 1.3032 | 1.406 | 1.2003 | 1.2689 | 1.3375 | 1.3032 |
| 10 | 1.3717 | 1.2689 | 1.3375 | 1.4403 | 1.2346 | 1.0288 | 1.0974 |
| 11 | 1.3032 | 1.2346 | .4801 | .8916 | 1.1317 | 1.0288 | 1.5432 |
| 12 | 1.2346 | 1.406 | 1.0288 | .8573 | 1.0631 | | 1.2346 |
| 13 | 1.0974 | 1.3717 | .9602 | .8573 | 1.1317 | | 1.1317 |
| 14 | 1.3717 | 1.2003 | 1.3375 | .7888 | 1.0974 | | 1.0288 |
| 15 | 1.3032 | 1.0631 | .9602 | .7545 | .9602 | | .8573 |
| 16 | 1.2346 | .9602 | .8573 | .7888 | .8573 | 1.4403 | .823 |
| 17 | 1.3717 | 1.0288 | .8573 | .823 | .7888 | 1.2346 | .9259 |
| 18 | 1.4403 | 1.1317 | .9602 | .823 | .8573 | 1.2689 | 1.166 |
| 19 | 1.5089 | 1.2003 | 1.166 | 1.0974 | 1.0288 | 1.5432 | 1.3375 |
| 20 | 1.4403 | 1.3717 | 1.5089 | 1.3375 | 1.2689 | 1.8861 | 1.406 |
| 21 | 1.4746 | 1.4746 | 1.2346 | 1.4403 | 1.5089 | 1.5775 | 1.3717 |
| 22 | 1.406 | 1.5089 | 1.2003 | 1.3032 | 1.7833 | 1.3717 | 1.4746 |
| 23 | 1.3032 | 1.4403 | 1.2689 | 1.406 | 1.3375 | 1.5089 | 1.4746 |
| 24 | .8573 | 1.166 | 2.3663 | .823 | 1.0974 | 1.0974 | 1.1317 |
| Max | 1.5089 | 1.5089 | 2.3663 | 1.4403 | 1.7833 | 1.8861 | 1.5432 |
| Min | .7545 | .8573 | .4801 | .6859 | .7888 | .7202 | .823 |
| Avg | 1.1803 | 1.1846 | 1.1760 | 1.0117 | 1.0988 | 1.2209 | 1.1846 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 312 / 22 KV Vodafone

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0288 | .8916 | 1.0288 | 1.166 | .8916 | .7888 | .823 |
| 2 | .9602 | .9259 | .9602 | 1.0974 | .823 | .7545 | .823 |
| 3 | .8916 | .9945 | .9259 | 1.0288 | .823 | .823 | .823 |
| 4 | .8916 | 1.0288 | .8916 | .9602 | .8573 | .7888 | .823 |
| 5 | .823 | 1.0974 | .8573 | 1.0288 | .9259 | .7202 | .8916 |
| 6 | .7888 | 1.0288 | .7888 | 1.166 | .9945 | .7888 | .9602 |
| 7 | .823 | 1.0631 | .823 | .823 | .9602 | .823 | .9602 |
| 8 | 1.1317 | 1.1317 | .8916 | .823 | 1.0631 | .8916 | .9945 |
| 9 | .823 | 1.1317 | .9259 | .823 | 1.0631 | .823 | .9602 |
| 10 | 1.2003 | .9602 | .823 | 1.2003 | 1.1317 | 1.1317 | .823 |
| 11 | .8916 | .823 | .823 | .8573 | 1.166 | 1.166 | .823 |
| 12 | .823 | .8573 | .8916 | .823 | 1.2346 | 1.2003 | 1.0631 |
| 13 | .9259 | .823 | .8573 | .9945 | 1.2346 | 1.2003 | .823 |
| 14 | .823 | .8573 | .9602 | 1.2003 | .823 | .9602 | .9259 |
| 15 | 1.0974 | .8916 | .8573 | .9945 | .9945 | 1.1317 | 1.0288 |
| 16 | 1.0288 | .8573 | .823 | .9259 | 1.0974 | 1.2003 | 1.1317 |
| 17 | .823 | .823 | 1.0974 | .823 | 1.0288 | 1.8861 | .823 |
| 18 | .8916 | .9259 | 1.3032 | .823 | .8573 | .823 | .823 |
| 19 | .6859 | 1.0288 | 1.2003 | .9602 | .823 | .823 | .823 |
| 20 | .7545 | 1.0974 | .823 | 1.0288 | 1.0974 | .8916 | .8916 |
| 21 | .7202 | 1.0288 | .823 | .9602 | .823 | .823 | .9602 |
| 22 | .6859 | .9602 | .823 | .823 | .9602 | .823 | .9602 |
| 23 | .7545 | .8916 | .9945 | 1.0288 | 1.1317 | .823 | 1.0288 |
| 24 | 1.166 | .823 | 1.0974 | .823 | .9602 | .823 | .823 |
| Max | 1.2003 | 1.1317 | 1.3032 | 1.2003 | 1.2346 | 1.8861 | 1.1317 |
| Min | .6859 | .823 | .7888 | .823 | .823 | .7202 | .823 |
| Avg | .8931 | .9559 | .9288 | .9659 | .9902 | .9545 | .9088 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 202 / 11 KV Reliance

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.3656 | 1.3885 | 1.4167 | 1.486 | 1.4747 | 1.4846 | 1.5074 |
| 2 | 1.3435 | 1.3733 | 1.4023 | 1.4685 | 1.4548 | 1.4693 | 1.496 |
| 3 | 1.3268 | 1.3428 | 1.3901 | 1.451 | 1.4465 | 1.4526 | 1.4807 |
| 4 | 1.3191 | 1.3351 | 1.3855 | 1.4411 | 1.4449 | 1.4396 | 1.4838 |
| 5 | 1.326 | 1.3733 | 1.4251 | 1.4639 | 1.4647 | 1.467 | 1.5028 |
| 6 | 1.3839 | 1.5257 | 1.55 | 1.5401 | 1.5562 | 1.5432 | 1.5554 |
| 7 | 1.4945 | 1.6895 | 1.691 | 1.7047 | 1.6194 | 1.6666 | 1.7284 |
| 8 | 1.6507 | 1.7741 | 1.7886 | 1.7908 | 1.7924 | 1.7787 | 1.7733 |
| 9 | 1.643 | 1.8739 | 1.8602 | 1.8465 | 1.9738 | 1.9456 | 1.7535 |
| 10 | 1.5623 | 2.1003 | 2.143 | 2.0889 | 2.1468 | 2.0012 | 1.8213 |
| 11 | 1.4762 | 2.2039 | 2.0904 | 2.1491 | 2.2291 | 2.1041 | 1.7993 |
| 12 | .7461 | 2.1346 | 1.9669 | 1.9845 | 2.1247 | 2.0264 | .9153 |
| 13 | 1.4091 | 2.0546 | 1.9486 | 1.9586 | 2.0546 | 1.9342 | |
| 14 | 1.3596 | 2.0249 | 2.0218 | 1.9868 | 2.111 | 1.9121 | |
| 15 | 1.3816 | 2.0744 | 2.0728 | 2.0622 | 2.1529 | 2.0843 | |
| 16 | 1.3489 | 1.086 | 2.0736 | 2.0485 | 2.1872 | 2.1224 | 1.0402 |
| 17 | 1.3786 | 2.0515 | 2.1155 | 2.0988 | 2.1986 | 2.0958 | .9671 |
| 18 | 1.5897 | 2.191 | 2.0958 | 2.1186 | 2.2268 | 2.1018 | 1.8671 |
| 19 | 1.8221 | 2.2557 | 2.2809 | 2.2565 | 2.3144 | 2.1788 | 2.0417 |
| 20 | 1.8069 | 2.1102 | 2.1179 | 2.2047 | 2.1689 | 2.0119 | 1.9448 |
| 21 | 1.7451 | 1.9243 | 1.9189 | 2.0157 | 1.9883 | 1.8975 | 1.8595 |
| 22 | 1.6811 | 1.7817 | 1.8107 | 1.8138 | 1.9128 | 1.8183 | 1.7475 |
| 23 | 1.5745 | .8909 | 1.672 | 1.6438 | 1.6956 | .9107 | 1.6598 |
| 24 | 1.4366 | 1.4761 | 1.4937 | 1.534 | 1.5257 | 1.5158 | 1.5669 |
| Max | 1.8221 | 2.2557 | 2.2809 | 2.2565 | 2.3144 | 2.1788 | 2.0417 |
| Min | .7461 | .8909 | 1.3855 | 1.4411 | 1.4449 | .9107 | .9153 |
| Avg | 1.4655 | 1.7515 | 1.8222 | 1.8399 | 1.8860 | 1.7901 | 1.5958 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 203 / 11 KV Mastek MBP s/stn NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .381 | .381 | .381 | .381 | .381 | .362 |
| 2 | .3429 | .381 | .362 | .381 | .381 | .381 | .362 |
| 3 | .3429 | .381 | .362 | .381 | .381 | .381 | .362 |
| 4 | .3429 | .381 | .3429 | .381 | .381 | .381 | .362 |
| 5 | .3429 | .381 | .362 | .381 | .381 | .381 | .362 |
| 6 | .3429 | .4001 | .4382 | .381 | .381 | | .362 |
| 7 | .362 | .4382 | | .4001 | .5716 | .4191 | .3429 |
| 8 | .4191 | .7621 | .8954 | .6859 | .8573 | .8192 | .4191 |
| 9 | .4382 | .8954 | .8192 | .8764 | .9907 | .8764 | .4382 |
| 10 | .4382 | .8764 | .9145 | .6478 | .8002 | .8764 | .7621 |
| 11 | .4191 | .8954 | .7049 | .6287 | .6668 | .8954 | .7621 |
| 12 | | .9526 | .9526 | .8573 | .743 | .6478 | |
| 13 | .4191 | .7049 | .9145 | .8954 | .7621 | .9145 | |
| 14 | .4382 | .8002 | .9145 | .8954 | .8764 | .8954 | |
| 15 | .4191 | .9526 | .9335 | .8002 | .9335 | .9335 | |
| 16 | .4191 | | .7049 | .7049 | .9145 | .8954 | |
| 17 | .4191 | .9717 | .9145 | .7049 | .9145 | .7621 | |
| 18 | .4191 | .9145 | .8573 | .7049 | .8573 | .6668 | .4382 |
| 19 | .4001 | .6478 | .6859 | .7049 | .8383 | .6478 | .4001 |
| 20 | .4191 | .6097 | .5716 | .6668 | .7621 | .5716 | .4191 |
| 21 | .4001 | .5525 | .5144 | .5716 | .5716 | .5335 | .4001 |
| 22 | .381 | .4572 | .4191 | .4382 | .5716 | .4382 | .4001 |
| 23 | .4001 | | .4191 | .4382 | .4191 | | .381 |
| 24 | .362 | .381 | .4191 | .4001 | .381 | .4191 | .381 |
| Max | .4382 | .9717 | .9526 | .8954 | .9907 | .9335 | .7621 |
| Min | .3429 | .381 | .3429 | .381 | .381 | .381 | .3429 |
| Avg | .3926 | .6417 | .6436 | .5962 | .6549 | .6417 | .4287 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 204 / 11 KV Hexaware MBP s/stn NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4336 | .4687 | .5494 | .5586 | .5723 | .5631 | .5304 |
| 2 | .4336 | .4671 | .551 | .5045 | .5266 | .5151 | .5121 |
| 3 | .4328 | .4504 | .5304 | .5037 | .525 | .5243 | .5083 |
| 4 | .4321 | .4489 | .5076 | .4976 | .509 | .5022 | .5052 |
| 5 | .4344 | .4489 | .4992 | .4786 | .4839 | .4816 | .4816 |
| 6 | .4344 | .4512 | .5022 | .4801 | .4831 | .4808 | .4763 |
| 7 | .4328 | .5335 | .6173 | .5312 | .6249 | .6637 | .5868 |
| 8 | .4977 | .8253 | .8687 | .8527 | .8733 | .8261 | .5891 |
| 9 | .4915 | 1.2026 | 1.278 | 1.179 | 1.3824 | 1.2346 | .7857 |
| 10 | .5052 | 1.3885 | 1.3565 | 1.2765 | 1.4876 | 1.3771 | .8063 |
| 11 | .5243 | 1.3702 | 1.3664 | 1.3504 | 1.5204 | 1.3954 | .8276 |
| 12 | .2789 | 1.438 | 1.4739 | 1.4327 | 1.4564 | 1.5295 | .4481 |
| 13 | .4725 | 1.4937 | 1.5493 | 1.4281 | 1.4647 | 1.5942 | |
| 14 | .5098 | 1.4625 | 1.4807 | 1.486 | 1.4998 | 1.5333 | |
| 15 | .5548 | 1.4815 | 1.4708 | 1.4716 | 1.3733 | 1.4883 | .3384 |
| 16 | .535 | .7979 | 1.4884 | 1.4975 | 1.5219 | 1.5204 | .4862 |
| 17 | .506 | 1.4899 | 1.4929 | 1.4365 | 1.4305 | 1.5744 | .4771 |
| 18 | .5014 | 1.3482 | 1.326 | 1.2544 | 1.2483 | 1.326 | .7377 |
| 19 | .4869 | 1.0982 | 1.1523 | 1.1211 | 1.2064 | 1.1691 | .7057 |
| 20 | .4839 | .8688 | .8322 | .9549 | 1.0365 | .8451 | .6424 |
| 21 | .4869 | .8032 | .7544 | .7857 | .7727 | .7248 | .5411 |
| 22 | .4885 | .7125 | .6867 | .6127 | .7079 | .6615 | .5029 |
| 23 | .4793 | .3361 | .6333 | .6135 | .663 | .3338 | .4908 |
| 24 | .4558 | .5038 | .5792 | .6181 | .6096 | .5799 | .5167 |
| Max | .5548 | 1.4937 | 1.5493 | 1.4975 | 1.5219 | 1.5942 | .8276 |
| Min | .2789 | .3361 | .4992 | .4786 | .4831 | .3338 | .3384 |
| Avg | .4705 | .9121 | .9811 | .9552 | .9991 | .9768 | .5680 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 205 / 11 KV Life Cycle

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5616 | .5372 | .5487 | .5662 | .5678 | .5959 | .5868 |
| 2 | .5571 | .5311 | .5441 | .5647 | .5792 | .6005 | .5792 |
| 3 | .5456 | .535 | .535 | .5541 | .5693 | .5853 | .5838 |
| 4 | .5289 | .541 | .5471 | .5708 | .5731 | .5876 | .5807 |
| 5 | .5471 | .5426 | .5594 | .5563 | .5769 | .5944 | .58 |
| 6 | .5548 | .5571 | .5845 | .5861 | .5838 | .5891 | .599 |
| 7 | .57 | .6028 | .5952 | .6432 | .6173 | .6394 | .6478 |
| 8 | .631 | .6905 | .7681 | .7545 | .7262 | .7308 | .6943 |
| 9 | .6294 | .8253 | .884 | .9594 | .8246 | .9046 | .8177 |
| 10 | .6135 | .9153 | .9808 | 1.0372 | .9823 | 1.0083 | .9449 |
| 11 | .6493 | .9709 | 1.0075 | 1.0212 | .9785 | 1.0661 | .9312 |
| 12 | .33 | .9709 | .9854 | 1.4136 | .99 | .9824 | .932 |
| 13 | .6585 | .9602 | .9923 | .9206 | .9343 | .9327 | .4908 |
| 14 | .6317 | .9908 | 1.0235 | .9892 | .9617 | .9518 | .9625 |
| 15 | .6294 | 1.0402 | 1.0311 | .9953 | .9892 | .9907 | .5144 |
| 16 | .6233 | .5175 | 1.044 | .9899 | 1.0006 | 1.0334 | .4976 |
| 17 | .634 | .948 | .9915 | .9816 | .9777 | .9785 | .4694 |
| 18 | .6546 | .9266 | .9541 | .9656 | .9899 | .9678 | .913 |
| 19 | .6706 | .8924 | .9229 | .9175 | .9976 | 1.0083 | .8901 |
| 20 | .631 | .8466 | .8215 | .8824 | .9724 | .9671 | .8733 |
| 21 | .6211 | .7727 | .7742 | .8093 | .9221 | .9183 | .7499 |
| 22 | .6119 | .7003 | .6889 | .7247 | .8985 | .887 | .7476 |
| 23 | .6043 | .3307 | .666 | .6432 | .8055 | .4313 | .6821 |
| 24 | .5655 | .301 | .6043 | .6272 | .6615 | .6668 | .6424 |
| Max | .6706 | 1.0402 | 1.044 | 1.4136 | 1.0006 | 1.0661 | .9625 |
| Min | .33 | .301 | .535 | .5541 | .5678 | .4313 | .4694 |
| Avg | .5939 | .7269 | .7939 | .8197 | .82 | .8174 | .7046 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 206 / 11 KV Aptech

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4748 | .4831 | .5548 | .5899 | .6013 | .5815 | .5639 |
| 2 | .4679 | .4755 | .5555 | .58 | .5891 | .5784 | .5647 |
| 3 | .4732 | .4725 | .5532 | .5815 | .5777 | .5784 | .5624 |
| 4 | .4732 | .4748 | .5456 | .58 | .5754 | .5754 | .5525 |
| 5 | .4748 | .4786 | .6371 | .5762 | .5731 | .5723 | .5479 |
| 6 | .4793 | .7438 | 1.0601 | .9374 | .7667 | .8588 | .5571 |
| 7 | .4748 | 1.1469 | 1.1424 | 1.0517 | .9724 | 1.1568 | .6218 |
| 8 | .5189 | 1.2674 | 1.2079 | 1.1569 | 1.2544 | 1.2125 | .7003 |
| 9 | .5548 | 1.4205 | 1.2819 | 1.2765 | 1.3352 | 1.3375 | .8566 |
| 10 | .5982 | 1.6408 | 1.5851 | 1.5021 | 1.5821 | 1.6125 | 1.1401 |
| 11 | .5899 | 1.7131 | 1.6773 | 1.6605 | 1.7231 | 1.7276 | 1.1752 |
| 12 | .314 | 1.7947 | 1.816 | 1.7718 | 1.7825 | 2.0097 | 1.262 |
| 13 | .6218 | 1.8755 | 1.8122 | 1.6819 | 1.8099 | 2.0401 | .6394 |
| 14 | .6294 | 1.9403 | 1.9288 | 1.8305 | 1.8297 | 1.8198 | 1.182 |
| 15 | .6013 | 1.9784 | 1.9075 | 1.8541 | 1.9876 | 1.7802 | .615 |
| 16 | .5464 | 1.0059 | 1.8731 | 1.8632 | 1.9258 | 1.7917 | .6013 |
| 17 | .5578 | 1.8762 | 1.7398 | 1.8221 | 1.7817 | 1.7444 | .5571 |
| 18 | .5616 | 1.6667 | 1.5089 | 1.6347 | 1.5234 | 1.5851 | .9114 |
| 19 | .5357 | 1.4937 | 1.3832 | 1.3992 | 1.3702 | 1.387 | .7187 |
| 20 | .5342 | 1.2407 | 1.153 | 1.246 | 1.2049 | 1.1927 | .6416 |
| 21 | .4892 | 1.0791 | .9496 | 1.1226 | 1.0731 | .9724 | .5876 |
| 22 | .4915 | .7933 | .7331 | .8261 | .9443 | .8429 | .5373 |
| 23 | .4657 | .3155 | .6294 | .6524 | .6211 | .3285 | .5312 |
| 24 | .5038 | .5319 | .6036 | .5998 | 1.1751 | .5944 | .5647 |
| Max | .6294 | 1.9784 | 1.9288 | 1.8632 | 1.9876 | 2.0401 | 1.262 |
| Min | .314 | .3155 | .5456 | .5762 | .5731 | .3285 | .5312 |
| Avg | .5180 | 1.1629 | 1.2016 | 1.1999 | 1.2325 | 1.2034 | .7163 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 207 / 11 KV ML Tower

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1913 | .1921 | .1906 | .1913 | .1906 | .1898 | .1906 |
| 2 | .1921 | .1921 | .1906 | .1913 | .1913 | .1906 | .1913 |
| 3 | .1921 | .1921 | .1906 | .1913 | .1913 | .1906 | .1913 |
| 4 | .1913 | .1921 | .1906 | .1913 | .1906 | .1906 | .1906 |
| 5 | .1921 | .1913 | .1898 | .1906 | .1906 | .1906 | .1898 |
| 6 | .1913 | .1913 | .1898 | .1898 | .1928 | .189 | .0945 |
| 7 | .1906 | .2127 | .2134 | .2188 | .221 | .2127 | .2066 |
| 8 | .1814 | .4458 | .3932 | .4169 | .4313 | .4359 | .3529 |
| 9 | .1814 | .4458 | .4138 | .4352 | .4587 | .4618 | .3582 |
| 10 | .1814 | .4961 | .4436 | .4671 | .4732 | .4633 | .3269 |
| 11 | .1845 | .4847 | .4695 | .4504 | .4778 | .4687 | .3086 |
| 12 | .0899 | .506 | .4946 | .4908 | .5189 | .487 | .2531 |
| 13 | .1852 | .5045 | .4999 | .477 | .4786 | .4717 | .1608 |
| 14 | .1852 | .5099 | .4808 | .4992 | .4877 | .4725 | .3338 |
| 15 | .1837 | .4915 | .477 | .4999 | .5045 | .4977 | .1646 |
| 16 | .1837 | .2591 | .4778 | .5053 | .5426 | .4908 | .1631 |
| 17 | .1837 | .4489 | .3864 | .4839 | .4534 | .4367 | .1608 |
| 18 | .1852 | .3132 | .247 | .3963 | .3079 | .2424 | .1867 |
| 19 | .1951 | .2447 | .2294 | .2812 | .279 | .2325 | .1883 |
| 20 | .1921 | .2203 | .2157 | .2591 | .2584 | .2157 | .1921 |
| 21 | .1928 | .2172 | .2157 | .2561 | .2028 | .2142 | .1921 |
| 22 | .1913 | .1944 | .1936 | .2317 | .1906 | .1921 | .1898 |
| 23 | .1913 | .0975 | .1921 | .1928 | .1898 | .0945 | .1898 |
| 24 | .1913 | .1921 | .1913 | .1951 | .189 | .1906 | .1898 |
| Max | .1951 | .5099 | .4999 | .5053 | .5426 | .4977 | .3582 |
| Min | .0899 | .0975 | .1898 | .1898 | .189 | .0945 | .0945 |
| Avg | .1842 | .3098 | .3074 | .3293 | .3255 | .3093 | .2153 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 208 / 11 KV core project

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7011 | .6935 | .7186 | .7377 | .7453 | .7079 | .6996 |
| 2 | .6896 | .6882 | .7186 | .7392 | .7445 | .7064 | .6996 |
| 3 | .6874 | .6912 | .7011 | .7354 | .7346 | .6706 | .7049 |
| 4 | .6866 | .6958 | .6988 | .7361 | .727 | .6706 | .7011 |
| 5 | .6919 | .6935 | .6996 | .7415 | .73 | .6683 | .6965 |
| 6 | .7003 | .7117 | .7088 | .7712 | .7415 | .6874 | .7232 |
| 7 | .7011 | .7537 | .7392 | .7278 | .7491 | .7385 | .7064 |
| 8 | .7034 | .7529 | .7087 | .7628 | .7369 | .7201 | .7552 |
| 9 | .8093 | .8489 | .8147 | .8086 | .7316 | .7705 | .8146 |
| 10 | .6881 | .8993 | .8817 | .8909 | .7803 | .8116 | .9229 |
| 11 | .8001 | .8924 | .8139 | .9046 | .8207 | .8245 | .9191 |
| 12 | .458 | .9427 | .9305 | .9198 | .8901 | .794 | .8459 |
| 13 | .8268 | .8885 | .9381 | .9259 | .8551 | .8672 | .4969 |
| 14 | .82 | .9305 | .9755 | .9709 | .852 | .8863 | .9069 |
| 15 | .8367 | .9579 | .9548 | .9663 | .8581 | .881 | .5601 |
| 16 | .7979 | .4512 | .9236 | .98 | .8764 | .8947 | .5235 |
| 17 | .7849 | .9884 | .8756 | .9305 | .8474 | .8398 | .4664 |
| 18 | .7902 | .8528 | .8885 | .8581 | .7979 | .8444 | .8086 |
| 19 | .7712 | .8253 | .7963 | .8017 | .7568 | .724 | .7606 |
| 20 | .7072 | .7507 | .7499 | .7773 | .7689 | .7064 | .7415 |
| 21 | .7293 | .7507 | .7674 | .7765 | .7659 | .7453 | .7674 |
| 22 | .7651 | .7545 | .7392 | .7514 | .772 | .7575 | .7461 |
| 23 | .7148 | .3833 | .7034 | .7582 | .7362 | .3559 | .7613 |
| 24 | .7133 | .7224 | .7209 | .7399 | .7438 | .6973 | .714 |
| Max | .8367 | .9884 | .9755 | .98 | .8901 | .8947 | .9229 |
| Min | .458 | .3833 | .6988 | .7278 | .727 | .3559 | .4664 |
| Avg | .7323 | .7717 | .7986 | .8213 | .7818 | .7488 | .7268 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 211 / 11 KV Rupa HT SS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1905 | .2286 | .2667 | .1143 | .2286 | .2286 | .1143 |
| 2 | .1905 | .4191 | .2286 | .1143 | .2286 | .1905 | .1143 |
| 3 | .1905 | .2286 | .2286 | .1143 | .2286 | .1905 | .1143 |
| 4 | .1905 | .1905 | .2286 | .1143 | .2286 | .1905 | .1143 |
| 5 | .1905 | .1905 | .2286 | .1143 | .2286 | .1905 | .1143 |
| 6 | .1905 | .1905 | .2286 | .1143 | .2286 | .1905 | .1143 |
| 7 | .1905 | .2286 | .2667 | .1143 | .2286 | .2667 | .1143 |
| 8 | .1905 | .2667 | .2667 | .1143 | .2286 | .2667 | .1143 |
| 9 | .1905 | .3048 | .3048 | .1334 | .3048 | .2667 | .1143 |
| 10 | .1905 | .381 | .3239 | .3239 | .3429 | .3048 | .3048 |
| 11 | .1905 | .381 | .4001 | .4001 | .381 | .4001 | .3048 |
| 12 | | .4191 | .362 | .362 | .4382 | .381 | .2667 |
| 13 | .1524 | .381 | .381 | .381 | .381 | .4191 | |
| 14 | .1524 | .4001 | .4191 | .381 | .3429 | .381 | |
| 15 | .2286 | .4382 | .4001 | .381 | .4763 | .4001 | |
| 16 | .2286 | | .4382 | .381 | .381 | .4001 | |
| 17 | .2286 | .4001 | .4191 | .381 | .381 | .381 | |
| 18 | .2286 | .4001 | .4001 | .381 | .381 | .381 | .3048 |
| 19 | .2286 | .4382 | .362 | .3429 | .3429 | .381 | .3048 |
| 20 | .2286 | .3239 | .362 | .3429 | .3429 | .3429 | .2667 |
| 21 | .2286 | .3048 | .3239 | .3048 | .3048 | .1334 | .3048 |
| 22 | .2286 | .3048 | .3048 | .2667 | .3048 | | .2286 |
| 23 | .2286 | | .1334 | .2667 | .2286 | .1334 | .2286 |
| 24 | .2286 | .2286 | .2667 | .1334 | .2286 | .2286 | .1143 |
| Max | .2286 | .4382 | .4382 | .4001 | .4763 | .4191 | .3048 |
| Min | .1524 | .1905 | .1334 | .1143 | .2286 | .1334 | .1143 |
| Avg | .2038 | .3204 | .3143 | .2532 | .3080 | .2891 | .1925 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 212 / 11 KV Rupa SS - 3

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .4191 | .4001 | .4001 |
| 2 | | | | .4001 | .4001 | .4001 |
| 3 | | | | .4001 | .4001 | .4001 |
| 4 | | | | .4001 | .381 | .4001 |
| 5 | | | | .4001 | .381 | .4001 |
| 6 | | | | .4001 | .381 | .4001 |
| 7 | | | | .4191 | .4572 | .4191 |
| 8 | | | | .5335 | .5335 | .4191 |
| 9 | | | | .5716 | .5716 | .5144 |
| 10 | | | | .6478 | .6478 | .5144 |
| 11 | .4572 | | | .6859 | .6478 | .5525 |
| 12 | | | .6859 | .6859 | .6859 | .5906 |
| 13 | | | .7049 | .6859 | .6859 | |
| 14 | | | .724 | .6859 | .6859 | |
| 15 | | | .724 | .6859 | .6859 | |
| 16 | | | .724 | .6859 | .7049 | |
| 17 | | .6668 | .724 | .6859 | .6859 | |
| 18 | | | .6478 | .6478 | .6478 | .362 |
| 19 | | | .5716 | .5716 | .5716 | .4954 |
| 20 | | | .5716 | .5335 | .4572 | .4763 |
| 21 | | | .4954 | .4954 | .4763 | .4763 |
| 22 | | | .4572 | .4954 | | .4382 |
| 23 | | | .4572 | .4572 | .4382 | .4382 |
| 24 | .4191 | | | .4191 | .4572 | .4001 |
| Max | .4572 | .6668 | .724 | .6859 | .7049 | .5906 |
| Min | .4191 | .6668 | .4572 | .4001 | .381 | .362 |
| Avg | .4382 | .6668 | .6240 | .5422 | .5384 | .4472 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 213 / 11 KV Rupa SS - 4

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7621 | .7621 | .7811 | .7621 | .8383 | .8383 | .7621 |
| 2 | .724 | .7621 | .7811 | .7621 | .7621 | .7621 | .7621 |
| 3 | .724 | .7621 | .7621 | .7621 | .7621 | .7621 | .7621 |
| 4 | .724 | .7621 | .7621 | .7621 | .7621 | .7621 | .7621 |
| 5 | .724 | .7811 | .7621 | .4001 | .7621 | .7621 | .7621 |
| 6 | .724 | .7621 | .7811 | .7811 | .7621 | .7621 | .7621 |
| 7 | .724 | .7811 | .7811 | .8002 | .8002 | .8383 | .7621 |
| 8 | .8383 | .7811 | .7811 | .7811 | .9145 | .8764 | .743 |
| 9 | .8383 | .8764 | .8573 | .8383 | .9526 | .9526 | .8002 |
| 10 | .8383 | .9526 | .9907 | .9907 | 1.0479 | 1.0669 | .8192 |
| 11 | .8383 | 1.0669 | 1.0669 | 1.086 | 1.1431 | 1.0098 | .8954 |
| 12 | | 1.0669 | 1.0479 | 1.086 | 1.086 | 1.0098 | .8954 |
| 13 | .7811 | 1.1241 | 1.0669 | 1.086 | 1.1812 | 1.0479 | |
| 14 | .8002 | 1.0669 | 1.0669 | 1.1431 | 1.1812 | 1.0288 | |
| 15 | .7811 | 1.086 | 1.0669 | 1.1812 | 1.086 | 1.0479 | |
| 16 | .7621 | 1.105 | 1.1431 | 1.1812 | 1.2193 | 1.086 | |
| 17 | .7811 | 1.0669 | .9907 | 1.1812 | 1.1431 | 1.0479 | |
| 18 | .7811 | 1.0479 | .9526 | 1.1431 | .9907 | .9717 | .8002 |
| 19 | .7811 | .9717 | .9145 | 1.0288 | .9907 | .9145 | .8002 |
| 20 | .7811 | .8573 | .8383 | .9907 | .9526 | .8383 | .7811 |
| 21 | .7811 | .8192 | .7811 | .9526 | .9145 | .7811 | .8002 |
| 22 | .7621 | .7811 | .7621 | .8764 | .9145 | | .8002 |
| 23 | .7621 | | .7811 | .8764 | .8764 | .7621 | .8002 |
| 24 | .8002 | .7621 | .8002 | .8002 | .8764 | .8764 | .7621 |
| Max | .8383 | 1.1241 | 1.1431 | 1.1812 | 1.2193 | 1.086 | .8954 |
| Min | .724 | .7621 | .7621 | .4001 | .7621 | .7621 | .743 |
| Avg | .7745 | .9046 | .8883 | .9272 | .9550 | .9046 | .7912 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 214 / 11 KV Rupa SS - 6

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1143 | .1143 | .1524 | .0572 | .1143 | .0572 | .0572 |
| 2 | .1143 | .1143 | .1524 | .0572 | .1143 | .0572 | .0572 |
| 3 | .1143 | .1143 | .1143 | .0572 | .1143 | .0572 | .0572 |
| 4 | .1143 | .1143 | .1143 | .0572 | .1143 | .0572 | .0572 |
| 5 | .1143 | .1143 | .1143 | .0572 | .1143 | .0572 | .0572 |
| 6 | .1143 | .1143 | .1143 | .0572 | .1143 | .0572 | .0572 |
| 7 | .1143 | .1143 | .1143 | .0572 | .1143 | .0762 | .0762 |
| 8 | .1524 | .1524 | .1524 | .0762 | .1905 | .0762 | .0572 |
| 9 | .1524 | .2286 | .1905 | .0953 | .2286 | .0953 | .0762 |
| 10 | .1524 | .2667 | .2286 | .2286 | .2667 | .1143 | .0762 |
| 11 | .1524 | .3048 | .2286 | .2286 | .2667 | .1334 | .1905 |
| 12 | | .3048 | .2667 | .2667 | .3429 | .1715 | .1334 |
| 13 | .2286 | .3048 | .3429 | .3429 | .1715 | .3048 | |
| 14 | .2286 | .3048 | .3048 | .3429 | .1715 | .1715 | |
| 15 | .2286 | .3048 | .3429 | .3429 | .1715 | .1715 | |
| 16 | .2286 | | .3048 | .3429 | .1524 | .1524 | |
| 17 | .1905 | .2667 | .1334 | .3429 | .1524 | .1334 | |
| 18 | .1905 | .2667 | .1334 | .3429 | .1524 | .1334 | .1905 |
| 19 | .1905 | .3048 | .1334 | .2667 | .1334 | .1715 | .1905 |
| 20 | .1905 | .2667 | .1143 | .2667 | .1334 | .1334 | .2286 |
| 21 | .1905 | .2286 | .1143 | .2667 | .1143 | .1143 | .2286 |
| 22 | .1905 | .1905 | .0953 | .2286 | .1143 | | .2286 |
| 23 | .1905 | | .0953 | .1905 | .0953 | .0953 | .2286 |
| 24 | .1143 | .1143 | .1143 | .0572 | .1524 | .0762 | .0762 |
| Max | .2286 | .3048 | .3429 | .3429 | .3429 | .3048 | .2286 |
| Min | .1143 | .1143 | .0953 | .0572 | .0953 | .0572 | .0572 |
| Avg | .1640 | .2096 | .1738 | .1929 | .1588 | .1160 | .1223 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 301 / 22 Kv O/G Indian Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | .1905 | .1905 | | .381 | .1905 | |
| 2 | .381 | .1905 | .1905 | | .381 | .1905 | |
| 3 | .381 | .1905 | .1905 | | .381 | .1905 | |
| 4 | .381 | .1905 | .1905 | | .381 | .1905 | |
| 5 | .381 | .1905 | .1905 | | .381 | .1905 | |
| 6 | | .1905 | .1905 | | .1905 | .1905 | |
| 7 | .1905 | .1905 | .1905 | | .1905 | | |
| 8 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| 9 | .1905 | | | .1905 | .1905 | | .1905 |
| 10 | .1905 | | .1905 | .1905 | .1905 | | .1905 |
| 11 | .1905 | | .1905 | .1905 | .1905 | .1905 | .1905 |
| 12 | .1905 | | .1905 | .1905 | .1905 | | .1905 |
| 13 | .1905 | | | .1905 | .1905 | .381 | .1905 |
| 14 | .1905 | | | .1905 | .1905 | .1905 | .1905 |
| 15 | .1905 | | | .1905 | .1905 | | .1905 |
| 16 | .1905 | | | .1905 | .1905 | .1905 | .1905 |
| 17 | .1905 | | | .1905 | .1905 | | .1905 |
| 18 | .1905 | | | .1905 | .1905 | | .1905 |
| 19 | .1905 | | | .1905 | .1905 | | .1905 |
| 20 | .1905 | | | .1905 | .1905 | | .1905 |
| 21 | .1905 | | | .1905 | .1905 | | .1905 |
| 22 | .1905 | | | .1905 | .1905 | | .1905 |
| 23 | .1905 | | | .1905 | .1905 | | .381 |
| 24 | .381 | .1905 | .1905 | .1905 | .381 | .1905 | .7621 |
| Max | .381 | .1905 | .1905 | .1905 | .381 | .381 | .7621 |
| Min | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 | .1905 |
| Avg | .2402 | .1905 | .1905 | .1905 | .2381 | .2064 | .2353 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 302 / 22 Kv L&T I

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 18-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 8 | .381 |
| Max | .381 |
| Min | .381 |
| Avg | .381 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 303 / 22Kv O/G Electronic Sadan NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5716 | .5716 | .7621 | | .7621 | .7621 | |
| 2 | .5716 | .5716 | .7621 | | .7621 | .7621 | |
| 3 | .5716 | .5716 | .7621 | | .7621 | .7621 | |
| 4 | .5716 | .5716 | .7621 | | .7621 | .7621 | |
| 5 | .5716 | .5716 | .7621 | | .7621 | .7621 | |
| 6 | .5716 | .5716 | .7621 | | .7621 | .7621 | |
| 7 | .5716 | .7621 | .7621 | | .7621 | .7621 | |
| 8 | .5716 | .7621 | .7621 | .7621 | .7621 | .7621 | .7621 |
| 9 | .5716 | | | .9526 | 1.1431 | | .7621 |
| 10 | .5716 | | .9526 | 1.1431 | 1.1431 | | .7621 |
| 11 | .5716 | | .9526 | 1.2193 | 1.1431 | 1.1431 | .7621 |
| 12 | .5716 | | 1.1431 | 1.1812 | 1.1431 | | .7621 |
| 13 | .5716 | | | 1.1431 | 1.1431 | 1.1431 | .7621 |
| 14 | .5716 | | | 1.1431 | 1.1431 | 1.1431 | .7621 |
| 15 | .5716 | | | 1.5242 | 1.1431 | | .7621 |
| 16 | .5716 | | | 1.5242 | 1.1431 | 1.1431 | .7621 |
| 17 | .5716 | | | 1.5242 | 1.1431 | | .7621 |
| 18 | .5716 | | | 1.1431 | 1.1431 | | .7621 |
| 19 | .5716 | | | .7621 | 1.1431 | | .381 |
| 20 | .5716 | | | .7621 | .7621 | | .381 |
| 21 | .5716 | | | .7621 | .7621 | | .1905 |
| 22 | .5716 | | | .7621 | .7621 | | .1905 |
| 23 | .5716 | | | .7621 | .7621 | | .1905 |
| 24 | .381 | .5716 | .7621 | .7621 | .7621 | .7621 | |
| Max | .5716 | .7621 | 1.1431 | 1.5242 | 1.1431 | 1.1431 | .7621 |
| Min | .381 | .5716 | .7621 | .7621 | .7621 | .7621 | .1905 |
| Avg | .5637 | .6139 | .8256 | 1.0490 | .9367 | .8793 | .6073 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 304 / 22Kv Hindustan Platinum NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | .381 | .381 | | .381 | .381 | |
| 2 | .381 | .381 | .381 | | .381 | .381 | |
| 3 | .381 | .381 | .381 | | .381 | .381 | |
| 4 | .381 | .381 | .381 | | .381 | .381 | |
| 5 | .381 | .381 | .381 | | .381 | .381 | |
| 6 | .381 | .381 | .381 | | .381 | .381 | |
| 7 | .381 | .381 | .381 | | .381 | .381 | |
| 8 | .381 | .381 | .381 | .381 | .381 | .381 | .381 |
| 9 | .381 | | | .381 | .7621 | | .7621 |
| 10 | .381 | | .7621 | .7621 | .7621 | | .7621 |
| 11 | .381 | | .7621 | 1.0288 | .7621 | .7621 | .7621 |
| 12 | .381 | | 1.0669 | 1.1431 | .7621 | | .7621 |
| 13 | .381 | | | 1.1431 | .7621 | .7621 | 1.1431 |
| 14 | .381 | | | 1.1431 | .7621 | .7621 | 1.1431 |
| 15 | .381 | | | 1.1431 | .7621 | | .7621 |
| 16 | .381 | | | 1.1431 | .7621 | .7621 | .7621 |
| 17 | .5716 | | | .7621 | .7621 | | .7621 |
| 18 | .381 | | | .381 | .7621 | | .381 |
| 19 | .381 | | | .381 | .381 | | .381 |
| 20 | .381 | | | .381 | .381 | | .381 |
| 21 | .381 | | | .381 | .381 | | .381 |
| 22 | .381 | | | .381 | .381 | | .381 |
| 23 | .381 | | | .381 | .381 | | .381 |
| 24 | .381 | .381 | .381 | .381 | .381 | .381 | .381 |
| Max | .5716 | .381 | 1.0669 | 1.1431 | .7621 | .7621 | 1.1431 |
| Min | .381 | .381 | .381 | .381 | .381 | .381 | .381 |
| Avg | .3889 | .381 | .5017 | .6881 | .5398 | .4983 | .6276 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 305 / 22KV Repro Press

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | .1905 | .381 | | .381 | .381 | |
| 2 | .381 | .1905 | .381 | | .381 | .381 | |
| 3 | .381 | .1905 | .381 | | .381 | .381 | |
| 4 | .381 | .1905 | .381 | | .381 | .381 | |
| 5 | .381 | .1905 | .381 | | .381 | .381 | |
| 6 | .381 | .1905 | .381 | | .381 | .381 | |
| 7 | .381 | .1905 | .381 | | .381 | .381 | |
| 8 | .381 | .381 | .381 | .381 | .381 | .381 | .6859 |
| 9 | .381 | | | .381 | .5716 | | .381 |
| 10 | .381 | | .381 | .381 | .5716 | | .381 |
| 11 | .381 | | | .7621 | .6859 | .381 | .381 |
| 12 | .381 | | .381 | .5716 | .5716 | | .381 |
| 13 | .381 | | | .381 | .5716 | .381 | .381 |
| 14 | .381 | | | .381 | .5716 | .381 | .381 |
| 15 | .381 | | | .381 | .5716 | | .381 |
| 16 | .381 | | | .381 | .5716 | .381 | .381 |
| 17 | .381 | | | .5716 | .5716 | | .381 |
| 18 | .381 | | | .381 | .5716 | | .381 |
| 19 | .381 | | | | .5716 | | .381 |
| 20 | .381 | | | .381 | .381 | | .381 |
| 21 | .381 | | | .381 | .381 | | .381 |
| 22 | .381 | | | .381 | .381 | | .381 |
| 23 | .381 | | | .381 | .381 | | .381 |
| 24 | .381 | .1905 | .381 | .381 | .381 | .381 | .381 |
| Max | .381 | .381 | .381 | .7621 | .6859 | .381 | .6859 |
| Min | .381 | .1905 | .381 | .381 | .381 | .381 | .381 |
| Avg | .381 | .2117 | .381 | .4286 | .4731 | .381 | .3989 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 306 / 22KV L&T - II

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .381 | .381 | .381 | | .381 | .381 | |
| 2 | .381 | .381 | .381 | | .381 | .381 | |
| 3 | .381 | .381 | .381 | | .381 | .381 | |
| 4 | .381 | .381 | .381 | | .381 | .381 | |
| 5 | .381 | .381 | .381 | | | .381 | |
| 6 | .381 | .381 | .381 | | | .381 | |
| 7 | .381 | .381 | .381 | | | .381 | |
| 8 | .381 | .381 | .381 | | | .381 | .381 |
| 9 | .381 | | | .381 | .381 | | .381 |
| 10 | .381 | | .381 | .381 | .381 | | .381 |
| 11 | .381 | | .381 | .7621 | .381 | .381 | .381 |
| 12 | .381 | | .381 | .381 | .381 | | .381 |
| 13 | .381 | | | .381 | .381 | | .381 |
| 14 | .381 | | | .381 | .381 | .5716 | .381 |
| 15 | .381 | | | .381 | .381 | | .381 |
| 16 | .381 | | | .381 | .381 | .381 | .381 |
| 17 | .381 | | | .5716 | .381 | | .381 |
| 18 | .381 | | | .381 | .381 | | .381 |
| 19 | .381 | | | .381 | .381 | | .381 |
| 20 | .381 | | | .381 | .381 | | .381 |
| 21 | .381 | | | .381 | .381 | | .381 |
| 22 | .381 | | | .381 | .381 | | .381 |
| 23 | .381 | | | .381 | | | .381 |
| 24 | .381 | .381 | .381 | .381 | .381 | .381 | .1905 |
| Max | .381 | .381 | .381 | .7621 | .381 | .5716 | .381 |
| Min | .381 | .381 | .381 | .381 | .381 | .381 | .1905 |
| Avg | .381 | .381 | .381 | .4167 | .381 | .3969 | .3698 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 307 / 22 kv CTRLS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2574 | 1.3336 | 1.3717 | | | 1.3717 | |
| 2 | 1.2574 | 1.3336 | 1.3717 | | | 1.3717 | |
| 3 | 1.2574 | 1.3336 | 1.3717 | | | 1.3717 | |
| 4 | 1.2574 | 1.3336 | 1.3717 | | | 1.3717 | |
| 5 | 1.2574 | | 1.3717 | | | 1.3717 | |
| 6 | 1.2574 | 1.3336 | 1.3717 | | | 1.3717 | |
| 7 | 1.2574 | 1.3336 | 1.3717 | | | 1.3717 | |
| 8 | 1.2574 | 1.3336 | 1.3717 | 1.448 | | 1.4098 | 1.3717 |
| 9 | 1.2955 | | | 1.3336 | 1.448 | | 1.3717 |
| 10 | 1.2955 | | 1.4098 | 1.3336 | 1.448 | | 1.3717 |
| 11 | 1.2955 | | 1.448 | 1.4098 | 1.448 | 1.4098 | 1.3717 |
| 12 | 1.1431 | | 1.448 | 1.448 | 1.448 | | 1.4098 |
| 13 | 1.2955 | | | 1.448 | 1.448 | 1.4098 | 1.3717 |
| 14 | 1.2955 | | | 1.448 | 1.448 | 1.4098 | 1.3717 |
| 15 | 1.4098 | | | 1.448 | 1.448 | | 1.3717 |
| 16 | 1.4098 | | | 1.448 | 1.448 | 1.3717 | 1.3717 |
| 17 | 1.4098 | | | 1.448 | 1.448 | | 1.3717 |
| 18 | 1.4098 | | | 1.448 | 1.448 | | 1.3717 |
| 19 | 1.4098 | | | 1.3336 | 1.448 | | 1.3717 |
| 20 | 1.3336 | | | 1.3336 | 1.3717 | | 1.3717 |
| 21 | 1.448 | | | 1.3336 | 1.3717 | | 1.3336 |
| 22 | 1.3336 | | | 1.3717 | 1.3717 | | 1.2955 |
| 23 | 1.3336 | | | 1.3717 | 1.3717 | | 1.2955 |
| 24 | 1.2574 | 1.3336 | 1.3717 | 1.3336 | 1.3336 | 1.3717 | 1.3717 |
| Max | 1.448 | 1.3336 | 1.448 | 1.448 | 1.448 | 1.4098 | 1.4098 |
| Min | 1.1431 | 1.3336 | 1.3717 | 1.3336 | 1.3336 | 1.3717 | 1.2955 |
| Avg | 1.3098 | 1.3336 | 1.3876 | 1.3964 | 1.4218 | 1.3834 | 1.3627 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 308 / 22 kv Electronic Zone

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.9052 | 2.2862 | 3.0483 | | 2.2862 | 2.2862 | |
| 2 | 1.9052 | 2.2862 | 3.0483 | | 2.2862 | 2.2862 | |
| 3 | 1.9052 | 2.2862 | 3.0483 | | 2.2862 | 2.2862 | |
| 4 | 1.9052 | 2.2862 | 3.0483 | | 2.2862 | 2.2862 | |
| 5 | 1.9052 | 2.2862 | 3.0483 | | 2.2862 | 2.2862 | |
| 6 | 1.9052 | 2.2862 | 3.0483 | | 2.2862 | 2.2862 | |
| 7 | 1.9052 | 2.2862 | 3.0483 | | 2.2862 | 2.2862 | |
| 8 | 1.9052 | 2.2862 | 3.0483 | 2.2862 | 2.2862 | 2.2862 | 2.2862 |
| 9 | 1.9052 | | | 3.0483 | 3.0483 | | 3.0483 |
| 10 | 1.9052 | | 4.1914 | 3.8104 | 4.1914 | | 3.8104 |
| 11 | 1.9052 | | 4.5725 | 4.5725 | 4.1914 | 4.1914 | 3.8104 |
| 12 | 2.2862 | | 4.5725 | 4.9535 | 4.1914 | | |
| 13 | 2.2862 | | | 4.9535 | 4.1914 | 4.1914 | 3.8104 |
| 14 | 2.2862 | | | 4.9535 | 4.5725 | 4.5725 | 4.5725 |
| 15 | 2.2862 | | | 4.9535 | 4.9535 | | 4.5725 |
| 16 | 2.2862 | | | 4.9535 | 4.9535 | 4.5725 | 4.5725 |
| 17 | 2.2862 | | | 4.9535 | 4.9535 | | 4.5725 |
| 18 | 2.2862 | | | 4.9535 | 4.9535 | | 4.5725 |
| 19 | 2.2862 | | | 3.8104 | 3.4294 | | 4.5725 |
| 20 | 2.2862 | | | 3.8104 | 3.0483 | | 3.8104 |
| 21 | 2.2862 | | | 3.4294 | 3.0483 | | 3.8104 |
| 22 | 2.2862 | | | 3.0483 | 3.0483 | | 3.0483 |
| 23 | 2.2862 | | | 2.6673 | 2.6673 | | 3.0483 |
| 24 | 2.2862 | 2.2862 | 3.0483 | 2.2862 | 2.6673 | 2.6673 | 2.2862 |
| Max | 2.2862 | 2.2862 | 4.5725 | 4.9535 | 4.9535 | 4.5725 | 4.5725 |
| Min | 1.9052 | 2.2862 | 3.0483 | 2.2862 | 2.2862 | 2.2862 | 2.2862 |
| Avg | 2.1116 | 2.2862 | 3.3976 | 3.9673 | 3.3500 | 2.9604 | 3.7628 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 202 / 11KV KRISHNA TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2193 | 1.2003 | 1.1812 | 1.3336 | 1.0974 | 1.0669 | 1.1431 |
| 2 | 1.1431 | 1.166 | 1.1812 | 1.2574 | 1.0288 | .9907 | 1.0669 |
| 3 | 1.1431 | 1.0974 | 1.3146 | 1.2574 | .9602 | .9526 | 1.0669 |
| 4 | 1.1431 | 1.0288 | 1.3146 | 1.2574 | .9602 | 1.0669 | 1.0669 |
| 5 | 1.2574 | 1.0288 | 1.3908 | 1.3336 | 1.0288 | 1.1812 | 1.1812 |
| 6 | 1.3336 | 1.2003 | 1.5242 | 1.4098 | 1.2003 | 1.2955 | 1.3336 |
| 7 | 1.7147 | 1.5432 | 1.6004 | 1.7909 | 1.3203 | 1.6194 | 1.9052 |
| 8 | 1.7528 | 1.6632 | 1.8099 | 1.7718 | 1.3203 | 2.1529 | 2.0005 |
| 9 | 1.5813 | 1.749 | 1.9052 | 1.7147 | 1.8176 | 1.9624 | 1.8176 |
| 10 | 1.7147 | 1.6118 | 2.0576 | 1.6461 | 1.7909 | 1.829 | 1.6118 |
| 11 | 1.869 | 1.9052 | 2.0005 | 1.5947 | 1.7147 | 1.9433 | 1.5432 |
| 12 | 1.8004 | 1.9433 | 1.848 | 1.6461 | 1.5242 | 1.6385 | 1.5432 |
| 13 | 1.8004 | 1.7147 | 1.6194 | 1.4746 | 1.448 | 1.7147 | 1.406 |
| 14 | 1.7147 | 1.3336 | 1.3908 | 1.3717 | 1.5242 | 1.829 | 1.406 |
| 15 | 1.5432 | 1.4289 | 1.448 | 1.3032 | 1.4861 | 1.7147 | 1.4403 |
| 16 | 1.3375 | 1.5242 | 1.448 | 1.286 | 1.448 | 1.7147 | 1.4746 |
| 17 | 1.2346 | 1.6385 | 1.4861 | 1.3032 | 1.4861 | 1.4098 | 1.5432 |
| 18 | 1.4746 | 1.7147 | 1.6194 | 1.3717 | 1.7718 | 1.6385 | 1.6118 |
| 19 | 1.406 | 2.0767 | 1.9624 | 1.4232 | 1.6194 | 1.7909 | 1.6461 |
| 20 | .583 | 1.6385 | 1.9433 | 1.6461 | 1.6766 | 1.8861 | 1.7147 |
| 21 | 1.5775 | 1.7528 | 1.9243 | 1.7833 | 1.9814 | 1.8671 | 1.8347 |
| 22 | 1.5261 | 1.448 | 1.7337 | 1.6118 | 1.7337 | 1.6956 | 1.749 |
| 23 | 1.4918 | 1.7718 | 1.5051 | 1.4403 | 1.2955 | 1.6385 | 1.2517 |
| 24 | 1.2765 | 1.286 | 2.0005 | 1.3908 | 1.2003 | 1.1812 | 1.2384 |
| Max | 1.869 | 2.0767 | 2.0576 | 1.7909 | 1.9814 | 2.1529 | 2.0005 |
| Min | .583 | 1.0288 | 1.1812 | 1.2574 | .9602 | .9526 | 1.0669 |
| Avg | 1.4433 | 1.5194 | 1.6337 | 1.4758 | 1.4348 | 1.5742 | 1.4832 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 204 / 11KV Mathadi HTP

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.7452 | 2.2268 | 1.8236 | 1.8549 | 1.6972 | 1.8785 | 1.893 |
| 2 | 1.6293 | 1.682 | 1.7238 | 1.7467 | 1.6492 | 1.787 | 1.7696 |
| 3 | 1.6019 | 1.6065 | 1.6682 | 1.6659 | 1.5272 | 1.6751 | 1.7696 |
| 4 | 1.5851 | 1.5242 | 1.7093 | 1.7695 | 1.5135 | 1.7574 | 1.7482 |
| 5 | 1.6613 | 1.5669 | 1.8183 | 1.829 | 1.7642 | 1.8762 | 1.9021 |
| 6 | 1.8016 | 2.0035 | 2.175 | 2.1399 | 2.1597 | 2.2535 | 2.1902 |
| 7 | 2.2999 | 2.4562 | 2.5599 | 2.4828 | 2.5797 | 2.7434 | 2.5118 |
| 8 | 2.4608 | 2.5099 | 2.8189 | 2.7321 | 2.7179 | 2.8166 | 2.6361 |
| 9 | 2.5964 | 2.4254 | 2.7854 | 2.6612 | 2.5903 | 2.7617 | 2.5434 |
| 10 | 2.5172 | 2.1971 | 2.4341 | 2.2669 | 2.396 | 2.5164 | 2.3884 |
| 11 | 2.2806 | 2.0972 | 2.0729 | 1.9783 | 2.1544 | 2.2047 | 2.2527 |
| 12 | 2.2085 | 1.9067 | 1.8876 | 1.8027 | 1.9555 | 1.9052 | 2.023 |
| 13 | 2.0938 | 1.8016 | 1.7032 | 1.6294 | 1.8397 | 1.7977 | 1.8934 |
| 14 | 1.912 | 1.7055 | 1.6255 | 1.5303 | 1.6788 | 1.7177 | 1.8126 |
| 15 | 1.7665 | 1.6095 | 1.5569 | 1.4289 | 1.6979 | 1.6644 | 1.7482 |
| 16 | 1.56 | 1.688 | 1.6156 | 1.4518 | 1.7223 | 1.6949 | 1.7463 |
| 17 | 1.803 | 1.8945 | 1.736 | .9252 | 1.8998 | 1.8008 | 1.8724 |
| 18 | 2.266 | 2.1841 | 2.2291 | 1.9818 | 2.1407 | 2.0546 | 2.2131 |
| 19 | 2.4699 | 2.6696 | 2.6132 | 2.3411 | 2.5682 | 2.4722 | 2.4996 |
| 20 | 2.4577 | 2.6794 | 2.6071 | 2.4379 | 2.6932 | 2.5011 | 2.5438 |
| 21 | 2.4885 | 2.6833 | 2.5682 | 2.4283 | 2.6413 | 2.4928 | 2.4626 |
| 22 | 2.2946 | 2.4836 | 2.4325 | 2.239 | 2.4904 | 2.3304 | 2.3202 |
| 23 | 2.1384 | 2.3426 | 2.242 | 2.1315 | 2.3145 | 2.2588 | 2.2702 |
| 24 | 1.9821 | 1.9262 | 2.0165 | 1.9975 | 1.901 | 2.1026 | 2.1377 |
| Max | 2.5964 | 2.6833 | 2.8189 | 2.7321 | 2.7179 | 2.8166 | 2.6361 |
| Min | 1.56 | 1.5242 | 1.5569 | .9252 | 1.5135 | 1.6644 | 1.7463 |
| Avg | 2.0675 | 2.0779 | 2.1010 | 1.9772 | 2.0955 | 2.1277 | 2.1312 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 205 / 11KV Sector-22&23

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 3.0255 | 2.9356 | 3.1024 | 3.0453 | 2.9568 | 3.149 | 3.1642 |
| 2 | 2.9218 | 2.7793 | 2.9721 | 2.9172 | 2.8563 | 3.0201 | 3.0667 |
| 3 | 2.8959 | 2.7328 | 3.0377 | 2.9263 | 2.7519 | 2.902 | 3.056 |
| 4 | 2.8852 | 2.6414 | 3.0179 | 2.9431 | 2.7153 | 2.9081 | 3.0133 |
| 5 | 2.9767 | 2.9904 | 3.1596 | 3.0484 | 2.9721 | 3.2122 | 3.1474 |
| 6 | 3.0987 | 3.4926 | 3.7876 | 3.4919 | 3.5139 | 3.6504 | 3.5391 |
| 7 | 3.5665 | 3.938 | 4.2295 | 4.2798 | 4.1312 | 4.3484 | 4.2051 |
| 8 | 3.8309 | 4.0718 | 4.6693 | 4.513 | 4.2242 | 4.6297 | 4.2959 |
| 9 | 4.007 | 3.9091 | 4.2669 | 4.017 | 3.9228 | 4.3736 | 4.0264 |
| 10 | 3.9781 | 3.3569 | 3.7044 | 3.352 | 3.6824 | 3.6541 | 3.5281 |
| 11 | 3.5399 | 3.1078 | 3.091 | 2.9268 | 3.1642 | 3.1871 | 3.2891 |
| 12 | 3.2022 | 2.8837 | 2.7998 | 2.7077 | 2.9622 | 2.979 | 2.9915 |
| 13 | 2.8716 | 2.7617 | 2.5682 | 2.6025 | 2.7184 | 2.7434 | 2.806 |
| 14 | 2.8365 | 2.6261 | 2.5392 | 2.5233 | 2.5468 | 2.5675 | 2.6604 |
| 15 | 2.6208 | 2.4593 | 2.3563 | 2.2451 | 2.492 | 2.4844 | 1.3733 |
| 16 | 2.5808 | 2.5294 | 2.4295 | 2.3213 | 2.5987 | 2.4661 | 2.5789 |
| 17 | 2.8605 | 2.7526 | 2.6078 | 2.7016 | 2.7709 | 2.7099 | 2.7679 |
| 18 | 3.3139 | 3.1024 | 3.2937 | 3.0117 | 3.2358 | 3.1215 | 3.3356 |
| 19 | 3.9213 | 4.0177 | 4.0536 | 3.7216 | 3.9384 | 3.818 | 3.8999 |
| 20 | 3.8615 | 4.1 | 4.1084 | 3.7464 | 4.0856 | 3.8782 | 3.9789 |
| 21 | 3.9304 | 4.0779 | 4.1221 | 3.9136 | 4.1716 | 4.0238 | 4.0104 |
| 22 | 3.7262 | 4.0856 | 3.9445 | 3.6648 | 4.0924 | 3.9697 | 3.8923 |
| 23 | 3.4903 | 3.7822 | 3.7068 | 3.5075 | 3.8348 | 3.7608 | 3.5818 |
| 24 | 3.2846 | 3.1767 | 3.296 | 3.3173 | 3.2019 | 3.4309 | 3.4362 |
| Max | 4.007 | 4.1 | 4.6693 | 4.513 | 4.2242 | 4.6297 | 4.2959 |
| Min | 2.5808 | 2.4593 | 2.3563 | 2.2451 | 2.492 | 2.4661 | 1.3733 |
| Avg | 3.3011 | 3.2630 | 3.3693 | 3.2269 | 3.3142 | 3.3745 | 3.3185 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 206 / 11 KV P-2 S/S

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2483 | 1.1424 | 1.2407 | 1.2887 | 1.1614 | 1.4769 | 1.275 |
| 2 | 1.1538 | 1.1203 | 1.1645 | 1.2445 | 1.1096 | 1.3169 | 1.2011 |
| 3 | 1.1371 | 1.0006 | 1.1202 | 1.1523 | 1.0608 | 1.2186 | 1.1813 |
| 4 | 1.1294 | .9892 | 1.1173 | 1.1287 | .9838 | 1.2147 | 1.1653 |
| 5 | 1.1287 | 1.1096 | 1.1195 | 1.2133 | 1.0951 | 1.265 | 1.2437 |
| 6 | 1.147 | 1.4236 | 1.3771 | 1.4084 | 1.3558 | 1.4357 | 1.3657 |
| 7 | 1.2971 | 1.5768 | 1.6789 | 1.7726 | 1.6179 | 1.8107 | 1.5409 |
| 8 | 1.2993 | 1.5562 | 1.7695 | 1.7611 | 1.6129 | 1.7711 | 1.5958 |
| 9 | 1.5288 | 1.6343 | 1.7193 | 1.6808 | 1.6812 | 1.752 | 1.5333 |
| 10 | 1.8077 | 1.7223 | 1.8107 | 1.6835 | 1.8138 | 1.8724 | 1.7516 |
| 11 | 1.7649 | 1.8572 | 1.9105 | 1.7459 | 1.8587 | 1.7757 | 1.8945 |
| 12 | 1.739 | 1.9425 | 1.7306 | 1.7071 | 1.8145 | 1.7337 | 1.9212 |
| 13 | 1.6419 | 1.7733 | 1.5775 | 1.5775 | 1.7169 | 1.6636 | 1.8724 |
| 14 | 1.5585 | 1.6064 | 1.5966 | 1.5349 | 1.6003 | 1.6309 | 1.8533 |
| 15 | 1.4937 | 1.7177 | 1.6431 | 1.6034 | 1.7063 | 1.6332 | 1.8229 |
| 16 | 1.4838 | 1.7459 | 1.6286 | 1.6949 | 1.7536 | 1.6789 | 1.8157 |
| 17 | 1.5227 | 1.8199 | 1.6834 | 1.6804 | 1.8084 | 1.7406 | 1.8549 |
| 18 | 1.8111 | 1.8999 | 1.8732 | 1.7657 | 1.7489 | 1.922 | 2.0576 |
| 19 | 2.0214 | 2.3091 | 2.085 | 2.055 | 2.0805 | 2.1392 | 2.2047 |
| 20 | 2.0359 | 2.13 | 2.0942 | 2.1292 | 2.1415 | 2.047 | 2.2177 |
| 21 | 1.9719 | 1.9387 | 2.0508 | 1.9406 | 2.0004 | 1.9265 | 1.9456 |
| 22 | 1.7943 | 1.765 | 1.9334 | 1.7543 | 1.8084 | 1.835 | 1.7867 |
| 23 | 1.5722 | 1.6019 | 1.7886 | 1.6472 | 1.7894 | 1.6438 | 1.7288 |
| 24 | 1.3679 | 1.3512 | 1.4815 | 1.419 | 1.4594 | 1.5554 | 1.5089 |
| Max | 2.0359 | 2.3091 | 2.0942 | 2.1292 | 2.1415 | 2.1392 | 2.2177 |
| Min | 1.1287 | .9892 | 1.1173 | 1.1287 | .9838 | 1.2147 | 1.1653 |
| Avg | 1.5274 | 1.6139 | 1.6331 | 1.6079 | 1.6158 | 1.6691 | 1.6808 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 207 / 11KV SECTOR-19

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5891 | .6119 | .6462 | .6394 | .6089 | .6653 | .6523 |
| 2 | .5822 | .5982 | .6074 | .5898 | .5818 | .6371 | .5952 |
| 3 | .5708 | .5921 | .6112 | .586 | .578 | .6127 | .5952 |
| 4 | .5715 | .5906 | .6173 | .5837 | .5658 | .6317 | .6013 |
| 5 | .5944 | .6767 | .6927 | .65 | .6531 | .6835 | .65 |
| 6 | .6561 | .7735 | .7819 | .804 | .7438 | .8116 | .7506 |
| 7 | .7216 | .8436 | .8985 | .9106 | .8947 | .9023 | .8916 |
| 8 | .8078 | .8764 | .9908 | .9656 | .9953 | .9877 | .9396 |
| 9 | .8733 | .7556 | .855 | .8322 | .9035 | .9381 | .8337 |
| 10 | .833 | .6985 | .7529 | .7079 | .8078 | .7826 | .6721 |
| 11 | .7316 | .6416 | .6363 | .5822 | .6882 | .6546 | .6325 |
| 12 | .6797 | .583 | .6119 | .5038 | .6066 | .5883 | .6241 |
| 13 | .5956 | .5563 | .564 | .5175 | .5609 | .5472 | .6195 |
| 14 | .575 | .5144 | .506 | .5015 | .5662 | .5358 | .5928 |
| 15 | .5533 | .2835 | .4778 | .4497 | .538 | .5357 | .5738 |
| 16 | .5457 | .5571 | .5449 | .4817 | .5601 | .5555 | .5449 |
| 17 | .6073 | .6386 | .586 | .5807 | .5998 | .6302 | .7011 |
| 18 | .7442 | .7659 | .7872 | .6752 | .7552 | .7217 | .791 |
| 19 | .8573 | .9007 | .8817 | .8311 | .8908 | .9046 | .9099 |
| 20 | .8543 | .9206 | .8787 | .8611 | .9533 | .8916 | .9251 |
| 21 | .8227 | .8726 | .8756 | .8794 | .9579 | .8977 | .8916 |
| 22 | .8143 | .8551 | .8581 | .8367 | .9068 | .8764 | .8123 |
| 23 | .7308 | .8085 | .7865 | .7305 | .7964 | .762 | .78 |
| 24 | .6508 | .65 | .6912 | .6981 | .6569 | .7156 | .7171 |
| Max | .8733 | .9206 | .9908 | .9656 | .9953 | .9877 | .9396 |
| Min | .5457 | .2835 | .4778 | .4497 | .538 | .5357 | .5449 |
| Avg | .6901 | .6902 | .7142 | .6833 | .7237 | .7279 | .7207 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 208 / 11KV BEVERLY PARK -II

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5906 | .6614 | .7827 | .823 | .7864 | .8733 | .82 |
| 2 | .5822 | .6485 | .7202 | .7171 | .7255 | .7994 | .7918 |
| 3 | .5662 | .6271 | .7133 | .7003 | .7095 | .7491 | .7834 |
| 4 | .5601 | .6028 | .7064 | .6881 | .6652 | .7011 | .7864 |
| 5 | .5853 | .6393 | .7468 | .7613 | .6896 | .7088 | .8215 |
| 6 | .6241 | .7278 | .8916 | .8901 | .7689 | .801 | .9007 |
| 7 | .7415 | .9084 | 1.0349 | 1.2369 | 1.0821 | 1.1942 | 1.1256 |
| 8 | .7552 | .9793 | 1.2132 | 1.3177 | 1.1885 | 1.3108 | 1.1675 |
| 9 | .7681 | .919 | .996 | 1.0677 | 1.1119 | 1.0746 | .9876 |
| 10 | .8962 | .8013 | .871 | .8905 | .9831 | .8695 | .9015 |
| 11 | .7434 | .8116 | .7567 | .6558 | .839 | .8062 | .8764 |
| 12 | .7712 | .7926 | .66 | .6634 | .775 | .7971 | .9023 |
| 13 | .7701 | .7956 | .666 | .7026 | .8642 | .7956 | .9073 |
| 14 | .8013 | .7385 | .7507 | .7068 | .916 | .7453 | .9446 |
| 15 | .8276 | .6683 | .6881 | .7122 | .8779 | .7468 | .9046 |
| 16 | .8184 | .6645 | .682 | .7152 | .8452 | .7605 | .8405 |
| 17 | .7556 | .6005 | .6592 | .7239 | .8467 | .7278 | .8436 |
| 18 | .8882 | .6379 | .6942 | .6733 | .7178 | .746 | .8878 |
| 19 | .8791 | .8246 | .8482 | .7941 | .7964 | .9457 | .9815 |
| 20 | .876 | .8657 | .9503 | .8977 | .9122 | .9228 | .9358 |
| 21 | .8715 | .8513 | .9518 | .9373 | 1.0731 | 1.0395 | .8809 |
| 22 | .7986 | .9008 | .9754 | .8908 | .9838 | .929 | .8212 |
| 23 | .7297 | .884 | .9541 | .8501 | 1.0144 | .8756 | .8223 |
| 24 | .6691 | .751 | .8695 | .8802 | .8886 | .9183 | .8703 |
| Max | .8962 | .9793 | 1.2132 | 1.3177 | 1.1885 | 1.3108 | 1.1675 |
| Min | .5601 | .6005 | .6592 | .6558 | .6652 | .7011 | .7834 |
| Avg | .7446 | .7626 | .8243 | .8290 | .8775 | .8683 | .8960 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 301 / 22 Kv SONY DADC

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3429 | .2286 | .1524 | .2286 | .1905 | .1905 | .2667 |
| 2 | .3429 | .1905 | .1524 | .2286 | .1905 | .1905 | .2667 |
| 3 | .2667 | .1905 | .1524 | .2286 | .1905 | .1524 | .2667 |
| 4 | .2286 | .1905 | .1524 | .2286 | .1905 | .1524 | .2667 |
| 5 | .2286 | .1905 | .1524 | .2286 | .1905 | .1524 | .2667 |
| 6 | .1524 | .1905 | .1524 | .2286 | .1905 | .1524 | .2667 |
| 7 | .1524 | .1905 | .1524 | .2286 | .1905 | .1524 | .3048 |
| 8 | .1524 | .2286 | .2286 | .2286 | .1905 | .1524 | .3429 |
| 9 | .1524 | .2286 | .2667 | .2667 | .1905 | .1524 | .381 |
| 10 | .1524 | .2667 | .2667 | .2667 | .1524 | .2286 | .3429 |
| 11 | .1524 | .3048 | .3048 | .2667 | .1524 | .2286 | .3429 |
| 12 | .1905 | .3048 | .3048 | .2667 | .1524 | .2286 | .3429 |
| 13 | .1905 | .3048 | .3048 | .2667 | .1524 | .2286 | .3429 |
| 14 | .1905 | .2667 | .2667 | .2667 | .1905 | .1905 | .3429 |
| 15 | .1905 | .2667 | .2667 | .2667 | .1905 | .1905 | .3048 |
| 16 | .1905 | .3048 | .2286 | .3048 | .1905 | | .2667 |
| 17 | .2286 | .3429 | .2286 | .2667 | .1905 | .1905 | .2667 |
| 18 | .2286 | .1905 | .1905 | .2667 | .1905 | .1905 | .1905 |
| 19 | .2667 | .1524 | .1905 | .2667 | .1905 | .1905 | .1905 |
| 20 | .2667 | .1524 | .1905 | .1905 | .1524 | .1905 | .1905 |
| 21 | .2667 | .1524 | .1905 | .1905 | .1524 | .1905 | .1905 |
| 22 | .2667 | .1905 | .1905 | .1905 | .1905 | .1905 | .2667 |
| 23 | .2667 | .1524 | .3048 | .1905 | .1905 | .2667 | .2667 |
| 24 | .3429 | .2667 | .1524 | .3048 | .1905 | .1905 | .2667 |
| Max | .3429 | .3429 | .3048 | .3048 | .1905 | .2667 | .381 |
| Min | .1524 | .1524 | .1524 | .1905 | .1524 | .1524 | .1905 |
| Avg | .2254 | .2270 | .2143 | .2445 | .1810 | .1888 | .2810 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 302 / 22 KV BASF

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1431 | .7621 | 1.1431 | 1.1431 | 1.1431 | 1.2193 | 1.1431 |
| 2 | 1.1431 | .9526 | 1.1431 | 1.1431 | 1.1431 | 1.2193 | 1.1431 |
| 3 | .9526 | .9526 | 1.1431 | 1.1431 | 1.1431 | 1.2193 | 1.1431 |
| 4 | .9526 | .9526 | 1.1431 | 1.1431 | 1.1431 | 1.2193 | 1.1431 |
| 5 | .9526 | .9526 | 1.1431 | 1.1431 | 1.1431 | 1.2193 | 1.1431 |
| 6 | .9526 | .9526 | 1.1431 | 1.1431 | 1.1431 | 1.2193 | 1.1431 |
| 7 | .9526 | 1.1431 | 1.1431 | 1.1431 | 1.1431 | 1.2193 | 1.1431 |
| 8 | .9526 | 1.1431 | 1.3336 | 1.3336 | 1.1431 | 1.2574 | 1.1431 |
| 9 | .9526 | 1.1431 | 1.4098 | 1.448 | 1.3336 | 1.3336 | 1.1431 |
| 10 | .9526 | 1.3336 | 1.4861 | 1.5242 | 1.5242 | 1.5242 | 1.3336 |
| 11 | .9526 | 1.5242 | 1.5242 | 1.5242 | 1.5242 | 1.5242 | 1.3336 |
| 12 | .9526 | 1.5242 | 1.5242 | 1.5242 | 1.7147 | 1.5242 | 1.3336 |
| 13 | .9526 | 1.5242 | 1.5242 | 1.5242 | 1.5242 | 1.5242 | 1.3336 |
| 14 | .9526 | 1.3336 | 1.5242 | 1.5242 | 1.448 | 1.7147 | 1.3336 |
| 15 | .9526 | 1.5242 | 1.5242 | 1.3336 | 1.5242 | 1.7147 | 1.1431 |
| 16 | .9526 | 1.5242 | 1.5242 | 1.448 | 1.5242 | 1.5242 | 1.1431 |
| 17 | 1.1431 | 1.5242 | 1.3336 | 1.3336 | 1.6385 | 1.5242 | 1.1431 |
| 18 | 1.1431 | 1.5242 | 1.3336 | 1.1431 | 1.5242 | 1.5242 | 1.1431 |
| 19 | .9526 | 1.3717 | 1.1431 | 1.1431 | 1.5242 | 1.5242 | 1.1431 |
| 20 | .9526 | 1.3336 | 1.1431 | 1.1431 | 1.3717 | 1.5242 | 1.3336 |
| 21 | .7621 | 1.1431 | 1.1431 | 1.1431 | 1.3336 | 1.448 | 1.3336 |
| 22 | .7621 | 1.1431 | 1.0669 | 1.1431 | 1.3336 | 1.3336 | 1.3336 |
| 23 | .7621 | 1.1431 | .9526 | 1.1431 | 1.1431 | 1.1431 | 1.3336 |
| 24 | 1.1431 | 1.1431 | 1.1431 | 1.1431 | 1.1431 | 1.2193 | 1.2574 |
| Max | 1.1431 | 1.5242 | 1.5242 | 1.5242 | 1.7147 | 1.7147 | 1.3336 |
| Min | .7621 | .7621 | .9526 | 1.1431 | 1.1431 | 1.1431 | 1.1431 |
| Avg | .9685 | 1.2320 | 1.2765 | 1.2717 | 1.3448 | 1.3924 | 1.2193 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 303 / 22 KV EVEREST ANGAN

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 3.8104 | 3.4294 | 4.1914 | 3.8104 | 4.1914 | 4.1914 | 3.8104 |
| 2 | 3.8104 | 3.4294 | 4.1914 | 3.8104 | 4.1914 | 4.1914 | 3.8104 |
| 3 | 3.4294 | 3.4294 | 4.1914 | 3.8104 | 4.1914 | 3.8104 | 3.8104 |
| 4 | 3.4294 | 3.4294 | 4.1914 | 3.8104 | 3.8104 | 3.8104 | 3.8104 |
| 5 | 3.4294 | 3.4294 | 3.8104 | 3.8104 | 3.8104 | 3.8104 | 3.8104 |
| 6 | 3.6199 | 3.8104 | 4.0009 | 3.8104 | 3.8104 | 3.8104 | 3.8104 |
| 7 | 3.6199 | 3.8104 | 3.6199 | 3.8104 | 3.8104 | 3.8104 | 3.8104 |
| 8 | 3.6199 | 3.8104 | 3.8104 | 3.8104 | 3.8104 | 3.8104 | 3.8104 |
| 9 | 3.6199 | 3.8104 | 3.8104 | 4.0009 | 3.8104 | 3.8104 | 3.8104 |
| 10 | 3.4294 | 4.382 | 3.8104 | 4.1914 | 4.382 | 4.1914 | 4.1914 |
| 11 | 3.4294 | 4.5725 | 4.1914 | 4.1914 | 4.4963 | 4.1914 | 4.1914 |
| 12 | 3.4294 | 4.5725 | 4.1914 | 4.5725 | 4.4963 | 4.1914 | 4.1914 |
| 13 | 3.4294 | 4.1914 | 4.1914 | 4.5725 | 4.1914 | 3.8104 | 3.8104 |
| 14 | 3.6199 | 4.5725 | 4.1914 | 4.5725 | 4.2676 | 4.1914 | 4.1914 |
| 15 | 3.6199 | 4.5725 | 4.1914 | 4.5725 | 3.5056 | 4.1914 | 3.8104 |
| 16 | 3.6199 | 4.5725 | 4.1914 | 4.5725 | 4.2676 | 3.8104 | 3.8104 |
| 17 | 3.6199 | 4.5725 | 4.1914 | 4.5725 | 4.3439 | 3.8104 | 3.8104 |
| 18 | 3.4294 | 4.4963 | 4.1914 | 4.5725 | 4.3439 | 3.8104 | 3.8104 |
| 19 | 3.4294 | 4.4963 | 4.1914 | 4.5725 | 4.1914 | 3.8104 | 3.8104 |
| 20 | 3.4294 | 4.382 | 4.1914 | 3.8104 | 4.382 | 3.8104 | 3.8104 |
| 21 | 3.4294 | 4.1914 | 4.1914 | 3.8104 | 4.1914 | 4.1914 | 3.8104 |
| 22 | 3.2388 | 4.1152 | 4.1914 | 3.8104 | 4.0009 | 3.8104 | 3.8104 |
| 23 | 3.2388 | 4.1914 | 4.1914 | 3.8104 | 4.1914 | 3.8104 | 3.8104 |
| 24 | 3.8104 | 3.2388 | 4.382 | 4.1914 | 4.1914 | 4.1914 | 3.8104 |
| Max | 3.8104 | 4.5725 | 4.382 | 4.5725 | 4.4963 | 4.1914 | 4.1914 |
| Min | 3.2388 | 3.2388 | 3.6199 | 3.8104 | 3.5056 | 3.8104 | 3.8104 |
| Avg | 3.5246 | 4.0629 | 4.1041 | 4.1200 | 4.1200 | 3.9533 | 3.8739 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 304 / 22 KV BHAVKALESHWAR

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 2.0957 | 1.9052 |
| 2 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 2.0957 | 1.9052 |
| 3 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 2.0957 | 1.9052 |
| 4 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 |
| 5 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 |
| 6 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 |
| 7 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.7528 | 1.9052 |
| 8 | 1.9052 | 1.9052 | 2.4768 | 1.9052 | 1.9052 | 1.7528 | 1.9052 |
| 9 | 2.2862 | 2.2862 | 2.6673 | 2.2862 | 2.6673 | 1.9052 | 2.2862 |
| 10 | 2.2862 | 3.2388 | 3.0483 | 3.0483 | 3.4294 | 1.9052 | 3.0483 |
| 11 | 2.6673 | 3.4294 | 3.8104 | 3.8104 | 3.7342 | 2.2862 | 3.4294 |
| 12 | 2.6673 | 3.4294 | 3.8104 | 3.8104 | 3.4294 | 2.2862 | 3.4294 |
| 13 | 2.6673 | 3.1245 | 3.8104 | 3.8104 | 3.4294 | 2.2862 | 3.0483 |
| 14 | 3.0483 | 3.6199 | 3.8104 | 3.8104 | 3.4294 | 2.2862 | 3.4294 |
| 15 | 3.0483 | 4.0009 | 3.8104 | 3.8104 | 3.8104 | 2.2862 | 3.4294 |
| 16 | 3.0483 | 3.4294 | 3.8104 | 3.8104 | 3.8104 | 2.2862 | 3.0483 |
| 17 | | 3.8104 | 3.8104 | 3.8104 | 3.8104 | 2.2862 | 3.0483 |
| 18 | 2.6673 | 3.0483 | 3.4294 | 3.4294 | 2.9721 | 2.2862 | 3.0483 |
| 19 | 2.6673 | 2.8578 | 3.0483 | 3.4294 | 2.8578 | 2.2862 | 3.0483 |
| 20 | 2.6673 | 2.2862 | 2.2862 | 2.2862 | 2.5149 | 2.2862 | 2.2862 |
| 21 | 2.2862 | 2.0957 | 1.9052 | 2.2862 | 2.2862 | 1.9052 | 2.2862 |
| 22 | 2.2862 | 2.0957 | 1.9052 | 2.2862 | 2.21 | 1.9052 | 2.2862 |
| 23 | 2.2862 | 1.9052 | 1.9052 | 2.2862 | 2.0957 | 1.9052 | 2.2862 |
| 24 | 1.9052 | 1.9052 | 1.9814 | 1.9052 | 1.9052 | 2.0957 | 1.9052 |
| Max | 3.0483 | 4.0009 | 3.8104 | 3.8104 | 3.8104 | 2.2862 | 3.4294 |
| Min | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.9052 | 1.7528 | 1.9052 |
| Avg | 2.3359 | 2.5752 | 2.6943 | 2.7149 | 2.6514 | 2.083 | 2.5244 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 305 / 22KV N0CIL RCD

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.2862 | 2.4768 | 2.4768 | 2.2862 | 2.4768 | 2.4768 | 2.2862 |
| 2 | 2.2862 | 2.4768 | 2.4768 | 2.2862 | 2.4768 | 2.4768 | 2.2862 |
| 3 | 2.2862 | 2.4768 | 2.4768 | 2.2862 | 2.4768 | 2.4768 | 2.2862 |
| 4 | 2.2862 | 2.4768 | 2.4768 | 2.2862 | 2.2862 | 2.4768 | 2.2862 |
| 5 | 2.2862 | 2.2862 | 2.4768 | 2.2862 | 2.2862 | 2.4768 | 2.2862 |
| 6 | 2.2862 | 2.2862 | 2.4768 | 2.2862 | 2.2862 | 2.4006 | 2.2862 |
| 7 | 2.2862 | 2.2862 | 2.3624 | 2.2862 | 2.0957 | 2.3624 | 2.2862 |
| 8 | 2.2862 | 2.4768 | 2.3624 | 2.2862 | 2.0957 | 2.553 | 2.2862 |
| 9 | 2.2862 | 2.4768 | 2.553 | 2.3624 | 2.2862 | 2.4768 | 2.2862 |
| 10 | 2.2862 | 2.4768 | 2.4768 | 2.4768 | 2.4768 | 2.4768 | 2.2862 |
| 11 | 2.2862 | 2.4768 | 2.4768 | 2.4768 | 2.4768 | 2.4768 | 2.4768 |
| 12 | 2.0957 | 2.6673 | 2.4768 | 2.4768 | 2.4768 | 2.4768 | 2.4768 |
| 13 | 2.0957 | 2.2862 | 2.4768 | 2.2862 | 2.4768 | 2.6673 | 2.2862 |
| 14 | 2.2862 | 2.0957 | 2.4768 | 2.2862 | 2.4768 | 2.6673 | 2.2862 |
| 15 | 2.2862 | 2.2862 | 2.4768 | 2.2862 | 2.5911 | 2.6673 | 2.2862 |
| 16 | 2.4768 | 2.4768 | 2.4768 | 2.4768 | 2.6673 | 2.4768 | 2.4768 |
| 17 | 2.4768 | 2.2862 | 2.4768 | 2.4768 | 2.4768 | 2.2862 | 2.4768 |
| 18 | 2.4768 | 2.4387 | 2.4768 | 2.4768 | 2.553 | 2.2862 | 2.4768 |
| 19 | 2.2862 | 2.4768 | 2.2862 | 2.4768 | 2.4768 | 2.2862 | 2.4768 |
| 20 | 2.2862 | 2.4768 | 2.2862 | 2.4768 | 2.3624 | 2.4768 | 2.4768 |
| 21 | 2.4768 | 2.4768 | 2.2862 | 2.4768 | 2.6673 | 2.6673 | 2.4768 |
| 22 | 2.4768 | 2.4768 | 2.2862 | 2.4768 | 2.4768 | 2.4768 | 2.4768 |
| 23 | 2.4768 | 2.2862 | 2.2862 | 2.4768 | 2.4006 | 2.4768 | 2.4768 |
| 24 | 2.2862 | 2.2862 | 2.3624 | 2.2862 | 2.4768 | 2.4768 | 2.2862 |
| Max | 2.4768 | 2.6673 | 2.553 | 2.4768 | 2.6673 | 2.6673 | 2.4768 |
| Min | 2.0957 | 2.0957 | 2.2862 | 2.2862 | 2.0957 | 2.2862 | 2.2862 |
| Avg | 2.3180 | 2.4037 | 2.4260 | 2.3767 | 2.4291 | 2.4800 | 2.3656 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 201 / 11 KV PATEL HEIGHT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2357 | 1.7194 | 1.5927 | 1.5546 | 1.6461 | 1.6461 | 1.6832 |
| 2 | 1.1641 | 1.6289 | 1.5364 | 1.6278 | 1.5546 | 1.6095 | 1.6289 |
| 3 | 1.3073 | 1.5546 | 1.3535 | 1.5181 | 1.5023 | 1.4632 | 1.5746 |
| 4 | 1.3969 | 1.4632 | 1.4632 | 1.4632 | 1.448 | 1.39 | 1.5181 |
| 5 | 1.4327 | 1.5546 | 1.4815 | 1.5546 | 1.46 | 1.39 | 1.7375 |
| 6 | 1.4998 | 1.6827 | 1.7741 | 1.7193 | 1.6263 | 1.5181 | 1.829 |
| 7 | 1.6644 | 1.9753 | 2.7435 | 2.0119 | 1.957 | 2.1033 | 1.9753 |
| 8 | 1.8839 | 2.2032 | 2.2131 | 2.0851 | 2.1948 | 2.2131 | 1.8665 |
| 9 | 1.9204 | 2.2177 | 2.0485 | 2.1253 | 2.2177 | 2.0668 | 2.0485 |
| 10 | 2.2314 | 2.2361 | 2.0119 | 2.0144 | 2.2361 | 2.268 | 2.2314 |
| 11 | 2.0668 | 2.0513 | 2.1216 | 2.1807 | 2.1582 | | 2.2314 |
| 12 | 1.9753 | 1.9035 | 1.957 | 1.8823 | 1.8473 | | 2.1399 |
| 13 | 1.7924 | 1.8484 | 1.7558 | 1.5362 | 1.7741 | 2.1491 | 2.1033 |
| 14 | 1.7193 | 1.7002 | 1.829 | 1.6095 | 1.7558 | 2.1132 | 1.9204 |
| 15 | 1.6278 | 1.7741 | 1.6278 | 1.6095 | 1.7924 | 1.8625 | 1.8107 |
| 16 | 1.701 | 1.848 | | 1.6461 | 1.7558 | 1.6832 | 1.8839 |
| 17 | 1.7193 | 1.9589 | 1.6827 | 1.7194 | 1.9387 | 1.8804 | 1.7924 |
| 18 | 1.9185 | 1.8461 | 1.829 | 1.8642 | 2.0302 | 2.0058 | 2.2131 |
| 19 | 2.2081 | 2.2624 | 2.4326 | 2.2624 | 2.524 | 2.4253 | 2.524 |
| 20 | 2.1357 | 2.19 | 2.3594 | 2.2443 | 2.3228 | 2.3348 | 2.524 |
| 21 | 2.2624 | 2.1538 | 2.4691 | 2.19 | 2.3045 | 2.2443 | 2.3045 |
| 22 | 2.0271 | 2.1176 | 2.2314 | 2.2862 | 2.1582 | 2.0995 | 2.1399 |
| 23 | 1.8461 | 1.9004 | 1.9204 | 1.8823 | 2.0485 | 1.9936 | 1.9936 |
| 24 | 1.7013 | 1.828 | 1.8642 | 1.7741 | 1.6651 | 1.7375 | 1.7375 |
| Max | 2.2624 | 2.2624 | 2.7435 | 2.2862 | 2.524 | 2.4253 | 2.524 |
| Min | 1.1641 | 1.4632 | 1.3535 | 1.4632 | 1.448 | 1.39 | 1.5181 |
| Avg | 1.7682 | 1.9008 | 1.9260 | 1.8484 | 1.9133 | 1.9181 | 1.9755 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 202 / 11 KV HAWARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.363 | 1.4632 | 1.4998 | 1.4969 |
| 2 | | 1.307 | 1.4266 | 1.4266 | 1.4266 |
| 3 | | 1.1576 | 1.3491 | 1.39 | 1.3352 |
| 4 | | 1.1949 | 1.2567 | 1.39 | 1.2567 |
| 5 | | 1.307 | 1.2012 | 1.5089 | 1.423 |
| 6 | | 1.6617 | 1.7372 | 1.7558 | 1.7193 |
| 7 | | 2.0538 | 2.0485 | 2.0119 | 1.885 |
| 8 | 1.8665 | 2.1098 | 2.1948 | 2.1582 | 2.0883 |
| 9 | 1.7741 | 1.9404 | 1.922 | 2.1033 | 1.9022 |
| 10 | 1.7741 | 1.8665 | 1.9022 | 1.8473 | 2.0668 |
| 11 | 1.8665 | 1.7002 | 1.7741 | | 1.9753 |
| 12 | 1.6804 | 1.6278 | 1.6278 | | 1.8473 |
| 13 | 1.5497 | 1.4842 | 1.5729 | 2.1491 | 1.7924 |
| 14 | 1.3817 | 1.2437 | 1.5364 | 1.6461 | 1.4998 |
| 15 | 1.363 | 1.2883 | 1.4266 | 1.4998 | 1.5181 |
| 16 | 1.3817 | 1.4003 | 1.4449 | 1.2986 | 1.5912 |
| 17 | 1.4377 | 1.4998 | 1.4815 | 1.3535 | 1.6278 |
| 18 | 1.8671 | 1.6095 | 1.6644 | 1.6289 | 1.7375 |
| 19 | 2.2032 | 2.0668 | 2.2131 | 2.0119 | 2.2862 |
| 20 | 2.2965 | 2.2916 | 2.3594 | 2.1538 | 2.3411 |
| 21 | 2.3152 | 2.19 | 2.3594 | 2.1538 | 2.3411 |
| 22 | 2.0165 | 2.0302 | 1.9936 | 2.0633 | 2.0851 |
| 23 | 1.8111 | 1.7013 | 1.8107 | 1.8296 | 1.7558 |
| 24 | | 1.531 | 1.4998 | 1.5912 | 1.5893 |
| Max | 2.3152 | 2.2916 | 2.3594 | 2.1582 | 2.3411 |
| Min | 1.363 | 1.1576 | 1.2012 | 1.2986 | 1.2567 |
| Avg | 1.7866 | 1.6511 | 1.7194 | 1.7487 | 1.7745 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 204 / 11 KV SPARE

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2241 | .3395 | .3018 | .2987 | .381 | .3429 | .3048 |
| 2 | .1867 | .3018 | .2241 | 1.8298 | | .3429 | .3048 |
| 3 | .1867 | .3018 | .2241 | .2614 | .3429 | .3048 | .2667 |
| 4 | .1867 | .2641 | .2987 | .2614 | .3048 | .3048 | .2667 |
| 5 | .2241 | .3395 | .3361 | .2987 | .2641 | .3048 | .3018 |
| 6 | .3395 | .4527 | .3547 | .3734 | .3395 | .381 | .3018 |
| 7 | .415 | .5716 | .4108 | .5041 | .4481 | .381 | .2987 |
| 8 | .547 | .5335 | .4294 | .4854 | .547 | .6668 | .2614 |
| 9 | .4338 | .5335 | .4481 | .6036 | .5716 | .6097 | .3018 |
| 10 | .5281 | .5335 | .4668 | .4527 | .4763 | .5335 | .5093 |
| 11 | .4854 | .4338 | .7095 | .4191 | .4527 | | .679 |
| 12 | .4481 | .5093 | .4854 | .4001 | .3961 | | .2641 |
| 13 | .4481 | .4527 | .3921 | .2772 | .4715 | .2772 | .2641 |
| 14 | .2801 | .3584 | .3361 | .2587 | .381 | .4435 | .4715 |
| 15 | .3961 | .3961 | .3174 | .3429 | .362 | .3772 | .3206 |
| 16 | .3772 | .415 | .3174 | .381 | .4382 | .1867 | .2096 |
| 17 | .3395 | .4527 | .2801 | .3772 | .5716 | .2896 | .2286 |
| 18 | .3961 | .3772 | .3361 | .415 | .362 | .2614 | .4763 |
| 19 | .3961 | .3772 | .3361 | .3772 | .381 | .2614 | .5144 |
| 20 | .3584 | .3961 | .3921 | .381 | .362 | .2829 | .4001 |
| 21 | .4527 | .3772 | .4481 | .4001 | .4001 | .2829 | .4954 |
| 22 | .3772 | .3961 | .3734 | .4572 | .381 | .2829 | .4191 |
| 23 | .4338 | .3584 | .3361 | .362 | .4572 | .2858 | .4763 |
| 24 | .3174 | .3395 | .3395 | .3174 | .415 | .362 | .2667 |
| Max | .547 | .5716 | .7095 | 1.8298 | .5716 | .6668 | .679 |
| Min | .1867 | .2641 | .2241 | .2587 | .2641 | .1867 | .2096 |
| Avg | .3657 | .4088 | .3706 | .4390 | .4133 | .3530 | .3585 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 205 / 11 KV Swaraj Ghansoli

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5 | | | | | | | .0343 |
| 6 | .0335 | | | | | | .0354 |
| 7 | .0335 | .0377 | | .0572 | .0381 | | .0358 |
| 8 | | | | | .0347 | | .0366 |
| 9 | | | | .0373 | .0716 | .0514 | |
| 11 | .0335 | | | | .0514 | | |
| 12 | .0514 | | .0572 | .0532 | | | .0754 |
| 13 | .0716 | .0566 | .0381 | | .0514 | .0503 | |
| 14 | .0537 | | | | | | |
| 15 | .0358 | | | | | | |
| 16 | .0543 | | | | | | |
| 17 | .0549 | | | | | | |
| 18 | .0566 | .0373 | .0381 | | | | |
| 19 | .0566 | .0373 | .0381 | | .0514 | | .0381 |
| 20 | .0566 | | | .0566 | .0514 | .056 | .0572 |
| 21 | | | | | | .037 | |
| 22 | .0566 | | | | | | |
| 23 | .0377 | | | | | | |
| Max | .0716 | .0566 | .0572 | .0572 | .0716 | .056 | .0754 |
| Min | .0335 | .0373 | .0381 | .0373 | .0347 | .037 | .0343 |
| Avg | .0490 | .0422 | .0429 | .0511 | .05 | .0487 | .0447 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 206 / 11 KV SHAKTI SEC-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | | | | .0943 |
| 2 | | | | | | | .0377 |
| 5 | .0739 | | | .0381 | | | |
| 6 | .1463 | | .0572 | .0381 | .0381 | .0358 | .0739 |
| 7 | .1829 | .0566 | .1715 | .1715 | .1334 | .1791 | .1663 |
| 8 | .1829 | .1886 | .1905 | .1524 | .1478 | .1791 | .1663 |
| 9 | | .1886 | .1905 | .2075 | .056 | .1612 | .1698 |
| 10 | .128 | .1698 | .2096 | | .1867 | .1433 | .2096 |
| 11 | .1886 | .1698 | .0572 | .1698 | .1791 | | .1715 |
| 12 | .1886 | .1698 | | | | | |
| 13 | | .1698 | .1524 | | | .1646 | .2096 |
| 14 | .1698 | .1698 | .1715 | | .1612 | .1463 | |
| 15 | .0377 | .1886 | | .1494 | .1612 | .0554 | |
| 16 | .1509 | .1698 | | .1698 | | | |
| 17 | .0943 | .1698 | .1524 | .1109 | .0537 | | |
| 18 | .0543 | .1886 | .1524 | .1886 | .197 | .1829 | .2096 |
| 19 | .181 | .1509 | .1905 | .2033 | .0537 | .0554 | .1905 |
| 20 | .0543 | .0377 | .0572 | .2033 | .1791 | .1829 | .0572 |
| 21 | .181 | .1698 | .0381 | .1886 | .1612 | .168 | .1905 |
| 22 | .0543 | .0566 | .1715 | .0566 | .0537 | .1867 | |
| 23 | .0543 | .0377 | .0381 | .0377 | .1612 | .0377 | |
| 24 | | .1886 | .1509 | | | | .1698 |
| Max | .1886 | .1886 | .2096 | .2075 | .197 | .1867 | .2096 |
| Min | .0377 | .0377 | .0381 | .0377 | .0381 | .0358 | .0377 |
| Avg | .1249 | .1467 | .1345 | .1390 | .1282 | .1342 | .1512 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 207 / 11 KV Tulsi Graphics

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5 | .0377 | | | | | | |
| 6 | .0377 | | | | | .0381 | .0377 |
| 7 | .0377 | .0377 | | | .0566 | .0572 | .0566 |
| 8 | .0377 | .0566 | .037 | | | .0762 | |
| 9 | | .0754 | .037 | .0377 | .0754 | .0762 | |
| 10 | | .0754 | | | | .0572 | |
| 11 | | | | .056 | .0191 | | .0572 |
| 12 | | | | .0366 | | | .0572 |
| 15 | .0377 | | | | | | |
| 17 | | | | | .0381 | | |
| 18 | .0566 | .0377 | | .0377 | .0572 | .1886 | |
| 19 | | .0377 | | | | | |
| 20 | .0566 | .0381 | | .0377 | | | .0381 |
| 21 | | .0381 | .0554 | .0381 | | | .0572 |
| 22 | | .0381 | | .0377 | .0572 | | |
| 23 | .0566 | .0381 | | | | | .0381 |
| Max | .0566 | .0754 | .0554 | .056 | .0754 | .1886 | .0572 |
| Min | .0377 | .0377 | .037 | .0366 | .0191 | .0381 | .0377 |
| Avg | .0448 | .0473 | .0431 | .0402 | .0506 | .0823 | .0489 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 202 / 11 KV SECTOR 10 HTP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6289 | 1.7013 | 1.7013 | 1.7194 | 1.7013 | 1.7737 | 1.7737 |
| 2 | 1.5384 | 1.5565 | 1.5746 | 1.6108 | 1.6476 | | 1.7556 |
| 3 | 1.4842 | 1.5364 | | 1.5565 | 1.6644 | | 1.7194 |
| 4 | 1.448 | 1.5384 | | 1.5384 | 1.6461 | | 1.6651 |
| 5 | 1.5384 | 1.6297 | | 1.6651 | 1.6461 | | 1.7375 |
| 6 | 1.6651 | 1.9909 | | 1.828 | 1.9728 | | 1.9185 |
| 7 | 1.7737 | 2.1033 | | 2.0271 | 2.0995 | | 2.009 |
| 8 | 2.1538 | 2.3529 | | 2.3167 | 2.3045 | | 2.2081 |
| 9 | 2.2443 | 2.4253 | 2.4615 | 2.3348 | 2.1719 | 2.5339 | 2.371 |
| 10 | 2.2081 | 2.2805 | | 2.0814 | 2.1538 | 2.3167 | 2.19 |
| 11 | 2.2262 | 1.9547 | 2.0271 | 1.9004 | 2.0633 | 2.19 | 2.1357 |
| 12 | 2.0995 | 1.9547 | 1.9909 | 1.8823 | 1.9366 | 2.0452 | 2.0633 |
| 13 | 1.7556 | 1.8099 | 1.828 | 1.7375 | 1.7918 | 1.8642 | 1.8823 |
| 14 | 1.7556 | 1.7556 | 1.7013 | 1.6651 | | 1.7375 | 1.7918 |
| 15 | 1.7013 | 1.647 | 1.6651 | 1.5927 | 1.6832 | 1.647 | 1.7013 |
| 16 | 1.7194 | 1.5927 | 1.5565 | 1.5203 | 1.6289 | 1.647 | 1.7556 |
| 17 | 1.9185 | | 1.7737 | 1.7909 | 1.7375 | 1.7737 | 1.9004 |
| 18 | 2.2443 | 2.0814 | 2.0814 | 2.0995 | 2.0271 | 2.0271 | 2.1538 |
| 19 | 2.5789 | 2.5158 | 2.4253 | 2.4434 | 2.4977 | 2.371 | 2.5158 |
| 20 | 2.6063 | 2.6244 | 2.4796 | 2.552 | 2.6244 | 2.4615 | 2.733 |
| 21 | 2.5339 | 2.6063 | 2.5339 | 2.552 | 2.552 | 2.4434 | 2.5701 |
| 22 | 2.396 | 2.4796 | 2.3529 | 2.2986 | 2.4072 | 2.3348 | 2.371 |
| 23 | 2.0995 | 2.2443 | 2.0995 | 2.1176 | | 2.1357 | 2.1357 |
| 24 | 1.7375 | 1.8099 | 1.8823 | 1.7918 | 1.8642 | | 1.9004 |
| Max | 2.6063 | 2.6244 | 2.5339 | 2.552 | 2.6244 | 2.5339 | 2.733 |
| Min | 1.448 | 1.5364 | 1.5565 | 1.5203 | 1.6289 | 1.647 | 1.6651 |
| Avg | 1.9606 | 2.0083 | 2.0079 | 1.9426 | 1.9919 | 2.0814 | 2.0399 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 203 / 11 KV SECTOR 9

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.6263 | 1.7737 | 1.8111 | 1.7926 | 1.7741 | 1.8296 | 1.9589 |
| 2 | 1.5524 | 1.6804 | | 1.6263 | 1.7187 | | 1.8296 |
| 3 | 1.4784 | 1.6078 | 1.5893 | 1.6078 | 1.6991 | | 1.7187 |
| 4 | 1.4045 | 1.6263 | | 1.6263 | 1.6632 | | 1.6632 |
| 5 | 1.5339 | 1.7002 | | 1.7926 | 1.6632 | | 1.8111 |
| 6 | 1.7372 | 2.2916 | | 2.2916 | 2.1807 | | 2.0883 |
| 7 | 2.6242 | 2.6427 | | 3.2156 | 3.1417 | | 3.0123 |
| 8 | 2.5688 | 2.7905 | | 3.0308 | 3.271 | | 2.9938 |
| 9 | 2.6981 | 2.6797 | 2.8645 | 2.6797 | 2.9199 | 2.9199 | 2.846 |
| 10 | 2.7351 | 2.6057 | | 2.6057 | 2.7351 | 2.5873 | 2.5688 |
| 11 | 2.5503 | 2.4209 | 2.2916 | 2.2177 | 2.4025 | 2.4394 | 2.4764 |
| 12 | 2.4025 | 2.2177 | 2.1992 | 2.1437 | 2.2361 | 2.347 | 2.384 |
| 13 | 2.2916 | 3.1047 | 2.0883 | 2.0328 | 2.1807 | 2.1253 | 2.2546 |
| 14 | 2.2546 | 2.1253 | 1.9959 | 2.0328 | | 2.1253 | 2.2177 |
| 15 | 2.0328 | 1.922 | 1.9035 | | 1.9959 | 1.9404 | 2.0698 |
| 16 | 1.9404 | 1.922 | 1.922 | 1.9035 | 2.0328 | 1.8665 | 2.0883 |
| 17 | 2.1807 | | 1.9774 | 1.9959 | 2.0513 | 1.9404 | 2.1807 |
| 18 | 2.4764 | 2.3285 | 2.2546 | 2.2361 | 2.2361 | 2.1807 | 2.347 |
| 19 | 2.8645 | 2.846 | 2.846 | 2.8645 | 2.8275 | 2.6427 | 2.9938 |
| 20 | 3.2341 | 2.9199 | 3.2895 | 3.1786 | 3.3265 | 3.1417 | 3.4189 |
| 21 | 3.2526 | 2.9754 | 3.4928 | 3.3265 | 3.5482 | 3.3819 | 3.4189 |
| 22 | 2.5318 | 3.6406 | 2.6427 | 2.7351 | 2.7721 | 2.6057 | 2.6427 |
| 23 | 2.2731 | 2.4025 | 2.2916 | 2.3285 | | 2.2916 | 2.4394 |
| 24 | 1.8111 | 1.9035 | 1.9774 | 1.885 | 2.0144 | | 2.0513 |
| Max | 3.2526 | 3.6406 | 3.4928 | 3.3265 | 3.5482 | 3.3819 | 3.4189 |
| Min | 1.4045 | 1.6078 | 1.5893 | 1.6078 | 1.6632 | 1.8296 | 1.6632 |
| Avg | 2.2523 | 2.3534 | 2.3198 | 2.3109 | 2.3814 | 2.3978 | 2.3948 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 204 / 11 KV SISILY PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2721 | .2818 | .3018 | .6529 | .6432 | .285 | .3005 |
| 2 | .2688 | .2652 | .285 | .6203 | .631 | | .2846 |
| 3 | .253 | .2622 | .285 | .6188 | .6264 | | .2846 |
| 4 | .253 | .2429 | | .6346 | .634 | | .2688 |
| 5 | .253 | .2753 | | .6407 | .6458 | | .2688 |
| 6 | .2688 | .3239 | | .655 | .6458 | | .2688 |
| 7 | .2846 | .3277 | | .6754 | .6476 | | .3005 |
| 8 | .3005 | .3113 | | .6717 | .7255 | | .3005 |
| 9 | .3321 | .3605 | .3353 | .7208 | .7026 | .3856 | .3795 |
| 10 | .3441 | .3185 | | .6968 | .7469 | .3185 | .3321 |
| 11 | .3113 | .3185 | .2846 | .6463 | .6859 | .3005 | .3005 |
| 12 | .3113 | .3018 | .2846 | .6573 | .6767 | .2846 | .3005 |
| 13 | .3441 | .285 | .253 | .6336 | .6523 | .2846 | .2846 |
| 14 | .3441 | .2683 | .253 | .6097 | .3368 | .253 | .2846 |
| 15 | .2785 | .2683 | .2372 | .5387 | .6067 | .2372 | .2688 |
| 16 | .2458 | .2515 | .2214 | .5224 | .5716 | .2372 | .253 |
| 17 | .2949 | | .2372 | .5386 | .5838 | .2688 | .2688 |
| 18 | .3481 | .3018 | .2846 | .5914 | .663 | .2688 | .3005 |
| 19 | .3315 | .3185 | .3163 | .7004 | .7362 | .3163 | .3479 |
| 20 | .3688 | .3521 | .3321 | .7385 | .7834 | .3163 | .3637 |
| 21 | .373 | .3856 | .3321 | .7724 | .8123 | .3321 | .3479 |
| 22 | .3391 | .3688 | .3637 | .777 | .823 | .3479 | .3637 |
| 23 | .3185 | .3353 | .3163 | .7564 | | .3163 | .3005 |
| 24 | .2881 | .2949 | .3353 | .6824 | .3113 | | .3005 |
| Max | .373 | .3856 | .3637 | .777 | .823 | .3856 | .3795 |
| Min | .2458 | .2429 | .2214 | .5224 | .3113 | .2372 | .253 |
| Avg | .3053 | .3052 | .2921 | .6563 | .6475 | .2970 | .3031 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 205 / 11 KV BHAKTI HTP 12A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 19-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 24 | .6335 |
| Max | .6335 |
| Min | .6335 |
| Avg | .6335 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 206 / 11 KV SECTOR 8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.1253 | 2.2177 | 2.0911 | 2.0883 | 2.1253 | 2.1658 | 2.1807 |
| 2 | 1.9959 | 2.0725 | | 1.9404 | 2.0328 | | 2.0698 |
| 3 | 1.9035 | 1.9589 | | 1.885 | 1.9589 | | 2.0144 |
| 4 | 1.7556 | 1.9404 | | 1.8665 | 1.9589 | | 1.9404 |
| 5 | 1.7926 | 1.9774 | | 2.0328 | 1.9774 | | 2.0513 |
| 6 | 1.9404 | 2.7351 | | 2.3101 | 2.4394 | | 2.3285 |
| 7 | 2.7166 | 1.0164 | | 3.271 | 3.1602 | | 3.0862 |
| 8 | 2.5503 | 2.8829 | | 3.0123 | 3.0308 | | 3.0308 |
| 9 | 2.5503 | 2.6981 | 2.8006 | 2.5503 | 2.6981 | 2.782 | 2.7351 |
| 10 | 2.6797 | 2.3152 | | 2.2731 | 2.4459 | 2.5019 | 2.4579 |
| 11 | 2.4209 | 2.1658 | 2.1622 | 2.1807 | 2.3152 | 2.3101 | 2.4025 |
| 12 | 2.347 | 2.1098 | 2.0698 | 1.9774 | 2.2405 | 2.1068 | 2.3101 |
| 13 | 2.0883 | 2.9313 | 1.9035 | 1.8665 | | 1.9959 | 2.1992 |
| 14 | 2.1068 | 2.0538 | 1.7926 | 1.8296 | | 1.9035 | 1.9033 |
| 15 | 2.0513 | 1.9605 | 1.7372 | 1.7187 | 1.8298 | 1.7926 | 1.9033 |
| 16 | 1.9774 | 1.8111 | 1.7002 | 1.7372 | 1.8298 | 1.7926 | 1.9959 |
| 17 | 2.1807 | | 1.8665 | 1.848 | 1.9978 | 1.8665 | 2.1253 |
| 18 | 2.7166 | 2.3899 | 2.2916 | 2.384 | 2.3152 | 2.2177 | 2.4579 |
| 19 | 3.1232 | 2.95 | 2.8275 | 2.8645 | 3.006 | 2.7536 | 3.1971 |
| 20 | 3.4189 | 3.0434 | 3.1602 | 3.271 | 3.2674 | 3.1786 | 3.4928 |
| 21 | 3.5852 | 3.1741 | 3.5298 | 3.6037 | 3.7529 | 3.4743 | 3.5852 |
| 22 | 3.0308 | 3.7342 | 2.9384 | 3.0123 | 3.0434 | 2.9938 | 3.0678 |
| 23 | 2.6797 | 2.8567 | 2.6242 | 2.846 | | 2.6981 | 2.809 |
| 24 | 2.3101 | 1.6467 | 2.4459 | 2.3101 | 2.347 | | 2.4209 |
| Max | 3.5852 | 3.7342 | 3.5298 | 3.6037 | 3.7529 | 3.4743 | 3.5852 |
| Min | 1.7556 | 1.0164 | 1.7002 | 1.7187 | 1.8298 | 1.7926 | 1.9033 |
| Avg | 2.4186 | 2.3757 | 2.3713 | 2.3616 | 2.4654 | 2.4084 | 2.4902 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 207 / 11 KV SHUBHAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9328 | .8962 | 1.0059 | .9511 | .9694 | 1.0242 | 1.0425 |
| 2 | .8779 | .8413 | | .9328 | .9145 | | .9694 |
| 3 | .8048 | .8413 | | .8962 | .8779 | | .9328 |
| 4 | .7499 | .8688 | | .8779 | .8779 | | .8779 |
| 5 | .823 | .9412 | | .9694 | .8962 | | .8962 |
| 6 | .9694 | 1.1041 | | 1.1157 | 1.0791 | | 1.0059 |
| 7 | .9511 | 1.2254 | | 1.2254 | 1.262 | | 1.0974 |
| 8 | 1.0425 | 1.2254 | | 1.2437 | 1.2437 | | 1.1523 |
| 9 | 1.2071 | 1.3169 | 1.2803 | 1.2986 | 1.2803 | 1.3535 | 1.262 |
| 10 | 1.3352 | 1.2254 | | 1.2437 | 1.262 | 1.39 | 1.3352 |
| 11 | 1.3352 | 1.2254 | 1.1157 | 1.0791 | 1.1888 | 1.262 | 1.2437 |
| 12 | 1.3169 | 1.0974 | 1.134 | 1.0791 | 1.0242 | 1.1157 | 1.262 |
| 13 | 1.2254 | 1.0425 | 1.0242 | .9877 | | 1.0974 | 1.0974 |
| 14 | 1.1706 | 1.0425 | 1.0242 | .9328 | | 1.0242 | 1.0791 |
| 15 | 1.0608 | 1.0242 | .9511 | .9231 | .9877 | .9328 | 1.0242 |
| 16 | 1.0059 | .9694 | .9145 | .8869 | .9145 | .9145 | 1.0425 |
| 17 | 1.0791 | | .9145 | .9412 | .9511 | .9145 | .9877 |
| 18 | 1.1706 | .9694 | .9694 | .9774 | .9511 | 1.0242 | 1.1157 |
| 19 | 1.2986 | 1.262 | 1.2254 | 1.2437 | 1.2803 | 1.2803 | 1.3717 |
| 20 | 1.3491 | 1.4083 | 1.2803 | 1.2986 | 1.3169 | 1.2986 | 1.4083 |
| 21 | 1.3676 | 1.3352 | 1.2986 | 1.3352 | 1.3169 | 1.3535 | 1.262 |
| 22 | 1.2803 | 1.2803 | 1.2803 | 1.2437 | 1.2803 | 1.3352 | 1.2254 |
| 23 | 1.1643 | 1.2071 | 1.1523 | 1.1888 | | 1.2437 | 1.1888 |
| 24 | .9877 | 1.0425 | 1.0791 | 1.0059 | 1.0425 | | 1.0974 |
| Max | 1.3676 | 1.4083 | 1.2986 | 1.3352 | 1.3169 | 1.39 | 1.4083 |
| Min | .7499 | .8413 | .9145 | .8779 | .8779 | .9145 | .8779 |
| Avg | 1.1044 | 1.1040 | 1.1031 | 1.0782 | 1.0913 | 1.1603 | 1.1241 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 301 / 22 KV MBP I (I/C)

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 18-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 4.5725 |
| 2 | 4.3591 |
| 3 | 4.2372 |
| 4 | 4.2372 |
| 5 | 4.2067 |
| 6 | 4.2067 |
| 7 | 4.7859 |
| 8 | 5.3041 |
| 9 | 6.5234 |
| 10 | 7.8647 |
| 11 | 8.5963 |
| 12 | 8.5048 |
| 13 | 8.9316 |
| 14 | 8.9621 |
| 15 | 9.1754 |
| 16 | 9.4803 |
| 17 | 9.1145 |
| 18 | 9.145 |
| 19 | 8.9316 |
| 20 | 8.4743 |
| 21 | 7.0416 |
| 22 | 6.371 |
| 23 | 5.6394 |
| 24 | 4.9383 |
| Max | 9.4803 |
| Min | 4.2067 |
| Avg | 6.8168 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 303 / 22KVPETROLPUMP

SHEDDABLE FEEDER HAVING WEEKLY

FDR.MAHAPES/STN Feeder KV- 22 /
OUTGOING

STAGGERING (MIDC, EQUIVALENT)

| DATE | 17-JAN-17 | 18-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 12.9858 | 12.4067 |
| 2 | 12.681 | 12.5591 |
| 3 | 12.1323 | 11.8275 |
| 4 | 11.7055 | 11.797 |
| 5 | 11.4617 | 11.3702 |
| 6 | 11.4007 | 11.5531 |
| 7 | 10.8825 | 10.974 |
| 8 | 10.7911 | 10.6996 |
| 9 | 12.0409 | 10.8825 |
| 10 | 17.1011 | 16.3695 |
| 11 | 20.3933 | 19.936 |
| 12 | 22.5576 | 21.704 |
| 13 | 22.649 | 22.1003 |
| 14 | 19.7226 | 20.0579 |
| 15 | 22.1308 | 22.1003 |
| 16 | 21.9784 | 22.5271 |
| 17 | 21.3687 | 22.649 |
| 18 | 21.826 | 22.0698 |
| 19 | 19.4178 | 20.5762 |
| 20 | 16.7658 | 17.9241 |
| 21 | 14.9368 | 15.2416 |
| 22 | 13.7784 | 13.3516 |
| 23 | 13.1383 | 12.9554 |
| 24 | 12.2542 | 12.681 |
| Max | 22.649 | 22.649 |
| Min | 10.7911 | 10.6996 |
| Avg | 16.0875 | 16.0964 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 305 / MHAPE MIDC - 1

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 18-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 6.2186 |
| 2 | 6.1576 |
| 3 | 6.0052 |
| 4 | 5.7918 |
| 5 | 5.7308 |
| 6 | 5.4565 |
| 7 | 5.5479 |
| 8 | 6.0662 |
| 9 | 7.4074 |
| 10 | 9.1754 |
| 11 | 11.0044 |
| 12 | 12.1018 |
| 13 | 11.797 |
| 14 | 10.8215 |
| 15 | 12.0713 |
| 16 | 11.8275 |
| 17 | 11.5836 |
| 18 | 11.6141 |
| 19 | 10.4557 |
| 20 | 8.8401 |
| 21 | 8.078 |
| 22 | 7.4074 |
| 23 | 6.6149 |
| 24 | 6.2795 |
| Max | 12.1018 |
| Min | 5.4565 |
| Avg | 8.5023 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 307 / 22KV HARDILLIYA FDR MAHAPE SHEDDABLE FEEDER HAVING WEEKLY
S/S Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 20-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 7.255 |
| 2 | 6.9197 |
| 3 | 6.7063 |
| 4 | 6.371 |
| 5 | 6.0052 |
| 6 | 6.1271 |
| 7 | 5.8528 |
| 8 | 5.6699 |
| 9 | 6.2491 |
| 10 | 7.8647 |
| 11 | 8.5353 |
| 12 | 8.9925 |
| 13 | 9.2364 |
| 14 | 8.8096 |
| 15 | 8.9011 |
| 16 | 8.9925 |
| 17 | 8.8401 |
| 18 | 3.9628 |
| 19 | 6.9807 |
| 20 | 6.8892 |
| 21 | 6.371 |
| 22 | 5.9442 |
| 23 | 5.8528 |
| 24 | 5.8833 |
| Max | 9.2364 |
| Min | 3.9628 |
| Avg | 7.0505 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 312 / 22 KV MAHAPE MIDC-II
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 20-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 6.2795 |
| 2 | 6.5844 |
| 3 | 6.4015 |
| 4 | 6.2186 |
| 5 | 5.9747 |
| 6 | 5.9137 |
| 7 | 6.0357 |
| 8 | 6.0357 |
| 9 | 6.7063 |
| 10 | 8.7792 |
| 11 | 9.9375 |
| 12 | 10.2424 |
| 13 | 10.6691 |
| 14 | 9.4498 |
| 15 | 8.6572 |
| 16 | 9.5108 |
| 17 | 9.4498 |
| 18 | 9.023 |
| 19 | 7.7427 |
| 20 | 6.9502 |
| 21 | 6.4015 |
| 22 | 6.0966 |
| 23 | 5.9137 |
| 24 | 5.8528 |
| Max | 10.6691 |
| Min | 5.8528 |
| Avg | 7.5344 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 314 / 22KV Krishna Steel-I
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 7.6208 | 7.316 |
| 2 | 7.6208 | 7.194 |
| 3 | 7.6818 | 7.316 |
| 4 | 7.5598 | 7.3769 |
| 5 | 7.4989 | 7.316 |
| 6 | 7.5598 | 7.194 |
| 7 | 7.6208 | 7.1331 |
| 8 | 7.4379 | 6.9502 |
| 9 | 7.6208 | 7.4379 |
| 10 | 8.1695 | 7.7427 |
| 11 | 8.2305 | 8.1695 |
| 12 | 8.5353 | 8.7792 |
| 13 | 8.5963 | 8.5963 |
| 14 | 8.6572 | 7.9256 |
| 15 | 8.4743 | 8.4134 |
| 16 | 8.3524 | 8.5353 |
| 17 | 8.4743 | 8.7792 |
| 18 | 8.2914 | 8.5353 |
| 19 | 7.9256 | 8.4134 |
| 20 | 8.2305 | 8.1085 |
| 21 | 7.8037 | 7.9256 |
| 22 | 7.4989 | |
| 23 | 7.4379 | |
| 24 | 7.255 | |
| Max | 8.6572 | 8.7792 |
| Min | 7.255 | 6.9502 |
| Avg | 7.9231 | 7.8647 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 315 / 22KV krishna steel -II
Feeder KV- 22 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 18-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 11.3398 |
| 2 | 11.1569 |
| 3 | 10.9435 |
| 4 | 10.7301 |
| 5 | 10.0595 |
| 6 | 9.907 |
| 7 | 9.968 |
| 8 | 10.3338 |
| 9 | 10.4557 |
| 10 | 12.5591 |
| 11 | 14.6015 |
| 12 | 15.2721 |
| 13 | 15.394 |
| 14 | 14.1137 |
| 15 | 15.5464 |
| 16 | 15.7598 |
| 17 | 16.339 |
| 18 | 15.6684 |
| 19 | 14.6015 |
| 20 | 13.9308 |
| 21 | 13.0163 |
| 22 | 11.5226 |
| 23 | 11.0959 |
| 24 | 11.4312 |
| Max | 16.339 |
| Min | 9.907 |
| Avg | 12.7394 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 201 / 11KV VASHI PLAZA OG SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6135 | .6024 | .6733 | .6201 | .6201 | .631 | .631 |
| 2 | .5847 | .5975 | .6516 | .5847 | .591 | .6556 | .5959 |
| 3 | .5552 | .5316 | .6089 | .5731 | .5552 | .691 | .567 |
| 4 | .5249 | .5359 | .5792 | .5552 | .5552 | .6733 | .5493 |
| 5 | .4961 | .5731 | .5973 | .6154 | .6036 | .7087 | .5731 |
| 6 | .5258 | .6268 | .6268 | .6154 | .6401 | .7087 | .5792 |
| 7 | .5083 | .6767 | .6379 | .6516 | .6653 | .788 | .6154 |
| 8 | .5784 | | .7087 | .7023 | .8326 | .7783 | .6584 |
| 9 | .7421 | 1.2071 | 1.0498 | 1.0136 | 1.0136 | 1.0136 | .905 |
| 10 | .8688 | 1.6108 | 1.5181 | 1.5746 | 1.6644 | 1.3969 | 1.5746 |
| 11 | | 1.8267 | 1.8642 | 1.8461 | 1.9547 | 1.7737 | 1.8823 |
| 12 | 1.3032 | 1.9004 | 2.0119 | 1.1222 | 1.9185 | 1.8823 | 2.0271 |
| 13 | 1.1946 | 1.9163 | 1.7918 | 1.7737 | 1.8625 | 1.8099 | |
| 14 | 1.086 | 1.7551 | 1.6655 | | 1.7737 | 1.6108 | 1.8461 |
| 15 | 1.0679 | 1.7737 | 1.6476 | 1.7194 | 1.7918 | 1.7556 | |
| 16 | 1.086 | 1.8983 | 1.773 | 1.7147 | 1.828 | 1.828 | 1.7375 |
| 17 | 1.086 | 1.8446 | 1.7909 | 1.8099 | 1.773 | 1.8804 | 1.828 |
| 18 | 1.0679 | 1.7372 | 1.6655 | | 1.7013 | 1.5939 | |
| 19 | | 1.6124 | 1.6476 | 1.5927 | 1.6655 | 1.6118 | 1.6289 |
| 20 | 1.086 | 1.4175 | 1.3969 | 1.4299 | 1.4352 | 1.3289 | 1.3756 |
| 21 | 1.0317 | 1.1517 | 1.1999 | 1.262 | 1.1283 | 1.1462 | 1.1765 |
| 22 | .7783 | .8859 | .9036 | .9795 | .8682 | | |
| 23 | .7059 | .7499 | .7265 | .7762 | .7602 | | .7577 |
| 24 | .6485 | .631 | .6154 | .6485 | .6556 | .6661 | 1.828 |
| Max | 1.3032 | 1.9163 | 2.0119 | 1.8461 | 1.9547 | 1.8823 | 2.0271 |
| Min | .4961 | .5316 | .5792 | .5552 | .5552 | .631 | .5493 |
| Avg | .8245 | 1.2201 | 1.1813 | 1.0991 | 1.2024 | 1.2242 | 1.1668 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 202 / 11KV RAILWAY QUARTERS OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8402 | .8775 | .9145 | .9145 | .8316 | .961 | .9431 |
| 2 | .8029 | .8215 | .8779 | .8686 | .7762 | .924 | .9149 |
| 3 | .8676 | .7655 | .8413 | .8501 | .7392 | .9055 | .8871 |
| 4 | .9242 | .7095 | .9979 | .9795 | .7023 | 1.0719 | .9425 |
| 5 | .9997 | .8962 | 1.1088 | 1.1088 | .9335 | 1.2012 | .9709 |
| 6 | 1.0456 | 1.0829 | 1.1458 | 1.1763 | 1.1576 | 1.2696 | 1.1763 |
| 7 | 1.1016 | 1.2382 | 1.3817 | 1.3817 | 1.3491 | 1.386 | 1.307 |
| 8 | 1.1576 | | 1.4377 | 1.4377 | 1.307 | 1.4815 | 1.251 |
| 9 | 1.2071 | 1.3491 | 1.3676 | 1.4003 | 1.386 | 1.363 | 1.2567 |
| 10 | 1.0829 | 1.2323 | 1.3306 | 1.2136 | 1.307 | 1.423 | 1.2382 |
| 11 | | 1.1763 | 1.2936 | 1.0903 | 1.1827 | 1.1273 | 1.1706 |
| 12 | 1.1203 | 1.1763 | 1.1643 | 1.1458 | 1.2197 | 1.2382 | 1.0642 |
| 13 | 1.0082 | 1.0425 | 1.1458 | | 1.1088 | 1.1458 | |
| 14 | 1.0269 | 1.0608 | 1.0791 | | 1.0534 | 1.0974 | .9335 |
| 15 | .9055 | .9694 | 1.0719 | 1.0164 | 1.0349 | 1.0059 | |
| 16 | .9055 | .9709 | 1.1157 | | 1.0719 | 1.0164 | .9425 |
| 17 | .9795 | .9522 | 1.0791 | .9979 | 1.0974 | .9694 | |
| 18 | 1.0719 | 1.0059 | 1.0903 | | 1.1523 | 1.0425 | |
| 19 | | 1.39 | 1.3717 | 1.2752 | 1.39 | 1.3575 | 1.423 |
| 20 | 1.2752 | 1.5912 | 1.4661 | 1.5524 | 1.4632 | 1.4299 | 1.5524 |
| 21 | 1.2437 | 1.5364 | 1.3352 | 1.1643 | 1.3535 | 1.2986 | 1.4045 |
| 22 | 1.2567 | 1.0974 | 1.2071 | 1.1088 | 1.2254 | | |
| 23 | 1.0719 | 1.0974 | 1.0974 | 1.0349 | 1.134 | | 1.0903 |
| 24 | .8686 | .9335 | .9709 | .9694 | .8871 | .929 | .9425 |
| Max | 1.2752 | 1.5912 | 1.4661 | 1.5524 | 1.4632 | 1.4815 | 1.5524 |
| Min | .8029 | .7095 | .8413 | .8501 | .7023 | .9055 | .8871 |
| Avg | 1.0347 | 1.0858 | 1.1622 | 1.1343 | 1.1193 | 1.1657 | 1.1269 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 203 / 11KV MGM OG NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3772 | .3772 | .3429 | .381 | .3048 | .362 | .3239 |
| 2 | .3584 | .3584 | .3239 | .362 | .2829 | .3429 | .2858 |
| 3 | .3395 | .3395 | .3048 | .3429 | .3395 | .3048 | .2829 |
| 4 | .3239 | .3395 | .3395 | .3239 | .3584 | .3239 | .3395 |
| 5 | .3239 | .362 | .3395 | .3206 | .3584 | .3429 | .3547 |
| 6 | .3772 | .381 | .3584 | .3772 | .3961 | .362 | .3395 |
| 7 | .3361 | .3961 | .3584 | .3584 | .3961 | .381 | .3395 |
| 8 | .415 | | .3772 | .4338 | .4338 | .3429 | .3142 |
| 9 | .3772 | .4715 | .4527 | .5281 | .3206 | .4338 | .3772 |
| 10 | .4527 | .5281 | .4763 | .4338 | .415 | .4954 | .4715 |
| 11 | | .4904 | .4954 | .4527 | .415 | .4763 | .5093 |
| 12 | .3961 | .5093 | .4001 | .4904 | .415 | .4191 | .5093 |
| 13 | .3584 | .5093 | .4572 | | .4763 | .4572 | |
| 14 | .3395 | .4715 | .4715 | | .381 | .4763 | .5281 |
| 15 | .3584 | .5281 | .3772 | .3395 | .4382 | .4191 | |
| 16 | .3772 | .4527 | .4572 | | .5093 | .4382 | .4338 |
| 17 | .3961 | .415 | .4904 | .4715 | .3734 | .4572 | |
| 18 | .415 | .4715 | .4572 | | .415 | .4763 | |
| 19 | | .4572 | .4527 | .4338 | .3734 | .4382 | .4527 |
| 20 | .415 | .4763 | .5144 | .3961 | .3772 | .381 | .4338 |
| 21 | .415 | .3921 | .4904 | .415 | .3395 | | .3584 |
| 22 | .3395 | .4001 | .3772 | .3772 | .3395 | | |
| 23 | .3961 | .3239 | .4191 | .3584 | .3584 | | .3206 |
| 24 | .4108 | .3961 | .3239 | .4191 | .3048 | .4572 | .5093 |
| Max | .4527 | .5281 | .5144 | .5281 | .5093 | .4954 | .5281 |
| Min | .3239 | .3239 | .3048 | .3206 | .2829 | .3048 | .2829 |
| Avg | .3772 | .4281 | .4107 | .4008 | .3801 | .4089 | .3939 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 204 / 11KV HTP ABHYUDAYA BANK OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4715 | .415 | .4715 | .4954 | .4294 | .4904 | .415 |
| 2 | .4338 | .3772 | .4527 | .4572 | .3772 | .4527 | .4001 |
| 3 | .3961 | .3206 | .4904 | .4954 | .3584 | .415 | .362 |
| 4 | .3584 | .3206 | .3961 | .3961 | .3584 | .3961 | .362 |
| 5 | .3206 | .3772 | .3961 | .4001 | .4108 | .4338 | .415 |
| 6 | .3361 | .4527 | .415 | .4338 | .4668 | .415 | .4527 |
| 7 | .3734 | .4715 | .4715 | .4904 | .4435 | .547 | .5093 |
| 8 | .4108 | | .5093 | .5281 | .4854 | .5093 | .5281 |
| 9 | .4904 | .5975 | .6036 | .6413 | .679 | .5975 | .5914 |
| 10 | .679 | .9896 | .9522 | .9896 | .9979 | .9709 | 1.0164 |
| 11 | | 1.5546 | 1.5524 | 1.423 | 1.5708 | 1.5546 | 1.6448 |
| 12 | 1.1706 | 1.6448 | 1.4969 | 1.5181 | 1.6263 | 1.5912 | 1.6632 |
| 13 | 1.0974 | 1.5729 | 1.5181 | | 1.6095 | 1.5546 | |
| 14 | 1.0719 | 1.5546 | 1.4632 | | 1.46 | 1.4661 | 1.5524 |
| 15 | 1.0534 | 1.5181 | 1.4998 | 1.4784 | 1.587 | 1.5364 | |
| 16 | 1.0719 | 1.5729 | 1.5181 | | 1.6078 | 1.4815 | 1.6078 |
| 17 | 1.2567 | 1.5729 | 1.5546 | 1.6095 | 1.5927 | 1.5912 | |
| 18 | 1.1946 | 1.6278 | 1.6461 | | 1.5927 | 1.6461 | |
| 19 | | 1.6832 | 1.6832 | 1.5565 | 1.6118 | 1.647 | 1.701 |
| 20 | 1.1765 | 1.448 | 1.4842 | 1.46 | 1.448 | 1.4842 | 1.5708 |
| 21 | 1.1946 | 1.2986 | 1.2851 | 1.2382 | 1.2308 | | 1.386 |
| 22 | .8215 | .7577 | .7316 | .9055 | .8316 | | |
| 23 | .5228 | .547 | .5415 | .5658 | .547 | | .5975 |
| 24 | .4904 | .4527 | .4805 | .5093 | .4668 | 1.3032 | 1.5893 |
| Max | 1.2567 | 1.6832 | 1.6832 | 1.6095 | 1.6263 | 1.647 | 1.701 |
| Min | .3206 | .3206 | .3961 | .3961 | .3584 | .3961 | .362 |
| Avg | .7451 | 1.0056 | .9839 | .8796 | .9912 | 1.0516 | .9666 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 205 / 11KV NBSA OG SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5093 | .5281 | .5415 | .5281 | .5228 | .5281 | .547 |
| 2 | .4715 | .4904 | .5228 | .5281 | .4854 | .5093 | .4954 |
| 3 | .4338 | .4715 | .5041 | .5144 | .4481 | .547 | .4572 |
| 4 | .4572 | .4668 | .5658 | .5716 | .4481 | .5658 | .4572 |
| 5 | .4904 | .5228 | .6036 | .6097 | .5601 | .5847 | .5658 |
| 6 | .5281 | .5658 | .6161 | .6224 | .6722 | .6224 | .6979 |
| 7 | .5601 | .6161 | .6908 | .7167 | .7577 | .7655 | .7733 |
| 8 | .6224 | | .7545 | .7922 | .7468 | .7733 | .7545 |
| 9 | .6602 | .6348 | .7356 | .7545 | .7095 | .7356 | .6908 |
| 10 | .6979 | .6979 | .7356 | .6722 | .7733 | .7733 | .7655 |
| 11 | | .6602 | .6668 | .7282 | .7167 | .679 | .6908 |
| 12 | .6979 | .6979 | .7356 | .7762 | .7167 | .6979 | .7356 |
| 13 | .6413 | .7282 | .7468 | | .8316 | .7356 | |
| 14 | .6413 | .6348 | .6224 | | .7577 | .679 | .7095 |
| 15 | .5847 | .6224 | .6602 | .7282 | .7023 | .6224 | |
| 16 | .547 | .6224 | .679 | | .6979 | .7167 | .7468 |
| 17 | .6036 | .6602 | .6979 | .6348 | .679 | .6413 | |
| 18 | .6722 | .7282 | .8402 | | .7167 | .6908 | |
| 19 | | .8501 | 1.0164 | .9145 | 1.0349 | .9877 | .9709 |
| 20 | .961 | .9795 | 1.1523 | .9979 | 1.2012 | 1.0608 | 1.2197 |
| 21 | .924 | .9055 | .9694 | .8962 | .8962 | | .9709 |
| 22 | .8402 | .7095 | .7282 | .7577 | .8131 | | |
| 23 | .6722 | .5975 | .6602 | .6348 | .7655 | | .6722 |
| 24 | .547 | .5658 | .5601 | .547 | .5658 | .924 | .6722 |
| Max | .961 | .9795 | 1.1523 | .9979 | 1.2012 | 1.0608 | 1.2197 |
| Min | .4338 | .4668 | .5041 | .5144 | .4481 | .5093 | .4572 |
| Avg | .6256 | .6503 | .7086 | .6963 | .7175 | .7067 | .7154 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 206 / 11KV SEC-6 ROW OG SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6268 | .6089 | .6653 | .6584 | .6154 | .6154 | .6154 |
| 2 | .5973 | .5792 | .6468 | .6219 | .5914 | .5792 | .567 |
| 3 | .5611 | .543 | .6283 | .6283 | .5544 | .5487 | .5487 |
| 4 | .5853 | .5601 | .6653 | .6653 | .5121 | .6219 | .5121 |
| 5 | .6283 | .6335 | .7023 | .6838 | .6099 | .6516 | .5914 |
| 6 | .6401 | .724 | .6838 | .7207 | .7023 | .7023 | .6838 |
| 7 | .6767 | .7468 | .8316 | .8775 | .7947 | .8871 | .7762 |
| 8 | .6219 | | .8779 | .9335 | .7947 | .8589 | .8501 |
| 9 | .8316 | .8316 | .7842 | .9149 | .7947 | .8775 | .7947 |
| 10 | .8686 | .7842 | .8402 | .8402 | .8402 | .8589 | .8686 |
| 11 | | .7468 | .7282 | .7392 | .6908 | .7468 | .8215 |
| 12 | .8029 | .6908 | .6535 | .6908 | .7095 | .7655 | .7842 |
| 13 | .679 | .6219 | .5544 | | .6219 | .6838 | |
| 14 | .7167 | .5853 | .5729 | | .6099 | .6283 | .6535 |
| 15 | .6036 | .5658 | .5544 | .5975 | .5788 | .5729 | |
| 16 | .5658 | .5359 | .5175 | | .5788 | .5175 | .5788 |
| 17 | .5847 | .5729 | .6283 | .5601 | .5853 | .5853 | |
| 18 | .6099 | .7023 | .5914 | | .6401 | .5487 | |
| 19 | | .8238 | .8145 | .8215 | .8326 | .8238 | .8589 |
| 20 | .8686 | .9671 | .8954 | .9149 | .905 | .8954 | .9149 |
| 21 | .8596 | .9214 | .8596 | .8962 | .8507 | | .8775 |
| 22 | .8686 | .8417 | .8326 | .8402 | .8326 | | |
| 23 | .7316 | .7783 | .7421 | .7947 | .7602 | | .8029 |
| 24 | .6447 | .6447 | .6767 | .6697 | .6516 | .8869 | .5729 |
| Max | .8686 | .9671 | .8954 | .9335 | .905 | .8954 | .9149 |
| Min | .5611 | .5359 | .5175 | .5601 | .5121 | .5175 | .5121 |
| Avg | .6897 | .6961 | .7061 | .7535 | .6941 | .7074 | .7196 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 302 / 22KV JAYSYNTH O/G FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2003 | 1.0402 | 2.0047 | 1.5242 | 2.148 | 3.871 | 2.4265 |
| 2 | 1.2003 | 1.0136 | 1.5105 | 1.4998 | 1.9014 | 3.5014 | 2.5179 |
| 3 | 1.1363 | 1.0136 | 1.4542 | 1.4232 | 1.6352 | 3.5722 | 2.0363 |
| 4 | 1.2003 | 1.0136 | .8327 | | 1.5181 | 3.2031 | 2.6124 |
| 5 | 1.2803 | 1.0402 | .7092 | | .7826 | 3.075 | 2.4844 |
| 6 | .9602 | 1.1145 | .6751 | | .7291 | 3.03 | 2.5271 |
| 7 | .8592 | 1.1145 | .6751 | 1.4373 | .6931 | 3.0605 | 2.7142 |
| 8 | .5601 | 1.2574 | .6594 | 1.4373 | .7993 | 3.1543 | 2.8395 |
| 9 | 1.2346 | 1.9147 | 2.0686 | 2.71 | 2.4045 | 3.5657 | 5.0919 |
| 10 | 1.262 | 2.9313 | 3.8477 | 3.1935 | 3.5848 | 2.3777 | 6.4099 |
| 11 | 1.2894 | 4.4873 | 4.3381 | 3.6054 | 4.1076 | 6.8732 | 9.0534 |
| 12 | 1.2894 | 4.6394 | 3.8477 | 3.7837 | 4.3317 | 8.703 | 10.4651 |
| 13 | 1.3169 | 4.4403 | 2.9424 | 4.02 | 3.3196 | 7.9706 | 9.5093 |
| 14 | 1.1203 | 3.6507 | 2.6612 | 4.1328 | 3.3951 | 7.9924 | 8.4853 |
| 15 | 1.0669 | 4.069 | 4.0741 | 4.4873 | 3.7723 | 8.0483 | 7.4493 |
| 16 | 1.0402 | 4.7154 | 3.7346 | 3.4122 | 4.3759 | 9.3096 | 7.4775 |
| 17 | 1.0669 | 2.6273 | 3.9609 | 2.9142 | 4.0741 | 10.1722 | 6.8522 |
| 18 | .9602 | 2.4669 | 3.5818 | 2.4396 | 2.4897 | 9.0566 | 6.6939 |
| 19 | 1.0402 | 2.2771 | 3.0178 | 2.6108 | 2.1125 | 7.2916 | 5.7142 |
| 20 | 1.0402 | 1.9176 | 2.2634 | 2.4042 | 2.1502 | 4.8483 | 4.446 |
| 21 | 1.0402 | 2.2509 | 1.949 | 2.2826 | 2.452 | 4.4673 | 4.1229 |
| 22 | 1.0669 | 1.7028 | | 2.3261 | 1.8861 | 4.7935 | 3.7929 |
| 23 | 1.0669 | 1.8418 | 1.8781 | 2.3669 | 1.8861 | 2.4935 | 3.5475 |
| 24 | 1.0669 | 1.0669 | 2.1043 | 1.8781 | 2.1128 | 4.3857 | |
| Max | 1.3169 | 4.7154 | 4.3381 | 4.4873 | 4.3759 | 10.1722 | 10.4651 |
| Min | .5601 | 1.0136 | .6594 | 1.4232 | .6931 | 2.3777 | 2.0363 |
| Avg | 1.0985 | 2.3170 | 2.3822 | 2.6614 | 2.4442 | 5.3674 | 5.1856 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 303 / 22KV PFIZER FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7926 | .6958 | .9768 | 1.7162 | 2.0253 | 1.8915 | 1.0395 |
| 2 | .8421 | .7461 | .8792 | 1.541 | 1.9907 | 1.8823 | 1.0181 |
| 3 | .8124 | .7461 | .8642 | 1.5272 | 1.9552 | 1.6316 | .9877 |
| 4 | .7621 | .7545 | .7081 | .8261 | 1.8436 | 1.6347 | 1.7284 |
| 5 | .7811 | .7888 | .7215 | .8048 | 1.7584 | 1.5668 | 1.6613 |
| 6 | .8124 | .7888 | .7583 | .7834 | 1.684 | 1.5516 | 1.6316 |
| 7 | .7926 | .7888 | .7215 | 1.5654 | 1.6292 | 1.5394 | 1.5379 |
| 8 | .7926 | .823 | .451 | 1.6773 | 1.6254 | .7956 | 1.7314 |
| 9 | .8535 | .9945 | .9273 | 2.1262 | 1.8103 | 1.5142 | 2.155 |
| 10 | .945 | 1.5211 | 1.3203 | 2.447 | 2.303 | .1128 | 2.5697 |
| 11 | 1.0669 | 1.6319 | 1.358 | 2.8168 | 2.8064 | 2.7195 | 3.0345 |
| 12 | 1.1279 | 1.6319 | 1.4712 | 2.8591 | 2.9782 | 2.5751 | 3.1259 |
| 13 | 1.0974 | 1.2145 | 1.1949 | 3.0394 | 2.7892 | 2.4478 | 3.2475 |
| 14 | 1.0974 | 1.407 | 1.4712 | 3.1154 | 2.9493 | 2.6635 | 3.2752 |
| 15 | 1.1279 | 1.369 | 1.4712 | 3.0788 | 3.0902 | 2.6109 | 3.1256 |
| 16 | 1.1279 | 1.4451 | 1.4712 | 3.05 | 3.1855 | 2.4425 | 3.2008 |
| 17 | .884 | 1.1271 | 1.3957 | 2.8386 | 3.0156 | 2.4676 | 3.026 |
| 18 | .823 | .9867 | 1.1317 | 2.7365 | 2.8578 | 2.1758 | 2.8289 |
| 19 | .7926 | .9488 | .9922 | 2.328 | 2.3693 | 1.9334 | 2.4237 |
| 20 | .7011 | .8266 | .8916 | 2.2368 | 2.05 | 1.582 | 2.0681 |
| 21 | .6325 | .759 | .8573 | 2.0083 | 1.717 | 1.5363 | 1.8639 |
| 22 | .8855 | .789 | .8573 | 1.943 | .8589 | 1.6823 | 1.6852 |
| 23 | .8855 | .9273 | .7545 | 1.8757 | 1.0082 | .9297 | 1.9061 |
| 24 | .7926 | .8539 | .8996 | 1.0822 | 1.0895 | 2.0317 | |
| Max | 1.1279 | 1.6319 | 1.4712 | 3.1154 | 3.1855 | 2.7195 | 3.2752 |
| Min | .6325 | .6958 | .451 | .7834 | .8589 | .1128 | .9877 |
| Avg | .8845 | 1.0236 | 1.0227 | 2.0843 | 2.1413 | 1.8299 | 2.2118 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 304 / 22KV NOVARTIS EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / (CONTINOUS PROCESS)(NO STAGGERING)
 OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .061 | .0686 | .0644 | .0914 | .0683 | .0305 | |
| 2 | .061 | .0686 | .0652 | .0972 | .0703 | .0457 | |
| 3 | .0914 | .0686 | .0644 | .1052 | .0703 | .0686 | |
| 4 | .0914 | .0686 | .0662 | | .0617 | .0709 | .0495 |
| 5 | .0914 | .0686 | .054 | | .0388 | .0709 | .0457 |
| 6 | .0914 | .0686 | .051 | | .0373 | .0823 | .0457 |
| 7 | .08 | .0686 | .0492 | .0914 | .0348 | .0823 | .061 |
| 8 | .0914 | .0686 | .0593 | .0972 | .0373 | .0549 | .0495 |
| 9 | .1029 | .0686 | .0608 | .1016 | .0652 | .0549 | .054 |
| 10 | .1029 | .1038 | .0937 | .1024 | .0366 | .0549 | .0669 |
| 11 | .1132 | .1135 | .061 | .1216 | .0366 | .1052 | .0684 |
| 12 | .1029 | .0841 | .1029 | .054 | .0366 | .08 | .0695 |
| 13 | .1029 | .107 | .1086 | .0543 | .0549 | .061 | .1141 |
| 14 | .1029 | .1004 | .1006 | .1141 | .0549 | .0533 | .1038 |
| 15 | .1029 | .1024 | .1029 | .1127 | .0549 | .0914 | .1044 |
| 16 | .0686 | .1016 | .1006 | .0744 | .0366 | .0914 | .054 |
| 17 | .0686 | .0902 | .0457 | .0751 | .0366 | .0518 | .0464 |
| 18 | .0686 | .0879 | .0533 | .0751 | .0366 | .061 | .054 |
| 19 | .0686 | .0866 | .0533 | .1127 | .0366 | .061 | .0601 |
| 20 | .0686 | .0912 | .0533 | .0925 | .0366 | .0648 | .0617 |
| 21 | .1029 | .0929 | .0533 | .0568 | .0366 | .061 | .0627 |
| 22 | .1029 | .0966 | .0914 | .0551 | .0312 | .0533 | .0617 |
| 23 | .1029 | .0966 | .0914 | .0543 | .0305 | | .0551 |
| 24 | .0572 | .1029 | .0586 | .0914 | .0738 | .0305 | |
| Max | .1132 | .1135 | .1086 | .1216 | .0738 | .1052 | .1141 |
| Min | .0572 | .0686 | .0457 | .054 | .0305 | .0305 | .0457 |
| Avg | .0874 | .0865 | .0710 | .0872 | .0464 | .0644 | .0644 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 305 / 22KV PHIZER EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0533 | .0594 | .0652 | .099 | .114 | .0572 | |
| 2 | .0533 | .061 | .0652 | .1067 | .116 | .0572 | |
| 3 | .0533 | .061 | .0644 | .099 | .1149 | .0533 | |
| 4 | .0533 | .061 | .054 | .0457 | .1216 | .0533 | .0602 |
| 5 | .0533 | .061 | .0311 | .0457 | .0769 | .0533 | .061 |
| 6 | .0533 | .061 | .0302 | .0457 | .0753 | .0533 | .0625 |
| 7 | .0533 | .061 | .0296 | .0869 | .0753 | .0533 | .061 |
| 8 | .0533 | .0213 | .0217 | .0747 | .082 | .0533 | .0229 |
| 9 | .0229 | .0221 | .0294 | .0734 | .0811 | .0533 | .018 |
| 10 | .0229 | .0246 | .0282 | .0759 | .0808 | .0229 | .0217 |
| 11 | .0229 | .0256 | .029 | .0781 | .0808 | .0191 | .0288 |
| 12 | .0229 | .0258 | .0251 | .0705 | .0808 | .0229 | .0212 |
| 13 | .0229 | .0256 | .0213 | .0734 | .0808 | .061 | .0246 |
| 14 | .0229 | .0212 | .0251 | .0744 | .029 | .0533 | .0226 |
| 15 | .0229 | .0226 | .0114 | .0734 | .029 | .0457 | .022 |
| 16 | .0229 | .0235 | .0114 | .0705 | .0267 | .0457 | .0226 |
| 17 | .0229 | .0617 | .0229 | .069 | .0267 | .0533 | .0235 |
| 18 | .0229 | .0644 | .0305 | .0708 | .0267 | .061 | .022 |
| 19 | .0229 | .0652 | .0305 | .0734 | .0267 | .061 | .0246 |
| 20 | .0229 | .0608 | .0381 | .0744 | .0259 | .0686 | .0607 |
| 21 | .0229 | .0601 | .0381 | .0751 | .0259 | .0686 | .0614 |
| 22 | .0229 | .0652 | .0533 | .0677 | .0236 | .0686 | .0607 |
| 23 | .0229 | .0637 | .0533 | .0744 | .0564 | | .0617 |
| 24 | .0533 | .0229 | .0668 | .064 | .0652 | .0572 | |
| Max | .0533 | .0652 | .0668 | .1067 | .1216 | .0686 | .0625 |
| Min | .0229 | .0212 | .0114 | .0457 | .0236 | .0191 | .018 |
| Avg | .0343 | .0459 | .0365 | .0734 | .0643 | .0520 | .0382 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 306 / 22KV LUBRIZOL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1317 | 1.4712 | 1.0648 | 3.0076 | 3.1398 | 3.2335 | 1.6248 |
| 2 | 1.1317 | 1.4335 | 1.0616 | 3.0574 | 3.0925 | 3.155 | 1.643 |
| 3 | 1.1317 | 1.4335 | .9867 | 3.0179 | 3.1215 | 3.1611 | 1.6309 |
| 4 | 1.1317 | 1.3957 | 1.1006 | 1.5364 | 3.1124 | 3.1264 | 3.1744 |
| 5 | 1.1317 | 1.3957 | 1.2524 | 1.5272 | 3.009 | 3.1009 | 3.1367 |
| 6 | 1.1317 | 1.1317 | 1.2904 | 1.4967 | 3.0182 | 3.2026 | 3.2274 |
| 7 | 1.1317 | 1.0185 | 1.2486 | 2.8364 | 3.0609 | 3.2495 | 3.264 |
| 8 | 1.1317 | 1.0562 | 1.331 | 2.748 | 3.0286 | 3.1531 | 3.0278 |
| 9 | 1.2071 | 1.1317 | 1.3283 | 2.9036 | 3.1001 | 3.2183 | 3.0117 |
| 10 | .9808 | 1.2169 | 1.358 | 3.071 | 3.2743 | 3.1855 | 3.2189 |
| 11 | 1.1317 | 1.5165 | 1.4335 | 3.2296 | 3.4137 | 3.1741 | 3.4162 |
| 12 | 1.2449 | 1.1385 | 1.4335 | 3.2698 | 3.4359 | 3.261 | 3.2647 |
| 13 | 1.2071 | 1.3663 | 1.448 | 3.2873 | 3.5696 | 3.2998 | 3.1093 |
| 14 | 1.0562 | 1.1028 | 1.4335 | 3.2524 | 3.2762 | 3.317 | 3.111 |
| 15 | .9808 | 1.0247 | 1.4712 | 3.2357 | 3.1192 | 3.0509 | 3.0713 |
| 16 | 1.2826 | 1.0247 | 1.3957 | 3.2841 | 3.2316 | 3.0948 | 3.1124 |
| 17 | 1.2449 | 1.3525 | 1.3957 | 3.2942 | 3.3738 | 3.1307 | 3.0971 |
| 18 | 1.4712 | 1.4422 | 1.3957 | 3.1854 | 3.2834 | 3.0513 | 3.0696 |
| 19 | | 1.4422 | 1.3957 | 3.4271 | 3.3882 | 2.7557 | 3.2932 |
| 20 | 1.4712 | 1.4451 | 1.3957 | 3.3895 | 3.3768 | 3.2976 | 3.345 |
| 21 | 1.4335 | 1.2169 | 1.3957 | 3.2526 | 3.3067 | 3.2823 | 3.3041 |
| 22 | 1.4335 | 1.1006 | 1.3957 | 3.1947 | 1.5844 | 3.3863 | 3.3664 |
| 23 | 1.4335 | 1.1006 | 1.4712 | 3.1916 | 1.5466 | 1.7558 | 3.3376 |
| 24 | 1.1317 | 1.4335 | 1.4422 | 3.0899 | 1.5181 | 3.2323 | |
| Max | 1.4712 | 1.5165 | 1.4712 | 3.4271 | 3.5696 | 3.3863 | 3.4162 |
| Min | .9808 | 1.0185 | .9867 | 1.4967 | 1.5181 | 1.7558 | 1.6248 |
| Avg | 1.2071 | 1.2663 | 1.3302 | 2.9494 | 3.0159 | 3.1198 | 2.9938 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 307 / 22KV NANDKAMAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0229 | .0274 | .0019 | .1905 | .1812 | .2339 | .1219 |
| 2 | | .0274 | .0022 | .1813 | .1855 | .237 | .1219 |
| 3 | .0229 | .0263 | .0021 | .1761 | .1813 | .2279 | .125 |
| 4 | .0229 | .0263 | .0032 | .1189 | .1839 | .2279 | .1936 |
| 5 | .0229 | .0263 | .0025 | .1158 | .2002 | .2279 | .1905 |
| 6 | .0229 | .0263 | .003 | .1189 | .2078 | .2316 | .1928 |
| 7 | .0229 | .0251 | .0032 | .2682 | .2047 | .2339 | .1818 |
| 8 | .0229 | .0251 | .0033 | .5151 | .584 | .3498 | .1905 |
| 9 | .0171 | .024 | .0021 | .6935 | .682 | .4808 | .487 |
| 10 | .0171 | .0021 | .0194 | .7849 | .7621 | .1097 | .5009 |
| 11 | .0171 | .0024 | .0103 | .8235 | .8428 | .5175 | .5284 |
| 12 | .0171 | .0022 | .4961 | .8573 | .919 | .4298 | .5195 |
| 13 | .0171 | .0024 | .3898 | .8725 | .8833 | .8528 | .5173 |
| 14 | .0263 | .0024 | .3772 | .8974 | .8924 | .862 | .4245 |
| 15 | .0274 | .0022 | .4344 | .8912 | .9053 | 2.4714 | .4763 |
| 16 | .0274 | .0021 | .3772 | .8085 | .9023 | .8662 | .4611 |
| 17 | .0274 | .0022 | .3898 | .7366 | .9548 | .8524 | .3733 |
| 18 | .0274 | .0019 | .3429 | .6975 | .3734 | .6684 | .3672 |
| 19 | .0274 | .0019 | .2439 | .5257 | .1494 | .5762 | .3051 |
| 20 | .0274 | .0027 | .0914 | .2925 | .112 | .3078 | .2513 |
| 21 | .0274 | .0025 | .061 | .232 | .112 | .2469 | .2406 |
| 22 | .0274 | .0021 | .0686 | .2091 | .112 | .2058 | .1969 |
| 23 | .0274 | .0022 | .0686 | .2061 | .112 | .125 | .1771 |
| 24 | .0229 | .0274 | .0022 | .2336 | .065 | .2339 | |
| Max | .0274 | .0274 | .4961 | .8974 | .9548 | 2.4714 | .5284 |
| Min | .0171 | .0019 | .0019 | .1158 | .065 | .1097 | .1219 |
| Avg | .0235 | .0122 | .1415 | .4769 | .4462 | .4907 | .3106 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 308 / 22KV BALMER LAWARIE NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS FE Feeder KV- 22 / (CONTINOUS PROCESS)(NO STAGGERING)
 OUTGOING

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.4632 | 1.1317 | 1.594 | 1.8861 | 1.8253 | 1.773 | |
| 2 | 1.7924 | 1.1203 | 1.7873 | 2.037 | 1.7458 | 1.8861 | |
| 3 | 1.8107 | 1.1203 | 1.8217 | 1.6975 | 1.627 | 1.7353 | |
| 4 | 1.773 | 1.1949 | 1.6732 | | 1.6732 | 1.6598 | 1.8671 |
| 5 | 1.773 | 1.1949 | 1.556 | | 1.5211 | 1.6598 | 1.9616 |
| 6 | 1.7353 | 1.1949 | 1.5211 | | 1.4451 | 1.6221 | 1.8107 |
| 7 | 1.5089 | 1.1949 | 1.5181 | 1.9993 | 1.369 | 1.6221 | 1.7353 |
| 8 | 1.2071 | 1.419 | 1.6319 | 2.0748 | 1.556 | 1.8861 | 1.7353 |
| 9 | 1.3203 | 1.4937 | 1.6732 | 2.0114 | 1.8634 | 2.1125 | 2.0155 |
| 10 | 1.2071 | 1.7078 | 1.6221 | 2.0114 | 1.9616 | 2.037 | 2.1611 |
| 11 | 1.358 | 1.4422 | 1.5466 | 2.0494 | 1.8484 | 2.037 | 2.0155 |
| 12 | 1.4712 | 1.4742 | 1.6975 | 1.9912 | 1.7353 | 1.9418 | 1.9394 |
| 13 | 1.2826 | 1.7113 | 1.8107 | 1.9394 | 1.773 | 2.1879 | 1.5165 |
| 14 | 1.3203 | 1.6303 | 1.6221 | 1.9355 | 1.773 | 1.9791 | 1.8596 |
| 15 | 1.358 | 1.6682 | 2.0195 | 1.854 | 1.773 | 2.0538 | 1.8162 |
| 16 | 1.2071 | 1.9355 | 1.8484 | 2.0494 | 1.8861 | 2.0748 | 1.9912 |
| 17 | 1.1317 | 1.9892 | 1.5089 | 2.1296 | 1.4335 | 1.7353 | 2.1253 |
| 18 | 1.1317 | 1.9774 | 1.5089 | 2.148 | 1.8107 | 1.7353 | 2.1253 |
| 19 | 1.0562 | 2.0535 | 1.5089 | 2.0535 | 1.8861 | 1.7353 | 2.2012 |
| 20 | 1.1317 | 1.6732 | 1.6975 | 1.8976 | 1.5844 | 1.773 | 1.9675 |
| 21 | 1.1694 | 1.7458 | 1.9616 | 1.8034 | 2.1125 | 1.8484 | 1.8785 |
| 22 | 1.2071 | 1.9735 | .0747 | 1.7458 | 1.8484 | 2.0748 | 1.8089 |
| 23 | 1.2071 | 1.556 | 1.8671 | 1.7113 | 1.8107 | | 1.5211 |
| 24 | 1.6804 | 1.2826 | 1.5972 | 1.8671 | 1.9596 | 1.9993 | |
| Max | 1.8107 | 2.0535 | 2.0195 | 2.148 | 2.1125 | 2.1879 | 2.2012 |
| Min | 1.0562 | 1.1203 | .0747 | 1.6975 | 1.369 | 1.6221 | 1.5165 |
| Avg | 1.3876 | 1.5369 | 1.6112 | 1.9473 | 1.7426 | 1.8769 | 1.9026 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 309 / 22KV PHIZER PHARMA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEE Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2987 | .2987 | .3036 | .3018 | .3405 | .6585 | .3475 |
| 2 | .3018 | .2987 | .3036 | .3018 | .3015 | .6432 | .3445 |
| 3 | .3018 | .2987 | .3036 | .3018 | .3042 | .6402 | .3384 |
| 4 | .3018 | .2987 | .3381 | | .3416 | .6463 | .5243 |
| 5 | .3018 | .2987 | .3042 | | .3015 | .6493 | .6371 |
| 6 | .3018 | .2987 | .3423 | | .3423 | .6371 | .4481 |
| 7 | .3018 | .2987 | .3423 | .2865 | .3042 | .6432 | .6401 |
| 8 | .2987 | .2987 | .3803 | .3772 | .3423 | .3445 | .634 |
| 9 | .2987 | .3734 | .4554 | .4554 | .3795 | .8135 | .6965 |
| 10 | .2987 | .4554 | .5281 | .4919 | .5281 | .4969 | .816 |
| 11 | .2987 | .4504 | .4904 | .4934 | .4527 | 1.0269 | .9279 |
| 12 | .2987 | .454 | .5281 | .526 | .4527 | 1.1134 | .9091 |
| 13 | .2987 | .5704 | .5658 | .5693 | .4527 | 1.033 | .9248 |
| 14 | .3361 | .5704 | .6413 | .5704 | .4527 | 1.0105 | .9005 |
| 15 | .3361 | .5324 | .6036 | .5704 | .4904 | 1.0239 | .9035 |
| 16 | .2987 | .5324 | .6036 | .4944 | .4527 | .9831 | .8581 |
| 17 | .2987 | .4934 | .5281 | .4563 | .4527 | 1.0166 | .8167 |
| 18 | .2987 | .4175 | .5281 | .4133 | .3772 | .8886 | .6603 |
| 19 | .2987 | .3795 | .3772 | .4183 | .3395 | .788 | .657 |
| 20 | .2987 | .3423 | .3772 | .3795 | .3395 | .7354 | .667 |
| 21 | .2987 | .3416 | .3772 | .3416 | .3018 | .6797 | .6548 |
| 22 | .2987 | .3423 | .3018 | .3405 | .3018 | .6645 | .6542 |
| 23 | .2987 | .3416 | .3018 | .3405 | .3395 | .3475 | .6521 |
| 24 | .2743 | .3361 | .3036 | .3018 | .3416 | .6524 | |
| Max | .3361 | .5704 | .6413 | .5704 | .5281 | 1.1134 | .9279 |
| Min | .2743 | .2987 | .3018 | .2865 | .3015 | .3445 | .3384 |
| Avg | .3016 | .3884 | .4221 | .4158 | .3764 | .7557 | .6788 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 302 / 22KV AMINES FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 4.8773 | 5.487 | 4.2676 | | 3.658 |
| 2 | | 4.8773 | 5.487 | 4.2676 | | 3.658 |
| 3 | | 4.8773 | 4.8773 | 4.2676 | | 3.0483 |
| 4 | | 4.8773 | 4.8773 | 4.2676 | | 3.0483 |
| 5 | | 4.2676 | 4.8773 | 3.658 | | 3.0483 |
| 6 | | 4.2676 | 4.8773 | 4.2676 | | 3.0483 |
| 7 | | 4.2676 | 4.8773 | 4.2676 | | 3.0483 |
| 8 | | 4.2676 | 4.8773 | 4.2676 | | 3.0483 |
| 9 | 5.487 | | 5.487 | 4.2676 | | 3.658 |
| 10 | 7.316 | | 7.316 | 5.487 | | 4.2676 |
| 11 | 7.9256 | | 7.9256 | 6.7063 | | 5.487 |
| 12 | 7.9256 | | 7.9256 | 6.7063 | | 5.487 |
| 13 | 8.5353 | 7.316 | 7.316 | 6.7063 | | 5.487 |
| 14 | 6.7063 | 5.487 | 5.487 | 5.487 | | 4.8773 |
| 15 | 7.316 | 7.316 | | 6.7063 | | 5.487 |
| 16 | 7.316 | 7.316 | 6.7063 | | | 6.7063 |
| 17 | 7.316 | 7.316 | 6.7063 | | | 6.0966 |
| 18 | 7.316 | 7.316 | 6.7063 | | 3.0483 | |
| 19 | 6.7063 | 6.0966 | 5.487 | | 4.2676 | |
| 20 | 6.0966 | 5.487 | 5.487 | | 4.2676 | |
| 21 | 4.2676 | 5.487 | 4.2676 | | 3.658 | |
| 22 | 4.8773 | 5.487 | 4.2676 | | 3.658 | |
| 23 | 4.2676 | 5.487 | 4.8773 | | 3.658 | |
| 24 | 4.8773 | 5.487 | 4.8773 | | 3.0483 | |
| Max | 8.5353 | 7.316 | 7.9256 | 6.7063 | 4.2676 | 6.7063 |
| Min | 4.2676 | 4.2676 | 4.2676 | 3.658 | 3.0483 | 3.0483 |
| Avg | 6.5158 | 5.6089 | 5.6990 | 5.0399 | 3.6580 | 4.3035 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 303 / 22KV KUKSHET FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1341 | 1.949 | 1.9464 | .1341 | 1.2803 | .6173 | 1.829 |
| 2 | .144 | 1.941 | 1.9631 | .1509 | 1.8976 | .6325 | 1.8442 |
| 3 | 1.941 | .128 | 1.973 | .1257 | 1.9204 | .602 | 1.8366 |
| 4 | 1.9296 | .1143 | 1.9128 | .08 | 1.957 | .6173 | 1.8442 |
| 5 | 1.917 | .0991 | 1.885 | .061 | 1.8976 | .6173 | 1.8671 |
| 6 | 1.893 | .0762 | 1.853 | .0457 | 1.893 | .6802 | 1.8823 |
| 7 | 1.8519 | .1219 | 1.8595 | .0838 | 1.8519 | .663 | 1.8823 |
| 8 | 1.2726 | 1.2433 | 1.2422 | .1219 | 1.2879 | .663 | 1.8442 |
| 9 | 1.2422 | 1.885 | 1.9052 | 1.3793 | .0381 | .6325 | 1.7832 |
| 10 | 1.3031 | 1.9868 | 1.9868 | 2.1338 | .0838 | .5841 | 2.4337 |
| 11 | 1.2574 | 2.1658 | 2.0862 | 2.1891 | .3155 | .176 | 2.4387 |
| 12 | 1.3633 | 2.7458 | 2.1994 | 2.1658 | .2599 | .2263 | 2.4291 |
| 13 | 1.2422 | 1.9128 | 2.0744 | 1.9692 | .0457 | .1372 | 2.4242 |
| 14 | 1.2955 | 1.4647 | .3185 | 2.0919 | .2542 | .0229 | 2.3929 |
| 15 | 1.2803 | 2.1338 | .2286 | 1.9281 | .2934 | .0991 | 1.7832 |
| 16 | 1.2345 | 2.0302 | .1524 | 1.9281 | .567 | 1.2726 | 1.7299 |
| 17 | 1.3412 | 2.047 | .0152 | 1.3641 | .5361 | 1.3565 | 1.7451 |
| 18 | 1.4174 | 1.9738 | .0381 | 1.2574 | .6783 | 1.9509 | 1.8366 |
| 19 | 1.387 | 1.9204 | .0914 | 1.3336 | .6935 | 1.9585 | .6859 |
| 20 | 1.3184 | 1.2422 | .1524 | 1.3489 | .7164 | 1.9738 | .7087 |
| 21 | 1.3107 | 1.3336 | .1067 | 1.3946 | .7087 | 1.9661 | .7164 |
| 22 | 1.3031 | 1.4174 | .1067 | 1.3717 | .6783 | 1.9661 | .6935 |
| 23 | 1.2993 | 1.2422 | .0152 | 1.2879 | .6097 | 1.8213 | .6249 |
| 24 | 1.925 | 1.933 | .072 | 1.3595 | .0457 | 1.7832 | .5716 |
| Max | 1.941 | 2.7458 | 2.1994 | 2.1891 | 1.957 | 1.9738 | 2.4387 |
| Min | .1341 | .0762 | .0152 | .0457 | .0381 | .0229 | .5716 |
| Avg | 1.3585 | 1.4628 | 1.0910 | 1.1378 | .8546 | .9592 | 1.6595 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 304 / 22KV TATA TELE NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 18-JAN-17 | 19-JAN-17 | 20-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0562 | 1.0562 | 1.0562 | 1.0562 | 1.0562 | 1.0562 |
| 2 | 1.0562 | 1.0185 | 1.0185 | 1.0185 | 1.0185 | 1.0185 |
| 3 | 1.0185 | 1.0185 | 1.0562 | 1.0185 | 1.0185 | 1.0185 |
| 4 | 1.0562 | 1.0562 | 1.0185 | 1.0562 | 1.0562 | 1.0562 |
| 5 | 1.0185 | 1.0185 | 1.0185 | 1.0562 | 1.0185 | 1.0562 |
| 6 | 1.0562 | 1.0185 | 1.0562 | 1.0185 | 1.0562 | 1.0562 |
| 7 | 1.0562 | .9808 | 1.0562 | 1.0185 | 1.0562 | 1.0562 |
| 8 | 1.0185 | 1.094 | 1.0562 | 1.094 | 1.094 | 1.094 |
| 9 | 1.0185 | 1.2071 | 1.2826 | 1.2826 | 1.1694 | 1.3203 |
| 10 | 1.094 | 1.4335 | 1.3957 | 1.3957 | 1.4335 | 1.358 |
| 11 | 1.094 | 1.4712 | 1.5089 | 1.5089 | 1.4712 | 1.4335 |
| 12 | 1.094 | 1.5089 | 1.4335 | 1.5089 | 1.5089 | 1.4712 |
| 13 | 1.094 | 1.3957 | 1.4335 | 1.4712 | 1.5466 | 1.5089 |
| 14 | 1.1317 | 1.4335 | 1.4335 | 1.4712 | 1.3957 | |
| 15 | 1.094 | 1.5844 | 1.5844 | 1.5466 | 1.4712 | |
| 16 | 1.094 | 1.5466 | 1.5089 | 1.5089 | 1.5089 | |
| 17 | 1.1317 | 1.5089 | 1.4712 | 1.5089 | 1.4335 | |
| 18 | 1.094 | 1.5089 | 1.4335 | 4.3439 | 1.358 | |
| 19 | 1.094 | 1.3203 | 1.358 | 1.3203 | 1.2826 | |
| 20 | 1.094 | 1.2071 | 1.2449 | 1.2071 | 1.1694 | |
| 21 | 1.094 | 1.1317 | 1.094 | 1.1317 | 1.1694 | |
| 22 | 1.0562 | 1.1317 | 1.0562 | 1.1694 | 1.094 | |
| 23 | 1.0562 | 1.094 | 1.094 | 1.094 | 1.0562 | |
| 24 | 1.0562 | 1.0562 | 1.094 | 1.0562 | 1.0562 | 1.094 |
| Max | 1.1317 | 1.5844 | 1.5844 | 4.3439 | 1.5466 | 1.5089 |
| Min | 1.0185 | .9808 | 1.0185 | 1.0185 | 1.0185 | 1.0185 |
| Avg | 1.0720 | 1.2417 | 1.2401 | 1.3693 | 1.2291 | 1.1856 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 305 / 22KV NANDKAMAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 15-JAN-17 | 16-JAN-17 | 17-JAN-17 | 20-JAN-17 | 21-JAN-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9526 | .9907 | .8764 | | .8002 |
| 2 | 1.0669 | .9145 | .9907 | | .8383 |
| 3 | 1.0288 | .9145 | .9145 | | .7621 |
| 4 | 1.0669 | .9907 | .9145 | | .8764 |
| 5 | 1.0669 | .9907 | .7621 | | .7621 |
| 6 | 1.0288 | 1.0288 | .724 | | .6859 |
| 7 | .9526 | 1.105 | .8383 | | 1.0288 |
| 8 | .9145 | 1.448 | .8002 | .2667 | 1.0669 |
| 9 | .9526 | 1.5623 | 1.5242 | .4191 | |
| 10 | .4954 | 1.6004 | 1.4861 | 1.5242 | |
| 11 | .4954 | 1.7147 | 1.5623 | 1.0669 | |
| 12 | .5716 | 1.6766 | | 1.0288 | |
| 13 | .5335 | 1.0669 | | | |
| 14 | 1.1812 | 1.0288 | | | |
| 15 | 1.2574 | 1.0669 | | | |
| 16 | 1.2574 | 1.3336 | | | |
| 17 | 1.1431 | 1.3717 | | | |
| 18 | .8764 | 1.2193 | | 1.2193 | .1524 |
| 19 | 1.0669 | 1.1431 | | 1.2574 | |
| 20 | 1.0288 | .9145 | | 1.2574 | |
| 21 | .9526 | .8383 | | .9145 | |
| 22 | .9526 | .7621 | | .8383 | |
| 23 | .8764 | .5335 | | .8002 | |
| 24 | .8764 | .9145 | .8383 | | .7621 |
| Max | 1.2574 | 1.7147 | 1.5623 | 1.5242 | 1.0669 |
| Min | .4954 | .5335 | .724 | .2667 | .1524 |
| Avg | .9415 | 1.1304 | 1.0193 | .9630 | .7735 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 309 / 22KV KUKSHET FEEDER NO. -
7 Feeder KV- 22 / OUTGOING

| DATE | 21-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 11 | 1.7238 |
| 12 | 3.0769 |
| 13 | 3.8211 |
| 14 | 3.5818 |
| 15 | 3.5475 |
| 16 | 3.6946 |
| 17 | 3.3265 |
| 18 | 4.4723 |
| 19 | 4.0287 |
| 20 | 3.5475 |
| 21 | 3.2861 |
| 22 | 3.2526 |
| 23 | 4.0329 |
| Max | 4.4723 |
| Min | 1.7238 |
| Avg | 3.4917 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 201 / 11KV CIDCO PUMP HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .7453 | .8291 |
| 2 | .6798 | .695 |
| 3 | .6661 | .6843 |
| 4 | .6752 | .6691 |
| 5 | .663 | .6691 |
| 6 | .6645 | .6981 |
| 7 | .8871 | .884 |
| 8 | .9313 | .9465 |
| 9 | .9328 | .9572 |
| 10 | 1.1446 | 1.1721 |
| 11 | 1.3931 | 1.7071 |
| 12 | 1.48 | 1.7238 |
| 13 | 1.419 | 1.6644 |
| 14 | 1.4297 | 1.5287 |
| 15 | 1.4159 | 1.4678 |
| 16 | 1.4723 | 1.5181 |
| 17 | 1.6324 | 1.483 |
| 18 | 1.6126 | 1.5074 |
| 19 | 1.6065 | 1.6202 |
| 20 | 1.4754 | 1.5607 |
| 21 | 1.2452 | 1.3474 |
| 22 | 1.1065 | |
| 23 | 1.0639 | |
| 24 | .9938 | |
| Max | 1.6324 | 1.7238 |
| Min | .663 | .6691 |
| Avg | 1.139 | 1.2063 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 202 / 11KV MAFCO OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .6036 | .6005 |
| 2 | .5959 | .5594 |
| 3 | .5807 | .567 |
| 4 | .5761 | .5746 |
| 5 | .567 | .57 |
| 6 | .5502 | .5533 |
| 7 | .5441 | .5487 |
| 8 | .5258 | .5121 |
| 9 | .4755 | .5167 |
| 10 | .6249 | .6569 |
| 11 | 1.0486 | 1.1584 |
| 12 | 1.3839 | 1.4068 |
| 13 | 1.4342 | 1.4861 |
| 14 | 1.4998 | 1.5562 |
| 15 | 1.4647 | 1.5165 |
| 16 | 1.5714 | 1.5836 |
| 17 | 1.5684 | 1.5897 |
| 18 | 1.5485 | |
| 19 | 1.451 | |
| 20 | 1.4175 | |
| 21 | 1.1645 | |
| 22 | .9404 | |
| 23 | .6981 | |
| 24 | .6356 | |
| Max | 1.5714 | 1.5897 |
| Min | .4755 | .5121 |
| Avg | .9779 | .9386 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 203 / 11KV FRUIT MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 2.5713 | 2.5926 |
| 2 | 2.3 | 2.3426 |
| 3 | 2.2588 | 2.3777 |
| 4 | 2.396 | 2.4432 |
| 5 | 2.553 | 2.6444 |
| 6 | 2.838 | 2.9447 |
| 7 | 3.3333 | 3.3974 |
| 8 | 3.4659 | 3.4476 |
| 9 | 3.7723 | 3.8058 |
| 10 | 3.7525 | 3.8028 |
| 11 | 3.5284 | 3.7616 |
| 12 | 3.2769 | 3.5406 |
| 13 | 3.1611 | 3.376 |
| 14 | 3.0224 | 3.2038 |
| 15 | 2.8243 | 3.1276 |
| 16 | 2.8075 | 2.9447 |
| 17 | 2.899 | 3.1748 |
| 18 | 3.2556 | 3.2175 |
| 19 | 3.4141 | 3.4492 |
| 20 | 3.6488 | 3.6808 |
| 21 | 3.4675 | 3.6184 |
| 22 | 3.312 | |
| 23 | 3.1184 | |
| 24 | 2.9874 | |
| Max | 3.7723 | 3.8058 |
| Min | 2.2588 | 2.3426 |
| Avg | 3.0819 | 3.1854 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 208 / 11KV PUNJAB NATIONAL BANK SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 1.355 | 1.3474 |
| 2 | 1.2696 | 1.2544 |
| 3 | 1.2209 | 1.1934 |
| 4 | 1.1721 | 1.1812 |
| 5 | 1.1568 | 1.1279 |
| 6 | 1.259 | 1.2102 |
| 7 | 1.4068 | 1.3489 |
| 8 | 1.4159 | 1.3992 |
| 9 | 1.4784 | 1.4876 |
| 10 | 1.5623 | 1.5988 |
| 11 | 1.8473 | 2.0546 |
| 12 | 1.989 | 2.1384 |
| 13 | 1.9555 | 2.0607 |
| 14 | 1.9799 | |
| 15 | 2.0287 | |
| 16 | 2.0271 | |
| 17 | 2.018 | |
| 18 | 2.0088 | |
| 19 | 2.0348 | |
| 20 | 2.021 | |
| 21 | 1.864 | |
| 22 | 1.6766 | |
| 23 | 1.6446 | |
| 24 | 1.5562 | |
| Max | 2.0348 | 2.1384 |
| Min | 1.1568 | 1.1279 |
| Avg | 1.6645 | 1.4925 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 304 / 22KV MAFCO COLD STORAGE SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 18-JAN-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 6.8282 |
| 2 | 5.7308 |
| 3 | 5.7004 |
| 4 | 5.365 |
| 5 | 4.9992 |
| 6 | 5.1821 |
| 7 | 5.7613 |
| 8 | 6.4624 |
| 9 | 6.7368 |
| 10 | 6.8282 |
| 11 | 6.5539 |
| 12 | 7.2855 |
| 13 | 7.7732 |
| 14 | 7.6818 |
| 15 | 7.3465 |
| 16 | 7.4074 |
| 17 | 7.8037 |
| 18 | 7.5598 |
| 19 | 7.4379 |
| 20 | 6.9502 |
| 21 | 6.432 |
| 22 | 6.432 |
| 23 | 6.6149 |
| 24 | 6.4929 |
| Max | 7.8037 |
| Min | 4.9992 |
| Avg | 6.6403 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 286007 / 100/22/11KV Vashi S/Stn

Feeder No / Name : 309 / 22KV JANTA MARKET TURBHE

Feeder KV- 22 / OUTGOING

| DATE | 18-JAN-17 | 19-JAN-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | 8.5353 | 10.5472 |
| 2 | 8.3219 | 10.4862 |
| 3 | 8.3829 | 10.5167 |
| 4 | 8.2 | 10.0595 |
| 5 | 7.6818 | 10.0595 |
| 6 | 7.6208 | 10.2424 |
| 7 | 7.8951 | 9.2974 |
| 8 | 7.5294 | 9.023 |
| 9 | 7.8342 | 9.7851 |
| 10 | 9.2669 | 11.6446 |
| 11 | 11.2483 | 13.9613 |
| 12 | 12.8029 | 14.571 |
| 13 | 15.2111 | 15.9732 |
| 14 | 15.4855 | 15.0282 |
| 15 | 16.5829 | 15.6379 |
| 16 | 17.1316 | 16.0342 |
| 17 | 17.3449 | 15.455 |
| 18 | 15.6379 | 11.3702 |
| 19 | 13.5955 | 11.1264 |
| 20 | 12.0713 | 9.1754 |
| 21 | 10.0595 | 7.0721 |
| 22 | 9.023 | |
| 23 | 9.3279 | |
| 24 | 9.7851 | |
| Max | 17.3449 | 16.0342 |
| Min | 7.5294 | 7.0721 |
| Avg | 11.1073 | 11.7651 |