

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 201 / 11 KV SAKALPAPER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914					
2	.1663			.1097	.128	.0914	
4	.0924	.0914	.1109	.0914	.1109	.1097	.0924
6		.0914		.1109	.1294	.0914	
8		.1097	.0934	.1294	.0924	.1097	.112
9					.0924		
10			.1307	.1109	.1109		.1307
11						.1663	
12			.128	.1848	.128		.1867
13		.168				.1478	
14	.1663		.1463	.1478	.128		.1663
15						.1663	
16	.1848		.1663	.2218	.1294		.1848
17		.1663					
18	.1848		.1646	.2033	.128		.1463
19						.1494	
20	.1663		.1663	.1663	.1097		.1294
21		.1478				.1663	
22	.1478			.1294	.128		.1294
23			.1097				
24	.1109	.1097	.112	.1109	.1294	.1097	.112
Max	.1848	.168	.1663	.2218	.1294	.1663	.1867
Min	.0924	.0914	.0934	.0914	.0924	.0914	.0924
Avg	.1525	.1220	.1328	.1431	.1188	.1308	.139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 202 / 11 KV KUKERAJA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6838					
2	1.643			.6099	.5914	.6584	
4		.567	.6348	.5914	.5544	.5853	.6908
6		.6283		.6468	.5914	.6584	
8		.7577	.7207	.7023	.6838	.7577	.7392
9					.7207		
10			1.3121	1.2382	.7392		1.4045
11						1.8111	
12			1.4415	1.423	.8871		1.6244
14	1.643		1.423	1.4415	.8501		1.6263
15						1.7177	
16	1.6804		1.4266	1.4415	.8131		1.7002
17		1.5684					
18	1.2936		1.2382	1.0903	.7577		1.3491
19						1.2197	
20	1.0164		.8871	.9055	.8501		.9511
21		.9149				.9335	
22	.7947			.7577	.7023		.8131
23			.7682				
24	.7392	.695	.7392	.7207	.6468	.695	.7392
Max	1.6804	1.5684	1.4415	1.4415	.8871	1.8111	1.7002
Min	.7392	.567	.6348	.5914	.5544	.5853	.6908
Avg	1.2586	.8307	1.0591	.9641	.7222	1.0041	1.1638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 203 / 11 KV GAUTAM COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8501					
2	2.347			.8501	.8501	.8871	
4		.7316	.8686	.7762	.7947	.823	.8686
6		.8316		.8686	.8131	.9055	
8		1.2197	1.1016	.8686	.8501	1.2752	1.3256
9					.8871		
10			1.6244	1.3676	.9795		2.1098
11						2.5133	
12			1.7741	1.6448	1.0534		2.347
14	2.347		1.7375	1.6448	1.0534		2.396
15						2.4764	
16	2.2177		1.8296	1.5893	1.0349		2.2916
17		2.1992					
18	1.848		1.6078	1.2752	1.0349		1.957
19						1.6244	
20	1.2197		1.1643	1.1273	1.0534		1.2936
21		1.0903				1.2012	
22	1.0164			1.0349	1.0349		1.1088
23			1.0608				
24	.7392	.924	.9522	.924	.9425	.924	1.0082
Max	2.347	2.1992	1.8296	1.6448	1.0534	2.5133	2.396
Min	.7392	.7316	.8686	.7762	.7947	.823	.8686
Avg	1.6764	1.1209	1.3721	1.1643	.9525	1.4033	1.6706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 205 / 11 KV ARENJA TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.439					
2	1.134			.4066	.3696	.4251	
4		.3658	.4435	.3881	.3511	.3658	.4066
6		.439		.4066	.3696	.4251	
8		.5914	.6348	.4805	.4805	.5914	.5788
9					.5175		
10			.8402	.7392	.5544		1.1016
11						1.2136	
12			.9795	.961	.5914		1.1827
14	1.134		.9328	1.0349	.6283		1.2197
15						1.2136	
16	1.2323		1.0349	.9055	.5359		1.2567
17		1.1458					
18	.924		.9055	.7023	.4805		.961
19						.8775	
20	.6838		.6468	.6653	.5359		.7207
21		.5914				.6099	
22	.6099			.6283	.5359		.6401
23			.6036				
24	.462	.4572	.4668	.4435	.4251	.4572	.4294
Max	1.2323	1.1458	1.0349	1.0349	.6283	1.2136	1.2567
Min	.462	.3658	.4435	.3881	.3511	.3658	.4066
Avg	.8829	.5757	.7488	.6468	.4904	.6866	.8497

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 206 / 11 KV CHANDRAMUKHI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4024					
2	.3696			.3658	.2957	.3841	
4		.3475	.3696	.3475	.2772	.3292	.3921
6		.3658		.3696	.3142	.3475	
8		.4805	.4481	.4251	.3326	.5359	.4805
9					.3881		
10			1.4003	1.3306	.4435		1.8111
11						2.5206	
12			1.7002		.6099		2.2731
14	2.0911		1.5708	1.5339	.6838		2.1622
15						2.4459	
16	2.3525		1.7002	1.5154	.6099		2.4394
17		2.1253					
18	1.7002		1.3121	.8871	.5121		1.8665
19						1.4969	
20	.8871		.8131	.6653	.5729		.924
21		.6653				.7095	
22	.5544			.5359	.4572		.5544
23			.499				
24	.4251	.462	.4481	.4066	.3696	.3881	.462
Max	2.3525	2.1253	1.7002	1.5339	.6838	2.5206	2.4394
Min	.3696	.3475	.3696	.3475	.2772	.3292	.3921
Avg	1.1971	.6927	1.0262	.7621	.4513	1.0175	1.3365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 207 / 11 KV CIDCO PUMP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4435					
2	.4066			.4435	.6099	.6838	
4		.439	.5359	.4435	.5175	.6219	.5975
6		.4805		.5359	.5544	.6099	
8		.6653	.5601	.6653	.6099	.5729	.6653
9					.6653		
10			.5228	.5729	.6653		.4805
11						.4108	
12			.4805	.4251	.499		.462
14	.3921		.4024	.4066	.4251		.4108
15						.4108	
16	.4108		.4251	.4435	.4435		.4251
18	.4435		.4251	.6099	.5359		.4435
19						.7392	
20	.7095		.5359	.7577	.5914		.5914
21		.5729				.7842	
22	.5175			.7207	.7392		.5487
23			.5487				
24	.499	.499	.5788	.5359	.7207	.7023	.5359
Max	.7095	.6653	.5788	.7577	.7392	.7842	.6653
Min	.3921	.439	.4024	.4066	.4251	.4108	.4108
Avg	.4827	.5167	.5015	.5467	.5829	.6151	.5161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 208 / 11 KV INFOTECH PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8871					
2	.8501			.7762	.7392	.7947	
4		.7682	.8215	.7207	.6838	.7682	.8686
6		.7392		.8501	.7207	.8131	
8		.961	.924	.8316	.7577	.961	1.0082
9					.7947		
10			1.2567	1.2936	.499		1.5497
11						1.6817	
12			1.4415	1.3676	.924		1.7741
14	1.587		1.3491	1.3306	.8686		1.922
15						1.885	
16	1.7737		1.5708	1.2752	.8686		1.9589
18	1.5154		1.3491	1.0534	.8413		1.6817
19						1.5123	
20	1.2012		1.1088	.961	.8316		1.2567
21		1.1016				1.0534	
22	.9979			.9055	.8501		1.0719
23			1.0164				
24	.924	.924	.924	.961	.7947	.7762	1.0082
Max	1.7737	1.1016	1.5708	1.3676	.924	1.885	1.9589
Min	.8501	.7392	.8215	.7207	.499	.7682	.8686
Avg	1.2642	.8969	1.1762	1.0272	.7826	1.1384	1.41

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 209 / 11 KV RBI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2561					
2	.2402			.2012	.2587	.2561	
4		.2195	.2033	.2378	.1848	.2195	.2402
6		.2772		.2772	.1848	.2772	
8		.2033	.2614	.2033	.2033	.2561	.2614
9					.2402		
10			.2241	.2033	.2012		.2241
11						.2218	
12			.2012	.2402	.2012		.2402
14	.2033		.2033	.2402	.2033		.2218
15						.2218	
16	.2218		.2033	.2033	.2033		.2772
18	.2587		.2402	.2033	.2012		.2587
19						.3174	
20	.3067		.2957	.2957	.2772		.3326
21		.2772				.2957	
22	.2772			.2957	.2957		.2957
23			.2743				
24	.2772	.2561	.2801	.2772	.2587	.2772	.2801
Max	.3067	.2772	.2957	.2957	.2957	.3174	.3326
Min	.2033	.2033	.2012	.2012	.1848	.2195	.2218
Avg	.2550	.2482	.2387	.2399	.2241	.2603	.2632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 210 / 11 KV MTNL / DIWALA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8131					
2	.7577			.7762	.7762	.8316	
4		.7762	.8215	.7762	.7392	.8131	.8775
6		.8131		.8131	.7762	.8501	
8		.9795	.8501	.924	.8686	1.0719	1.0534
9					.8501		
10			1.4784	1.3306	.9425		2.0513
11						2.5206	
12			1.5708	1.4415	.9425		2.2497
14	2.1253		1.5524	1.4045	.9795		2.2177
15						2.4646	
16	2.2546		1.6263	1.4415	1.0349		2.347
18	1.5893		1.2696	1.1088	.924		1.7002
19						1.4969	
20	1.5708		.9795	.9425	.924		1.0791
21		.9522				1.0269	
22	.8501			.9425	.8686		.961
23			.8962				
24	.8316	.8131	.8501	.8686	.8501	.8501	.9055
Max	2.2546	.9795	1.6263	1.4415	1.0349	2.5206	2.347
Min	.7577	.7762	.8215	.7762	.7392	.8131	.8775
Avg	1.4256	.8579	1.1895	1.0642	.8828	1.3251	1.5442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 212 / 11 KV MAYURESH COSMOSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914					
2	.0924			.0739	.0739	.0914	
4		.0732	.0747	.0924	.0739	.0732	.1109
6		.0914		.0924	.0739	.0732	
8		.1097	.1109	.1109	.0924	.0914	.112
9					.1109		
10			.2587	.2218	.0924		.2614
11						.3326	
12			.2772	.2772	.1097		.3142
14	.2957		.2587	.2587	.128		.2772
15						.3326	
16	.3547		.2957	.2772	.0914		.3841
18	.2772		.2218	.2033	.0914		.2957
19						.2054	
20	.1109		.0914	.0924	.1109		.1478
21		.0934				.0924	
22	.0914			.0924	.128		.0914
23			.0924				
24	.0924	.0914	.0739	.0924	.0924	.0914	.0934
Max	.3547	.1097	.2957	.2772	.128	.3326	.3841
Min	.0914	.0732	.0739	.0739	.0739	.0732	.0914
Avg	.1878	.0918	.1755	.1571	.0976	.1537	.2088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284002 / 33/11KV Sec-11, CBD S/Stn

Feeder No / Name : 403 / 33 KV NMMC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2752					
2	1.358			.7922	1.1317	1.2752	
4		.7682	1.4861	1.2449	1.3306	1.2752	1.829
6		1.2752		1.3014	1.2449	1.2752	
8		1.2752	1.2449	1.3014	.7922	1.7741	1.8861
9					.7922		
10			.7922	.7922	1.2752		.8488
11						.4572	
12			1.2449	1.2752	1.2197		1.8673
14	1.8296		1.8107	1.8107	1.7741		1.8673
15						.3429	
16	1.8296		1.8673	1.3014	1.7741		1.8673
18	1.2752		1.3014	1.2752	1.2752		1.3014
19						.8573	
20	.7762		.7922	1.3014	1.3306		.7922
21		1.3146				.8002	
22	1.2197			1.3014	1.2752		1.8673
23			1.8107				
24	1.2449	1.2071	1.8861	1.3014	.7762	1.2752	1.8107
Max	1.8296	1.3146	1.8861	1.8107	1.7741	1.7741	1.8861
Min	.7762	.7682	.7922	.7922	.7762	.3429	.7922
Avg	1.3619	1.1859	1.4237	1.2499	1.2301	1.0369	1.5937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 201 / 11 KV Sector 8-A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1203			1.2696	
3		1.0642	1.0082			1.0456	1.0456
4		1.0642					
5		1.0456	1.0082		1.0269	1.0829	1.1203
6		1.1576	1.0456		1.0456	1.2323	1.2696
7	1.3443	1.1949	1.251	1.1203	1.0269	1.3443	1.3443
8	1.2323	1.3817		1.2136	1.1203	1.2883	1.307
9	1.3443	1.3443	1.4003	1.307		1.4563	
10		1.2883	1.1389	1.3443	1.3443	1.2883	1.251
11		1.1576	1.1389		1.3443	1.2136	
12		1.1576		1.1203	1.2323		
13				1.1203	1.1389		
14				1.1016	1.1389		
15			.9149	1.0642	1.0829		
16					1.0829		1.0269
17			.8589	1.0456	1.0456		1.0269
18			.9709	1.1203	1.0829		1.0082
19	1.3443		1.2696	1.4003	1.363	1.4563	1.3817
20	1.4003		1.3817	1.4003	1.3817	1.4563	1.3817
21	1.3817		1.4377	1.419	1.4003		1.4377
22	1.3443		1.4377		1.4003		1.4377
23	1.2323		1.3443	1.4003	1.4377	1.3443	1.4563
24	1.2696	1.1203	1.1949	1.2136	1.2696	1.3443	1.2883
Max	1.4003	1.3817	1.4377	1.419	1.4377	1.4563	1.4563
Min	1.2323	1.0456	.8589	1.0456	1.0269	1.0456	1.0082
Avg	1.3215	1.1797	1.1719	1.2261	1.2087	1.2940	1.2522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 203 / 11 KV CBD SEC 8 B

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5228			.5415	
3		.5228	.4481			.4668	.5228
4		.5228					
5		.5601	.4481		.4854	.4854	.5228
6		.5601	.4481		.5041	.5601	.5975
7	.6722	.6722	.7095	.5601	.5228	.6535	.6722
8	.7468	.7095		.6908	.6348	.6722	.7468
9	.7842	.7468	.6722	.6348		.6722	
10		.6908	.6161	.6348	.6908	.6535	.6722
11		.6908	.6161		.6722	.6722	
12		.6908		.5415	.6722		
13				.5601	.6161		
14				.5788	.5975		
15			.4854	.5415	.4668		
16					.5975		.5228
17			.4108	.5041	.5601		.5788
18			.5601	.5228	.6348		.5975
19	.7095		.6535	1.4003	.7842	.7095	.7095
20	.7468		.6348	.7095	.7095	.8589	.8402
21	.6535		.6722	.7095	.6535		.7095
22	.7095		.6722		.6908		.7282
23			.6161	.5975	.6161	.5975	.6535
24	.5975	.5601	.5601	.5601	.5601	.6535	.5788
Max	.7842	.7468	.7095	1.4003	.7842	.8589	.8402
Min	.5975	.5228	.4108	.5041	.4668	.4668	.5228
Avg	.7025	.6297	.5733	.6497	.6142	.6305	.6435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 204 / 11 KV S/STN T/F SECT-06

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0934			.0934	
3		.0747	.0934			.0934	.0934
4		.0747					
5		.0747	.0934		.0747	.0934	.0934
6		.112	.0934		.0747	.112	.112
7	.1307	.112	.112	.112	.0934	.112	.112
8	.1307	.1307		.168	.112	.0934	.1307
9	.112	.0934	.1307	.0934		.0934	
10		.0934	.112	.112	.112	.112	.1307
11		.112	.112		.0934	.0934	
12		.112		.112	.0934		
13				.0934	.0747		
14				.112	.0747		
15			.1307	.112	.0934		
16					.0934		.0747
17			.112	.0934	.0747		.112
18			.112	.0934	.0747		.0934
19	.112		.0934	.0934	.112	.112	.112
20	.0934		.112	.112	.112	.0934	.1307
21	.0934		.112	.112	.112		.1494
22	.1494		.112		.112		.1307
23			.112	.112	.112	.1494	.1307
24	.0934	.112	.0934	.0934	.112	.112	.112
Max	.1494	.1307	.1307	.168	.112	.1494	.1494
Min	.0934	.0747	.0934	.0934	.0747	.0934	.0747
Avg	.1144	.1001	.1076	.1083	.0953	.1049	.1145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 206 / 11 KV KENDRIYA SADAN SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2987			.2987	
3		.2801	.2614			.2614	.2801
4		.2614					
5		.2614	.2614		.2614	.2801	.2801
6		.2987	.2987		.2801	.2987	.3174
7	.3174	.2987	.3174	.2987	.2801	.2801	.2987
8	.3361	.3547		.3174	.2801	.3547	.3734
9	.3734	.3734	.3361	.3734			
10	.4668	.4108	.3734	.4481	.3921	.4481	.4108
11		.4854	.3734		.3734	.4854	
12		.4854		.5228	.4108		
13					.4294		
14				.4668	.3361		
15	.4854		.3734	.4294	.3174		
16					.3361		.4854
17			.4108	.4668	.3174		.5228
18			.4668	.4668	.3547		.4854
19	.5601		.4854	.5601	.4481	.5975	.5788
20	.5601		.4668	.5601	.4668	.5601	.5975
21	.4854		.4668	.4854	.4481		.5601
22	.4854		.4108		.4108		.4668
23	.3734		.3734	.4108	.3547	.4108	.4108
24	.3734	.3361	.3361	.3547	.3547	.3361	.3361
Max	.5601	.4854	.4854	.5601	.4668	.5975	.5975
Min	.3174	.2614	.2614	.2987	.2614	.2614	.2801
Avg	.4379	.3496	.3712	.4401	.3606	.3843	.4269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 207 / 11 KV SECTOR-09 NEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6161			.5975	
3		.5228	.5228			.4854	.5228
4		.5228					
5		.5415	.4668		.5041	.5041	.5041
6		.6535	.4854		.5041	.5415	.5975
7	.6161	.5975	.6161	.5228	.4854	.5975	.6348
8	.6722	.6722		.6722	.5228	.6722	.6348
9	.7468	.6722	.6908	.7468		.6722	
10		.6908	.5788	.6535	.5975	.6348	.5975
11			.5041		.5601	.5228	
12		.5041		.5415	.5041		
13				.5228	.5041		
14				.4854	.5041		
15			.4481	.4668	.4481		
16					.4668		.5041
17			.4108	.4854	.5228		.4668
18			.4668	.5041	.5228		.4854
19	.6535		.6722	.7095	.7655	.7468	.7282
20	.6722		.6722	.7095	.7655	.7842	.8402
21	.6722		.6722	.7468	.7655		.7842
22	.6535		.6722		.7282		.7842
23			.6535	.6908	.6348	.6722	.6722
24	.5975	.5975	.6161	.5975	.6348	.6348	.5975
Max	.7468	.6908	.6908	.7468	.7655	.7842	.8402
Min	.5975	.5041	.4108	.4668	.4481	.4854	.4668
Avg	.6605	.5975	.5744	.6037	.5758	.6205	.6236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 208 / 11 KV RBI SEC 10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5975			.5601	
3		.4854	.4854			.4854	.5228
4		.4854					
5		.4854	.4854		.4854	.5041	.5041
6		.4668	.5228		.5228	.4481	.5228
7	.5415	.5228	.5415	.5228	.5228	.5601	.5228
8	.6535	.6535		.5788	.5601	.5975	.6348
9	.9335	.8402	.6722	.6535		1.1203	
10		1.5497	.8589	.7095	.5975	1.7737	1.7737
11			.9709		.5601	1.9418	
12		1.7924		.8215	.6722		
13				.8402	.6535		
14				.7282	.6722		
15			1.0269	.8402	.7095		
16					.6348		1.9605
17			1.0829	.7842	.6535		
18			.8589	.7468	.5788		1.5497
19	1.1576		.7842	.7468	.7655	1.2136	1.2883
20	.8402		.6348	.7842	.7842	.7842	.8029
21	.7842		.6908	.7842	.7655		.7655
22	.7468		.6535		.7468		.6908
23			.6535	.7468	.6722	.7095	.7095
24	.5415	.6722	.6722	.6161	.6722	1.7737	.6535
Max	1.1576	1.7924	1.0829	.8402	.7842	1.9418	1.9605
Min	.5415	.4668	.4854	.5228	.4854	.4481	.5041
Avg	.7749	.7954	.7172	.7269	.6437	.9594	.9216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284007 / 33/22/11KV Sec-6, CBD S/Stn

Feeder No / Name : 210 / 11 KV RBI (NEW)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3734			.3734	
3		.3361	.3734			.3734	.3361
4		.3361					
5		.3361	.3734		.3547	.3734	.3361
6		.3547	.3734		.3547	.3734	.3547
7	.3734	.3921	.4108	.3734	.3547	.3734	.4108
8	.4481	.3734		.3734	.3734	.4108	.4294
9	.4668	.4481	.4108	.4481		.4668	
10		.5975	.5601	.4481	.3734	.7842	.7095
11			.4481		.3734	.6908	
12		.7655		.4854	.3734		
13				.4668	.4108		
14				.4481	.4108		
15			.4481	.5041	.4108		
16					.3734		.7282
17			.3734	.4668	.4668		
18			.3734	.4294	.4108		.5228
19	.4481		.4108	.4108	.3734	.4481	
20	.4481		.3734	.3734	.3734	.4481	.4108
21	.3734		.3547	.3921	.3734		.4108
22	.3734		.3734		.3734		.3921
23			.3734	.3734	.3734	.3547	.3734
24	.5228	.3547	.3734	.3734	.3547	.7842	.3547
Max	.5228	.7655	.5601	.5041	.4668	.7842	.7282
Min	.3734	.3361	.3547	.3734	.3547	.3547	.3361
Avg	.4318	.4294	.3987	.4244	.3823	.4811	.4438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 201 / 11KV PHANASPADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.9526	.9328	.9335	.9907
2		.7947			.8962		.9526
3			.9511	.8764		.8501	
4	.7442	.8131			.8316		
5						.7682	
6	.8413	.9335	.9425	1.0479	.7947		1.105
7				1.0288	.823		1.0669
8	.9536	1.0829		1.0479	.924	1.0608	1.1812
9	.8589	.961	.9979	1.0098	.9979	.9511	1.0669
10		.7947		.8954	.9979	.8048	.9145
11	.7282		.8383	.8764	.8779	.8192	.8215
12	.7468		.8002	.9313	.7499	.8002	.7842
13	.7655	.695	.8192	.8238	.8145	.8954	.7577
14	.7023		.8192	.8145		.7621	.6838
15	.6468		.6859	.7783		.7621	.6653
16	.6838	.6584	.6668	.7499		.743	.7023
17	.7392		.743	.7499	.7783	.7621	.7392
18	.8413	.7499	.8383	.7682		.8954	.8871
19	1.0242		1.0288	1.0425	.9511	1.1622	1.1273
20	1.0242	1.0242	1.0098	1.0791	.9877	1.1622	1.1273
21	1.0608	1.0242	1.0098	1.0608	.9795	1.2003	1.1827
22	1.0425	.9593	1.0669	1.0974	1.0164	1.2003	1.1827
23	1.0059	.9412	1.0669	1.0791		1.2003	1.1203
24	.9134	.8779	.8779	.9907	1.0059	1.086	
Max	1.0608	1.0829	1.0669	1.0974	1.0164	1.2003	1.1827
Min	.6468	.6584	.6668	.7499	.7499	.743	.6653
Avg	.8513	.8793	.8919	.9381	.9035	.9410	.9530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 202 / 11KV PUJIT PLAZA SECTOR-11 SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5525	.543	.5068	.4954
2		.4435			.5068		.5335
3			.4481	.4763	.462	.5304	
4	.3898	.4251					
5					.4435	.5853	
6	.5731	.5975	.6653	.5716	.4435		.5906
7				.5525			.6097
8	.6767	.6908		.6668	.5544	.6838	.743
9	.6401	.6283	.6908	.6478	.5914	.695	.724
10		.6099		.6287	.5544	.695	.6767
11	.5611		.6287	.7133	.462	.5906	.6767
12	.5249		.6097	.8048	.462	.5716	.567
13	.543	.5304	.5525	.5487	.5121	.5906	.5914
14	.4755		.5335	.5487		.4001	.5914
15	.5487		.6097	.5487		.4001	.5729
16	.5304	.543	.5906	.5487		.5335	.6099
17	.6219		.6287	.567	.4656	.5335	.6468
18	.6335	.6335	.6287	.5611		.5716	.6838
19	.6154		.7049	.6516	.543	.6287	.6838
20	.6154	.5973	.6668	.6154	.5792	.6478	.6838
21	.5792	.5853	.6097	.6154	.567	.6097	.6653
22	.5973	.6036	.6287	.6154	.5853	.6287	.6283
23	.5611	.5853	.6287	.6335		.5716	.6401
24	.5552	.6099	.5228	.6097	.5611	.5525	
Max	.6767	.6908	.7049	.8048	.5914	.695	.743
Min	.3898	.4251	.4481	.4763	.4435	.4001	.4954
Avg	.5690	.5774	.6087	.6037	.5198	.5763	.6307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 203 / 11KV BELAPUR DTC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8192	.8501	.7865	.8383
2		.6908			.7762		.8192
3			.6584	.6859	.7023	.0739	
4	.5853	.5975			.6468		
5						.7207	
6	.6219	.7545	.7023	.8573	.7023		.9145
7				.8383			.9145
8	.8131	.9054		.8764	.7947	.8131	.9335
9	.7023	.811	.7922	.8383	.8686	.8316	.8383
10		.7468		.724	.7392	.7207	.7316
11	.5788		.6478	.7207	.6767	.6097	.6413
12	.6348		.6478	.7762	.6401	.6097	.6224
13	.5975	.5729	.6287	.6283	.6154	.6287	.6161
14	.5544		.6097	.6283		.6097	.5788
15	.5729		.6287	.6283		.6097	.5975
16	.6099	.5359	.6097	.6283		.6287	.6161
17	.6468		.6478	.6468	.6697	.6287	.6283
18	.6653		.724	.6468		.724	.6468
19	.8316		.8002	.8316	.7865	.9335	.7392
20	.8501	.8316	.9145	.8871	.823	.9335	.8871
21	.8871	.8029	.9335	.8871	.8413	.9335	.9055
22	.8686	.8589	.9526	.924	.8326	.9526	.9425
23	.8871	.8316	.9145	.9055		.9907	.9522
24	.7499	.8131	.7392	.8764	.8871	.9335	
Max	.8871	.9054	.9526	.924	.8871	.9907	.9522
Min	.5544	.5359	.6097	.6283	.6154	.0739	.5788
Avg	.7032	.7502	.7383	.7740	.7560	.7336	.7682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 204 / 11KV S/STN TRANSFORMER

SHEDDABLE URBAN

R.M.U S Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0762	.0762	.0762	.0762
2		.0953			.0762		.0762
3			.0762	.0762	.0572	.0953	
4	.0762	.0572			.0572		
5					.0572	.0762	
6	.0572	.0381		.0762	.0572		.0762
7				.0762	.0572		.0762
8	.0381	.0572		.0762	.0572	.0572	.0762
9	.0381	.0572	.0572	.0762	.0572	.0381	.0762
10		.0572		.0762	.0381	.0572	.0381
11	.0572		.0762	.0762	.0762	.0762	.0381
12	.0381		.0762	.0572	.0572	.0762	.0572
13	.0381	.0572	.0762	.0762	.0762	.0762	.0572
14	.0381		.0762	.0762		.0762	.0572
15	.0762		.0762	.0572		.0762	.0572
16	.0572	.0762	.0762	.0572		.0572	.0572
17	.0572		.0762	.0572	.0572	.0572	.0572
18	.0762		.0572	.0572		.0572	.0572
19	.0572		.0762	.0572	.0762	.0762	.0572
20	.0572	.0762	.0762	.0572	.0762	.0762	.0572
21	.0381	.0762	.0762	.0572	.0572	.0762	.0762
22	.0762	.0762	.0762	.0762	.0762		.0572
23	.0572	.0572	.0762	.0762		.0762	.0572
24	.0762	.0572	.0762	.0762	.0762	.0762	
Max	.0762	.0953	.0762	.0762	.0762	.0953	.0762
Min	.0381	.0381	.0572	.0572	.0381	.0381	.0381
Avg	.0561	.0645	.0738	.0690	.0642	.0702	.0619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 205 / 11KV SAI VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.105		.9412	1.0288
2		.8764			.9568		.9717
3			.8505	.9907		.8059	
4	.7796	.8764			.8859		
5						.8328	
6	.8505	.9816	.8063	1.0288	.9671		1.0288
7				1.0479			1.0669
8	1.0166	1.0341		1.086	1.0498	.985	1.0669
9	1.1744	1.1744	1.0692	1.1431	1.0136	1.0277	1.1812
10		1.4198		1.4098	1.0136	1.3466	1.4327
11	1.3432		1.5623	1.3306		1.7147	1.7002
12	1.4299		1.5813	1.2936	1.0029	1.7718	1.6263
13	1.5384	1.3466	1.3717	1.5708	1.1163	1.6956	1.6263
14	1.4661		1.4289	1.5364		1.6956	1.5339
15	1.5746		1.6194			1.6956	1.6078
16	1.6095	1.5223	1.5813	1.5364		1.6575	1.5893
17	1.6278		1.5242	1.4815	1.0631	1.6385	1.5364
18	1.5592		1.448	1.3535		1.5242	1.4998
19	1.4883		1.5623	1.3756	1.2048	1.6004	1.4998
20	1.382	1.3073	1.5051	1.4299	1.2752	1.4289	1.4815
21	1.2757	1.2178	1.4289	1.5023	1.2536	1.4289	1.3535
22	1.258	1.2048	1.3336	1.3937	1.2489		1.3169
23	1.2048	1.134	1.2765	1.267		1.2574	1.2403
24	1.0749	1.0454	.9492	1.1812	1.1765	1.1812	
Max	1.6278	1.5223	1.6194	1.5708	1.2752	1.7718	1.7002
Min	.7796	.8764	.8063	.9907	.8859	.8059	.9717
Avg	1.3141	1.1647	1.3470	1.3032	1.0877	1.3805	1.3695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 206 / 11KV CHROMA SECTOR-15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5144		.543	.5525
2		.5121			.4252		.5144
3			.4344	.4001		.4477	
4	.3688	.4755			.3982		
5						.394	
6	.4409	.5487	.4163	.4001	.4207		.4572
7				.381			.4763
8	.4862	.5304		.381	.4024	.5121	.5525
9	.5365	.6584	.4572	.4001	.4572	.5792	.6287
10		.7316		.5716	.4572	.6516	.7011
11	.8413		.8573	.4572		.8764	.8962
12	.8962		.8573	.4755	.724	.9145	.9511
13	.9328	.9231	.8192	.8413		1.0669	.9511
14	.8779		.7811	.8413		.9717	.9328
15	.8779		.9526	.8145		.9717	.9328
16	.8596		.9335	.8145			.9694
17	.8596		.8573	.7964	.6733	.9526	.905
18	.8682		.8192	.7499		.9526	.8145
19	.8682		.8192	.8048	.691	.8764	.8507
20	.8145	.7059	.8192	.7133	.7265	.7621	.8688
21	.724	.6335	.7621	.7499	.7522	.7621	.7964
22		.6219	.7049	.6697	.7343		.7421
23	.6154	.567	.5716	.6516		.724	.7164
24	.5316	.5792	.5487	.5716	.5792	.6287	
Max	.9328	.9231	.9526	.8413	.7522	1.0669	.9694
Min	.3688	.4755	.4163	.381	.3982	.394	.4572
Avg	.7294	.6239	.7301	.6190	.5724	.7549	.7605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 207 / 11KV OLD R.M.U SECTOR-15 SHEDDABLE URBAN
S/Stn Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0953		.0686	.0953
2		.0857			.1029		.0953
3			.0509	.0953		.0678	
4	.0514	.0648			.081		
5						.0503	
6	.0678	.0625	.0492	.0953	.081		.0953
7				.0953			.0953
8	.0678	.0781		.0953	.0838	.0671	.0762
9	.0509	.0625	.0469	.0953	.0857	.0497	.0953
10		.1718		.2096	.0857	.1658	.156
11	.181		.0762	.1886		.2096	.2629
12	.2033		.0953	.1886	.0678	.3048	.1928
13	.1848	.1562	.0953	.1715		.2286	.1753
14	.2033			.1715		.1905	.1753
15	.1848		.0953	.1715		.1905	.1928
16	.1848		.1143	.1715			.1928
17	.1848		.0953	.1715	.0829	.1905	.1715
18	.1029		.0953	.1006		.1334	.1029
19	.0857		.1143	.1174	.0838	.1143	.1029
20	.0867	.0838	.0953	.1006	.0838		.1029
21	.0867	.0678	.0953	.1006	.0848	.0953	.1029
22	.0867	.0848	.1143	.0857	.0678		.1029
23	.0867	.0686	.1143	.0857		.0953	.08
24	.0693	.0867	.0953	.1886	.1029	.0953	
Max	.2033	.1718	.1143	.2096	.1029	.3048	.2629
Min	.0509	.0625	.0469	.0857	.0678	.0497	.0762
Avg	.1205	.0894	.0902	.1331	.0841	.1363	.1333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284054 / 33/11KV Sec-15, CBD S/Stn

Feeder No / Name : 208 / 11KV GREAT EASTERN SUMMIT SHEDDABLE URBAN
SECT Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2574		1.0631	1.2574
2		.9339			1.0395		1.1812
3			.8619	1.1812		1.0227	
4	.8916	.9012			.9012		
5						.8951	
6	.8648	.9717	.852	1.086	.8192		1.105
7				1.0669			1.1431
8	.8886	.9393		.9526	.8684	1.0242	1.0288
9	1.0227	1.1012	.9878	1.086	.8718	1.065	1.1812
10		1.4251		1.3908	.9389	1.4419	1.3717
11	1.6289		1.6766	1.2003		2.0005	1.6476
12	1.7528		1.6766	1.286	.9448	2.0767	1.7551
13	1.5775	1.4582	1.6766	1.286		1.9052	1.7551
14	1.4723		1.6575	1.2517		1.8671	1.7013
15	1.5775		1.6385	1.2517		1.8671	1.6476
16	1.5424		1.6575	1.2174			1.5939
17	1.5432		1.6956	1.2003	.8951	1.8671	1.406
18	1.3717		1.5242	1.2346		1.7909	1.3375
19	1.4232		1.6004	1.2517	1.1401	1.5813	1.3375
20	1.2239	1.1469	1.467	1.2003	1.1568	1.5051	1.3375
21	1.1736	1.1768	1.467	1.2346	1.17	1.4289	1.2517
22	1.1233	1.1105	1.3717	1.1317	1.1361		1.2346
23	1.1233	1.0395	1.3527	1.1317		1.3527	1.1904
24	1.1218	1.0395	1.6575	1.2955	1.1145	1.2955	1.2955
Max	1.7528	1.4582	1.6956	1.3908	1.17	2.0767	1.7551
Min	.8648	.9012	.852	.9526	.8192	.8951	1.0288
Avg	1.2957	1.1037	1.4601	1.1997	.9997	1.5028	1.3695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 401 / 33KV SBI - 2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658	.5658	.503	.5487	.5144	.4801
2		.5144	.5144	.4915	.543	.5144	.4744
3		.5144	.5144	.4915	.5373	.5144	.4218
4	.3909	.5144	.5144	.4424	.5316	.5144	.4167
5		.5658	.5144	.4372	.5258	.5144	.4115
6		.6687	.5144	.4801	.5721	.5144	.4167
7	.4778	.6687	.5658	.4801	.5658	.5144	.4167
8	.5658	.6687	.5658	.503	.5596	.5658	.5761
9	.823	.6687	.5144	.6104	.5658	.7202	.6882
10	.9774	1.0802	.6613	.6687	.5721	.7122	.7459
11	.9774	1.0288	.7282	.6762	.5144	.7202	.8048
12	1.1317	.9774	.7362	.6836	.6173	1.0517	.8648
13	1.1317	1.0802	.7442	.6984	.5658	1.0099	.9259
14	1.1317	1.0802	.7442	.7602	.5658	1.0517	.9882
15	1.1831	.9774	.7522	.823	.5144	1.0517	1.0517
16	1.1831	1.1317	.7442	.8871	.5144	1.0099	1.1163
17	.9774	.9774	.7362	.9522	.5144	.8939	1.182
18	.9259	.823	.7442	.8871	.5658	.7973	1.1403
19	.7202	.7202	.6447	.823	.5658	.7202	1.0745
20	.6687	.6687	.6036	.7602	.5658	.6036	1.0099
21	.6173	.6173	.5784	.6984	.5144	.6036	.8939
22	.5658	.5658	.5144	.691	.5144	.4915	.7802
23	.5658	.5658	.5144	.5784	.5144	.4915	.7202
24	.503	.5658	.5658	.503	.5144	.5144	.4858
Max	1.1831	1.1317	.7522	.9522	.6173	1.0517	1.182
Min	.3909	.5144	.5144	.4372	.5144	.4915	.4115
Avg	.8167	.7587	.6165	.6471	.5451	.6921	.7536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 403 / 33KV SBI - 1 & SUB ST/N NON SHEDDABLE EXPRESS HV FEEDERS
XMER Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	27-FEB-17
HR	Load (MW)
17	.8939
Max	.8939
Min	.8939
Avg	.8939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

CBD BELAPUR S/DN.[652] BU 4652

Substation No/ Name :- 284061 / 33/33KV SBI IDBI NMMC

Swt/Stn

Feeder No / Name : 404 / 33KV NMMC - 2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1543	.1543	.1303		.1543	
2		.1543	.1543	.1303		.1543	.1252
3		.1543	.1543	.1303		.1543	.1235
4	.1303	.1543	.1543	.1286		.1543	.1217
5		.1543	.1543	.1269		.1543	.12
6		.1543	.1543	.1286		.1543	.1235
7	.1372	.1543	.1543	.1355		.1543	.1269
8	.1543	.1543	.1543	.1806		.1543	.1286
9	.463	.4115	.1543	.1875	.1543	.4115	.2743
10	.463	.4115	.5487		.1543	.5601	
11	.463	.463	.5601		.1543	.5658	
12	.463	.463	.5544		.1543	.679	
13	.463	.463	.5487		.1543	.6224	
14	.5144	.463	.5544		.1543	.679	
15	.5144	.4115	.5487		.1543	.679	
16	.5658	.4115	.543		.1543	.6161	
17	.5144	.463	.5487		.1543	.6036	
18	.463	.4115	.407		.1543	.6099	
19	.4115	.4115	.192		.1543	.3189	
20	.3601	.1543	.1423		.1543	.1355	
21	.1543	.1543	.1423		.1543	.1355	
22	.1543	.1543	.1355		.1543	.1355	
23	.1543	.1543	.1337		.1543	.1337	
24	.1355	.1543	.1543	.132		.1543	.1303
Max	.5658	.463	.5601	.1875	.1543	.679	.2743
Min	.1303	.1543	.1337	.1269	.1543	.1337	.12
Avg	.3515	.2829	.2959	.1411	.1543	.3448	.1416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 201 / 11KV AIR INDIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029	.7202	.703	.7888	.9149	.8573	.823
2	.7468	.6859	.6516	.7202	.8589	.7545	.7888
3	.7095	.6859	.6173	.6859	.7468	.6859	.7888
4	.6722	.7202	.583	.6859	.7095	.6516	.823
5	.7095	.7545	.6173	.6859	.6908	.6859	.8573
6	.7842	.7888	.6516	.7202	.6908	.7888	.8573
7	.9709	.8402	.7202	.703	.7282	.9088	.8745
8		.823	.7545	.7202	.7468	.823	.8402
9	.8775	.8916	.823	.8589	.8589	.7716	.9149
10	.7545	.703	.8573	.8215	.8029	.8745	.8402
11		.7545		.8775	.8916	.2915	.8215
12		.6344	.8059	.7842	.8573	.7202	.7468
13		.6859	.7373	.7282	.8059	.6859	.7282
14		.6344	.6687	.7282	.7716		.6908
15		.5658	.6173	.7468	.8059		.6722
16	.6173	.6001		.7655	.7716		.7095
17	.6687	.6344	.6344	.7468	.7202	.6687	.7282
18	.7888	.6687	.6687	.8029	.703	.7545	.8402
19	.823	.823	.8402	.9335	.8745	.823	.9335
20		.8402	.823	.9149	.8573	.8402	.9335
21	.8402	.7888	.8059	.9149	.8402	.8059	.9335
22	.7888	.8573	.823	.9335	.8916	.8916	.9522
23	.7716	.7888	.8573	.9896	.9259	.9088	1.0082
24	.9335	.7545	.7888	.9149	.9335	.9259	.9522
Max	.9709	.8916	.8573	.9896	.9335	.9259	1.0082
Min	.6173	.5658	.583	.6859	.6908	.2915	.6722
Avg	.7800	.7352	.7295	.7988	.8083	.7675	.8358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 202 / 11KV JAWAHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1543	.1715	.1715	.168	.2058	.2058
2	.168	.1543	.1543	.1715	.1494	.1715	.1715
3	.1494	.1543	.1372	.1372	.1494	.1543	.1715
4	.1494	.1543	.1372	.1372	.168	.1543	.1543
5	.1494	.1543	.1372	.1372	.1867	.1543	.1543
6	.168	.1886	.1715	.1715	.1867	.1715	.1715
7	.2241	.2229	.2058	.1886	.168	.2058	.2229
8	.2427	.2401	.1886	.1886	.1867	.2401	.2229
9	.1867	.2058	.1886	.2054	.1867	.2058	.2241
10		.2572	.2401	.2427	.2054	.2743	.2801
11		.2743		.3547	.2743		.2241
12		.2572	.2229	.4108	.2743		.2241
13		.2572		.2801	.2572	.2229	.2241
14		.2401		.3361	.2229		.2241
15		.2401		.1867	.2229		.2241
16	.2743	.2572		.4108	.2572		.2801
17	.2915	.2743	.2401	.4108	.2572	.2572	.2987
18	.1886	.1715	.1715	.2614	.2915	.2229	.2054
19	.2058	.1886	.2401	.3734	.3601	.1715	.2427
20		.2229	.2572	.3547	.3429	.1715	.2987
21	.2058	.2229	.2058	.6348	.2743	.1886	.2054
22	.1715	.1715	.2229	.2241	.2743	.2401	.2054
23	.1886	.1886	.2058	.2054	.2743	.2572	.2054
24	.2241	.1715	.2229	.2058	.1867	.2572	.2401
Max	.2915	.2743	.2572	.6348	.3601	.2743	.2987
Min	.1494	.1543	.1372	.1372	.1494	.1543	.1543
Avg	.1974	.2093	.1959	.2667	.2302	.2067	.2201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 203 / 11KV BANK OF INDIA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1016	.9602	.9602	.9259	1.1389	1.1317	.9259
2	1.0269	.9259	.9602	.8916	1.0082	1.0288	.8573
3	.9335	.8573	.8916	.8573	.9709	.9945	.8573
4	1.0829	.9602	.8916	.9602	1.0269	.9259	.9259
5	1.2136	1.0288	1.0974	1.0974	1.251	1.0974	.9945
6	1.307	1.2346	1.1831	1.2346	1.1763	1.1831	1.0631
7	1.419	1.4575	1.3889	1.3717	1.5684	1.286	1.3375
8	1.7364	1.6118	1.4575	1.5432	1.4563	1.6289	1.7318
9	1.8484	1.6804	1.286	1.5684	1.419	1.8519	2.1098
10		1.9547	1.3546	1.9044	1.4563	2.0062	2.1285
11		1.9204		1.9791	1.3203	1.8519	2.2592
12		1.9376	1.4403	1.9418	1.406		2.1845
13		1.7833		1.5684	1.166	1.8519	2.0538
14		1.8861		1.6617	.9431		1.8858
15		1.9376		1.8111	1.286		2.0165
16	1.8519	1.8347		1.9791	1.4403		2.2592
17	1.9033	1.6975	1.5089	1.7551	1.4403	1.9033	1.9418
18	1.5947	1.6118	1.3889	1.7177	1.4403	1.7147	1.7551
19	1.5432	1.6975	1.4232	1.8111	1.6632	1.7661	1.9044
20		1.286	1.406	1.4377	1.2174	1.5089	1.9231
21	1.2346	1.2689	1.1488	1.4003	1.2517	1.2517	1.4563
22	1.2517	1.2174	1.2517	1.3256	1.166	1.1145	1.419
23	1.1488	1.2174	1.1317	1.3256	1.2174	1.0288	1.307
24	1.251	.9945	1.1145	1.046	1.2136	1.2174	.823
Max	1.9033	1.9547	1.5089	1.9791	1.6632	2.0062	2.2592
Min	.9335	.8573	.8916	.8573	.9431	.9259	.823
Avg	1.3793	1.4568	1.2255	1.4631	1.2768	1.4172	1.5883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 205 / 11KV ARMY NIWAS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1543	.1372	.1715	.1867	.1715	.1715
2	.168	.1372	.12	.1715	.168	.1543	.1715
3	.1494	.12	.1029	.1715	.1494	.1543	.1543
4	.1494	.12	.1029	.1715	.1494	.1543	.1543
5	.1494	.12	.1029	.1886	.168	.1372	.1543
6	.2241	.1715	.12	.1886	.1494	.1543	.2058
7	.2241	.2229	.2401	.2058	.2427	.2058	.2229
8	.2241	.2229	.1886	.1715	.1867	.2058	.2229
9	.1494	.2058	.2743	.1494	.168	.1257	.2241
10		.1886	.2401	.168	.1867	.1715	.1867
11		.12		.1867	.2058	.1372	.1867
12		.1715		.2054	.2229		.1867
13		.1372		.1494	.1372	.1715	.1494
14		.12		.1494	.1543		.1494
15		.1372		.168	.1543		.168
16	.12	.12		.1494	.1543		.1494
17	.12	.1029	.12	.1307	.1372	.1372	.1307
18	.1372	.12	.12	.1494	.12	.1543	.1494
19	.1715	.1886	.2229	.3174	.1886	.2058	.2427
20		.2229	.2229	.2427	.2058	.1886	.2801
21	.1715	.1715	.1543	.1867	.1715	.2058	.2614
22	.1543	.1715	.1715	.1867	.1886	.2058	.2241
23	.1715	.1715	.1886	.2054	.2229	.2401	.2241
24	.1867	.1543	.1715	.1494	.2054	.2058	.2058
Max	.2241	.2229	.2743	.3174	.2427	.2401	.2801
Min	.12	.1029	.1029	.1307	.12	.1257	.1307
Avg	.1670	.1572	.1667	.1806	.1760	.1743	.1907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 206 / 11 KV LENYADRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3429	.3601	.4115	.4668	.4458	.4458
2	.3734	.3086	.3086	.4115	.4481	.3944	.4287
3	.3361	.3086	.2743	.3944	.4294	.3429	.4115
4	.3361	.3086	.2743	.3772	.3734	.3086	.4115
5	.3511	.3086	.2915	.3772	.3734	.3258	.4287
6	.3921	.3429	.3258	.3944	.3361	.3772	.4458
7	.4294	.3944	.3772	.4115	.3361	.4287	.4458
8	.5041	.4973	.4115	.3429	.3547	.4115	.3772
9	.4108	.3315	.463	.4481	.4108		.4668
10		.3429	.4287	.4668	.4294	.3772	.4668
11		.3429		.3734	.4115	.4115	.4294
12		.3258		.4108	.3772		.3734
13		.3258			.3601	.3258	.3547
14		.3086		.4294	.3601		.3361
15		.3086		.4294	.4115		.3547
16	.3429	.2915		.4294	.3772		.3734
17	.3258	.3086	.3086	.3734	.3772	.3601	.3174
18	.3258	.3258	.3258	.3547	.3772	.3429	.3361
19	.4458	.3944	.463	.4854	.4458	.4115	.4668
20		.4115	.4115	.4668	.4115	.4287	.4668
21	.4115	.4287	.4287	.4668	.4801	.4287	.4668
22	.3944	.4801	.4287	.4668	.5144	.463	.5228
23	.4287	.4115	.4801	.5601	.4973	.4973	.5975
24	.4668	.3772	.3944	.4108	.5228	.5316	.4973
Max	.5041	.4973	.4801	.5601	.5228	.5316	.5975
Min	.3258	.2915	.2743	.3429	.3361	.3086	.3174
Avg	.3922	.3553	.3753	.4214	.4118	.4007	.4259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 207 / 11KV BHIMA SHANKAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161	.5144	.5487	.6173	.6722	.6687	.6516
2	.5788	.4801	.5144	.583	.6348	.6173	.6173
3	.5415	.4458	.463	.4973	.5415	.5658	.583
4	.5788	.5144	.4458	.4458	.4854	.5316	.5487
5	.5975	.5487	.463	.4458	.5975	.5658	.5487
6	.6161	.583	.5316	.4801	.5601	.6001	.583
7	.7468	.6344	.583	.5316	.5788	.6344	.6001
8	.8215	.6516	.6516	.5487	.5788	.6516	.7373
9	.7095	.6344	.6173	.5975	.6722	.6516	.7282
10		.5316	.6344	.6908	.6722	.5487	.6908
11		.5144		.4294	.6001	.6001	.5041
12		.4458		.5788	.5487		.5041
13		.4801			.5658	.4458	.5415
14		.4287		.5788	.5316		.5041
15		.4115		.5788	.5658		.4854
16	.4287	.3944		.5041	.5144		.4854
17	.4115	.4115	.4287	.5041	.5144	.3944	.5228
18	.4458	.4801	.4801	.5788	.583	.5658	.5415
19	.6173	.583	.6001	.6908	.6687	.6173	.6908
20		.6173	.6001	.7095	.6344	.6344	.6908
21	.6344	.6344	.6687	.7282	.6859	.6344	.7282
22	.6516	.6516	.6859	.7282	.7202	.7373	.7655
23	.6859	.7202	.6859	.7468	.7888	.7545	.8589
24	.6535	.5658	.6173	.5601	.7095	.7202	.6859
Max	.8215	.7202	.6859	.7468	.7888	.7545	.8589
Min	.4115	.3944	.4287	.4294	.4854	.3944	.4854
Avg	.6080	.5366	.5678	.5806	.6094	.6070	.6166

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284001 / 33/22/11KV CPWD S/Stn

Feeder No / Name : 209 / 11 KV STN TRF

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.3944	.4115	.4458	.5415	.5144	.4801
2	.4481	.3601	.3601	.4115	.4854	.463	.4458
3	.3734	.3601	.3429	.3772	.4481	.4115	.4458
4	.4108	.3772	.3429	.3772	.4108	.3944	.4801
5	.4481	.4287	.3601	.4115	.4668	.4287	.5144
6	.4681	.4801	.4115	.4458	.4481	.5144	.5487
7	.5601	.5316	.4458	.4458	.5041	.5658	.5658
8	.6908	.6001	.4973	.4973	.5041	.5316	.6001
9	.6348	.6173	.583	.5788	.5415	.583	.6348
10		.4458	.5487	.5601	.5975	.5144	.5975
11		.5316		.5228	.6001		.5415
12		.4458	.4973	.7095	.463	.3201	.4854
13		.4287		.5601	.5316	.4287	.5041
14		.3429	.4287	.4668	.4458		.4668
15		.3258		.4294	.4458		.3944
16	.3601	.3772		.4108	.4287		.4108
17	.3601	.3429	.3601	.4108	.4458	.3772	.4294
18	.3944	.3944	.3944	.4294	.4801	.4287	.4668
19	.4973	.5487	.5658	.6348	.5658	.5658	.6161
20		.583	.5658	.6535	.6001	.583	.6535
21	.5658	.5658	.6173	.6348	.583	.6001	.6348
22	.5658	.5487	.5658	.6348	.5658	.583	.6348
23	.5144	.5487	.5658	.6161	.5658	.5658	.6348
24	.5601	.4287	.4973	.4973	.5601	.5658	.5975
Max	.6908	.6173	.6173	.7095	.6001	.6001	.6535
Min	.3601	.3258	.3429	.3772	.4108	.3201	.3944
Avg	.4904	.4587	.4681	.5067	.5096	.4970	.5327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 202 / 11KV APPEJAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2351	1.1364	1.2039	1.2149	1.3979	1.2323	.6722
2	1.1593	1.0683	1.105	1.129	1.3195	1.1705	.6161
3	1.0972	.996	1.0417	1.0711	1.2125	1.0932	.5788
4	1.0466	.9469	.9807	.9877	1.1141	1.0613	.5041
5	1.0827	1.0502	1.0469	1.0055	1.1018	1.1149	.5228
6	1.1883	1.139	1.1706	1.0844	1.1608	1.227	.5601
7	1.2593	1.2033	1.1898	1.1454	1.2623	1.3146	.6161
8	.708	1.3575	1.3217	.6386	1.206	1.3682	.6908
9	1.3302	1.3026	.6462	1.2782	1.2418	1.3073	.6722
10	.7057	1.3432	.6775	.644	1.2681	.7369	
11	.7552	1.4426	.7125	1.4087	1.4183	.7735	
12	.7636	.7179	.7209	.7575	1.4796	1.5279	
13	.772	1.5425	.7141	1.6103	1.5421	.8078	
14	.7667	1.4575	.6783	.8063	1.4635	.8063	.7095
15	.6836	1.3851	1.2445	1.4457	1.3093	1.4148	.7095
16	.6737	.6843	1.2788	1.4548	1.2982	1.4373	.5975
17	.6874	.7072	.6386	.7308	1.3192	.7141	.7095
18	.7385	1.3948	1.3618	1.5964	1.3492	.7446	.7095
19	.9267	1.7367	.8878	1.8374	1.7284	1.8398	.924
20	1.7383	1.8496	.9214	1.9067	1.8358	.9526	.9145
21	1.6514	1.7682	.8779	1.9296	1.6995	1.8099	.8596
22	1.5409	1.6789	.8116	1.7703	1.6179	.8787	.8316
23	1.3215	1.4045	.7491	1.5596	1.4461	1.5081	.7468
24	1.2803	1.2258	1.2854	1.3165	1.4754	1.3645	.6908
Max	1.7383	1.8496	1.3618	1.9296	1.8358	1.8398	.924
Min	.6737	.6843	.6386	.6386	1.1018	.7141	.5041
Avg	1.0463	1.2725	.9694	1.2637	1.3861	1.1753	.6918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 203 / 11KV CIDCO OFFICE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1035	.9486	1.0509	1.0587	1.2186	1.214	.5611
2	1.0326	.913	.9728	1.0094	1.1268	1.1161	.543
3	.9968	.8358	.9237	.9168	1.0474	1.0336	.4887
4	.9558	.8071	.8558	.8749	.9633	1.0059	.4525
5	.9644	.8467	.9289	.868	.8955	1.0242	.4706
6	1.0633	.9404	1.0128	.9185	.9633	1.0989	.5068
7	1.1574	1.0539	.9688	.9243	.9974	1.1401	.5249
8	.6241	1.1871	1.0845	.535	1.054	1.1942	.5973
9	1.2622	1.2384	.5914	1.1104	1.0338	1.2661	.5068
10	.5456	1.0661	.5281	.5716	1.0433	.5685	
11	.5396	1.1027	.4893	1.0417	1.025	.618	
12	.5365	.5624	.4832	.5418	.9693	1.1805	
13	.551	1.0827	.4748	1.0112	1.0351	.6089	
14	.535	1.0524	.4969	.5624	.9983	.5693	.5121
15	.5327	1.012	.951	.9956	1.0074	1.1187	.5487
16	.5548	.5487	.4755	1.0524	.9876	1.1454	.5121
17	.5411	.5495	.4786	.5365	.9907	.586	.5304
18	.5243	1.0378	.9602	.9783	.9593	.5533	.5249
19	.6554	1.3367	.6333	1.3119	1.2601	1.4655	.6447
20	1.2723	1.3473	.644	1.3991	1.3119	.727	.6805
21	1.227	1.323	.6356	1.3278	1.3104	1.3386	.6447
22	1.1439	1.2874	.6325	1.3108	1.2601	.695	.6447
23	1.1332	1.2403	.6577	1.3087	1.2946	1.3074	.6697
24	1.1372	1.1007	1.166	1.2129	1.327	1.2935	.6154
Max	1.2723	1.3473	1.166	1.3991	1.327	1.4655	.6805
Min	.5243	.5487	.4748	.535	.8955	.5533	.4525
Avg	.8579	1.0175	.7540	.9741	1.0867	.9945	.5590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 204 / 11KV STEP GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8924	.7865	.8086	.8841	.965	.9366	.4805
2	.8315	.74	.7392	.8242	.897	.8604	.4435
3	.7891	.6958	.6945	.789	.8063	.8055	.3881
4	.7605	.6777	.6577	.7499	.7735	.7624	.3696
5	.7754	.6885	.7075	.7569	.7522	.7981	.4066
6	.9014	.7771	.8088	.8204	.7859	.8814	.4435
7	.9267	.8776	.8425	.8694	.8027	.9282	.4805
8	.4854	.9305	.9305	.4626	.8318	.9825	.499
9	.951	.8981	.4885	.9322	.9263	.9206	.4435
10	.4123	.7796	.4672	.4359	.8453	.4572	
11	.4123	.4336	.4405	.8478	.8977	.4679	
12	.4092	.4153	.4199	.4245	.8825	.9053	
13	.3993	.7392	.4092	.792	.8208	.41	
14	.3818	.3788	.4039	.3841	.7819	.4077	.4066
15	.3635	.7283	.7667	.7194	.7966	.7834	.3881
16	.3483	.3635	.3605	.7354	.7697	.743	.3511
17	.3658	.3574	.3643	.3841	.7613	.381	.3696
18	.3849	.7644	.7274	.7819	.7855	.4092	.3982
19	.9237	.9637	.4672	1.0122	.913	.9471	.4706
20	.9602	1.0069	.4748	1.0283	.9789	.5243	.4938
21	.901	.9667	.4763	1.0082	.9562	1.0107	.5121
22	.8896	.9456	.487	.9842	.9366	.5274	.5121
23	.913	.9701	.4893	1.057	1.0223	1.0341	.5175
24	.92	.8688	.9191	.9846	1.0517	.9993	.499
Max	.9602	1.0069	.9305	1.057	1.0517	1.0341	.5175
Min	.3483	.3574	.3605	.3841	.7522	.381	.3511
Avg	.6791	.7397	.5980	.7778	.8642	.7451	.4437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 205 / 11KV JUINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4288	2.345	2.4074	2.46	2.6139	2.6246	1.262
2	2.2933	2.1963	2.254	2.2855	2.4471	2.4303	1.1827
3	2.1782	2.0833	2.1298	2.1117	2.3144	2.2494	1.1273
4	2.0323	1.978	2.0157	2.0104	2.1275	2.1837	1.0349
5	2.2001	2.0256	2.1696	2.1307	2.1287	2.3457	1.1088
6	2.6647	2.6154	2.3912	2.3747	2.3542	2.6919	1.3676
7	3.1163	3.1142	2.7961	2.7922	2.8342	3.1744	1.6448
8	1.7299	3.3179	3.3817	1.6751	3.3184	3.4431	1.6448
9	3.0622	2.8772	1.6918	2.954	1.6842	2.9786	1.3121
10	1.3382	2.3164	1.4266	1.3748	2.6936	1.3756	
11	1.1225	1.038	1.2071	2.2643	2.4455	1.1477	
12	1.0425	1.0143	1.0761	1.1294	2.3007	2.0104	
13	.9122	1.7505	.9305	1.9168	2.1216	.9732	
14	.9153	.8939	.9183	.9739	2.0592	.9663	.8413
15	.8779	1.7398	1.7558	1.8412	2.0175	1.8675	.8686
16	.8558	.8855	.8817	1.874	1.9852	1.8801	.8871
17	.8947	.9054	.9023	.9838	1.4518	.9915	.8962
18	.9656	1.8387	1.7886	2.0464	2.0904	1.0395	.9774
19	1.3336	2.7849	1.2567	2.6875	2.6809	2.6429	1.3575
20	2.8933	2.9358	1.4342	2.9752	2.969	1.5234	1.5581
21	3.0391	3.1471	1.576	3.2263	3.1341	3.0065	1.6108
22	3.0293	3.0497	1.5592	3.1717	3.1451	1.5668	1.6289
23	2.745	2.8829	1.5219	3.0116	3.0201	2.9759	1.5364
24	2.5735	2.6116	2.6574	2.7473	2.8921	2.8289	1.3169
Max	3.1163	3.3179	3.3817	3.2263	3.3184	3.4431	1.6448
Min	.8558	.8855	.8817	.9739	1.4518	.9663	.8413
Avg	1.9268	2.1811	1.7554	2.2091	2.4512	2.1216	1.2582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 206 / 11KV TRUPTI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4875	1.3773	1.3986	1.39	1.5508	1.534	.7577
2	1.4118	1.2824	1.3077	1.2651	1.4184	1.4209	.6722
3	1.3127	1.134	1.2483	1.2025	1.3302	1.3342	.5975
4	1.2212	1.1435	1.2902	1.2113	1.2611	1.2982	.5788
5	1.3276	1.2262	1.331	1.2734	1.2418	1.3497	.7095
6	1.5455	1.4442	1.4072	1.4494	1.3912	1.5973	.8215
7	1.7722	1.6953	1.6595	1.6537	1.6682	1.8103	.9335
8	.9549	1.8862	1.8358	.9198	1.7646	1.8374	.9709
9	1.5741	1.4632	.8756	1.6095	1.5885	1.5276	.7842
10	.7133	1.3664	.7217	.7522	1.3883	.7484	
11	.7072	.6988	.6562	1.3703	1.4245	.7308	
12	.6866	.6859	.6363	.7247	1.3801	1.3902	
13	.6584	1.3016	.612	1.4026	1.3542	.7164	
14	.6584	.6592	.6112	.6889	1.3824	.7118	.6283
15	.6363	1.1694	1.1605	1.3014	1.3395	1.2814	.6283
16	.6363	.6142	.5799	1.2928	1.3258	1.3075	.6468
17	.6775	.6546	.602	.6722	1.3389	.6783	.6584
18	.7026	1.3168	1.2361	1.38	1.4106	.7377	.7059
19	.9198	1.8589	.8589	1.8304	1.8393	1.8259	.905
20	1.7875	1.9052	.9252	1.935	1.9136	.9724	.9774
21	1.8281	1.8456	.8985	1.89	1.7657	1.8473	.9694
22	1.7514	1.7352	.8787	1.7779	1.73	.9572	.8596
23	1.5615	1.6836	.8436	1.7488	1.704	1.744	.8871
24	1.5444	1.5162	1.5655	1.5925	1.7179	1.6374	.7947
Max	1.8281	1.9052	1.8358	1.935	1.9136	1.8473	.9774
Min	.6363	.6142	.5799	.6722	1.2418	.6783	.5788
Avg	1.1699	1.3193	1.0475	1.3473	1.5096	1.2915	.7743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 207 / 11KV AUGUSTEEN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788	.5228	.5601	.5601	.6161	.5975	.5975
2	.5415	.4854	.5228	.5041	.5601	.5601	.5601
3	.5041	.4527	.4854	.4668	.499	.5281	.5041
4	.4668	.4715	.4294	.4108	.4435	.5093	.4668
5	.5228	.5281	.4854	.4481	.4805	.5281	.4854
6	.5601	.5975	.6535	.4854	.5359	.5975	.5415
7	.5788	.6535	.5415	.5415	.6908	.6161	.5975
8		.7095	.7468		.6908	.7468	.7468
9	.7282	.6908		.5415	.6535	.5788	.5601
10		.5975			.6161		
11				.6722	.6348		
12					.6535	.6722	
13		.5975		.6161	.5975		
14					.6161		.6348
15		.5601	.5658	.6283	.5601	.6224	.6161
16				.6283	.5788	.5975	.6535
17					.5975		.6348
18		.6161	.5788	.6099	.6535		.6348
19	.8775	.9896		1.0269	.9709	.961	.9522
20	.8029	.9896		.9896	.7842		.8402
21	.7282	.7602		.7842	.7842	.7577	.7842
22	.6908	.7095		.7282	.7282		.7282
23	.5975	.6161		.6535	.6908	.6722	.6722
24	.6161	.5415	.5975	.5975	.6348	.6161	.6161
Max	.8775	.9896	.7468	1.0269	.9709	.961	.9522
Min	.4668	.4527	.4294	.4108	.4435	.5093	.4668
Avg	.6282	.6363	.5606	.6259	.6363	.6351	.6413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 208 / 11KV RAILWAY COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4732	.4491	.4995	.4839	.5523	.5433	.2641
2	.4512	.4165	.4709	.4575	.4985	.5249	.2477
3	.413	.3878	.4203	.4302	.4472	.4529	.2286
4	.3948	.3852	.3931	.3999	.4064	.4264	.1905
5	.4321	.3993	.4165	.4168	.421	.4618	.2096
6	.4786	.4378	.4908	.4302	.4355	.4611	.2263
7	.5548	.4748	.5342	.4672	.4822	.5117	.2452
8	.2606	.4908	.4873	.2484	.502	.5031	.2641
9	.682	.6211	.2926	.5438	.5972	.6165	.3018
10	.8718	.8642	.4001	.378	.6491	.458	
11	.554	.522	.4938	.9572	.8428	.5655	
12	.5807	.5624	.5502	.5007	.8444	1.2407	
13	.5617	1.044	.5434	.9804	.8631	.612	
14	.554	.5357	.5045	.5091	.8543	.5982	.5335
15	.5914	1.1858	1.0402	1.0094	.8504	1.2841	.6097
16	.6066	.6188	.5068	1.0165	.8406	1.2346	.5658
17	.5777	.5982	.4809	.5281	.7781	.6226	.6602
18	.5746	1.1155	.8623	.9215	.8024	.6112	.547
19	1.0837	1.1368	.4969	1.0555	.8204	1.2029	.5281
20	.9785	.989	.471	.9699	.6851	.5479	.4527
21	.708	.7986	.4092	.7382	.6727	.8387	.415
22	.6226	.6962	.3467	.66	.6714	.3589	.3429
23	.5197	.6211	.3102	.6264	.6135	.6597	.3239
24	.5075	.5235	.5641	.5569	.6143	.5815	.2829
Max	1.0837	1.1858	1.0402	1.0555	.8631	1.2841	.6602
Min	.2606	.3852	.2926	.2484	.4064	.3589	.1905
Avg	.5847	.6614	.4994	.6369	.6560	.6633	.3720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 201 / 11KV NRI COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.2803	1.39	1.39	1.4266	1.5546	1.6095
2	1.2803	1.1706	1.2803	1.3169	1.3352	1.4632	1.3535
3	1.1706	1.0608	1.1888	1.2071	1.2254	1.39	1.2803
4	1.1157	1.0974	1.0974	1.1523	1.1523	1.2803	1.2437
5	1.2254	1.1827	1.0242	1.1088	1.0974	1.1706	1.2803
6	1.2803	1.2936	1.0974	1.1088	1.134	1.3169	1.3535
7	1.4632	1.386	1.1523	1.1273	1.0791	1.4632	1.5524
8	1.2803	1.4045			1.0974		.1441
9	1.4815	1.4815	1.6095	1.4969	1.2437		1.6263
10	1.4266	1.5181		1.5893	1.4266		1.3306
11			1.4083			1.3306	1.3491
12		1.1706		1.39	1.4266	1.2883	
13			1.2382	1.3717	1.4632		
14		1.134	1.2136		1.3352		1.2197
15				1.39			1.3306
16				1.3169		1.1523	1.2803
17		1.0974	1.1273	1.2437	1.3352		
18	1.0903	1.0425	1.0903	1.1888		.1097	1.0608
19	1.2382		1.2803	1.3169	1.5364	1.4449	1.4266
20	1.5154		1.5364		1.5729	1.5893	1.4998
21	1.4815			1.4998		1.6078	1.5912
22	1.39	1.5364	1.5546	1.5729		1.7002	1.6461
23	1.4266		1.6278	1.5546		1.7741	1.7375
24	1.4266	1.3535	1.4632	1.4815	1.5546	1.6461	1.6817
Max	1.5154	1.5364	1.6278	1.5893	1.5729	1.7741	1.7375
Min	1.0903	1.0425	1.0242	1.1088	1.0791	.1097	.1441
Avg	1.3332	1.2631	1.2989	1.3412	1.3201	1.3695	1.3618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 203 / 11KV BPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.134	1.2803	1.2803	1.4632	1.4632	1.4632
2	1.2803	1.0608	1.2071	1.2197	1.3352	1.39	1.3717
3	1.1157	.9877	1.0974	1.134	1.1888	1.2803	1.2803
4	1.1706	.9145	1.0608	1.0608	1.134	1.3717	1.1706
5	1.2254	1.0242	1.2071	1.1458	1.1157	1.4632	1.2803
6	1.2986	1.1827	1.3169	1.2567	1.1706	1.5729	1.4083
7	1.4815	1.4415	1.4083	1.4045	1.2437	1.6461	1.587
8	1.5181	1.423			1.3535		1.7002
9	1.5912	1.5123	1.4632	1.5708	1.3717		1.6817
10		1.6263		1.6817	1.5364		1.4045
11			1.4083			1.3491	1.4045
12		1.2803		1.2936	1.4632	1.4969	
13			1.1643	1.3535	1.3169		
14			1.1273		1.4632		1.3676
15				1.1888			1.1827
16				1.2986		1.262	1.3717
17		1.2986	1.1458	1.2986	1.4083		
18	1.3491	1.3717	1.386	1.5364		1.5912	1.3352
19	1.6078		1.4415	1.5729	1.7924	1.701	1.6461
20	1.6804		1.4449		1.5912	1.6278	1.701
21	1.5154			1.701		1.7187	1.6827
22	1.4083	1.5546	1.4998	1.4998		1.6263	1.7741
23	1.3717		1.4998	1.5912		1.6817	1.7193
24	1.3535	1.2254	1.3717	1.3717	1.5546	1.5912	1.5339
Max	1.6804	1.6263	1.4998	1.701	1.7924	1.7187	1.7741
Min	1.1157	.9145	1.0608	1.0608	1.1157	1.262	1.1706
Avg	1.3905	1.2692	1.3073	1.3730	1.3825	1.5196	1.4794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 204 / 11KV SWP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.3772	.2801	.3734	.3361	.4668	.3361
2	.3361	.3361	.3361	.3361	.3361	.4108	.3734
3	.3174	.2987	.3734	.2987	.3174	.3734	.3734
4	.2987	.2987	.4108	.0299	.2801	.3361	.3921
5	.3174	.3361	.4668	.3361	.2987	.2801	.3547
6	.3361	.3734	.4294	.3734	.2987	.3734	.3547
7	.3547	.3547	.3734	.4481	.4108	.4108	.3547
8	.3921	.4294			.3361		.4435
9	.4668	.5359	.4668	.3921	.5415		.4251
10		.4435		.4251	.4854		.4066
11			.439			.5601	.4805
12		.3734		.4435	.4294	.2987	
13			.4481	.3881	.4108		
14			.3696		.3361		.5975
15				.3734			.4805
16				.3734		.3547	.5601
17		.3921	.4435	.4108	.4854		
18	.5788	.4668	.4805	.4668		.3734	.5415
19	.5359		.3696	.3734	.4854	.4668	.4854
20	.462		.4251		.4481	.3547	.6161
21	.4108			.2987		.3142	.3921
22	.3326	.3734	.3658	.3734		.4435	.4668
23	.4066		.439	.3734		.2957	.4481
24	.5788	.4251	.3361	.439	.3547	.4294	.3326
Max	.9335	.5359	.4805	.4668	.5415	.5601	.6161
Min	.2987	.2987	.2801	.0299	.2801	.2801	.3326
Avg	.4411	.3876	.4030	.3663	.3877	.3849	.4388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 205 / 11KV DELHI PUBLIC SCHOOL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.0381	.0572	.0572	.0381	.0381
2	.0381	.0381	.0381	.0381	.0572	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0572	.0381	.0572	.0381	.0381	.0762
5	.0572	.0572	.0572	.0572	.0572	.0572	.0762
6	.0762	.0572	.0762	.0572	.0572	.0572	.0762
7	.0762	.0762	.0762	.0572	.0762	.0572	.0572
8	.0953	.0762			.0762		.0762
9	.1334	.1143	.0381	.0762	.0381		.0953
10		.1143		.0572	.0572		.1143
11			.0381			.1143	.0953
12		.1143			.0762	.0762	
13			.0762	.0762	.0762		
14					.0572		.0762
15				.0572			.0572
16				.0572		.0381	.0572
17		.0572	.0572	.0572	.0572		
18	.0381	.0572	.0572	.0381		.0572	.0572
19	.0381		.0572	.0572	.0572	.0572	.0572
20	.0572		.0572		.0572	.0381	.0572
21	.0953			.0572		.0381	.0572
22	.0762	.0381	.0572	.0572		.0381	.0572
23	.0762		.0572	.0572		.0572	.0381
24	.0572	.0572	.0572	.0762	.0572	.0572	.0381
Max	.1334	.1143	.0762	.0762	.0762	.1143	.1143
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0655	.0661	.0538	.0572	.0583	.0527	.0635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 206 / 11KV NEELKANTH TOWER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.2936	1.3717	1.3817	1.39	1.6461	1.5154
2	1.2986	1.1949	1.2803	1.2936	1.2986	1.5729	1.39
3	1.1888	1.0719	1.1706	1.2323	1.2254	1.4632	1.3443
4	1.2437	1.0082	1.0974	1.1576	1.1523	1.3717	1.2567
5	1.3169	1.0903	1.2437	1.2323	1.1888	1.4632	1.419
6	1.4266	1.2437	1.3535	1.3256	1.2437	1.5729	1.6263
7	1.6461	1.4815	1.4632	1.419	1.2803	1.7375	1.6278
8	1.6278	1.5912			1.3352		1.6461
9	1.5729	1.5729	1.5181	1.3717	1.3352		1.5912
10		1.5729		1.4632	1.39		1.4632
11			1.5339			1.6448	1.4632
12		1.5181		1.4266	1.4083	1.5524	
13			1.3535	1.4266	1.4632		
14					1.3717		1.4815
15				1.3535			1.4083
16				1.4266		1.5154	1.5729
17		1.5729	1.3717	.8779	1.6095		
18	1.4998	1.4632	1.39	1.5364		1.4998	1.5546
19	1.5912		1.5546	1.6644	1.7375	1.6461	1.6278
20	.1591		1.4998		1.701	1.6827	1.6461
21	1.5546			1.5912		1.6827	1.6827
22	1.4449	1.5546	1.5339	1.5912		1.701	1.6827
23	1.4998		1.5893	1.6827		1.7558	1.7375
24	1.4083	1.3491	1.4632	1.5123	1.5912	1.6827	.1645
Max	1.6461	1.5912	1.5893	1.6827	1.7375	1.7558	1.7375
Min	.1591	1.0082	1.0974	.8779	1.1523	1.3717	.1645
Avg	1.3657	1.3719	1.3993	1.3983	1.3954	1.5995	1.4715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 207 / 11KV KOKAN RAILWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	.8131	.924	.9709	1.0425	1.1088	1.0456
2	.8686	.7762	.8501	.8871	.9425	1.0164	.961
3	.8316	.7842	.7392	.8215	.8501	.924	.8871
4	.9055	.8589	.7947	.7282	.7762	.8501	.7762
5	.9425	.9149	.8501	.8215	.7499	.924	.8871
6	1.0349	.9877	.9425	.8962	.8316	1.1088	1.1273
7	1.1827	1.134	1.0164	1.0456	.8501	1.2197	1.1888
8	1.2197	1.2071			.961		1.262
9	1.1888	1.134	1.2567	1.1706	1.0719		1.2437
10		1.0608		1.1523	1.1827		1.0059
11			1.0349			.9055	.9328
12		.7947		.9145	.9979	.924	
13				.8779	.9795		
14					.8871		.7499
15				.7316			.7499
16						.8316	.7499
17		.7762	.7316	.8779	.961		
18	.8779	.924	.8686	.9877		.9335	.8779
19	1.0974		1.1088	1.134	1.2382	1.134	1.1157
20			1.0719		1.2012	1.1888	1.1157
21	1.0608			1.1706		1.1706	1.1888
22	1.0791	1.1458	1.1088	1.134		1.2254	1.1706
23	1.0242		1.1088	1.1523		1.1523	1.1523
24	.961	.8686	1.0164	.9877	1.1157	1.1827	1.0903
Max	1.2197	1.2071	1.2567	1.1706	1.2382	1.2254	1.262
Min	.8316	.7762	.7316	.7282	.7499	.8316	.7499
Avg	1.0132	.9453	.9640	.9717	.9788	1.0471	1.0133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 208 / 11kV KENDRIYA VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9425	.9335	.924	.9709	1.1088	1.1088	1.0829
2	.8871	.8962	.8316	.9335	.9979	1.0349	1.0082
3	.8316	.8215	.7392	.8775	.9425	.924	.9335
4	.8686	.7468	.7762	.8029	.8686	.8316	.8686
5	.924	.8962	.8316	.8215	.7947	.924	.9709
6	.961	1.0082	.8871	.8589	.8501	.9979	1.0642
7	1.0719	1.1203	.924	.9149	.8131	1.1088	1.0642
8	1.1273	1.1203			.9979		.9979
9	1.1203	1.1203	1.1458	1.1203	.9795		1.2012
10		1.1273		1.2696	1.2012		1.2012
11			1.2936			1.2197	1.1643
12		1.2197		1.2323	1.2567	1.2382	
13				1.1827	1.2382		
14					1.2197		1.1273
15				1.1827			1.1088
16				1.1827		1.1763	1.1643
17		1.2382	1.1643	1.1827	1.2936		
18	1.262	1.2936	1.2254	1.2936		1.2883	1.2936
19	1.3717		1.39	1.3676	1.423	.1438	1.423
20			1.3717		1.4784	1.4937	1.3676
21	1.4045			1.423		1.4415	1.4415
22	1.2752	1.1827	1.2254	1.2197		1.3491	1.3121
23	1.1389		1.1706	1.2197		1.2382	1.2936
24	1.0164	.961	1.0349	1.0242	1.2012	1.1827	1.1576
Max	1.4045	1.2936	1.39	1.423	1.4784	1.4937	1.4415
Min	.8316	.7468	.7392	.8029	.7947	.1438	.8686
Avg	1.0802	1.0457	1.0585	1.1040	1.0979	1.1001	1.1546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

NERUL S/DN.[642]

BU 4642

Substation No/ Name :- 284004 / 33/11KV Sec-50, NRI S/Stn

Feeder No / Name : 209 / 11KV SEAWOODS PH-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5935	.5087	.57	.6859	.6783	.6706	.5935
2	.5596	.4801	.503	.6516	.6274	.6036	.5487
3	.5426	.4801	.4694	.583	.5935	.5533	.5144
4	.5087	.4954	.503	.5316	.5256	.503	.4801
5	.5256	.4801	.503	.4801	.4748	.5868	.5316
6	.5596	.5487	.5533	.5144	.5087	.6706	.6001
7	.6443	.6173	.5868	.5658	.4748	.7209	.6516
8	.5868	.5935			.5256		.5765
9	.5533	.5596	.6036	.5256	.5533		.5765
10		.5765		.6274	.5365		.5596
11			.5533	.5426		.5596	.5256
12		.503			.6036	.5365	
13			.061	.5935	.5533		
14					.5868	.5197	.4917
15				.5426			.5087
16				.5533		.5087	.5256
17		.5533	.5426	.6036	.7042		
18	.5533	.5868	.6036	.57		.57	.5935
19	.6203		.6104	.6203	.6203	.6036	.6539
20	.6036		.6274		.6036	.6274	.6203
21	.5868			.5533		.6539	.6371
22	.5765	.6371	.5935	.6203		.6952	.6539
23	.6274		.5935	.6706		.7122	.6706
24	.6104	.5596	.6371	.6952	.5365	.7042	.6613
Max	.6443	.6371	.6371	.6952	.7042	.7209	.6706
Min	.5087	.4801	.061	.4801	.4748	.503	.4801
Avg	.5783	.5453	.5361	.5865	.5710	.6111	.5798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284003 / 33/11KV Sec-11, Nerul S/Stn

Feeder No / Name : 201 / 11KV NERUL GAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9357	1.8229	1.9006	1.925	2.05	2.0424
2	1.8442	1.7177	1.7711	1.7848	1.9052	1.9326
3	1.7558	1.6766	1.7193	1.7223	1.8214	1.8762
4	1.7269	1.6339	1.7147	1.6949	1.7589	1.8
5	1.8503	1.7513	1.7467	1.7528	1.7436	1.8869
6	2.6063	2.5469	2.4006	2.399	2.2878	2.6627
7	2.8791	2.8395	2.7115	2.7359	2.556	2.9706
8	2.9005	2.8654	2.7237	2.7603	2.6917	2.9965
9	2.4097	2.3076	2.3152	2.2756	2.2146	2.4158
10	2.1735	2.1247	2.1262	2.1887	2.1597	2.2786
11	2.0774	2.0485	2.0165	2.1018	2.0805	2.2298
12	1.9829	1.9982	1.8976	2.0607	2.0591	2.1963
13	1.9006	1.9738	1.9052	2.0226	2.0256	2.1232
14	2.0774	2.0226	1.8762	2.0226	2.0012	2.0256
15	2.0073	1.9616	1.8061	1.9342	1.8381	2.0927
16	2.0972	2.0104	1.7787	2.0165	1.8778	2.1826
17	2.1201	2.0713	1.8381	2.1079	1.9677	2.1978
18	2.2512	2.1674	1.9982	2.2558	2.0896	2.2497
19	2.5774	2.9797	2.8288	3.0529	2.931	2.6749
20	2.5652	2.8532	2.71	2.9569	2.87	2.6353
21	2.7221	2.5408	2.4143	2.6337	2.5377	2.5606
22	2.649	2.4508	2.4158	2.5316	2.5088	2.713
23	2.1674	2.2817	2.242	2.3929	2.3975	2.6764
24	1.9951	2.0805	2.0805	2.2375	2.2268	2.2649
Max	2.9005	2.9797	2.8288	3.0529	2.931	2.9965
Min	1.7269	1.6339	1.7147	1.6949	1.7436	1.8
Avg	2.2197	2.1970	2.1224	2.2320	2.1917	2.3202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 201 / 11KV SAMNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.4973	.6344	.6859	.7545	.6859	.703
2	.5658	.4801	.6687	.6516	.6516	.7202	.6001
3	.583	.463	.6001	.6001	.6001	.6516	.5487
4	.5144	.4287	.4458	.5487	.4801	.6001	.4801
5	.463	.4801	.4801	.5144	.4458	.5487	.4458
6	.4801	.4801	.5144	.4973	.4458	.6516	.4458
7	.5487	.5487	.4801	.463	.4287	.6001	.5144
8	.463	.4973	.463	.4287	.4458	.4801	.5144
9	.5487	.4801	.4973	.463	.4973	.5144	.5144
10	.5658	.5487	.6344	.583	.5658	.6859	.6173
11	.5487	.6001	.6516	.6001	.583	.583	.6001
12	.4973	.5316	.6001	.6516	.6001	.5316	.583
13	.4973	.4458	.5316	.5487	.5316	.5144	.5658
14	.5144	.4458	.5144	.5144	.4801	.4801	.5487
15	.5487	.463	.5144	.5144	.5658	.583	.5487
16	.5316	.4973	.5144	.5487	.583	.5487	.5487
17	.463	.4801	.4801	.6516	.5144	.5144	.5658
18	.4801	.4973	.4801	.5487	.5144	.5316	.583
19	.6001	.6173	.6344	.6516	.6516	.583	.6001
20	.6173	.6173	.6516	.6001	.6173	.5658	.6344
21	.6516	.583	.6516	.6859	.6173	.6173	.6859
22	.703	.6687	.6859	.6859	.6859	.6516	.6859
23	.6344	.6173	.703	.7373	.7716	.7888	.6859
24	.6516	.5316	.6173	.7202	.823	.7716	.7373
Max	.703	.6687	.703	.7373	.823	.7888	.7373
Min	.463	.4287	.4458	.4287	.4287	.4801	.4458
Avg	.5516	.5208	.5687	.5873	.5773	.6001	.5816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 202 / 11 KV MITTAL TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.12	.1543	.1372	.1543	.1372
2	.1372	.1372	.1372	.1372	.1372	.1715	.1372
3	.12	.1372	.12	.12	.12	.1372	.12
4	.12	.12	.1029	.12	.12	.12	.12
5	.12	.1372	.12	.12	.12	.12	.12
6	.1372	.1543	.1372	.12	.1372	.1372	.1372
7	.1543	.1886	.1543	.12	.1372	.1543	.1543
8	.1372	.1715	.1372	.1543	.1372	.1372	.1372
9	.1372	.1372	.1372	.1543	.1372	.1372	.1543
10	.1372	.1372	.1715	.1715	.1372	.1543	.1543
11	.1543	.1372	.1372	.1543	.1372	.1543	.1543
12	.1543	.12	.1543	.1543	.12	.1543	.1715
13	.1543	.1372	.1543	.1543	.12	.1543	.1715
14	.1543	.1372	.1543	.1543	.1029	.1372	.1715
15	.1715	.1372	.1543	.1543	.1372	.1543	.1715
16	.1715	.1372	.1543	.1543	.1372	.1543	.1715
17	.1543	.1372	.1543	.1543	.1372	.1543	.1543
18	.1715	.1372	.1543	.1543	.12	.1543	.1543
19	.1715	.1372	.1543	.1543	.1372	.1543	.1715
20	.1543	.12	.1543	.1543	.1715	.1543	.1715
21	.1543	.1372	.1715	.1372	.1372	.1372	.1715
22	.1372	.1372	.1715	.1372	.1372	.1543	.1715
23	.1543	.0686	.1715	.1372	.1372	.1543	.1715
24	.1543	.1543	.1372	.1715	.1715	.1715	.1543
Max	.1715	.1886	.1715	.1715	.1715	.1715	.1715
Min	.12	.0686	.1029	.12	.1029	.12	.12
Avg	.1479	.1372	.1465	.1457	.1343	.1486	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 203 / 11 KV IPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2401	.2743	.2915	.2401	.2401	.2401
2	.2229	.2401	.2572	.2915	.2229	.2401	.2058
3	.2229	.2401	.2229	.2743	.2058	.2058	.2058
4	.2058	.2229	.2058	.2743	.1886	.2058	.1886
5	.2058	.2229	.2058	.2743	.1886	.2229	.1886
6	.2058	.2229	.2229	.2915	.2058	.2572	.1886
7	.2229	.2572	.1886	.1886	.1886	.2229	.2058
8	.2229	.2401	.2572	.2401	.1886	.2058	.2229
9	.3258	.3086	.2915	.2572	.2229	.2743	.3258
10	.4115	.3429	.3601	.3601	.2401	.4287	.4287
11	.4458	.4801	.4115	.3944	.2743	.4801	.4458
12	.4801	.4287	.4287	.4458	.3258	.5144	.4801
13	.4973	.4458	.4287	.4287	.3086	.4973	.4973
14	.4801	.4287	.4287	.4115	.3086	.463	.4973
15	.463	.4458	.4115	.4287	.3086	.4801	.5316
16	.4458	.4458	.3772	.3944	.3429	.5144	.5316
17	.4973	.4458	.3429	.4287	.3258	.4973	.5658
18	.4458	.4287	.4287	.4115	.3086	.4973	.5658
19	.4458	.4801	.4458	.4287	.3086	.4973	.5487
20	.4115	.4115	.4115	.3772	.3258	.4287	.4287
21	.3944	.3258	.3429	.3429	.3429	.3944	.3944
22	.3772	.3429	.3258	.3258	.3258	.3601	.3772
23	.3258	.3086	.3086	.3258	.3086	.3086	.3429
24	.2915	.2572	.2743	.3086	.2915	.2915	.2915
Max	.4973	.4801	.4458	.4458	.3429	.5144	.5658
Min	.2058	.2229	.1886	.1886	.1886	.2058	.1886
Avg	.3529	.3422	.3272	.3415	.2708	.3637	.3708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 208 / 11 KV PUDHARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.12	.1029	.1543	.1372	.12	.1372
2	.1029	.12	.1029	.1372	.1029	.1029	.1029
3	.0857	.1029	.0857	.12	.1029	.1029	.1029
4	.0857	.1029	.0857	.1029	.0857	.0857	.0857
5	.0857	.1029	.1029	.1029	.0686	.0857	.0857
6	.0857	.12	.1029	.1029	.0686	.1029	.1029
7	.1029	.12	.1029	.1029	.0857	.1029	.1372
8	.1029	.1372	.12	.0857	.1029	.12	.1372
9	.2743	.2401	.2572	.2058	.1372	.2743	.2401
10	.3258	.3258	.2915	.2915	.1372	.3601	.3772
11	.3429	.3258	.3429	.2915	.1372	.4287	.4115
12	.3601	.3772	.3258	.2915	.1372	.4801	.4287
13	.3601	.3258	.3258	.2915	.1715	.4458	.4458
14	.3772	.3944	.3086	.2915	.1372	.4115	.4458
15	.3601	.463	.4115	.3086	.1372	.4287	.4801
16	.3944	.463	.3944	.2915	.1543	.4458	.4801
17	.4287	.4287	.3772	.2572	.12	.463	.4458
18	.4287	.4287	.2915	.2401	.12	.3944	.3429
19	.2915	.2915	.2743	.1886	.1372	.3086	.2743
20	.2743	.2572	.2401	.2229	.1715	.2572	.2401
21	.2401	.1886	.2058	.1886	.12	.1886	.2401
22	.1886	.1543	.2058	.1886	.1372	.1543	.2229
23	.1886	.1543	.2058	.1715	.1543	.1715	.2058
24	.1543	.1372	.4115	.1715	.1543	.1372	.1543
Max	.4287	.463	.4115	.3086	.1715	.4801	.4801
Min	.0857	.1029	.0857	.0857	.0686	.0857	.0857
Avg	.2393	.2451	.2365	.2001	.1258	.2572	.2636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284005 / 33/11KV Sec 30, Sanpada

S/Stn

Feeder No / Name : 209 / 11 KV MILLENIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.0514	.0572	.0686	.0686	.0762
2	.0572	.0572	.0686	.0572	.0572	.0686	.0572
3	.0572	.0572	.0514	.0572	.0514	.0514	.0572
4	.0572	.0572	.0514	.0572	.0572	.0514	.0572
5	.0762	.0572	.0514	.0572	.0762	.0686	.0762
6	.0762	.0762	.0686	.0572	.0686	.0514	.0762
7	.0686	.0762	.0514	.0762	.0686	.0686	.0762
8	.0762	.0762	.0514	.0762	.0762	.0686	.0762
9	.0686	.0762	.0514	.0762	.0762	.0514	.0762
10	.0762	.0686	.0514	.0762	.0762	.0514	.0762
11	.0762	.0514	.0572	.0762	.0686	.0686	.0762
12	.0762	.0514	.0762	.0762	.0514	.0686	.0762
13	.0762	.0514	.0762	.0762	.0514	.0762	.0762
14	.0762	.0514	.0762	.0762	.0686	.0762	.0762
15	.0762	.0514	.0762	.0762	.0686	.0686	.0762
16	.0762	.0514	.0762	.0762	.0686	.0762	.0762
17	.0762	.0514	.0762	.0762	.0686	.0762	.0762
18	.0762	.0514	.0762	.0762	.0686	.0762	.0762
19	.0762	.0514	.0762	.0762	.0686	.0762	.0762
20	.0762	.0514	.0762	.0762	.0686	.0762	.0762
21	.0762	.0514	.0762	.0762	.0514	.0762	.0762
22	.0762	.0514	.0762	.0572	.0686	.0572	.0762
23	.0762	.0686	.0762	.0572	.0686	.0572	.0762
24	.0762	.0762	.1029	.0762	.0762	.0514	.0762
Max	.0762	.0762	.1029	.0762	.0762	.0762	.0762
Min	.0572	.0514	.0514	.0572	.0514	.0514	.0572
Avg	.0732	.0592	.0676	.0699	.0664	.0659	.0738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 201 / 11 KV VASHI RLY I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754		.0754		.0686	.0754	.0686
2	.0754		.0754	.0754		.0754	.0686
3			.0754		.0686	.0754	.0754
4	.0754		.0754	.0754		.0754	
5	.0754	.0754	.0754		.0686	.0754	.0754
6	.0754	.0754	.0754	.0754		.0754	.0762
19		.0754		.0686	.0754	.0754	.0686
20		.0754	.0754	.0686	.0754	.0754	.0686
21		.0754	.0686	.0686	.0754		.0686
22	.0754	.0754			.0754		.0686
23		.0754	.0754	.0686	.0754		.0686
24	.0754		.0754	.0754	.0754		
Max	.0754	.0754	.0754	.0754	.0754	.0754	.0762
Min	.0754	.0754	.0686	.0686	.0686	.0754	.0686
Avg	.0754	.0754	.0747	.072	.0731	.0754	.0707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 202 / 11 KV SHAH GROUP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641		.2452		.2743	.2641	.2058
2	.2641		.2263	.2229		.2641	.2229
3			.2263		.2058	.2452	.2641
4	.2263		.2263	.2263		.2452	
5	.2641	.1886	.2452		.1715	.3018	.2641
6	.2829	.2641	.2829	.2452		.3206	.2641
7	.3206	.2829	.2641	.2452	.2229	.3395	.3018
8	.3018	.3018	.3206	.2263	.2572	.3206	.2743
9	.2829	.3018	.2829	.2641	.2401	.3018	.2572
10		.2641	.3018	.3206	.2401	.2641	.024
11		.2452	.2641	.2572	.2829	.2452	.2229
12		.2641	.2452	.2058	.2641	.0754	.2058
13		.2641	.2452	.0206	.2641	.2641	.2058
14		.2263		.2058	.2452	.2452	.2058
15		.1886		.2058	.2452	.2075	.2058
16	.2096	.2075	.1621	.2058	.2641	.1886	.2058
17		.2452		.2229	.2452	.2263	.2058
18		.2452		.2401	.2641		.2229
19		.2829	.2641	.2743	.3018	.2641	.2401
20		.2641	.2452	.2572	.2829	.2829	.2401
21		.2641	.2263	.2401	.3018		.2401
22	.2829	.2452			.2829		.2572
23		.2641	.2829	.2743	.3206		.2915
24	.2829	.2829	.2829	.2641	.3018	.2641	.2263
Max	.3206	.3018	.3206	.3206	.3206	.3395	.3018
Min	.2096	.1886	.1621	.0206	.1715	.0754	.024
Avg	.2711	.2546	.2547	.2312	.2609	.2565	.2284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 203 / 11 KV ASSAM BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754		.0754		.0686	.0754	.0686
2	.0754		.0754	.0754		.0754	.0686
3			.0754		.0686	.0754	.0754
4	.0754		.0754	.0754		.0754	
5	.0754	.0754	.0754		.0069	.0784	.0754
6	.0754	.0754	.0754	.0754		.0754	.0754
7	.0762	.0754	.0754	.0754	.0686	.0792	.0754
8	.0754	.0754	.0754	.0754	.0686	.0815	.0686
9	.0754	.0754	.0754	.0754	.0686	.0754	.0686
10		.0754	.0754	.0754	.0069	.0754	.0686
11		.0754		.0686	.0754	.0754	.0686
12		.0754	.0754	.0686	.0754	.0754	.0686
13		.0754	.0754	.0762	.0754	.0754	.0686
14		.0754		.0686	.0754	.0754	.0686
15		.0754		.0686	.0754	.0754	.0686
16	.0754	.0754	.0686	.0686	.08	.1059	.0686
17		.0762		.0686	.0754	.1112	.0686
18		.0754		.0686	.0754		.0686
19	.0213	.0754	.0686	.0686	.0754	.0943	.0686
20	.0046	.0754	.0754	.0709	.0769	.0769	.0686
21	.0069	.0754	.0754	.1098	.08	.0343	.0686
22	.0754	.0754		.0122	.0899	.0084	.0686
23		.0754	.0754	.0686	.0998	.0023	.0686
24	.0754	.0754	.0754	.0754	.083	.0762	.0754
Max	.0762	.0762	.0754	.1098	.0998	.1112	.0754
Min	.0046	.0754	.0686	.0122	.0069	.0023	.0686
Avg	.0616	.0754	.0746	.0709	.0700	.0719	.0701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 204 / 11 KV REAL TRADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8326	.4016	.8235	.3993	.8695	.7794	.3772
2	.7785	.3788	.7953	.7151	.3849	.7445	.3772
3	.3513	.3422	.7445	.349	.9335	.6619	.3772
4	.7067	.3048	.8143	.6718	.5114	.6931	
5	.7013	.5877	.7045	.3208	.777	.8234	.3584
6	.7013	.8402	.709	.6702	.4001	.7384	.3584
7	.7234	.8164	.7053	.684	.764	.7529	.3395
8	.7765	1.0425	.7712	1.1178	.8489	.8718	.4458
9	1.1457	1.073	1.0848	1.1952	.8832	1.0798	.583
10	.7186	1.2674	1.358	1.2862	1.0143	1.4285	.8573
11	.8962	.8429	.9168	1.6362	1.3862	2.0214	.8916
12	.9374	1.8715	2.0228	1.9616	1.6173	1.1363	.9259
13	.9282	1.8595	1.9816	2.092	1.5947	2.1209	.9259
14	1.0745	1.9944	1.0052	1.154	1.6313	2.1681	.9088
15	1.0928	1.9292	1.0783	2.01	1.7192	2.1505	.9088
16	2.0119	1.9989	2.2005	2.0481	1.6022	2.1551	.9259
17	1.0479	2.0907	1.1134	2.0588	1.5714	2.3022	.9602
18	1.0425	2.149	1.2163	1.9989	1.5562	1.0783	.9259
19	1.0463	2.1307	2.1696	2.0405	1.7122	2.1733	.9088
20	1.0776	1.8969	1.9019	1.9097	1.6663	2.2809	.8573
21	.8185	1.6393	1.6767	1.6789	1.5192	.9488	.7373
22	1.3148	1.2132	.7316	.7621	1.1914	.6828	.6516
23	.5266	.9987	.9653	1.0471	.9246	.4877	.4115
24	.9147	.8987	.8705	.9299	.93	1.6516	.4527
Max	2.0119	2.149	2.2005	2.092	1.7192	2.3022	.9602
Min	.3513	.3048	.7045	.3208	.3849	.4877	.3395
Avg	.9236	1.2737	1.1817	1.2807	1.1670	1.3305	.6724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 205 / 11 KV VASHI RLY -2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2753	.141	.2934	.1478	.2656	.2806	.12
2	.273	.1417	.2745	.2791	.144	.2776	.12
3	.1425	.1395	.2745	.1463	.2656	.2603	.1509
4	.2715	.1425	.273	.2603	.1433	.2595	
5	.2722	.2919	.273	.1463	.2462	.2783	.132
6	.2753	.2737	.276	.289	.1433	.2783	.1509
7	.3056	.3003	.2905	.3071	.2663	.2949	.1067
8	.2965	.3018	.2995	.2957	.2595	.3003	.1543
9	.3445	.3677	.3464	.3443	.2633	.373	.1543
10	.2286	.4248	.4549	.4081	.3041	.4348	.2401
11	.2705	.5074	.2462	.4416	.3254	.617	.2743
12	.2378	.2683	.4354	.4398	.3216	.5301	.2229
13	.2202	.5194	.4624	.2507	.3178	.2926	.2401
14	.2751	.5232	.2279	.4687	.3254	.6135	.2572
15	.2568	.5256	.25	.4927	.3239	.5372	.2401
16	.4709	.5096	.4436	.4802	.3285	.5278	.2229
17	.2576	.5217	.2294	.4802	.3224	.5565	.2229
18	.2599	.5074	.2294	.4538	.3452	.2507	.2229
19	.2583	.4808	.4384	.4504	.4323	.5468	.2058
20	.2202	.4247	.3921	.3826	.3822	.4671	.1886
21	.1814	.3875	.3557	.3448	.314	.205	.1715
22	.3336	.3535	.1684	.1799	.3163	.1707	.1543
23	.1669	.3193	.3178	.2785	.3079	.1661	.1372
24	.298	.2957	.3003	.2957	.2806	.4535	.1698
Max	.4709	.5256	.4624	.4927	.4323	.617	.2743
Min	.1425	.1395	.1684	.1463	.1433	.1661	.1067
Avg	.2663	.3612	.3147	.3360	.2894	.3738	.1852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 206 / 11 KV CIDCO WATER PUMP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8052	.378	.7817	.3384	.7689	.7316	.3429
2	.7361	.3086	.7255	.6459	.33	.7163	.3086
3	.3368	.3224	.658	.3125	.6736	.6443	.3018
4	.6504	.394	.6474	.6087	.2934	.6299	
5	.652	.6445	.6489	.2873	.5929	.6306	.2829
6	.7509	.6508	.741	.7112	.362	.7045	.2829
7	.8242	.7282	.775	.7377	.743	.728	.3395
8	.8024	.7819	.8433	.7392	.4153	.7909	.3429
9	.7814	.8779	.8236	.7893	.7354	.757	.4115
10	.6142	1.1487	1.1816	1.1401	.8253	1.0974	.4973
11	.7857	1.4811	.7446	1.3207	.9425	1.6879	.823
12	.8101	1.627	1.5289	1.5992	.9941	1.8585	.823
13	.8573	1.6371	1.5422	1.6248	1.0539	.9457	.823
14	.8642	1.6328	.7514	1.6434	.9534	1.8313	.823
15	.9054	1.685	.7842	1.6122	1.0623	1.873	.8402
16	.8939	1.7288	1.5758	1.5669	1.0056	1.7764	.8402
17	.8421	1.6038	.7659	1.515	.9458	1.7387	.7545
18	.7575	1.4811	.6996	1.448	.8373	.8269	.6859
19	.6409	1.3354	1.146	1.3184	1.0069	1.375	.6344
20	.5106	1.0307	1.0684	1.0943	.9569	1.0772	.5316
21	.4176	.9758	.9562	1.0197	.9569	.5022	.463
22	.9717	.926	.4595	.5357	.9455	.5083	.4287
23	.6767	.9183	.8412	1.0029	.9069	.474	.4115
24	.8773	.8743	.7953	.823	.889	1.2248	.3961
Max	.9717	1.7288	1.5758	1.6434	1.0623	1.873	.8402
Min	.3368	.3086	.4595	.2873	.2934	.474	.2829
Avg	.7402	1.0488	.8952	1.0181	.7999	1.0471	.5386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 208 / 11 KV LIFE STYLE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754		.0754		.0686	.0754	
2	.0754		.0754			.0754	
3			.0754		.0686	.0754	
4	.0754						
17				.0686			
18				.0069			.0686
19				.0686			.0686
21					.0754		
22		.0754			.0754		.0686
23		.0754			.0754		.0686
24	.0754		.0754				
Max	.0754	.0754	.0754	.0686	.0754	.0754	.0686
Min	.0754	.0754	.0754	.0069	.0686	.0754	.0686
Avg	.0754	.0754	.0754	.0480	.0727	.0754	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 402 / 33 KV BSEL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263		.2263		.2058	.2263	.2058
2	.2263		.2263	.2263		.2263	.2058
3			.2263		.2058	.2263	.2263
4	.2263		.2263	.2263		.2263	
5	.2263	.2263	.2263		.2058	.2263	.2263
6	.2263	.2263	.2263	.2263		.2263	.2263
7	.2263	.2263	.2263	.2263	.2058	.2263	.2058
8	.2263	.2263	.2263	.2263	.2058	.2263	.2058
9	.4527	.2263	.4527	.2263	.2058	.4527	.2058
10		.679	.679	.2263	.2058	.679	.823
11		.9054		.0412	.2263	.9054	.823
12		.9054	.679	.4115	.2263	.9054	.823
13		.679	.2263		.2263		.823
14		.679		.4115	.2263	.9054	.823
15		.9054		.4115	.2263	.9054	.823
16	.9054	.9054	.9054	.4115	.2263	.9054	.823
17		.9054		.4115	.2263	.9054	.823
18		.679		.4115	.2263		.823
19		.4527	.9054	.4115	.2263	.679	.4115
20		.2263	.2263	.2058	.2263	.4527	.4115
21		.2263		.2058	.2263		.2058
22	.2263	.2263			.2263		.2058
23		.2263	.2263	.2058	.2263		.2058
24	.2263	.2263	.2263	.2263	.2263	.9054	.2263
Max	.9054	.9054	.9054	.4115	.2263	.9054	.823
Min	.2263	.2263	.2263	.0412	.2058	.2263	.2058
Avg	.3086	.4979	.3728	.2816	.2195	.5480	.4688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 403 / 33 KV VISHWAROOP

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358		1.2449		.9259	.9054	1.0288
2	1.2449		1.2449	1.1317		.7922	1.0288
3			1.1317		.823	.7922	1.0185
4	1.1317		1.0185	1.1317		.7922	
5	1.0185	1.1317	1.0185		.7202	.9054	1.0185
6	1.0185	1.0185	1.0185	1.0185		.9054	1.0185
7	1.0185	1.1317	1.1317	1.0185	.823	1.0185	1.0185
8	1.2449	1.2449	1.2449	1.0185	.0926	1.358	1.0288
9	1.5844	1.4712	1.4712	1.1317	.9259	1.5844	1.3375
10		1.6975	1.8107	1.2449	.7202	1.8107	1.6461
11		1.8107		1.2346	.7922	2.1502	1.6461
12		1.8107	1.6975	1.2346	.9054	2.037	1.6461
13		1.6975	1.6975	1.2346	1.2449	2.037	1.6461
14		1.6975		1.1317	1.2449	1.8107	.1543
15		1.8107		1.2346	1.1317	1.8107	1.6461
16	1.9239	1.9239	1.8107	1.2346	1.0185	1.9239	1.749
17		1.9239		1.2346	1.1317	1.9239	1.749
18		2.037		1.2346	1.1317		1.749
19		1.9239	1.8107	1.2346	1.0185	2.037	1.6461
20		1.6975	1.5844	1.1317	1.1317	1.8107	1.5432
21		1.5844		1.0288	1.0185		1.4403
22	1.358	1.4712			.9054		1.3375
23		1.358	1.358	.9259	1.0185		1.2346
24	1.4712	1.358	1.358	1.2449	1.0185	.9054	1.358
Max	1.9239	2.037	1.8107	1.2449	1.2449	2.1502	1.749
Min	1.0185	1.0185	1.0185	.9259	.0926	.7922	.1543
Avg	1.3066	1.5900	1.3913	1.1518	.9401	1.4655	1.3343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284006 / 33/22/11KV Vashi Railway

S/Stn

Feeder No / Name : 404 / 33 KV SEC 30 SANPADA FRM NON SHEDDABLE EXPRESS HV FEEDERS

VASHI Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0802	1.0288	1.1317	1.3375	1.286	1.2346	1.2346
2	1.0288	1.0288	1.2346	1.2346	1.1317	1.2346	1.0288
3	1.0288	.9259	1.0802	1.1317	1.0288	1.1317	.9774
4	.9774	.8745	.823	1.0802	.9259	1.0288	.9259
5	.9259	.9259	.9259	1.0288	.8745	1.0288	.8745
6	.9259	.9774	1.0288	.9259	.8745	1.1831	.9259
7	1.0802	1.1317	.9774	.8745	.8745	1.1317	1.0802
8	.9774	1.0802	1.0288	.9774	.9259	.9774	1.0288
9	1.3375	1.1831	1.1831	1.1317	1.0288	1.2346	1.286
10	1.4918	1.3889	1.4918	1.4403	1.0802	1.6461	1.5947
11	1.5432	1.6975	1.5432	1.4918	1.1317	1.6461	1.6461
12	1.5432	1.4403	1.5432	1.5947	1.2346	1.6975	1.6975
13	1.5432	1.3889	1.4403	1.4918	1.1317	1.6461	1.6975
14	1.5432	.144	1.4403	1.4403	1.0802	1.5432	1.6975
15	1.5432	1.4918	1.5432	1.4403	1.1831	1.6461	1.8004
16	1.5947	1.5432	1.4918	1.4403	1.286	1.6975	1.8004
17	1.5432	1.5432	1.3889	1.5432	1.1317	1.6461	1.8004
18	1.5947	1.5432	1.3889	1.3889	1.1317	1.6461	1.6975
19	1.5947	1.4918	1.5432	1.4918	1.2346	1.5947	1.6461
20	1.4918	1.4403	1.4403	1.3889	1.3375	1.4403	1.4918
21	1.4918	1.2346	1.4403	1.3889	1.2346	1.3375	1.5432
22	1.4403	1.286	1.3889	1.3375	1.286	1.3375	1.4918
23	1.3375	1.286	1.3889	1.3889	1.4403	1.4403	1.4403
24	1.286	1.1317	1.2346	1.4403	1.4403	1.3889	1.3889
Max	1.5947	1.6975	1.5432	1.5947	1.4403	1.6975	1.8004
Min	.9259	.144	.823	.8745	.8745	.9774	.8745
Avg	1.3310	1.2170	1.2967	1.3096	1.1381	1.3975	1.4082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 201 / 11 KV NMMC WATER PUMP SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4415	1.5154	1.46	1.5524	1.7002	1.4969
2		1.423	1.4969	1.423	1.4969	1.6448	1.6448
3		1.4415	1.4784		1.4415	1.6078	1.6263
4		1.4784	1.4712		1.4415	1.5893	1.6078
5		1.4043	1.4969		1.4045	1.5524	1.5708
6		1.5154	1.5524		1.4045	1.5524	1.5524
7		1.5339	1.5708		1.2382	1.6078	1.6263
8		1.6817	1.6448	1.6078	1.5893	1.7187	1.6817
9		1.6817	1.7002	1.6263	1.5339	1.5893	1.5893
10		1.4969	1.5339	1.5524	1.5154	1.4969	1.5524
11	1.2752			1.46	1.423	1.3306	1.4969
12			1.2382	1.2803	1.3121	1.2197	1.4266
13				1.2197	1.2382	1.2752	1.3717
14	1.1088	1.2012		1.1827	1.2382		1.3352
15	1.1273	1.1273		1.3306	1.2197	1.2197	1.3535
16	1.1273	1.1643	1.1157	1.2382	1.2382		1.3121
17	1.3491	1.2012		1.2197	1.2567	1.2382	1.9774
18	1.4969	1.423		1.6632	1.5524	1.2382	1.8665
19	1.7187		1.701	1.8296	1.7926		1.9774
20	1.8296	1.8665		1.8111	1.9035		2.0144
21	1.7926	1.8111		1.885	1.8296		1.9959
22	1.5708	1.8296		1.6817	1.7372		1.885
23	1.5154			1.7556	1.8296		1.8111
24	1.46	1.46	1.5524	1.5154	1.7372	1.7741	1.7187
Max	1.8296	1.8665	1.701	1.885	1.9035	1.7741	2.0144
Min	1.1088	1.1273	1.1157	1.1827	1.2197	1.2197	1.3121
Avg	1.4476	1.4833	1.5049	1.5128	1.4969	1.4915	1.6455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 202 / 11 KV TEJASWINI HOSTEL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5089	1.5655	1.4712	1.5154	1.5524	1.4969
2		1.1317	1.5278	1.3957	1.4784	1.4969	1.4415
3		1.4712	1.5089		1.4415	1.4415	1.4045
4		1.4335	1.4712		1.4045	1.386	1.3676
5		1.3957	1.4335		1.3676	1.3121	1.3491
6		1.3769	1.4335		1.2752	1.3491	1.3676
7		1.4335	1.3957		1.386	1.3676	1.5524
8		1.5278	1.6409	1.6787	1.4784	1.5524	1.6448
9		1.5466	1.6975	1.6409	1.5154	1.5524	1.5708
10		1.6409	1.7353	1.6598	1.6448	1.848	1.5893
11				1.7353	1.5893	1.8296	1.6448
12			1.6804	1.8673	1.6078	1.848	1.7541
13				1.8673	1.5339		1.7918
14	1.7541	1.7164		1.7353	1.5524		1.773
15	1.8861	1.7541		1.8107	1.5708	1.885	1.8296
16	1.8861	1.8484	1.6409	1.8861	1.6078		1.8484
17	1.7918	1.8107		1.9427	1.6263		2.1845
18	1.9427	1.9239		2.0748	1.7372	1.9404	1.9978
19	2.0936		1.9805	2.1691	1.9035		2.1845
20	2.0182	2.1125		2.0748	1.9774		2.1472
21	1.9616	1.9805		2.0559	1.9959		2.0725
22	1.7164	1.8484		1.8107	1.9035		1.9418
23	1.6409			1.7541	1.7556		1.8107
24	1.5655	1.5466	1.5844	1.5466	1.7353	1.6448	1.6078
Max	2.0936	2.1125	1.9805	2.1691	1.9959	1.9404	2.1845
Min	1.5655	1.1317	1.3957	1.3957	1.2752	1.3121	1.3491
Avg	1.8415	1.6320	1.5926	1.7988	1.6085	1.6004	1.7239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 203 / 11 KV SANPADA INDL SEC 6 SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143	.1334	.1334	.1143	.1334	.1334
2		.0953	.1334	.1334	.1143	.1143	.1334
3		.0953	.1524		.1143	.1143	.1334
4		.1143	.1524		.1334	.1334	.1524
5		.1334	.1524		.1334	.1334	.1524
6		.1334	.1334		.1334	.1334	.1334
7		.1524	.1334		.1143	.1334	.1334
8		.1334	.1143	.1524	.1524	.1524	.1143
9		.1334	.1334	.1524	.1334	.1715	.1334
10		.1524	.1334	.1715	.1334	.1334	.1334
11	.1715			.1905	.1143	.1905	.1524
12			.1715	.2096	.1334		.1524
13				.1905	.1334		.1715
14	.1715			.2096	.1143		.1715
15	.1715	.1905		.2286	.1143	.1715	.1905
16	.1905	.1905	.1524	.2667	.1334		.1905
17	.1905	.1715		.2286	.1334		.1905
18	.2096	.1715		.2096	.1143	.1905	.1905
19	.1524		.1524	.1905	.1334		.1905
20	.1715	.1715		.1715	.1334		.1905
21	.1715	.1715		.1715	.1143		.1524
22	.1524	.1524		.1715	.1143		.1524
23	.1334			.1524	.1143		.1524
24		.1334	.1334	.1334	.1334	.1905	.1143
Max	.2096	.1905	.1715	.2667	.1524	.1905	.1905
Min	.1334	.0953	.1143	.1334	.1143	.1143	.1143
Avg	.1715	.1450	.1415	.1825	.1254	.1497	.1548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 204 / 11 KV SEC 6 SUBSTATION SHEDDABLE URBAN

TRANSFO Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668	.5228	.5601	.6908	.7655	.5975
2		.4668	.5228	.4668	.6535	.6535	.6535
3		.4481	.5041		.6348	.5601	.5601
4		.4294	.4668		.5975	.4854	.5041
5		.4481	.4481		.5228	.3921	.4108
6		.4294	.4668		.3734	.4294	.4294
7		.4854	.4294		.3921	.5228	.4481
8		.4668	.4481	.5041	.4108	.4668	.5041
9		.5041	.5041	.4854	.4481	.5041	.5415
10		.5041	.4668	.4854	.4668	.4854	.5228
11				.5041	.5041	.4481	.4668
12			.4294	.5041	.5415		.4294
13					.5228		.3921
14		.3921		.4481	.5041		.3734
15	.3547	.3734		.4294	.4854	.3547	.3547
16	.3547	.3547	.3921	.4481	.4854		.3921
17	.3921	.3921		.4294	.4854		.5788
18	.4668	.3921		.5041	.4668	.3921	.4854
19	.5041		.5415	.5041	.5228		.5788
20	.5788	.5415		.5601	.5788		.5975
21	.5415	.6161		.5788	.5788		.5788
22	.5041	.5415		.5601	.5975		.7468
23	.6908			.6535	.8029		.8775
24		.4854	.5788	.5601	.6535	.3547	.8589
Max	.6908	.6161	.5788	.6535	.8029	.7655	.8775
Min	.3547	.3547	.3921	.4294	.3734	.3547	.3547
Avg	.4875	.4599	.4801	.5103	.5384	.4868	.5368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 205 / 11 KV SAIKRIPA SEC 10 SHEDDABLE URBAN
 SANPADA Feeder KV- 11 /
 OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4001	.4001	.3429	.415	.4338	.415
2		.381	.381	.3239	.4338	.3961	.3961
3		.4001	.4001		.415	.3584	.3772
4		.4001	.4001		.415	.3206	.3395
5		.4191	.4191		.3961	.3395	.3584
6		.4191	.4191		.3772	.3961	.415
7		.4191	.4382		.3018	.3961	.4338
8		.4763	.4763	.5144	.3772	.5093	.4715
9		.5144	.5144	.4954	.3961	.4715	.4715
10		.4001	.4191	.4191	.4338	.4904	.4715
11	.4382			.4191	.3395	.4527	.4338
12			.2829	.3961	.3395	.4338	.4108
13				.3395	.3395		.3921
14	.362	.3048		.3395	.3206		.3361
15	.3429	.3239		.3206	.3206	.3584	.3174
16	.3048	.2858	.2614	.3206	.3206		.2987
17	.2858	.2858		.3018	.3206		.2987
18	.3048	.2667		.3206	.3584	.3395	.3734
19	.4191		.4481	.415	.3772		.4481
20	.4382	.4382		.415	.4338		.4715
21	.4382	.4382		.4715	.415		.4527
22	.4572	.4382		.4338	.415		.4715
23	.4572			.5281	.5093		.4904
24		.4191	.4001	.381	.4904	.5093	.4904
Max	.4572	.5144	.5144	.5281	.5093	.5093	.4904
Min	.2858	.2667	.2614	.3018	.3018	.3206	.2987
Avg	.3862	.3911	.4043	.3946	.3859	.4137	.4098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 206 / 11 KV SAMTA SEC 4/7 SHEDDABLE URBAN
 SANPADA Feeder KV- 11 /
 OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9709	1.0642	.9522	.9979	1.1088	1.0164
2		.9522	1.0269	.9149	.924	1.0534	.9979
3		.9335	1.0082		.8871	1.0164	1.0164
4		.9149	.9522		.8501	.9425	.961
5		.9335	.9335		.8501	.8686	.8871
6		.9335	.8962		.8316	.8686	.8686
7		1.0642	.9709		.8871	1.1273	.9979
8		1.1576	1.0829	1.1203		1.1458	1.0903
9		1.1016	1.1389	1.0642		1.1273	1.0534
10		1.0456	1.0642	1.0269	1.1273	.9979	1.0903
11				1.0082	1.0719	1.0903	1.0164
12			.8871	.961	.9979	.961	.9896
13				.8686	.8871		.9522
14	.9149	.8775		.924	.8871		.9149
15	.8775	.9149		.8871	.8686	.8501	.8775
16	.8402	.9522	.9328	.9425	.8871		.8871
17	.9522	.8775		.9979	.924		.924
18	.8962	.9709		1.0349	.9425	.9055	1.0534
19	1.1949		1.1888	1.2567	1.2382		1.3306
20	1.2136	1.2323		1.3121	1.1458		1.386
21	1.2136	1.2136		1.2197	1.1643		1.2197
22	1.1389	1.2136		1.1088	1.1273		1.2382
23	1.0456			1.1273	1.1827		1.2012
24		.9896	1.1016	1.0269	1.1458	1.1827	1.1458
Max	1.2136	1.2323	1.1888	1.3121	1.2382	1.1827	1.386
Min	.8402	.8775	.8871	.8686	.8316	.8501	.8686
Avg	1.0288	1.0131	1.0177	1.0397	.9921	1.0164	1.0465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284052 / 33/11KV Sec-6, Sanpada S/Stn

Feeder No / Name : 208 / 11 KV LAXMI SEC10 SANPADA SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.307	1.4003	1.307	1.3256	1.4563	1.3443
2		1.2696	1.3817	1.2696	1.307	1.3817	1.3817
3		1.307	1.419		1.2696	1.307	1.3256
4		1.2883	1.3443		1.2323	1.2696	1.2883
5		1.307	1.3256		1.2323	1.251	1.251
6		1.3256	1.2883		1.2136	1.3817	1.3817
7		1.363	1.419		1.3256	1.4563	1.419
8		1.4563	1.5123	1.6991	1.4937	1.5123	1.4377
9		1.2883	1.5497	1.643	1.419	1.3817	1.307
10		1.1203	1.4377	1.475	1.307	1.1576	1.251
11	1.0082			1.2696	1.251	1.1016	1.1949
12			1.1576	1.0642	1.1389	1.1016	1.1203
13				1.0829	1.1763		1.0456
14	.9522	.9335		1.0456	1.1203		.9896
15	.9709	.9522		1.0829	1.0829	1.0829	.9522
16	.9709	1.0082	1.0269	1.1016	1.1016		1.0082
17	1.0829	1.0829		1.1203	1.1203		1.0642
18	1.1576	1.1576		1.1949	1.1949	1.1389	1.1763
19	1.363		1.4377	1.4563	1.4563		1.587
20	1.531	1.5123		1.531	1.531		1.6057
21	1.475	1.5497		1.5684	1.6057		1.6244
22	1.4377	1.531		1.587	1.5684		1.6617
23	1.4003			1.5684	1.5497		1.6057
24		1.3443	1.4003	1.363	1.5497	1.5123	1.4937
Max	1.531	1.5497	1.5497	1.6991	1.6057	1.5123	1.6617
Min	.9522	.9335	1.0269	1.0456	1.0829	1.0829	.9522
Avg	1.2136	1.2686	1.3643	1.3384	1.3155	1.2995	1.3132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 201 / 11 KV SUN HOME

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.0349	1.1317	1.1763	1.2567	1.3014	1.2323
2	1.0456	.9808	1.0829	1.1389	1.1576	1.2071	1.1763
3	1.0456	.961	1.0456	1.1203	1.1088	1.1016	1.1389
4	1.0642	1.0082	1.0082	1.1576	1.1203	1.0829	1.1763
5	1.0829	1.0082	1.0269	1.1389	1.1576	1.1317	1.2136
6	1.1949	1.1763	1.1317	1.1949	1.2197	1.3392	1.307
7	1.3392	1.2752	1.2071	1.2696	1.2136	1.3957	1.363
8	1.4335	1.4563	1.4335	1.251	1.307	1.3769	1.4937
9	1.4377	1.3443	1.5089	1.3443	1.4377	1.3957	1.475
10	1.2323	1.2136	1.2637	1.3256	1.3769	1.1883	1.2883
11	1.0829	.9709	1.2136	1.1273	1.2449	1.0829	1.1576
12	.8775	.9149	.9335	1.0456	1.1203	.9522	.9808
13	.9149	.8402	.9335	.9795	1.0082	.9709	.9335
14	.8775	.8962	.8775	.961	1.0082	.9522	.9149
15	.8589	.8215	.8962	.9795	1.0082	.9335	.9709
16	.8775	.8775	.8775	.9979	1.1203	.9335	.9149
17	.8775	.8029	.9335	1.0269	1.0642	.9522	.9709
18	.8775	.9335	.8775	1.0269	1.0456	.9896	.961
19	1.1576	1.2071	1.1763	1.2323	1.2637	1.2323	1.2012
20	1.2696	1.2637	1.2323	1.2382	1.2826	1.3256	1.3443
21	1.2936	1.3392	1.3817	1.3121	1.358	1.3443	1.4146
22	1.251	1.3392	1.3817	1.3491	1.3957	1.3443	1.475
23	1.2197	1.2637	1.3817	1.4003	1.4712	1.4377	1.4937
24	1.1949	1.2012	1.2449	1.3256	1.363	1.3769	1.363
Max	1.4377	1.4563	1.5089	1.4003	1.4712	1.4377	1.4937
Min	.8589	.8029	.8775	.961	1.0082	.9335	.9149
Avg	1.1095	1.0888	1.1326	1.1717	1.2129	1.1812	1.2067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 205 / 11 KV SUBSTATION

SHEDDABLE URBAN

TRANSFORMER S Feeder KV- 11 /
OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0747	.056	.0566	.056
2	.0566	.0566	.056	.056	.056	.0566	.056
3	.056	.0566	.0566	.056	.056	.056	.056
4	.0566	.0566	.0566	.056	.0566	.056	.056
5	.0566	.0566	.056	.056	.0566	.056	.056
6	.0566	.0566	.056	.056	.0566	.0566	.056
7	.0566	.0549	.0566	.056	.0566	.0566	.056
8	.0566	.0566	.0566	.0747	.0566	.0754	.0747
9	.0566	.056	.0377	.056	.0566	.0566	.056
10	.056	.056	.0566	.0747	.0566	.0566	.056
11	.0747	.056	.056	.0566	.0566	.056	.056
12	.0747	.056	.0373	.0566	.056	.0747	.0566
13	.0747	.056	.0747	.0566	.056	.0747	.0566
14	.0747	.056	.0747	.0566	.0747	.0747	.0566
15	.0747	.056	.0747	.0566	.056	.056	.0566
16	.0747	.056	.0747	.0566	.0566	.056	.0566
17	.0747	.056	.0747	.0566	.0373	.056	.0566
18	.0747	.056	.0747	.0566	.0373	.056	.0566
19	.0747		.0747	.056	.0566	.056	.0566
20	.0566	.0377	.0934	.0554	.0566	.056	.0566
21	.056	.0377	.0934	.0566	.0754	.0747	.0566
22	.0566	.0566	.056	.0566	.0754	.056	.0566
23	.0566	.0566	.056	.0566	.0566	.056	.056
24	.0549	.0566	.0377	.056	.0566	.0566	.056
Max	.0747	.0566	.0934	.0747	.0754	.0754	.0747
Min	.0549	.0377	.0373	.0554	.0373	.056	.056
Avg	.0632	.0546	.0624	.0586	.0572	.0601	.0571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 206 / 11 KV KUKSHET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1128	1.1203	1.0751	1.1203	1.1763	1.2826	1.1949
2	1.0642	1.0082	1.0374	1.0829	1.1576	1.2071	1.1389
3	.9979	1.0082	1.0082	1.0456	1.1016	1.1389	1.1203
4	1.0185	1.0642	1.0082	1.1016	1.0719	1.1203	1.0829
5	1.0829	1.0903	1.0374	1.1389	1.1317	1.1128	1.1389
6	1.1317	1.1576	1.1506	1.1763	1.1576	1.2637	1.251
7	1.1576	1.4003	1.2637	1.2323	1.1643	1.4146	1.5123
8	1.4377	1.4146	1.3957	1.3817	1.4003	1.5466	1.531
9	1.1763	1.2382	1.2826	1.2323	1.2883	1.3392	1.1949
10	1.0642	1.0456	1.0751	1.1389	1.094	1.1694	1.0642
11	.9335	.9774	.9335	1.1128	1.1506	1.0456	.9425
12	.9709	.9149	.8962	.9619	1.0642	1.0269	.9709
13	.8962	.9335	.8962	.9149	1.1016	.9896	1.0269
14	.9149	.8962	.8589	.9431	.9896	.9522	.961
15	.9335	.8402	.9149	.9335	.9896	.9522	.9619
16	.9335	.9335	.8775	.9149	.9522	1.0269	.9619
17	.9149	.8962	.8962	.9242	.9709	.9709	.9149
18	.9335	.9335	.9335	1.0456	.9709	.9522	1.0185
19	1.2883	1.3203	1.251	1.3443	1.358	1.307	1.3203
20	1.3256	1.4146	1.363	1.3817	1.4335	1.4377	1.5123
21	1.307	1.4146	1.3443	1.46	1.3957	1.4563	1.4377
22	1.3443	1.358	1.3256	1.4377	1.4335	1.4563	1.5089
23	1.2696	1.2637	1.307	1.3676	1.4335	1.4003	1.4045
24	1.2323	1.2136	1.2449	1.251	1.2826	1.358	1.3443
Max	1.4377	1.4146	1.3957	1.46	1.4335	1.5466	1.531
Min	.8962	.8402	.8589	.9149	.9522	.9522	.9149
Avg	1.1017	1.1191	1.0990	1.1518	1.1779	1.2053	1.1882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 207 / 11 KV AGRI KOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4481	.5093	.5415	.5415	.5601	.5601
2	.4668	.4251	.4715	.5228	.5228	.5228	.5041
3	.4527	.4251	.4481	.4854	.4854	.4668	.4854
4	.4481	.4294	.4481	.4668	.4481	.4481	.4668
5	.4481	.462	.4481	.5041	.4251	.4527	.5041
6	.4527	.5601	.5093	.5228	.462	.5281	.5415
7	.5041	.6468	.5658	.5415	.4668	.6036	.6535
8	.5975	.5975	.5847	.5601	.5041	.5658	.6535
9	.5415	.4668	.6036	.5228	.5975	.5658	.6161
10	.462	.4481	.5658	.5228	.5281	.5281	.4668
11	.4294	.4108	.4854	.4805	.5281	.4294	.4481
12	.4854	.3921	.4668	.4435	.5415		.4668
13	.3921	.4294	.3921	.4294	.4904	.3734	.4668
14	.3734	.3547	.3921	.415	.4854	.4481	.4108
15	.3921	.3547	.4294	.4527	.4854	.4108	.4294
16	.3921	.3734	.3734	.5415	.7282	.3921	.4294
17	.4481	.4108	.6348	.5975	.7095	.4294	.3734
18	.4715	.4294	.5975	.6161	.6535	.4481	.4668
19	.4715	.547	.6908	.6908	.6979	.5788	.5228
20	.5175	.547	.6348	.6535	.5658	.5788	.5601
21	.499	.4904	.6161	.6908	.6413	.5788	.5359
22	.5175	.5658	.5228	.5914	.5847	.5788	.5975
23	.499	.5281	.5788	.6468	.6224	.5975	.5975
24	.5228	.4904	.547	.5415	.6036	.5975	.5975
Max	.5975	.6468	.6908	.6908	.7282	.6036	.6535
Min	.3734	.3547	.3734	.415	.4251	.3734	.3734
Avg	.4696	.4680	.5215	.5409	.5550	.5080	.5148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284055 / 33/11 KV Sec 14,Nerul s/stn

Feeder No / Name : 401 / 33 KV SEC 30 NERUL S/STN SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1043		1.262	1.1831	1.2346	1.1831
2	1.1043	1.0517	1.1568	1.2883	1.1831		1.1317
3	1.1043	.9465		1.1568	1.1317		1.1317
4	1.0517	.8939	.8413	1.2323	1.0802	1.0802	1.1831
5	1.1568	.9991		1.1043			1.2346
6	1.2094	1.0517	1.0517	1.0517	1.1831	1.0802	
7	1.262	1.1568		1.1568	1.2346	1.0288	
8	1.262	1.4003	1.3146	1.0802		1.2346	1.4563
9	1.262	1.262	1.3146	1.1317			1.286
10	1.3146	1.3672	1.4198	1.2346	1.2346	1.286	1.2346
11	1.2757	1.262	1.4563	1.3889	1.286		1.4352
12	1.2757	1.262		1.3375	1.286	.1337	
13	1.2757			1.286	1.286	1.3375	1.3443
14		1.1043		1.2346	1.1831		1.2883
15		1.1568	1.1568	1.2346	1.1317	1.1831	
16	1.2094	1.2323		1.1831	1.1831	1.1831	
17	1.3146	1.2094	1.1043	1.1831	1.2346	1.2346	1.4563
18	1.3289	1.262	1.3146	1.3375		1.286	1.5123
19			1.5684	1.5432	1.5432	1.5432	1.6804
20		1.5249	1.4563	1.5432	.1492	1.5432	
21		1.5249	1.4723	1.4403	1.286	1.5432	1.6478
22	1.182	1.4723		1.4403	1.3889	1.4918	1.5043
23		1.3146	1.262	1.3375	1.286	1.4403	1.4506
24	1.1568	1.3672	1.1523	1.3443	1.286	1.3375	1.3375
Max	1.3289	1.5249	1.5684	1.5432	1.5432	1.5432	1.6804
Min	1.0517	.8939	.8413	1.0517	.1492	.1337	1.1317
Avg	1.2203	1.2239	1.2695	1.2722	1.1880	1.2334	1.3610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 201 / 11 KV SEC 24, SEC 30 STN SHEDDABLE URBAN
NERU Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	1.307		1.6057	1.3717	1.406	1.4403
2	1.419	1.2883	1.307	1.5497	1.3546		1.406
3	1.4003	1.2323		1.5497	1.3375		1.3889
4		1.1576	1.1949	1.5497	1.3203	1.3889	1.406
5	1.419	1.1949		1.4937			
6	1.5497	1.307	1.419	1.4563	1.3546	1.4575	1.5947
7	1.6991	1.475		1.6617	1.3889	1.5089	
8	1.8858	1.7924	1.7364	1.406	1.4575	1.6804	1.6975
9	1.4937	1.4563	1.6057	1.4232		1.4403	1.4403
10	1.3443		1.4937	1.3546	1.406	1.4918	1.1831
11	1.2696	1.2136		1.166	1.2689	1.1831	1.1949
12	1.1949	1.0829		1.1488	1.2346	1.0631	1.1389
13	1.1203			1.0802	.1372	.9945	1.1763
14	1.1763	1.1203	1.1949	1.0631	1.1488	.9945	1.1763
15	1.1203	1.0456	1.0642	1.0288	1.0974	1.0631	
16	1.0269	1.0082	1.1203	.9945	1.1488	1.0288	1.1576
17	1.1203	1.0829	1.0829	1.0288	1.166	1.046	1.1203
18	1.3256	1.0829	1.1203	1.0974		1.1145	1.2323
19		1.4563	1.3817	1.3375	1.3889	1.3032	1.3817
20	1.5497	1.5684	1.5123	1.4403	1.3889	1.4746	
21	1.5497	1.6057	1.5684	1.5089	1.5432	1.4746	1.643
22	1.5123	1.6057		1.5261	1.5775	1.5089	1.7177
23		1.6244	1.6244	1.5261	1.6118	1.4403	1.7364
24	1.4563	1.419		1.6057	1.4746	1.4575	1.643
Max	1.8858	1.7924	1.7364	1.6617	1.6118	1.6804	1.7364
Min	1.0269	1.0082	1.0642	.9945	.1372	.9945	1.1203
Avg	1.3852	1.3239	1.3617	1.3584	1.2942	1.3105	1.3938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 202 / 11 KV METRO,SEC 30 STN SHEDDABLE URBAN

NERUL Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1307			.12	.12	.12
2	.112	.1494	.112	.112	.12		.12
3	.112	.1494		.112	.1029		
4		.1307	.112	.112	.1029	.1029	.1029
5	.112	.1494		.112			.0857
6	.1307	.1307	.112	.1307	.1029	.1029	.1029
7	.1307	.1494		.1494	.12	.12	
8	.112	.1494	.1307	.1372	.12		.12
9	.1494	.1307	.1494	.1372		.12	.12
10	.1494	.112	.1307	.12	.12	.1372	.12
11	.1478	.112	.1307	.12	.12	.1029	.1294
12	.1307	.112		.1029	.12	.12	.112
13	.1307			.12	.12	.12	.112
14	.0747	.112	.112	.12	.12	.12	.112
15	.0934	.112	.0934	.12	.12	.12	
16		.112	.1307	.0857	.0857	.12	.112
17	.1307	.112	.112	.1029	.0857	.1029	.112
18	.1307		.112	.823		.0857	.1307
19			.1307	.12	.12	.1029	.1494
20	.1307	.1307	.1307	.1029	.0857	.12	
21	.1307	.1307	.1307	.1029	.12	.12	.1307
22	.1307	.1494		.12	.12	.12	.1494
23		.1307	.1307	.1543	.12	.12	.1494
24	.1307	.1307		.112	.12	.12	.1494
Max	.1494	.1494	.1494	.823	.12	.1372	.1494
Min	.0747	.112	.0934	.0857	.0857	.0857	.0857
Avg	.1250	.1298	.1225	.1491	.1127	.1149	.1220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 204 / 11 KV NERUL GYMKHANA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0747			.0514	.0686	.0686
2	.056	.056	.056	.056	.0514		.0686
3	.056	.056			.0514		.0686
4		.0747	.056	.056	.0514	.0514	.0514
5	.0747	.0747		.0747			.0514
6	.0747	.0747	.0747	.0747	.0686	.0305	.0343
7	.0747	.0747		.0934	.0686	.0686	
8	.0747	.0934	.0934	.0686	.0686	.0686	.0686
9	.0934	.0934	.0934	.0686		.0686	.0686
10	.0934	.0747		.0686	.0686	.0686	.0051
11	.056	.0934	.0747	.0686	.0686	.0514	.056
12	.0747	.056		.0686	.0686	.0686	.056
13	.056			.0686	.0686	.0686	.056
14		.056	.056	.0686	.0686	.0686	.056
15		.0373	.056	.0686	.0686	.0514	
16		.0373	.056	.0686	.0686	.0514	.056
17	.0554	.056	.056	.0686	.0686	.0343	.0373
18	.1494		.056	.0514		.0343	.0747
19			.0747	.0686	.0686	.0514	.0934
20	.112	.0934	.112	.0686	.0686	.0514	
21	.1307	.0934	.056	.0514	.0514	.0343	
22	.056	.0747		.0686	.0514	.0686	.0747
23		.0747	.056	.0343	.0514	.0686	.056
24	.056	.0747		.0514	.0343	.0686	.056
Max	.1494	.0934	.112	.0934	.0686	.0686	.0934
Min	.0554	.0373	.056	.0343	.0343	.0305	.0051
Avg	.0778	.0711	.0685	.0652	.0612	.0570	.0579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 205 / 11 KV SEC 14 S/S NERUL

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.0171
10	.0171	.0171		
11			.0171	
Max	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 206 / 11 KV SEC-50 NRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				6.4129
10	.0171	.0171		
11			.0171	
24				.0171
Max	.0171	.0171	.0171	6.4129
Min	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	3.215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284056 / 33/11 KV Nerul , Sector- 30,

Feeder No / Name : 208 / 11 KV HAWARE SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.2987		.3658		.3429	.3429
2	.3109	.2801	.2378	.3547	.2743		.3258
3	.2926	.2614		.3292	.2915		.3429
4		.3921	.2195	.3292	.2915	.9945	.3601
5	.3734	.2241		.3109			.3429
6	.3658	.2987	.2561	.2926	.2743	.3772	.3601
7	.4207	.3547		.4024	.3429	.3944	
8	.4207	.5041	.4207	.3429	.3601	.4287	.3944
9	.3841	.4481	.4755	.3601		.3944	.4115
10	.4207	.3881		.3258	.3944	.3086	.2915
11	.3547	.2957		.2915	.3601		.3174
12	.2987	.2587		.2915	.3429	.2743	.2614
13	.2614			.2572	.2915	.0257	.2427
14	.2614	.2195		.2401	.2743		.2241
15		.2378	.2195	.2229	.2572	.2229	
16	.2241	.2195		.2229	.2743	.2229	
17	.2427	.2195	.2561	.2572	.2572	.2401	.2614
18	.2241		.2561	.2572		.2401	.2801
19	.3361		.3361	.3258	.3086	.2915	.2987
20	.2987	.3475	.3292	.3086	.3601	.3086	
21	.3361	.3658	.3658	.3258	.2915	.3086	.3547
22	.3921	.3475		.2572	.2401	.3258	.3734
23		.3292	.3658	.3429	.3429	.3601	.3921
24	.3547	.2926	.2614	.2572	.2915	.3772	.3174
Max	.4207	.5041	.4755	.4024	.3944	.9945	.4115
Min	.2241	.2195	.2195	.2229	.2401	.0257	.2241
Avg	.3296	.3135	.3077	.3030	.3061	.3389	.3248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 201 / 11 KV RAGHULEELA NEW

SHEDDABLE URBAN

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3174		.3174			.2987
4		.2241		.2801			.2427
6		.2054		.2427			.2241
7		.1867		.2241			.2614
8		.2241		.2427			.2614
9	.3921	.3361	.3361	.3734	.3547		.3734
10	1.4377			.9709	1.4563		.4108
11		1.643	1.531	1.9605	2.0911	1.643	1.7737
12	2.1285	1.6804	2.0911	2.2218	2.3152	2.3525	2.0538
13			2.3152	2.1285	2.2779	2.3339	2.2965
14		2.2592	2.0538	2.1285	2.4331	2.3525	1.8858
15					2.4272		1.8671
16	1.9044	1.8671	1.9044	2.2218	2.2592	1.8671	1.2136
17	1.7737		1.8298			1.8111	1.8111
18	1.8484		1.9044	2.1658	2.4272	1.5497	1.8858
19	2.1472		2.2405	2.3899	2.3712	2.1098	
20	2.0538	2.2592	2.1472	2.3899	2.0911	1.8111	
21	1.6057		1.6057	2.1098		1.7364	
22	.5415	.9709	.6722	.8775		1.4003	1.1389
23	.4108	.7282	.4854	.7095	.7655	.4854	.9149
24	.6348	.2987		.3547	.3361		.3734
Max	2.1472	2.2592	2.3152	2.3899	2.4331	2.3525	2.2965
Min	.3921	.1867	.3361	.2241	.3361	.4854	.2241
Avg	1.4066	.9429	1.6244	1.2794	1.8158	1.7877	1.0715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 203 / 11 KV VASHI RLY 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.112		.1307			.1307
4		.0934		.1307			.1307
6		.0934		.112			.112
7		.112		.112			.112
8		.1307		.1494			.1494
9	.2801	.2801	.1867	.1494	.168		.2801
10				.1494	.1494		.2801
11		.2801		.168	.168	.2801	.2987
12		.3361		.168	.1494	.3174	.2987
13			.2427		.1494		
14			.2427	.1494	.1494		.2614
15					.168		.2801
16	.3174	.2614	.2241	.1494		.2987	.2801
17	.3174				.1494	.2614	.2801
18	.2987		.2801	.168		.2987	.2614
19	.2987		.2241	.2054	.1494	.2801	
20	.2241	.2054	.1867	.1867		.2054	
21	.168		.2054	.168	.1494	.2054	
22	.168	.1494	.1494	.168		.1494	.1867
23	.1494	.1307	.168	.1494	.168	.1494	.112
24	.1307	.112		.1494	.1494		.1494
Max	.3174	.3361	.2801	.2054	.168	.3174	.2987
Min	.1307	.0934	.1494	.112	.1494	.1494	.112
Avg	.2353	.1767	.2110	.1535	.1556	.2446	.2120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 204 / 11 KV MICROTECH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3361		.3547			.3547
4		.2987		.2801			.3174
6		.2614		.2427			.2987
7		.2614		.2241			.2801
8		.3547		.2427			.4294
9	.5975	.5415	.5415	.2614	.2241		.5601
10				.3734	.2987		.7655
11		1.0082		.5041	.3921	1.0642	1.0642
12		1.0456		.6348	.4854	1.1389	1.1576
13			1.1203		.5601		
14			1.0642	.6908	.5041		1.251
15							1.2323
16	.9896		1.0456	.6722	.4481	1.1949	1.1576
17	1.0456				.4481	1.0082	.9709
18	.9335		.7842	.5228		.9522	.9709
19	.9335		.8589	.6535	.5041	.9522	
20		.8402	.8029	.6161		.8775	
21	.6722		.7468	.6161	.5415	.7655	
22	.5601	.5975	.6908	.5601		.6535	.6722
23	.4854	.5041	.5975	.4854	.3921	.5041	.5228
24	.3921	.3734		.4108	.3734		.4108
Max	1.0456	1.0456	1.1203	.6908	.5601	1.1949	1.251
Min	.3921	.2614	.5415	.2241	.2241	.5041	.2801
Avg	.7344	.5352	.8253	.4637	.4310	.9111	.7304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 205 / 11 kv SUBSTATION

SHEDDABLE URBAN

TRANSFORMER Feeder KV- 11 /
OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0747		.0754			.0747
4		.0747		.0747			.0747
6		.0747		.0747			.0747
7		.056		.056			.056
8		.056		.056			.056
9	.0566	.056	.0566	.056	.0747		.056
10				.0754	.0566		.0754
11		.056		.0566	.0566	.0747	.0754
12		.056		.0754	.0566	.0754	.0747
13			.0566				
14			.0566	.056			.0754
15							.0566
16	.056		.0566	.0566			.056
17						.0754	.0566
18	.056		.0566	.0566		.0566	.0566
19	.056		.0566	.056		.056	
20	.056	.0566	.0566	.056		.0566	
21	.056		.056	.056		.0566	
22	.056	.0754	.056	.056		.0747	.0566
23	.056	.0754	.056	.056		.056	.056
24	.0747	.0754			.0747		
Max	.0747	.0754	.0566	.0754	.0747	.0754	.0754
Min	.056	.056	.056	.056	.0566	.056	.056
Avg	.0581	.0656	.0564	.0617	.0638	.0647	.0645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 206 / 11 KV MAITHILLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.4937		1.4937			1.5123
4		1.4563		1.4563			1.475
6		1.4377		1.475			1.475
7		1.4563		1.4937			1.531
8		1.5497		1.5123			1.531
9	1.9231	1.8671	1.8671	1.587	1.531		1.8298
10				1.6991	1.5684		2.0351
11		2.2405		1.9605	1.6057	2.3152	2.1845
12		2.2405		2.0165	1.7177	2.3525	
13			2.2032		1.6991		
14			2.2218	2.0165	1.6617		2.3899
15					1.6991		2.3712
16	2.3525		2.1098	2.0538	1.643		2.3525
17						2.3899	2.2965
18	2.2592		2.2032	1.9418	1.6804	2.1472	
19	1.9605		1.9605	1.8484		1.9044	
20	1.7737	1.7364	1.6991	1.8298		1.7551	
21	1.7364		1.7737	1.7177	1.6617	1.6804	
22	1.5684	1.5684	1.6244	1.6057		1.5684	1.587
23	1.5497	1.5089	1.5684	1.5497	1.5123	1.587	1.5123
24	1.531	1.5684		1.5497	1.5497		1.5684
Max	2.3525	2.2405	2.2218	2.0538	1.7177	2.3899	2.3899
Min	1.531	1.4377	1.5684	1.4563	1.5123	1.5684	1.475
Avg	1.8505	1.6770	1.9231	1.7115	1.6275	1.9667	1.8434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela
s/s

Feeder No / Name : 207 / 11 KV FISH MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.6348		.6161			.6535
4		.5975		.5601			.5975
6		.6722		.6161			.6722
7		.7468		.6535			.7282
8		.7468		.7095			.7282
9	.6722	.6535	.6908	.7095	.7095		.6908
10				.6348	.6161		.5788
11		.5601		.6161	.5788	.6348	.6348
12		.5601		.5975	.5975	.5975	
13					.6348		
14				.5415	.6722		.5601
15							.5975
16	.5601	.5788	.5788	.5601	.5975		.5601
17					.6348	.6161	
18	.6161		.5975	.5788	.5601	.5975	.5975
19	.7906		.6722	.7842		.7095	
20	.7842	.7842	.7468	.8029		.7842	
21	.7282		.7468	.7655	.5601	.8029	
22	.6908	.7095	.7095	.7282		.8029	.7655
23	.7095	.7282	.7095	.7468		.7655	.7655
24	.6535	.6722		.6535	.7282		.7282
Max	.7906	.7842	.7468	.8029	.7282	.8029	.7655
Min	.5601	.5601	.5788	.5415	.5601	.5975	.5601
Avg	.6895	.6650	.6815	.6597	.6263	.7012	.6572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 208 / 11 KV ORISSA BHAVAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1307		.1494			.1494
4		.112		.1307			.1307
6		.112		.112			.1307
7		.112		.112			.1494
8		.168		.1307			.168
9	.3174	.2614	.2801	.1867	.1494		.3921
10				.3174	.1494		.5975
11		.5601		.3361	.1494	.6161	.5788
12		.5228		.3734	.168	.8029	
13					.168		
14				.4668	.1494		.7282
15							.6535
16	.6348	.6348	.5041	.4294	.1494		.6535
17						.6535	
18	.4854		.5041	.2801		.5788	.6535
19	.4108		.3921	.2054		.4108	
20	.3174	.3174	.2614	.2054	.1307	.2801	
21	.2427		.2241	.1867		.2241	
22	.1867	.168	.1867	.1867		.2614	.2614
23	.1867	.168	.1867	.1494	.1494	.168	.2054
24	.168	.168		.1494	.1494		.168
Max	.6348	.6348	.5041	.4668	.168	.8029	.7282
Min	.168	.112	.1867	.112	.1307	.168	.1307
Avg	.3278	.2642	.3174	.2282	.1513	.4440	.3747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284057 / 33/11 KV Sec 30,Raghuleela

s/s

Feeder No / Name : 209 / 11 KV CIDCO BUSINESS

CENTER Feeder KV- 11 /
OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0747		.0747			.0747
4		.0747		.0747			.0373
6		.0747		.0747			.0373
7		.056		.056			.056
8		.0747		.056			.056
9	.0934	.112	.056	.056	.0934		.0373
10				.056	.0934		.056
11		.112		.056	.1307	.0934	.0934
12		.1307		.056	.1307	.0934	
13					.112		
14				.056	.168		.0747
15					.2614		.0934
16	.112	.168	.1307	.0747	.2614		.0934
17					.2241	.0747	
18	.0934		.2614	.0747		.0747	.112
19	.1867		.2241	.168		.112	
20		.2241	.2241	.168	.3174	.1307	
21	.1867		.2427	.168	.2241	.1307	
22	.112	.1494	.2054	.168	.2054	.112	.2427
23	.112	.1494	.1307	.112		.0934	.2054
24	.2054	.0747		.0747	.0747		.0747
Max	.2054	.2241	.2614	.168	.3174	.1307	.2427
Min	.0934	.056	.056	.056	.0747	.0747	.0373
Avg	.1377	.1135	.1844	.0902	.1767	.1017	.0896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 201 / 11 KV RELIANCE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				.4161			.4854
7	.583			.439	.4115		.6089
8	.6001			.4477	.463		.6089
9	.6447	.5611		.4706			.6268
10				.7545		.8871	.8417
11		.9511	.788	.823			.8238
12		1.0242	.7682	.823	.5975		.8326
13	.8326		.7783	.7545		.8688	
14	.724	.8131	.8962		.7095	.815	
15				.7202		.9593	
16	.8238		.8326	.7202	.6653		.905
17	.7701			.7202		.9671	
18	.724	.8131	.7964	.7545		.8326	.7265
19	.7796		.7973		.7023	.7796	.8238
20	.691		.6379	.6859		.7343	
21	.6024	.7095	.6379	.6859		.7164	.691
22					.6722	.6733	.6485
23			.5959	.6173		.6836	.6836
24	.583	.5028	.5959	.6173	.6173	.7762	.6762
Max	.8326	1.0242	.8962	.823	.7095	.9671	.905
Min	.583	.5028	.5959	.4161	.4115	.6733	.4854
Avg	.6965	.7678	.7386	.6531	.6048	.8078	.7131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 202 / 11 KV SAI PRIDE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				.7253			.8745
7	.9145			.724	.7621		1.0288
8	.8535	.743		.6716	.7468		.8253
9	.9511	.9831		.8802			.9282
10	.8951			.945		1.0974	
11		.9511	.8684	.8535			.8421
12		1.0059	.6874	.7926	.9877		.8421
13			.7202	.7621		.7042	
14	.6401	.7762	.7042		.9877	.6796	
15				.7316		.7095	
16	.6015		.6455	.7926	.9877	.6161	.6964
17	.7202			.823		.7907	
18	.8539	.9145	.8002	.884		.8162	.8162
19	.8145		.7922		1.0608	.8002	.7922
20	.7613		.823	.884		.9095	
21	.9145	1.0242	.8642	.884		1.012	.9877
22					1.134	1.0059	.9431
23			.8459	1.0364		1.0288	1.001
24	.884	.7716	.7682		1.0364	1.2437	1.0416
Max	.9511	1.0242	.8684	1.0364	1.134	1.2437	1.0416
Min	.6015	.743	.6455	.6716	.7468	.6161	.6964
Avg	.8170	.8962	.7745	.8260	.9629	.8780	.8938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada

s/stn

Feeder No / Name : 203 / 11 KV SEWERAGE TREATMENT

SHEDDABLE URBAN

PLANT Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.4338		.3961			.3395
7	.3429			.3241	.3429		.4904
8		.6036		.4435	.4287		.4435
9	.7316	.6653		.567			.8413
10	1.0608			.6859		.9145	
11		.7762	.7095	.6516			.8402
12		.7392	.7947	.6001	.4481		.9335
14	.9431	.8131	.8865		.3395		
15				.3429		.9242	
16	.6722		.8589	.583	.4108	.8589	.9522
17	.6413			.3772		.9335	
18	.6161	.6722	.6535	.3772		.7282	.7167
19	.4527		.5228		.4108	.7023	.4294
20	.6348			.4458		.5847	
21	.415	.5601	.5093	.3429		.3734	.4904
22					.3734	.4108	.4075
23			.4904	.3429		.3366	.4557
24	.4801		.4075		.3429	1.0374	.3475
Max	1.0608	.8131	.8865	.6859	.4481	1.0374	.9522
Min	.3429	.4338	.4075	.3241	.3395	.3366	.3395
Avg	.6355	.6579	.6481	.4629	.3871	.7095	.5914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 204 / 11 KV PAN INDIA VASHI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.2503		.3185			.2787
7	.3772			.3563	.3772		.3521
8	.4115	.3086		.3277	.3944		.3612
9	.5601	.5175		.4108			.5359
10				.5144		.8501	
11		.8871	.5967	.6173			.8215
12		.9145	.779	.5639	.4854		.7712
13	.7373		.7922			.823	
14	.8059	.9145	.7202		.5228	.8139	
15				.3429		.9619	
16	.8676		.7947	.583	.4854	.9522	1.0374
17	.9149			.583		.9335	
18	.7762	.8501	.7392	.5487		.9149	.8316
19	.5182		.5281		.4108	.3498	.5761
20	.4481		.5281	.4801		.6348	
21	.5093	.5975	.5093	.4115		.5729	.547
22					.415	.5658	.4904
23			.4024	.4115		.4024	.39
24	.4458		.4108		.4115	.415	.3384
Max	.9149	.9145	.7947	.6173	.5228	.9619	1.0374
Min	.3772	.2503	.4024	.3185	.3772	.3498	.2787
Avg	.6143	.6550	.6182	.4621	.4378	.7069	.5640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada
s/stnFeeder No / Name : 205 / 11 KV KESHAV KUNJ
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.7049		.7762			.695
7	.9602			.7461	.7545		.9496
8	.9259	.7621		.6706	.8402		.7773
9	.9602	.9088		.8916			.9259
10				1.1317		1.134	
11		1.2071	1.1488	1.2346			1.0974
12		1.0242	1.0974	1.1145	1.1706		1.166
13			1.1568			1.0852	
14		1.0608	.9945		1.134	.9448	
15				1.0974		.9614	
16	.9614		.9892	1.1317	1.2071		1.0442
17	.9945			1.0288		1.0117	
18	.9774	1.0242	.9221			.9259	.9774
19	.9724		1.0059		1.134	1.073	1.0774
20	.9724		.9556	1.0288		1.0277	
21	.9945	1.0608	.9892	1.0974		1.0442	1.0227
22					1.0974	1.0608	1.0753
23			.9804	1.1317		1.0437	1.2197
24	.9774	.7773	.8688	.9945	1.1317	1.2071	1.0364
Max	.9945	1.2071	1.1568	1.2346	1.2071	1.2071	1.2197
Min	.9259	.7049	.8688	.6706	.7545	.9259	.695
Avg	.9696	.9478	1.0099	1.0054	1.0587	1.0433	1.0049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20,Sanpada

s/stn

Feeder No / Name : 206 / 11 KV LADIES HOSTELL,SEC

SHEDDABLE URBAN

10,SA Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.6535		.9808			.6979
7	.7888			.7545	.7545		.7468
8	.823	.7922		.8402	.8402		.8488
9	.7842	.7282		.7282			.7655
10				.7545		.7095	
11		.7095	.7095	.7202			.8029
12		.7392	.7282	.7716	.6348		.6722
13			.6722			.7095	
14		.5601	.5788		.6348	.6348	
15				.583		.6348	
16	.6348		.5788	.6173	.5975	.6908	.6602
17	.6161			.6173		.7095	
18	.8029	.7762	.6722			.7282	.8589
19	.9335		.8029		.8871	.8402	1.0082
20	.9149		.8589	.8916		.8589	
21	.8686	.9145	.8775	.8916		.8215	.9979
22					.8871	.7922	.8215
23			.8215	.7888		.7655	.7842
24	.6173	.6348	.679	.7888	.7888	.7392	.6979
Max	.9335	.9145	.8775	.9808	.8871	.8589	1.0082
Min	.6161	.5601	.5788	.583	.5975	.6348	.6602
Avg	.7784	.7231	.7254	.7663	.7531	.7411	.7971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 207 / Sector 11 sanpada Bhoomi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.3481		.3077			.3361
7	.4458			.3258	.3086		.4525
8	.4458	.4973		.3944	.4458		.4557
9	.5792	.4887		.4344			.5249
10				.6516		.7762	
11		.7392	.7762				.7762
12		.7095	.6878	.6344	.4854		.7133
13			.6268			.6984	
14			.6154		.4854	.7421	
15						.695	
16	.6878		.6447	.5144	.4481	.7522	.6697
17	.7059			.5487		.6626	
18	.543	.6348	.5249			.6089	.5792
19	.5194		.5138		.4854	.543	.5731
20	.4075		.4835	.5487		.4961	
21	.4961	.5228	.4784	.4458		.4477	.5316
22					.4481	.4607	.463
23			.3647	.4801		.463	.5144
24	.4458	.4973	.4359	.5144	.4481	.5228	.4359
Max	.7059	.7392	.7762	.6516	.4854	.7762	.7762
Min	.4075	.3481	.3647	.3077	.3086	.4477	.3361
Avg	.5276	.5547	.5593	.4834	.4444	.6053	.5404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 284253 / 33/11 KV Sec 20, Sanpada

s/stn

Feeder No / Name : 209 / Cidco Exhibition

Centre, Vashi Feeder KV- 11 /
OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0747		.056			.0747
7	.0857			.056	.0686		.0747
8	.0686	.0747		.0934	.0857		.0747
9	.056	.0747		.0934			.0754
10				.0857		.0566	
11		.0566	.056				.0566
12		.0566	.056	.0857	.0566		.056
13			.056			.056	
14		.0566	.056		.0566	.056	
15						.056	
16	.056				.0566	.0566	.056
17	.056			.0857		.056	
18	.0754	.0566	.056			.056	.056
19	.0747		.056		.0754	.056	.0747
20	.0747		.056	.0686		.0747	
21	.0747	.0754	.0747	.0857		.0747	.0747
22					.0754	.0747	.0747
23			.0747	.0686		.0747	
24	.0686		.0747	.0857	.0566	.0754	.0747
Max	.0857	.0754	.0747	.0934	.0857	.0754	.0754
Min	.056	.0566	.056	.056	.0566	.056	.056
Avg	.0690	.0657	.0616	.0786	.0664	.0633	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 401 / 33 KV IC-1 SEC 6 SANPADA NON SHEDDABLE EXPRESS HV FEEDERS
SS Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 402 / 33KV INCOMER to NRI SS NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 403 / 33 KV IC-1 SEC 30

RAGHULEELA Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 404 / 33 KV IC-1 SEC 20 SANPADA NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 407 / 33 KV IC-1 SEC 14 NERUL NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0057
Max	.0057
Min	.0057
Avg	.0057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 408 / 33 KV IC-2 SEC 30 NON SHEDDABLE EXPRESS HV FEEDERS
RAGHULEELA Feeder KV- 33 / (NON-CONTINUOUS PROCESS)(NO
INCOMING STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0057
Max	.0057
Min	.0057
Avg	.0057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 409 / 33 KV INCOMER TO SEC-12 B NON SHEDDABLE EXPRESS HV FEEDERS
SS Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 410 / 33 KV IC-2 SEC 20 SANPADA NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 411 / 33KV INCOMER to Sec-19D NON SHEDDABLE EXPRESS HV FEEDERS
VASHI Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 413 / 33 KV IC-2 SEC 14 NERUL NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 414 / 33KV INCOMER to Sec-19D NON SHEDDABLE EXPRESS HV FEEDERS
Vashi Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 415 / 33 KV IC VASHI RLY S/STN

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	28-FEB-17
HR	Load (MW)
24	.0112
Max	.0112
Min	.0112
Avg	.0112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 416 / 33 KV IC-2 SEC 6 SANPADA NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

NERUL O&M DIVISION[405]

PALM BEACH S/DN.[752] BU 4752

Substation No/ Name :- 288065 / 220/33KV Sonkhar S/Stn

Feeder No / Name : 417 / 33 KV IC SEC 30 NERUL STN NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	.0056
Max	.0056
Min	.0056
Avg	.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 203 / 11 KV V M JOG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	24-FEB-17
HR	Load (MW)
1	1.6911
2	1.5562
3	1.4822
4	1.4556
5	1.4708
6	1.5646
7	1.7497
8	1.9265
9	1.9334
10	1.8275
11	1.6118
12	1.435
13	1.3778
14	1.3298
15	1.2399
16	1.2186
17	1.2894
18	1.2872
19	1.563
20	1.8145
21	1.8259
22	1.864
23	1.9296
24	1.9044
Max	1.9334
Min	1.2186
Avg	1.5979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223007 / 22/11 KV KALAMBOLI HOUSING

S/S

Feeder No / Name : 204 / 11 KV Herambha

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	24-FEB-17
HR	Load (MW)
1	1.7711
2	1.6613
3	1.592
4	1.5501
5	1.6065
6	1.6674
7	1.6705
8	1.8503
9	1.9174
10	1.6712
11	1.6156
12	1.5485
13	1.5394
14	1.3733
15	1.4716
16	1.4937
17	1.435
18	1.4754
19	1.8557
20	2.018
21	1.9776
22	1.9418
23	1.9791
24	1.9235
Max	2.018
Min	1.3733
Avg	1.6919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 223032 / 22/11 KV Kalmboli Steel

Market

Feeder No / Name : 201 / 11 KV STEEL CHAMBER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1387	.2661	.2621	.2686	.2618	.2523	.1262
2	.2742	.27	.2679	.2679	.2626	.2545	.1297
3	.2734	.2656	.2736	.2686	.2588	.2527	.1262
4	.2676	.2608	.2762	.267	.2576	.2538	.1227
5	.2687	.248	.2641	.2632	.253	.2481	.1157
6	.2451	.1387	.2555	.2482	.2576	.2451	.1122
7	.2282	.2277	.229	.2517	.2199	.2285	.1052
8	.2611	.2267	.2336	.2284	.1132	.2387	.1017
9	.3883	.3681	.269	.1776	.2615	.213	.128
10	.5871	.6234	.4656	.5316	.2995	.631	.2542
11	.798	.7343	.6665	.7331	.347	.8457	.3891
12	.7977	.7791	.6949	.788	.3772	.9346	.3926
13	.8786	.7716	.6792	.7914	.3748	.9878	.3996
14	.7486	.8386	.6144	.7556	.1787	.894	.4242
15	.7659	.7819	.3185	.7575	.3216	.8637	.3961
16	.8687	.7831	.7311	.7636	.1699	.8873	.3926
17	.8681	.815	.6019	.7632	.3057	.8302	.3891
18	.4199	.7407	.496	.7076	.3007	.7885	.3541
19	.6865	.6379	.4792	.6077	.3159	.6779	
20	.4924	.479	.4057	.4497	.3202	.5027	
21	.4128	.3746	.3614	.3708	.1597	.3873	.1718
22	.3058	.3555	.3085	.3216	.149	.3238	.163
23	.1467	.2934	.2683	.2942	.2678	.3041	.1262
24	.265	.2814	.2683	.2604	.2602	.2612	.1244
Max	.8786	.8386	.7311	.7914	.3772	.9878	.4242
Min	.1387	.1387	.229	.1776	.1132	.213	.1017
Avg	.4745	.4817	.4038	.4641	.2622	.5128	.2293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 201 / 11 KV C.E. FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.7737			1.9605	
2	1.6766		1.6804			1.8671	
3	1.6766		1.587			1.7002	
4	1.6766		1.587			1.6804	
5	1.6766		1.7737			1.9605	
6	1.829	1.8176	1.9044	1.7147		2.0538	
7	2.2862		2.0911			2.2779	
8	2.2862	2.1262	2.1658	1.8519		2.1472	
9	2.4387				1.9993	1.9605	
10	1.9814	1.6804			2.0538		1.7737
11	1.9814			1.7551	2.0538		1.8298
12	3.1169	1.531	1.5089	1.7177	1.8671	1.7177	
13	1.5242	1.4937		1.5684	1.7177	1.5684	1.587
14	1.5242	1.4937		1.531	1.7924	1.531	1.6804
15	1.5242	1.4003	1.4403	1.6057	1.7177	1.7177	1.6804
16	2.8617	1.4632	1.4403	1.6804	1.7177	1.8298	1.7177
17	1.6766	1.4937		1.7177	1.7177	1.6804	1.6804
18	1.6766	1.6804		1.8671	1.7737	1.8671	1.8671
19	1.9814	2.2032		2.2032	2.2405	1.9418	2.2779
20	2.2862	2.2779	1.9204	2.3152	2.2779	2.1658	2.2779
21	2.2862	2.3152		2.2405	2.3339	2.4272	2.3339
22	2.2862	2.1285	2.0576	2.2405	2.3339	2.4272	2.3339
23	2.2862	2.0538		2.2257	2.2779	2.5393	2.3339
24	2.1338	1.7833	1.9044	1.8519	2.1879	2.1253	2.1285
Max	3.1169	2.3152	2.1658	2.3152	2.3339	2.5393	2.3339
Min	1.5242	1.4003	1.4403	1.531	1.7177	1.531	1.587
Avg	2.0293	1.8089	1.7739	1.8804	2.0039	1.9612	1.9645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 202 / 11 KV N.T.F.C. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2241			.2241	
2			.2241			.2241	
3			.2241			.2241	
4			.1867			.2241	
5			.1867			.2241	
6		.1715	.1867	.1715		.2241	
7			.2241			.2241	
8		.2401	.2241	.2058		.2614	
9					.2263	.2614	
10		.2614			.2241		.2987
11		.2614			.2241		.2987
12	.2401	.2614	.2401	.2263	.2241	.3429	
13				.2286	.2195	.3018	.2987
14		.2987		.2286	.2241	.3048	.2987
15			.2401	.2286	.2241	.3429	
16	.2401	.2614	.2401	.2286	.2241	.3429	.2614
17		.2614		.2286	.2241	.3429	.2614
18		.2241		.2286		.2667	.2241
19		.2241		.2263	.2241	.2286	.2241
20		.2241	.2401	.2263	.2241	.1905	.0934
21		.2241		.2263	.2218	.1905	.0934
22		.2241	.1715	.2263	.2241	.1905	.0934
23		.2241		.2263	.2241	.1905	.0934
24		.1715	.2241	.1715	.2286	.2241	.2241
Max	.2401	.2987	.2401	.2286	.2286	.3429	.2987
Min	.2401	.1715	.1715	.1715	.2195	.1905	.0934
Avg	.2401	.2356	.2169	.2185	.2241	.2523	.2126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 203 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0187			.0187	
2			.0187			.0187	
3			.0187			.0189	
4			.0187			.0187	
5			.0187			.0187	
6		.0171	.0187	.0171		.0187	
7			.0187			.0187	
8		.0171	.0187	.0171		.0187	
9					.0191	.0187	
10		.0187			.0187		.0187
11					.0187		.0187
12	.0171	.0187	.0171	.0189	.0187	.0191	
13				.0191	.0187	.0191	.0187
14		.0187		.0191	.0187	.0191	.0187
15			.0171	.0191	.0187	.0191	
16	.0171	.0187	.0171	.0191	.0187	.0191	.0187
17		.0187		.0191	.0187	.0191	.0187
18		.0187		.0191		.0191	.0187
19		.0187		.0191	.0187	.0191	.0187
20		.0187	.0171	.0191	.0187	.0191	.0187
21		.0187		.0191	.0187	.0191	.0187
22		.0187	.0171	.0191	.0187	.0191	.0187
23		.0187		.0191	.0187	.0191	.0187
24		.0171	.0187	.0171	.0191	.0187	.0191
Max	.0171	.0187	.0187	.0191	.0191	.0191	.0191
Min	.0171	.0171	.0171	.0171	.0187	.0187	.0187
Avg	.0171	.0184	.0181	.0187	.0188	.0189	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 204 / 11 KV MHATMA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.9605			2.1253	
2			1.7737			1.9605	
3			1.587			1.8671	
4			1.587			1.7556	
5			1.7737			1.7737	
6		1.9204	1.8671	1.7147		2.1472	
7			2.0538			2.4025	
8		1.989	2.2405	1.8519		2.3339	
9					2.1658	2.3339	
10		2.0538			2.2624		1.8671
11					2.2405		1.9605
12	1.5775	1.8671	1.5775	1.9418	2.0911	1.8671	
13				1.8671	1.9605	1.8484	1.8671
14		1.5684		1.8671	1.9605	1.8298	1.6632
15		1.587	1.5089	1.829	1.848	1.7551	
16	1.4403	1.4937	1.5089	1.7177	1.8671	1.6975	1.587
17		1.587		1.7177	1.8671	1.643	1.7737
18		1.8671		2.4025	1.8671	2.2257	1.8671
19		2.5206		2.4764	2.5206	2.3152	2.4025
20		2.6139	2.0576	2.5133	2.6139	2.4897	2.5873
21		2.5206		2.4025	2.5206	2.4272	2.6139
22		2.3339	2.1948	2.3655	2.5206	2.4272	2.6139
23		2.3339		2.3765	2.4949	2.4646	2.4949
24		1.989	2.2405	2.0576	2.3624	2.3101	2.3152
Max	1.5775	2.6139	2.2405	2.5133	2.6139	2.4897	2.6139
Min	1.4403	1.4937	1.5089	1.7147	1.848	1.643	1.587
Avg	1.5089	2.0164	1.8523	2.0734	2.1977	2.0909	2.1241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 205 / 11Kv Pump P2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.9605			2.1807	
2			1.7737			1.9605	
3			1.7737			1.8671	
4			1.6804			1.7924	
5			1.7737			1.7556	
6		2.0576	1.8671	1.8519		2.1472	
7			2.1472			2.3339	
8		2.2634	2.2405	2.1262		2.4434	
9					2.2405	2.4272	
10		2.2405			2.3339		2.2405
11					2.2405		2.0538
12	1.8519	2.1472	1.7147	2.1437	2.0271	2.0911	
13		1.9605		1.829	2.1472	2.1285	1.9791
14		1.8671		1.7924	2.0538	1.8671	1.9605
15		1.587	1.5089	1.7924	1.9605	1.8484	1.848
16	1.5089	1.4937	1.5089	1.7558	1.8671	1.6804	1.8671
17		1.8671		1.7558	1.8671	1.643	1.7737
18		1.9605		1.829	1.9404	2.3152	1.848
19		2.4272		2.268	2.5206	2.4272	2.4272
20		2.6139	2.0576	2.4143	2.5206	2.5393	2.5206
21		2.5206		2.4143	2.5206	2.4272	2.5206
22			2.1948	2.4143	2.5206	2.5019	2.5206
23		2.4272		2.4143	2.6139	2.6139	2.5206
24		1.9204	2.2405	1.9204	2.3388	2.3712	2.3152
Max	1.8519	2.6139	2.2405	2.4143	2.6139	2.6139	2.5206
Min	1.5089	1.4937	1.5089	1.7558	1.8671	1.643	1.7737
Avg	1.6804	2.0903	1.8887	2.0481	2.2321	2.1528	2.1711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 206 / HORIZON SCHOOL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0183			.0183	
2			.0187			.0183	
3			.0183			.0181	
4			.0183			.0183	
5			.0183			.0183	
6		.0343	.0183	.0171		.0183	
7			.0187			.0183	
8		.0343	.0187	.0171		.0183	
10		.0366			.0183		.0366
11					.0187		.0366
12	.0343	.0373	.0171		.0171	.037	
13					.0183	.0381	.0366
14		.0366			.0183	.0381	.0373
15		.0373	.0171		.0183	.0381	
16	.0343	.0366	.0171		.0187	.0381	.0366
17		.0366			.0183	.0381	.0366
18		.0366			.0183	.0381	.0373
19		.0366			.0187	.0381	.0187
20		.0183	.0171		.0183	.0381	.0183
21		.0183			.0187	.0381	.0183
22		.0183	.0171		.0183	.0381	.0187
23		.0183			.0183	.0381	.0183
24		.0343	.0183	.0171		.0183	
Max	.0343	.0373	.0187	.0171	.0187	.0381	.0373
Min	.0343	.0183	.0171	.0171	.0171	.0181	.0183
Avg	.0343	.0314	.0180	.0171	.0183	.0296	.0292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 207 / 11 kv khandeshwar railway NON SHEDDABLE EHV INDUSTRIAL FEEDERS
 stn Feeder KV- 11 / OUTGOING (NON CONTINOUS PROCESS)(NO
 STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0305			.0305	
2			.0305			.0305	
3			.0305			.0305	
4			.0305			.0305	
5			.0305			.0305	
6		.0305	.0305	.0305		.0305	
7			.0305			.0191	
8		.0305	.0076	.0305		.0191	
9					.0088	.0076	
10		.0076			.0076		.0076
11					.0076		.0076
12	.0305	.0076	.0305	.0206	.0076		
13				.0191	.0076	.0343	.0076
14				.0213	.0076	.0343	.0076
15		.0373	.0305	.0248	.0076	.0343	
16	.0762	.0373	.0305	.0225	.0076	.0343	.0076
17		.0076		.0217	.0076	.0343	.0076
18		.0191		.0351		.0343	.0191
19		.0305		.0351	.0305	.0343	.0305
20		.0305	.0305	.0351	.0305	.0343	.0305
21		.0305		.0351	.0305	.0343	.0305
22		.0305	.061	.0351	.0305	.0343	.0305
23		.0305		.0351	.0305	.0343	.0343
24		.061	.0305	.061	.0366	.0305	.0305
Max	.0762	.061	.061	.061	.0366	.0343	.0343
Min	.0305	.0076	.0076	.0191	.0076	.0076	.0076
Avg	.0534	.0279	.0310	.0308	.0172	.0303	.0193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224005 / 33/11 KV PANVEL(W),SECT-14

Feeder No / Name : 208 / MGM (EXPRESS)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4481			.4294	
2			.4294			.4294	
3			.4294			.4108	
4			.4108			.4294	
5			.4481			.4668	
6		.4338	.4668	.4938		.5228	
7			.5788			.5975	
8		.5178	.6161	.5316		.6161	
9					.3867	.8962	
10		.8871			.5228		1.0082
11					.5601		1.0456
12	.9156	1.1016	.7425	.862	.5041	1.0732	
13				.8412	.4854	1.0298	1.0642
14		1.1016		.8148	.4854	.9978	1.1016
15		1.0456	.6944	.7658	.4668	.5923	
16	.7922	.8962	.703	.6639	.4481	.928	.9149
17		.8029		.6111	.4108	.8525	.7842
18		.6535		.63	.4294	.6526	.6161
19		.5788		.5923	.4108	.5828	.5975
20		.5601	.4973	.5753	.4481	.5262	.5788
21		.5415		.5658	.4294	.464	.5228
22		.4854	.4664	.4791	.4805	.4885	.4805
23		.5041		.4621	.4481	.5074	.5041
24		.415	.4668	.4115	.4621	.4481	.4481
Max	.9156	1.1016	.7425	.862	.5601	1.0732	1.1016
Min	.7922	.415	.4108	.4115	.3867	.4108	.4481
Avg	.8539	.7017	.5284	.6200	.4612	.6337	.7436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 201 / 11 KV STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0514			.0566	.0514	
2	.0566				.0566		
3	.0566				.0566	.0514	
4	.0566				.0566		
5	.0566				.0566	.0686	
6	.0566			.0514	.0566	.0514	
7	.0377			.0051	.0566		
8	.0566	.0514			.0377	.0514	.0514
9	.0514			.0566			.0543
10				.0566			.0543
11			.0543	.0566			.0543
12			.0543	.0566	.0514		.0543
13			.0543	.0754	.0514		.0543
14			.0543	.0566	.0514		.0543
15			.0543	.0566			.0543
16	.0566	.0514	.0543	.0566	.0514	.0514	
17				.0754	.0514		
18				.0754			
19				.0754			
20				.0566	.0514		
21		.0514					.0514
22			.0514	.0566			
23			.0514	.0566	.0514		.0514
24	.0566	.0514	.0514	.0514	.0686		
Max	.0566	.0514	.0543	.0754	.0686	.0686	.0543
Min	.0377	.0514	.0514	.0051	.0377	.0514	.0514
Avg	.0544	.0514	.0533	.0574	.0539	.0543	.0534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 203 / 11 KV JUI GAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4143	1.7661	2.0576	2.4006	2.6029	2.1948	2.4006
2	2.3765	1.7318	1.8861	2.2291	2.4897	2.1091	2.2291
3	2.3011	1.6289	1.7147	2.1434	2.3577	1.9033	2.0576
4	2.2634	1.7147	1.5432	2.0576	2.1879	1.8519	2.2291
5	2.2445	2.0062		2.0062	1.9616	1.869	2.4006
6	2.3388	2.0576		1.989	1.9805	2.0919	2.572
7	2.6406	2.1434		2.2462	2.0936	2.3148	2.6406
8	2.7161	2.1434		2.5892	2.5274	2.5377	2.9664
9	2.7263	2.2291		2.7161	2.332	2.4006	3.0769
10	2.7263			2.584	2.2977		2.371
11	2.8635	2.3663	2.5701	2.6595	2.3834		2.3529
12	2.572	2.0233	2.2081	2.5086	2.4006		2.2805
13	2.4177	1.9719	2.0271	2.3954	2.3834		2.1719
14	2.5206	1.8861	1.8461	2.0559	2.3491		2.0452
15	2.0405	1.7318	1.9909	2.4331	2.3834		1.9909
16	1.9204	1.9033	2.0271	2.1125	2.4177	2.0576	1.9004
17		2.0576	1.9204	2.0559	2.4006		1.8861
18		2.2291	2.0405	2.1691	2.452	2.2291	2.1434
19		2.4006	2.5377	3.1687	2.7263		2.2291
20		2.5892	2.5377	2.9235	2.692		2.7092
21		2.7092	2.5377	3.0178	2.7606		
22			2.452	3.0744	2.8464		3.0178
23			2.5034	2.9424	2.6779		2.5377
24	2.584	1.8861	2.2291	2.4006	2.3491		2.572
Max	2.8635	2.7092	2.5701	3.1687	2.8464	2.5377	3.0769
Min	1.9204	1.6289	1.5432	1.989	1.9616	1.8519	1.8861
Avg	2.4510	2.0560	2.1461	2.4533	2.4189	2.1418	2.3818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 204 / 11 KV SURAJ PARK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7349	2.2634		2.572	2.9424	2.8292	3.1379
2	2.6783	2.2291		2.5377	2.7915	2.7092	3.0521
3	2.6406	2.0405		2.5034	2.6217	2.572	2.915
4	2.584	2.0748		2.452	2.5463	2.4006	2.7435
5	2.5274	2.2977		2.4006	2.452	2.332	2.915
6	2.6783	2.452		2.4177	2.4897	2.6749	3.2236
7	3.1499	2.572		2.9492	2.6972	3.1379	3.3436
8	3.8477	2.6578		3.4294	3.4517	3.4637	
9	3.3436	2.7435		3.3573	3.0864	2.452	2.9502
10	3.2922	2.7606		3.1876	3.0521		2.9502
11	3.155	2.6406	2.7149	3.0556	2.9321		2.7692
12	2.915	2.5206	2.5701	2.9613	2.9321		
13	2.692	2.4006	2.4615	2.7161	2.6406		
14	2.6235	2.3148	2.3348	2.584	2.6063		
15	2.4863	2.2291	2.3167	2.5086	2.5377		3.2217
16	2.3491	2.1776	2.3167	2.6406	2.572	2.452	3.0407
17		2.572	2.2291	2.6595	2.572		2.7778
18			2.3148	2.7538	2.7949	2.572	2.6406
19		2.915	2.7263	3.2442	3.035		2.915
20		3.1893	2.8807	3.5271	3.2236		3.0864
21		3.1207	3.0521	3.4894	3.1893		3.3608
22			3.0178	3.4705	3.155		3.2065
23			2.8635	3.3573	3.0007		3.155
24	2.8858	2.4177		2.7435	2.915		3.2236
Max	3.8477	3.1893	3.0521	3.5271	3.4517	3.4637	3.3608
Min	2.3491	2.0405	2.2291	2.4006	2.452	2.332	2.6406
Avg	2.8579	2.5043	2.5999	2.8966	2.8432	2.6905	3.0314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 205 / 11 KV AWAS FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7915	2.3663		2.7435	3.0556	2.7435	3.4294
2	2.7349	2.0576		2.572	2.8292	2.6063	3.3608
3	2.6972	2.1091		2.572	2.7538	2.452	3.2579
4	2.6406	2.0233		2.4006	2.6029	2.3663	3.0864
5	2.6406	2.1605		2.4006	2.5274	2.2977	2.915
6	2.7161	2.4006		2.4006	2.5652	2.6435	2.7435
7	3.1876	2.452		2.8807	2.6972	2.915	3.155
8	3.3951	2.5034		2.9321	3.1499	3.0864	3.2065
9	2.9835			3.1876	2.7435	2.915	3.1855
10	3.155			2.9424	2.8978		2.7511
11	3.0178		2.6968	3.0178	2.8978		2.6425
12	2.7435		2.5701	2.8858	2.8464		2.5339
13	2.7778		2.5158	2.6029	2.7435		2.4253
14	2.7092		2.2986	2.6029	2.7092		2.371
15	2.4863		2.4615	2.6217	2.7949		
16	2.2977		2.4615	2.5652	2.7263	2.572	
17		2.4006	2.3491	2.7915	2.7606		2.2291
18		3.0864	2.4348	2.8669	3.2407	2.7435	3.275
19		3.2579	3.3093	3.6403	3.4979		3.6008
20			3.2407	3.9798	3.5665		3.618
21		3.3951	3.2922	3.9043	3.4808		3.6694
22			3.155	3.7346	3.2236		3.4294
23			2.9835	3.5082	3.1893		3.3265
24	2.9424	2.4177		2.915	2.915		3.5322
Max	3.3951	3.3951	3.3093	3.9798	3.5665	3.0864	3.6694
Min	2.2977	2.0233	2.2986	2.4006	2.5274	2.2977	2.2291
Avg	2.8186	2.5100	2.7515	2.9445	2.9340	2.6674	3.0793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 206 / 11 KV KAMOTHE VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1313	1.7661		2.0576	2.3011	2.1434	2.6235
2	2.0748	1.6804		1.9719	2.1879	2.0233	2.6235
3	2.0182	1.6289		1.8861	2.0936	1.8861	2.572
4	1.9805	1.6289		1.7147	1.9993	1.869	2.4006
5	1.9993	1.7318		1.8004	1.8861	1.8176	2.3148
6	2.0936	1.8861		1.8519	1.9616	2.0233	2.2291
7	2.3388	1.869		1.9376	1.9616	2.1091	2.1434
8	2.452	1.8176		2.1776	2.32	2.2977	2.2634
9	2.2977	1.7661		2.3388	2.0576	2.2291	2.1719
10	2.1948	1.7318		2.1502	1.989		1.9728
11	2.0405	1.5604	1.9909	1.9993	1.989		1.8099
12	1.9547	1.5432	1.8461	1.905	1.9033		1.6476
13	1.8519	1.5089	1.6832	1.773	1.869		1.6289
14	1.8347		1.6289	1.7353	1.8004		1.5565
15	1.749	1.4575	1.6651	1.6975	1.7318		1.5746
16	1.406	1.4918	1.6651	1.773	1.7147	1.6804	1.6289
17		1.5432	1.5775	1.8296	1.749		1.5775
18		1.7147	1.6632	1.9616	1.8861	1.8861	2.0233
19		2.0576	2.2291	2.584	2.4177		2.1434
20		2.6063	2.3148	2.7915	2.5377		2.4006
21		2.4177	2.4177	2.7915	2.5206		2.5549
22			2.4006	2.8104	2.4863		2.5206
23			2.3491	2.7161	2.4006		2.4863
24	2.2445	1.9033		2.2291	2.2805		2.7092
Max	2.452	2.6063	2.4177	2.8104	2.5377	2.2977	2.7092
Min	1.406	1.4575	1.5775	1.6975	1.7147	1.6804	1.5565
Avg	2.0390	1.7767	1.9563	2.1035	2.0852	1.9968	2.1491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 208 / 11 KV O/G SPARE-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0514			.0754	.0514	
2	.0754				.0754		
3	.0754				.0754	.0514	
4	.0754				.0754		
5	.0754				.0754	.0514	
6	.0754			.0514	.0754	.0514	
7	.0754				.0754		
8	.0754	.0514		.0514	.0754	.0514	
9	.12	.0514		.0754			.0543
10	.12	.1372		.1509			.0543
11	.12	.1372	.1448	.1509			.1448
12	.12	.1372	.1448	.1509	.1372		.1448
13	.12	.1372	.1448	.0754			.1448
14	.12	.1372	.1448	.132	.1372		.1448
15	.12	.1543	.1448	.132	.1372		.1448
16	.12	.1372	.1448	.1509	.1372	.1372	.1433
17		.1372		.132	.1372		.1372
18		.1372		.1509	.1372		.1372
19		.1372		.1509	.1372		.1372
20		.1372		.1509	.1372		.1372
21		.1372		.1698	.1372		.1372
22			.1372	.1698	.0686		.1372
23			.0514	.0566	.0686		.1372
24	.0754	.0514	.0514	.0514	.0514		
Max	.12	.1543	.1448	.1698	.1372	.1372	.1448
Min	.0754	.0514	.0514	.0514	.0514	.0514	.0543
Avg	.0964	.1168	.1232	.1196	.1013	.0657	.1291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 302 / 22 KV Venkatesh Feeder

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4335	1.0974		1.3717	1.5089	1.3717	1.4403
2	1.4335	1.0974		1.3032	1.3957	1.3032	1.3717
3	1.358	1.0974		1.2689	1.3203	1.2346	1.3032
4	1.2826	1.0974		1.2346	1.2449	1.166	1.2346
5	1.3203	1.1317		1.2346	1.2071	1.166	1.3032
6	1.358	1.2003		1.2346	1.2449	1.3032	1.3375
7	1.5089	1.2689		1.4403	1.3203	1.3375	1.3375
8	1.773	1.2689		1.4746	1.6221	1.6461	1.6461
9	1.5775	1.3032		1.6221	1.4403	1.3375	1.5565
10	1.5432	1.3375		1.4712	1.406		1.3394
11	1.406	1.3375	1.448	1.5466	1.3717		1.4118
12	1.5089	1.1317	1.3032	1.3957	1.2003		
13	1.3778	1.1317	1.2308	1.3957	1.3375		
14	1.3375	1.1317	1.1946	1.3957	1.3375		1.4118
15	1.3032	1.166	1.1946	1.3957	1.3032		1.3394
16	1.166	1.0631	1.1946	1.3957	1.2689	1.2689	1.3032
17	1.166	1.0631	1.0974	1.3203	1.3032		1.2346
18		1.1317	1.2346	1.3203	1.3717	1.3717	1.2346
19		1.2346	1.4403	1.6221	1.4746		1.3717
20		1.3717	1.4403	1.7353	1.5432		1.4746
21		1.5089	1.4403	1.7353	1.5432		1.5432
22			1.5089	1.6975	1.5432		1.6118
23			1.4403	1.6975	1.5775		1.6118
24	1.5089	1.2689		1.406	1.5089		1.6118
Max	1.773	1.5089	1.5089	1.7353	1.6221	1.6461	1.6461
Min	1.166	1.0631	1.0974	1.2346	1.2003	1.166	1.2346
Avg	1.4090	1.2019	1.3206	1.4465	1.3915	1.3188	1.4105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KALAOMBOLI SUB DIVN[569] BU 0345

Substation No/ Name :- 224011 / 33/22/11 KV KAMOTHE

Feeder No / Name : 303 / 22 KV JAWAHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712	1.5432		1.4746	1.8484	1.5432	1.5775
2	1.4335	1.5089		1.4403	1.8107	1.5089	1.3717
3	1.358	1.4403		1.406	1.7353	1.5432	1.3032
4	1.3957	1.5775		1.4746	1.6598	1.4403	1.166
5	1.4335	1.5775		1.5089	1.6598	1.5089	1.3032
6	1.5466	1.6118		1.5432	1.7353	1.5089	1.3717
7	1.5844	1.7147		1.5432	1.773	1.5775	1.406
8	1.8107	2.0576		1.749	1.9993	1.7833	1.3717
9	1.9547	2.2291		2.7161	2.0576	2.0576	1.5565
10	2.5034	2.4691		2.9801	2.4006		1.7013
11	2.4006	2.8807	3.1493	2.9801	2.7435		1.5203
12	2.7435	2.8807	3.0769	3.6214	2.7435		2.0271
13	2.4006	2.8807	3.0769	3.0178	2.2977		1.9547
14	2.6063	2.8121	3.0769	2.9047	2.2977		1.9185
15	2.6063	2.8464	3.1131	3.3196	2.3663		1.8823
16	2.7435	3.155	3.0769	3.6591	2.332	2.8121	1.8461
17		3.155	2.8807	2.9424	2.332		1.7833
18		2.7435	2.6063	3.0178	2.2977	2.6063	1.5432
19		2.4006	1.8861	2.7538	2.0919		1.4746
20		2.0576	1.8861	2.3011	1.8861		1.4403
21		1.9204	1.8176	2.1879	1.8176		1.4403
22			1.7833	2.1125	1.7833		1.3717
23			1.7147	2.0748	1.7147		1.406
24	1.5466	1.5089		1.5432	1.6804		1.6461
Max	2.7435	3.155	3.1493	3.6591	2.7435	2.8121	2.0271
Min	1.358	1.4403	1.7147	1.406	1.6598	1.4403	1.166
Avg	1.9729	2.2260	2.5496	2.3447	2.0443	1.8082	1.5576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 202 / 11 KV HILL REGENCY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
8	1.6632		
15		1.5524	
16		1.5154	1.4969
17		1.4969	1.4415
18		1.423	1.46
19		1.922	1.885
20		1.8665	1.9404
21		1.9035	1.9774
22		1.848	2.0144
23		2.0328	1.9959
24			1.9404
Max	1.6632	2.0328	2.0144
Min	1.6632	1.423	1.4415
Avg	1.6632	1.7289	1.7947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 203 / 11 KV KENDRIYA VIHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
8	1.3676		
15		1.0164	
16			.9425
17		.9511	.9694
18		1.0059	1.0059
19		1.2071	1.1888
20		1.2071	1.2071
21		1.262	1.2803
22		1.2254	1.2936
23		1.39	1.3169
24			1.9204
Max	1.3676	1.39	1.9204
Min	1.3676	.9511	.9425
Avg	1.3676	1.1581	1.2361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 204 / 11KV LINK LINE FEEDER
 (Vighnah Feeder KV- 11 /
 OUTGOING

SHEDDABLE URBAN

DATE	23-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
8	1.7741		
16			1.6263
17		1.6804	1.6991
18		1.9044	1.8484
19		2.2405	2.1845
20		2.3152	2.3712
21		1.5806	2.3525
22		2.2218	2.2218
23		2.1098	2.2592
24			2.0165
Max	1.7741	2.3152	2.3712
Min	1.7741	1.5806	1.6263
Avg	1.7741	2.0075	2.0644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 206 / 11 KV HIRANANDANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	28-FEB-17
HR	Load (MW)
22	.037
Max	.037
Min	.037
Avg	.037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 207 / 11 KV MILLANIUM PARK
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)
16		1.6632
17	1.5364	1.6461
18	1.7193	1.7193
19	1.8839	1.9387
20	1.8473	1.9936
21	1.9204	1.9387
22	1.9387	1.9387
23	1.9753	1.9936
24		1.8473
Max	1.9753	1.9936
Min	1.5364	1.6461
Avg	1.8316	1.8532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224008 / 33 /11 KV KHARGHAR SEC-12

S/ST

Feeder No / Name : 208 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)
12	.024	
13	.024	
15	.024	
16	.024	
17		.024
18	.024	.024
19	.024	.024
20		.024
21	.024	.024
22	.024	.024
23	.024	.024
24	.024	.024
Max	.024	.024
Min	.024	.024
Avg	.024	.024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 202 / 11 KV PUMP HOUSE SEC 11

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.4287		.3429	.5144	.6859
4		.4115		.4287			
5						.5144	
6					.3429		
7		.8916	.6859	.7545		.6859	
9			1.0288	1.0974		.6001	.8573
10		.9602					
11					.6859	.6859	
12			1.0288				.823
13		.6859				.6859	
14					.3429		
15			.9602			.6859	.8916
16		.6859					
17			1.0288		.6859	.6859	1.0288
19		.8573				.6859	
20			1.0288		.6859		1.166
21	.6859					.8573	
22		.8573			.6859		
23	.7545		.6001			.8573	
24	.5144	.6401	.4287	.5487	.6859	.6859	.6859
Max	.7545	.9602	1.0288	1.0974	.6859	.8573	1.166
Min	.5144	.4115	.4287	.4287	.3429	.5144	.6859
Avg	.6516	.7487	.8021	.7073	.5573	.6787	.8769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 203 / 11 KV MURBI SECTOR-19

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6097						
3	.6097		.6859		.8573	.7716	.8573
4	.6097	.6173		.6859			
5	.6097					.8573	
6	.6097				.8573		.8573
7	.9145	1.0974	.8573	.823		1.1145	
8	.9145						
9	.9145		.9431	1.0288		.9431	1.0288
10	.9145	.8916					
11	.9145				1.0288	.8573	
12	.9145		.7545				.823
13	.6097	.7716				.8573	
14	.6097				.7716		
15	.6097		.6859			.8573	.823
16	.6097	.6859					
17	.6097		.6859		.7716	.8573	.7545
18	.6097						
19	.9145	.8573					
20	.9145		.823		.9431		.8916
21	1.8061						
22	.9145	.8573			1.0288		
23	1.8061		.9602				1.166
24	1.9433	.823	.6859	.8916	.7716	1.0288	1.0288
Max	1.9433	1.0974	.9602	1.0288	1.0288	1.1145	1.166
Min	.6097	.6173	.6859	.6859	.7716	.7716	.7545
Avg	.8910	.8252	.7869	.8573	.8788	.9049	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 206 / 11 KV AWHO SECTOR-14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			1.286		1.2003	1.2003	1.286
4		1.1145		1.2003			
5						.9145	
6					1.286		1.2003
7		1.5432	1.3717	1.286		1.7147	
8					1.286		
9			1.5432	1.3717		1.3717	1.5432
10		1.6289					
11					1.7147	1.3717	
12			1.5432				1.5432
13		1.3717				1.4575	
14					1.5432		
15			1.286			1.4575	1.3717
16		1.2003					
17			1.4575		1.4575	1.5432	1.4575
19		1.7147				1.7147	
20			1.5432		1.8861		1.8861
21	1.7147					1.8004	
22		1.7147			1.8861		
23	1.5432		1.7147			1.8861	1.8861
24	1.5432	1.3717	1.286	1.5432	1.8004	1.8004	1.8861
Max	1.7147	1.7147	1.7147	1.5432	1.8861	1.8861	1.8861
Min	1.5432	1.1145	1.286	1.2003	1.2003	.9145	1.2003
Avg	1.6004	1.4575	1.4479	1.3503	1.5623	1.5194	1.5622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 207 / VISHWAJYOTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.6001		.6859	.6859	.6859
4		.6001		.6001			
5						.7716	
6					.6859		.6859
7		.8573	.6859	.6859		.8573	
8					.7716		
9			.8573	.8573		.8573	.9431
10		.7716					
11					.9431	.8573	
12			.8573				.8573
13		.6859				.7716	
14					.8573		
15			.6859			.7716	.7716
16		.6859					
17			.6859		.8573	.7716	.7716
19		.8573					
20			.8573		.8573		.9431
21	.8573						
22		.8573			.8573		
23	.7716		.8573				.9431
24	.8573	.7716	.6001	.8573	.9431	.8573	.9431
Max	.8573	.8573	.8573	.8573	.9431	.8573	.9431
Min	.7716	.6001	.6001	.6001	.6859	.6859	.6859
Avg	.8287	.7609	.7430	.7502	.8288	.8002	.8383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 208 / 11 KV JALVAYU SECTOR-20

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			1.0288		1.2003	1.2003	1.1145
4		1.2003		1.0288			
5						1.2003	
6					1.2003		1.1145
7		1.3717	1.2003	1.0288		1.4575	
8					1.1145		
9			1.2003	1.3717		1.3717	1.286
10		1.2003					
11					1.3717	1.3717	
12			1.2003				1.2003
13		1.0288				1.286	
14					1.286		
15			1.0288			1.286	1.2003
16		1.0288					
17			1.2003		1.3717	1.286	1.286
19		1.5432				1.4575	
20			1.3717		1.5432		1.6289
21	1.5432						
22		1.4575			1.5432		
23	1.286		1.4575				1.7147
24	1.3717	1.2003	1.0288	1.3717	1.6289	1.7147	1.5432
Max	1.5432	1.5432	1.4575	1.3717	1.6289	1.7147	1.7147
Min	1.286	1.0288	1.0288	1.0288	1.1145	1.2003	1.1145
Avg	1.4003	1.2539	1.1908	1.2003	1.3622	1.3632	1.3432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 209 / 11 kV \sector 18

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.6859		.6859	.8573	.6859
4		.7716		.6859			
5						.8573	
6					.7716		.6859
7		.9945	.7716	.7716		1.0288	
8					.7716		
9			.8573	.8573		.9431	.8573
10		.7716					
11					.8573	.8573	
12			.7716				.7716
13		.6859				.7716	
14					.8573		
15			.6859			.6859	.6859
16		.6001					
17			.6859		.8573	.6859	.7716
19		.8573					
20			.8573		.8573		1.0288
21	.8573						
22		.8573			1.0288		
23	.8573		1.0288				1.2003
24	1.0288	.8573	.6859	.9431	1.1145	1.1145	1.1145
Max	1.0288	.9945	1.0288	.9431	1.1145	1.1145	1.2003
Min	.8573	.6001	.6859	.6859	.6859	.6859	.6859
Avg	.9145	.7995	.7811	.8145	.8668	.8669	.8669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 210 / 11 kV \ Vastuvihar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.2572		.2572	.2572	.2572
4		.3429					
5						.3429	
6					.3429		.2572
7		.3429	.3429	1.2689		.3429	
8					.3429		
9			.2572	.2572		.2572	.3429
10		.2401					
11					.2572	.2572	
12			.2058				.2229
13		.1715				.1715	
14					.1715		
15			.1715			.1715	.1715
16		.1715					
17			.1886		.1715	.2572	.2058
19		.3429					
20			.2743		.2572		.2915
21	.2915						
22		.3429			.3429		
23	.3429		.3429				.3429
24	.3429	.3429	.3429	.3429	.3429	.3429	.4287
Max	.3429	.3429	.3429	1.2689	.3429	.3429	.4287
Min	.2915	.1715	.1715	.2572	.1715	.1715	.1715
Avg	.3258	.2872	.2648	.623	.2762	.2667	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 211 / 11 kV Sector 27

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.0857		.1715	.1715	.0857
4		.1715		.1543			
5						.1715	
6					.1715		.0857
7		.1715	.0857	.1715		.1715	
8					.1715		
9			.0857	.1886		.1715	.1715
10		.1029					
11					.1715	.1715	
12			.1372				.12
13		.0857				.1715	
14					.1715		
15			.1029			.0857	.12
16		.0857					
17			.1029		.1715	.0857	.1029
19		.0857					
20			.1715		.1715		.1715
21	.1372						
22		.0857			.1715		
23	.1543		.1715				.1715
24	.1715	.1543	.0857	.1715	.1715	.1715	.1715
Max	.1715	.1715	.1715	.1886	.1715	.1715	.1715
Min	.1372	.0857	.0857	.1543	.1715	.0857	.0857
Avg	.1543	.1179	.1143	.1715	.1715	.1524	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224009 / 33/11 KV SEC 19 KHARGHAR

S/STN

Feeder No / Name : 241 / 11kV incomer-

SHEDDABLE URBAN

1(10/12.5MVA)Tr Feeder KV- 11

/ INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5051	1.4098	1.5242	1.6575	1.7909	1.7718
2	1.3908	1.2955	1.4098	1.4861	1.6385	1.6385
3	1.3146	1.2193	1.2955	1.3717	1.5242	1.5242
4	1.2765	1.1812	1.2384	1.3146	1.4289	1.448
5	1.2574	1.1812	1.2384	1.2765	1.3527	1.3717
6	1.6004	1.4289	1.448	1.5623	1.3527	1.7147
7	2.0576	2.1719	1.7337	1.7147	1.6194	1.9814
8	2.3243	2.2862	1.9814	2.1529	1.7909	2.0576
9	2.1529	2.2862	2.0767	2.2862	1.9052	1.7528
10	2.0576	2.3434	2.0767	2.0767	1.7909	1.8861
11	2.4006	2.1338	2.1529	2.2672	1.9624	1.9433
12	2.3815	1.8861	1.9814	2.0957	1.8671	1.848
13	2.3053	1.9433	1.8671	1.8861	1.7909	1.6385
14	2.21		1.6766	1.6956	1.7718	1.5242
15	2.0767		1.7909	1.6194	1.7147	1.7718
16	2.191		1.7718	1.6194	1.6575	1.7147
17	2.3434		1.848	1.7147	1.6956	1.7528
18	2.3815		1.8861	1.6575	1.9624	1.7718
19	2.4387		1.8099	1.7718	1.848	1.6956
20	2.1529		2.0386	1.848	1.7147	1.7147
21	2.0767		2.1338	1.7909	1.7337	1.7147
22	1.8671		1.9052	1.7337	1.829	1.9624
23	1.848		1.829	2.0005	1.9052	2.0195
24	1.6575		1.7337	1.8671	1.9052	1.9243
Max	2.4387	2.3434	2.1529	2.2862	1.9624	2.0576
Min	1.2574	1.1812	1.2384	1.2765	1.3527	1.3717
Avg	1.9695	1.7513	1.7687	1.7695	1.7314	1.7560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 202 / 11 KV CIDCO S/STN SEC-10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082			1.0829		1.2136	1.0829
2	.9709	.9335	.9335	1.0456	1.1576	1.0082	1.0456
3	.9335			1.0082		.9896	1.0269
4	.9335		.8962	.9709		.9709	
5	.9709			.8962	1.0269	.9896	.9709
6	1.0456			.8962		1.0642	
7	1.0269			.8775		1.1389	1.0082
8	1.0082	.9896	1.0082	.9335	.8962	1.0829	1.0269
9			1.0082		.8962		
10	.8402	.8589	.9896		.9896	.9335	
11		.8215	.8589	.9709	.9522	.8589	
12		.7655	.8962		.9149	.8589	.8589
13		.8215	.8775		.9896	.8962	
14		.8215	.8215	.8402	.8775	.8962	.7842
15		.8402	.8215		.9522	.8962	
16			.8589		.9709	.9335	.8589
17		.8775	.8215	1.0269	1.0829	.9709	.8775
18	.8589	.9335	.9896	.9896	.9335	1.0269	
19		1.0269	1.0456		1.1016	1.1203	1.0269
20		.9522	.9709		1.0456		
21	1.0269		1.0082		1.0269	1.1576	1.1016
22			1.0269	1.0456	1.0829	1.1576	
23	1.0269		1.0456		1.2323		1.2883
24	1.0642	1.0456	.9709	1.1203	1.2883	1.2323	1.1203
Max	1.0642	1.0456	1.0456	1.1203	1.2883	1.2323	1.2883
Min	.8402	.7655	.8215	.8402	.8775	.8589	.7842
Avg	.9781	.8991	.9394	.9789	1.0220	1.0189	1.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 203 / 11KV CIDCO Sec-2 Kharghar SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9605			2.1285		2.2779	2.8006
2	1.8671	2.0351	2.2779	1.9791	2.0351	1.9044	2.6139
3	1.8298			1.8671		1.8484	2.5766
4	1.7924		2.0538	1.7924		1.8298	
5	1.7924			1.7924	1.7737	1.8298	2.0538
6	1.8671			1.8298		1.9978	
7	2.0351			1.7364		2.2032	1.8671
8	1.9605	1.8858	1.9044	1.7924	1.7177	1.9605	1.9605
9			2.4272		2.0911		
10		2.4272	2.6513		2.6139	2.8006	
11		2.894	3.0434	3.3981	3.006	3.4541	
12		3.2861	3.1741		3.2114	3.3608	
13		3.1741	2.95		3.2301	3.1741	
14		3.1741	2.8006	3.1927	3.1367	3.1741	3.1181
15		3.0807	2.782		2.894	3.1181	
16		3.0434	2.7446		2.9313	3.3234	3.2487
17		3.0994	2.7073	2.9874	2.9874	3.2674	3.1741
18		3.1927	2.8753	3.2114	3.0994	3.3608	
19		3.4915	3.3048		3.4355	3.5475	3.6782
20		3.3981	3.1927		3.5101		
21	3.1927		3.1367		3.3608	3.3608	3.4541
22			2.7073	3.0994	3.062	2.9687	
23	2.4086		2.5766		2.8753		2.782
24	2.3339	2.3152	2.3525	2.3339	2.3899	2.5579	2.894
Max	3.1927	3.4915	3.3048	3.3981	3.5101	3.5475	3.6782
Min	1.7924	1.8858	1.9044	1.7364	1.7177	1.8298	1.8671
Avg	2.0946	2.8927	2.7191	2.3672	2.8085	2.7295	2.7863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 204 / 11 KV Prajapati S/stn Sec- SHEDDABLE URBAN
2 kh Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0934		.112	.112
2	.0747	.112	.0934	.0747	.112	.0934	.0934
3				.0747		.0747	.0747
4	.0747		.0934	.0747		.0747	
5				.0934	.0934	.0934	.0747
6	.0934			.0934		.112	
7				.0934		.0934	.0747
8	.0934	.0934	.0934	.0934	.0934	.0747	.0747
9			.112		.0934		
10		.112	.112		.112	.1307	
11		.112	.1307	.1307	.1307	.1494	
12		.1307	.1307		.1307	.1494	
13		.1307	.1307		.1307	.1494	
14		.112	.1307	.1494	.1307	.1494	.112
15		.112	.1494		.1494	.1494	
16		.112	.1307		.1307	.1494	.1307
17		.1307	.1307	.1494	.1307	.1494	.1494
18		.1307	.1494	.1494	.1307	.168	
19		.1867	.168		.168	.168	.1494
20		.1307	.1494		.168		
21	.1307		.1494		.168	.1494	.1494
22			.1307	.1307	.1307	.1307	
23	.1307		.1307		.1307		.1494
24	.0934	.112	.0934	.112	.112	.1307	.112
Max	.1307	.1867	.168	.1494	.168	.168	.1494
Min	.0747	.0934	.0934	.0747	.0934	.0747	.0747
Avg	.0987	.1227	.1268	.1081	.1287	.1263	.1120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 205 / 11 KV Railway station SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.168		.168	.112
2	.1307	.1494	.112	.1494	.1494	.1494	.0934
3				.168		.1494	.0934
4	.1307		.0747	.1494		.168	
5				.168	.0934	.168	.0934
6	.0934			.168		.1494	
7				.112		.1307	.0934
8	.112	.112	.0747	.0747	.0747	.0934	.0934
9			.0934		.0747		
10		.112	.0934		.0747	.112	
11		.0934	.0934	.1307	.0747	.1494	
12		.0934	.112		.0747	.1494	
13		.0934	.0934		.0934	.1307	
14		.112	.0934	.0934	.0934	.1307	.1307
15		.112	.0934		.0934	.1307	
16		.112	.0934		.0747	.1494	.168
17		.0934	.0934	.0747	.0934	.1494	.1307
18		.0934	.0934	.0747	.0934	.168	
19		.2054	.1494		.1867	.1867	.2241
20		.1867	.2054		.168		
21	.1867		.2241		.2241	.1867	.2241
22			.2241	.2054	.2054	.1867	
23	.1494		.2054		.1867		.2054
24	.168	.168	.1494	.1867	.1867	.168	.1494
Max	.1867	.2054	.2241	.2054	.2241	.1867	.2241
Min	.0934	.0934	.0747	.0747	.0747	.0934	.0934
Avg	.1387	.1240	.1248	.1374	.1219	.1511	.1393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 206 / SUB STATION T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0187
2		.0187		.0187
3				.0187
4		.0187		
5				.0187
7				.0187
8		.0187		.0187
10	.0187		.0187	
11	.0187		.0187	
12	.0187		.0187	
13	.0187		.0187	
14	.0187		.0187	
15			.0187	
16	.0187		.0187	
17	.0187		.0187	
18	.0187			
19	.0187		.0187	
20	.0187			
21			.0187	
22			.0187	
24		.0187		.0187
Max	.0187	.0187	.0187	.0187
Min	.0187	.0187	.0187	.0187
Avg	.0187	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 207 / 11 KV Glow Max

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.056		.0747	.0747
2	.0187	.0373	.0934	.0187	.0373	.0373	.0373
3				.0187		.0187	.0373
4	.0187		.0373	.0187		.0187	
5				.0187	.0187	.0187	.0373
6	.0187			.0187		.0187	
7				.0187		.0187	.0373
8	.0187			.0187		.0373	.0373
9			.112		.1307		
10		.112	.2054		.2054	.1494	
11		.1494	.2054	.2614	.2054	.2054	
12		.2241	.2241		.2614	.2054	
13		.2241	.2054		.2427	.2054	
14		.2241	.2427	.2614	.2427	.1867	.2054
15		.2241	.2427		.2427	.1867	
16		.2241	.2427		.2427	.1867	.2054
17		.2241	.2241	.2054	.2241	.1867	.2054
18		.2427	.2614	.2054	.2427	.1867	
19		.2054	.2801		.2614		.1867
20		.2054	.168		.2241		
21	.2054		.2054		.2054	.168	.2054
22			.2054	.2987	.1867	.1494	
23	.168		.1867		.1494		.2054
24	.112	.1307	.1307	.1494	.168	.1494	.112
Max	.2054	.2427	.2801	.2987	.2614	.2054	.2054
Min	.0187	.0373	.0373	.0187	.0187	.0187	.0373
Avg	.0800	.1867	.1929	.1120	.1940	.1204	.1221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 208 / 11 KV Balaji Angan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.5684		1.643	1.7551
2	1.307	1.4003	1.5684	1.3817	1.6804	1.4937	1.7177
3				1.419		1.3817	1.6804
4	1.2696		1.531	1.3817		1.3443	
5				1.363	1.4937	1.419	1.6804
6	1.531			1.363		1.6244	
7				1.4377		1.8298	1.8671
8	1.9791	1.9044	1.7551	1.7364	1.531	1.9231	1.9978
9			2.0538		1.6991		
10		2.3152	2.3339		1.9605	2.5206	
11		2.1624	2.0725	2.1845	2.1472	2.726	
12		2.3525	2.1285		1.8671	2.6513	
13		2.3152	1.9044		1.8111	2.6139	
14		2.2779	2.0165	1.9418	1.7551	2.5766	2.3525
15		2.2405	2.0351		1.8298	2.5393	
16		2.1845	2.0165		1.6991	2.5019	2.3899
17		2.0538	1.8671	1.6804	1.643	2.4272	2.0538
18		1.8111	1.6244	1.6804	1.6804	2.2405	
19		1.9978	1.8298		1.8858	2.0911	2.0538
20		1.9605	1.8858		1.8671		
21	1.9044		1.9418		1.9044	2.0165	1.9978
22			1.9231	1.9418	1.9231	1.9418	
23	1.643		1.8484		1.9418		1.9605
24	1.6057	1.5497	1.6057	1.7177	1.8111	1.8298	1.7737
Max	1.9791	2.3525	2.3339	2.1845	2.1472	2.726	2.3899
Min	1.2696	1.4003	1.531	1.363	1.4937	1.3443	1.6804
Avg	1.6057	2.0376	1.8917	1.6284	1.7964	2.0636	1.9447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 209 / 11kV NIFT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0187
2		.0187		.0187
3				.0187
4		.0187		
5				.0187
7				.0187
8		.0187		.0187
10	.0187		.0187	
11	.0187		.0187	
12	.0187		.0187	
13	.0187		.0187	
14	.0187		.0187	
15	.0187		.0187	
16	.0187		.0187	
17	.0187		.0187	
18	.0187		.0187	
19	.0187		.0187	
20	.0187			
21			.0187	
22			.0187	
24		.0187		.0187
Max	.0187	.0187	.0187	.0187
Min	.0187	.0187	.0187	.0187
Avg	.0187	.0187	.0187	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 210 / 11kV outgoing feeder 10 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0829		1.2696	1.2696
2	1.1203	1.1203	1.1203	1.0082	1.2136	1.251	1.2323
3				1.0082		1.2136	1.1949
4	1.0082		1.1203	1.0456		1.1949	
5				1.0456	1.0269	1.2323	1.1576
6	1.1203			1.0269		1.2136	
7				1.1016		1.251	1.1949
8	1.307	1.2696	1.1763	1.0456	1.0456	1.1949	1.2136
9			1.1203		1.0829		
10		1.1203	1.0829		1.2323	1.0269	
11		.9335	.9709	1.0269	1.1576	.8589	
12		.7655	.9335		1.1576	.8589	
13		.8215	.9335		1.0829	.8962	
14		.8215	.8962	1.0269	1.1576	.9335	.9335
15		.8402	.8402		1.0829	.9335	
16		.8402	.8589		1.0829	.9709	.9709
17		.8402	.8215	.9335	.9896	1.0082	.9709
18		.8402	.9335	.9896	1.0082	1.0456	
19		1.1203	1.0642		1.2323	1.0829	1.2136
20		1.1203	1.1016		1.307		
21	1.1203		1.1763		1.2696	1.307	1.2136
22			1.1763	1.2136	1.307	1.3443	
23	1.1576		1.307		1.363		1.4003
24	1.2136	1.1763	1.1576	1.1203	1.307	1.2883	1.307
Max	1.307	1.2696	1.307	1.2136	1.363	1.3443	1.4003
Min	1.0082	.7655	.8215	.9335	.9896	.8589	.9335
Avg	1.1496	.9736	1.0416	1.0482	1.1635	1.1131	1.1748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 211 / 11 KV S N Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.8215		1.0082	.9709
2	.7468	.7842	.8962	.7842	.8402	1.0456	.9335
3				.7468		.8215	.9335
4	.7468		.8589	.7468		.7842	
5				.7468	.7842	.8962	1.0082
6	.9149			.7468		.8775	
7				.8962		1.1203	1.1576
8	1.1203	1.1949	1.1949	.8775	.8589	1.1949	1.2136
9			1.1203		1.0642		
10		1.0082	.9709		.9709	1.0269	
11		.9335	.8962	1.0269	.8215	1.0082	
12		.8402	.8589		.7468	.9709	
13		.8402	.9149		.8215	.9335	
14		.8402	.8589	.8029	.8215	.9335	1.0082
15		.8215	.8402		.7468	.9335	
16		.8215	.7655		.7842	.9335	.8775
17		.8215	.7282	.7842	.7468	.9335	.8215
18		.8215	.7282	.7842	.8402	.9335	
19		1.0642	.8775		.9522	.9709	.9522
20		1.0082	.9896		.9522		
21	.9522		.8962		1.0082	1.0269	.9896
22			.9335	.9522	1.0082	1.0456	
23	.8962		.9709		1.0456		1.0456
24	.8589	.8402	.8962	.9149	.9709	.9709	1.0082
Max	1.1203	1.1949	1.1949	1.0269	1.0642	1.1949	1.2136
Min	.7468	.7842	.7282	.7468	.7468	.7842	.8215
Avg	.8909	.9029	.9051	.8309	.8834	.9700	.9939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 212 / 11kV outgoing feeder 12

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	25-FEB-17
HR	Load (MW)
17	.0934
Max	.0934
Min	.0934
Avg	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224010 / 33/11 KV SEC-2 KHARGHAR

Feeder No / Name : 213 / 11kV BPCL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0187		.0187	.0187
2	.0187	.0187		.0187	.0187	.0187	.0187
3				.0187		.0187	.0187
4	.0187			.0187		.0187	
5				.0187	.0187	.0187	.0187
6	.0373			.0187		.0187	
7				.0187		.0187	.0187
8	.3357	.1307		.1166	.0187	.3575	.0747
9	.1829		.0934	.0648		.2248	
10	.2286	.1867	.1867	.0686		.4455	
11	.2362	.2241	.168	.1547		.468	
12	.2362	.2241	.2241	.0495	.0187	.4794	
13	.2401	.2241	.1867	.0533		.5137	
14	.2515	.2241	.2427	.1433		.5396	.2427
15	.2591	.2054	.2241	.0914	.0187	.5281	
16	.2515	.2054	.2241	.1296	.0187	.5319	.2427
17	.2477	.2054	.2241	.1219	.0187	.5205	.2427
18	.2362	.1867	.1867	.2077	.0373	.4718	
19	.1867	.0373	.056	.0953	.0373	.2351	.0747
20	.0419	.0373	.0373		.0373	.0114	
21	.0373		.0373		.0373	.0373	.056
22			.0373	.0373	.0373	.0373	
23	.0373		.0373		.0187		.0373
24	.0373	.0373	.0373	.0373	.0373	.0187	.0187
Max	.3357	.2241	.2427	.2077	.0373	.5396	.2427
Min	.0187	.0187	.0373	.0187	.0187	.0114	.0187
Avg	.1643	.1534	.1377	.0715	.0267	.2414	.0833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 201 / plot no 51 sec-30 feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.8176		
24	1.7661	1.8519	2.0748	2.1948
Max	1.7661	1.8519	2.0748	2.1948
Min	1.7661	1.8176	2.0748	2.1948
Avg	1.7661	1.8348	2.0748	2.1948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 202 / mass housing s/s no-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0514	.0514	.0514	.0514
Max	.0514	.0514	.0514	.0514
Min	.0514	.0514	.0514	.0514
Avg	.0514	.0514	.0514	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 203 / sec-34C feder prop.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0343		
24	.0514	.0514	.0343	.0343
Max	.0514	.0514	.0343	.0343
Min	.0514	.0343	.0343	.0343
Avg	.0514	.0429	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 204 / sec-34A feeder prop.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.5487		
24	.6001	.7202	.7888	.7545
Max	.6001	.7202	.7888	.7545
Min	.6001	.5487	.7888	.7545
Avg	.6001	.6345	.7888	.7545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 205 / pl no.42 & 43, sec-35D

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0343		
24	.0514	.0514	.0514	.0514
Max	.0514	.0514	.0514	.0514
Min	.0514	.0343	.0514	.0514
Avg	.0514	.0429	.0514	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 206 / PLOT NO 53 & 54 STATUS SHEDDABLE URBAN
VIHAR S Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.463		
24	.4458	.4801	.5487	.6001
Max	.4458	.4801	.5487	.6001
Min	.4458	.463	.5487	.6001
Avg	.4458	.4716	.5487	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 207 / MASS HOUSING S/S NO.3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0857		
24	.0686	.0857	.0686	.0686
Max	.0686	.0857	.0686	.0686
Min	.0686	.0857	.0686	.0686
Avg	.0686	.0857	.0686	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 210 / MASS HOUSING S/S NO.4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0857		
24	.0857	.0857	.12	.0857
Max	.0857	.0857	.12	.0857
Min	.0857	.0857	.12	.0857
Avg	.0857	.0857	.12	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 211 / MASS HOUSING S/S NO.2 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
24	.0343	.0343	.0343
Max	.0343	.0343	.0343
Min	.0343	.0343	.0343
Avg	.0343	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 224013 / 33/11 KV Sector-35I Kharghar

Feeder No / Name : 212 / arihant abhilasha pl no-10

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.0802		
24	1.406	1.5089	1.8004	***
Max	1.406	1.5089	1.8004	16.8553
Min	1.406	1.0802	1.8004	16.8553
Avg	1.406	1.2946	1.8004	16.8553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 402 / 33KV SECTOR-12

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)
1	21.7421	21.605
2	19.8217	19.8903
3	18.1756	18.5871
4	17.284	17.5583
5	16.4609	16.8725
6	16.1866	17.8327
7	16.4609	19.9589
8	17.5583	21.0563
9	19.4788	20.2332
10	20.0275	19.8217
11	20.5076	19.6159
12	20.2332	19.2044
13	19.9589	18.5871
14	19.4788	18.2442
15	19.0672	18.0384
16	18.8615	17.9013
17	19.1358	17.7641
18	19.0672	18.1756
19	21.262	21.0563
20	22.771	22.8395
21	22.428	22.8395
22	22.3594	22.7024
23	22.771	23.2511
24	23.1139	23.4568
Max	23.1139	23.4568
Min	16.1866	16.8725
Avg	19.7588	19.8789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

KHARGHAR SUB-DIVN.[795] BU 4795

Substation No/ Name :- 229019 / 400/33/22KV Kharghar S/Stn

Feeder No / Name : 405 / 33KV SECTOR-19

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	21.0563	19.4788	24.8972	24.8972
2	19.3416	17.6269	22.5652	22.6338
3	18.0384	16.5295	20.9877	20.9877
4	17.284		19.6845	19.5474
5	16.8039		18.7243	18.6557
6	18.45		18.2442	19.8217
7	23.0453		18.9987	23.8683
8	25.2401		20.096	24.9657
9	23.1825		21.7421	21.9479
10	21.4678		22.9767	21.8793
11	22.2223		23.2511	21.5364
12	22.2223		23.3196	21.1934
13	21.4678		22.771	20.0275
14	20.0275		21.8793	19.1358
15	18.8615		20.7133	19.4102
16	19.6159		20.9191	19.2044
17	21.1249		21.3306	19.3416
18	21.8793		22.4966	20.7819
19	23.2511		23.5254	22.0165
20	24.4856		23.8683	23.3196
21	24.6914		23.8683	24.2113
22	23.0453		24.8972	25.3087
23	22.5652		25.9945	26.6804
24	21.5364		26.4061	26.6804
Max	25.2401	19.4788	26.4061	26.6804
Min	16.8039	16.5295	18.2442	18.6557
Avg	21.2878	17.8784	22.2565	22.0022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 304 / 22KV GAVAN

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	11.6751	14.2052	14.4186	13.9918	13.565	11.3398
2	11.0654	14.3271	14.5405	13.1992	14.1747	11.2178
3	11.2483	11.797	12.8334	12.4067	14.2357	10.0899
4	10.6386	11.5836	13.0163	13.3821	13.1078	9.968
5	10.7606	13.0163	14.2052	13.2297	12.8639	11.7665
6	12.5896	12.4676	13.8089	13.2907	11.7665	11.9189
7	11.5531	10.5167	11.5531	11.3702	10.4862	9.9985
8	9.6937	8.2914	12.2847	11.797	9.8766	8.9316
9	12.5896	6.2186	12.1628	11.4922	10.852	9.6327
10	13.3212	5.1517	13.626	14.8758	11.5226	11.797
11	16.0342	13.2907	14.7234	14.571	11.0349	17.3449
12	15.0282	14.2052	15.394	14.3576	11.1569	17.4974
13	15.0892	14.3881	14.6319	12.4981	9.9375	16.4
14	11.0349	10.5167	10.9435	9.6022	9.1754	13.7479
15	14.7234	13.565	14.9673	12.7725	10.5167	17.9546
16	13.7479	15.9122	13.3516	11.797	10.0595	17.6193
17	13.8699	15.1197	13.1383	11.5226	6.9197	16.4
18	14.3881	15.1197	14.0223	12.1323	6.371	16.339
19	13.0468	6.8892	11.8884	11.7055	8.6267	13.4736
20	12.2847	13.4736	12.4676	11.4312	11.2178	13.687
21	12.9554	14.9977	13.4736	14.3576	10.8215	13.9613
22	14.1747	14.3271	12.8944	15.8817	10.5472	14.2966
23	12.681	12.6505	12.9858	13.5041	11.6751	15.1502
24	15.3635	13.2297	14.2966	14.9673	11.736	16.3695
Max	16.0342	15.9122	15.394	15.8817	14.2357	17.9546
Min	9.6937	5.1517	10.9435	9.6022	6.371	8.9316
Avg	12.8982	12.3025	13.4012	12.9223	10.9270	13.6209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 306 / Nere

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17
HR	Load (MW)
1	8.7792
2	8.1695
3	7.8647
4	7.6818
5	7.6818
6	4.9383
11	8.9621
12	11.6141
13	10.1509
14	8.7487
15	5.7613
16	8.7182
17	8.6877
18	8.9011
19	9.2974
20	11.1873
21	11.1569
22	10.6082
23	10.3338
24	9.6937
Max	11.6141
Min	4.9383
Avg	8.9468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 226003 / 100/22 KV TALOJA S/STN

Feeder No / Name : 306 / 22kv Feeder MIDC-3

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	24-FEB-17
HR	Load (MW)
1	14.6624
2	14.2052
3	14.2357
4	13.4736
5	12.8639
6	12.1933
7	11.736
8	10.913
9	10.0595
10	10.1204
11	10.913
12	11.0044
13	11.5836
14	11.4312
15	10.6996
16	10.6691
17	11.2178
18	11.1569
19	10.5777
20	10.6691
21	10.6691
22	10.913
23	10.8825
24	11.2788
Max	14.6624
Min	10.0595
Avg	11.5887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 301 / 22kv Feeder VVF

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	27-FEB-17
HR	Load (MW)
1	3.8409
2	3.8714
3	4.0695
4	4.0695
5	4.0238
6	4.0238
7	4.039
8	4.2372
9	4.2524
10	4.1457
11	4.1305
12	4.2219
13	4.1305
14	4.2676
15	4.2524
16	4.2981
17	3.5361
18	3.9781
19	3.8866
20	4.0543
21	4.0543
22	4.0543
23	3.8104
24	3.9323
Max	4.2981
Min	3.5361
Avg	4.0492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL I (BHINGARI)[124] BU 0329

Substation No/ Name :- 228028 / 220/100/22 KV TALOJA S/STN

Feeder No / Name : 304 / 22kv Feeder Exide
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	27-FEB-17
HR	Load (MW)
1	8.3829
2	8.078
3	7.5598
4	7.6818
5	7.4684
6	7.4379
7	7.4379
8	7.255
9	8.1085
10	8.3829
11	8.9316
12	8.7792
13	8.5658
14	8.5963
15	8.8401
16	8.6572
17	9.2669
18	8.9011
19	8.7182
20	8.7487
21	8.6572
22	8.7792
23	8.7182
24	7.8037
Max	9.2669
Min	7.255
Avg	8.3232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 302 / 22 KV PANVEL-I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9204	2.8807	2.7435	2.915	3.3608	2.9492	2.8121
2	1.8519	3.2922	2.4691	2.7435	3.155	2.9492	2.7435
3	1.8861	3.3265	2.332	2.572	3.0178	2.8807	2.6749
4	1.8861	2.7435	2.332	2.4691	2.8807	2.6749	2.6063
5	1.9547	2.8807	2.4006	2.5034	2.8121	2.5377	2.572
6	1.9547	2.8121	2.4691	2.572	2.572	2.4691	2.7778
7	1.9547	2.8807	2.6063	2.7092	2.6063	2.9492	2.8807
8	.2298	2.7435	2.8807	2.7778	2.7778	2.7778	2.9492
9	2.0919	2.915	6.1728	3.0178	3.0864	3.0178	2.9492
10	2.1948	3.0521	2.9492	2.9492	3.1893	3.2579	3.2236
11	2.9492	3.1207	2.9835	2.915	3.6694	4.1495	3.2236
12	2.8807	3.0864	2.9492	2.9835	3.738	4.1838	2.2634
13	2.8464	2.9835	2.9492	2.9492	3.738	4.0466	3.0864
14	2.8464	2.8464	2.6063	2.8464	3.6351	4.1152	2.0233
15	2.8121	2.9492	2.6749	2.915	3.6008	4.1152	3.0864
16	2.1262	3.0178	2.6406	2.9835	3.5322	3.8409	2.915
17	2.1948	3.0864	2.6063	2.9835	3.2922	3.7723	2.8807
18	3.4294	3.155	2.7435	2.9492	2.6063	3.0521	3.2236
19	3.5665	3.738	3.6694	4.3553	4.2867	3.7037	3.7037
20	3.5665	3.5322	3.4294	4.4582	4.4925	3.7037	
21	3.2922	3.3608	3.3608	4.4925	4.321	3.4294	3.4637
22	3.1207	3.1893	3.2579	4.1152	3.9781	3.4294	3.6008
23	3.0178	3.155	3.2236	3.738	3.738	3.2236	3.1893
24	1.5432	2.7435	3.0178	3.155	3.4637	3.3608	3.0864
Max	3.5665	3.738	6.1728	4.4925	4.4925	4.1838	3.7037
Min	.2298	2.7435	2.332	2.4691	2.572	2.4691	2.0233
Avg	2.4216	3.0621	2.9778	3.1279	3.3979	3.3579	2.9537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 307 / Sainagar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.7435	2.7435	2.8464	2.9492	3.0864	2.915
2	2.5377	2.6749	2.572	2.7435	2.8807	3.2236	2.8807
3	2.5377	2.6063	2.0919	2.4348	2.7435	2.8807	2.8121
4	2.572	2.5377	2.2291	2.4006	2.6749	2.8121	2.7435
5	2.6063	2.4006	2.3663	2.4691	2.6063	2.7435	2.6749
6	2.6063	2.332	2.4691	2.5377	2.4691	2.6749	2.6063
7	2.572	2.5377	2.572	2.5377	2.6063	2.6749	2.7092
8	2.5377	2.6063	2.5034	2.5034	2.4348	2.7092	2.332
9	2.332	2.3663	2.4691	2.4691	2.4691	2.5034	2.1605
10	2.1948	2.4006	2.4006	2.4691	2.572	2.5377	2.0233
11	1.989		2.4006	2.2977	2.2977	2.1605	2.1262
12	1.9547	2.0576	2.2634	2.0576	2.3663	2.1948	
13	1.9204	1.8861		2.0919	2.0919	2.0919	2.7092
14	1.9547	2.0233	2.0919	2.1605	2.2291	2.2634	2.2977
15	1.9547	2.0233	2.1948	2.2977	2.4348	2.1262	2.2634
16	2.0233	1.989	2.0919	2.2634	2.4006	2.2634	2.3663
17	2.0919	1.9204	2.0576	2.1262	2.2634	2.0919	2.1948
18	2.4006	2.0233	1.989	2.2291	2.0919	2.2291	2.1605
19	2.5034	2.6406	2.4348	2.6749	2.4691	2.6406	2.6749
20		2.572	2.572	2.7092	2.6063	2.8121	2.8121
21	2.4006	2.6749	2.6063	2.7092	2.572	3.0178	2.915
22	2.572	2.8121	2.7778	2.9492	2.8464	3.0178	3.0178
23	2.8807	3.0178	2.915	3.0521	3.1207	3.2579	
24	2.915	2.0919	2.1605	3.0521	3.0178	3.155	3.2922
Max	2.915	3.0178	2.915	3.0521	3.1207	3.2579	3.2922
Min	1.9204	1.8861	1.989	2.0576	2.0919	2.0919	2.0233
Avg	2.3827	2.3886	2.3901	2.5034	2.5506	2.6320	2.5767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 223001 / 22/22 KV BHINGARI SWITCHING

ST

Feeder No / Name : 310 / 22 KV PANVEL-III

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6067	5.2804	5.6615	5.833	4.9261	4.9108	1.5432
2	4.4703	5.2652	5.3643	5.4778	4.7325	4.5724	1.0288
3	4.4642	5.2843	5.1181	5.192	4.4596	4.6342	1.5089
4	4.3553	5.301	4.9093	5.0526	4.3088	4.6571	1.4403
5	4.5961	5.218	5.0937	5.0937	4.1739	4.8186	1.5775
6	4.8659	5.5518	5.2926	5.317	4.2456	4.9977	1.6118
7	6.2437	5.7164	5.4367	5.5937	4.5527	5.1524	1.749
8	5.1661	5.6318	5.9382	5.6615	4.8498	4.923	1.6461
9	5.4817	6.2681	6.8724	6.499	5.7354	5.1608	1.6461
10	5.8734	7.5149	8.1741	8.1863	6.3755	6.4129	1.7147
11	6.7467	10.1722	10.5236	10.6013	6.2918	6.9936	2.4348
12	6.9402	10.0686	10.4885	10.1022	6.547	7.3266	2.5377
13	6.4762	9.6236	9.9916	10.2774	6.0265	6.768	2.4348
14	6.5074	9.1899	9.3515	10.634	6.0555	6.6926	2.6063
15	6.7726	9.7073	9.6754	10.7324	6.166	6.9273	2.6406
16	7.8617	6.8679	10.0297	10.9617	7.4013	6.9105	2.6063
17	9.0269	9.824	9.8361	9.9833	8.4598	7.1384	2.5377
18	9.689	9.5969	9.2235	10.2843	7.9149	9.2082	2.4348
19	10.0487	9.635	10.1189	10.5136	6.5607	9.6647	2.6406
20	6.8862	9.1755	9.6792	6.5394	6.5508	9.4048	2.572
21	8.9529	8.648	8.9201	6.3336	5.99	8.389	2.4006
22	7.8266	7.5834	8.2739	5.8017	5.6043	7.8921	2.1948
23	6.8572	6.6842	7.1666	5.5266	5.2896	7.0218	2.0233
24	5.5944	6.0547	6.3703	5.6196	5.1974	5.7887	1.6804
Max	10.0487	10.1722	10.5236	10.9617	8.4598	9.6647	2.6406
Min	4.3553	5.218	4.9093	5.0526	4.1739	4.5724	1.0288
Avg	6.5129	7.4943	7.8129	7.5757	5.7673	6.5153	2.0505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 206 / 11kv sect-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	27-FEB-17
HR	Load (MW)
11	.1164
Max	.1164
Min	.1164
Avg	.1164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 207 / 11KV SECT-5

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	27-FEB-17
HR	Load (MW)
11	.2239
Max	.2239
Min	.2239
Avg	.2239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 208 / 11kv mpk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	27-FEB-17
HR	Load (MW)
11	.1109
Max	.1109
Min	.1109
Avg	.1109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 209 / 11 KV ESRGSR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	25-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5662	.5434	.5502	
2	.538	.4961	.5197	
3	.5098	.4733	.506	
4	.4938		.4847	
5	.5708		.5365	
6	.644		.6363	
7	.7171		.6706	
8	.7232		.6638	
9	.7026		.6798	
10	.6508		.6211	
11	.5456		.5502	.0517
12	.5136		.5312	
13	.5075		.5053	
14	.4786		.506	
15	.4938		.4473	
16	.5136		.4999	
17	.5319		.4893	
18	.522		.5639	
19	.5982		.7171	
20	.6066		.6752	
21	.6089		.6203	
22	.5891		.6219	
23	.5952		.6386	
24	.5777		.612	
Max	.7232	.5434	.7171	.0517
Min	.4786	.4733	.4473	.0517
Avg	.5749	.5043	.5770	.0517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224004 / 33/11KV NEW PANVEL SEC-7

S/STN

Feeder No / Name : 242 / 11 KV Transformer I/C - 2 NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-FEB-17
HR	Load (MW)
1	2.3457
2	2.0485
3	1.8991
4	1.8107
5	1.7726
6	2.0058
7	2.6017
8	2.6078
9	2.6581
10	2.4234
11	2.4112
12	2.4143
13	2.2451
14	2.0713
15	1.9799
16	1.9448
17	2.0729
18	2.1933
19	2.5255
20	2.8212
21	2.8441
22	2.7572
23	2.62
24	2.4524
Max	2.8441
Min	1.7726
Avg	2.3136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 201 / 11KV KALPATARU KRISHNA-1 SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966			.2261	.2271	.2377	.0754
2	.1762			.1846	.2133	.2164	.0566
3	.161			.1724	.1892	.1884	.0566
4	.1564		.0566	.1663	.1692	.1808	.0566
5	.1752			.176	.1882	.1958	.0754
6	.2063	.0943		.1912	.2117	.1303	.1132
7	.3192			.2684	.2489	.2528	.1698
8	.3959			.3268	.2896	.2966	.1698
9	.1997	.1698	.1509	.3603	.3186	.2981	.132
10	.1501	.132	.1509	.3087	.1783	.2565	
11	.1196	.0943	.132	.144	.2966	.1957	
12	.1151	.0754	.1132	.2549	.2913	.1934	
13	.1082	.0754	.1132	.1341	.2821	.188	
14	.1699	.0754	.1132	.2056	.2633	.185	.0566
15	.0983	.0754	.1132	.1075	.2588	.1888	.0943
16	.1602	.0754	.1132	.1067	.2588	.1865	
17	.1014	.0943	.1132	.2231	.2618	.1684	.0754
18	.1214		.132	.2336	.2504	.1827	.0943
19	.2562		.1509	.26	.2791	.213	.132
20	.1448		.1509	.2913	.1616	.2351	
21	.1593		.1698	.2778	.2763	.2707	.132
22	.1425		.132	.2421	.2633	.2949	.1132
23	.1265	.0943	.1132	.2489	.258	.2821	
24	.2239	.0943	.1132	.2595	.2551	.2505	.1132
Max	.3959	.1698	.1698	.3603	.3186	.2981	.1698
Min	.0983	.0754	.0566	.1067	.1616	.1303	.0566
Avg	.1743	.0959	.1254	.2237	.2454	.2203	.1010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 202 / 11KV KALPATARU NARMADA-1 SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566			.0754	.0566	.0754	.0754
2	.0566			.0566	.0566	.0566	.0754
3	.0377			.0566	.0566	.0566	.0566
4	.0377		.0566	.0566	.0566	.0566	.0566
5	.0566			.0754	.0566	.0566	.0943
6	.0754	.0754		.0754	.0566		.0943
7	.0943			.0754	.0566	.0754	.1132
8	.1132			.0754	.0943	.0943	.1132
9		.1509	.1132	.132	.0943	.132	.132
10		.1132	.1132			.0943	
11		.0754	.0943		.0876	.0754	
12		.0754	.0943		.0943	.0754	
13		.0754	.0943		.0754	.0754	
14	.0566	.0566	.1132	.0754	.0754	.0754	.0566
15		.0566	.0754		.0943	.0943	.0754
16	.0566	.0754	.0754			.1132	
17		.0943	.0754	.0943	.0943	.0943	.0754
18			.0943	.0943	.0943	.0754	.0566
19	.0754		.0943	.0754	.0754	.0754	.0754
20			.0943	.0754	.0754	.0943	
21			.0943	.0754	.0754	.0943	.0754
22			.0943	.0754	.0754	.0943	.0943
23		.0943	.0943	.0754	.0754	.0943	
24	.0754	.0754	.0754	.0943	.0943	.0754	.132
Max	.1132	.1509	.1132	.132	.0943	.132	.132
Min	.0377	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.0660	.0849	.0910	.0786	.0760	.0828	.0854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 203 / 11 KV KALPATARU KAVERI-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701			.0701	.1799	.1783	.0754
2	.0351			.0526	.1623	.1562	.0526
3	.0351			.0526	.1585	.1509	.0526
4	.0351		.0526	.0701	.1479	.1479	.0526
5	.0526			.0701	.1456	.1463	.0701
6	.1052	.0701		.0701	.1456	.1097	.0876
7	.1227			.0701	.1958	.2134	.0876
8	.1052			.0876	.1935	.1943	.1052
9		.0876	.1052	.0876	.2393	.1768	.0876
10		.0876	.1052		.1509	.1775	
11		.0876	.1227		.2972	.1905	
12		.0876	.1052		.2896	.2179	
13		.0701	.1052		.2264	.2019	
14	.0701	.0701	.0876	.0701	.2264	.1737	.0876
15		.0701	.0876		.2317	.1951	.0876
16	.0701	.0732	.1052		.1448	.2011	
17		.0876	.1052	.1052	.2293	.1623	.1052
18			.0876	.1052	.2057	.1882	.0701
19	.0876		.0876	.0876	.2118	.1783	.0876
20			.0876	.0876	.2248	.1874	
21			.0701	.0876	.2325	.1912	.0876
22			.0701	.0876	.218	.1912	.0876
23		.0876	.0701	.0876	.2057	.1928	
24	.0876	.0701	.0701	.0701	.2203	.1836	.1052
Max	.1227	.0876	.1227	.1052	.2972	.2179	.1052
Min	.0351	.0701	.0526	.0526	.1448	.1097	.0526
Avg	.0730	.0791	.0897	.0789	.2035	.1794	.0818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 205 / 11 KV KALPATARU INCOMING-1

SHEDDABLE RURAL

Feeder KV- 11 / INCOMING

DATE	22-FEB-17	23-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2865	.2774	.3018	.3307	.3323
2	.2698	.2515	.2789	.3185	.3155
3	.2469	.2347	.2622	.3018	.2926
4	.2393		.2362	.2652	.2698
5	.2317		.2301	.25	.2683
6	.2759		.2652	.2652	.3003
7	.407		.2865	.3064	.3978
8	.4268		.3277	.3292	.3628
9	.413		.407	.4146	.4146
10	.4009		.3841	.4374	.3551
11	.3338		.3399	.4207	.2942
12	.3109		.3612	.4268	.2957
13	.3018		.2987	.3506	.285
14	.2652		.2713	.3475	.2652
15	.25		.2728	.3521	.2667
16	.2469		.2606	.3536	.2957
17	.2835		.3536	.349	.2454
18	.2972		.3231	.3429	.2743
19	.2881		.317	.3338	.2942
20	.3506		.3597	.3765	.314
21	.3536		.3673	.381	.3353
22	.3368		.3612	.3521	.3445
23	.3582		.3368	.3612	.3536
24	.2972		.3399	.346	.3521
Max	.4268	.2774	.407	.4374	.4146
Min	.2317	.2347	.2301	.25	.2454
Avg	.3113	.2545	.3143	.3464	.3135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 208 / 11 KV KALPATARU NARMADA-2 SHEDDABLE URBAN
Feeder KV- 11 / INCOMING

DATE	22-FEB-17
HR	Load (MW)
2	***
3	***
5	***
6	***
8	***
9	***
11	***
12	***
14	***
15	***
17	***
18	***
20	***
21	***
23	***
24	***
Max	49.9429
Min	49.9429
Avg	49.9429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 209 / 11 KV KALPATARU KAVERI-2 SHEDDABLE URBAN
Feeder KV- 11 / INCOMING

DATE	22-FEB-17
HR	Load (MW)
2	***
3	***
5	***
6	***
8	***
9	***
11	***
12	***
14	***
15	***
17	***
18	***
20	***
21	***
23	***
24	***
Max	49.9429
Min	49.9429
Avg	49.9429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125]

BU 0311

Substation No/ Name :- 224012 / 33/11 KV KALPATARU RIVERSIDE

Feeder No / Name : 303 / 22KV O/g 2(Panvel 2)

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3896			3.0864	3.2556	3.1824	3.4751
2	3.658			3.1093	3.1093	2.9264	2.9264
3	3.4751			2.7435	2.9264	2.8166	2.7069
4	3.2922		2.4874	2.5606	2.8166	2.8166	2.7435
5	3.219			2.9264	2.8166	2.9264	2.9264
6	4.0238	2.9264		3.1093	2.9264		3.2922
7	4.5359			3.2922	2.9995	3.219	3.658
8	4.6822			3.4019	3.219	3.4385	3.3653
9		3.5117	3.658	3.4385	3.5848	3.5482	3.4751
10			3.8409			4.0238	
11		4.4262	4.2798		3.914	4.7188	
12		4.353	4.1701		3.8775	4.5359	
13		4.353	4.0238		3.8409	4.3896	
14	5.1578	4.2798	3.9872	4.1701	2.3548	4.5359	4.5359
15		4.2067	4.0969		3.8409	4.6091	4.4993
16	5.3772	4.353	4.1701		3.8409	4.6456	
17		4.4993	4.6822	4.5725	3.8775	5.1212	4.7188
18			4.9749	5.3041	4.0969	5.3041	4.6456
19	4.0238		5.1943	5.5967	4.7554	5.6333	5.2309
20			4.9749	5.487	4.6822	5.487	
21			4.7554	4.9017	4.5359	4.7554	4.8651
22			4.0238	4.2433	4.3164	4.2067	4.1335
23		3.8043	3.8409	4.0604	4.0969	4.0604	
24	4.7554	4.2798	3.4385	3.5848	3.5482	3.5117	3.4751
Max	5.3772	4.4993	5.1943	5.5967	4.7554	5.6333	5.2309
Min	3.219	2.9264	2.4874	2.5606	2.3548	2.8166	2.7069
Avg	4.2158	4.0903	4.1529	3.8660	3.6188	4.1049	3.8043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 301 / 22Kv ONGC Express
Feeder KV- 22 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.2498	1.2193
2	1.1584	1.1584	1.1584
3	1.1279	1.1584	1.1279
4	1.1584	1.1584	1.1584
5	1.1584	1.1279	1.1584
6	1.1888	1.2803	1.2803
7	1.4327	1.2803	1.4632
8	1.6461	1.2193	1.7985
9	2.3777	1.1279	2.2253
10	2.8349	1.2498	2.713
11	3.2617	1.4937	3.2922
12	3.3532	1.4632	3.2007
13	3.1703	1.3717	3.5056
14		1.4327	3.4446
15		1.3413	3.2312
16		1.3413	3.2312
17		1.3413	3.1703
18		1.3413	1.9509
19		1.5851	1.8595
20		1.5242	1.7071
21		1.3717	1.4327
22		1.3413	1.3413
23		1.3413	1.3108
24		1.2803	1.3413
Max	3.3532	1.5851	3.5056
Min	1.1279	1.1279	1.1279
Avg	1.9275	1.3159	2.0551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

PANVEL[125] BU 0311

Substation No/ Name :- 228013 / 220/33/22 KV ONGC PANVEL

Feeder No / Name : 405 / 33KV KALPATARU INCOMING-1 NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	18.994			15.3177	16.1408	16.086	3.9597
2	17.0028			14.1907	14.6159	14.6983	3.4637
3	15.8345			13.2717	13.8204	13.7106	3.2991
4	15.3132		3.1345	13.299	13.2305	13.2305	3.2991
5	15.2607			12.7526	12.8875	13.1345	3.5208
6	17.707	3.5208		13.6305	13.1916	14.4536	3.7975
7	20.2218			14.8263	13.8775	15.8848	4.241
8	20.5213			15.5829	14.8422	14.8491	4.1312
9	15.5007	4.241	3.8958	16.6278	15.2561	16.2963	4.1861
10	16.0494	4.6227	4.513	17.6955	12.3457	17.6658	
11	17.7641	5.0046	4.8994	14.6777	18.2054	20.5876	
12	17.8327	4.8377	4.7325	15.0206	18.3676	20.7111	
13	17.1468	4.8377	4.513	14.6091	18.2441	20.407	
14	22.7252	.2286	4.4559	14.0604	17.7893	20.1738	4.9474
15		4.6731	4.5656	13.9232	17.2839	20.0801	
16	5.7156	4.8925	4.6754	14.952	17.4349	20.3544	
17		5.0571	5.1143	20.3407	17.5149	20.503	5.1143
18	6.0997		5.3909	21.015	17.4875	20.7636	5.0571
19	4.1701		5.7179	23.4957	20.1349	23.6603	5.8299
20			5.3909	24.0032	20.9602	24.209	
21			5.2812	23.1939	20.7797	22.7297	5.2241
22			4.5656	20.1761	19.2022	19.7394	4.8691
23		4.2364	4.401	18.1597	18.1459	18.2716	
24	5.2789	3.7403	4.0169	17.5812	17.6498	17.7047	4.1861
Max	22.7252	5.0571	5.7179	24.0032	20.9602	24.209	5.8299
Min	4.1701	.2286	3.1345	12.7526	12.3457	13.1345	3.2991
Avg	14.9521	4.1577	4.6626	16.7668	16.6420	18.3294	4.3204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126]

BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 302 / 22 KV Dronagiri

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		2.0268		1.2839
20		2.2895		
24	1.6139		1.9892	
Max	1.6139	2.2895	1.9892	1.2839
Min	1.6139	2.0268	1.9892	1.2839
Avg	1.6139	2.1582	1.9892	1.2839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126] BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 303 / 22 KV Chirner

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		5.3351		2.9513
20		5.5999		
24	4.8053		5.2215	
Max	4.8053	5.5999	5.2215	2.9513
Min	4.8053	5.3351	5.2215	2.9513
Avg	4.8053	5.4675	5.2215	2.9513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

PANVEL URBAN DIVISION[031]

URAN[126] BU 0337

Substation No/ Name :- 223033 / 22/22 KV URAN SWITCHING

Feeder No / Name : 304 / 22 KV Industrial

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		1.6699		1.3663
20		1.6319		
24	1.7078		1.7837	
Max	1.7078	1.6699	1.7837	1.3663
Min	1.7078	1.6319	1.7837	1.3663
Avg	1.7078	1.6509	1.7837	1.3663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 201 / 11 KV Sector - 14

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8578				2.9912		2.934
3				2.4387			
4	2.6292						
5						2.4958	
6			2.4006	2.5339			2.7435
7	2.7054		2.8959		2.8197	3.1626	3.1055
8	2.8578		2.8197	2.7625	2.4958	3.2388	3.0674
9	2.6863				2.553	2.8197	2.7054
10				2.7435	2.7625	2.7244	2.6673
11		2.5149					2.7054
12				2.7244	2.8197		
13					2.7435		
14						2.6292	2.6101
15	2.5149	2.3815	2.2672	2.5149	2.7244		
16		2.4006	2.191	2.6101	2.7054		
17		2.4196	2.3053	2.6673	2.6673	2.5911	
18			2.3434	2.7816	2.6673	2.6673	2.5911
19	3.0864	3.1817	3.0674	3.3532	3.0483	3.2579	3.3532
20		3.7723	3.4865	3.7151	3.677	3.658	3.677
21	3.3341	3.4675	3.3722	3.5437	3.5246	3.5818	3.658
22	3.1245	3.2388	3.2769	3.3532	3.4294	3.4484	
23	3.0293	3.2579	3.2769		3.5627	3.5246	
24	2.915	2.8769	2.9912	3.0864	3.3532	3.3341	
Max	3.3341	3.7723	3.4865	3.7151	3.677	3.658	3.677
Min	2.5149	2.3815	2.191	2.4387	2.4958	2.4958	2.5911
Avg	2.8855	2.9512	2.8226	2.9163	2.9732	3.0810	2.9848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 202 / 11 KV Sector - 7

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957				2.4577		2.4196
3				1.9433			
4	1.848						
5						1.8861	
6			1.6385	1.7337			2.0386
7	2.0957		1.9052		1.9243	2.191	2.191
8	2.3243		2.1148	2.0386	1.9243	2.3434	2.2481
9	2.2862				2.0957	2.21	2.1529
10				2.1148	2.191	2.2291	2.1338
11		2.1148					2.0386
12				2.21	2.4006	2.1529	
13					2.3815		
14						2.1148	2.1148
15	1.829	1.8671	1.829	2.1338	2.2291		
16		1.8671	1.7909	2.1338	2.21		
17		2.0386	1.7909	2.1719	2.1719	1.9243	
18			1.848	2.3243	2.21	2.0576	2.0957
19	2.4387	2.4387	2.3434	2.572	2.4768	2.4768	2.6673
20		2.6863	2.5339	2.7625	2.7816	2.572	2.7816
21	2.5149	2.5911	2.5149	2.7625	2.7054	2.7054	2.8578
22	2.3243	2.4196	2.3243	2.572	2.7625	2.6673	
23	2.2481	2.3815	2.5149		2.8387	2.8578	
24	2.2862	2.1338	2.2672	2.3815	2.7244	2.7816	
Max	2.5149	2.6863	2.5339	2.7625	2.8387	2.8578	2.8578
Min	1.829	1.8671	1.6385	1.7337	1.9243	1.8861	2.0386
Avg	2.2083	2.2539	2.1089	2.2753	2.3815	2.3447	2.3117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 204 / 11 KV Sector -15

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953				.1905		.1715
3				.1334			
4	.1334						
5						.1334	
6			.1143	.1334			.1334
7	.1334		.1334		.1143	.1524	.1334
8	.1334		.1334	.1143	.1143	.1715	.1524
9	.1334				.1143	.1524	.1524
10				.1143	.1334	.1524	.1334
11		.0953					.1143
12				.1143	.1334	.1334	
13					.1334		
14						.1143	.1143
15	.0953	.0953	.0953	.1143	.1524		
16		.1143		.1143	.1524		
17		.1143	.0953	.1143	.1334	.1143	
18			.0953	.1143	.1334	.1143	.1143
19	.1715	.1715	.1524	.1905	.1334	.1143	.1334
20		.1905	.1905	.1905	.1524	.1715	.1905
21	.1524	.1715	.1524	.1715	.1905	.1715	.1905
22	.1524	.1715	.1524	.1905	.1905	.1715	
23	.1524	.1524	.1715		.2096	.1905	
24	.0953	.1524	.1524	.1715	.1905	.1905	
Max	.1715	.1905	.1905	.1905	.2096	.1905	.1905
Min	.0953	.0953	.0953	.1143	.1143	.1143	.1143
Avg	.1317	.1429	.1366	.1415	.1513	.1499	.1445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 205 / 11 KV Railway

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143				.1143		.1143
3				.0953			
4	.0953						
5						.0953	
6			.0953	.0953			.1143
7	.1143		.1143		.1143	.1143	.1143
8	.1143		.1143	.1143	.1143	.1334	.1143
9	.1143				.0953	.1334	.1143
10				.1143	.1143	.1143	.1143
11		.1143					.1143
12				.1143	.1143	.0953	
13					.1143		
14						.0953	.0953
15	.0953	.0953		.1143	.0953		
16		.1143	.0953	.1143	.1143		
17		.1143	.0953	.1143	.1143	.0953	
18			.1143	.1143	.1143	.1143	.0953
19	.1143	.0953	.0953	.1143	.1143	.1143	.1143
20		.1334	.1143	.1334	.1143	.0953	
21	.1143	.1143	.1143	.1143	.1143	.1143	.1143
22	.1143	.1143	.1143	.0953	.1143	.1143	
23	.1143	.1143	.1143			.1143	
24	.0953	.1143	.1143	.0953	.1143	.1143	
Max	.1143	.1334	.1143	.1334	.1143	.1334	.1143
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.1091	.1124	.1080	.1102	.1119	.1105	.1108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 206 / 11 KV Ajanta Sector -13

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953				.0953		.0953
3				.0953			
4	.0953						
5						.0953	
6			.0953	.0953			.0953
7	.1143		.0953		.0953	.0953	.0953
8	.1143		.0953	.0953	.0953	.0953	.0953
9	.1143				.0953	.0953	.0953
10				.0953	.0953	.0953	.0953
11		.0953					.0953
12				.0953	.1143	.0953	
13					.1143		
14						.0953	.0953
15	.0953	.0953	.0953	.0953	.1143		
16		.0953	.0953	.0953	.1143		
17		.0953	.0953	.0953	.1143	.0953	
18			.0953	.0953	.1143	.0953	.0953
19	.0953	.0953	.0953	.0953	.1143	.1143	.1143
20		.0953	.0953	.0953	.1143	.1143	.1143
21	.0953	.0953	.0953	.0953	.1143	.1143	.1143
22	.0953	.0953	.0953	.0953	.1143	.1143	
23	.0953	.0953	.0953		.1143	.1143	
24	.1143	.0953	.0953	.0953	.0953	.1143	
Max	.1143	.0953	.0953	.0953	.1143	.1143	.1143
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.1022	.0953	.0953	.0953	.1076	.1029	.1001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 207 / 11 KV Sector - 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.934				3.0674		3.0293
3				2.5149			
4	2.7054						
5						2.6101	
6			2.553	2.6482			2.915
7	2.8578		3.2007		2.9912	3.5437	3.6008
8	3.3532		3.3913	2.9912	2.8387	3.4484	3.5246
9	3.296		3.1626		2.8578	3.2007	3.296
10				2.8959	2.934	3.1245	3.2388
11		2.934					2.9912
12				3.0102	3.0483	2.9721	
13					3.1436		
14						2.8959	2.8387
15	2.5149	2.6101	2.4768	2.7435	2.7244		
16		2.553	2.4387	2.915	2.7054		
17		2.7625	2.5339	2.934	2.6673	2.4768	
18			2.4958	2.9912	2.7054	2.8006	2.7625
19	3.1245	3.3532	3.2007	3.4675	3.2388	3.2388	3.3532
20		3.9057	3.658	3.7532	4.1343	3.5627	3.677
21	3.5437	3.7723	3.5246	3.7913	3.6199	3.6199	3.9628
22	3.2579	3.3722	3.4484	3.5246	3.5818	3.5437	
23	3.1436	3.315	3.315		3.6008	3.5818	
24	3.0102	2.8769	3.1436	3.0674	3.4103	3.4484	
Max	3.5437	3.9057	3.658	3.7913	4.1343	3.6199	3.9628
Min	2.5149	2.553	2.4387	2.5149	2.6673	2.4768	2.7625
Avg	3.0674	3.1455	3.0388	3.0892	3.1335	3.2045	3.2658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 208 / 11 KV Sector-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526				1.1812		1.0288
3				.8002			
4	.7621						
5						.8573	
6			.743	.7621			.8954
7	1.105		.8383		.8954	1.1622	1.0288
8	1.2003		1.105	1.0098	.9335	1.1812	1.105
9	1.1812		1.1241		1.0288	1.1431	1.2955
10				1.0479	1.0479	1.1431	1.2765
11		1.0288					1.0669
12				.9907	1.0288	1.105	
13		1.0288	.9145		1.0288	1.086	
14						.9335	.9145
15	.8002	.8573	.8002	.7621	.9145		.8954
16		.8002	.7621	.9335	.8764	.9145	
17		.7621	.7049	.9526	.8573	.8002	
18	.724		.7621	.9907	.8954	.8002	.8383
19	.9145	.8764	.9145	.9717	.9145	.9907	.9717
20		1.0288	.9526	1.0288	1.0288	1.0479	1.086
21	1.0098	.9907	1.0288	1.086	1.0669	1.0479	1.1241
22	.9717	.9907	1.0288	.9907	1.105	.9717	
23	.9907	1.0288	1.0479		1.2193	1.2574	
24	.9907	.9526	1.0288	1.086	1.2384	1.2765	
Max	1.2003	1.0288	1.1241	1.086	1.2384	1.2765	1.2955
Min	.724	.7621	.7049	.7621	.8573	.8002	.8383
Avg	.9669	.9405	.9170	.9581	1.0153	1.0423	1.0405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 283002 / 22/11 KV Airoli, Sec-15

S/Stn

Feeder No / Name : 301 / 22KV Diva Gaon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764				.9145		.9526
3				.7621			
4	.724						
5						.8383	
6			.7621	.8002			.8764
7	.9145		.8383		.9526	1.0288	.9907
8	.9907			.9526	.9526	.9907	.9526
9	.8383				.8764	.8764	.8764
10				.8002	.8764	.8002	.8002
11		.724					.7621
12					.8383	.7621	
13					.8002		
14						.724	.8002
15	.724	.6859	.6859	.7621	.8002		
16		.6859	.6859	.8002	.8002		
17		.7621	.6478	.7621	.8002	.724	
18			.6859	.8002	.8002	.7621	.8002
19	.9145	.9526	.9526	1.0669	1.0288	.9526	1.0288
20		1.105	1.0288	.8764	1.0288	1.1431	1.105
21	1.0288	1.105	1.0669	1.1431	1.1431	1.1431	1.1431
22	.9907	.9907	.9907	.9907	1.0669	1.0669	
23	.8764	1.0288	.9907		1.105	1.105	
24	.9145	.8764	.8764	.9526	1.0288	.9907	
Max	1.0288	1.105	1.0669	1.1431	1.1431	1.1431	1.1431
Min	.724	.6859	.6478	.7621	.8002	.724	.7621
Avg	.8903	.8916	.851	.8823	.9302	.9272	.9240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 301 / 22 KV KALWA - I

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.738	3.7037	3.6694	3.7723	3.9438	4.4239	3.6694
2	3.8066	3.5665	3.4637	3.6694	3.7723	4.0124	3.5322
3	3.6694	3.4637	3.6008	3.6008	3.6694	3.738	3.4637
4	3.6008	3.4294	3.6694	3.5322	3.5665	3.3951	3.3951
5	3.4637	3.6008	3.6694	3.3951	3.4637	3.0521	3.6351
6	3.738	3.9781	3.8752	3.6694	3.4979	3.4294	3.9438
7	3.8752	4.1152	3.9438	3.9438	3.7723	3.4637	4.2524
8	4.0124	4.321	4.0809	4.0466	4.1152	3.5322	4.321
9	3.9781	3.7723	4.1152	3.8752	4.2867	3.6008	3.8066
10	3.4979	3.4979	3.5322	3.5665	4.1152	3.4637	3.4294
11	3.2579	3.2236	3.4637	3.4294	4.0124	3.4294	3.3608
12	2.9835	3.1207	3.2922	3.155	3.738	3.1893	3.155
13	3.1207	3.4637	3.0521	3.155	3.3608	2.9492	3.1207
14	3.0178	4.0124	3.8409	3.0864	3.2236	3.0521	3.0864
15	2.915	3.8752	3.738	3.0864	3.3608	3.0864	3.0178
16	2.9835	3.738	3.7723	3.1893	3.3265	3.0178	2.8807
17	3.0521	4.0124	3.8752	3.2579	3.2922	3.0864	3.0521
18	3.1893	4.1495	3.9438	3.4294	3.3608	3.5322	3.3608
19	4.1838	4.2181	5.1783	4.3896	4.3896	4.2867	4.321
20	4.4925	4.4239	4.4239	4.7668	4.7668	4.5268	4.6639
21	4.4582	4.3896	4.5268	4.7325	4.7325	4.6982	4.7325
22	4.4582	4.4582	4.4925	4.6296	4.7668	4.8011	4.7325
23	4.321	4.321	4.1838	4.3896	4.4925	4.4925	4.5953
24	3.9095	3.8066	3.738	3.8752	4.0809	4.321	3.8157
Max	4.4925	4.4582	5.1783	4.7668	4.7668	4.8011	4.7325
Min	2.915	3.1207	3.0521	3.0864	3.2236	2.9492	2.8807
Avg	3.6551	3.8609	3.8809	3.7351	3.8795	3.6909	3.7227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 302 / 22 KV Airoli - I

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4348	2.7435	2.7092	2.7778	2.8807	2.4348	2.9492
2	2.332	2.6406	2.7778	2.915	2.7435	2.572	2.915
3	2.2291	2.572	2.6749	2.6749	2.6749	2.6406	2.7092
4	2.6406	2.6749	2.572	2.6063	2.0576	2.7092	2.0233
5	2.7778	2.0576	2.3663	2.6406	1.989	2.7778	1.9547
6	2.9835	1.989	2.4348	2.4006	1.8176	3.0521	2.2291
7	3.1893	2.7778	2.5377	1.989	2.1262	3.3951	2.4348
8	3.2579	2.6063	2.6063	2.0576	1.8519	3.4637	2.8807
9	3.4294	3.0178		2.1262	1.7147	3.5322	2.9492
10	2.8807	3.155	2.7778	2.0576	1.8176	3.6008	3.0521
11	3.155	3.4979	3.0521	2.1948	1.8861	3.6694	3.155
12	3.2579	3.4637	2.7435	2.5377	1.9547	3.4637	3.2236
13	2.9492	3.6694	2.7778	2.332	2.0576	3.3608	3.7037
14	3.3608	3.7723	2.8464	2.1948	1.989	3.6351	3.2236
15	3.0178	3.738	2.9492	2.6749	2.0233	3.8409	3.3608
16	3.3608	3.6694	3.0178	2.332	2.0919	3.9438	3.4979
17	4.0466	3.8066	3.3265	2.2291	2.2977	4.0466	3.8409
18	3.6351	3.9438	3.5322	2.6063	2.4691	3.8066	3.6694
19	3.7037	3.8409	3.4294	2.6749	2.4348	3.7037	3.7037
20	3.8752	3.738	3.2579	2.8807	2.3663	3.2579	3.4294
21	2.8121	2.8807	3.0178	2.2291	2.2977	2.8807	3.2579
22	2.7778	2.7778	2.5377	2.1605	2.3663	3.1893	2.6749
23	3.2922	2.7092	3.1207	2.5377	2.4348	3.2579	2.9492
24	2.3663	2.8807	2.572	2.7092	2.1948	2.6063	2.6406
Max	4.0466	3.9438	3.5322	2.915	2.8807	4.0466	3.8409
Min	2.2291	1.989	2.3663	1.989	1.7147	2.4348	1.9547
Avg	3.0736	3.1093	2.8538	2.4391	2.1891	3.2850	3.0178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 303 / 22 KV Airoli - II

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.8916	.8916	.8916	1.0288	1.0631	.9945
2	.9602	.823	.6859	.7888	.7545	1.0974	.9602
3	1.0288	.823	.7545	.7888	.7545	.8916	.8573
4	1.0974	.8916	.823	.6859	.823	.7545	.7545
5	1.166	.9602	.823	.7202	.8916	.823	.7888
6	.9259	1.0288	.7545	.8916	.8916	.8916	.8916
7	.9945	.9602	.8916	.9602	.9945	.9602	.9945
8	1.0631	.9602	.8916	1.0288	.9602		.9602
9	.8573	.8916	.9602	.8573	.9602	.9945	.9602
10	.9259	.9602	.9259	.9259	.9602	.8916	.9602
11	.5487	.8916	.8573	.8916	.8916	.9602	.8916
12	.823	.823	.7888	.8573	.9602	.8573	.8573
13	.7545	.8916	.7202	.823	1.0631	.7545	.7888
14	.7888	.9602	.7545	.823	.9945	.7888	.7545
15	.7545	1.0288	.6859	.823	.8916	.823	.7888
16	.7545	1.0974	.7888	.823	.7545	.7888	.7545
17	.7545	.9945	.7545	.823	.9259	.7545	.7888
18	.7888	1.0631	.7202	.823	.8573	.9259	.823
19	.9602	1.0974	.7202	1.0974	.9259	1.0974	1.0288
20	1.0974	1.166	1.0631	1.2346	1.0631	1.166	1.1317
21	1.0974	1.166	1.1317	1.2003	1.2346	1.2346	1.2003
22	1.0974	1.0974	1.0974	1.166	1.0631	1.2003	1.2346
23	1.0631	1.0288	1.0631	1.166	1.0974	1.166	1.166
24	1.0288	.9602	.9602	.9945	1.0974	1.1317	1.0974
Max	1.166	1.166	1.1317	1.2346	1.2346	1.2346	1.2346
Min	.5487	.823	.6859	.6859	.7545	.7545	.7545
Avg	.9259	.9774	.8545	.9202	.9516	.9572	.9345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 304 / 22 KV Rabale MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3951	3.2922	3.3265	3.155	3.0178	3.1207	3.3608
2	3.4637	3.2236	3.2922	3.0864	2.9835	3.0864	3.1893
3	3.3608	3.0864	3.3951	3.0521	2.915	3.0521	3.0864
4	3.4637	3.1207	3.4294	3.0178	2.8807	3.0864	3.0178
5	3.4637	3.1893	3.2236	2.9492	2.915	3.1207	3.0864
6	3.8409	3.2579	3.3265	2.8807	2.8464	3.6694	3.155
7	4.4239	3.1893	3.4637	2.8121	3.0178	3.8066	3.2236
8	4.4925	3.8066	3.4979	3.3265	3.3265	4.3553	4.1152
9	4.6296	5.0412	3.4294	3.7037	3.8409	4.4925	4.3553
10	5.5213	5.8985	3.8752	4.5268	4.4925	5.1097	6.5158
11	5.8299	6.31	3.9781	4.9383	4.4239	5.2469	6.8587
12	6.07	6.1386	3.738	4.904	4.4925	5.7956	6.9273
13	4.7325	6.2071	3.7037	3.8066	4.4582	4.0466	5.144
14	6.0014	6.3443	3.738	4.9726	4.4239	5.0755	6.31
15	6.31	6.1386	3.7037	5.1097	4.4582	5.2469	6.3786
16	6.0014	5.8642	3.7723	5.0755	4.4239	5.5899	6.5158
17	6.0357	5.6584	3.6351	5.0069	4.1495	6.0357	6.1043
18	5.2126	5.4527	3.4979	4.1495	3.5322	4.5268	5.487
19	5.0755	5.3841	3.5665	3.9095	3.4637	5.1783	5.2812
20	4.3896	4.4239	3.4979	3.6008	3.5665	4.8354	4.6296
21	4.2524	3.9438	3.4294	3.3265	3.4979	4.1152	4.1838
22		3.738	3.2579	3.1893	3.4294	3.8066	3.8409
23	3.3608	3.6694	3.2922	3.0178	3.3608	3.5665	3.6008
24	3.3265	3.3951	3.3608	3.2236	3.0864	3.2236	3.4637
Max	6.31	6.3443	3.9781	5.1097	4.4925	6.0357	6.9273
Min	3.3265	3.0864	3.2236	2.8121	2.8464	3.0521	3.0178
Avg	4.6371	4.5739	3.5180	3.7809	3.6251	4.2996	4.6596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 305 / 22 KV Ghansoli

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.4815	5.487	5.7956	6.2757	5.7613	6.4815	6.1043
2	6.2757	5.4184	6.0014	5.7613	5.144	6.07	5.8985
3	6.1386	5.2126	5.8642	5.5899	5.3155	5.727	5.7613
4	6.1043	5.144	5.7613	5.4184	5.7613	5.5213	5.5899
5	5.727	5.4184	6.0014	6.1386	5.8299	5.6584	6.1386
6	5.8642	7.1331	6.4472	6.7901	5.8985	5.4527	7.1331
7	6.2071	7.6132	6.5158	7.6818	6.9273	5.5213	7.9218
8	6.4129	7.5446	6.653	7.5446	7.6475	5.487	7.7161
9	6.7215	6.7215	6.8587	6.6873	7.5446	5.5899	6.7215
10	5.8985	5.8299	5.5899	6.0357	6.9959	5.6584	5.9328
11	5.3155	4.8011	5.2812	5.487	6.8244	5.6927	5.2126
12	4.9726	5.1097	5.0412	5.2469	5.3841	5.1097	5.0412
13	4.7325	5.3841	4.8011	5.144	5.727	4.5953	4.9726
14	4.7325	5.487	4.7668		5.4527	4.6296	4.9726
15	4.7668	5.5213	4.6982		5.3155	4.6639	4.9383
16	4.8697	5.4527	4.8011	4.6296	5.4184	4.7325	4.9726
17	4.9383	5.5213	5.0069	5.6242	5.4527	4.8011	5.2469
18	5.2126	5.487	5.144	5.4527	5.6927	5.8985	5.6242
19	6.8587	6.9273	6.4129	6.8587	6.893	6.7215	7.1331
20	7.4074	7.4417	7.5446	7.5446	7.6818	7.6132	7.7504
21	7.4074	7.6818	7.3045	7.7504	7.4074	7.9561	7.7161
22	7.1331	7.1674	6.9959	7.4074	7.1674	7.5446	7.6132
23	6.5501	6.6873	6.2414	7.1674	7.0988	6.9616	7.0988
24	6.4129	5.7613	5.8299	6.07	6.4472	6.7558	6.2414
Max	7.4074	7.6818	7.5446	7.7504	7.6818	7.9561	7.9218
Min	4.7325	4.8011	4.6982	4.6296	5.144	4.5953	4.9383
Avg	5.9642	6.0814	5.8899	6.2867	6.2829	5.8685	6.2272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 306 / 22 KV Railway -II

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4801	.5144	.4801	.4801	.5144	.4801
2	.5144	.4801	.4801	.4801	.4801	.5144	.4801
3	.4801	.4801	.4801	.4801	.4801	.4801	.4801
4	.4801	.4801	.4801	.4801	.4801	.4801	.4801
5	.5144	.4801	.5144	.4801	.4801	.4801	.4801
6	.5144	.4801	.5144	.4801	.4801	.4801	.4801
7	.4801	.4801	.4801	.4801	.4801	.4801	.4801
8	.5144	.4801	.4801	.4801	.4801	.4801	.4801
9	.4801	.4801	.4801	.4801	.4801	.4801	.4801
10	.4801	.4801	.4801	.4801	.4801	.4801	.4801
11	.4801	.4801	.4801	.4801	.4801	.4801	.4801
12	.4801	.5144	.4801	.4801	.4801	.5144	.4801
13	.4801	.4801	.4801	.4801	.5144	.5487	.4801
14	.4801	.4801	.4801	.4801	.5144	.5144	.4801
15	.4801	.4801	.4801	.4801	.5144	.4801	.4801
16	.4801	.5144	.4801	.4801	.4801	.4801	.4801
17	.4801	.5144	.4801	.4801	.5144	.4801	.4801
18	.4801	.4801	.4801	.4801	.4801	.4801	.4801
19	.4801	.4801	.4801	.4801	.4801	.5144	.4801
20	.4801	.5144	.4801	.5144	.5144	.4801	
21	.4801	.4801	.4801	.4801	.4801	.4801	.4801
22	.4801	.5144	.4801	.4801	.5144	.4801	.4801
23	.4801	.4801	.4801	.4801	.4801	.4801	.4801
24		.4801	.5144	.4801	.4801	.4801	.4801
Max	.5144	.5144	.5144	.5144	.5144	.5487	.4801
Min	.4801	.4801	.4801	.4801	.4801	.4801	.4801
Avg	.4876	.4872	.4858	.4815	.4887	.4901	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 309 / 22 KV Railway -I

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989	1.6461	1.6461	1.6804	1.8519	1.989	1.8861
2	2.1262	1.5089	1.7147	1.5775	1.8176	1.9204	1.8176
3	2.0576	1.5775	1.7833	1.4746	1.7833	1.8519	1.749
4	1.8519	1.5432	1.6118	1.5432	1.8861	1.9547	1.7833
5	1.7833	1.6461	1.6804	1.6804	1.7833	2.0919	1.9547
6	2.0233	1.8861	1.7147	1.9204	1.7147	2.0233	2.0919
7	2.0919	1.9204	1.749	2.0919	1.989	2.0576	2.2291
8	1.8861	1.7833	1.6118	1.989	1.989	2.0919	1.8176
9	1.8519	1.7833	1.7833	1.8519	1.989	1.989	1.7833
10	1.6804	1.6461	1.5089	1.6461	1.6461	1.8519	1.5432
11	1.6461	1.7147	1.5432	1.7147	1.7147	1.749	1.6118
12	1.5775	1.6461	1.6118	1.6461	1.9204	1.7833	1.6461
13	1.5089	1.6461	1.5775	1.5432	1.9547	1.7147	1.7147
14	1.5775	1.7147	1.5432	1.749	1.8519	1.6118	1.7147
15	1.5775	1.8176	1.5775	1.7147	1.7147	1.5432	1.749
16	1.3717	1.9547	1.4403	1.6461	1.6118	1.6118	1.5775
17	1.5432	2.0576	1.4746	1.5432	1.6804	1.6461	1.6804
18	1.6118	1.989	1.4403	1.6461	1.749	1.7833	1.5775
19	1.8861	2.0233	1.8519	1.989	1.9547	1.8861	1.989
20	2.0919	1.989	1.989	2.2634	1.9204	2.0576	2.1948
21	1.9204	2.0576	2.1262	2.0919	2.2634		2.2977
22	2.1262	2.1262	2.1262	2.1948	1.989	2.332	2.3663
23	1.9204	1.8519	1.989	2.1948	2.0919	2.2634	2.2291
24	1.9547	1.749	1.7147	1.8861	1.989	2.1262	1.989
Max	2.1262	2.1262	2.1262	2.2634	2.2634	2.332	2.3663
Min	1.3717	1.5089	1.4403	1.4746	1.6118	1.5432	1.5432
Avg	1.8190	1.8033	1.7004	1.8033	1.869	1.9100	1.8747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641]

BU 4641

Substation No/ Name :- 288001 / 220/100/22 KV Kalwa SS

Feeder No / Name : 311 / 22 KV Cidco II

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.3717	1.3032	1.3032	1.0288	1.0631	1.0288
2	1.3375	1.3032	1.3375	1.2346	.9602	1.2003	.9945
3	1.406	1.2346	1.406	1.1317	.9259	1.0974	.9602
4	1.6118	1.3032	1.3717	1.2003	.9602	1.0974	1.0288
5	1.7147	1.3717	1.4746	1.166	1.0288	1.166	1.1317
6	1.6461	1.5775	1.5089	1.3032	1.1317	1.0631	1.2003
7	1.6804	1.6461	1.5432	1.4746	1.3717	1.1317	1.3032
8	1.749	1.6461	1.5775	1.5432	1.2003	1.2003	1.3375
9	1.7147	1.5432	1.4746	1.5089		1.2346	1.7147
10	1.7833	1.6118	1.3717	1.5089	1.2003	1.166	1.5432
11	1.5089	1.7147	1.3032	1.7147	1.2346		1.4403
12	1.4746	1.6461	1.2346	1.2689	1.0288		1.5089
13	1.3717	1.6118	1.166	1.1317	1.0974	1.3032	1.4403
14	1.4403	1.6461	1.1317	1.2003	1.0631	1.166	1.5432
15	1.3032	1.5089	1.0974	1.2346	1.0974	1.0631	1.3375
16	1.4403	1.4403	1.0631	1.166	1.0288	1.0288	.9602
17	1.5089	1.5775	1.0974	1.0974	.9945	1.0974	1.2689
18	1.3032	1.5089	1.1317	1.0974	1.166	1.166	1.0974
19	1.5089	1.406	1.3375	1.3032	1.2346	1.2346	1.406
20	1.7147	1.4403	1.3717	1.4403	1.2689	1.3717	1.406
21	1.6804	1.5089	1.5089	1.166	1.3375	1.5089	1.3717
22	1.6118	1.6118	1.6461	1.4403	1.2689	1.5775	1.5432
23	1.5432	1.5432	1.406	1.2003	1.2003	1.1317	1.166
24	1.4746	1.406	1.3717	1.406	1.0288	1.166	1.1317
Max	1.7833	1.7147	1.6461	1.7147	1.3717	1.5775	1.7147
Min	1.3032	1.2346	1.0631	1.0974	.9259	1.0288	.9602
Avg	1.5446	1.5075	1.3432	1.3017	1.1242	1.1925	1.2860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288068 / 220/100/22 KV Patani

Knowledge

Feeder No / Name : 302 / 22 KV KALWA - II

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	28-FEB-17
HR	Load (MW)
24	.4564
Max	.4564
Min	.4564
Avg	.4564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

AIROLI S/DN.[641] BU 4641

Substation No/ Name :- 288068 / 220/100/22 KV Patani

Knowledge

Feeder No / Name : 311 / PATNI COMPUTER SYSTEM LTD. NON SHEDDABLE EXPRESS HV FEEDERS
- I Feeder KV- 22 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	28-FEB-17
HR	Load (MW)
24	2.1719
Max	2.1719
Min	2.1719
Avg	2.1719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 202 / 11 KV Reliance

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.6028	1.1607	.628	.6249	.6158	
2	.6066	.5906	.6295	.6059	.6051	.5959	
3	.599	.5777	.6135	.5937	.5982	.5883	
4	.6097	.5784	.6043	.5944	.6036	.5845	
5	.6203	.5967	.6302	.6173	.5853	.6051	
6	.6516	.6341	.6363	.6356	.6081	.6691	
7	.6943	.6828	.679	.66	.6379	.6889	
8	1.3687	1.323	.7148	1.3077	.6607	.6904	
9	1.7268	.8253	1.8511	.6836	.6302	.8474	
10	1.054	1.0067	.9884	.7727	.5967	1.1172	
11	1.0883	2.0835	1.0677	.7918	.6203	1.1309	1.1431
12	1.07	1.0448	2.031	.7758	.6226	2.2542	1.1431
13	1.0395	.9816	1.9776	.7644	.5937	2.143	1.0098
14	.9846	2.066	.9663	.7156	.6028	1.054	1.105
15	1.0783	1.1142	1.0989	.7552	.5982	1.1904	
16	1.0913	1.0982	1.0905	.7308	.5975	1.1591	
17	2.0866	2.1819	1.9471	.7011	.5998	1.1378	
18	1.0159	1.0799	1.009	.6882	.6325	1.1058	
19	1.0311	.8169	.9671	.7735	.7377	1.102	
20	.9922	1.0273	.9435	.7872	.7522	1.0334	
21	.833	.8657	.8284	.7407	.7316	.8954	
22	.7461	.8017	.7583	.708	.6965	.791	.6668
23	.6935	.7545	.7141	.6813	.6783	.7506	.6097
24	1.1645	1.1934	1.6621	1.201	.6325	.6973	
Max	2.0866	2.1819	2.031	1.3077	.7522	2.2542	1.1431
Min	.599	.5777	.6043	.5937	.5853	.5845	.6097
Avg	.9781	1.0220	1.0654	.7464	.6353	.9770	.9463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 203 / 11 KV Mastek MBP s/stn NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4191			
8	.6859	.9907		.4382		
9	.7811					
11		.9526				1.0288
12			.9717		1.086	1.0288
13					1.1241	.9526
14		.9526				1.1622
17	1.086	.9145	.6478			
22						.4954
23						.4572
24	.4191	.4001	.4001	.4001		
Max	1.086	.9907	.9717	.4382	1.1241	1.1622
Min	.4191	.4001	.4001	.4001	1.086	.4572
Avg	.7430	.8421	.6097	.4192	1.1051	.8542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 204 / 11 KV Hexaware MBP s/stn NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3338	.6066	.346	.2736	.2789	
2	.3353	.3094	.3285	.3429	.2759	.2843	
3	.3452	.2972	.3254	.3445	.2858	.2911	
4	.3452	.3048	.3117	.3422	.2873	.2896	
5	.3178	.2987	.2751	.3346	.2843	.2896	
6	.2782	.2766	.2637	.2942	.285	.2888	
7	.4199	.4024	.3955	.3445	.266	.3559	
8	.9907	1.137	.6066	.8467	.2698	.6059	
9	1.5234	.823	1.454	.4992	.2843	.9899	
10	.8223	.8299	.8276	.5182	.2911	1.0311	
11	.8528	1.589	.8284	.5838	.3117	1.0258	.8573
12	.8665	.8993	1.6911	.7202	.3269	1.9928	.9526
13	.9168	.9678	.9046	1.2597	.3018	2.1209	.9907
14	.9206	.9793	.9275	1.2635	.3071	1.0921	.9526
15	.932	.9473	.8962	1.3039	.3125	1.0692	
16	.9549	.9724	.9229	1.0296	.3132	1.0921	
17	1.8587	.9709	1.464	.6165	.3109	1.0616	
18	.897	.647	.8939	.471	.3033	.9328	
19	.7674	.7865	.6783	.4092	.2904	.8337	
20	.5037	.5213	.5617	.3323	.3056	.5251	
21	.506	.4702	.4885	.3269	.3048	.4672	
22	.4214	.3963	.3986	.3185	.2926	.407	.3429
23	.3551	.362	.3711	.3003	.2896	.4009	.3239
24	.6454	.6485	.663	.6416	.2865	.3696	
Max	1.8587	1.589	1.6911	1.3039	.3269	2.1209	.9907
Min	.2782	.2766	.2637	.2942	.266	.2789	.3239
Avg	.7127	.6738	.7119	.5746	.2942	.7540	.7367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 205 / 11 KV Life Cycle

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3094	.3178	.644	.2957	.3155	.2713	
2	.2896	.2964	.3163	.2888	.3048	.269	
3	.2964	.2911	.3132	.2812	.285	.2553	
4	.2515	.2629	.2721	.2416	.2553	.2324	
5	.269	.2698	.2766	.2522	.3216	.2355	
6	.3711	.3749	.3483	.349	.3048	.3452	
7	.3696	.3452	.3483	.3361	.3086	.3551	
8	.8093	.7552	.4039	.3696	.3399	.4412	
9	.9922	.4946	.8931	.3894	.3567	.5502	
10	.5761	.5434	.5251	.4298	.3696	.602	
11	.6089	1.0783	.5258	.4207	.3704	.5967	.5525
12	.6135	.5693	1.022		.3772	1.2369	.5716
13	.57	.5266	.5152		.3795	1.2117	.6097
14	.6165	.5731	.5289		.3925	.6386	.5906
15	.5975	.5959	.5274		.397	.6447	.6097
16	.6142	.5617	.5289	.4123	.3765	.6272	
17	1.0921	.5761	.9769	.4283	.3635	.5868	
18	.5304	.5068	.506	.4153	.3681	.5373	
19	.5517	.5091	.4862	.4611	.3727	.5411	
20	.5014	.4854	.506	.4611	.3589	.4877	
21	.5014	.4313	.4451	.4351	.349	.4283	
22	.4885	.4024	.407	.4176	.3437	.4092	.381
23	.4512	.3742	.346	.407	.3201	.3475	.3429
24	.7232	.7148	.6402	.7225	.2934	.3231	
Max	1.0921	1.0783	1.022	.7225	.397	1.2369	.6097
Min	.2515	.2629	.2721	.2416	.2553	.2324	.3429
Avg	.5414	.4940	.5126	.3907	.3427	.5073	.5226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 206 / 11 KV Aptech

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2919	.2827	.5837	.2675	.2401	.2599	
2	.2873	.2751	.5365	.266	.2393	.2561	
3	.2881	.2736	.2766	.2782	.2492	.2515	
4	.2751	.2721	.2736	.2782	.2469	.2507	
5	.2759	.2759	.2736	.2667	.2446	.2454	
6	.4862	.4595	.4832	.2606	.253	.6226	
7	.6219	.6043	.6219	.3536	.2561	.7057	
8	1.3558	1.3252	.7293	.8078	.2545	.8017	
9	1.5867	.8147	1.6956	.4649	.2698	.9145	
10	1.0143	.9625	.9808	.6234	.2843	1.1652	
11	1.0814	2.0309	1.0684	.618	.3201	1.2216	1.0669
12	1.1309	1.1309	2.1567		.3056	2.447	1.1431
13	1.1142	1.1523	1.1675		.3109	2.5004	1.2003
14	1.1286	1.1606	1.166		.33	1.3032	1.1622
15	1.2003	1.217	1.2102		.3323	1.3154	
16	1.1896	1.1919	1.1827	.5586	.3483	1.323	
17	2.1758	1.185	1.9128	.5655	.3117	1.2513	
18	1.0273	.7583	1.0181	.4466	.298	1.1241	
19	.7895	.7644	.868	.4016	.2926	1.0174	
20	.6897	.6661	.7087	.3498	.2881	.7697	
21	.5784	.5373	.5914	.3239	.2797	.6097	
22	.4816	.4169	.4725	.2911	.2743	.519	.381
23	.3231	.3346	.3399	.2827	.2667	.3856	.381
24	.5609	.5616	.6203	.5373	.266	.33	
Max	2.1758	2.0309	2.1567	.8078	.3483	2.5004	1.2003
Min	.2751	.2721	.2736	.2606	.2393	.2454	.381
Avg	.8314	.7772	.8724	.4121	.2818	.8996	.8891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 207 / 11 KV ML Tower

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0937	.093	.1867	.0922	.093	.093	
2	.0937	.093	.0922	.0922	.093	.093	
3	.0937	.0945	.0922	.0922	.0922	.0922	
4	.0937	.093	.0914	.0922	.0922	.0922	
5	.0937	.093	.0914	.0922	.0922	.0922	
6	.1006	.0953	.1059	.0953	.0922	.1044	
7	.1189	.1174	.1212	.1151	.0876	.1174	
8	.5426	.4824	.2507	.5151	.0846	.2751	
9	.5175	.2538	.5151	.253	.0861	.282	
10	.2622	.2576	.2683	.2789	.0854	.2949	
11	.269	.541	.266	.2736	.0884	.3064	.2858
12	.2721	.2782	.5365		.0892	.6073	.3048
13	.2812	.2896	.2705		.0876	.5883	.2667
14	.282	.2911	.2865		.0899	.3071	.2858
15	.2904	.2827	.2774		.0884	.3048	
16	.2835	.2743	.2766	.3025	.0869	.2896	
17	.5273	.2583	.4092	.2629	.0861	.2705	
18	.1859	.1296	.1631	.1509	.0884	.157	
19	.157	.125	.1532	.1296	.096	.1425	
20	.1227	.1189	.1158	.1166	.096	.1196	
21	.1196	.1135	.1128	.0945	.0953	.1082	
22	.096	.0991	.0945	.0953	.0945	.0945	.0953
23	.093	.0914	.0953	.096	.0922	.0945	.0953
24	.1898	.1875	.1875	.1875	.093	.093	
Max	.5426	.541	.5365	.5151	.096	.6073	.3048
Min	.093	.0914	.0914	.0922	.0846	.0922	.0953
Avg	.2158	.1981	.2108	.1714	.0904	.2092	.2223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 208 / 11 KV core project

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3384	.3285	.6653	.3109	.3224	.333	
2	.3346	.3254	.3048	.3064	.3216	.3277	
3	.3315	.3185	.3056	.3079	.317	.33	
4	.3315	.3208	.3033	.3048	.3147	.3338	
5	.3277	.3185	.3086	.3079	.3208	.3208	
6	.3292	.3201	.3064	.3125	.3254	.3262	
7	.3231	.3155	.3025	.3117	.3559	.3475	
8	.7339	.6165	.3033	.7262	.4207	.4786	
9	.8406	.317	.6889	.4915	.4931	.5136	
10	.4527	.3277	.3079	.5677	.5266	.5274	
11	.4733	.4572	.3094	.5792	.5205	.5296	.5335
12	.4679		.7926	.6043	.5479	1.0936	.5144
13	.4854		.3315	.5738	.5594	1.1111	.5525
14	.49		.3307	.5822	.5662	.5472	.5525
15	.4969	.3086	.3262	.5677	.5601	.5746	
16	.5121	.3216	.3277	.5502	.5533	.5373	
17	.9587	.3285	.7286	.4908	.503	.5327	
18	.4252	.3216	.3231	.4809	.4428	.4504	
19	.3887	.3178	.3125	.4207	.4336	.4085	
20	.3528	.3003	.3125	.3856	.3887	.3849	
21	.3628	.3064	.3102	.3742	.3765	.381	
22	.3628	.3048	.3147	.3612	.3658	.3559	.381
23	.3429	.3064	.3064	.3246	.3307	.33	.3239
24	.6645	.6066	.6531	.6416	.3384	.8771	
Max	.9587	.6165	.7926	.7262	.5662	1.1111	.5525
Min	.3231	.3003	.3025	.3048	.3147	.3208	.3239
Avg	.4636	.3518	.3948	.4535	.4252	.4980	.4763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 211 / 11 KV Rupa HT SS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2286			
8	.3429	.2286		.2286		
9	.3048		.3048			
11		.3048				.4572
12			.3429		.4763	.4572
13					.4382	.4382
14						.4191
15						.4572
17	.381		.381			
22						.3429
23						.362
24	.3048	.2286	.2286	.2667		
Max	.381	.3048	.381	.2667	.4763	.4572
Min	.3048	.2286	.2286	.2286	.4382	.3429
Avg	.3334	.254	.2972	.2477	.4573	.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 212 / 11 KV Rupa SS - 3

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4572			
8	.5716	.5716		.4954		
9	.6859		.6478			
11		.724				.8192
12			.6859		.8764	.8002
13					.7811	.8573
14						.8573
15						.8383
16						.8954
17	.8383		.5716			
22						.5335
23						.4763
24	.4191	.4572	.4572	.4954		
Max	.8383	.724	.6859	.4954	.8764	.8954
Min	.4191	.4572	.4572	.4954	.7811	.4763
Avg	.6287	.5843	.5639	.4954	.8288	.7597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 213 / 11 KV Rupa SS - 4

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.724			
8	.7049	.7621		.9145		
9	.8383		.9145			
11		1.105				1.2384
12			1.2193		1.2955	1.2574
13					1.2193	1.2384
14						1.1812
17	1.2193		1.0669			
22						.8573
23						.8383
24	.6287	.724	.724	.8764		
Max	1.2193	1.105	1.2193	.9145	1.2955	1.2574
Min	.6287	.724	.724	.8764	1.2193	.8383
Avg	.8478	.8637	.9297	.8955	1.2574	1.1018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283003 / 22/11KV MBP, Mahape S/Stn

Feeder No / Name : 214 / 11 KV Rupa SS - 6

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0762			
8	.0953	.0953		.1143		
9	.1143	.1715	.1334			
11						.3239
12			.1715		.4191	.4382
13					.4191	.4382
14						.4382
17	.1715		.1905			
22						.1334
23						.1143
24	.0762	.0762	.0762	.0953		
Max	.1715	.1715	.1905	.1143	.4191	.4382
Min	.0762	.0762	.0762	.0953	.4191	.1143
Avg	.1143	.1143	.1296	.1048	.4191	.3144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 301 / 22 Kv O/G Indian Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905			.1905		.381
2		.1905			.1905		.381
3		.1905			.1905		.381
4		.1905			.1905		.381
5		.1905			.1905		.381
6		.1905			.3048		.1905
7		.1905			.1905		.1905
8	.1905	.1905		.1905	.1905	.1905	.1905
9			.1905	.1905		.1905	.1905
10				.1905		.1905	.1905
11				.1905		.1905	
12				.1905	.1905	.1905	.1905
13				.1905		.1905	.1905
14				.1905		.1905	.1905
15				.1905		.1905	.1905
16				.1905	.1905	.1905	.1905
17	.1905			.1905		.1905	.1905
18				.1905		.1905	
19	.1905			.1905		.1905	
20	.1905			.1905	.1905	.1905	
21	.1905		.1905	.1905		.1905	
22	.1905			.1905		.1905	
23	.1905			.1905	.1905	.381	.1905
24	.1905	.1905		.1905	.1905		.381
Max	.1905	.1905	.1905	.1905	.3048	.381	.381
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.1905	.1905	.1905	.1905	.1993	.2024	.254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 302 / 22 Kv L&T I

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	27-FEB-17
HR	Load (MW)
16	5.7156
Max	5.7156
Min	5.7156
Avg	5.7156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 303 / 22Kv O/G Electronic Sadan NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7621			.7621		.7621
2		.7621			.7621		1.9052
3		.7621			.7621		.7621
4		.7621			.7621		.7621
5		.7621			.7621		.7621
6		.7621			.7621		.7621
7		.7621			.7621		
8	.7621	.7621		.7621	.7621	.7621	1.0669
9						1.1431	.9526
10				1.1431		1.5623	.9526
11				1.1431		1.5242	
12				1.1431	.7621	1.5242	1.1431
13				1.1431		1.5242	1.1431
14				1.1431		1.5242	1.1431
15				1.1431		1.5242	1.5242
16				1.1431	.7621	1.5242	1.7147
17	1.5242			1.1431		1.5242	1.7147
18	1.3336			1.1431		1.5242	
19	1.1431			1.1431		1.1431	
20	1.1431			.7621	.5716	1.1431	
21	.7621		.7621	.7621		1.1431	
22	.7621			.7621		.7621	
23	.7621			.7621	.5716	.7621	.7621
24	.7621	.7621		.7621	.7621		.7621
Max	1.5242	.7621	.7621	1.1431	.7621	1.5623	1.9052
Min	.7621	.7621	.7621	.7621	.5716	.7621	.7621
Avg	.9949	.7621	.7621	1.0002	.7328	1.2884	1.0938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 304 / 22Kv Hindustan Platinum NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381			.381		.381
2		.381			.381		.381
3		.381			.381		.381
4		.381			.381		.381
5		.381			.6859		.381
6		.381			.381		.381
7		.381			.381		.381
8	.381	.381		.381	.381	.1905	.381
9				.7621		.381	.7621
10				1.1431		.7621	.7621
11				1.1431		.7621	
12				1.1431		.7621	.7621
13				1.1431		.7621	.7621
14				1.1431		.7621	.7621
15				1.1431		.7621	.9526
16				1.1431		.7621	1.1431
17	1.1431			.5716		.7621	1.1431
18	.5716			.5716		.7621	
19	.5716			.381			
20	.5716			.381	.1905	.381	
21	.381		.381	.381		.381	
22	.381			.381		.381	
23	.381				.1905	.381	.381
24	.381	.381		.381	.381		.381
Max	1.1431	.381	.381	1.1431	.6859	.7621	1.1431
Min	.381	.381	.381	.381	.1905	.1905	.381
Avg	.5292	.381	.381	.7621	.3741	.5970	.6033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 305 / 22KV Repro Press

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381			.381		.381
2		.381			.381		.381
3		.381			.381		.381
4		.381			.381		.381
5					.381		
6					.381		.381
7					.381		.381
8	.381			.381	.381	.1905	.381
9				.381		.1905	.5716
10				.7621		.381	.5716
11				.7621		.381	
12				.7621	.381	.381	.5716
13				.7621		.381	.5716
14				.7621		.381	.5716
15				.7621		.381	.5716
16				.7621	.381	.381	.7621
17	.381			.7621		.381	.7621
18	.381			.381		.381	
19	.381			.381		.381	
20	.381			.381	.1905	.381	
21	.381		.381	.381		.381	
22	.381			.381		.381	
23	.381			.381	.1905	.381	.381
24	.381	.381		.381	.381		.381
Max	.381	.381	.381	.7621	.381	.381	.7621
Min	.381	.381	.381	.381	.1905	.1905	.381
Avg	.381	.381	.381	.5603	.3517	.3572	.4931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 306 / 22KV L&T - II

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381			.381		.381
2		.381			.381		.381
3		.381			.381		.381
4		.381			.381		
5		.381			.381		.381
6		.381			.381		.381
7		.381			.381		.381
8	.381	.381		.381	.381	.381	.381
9				.381		.381	.381
10				.381		.381	.381
11				.381		.381	
12				.381	.381	.381	.5716
13				.381		.381	.5716
14				.381		.381	.5716
15				.381		.381	.7621
16				.381	.381	.381	.7621
17	.5716			.381		.381	.7621
18	.5716			.381		.7621	
19	.5716			.381		.381	
20	.5716			.381	.381	.7621	
21	.5716		.381	.1905		.381	
22	.5716			.1905		.381	
23	.5716			.381	.381	.381	.381
24	.381	.5716		.381	.381		.381
Max	.5716	.5716	.381	.381	.381	.7621	.7621
Min	.381	.381	.381	.1905	.381	.381	.381
Avg	.5292	.4022	.381	.3586	.381	.4286	.4819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 307 / 22 kv CTRLS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3336			1.4098		1.4098
2		1.3336			1.4098		1.4098
3		1.3336			1.4098		1.4098
4		1.3336					1.4098
5		1.3336			1.4098		1.4098
6		1.3336			1.4098		1.4098
7		1.3336			1.4098		1.4098
8	1.2955	1.3336		1.3336	1.4098	1.4098	1.4098
9				1.3336		1.4098	1.4861
10				1.3336		1.4861	1.4861
11				1.3717		1.4861	
12				1.3717	1.4098	1.5242	1.5242
13				1.1431		1.5242	1.4861
14				1.1431		1.5242	1.4861
15				1.1431		1.5242	1.5623
16				1.1812	1.4098	1.5242	1.5242
17	1.0288			1.1812		1.5242	1.5242
18	1.0288			1.4861		1.4861	
19	1.3336			1.4861		1.448	
20	1.3336			1.4861	1.4098	1.448	
21	1.3336		1.3336	1.448		1.3717	
22	1.3336			1.448		1.3717	
23	1.3336			1.448	1.4098	1.3717	1.448
24	1.2955	1.3336		1.3336	1.4098		1.4098
Max	1.3336	1.3336	1.3336	1.4861	1.4098	1.5242	1.5623
Min	1.0288	1.3336	1.3336	1.1431	1.4098	1.3717	1.4098
Avg	1.2574	1.3336	1.3336	1.3336	1.4098	1.4646	1.4564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283004 / 22/22KV Mahape Swt/Stn

Feeder No / Name : 308 / 22 kv Electronic Zone
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2862			1.9052		2.6673
2		2.2862			1.9052		2.2862
3		2.2862			1.9052		2.2862
4		2.2862			1.9052		2.2862
5		2.2862			1.9052		2.2862
6		2.2862			1.9052		2.2862
7		2.2862			1.9052		2.2862
8	2.6673	2.2862		2.2862	1.9052	1.9052	2.2862
9				3.0483		3.0483	3.4294
10				4.5725		5.7156	3.8104
11				4.5725		5.7156	
12				4.5725	2.2862	5.7156	6.0966
13				4.5725		5.7156	6.0966
14				4.5725		5.7156	6.0966
15				4.5725		5.7156	5.7156
16				4.5725	2.2862		5.9061
17	5.3346			4.5725		5.7156	5.9061
18	4.5725			3.8104		5.3346	
19	3.8104			3.0483		4.1914	
20	2.6673			2.6673	1.9052		
21	2.6673		2.6673	2.6673		3.0483	
22	2.6673			2.6673		2.6673	
23	2.6673			2.6673	1.9052	2.6673	3.0483
24	2.6673	2.6673		2.2862	1.9052		2.6673
Max	5.3346	2.6673	2.6673	4.5725	2.2862	5.7156	6.0966
Min	2.6673	2.2862	2.6673	2.2862	1.9052	1.9052	2.2862
Avg	3.3024	2.3285	2.6673	3.6311	1.9638	4.4908	3.7469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 202 / 11KV KRISHNA TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6385	1.4403	1.9052	1.9433	1.4403	1.9052	1.8861
2	1.5623	1.3717	1.7147	1.829	1.3717	1.7147	1.7718
3	1.448	1.3032	1.5242	1.7147	1.3032	1.6385	1.6956
4	1.448	1.2003	1.5242	1.6004	1.2003	1.6385	1.6385
5	1.5242	1.2003	1.5623	1.6385	1.3032	1.7147	1.7147
6	1.6766	1.3717		1.6766	1.3717	1.7147	1.829
7	1.7528	1.8176	1.6385	1.7528	1.5432	1.9052	1.9243
8	1.9814	1.7833	1.6004	1.7718	1.5604	1.7909	1.6956
9	1.8861	1.9052	2.0195	1.7337	1.8004	1.7147	1.7661
10	1.4232	1.8861	1.6575	1.6385	1.5432	1.8671	1.6289
11	1.1488	1.4861	1.7147	1.6289	1.5242	2.0386	1.2346
12	1.0631	1.6766	1.7528	1.5432	1.6956	1.9814	1.3717
13	1.0288	1.448	1.7147	1.4403	1.7528	1.5051	1.4403
14	1.0117	1.448	1.6766	1.3717	1.6766	1.3908	1.3717
15	1.2003	1.7147	1.6004	1.3717	1.5242	1.5242	1.2174
16	1.4575	1.7337	1.448	1.5432	1.5242	1.6956	1.2003
17	1.5089		1.3146	1.6289	1.5242	1.6385	1.1488
18	1.5432	1.7147	1.7337	1.286	1.6004	1.7909	1.4403
19	1.6289	1.6956	1.1812	1.7147	1.9052	1.7337	1.6632
20	1.8519	1.8671	1.5813	1.9204	1.5242	1.6194	1.7833
21	1.9204	2.0195	2.0195	2.0405	1.829	1.829	1.989
22	1.6632	1.829	1.8099	1.8519	1.7909	1.7718	1.9547
23	1.4746	1.9814	2.0386	1.5775	1.9814	2.1719	1.7661
24	2.0005	1.7147	2.0005	2.0767	1.5432	1.9624	2.21
Max	2.0005	2.0195	2.0386	2.0767	1.9814	2.1719	2.21
Min	1.0117	1.2003	1.1812	1.286	1.2003	1.3908	1.1488
Avg	1.5351	1.6352	1.6840	1.6790	1.5764	1.7607	1.6393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 204 / 11KV Mathadi HTP

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7458	2.5347	2.7572	2.8533	2.8929	3.12	1.5623
2	2.5956	2.4105	2.5758	2.7023	2.6437	3.0103	1.4289
3	2.4478	2.2573	2.4798	2.4783	2.5141	2.8472	1.3527
4	2.4386	2.1414	2.4417	2.4325	2.4143	2.7786	1.2955
5	2.5499	2.1475	2.4996	2.5087	2.2771	2.7557	1.2955
6	2.8502	2.5202	2.6428	2.6871	2.4608	2.9447	1.3717
7	3.0384	2.9294	2.8761	2.7038	2.6506	3.1703	1.448
8	2.9973	2.8948	2.9889	2.9424	2.7382	3.1741	1.467
9	2.9141	2.8623	3.0369	2.7663	2.6787	2.8769	1.2689
10	2.5846	2.6398	2.8692	2.7641	2.8007	2.6566	1.166
11	2.3331	2.377	2.5956	2.5625	2.7641	2.46	1.046
12	2.1704	2.2695	2.271	2.4181	2.5919	2.3968	1.0288
13	2.0477	2.0713	2.1994	2.2466	2.4882	2.2344	.9774
14	2.053	2.0386	2.1094	2.178	2.5057	2.1658	.9945
15	2.0271	2.0363	2.1011	2.098	2.6093	2.2063	.9945
16	2.0454	2.1377	2.1826	2.2908	2.559	2.252	1.0288
17	2.2039	2.2017	2.2154	2.4303	2.524	2.3228	1.046
18	2.335	2.2573	2.2352	2.2862	2.4684	2.4227	1.3032
19	2.6734	2.9073	2.7815	2.6292	3.0087	2.9713	1.3889
20	2.8639	3.1999	2.7671	2.7991	3.0148	3.1923	1.4403
21	2.9241	3.0956	2.9203	2.9092	3.1207	3.1627	1.5261
22	2.7397	3.0377	2.9698	2.9507	3.2053	3.3219	1.406
23	2.8262	3.0834	3.0948	3.1047	3.4492	3.395	1.5261
24	2.9691	2.8182	2.9752	3.1322	3.1092	3.3806	1.6766
Max	3.0384	3.1999	3.0948	3.1322	3.4492	3.395	1.6766
Min	2.0271	2.0363	2.1011	2.098	2.2771	2.1658	.9774
Avg	2.5573	2.5362	2.6078	2.6198	2.7287	2.8008	1.2933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 205 / 11KV Sector-22&23

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2806	3.7708	4.2905	4.321	4.2798	4.8895	2.3053
2	4.0558	3.5665	4.0283	4.0444	3.9598	4.4551	2.1529
3	3.8714	3.3211	3.9963	3.8988	3.7982	4.3758	2.0195
4	3.8424	3.1276	3.943	3.8622	3.5536	4.292	2.0195
5	4.0017	3.2205	4.0268	3.9841	3.5277	4.356	2.0957
6	4.4292	3.9926	4.3057	4.3416	3.751	4.6715	2.3243
7	4.9917	4.6556	4.6944	4.6876	4.2631	5.0603	2.553
8	5.0183	4.7199	4.9581	4.7142	4.4673	5.0061	2.5149
9	4.4376	4.2707	4.6258	4.4825	4.4037	4.6502	2.0233
10	4.1069	3.911	2.2131	4.2517	4.1751	4.1198	1.7833
11	3.581	3.613	3.8531	3.7921	4.2029	3.7479	1.6118
12	3.2876	3.3623	3.4507	3.533	4.0063	3.5932	1.6118
13	3.1287	3.2304	3.2541	3.3356	3.8729	3.4172	1.5604
14	2.9584	3.1429	3.2099	3.2426	3.8005	3.3463	1.5432
15	3.0193	3.1657	3.1383	3.2594	3.7075	3.4286	1.4575
16	3.1318	3.1992	3.1954	3.3432	3.7662	1.7238	1.5432
17	3.2945	3.2907	3.2457	3.4522	3.7723	3.5025	1.6118
18	3.5528	3.3989	3.4362	3.5936	3.8455	3.6717	1.7833
19	4.0489	4.4048	4.2181	4.0741	4.6227	4.4414	2.0405
20	4.3286	4.6227	4.4468	4.3903	4.6883	4.6876	2.0576
21	4.4719	4.779	4.5968	4.6376	4.8911	4.8964	2.3663
22	4.337	4.779	4.6944	4.6799	4.8811	5.2447	2.2634
23	4.3123	4.8506	4.7843	4.6838	5.1654	5.269	2.332
24	4.5404	4.263	4.606	4.7416	4.6685	5.1555	2.5149
Max	5.0183	4.8506	4.9581	4.7416	5.1654	5.269	2.553
Min	2.9584	3.1276	2.2131	3.2426	3.5277	1.7238	1.4575
Avg	3.9595	3.8608	3.9672	4.0561	4.1696	4.2501	2.0037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 206 / 11 KV P-2 S/S

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0196	1.7482	2.098	2.0294	2.1559	2.3495	1.0669
2	1.8747	1.5943	1.9692	1.8633	2.021	2.1993	1.0098
3	1.7741	1.5189	1.8915	1.72	1.848	2.1132	.9907
4	1.7276	1.3939	1.8519	1.6278	1.7771	2.037	.9145
5	1.7344	1.3741	1.7185	1.5554	1.6522	1.8214	.8764
6	1.8526	1.5417	1.5615	1.5989	1.5531	1.7147	.8954
7	1.8488	1.6881	1.6598	1.5813	1.5672	1.8336	.9145
8	1.8511	1.6533	1.64	1.467	1.43	1.7757	.9335
9	2.0027	1.8778	1.7642	1.736	1.4716	1.6804	.8402
10	1.8937	1.9685	1.9486	2.1132	1.7669	1.9022	.8402
11	2.0111	1.9639	2.0736	2.1795	1.8602	2.1315	.9602
12	2.0668	1.9402	2.0958	2.1757	1.8435	2.0691	.9259
13	1.7402	1.8412	1.9463	2.0949	1.8755	2.0134	
14	1.8347	1.8427	1.9044	2.018	1.8549	1.9898	.8745
15	1.9135	1.9845	1.9539	2.1026	1.9182	2.0972	.9774
16	1.9593	1.97	2.0226	2.1312	1.9852	2.1338	.9774
17	2.0187	1.9662	2.1231	2.1015	2.0005	2.1536	.9774
18	2.066	2.098	1.9539	1.1622	1.9914	2.021	1.0288
19	2.1899	2.6558	2.2801	1.2689	2.399	2.4493	1.166
20	2.4242	2.5103	2.2017	1.2803	2.4135	2.4196	1.166
21	2.2032	2.3998	2.2519	1.2955	2.3373	2.3777	1.2003
22	2.1079	2.351	2.2961	2.4387	2.3403	2.4814	1.0974
23	2.0164	2.3838	2.4646	2.3338	2.4821	2.6193	1.1488
24	2.1102	2.0774	2.3228	2.3518	2.3007	2.5788	1.2193
Max	2.4242	2.6558	2.4646	2.4387	2.4821	2.6193	1.2193
Min	1.7276	1.3741	1.5615	1.1622	1.43	1.6804	.8402
Avg	1.9684	1.9310	1.9998	1.8428	1.9519	2.1234	1.0001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 207 / 11KV SECTOR-19

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8939	.8406	.8619	.9297	.868	.919	.4572
2	.8101	.7811	.7971	.8466	.7971	.8847	.4382
3	.7796	.7316	.788	.788	.7663	.8261	.4191
4	.769	.7232	.7834	.3902	.7232	.8146	.4191
5	.7788	.698	.8169	.7925	.7095	.852	.4382
6	.8946	.7986	.8878	.8261	.7659	.9586	.4763
7	.9404	.9953	.9831	.9213	.8695	1.0433	.4954
8	1.0486	.9919	1.025	.9747	.9256	1.035	.5335
9	.9633	.9785	.9571	.9777	.9111	.9526	.4458
10	.8261	.8734	.8314	.8703	.8596	.8162	.3944
11	.7228	.7148	.7811	.7594	.8474	.7918	.3258
12	.6988	.6889	.7514	.7404	.7925	.7674	.3258
13	.6466	.65	.6912	.7178	.794	.7362	.3429
14	.6024	.6386	.6439	.6805	.7728	.6889	.3429
15	.6127	.6355	.6234	.7	.7705	.6844	.3086
16	.6203	.6371	.6462	.7152	.8146	.7201	.3258
17	.6592	.6721	.7117	.7206	.8116	.7545	.3258
18	.7285	.7636	.714	.7777	.8314	.8208	.3429
19	.8954	.9885	.9289	.8703	1.025	1.0037	.4287
20	.9858	1.0486	.9984	.9511	1.0387	1.0875	.4801
21	1.0075	1.0555	1.0395	1.0181	1.0258	1.1028	.4973
22	.9206	1.0319	.9869	.9975	1.0631	1.1012	.4801
23	.9332	1.0342	1.0181	.9454	1.041	1.1134	.4801
24	.9419	.9134	.9449	1.0083	.9236	1.028	.5144
Max	1.0486	1.0555	1.0395	1.0181	1.0631	1.1134	.5335
Min	.6024	.6355	.6234	.3902	.7095	.6844	.3086
Avg	.8200	.8285	.8421	.8300	.8645	.8960	.4183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283025 / 22/11KV Koperkhairne S/Stn

Feeder No / Name : 208 / 11KV BEVERLY PARK -II
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1035	1.0536	1.0753	1.06	.9046	.9495	.5716
2	1.0441	.996	1.054	1.0106	.8314	.4954	.5144
3	.983	.9434	1.0235	.9449	.7704	.8489	.5144
4	.9693	.8291	.9908	.9282	.7598	.8245	.4954
5	1.0547	.8169	1.0593	.9961	.775	.852	.5144
6	1.1317	.996	1.1454	1.0837	.8314	.903	.5335
7	1.2956	1.2201	1.3032	1.0989	.9747	.9594	.5716
8	1.3207	1.1927	1.3535	1.185	1.0041	.9419	.6097
9	1.1759	1.1508	1.0997	1.1691	1.0768	.9381	.4458
10	1.0247	1.0456	.9374	1.1271	1.0379	.8619	.3772
11	.8337	.8916	.9686	1.0204	1.0273	.7949	.3772
12	.7994	.855	.08	.9114	1.0844	.7453	.4115
13	.7556	.8489	.9724	.9602	1.1195	.7834	.4115
14	.7648	.8131	.951	.9023	1.1698	.8032	.3772
15	.8283	.9061	.9297	.9678	1.1843	.7575	.3601
16	.8067	.8612	.8794	.9975	1.0822	.7201	.3429
17	.8052	.8405	.8337	1.0014	1.0852	.7346	.3429
18	.8192	.8558	.9267	.9922	.9914	.695	.3772
19	.8939	.9609	1.0243	1.0097	.5906	.8863	.4287
20	1.0646	1.1774	1.1081	1.0623	1.1645	1.1439	.4801
21	1.153	1.2285	1.1599	1.0521	1.1935	1.2254	.5487
22	1.0064	1.2224	1.1523	.998	1.089	.6478	.5144
23	1.1108	1.1866	1.1294	1.0041	1.0943	1.2544	.5658
24	1.1462	1.1195	1.1333	1.0517	.9968	1.1081	.5906
Max	1.3207	1.2285	1.3535	1.185	1.1935	1.2544	.6097
Min	.7556	.8131	.08	.9023	.5906	.4954	.3429
Avg	.9955	1.0005	1.0121	1.0223	.9933	.8698	.4699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 301 / 22 Kv SONY DADC

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3048	.2667	.2667	.3048	.2667	.381
2	.2286	.3048	.2667	.2667	.3048	.2667	.381
3	.2286	.2667	.2667	.2667	.3048	.2667	.381
4	.2286	.2667	.2667	.2667	.3048	.2667	.2667
5	.2286	.2667	.2667	.2667	.2667	.2667	.2667
6	.2286	.2667	.2667	.2667	.2667	.2667	.2667
7	.2286	.2667	.2667	.2667	.2667	.2667	.2667
8	.2286	.2667	.2667	.2667	.1905	.2667	.2667
9	.2667	.2667	.2667	.2667	.1905	.3048	.3048
10	.3048	.2667	.3048	.3429	.1905	.381	.3048
11	.3048	.2667	.3048	.4191	.1905	.381	.3048
12	.381	.3048	.3429	.381	.1905	.4191	.3048
13	.381	.3048	.3429	.381	.1905	.4191	.3048
14	.381	.3048	.3429	.381	.1905	.4191	.3048
15	.381	.3048	.3429	.381	.1905	.4191	.381
16	.381	.3048	.3429	.381	.2286	.4191	.381
17	.381	.3048		.381	.2286	.4191	.2667
18	.2286	.3048		.381	.2286	.4191	.2667
19	.2286	.3048		.2286	.2286	.4191	.2286
20	.1905	.2667		.1905	.2286	.2286	.2286
21	.1905	.2667		.1905	.2667	.2286	.2667
22	.1905	.2667		.2667	.2667	.2286	.2667
23	.2667	.2667		.3048	.2667	.2286	.3429
24	.3048	.3048	.2667	.2667	.3048	.2667	.381
Max	.381	.3048	.3429	.4191	.3048	.4191	.381
Min	.1905	.2667	.2667	.1905	.1905	.2286	.2286
Avg	.2746	.2842	.2936	.3032	.2413	.3223	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 302 / 22 KV BASF

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.3336	1.3336	1.3336	1.1431	.9526	.9526
2	1.1431	1.3336	1.1431	1.3336	1.1431	.9526	.9526
3	1.1431	1.3336	1.1431	1.3336	1.1431	.9526	.9526
4	1.1431	1.3336	1.1431	1.3336	1.1431	.9526	.9526
5	1.1431	1.3336	1.1431	1.3336	1.1431	.9526	.9526
6	1.1431	1.3336	1.1431	1.3336	1.1431	.9526	1.3336
7	1.3336	1.3336	1.1431	1.3336	1.1431	.9526	1.3336
8	1.5242	1.5242	1.3336	1.3336	1.1431	1.1431	1.3336
9	1.7147	1.3336	1.5242	1.5242	1.0288	1.5242	1.5242
10	1.7147	1.7147	1.5242	1.6004	1.1431	1.9052	1.9052
11	1.9052	1.9052	1.7147	1.3336	.9526	1.9052	2.0957
12	2.2862	2.0957	1.9052	1.6385	.9526	2.2862	1.9052
13	2.2862	1.7147	1.9052	1.5242	.9526	2.0957	1.9052
14	2.0957	1.7147	1.9052	1.2574	.9526	2.0957	1.9052
15	2.0957	1.9052	1.9052	1.448	.9526	2.0957	2.2862
16	2.0957	2.0957	1.9052	1.5242	1.1431	2.0957	1.9052
17	2.0957	2.0957		1.3336	.9526	2.0957	1.9052
18	1.7147	1.5242		1.3336	.9526	1.5242	1.5242
19	1.7147	1.5242		1.3336	.9526	1.5242	1.3336
20	1.5242	1.5242		1.2574	.9526	1.3336	1.3336
21	1.5242	1.3336		1.2574	.9526	1.1431	1.1431
22	1.3336	1.3336		1.2574	.9526	1.3336	1.1431
23	1.3336	1.3336		1.0669	.9526	1.3336	1.1431
24	1.1431	1.3336	1.3336	1.3336	1.1431	.9526	.9526
Max	2.2862	2.0957	1.9052	1.6385	1.1431	2.2862	2.2862
Min	1.1431	1.3336	1.1431	1.0669	.9526	.9526	.9526
Avg	1.5956	1.5559	1.4793	1.3622	1.0431	1.4606	1.4448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 303 / 22 KV EVEREST ANGAN

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8104	3.8104	3.8104	3.8104	3.8104	3.8104	4.1914
2	3.8104	3.8104	3.8104	3.8104	3.8104	3.8104	4.1914
3	3.8104	3.8104	3.8104	3.8104	3.8104	3.4294	4.1914
4	3.8104	3.8104	3.4294	3.4294	3.8104	3.4294	4.0009
5	3.8104	3.8104	3.4294	3.4294	3.4294	3.4294	4.0009
6	3.8104	3.8104	3.4294	3.4294	3.4294	3.4294	4.0009
7	3.8104	3.8104	3.4294	3.4294	3.2769	3.4294	3.8104
8	3.8104	3.8104	3.4294	3.4294	3.4294		3.8104
9	4.1914	4.1914	3.4294		3.4294	3.4294	3.8104
10	4.5725	4.5725	3.8104	4.382	3.4294	3.8104	4.5725
11	4.5725	4.763	3.8104	4.5725	3.4294	4.9535	4.9535
12	4.5725		3.8104	4.5725	3.8104	4.9535	4.9535
13	4.5725	3.658	3.8104	4.1914	3.4294	4.9535	4.5725
14	4.9535	4.9535	3.8104	4.5725	3.6199	5.3346	3.8104
15	4.9535	4.9535	3.8104	4.4963	3.6199	5.3346	4.5725
16	4.5725	4.9535	3.8104	4.382	3.8104	4.9535	4.5725
17	4.5725	4.9535		4.1914	3.8104	4.9535	4.1914
18	4.5725	4.1914		3.8866	3.6199	4.5725	4.1914
19	4.5725			2.6673	3.4294	4.5725	4.1914
20	4.1914	3.6199		4.1152	3.6199	4.5725	4.1914
21	4.1914	4.1914		3.8104	3.6199	4.5725	4.1914
22	3.8104	4.1914		3.8104	3.6199	4.1914	4.1914
23	3.8104	4.1914		4.0009	3.6199	4.1914	4.1914
24	3.8104	4.763	4.1914	3.4294	3.8104	3.6199	4.1914
Max	4.9535	4.9535	4.1914	4.5725	3.8104	5.3346	4.9535
Min	3.8104	3.6199	3.4294	2.6673	3.2769	3.4294	3.8104
Avg	4.2073	4.2105	3.6983	3.8982	3.6056	4.2494	4.2311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 304 / 22 KV BHAVKALESHWAR

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.9052	2.2862	2.2862	2.0957	1.9052	1.9052
2	1.9052	1.9052	1.9052	1.9052	2.0957	1.9052	1.9052
3	1.9052	1.9052	1.9052	1.9052	2.0957	1.9052	1.9052
4	1.9052	1.9052	1.9052	1.9052	2.0957	1.9052	1.9052
5	1.9052	1.9052	1.9052	1.9052	2.0957	1.9052	1.9052
6	1.9052	1.9052	1.9052	1.9052	1.9814	1.9052	1.9052
7	1.9052	1.9052	1.9052	1.9052	1.9052	1.9052	2.2862
8	2.2862	1.9052	1.9052	1.9052	1.9814	2.2862	2.2862
9	3.0483	1.5242	1.9052		2.8578	2.2862	3.0483
10	3.8104	3.8104	1.9052	3.8104	2.8578	3.0483	3.4294
11	4.1914	3.8104	2.2862	4.0009	3.0483	3.8104	3.8104
12	4.1914		2.2862	4.0009	3.0483	4.1914	3.0483
13	4.1914	3.4294	2.2862	3.8104	2.6673	4.1914	3.0483
14	3.8104	3.4294	2.2862	3.4294	3.0483	4.1914	3.0483
15	3.8104	4.1914	2.2862	3.8104	2.8578	4.1914	3.8104
16	3.8104	3.8104	2.2862	4.0009	3.0483	3.8104	3.8104
17	3.8104	3.8104		4.0009	2.6673	3.8104	3.0483
18	3.6199	3.0483		3.2388	2.6673	3.0483	3.0483
19	3.0483			3.0483	2.2862	3.0483	2.6673
20	2.6673	3.0483		2.8578	2.2862	2.6673	2.2862
21	1.9052	3.0483		2.4768	1.9052	2.6673	2.2862
22	1.9052	2.6673		2.0957	1.9052	2.2862	1.9052
23	1.9052	2.6673		1.9052	1.9052	2.2862	1.9052
24	1.9052	3.8104	2.2862	1.9052	2.0957	1.9052	1.9052
Max	4.1914	4.1914	2.2862	4.0009	3.0483	4.1914	3.8104
Min	1.9052	1.5242	1.9052	1.9052	1.9052	1.9052	1.9052
Avg	2.8022	2.7885	2.0845	2.7832	2.3958	2.7943	2.5879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283030 / 22/22KV Krishna Steel

Swt/Stn

Feeder No / Name : 305 / 22KV N0CIL RCD

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.2862	2.2862	2.2862	2.1719	2.0957	2.2862
2	2.2862	2.2862	2.2862	2.2862	2.1719	2.0957	2.2862
3	2.2862	2.2862	2.2862		2.1719	1.9052	2.2862
4	2.2862	2.2862	2.2862	2.2862	2.1719	1.9052	2.2862
5	2.2862	2.2862	2.2862	2.2862	2.1719	1.9052	1.9052
6	2.2862	2.2862	2.2862	2.2862	2.1719	1.9052	1.9052
7	2.3624	2.2862	2.2862	2.2862	2.0195	1.9052	1.9052
8	2.4768	2.0957	2.2862	1.9052	2.0195	2.0957	1.9052
9	2.3624	2.2862	2.2862		2.0957	2.0957	2.0957
10	2.4768	2.2862	2.2862	2.0957	2.0957	2.2862	2.0957
11	2.4768	2.4768	1.9052	2.0195	2.0957	2.2862	2.0957
12	2.6673	2.4768	1.9052	2.0957	1.9052	2.2862	2.0957
13	2.6673	2.4768	1.9052	1.9052	2.0957	2.0957	2.0957
14	2.2862	2.2862	1.9052	2.0195	1.9052	2.0957	2.0957
15	2.2862	2.2862	1.9052	2.0195	1.9052	2.0957	1.9052
16	2.2862	2.4768	1.9052	2.0195	2.0957	2.2862	1.9052
17	2.2862	2.4768		2.0195	1.9052	2.2862	1.9052
18	2.2862	2.2862		2.1719	2.0957	2.2862	1.9052
19	2.2862	2.2862		2.2862	2.0957	2.2862	2.0957
20	2.2862	2.2862		2.1719	2.0957	2.0957	2.0957
21	2.2862	2.2862		2.1719	1.9052	2.0957	1.9052
22	2.2862	2.2862		2.0957	1.9052	2.0957	1.9052
23	2.0957	2.2862		2.0195	2.0957	2.0957	1.9052
24	2.2862	2.2862	2.2862	2.2862	2.0957	2.0957	2.2862
Max	2.6673	2.4768	2.2862	2.2862	2.1719	2.2862	2.2862
Min	2.0957	2.0957	1.9052	1.9052	1.9052	1.9052	1.9052
Avg	2.3402	2.3180	2.1517	2.1373	2.0608	2.1116	2.0481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 201 / 11 KV PATEL HEIGHT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1216	2.2862	2.268	2.4025	2.5701	2.371
2		1.9022	2.1948	2.1765	2.2916	2.2624	2.1719
3		1.5546	2.0883	2.0485	2.2177	2.0633	1.9728
4		1.6827	1.9774	2.0144	2.0698	1.9909	1.8823
5		1.829	1.848	1.848	1.9959	2.0271	1.9366
6		2.1582	2.1622	1.9035	1.848	2.1357	2.009
7		2.2314	2.2131	1.9589	1.9589	2.3101	2.1357
8		2.268	2.0851	1.957	2.0698	2.3101	2.2731
9		2.2314	2.3954	2.3411	2.1622	2.4209	2.347
10		2.4209	2.5057	2.4579	2.1807	2.5133	2.5133
11		2.4209	2.3777	2.6242	2.4579	2.5503	2.2546
12		2.0851		2.3285	2.4025	2.1992	2.2546
13		2.3101		2.2546		2.2177	2.2177
14		2.2546		2.2361	2.2731	2.1992	2.2177
15		2.1437		2.4025	2.3655	2.4579	2.1437
16		2.0668		2.2916	2.2916	2.1622	2.0698
17		2.2497		2.4394	2.3285	2.2546	2.2916
18		2.2916	2.7435	2.4949	2.3655	2.4209	2.4025
19		2.7252	2.9569	2.7721	2.6606	2.8235	2.7069
20		2.7252	2.9569	2.8532	2.6606	2.6787	2.7801
21		2.6981	2.6886	2.7069	2.6425	2.8235	3.3836
22		2.6981	2.7801	2.7618	2.7149	2.6787	2.8532
23		2.7069	2.8829	2.7351	2.8054	2.8416	2.9938
24	2.3891	2.3228	2.4143	2.6797	2.7351	2.6244	2.1719
Max	2.3891	2.7252	2.9569	2.8532	2.8054	2.8416	3.3836
Min	2.3891	1.5546	1.848	1.848	1.848	1.9909	1.8823
Avg	2.3891	2.2541	2.4198	2.3564	2.3435	2.3973	2.3481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 202 / 11 KV HAWARE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7741	1.9035	1.8839	2.0698	2.3655	1.7924
2		1.701	1.8111	1.7924	1.848	2.2177	1.7924
3		1.4449	1.7187	1.701	1.7372	2.1622	1.701
4		1.4266	1.6263	1.6632	1.6632	2.0328	1.8107
5		1.5729	1.7741	1.7375	1.7741	2.0698	1.8107
6		1.9387	2.0119	1.8099	1.848	2.1807	2.0119
7		2.1399	2.1582	1.9366	1.9589	2.3045	2.2131
8		2.2314	2.2177	2.1033	2.1253	2.2731	2.1992
9		2.0119	2.2862	2.1807	2.1253	2.1622	2.0513
10		2.1253	2.1582	2.1992	2.2731	2.2177	2.1622
11		2.0698	2.0851	2.2177	2.347	1.885	1.9959
12		1.885	1.922	2.1622	2.1622	2.0328	1.9959
13		1.8111	1.7375	2.0328	2.0698	2.1253	1.9404
14		1.6817	1.6651	1.848	1.9589	1.9035	1.8111
15		1.7375	1.6632	1.922	2.0144	1.922	1.7741
16		1.701	1.7375	1.9239	2.0328	1.8665	1.7372
17		1.7558	1.7741	1.9589	2.0698	1.8665	1.8111
18		1.9035	1.8111	2.0328	2.1253	2.0144	1.885
19		2.347	2.2131	2.396	2.524	2.3228	2.4025
20		2.5606	2.4072	2.5972	2.5953	2.652	2.6242
21		2.5972	2.5057	2.6703	2.6242	2.7252	2.6242
22		2.4143	2.3655	2.524	2.5503	2.6886	2.6242
23		2.2546	2.3285	2.4025	2.4949	2.5057	2.5503
24	2.0851	1.9204	2.0883	2.2361	2.3655	2.2731	2.2862
Max	2.0851	2.5972	2.5057	2.6703	2.6242	2.7252	2.6242
Min	2.0851	1.4266	1.6263	1.6632	1.6632	1.8665	1.701
Avg	2.0851	1.9586	1.9987	2.0805	2.1399	2.1987	2.0670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 204 / 11 KV SPARE

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3395	.4001	.4207	.4527	.5658	.4715
2		.3395	.381	.3921	.415	.5281	.3772
3		.3018	.3772	.3734	.3772	.5281	.3395
4		.3772	.3361	.3395	.3395	.4904	.3961
5		.4338	.2987	.3395	.3018	.4904	.3961
6		.3961	.415	.381	.3018	.5093	.3982
7		.5093	.5525	.4382	.3395	.5093	.3961
8		.547	.6478	.3734	.415	.4382	.6224
9		.6224	.5716	.3584	.5281	.4001	.5093
10		.5281	.4763	.679	.4715	.5335	.6036
11		.5281	.5144	.6224	.6036	.4001	.3395
12		.5175	.4108	.4904	.5658	.4001	.3395
13		.3921	.4656	.415	.5281	.4001	.4527
14		.4481	.3601	.3395	.4715	.4191	.4066
15		.3921	.3206	.4338	.4715	.4382	.3772
16		.3239	.3658	.415	.4527	.4382	.2366
17		.381	.3395	.3772	.4527	.4527	.3772
18		.3395	.3395	.415	.4527	.3584	.415
19		.4294	.3921	.4527	.415	.3584	.4904
20		.5525	.4001	.4904	.415	.5093	.415
21		.5093	.462	.4338	.4904	.4527	.5093
22		.5601	.4481	.5281	.4715	.4527	.4715
23		.4251	.5658	.4904	.4904	.5281	.5335
24	.4572	.3961	.4572	.5228	.4715	.4382	.5093
Max	.4572	.6224	.6478	.679	.6036	.5658	.6224
Min	.4572	.3018	.2987	.3395	.3018	.3584	.2366
Avg	.4572	.4412	.4291	.4384	.4456	.4600	.4326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 205 / 11 KV Swaraj Ghansoli

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.037		.0381		.0377	
2		.037		.0381		.0377	.0377
4		.037					
5		.037					.0377
6		.037					.0377
7		.037		.0373			.0377
8		.037				.0381	.0366
9						.0762	.0549
10		.037		.0381		.0572	
11				.0572	.0762		.0754
12		.0572	.0566	.0762	.0762		.0754
13		.0572	.0381	.0572	.0762		.0566
14			.0381	.0572	.0762		
15			.0381	.0572	.0572		
16			.0377	.0572			
17		.0381		.0572			
18		.0377		.0572			
19		.0377	.0377	.0572	.0572		.0566
20		.037		.0572		.0377	.0377
21		.0381		.0572		.0377	.0377
22		.0381	.0381	.0381	.0572	.0377	.0377
23			.0381	.0572	.0381	.0377	.0373
24	.0381	.037		.037	.0566	.0381	.0377
Max	.0381	.0572	.0566	.0762	.0762	.0762	.0754
Min	.0381	.037	.0377	.037	.0381	.0377	.0366
Avg	.0381	.0397	.0403	.0518	.0635	.0436	.0463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 206 / 11 KV SHAKTI SEC-8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0381	.056	.1886	.0566	.037
2		.0381	.0572	.0754	.0377	.0346
4	.0377					
5					.0377	.037
6	.0377	.1494	.0754		.0754	.0754
7	.1886	.2096	.1494		.1886	.2033
8	.1886	.1905	.168	.0566	.0381	.168
9	.1509	.0747	.1791	.0566	.0572	.1867
10	.168	.168	.128	.0566	.1715	.1698
11	.0377	.1905	.1829	.2075	.1905	.056
12	.0381		.1829	.1886	.2096	.056
13	.0381		.1829	.0754	.1905	.1867
14			.0549	.0754	.0572	.056
15	.1715		.2195	.0566	.1715	.056
16			.2195	.0754	.1715	.056
17	.1509		.2012	.1886	.0377	.056
18	.1867	.0572	.2012	.1886	.1698	.0747
19	.0373	.0747	.2012	.0566	.0739	.2241
20	.168	.0566	.168	.2075	.0739	.2241
21	.1772	.056	.2054	.0566	.0554	.1867
22	.0566	.0566	.2241	.2075	.2033	.168
23	.0566	.1867	.0747	.132	.2033	.2054
24	.0377	.0566	.056	.2054	.0754	.037
Max	.1886	.2096	.2241	.2075	.2096	.2241
Min	.0373	.0381	.0549	.0566	.0377	.0346
Avg	.1044	.1069	.1518	.1240	.1157	.1161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 283032 / 22/11KV Ghansoli Gharonda

S/St

Feeder No / Name : 207 / 11 KV Tulsi Graphics

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0381		.0377	
3	.0377					
4	.0377					
5	.0377					
6	.0377	.0377	.0377			
7			.0377			
8		.0381				
9		.0572	.0377		.0572	
10					.0381	
12			.0566	.0566		
13				.0566		
14				.0566		
15				.0566		
17				.0566		
18	.0572	.0572		.0754	.0572	
19		.0381	.0566	.0566		
20			.0566	.0377		
21	.0381	.0549	.0566	.0377	.0381	.0381
22	.0381	.056	.0566	.0377	.0381	
23	.0381	.0566	.0566	.0377	.0572	.0566
24	.0377	.0381	.0381	.0566	.0377	
Max	.0572	.0572	.0566	.0754	.0572	.0566
Min	.0377	.0377	.0377	.0377	.0377	.0381
Avg	.04	.0472	.0481	.0519	.0452	.0474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 202 / 11 KV SECTOR 10 HTP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1719	2.3167			2.4253	2.4977
2		2.009	2.1538		2.3167	2.2805	2.371
3		1.9547	2.0814		2.1948	2.1357	2.2624
4		1.9004	1.9909		2.1582	2.0995	2.1538
5		1.9366	2.1357		2.1216	2.1538	2.2986
6		2.2262	2.1719		2.1948	2.4072	2.4434
7		2.2805	2.2624		2.1538	2.4253	2.371
8	2.3926	2.4253	2.4253		2.3167	2.5882	2.5882
9		2.4253	2.4434		2.5158	2.6063	2.5339
10		2.2081	2.4615	2.4072	2.371	2.4434	2.3891
11	2.1357	2.1176		2.3167		2.3348	
12		2.1357		2.3167	2.371	2.2443	
13		1.9728		2.1719	2.2081	2.0814	
14		1.9366		2.0814	2.19	2.1357	
15		1.9366		2.0995	2.1176	2.0995	
16	1.9547	1.9728		2.0995	2.19	2.0452	
17	1.9909	2.0452		2.1807	2.2805	2.0452	
18	2.1538	2.2624		2.3167	2.371	2.3167	
19	2.5339	2.6244		2.733	2.6787	2.7511	
20	2.7149	2.8416			2.8959	2.8959	
21	2.7511	2.8235		2.963	2.914	2.9321	
22	2.6425	2.7692			2.8416	2.8778	
23	2.5158	2.6787		2.7511	2.8054	2.7873	
24		2.3529	2.4615		2.6425	2.6787	2.733
Max	2.7511	2.8416	2.4615	2.963	2.914	2.9321	2.733
Min	1.9547	1.9004	1.9909	2.0814	2.1176	2.0452	2.1538
Avg	2.3786	2.2503	2.2640	2.3698	2.4023	2.4080	2.4220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 203 / 11 KV SECTOR 9

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2916	2.5133			2.7721	2.7721
2		2.1992	2.347		2.5503	2.6057	2.6057
3		2.1253	2.2361		2.3339	2.4394	2.4209
4		2.0698	2.0883		2.2965	2.3655	2.2916
5		2.0883	2.2177		2.2546	2.3101	2.4209
6		2.5873	2.3101		2.3285	2.9199	2.6612
7		3.4558	3.2895		2.9754	3.7146	3.4928
8	3.2941	3.1971	3.1971		3.1417	3.2526	3.3634
9		2.9199	3.1232		2.9569	3.0678	3.0862
10		2.8829	3.0123	2.9569	3.0493	3.1047	2.8829
11		2.6797		2.7166	2.914	2.9014	
12		2.6242		2.6797	2.8829	2.7536	
13		2.5688		2.6981	2.7351	2.7536	
14		2.6057		2.5318	2.6427	2.7351	
15		2.5503		2.5873	2.6612	2.6427	
16	2.4394	2.5133		2.5057	2.6427	2.6427	
17	2.6057	2.5503		2.6427	2.6242	2.6797	
18	2.5688	2.6242		2.7069	2.7351	2.7351	
19	2.9938	3.1602		3.1417	3.1232	3.1971	
20	3.6037	3.6776		3.0308	3.345	3.4374	
21	3.77	3.807		4.3059	4.0103	3.4928	
22	3.5113	3.1786			3.1971	4.2875	
23	2.8645	3.0123		3.1047	3.2341	3.2526	
24		2.6057	2.8275		2.9014	3.0308	3.0493
Max	3.77	3.807	3.2895	4.3059	4.0103	4.2875	3.4928
Min	2.4394	2.0698	2.0883	2.5057	2.2546	2.3101	2.2916
Avg	3.0724	2.7490	2.6511	2.8930	2.8494	2.9623	2.8225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 204 / 11 KV SISILY PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3647	.4024			.503	.4862
2		.3605	.3856		.4144	.4694	.4527
3		.3441	.3521		.4024	.4191	.4024
4		.3239	.3353		.3812	.4024	.3856
5		.3239	.3353		.3812	.4191	.4191
6		.3605	.3521		.3605	.4191	.4191
7		.3605	.3521		.3481	.4359	.4191
8	.39	.4588	.4024		.3605	.3856	.3521
9		.4096	.4359		.3605	.3688	.3856
10	.3812	.3605	.4024	.3605	.3441	.3688	.3688
11		.3856		.3768	.4144	.4024	
12		.3688		.3768	.3812	.3688	
13		.3521		.3441	.431	.3353	
14		.3353		.3725	.4191	.3521	
15		.3185		.3932	.4024	.3521	
16	.2949	.3185		.3277	.4359	.3521	
17	.3441	.3353		.3932	.4024	.3521	
18	.3441	.3856		.3563	.3856	.3688	
19	.426	.4191		.426	.4527	.4359	
20	.431	.4359		.426	.4527	.4527	
21	.431	.4359		.4527	.4694	.4862	
22	.431	.4359			.4694	.4359	
23	.431	.4694		.4359	.5197	.5365	
24		.431	.4694		.503	.5197	.5197
Max	.431	.4694	.4694	.4527	.5197	.5365	.5197
Min	.2949	.3185	.3353	.3277	.3441	.3353	.3521
Avg	.3904	.3789	.3841	.3878	.4127	.4142	.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 205 / 11 KV BHAKTI HTP 12A

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8149	.8842			.9709	.9536
2		.7186	.8322		.929	.8669	.8495
3		.6836	.7628		.8413	.8149	.7802
4		.6485	.7108		.7537	.7802	.7455
5		.6588	.6935		.7186	.7628	.8149
6		.7628	.6762		.7888	.8669	.8669
7		.8939	.7975		.7282	.9882	.9015
8	.9362	.8842	.9362		.7628	.8322	.8322
9		.8495	.9536		.8495	.8669	.9362
10		.7802	.8495	.8322	.8495	.7802	.7975
11		.7282		.8495	.9259	.7802	
12		.7108		.7628	.8745	.7455	
13		.6935		.7628	.7716	.6588	
14		.6935		.7975	.7628	.6762	
15		.5375		.7202	.8149	.6415	
16	.5895	.6241		.703	.8669	.6415	
17	.6687	.5895		.7888	.8495	.6241	
18	.6415	.7108		.703	.7628	.6588	
19	.7975	.8149		.8149	.9015	.8322	
20	.8939	.8495		.9114	.8495	.8842	
21	.8764	.8842		.9313	.9015	.9362	
22	.8764	.9709			1.0923	.9882	
23	.9816	.9362		1.0517	1.0576	1.0576	
24		.929	.9709		1.0692	1.0749	1.0749
Max	.9816	.9709	.9709	1.0517	1.0923	1.0749	1.0749
Min	.5895	.5375	.6762	.703	.7186	.6241	.7455
Avg	.8069	.7653	.8243	.8176	.8575	.8221	.8684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 206 / 11 KV SECTOR 8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.7166	2.9384			3.1786	3.1417
2		2.4949	2.7351		2.846	2.9199	2.9938
3		2.384	2.5873		2.6886	2.7351	2.7905
4		2.2916	2.5133		2.5688	2.6057	2.6981
5		2.3285	2.5688		2.5503	2.6797	2.8275
6		2.809	2.6057		2.5503	2.9938	3.0123
7		3.5113	3.271		3.0493	3.807	3.5852
8	3.3265	3.3265	3.2341		3.1232	3.345	3.3819
9		2.8275	3.1232		2.9569	2.9014	2.9014
10		2.5688	2.7351	2.7905	3.0308	2.6242	2.5503
11		2.4579		2.8645	2.846	2.6057	
12		2.4209		2.6981	2.846	2.5873	
13		2.347		2.6797	2.7351	2.5503	
14		2.347		2.5688	2.7536	2.4764	
15		2.2731		2.5873	2.7166	2.4579	
16	2.2916	2.3101		2.4874	2.7351	2.4209	
17	2.347	2.4025		2.6981	2.7166	2.4949	
18	2.4209	2.5133		2.7069	2.8275	2.6612	
19	3.0862	3.271		3.345	.961	3.3265	
20	3.6406	3.7515		3.8624	3.9363	3.2895	
21	3.9918	3.9918		4.269	3.8439	3.6961	
22		3.6776			3.6776	4.5092	
23	3.3634	3.5113		3.6222	3.5852	3.7885	
24		3.1232	3.2156		3.4928	3.345	3.3819
Max	3.9918	3.9918	3.271	4.269	3.9363	4.5092	3.5852
Min	2.2916	2.2731	2.5133	2.4874	.961	2.4209	2.5503
Avg	3.0585	2.8190	2.8661	3.0138	2.9147	3.0000	3.0241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 284059 / 33/11 KV Sector- 12B, K

Khaira

Feeder No / Name : 207 / 11 KV SHUBHAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3717	1.4998			1.8473	1.7924
2		1.2437	1.4083		1.6644	1.7741	1.6461
3		1.134	1.3352		1.4998	1.7375	1.5181
4		1.1157	1.2803		1.4449	1.6461	1.4266
5		1.1523	1.262		1.39	1.5546	1.39
6		1.3169	1.2986		1.4083	1.6827	1.4449
7		1.4266	1.39		1.4083	1.4998	1.5729
8	1.4266	1.262	1.39		1.2986	1.4998	1.4449
9		1.3717	1.4815		1.3717	1.4083	1.4266
10		1.2803	1.5181	1.4449	1.4632	1.2986	
11		1.1888		1.3717	1.4449	1.39	
12		1.2071		1.3717	1.5364	1.3535	
13		1.2071		1.3717	1.4632	1.2071	
14		1.134		1.2851	1.4083	1.2803	
15		1.0974		1.3394	1.4998	1.3169	
16	1.1403	1.134		1.3394	1.4632	1.2437	
17	1.134	1.1157		1.2489	1.3169	1.2254	
18	1.1157	1.1706		1.2308	1.39	1.262	
19	1.3394	1.4083		1.448	1.5364	1.4266	
20	1.4083	1.4815		1.5364	1.5546	1.5546	
21	1.4969	1.4998		1.5893	1.5729	1.6461	
22	1.5708	1.5546			1.6644	1.7193	
23	1.6263	1.5729		1.7558	1.8656	1.9022	
24		1.5546	1.6278		1.829	1.9022	1.957
Max	1.6263	1.5729	1.6278	1.7558	1.8656	1.9022	1.957
Min	1.1157	1.0974	1.262	1.2308	1.2986	1.2071	1.39
Avg	1.3620	1.2917	1.4083	1.4102	1.4998	1.5158	1.5620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

KOPARKHAIRENE S/DN.[753] BU 4753

Substation No/ Name :- 288060 / 220/22KV Mahape S/Stn

Feeder No / Name : 302 / 22 KV MBP II (I/C)

Feeder KV- 22 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5789	2.6094	2.5972	2.6277	2.4326	2.4021
2	2.5606	2.5057	2.6155	2.5728	2.3838	2.3411
3	2.5789	2.463	2.5667	2.5484	2.3899	2.3533
4	2.5789	2.4874	2.5362	2.5545	2.4082	2.3533
5	2.5423	2.5057	2.524	2.5728	2.3533	2.3838
6	2.5728	2.5484	2.5362	2.4935	2.4691	2.5423
7	3.1581	3.0666	3.4385	2.7435	2.585	2.9386
8	3.9201	4.5847	4.5847	3.0727	2.6337	4.5237
9	4.981	5.3711	5.109	3.9323	2.6337	5.8406
10	6.2186	5.5967	5.4992	4.3591	2.5911	6.4746
11	6.2491	5.6699	5.615	4.4384	2.6642	6.5173
12	5.9442	5.5906	5.7065	4.5115	2.6703	6.5905
13	6.1027	5.7186	5.6943	5.5175	2.5972	6.5905
14	5.9015	5.8589	5.7004	5.6455	2.6337	6.8099
15	6.0357	5.9381	5.8162	5.7613	2.6581	7.0721
16	6.2552	5.993	5.8345	5.3589	2.6216	7.0477
17	6.0966	5.932	6.0479	3.8653	2.5789	6.8099
18	5.8772	2.1033	5.8406	3.1581	2.6398	6.2795
19	5.5845	4.6273	4.5359	3.1215	2.8166	5.8345
20	4.1274	4.1701	4.1457	3.0056	2.7984	4.6395
21	3.725	3.6336	3.6763	2.8959	2.7557	3.8165
22	3.28	3.3044	3.2739	2.7313	2.6398	3.2861
23	2.8654	3.091	2.9752	2.6337	2.5728	3.1642
24	2.652	2.7679	2.7374	2.5911	2.4813	2.8898
Max	6.2552	5.993	6.0479	5.7613	2.8166	7.0721
Min	2.5423	2.1033	2.524	2.4935	2.3533	2.3411
Avg	4.3494	4.0891	4.2336	3.5297	2.5837	4.6459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 201 / 11KV VASHI PLAZA OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9231	.7522	.8413	.905	.905	.9774	.9593
2	.8688	.691	.7392	.8596	.8413	.9145	.8507
3	.823	.6447	.7023	.823	.7316	.8326	
4	.7762	.6219	.6653	.7947	.7762	.7499	
5	.7282	.6335	.7207	.7577	.7577	.7499	
6	.7577	.695	.7023	.8048	.7577	.7865	.6584
7	.7762	.6878	.6653	.7682	.6283	.7865	.695
8	.8131	.823	.7762	.695	.6653	.823	.8316
9	1.0974	1.2012	1.0349	.9593	.823	1.1403	1.2127
10	1.9879	1.8642	1.5927	1.5181	1.134	1.9909	1.9185
11	2.1312	2.1948	1.9366	1.9753	1.4842	2.4874	2.5158
12	2.2207	2.2443	1.9185	2.19	1.4118	2.5606	2.652
13	2.19	2.2081	1.9185	2.0668	1.4083	2.524	2.4508
14	2.2028	2.0995	1.7556	1.957	1.3717	2.4326	2.4691
15	2.2443	2.2805	1.8823	2.0485	1.2254	2.524	2.524
16	2.3529	2.4072	1.9366	1.9909	1.1706	2.6155	2.5423
17	2.3102	2.3777	1.7737	2.1399	1.2437	2.4326	2.396
18	1.97	1.9547	1.5746	1.7558	1.1222	2.2081	2.1582
19	1.8446	1.9366	1.5927	1.7924	1.3169	2.0668	2.0271
20	1.4842	1.7013	1.3575	1.4998	1.2254	1.7194	1.828
21	1.2536	1.3394	1.1584	1.3717	1.134	1.4148	1.5023
22	.9877	.9774	.9955	1.0317	1.0608	1.1403	1.1584
23	.8954	.9412	.9774	1.0136	1.0059	1.086	1.1222
24	.9671	.8059	.8596	.9412	1.0349	1.0498	1.0498
Max	2.3529	2.4072	1.9366	2.19	1.4842	2.6155	2.652
Min	.7282	.6219	.6653	.695	.6283	.7499	.6584
Avg	1.4419	1.4201	1.2532	1.3608	1.0515	1.5839	1.6915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 202 / 11KV RAILWAY QUARTERS OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.2803	1.2437	1.3352	1.4632	1.4815	1.4998
2	1.2986	1.1765	1.2012	1.2936	1.39	1.39	1.3717
3	1.2752	1.0745	1.1576	1.2323	1.1088	1.2986	
4	1.3817	1.0164	1.1203	1.1883	1.1273	1.1888	
5	1.423	1.0974	1.1389	1.226	1.1458	1.2197	
6	1.4449	1.2936	1.1523	1.2883	1.3676	1.2382	1.262
7	1.4998	1.5708	1.3535	1.3491	1.3306	1.2567	1.423
8	1.4632	1.3535	1.3352	1.4045	1.2752	1.423	1.531
9	1.4937	1.4563	1.2382	1.4415	1.307	1.5154	1.587
10	1.46	1.46	1.2323	1.1949	1.307	1.4563	1.5497
11	1.39	1.3817	1.1949	1.4003	1.2752	1.4415	1.4937
12	1.3352	1.2936	1.1763	1.3306	1.2936	1.386	1.4969
13	1.2071	1.2323	1.0829	1.4045	1.2567	1.423	1.386
14	1.2254	1.1827	1.086	1.2936	1.2012	1.3491	1.3676
15	1.2567	1.1643	1.0829	1.4045	1.2197	1.3306	1.4045
16	1.2936	1.1763	1.0719	1.386	1.2197	1.307	1.4563
17	1.2382	1.2197	1.2012	1.3121	1.2936	1.2567	1.2883
18	1.2197	1.2197	1.1523	1.2936	1.2986	1.3352	1.3535
19	1.4998	1.6289	1.4842	1.6095	1.4969	1.5546	1.5912
20	1.6827	1.7013	1.6461	1.7741	1.6461	1.647	1.6817
21	1.4784	1.531	1.4083	1.5181	1.5524	1.5546	1.5364
22	1.3717	1.4449	1.4266	1.5364	1.5912	1.5546	1.5339
23	1.4449	1.4083	1.39	1.6078	1.6644	1.5729	1.6644
24	1.4449	1.3717	1.2986	1.3717	1.5364	1.5729	1.5729
Max	1.6827	1.7013	1.6461	1.7741	1.6644	1.647	1.6817
Min	1.2071	1.0164	1.0719	1.1883	1.1088	1.1888	1.262
Avg	1.3833	1.3223	1.2448	1.3832	1.3487	1.4064	1.4786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 203 / 11KV MGM OG NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3048	.2641	.3018	.3206	.3395	.3429
2	.3584	.3048	.2858	.3206	.3048	.3048	.3048
3	.3395	.2829	.2477	.3584	.2858	.2641	
4	.3206	.2858	.2667	.3395	.2667	.2667	
5	.3206	.3206	.2477	.3206	.2477	.3048	
6	.3395	.3395	.2477	.2829	.362	.3395	.3429
7	.3772	.3772	.3239	.2987	.3395	.3395	.4382
8	.3961	.3584	.3772	.3206	.3239	.4338	.4954
9	.4338	.3584	.3395	.4527	.4338	.4954	.4715
10	.415	.4382	.4382	.4715	.3961	.4191	.4954
11	.4854	.5144	.3429	.5847	.4527	.5335	.5093
12	.4715	.4527	.4338	.4904	.4338	.5525	.5093
13	.3961	.5144	.415	.5906	.4904	.5525	.415
14	.4715	.5144	.415	.5335	.3772	.5144	.5144
15	.5041	.381	.4338	.3961	.415	.5335	.5335
16	.4904	.5716	.4527	.4715	.415	.4572	.4954
17	.4338	.4763	.3395	.5658	.3395	.5525	.5847
18	.4338	.5144	.4338	.4763	.415	.5144	.5525
19	.415	.3961	.3772	.4338	.3772	.5144	.4527
20	.3206	.4338	.4338	.415	.4527	.4527	.4338
21	.2858	.3584	.3395	.4338	.3961	.4001	.4191
22	.2829	.3018	.415	.4108	.4338	.4382	.4572
23	.2858	.3584	.3048	.415	.4763	.4572	.415
24	.3734	.3239	.2858	.2829	.3395	.381	.3772
Max	.5041	.5716	.4527	.5906	.4904	.5525	.5847
Min	.2829	.2829	.2477	.2829	.2477	.2641	.3048
Avg	.3887	.3951	.3525	.4153	.3790	.4317	.4552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 204 / 11KV HTP ABHYUDAYA BANK OG SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5415	.5544	.547	.5788	.5487	.5975	.6161
2	.5093	.5121	.4527	.5415	.5041	.547	.5658
3	.4715	.4715	.3772	.5093	.4904	.4904	
4	.4338	.3961	.415	.4715	.4715	.4527	
5	.3961	.4527	.3961	.4904	.4527	.4904	
6	.4527	.5281	.4904	.5093	.4715	.5281	.5041
7	.5093	.5847	.5093	.5281	.4715	.547	.5228
8	.547	.547	.5847	.5281	.5093	.547	.547
9	.6224	.6535	.6602	.6535	.6224	.6535	.6722
10	1.2012	1.0349	1.0719	1.0719	.8402	1.2197	1.1643
11	1.8665	1.7187	1.5893	1.8296	1.2567	1.8296	1.9035
12	1.8473	1.8267	1.6461	1.8642	1.2567	2.1622	2.0513
13	1.8107	1.7924	1.6644	1.7924	1.3169	1.9936	2.0328
14	1.829	1.7375	1.5203	1.7375	1.2986	1.8473	1.9404
15	1.885	1.8473	1.701	1.8473	1.3306	2.0698	1.9589
16	1.922	1.957	1.6108	1.8839	1.3169	2.1068	2.0698
17	1.9204	1.9204	1.5546	1.0791	1.2803	2.0668	2.0698
18	1.7375	1.829	1.5927	1.7193	1.2308	1.9204	1.9753
19	1.8107	1.8823	1.5927	1.829	1.3394	1.9936	1.9204
20	1.5546	1.6651	1.5384	1.6827	1.4632	1.7375	1.829
21	1.3352	1.3937	1.3575	1.4998	1.3352	1.4632	1.4842
22	.823	.8686	.905	.9511	1.0456	.8871	.9511
23	.6838	.679	.6535	.8962	.7095	.8131	.7655
24	.5601	.5914	.5847	.6348	.6224	.6602	.6535
Max	1.922	1.957	1.701	1.8839	1.4632	2.1622	2.0698
Min	.3961	.3961	.3772	.4715	.4527	.4527	.5041
Avg	1.1363	1.1435	1.0423	1.1304	.9244	1.2344	1.3428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 205 / 11KV NBSA OG SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6979	.6859	.7356	.7167	.7356	.7545	.7922
2	.6602	.6478	.679	.6602	.679	.7167	.7545
3	.6224	.6036	.6413	.6224	.5658	.679	
4	.5847	.5906	.6036	.5847	.5847	.6413	
5	.6036	.6224	.5658	.547	.6036	.6979	
6	.6602	.679	.6224	.6036	.6413	.7545	.7733
7	.7167	.7545	.7733	.6413	.6979	.811	.8488
8	.7922	.7356	.8299	.7733	.7545	.7167	.8865
9	.8299	.8299	.6413	.7356	.7356	.743	.8962
10	1.226	.8299	.724	.7167	.7468	.8299	.9149
11	.8775	.8676	.7167	.7733	.7842	.9619	.9335
12	.8215	.9054	.6859	.8029	.7762	.9335	.9522
13	.8029	.8488	.6979	.8488	.7356	.9149	.9149
14	.7842	.8676	.6602	.811	.679	.9054	.8962
15	.7842	.7922	.6602	.8488	.6979	.9335	.9709
16		.8865	.6859	.8488	.679	.9054	.961
17	.8589	.9149	.6668	.811	.679	.9242	.9335
18	.8029	.8029	.7167	.8299	.679	.8962	.8589
19	1.1389	1.0269	.8775	1.0751	.9795	1.0534	1.2071
20	1.251	1.2254	1.0269	1.2449	1.1827	1.1643	1.1827
21	.9709	.9896	.9149	.9997	.9328	.9709	1.0534
22	.8589	.8215	.8299	.8962	.9054	.9431	.9709
23	.7545	.8299	.8775	.9997	.8488	.9054	.8676
24	.7356	.7167	.811	.7545	.811	.7922	.8488
Max	1.251	1.2254	1.0269	1.2449	1.1827	1.1643	1.2071
Min	.5847	.5906	.5658	.547	.5658	.6413	.7545
Avg	.8189	.8115	.7352	.7978	.7548	.8562	.9247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283019 / 22/11KV Vashi, Sec-1 S/Stn

Feeder No / Name : 206 / 11KV SEC-6 ROW OG SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0242	.9231	.9877	1.1157	1.1088	1.134	1.1523
2	.9979	.8688	.9145	1.0425	.924	1.0791	1.0791
3	.961	.823	.8871	.9979	.8962	1.0242	
4	.9335	.7865	.8775	.9522	.8589	.9511	
5	.9425	.8501	.8589	.8775	.8775	.9328	
6	.9896	.9149	.8962	.8131	.8871	.961	.9511
7	1.0082	.9709	.8589	.8686	.8501	.961	.9979
8	.9522	1.0269	.9145	.8871	.8316	.9425	.9896
9	.8871	.8029	.8596	.8589	.8215	.8775	.9149
10	.8402	.8402	.8589	.8402	.8589	.8402	.8589
11	.8589	.8402	.8402	.8775	.8589	.8402	.8029
12	.7282	.7655	.7842	.7947	.7762	.7468	.7468
13	.7468	.7842	.7282	.7762	.8131	.7842	.7655
14	.7468	.7282	.7468	.7655	.7947	.7655	.7468
15	.7392	.7095	.7655	.7947	.8501	.7842	.7842
16		.7468	.7577	.7392	.7762	.8215	.7282
17	.7207	.7095	.7282	.7468	.7392	.7282	.7095
18	.6468	.7095	.6653	.7095	.7207	.6908	.7095
19	.8962	.9231	.9231	.9149	.924	.9511	.905
20	1.0425	1.1157	1.0679	1.1016	1.0719	1.0498	1.0679
21	1.0349	1.0719	1.1041	1.0642	1.0425	1.0608	.9955
22	1.0242	1.0829	1.1222	1.0136	1.134	1.1523	1.1041
23	1.0425	1.134	1.2308	1.0498	1.2437	1.2437	1.1706
24	1.0608	.9774	1.0791	1.1523	1.1403	1.1888	1.1888
Max	1.0608	1.134	1.2308	1.1523	1.2437	1.2437	1.1888
Min	.6468	.7095	.6653	.7095	.7207	.6908	.7095
Avg	.9054	.8794	.8940	.9064	.9083	.9380	.9223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 302 / 22KV JAYSYNTH O/G FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.7915	.7999	.7537	2.3765	.7773	
2		2.037	.7758	.6722	1.9616	.7316	
3		1.9616	.8194	.7865	1.8861	.6097	2.0432
4		1.9616	.837	1.166	1.773	.6401	
5		1.8861	.834		1.6975	.7377	
6		1.8861	.8127		1.6598	.6722	
7		1.7353	.8012		1.6221	.8002	
8	1.0997	1.8107	.7298		1.6598	.9145	1.0495
9	3.2259	1.5089	.7148	3.7723	1.9616	2.4272	2.5924
10	4.7908	1.6028	.6859	4.5268	2.9424	3.7837	3.5475
11		1.6225		4.7154	2.7161	5.6378	4.5931
12		1.6225		5.2058	2.4768	5.6378	5.6584
13		1.588		4.1495	2.3899	4.9717	4.8663
14		1.627		4.5268	2.2405		4.4136
15		1.7405		5.0549	1.2574		4.904
16	6.1488	1.7405		5.0549	1.1203		5.5453
17	5.4698	1.7027		3.7723	1.1203	4.6963	5.5076
18		1.4757	.6401	3.4294	1.1873		3.0178
19		1.5135	.6722	2.1125	.7811		2.5274
20		1.5545	.6401	2.1502	.6882		2.4897
21	1.8861	.9202		2.3765		2.4118	2.8669
22	2.9047	.7182		2.7538		2.3669	2.6406
23	2.9047	.7519		2.6406			2.3765
24	2.9127	3.0178	.7639	3.7723	2.452	.8383	4.904
Max	6.1488	3.0178	.837	5.2058	2.9424	5.6378	5.6584
Min	1.0997	.7182	.6401	.6722	.6882	.6097	1.0495
Avg	3.4826	1.6990	.7519	3.1696	1.8081	2.2738	3.6413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 303 / 22KV PFIZER FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8192	.9144	.6874	.7407	.7621	
2		.7865	.8996	.7499	.7926	.7621	
3		.7865	.9218	.7316	.7926	.7449	.9081
4		.7865	.8015	.7621	.7621	.6874	
5		.7537	.7202		.7316	.7362	
6		.7537	.6822		.6401	.7011	
7		.7537	.6813		.7621	.7011	
8	.8729	.7865	.7688			.7316	.8697
9	1.173	1.0486	.749	1.2742	.7926	1.2308	1.2145
10		1.5181	.9709	1.4754	1.1203		1.6221
11		1.5181	1.1203	1.576	1.2936		1.773
12		1.5513		1.5424	1.4335		1.8484
13		1.2524		1.3413	1.2178		1.4335
14		1.5892	1.2936	1.4083	1.2803		1.7353
15		1.7405	.8935	1.7436	1.2803		1.6598
16	1.7353	1.627	1.4563	1.7436	1.1203		1.773
17	1.1317	1.5165	1.1203	1.3413	1.086	1.6648	1.5844
18		1.2486	.6668	1.4083			1.2826
19		1.0594	.5335	.9724	1.086		1.0185
20		.9459	.5335	.8383	.8573		.9431
21	.8676	.749		.679		.7993	.9054
22	.9054	.6762		.7099		.834	.9431
23	.9054	.7828		.7099			.8676
24	.8976	.9054	.7828	.5335	.7407	.0892	.8807
Max	1.7353	1.7405	1.4563	1.7436	1.4335	1.6648	1.8484
Min	.8676	.6762	.5335	.5335	.6401	.0892	.8676
Avg	1.0611	1.0815	.8690	1.1114	.9753	.8034	1.2924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 304 / 22KV NOVARTIS EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754	.0751	.0747	.0732	.0686	
2		.0754	.0757	.0747	.0732	.0686	
3		.0754	.0751	.0754	.0732	.0743	.0644
4		.0754	.0757	.0754	.0732	.08	
5		.0754	.0759		.0732	.1486	
6		.0754	.0759		.0732	.0686	
7		.0754	.0759		.0732	.0629	
8	.0757	.0754	.0751		.0732	.0617	.1127
9	.0759	.0754	.0757	.0732	.0732	.061	.1139
10		.0758		.0732	.0754		.1132
11		.0759		.0732	.0754		.1132
12		.0757		.0732	.0457		.1132
13		.1135		.0732	.061		.1132
14		.0757	.0747	.0732	.061		.1132
15		.1135	.0747	.0732	.0457		.1132
16		.0757	.0747	.0732	.0533		.1132
17	.0754	.0757	.0754	.0732	.0472	.0582	.1132
18		.0757	.0754	.0732	.0472		.1132
19		.1135	.0701	.0732	.0709		.1132
20		.1135	.0754	.0732	.0709		.1132
21	.0754	.0757		.0732		.0925	.1132
22	.1132	.0751		.0732		.0613	.1132
23		.1127		.0732			.1132
24	.0751	.0754	.0751	.0732	.0732	.0686	.0879
Max	.1132	.1135	.0759	.0754	.0754	.1486	.1139
Min	.0751	.0751	.0701	.0732	.0457	.0582	.0644
Avg	.0818	.0834	.0750	.0736	.0660	.0750	.1091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 305 / 22KV PHIZER EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0648	.0677	.0686	.0221	.061	
2		.0648	.0683	.0686	.0221	.061	
3		.0648	.0692	.0686	.0229	.0686	.0586
4		.0648	.0683	.0457	.0229	.0686	
5		.0648	.0677		.0229	.0701	
6		.0648	.0683		.0229	.0701	
7		.0648	.0681		.0229	.0457	
8	.0281	.0655	.0697		.0229	.0183	.023
9	.0233	.0655	.0695	.0229	.0229	.0229	.0296
10		.0617	.0191	.0229	.0267		.029
11		.069		.0229	.0235		.029
12		.0683		.0229	.0267		.029
13		.069		.0229			.029
14		.0688	.013	.0229			.029
15		.0713	.0229	.0229			.029
16		.0561	.0229	.0229	.0229		.029
17		.0561	.0343	.0229	.0305	.0296	.029
18		.021	.061	.0229	.061		.029
19		.0256	.0648	.0229	.0686		.029
20		.0424	.0686	.0229	.0693		.029
21	.0229	.0677		.0229		.0608	.029
22	.0251	.0713		.0229		.0683	.029
23		.0703		.0229			.029
24	.0751	.0229	.0695	.0686	.0221	.061	.0683
Max	.0751	.0713	.0697	.0686	.0693	.0701	.0683
Min	.0229	.021	.013	.0229	.0221	.0183	.023
Avg	.0349	.0594	.0552	.0332	.0309	.0543	.0325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 306 / 22KV LUBRIZOL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5089	1.6303	1.5844	1.5844	1.5089	
2		1.5089	1.594	1.1043	1.5089	1.5089	
3		1.5089	1.5211	1.6221	1.5089	1.5089	1.5513
4		1.5089	1.5181	1.6221	1.4335	1.5466	
5		1.5089	1.4801		1.4335	1.5089	
6		1.4712	1.4378		1.3957	1.5089	
7		1.3957	1.4		1.3957	1.5089	
8	1.5181	1.3957	1.3663		1.4335	1.5242	1.3243
9	1.627	1.6221	1.5135	1.6221	1.4335	1.6598	1.556
10		1.6319	1.5844	1.6598	1.4335		1.6598
11		1.7078	1.6221	1.6221	1.4335		1.6975
12		1.7405		1.5844	1.4335		1.6598
13		1.6699		1.5844	1.4335		1.7353
14		1.6648	1.5089	1.5466	1.4335		1.7353
15		1.4422	1.5089	1.5089	1.4335		1.7353
16		1.5135	1.5466	1.4335	1.4335		1.6975
17	1.5089	1.5135	1.5844	1.4335	1.5089	1.627	1.5844
18		1.5892	1.5844	1.4335	1.5089		1.6221
19		1.627	1.7353	1.6221	1.5089		1.6975
20		1.6648	1.6221	1.6975	1.5089		1.6975
21	1.5844	1.594		1.7353		1.6648	1.6598
22	1.5089	1.5892		1.6975		1.5892	1.5089
23		1.5513		1.6221			1.5089
24	1.556	1.3203	1.6319	1.6598	1.5844	1.5089	1.6319
Max	1.627	1.7405	1.7353	1.7353	1.5844	1.6648	1.7353
Min	1.5089	1.3203	1.3663	1.1043	1.3957	1.5089	1.3243
Avg	1.5506	1.5520	1.5469	1.5698	1.4658	1.5518	1.6257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 307 / 22KV NANDKAMAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0023	.0229	.0114	.0011	
2		.0171	.0021	.0343	.0114	.0115	
3		.0149	.0022	.0229	.0122	.0343	.0021
4		.0149	.0023	.1029	.0122	.0183	
5		.0171	.0029	.0011	.0122	.016	
6		.0171	.0025	.0114	.0145	.0149	
7		.0171	.0023	.0114	.0145	.016	
8	.0023	.0171	.0021	.0114	.0145	.0149	.0023
9	.0022	.0171	.0021	.0183	.0145	.0194	.0023
10	.0145	.0021	.0114	.0183	.0103		.0229
11	.0145	.0021	.0114	.0122	.0126		.0229
12	.0145	.0021		.0122	.0137		.0137
13	.0217	.0021		.0122	.0023		.0137
14	.0217	.0026	.1143	.0122	.0229		.016
15	.0217	.0017	.0572	.0122	.0229		.016
16	.0217	.0021	.0171	.0122	.0023		.016
17	.0217	.0029	.0171	.0122	.0229	.0022	.016
18		.0021	.0171	.0122	.0229		.016
19		.0021	.0251	.0122	.0229		.016
20		.0021	.0274	.0122	.0229		.016
21	.0217	.0021		.0122		.0023	.016
22	.0217	.0021		.0122		.0021	.016
23		.0021		.0122			.016
24	.0022	.0263	.0114	.0274	.0114	.0114	.0022
Max	.0217	.0263	.1143	.1029	.0229	.0343	.0229
Min	.0022	.0017	.0021	.0011	.0023	.0011	.0021
Avg	.0155	.0086	.0174	.0184	.0146	.0126	.0135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 308 / 22KV BALMER LAWARIE NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS FE Feeder KV- 22 / (CONTINUOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8484	1.9258	1.8861	1.6221	1.1317	
2		1.8861	1.8976	1.8107	2.037	1.1317	
3		1.8484	1.8578	1.8107	1.8861	1.2449	1.6319
4		1.8107	1.8198	1.6975	1.773	1.1694	
5		1.8107	1.7078		1.1317	1.2574	
6		1.5844	1.7405		1.1317	1.3203	
7		1.5089	1.7078		1.094	1.7353	
8	1.6699	1.7353	1.556		1.2449	1.8861	1.7784
9	2.0494	1.9993	1.8162	1.8107	1.2449	1.8861	2.0494
10		2.0432		2.037	1.3203		1.8861
11		2.1189		1.9993	1.3203		2.1879
12		2.0094		1.773	1.2071		2.037
13		2.0054		1.773	1.2826		1.9993
14		1.9735	1.9239	1.8107	1.2826		1.6598
15		1.7405	1.9387	1.8484	1.3336		1.8861
16		1.7027	1.8107	3.0178	1.3203		2.037
17	1.4335	1.6648	1.6221	1.8107	1.3203	1.6648	1.773
18		2.1632	1.8107	1.7353	1.3203		2.0748
19		1.8919	1.9993	1.8484	1.3203		1.8861
20		1.6648	1.5089	1.5844	1.3203		1.8861
21	1.5844	1.8919		1.8861		1.9355	1.9993
22	1.8861	1.7405		1.9616		1.327	.1132
23		1.5892		1.773			1.7353
24	2.1253	1.9616	1.9307	1.8861	1.8861	1.1317	1.173
Max	2.1253	2.1632	1.9993	3.0178	2.037	1.9355	2.1879
Min	1.4335	1.5089	1.5089	1.5844	1.094	1.1317	.1132
Avg	1.7914	1.8414	1.7985	1.8880	1.4000	1.4478	1.7663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283028 / 22/22KV Turbhe MIDC Swt/Stn

Feeder No / Name : 309 / 22KV PHIZER PHARMA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEE Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2987	.3006	.2641	.3018	.3018	
2		.2987	.3033	.2641	.3018	.3018	
3		.3018	.3036	.2641	.3018	.415	.4162
4		.3018	.3036	.2641	.3018	.5281	
5		.2987	.3405		.3018	.4527	
6		.2614	.3416		.3018	.4904	
7		.2614	.3416		.3018	.4904	
8	.4175	.3734	.4934		.3018	.4904	.4919
9	.5297	.4854	.6054	.3772	.3018	.679	.6432
10	.5228	.454	.6036	.4904	.2987		.6036
11	.5975	.4919	.6413	.5281	.2987		.679
12	.5601	.5297		.6036	.3018		.5658
13	.4854	.4934		.5658	.3395		.679
14	.6036	.5676	.6413	.5658	.3018		.7167
15	.5658	.5693	.5281	.3395	.3018		.6036
16	.5281	.5676	.5281	.3772	.3018		.6413
17	.6413	.5676	.5281	.3018	.3018	.7189	.5658
18		.5693	.4527	.3018	.3018		.5281
19		.4919	.4527	.3395	.3018		.5281
20		.4554	.4904	.3018	.3018		.4904
21	.3018	.5313		.3395		.454	.4904
22	.3018	.3412		.3018		.455	.4527
23		.3405		.3018			.4527
24	.3416	.3018	.3006	.2987	.3018	.3018	.4175
Max	.6413	.5693	.6413	.6036	.3395	.7189	.7167
Min	.3018	.2614	.3006	.2641	.2987	.3018	.4162
Avg	.4921	.4231	.4474	.3695	.3033	.4676	.5537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 303 / 22KV KUKSHET FEEDER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.8413	.8871	.788	.7087	.6859	.7011
2	.6859	.7362	.8413	.7164	.6935	.6783	.6859
3	.7362	.8326	.788	.7164	.7122	.6935	.7442
4	.7442	.8413	.7362	.7087	.7011	.6859	.7362
5	.6783	.8238	.6783	.7164	.7282	.6859	.6859
6	.663	.788	.6706	.7087	.6706	.6859	.6935
7	.6249	.8238	.663	.7087	.6859	.6935	.6859
8	.788	.8238	.7011	.7442	.6935	.6935	.7011
9	.7964	.7964	.788	.7362	.7087	.724	.7602
10	1.094	1.094	.9709	.7964	.8048	.9145	.8779
11	.961	.9979	.924	.8131	.7602	.7442	.9145
12	.9145	.924	.8779	.8501	.7964	.6935	.9335
13	.7442	.7468	.8326	.7602	.7087	.7011	.7964
14	.788	.9054	.8501	.8962	.7602	.8501	.8048
15	.8871	.8676	.7011	.9054	.7087	.8871	.7522
16	.7011	.9054	.6783	.7011	.7011	.7602	.7522
17	.7011	.9054	.663	.7011	.6706	.7316	.724
18	.7087	.724	.6478	.6859	.5944	.6859	.6783
19	.6859	.7087	.6249	.663	.5792	.6554	.6783
20	.6249	.6706	.5335	.6478	.5487	.602	.5944
21	.5716	.6325	.602	.5563	.5258	.6097	.5868
22	.6401	.6554	.6401	.5639	.5182	.6173	.6554
23	.7011	.8413	.7602	.7087	.6554	.7011	.6325
24	.6706	.6935	.8871	.7522	.7164	.6783	.6935
Max	1.094	1.094	.9709	.9054	.8048	.9145	.9335
Min	.5716	.6325	.5335	.5563	.5182	.602	.5868
Avg	.7412	.8158	.7478	.7310	.6813	.7108	.7279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 304 / 22KV TATA TELE NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	1.0669	1.0669	1.0669	1.105	1.0669	1.105
2	1.0669	1.0669	1.105	1.0288	1.0288	1.0669	1.0288
3	1.105	1.0288	1.0669	1.0288	1.0669	1.105	1.0669
4	1.0669	1.0288	1.0669	1.0669	1.0669	1.0669	1.0669
5	1.0288	.9907	1.0288	1.0669	1.105	1.0288	1.105
6	1.0669	1.0288	1.0669	1.0669	1.0669	1.0288	1.0669
7	1.0288	1.0669	1.105	1.105	1.0669	1.1431	1.0669
8	1.1431	1.105	1.1431	1.105	1.105	1.1431	1.1431
9	1.1812	1.1812	1.2193	1.1431	1.0669	1.1812	1.1431
10	1.5623	1.4861	1.6004	1.2955	1.105	1.6004	1.6004
11	1.5623	1.6004	1.6004	1.3717	1.1812	1.7147	1.7147
12	1.6385	1.6385	1.6385	1.448	1.2193	1.7147	1.6385
13	1.5242	1.5623	1.6385	1.448	1.1812	1.6766	1.7147
14	1.6004	1.6385	1.5623	1.4861	1.2574	1.7147	1.6766
15	1.6385	1.6385	1.6766	1.448	1.2955	1.6766	1.7528
16	1.6766	1.6385	1.6385	1.448	1.2193	1.6766	1.6766
17	1.5242	1.6385	1.6004	1.3717	1.2193	1.6766	1.6385
18	1.5242	1.5623	1.5623	1.2574	1.1812	1.5623	1.6385
19	1.3717	1.448	1.4098	1.1812	1.1812	1.3336	1.4098
20	1.2574	1.2955	1.1812	1.2193	1.0669	1.2193	1.2955
21	1.1812	1.2193	1.1431	1.2193	1.105	1.1431	1.1812
22	1.105	1.1431	1.1812	1.1431	1.105	1.1431	1.1812
23	1.0669	1.1431	1.105	1.0669	1.105	1.105	1.105
24	1.0669	1.0288	1.105	1.105	1.105	1.0669	1.1431
Max	1.6766	1.6385	1.6766	1.4861	1.2955	1.7147	1.7528
Min	1.0288	.9907	1.0288	1.0288	1.0288	1.0288	1.0288
Avg	1.2955	1.3019	1.313	1.2161	1.1336	1.3273	1.3400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 305 / 22KV NANDKAMAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 22 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.9907	1.1431	.9526	.5716	1.0669	1.1812
2	1.105	.9145	1.1812	1.0669	.8002	1.105	1.1431
3	1.0288	.9145	1.105	1.0669	.9145	1.105	1.105
4	1.0669	.9526	1.0669	1.1431	1.0288	1.1431	1.0669
5	1.0669	.9907	1.1431	1.2574	1.105	1.105	1.0288
6	.9907	.9526	1.1812	1.1431	1.0669	1.105	1.1431
7	.4191	.9907	1.2193	1.1812	1.0288	1.448	1.2193
8	.6097	.9526	1.3336	1.2574	1.0288	1.448	1.5623
9	.6859	1.0669	1.3717	1.6385	1.0288	1.6766	1.6766
10	.724	1.2193	1.4098	1.4861	1.0288	1.7147	1.6766
11	1.2574	1.7528	1.4098	1.3336	1.0669	1.7909	1.7909
12	1.1431	.8383	1.4861	1.4098	1.0669	1.829	1.7909
13	1.0669	1.1431	1.448	1.1431	1.0288	1.7528	1.6766
14	1.4861	1.6766	1.448	1.2574	1.0288	1.7147	1.5242
15	1.5242	1.829	1.4098	1.3336	1.0669	1.7909	.8383
16	1.5623	1.6766	1.4098	1.3336	.9526	1.7528	.9145
17	1.6766	1.7528	1.2955	1.2955	1.0669	1.7528	.7621
18	1.448	1.448	1.1431	1.2193	1.0669	1.6385	.5335
19	1.2955	1.4098	1.105	1.2574	1.1431	1.4098	.4191
20	1.1812	1.2574	1.105	1.2574	1.105	1.3336	.3429
21	1.0669	1.2193	.9907	1.2955	1.1431	1.2955	.3429
22	1.0288	1.1812	.9526	1.105	1.1431	1.2193	.3429
23	.9907	1.1812	.9526	1.1431	1.105	1.1812	.3048
24	1.1812	.9907	1.1431	.9145	.6097	1.105	1.1812
Max	1.6766	1.829	1.4861	1.6385	1.1431	1.829	1.7909
Min	.4191	.8383	.9526	.9145	.5716	1.0669	.3048
Avg	1.1145	1.2209	1.2273	1.2288	1.0082	1.4368	1.0653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 307 / 22KV KUKSHET FEEDER NO. -
5 Feeder KV- 22 / OUTGOING

DATE	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.3951	3.2819	3.0556	3.6969
2		3.3573	3.3951	3.0178	3.9247
3		3.3196	3.3573	2.9424	3.6214
4		3.3951	3.2442	2.9801	3.6969
5		3.3951	3.3196	3.0178	3.9609
6		3.4328	3.546	2.9424	4.0741
7		3.5082	3.2819	3.0178	3.9609
8		3.8855	4.4136	3.0933	4.7154
9		4.9417	4.5645	4.5268	5.1303
10		5.6584	4.5268	5.3944	6.262
11		5.583	3.9232	5.2812	5.3944
12		4.9417	4.5645	6.1111	6.941
13		5.0549	3.9232	5.3944	4.1872
14		3.8477	3.4705	3.7346	4.4513
15		4.4136	4.3381	5.9225	5.583
16		6.2243	3.8855	6.1866	5.8093
17		6.0734	3.0933	5.583	5.6584
18		4.9794	2.9424	5.3944	4.6399
19	2.4897	4.1152	3.0178	3.9986	4.1495
20	2.5274	3.81	3.0178	3.6969	4.3381
21	3.5082	3.8477	3.0178	3.3573	3.3196
22	3.5082	3.9609	2.9424	3.9986	4.5268
23	3.3573	3.7346	3.0178	3.7723	3.8477
24		3.4705	3.5082	3.0178	3.81
Max	3.5082	6.2243	4.5645	6.1866	6.941
Min	2.4897	3.3196	2.9424	2.9424	3.3196
Avg	3.0782	4.2644	3.5664	4.1432	4.5708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 308 / 22KV KUKSHET FEEDER NO. -
6 Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.5911	1.829	1.7528
2	2.4768	1.7147	1.9814
3	2.3624	1.5242	2.0576
4	2.0576	1.5242	1.829
5	2.1338	1.8671	2.1338
6	2.0576	1.7147	2.0195
7	1.6004	1.6766	1.7528
8	1.8671	1.6385	1.829
9	3.4675	2.6673	2.7054
10	3.0483	3.1245	
11	3.0483	4.0009	
12	3.8485	3.8104	
13	4.039	3.8485	
14	3.0864	3.4294	
15	3.0864	3.5818	
16	3.9628	4.1914	
17	3.1626	3.8104	
18	2.7435	3.1626	
19	2.4768	2.2481	
20	2.0576	2.1338	
21	1.9814	2.4768	
22	2.0195	2.7816	
23	1.8671	2.553	
24	2.4006	1.829	2.5149
Max	4.039	4.1914	2.7054
Min	1.6004	1.5242	1.7528
Avg	2.6435	2.6308	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

BHANDUP (U) ZONE[053]

WASHI CIRCLE[565]

WASHI DIVISION[404]

WASHI O&M S/DN.[127] BU 4127

Substation No/ Name :- 283031 / 22/22KV Kukshet Swt/Stn

Feeder No / Name : 309 / 22KV KUKSHET FEEDER NO. -
7 Feeder KV- 22 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7538	2.6406	2.452	1.9616	3.4328	2.9801	3.8855
2	2.5652	2.5652	2.3388	2.2634	3.546	3.0178	3.6969
3	2.6406	2.452	2.3011	2.2634	3.3951	2.9424	3.6214
4	2.452	2.2634	2.452	2.2634	3.3196	2.9424	3.4705
5	2.5652	2.4897	2.3765	2.1125	3.2065	3.0178	3.3196
6	2.4897	2.7538	2.6292	2.0748	3.3573	3.0933	3.0556
7	1.9616	3.3951	2.452	2.1125	3.2442	3.2065	3.0178
8	2.1125	3.7723	2.3765	2.2634	3.131	3.2442	2.3011
9	2.6029	4.9417	2.8669	2.8292	3.2819	3.81	3.1687
10	3.4328	5.5453	2.5652	4.5268	3.7723	4.904	3.9609
11	3.81	3.5082	3.7723	4.8285	3.8477	5.3189	
12	4.225	3.8855	4.7531	5.2812	4.3759	6.0357	4.3759
13	3.81	3.9609	4.7908	4.9417	3.8855	5.3567	5.3189
14	4.0364	3.8855	4.5645	4.904	3.3951	5.5076	5.2058
15	4.3004	3.7723	4.3004	4.8285	3.5837	4.9794	5.5076
16	6.5261	3.9609	3.7723	4.6776	3.4328	5.3567	4.7908
17	6.4129	4.4136	4.2627	4.6399	3.1687	5.0549	4.9417
18	3.8477	3.0178	3.6591	4.7154	2.7538	4.7908	4.1118
19	3.4328	2.6029	3.1687	3.9232	2.7915	3.9986	3.8477
20	2.3011	2.4897	3.2442	3.5082	2.4897	3.2065	3.1687
21	2.2634	2.452	1.8861	3.2819	2.4897	2.7915	3.2819
22	2.2634	2.7915	1.5089	3.2065	2.9424	2.8669	3.3951
23	2.6406	2.5652	1.9993	3.546	3.131	3.4328	3.2819
24	2.7054	2.6406	2.6673	1.8484	3.8855	3.0556	3.3951
Max	6.5261	5.5453	4.7908	5.2812	4.3759	6.0357	5.5076
Min	1.9616	2.2634	1.5089	1.8484	2.4897	2.7915	2.3011
Avg	3.2563	3.2819	3.0483	3.4501	3.3275	3.9546	3.8313