

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 201 / 11KV GANESHWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.6658    | 2.8029    | 2.8715    | 2.9279    | 2.9188    | .8627     | .8688     |
| 2    | 2.6109    | 2.8288    | 2.8487    | 2.9233    | 2.8868    | .8657     | .8733     |
| 3    | 2.6505    | 2.8121    | 2.8197    | 2.8365    | 2.8746    | .8749     | .8855     |
| 4    | 2.8304    | 2.9858    | 2.8593    | 2.9066    | 2.8365    | .8825     | .9023     |
| 5    | 3.2648    | 3.2602    | 3.1078    | 2.934     | 2.9538    | .8855     | .9175     |
| 6    | 3.6717    | 3.5223    | 3.3577    | 3.2693    | 3.1306    | .6798     | .9236     |
| 7    | 4.161     | 3.8287    | 4.0177    | 4.0985    | 3.9278    |           |           |
| 8    | 4.5085    | 3.9918    | 4.1549    | 4.0863    | 4.1198    |           |           |
| 9    | 4.4033    | 4.0405    | 4.1335    | 4.039     | 4.0512    |           |           |
| 11   |           |           |           |           |           | 2.2954    | 2.3685    |
| 12   |           |           |           |           |           | 4.0466    | 4.0299    |
| 13   |           |           |           |           |           | 4.2265    | 3.629     |
| 14   |           |           |           |           |           | 3.9826    | 4.1       |
| 15   |           |           |           |           |           | 3.9354    | 4.1076    |
| 16   |           |           |           |           |           | 3.719     | 3.879     |
| 17   | .0625     |           |           |           | .381      | 3.7997    | 3.8698    |
| 18   | .8352     | .8337     | .8368     | .5014     | .8261     | 3.8089    | 3.6366    |
| 19   | .8947     | .8642     | .9054     | .9099     | .8871     | 3.3699    | 2.7618    |
| 20   | .8581     | .8474     | .9099     | .9313     | .8855     | .8932     | .8794     |
| 21   | .8383     | .8246     | .8612     | .8947     | .8535     | .8825     | .881      |
| 22   | .8215     | .7895     | .8307     | .8627     | .8383     | .8551     | .8459     |
| 23   | 1.7513    | 2.1506    | 2.2527    | 1.9662    | .8551     | .8642     | .8612     |
| 24   | 3.4172    | 2.7984    | 2.9325    | 2.9675    | .8612     | .8688     | .8551     |
| Max  | 4.5085    | 4.0405    | 4.1549    | 4.0985    | 4.1198    | 4.2265    | 4.1076    |
| Min  | .0625     | .7895     | .8307     | .5014     | .381      | .6798     | .8459     |
| Avg  | 2.3674    | 2.4488    | 2.4813    | 2.4409    | 2.1228    | 2.1299    | 2.1038    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 202 / 11 KV SONAI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6249     |
| Max  | .6249     |
| Min  | .6249     |
| Avg  | .6249     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 203 / 11 KV HANUMANWADI  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6401     |
| Max  | .6401     |
| Min  | .6401     |
| Avg  | .6401     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 204 / 11 KV MSSK

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    | .0457     | .0457     |           | .0457     |
| 10   | .0305     | .0305     |           | .0457     |
| 11   | .0305     | .0305     |           | .0305     |
| 12   | .0305     | .0305     |           | .0305     |
| 13   | .0305     | .0457     |           | .0305     |
| 14   | .0305     | .0305     |           | .0305     |
| 15   | .0305     | .0457     |           | .0457     |
| 16   | .0305     | .0457     | .0457     | .0305     |
| 17   | .0305     | .0305     | .0457     | .0305     |
| 18   | .0305     | .0457     | .0305     |           |
| 19   | .0305     | .0457     | .0305     |           |
| 20   | .0457     | .0457     | .0457     |           |
| 21   | .0457     |           | .0152     |           |
| 24   | .7621     |           |           |           |
| Max  | .7621     | .0457     | .0457     | .0457     |
| Min  | .0305     | .0305     | .0152     | .0305     |
| Avg  | .0860     | .0394     | .0356     | .0356     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 205 / 11 KV SHINGNAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.7071    |           | 1.6461    |
| 2    | 1.5851    |           | 1.5851    |
| 3    | 1.6461    |           | 1.5851    |
| 4    | 1.768     |           | 1.5851    |
| 5    | 1.89      |           | 1.7071    |
| 6    | 2.0729    |           | 1.9509    |
| 7    | 2.6825    |           | 2.4387    |
| 8    | 3.5361    |           | 3.1703    |
| 9    | 3.658     |           | 3.2922    |
| 10   |           |           | .6097     |
| 24   | .6859     | 1.5851    |           |
| Max  | 3.658     | 1.5851    | 3.2922    |
| Min  | .6859     | 1.5851    | .6097     |
| Avg  | 2.1232    | 1.5851    | 1.9570    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 207 / 11 KV BELHEKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.829     |
| Max  | 1.829     |
| Min  | 1.829     |
| Avg  | 1.829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 208 / 11 KV LOHAGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           | .1021     |           | .0549     |
| 5    |           | .1631     | .0655     | .16       |
| 6    |           | .1677     | .1448     | .1707     |
| 7    |           |           | .0793     | .1052     |
| 12   |           | 3.2876    | 3.5452    |           |
| 13   |           | 3.9339    | 3.7997    |           |
| 14   |           | 3.8272    | 3.6046    |           |
| 15   |           | 3.6961    | 3.8089    |           |
| 16   |           | 3.8653    | 3.8805    |           |
| 17   |           | 3.7708    | 3.7296    |           |
| 18   |           | 3.6153    | 3.597     |           |
| 19   |           | 3.5452    | 3.344     |           |
| 20   |           | 2.8319    | 2.7877    |           |
| 21   |           | .2972     | .2439     |           |
| 22   |           | .2911     | .2423     |           |
| 23   |           | .3018     | .2454     |           |
| 24   | .6859     | .1905     | .1539     |           |
| Max  | .6859     | 3.9339    | 3.8805    | .1707     |
| Min  | .6859     | .1021     | .0655     | .0549     |
| Avg  | .6859     | 2.1179    | 2.0795    | .1227     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 209 / 11 KV DHANGARWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12   |           | 3.0483    | 2.5911    |           |           |
| 13   | 3.3227    | 3.4751    | 3.0483    | 7.7732    |           |
| 14   | 3.5665    | 3.4141    | 3.0483    | 2.3167    |           |
| 15   | 3.5361    | 3.3227    | 2.8959    | 3.0788    |           |
| 16   | 3.1703    | 3.3227    | 2.8045    | 2.8654    |           |
| 17   | 3.3532    | 3.2007    | 2.652     | 3.0178    |           |
| 18   | 3.3227    | 2.9874    | 2.5301    | 2.2253    |           |
| 19   | 3.1703    | 2.5911    | 2.5606    | 2.652     |           |
| 20   | 1.0669    | .5792     | .8535     | .7926     |           |
| 24   | .3429     |           |           |           | 1.4022    |
| Max  | 3.5665    | 3.4751    | 3.0483    | 7.7732    | 1.4022    |
| Min  | .3429     | .5792     | .8535     | .7926     | 1.4022    |
| Avg  | 2.7613    | 2.8824    | 2.5538    | 3.0902    | 1.4022    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 210 / 11 KV LANDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.1535    | 2.9401    | 2.998     | 2.8662    | 2.8174    | .5114     | .5159     |
| 2    | 3.1276    | 2.9668    | 2.95      | 2.8814    | 2.6757    | .5159     | .5258     |
| 3    | 3.1146    | 2.931     | 2.9279    | 2.8098    | 2.6635    | .5182     | .538      |
| 4    | 2.9355    | 2.8578    | 2.979     | 2.8014    | 2.6894    | .5426     | .5556     |
| 5    | 2.9203    | 2.9843    | 3.1291    | 2.886     | 2.8532    | .5731     | .5998     |
| 6    | 3.2808    | 3.1916    | 3.5033    | 3.0079    | 3.0323    | .5784     | .6241     |
| 7    | 3.6008    | 3.4629    | 3.6412    | 3.235     | 3.4919    | .0008     | .0114     |
| 8    | 1.7231    | 3.9735    | 3.8165    | 3.8409    | 3.7144    |           | .0076     |
| 9    | 1.3839    | 3.3532    | 3.9201    | 3.7974    | 3.7045    |           | .0076     |
| 10   | .0038     | .003      | .0008     | .0015     | .1052     | .0008     | .0099     |
| 11   | .0023     |           |           | .003      |           | .0107     | .0084     |
| 12   |           |           |           | .0023     | .0114     | 3.594     | 3.309     |
| 13   |           |           | .0008     | .0023     | .0076     | 3.5284    | 3.328     |
| 14   |           |           | .0008     | .0023     | .0008     | 4.0253    | 3.5551    |
| 15   | .013      |           | .0015     | .0023     |           | 4.0093    | 3.4835    |
| 16   | .0038     |           | .0023     | .0008     |           | 3.437     | 3.2853    |
| 17   |           |           | .0023     | .0008     |           | 3.28      | 2.8791    |
| 18   | .4534     | .4481     | .4649     |           | .442      | 3.5726    | 2.9271    |
| 19   | .5655     | .5571     | .5586     | .5845     | .5693     | 3.3394    | 2.4592    |
| 20   | .6485     | .6089     | .5838     | .6142     | .6287     | .5792     | .5685     |
| 21   | .6272     | .5914     | .5677     | .5891     | .6158     | .5807     | .5898     |
| 22   | .5876     | .5777     | .5617     | .5693     | .5929     | .599      | .5754     |
| 23   | .567      | .7773     | .6821     | .5289     | .5548     | .5738     | .5464     |
| 24   | 3.3982    | 2.963     | 2.8037    | 2.7839    | .5144     | .5205     | .4923     |
| Max  | 3.6008    | 3.9735    | 3.9201    | 3.8409    | 3.7144    | 4.0253    | 3.5551    |
| Min  | .0023     | .003      | .0008     | .0008     | .0008     | .0008     | .0076     |
| Avg  | 1.6055    | 2.0699    | 1.6407    | 1.4701    | 1.5843    | 1.5860    | 1.3085    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014055 / 33/11 KV SONAI

Feeder No / Name : 211 / MORECHINCHORE GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .1315     | .1296     | .1276     |
| 2    |           | .1334     | .1284     | .1265     |
| 3    |           | .1322     | .1242     |           |
| 4    |           | .1478     | .1395     |           |
| 5    |           | .1799     | .1734     |           |
| 6    |           | .2332     | .2271     |           |
| 7    |           | .3128     | .2816     |           |
| 8    |           | .3448     | .3037     |           |
| 9    |           | .3311     | .3018     |           |
| 10   |           | .3052     | .2896     |           |
| 11   |           |           | .2595     |           |
| 12   |           | .1993     | .2225     |           |
| 13   |           | .2046     | .1978     |           |
| 14   |           | .1905     | .1387     |           |
| 15   |           | .1802     | .1475     |           |
| 16   |           | .1478     | .1745     |           |
| 17   |           | .1764     | .1844     |           |
| 18   |           | .2214     | .1867     |           |
| 19   |           | .2351     | .2252     |           |
| 20   |           | .2572     | .2724     |           |
| 21   |           | .2294     | .2416     |           |
| 22   |           | .1791     | .2176     |           |
| 23   |           | .1635     | .1791     |           |
| 24   | .6859     | .1429     | .1364     |           |
| Max  | .6859     | .3448     | .3037     | .1276     |
| Min  | .6859     | .1315     | .1242     | .1265     |
| Avg  | .6859     | .2078     | .2035     | .1271     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 201 / 11 KV CHANDA OLD(AG)  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 202 / 11 KV GHODEGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6097     |
| Max  | .6097     |
| Min  | .6097     |
| Avg  | .6097     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 203 / 11 KV SHASTRINAGAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | 1.3927    |           |           |
| 2    |           |           |           | 1.3927    |           |           |
| 3    |           | 1.1888    | 1.286     | 1.3923    |           | .1219     |
| 4    |           |           |           | 1.3927    |           |           |
| 5    |           | 1.7985    |           | 1.4575    |           |           |
| 6    |           |           | 1.7833    | 1.6194    |           |           |
| 7    | 2.0233    |           |           | 2.0873    |           |           |
| 8    |           | 2.2862    | 2.2977    | 2.4806    |           |           |
| 9    | 2.3148    | 2.2558    | 2.4863    | 2.3482    | 2.34      |           |
| 12   |           |           |           |           |           | 2.5101    |
| 18   |           |           | .0754     |           |           | 2.625     |
| 19   | .1219     | .1017     | .1886     |           | .1715     |           |
| 20   |           |           | .1698     |           | .1715     |           |
| 21   |           |           | .1509     |           |           |           |
| 22   |           |           | .1132     |           |           |           |
| 23   | .1219     |           | .0754     |           | .1219     |           |
| 24   | .8573     | 1.1888    | 1.2887    | 1.3272    |           |           |
| Max  | 2.3148    | 2.2862    | 2.4863    | 2.4806    | 2.34      | 2.625     |
| Min  | .1219     | .1017     | .0754     | 1.3272    | .1219     | .1219     |
| Avg  | 1.0878    | 1.4700    | .9014     | 1.6891    | .7012     | 1.7523    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 204 / 11 KV KAUTHA MIRI ROAD(AG) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5792     | .57       | .5228     | 1.0681    | .5761     | 1.2407    | 2.535     |
| 2    | .6066     | .5914     | .5594     | 1.0961    | .5959     | 1.3321    | 2.4943    |
| 3    | .9884     | .5228     | .9112     | 1.0047    | .9991     | 2.5324    | 2.4814    |
| 4    | .0884     |           |           |           | .6219     | 1.4708    | 2.6677    |
| 5    |           |           |           |           | .3353     | 1.7314    | 2.9538    |
| 6    |           |           |           |           |           | 3.8192    | 3.7635    |
| 7    |           |           |           |           |           | 5.0693    | 5.5289    |
| 8    |           |           |           |           |           | 5.7987    | 6.0467    |
| 9    |           |           |           |           |           | 4.2688    | 2.4554    |
| 11   |           | 2.463     | .7042     | 2.0561    | 2.4249    |           |           |
| 12   | .8871     | 4.9562    | 4.9634    | 5.141     | 5.1212    |           |           |
| 13   | 2.9782    | 2.7557    | 4.7897    | 5.3792    | 2.6536    |           |           |
| 14   | 2.963     | 2.7907    | 4.7241    | 2.8685    | 5.032     |           |           |
| 15   | 2.6139    | 2.7359    | 4.5039    | 2.7481    | 2.5438    |           |           |
| 16   | 1.5196    | 2.8807    | 4.422     | 2.9813    | 5.0549    |           |           |
| 17   | 3.1398    | 2.7603    | 4.012     | 2.9279    | 2.6536    | .413      |           |
| 18   | 2.9157    | 2.7039    | 4.5171    | 2.7389    | 2.5347    | .982      |           |
| 19   | 2.1171    | 3.972     | 3.1562    | 2.3914    | 3.6933    | .3765     | .7362     |
| 20   | .7362     | .7057     | 1.3546    | .7011     | 1.2277    | 1.2834    | .6523     |
| 21   | .6996     | .6722     | 1.2879    | .6234     | .5594     | 1.0528    | .6066     |
| 22   | .6158     | .6173     | 1.1983    | .6112     | .4603     | .893      | .4877     |
| 23   | .5777     | .5411     | 1.062     | .5838     | 1.5108    | 1.5662    | 1.291     |
| 24   | 1.0364    | .9907     | .9688     | 1.0293    | 1.6118    | 2.4455    | 2.4235    |
| Max  | 3.1398    | 4.9562    | 4.9634    | 5.3792    | 5.1212    | 5.7987    | 6.0467    |
| Min  | .0884     | .5228     | .5228     | .5838     | .3353     | .3765     | .4877     |
| Avg  | 1.4743    | 1.9547    | 2.5681    | 2.1147    | 2.1163    | 2.1339    | 2.4749    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 205 / 11 KV WANJOLI EXPRESS      NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 11 / OUTGOING      UTILITY

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .061      | .1153     |           |           | .0189     |
| 2    |           |           |           | .117      |           |           | .0189     |
| 3    |           | .0171     | .0183     | .117      |           |           | .0189     |
| 4    |           |           |           | .117      |           |           | .0187     |
| 5    |           | .0152     |           | .117      |           |           | .0187     |
| 6    |           |           | .017      | .1334     |           | .0183     | .0183     |
| 7    | .0171     |           | .0762     | .0634     |           |           | .0181     |
| 8    |           | .0179     | .1119     | .1977     |           | .0183     | .0183     |
| 9    | .0171     | .0183     | .0549     | .213      | .0183     | .0181     |           |
| 10   | .1067     |           | .1859     | .1219     |           | .0354     |           |
| 11   | .061      |           | .2153     | .1372     |           |           |           |
| 12   | .061      |           | .2233     | .1219     | .0366     | .0177     |           |
| 13   | .1124     |           | .1319     | .0914     |           |           |           |
| 14   | .061      |           | .1607     | .0914     | .0328     |           |           |
| 15   | .061      |           | .1977     | .0457     |           |           |           |
| 16   | .061      |           | .213      | .0457     | .0343     | .0532     | .0305     |
| 17   |           | .0819     | .1429     | .0457     |           | .0543     | .0305     |
| 18   |           |           | .1294     |           |           | .0181     |           |
| 19   | .0171     | .0183     | .1819     |           | .0366     | .0181     |           |
| 20   |           |           | .1486     |           | .0183     | .0183     |           |
| 21   |           |           | .1176     |           |           | .0183     |           |
| 22   |           |           | .1364     |           |           | .0183     |           |
| 23   | .0171     |           | .117      |           | .0171     | .0183     |           |
| 24   | .0171     | .0781     | .1159     | .0543     |           | .0183     | .0189     |
| Max  | .1124     | .0819     | .2233     | .213      | .0366     | .0543     | .0305     |
| Min  | .0171     | .0152     | .017      | .0457     | .0171     | .0177     | .0181     |
| Avg  | .0508     | .0353     | .1313     | .1081     | .0277     | .0245     | .0208     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 206 / 11 KV CHANDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4115     |           |           | .6809     |           |           | .7893     |
| 2    | .381      |           |           | .6498     |           |           | .7735     |
| 3    | .3658     | .3353     | .3086     | .6651     |           | .4115     | .7583     |
| 4    | .4115     |           |           | .7545     |           |           | .8356     |
| 5    | .503      | .4572     |           | .9193     |           |           | .9956     |
| 6    | .7316     |           | .6401     | 1.2499    |           | .7545     | 1.3942    |
| 7    | 1.6099    |           |           | 1.4929    |           |           | 1.5851    |
| 8    | .945      | .6401     | .7316     | 1.4327    | .8059     | .6097     |           |
| 9    | 1.589     | .5944     | 1.6318    | .0152     |           | 1.5632    |           |
| 10   | .7621     |           | 1.3131    | .7011     |           | 1.3717    |           |
| 11   | .5944     |           | 1.2509    | .6097     |           | .6554     |           |
| 12   | .6097     | .4744     | 1.041     | .9622     | .4572     | .9145     |           |
| 13   | .9145     |           | .8078     | .8992     |           | .4877     |           |
| 14   | .503      |           | .3121     | .4268     | .381      | .4572     |           |
| 15   | .0914     |           | .7236     | .4268     |           |           |           |
| 16   |           |           | .7773     | .503      |           |           |           |
| 17   |           |           | .9603     | .5639     |           |           |           |
| 18   |           |           | 1.2346    |           |           | .6167     |           |
| 19   | .8078     | .7621     | 1.5851    |           | .7888     | .8078     |           |
| 20   |           |           | 1.6613    |           | .8139     | 1.7655    |           |
| 21   |           |           | 1.326     |           |           | 1.5289    |           |
| 22   |           |           | 1.0824    |           |           | 1.2184    |           |
| 23   | .3506     |           | .9374     |           | .3932     | 1.0055    |           |
| 24   | .3772     | .3353     | .8231     | .2778     | .3429     | .8383     | .3201     |
| Max  | 1.6099    | .7621     | 1.6613    | 1.4929    | .8139     | 1.7655    | 1.5851    |
| Min  | .0914     | .3353     | .3086     | .0152     | .3429     | .4115     | .3201     |
| Avg  | .6644     | .5141     | 1.0078    | .7350     | .5690     | .9379     | .9315     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014066 / 33/11KV GHODEGAON

Feeder No / Name : 207 / 11 KV GHODEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .442      |           |           | .8935     |           |           | .9249     |
| 2    | .4572     |           |           | .8935     |           |           | .9249     |
| 3    | .4725     | .4115     | .4424     | .9087     |           | .4801     | .9249     |
| 4    | .5182     |           |           | .9915     |           |           | .9768     |
| 5    | .6249     | .5182     |           | 1.1619    |           |           | 1.1157    |
| 6    | .7926     |           | .7316     | 1.5699    |           | .8059     | 1.3964    |
| 7    | 1.9643    |           |           | 1.8747    |           |           | 1.8598    |
| 8    | 1.0517    | .823      | .7621     | 1.8848    | .9259     |           | 1.8694    |
| 9    | 1.8975    | .7621     | 1.768     | 1.7775    | .8817     | 1.8898    |           |
| 10   | .7316     |           | .8688     | .9297     |           | 1.6308    |           |
| 11   |           |           |           | .7773     |           | 1.326     | .6001     |
| 12   |           | .503      |           | 1.4175    | .6097     | 1.1583    |           |
| 13   | .4877     |           | .6401     | 1.2917    |           | .6097     |           |
| 14   | .7621     |           | 1.3271    |           | .442      | .5335     |           |
| 15   | .2439     |           | 1.1736    |           |           |           |           |
| 16   |           | .4207     | 1.0852    | .6859     |           |           |           |
| 17   |           |           | 1.0822    | .6706     |           |           |           |
| 18   |           |           | 1.257     |           |           | 1.4784    |           |
| 19   | .9145     | .8139     | 1.579     |           | .7621     | .8383     |           |
| 20   |           |           | 1.6461    |           | .823      | 1.5546    |           |
| 21   |           |           | 1.486     |           |           | 1.5635    |           |
| 22   |           |           | 1.3009    |           |           | 1.3298    |           |
| 23   | .4572     |           | 1.114     |           | .442      | 1.1412    |           |
| 24   | .4458     | .4572     | .945      | .421      | .4287     | .9145     | .421      |
| Max  | 1.9643    | .823      | 1.768     | 1.8848    | .9259     | 1.8898    | 1.8694    |
| Min  | .2439     | .4115     | .4424     | .421      | .4287     | .4801     | .421      |
| Avg  | .7665     | .5887     | 1.1299    | 1.1344    | .6644     | 1.1503    | 1.1014    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 201 / 11 KV Wadala NO.1

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .6859     | .4725     | .4725     | 1.0669    | 1.1431    |
| Max  | .6859     | .4725     | .4725     | 1.0669    | 1.1431    |
| Min  | .6859     | .4725     | .4725     | 1.0669    | 1.1431    |
| Avg  | .6859     | .4725     | .4725     | 1.0669    | 1.1431    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 202 / 11 kv tamaswadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0684    | 1.1325    | 1.0501    | .9572     | 1.1142    | .3887     | .3628     |
| 2    | 1.073     | 1.1233    | 1.0273    | .977      | 1.1096    | .4161     | .3871     |
| 3    | 1.1096    | 1.1355    | 1.0197    | .9922     | 1.0959    | .4832     | .4374     |
| 4    | 1.1431    | 1.1553    | 1.0395    | .9907     | 1.1004    | .5822     | .5365     |
| 5    | 1.2209    | 1.2071    | 1.1736    | 1.1187    | 1.1614    | .6341     | .6112     |
| 6    | 1.3489    | 1.3138    | 1.2346    | 1.2041    | 1.3611    | .5411     |           |
| 7    | 1.5638    | 1.4815    | 1.4159    | 1.4464    | 1.3977    |           |           |
| 8    | 1.515     | 1.4998    | 1.448     | 1.4449    | 1.4434    |           |           |
| 9    | .8535     | 1.2117    | .8429     | .6386     | .9069     |           |           |
| 11   |           |           |           |           |           | 1.3077    | 1.3352    |
| 12   |           |           |           |           |           | 1.4159    | 1.3824    |
| 13   |           |           |           |           |           | 1.3778    | 1.3397    |
| 14   |           |           |           |           |           | 1.291     | 1.2422    |
| 15   |           |           |           |           |           | 1.2498    | 1.23      |
| 16   |           |           |           |           |           | 1.2666    | 1.2574    |
| 17   |           |           |           |           |           | 1.3032    | 1.2376    |
| 18   | .6219     | .3033     | .602      | .3048     | .4694     | 1.3565    | 1.2818    |
| 19   | .7225     | .7468     | .6965     | .7133     | .7042     | .8551     | .6859     |
| 20   | .6752     | .7011     | .6661     | .6706     | .6843     | .6112     | .6325     |
| 21   | .5548     | .5883     | .567      | .5197     | .5609     | .5396     | .5243     |
| 22   | .474      | .4618     | .4542     | .4557     | .471      | .4572     | .4633     |
| 23   | 1.0349    | .977      | .849      | 1.012     | .3856     | .3628     | .3749     |
| 24   | 1.9631    | 1.954     | 1.669     | 1.8671    | 1.2087    | .666      | .6294     |
| Max  | 1.9631    | 1.954     | 1.669     | 1.8671    | 1.4434    | 1.4159    | 1.3824    |
| Min  | .474      | .3033     | .4542     | .3048     | .3856     | .3628     | .3628     |
| Avg  | 1.0589    | 1.0621    | .9847     | .9571     | .9484     | .8553     | .8396     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 203 / 11 kv rastapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6203     | .692      | .6173     | .6371     | .6127     | 2.2756    | 2.4813    |
| 2    | .6706     | .7026     | .6737     | .6417     | .5914     | 2.3365    | 2.4508    |
| 3    | .7514     | .8048     | .7712     | .7423     | .6813     | 2.2832    | 2.5423    |
| 4    | .8871     | .9846     | .9343     | .8886     | .8002     | 2.3472    | 2.5758    |
| 5    | 1.0913    | 1.1568    | 1.1233    | 1.0837    | .9709     | 2.4219    | 2.7115    |
| 6    | .285      | 1.2041    | .4496     | .0168     | .7179     | 2.6048    | 3.251     |
| 7    |           | 1.0501    |           |           |           | 3.629     | 3.9201    |
| 8    |           |           |           |           |           | 3.7616    | 3.9948    |
| 9    |           |           |           |           |           | 1.1812    | 1.294     |
| 11   | 3.8226    | 3.7525    | 3.6443    | 3.6092    | 3.8424    |           |           |
| 12   | 3.8363    | 4.2951    | 3.9491    | 4.3103    | 4.1472    |           |           |
| 13   | 4.135     | 4.228     | 4.0284    | 4.3423    | 3.7235    |           |           |
| 14   | 4.2174    | 4.164     | 3.9796    | 4.1777    | 3.7845    |           |           |
| 15   | 4.2539    | 4.1183    | 3.911     | 3.972     | 3.7708    |           |           |
| 16   | 4.1122    | 4.1991    | 4.0512    | 3.972     | 3.7921    |           |           |
| 17   | 4.1747    | 4.1381    | 4.0375    | 4.1198    | 3.6717    |           |           |
| 18   | 4.0878    | 4.0832    | 3.8058    | 4.0024    | 3.626     | .7179     | .6249     |
| 19   | 2.7496    | 1.9662    | 1.4297    | 2.4615    | 1.2696    | 1.1111    | 1.1446    |
| 20   | 1.137     | .9816     | 1.0059    | 1.0898    | .9175     | .9496     | .9496     |
| 21   | .8977     | .8718     | .8246     | .8794     | .8352     | .7225     | .8307     |
| 22   | .7956     | .7484     | .7788     | .7926     | .6783     | .5868     | .6828     |
| 23   | .6874     | .6447     | .6981     | .7133     | 1.8656    | 2.2862    | 2.2268    |
| 24   | .9128     | .8718     | .9145     | .9273     | 2.3548    | 3.1261    | 3.2708    |
| Max  | 4.2539    | 4.2951    | 4.0512    | 4.3423    | 4.1472    | 3.7616    | 3.9948    |
| Min  | .285      | .6447     | .4496     | .0168     | .5914     | .5868     | .6249     |
| Avg  | 2.2063    | 2.1742    | 2.0814    | 2.1690    | 2.1327    | 2.0213    | 2.1845    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 204 / 11 KV Wadala No.2  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5335     |
| Max  | .5335     |
| Min  | .5335     |
| Avg  | .5335     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 205 / 11 KV Bhairawanath  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | .2591     | 1.2193    | 1.2193    |
| Max  | .2591     | 1.2193    | 1.2193    |
| Min  | .2591     | 1.2193    | 1.2193    |
| Avg  | .2591     | 1.2193    | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 206 / 11 KV Nipani Nimgaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | 1.2883    | .9145     | .9755     | 1.0212    | 1.1736    | .2896     | .2439     |
| Max  | 1.2883    | .9145     | .9755     | 1.0212    | 1.1736    | .2896     | .2439     |
| Min  | 1.2883    | .9145     | .9755     | 1.0212    | 1.1736    | .2896     | .2439     |
| Avg  | 1.2883    | .9145     | .9755     | 1.0212    | 1.1736    | .2896     | .2439     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 207 / 11 KV Sajalpur

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .1772     |           |           |           |
| 24   | .1867     | .1802     | .1638     |           | .1677     | .1715     | .1524     |
| Max  | .1867     | .1802     | .1638     | .1772     | .1677     | .1715     | .1524     |
| Min  | .1867     | .1802     | .1638     | .1772     | .1677     | .1715     | .1524     |
| Avg  | .1867     | .1802     | .1638     | .1772     | .1677     | .1715     | .1524     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 208 / 11 KV MaliChinchora

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .1753     |           |           |           |
| 24   | .8962     | .213      | .16       |           | .1524     | .1715     | .1715     |
| Max  | .8962     | .213      | .16       | .1753     | .1524     | .1715     | .1715     |
| Min  | .8962     | .213      | .16       | .1753     | .1524     | .1715     | .1715     |
| Avg  | .8962     | .213      | .16       | .1753     | .1524     | .1715     | .1715     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 209 / DHRUVTARA EXPRESS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .1578     |           |           |           |
| 24   | .1848     | .1448     | .1254     |           | .1372     | .1829     | .1829     |
| Max  | .1848     | .1448     | .1254     | .1578     | .1372     | .1829     | .1829     |
| Min  | .1848     | .1448     | .1254     | .1578     | .1372     | .1829     | .1829     |
| Avg  | .1848     | .1448     | .1254     | .1578     | .1372     | .1829     | .1829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 210 / 11 KV RASTAPUR NO 2

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | .3241     |           |           |           |
| 24   | .3241     | .3353     | .3353     |           | .2439     | 1.5546    | 1.6918    |
| Max  | .3241     | .3353     | .3353     | .3241     | .2439     | 1.5546    | 1.6918    |
| Min  | .3241     | .3353     | .3353     | .3241     | .2439     | 1.5546    | 1.6918    |
| Avg  | .3241     | .3353     | .3353     | .3241     | .2439     | 1.5546    | 1.6918    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 211 / NATH BABA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           |           | 1.448     |           |           |           |
| 24   | 1.2191    | 1.3717    | 1.4327    |           | 1.2651    | .1981     | .1981     |
| Max  | 1.2191    | 1.3717    | 1.4327    | 1.448     | 1.2651    | .1981     | .1981     |
| Min  | 1.2191    | 1.3717    | 1.4327    | 1.448     | 1.2651    | .1981     | .1981     |
| Avg  | 1.2191    | 1.3717    | 1.4327    | 1.448     | 1.2651    | .1981     | .1981     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014077 / 33 KV WADALA

Feeder No / Name : 212 / LAKHEFAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    |           | .8383     |           |           |           |
| 24   | .6171     |           | .8383     | .1524     | .1219     |
| Max  | .6171     | .8383     | .8383     | .1524     | .1219     |
| Min  | .6171     | .8383     | .8383     | .1524     | .1219     |
| Avg  | .6171     | .8383     | .8383     | .1524     | .1219     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014082 / 33/11KV KARAJGAON

Feeder No / Name : 206 / Shiregaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2439     |           | .2439     |
| 2    | .2439     |           | .2439     |
| 3    | .2439     |           | .2439     |
| 4    | .2439     |           | .2439     |
| 5    | .5487     |           | .4268     |
| 6    | .7316     |           | .7316     |
| 7    | .9755     |           | 1.0364    |
| 8    | 1.0364    |           | 1.0974    |
| 9    | .9145     | .9755     |           |
| 10   | .7926     | .7316     |           |
| 11   | .6097     | .6706     |           |
| 12   | .5487     | .6097     |           |
| 13   | .4268     | .4877     |           |
| 14   | .4877     | .4877     |           |
| 15   | .4268     | .4268     |           |
| 16   | .4877     | .4877     |           |
| 17   | .5487     | .5487     |           |
| 18   | .6097     | .6097     |           |
| 19   | .7926     | .7926     |           |
| 20   | .9145     | .8535     |           |
| 21   | .7926     | .7316     |           |
| 22   | .6706     | .6706     |           |
| 23   | .6097     | .6097     |           |
| 24   |           | .3048     |           |
| Max  | 1.0364    | .9755     | 1.0974    |
| Min  | .2439     | .3048     | .2439     |
| Avg  | .6044     | .6249     | .5335     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 201 / 11 kv deogaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .7716     |           | .7716     |
| 2    |           |           | .7716     |           | .8573     |
| 3    |           |           | .7888     |           | .9431     |
| 4    |           |           | .8573     |           | 1.0288    |
| 5    |           |           | .8916     |           | 1.1145    |
| 6    |           |           | 1.166     |           |           |
| 7    |           |           | 1.4918    |           | 1.5432    |
| 8    |           |           | 1.8176    |           | 1.8004    |
| 9    | 1.5432    |           | 1.7804    |           | 1.6956    |
| 19   |           | .2743     | .2229     |           | .2229     |
| 20   |           | .2743     | .2401     |           | .2229     |
| 21   |           | .2572     | .2058     |           | .2743     |
| 22   |           | .2401     | .2401     |           | .2401     |
| 23   |           | .2229     | .2229     |           | .2229     |
| 24   |           |           | .6516     | .5487     | .6859     |
| Max  | 1.5432    | .2743     | 1.8176    | .5487     | 1.8004    |
| Min  | 1.5432    | .2229     | .2058     | .5487     | .2229     |
| Avg  | 1.5432    | .2538     | .8080     | .5487     | .8303     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 202 / 11 kv shahapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .8573     |           | .9431     |           |
| 2    |           |           | .8573     |           | 1.0288    |           |
| 3    |           |           | .8573     |           | 1.1145    |           |
| 4    |           |           | .9431     |           | 1.2003    |           |
| 5    |           |           | 1.0288    |           | 1.286     |           |
| 6    |           |           | 1.286     |           | 1.3717    |           |
| 7    |           |           | 1.8519    |           | 1.6956    |           |
| 8    |           |           | 1.989     |           | 2.0348    |           |
| 9    |           |           | 1.7974    | 1.8004    | 1.6956    |           |
| 12   |           |           |           |           |           | 1.6804    |
| 16   |           |           | .2401     |           | .1543     |           |
| 17   |           |           | .2058     |           | .1753     |           |
| 18   |           |           | .2401     |           | .2454     |           |
| 19   |           |           | .4287     |           | .3086     |           |
| 20   |           |           | .4458     |           | .463      |           |
| 21   |           |           | .3429     |           | .4115     |           |
| 22   |           |           | .2743     |           | .3429     |           |
| 23   |           |           | .2743     |           | .3086     |           |
| 24   | .9145     | .823      | .823      | .8573     | .7716     |           |
| Max  | .9145     | .823      | 1.989     | 1.8004    | 2.0348    | 1.6804    |
| Min  | .9145     | .823      | .2058     | .8573     | .1543     | 1.6804    |
| Avg  | .9145     | .823      | .8191     | 1.3289    | .8640     | 1.6804    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 203 / 11 kv rammandir

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7621     |
| Max  | .7621     |
| Min  | .7621     |
| Avg  | .7621     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 204 / 11 kv lalgate

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .9907     |
| Max  | .9907     |
| Min  | .9907     |
| Avg  | .9907     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 205 / 11 kv fattepur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .1543     |           | .1715     |           |
| 2    |           |           | .1543     |           | .1715     |           |
| 3    |           |           | .1543     |           | .1715     |           |
| 4    |           |           | .1715     |           | .1715     |           |
| 5    |           |           | .1886     |           | .1715     |           |
| 9    |           |           |           |           |           | 2.0919    |
| 12   |           |           | 2.5095    | 2.4863    | 2.6113    |           |
| 13   |           |           | 2.4756    | 2.5377    | 2.5434    |           |
| 14   |           |           | 2.5095    | 2.7092    | 2.5434    |           |
| 15   |           |           | 1.95      | 2.5377    | 2.4756    |           |
| 16   |           |           | 2.4587    | 1.7833    | .6104     |           |
| 17   |           |           | 2.5434    |           | 2.5774    |           |
| 18   |           |           |           |           | 2.2891    |           |
| 19   |           |           | .2374     |           | 2.0919    |           |
| 20   |           |           | .2401     |           | .2103     |           |
| 21   |           |           | .2058     |           | .2058     |           |
| 22   |           |           | .2572     |           | .1715     |           |
| 23   |           |           | .2058     |           | .1715     |           |
| 24   | .9145     | .1543     | .1543     | .2058     | .1715     |           |
| Max  | .9145     | .1543     | 2.5434    | 2.7092    | 2.6113    | 2.0919    |
| Min  | .9145     | .1543     | .1543     | .2058     | .1715     | 2.0919    |
| Avg  | .9145     | .1543     | .9747     | 2.0433    | 1.0850    | 2.0919    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 206 / 11 kv dedgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .3086     |           | .2572     |
| 2    |           |           | .3086     |           | .2572     |
| 3    |           |           | .3086     |           | .2572     |
| 4    |           |           | .3429     |           | .3429     |
| 5    |           |           | .4115     |           | .3429     |
| 12   | 1.749     | 1.8004    | 1.56      | 1.9547    | 1.8652    |
| 13   | 1.9204    | 1.7147    | 1.6956    | 1.9204    | 1.6956    |
| 14   | 1.8861    | 1.5432    | 1.5261    | 1.8519    | 1.6956    |
| 15   | 1.9204    | 1.7147    | 1.6956    | 1.7147    | 1.6956    |
| 16   | 1.8176    | 1.7147    | 1.6956    | 1.749     | 1.7974    |
| 17   |           | 1.7147    | 1.6956    |           | 1.6956    |
| 18   |           | 1.5432    | 1.56      |           | 1.5261    |
| 19   |           | 1.5432    | 1.56      |           | 1.4575    |
| 20   |           | .4115     | .3772     |           | .4458     |
| 21   |           | .4115     | .3429     |           | .4115     |
| 22   |           | .3772     | .4115     |           |           |
| 23   |           | .3429     | .3429     |           | .3086     |
| 24   | .5335     |           | .3086     | .3429     | .1886     |
| Max  | 1.9204    | 1.8004    | 1.6956    | 1.9547    | 1.8652    |
| Min  | .5335     | .3429     | .3086     | .3429     | .1886     |
| Avg  | 1.6378    | 1.2360    | .9140     | 1.5889    | .9553     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 207 / 11 KV Balaji Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1619     |
| Max  | .1619     |
| Min  | .1619     |
| Avg  | .1619     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 209 / Jeur-I

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7773     |
| Max  | .7773     |
| Min  | .7773     |
| Avg  | .7773     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014091 / 33/11 KV DEOGAON

Feeder No / Name : 210 / Jeur-II

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8383     |
| Max  | .8383     |
| Min  | .8383     |
| Avg  | .8383     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014153 / 33/11 KV CHANDA SUBSTATION

Feeder No / Name : 201 / 11 KV SHASHTRINAGAR 1 SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 16   |           | .0905     |
| 24   | .4572     |           |
| Max  | .4572     | .0905     |
| Min  | .4572     | .0905     |
| Avg  | .4572     | .0905     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014153 / 33/11 KV CHANDA SUBSTATION

Feeder No / Name : 202 / 11 KV NEW CHANDA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5335     |
| Max  | .5335     |
| Min  | .5335     |
| Avg  | .5335     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014153 / 33/11 KV CHANDA SUBSTATION

Feeder No / Name : 203 / 11 KV MIRI ROAD 1

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 16   |           | 1.5752    |
| 24   | .3048     |           |
| Max  | .3048     | 1.5752    |
| Min  | .3048     | 1.5752    |
| Avg  | .3048     | 1.5752    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014153 / 33/11 KV CHANDA SUBSTATION

Feeder No / Name : 204 / 11 KV M.L.HIWARE 1      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 16   |           | 1.5638    |
| 24   | .5335     |           |
| Max  | .5335     | 1.5638    |
| Min  | .5335     | 1.5638    |
| Avg  | .5335     | 1.5638    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014153 / 33/11 KV CHANDA SUBSTATION

Feeder No / Name : 205 / 11 KV MAK A 1

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 16   |           | 1.0254    |
| 24   | .6097     |           |
| Max  | .6097     | 1.0254    |
| Min  | .6097     | 1.0254    |
| Avg  | .6097     | 1.0254    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 201 / 11 KV SHINGANAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7842     | .7282     | .3765     | .6161     | .7655     |           | .5525     |
| 2    | .8029     | .7282     | .3909     | .6478     | .7655     |           | .5525     |
| 3    | .8215     | .7842     | .4515     | .6722     | .8402     | .5716     | .5906     |
| 4    | .8589     | .8402     | .4633     | .7095     | .8962     |           |           |
| 5    | .8962     | .9149     |           | .7842     | .9522     |           |           |
| 6    | 1.0082    | 1.0642    | .7529     | 1.0456    | 1.1203    |           |           |
| 7    | 1.363     | 1.3443    | 1.0136    | 1.4937    | 1.587     |           |           |
| 8    | 1.6991    | 1.5497    | 1.5051    | 1.6991    | 1.7364    |           |           |
| 9    | 1.4377    | 1.475     | 1.4937    | 1.5123    | 1.6804    |           |           |
| 12   |           |           |           |           |           | 1.1584    | 1.6991    |
| 13   |           |           |           |           |           | 1.1294    | 1.6804    |
| 14   |           |           |           |           |           | 1.1591    | 1.6804    |
| 15   |           |           |           |           |           | 1.1294    | 1.7177    |
| 16   | .4572     | .4763     |           |           |           | 1.1004    | 1.7177    |
| 17   | .4572     | .5144     |           |           | .4954     | 1.07      | 1.5684    |
| 18   | .5906     | .5975     | .6161     |           |           | 1.0105    | 1.4563    |
| 19   | .6478     | .743      | .7811     |           | .7621     | .9065     | 1.307     |
| 20   | .743      | .724      | .724      |           |           | .3715     | .743      |
| 21   | .724      | .6287     | .7049     | .7621     |           | .5716     | .724      |
| 22   | .6668     | .4733     | .6668     | .7621     |           | .6859     | .6668     |
| 23   | .4763     | .4191     | .5716     | .6478     | .4763     | .5525     | .5906     |
| 24   | 1.6991    | .7282     | .3765     | .5975     | .7655     | .5716     | .5525     |
| Max  | 1.6991    | 1.5497    | 1.5051    | 1.6991    | 1.7364    | 1.1591    | 1.7177    |
| Min  | .4572     | .4191     | .3765     | .5975     | .4763     | .3715     | .5525     |
| Avg  | .8963     | .8185     | .7259     | .9192     | .9879     | .8563     | 1.1125    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 202 / 11 KV DEVSTHAN SHNGNAPUR NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0526     | .0526     | .0747     | .0701     | .0701     |           | .0526     |
| 2    | .0526     | .0526     | .0762     | .0701     | .0701     |           | .0526     |
| 3    | .0526     | .0526     | .0762     | .0701     | .0701     |           | .0526     |
| 4    | .0526     | .0526     | .0762     | .0701     | .0701     |           | .0526     |
| 5    | .0526     | .0526     | .0762     | .0701     | .0701     |           | .0526     |
| 6    | .0701     | .0701     | .0762     | .0876     | .0701     |           | .0526     |
| 7    | .0701     | .0526     | .0572     | .0876     | .0701     |           | .0526     |
| 8    | .0701     | .0526     | .0762     | .0876     | .0526     |           | .0526     |
| 9    | .0701     | .0701     | .0701     | .0701     | .0701     | .0762     | .0701     |
| 10   | .0701     | .0762     | .0701     | .0701     | .0762     | .056      | .0701     |
| 11   | .0701     | .0572     | .0701     | .0686     |           | .0572     | .0701     |
| 12   | .0701     | .0572     | .0701     |           |           | .0701     | .0701     |
| 13   | .0701     | .0572     | .0701     |           |           | .0747     | .0701     |
| 14   | .0701     | .0572     |           |           |           | .0762     | .0701     |
| 15   | .0701     | .0381     |           |           | .0762     | .0762     | .0701     |
| 16   | .0701     | .0572     |           |           |           | .0762     | .0526     |
| 17   | .0876     | .0762     |           |           |           | .0953     | .0526     |
| 18   | .0876     | .0953     | .0876     |           |           | .0953     | .0876     |
| 19   | .1052     | .1143     | .0876     |           | .0953     | .1143     | .1052     |
| 20   | .0876     | .0953     | .0876     |           |           | .0701     | .1052     |
| 21   | .0876     | .0762     | .0701     | .0876     |           | .0701     | .0876     |
| 22   | .0701     | .0762     | .0701     | .1052     |           | .0701     | .0876     |
| 23   | .0701     | .0747     | .0701     | .0876     | .0762     | .0526     | .0701     |
| 24   | .0701     | .0526     | .0572     | .0701     | .0701     | .0762     | .0526     |
| Max  | .1052     | .1143     | .0876     | .1052     | .0953     | .1143     | .1052     |
| Min  | .0526     | .0381     | .0572     | .0686     | .0526     | .0526     | .0526     |
| Avg  | .0708     | .0654     | .0735     | .0782     | .0720     | .0754     | .0672     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 203 / 11 KV PANASWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8916     | .9412     |           | 1.0997    | .9297     |           | .2286     |
| 2    | .9214     | .9659     |           | 1.1145    | .9297     |           | .2286     |
| 3    | .9511     | 1.0254    | .7385     | 1.1443    | .9602     | .2667     | .2667     |
| 4    | .9808     | 1.1145    |           | 1.1591    | .9957     |           |           |
| 5    | 1.0402    | 1.1294    |           | 1.1888    | 1.0254    |           |           |
| 6    | 1.1294    | 1.1728    |           | 1.2334    | 1.1294    |           |           |
| 7    | 1.4118    | 1.2742    | 1.2597    | 1.4861    | 1.2887    |           |           |
| 8    | 1.5455    | 1.5059    | 1.5203    | 1.5901    | 1.4335    |           |           |
| 9    | 1.4861    | 1.5901    | 1.4118    | 1.4563    | 1.3756    |           |           |
| 12   |           |           |           |           |           | 1.5059    | 1.3969    |
| 13   |           |           |           |           |           | 1.6049    | 1.4118    |
| 14   |           |           |           |           |           | 1.7238    | 1.4266    |
| 15   |           |           |           |           |           | 1.6644    | 1.382     |
| 16   | .2096     | .2286     |           |           |           |           | 1.2929    |
| 17   | .2858     |           |           |           |           | 1.6347    | 1.3226    |
| 18   | .3048     | .3239     | .3239     |           |           | 1.5158    | 1.382     |
| 19   | .3048     | .3239     | .4572     |           | .2858     | 1.3672    | 1.4712    |
| 20   | .3048     |           | .4382     |           |           | .2667     | .3429     |
| 21   |           |           | .4191     | .3429     |           | .3048     | .3239     |
| 22   | .2667     |           | .3429     | .3239     |           | .3048     | .3048     |
| 23   | .2667     | .2279     | .3239     | .2858     | .2667     | .2667     | .2858     |
| 24   | .8619     | .9412     | .7964     | 1.07      | .9297     | .2858     | .2286     |
| Max  | 1.5455    | 1.5901    | 1.5203    | 1.5901    | 1.4335    | 1.7238    | 1.4712    |
| Min  | .2096     | .2279     | .3239     | .2858     | .2667     | .2667     | .2286     |
| Avg  | .7743     | .9118     | .7302     | 1.0381    | .9625     | .9779     | .8310     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 204 / 11 KV GHODEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3239     |           |           | .381      | .2667     |           |           |
| 2    | .3048     |           |           | .3429     | .2667     |           |           |
| 3    | .3048     |           | .2858     | .3429     | .3048     | .724      | .6516     |
| 4    |           |           |           |           |           |           | .6687     |
| 5    |           |           |           |           |           |           | .8025     |
| 6    |           |           |           |           |           |           | .8619     |
| 7    |           |           |           |           |           |           | .9957     |
| 8    |           |           |           |           |           |           | 1.0551    |
| 9    |           |           |           |           |           | .9214     | .9659     |
| 12   | 1.1145    | 1.0425    | 1.1145    |           | 1.028     |           |           |
| 13   | .9659     | 1.0136    | 1.0551    |           |           |           |           |
| 14   | .9659     | .9846     | 1.0402    |           |           |           |           |
| 15   | .9659     | .9122     | 1.0402    |           | .9511     |           |           |
| 16   | .9659     | .9122     | 1.0105    |           |           | .2667     |           |
| 17   |           | .8398     | .9808     |           |           | .381      | .3048     |
| 18   |           | .7674     | .9957     |           |           | .4572     |           |
| 19   | .8398     | .7674     | .9297     |           | .8688     | .4954     |           |
| 20   |           |           | .4191     |           |           |           | .4572     |
| 21   |           |           | .4382     | .8025     |           |           | .4191     |
| 22   |           |           | .381      | .4382     |           |           | .3429     |
| 23   | .381      | .3239     | .362      | .3239     | .3734     | .3048     | .3048     |
| 24   | .3429     | .3155     | .2858     | .381      | .2667     | .4633     | .5937     |
| Max  | 1.1145    | 1.0425    | 1.1145    | .8025     | 1.028     | .9214     | 1.0551    |
| Min  | .3048     | .3155     | .2858     | .3239     | .2667     | .2667     | .3048     |
| Avg  | .6796     | .7879     | .7385     | .4303     | .5408     | .5017     | .6480     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 205 / 11 KV BARHANPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4763     |           |           | .5144     | .4382     |           |           |
| 2    | .4572     |           |           | .4954     | .4382     |           |           |
| 3    | .4763     |           | .5144     | .4763     | .5144     | 1.0136    | .639      |
| 9    |           |           |           |           |           | 1.7684    | 1.6198    |
| 11   |           | 2.2862    |           |           |           |           |           |
| 12   | .8619     |           | 1.9271    |           | 1.7981    |           |           |
| 13   | 1.8278    |           | 1.9433    |           |           |           |           |
| 14   | 1.781     |           | 1.9433    |           |           |           |           |
| 15   | 1.7955    |           | 1.9595    |           |           |           |           |
| 16   | 1.6941    |           | 1.9204    |           |           | .4572     |           |
| 17   |           |           | 1.8623    |           |           | .4572     | .2858     |
| 18   |           |           | 1.8947    |           |           | .5335     |           |
| 19   | 1.2018    | 1.4045    | 1.8299    |           | 1.4415    | .6287     |           |
| 20   |           |           | .5716     |           |           |           | .5525     |
| 21   |           |           | .5906     | 1.4289    |           |           |           |
| 22   |           |           | .5525     | .5335     |           |           | .4382     |
| 23   | .4031     | .4191     | .5335     | .4954     | .5335     | .2675     | .362      |
| 24   | .4954     | .3856     | .4191     | .5144     | .4382     | .7133     | 1.0105    |
| Max  | 1.8278    | 2.2862    | 1.9595    | 1.4289    | 1.7981    | 1.7684    | 1.6198    |
| Min  | .4031     | .3856     | .4191     | .4763     | .4382     | .2675     | .2858     |
| Avg  | 1.0428    | 1.1239    | 1.3187    | .6369     | .8003     | .7299     | .7011     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014154 / 33/11 KV SHINGANAPUR

Feeder No / Name : 206 / 11 KV VITTHALWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3672    |           | 1.0136    | 1.2742    | 1.4327    |           | .301      |
| 2    | 1.3969    |           | 1.028     | 1.3032    | 1.4327    |           | .3734     |
| 3    | 1.4266    |           | 1.057     | 1.3611    | 1.5752    | .4031     | .3269     |
| 4    | 1.4563    |           | 1.1145    | 1.3756    | 1.6049    |           |           |
| 5    | 1.4861    |           | 1.1294    | 1.419     | 1.6644    |           |           |
| 6    | 1.5455    |           | 1.4624    | 1.6217    | 1.7535    |           |           |
| 7    | 1.709     |           | 1.8823    | 1.7665    | 1.9692    |           |           |
| 8    | 1.9616    |           | 1.9837    | 1.9837    | 2.1285    |           |           |
| 9    | 1.9319    | 2.0995    | 2.0508    | 2.0062    | 2.0995    |           |           |
| 12   |           |           |           |           |           | 1.9403    | 2.1864    |
| 13   |           |           |           |           |           | 1.9547    | 2.2009    |
| 14   |           |           |           |           |           | 1.9982    | 2.1864    |
| 15   |           |           |           |           |           | 2.0271    | 2.0995    |
| 16   | .362      | .3982     | .3239     |           | .3048     | 2.0805    | 2.0416    |
| 17   |           | .3982     | .381      |           |           | 2.0508    | 2.0271    |
| 18   |           | .543      | .4954     |           |           | 1.9692    | 2.114     |
| 19   | .5258     | .6097     | .5906     |           | .6097     | 2.021     | 2.0271    |
| 20   |           |           | .5906     |           |           |           | .6097     |
| 21   |           |           | .5716     | .4382     |           |           | .5525     |
| 22   |           |           | .5335     | .4382     |           |           | .5525     |
| 23   | .3856     | .3547     | .5144     | .4191     | .3864     | .2972     | .5144     |
| 24   | 1.3375    | 1.3611    | 1.086     | 1.2452    | 1.4327    | .4163     | .3734     |
| Max  | 1.9616    | 2.0995    | 2.0508    | 2.0062    | 2.1285    | 2.0805    | 2.2009    |
| Min  | .362      | .3547     | .3239     | .4191     | .3048     | .2972     | .301      |
| Avg  | 1.2994    | .8235     | .9894     | 1.2809    | 1.4149    | 1.5599    | 1.2804    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014161 / 33/ 11 KV MIDC Pandharipul

Feeder No / Name : 201 / 11 kv Spark

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0191     |           |           |
| 2    | .0762     |           |           |
| 3    | .0762     |           |           |
| 4    | .0762     |           |           |
| 5    | .0762     |           |           |
| 6    | .0762     |           |           |
| 7    | .0762     |           |           |
| 8    | .0953     |           |           |
| 9    | .0762     | .0762     |           |
| 10   |           | .0762     |           |
| 11   |           | .0762     |           |
| 12   |           | .0953     |           |
| 13   |           | .0953     |           |
| 14   |           | .0762     |           |
| 15   |           | .0762     |           |
| 16   |           | .1143     |           |
| 17   |           | .1143     |           |
| 18   |           | .0762     |           |
| 19   |           | .0762     |           |
| 20   |           | .0953     |           |
| 21   |           | .0953     |           |
| 22   |           | .0953     |           |
| 23   |           | .0762     |           |
| 24   | .0762     |           | .0684     |
| Max  | .0953     | .1143     | .0684     |
| Min  | .0191     | .0762     | .0684     |
| Avg  | .0724     | .0876     | .0684     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014161 / 33/ 11 KV MIDC Pandharipul

Feeder No / Name : 202 / 11 KV Ujjwal  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0191     |           | .0381     |
| 2    | .0191     |           | .0381     |
| 3    | .0191     |           |           |
| 4    | .0191     |           | .0381     |
| 5    | .0191     |           | .0381     |
| 6    | .0191     |           | .0381     |
| 7    | .0191     |           | .0381     |
| 8    | .0191     |           | .0381     |
| 9    | .0191     | .0381     |           |
| 10   |           | .0381     |           |
| 11   |           | .0381     |           |
| 12   |           | .0381     |           |
| 13   |           | .0381     |           |
| 14   |           | .0381     |           |
| 15   |           | .0381     |           |
| 16   |           | .0381     |           |
| 18   |           | .0381     |           |
| 19   |           | .0381     |           |
| 20   |           | .0381     |           |
| 21   |           | .0381     |           |
| 22   |           | .0381     |           |
| 23   |           | .0381     |           |
| 24   | .0191     | .0381     | .0381     |
| Max  | .0191     | .0381     | .0381     |
| Min  | .0191     | .0381     | .0381     |
| Avg  | .0191     | .0381     | .0381     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014161 / 33/ 11 KV MIDC Pandharipul

Feeder No / Name : 203 / 11 KV MIDC No-2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 4    | .0762     |
| Max  | .0762     |
| Min  | .0762     |
| Avg  | .0762     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

GHODEGAON[550] BU 6734

Substation No/ Name :- 014161 / 33/ 11 KV MIDC Pandharipul

Feeder No / Name : 204 / 11 KV Zapwadi AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7186     |           | 1.7451    |
| 2    | .8002     |           | 1.7964    |
| 3    | .7528     |           | 1.8991    |
| 4    | .7528     |           | 2.0873    |
| 5    | .787      |           |           |
| 9    |           | 3.3875    |           |
| 16   |           | .3593     |           |
| 17   |           | .4448     |           |
| 18   |           | .4448     |           |
| 19   |           | .0729     |           |
| 20   |           | .7015     |           |
| 21   |           | .7015     |           |
| 22   |           | .633      |           |
| 23   |           | .5988     |           |
| 24   | .7186     |           | 1.6253    |
| Max  | .8002     | 3.3875    | 2.0873    |
| Min  | .7186     | .0729     | 1.6253    |
| Avg  | .755      | .8160     | 1.8306    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 203 / TARAWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .0579     |           | .7941     | .756      |
| 2    |           |           |           | .1067     | .0015     | .7804     | .7971     |
| 3    |           |           |           | .1646     | .0564     | .8048     | .8169     |
| 4    | .125      | .1555     | .0975     | .1844     | .1768     | .8429     | .8261     |
| 5    | .1768     | .192      | .1859     | .218      | .2134     | .884      | .9556     |
| 6    | .2164     | .2362     | .2119     | .2347     | .2256     | 1.0212    | 1.0547    |
| 7    | .0091     | .0107     | .1966     | .0442     | .0076     | 1.2849    | 1.4205    |
| 8    |           |           |           |           |           | 1.7177    | 1.8564    |
| 9    |           |           |           |           |           | 1.7162    | 3.959     |
| 10   |           |           |           |           |           | .0381     |           |
| 12   | 1.9692    | 1.9296    | 1.8183    | 1.8153    | 1.7802    |           |           |
| 13   | 2.1049    | 2.1689    | 1.9738    | 2.0393    | 1.9616    |           |           |
| 14   | 2.0729    | 2.1338    | 1.9311    | 2.1475    | 1.7193    |           |           |
| 15   | 2.0576    | 2.1719    | 2.0317    | 2.2009    | 1.8762    |           |           |
| 16   | 2.1003    | 2.0271    | 2.0363    | 2.2222    | 3.985     |           |           |
| 17   | 2.0683    | 2.0607    | 2.0409    | 2.1582    | 1.9966    |           |           |
| 18   | 2.0043    | 1.9342    | 1.7147    | 1.9372    | 3.7273    |           |           |
| 19   | 1.858     | 1.3367    | 1.736     | 1.8183    | 1.7421    |           |           |
| 20   | .1966     | .1753     | .1997     | .1905     | .1539     | .1753     | .029      |
| 21   | .1905     | .1722     | .1997     | .1844     | .1616     | .1753     | .0975     |
| 22   | .189      | .1738     | .1981     | .1905     | .1692     | .1722     | .0137     |
| 23   | .1661     | .1661     | .1936     | .1844     | .0793     | .1616     | .0046     |
| 24   | 1.0334    | .0061     | .157      | .0762     | .7804     | .7331     | .7514     |
| Max  | 2.1049    | 2.1719    | 2.0409    | 2.2222    | 3.985     | 1.7177    | 3.959     |
| Min  | .0091     | .0061     | .0975     | .0442     | .0015     | .0381     | .0046     |
| Avg  | 1.0905    | 1.0030    | .9955     | .9088     | 1.0955    | .7535     | .9528     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 204 / 11 KV BHANASHIVARA  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8573     |
| Max  | .8573     |
| Min  | .8573     |
| Avg  | .8573     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 205 / GEVRAI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.4662    | 1.5287    | 1.5653    | 1.48      | 1.4281    | .2256     | .2103     |
| 2    | 1.4739    | 1.5806    | 1.5424    | 1.4967    | 1.4297    | .2286     | .2134     |
| 3    | 1.4876    | 1.6065    | 1.5379    | 1.5318    | 1.4952    | .2423     | .2317     |
| 4    | 1.4937    | 1.7116    | 1.5653    | 1.5516    | 1.4449    | .2698     | .2667     |
| 5    | 1.5348    | 1.7452    | 1.6476    | 1.7025    | 1.4937    | .3064     | .3079     |
| 6    | 1.7421    | 1.9326    | 1.9022    | 1.8412    | 1.7345    | .3323     | .3445     |
| 7    | 2.303     | 2.3929    | 2.0439    | 2.3442    | 2.21      |           |           |
| 8    | 2.7359    | 2.7648    | 2.841     | 2.7923    | 2.6795    |           |           |
| 9    | 2.777     | 2.7237    | 2.7892    | 5.0785    | 2.7968    |           |           |
| 11   |           |           |           |           |           | .503      | .567      |
| 12   |           |           |           |           |           | 2.7511    | 2.6825    |
| 13   |           |           |           |           |           | 2.7831    | 2.6597    |
| 14   |           |           |           |           |           | 2.6414    | 2.5926    |
| 15   |           |           |           |           |           | 2.5286    | 2.5149    |
| 16   |           |           |           |           |           | 2.4188    | 1.9677    |
| 17   |           |           |           |           |           | 2.1216    | 2.3579    |
| 18   |           |           |           |           |           | 2.2817    | 2.4036    |
| 19   | .061      | .0503     | .029      | .0762     | .061      | 2.1841    | 2.2161    |
| 20   | .3887     | .349      | .3658     | .3551     | .3582     | .3429     | .3368     |
| 21   | .3551     | .3475     | .3353     | .3414     | .3567     | .3185     | .3338     |
| 22   | .3292     | .3201     | .3094     | .3109     | .3567     | .3338     | .3246     |
| 23   | .6219     | .503      | .5228     | .4923     | .3094     | .3155     | .2865     |
| 24   | 2.8197    | 1.5318    | 1.48      | 1.4114    | .2286     | .2103     | .2119     |
| Max  | 2.8197    | 2.7648    | 2.841     | 5.0785    | 2.7968    | 2.7831    | 2.6825    |
| Min  | .061      | .0503     | .029      | .0762     | .061      | .2103     | .2103     |
| Avg  | 1.4393    | 1.4059    | 1.3651    | 1.5204    | 1.2255    | 1.1670    | 1.1515    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 206 / BHENDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           |           | .6962     |
| 10   |           | .6859     |           |           |
| 16   |           |           | .3239     |           |
| 18   |           |           | .4954     |           |
| 24   | 1.0288    |           |           |           |
| Max  | 1.0288    | .6859     | .4954     | .6962     |
| Min  | 1.0288    | .6859     | .3239     | .6962     |
| Avg  | 1.0288    | .6859     | .4097     | .6962     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 208 / GONDEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3178     | .3898     | .3932     | .3635     | .3475     | 2.0176    | 2.1502    |
| 2    | .3086     | .4035     | .4024     | .3875     | .3635     | 2.0416    | 2.1696    |
| 3    | .3281     | .4207     | .4252     | .4047     | .3909     | 2.0222    | 2.1536    |
| 4    | .3361     | .4492     | .4607     | .4252     | .4252     | 2.0508    | 2.1434    |
| 5    | .3704     | .4675     | .5258     | .4733     | .479      | 2.1731    | 2.1811    |
| 6    | .4081     | .4973     | .5533     | .519      | .5258     | 2.396     | 2.4303    |
| 7    |           |           | .519      |           |           | 3.027     | 3.0738    |
| 8    |           |           |           |           |           | 3.7083    | 3.5825    |
| 9    |           |           |           |           |           | 3.6305    | 6.3323    |
| 11   | .5613     | .4412     | .4881     | .5681     | .2149     |           |           |
| 12   | 3.7026    | 3.9083    | 3.874     | 3.9598    | 3.5117    |           |           |
| 13   | 3.7426    | 4.0867    | 3.8375    | 4.0535    | 3.722     |           |           |
| 14   | 3.7986    | 4.0284    | 3.7609    | 3.8809    | 3.4168    |           |           |
| 15   | 3.6717    | 3.6637    | 3.7106    | 3.5059    | 3.5562    |           |           |
| 16   | 3.6626    | 3.8192    | 3.8375    | 3.3653    | 6.7364    |           |           |
| 17   | 3.6488    | 3.7723    | 3.8317    | 3.5448    | 3.6271    |           |           |
| 18   | 3.7071    | 3.8352    | 3.3573    | 3.3368    | 6.1608    |           |           |
| 19   | 3.2785    | 2.0702    | 3.0853    | 2.9984    | 2.9481    | .0263     | .0343     |
| 20   | .5018     | .5155     | .487      | .5224     | .5098     | .5167     | .471      |
| 21   | .4721     | .4584     | .4538     | .4847     | .4824     | .4813     | .4424     |
| 22   | .4412     | .4412     | .4607     | .4378     | .4618     | .4424     | .415      |
| 23   | .4515     | .4538     | .3818     | .4264     | .5441     | .5544     | .4367     |
| 24   | 1.845     | .3989     | .3464     | .3761     | 1.909     | 2.0062    | 1.877     |
| Max  | 3.7986    | 4.0867    | 3.874     | 4.0535    | 6.7364    | 3.7083    | 6.3323    |
| Min  | .3086     | .3898     | .3464     | .3635     | .2149     | .0263     | .0343     |
| Avg  | 1.7777    | 1.7261    | 1.6758    | 1.7017    | 2.0167    | 1.8063    | 1.9929    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 209 / BHENDA .BK

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9046     | .932      | .8932     | 1.0242    | 1.1004    | .1257     | .1235     |
| 2    | .9023     | .9358     | .9153     | 1.0113    | 1.1309    | .1379     | .1326     |
| 3    | .9008     | .9511     | .9358     | 1.1081    | 1.1309    | .1532     | .1486     |
| 4    | .9496     | .9678     | .9732     | 1.1065    | .455      | .1677     | .1638     |
| 5    | 1.0555    | 1.0486    | 1.1408    | 1.1675    |           | .1768     | .1844     |
| 6    | 1.2315    | 1.2003    | 1.291     | 1.3626    |           | .1745     | .1936     |
| 7    | 1.4556    | 1.6362    | 1.5181    | 1.4883    | .013      |           |           |
| 8    | 1.6728    | 1.7261    | 1.512     | 1.8587    | 1.7261    |           |           |
| 9    | 1.7612    | 1.7779    | 1.8663    | 3.3383    | 1.7977    |           |           |
| 11   |           |           |           |           |           | 1.0928    | .6775     |
| 12   |           |           |           |           |           | 2.2573    | 2.2123    |
| 13   |           |           |           |           |           | 2.2321    | 2.1704    |
| 14   |           |           |           |           |           | 1.8458    | 2.2413    |
| 15   |           |           |           |           |           | 2.1148    | 2.1795    |
| 16   |           |           |           |           |           | 2.0645    | 2.0995    |
| 17   |           |           |           |           |           | 1.6949    | 2.1033    |
| 18   |           |           |           |           |           | 1.7589    | 1.986     |
| 19   | .1135     | .0922     | .1174     | .1219     | .1181     | 1.7429    | 1.7871    |
| 20   | .1715     | .1684     | .1829     | .1593     | .1837     | .1776     | .1814     |
| 21   | .1623     | .1539     | .1692     | .1555     | .1646     | .1654     | .1669     |
| 22   | .1585     | .1661     | .1661     | .1562     | .1677     | .1669     | .1532     |
| 23   | .6645     | .6264     | .7857     | .7446     | .1631     | .1494     | .1463     |
| 24   | 2.0458    | .881      | 1.1134    | 1.0105    | .1242     | .1372     | .1158     |
| Max  | 2.0458    | 1.7779    | 1.8663    | 3.3383    | 1.7977    | 2.2573    | 2.2413    |
| Min  | .1135     | .0922     | .1174     | .1219     | .013      | .1257     | .1158     |
| Avg  | .9433     | .8843     | .9054     | 1.0542    | .6366     | .9268     | .9584     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014061 / 33/11 KV BHENDA

Feeder No / Name : 210 / Bhanashiwra Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           |           | .8954     |
| 10   |           | .5144     |           |           |
| 16   |           |           | .2743     |           |
| 18   |           |           | .5544     |           |
| 24   | .8573     |           |           |           |
| Max  | .8573     | .5144     | .5544     | .8954     |
| Min  | .8573     | .5144     | .2743     | .8954     |
| Avg  | .8573     | .5144     | .4144     | .8954     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 201 / 11 KV DIGHI OLD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0288    |
| Max  | 1.0288    |
| Min  | 1.0288    |
| Avg  | 1.0288    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 202 / 11 KV GIDEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5432    |
| Max  | 1.5432    |
| Min  | 1.5432    |
| Avg  | 1.5432    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 203 / MANGALAPUR

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.8004    |
| Max  | 1.8004    |
| Min  | 1.8004    |
| Avg  | 1.8004    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 204 / GALNIMB

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.4575    |
| Max  | 1.4575    |
| Min  | 1.4575    |
| Avg  | 1.4575    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 205 / SALABATPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2003    |
| Max  | 1.2003    |
| Min  | 1.2003    |
| Avg  | 1.2003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 206 / GOGALGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0288    |
| Max  | 1.0288    |
| Min  | 1.0288    |
| Avg  | 1.0288    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 207 / SUREGAON AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.4575    |
| Max  | 1.4575    |
| Min  | 1.4575    |
| Avg  | 1.4575    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 209 / new dighigaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8573     |
| Max  | .8573     |
| Min  | .8573     |
| Avg  | .8573     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 210 / Water works  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.7146    |
| Max  | 1.7146    |
| Min  | 1.7146    |
| Avg  | 1.7146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 211 / Gevrai ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.1145    |
| Max  | 1.1145    |
| Min  | 1.1145    |
| Avg  | 1.1145    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014067 / 33/11KV SALABATPUR

Feeder No / Name : 212 / Pravra Sangam AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.3148    |
| Max  | 2.3148    |
| Min  | 2.3148    |
| Avg  | 2.3148    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014080 / 33/11 KV CHILEKHENWADI

Feeder No / Name : 201 / 11 KV CHILEKHENWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0288    |
| Max  | 1.0288    |
| Min  | 1.0288    |
| Avg  | 1.0288    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014080 / 33/11 KV CHILEKHENWADI

Feeder No / Name : 203 / 11 KV KUKANA -CH- SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2003    |
| Max  | 1.2003    |
| Min  | 1.2003    |
| Avg  | 1.2003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014080 / 33/11 KV CHILEKHENWADI

Feeder No / Name : 205 / 11 KV KUKANA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2003    |
| Max  | 1.2003    |
| Min  | 1.2003    |
| Avg  | 1.2003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014080 / 33/11 KV CHILEKHENWADI

Feeder No / Name : 207 / 11 kv Patharwala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2003    |
| Max  | 1.2003    |
| Min  | 1.2003    |
| Avg  | 1.2003    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014080 / 33/11 KV CHILEKHENWADI

Feeder No / Name : 208 / TARWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5432    |
| Max  | 1.5432    |
| Min  | 1.5432    |
| Avg  | 1.5432    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014080 / 33/11 KV CHILEKHENWADI

Feeder No / Name : 209 / SUKALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.3717    |
| Max  | 1.3717    |
| Min  | 1.3717    |
| Avg  | 1.3717    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014082 / 33/11KV KARAJGAON

Feeder No / Name : 201 / 11 KV PANEGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.3717    |
| Max  | 1.3717    |
| Min  | 1.3717    |
| Avg  | 1.3717    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014082 / 33/11KV KARAJGAON

Feeder No / Name : 202 / 11 KV NIMBHARI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.7147    |
| Max  | 1.7147    |
| Min  | 1.7147    |
| Avg  | 1.7147    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014082 / 33/11KV KARAJGAON

Feeder No / Name : 203 / KARAJGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2003    |
| Max  | 1.2003    |
| Min  | 1.2003    |
| Avg  | 1.2003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014082 / 33/11KV KARAJGAON

Feeder No / Name : 204 / Amalner feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5432    |
| Max  | 1.5432    |
| Min  | 1.5432    |
| Avg  | 1.5432    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014082 / 33/11KV KARAJGAON

Feeder No / Name : 205 / Khupti

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1433    |
| Max  | 2.1433    |
| Min  | 2.1433    |
| Avg  | 2.1433    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 201 / WAKADI-1

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1143     | .1776     | .1631     | .109      | .1478     | 1.1294    | 1.5203    |
| 2    | .1143     | .1753     | .1631     | .1082     | .1486     | 1.1393    | 1.4495    |
| 3    | .1135     | .1242     | .1341     | .0953     | .1478     | 1.1957    | 1.3999    |
| 4    | .1135     |           |           |           | .1463     | 1.1957    | 1.3542    |
| 5    | .1204     |           |           |           | .1494     | 1.1797    | 1.4228    |
| 6    | .1219     |           |           |           | .1189     | 1.1721    | 1.5562    |
| 7    | .0137     |           |           |           |           | 1.8846    | 2.0774    |
| 8    |           |           |           |           |           | 2.1422    | 2.2215    |
| 9    |           |           |           |           |           | 3.3025    | 1.624     |
| 11   | 2.6307    | 2.5522    | 1.765     | 2.3304    | 2.1963    |           |           |
| 12   | 2.9485    | 2.822     | 2.6924    | 2.6513    | 2.6818    |           |           |
| 13   | 2.6604    | 5.2115    | 2.6871    | 2.6619    | 4.8731    |           |           |
| 14   | 2.5697    | 2.5248    | 2.4897    | 2.5179    | 2.3518    |           |           |
| 15   | 2.5111    | 2.5172    | 2.1506    | 2.3213    | 1.9067    |           |           |
| 16   | 2.4417    | 4.6723    | 2.2337    | 2.2382    | 3.8397    |           |           |
| 17   | 2.4272    | 2.4829    | 2.2352    | 2.2016    | 2.0523    |           |           |
| 18   | 2.2542    | 2.2306    | 1.9494    | 2.1079    | 1.9555    | .0998     | .1097     |
| 19   | 1.7962    | 1.5295    | 1.3001    | 1.3298    | 1.0098    | .1143     | .1471     |
| 20   | .2256     | .2545     | .1738     | .2431     | .1707     | .0945     | .1364     |
| 21   | .2164     | .2218     | .1471     | .2164     | .1478     | .0823     | .1227     |
| 22   | .1974     | .2103     | .1395     | .202      | .1166     | .0671     | .1166     |
| 23   | .1707     | .205      | .1235     | .1776     | 1.0006    | 1.3725    | 1.2193    |
| 24   | .1776     | .173      | .112      | .1478     | 1.0418    | 1.563     | 1.5417    |
| Max  | 2.9485    | 5.2115    | 2.6924    | 2.6619    | 4.8731    | 3.3025    | 2.2215    |
| Min  | .0137     | .1242     | .112      | .0953     | .1166     | .0671     | .1097     |
| Avg  | 1.1400    | 1.6520    | 1.2153    | 1.2741    | 1.3102    | 1.1084    | 1.1262    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 202 / SHIRASGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2407    | 1.2955    | 1.3885    | 1.3855    | 1.4175    |           |           |
| 2    | 1.2468    | 1.2757    | 1.4022    | 1.4114    | 1.3992    |           |           |
| 3    | 1.2864    | 1.2849    | 1.3687    | 1.4114    | 1.3885    |           |           |
| 4    | 1.2635    | 1.3138    | 1.3809    | 1.4144    | 1.3916    |           |           |
| 5    | 1.3138    | 1.4388    | 1.3336    | 1.5028    | 1.454     |           |           |
| 6    | 1.4617    | 1.4769    | 1.5333    | 1.6857    | 1.5333    |           |           |
| 7    | 1.9646    | 1.797     | 1.9662    | 1.9601    | 1.8595    |           |           |
| 8    | 2.1826    | 2.0546    | 2.175     | 2.2893    | 2.1795    |           |           |
| 9    | 2.1018    | 3.7563    | 3.8839    | 2.2283    | 2.1978    |           |           |
| 11   |           |           |           |           |           | 1.5501    | 1.5638    |
| 12   |           |           |           |           |           | 2.3243    | 2.4173    |
| 13   |           |           |           |           |           | 2.6292    | 2.7557    |
| 14   |           |           |           |           |           | 2.7084    | 2.7709    |
| 15   |           |           |           |           |           | 2.8045    | 2.774     |
| 16   |           |           |           |           |           | 2.7481    | 2.7511    |
| 17   |           |           |           |           |           | 2.6947    | 2.6688    |
| 18   |           |           |           |           |           | 2.5255    | 2.5377    |
| 19   |           |           |           |           | .1387     | 2.2695    | 2.3609    |
| 20   |           |           |           |           | .1677     |           |           |
| 21   |           |           |           |           | .1631     |           |           |
| 22   |           |           |           |           | .157      |           |           |
| 23   | .8871     | .8672     | 1.0517    | .8002     | .1357     |           |           |
| 24   | 1.2696    | 1.358     | 1.3519    | 1.3458    |           |           |           |
| Max  | 2.1826    | 3.7563    | 3.8839    | 2.2893    | 2.1978    | 2.8045    | 2.774     |
| Min  | .8871     | .8672     | 1.0517    | .8002     | .1357     | 1.5501    | 1.5638    |
| Avg  | 1.4744    | 1.6290    | 1.7124    | 1.5850    | 1.1131    | 2.4727    | 2.5111    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 203 / RAMDOH

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 9    |           | 1.2346    | 1.286     |
| 24   | 1.1145    |           |           |
| Max  | 1.1145    | 1.2346    | 1.286     |
| Min  | 1.1145    | 1.2346    | 1.286     |
| Avg  | 1.1145    | 1.2346    | 1.286     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 204 / WAKADI - 11

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 02-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           | 1.4918    |
| 13   | 1.5432    | 1.6118    |           |
| 16   | 1.4918    | 1.406     |           |
| Max  | 1.5432    | 1.6118    | 1.4918    |
| Min  | 1.4918    | 1.406     | 1.4918    |
| Avg  | 1.5175    | 1.5089    | 1.4918    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 205 / SHIRASGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    | .9945     | .9431     |           | .9602     |
| 13   | .2743     |           | .3429     |           |
| 16   | .3429     |           | .3429     |           |
| Max  | .9945     | .9431     | .3429     | .9602     |
| Min  | .2743     | .9431     | .3429     | .9602     |
| Avg  | .5372     | .9431     | .3429     | .9602     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 206 / 11kv warkhed  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           |           | 1.7071    | 1.6331    |
| 2    |           |           |           |           |           | 1.6956    | 1.6118    |
| 3    |           |           |           |           |           | 1.6888    | 1.5912    |
| 4    |           |           |           |           |           | 1.6766    | 1.6171    |
| 5    |           |           |           |           |           | 1.6583    | 1.6148    |
| 6    |           |           |           |           |           | 1.6621    | 1.6804    |
| 7    |           |           |           |           |           | 1.8191    | 1.8176    |
| 8    |           |           |           |           |           | 1.9738    | 1.9989    |
| 9    |           |           |           |           |           | 3.815     | 1.9753    |
| 11   | .2774     | .2843     |           |           | .3681     |           |           |
| 12   | 2.1315    | 2.3731    | 2.2893    | 1.8031    | 2.0203    |           |           |
| 13   | 2.1407    | 4.9307    | 2.4135    | 2.1094    | 4.6384    |           |           |
| 14   | 2.4234    | 2.4859    | 2.428     | 2.3548    | 2.3845    |           |           |
| 15   | 2.2009    | 2.4455    | 2.351     | 2.3845    | 2.3106    |           |           |
| 16   | 2.0073    | 4.4693    | 2.3236    | 2.274     | 4.2089    |           |           |
| 17   | 2.1712    | 2.3464    | 2.3152    | 2.2055    | 2.2901    |           |           |
| 18   | 2.1201    | 2.3266    | 2.2718    | 2.2565    | 2.2641    |           |           |
| 19   | 2.0782    | 2.255     | 2.1353    | 2.2116    | 2.0706    |           |           |
| 23   |           |           |           |           | .253      | .2766     |           |
| 24   |           |           |           |           | 1.6042    | 1.6148    | 1.7619    |
| Max  | 2.4234    | 4.9307    | 2.428     | 2.3845    | 4.6384    | 3.815     | 1.9989    |
| Min  | .2774     | .2843     | 2.1353    | 1.8031    | .253      | .2766     | 1.5912    |
| Avg  | 1.9501    | 2.6574    | 2.3160    | 2.1999    | 2.2193    | 1.7807    | 1.7302    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014088 / 33/11KV SHIRASGAON

Feeder No / Name : 207 / 11 kv chikni khamgoan  
no.3 Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 9    | .7202     | .8059     |
| Max  | .7202     | .8059     |
| Min  | .7202     | .8059     |
| Avg  | .7202     | .8059     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014104 / 33/11KV BHANAS HIVARE

Feeder No / Name : 201 / SURESHNAGAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | 1.2003    | 1.6194    | 1.7814    |
| Max  | 1.2003    | 1.6194    | 1.7814    |
| Min  | 1.2003    | 1.6194    | 1.7814    |
| Avg  | 1.2003    | 1.6194    | 1.7814    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014104 / 33/11KV BHANAS HIVARE

Feeder No / Name : 202 / NEWASA PHATA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 10   |           | 1.386     |           |           |
| 24   | 1.4575    |           | .6401     | .7316     |
| Max  | 1.4575    | 1.386     | .6401     | .7316     |
| Min  | 1.4575    | 1.386     | .6401     | .7316     |
| Avg  | 1.4575    | 1.386     | .6401     | .7316     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014104 / 33/11KV BHANAS HIVARE

Feeder No / Name : 203 / MAKTAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0288    |
| Max  | 1.0288    |
| Min  | 1.0288    |
| Avg  | 1.0288    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014104 / 33/11KV BHANAS HIVARE

Feeder No / Name : 204 / KHUNEGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | 1.2003    | 1.0402    | 1.2003    |
| Max  | 1.2003    | 1.0402    | 1.2003    |
| Min  | 1.2003    | 1.0402    | 1.2003    |
| Avg  | 1.2003    | 1.0402    | 1.2003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014155 / 33/11 KV USTHAL KHALSA

Feeder No / Name : 201 / 11 KV SUREGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0521    |
| Max  | 3.0521    |
| Min  | 3.0521    |
| Avg  | 3.0521    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014155 / 33/11 KV USTHAL KHALSA

Feeder No / Name : 202 / 11 KV BHALGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5775    |
| Max  | 1.5775    |
| Min  | 1.5775    |
| Avg  | 1.5775    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014155 / 33/11 KV USTHAL KHALSA

Feeder No / Name : 203 / 11 KV GFSS USTHALKHALSA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6859     |
| Max  | .6859     |
| Min  | .6859     |
| Avg  | .6859     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014155 / 33/11 KV USTHAL KHALSA

Feeder No / Name : 204 / 11 KV GODHEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5432    |
| Max  | 1.5432    |
| Min  | 1.5432    |
| Avg  | 1.5432    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014155 / 33/11 KV USTHAL KHALSA

Feeder No / Name : 206 / 11 KV USTHALKHALSA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0288    |
| Max  | 1.0288    |
| Min  | 1.0288    |
| Avg  | 1.0288    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014156 / 33/11 Kv KHADKA

Feeder No / Name : 201 / 11 KV TOKA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.286     |
| Max  | 1.286     |
| Min  | 1.286     |
| Avg  | 1.286     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014156 / 33/11 Kv KHADKA

Feeder No / Name : 202 / 11KV JALKA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1524     | .2286     | .2096     | .2096     | .2096     | 1.0848    |           |
| 2    | .1715     | .2096     | .2096     | .2096     | .2096     | 1.0848    |           |
| 3    | .1715     | .2096     | .2096     | .1715     | .2096     | 1.0848    |           |
| 4    |           |           |           |           |           | 1.0848    |           |
| 5    |           |           |           |           |           | 1.0848    |           |
| 6    |           |           |           |           |           | 1.448     |           |
| 7    |           |           |           |           |           | 1.9271    |           |
| 8    |           |           |           |           |           | 2.1052    |           |
| 9    |           |           |           |           |           | 2.0405    | 2.1125    |
| 12   | 2.4985    | 2.3878    | 2.5101    | 2.6397    | 2.3158    |           |           |
| 13   | 2.556     | 2.2929    | 2.4291    | 2.7368    | 2.1628    |           |           |
| 14   | 2.4905    | 2.1822    |           | 2.7206    | 1.4232    |           |           |
| 15   | 2.1125    | 2.3403    | .9031     | 2.2885    | 1.9204    |           |           |
| 16   | 2.0466    | 2.3878    |           | 2.4615    | 2.0005    |           |           |
| 17   | 2.1765    | .2841     | 2.3045    | 2.1348    | 2.1445    |           |           |
| 18   | 1.9766    | .8535     | 2.1715    | 2.0805    | 1.8084    |           |           |
| 19   | 1.7654    | 1.3413    | 1.9524    | 1.7008    | 1.5813    |           |           |
| 20   | .2667     | .2286     | .2477     | .2667     | .2477     | .2858     | .2858     |
| 21   | .3048     | .2286     | .2286     | .2096     | .2096     | .2477     | .2858     |
| 22   | .2858     | .2096     | .2477     | .2286     | .1905     | .1905     | .2667     |
| 23   | .2667     | .2096     | .2096     | .2286     | .1905     | .1715     | .2477     |
| 24   | .1524     | .2286     | .2096     | .2096     | .2096     | .9755     | 1.0536    |
| Max  | 2.556     | 2.3878    | 2.5101    | 2.7368    | 2.3158    | 2.1052    | 2.1125    |
| Min  | .1524     | .2096     | .2096     | .1715     | .1905     | .1715     | .2477     |
| Avg  | 1.2122    | .9889     | 1.0031    | 1.2811    | 1.0646    | 1.0583    | .7087     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014156 / 33/11 Kv KHADKA

Feeder No / Name : 203 / 11 KV KHADKA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9766    | 1.8947    | 2.1052    | 1.906     |           | .7783     |           |
| 2    | 1.9528    | 1.8947    | 2.1052    | 1.9528    | 2.0645    | .8145     |           |
| 3    | 1.929     | 1.9109    | 2.1052    | 1.9841    | 2.0809    | .905      |           |
| 4    | 1.8519    | 1.9109    | 2.2672    | 2.2996    | 2.0809    | .905      |           |
| 5    | 2.0805    | 2.452     | 2.5911    | 2.8464    | 2.7263    | 1.0974    |           |
| 6    | 2.7606    | 3.3808    | 3.2388    | 3.4675    | 3.2421    | 1.4632    |           |
| 7    | 3.5056    | 3.6408    |           | 3.155     |           | 1.922     |           |
| 8    | 2.1033    | 2.2276    | 2.4615    | 2.1491    | 2.0245    | 1.6817    |           |
| 9    | 1.9511    | 2.3929    | 2.2834    |           | 1.8004    | 1.5893    | 1.3817    |
| 10   | 1.267     | 1.2254    | 1.1765    | 1.6301    | 1.4969    | .9593     |           |
| 11   | .9671     | .8775     | .8745     | 1.0974    | 1.0534    | .788      | .8507     |
| 12   | .7164     | .7783     | .8505     | .7975     | .7421     | 2.7989    | 2.7366    |
| 13   | .691      | .6878     | .7087     | .6024     | .6516     | 2.7831    | 2.649     |
| 14   | .5552     | .6335     | .7265     | .691      | .5973     | 2.4691    | 2.4985    |
| 15   | .5784     | .7421     | .6201     | .6762     | .6516     | 2.392     | 2.4669    |
| 16   | .5401     | .724      | .8326     | .703      | .724      | 2.4996    | 2.3611    |
| 17   | .8402     | .7964     | .8507     | .8764     | .7964     | 2.3122    | 2.5286    |
| 18   | 1.1641    | 1.1643    | 1.0631    | 1.1458    | 1.1523    | 2.3122    | 2.7368    |
| 19   | 1.7187    | 1.6632    | 1.6817    | 1.6817    | 1.6263    | 2.7692    | 2.8121    |
| 20   | 1.6617    | 1.5339    | 1.643     | 1.6263    | 1.5339    | 1.6804    | 1.5524    |
| 21   | 1.2567    | 1.2012    | 1.251     | 1.226     | 1.2254    | 1.2567    | 1.2197    |
| 22   | 1.1088    | .905      | 1.0349    | 1.094     | 1.0791    | 1.0059    | 1.0349    |
| 23   | .8871     | .8326     | .8589     | .9335     | .905      | .8775     | .8775     |
| 24   | 1.8724    | 1.8187    | 1.8299    | 1.8278    | 1.7901    | .7964     | .8215     |
| Max  | 3.5056    | 3.6408    | 3.2388    | 3.4675    | 3.2421    | 2.7989    | 2.8121    |
| Min  | .5401     | .6335     | .6201     | .6024     | .5973     | .7783     | .8215     |
| Avg  | 1.4973    | 1.5537    | 1.5287    | 1.5813    | 1.4566    | 1.6190    | 1.9019    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014156 / 33/11 Kv KHADKA

Feeder No / Name : 204 / 11 KV MURMA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0953     | .0953     | .1143     | .1143     | .1143     | 1.7071    |           |
| 2    | .0953     | .0953     | .1143     | .1143     | .1143     | 1.7071    |           |
| 3    | .0953     | .0953     | .1143     | .1143     | .1143     | 1.7375    |           |
| 4    |           |           |           |           |           | 1.7375    |           |
| 5    |           |           |           |           |           | 1.7528    |           |
| 6    |           |           |           |           |           | 1.829     |           |
| 7    |           |           |           |           |           | 2.2862    |           |
| 8    |           |           |           |           | .1143     | 2.3777    |           |
| 9    |           |           |           |           |           | 2.3624    | 2.4383    |
| 12   | 3.0178    | 2.713     | 3.0045    | 3.1703    | 3.216     |           |           |
| 13   | 3.0178    | 2.9264    | 3.1626    | 3.2769    | 3.2312    |           |           |
| 14   | 3.0331    | 2.8654    | 3.3808    | 3.155     | 3.1703    |           |           |
| 15   | 2.8502    | 2.8502    | 2.7435    | 3.155     | 2.8502    |           |           |
| 16   |           | 2.9264    | 3.0769    | 3.1093    | 2.8197    |           |           |
| 17   | 2.6673    | 2.7892    | 3.0045    | 3.0636    | 2.8197    |           |           |
| 18   | 2.5911    | 2.6673    | 2.8746    | 2.9874    | 2.4844    |           |           |
| 19   | 2.5606    | 2.5453    | 2.4844    | 2.8654    | 2.332     |           |           |
| 20   | .1143     | .1334     | .1334     | .1334     | .1143     | .1143     | .1334     |
| 21   | .1143     | .1334     | .1334     | .1143     | .1143     | .0953     | .1334     |
| 22   | .1143     | .1143     | .1334     | .1143     | .0762     | .0953     | .1143     |
| 23   | .1143     | .1143     | .1143     | .1143     | .0762     | .0572     | .0953     |
| 24   | .0762     | .0953     | .1143     | .1143     | .0953     | 1.6309    | 1.6975    |
| Max  | 3.0331    | 2.9264    | 3.3808    | 3.2769    | 3.2312    | 2.3777    | 2.4383    |
| Min  | .0762     | .0953     | .1143     | .1143     | .0762     | .0572     | .0953     |
| Avg  | 1.3705    | 1.4475    | 1.5440    | 1.6073    | 1.4034    | 1.3922    | .7687     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 014156 / 33/11 Kv KHADKA

Feeder No / Name : 205 / 11 KV PRAVRASANGAM NEW  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.7124    | 1.7166    | 1.668     | 1.6356    | 1.7072    | .0572     |           |
| 2    | 1.7124    | 1.7328    | 1.668     | 1.6356    | 1.7072    | .0572     |           |
| 3    | 1.692     | 1.7652    | 1.668     | 1.6356    | 1.7072    | .0572     |           |
| 4    | 1.7444    | 1.7652    | 1.6842    | 1.6549    | 1.7072    |           |           |
| 5    | 1.7814    | 1.8023    | 1.7004    | 1.6907    | 1.7404    |           |           |
| 6    | 1.8842    | 1.8187    | 1.7004    | 1.7072    | 1.7736    |           |           |
| 7    | 2.1051    | 1.9559    | 1.8138    | 1.8023    | 1.873     |           |           |
| 8    | 2.1714    | 2.1795    | 2.0405    | 2.146     | 2.0957    |           |           |
| 9    | 2.0241    | 2.1795    | 2.0243    |           | 2.0481    |           |           |
| 12   |           |           |           |           |           | 2.6658    | 3.4252    |
| 13   |           |           |           |           |           | 3.0864    |           |
| 14   |           |           |           |           |           | 3.2217    | 3.618     |
| 15   |           |           |           |           |           | 3.2217    | 3.8152    |
| 16   |           |           |           |           |           | 3.2726    |           |
| 17   |           |           |           |           |           | 3.4808    | 3.2861    |
| 18   |           |           |           |           |           | 2.9959    | 3.2526    |
| 19   |           |           |           |           |           | 2.8502    | 3.0445    |
| 20   |           | .0762     | .0572     | .0953     | .0762     | .0953     | .0953     |
| 21   | .0762     | .0762     | .0572     | .0953     | .0762     | .0762     | .0953     |
| 22   | .0762     | .0762     | .0572     | .0953     | .0572     | .0762     | .0953     |
| 23   | .0572     | .0762     | .0572     | .0762     | .0572     | .0762     | .0953     |
| 24   | 1.7124    | 1.7204    | 1.6356    | 1.6194    | 1.6933    | .0572     | .0572     |
| Max  | 2.1714    | 2.1795    | 2.0405    | 2.146     | 2.0957    | 3.4808    | 3.8152    |
| Min  | .0572     | .0762     | .0572     | .0762     | .0572     | .0572     | .0572     |
| Avg  | 1.4423    | 1.3529    | 1.2737    | 1.2223    | 1.3086    | 1.5842    | 1.8982    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 201 / MUKINDPUR W/S  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0288    |
| Max  | 1.0288    |
| Min  | 1.0288    |
| Avg  | 1.0288    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 203 / DEOGAD

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2003    |
| Max  | 1.2003    |
| Min  | 1.2003    |
| Avg  | 1.2003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 204 / NEWASA URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.8861    |
| Max  | 1.8861    |
| Min  | 1.8861    |
| Avg  | 1.8861    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 205 / NEWASA BK.GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2003    |
| Max  | 1.2003    |
| Min  | 1.2003    |
| Avg  | 1.2003    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 206 / KHUPATI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2003    |
| Max  | 1.2003    |
| Min  | 1.2003    |
| Avg  | 1.2003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 207 / SAINATH NAGAR AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2003    |
| Max  | 1.2003    |
| Min  | 1.2003    |
| Avg  | 1.2003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 208 / Belpandhari

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2003    |
| Max  | 1.2003    |
| Min  | 1.2003    |
| Avg  | 1.2003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 211 / BELPIMPALGAON

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.4575    |
| Max  | 1.4575    |
| Min  | 1.4575    |
| Avg  | 1.4575    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 403 / 33 KV SALABATPUR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 10.2881   |
| Max  | 10.2881   |
| Min  | 10.2881   |
| Avg  | 10.2881   |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 404 / 33 KV BHOKAR

Feeder KV- 33 / INCOMING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 7.7161    |
| Max  | 7.7161    |
| Min  | 7.7161    |
| Avg  | 7.7161    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 017005 / 132/33/11 KV NEWASA

Feeder No / Name : 406 / 33 KV USTHALKHALSA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 4.1152    |
| Max  | 4.1152    |
| Min  | 4.1152    |
| Avg  | 4.1152    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 018012 / 220/33 KV SAUNDALA

Feeder No / Name : 405 / BHATKUDGAON

Feeder KV- 33 / INCOMING

SHEDDABLE HV(AGRICULTURE)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.8004    |
| Max  | 1.8004    |
| Min  | 1.8004    |
| Avg  | 1.8004    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

NEWASA[199] BU 5738

Substation No/ Name :- 018012 / 220/33 KV SAUNDALA

Feeder No / Name : 406 / 33KV DEOGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5432    |
| Max  | 1.5432    |
| Min  | 1.5432    |
| Avg  | 1.5432    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014074 / 33/11 KV TISGAON

Feeder No / Name : 201 / MANDVA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.3717    |
| Max  | 1.3717    |
| Min  | 1.3717    |
| Avg  | 1.3717    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014074 / 33/11 KV TISGAON

Feeder No / Name : 203 / Tisgaon

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .0171     |
| Max  | .0171     |
| Min  | .0171     |
| Avg  | .0171     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014074 / 33/11 KV TISGAON

Feeder No / Name : 204 / KAUDGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .0152     |
| Max  | .0152     |
| Min  | .0152     |
| Avg  | .0152     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014074 / 33/11 KV TISGAON

Feeder No / Name : 205 / GFSS Tisgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5144     |
| Max  | .5144     |
| Min  | .5144     |
| Avg  | .5144     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014074 / 33/11 KV TISGAON

Feeder No / Name : 206 / 11kV MANDVA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6001     |
| Max  | .6001     |
| Min  | .6001     |
| Avg  | .6001     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014074 / 33/11 KV TISGAON

Feeder No / Name : 207 / GHATSHIRAS AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .0343     |
| Max  | .0343     |
| Min  | .0343     |
| Avg  | .0343     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014146 / midsangvi

Feeder No / Name : 202 / 11 kv Bhalgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2096     | .2096     | .2286     | .2096     | .1905     | .6859     | .6859     |
| 2    | .2096     | .1886     | .2286     | .2096     | .1905     | .7049     | .6859     |
| 3    | .2096     | .2286     | .2286     | .2096     | .2286     | .743      | .7049     |
| 4    | .2286     | .2263     | .2286     | .2286     | .2286     | .7621     | .743      |
| 5    | .2477     | .2452     | .2667     | .2667     | .2667     | .8383     | .7811     |
| 6    |           |           |           |           |           | 1.2574    | .9335     |
| 7    |           |           |           |           |           | 1.6194    | 1.6194    |
| 8    |           |           |           |           |           | 1.8671    | 2.0386    |
| 9    |           |           |           |           |           | 1.5242    | 1.6956    |
| 12   | 2.0005    | 1.7909    | 1.6385    | 1.6766    |           |           |           |
| 13   | 1.829     | 1.9433    | 1.7909    | 2.0005    | 1.6956    |           |           |
| 14   | 1.6194    | 1.9052    | 1.6975    | 1.8671    | 1.829     |           |           |
| 15   |           | 1.8671    | 1.6032    | 1.7147    | 1.6975    |           |           |
| 16   | 1.4098    | 1.6194    | 1.5432    | 1.5813    | 1.5384    | .1524     | .1905     |
| 17   | 1.5242    | 1.5623    | 1.3336    | 1.5432    | 1.5242    | .1905     | .2286     |
| 18   | 1.5242    | 1.2765    | 1.2384    | 1.3717    | 1.4861    | .2477     | .2667     |
| 19   | 1.2689    | 1.2384    | 1.2003    | 1.1622    | 1.2765    | .362      | .381      |
| 20   | .3584     | .3206     | .3048     |           | .3239     | .3048     | .3429     |
| 21   | .2667     | .2667     | .2667     | .2477     | .2667     | .2858     | .2667     |
| 22   | .2286     | .2452     | .2477     | .2477     | .2286     | .2477     | .2477     |
| 23   | .2286     | .2286     | .2286     | .2286     | .2096     | .2286     | .2286     |
| 24   | .2096     | .2096     | .2286     | .1781     | .1905     | .6287     | .6668     |
| Max  | 2.0005    | 1.9433    | 1.7909    | 2.0005    | 1.829     | 1.8671    | 2.0386    |
| Min  | .2096     | .1886     | .2286     | .1781     | .1905     | .1524     | .1905     |
| Avg  | .7984     | .8651     | .8057     | .8790     | .7866     | .7028     | .7060     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014146 / midsangvi

Feeder No / Name : 203 / 11 kv Midsangvi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1905     | .2286     | .2096     | .2286     | .2286     | .2096     | .2096     |
| 2    | .1905     | .2286     | .2096     | .2286     | .2286     | .2096     | .2096     |
| 3    | .1905     | .2286     | .2096     | .2286     | .2286     | .2286     | .2096     |
| 4    | .2477     | .3239     | .3239     | .3048     | .3048     | .3239     | .3239     |
| 5    | .2667     | .381      | .4191     | .4954     | .3429     | .4572     | .4382     |
| 6    | .4001     | .4954     | .4763     | .5716     | .4191     | .5906     | .5906     |
| 7    | .6668     | .7049     | .5716     | .6097     | .6859     | .743      | .6478     |
| 8    | .6287     | .7621     | .5144     | .7049     | .7049     | .7621     | .6859     |
| 9    | .5716     | .724      | .4954     | .6859     | .7049     | .7049     | .6668     |
| 10   | .4191     | .4763     | .4191     | .5716     | .5716     | .4763     | .4954     |
| 11   | .362      | .2858     | .3239     | .3429     | .4001     | .3239     | .3239     |
| 12   | .2858     | .2286     | .2286     | .2477     | .2858     | .3239     | .2667     |
| 13   | .2286     | .2286     | .2286     | .2286     | .2096     | .2858     | .2477     |
| 14   | .2286     | .2286     | .2286     | .2858     | .1905     | .2858     | .2477     |
| 15   |           | .2477     | .2858     | .2858     | .1905     | .3048     | .2477     |
| 16   | .2286     | .2667     | .2858     | .2858     | .2667     | .3048     | .2667     |
| 17   | .2667     | .2858     | .3048     | .3048     | .2858     |           | .3429     |
| 18   | .4001     | .4382     | .4572     | .4763     | .4191     | .4954     | .4572     |
| 19   | .6287     | .6478     | .7621     | .743      | .6859     | .8002     | .7049     |
| 20   | .4763     | .4572     | .4763     |           | .5335     | .4763     | .5335     |
| 21   | .3239     | .3429     | .362      | .381      | .362      | .3048     | .362      |
| 22   | .2667     | .2667     | .2858     | .2858     | .3048     | .2667     | .2858     |
| 23   | .2477     | .2477     | .2477     | .2477     | .2477     | .2286     | .2667     |
| 24   | .1905     | .2286     | .2096     | .2286     | .2286     | .2096     | .2096     |
| Max  | .6668     | .7621     | .7621     | .743      | .7049     | .8002     | .7049     |
| Min  | .1905     | .2286     | .2096     | .2286     | .1905     | .2096     | .2096     |
| Avg  | .3438     | .3731     | .3556     | .3902     | .3763     | .4051     | .3850     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014147 / 33/11 KV KASAR PIMPALGAON

Feeder No / Name : 201 / 11 KV Kasar Pimpalgaon

GAOTHAN FEEDER

Gathan Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0288    |
| Max  | 1.0288    |
| Min  | 1.0288    |
| Avg  | 1.0288    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

PATHARDI[195] BU 5746

Substation No/ Name :- 014147 / 33/11 KV KASAR PIMPALGAON

Feeder No / Name : 202 / 11kv Kasar pimpalgaon Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6173     |
| Max  | .6173     |
| Min  | .6173     |
| Avg  | .6173     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014056 / 33/11 KV SHEGAON URBAN

Feeder No / Name : 201 / 11 KV SHEVGAON (U)- SHEDDABLE URBAN  
 KHANDOBA NA Feeder KV- 11 /  
 OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7362     | .815      | .7011     |           |           |
| 2    | .7362     | .815      | .7011     |           |           |
| 3    | .7362     |           | .7011     |           |           |
| 4    | .7888     | .815      | .7888     |           |           |
| 5    | .9465     | .9568     | 1.0166    |           |           |
| 6    | 1.5775    |           | 1.5424    |           |           |
| 7    | 2.0858    | .2038     | 2.1033    |           |           |
| 8    | 2.3137    |           | 2.2786    |           |           |
| 9    |           | 1.949     | 1.9105    | 1.8004    | 1.8781    |
| 10   |           | 1.6478    | 1.6827    | 1.5432    |           |
| 11   |           | 1.3289    |           | 1.4403    |           |
| 12   |           | 1.3289    | 1.7528    |           |           |
| 13   |           | 1.2048    | 1.4022    |           |           |
| 14   |           |           | 1.2269    | 1.4918    | 1.2048    |
| 15   |           | 1.4175    | 1.4022    | 1.3375    |           |
| 16   |           | 1.3289    |           | 1.3717    |           |
| 17   | 1.2757    |           |           |           | 1.286     |
| 18   | 1.4883    |           |           |           | 1.4403    |
| 19   | 1.701     |           |           |           | 1.6289    |
| 20   |           |           |           |           | 1.6118    |
| 21   |           |           |           |           | 1.3717    |
| 22   |           |           |           |           | 1.2003    |
| 23   | .9214     |           |           |           | .9945     |
| 24   | .7362     | .815      | .7888     |           |           |
| Max  | 2.3137    | 1.949     | 2.2786    | 1.8004    | 1.8781    |
| Min  | .7362     | .2038     | .7011     | 1.3375    | .9945     |
| Avg  | 1.2341    | 1.1251    | 1.3333    | 1.4975    | 1.4018    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014056 / 33/11 KV SHEGAON URBAN

Feeder No / Name : 205 / Amrapur W/S NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3734     |           | .3734     |           |           |           |
| 2    | .3734     |           | .3734     |           |           |           |
| 3    | .3734     |           | .3734     |           |           |           |
| 4    | .3734     |           | .3734     |           |           |           |
| 5    | .3174     | .168      | .3734     |           |           |           |
| 6    | .3734     |           | .3921     |           |           |           |
| 7    | .3361     | .1663     | .3734     |           |           |           |
| 8    | .3547     |           | .3734     |           |           |           |
| 9    |           | .2614     | .2614     |           | .3921     |           |
| 10   |           | .168      | .2241     | .2801     | .3734     |           |
| 11   |           | .168      | .2241     | .2801     | .3547     |           |
| 12   |           | .168      | .2614     | .3734     | .3734     |           |
| 13   |           | .168      | .2801     | .3734     | .3734     |           |
| 14   |           | .168      | .168      |           | .3734     | .3696     |
| 15   |           | .168      | .168      |           | .3547     |           |
| 16   |           | .168      |           |           | .2427     |           |
| 17   | .3326     |           |           |           |           | .3734     |
| 18   | .1663     |           |           |           |           | .3547     |
| 19   | .1848     | .168      |           |           |           | .2241     |
| 20   | .3361     |           |           |           |           | .2241     |
| 21   | .3361     |           |           |           |           | .168      |
| 22   | .3547     |           |           |           |           | .3547     |
| 23   | .3547     |           |           |           |           | .3547     |
| 24   | .3734     |           | .2801     |           |           |           |
| Max  | .3734     | .2614     | .3921     | .3734     | .3921     | .3734     |
| Min  | .1663     | .1663     | .168      | .2801     | .2427     | .168      |
| Avg  | .3321     | .1763     | .3046     | .3268     | .3547     | .3029     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014056 / 33/11 KV SHEGAON URBAN

Feeder No / Name : 206 / 11 KV SHEVGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3734     |           | .3734     |           |           |
| 2    | .3734     |           | .3734     |           |           |
| 3    | .3734     |           | .3734     |           |           |
| 4    | .4668     |           | .4668     |           |           |
| 5    | .6535     | .6348     | .7095     |           |           |
| 6    | 1.1203    |           | 1.1203    |           |           |
| 7    | 1.4937    | 1.4003    | 1.5123    |           |           |
| 8    | 1.307     |           | 1.3817    |           |           |
| 9    |           | 1.1576    | 1.251     | 1.1458    | 1.0164    |
| 10   |           | .7842     | .4108     | .7468     |           |
| 11   |           | .5228     | .6908     | .4668     |           |
| 12   |           | .3734     | .4668     | .3174     |           |
| 13   |           | .2801     | .3734     | .2801     |           |
| 14   |           | .3174     | .3547     | .2801     | .2587     |
| 15   |           | .3174     | .3547     | .3174     |           |
| 16   |           | .3361     |           | .3547     |           |
| 17   | .4251     |           |           |           | .4108     |
| 18   | .7392     |           |           |           | .6348     |
| 19   |           |           |           |           | 1.1763    |
| 20   | 1.1203    |           |           |           | .8962     |
| 21   | .8775     |           |           |           | .7095     |
| 22   |           |           |           |           | .5228     |
| 23   | .4481     |           |           |           | .4668     |
| 24   | 1.5165    |           | .4108     |           |           |
| Max  | 1.5165    | 1.4003    | 1.5123    | 1.1458    | 1.1763    |
| Min  | .3734     | .2801     | .3547     | .2801     | .2587     |
| Avg  | .8063     | .6124     | .6640     | .4886     | .6769     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014056 / 33/11 KV SHEGAON URBAN

Feeder No / Name : 207 / 11 KV SHEVGAON (U) SHEDDABLE URBAN  
 Shasrinagar Feeder KV- 11 /  
 OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7392     |           | .7392     |           |           |           |
| 2    | .7392     |           | .7392     |           |           |           |
| 3    | .7392     |           | .7392     |           |           |           |
| 4    | .8316     |           | .8316     |           |           |           |
| 5    | .9795     | .9335     | 1.0349    |           |           |           |
| 6    | 1.4784    |           | 1.5339    |           |           |           |
| 7    | 1.9404    | 1.9791    | 2.0328    |           |           |           |
| 8    | 1.9035    |           | 1.9959    |           |           |           |
| 9    |           | 1.7741    | 1.848     | 1.7924    | 1.6817    | 1.6632    |
| 10   |           | 1.4784    | 1.5339    | 1.4003    | 1.5524    |           |
| 11   |           | 1.3306    | 1.386     | 1.4003    | 1.4415    |           |
| 12   |           | 1.2012    | 1.3491    | 1.307     | 1.2936    |           |
| 13   |           | 1.1458    |           | 1.2136    | 1.1458    |           |
| 14   |           | 1.0164    | 1.1827    |           | 1.0349    | 1.1088    |
| 15   |           | 1.1458    | 1.1273    |           | 1.1088    |           |
| 16   |           | 1.1643    |           |           | 1.1458    |           |
| 17   | 1.0269    |           |           |           |           | 1.3121    |
| 18   | 1.363     |           |           |           |           | 1.4415    |
| 19   | 1.8298    |           |           |           |           | 1.7926    |
| 20   | 1.6804    |           |           |           |           | 1.5893    |
| 21   | 1.5524    |           |           |           |           | 1.423     |
| 22   | 1.386     |           |           |           |           | 1.1827    |
| 23   | .8871     |           |           |           |           | .9795     |
| 24   | 2.6444    |           | .7762     |           |           |           |
| Max  | 2.6444    | 1.9791    | 2.0328    | 1.7924    | 1.6817    | 1.7926    |
| Min  | .7392     | .9335     | .7392     | 1.2136    | 1.0349    | .9795     |
| Avg  | 1.3576    | 1.3169    | 1.2567    | 1.4227    | 1.3006    | 1.3881    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014063 / 33/11KV CHAPADGAON

Feeder No / Name : 201 / Mungi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014063 / 33/11KV CHAPADGAON

Feeder No / Name : 202 / Mangrul SPS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014063 / 33/11KV CHAPADGAON

Feeder No / Name : 203 / 11 KV PINGEWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014063 / 33/11KV CHAPADGAON

Feeder No / Name : 204 / 11 KV HATGAON

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014063 / 33/11KV CHAPADGAON

Feeder No / Name : 206 / Water Supply EXP.  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014063 / 33/11KV CHAPADGAON

Feeder No / Name : 207 / 11 KV CHAPADGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014063 / 33/11KV CHAPADGAON

Feeder No / Name : 208 / 11 kv RANEGAON SPS SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014063 / 33/11KV CHAPADGAON

Feeder No / Name : 209 / 11 KV RAKSHI (SPS) SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014063 / 33/11KV CHAPADGAON

Feeder No / Name : 210 / 11kv Gadewadi feeder(SPS) SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014063 / 33/11KV CHAPADGAON

Feeder No / Name : 211 / 11 KV KHAMPIMPRI FEEDER  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014064 / 33/11KV SHAHARTAKALI

Feeder No / Name : 201 / DHORSADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014064 / 33/11KV SHAHARTAKALI

Feeder No / Name : 203 / Shahartakali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014064 / 33/11KV SHAHARTAKALI

Feeder No / Name : 204 / Deotakali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014064 / 33/11KV SHAHARTAKALI

Feeder No / Name : 205 / Majaleshahar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 201 / 11 KV ERANDGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           |           |           | 2.0119    | 1.8107    |
| 24   | .945      | .503      | .6706     |           |           |
| Max  | .945      | .503      | .6706     | 2.0119    | 1.8107    |
| Min  | .945      | .503      | .6706     | 2.0119    | 1.8107    |
| Avg  | .945      | .503      | .6706     | 2.0119    | 1.8107    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 202 / 11KV OLD DAHIFAL AG      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | 2.4863    | 2.7435    | 4.1152    | 3.2579    | 3.275     |
| Max  | 2.4863    | 2.7435    | 4.1152    | 3.2579    | 3.275     |
| Min  | 2.4863    | 2.7435    | 4.1152    | 3.2579    | 3.275     |
| Avg  | 2.4863    | 2.7435    | 4.1152    | 3.2579    | 3.275     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 203 / 11 KV TALANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | 1.6575    | 2.0719    | 1.8233    |
| 20   | .1326     |           |           |           |
| 24   |           | .4973     | 2.2211    | 1.4918    |
| Max  | .1326     | 1.6575    | 2.2211    | 1.8233    |
| Min  | .1326     | .4973     | 2.0719    | 1.4918    |
| Avg  | .1326     | 1.0774    | 2.1465    | 1.6576    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 204 / 11 KV Water Supply EXP NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    | .3144     | .0714     | .3144     | .3144     | .3001     | .3001     | .3144     |
| 16   | .2286     |           | .3144     | .3144     | .3144     | .3144     | .3144     |
| 24   | .2515     | .2858     | .3144     | .3144     | .3144     | .3144     | .2858     |
| Max  | .3144     | .2858     | .3144     | .3144     | .3144     | .3144     | .3144     |
| Min  | .2286     | .0714     | .3144     | .3144     | .3001     | .3001     | .2858     |
| Avg  | .2648     | .1786     | .3144     | .3144     | .3096     | .3096     | .3049     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 205 / 11 KV GHOTAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    | 1.8442    | 2.1795    | 1.6766    | 1.6766    | 2.0119    |           |           |
| 24   | .2108     | .1341     | .0838     | .0838     | .1174     | 1.0059    | 1.0288    |
| Max  | 1.8442    | 2.1795    | 1.6766    | 1.6766    | 2.0119    | 1.0059    | 1.0288    |
| Min  | .2108     | .1341     | .0838     | .0838     | .1174     | 1.0059    | 1.0288    |
| Avg  | 1.0275    | 1.1568    | .8802     | .8802     | 1.0647    | 1.0059    | 1.0288    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 206 / 11 KV GHOTAN GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   | .5658     |           | .823      | .5487     | .583      | .5487     | .3772     |
| 24   | .4668     | .5144     | .4801     | .6859     | .6173     | .4458     | .5144     |
| Max  | .5658     | .5144     | .823      | .6859     | .6173     | .5487     | .5144     |
| Min  | .4668     | .5144     | .4801     | .5487     | .583      | .4458     | .3772     |
| Avg  | .5163     | .5144     | .6516     | .6173     | .6002     | .4973     | .4458     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 207 / 11 KV LAKHEFAL AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           |           |           |           |           | 2.0576    | 2.0919    |
| 24   | 1.6194    | .7716     | .8573     | .8573     | .8573     |           |           |
| Max  | 1.6194    | .7716     | .8573     | .8573     | .8573     | 2.0576    | 2.0919    |
| Min  | 1.6194    | .7716     | .8573     | .8573     | .8573     | 2.0576    | 2.0919    |
| Avg  | 1.6194    | .7716     | .8573     | .8573     | .8573     | 2.0576    | 2.0919    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 208 / 11KV G&amp;P EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.6071    | 1.6949    | 2.7435    | 2.5354    | 2.6238    | 1.0837    | 2.3137    |
| 2    | 2.6071    | 1.6933    | 2.6414    | 2.4082    | 2.4691    | 1.0242    | 2.319     |
| 3    | 2.4912    | 1.6712    | 2.5659    | 2.4173    | 2.2733    | 1.0075    | 2.3472    |
| 4    | 2.4752    | 1.6949    | 2.4836    | 2.5781    | 2.2763    | .9899     | 2.4242    |
| 5    | 2.4707    | 1.7208    | 2.4874    | 2.5179    | 2.2664    | .9442     | 2.3655    |
| 6    | 2.5507    | 1.7482    | 2.4768    | 2.4326    | 2.447     | 1.0494    | 2.3434    |
| 7    | 2.2641    | 1.7154    | 2.508     | 2.447     | 2.3167    | 1.041     | 2.3175    |
| 8    | 3.3181    | 3.2945    | 4.7035    | 4.2623    | 3.6268    | 2.5438    | 4.1655    |
| 9    | 1.6522    | 1.8229    | 2.13      | 1.9921    | 1.4815    | 2.0401    | 2.0797    |
| 10   | 1.374     | 1.9342    | 1.9852    | 1.9044    |           | 1.8801    | 1.8549    |
| 11   | 1.1485    | 1.8808    | 2.4592    | 1.8717    | 1.0875    | 2.1613    | 1.8983    |
| 12   | 1.4228    | 1.874     | 2.5019    | 1.8564    | 1.1317    | 2.5408    | 2.1651    |
| 13   |           | 1.7345    | 2.2329    | 1.8549    | 1.1378    | 2.5042    | 2.0782    |
| 14   |           | 1.8701    | 1.6872    | 1.6354    | .9564     | 2.3182    | 1.9303    |
| 15   | 1.1363    | 1.8473    | 1.6141    | 1.166     | .7339     | 2.3038    | 1.861     |
| 16   | 2.7339    | 1.7452    | 3.61      | 2.9313    | .8589     | 3.7372    | 3.2503    |
| 17   | .3231     |           | 1.3862    | 1.5371    | .4915     | 2.0713    | 1.9273    |
| 18   | .3856     |           | 1.6606    | 1.5409    | .6706     | 1.8816    | 1.6796    |
| 19   | 1.0303    | .6539     | 1.8839    | 1.4098    | .7057     | 2.3282    | 1.7299    |
| 20   | 1.8031    | 1.8115    | 2.127     | 1.7589    | .8886     | 2.0363    | 1.7741    |
| 21   | 2.2862    | 2.4394    | 2.4105    | 2.2558    | .9747     | 2.2032    | 1.8153    |
| 22   | 1.8214    | 2.6223    | 2.4051    | 2.3716    | .9617     | 2.2131    | 2.0896    |
| 23   | 1.6286    | 2.5522    | 2.3556    | 2.3891    | 1.0235    | 2.1887    | 2.1079    |
| 24   | 2.9374    | 4.1892    | 4.59      | 4.3248    | 2.8429    | 3.2571    | 3.8306    |
| Max  | 3.3181    | 4.1892    | 4.7035    | 4.3248    | 3.6268    | 3.7372    | 4.1655    |
| Min  | .3231     | .6539     | 1.3862    | 1.166     | .4915     | .9442     | 1.6796    |
| Avg  | 1.9303    | 2.0096    | 2.4854    | 2.2666    | 1.5759    | 1.9729    | 2.2778    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 209 / 11 KV NEW DAHIFAL AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    | 2.4863    |           | 2.7435    | 2.7435    | 2.6578    |           |           |
| 24   | .0457     | .0514     | .0514     | .0514     | .0514     | .0514     | 1.7147    |
| Max  | 2.4863    | .0514     | 2.7435    | 2.7435    | 2.6578    | .0514     | 1.7147    |
| Min  | .0457     | .0514     | .0514     | .0514     | .0514     | .0514     | 1.7147    |
| Avg  | 1.266     | .0514     | 1.3975    | 1.3975    | 1.3546    | .0514     | 1.7147    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014068 / 33/11KV GHOTAN STN

Feeder No / Name : 210 / 11 KV BODAKHA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 8    | .0857     | 2.915     | 2.1091    |
| 24   | 1.4575    | .7202     | .6859     |
| Max  | 1.4575    | 2.915     | 2.1091    |
| Min  | .0857     | .7202     | .6859     |
| Avg  | .7716     | 1.8176    | 1.3975    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 201 / 11 KV DHORJALGAON AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5218     | .5376     | .5468     |           | .0791     | .128      | .128      |
| 2    | .5376     | .5441     | .6009     |           | .064      | .128      | .1265     |
| 3    | .6081     | .6081     | .6325     |           | .064      | .112      | .112      |
| 4    | .6325     | .6882     | .7186     |           | .064      | .1107     | .1134     |
| 5    | .6874     | .8802     | .8592     |           | .064      | .1107     | .1134     |
| 6    | .8796     | 1.4083    | 1.2346    |           |           |           |           |
| 7    | 1.3904    | 1.8185    | 1.6821    |           |           |           |           |
| 8    | 1.7438    | 1.9509    | 2.1091    | 1.7901    | 1.9044    |           |           |
| 9    | 1.6248    | 1.8138    | 1.0669    | 1.5339    | 1.8027    |           |           |
| 12   |           |           |           |           |           | 1.7497    | 1.5935    |
| 13   |           |           |           |           |           |           | 1.6404    |
| 14   |           |           |           |           |           |           | 1.8827    |
| 15   |           |           |           |           |           |           | 1.7071    |
| 16   |           |           |           |           |           | 1.5971    | 1.4632    |
| 17   |           |           |           |           |           |           | 1.5051    |
| 18   |           |           |           |           |           |           | .6859     |
| 19   | .1219     |           | .144      |           | .1581     |           | .9414     |
| 20   | .1698     |           | .16       | .1543     | .176      | .1457     | .1562     |
| 21   | .1562     | .1265     |           | .1852     | .1619     |           | .125      |
| 22   | .125      | .128      |           | .1562     | .144      | .128      | .125      |
| 23   | .1107     | .1265     |           | .1094     | .144      | .1296     | .1094     |
| 24   | .4744     | .506      | .4321     |           | .0949     | .128      |           |
| Max  | 1.7438    | 1.9509    | 2.1091    | 1.7901    | 1.9044    | 1.7497    | 1.8827    |
| Min  | .1107     | .1265     | .144      | .1094     | .064      | .1107     | .1094     |
| Avg  | .6523     | .8567     | .8489     | .6549     | .3785     | .4061     | .7370     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 202 / 11 KV WADULE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .4744     | .4744     |           | .4744     | .0781     |           |
| 2    |           | .4744     | .4744     |           | .506      | .0791     |           |
| 3    |           | .5121     | .5624     |           | .5921     | .0791     |           |
| 4    |           | .5281     | .703      |           | .6882     | .08       |           |
| 5    |           | .7042     | .787      |           | .7522     | .0791     |           |
| 6    |           | .9804     | .9374     |           | .9717     |           |           |
| 7    |           | 1.2809    | 1.2955    |           |           |           |           |
| 8    |           | 1.3889    | 1.5242    |           | 1.5524    |           |           |
| 9    |           | 1.2193    | 1.358     | 1.3748    | 1.5181    |           |           |
| 12   |           |           |           |           |           |           | 1.387     |
| 13   |           |           |           |           |           |           | 1.4022    |
| 14   |           |           |           |           |           |           | 1.4449    |
| 15   |           |           |           |           |           |           | 1.1288    |
| 16   |           |           |           |           |           |           | 1.3245    |
| 17   |           |           |           |           |           |           | 1.3375    |
| 18   |           |           |           |           |           |           | .4515     |
| 19   | .0937     | .0949     |           | .0926     | .0949     |           | .0926     |
| 20   | .0937     | .112      |           | .0926     | .096      |           | .0937     |
| 21   |           | .0949     |           | .0772     | .081      |           | .0781     |
| 22   | .0791     | .08       |           | .0781     | .081      |           | .0781     |
| 23   | .0791     | .08       |           | .0633     | .08       |           | .0625     |
| 24   |           | .3795     | .4062     |           | .3795     | .08       |           |
| Max  | .0937     | 1.3889    | 1.5242    | 1.3748    | 1.5524    | .08       | 1.4449    |
| Min  | .0791     | .08       | .4062     | .0633     | .08       | .0781     | .0625     |
| Avg  | .0864     | .5603     | .8523     | .2964     | .5620     | .0792     | .7401     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 204 / 11 KV GARADWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0648     | .0633     | .0791     |           | .0633     | .4428     | .4321     |
| 2    |           | .0633     | .0791     |           | .0633     | .4374     | .4481     |
| 3    |           | .064      | .064      |           | .064      | .4687     | .4586     |
| 4    | .064      | .064      | .064      |           | .064      | .4744     | .4744     |
| 5    | .0648     | .064      | .0633     | .0648     | .064      | .4999     | .5535     |
| 6    |           |           |           |           |           | .6173     | .6642     |
| 7    |           |           |           |           |           | .7621     | .9061     |
| 8    |           |           |           |           |           | 1.0185    | .9374     |
| 9    |           |           |           |           |           | .9842     | .7907     |
| 12   | .7773     |           | .5851     | 1.034     | .9842     |           |           |
| 13   | 1.0185    | .9259     | .8905     | 1.0059    | 1.0031    |           |           |
| 14   | .9907     | 1.0031    |           | .9145     | 1.0936    |           |           |
| 15   | .9907     | 1.0031    | .8539     | .884      | 1.0494    |           |           |
| 16   | .9031     | .8905     | .8749     | 1.0136    | 1.0974    |           |           |
| 17   | .9482     | 1.1265    | 1.4373    | 1.0235    | 1.0467    |           |           |
| 18   | .7727     | .8124     | .4961     | .9145     | .9686     |           |           |
| 19   | .7225     | .68       | .6081     | .8642     | .8436     |           | .0937     |
| 20   | .0926     | .096      | .096      | .0926     | .0949     | .081      | .0937     |
| 21   | .0937     | .0949     |           | .0772     | .096      |           | .0937     |
| 22   | .0791     | .0791     |           | .0625     | .08       | .064      | .0937     |
| 23   | .0633     | .0781     |           | .0633     | .0791     | .064      | .0781     |
| 24   | .064      | .0633     | .096      |           | .0633     | .4111     |           |
| Max  | 1.0185    | 1.1265    | 1.4373    | 1.034     | 1.0974    | 1.0185    | .9374     |
| Min  | .0633     | .0633     | .0633     | .0625     | .0633     | .064      | .0781     |
| Avg  | .4819     | .4219     | .4491     | .6165     | .4899     | .4866     | .437      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 205 / 11 KV DORJALGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5658     | .7023     | .5544     |           | .6401     | .5975     |           |
| 2    | .5601     | .7023     | .5544     |           | .6401     | .5975     | .5914     |
| 3    | .5544     | .7392     | .6219     |           | .7468     | .6468     | .5914     |
| 4    | .6979     | .7842     | .724      |           |           | .7316     | .6099     |
| 5    | .8299     | .8215     | .823      |           | .811      | .8779     | .8775     |
| 6    | 1.4377    | .8962     | 1.5708    |           | 1.3392    | 1.3676    | 1.3769    |
| 7    | 1.9993    |           | 1.9909    |           |           | 1.8823    | 1.9993    |
| 8    | 2.0351    | 2.1845    | 2.1357    | 2.0725    | 2.0538    | 1.957     | 2.1658    |
| 9    | 2.0668    | 1.949     | 2.0953    | 1.848     | 2.1098    | 1.848     | 1.848     |
| 10   | 1.4899    | 1.3717    | 1.2689    |           | 1.5708    |           |           |
| 11   | .9339     | 1.0269    | 1.0513    | .4525     | 1.251     |           |           |
| 12   | .7455     |           | .8417     | .9745     | 1.0719    |           |           |
| 13   | .6859     | .7682     | .5973     | .8764     | .8596     |           |           |
| 14   | .6952     | .6401     | .5731     | .6859     | .8686     |           |           |
| 15   | .7209     | .6401     | .5765     | .788      | .7842     |           |           |
| 16   | .6952     | .7023     | .6274     | .8478     | .9511     | .7802     |           |
| 17   | .7291     | .8779     | .7461     | .8309     | 1.1088    |           |           |
| 18   | 1.1736    | 1.2936    | .6613     | 1.2795    | 1.2071    |           |           |
| 19   | 1.8604    | 1.701     | 1.5384    |           | 1.7002    |           |           |
| 20   | 1.4327    | 1.4969    |           | 1.5061    | 1.3535    | 1.5043    |           |
| 21   | .9231     | 1.1706    |           | .9745     | 1.0719    |           |           |
| 22   | .823      | .8779     |           | .8589     | .8871     | .8413     |           |
| 23   | .6516     | .7023     |           | .724      | .7316     | .8413     |           |
| 24   | .5415     | .6219     | 1.1889    |           | .6878     | .6535     |           |
| Max  | 2.0668    | 2.1845    | 2.1357    | 2.0725    | 2.1098    | 1.957     | 2.1658    |
| Min  | .5415     | .6219     | .5544     | .4525     | .6401     | .5975     | .5914     |
| Avg  | 1.0354    | 1.0305    | 1.0371    | 1.0514    | 1.1112    | 1.0805    | 1.2575    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 206 / 11 KV DINDEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 207 / 11 KV WAGHOLI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6167     | .6958     | .7202     |           |           | .1739     | .192      |
| 2    | .6401     | .7907     | .7202     |           | .6167     | .1739     |           |
| 3    | .7202     | .8802     | .8223     |           | .759      | .176      | .1781     |
| 4    | .7748     | 1.1043    | .9488     |           | .8802     | .192      | .1781     |
| 5    | .7907     | 1.1203    | 1.3435    |           | 1.2003    | .1898     | .176      |
| 6    | 1.3592    | 1.4883    | 1.6975    |           | 1.7604    |           |           |
| 7    | 1.8364    | 2.3403    | 2.1338    |           |           |           |           |
| 8    | 2.4082    | 2.4383    | 2.6698    | 2.392     | 2.4352    |           |           |
| 9    | 2.0062    | 2.0881    | 2.0833    | 2.1715    | 2.1872    |           |           |
| 12   |           |           |           |           |           | 2.2965    | 2.6698    |
| 13   |           |           |           |           |           |           | 2.6698    |
| 14   |           |           |           |           |           |           | 2.6673    |
| 15   |           |           |           |           |           |           | 2.348     |
| 16   |           |           |           |           |           | 2.6235    | 2.2426    |
| 17   |           |           |           |           |           |           | 2.5149    |
| 18   |           |           |           |           |           |           | 2.3148    |
| 19   | .2778     | .2846     | .2721     | .2315     | .192      |           | 1.0648    |
| 20   | .2469     | .2561     | .2591     | .2469     | .2372     | .2401     | .25       |
| 21   | .2343     | .2267     |           | .2315     | .2241     |           | .2343     |
| 22   | .2056     | .208      |           | .2187     | .2056     | .1943     | .2031     |
| 23   | .1898     | .192      |           | .1581     | .2056     | .1943     | .1875     |
| 24   | .5535     | .6958     | 1.2967    |           | .5376     | .3478     |           |
| Max  | 2.4082    | 2.4383    | 2.6698    | 2.392     | 2.4352    | 2.6235    | 2.6698    |
| Min  | .1898     | .192      | .2591     | .1581     | .192      | .1739     | .176      |
| Avg  | .8574     | .9873     | 1.2473    | .8072     | .8801     | .6184     | 1.2557    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 208 / 11 KV AVHANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .048      | .032      |           | .048      | .1562     | .1739     |
| 2    |           | .048      | .032      |           | .048      | .125      | .1898     |
| 3    |           | .0486     | .0324     |           | .048      | .1265     | .2968     |
| 4    |           | .0486     | .0474     |           | .0486     | .1107     | .3125     |
| 5    | .0324     | .0486     | .0474     |           | .0486     | .1094     |           |
| 6    |           |           |           |           |           | .2372     | .5921     |
| 7    |           |           |           |           |           | .2656     | .9014     |
| 8    |           |           |           | .0324     |           | .2006     | .9172     |
| 9    |           |           |           |           |           | .2031     | .506      |
| 12   | .9722     |           |           | 1.0494    | .9374     |           |           |
| 13   | .7253     | .9061     | 1.0279    | 1.1431    | 1.2037    |           |           |
| 14   | .9907     | 1.1092    |           | 1.1138    | 1.1584    |           |           |
| 15   | 1.0669    | 1.1092    | 1.186     | 1.0385    | 1.142     |           |           |
| 16   | 1.0686    | .8488     | 1.2029    | 1.07      | .945      |           |           |
| 17   | 1.2041    | 1.0155    | 1.2186    | 1.0987    | 1.1248    |           |           |
| 18   | 1.0669    | 1.0494    | .9646     | .9907     | .9722     |           |           |
| 19   | .8951     | .8592     | .8592     | .8025     | .9374     |           | .0457     |
| 20   | .0617     | .0633     | .032      | .0463     | .064      | .0324     | .0463     |
| 21   | .0469     | .048      |           | .0463     | .064      |           | .0463     |
| 22   | .0469     | .0486     |           | .0469     | .048      | .0324     | .0463     |
| 23   | .0474     | .048      |           | .0474     | .0474     | .0324     | .0474     |
| 24   | .0324     | .0474     | .032      |           | .0474     | .2846     |           |
| Max  | 1.2041    | 1.1092    | 1.2186    | 1.1431    | 1.2037    | .2846     | .9172     |
| Min  | .0324     | .0474     | .032      | .0324     | .0474     | .0324     | .0457     |
| Avg  | .5898     | .4350     | .5165     | .6558     | .4963     | .1474     | .3171     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014072 / 33/11KV DHORJALGAON

Feeder No / Name : 209 / 11 KV NANDUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .6009     | .5535     |           | .6009     | .096      | .0972     |
| 2    |           | .6009     | .5468     |           | .6009     | .096      | .081      |
| 3    |           | .6401     | .5937     |           | .6401     | .0949     | .08       |
| 4    |           | .6802     | .6173     |           | .6722     | .0949     | .08       |
| 5    |           | .6964     | .6859     |           | .7682     | .0949     | .081      |
| 6    |           | .9393     | .9259     |           | .9122     |           |           |
| 7    | 1.0494    | 1.1544    | 1.3272    |           |           |           |           |
| 8    |           | 1.5741    | 1.5623    | 1.2498    | 1.7078    |           |           |
| 9    | 1.3735    | 1.4784    | 1.4327    | 1.4864    | 1.7185    |           |           |
| 12   |           |           |           |           |           | 1.5339    | 1.5432    |
| 13   |           |           |           |           |           |           | 1.6004    |
| 14   |           |           |           |           |           |           | 1.5851    |
| 15   |           |           |           |           |           |           | 1.46      |
| 16   |           |           |           |           |           | 1.5935    | 1.5804    |
| 17   |           |           |           |           |           |           | 1.4299    |
| 18   |           |           |           |           |           |           | 1.4632    |
| 19   | .0926     | .128      | .112      | .108      | .1107     |           | 1.2346    |
| 20   | .125      | .1134     | .096      | .108      | .112      | .112      | .125      |
| 21   | .1094     | .112      |           | .108      | .1134     |           | .125      |
| 22   | .0937     | .0949     |           | .0937     | .096      | .096      | .1094     |
| 23   | .0937     | .0949     |           | .0791     | .096      | .096      | .0937     |
| 24   | 1.387     | .4744     | .4744     |           | .506      | .0949     |           |
| Max  | 1.387     | 1.5741    | 1.5623    | 1.4864    | 1.7185    | 1.5935    | 1.6004    |
| Min  | .0926     | .0949     | .096      | .0791     | .096      | .0949     | .08       |
| Avg  | .5405     | .6255     | .7440     | .4619     | .6182     | .3639     | .7511     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014078 / 33/11KV BALAMTAKELI

Feeder No / Name : 203 / 11 KV LADJALGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5544     | .6401     |           |           |           |
| 2    | .5601     | .7316     |           |           |           |
| 3    | .8402     | .7392     |           |           |           |
| 4    | .9145     | .9955     |           |           |           |
| 5    | .924      |           |           |           |           |
| 6    | 1.2012    | 1.4632    |           |           |           |
| 7    | 1.307     | 1.5708    |           |           |           |
| 8    | 1.1203    | 1.4784    |           |           |           |
| 9    | .8316     |           | .6336     | .6516     |           |
| 10   | 1.0164    |           | .7407     | .7316     |           |
| 11   | .8402     |           | .9816     | .8316     |           |
| 12   |           |           | .7292     | .8316     |           |
| 13   |           |           | .7508     | .9145     |           |
| 14   |           |           |           | .823      |           |
| 15   | .7392     |           | .7142     | .8316     |           |
| 16   | 1.2012    |           | .6714     | .924      |           |
| 17   |           |           |           |           | .7392     |
| 18   |           |           |           |           | .823      |
| 19   |           |           |           |           | .823      |
| 20   |           |           |           |           | .3696     |
| 21   |           |           |           |           | .2772     |
| 22   |           |           |           |           | .2772     |
| 23   |           |           |           |           | .2427     |
| Max  | 1.307     | 1.5708    | .9816     | .924      | .823      |
| Min  | .5544     | .6401     | .6336     | .6516     | .2427     |
| Avg  | .9269     | 1.0884    | .7459     | .8174     | .5074     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014078 / 33/11KV BALAMTAKELI

Feeder No / Name : 204 / 11 KV GOLEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .924      | .823      |           | .5487     |           |
| 2    | 1.0269    | .8316     | .837      | .5544     |           |
| 3    | 1.0269    | .924      | .7683     | .6468     |           |
| 4    | 1.0974    | 1.327     | .977      | .7392     |           |
| 5    | 1.2012    | 1.5546    | .9765     |           |           |
| 6    | 1.5708    | 2.0119    | 1.0931    |           |           |
| 7    | 1.6804    | 2.1253    | 1.1615    |           |           |
| 8    | 1.587     | 2.3101    | 1.2706    |           |           |
| 9    |           |           |           |           | 2.1216    |
| 10   |           |           |           |           | 1.4998    |
| 11   |           |           |           |           | 2.0328    |
| 12   |           |           |           |           | 1.9204    |
| 13   |           |           |           |           | 2.1948    |
| 14   |           |           |           |           | 2.0119    |
| 15   |           |           |           |           | 2.1253    |
| 16   |           |           |           |           | 1.9204    |
| 24   | 2.8578    |           | .8466     |           |           |
| Max  | 2.8578    | 2.3101    | 1.2706    | .7392     | 2.1948    |
| Min  | .924      | .823      | .7683     | .5487     | 1.4998    |
| Avg  | 1.4414    | 1.4884    | .9913     | .6223     | 1.9784    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014078 / 33/11KV BALAMTAKELI

Feeder No / Name : 205 / 11KV KEDARESHWAR SSK EXP SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0739     | .0185     |           | .0345     | .0185     |           |
| 2    | .0747     | .0185     |           | .033      |           |           |
| 3    | .0747     | .0187     |           | .0341     |           |           |
| 4    | .0732     | .0185     |           | .0322     |           |           |
| 5    | .0924     | .037      |           | .0598     |           |           |
| 6    | .0924     | .0366     |           | .0544     |           |           |
| 7    | .112      | .037      |           | .0757     |           |           |
| 8    | .0934     | .037      |           | .0535     |           |           |
| 9    | .0924     |           |           | .0362     |           | .0366     |
| 10   | .0924     |           | .0329     | .0362     |           | .0366     |
| 11   | .0747     |           |           | .037      |           | .037      |
| 12   |           |           | .0351     | .037      |           | .0366     |
| 13   |           |           | .028      | .0554     |           | .037      |
| 14   |           |           |           | .037      |           | .0549     |
| 15   |           |           |           | .0366     |           | .0554     |
| 16   | .0924     |           | .0337     | .037      |           | .037      |
| 17   | .0732     |           | .0303     |           |           | .0554     |
| 18   |           |           | .031      | .037      |           | .0747     |
| 19   | .0373     |           | .0345     | .0373     |           | .0747     |
| 20   | .0373     |           | .0658     | .037      |           | .0924     |
| 21   | .037      |           | .0683     | .0373     |           | .0739     |
| 22   | .0366     |           |           | .0373     |           | .0934     |
| 23   | .0183     |           |           | .0187     |           | .0924     |
| 24   | .0681     | .0181     |           |           | .0187     |           |
| Max  | .112      | .037      | .0683     | .0757     | .0187     | .0934     |
| Min  | .0183     | .0181     | .028      | .0187     | .0185     | .0366     |
| Avg  | .0709     | .0267     | .0400     | .0406     | .0186     | .0592     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014078 / 33/11KV BALAMTAKELI

Feeder No / Name : 208 / 11KV SUKALI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 17   | 2.073     |           | 2.0819    |           |
| 18   | 2.1369    |           | 1.9393    |           |
| 19   | 1.6813    |           | 1.7535    |           |
| 20   | 1.1514    |           |           |           |
| 21   | .9536     |           | 1.2814    |           |
| 22   | 1.1368    |           | 1.0837    |           |
| 23   | 1.0806    |           | 1.0117    |           |
| 24   | 2.6673    | .9482     |           | .9482     |
| Max  | 2.6673    | .9482     | 2.0819    | .9482     |
| Min  | .9536     | .9482     | 1.0117    | .9482     |
| Avg  | 1.6101    | .9482     | 1.5253    | .9482     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014081 / 33/11KV DAHIGAON-NE

Feeder No / Name : 201 / Dahigaon-ne

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014081 / 33/11KV DAHIGAON-NE

Feeder No / Name : 203 / Ranjani/Khamgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.4294    |
| Max  | 3.4294    |
| Min  | 3.4294    |
| Avg  | 3.4294    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014081 / 33/11KV DAHIGAON-NE

Feeder No / Name : 204 / Gheori

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014081 / 33/11KV DAHIGAON-NE

Feeder No / Name : 205 / 11 KV BHAVINIMGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1311     | .1349     | .1235     | .128      | .1227     | .9107     | .9313     |
| 2    | .1341     | .1402     | .1235     | .1395     | .1303     | .9739     | .9998     |
| 3    | .1478     | .1417     | .1334     | .1433     | .1326     | .993      | 1.07      |
| 4    | .1547     | .1433     | .1395     | .1501     | .1303     | 1.0494    | 1.1264    |
| 5    | .16       | .1509     | .141      | .1501     | .1311     | 1.1614    | 1.243     |
| 6    |           |           |           |           | .0168     | 1.2369    | 1.3199    |
| 7    |           |           |           |           |           | 1.704     | 1.7261    |
| 8    |           |           |           |           |           | 2.1369    | 1.9852    |
| 9    |           |           |           |           |           | 2.1933    | 1.9951    |
| 11   | .2972     | .3467     | .2972     | .269      | .3064     |           |           |
| 12   | 2.1026    | 2.0858    | 2.1521    | 2.2695    | 2.268     |           |           |
| 13   | 2.2756    | 2.2954    | 2.3678    | 2.3617    | 2.2901    |           |           |
| 14   | 2.2687    | 2.3137    | 2.3       | 2.4082    | 2.3426    |           |           |
| 15   | 2.3114    | 2.2626    | 2.1818    | 2.3396    | 2.3015    |           |           |
| 16   | 1.9692    | 2.3525    | 2.1628    | 2.38      | 2.2901    |           |           |
| 17   | 2.3015    | 2.3503    | 2.1171    | 2.3777    | 2.2946    |           |           |
| 18   | 2.3442    | 2.2733    | 2.1186    | 2.239     | 2.1643    |           |           |
| 19   | 2.1498    | 1.5043    | 1.9662    | 2.0942    | 1.9951    | .1105     | .1006     |
| 20   | .1425     | .1456     | .1486     | .1509     | .141      | .1318     | .125      |
| 21   | .1288     | .1219     | .1303     | .1341     | .1075     | .0998     | .1014     |
| 22   | .1433     | .1334     | .1334     | .1326     | .0998     | .0861     | .0892     |
| 23   | .1257     | .1128     | .1318     | .1212     | .1661     | .1158     | .2279     |
| 24   | .125      | .1075     | .1288     | .1105     | .8672     | .9252     | .9137     |
| Max  | 2.3442    | 2.3525    | 2.3678    | 2.4082    | 2.3426    | 2.1933    | 1.9951    |
| Min  | .125      | .1075     | .1235     | .1105     | .0168     | .0861     | .0892     |
| Avg  | 1.0217    | 1.0061    | .9999     | 1.0579    | 1.0149    | .9219     | .9303     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014081 / 33/11KV DAHIGAON-NE

Feeder No / Name : 206 / 11 KV DAHIGAON-NE GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1783     |
| Max  | .1783     |
| Min  | .1783     |
| Avg  | .1783     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014081 / 33/11KV DAHIGAON-NE

Feeder No / Name : 207 / 11 KV CHANDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014081 / 33/11KV DAHIGAON-NE

Feeder No / Name : 208 / 11 KV DEVALANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7621     |
| Max  | .7621     |
| Min  | .7621     |
| Avg  | .7621     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014148 / 33/11 KV KHANAPUR S/STN

Feeder No / Name : 201 / 11 KV KHANAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           |           |           |           | 1.0479    |
| 24   | 1.5356    | .8573     | 1.3336    | 1.4289    |           |
| Max  | 1.5356    | .8573     | 1.3336    | 1.4289    | 1.0479    |
| Min  | 1.5356    | .8573     | 1.3336    | 1.4289    | 1.0479    |
| Avg  | 1.5356    | .8573     | 1.3336    | 1.4289    | 1.0479    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014148 / 33/11 KV KHANAPUR S/STN

Feeder No / Name : 202 / 11 KV KARHETAKALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   |           |           |           |           |           | 1.8501    |
| 24   | 1.9548    | 1.2334    | 1.4074    | .9488     | 1.9608    |           |
| Max  | 1.9548    | 1.2334    | 1.4074    | .9488     | 1.9608    | 1.8501    |
| Min  | 1.9548    | 1.2334    | 1.4074    | .9488     | 1.9608    | 1.8501    |
| Avg  | 1.9548    | 1.2334    | 1.4074    | .9488     | 1.9608    | 1.8501    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014148 / 33/11 KV KHANAPUR S/STN

Feeder No / Name : 203 / 11 KV KHANAPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           |           |           |           |           |           | .4572     |
| 16   |           |           |           |           |           |           | .0914     |
| 24   | .1829     | .1097     | .1097     | .0914     | .128      | .1097     |           |
| Max  | .1829     | .1097     | .1097     | .0914     | .128      | .1097     | .4572     |
| Min  | .1829     | .1097     | .1097     | .0914     | .128      | .1097     | .0914     |
| Avg  | .1829     | .1097     | .1097     | .0914     | .128      | .1097     | .2743     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014148 / 33/11 KV KHANAPUR S/STN

Feeder No / Name : 204 / 11 KV KARHETAKALI W/S NON SHEDDABLE WATER SUPPLY AND  
 EXPRESS Feeder KV- 11 / UTILITY  
 OUTGOING

| DATE | 01-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           |           |           |           | .0381     |
| 16   |           |           |           |           | .0381     |
| 24   | .1143     | .0572     | .0381     | .0381     | .0381     |
| Max  | .1143     | .0572     | .0381     | .0381     | .0381     |
| Min  | .1143     | .0572     | .0381     | .0381     | .0381     |
| Avg  | .1143     | .0572     | .0381     | .0381     | .0381     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014148 / 33/11 KV KHANAPUR S/STN

Feeder No / Name : 205 / 11 KV BACK WATER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 16   |           |           |           |           |           | 1.6004    |
| 24   | .9526     | .9602     | 1.1241    | .9526     | 1.6004    |           |
| Max  | .9526     | .9602     | 1.1241    | .9526     | 1.6004    | 1.6004    |
| Min  | .9526     | .9602     | 1.1241    | .9526     | 1.6004    | 1.6004    |
| Avg  | .9526     | .9602     | 1.1241    | .9526     | 1.6004    | 1.6004    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014149 / 33/11 KV KHARADGAON S/STN

Feeder No / Name : 201 / 11 KV KHARADGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .128      | .125      | .1219     | .1457     | .125      | .1429     | .1429     |
| 2    | .128      | .1235     | .1235     | .1296     | .125      | .1429     | .1593     |
| 3    | .128      | .1235     | .108      | .0972     | .125      | .1715     | .1715     |
| 4    |           |           |           |           |           | .2286     | .2027     |
| 5    |           |           |           |           |           | .2896     | .2606     |
| 6    |           |           |           |           |           | .3982     | .3909     |
| 7    |           |           |           |           |           | .6973     | .8278     |
| 8    |           |           |           |           |           | .9976     | .6773     |
| 9    |           |           |           |           |           | .9389     | 1.0536    |
| 12   |           | 1.0254    | .8916     | .8907     |           |           |           |
| 13   | 1.2651    |           | .9362     | 1.0202    |           |           |           |
| 14   | 1.1069    | 1.0433    |           | 1.0202    |           |           |           |
| 15   | 1.2809    | 1.0122    | .9065     | 1.0364    |           |           |           |
| 16   | .759      | 1.0002    | .8802     | 1.0526    |           |           |           |
| 17   | 1.0753    | .8269     | .9065     | .4858     | .884      |           |           |
| 18   | .9804     | .744      | .5639     | .7628     | .884      |           |           |
| 19   | .5944     | .487      | .503      | .5796     | .5792     | .213      | .213      |
| 20   | .1698     | .1082     | .1619     | .1802     | .1802     | .1966     | .1802     |
| 21   | .1543     | .1067     | .1296     | .1638     | .1619     | .1619     | .1457     |
| 22   |           | .0934     | .1296     | .1619     | .1134     | .1457     | .1296     |
| 23   |           | .0947     | .1147     | .144      | .1134     | .1457     | .1134     |
| 24   | 3.1192    | .1406     | .1219     | .1311     | .128      | .1448     | .1429     |
| Max  | 3.1192    | 1.0433    | .9362     | 1.0526    | .884      | .9976     | 1.0536    |
| Min  | .128      | .0934     | .108      | .0972     | .1134     | .1429     | .1134     |
| Avg  | .8376     | .4703     | .4399     | .5001     | .3108     | .3343     | .3208     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014149 / 33/11 KV KHARADGAON S/STN

Feeder No / Name : 202 / 11 KV WADGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4054     |           | .3144     | .3401     | .2675     | .128      | .0972     |
| 2    | .4778     |           | .4287     | .4641     | .2934     | .1265     | .08       |
| 3    | .5575     |           | .5357     | .5851     | .4988     | .1296     | .081      |
| 4    | .6161     |           | .695      | .6642     | .602      |           |           |
| 5    | .7922     |           | .8688     | .8065     | .7827     |           |           |
| 6    | .8916     |           | 1.0269    | 1.0402    | .9181     |           |           |
| 7    | 1.6766    | 1.6049    | 1.9218    | 2.1445    | 1.906     |           |           |
| 8    | 2.2862    |           | 2.4499    | 2.5286    | 2.7206    |           |           |
| 9    | 2.0062    | 1.5718    | 2.2834    | 2.2565    |           |           |           |
| 12   |           |           |           |           |           | 2.2068    | 1.929     |
| 13   |           |           |           |           |           | 2.4846    | 2.0988    |
| 14   |           |           |           |           |           | 2.4228    | 2.1872    |
| 15   |           |           |           |           |           | 2.1091    | 2.1403    |
| 16   |           |           |           |           |           | 2.2028    | 2.1559    |
| 17   |           |           |           |           |           | 2.21      | 2.1142    |
| 18   |           |           |           |           |           | 1.9204    | 1.7438    |
| 19   | .1981     | .23       | .2915     | .2949     | .1966     | 1.2651    | 1.2346    |
| 20   | .1981     | .2164     | .2915     | .2949     | .1802     | .1966     | .1966     |
| 21   | .2134     | .2029     | .2915     | .2652     | .1658     | .2105     | .1966     |
| 22   | .1543     | .1758     | .2429     | .2105     | .1457     | .1619     | .1823     |
| 23   | .1235     | .1669     | .208      | .1638     | .128      | .144      | .1638     |
| 24   | .3475     |           | .3286     | .4049     | .2972     | .128      | .0972     |
| Max  | 2.2862    | 1.6049    | 2.4499    | 2.5286    | 2.7206    | 2.4846    | 2.1872    |
| Min  | .1235     | .1669     | .208      | .1638     | .128      | .1265     | .08       |
| Avg  | .7296     | .5955     | .8119     | .8309     | .6502     | 1.1279    | 1.0437    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014149 / 33/11 KV KHARADGAON S/STN

Feeder No / Name : 203 / 11 KV KHARADGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6759     |           | .3121     | .3077     | .2896     | .2534     | .2715     |
| 2    | .715      |           | .3012     | .3077     | .3077     | .2507     | .2715     |
| 3    | .7681     |           | .2658     | .3439     | .3439     | .2896     | .3077     |
| 4    | .9766     |           | .394      | .394      | .4344     | .4525     | .362      |
| 5    | 1.3049    |           | .5552     | .4656     | .5487     | .5792     | .5068     |
| 6    | 1.5067    |           | .8417     | .6984     | .6584     | .7059     | .6335     |
| 7    | 1.1203    | .9774     | .985      | 1.0745    | 1.0608    | 1.0059    | .9328     |
| 8    | 1.0082    |           | .9671     | .9391     | .9328     | .9511     | .9145     |
| 9    | .9335     | .9412     | .9055     | .7973     |           | .9412     | .9328     |
| 10   | .6161     | .6401     | .6653     | .6024     |           | .6697     | .6878     |
| 11   | .4251     | .3982     | .2715     | .3366     |           | .4119     | .362      |
| 12   | .3696     | .2507     | .1791     | .2303     |           | .2658     | .2561     |
| 13   | .2587     |           | .1612     | .1949     |           | .2481     | .2378     |
| 14   | .2033     | .2328     |           | .1949     |           | .2686     | .1991     |
| 15   | .2195     | .2866     | .1595     | .1949     |           | .1254     | .2195     |
| 16   | .2561     | .1417     | .1791     | .1949     |           | .1433     | .439      |
| 17   | .2926     | .1595     | .2926     | .1448     | .3658     | .3258     | .2865     |
| 18   | .4572     | .4961     | .5544     | .5487     | .5487     | .4938     | .4344     |
| 19   | .823      | .8059     | .8962     | .8589     | .8686     | .8402     | .8131     |
| 20   | .6024     | .6447     | .811      | .7655     | .7655     | .7922     | .7468     |
| 21   | .443      | .5138     | .547      | .543      | .4887     | .4525     | .5853     |
| 22   | .3721     | .4252     | .4024     | .3982     | .3475     | .362      | .3658     |
| 23   | .2835     | .3467     | .2926     | .3077     | .2686     | .2896     | .2896     |
| 24   | 1.105     |           | .3121     | .2743     | .2896     | .2715     | .2896     |
| Max  | 1.5067    | .9774     | .985      | 1.0745    | 1.0608    | 1.0059    | .9328     |
| Min  | .2033     | .1417     | .1595     | .1448     | .2686     | .1254     | .1991     |
| Avg  | .6557     | .4840     | .4892     | .4633     | .5325     | .4746     | .4727     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014149 / 33/11 KV KHARADGAON S/STN

Feeder No / Name : 204 / 11 KV VARUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1806     | .1894     | .1783     | .1758     | .1715     |           |           |
| 2    | .1806     | .1783     | .192      | .1758     | .1858     |           |           |
| 3    | .1806     | .2195     | .2195     | .1947     | .1858     |           |           |
| 4    | .2258     | .2469     | .2469     | .2225     | .2572     |           |           |
| 5    | .2572     | .2782     | .2921     | .2643     | .3982     |           |           |
| 6    | .2858     | .3102     | .3477     | .3338     | .4887     |           |           |
| 7    | .6676     | .7002     | .7788     | .8459     | .7145     |           |           |
| 8    | .9179     |           | 1.0151    | .4793     | .9587     |           |           |
| 9    | .9717     | .7859     | .9991     |           |           |           |           |
| 12   |           |           |           |           |           | .8484     | .8459     |
| 13   |           |           |           |           |           | .8882     | .9574     |
| 14   |           |           |           |           |           | .9305     | .9431     |
| 15   |           |           |           |           |           | 1.0151    | .9412     |
| 16   |           |           |           |           |           | .9859     | .7674     |
| 17   |           |           |           | .9446     |           | .6344     | .8833     |
| 18   |           |           |           |           |           | .7331     | .8145     |
| 19   |           |           |           |           |           |           | .578      |
| 24   | .1957     | .1894     | .1894     | .1947     | .1715     |           |           |
| Max  | .9717     | .7859     | 1.0151    | .9446     | .9587     | 1.0151    | .9574     |
| Min  | .1806     | .1783     | .1783     | .1758     | .1715     | .6344     | .578      |
| Avg  | .4064     | .3442     | .4459     | .3831     | .3924     | .8622     | .8414     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 201 / Bhatkudgaon AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6001     | .514      | .4801     | .5792     | .5921     | .2241     | .2096     |
| 2    | .5335     | .514      | .4938     | .5792     | .5921     | .2241     | .2096     |
| 3    | .5792     | .514      | .5716     | .6097     | .6203     | .2241     | .2096     |
| 4    | .6401     | .5841     | .6371     | .5601     | .7145     | .2241     | .2286     |
| 5    | .7621     | .8002     | .7282     | .6135     | .7716     | .2427     | .2858     |
| 6    | 1.0059    | 1.0551    | 1.1888    | .9736     | 1.1591    |           |           |
| 7    | 1.4632    | 1.475     | 1.5699    | 1.3336    | 1.5804    |           |           |
| 8    | 1.6347    | 1.7911    | 1.6461    | 1.427     | 1.7901    |           |           |
| 9    | 1.5242    |           | 1.4327    |           | 1.4969    |           |           |
| 12   |           |           |           |           |           | 1.6248    |           |
| 13   |           |           |           |           |           | 1.6248    |           |
| 14   |           |           |           |           |           | 1.587     |           |
| 16   | .1109     | .1143     | .1494     | .1463     | .1334     |           | 1.4299    |
| 17   | .1294     | .0914     | .1867     | .1448     | .1509     | 1.5432    | 1.3413    |
| 18   | .1294     | .128      | .2058     | .1991     | .2054     | 1.2346    | 1.3565    |
| 19   | .2402     | .2743     | .2915     | .2801     | .2614     | 1.0212    | 1.2574    |
| 20   | .2218     | .2641     | .2229     | .2452     | .2614     | .1981     | .2614     |
| 21   | .2033     | .2075     | .2058     | .2263     | .2241     | .2477     | .2241     |
| 22   | .1848     | .1886     | .2096     | .2075     | .1867     | .2286     | .2241     |
| 23   | .1663     | .1698     | .1905     | .1698     | .2054     | .2286     | .2054     |
| 24   | .5144     | .5005     | .6535     | .5792     | .5639     | .2241     | .2096     |
| Max  | 1.6347    | 1.7911    | 1.6461    | 1.427     | 1.7901    | 1.6248    | 1.4299    |
| Min  | .1109     | .0914     | .1494     | .1448     | .1334     | .1981     | .2054     |
| Avg  | .5913     | .5404     | .6147     | .5220     | .6394     | .6814     | .5466     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 202 / Gumpha Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2146    |
| Max  | 1.2146    |
| Min  | 1.2146    |
| Avg  | 1.2146    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 203 / Hingangaon ne Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1494     | .3223     | .1698     | .1905     | .168      | 1.6461    |           |
| 2    | .1494     | .3223     | .1698     |           | .168      | 1.6461    |           |
| 3    | .1494     | .336      | .1698     |           | .168      | 1.6804    |           |
| 4    | .1494     | .3223     | .1698     |           | .168      | 1.7147    |           |
| 5    | .1494     | .3223     | .1698     |           | .168      | 1.7147    |           |
| 6    |           |           |           |           |           | 1.9631    |           |
| 7    |           |           |           |           |           | 2.4714    |           |
| 8    |           |           |           |           |           | 2.7343    |           |
| 9    |           |           |           |           |           | 2.6993    |           |
| 12   |           | 4.2943    |           | 3.1539    | 2.5339    |           |           |
| 13   |           | 5.4032    |           | 3.3065    | 2.6006    |           |           |
| 14   | 3.1369    | 5.0412    | 3.0331    | 2.9001    | 2.5339    |           |           |
| 15   | 3.2693    | 4.9627    | 3.0483    | 2.9656    | 2.4006    |           |           |
| 16   | 3.4034    | 2.4669    | 3.0178    | 3.2278    | 2.3339    |           | .128      |
| 17   | 3.2556    | 2.9504    | 2.9874    | 3.0803    | 3.0664    | .12       | .1307     |
| 18   | 3.1036    | 2.9504    | 2.5911    | 2.9165    | 2.8675    | .1543     | .1307     |
| 19   | 2.8292    | 2.6113    | 2.3929    | 2.649     | 2.536     | .2058     | .2241     |
| 20   | .2054     | .2452     | .2229     | .2054     | .2427     | .1905     | .2241     |
| 21   | .2054     | .1509     | .2058     | .1867     | .2054     | .1715     | .1867     |
| 22   | .1867     | .132      | .1886     | .168      | .1867     | .1524     | .1494     |
| 23   | .1867     | .132      | .2096     | .1307     | .1307     | .1334     | .112      |
| 24   | .1494     | .3223     | .1698     | .1905     | .168      | 1.6278    |           |
| Max  | 3.4034    | 5.4032    | 3.0483    | 3.3065    | 3.0664    | 2.7343    | .2241     |
| Min  | .1494     | .132      | .1698     | .1307     | .1307     | .12       | .112      |
| Avg  | 1.2924    | 1.8493    | 1.1823    | 1.8051    | 1.2581    | 1.2368    | .1607     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 204 / Bhatkudgaon Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0191     | .0191     | .0191     | .0191     | .0191     | .0191     |           |
| 2    | .0191     | .0191     | .0191     | .0191     | .0191     | .0191     |           |
| 3    |           | .0191     | .0191     | .0191     | .0191     | .0191     |           |
| 4    |           | .0191     | .0191     | .0191     | .0191     | .0191     |           |
| 5    |           | .0191     | .0191     | .0191     | .0191     | .0191     |           |
| 6    |           | .0191     | .0191     | .0191     | .0191     | .0191     |           |
| 7    |           | .0191     | .0191     | .0191     | .0191     | .0191     |           |
| 8    |           | .0191     | .0191     | .0191     |           | .0191     |           |
| 9    | .0381     | .0191     | .0191     |           | .0191     | .0191     |           |
| 10   | .0191     | .0191     |           | .0191     | .0191     | .0381     |           |
| 11   | .0191     | .0191     |           | .0191     |           | .0381     |           |
| 13   | .0191     |           |           |           |           |           |           |
| 16   |           | .0191     |           |           |           |           |           |
| 17   |           | .0191     |           | .0191     | .0191     |           | .0191     |
| 18   |           | .0191     | .0191     | .0191     | .0191     | .0191     | .0191     |
| 19   | .0191     | .0191     | .0381     | .0191     | .0191     |           | .0381     |
| 20   | .0191     | .0191     | .0381     | .0191     | .0191     | .0381     | .0191     |
| 21   | .0191     | .0191     | .0191     | .0191     | .0191     | .0381     | .0191     |
| 22   | .0191     | .0191     | .0191     | .0191     | .0191     | .0381     | .0191     |
| 23   | .0191     | .0191     | .0191     | .0191     | .0191     | .0381     | .0191     |
| 24   | .0191     | .0191     | .0191     | .0191     | .0191     | .0191     |           |
| Max  | .0381     | .0191     | .0381     | .0191     | .0191     | .0381     | .0381     |
| Min  | .0191     | .0191     | .0191     | .0191     | .0191     | .0191     | .0191     |
| Avg  | .0207     | .0191     | .0215     | .0191     | .0191     | .0258     | .0218     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 205 / Bhatkudgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0953     | .0762     | .0953     | .0953     | .0953     | .0762     | .0953     |
| 2    | .0953     | .0953     | .0953     | .0953     | .0953     | .0762     | .0953     |
| 3    | .0953     | .0953     | .1143     | .0953     | .0953     | .0762     | .0953     |
| 4    | .1143     | .1143     | .1143     | .1143     | .1143     | .0762     | .1143     |
| 5    | .1334     | .1334     | .1334     | .1334     | .1334     | .0762     | .1334     |
| 6    | .1715     | .1715     | .1905     | .1905     | .1905     | .0953     | .2286     |
| 7    | .1905     | .1905     | .2286     | .2286     | .2286     | .1267     | .2477     |
| 8    | .2096     | .2096     | .2096     | .2096     | .2286     | .128      | .2286     |
| 9    | .2096     | .2096     | .1905     | .2286     | .2096     | .1307     | .2477     |
| 10   | .2096     | .3048     |           | .1905     | .1905     | .0747     | .2096     |
| 11   | .1715     | .2096     |           | .2096     | .1905     | .2096     | .1715     |
| 12   | .0953     | .1143     |           | .1524     | .0762     | .1334     | .1143     |
| 13   | .0762     | .0953     |           | .0762     | .0572     | .1334     | .0762     |
| 14   | .0572     | ***       | .0762     | .0762     | .0572     | .0572     |           |
| 15   | .0572     | .0762     | .0762     | .0572     | .0762     | .0762     |           |
| 16   | .0572     | .1143     | .0953     | .0762     | .0572     |           |           |
| 17   | .0953     | .0762     | .1143     | .0953     | .0953     | .1334     | .0953     |
| 18   | .1334     | .1334     | .1524     | .1334     | .0819     | .1715     | .1143     |
| 19   | .2096     | .1905     | .2286     | .2477     | .12       | .2477     | .2096     |
| 20   | .1715     | .1905     | .0381     | .2096     | .128      | .2286     | .1905     |
| 21   | .1524     | .1524     | .1143     | .1524     | .0747     | .1905     | .1524     |
| 22   | .1334     | .1334     | .0953     | .1143     | .0747     | .1524     | .1143     |
| 23   | .0953     | .1143     | .0953     | .0953     | .0747     | .1143     | .0953     |
| 24   | .0953     | .0762     | .0953     | .0953     | .0953     | .0762     | .0762     |
| Max  | .2096     | 35.3986   | .2286     | .2477     | .2286     | .2477     | .2477     |
| Min  | .0572     | .0762     | .0381     | .0572     | .0572     | .0572     | .0762     |
| Avg  | .1302     | 1.6115    | .1277     | .1405     | .1184     | .1244     | .1479     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 014159 / Bhatkudgaon

Feeder No / Name : 206 / 11KV Akhatwade

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1494     | .1509     |           | .1715     | .1886     | .3111     |           |
| 2    | .1494     | .1509     |           | .1715     | .1886     | .3111     |           |
| 3    | .1494     | .1509     |           | .1715     | .1886     | .3246     |           |
| 4    | .1494     | .1698     |           | .1715     | .1886     | .3517     |           |
| 5    | .1494     | .1698     |           | .1715     | .1886     | .3978     |           |
| 6    |           |           |           |           |           | .5647     |           |
| 7    |           |           |           |           |           | .8278     |           |
| 8    |           |           |           |           |           | 1.0669    |           |
| 9    |           |           |           |           |           | 1.1265    |           |
| 12   | .9393     | 1.8442    |           | 1.0623    | 1.0936    |           |           |
| 13   | .4199     | 1.9204    |           | 1.0648    | 1.1336    |           |           |
| 14   | .4633     | .8669     | .9907     | .9602     | 1.0669    |           |           |
| 15   | 1.2029    |           | 1.0059    | .7922     | 1.0136    |           |           |
| 16   | 1.2811    |           | 1.0669    | .8993     | 1.0002    |           | .1097     |
| 17   | 1.0974    | .5312     | 1.0669    | .9297     | 1.0669    | .1543     | .1307     |
| 18   | .9755     | .7655     | .9297     | .9536     | .6767     | .1715     | .1307     |
| 19   | .8642     | .587      | .8078     | .8535     | .7773     | .2229     | .2241     |
| 20   | .2054     | .2263     |           | .2263     |           | .1905     | .2614     |
| 21   | .1867     | .1698     | .1715     | .2054     | .2054     | .1715     | .1867     |
| 22   | .168      | .1509     | .1715     | .2054     | .1867     | .1715     | .1494     |
| 23   | .1494     | .1509     | .1905     | .2054     | .1494     | .1524     | .1307     |
| 24   | .1494     | .1509     | .132      | .1715     | .1886     | .3111     |           |
| Max  | 1.2811    | 1.9204    | 1.0669    | 1.0648    | 1.1336    | 1.1265    | .2614     |
| Min  | .1494     | .1509     | .132      | .1715     | .1494     | .1524     | .1097     |
| Avg  | .4916     | .5098     | .6533     | .5215     | .5589     | .4016     | .1654     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 017014 / 132/33 kv SHEVGAON S/S

Feeder No / Name : 401 / 33 KV BALAMTAKALI

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 33 / INCOMING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 11.4312   |
| Max  | 11.4312   |
| Min  | 11.4312   |
| Avg  | 11.4312   |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 017014 / 132/33 kv SHEVGAON S/S

Feeder No / Name : 406 / 33 KV KHARADGAON

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 33 / INCOMING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 11.4312   |
| Max  | 11.4312   |
| Min  | 11.4312   |
| Avg  | 11.4312   |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR RURAL DIVISION[571]

SHEVGAON[194] BU 5754

Substation No/ Name :- 017014 / 132/33 kv SHEVGAON S/S

Feeder No / Name : 703 / 132KV GANGAMAI CO. GEN. NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
FEEDER Feeder KV- 132 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 4.5725    |
| Max  | 4.5725    |
| Min  | 4.5725    |
| Avg  | 4.5725    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 201 / 11 kv Jeur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2772     |
| Max  | .2772     |
| Min  | .2772     |
| Avg  | .2772     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 202 / 11 kv Dongargan

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .9724     |
| Max  | .9724     |
| Min  | .9724     |
| Avg  | .9724     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 203 / 11 KV PANGARMAL (AG)  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.9909    |
| Max  | 1.9909    |
| Min  | 1.9909    |
| Avg  | 1.9909    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 204 / 11 kv Manjarsumba -GFSS-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2587     |
| Max  | .2587     |
| Min  | .2587     |
| Avg  | .2587     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 206 / 11 KV SASEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6036     |
| Max  | .6036     |
| Min  | .6036     |
| Avg  | .6036     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 207 / DHANGARWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2033     |
| Max  | .2033     |
| Min  | .2033     |
| Avg  | .2033     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 208 / UDARMAL (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.009     |
| Max  | 2.009     |
| Min  | 2.009     |
| Avg  | 2.009     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014037 / 33/11 KV JEUR S/STN

Feeder No / Name : 209 / 11 KV IMAMPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1719    |
| Max  | 2.1719    |
| Min  | 2.1719    |
| Avg  | 2.1719    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014038 / 33/11 KV CHICHONDI PATIL

Feeder No / Name : 202 / Takli kazi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5944     |
| Max  | .5944     |
| Min  | .5944     |
| Avg  | .5944     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014038 / 33/11 KV CHICHONDI PATIL

Feeder No / Name : 204 / 11 kv Athwad -GFSS-

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2481     |
| Max  | .2481     |
| Min  | .2481     |
| Avg  | .2481     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014038 / 33/11 KV CHICHONDI PATIL

Feeder No / Name : 205 / 11 kv Renuka Devi ( C. SEPARATED AG FEEDERS HAVING SPECIAL  
Patil ) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .181      |
| Max  | .181      |
| Min  | .181      |
| Avg  | .181      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014038 / 33/11 KV CHICHONDI PATIL

Feeder No / Name : 206 / Bhatodi (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2136    |
| Max  | 1.2136    |
| Min  | 1.2136    |
| Avg  | 1.2136    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 201 / Kaudgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .1526     | .1509     | .1296     | .1296     | .9393     | 1.3413    |
| Max  | .1526     | .1509     | .1296     | .1296     | .9393     | 1.3413    |
| Min  | .1526     | .1509     | .1296     | .1296     | .9393     | 1.3413    |
| Avg  | .1526     | .1509     | .1296     | .1296     | .9393     | 1.3413    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 202 / Mehekari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1509     | .1669     | .1692     | .1471     | .1585     | 1.0418    | 1.4114    |
| 2    | .1578     | .1692     | .1692     | .1463     | .1593     | 1.0395    | 1.4662    |
| 3    | .1684     | .1738     | .1654     | .1478     | .1608     | 1.0806    | 1.4556    |
| 4    | .1684     | .1882     | .176      | .1623     | .1661     | 1.102     | 1.4914    |
| 5    | .1806     | .189      | .1867     | .1692     | .1669     | 1.1782    | 1.6049    |
| 6    | .0312     |           | .0137     |           |           | 1.4434    | 1.9425    |
| 7    |           |           |           |           |           | 1.7269    | 2.8441    |
| 8    |           |           |           |           |           | 2.7945    | 3.4446    |
| 9    |           |           |           |           |           | 2.8776    | 3.3265    |
| 11   | .6066     | .1395     | .2256     | .5136     | .202      |           |           |
| 12   | 3.1847    | 3.376     | 3.0133    | 3.2564    | 3.5254    |           |           |
| 13   | 3.5818    | 3.6283    | 3.4987    | 2.5271    | 3.0879    |           |           |
| 14   | 3.4545    | 3.6374    | 3.5803    | 3.2122    | 3.0712    |           |           |
| 15   | 3.6847    | 3.5292    | 3.5559    | 3.3059    | 3.5277    | .0122     | .0137     |
| 16   | 3.8127    | 3.6885    | 3.3547    | 3.4202    | 3.4339    | .0884     | .1128     |
| 17   | 3.8874    | 3.7906    | 3.501     | 3.4972    | 3.2922    | .0998     | .1357     |
| 18   | 3.3471    | 2.4013    | 3.4149    | 3.3852    | 3.2808    | .1425     | .1341     |
| 19   | 3.1321    | 2.9957    | 2.8913    | 2.3503    | 3.0079    | .218      | .2119     |
| 20   | .2279     | .2362     | .2583     | .2423     | .2256     | .2492     | .2416     |
| 21   | .221      | .2218     | .218      | .2149     | .2218     | .2126     | .2263     |
| 22   | .205      | .2035     | .189      | .1974     | .1913     | .1997     | .205      |
| 23   | .1943     | .1959     | .1646     | .1806     | .2919     | .2881     | .4435     |
| 24   | .3225     | .3278     | .2989     | .3103     | 1.1568    | 2.0775    | 2.7138    |
| Max  | 3.8874    | 3.7906    | 3.5803    | 3.4972    | 3.5277    | 2.8776    | 3.4446    |
| Min  | .0312     | .1395     | .0137     | .1463     | .1585     | .0122     | .0137     |
| Avg  | 1.5360    | 1.5399    | 1.4522    | 1.4414    | 1.5436    | .9407     | 1.2329    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 203 / 11 kv Parewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 14   |           |           |           |           |           | 2.4034    |
| 16   |           |           |           | .2058     |           |           |
| 17   |           |           |           | .2915     |           |           |
| 24   | 1.448     | 1.4403    | 1.3603    | 1.1873    | .1829     | 2.4034    |
| Max  | 1.448     | 1.4403    | 1.3603    | 1.1873    | .1829     | 2.4034    |
| Min  | 1.448     | 1.4403    | 1.3603    | .2058     | .1829     | 2.4034    |
| Avg  | 1.448     | 1.4403    | 1.3603    | .5615     | .1829     | 2.4034    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 204 / 11 kv pargaon-GFSS-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .1524     |           | .1524     | .1524     | .1829     | .1829     |
| 2    |           | .1524     |           | .1524     | .1524     | .1829     | .1829     |
| 3    |           | .1524     |           | .1524     | .1829     | .1829     | .1829     |
| 4    |           | .1829     |           | .1829     | .2134     | .2134     | .2134     |
| 5    |           | .2743     |           | .3048     | .3048     | .3353     | .3048     |
| 6    |           | .4268     |           | .4572     | .4572     | .5182     | .4572     |
| 7    |           | .6097     |           | .6401     | .6706     | .7011     | .6401     |
| 8    |           | .5792     |           | .6401     | .7011     | .7011     | .6401     |
| 9    |           | .4877     |           | .5182     | .5792     | .5487     | .5182     |
| 10   |           | .3963     |           | .4268     | .5182     | .4877     |           |
| 11   |           | .3048     |           | .3048     | .3658     | .3048     |           |
| 12   |           | .2134     |           | .2134     | .2134     | .2134     |           |
| 13   |           | .1219     |           | .1219     | .1829     | .1219     |           |
| 14   |           | .0914     |           | .1219     | .1524     | .1219     | .1029     |
| 15   | .1219     | .1219     |           | .1219     | .1524     | .1219     |           |
| 16   | .0914     | .1219     | .1219     | .1219     | .1219     |           | .1219     |
| 17   | .1219     | .1524     | .1219     | .1219     | .1219     | .1524     | .1524     |
| 18   | .1829     | .1524     | .1829     | .1829     | .1829     | .2134     | .2439     |
| 19   | .3353     | .3658     | .4268     | .3048     | .3963     | .4572     | .4268     |
| 20   | .4572     | .4572     | .5487     | .5182     | .5182     | .5182     | .5182     |
| 21   | .3658     | .3353     | .3963     | .4572     | .4572     | .4572     | .4877     |
| 22   | .3048     | .2743     | .2439     | .3048     | .3353     | .3048     | .3048     |
| 23   | .2134     | .2439     | .2134     |           | .2439     | .2439     | .2743     |
| 24   | .3582     | .1433     | .3323     | .2987     | .3475     | .3963     | .3963     |
| Max  | .4572     | .6097     | .5487     | .6401     | .7011     | .7011     | .6401     |
| Min  | .0914     | .0914     | .1219     | .1219     | .1219     | .1219     | .1029     |
| Avg  | .2553     | .2714     | .2876     | .2966     | .3218     | .3340     | .3343     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 205 / 11 kv Shahapur -GFSS-  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 14   |           |           |           |           |           |           | .4458     |
| 24   | .4908     | .5373     | .5601     | .5121     | .5487     | .5487     | .4458     |
| Max  | .4908     | .5373     | .5601     | .5121     | .5487     | .5487     | .4458     |
| Min  | .4908     | .5373     | .5601     | .5121     | .5487     | .5487     | .4458     |
| Avg  | .4908     | .5373     | .5601     | .5121     | .5487     | .5487     | .4458     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 206 / 11 kv Pimpalgaon Landga      SEPARATED AG FEEDERS HAVING SPECIAL  
 (AG) Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

| DATE | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 14   |           |           |           |           |           | .9945     |
| 24   | .4191     | .4359     | .3688     | .4024     | .0648     | .0762     |
| Max  | .4191     | .4359     | .3688     | .4024     | .0648     | .9945     |
| Min  | .4191     | .4359     | .3688     | .4024     | .0648     | .0762     |
| Avg  | .4191     | .4359     | .3688     | .4024     | .0648     | .5354     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014039 / 33/11 KV MEHEKARI

Feeder No / Name : 208 / 11 kv Barababhali  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 14   |           |           |           |           |           |           | .9945     |
| 16   |           |           |           |           | .463      |           |           |
| 17   |           |           |           |           | .3086     |           |           |
| 24   | .6104     | .5335     | .5121     | .4801     | .4801     | .1524     | .2591     |
| Max  | .6104     | .5335     | .5121     | .4801     | .4801     | .1524     | .9945     |
| Min  | .6104     | .5335     | .5121     | .4801     | .3086     | .1524     | .2591     |
| Avg  | .6104     | .5335     | .5121     | .4801     | .4172     | .1524     | .6268     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014040 / 33/11 KV DEHARE S/STN

Feeder No / Name : 202 / 11 kv Dehare

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.1131    |
| Max  | 3.1131    |
| Min  | 3.1131    |
| Avg  | 3.1131    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014040 / 33/11 KV DEHARE S/STN

Feeder No / Name : 203 / 11 KV Nandgaon (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5487     |
| Max  | .5487     |
| Min  | .5487     |
| Avg  | .5487     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014040 / 33/11 KV DEHARE S/STN

Feeder No / Name : 204 / 11 kv Kolewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.0805    |
| Max  | 2.0805    |
| Min  | 2.0805    |
| Avg  | 2.0805    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014041 / Mula Dam

Feeder No / Name : 201 / CEO ZP ANGR MIRI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .543      |
| Max  | .543      |
| Min  | .543      |
| Avg  | .543      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014041 / Mula Dam

Feeder No / Name : 202 / COMMISSIONER ANGR MIRI  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.267     |
| Max  | 1.267     |
| Min  | 1.267     |
| Avg  | 1.267     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 201 / Deulgaon sidhhi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2717    |
| Max  | 1.2717    |
| Min  | 1.2717    |
| Avg  | 1.2717    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 202 / Walki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1719    |
| Max  | 2.1719    |
| Min  | 2.1719    |
| Avg  | 2.1719    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 203 / 11 kV Khadaki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE       | 01-FEB-17     | 02-FEB-17    |
|------------|---------------|--------------|
| HR         | Load (MW)     | Load (MW)    |
| 1          | .4572         | .3048        |
| 2          | .4572         |              |
| 3          | .4572         |              |
| 4          | .4572         |              |
| 5          | .4572         |              |
| 12         | 1.2193        |              |
| 13         | 1.2193        |              |
| 14         | 1.0669        |              |
| 15         | .9145         |              |
| 16         | 1.0669        |              |
| 17         | 1.0669        |              |
| <b>Max</b> | <b>1.2193</b> | <b>.3048</b> |
| <b>Min</b> | <b>.4572</b>  | <b>.3048</b> |
| <b>Avg</b> | <b>.8036</b>  | <b>.3048</b> |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 204 / 11 kv Sarola kasar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.0119    |
| Max  | 2.0119    |
| Min  | 2.0119    |
| Avg  | 2.0119    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 205 / 11 kv Hiware zare  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4405     | .4496     | .4618     | .4298     | .4435     | .6219     | .6843     |
| 2    | .4633     | .4931     | .4778     | .4481     | .4611     | .647      | .7156     |
| 3    | .4862     | .5152     | .4938     |           | .4938     | .6821     | .7735     |
| 4    | .5152     |           | .519      |           | .4976     | .759      | .8162     |
| 5    | .2545     |           | .1837     |           | .192      | .9282     | .996      |
| 6    |           |           |           |           |           | 1.2879    | 1.3801    |
| 7    |           |           |           |           |           | 1.659     | 1.8808    |
| 8    |           |           |           |           |           | 1.8267    | 2.0713    |
| 9    |           |           |           |           |           | .8718     | 1.0197    |
| 11   | 1.5767    | 1.4929    | 1.3314    | 1.2666    | 1.3306    |           |           |
| 12   | 1.6842    | 1.6309    | 1.4015    | 1.374     | 1.5478    |           |           |
| 13   | 1.6728    | 1.6636    | 1.4068    | 1.4121    | 1.5303    |           |           |
| 14   | 1.6194    | 1.5402    | 1.2856    | 1.4015    | 1.2849    |           | .0008     |
| 15   | 1.6369    | 1.56      | 1.2872    | 1.3512    | 1.4464    | .2721     | .2599     |
| 16   | 1.6819    | 1.5638    | 1.2772    | 1.4114    | 1.4777    | .2622     | .2782     |
| 17   | 1.701     | 1.5966    | 1.4045    | 1.4373    | 1.4693    | .3262     | .3391     |
| 18   | 1.6918    | 1.6164    | 1.5104    | 1.448     | 1.5005    | .3704     | .4016     |
| 19   | .6874     | .4649     | .6462     | .6043     | .615      |           |           |
| 20   | .41       | .0305     |           |           | .3582     | .2309     | .2187     |
| 21   | .3795     | .0663     | .1113     | .0244     | .4611     | .4351     | .4611     |
| 22   | .4679     | .4481     | .4374     | .4351     | .4397     | .4016     | .4313     |
| 23   | .4435     | .4397     | .4283     | .4245     | .5533     | .5937     | .708      |
| 24   | 2.4707    | .458      | .4115     | .4237     | .5815     | .6424     | .7537     |
| Max  | 2.4707    | 1.6636    | 1.5104    | 1.448     | 1.5478    | 1.8267    | 2.0713    |
| Min  | .2545     | .0305     | .1113     | .0244     | .192      | .2309     | .0008     |
| Avg  | 1.0675    | .9429     | .8375     | .9261     | .8781     | .7121     | .7468     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 206 / 11 kv Babhurdi Ghumat -  
GFSS- Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6335     |
| Max  | .6335     |
| Min  | .6335     |
| Avg  | .6335     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 207 / 11 KV Khandala (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .543      |
| Max  | .543      |
| Min  | .543      |
| Avg  | .543      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 208 / Ahmednagar Goat Farm NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2069     |
| Max  | .2069     |
| Min  | .2069     |
| Avg  | .2069     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 209 / Sakhar Karkhana (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .4858     |
| Max  | .4858     |
| Min  | .4858     |
| Avg  | .4858     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 210 / 11 KV GHOSPURI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .543      |
| Max  | .543      |
| Min  | .543      |
| Avg  | .543      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014042 / 33/11 kV Baburdi Bend

Feeder No / Name : 211 / SHRIKHAND MALA  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1719    |
| Max  | 2.1719    |
| Min  | 2.1719    |
| Avg  | 2.1719    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 201 / 11 kv Rui chh. SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6401     |
| Max  | .6401     |
| Min  | .6401     |
| Avg  | .6401     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 202 / 11 kv Gunwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3887     |
| Max  | .3887     |
| Min  | .3887     |
| Avg  | .3887     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 203 / 11 kv Math pimpri SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 17   |           | 1.6446    |
| 18   |           | 1.6575    |
| 19   |           | 1.3599    |
| 20   |           | .4588     |
| 21   |           | .431      |
| 22   |           | .3315     |
| 23   |           | .2652     |
| 24   | .7362     |           |
| Max  | .7362     | 1.6575    |
| Min  | .7362     | .2652     |
| Avg  | .7362     | .8784     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 207 / Ambilwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 12   |           | .5864     |           |
| 17   |           |           | .0633     |
| 18   |           |           | .0995     |
| 19   |           |           | .2294     |
| 20   |           |           | .1966     |
| 21   |           |           | .2012     |
| 22   |           |           | .1638     |
| 23   |           |           | .1638     |
| 24   | .1296     |           |           |
| Max  | .1296     | .5864     | .2294     |
| Min  | .1296     | .5864     | .0633     |
| Avg  | .1296     | .5864     | .1597     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 208 / 11 kv Ralegan SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 18   |           | 1.2266    |
| 20   |           | .5079     |
| 21   |           | .4915     |
| 22   |           | .4641     |
| 23   |           | .3647     |
| 24   | .6241     |           |
| Max  | .6241     | 1.2266    |
| Min  | .6241     | .3647     |
| Avg  | .6241     | .6110     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014043 / 33/11KV RUI CHHATTISHI S/S

Feeder No / Name : 209 / VENKATESHWRA HATCHRIES  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 11   |           | .1696     |           |
| 12   |           | .208      |           |
| 17   |           |           | .1581     |
| 18   |           |           | .1823     |
| 19   |           |           | .2321     |
| 20   |           |           | .1677     |
| 21   |           |           | .1966     |
| 22   |           |           | .1966     |
| 23   |           |           | .213      |
| 24   | .1943     |           |           |
| Max  | .1943     | .208      | .2321     |
| Min  | .1943     | .1696     | .1581     |
| Avg  | .1943     | .1888     | .1923     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014044 / 33/11 KV BHOIRE PATHAR

Feeder No / Name : 201 / Kamargaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.2579    |
| Max  | 3.2579    |
| Min  | 3.2579    |
| Avg  | 3.2579    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014044 / 33/11 KV BHOIRE PATHAR

Feeder No / Name : 202 / Chass

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1719    |
| Max  | 2.1719    |
| Min  | 2.1719    |
| Avg  | 2.1719    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014044 / 33/11 KV BHOIRE PATHAR

Feeder No / Name : 203 / PIMPALGAON KAUDA (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6335     |
| Max  | .6335     |
| Min  | .6335     |
| Avg  | .6335     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014044 / 33/11 KV BHOIRE PATHAR

Feeder No / Name : 204 / SONEWADI (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5792     |
| Max  | .5792     |
| Min  | .5792     |
| Avg  | .5792     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014121 / Hiware Bazar

Feeder No / Name : 201 / Jakhangaon (New)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .2846     | .2743     | .1646     |
| 2    |           |           | .3041     | .3048     | .1646     |
| 3    |           |           | .3201     | .3353     | .1646     |
| 4    |           |           | .4481     | .3658     | .1848     |
| 5    |           |           | .6226     | .442      | .2987     |
| 6    |           |           |           | .6097     | .4481     |
| 7    |           |           | 1.166     | .9145     | .5415     |
| 8    | 1.1873    | 1.1248    |           | 1.0059    | .4668     |
| 9    | .8749     | .945      | .8987     | .9145     |           |
| 10   | .2591     | .2439     | .1619     | .2743     |           |
| 11   | .1677     | .1966     | .1943     |           |           |
| 12   | .1509     |           | .1524     |           |           |
| 13   | .1509     | .1475     | .1067     |           |           |
| 14   | .1311     | .1311     | .1219     |           |           |
| 15   | .1311     | .112      | .1372     |           |           |
| 16   | .1372     |           | .0914     |           | .5247     |
| 17   | .1372     |           | .1219     |           | .6097     |
| 18   | .1829     |           | .1829     |           | .5792     |
| 19   | .2896     |           | .3048     |           | .5335     |
| 20   |           |           | .3353     |           |           |
| 21   |           |           | .2286     |           |           |
| 22   |           |           | .1981     |           |           |
| 23   |           |           | .1677     |           |           |
| 24   | 1.267     |           | .2881     | .2896     | .1663     |
| Max  | 1.267     | 1.1248    | 1.166     | 1.0059    | .6097     |
| Min  | .1311     | .112      | .0914     | .2743     | .1646     |
| Avg  | .3898     | .4144     | .3108     | .5210     | .3729     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014121 / Hiware Bazar

Feeder No / Name : 202 / Hiware Bazar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0566     |           | .0543     | .0579     | .061      |
| 2    | .0754     |           | .0543     | .0579     | .061      |
| 3    | .1109     |           | .0554     | .0705     | .0617     |
| 4    | .1109     |           | .0739     | .0846     | .08       |
| 5    | .1886     |           | .1109     | .0987     | .1094     |
| 6    | .2241     |           | .2402     | .1269     | .1543     |
| 7    | .2614     |           | .2427     | .1551     | .2656     |
| 8    | .2427     | .2402     | .1867     | .1269     | .3704     |
| 9    | .1612     | .1848     | .1494     | .1128     |           |
| 10   | .1227     | .1433     | .1097     | .1355     |           |
| 11   | .0716     | .1029     | .0732     |           |           |
| 12   | .141      | .1269     |           |           |           |
| 13   | .0987     | .1269     | .1189     |           |           |
| 14   | .1067     | .1128     | .1128     |           |           |
| 15   | .0934     |           | .1269     |           |           |
| 16   | .1067     |           | .1593     |           | .0373     |
| 17   |           |           | .1593     |           | .0686     |
| 18   |           |           | .2027     |           | .0857     |
| 19   |           |           | .1593     |           | .1715     |
| 20   |           |           | .1448     |           |           |
| 21   |           |           | .1158     |           |           |
| 22   |           |           | .0869     |           |           |
| 23   |           |           | .0579     |           |           |
| 24   | .056      | .1448     | .0543     | .0579     | .0625     |
| Max  | .2614     | .2402     | .2427     | .1551     | .3704     |
| Min  | .056      | .1029     | .0543     | .0579     | .0373     |
| Avg  | .1311     | .1478     | .1239     | .0986     | .1222     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014121 / Hiware Bazar

Feeder No / Name : 203 / Takali Khatgaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0402    |
| Max  | 1.0402    |
| Min  | 1.0402    |
| Avg  | 1.0402    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014121 / Hiware Bazar

Feeder No / Name : 204 / Nimgaonwagha GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .112      |
| Max  | .112      |
| Min  | .112      |
| Avg  | .112      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014121 / Hiware Bazar

Feeder No / Name : 206 / 11 kv Pimpalgaon (AG)  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0754     |           | .0732     | .0594     | .0625     |
| 2    | .112      |           | .0732     | .0743     | .0625     |
| 3    | .1509     |           | .0732     | .0892     | .0594     |
| 4    | .1509     |           | .0914     | .104      | .0518     |
| 5    | .1867     |           | .1829     | .1337     | .0974     |
| 6    | .2957     |           | .1848     | .1783     | .1829     |
| 7    | .3174     |           | .2987     | .2378     | .2721     |
| 8    | .2587     | .2896     | .2987     | .2229     | .3637     |
| 9    | .2149     | .1991     | .2801     | .1829     |           |
| 10   | .1753     | .2035     | .2402     | .1829     |           |
| 11   | .12       | .1696     | .1829     |           |           |
| 12   | .1572     | .1882     | .1882     |           |           |
| 13   | .1128     | .1014     | .1692     |           |           |
| 14   | .0934     | .1448     | .1551     |           |           |
| 15   | .12       | .1551     | .1692     |           |           |
| 16   | .1467     |           | .1593     |           | .0934     |
| 17   |           |           | .1738     |           | .112      |
| 18   |           |           | .2027     |           | .1307     |
| 19   |           |           | .1738     |           | .2058     |
| 20   |           |           | .1448     |           |           |
| 21   |           |           | .104      |           |           |
| 22   |           |           | .0892     |           |           |
| 23   |           |           | .0743     |           |           |
| 24   | .0747     |           | .0732     | .0594     | .064      |
| Max  | .3174     | .2896     | .2987     | .2378     | .3637     |
| Min  | .0747     | .1014     | .0732     | .0594     | .0518     |
| Avg  | .1625     | .1814     | .1607     | .1386     | .1352     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014158 / NARAYAN DOH

Feeder No / Name : 202 / 11 kv Mandwa

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3086     |
| Max  | .3086     |
| Min  | .3086     |
| Avg  | .3086     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014158 / NARAYAN DOH

Feeder No / Name : 203 / 11 kv Walunj Pargaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2631    |
| Max  | 1.2631    |
| Min  | 1.2631    |
| Avg  | 1.2631    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR (R)-II[202] BU 6726

Substation No/ Name :- 014158 / NARAYAN DOH

Feeder No / Name : 204 / venkateshwara

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1132     |
| Max  | .1132     |
| Min  | .1132     |
| Avg  | .1132     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014032 / 33/11 KV SOLAPUR RD.

Feeder No / Name : 201 / 11 kV Ashoka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4161     | .3749     | .423      | .3993     | .4397     | .4016     | .4291     |
| 2    | .3909     | .3673     | .407      | .381      | .4115     | .378      | .4191     |
| 3    | .3909     | .3544     | .3963     | .3711     | .4161     | .3696     | .3963     |
| 4    | .3917     | .3528     | .3917     | .3765     | .4153     | .3749     | .3986     |
| 5    | .4009     | .3788     | .4367     | .4024     | .4169     | .4054     | .4214     |
| 6    | .5456     | .4809     | .5312     | .4733     | .49       | .4999     | .5053     |
| 7    | .538      | .5487     | .5685     | .4984     | .4679     | .5357     | .5251     |
| 8    | .567      | .5723     | .5883     | .5312     | .551      | .5624     | .5464     |
| 9    | .6089     | .5883     | .6318     | .602      | .5944     | .6112     | .644      |
| 10   | .6051     | .612      | .6386     | .647      | .6531     | .6531     | .6173     |
| 11   | .5937     | .6028     | .5959     | .5876     | .6028     | .5883     | .6287     |
| 12   | .6287     | .5914     | .6036     | .128      | .5533     | .5677     | .6051     |
| 13   | .6028     | .5548     | .5822     | .1417     | .5533     | .5441     | .5517     |
| 14   | .538      | .5243     | .5418     | .6287     | .5091     | .5114     | .5571     |
| 15   | .4976     | .5213     | .4976     | .6081     | .5327     | .5022     | .5578     |
| 16   | .4931     | .5525     | .5037     | .5533     | .4961     | .5136     | .5388     |
| 17   | .0975     | .5411     | .5106     | .5441     | .4755     | .5205     | .5685     |
| 18   | .6523     | .628      | .5883     | .5944     | .551      | .5807     | .6036     |
| 19   | .6988     | .7004     | .6744     | .6965     | .6226     | .724      | .7255     |
| 20   | .6775     | .6546     | .6455     | .6539     | .6287     | .6889     | .6798     |
| 21   | .6424     | .6348     | .6485     | .6325     | .6394     | .6234     | .6729     |
| 22   | .5769     | .551      | .5807     | .5982     | .5769     | .5632     | .6127     |
| 23   | .4931     | .4816     | .5037     | .5037     | .4938     | .4923     | .4893     |
| 24   | 1.6453    | .4367     | .4344     | .4534     | .423      | .4626     | .413      |
| Max  | 1.6453    | .7004     | .6744     | .6965     | .6531     | .724      | .7255     |
| Min  | .0975     | .3528     | .3917     | .128      | .4115     | .3696     | .3963     |
| Avg  | .5705     | .5252     | .5385     | .5003     | .5214     | .5281     | .5461     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014032 / 33/11 KV SOLAPUR RD.

Feeder No / Name : 202 / 11 kV Ganj Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5205     | .5434     | .5373     | .5624     | .5632     | .5647     | .5373     |
| 2    | .4999     | .5083     | .5045     | .5213     | .5213     | .5289     | .5129     |
| 3    | .4672     | .4938     | .4854     | .4961     | .4923     | .5114     | .4885     |
| 4    | .4687     | .5655     | .4748     | .5723     | .4946     | .5815     | .4877     |
| 5    | .4931     | .5929     | .5312     | .5982     | .5533     | .5883     | .5464     |
| 6    | .7689     | .6401     | .807      | .6683     | .7674     | .6562     | .7842     |
| 7    | 1.0532    | .8817     | 1.0006    | .8208     | .9122     | .7956     | .9526     |
| 8    | 1.0159    | 1.0029    | 1.1043    | .9054     | .9473     | .9366     | 1.009     |
| 9    | 1.1614    | 1.0555    | 1.1332    | 1.0456    | 1.1027    | 1.0479    | 1.0966    |
| 10   | 1.1142    | 1.0608    | 1.134     | 1.0059    | 1.0959    | 1.0524    | 1.1164    |
| 11   | 1.0151    | 1.0151    | 1.1462    | 1.0341    | 1.0829    | 1.0715    | 1.0722    |
| 12   | .8977     | .9717     | 1.1096    | 1.0608    |           | 1.0273    | 1.0166    |
| 13   | .916      | 1.0113    | 1.1286    | 1.0448    |           | 1.0319    | .9602     |
| 14   | .8551     | .9656     | 1.0402    | 1.0219    |           | .9755     | .929      |
| 15   | .7758     | .8954     | .9282     | .8817     |           | .8688     | .8627     |
| 16   | .7628     | .8909     | .8154     | .8962     | 1.259     | .8756     | .8886     |
| 17   | .7811     | .9008     | .881      | .9069     | 1.1965    | .8794     | .8947     |
| 18   | .8825     | .9983     | 1.0082    | .9724     | 1.0669    | .9998     | 1.0235    |
| 19   | 1.1949    | 1.3481    | 1.3481    | 1.3481    | 1.2475    | 1.3588    | 1.3809    |
| 20   | 1.1858    | 1.339     | 1.3733    | 1.3695    | 1.2445    | 1.355     | 1.3877    |
| 21   | 1.0692    | 1.2071    | 1.2064    | 1.2376    | 1.0715    | 1.2178    | 1.2323    |
| 22   | .8657     | .9008     | .8977     | .9419     | .9122     | .9008     | .945      |
| 23   | .7651     | .7659     | .7712     | .7781     | .7689     | .7651     | .7895     |
| 24   | 1.507     | .6097     | .6318     | .6455     | .6318     | .6112     | .6325     |
| Max  | 1.507     | 1.3481    | 1.3733    | 1.3695    | 1.259     | 1.3588    | 1.3877    |
| Min  | .4672     | .4938     | .4748     | .4961     | .4923     | .5114     | .4877     |
| Avg  | .8765     | .8819     | .9166     | .8890     | .8966     | .8834     | .8978     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014032 / 33/11 KV SOLAPUR RD.

Feeder No / Name : 203 / 11 kV Darewadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4793     |           | .5152     | .5098     |           | .5007     | .4656     |
| 2    | .4534     |           | .4984     | .4984     |           | .4847     | .4458     |
| 3    | .4572     | .4641     | .4915     | .4847     | .5106     | .4854     | .4451     |
| 4    | .4664     | .5091     | .5182     | .5091     | .5274     | .5083     | .4595     |
| 5    | .6005     | .6531     | .6775     | .6257     | .6356     | .6333     | .5853     |
| 6    | 1.1279    | 1.2087    | 1.0608    | .9816     | .8627     | 1.1538    | 1.0654    |
| 7    | 1.5097    | 1.4678    | 1.4769    | 1.419     | 1.246     | 1.4586    | 1.3085    |
| 8    | 1.5874    | 1.5745    | 1.7017    | 1.6179    | 1.6293    | 1.6126    | 1.531     |
| 9    | 1.6049    | 1.5767    | 1.7695    | 1.6476    | 1.733     | 1.5181    | 1.5752    |
| 10   | 1.496     | 1.3656    | 1.5074    | 1.4464    | 1.4617    | 1.3626    | 1.5158    |
| 11   | 1.3275    | 1.2262    | 1.4472    | 1.2993    | 1.3565    | 1.198     | 1.3542    |
| 12   | 1.2163    | 1.1126    | 1.2361    | 1.1378    | 1.2125    | 1.1805    | 1.118     |
| 13   | 1.0334    | 1.1058    | 1.1515    | 1.0197    | 1.1469    | 1.1515    | 1.0311    |
| 14   | 1.0319    | 1.0593    | 1.0235    | .9953     | .9838     | 1.1058    | .9686     |
| 15   | 1.0204    | .9892     | .9412     | .9191     | 1.0235    | 1.0456    |           |
| 16   | .9938     | .9938     | .98       | .9046     | 1.0585    | 1.0296    |           |
| 17   |           | 1.0608    | 1.0334    | .9534     | 1.1157    | 1.1378    |           |
| 18   |           | 1.1012    | 1.1294    | 1.0844    | 1.1446    | 1.1759    |           |
| 19   |           | 1.2818    | 1.2978    | 1.2201    | 1.23      | 1.2864    | 1.2353    |
| 20   |           | 1.1911    | 1.2231    | 1.2094    | 1.1904    | 1.2102    | 1.2239    |
| 21   |           | 1.0372    | 1.0601    | 1.0197    | 1.0402    | 1.028     | 1.0761    |
| 22   |           | .9457     | .9366     | .8985     | .8101     | .9389     | .9191     |
| 23   |           | .7331     | .7583     | .7537     | .7308     | .7004     | .7324     |
| 24   | 1.0242    | .5662     | .5822     |           | .5746     | .5258     | .5647     |
| Max  | 1.6049    | 1.5767    | 1.7695    | 1.6476    | 1.733     | 1.6126    | 1.5752    |
| Min  | .4534     | .4641     | .4915     | .4847     | .5106     | .4847     | .4451     |
| Avg  | 1.0253    | 1.0556    | 1.0424    | 1.0067    | 1.0557    | 1.0180    | .9810     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014032 / 33/11 KV SOLAPUR RD.

Feeder No / Name : 204 / 11 kV Bhingar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6644    |
| Max  | 1.6644    |
| Min  | 1.6644    |
| Avg  | 1.6644    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014032 / 33/11 KV SOLAPUR RD.

Feeder No / Name : 205 / 11 kV MES-II

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3445     |           | .5906     |           | .5026     | .5658     |
| 2    | .3456     | .3414     |           | .4374     | .5152     | .5559     |
| 3    | .3448     | .341      |           | .4675     | .5396     | .5338     |
| 4    | .3631     | .4538     |           | .394      | .535      | .3502     |
| 5    | .4553     | .602      |           | .4165     | .426      | .5011     |
| 6    | .7983     | .8947     |           | .5586     | .767      | .8044     |
| 7    | .8722     | .9717     |           | .7205     | .831      | .8059     |
| 8    | .8162     | .993      |           | .7381     | .8512     | .8135     |
| 9    | .7491     | .8665     |           | .8684     | .7423     | .727      |
| 10   | .6741     | .8322     |           | .9008     | .8326     | .7865     |
| 11   |           | .6744     |           | .8299     | .8608     | .8558     |
| 12   |           | .5216     |           | .7064     | .7895     | .7476     |
| 13   |           | .4957     |           | .6203     | .7884     | .7228     |
| 14   |           | .4268     |           | .381      | .4744     | .6154     |
| 15   |           | .3932     |           | .3502     | .4172     | .3635     |
| 16   |           | .3688     |           | .3132     | .402      | .3429     |
| 17   |           | .4245     |           | .3551     | .3955     | .3902     |
| 18   |           | .551      |           | .4047     | .4412     | .4412     |
| 19   |           | .6904     |           | .6615     | .6382     | .6382     |
| 20   |           | .7663     |           | .6851     | .6904     | .6756     |
| 21   |           | .6619     |           | .6615     | .6542     | .6581     |
| 22   |           | .5986     |           | .5746     | .5994     | .583      |
| 23   |           | .5133     |           | .49       | .4839     | .4683     |
| 24   | .2195     | .4386     |           | .519      | .5979     | .3593     |
| Max  | .8722     | .993      | .5906     | .9008     | .8608     | .8558     |
| Min  | .2195     | .341      | .5906     | .3132     | .3955     | .3429     |
| Avg  | .5439     | .6009     | .5906     | .5676     | .6156     | .5961     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014162 / 33 KV Vidyut Bhavan

Feeder No / Name : 201 / Market Yard

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.4927    | 1.5133    | 1.5775    | 1.6158    | 1.5787    | 1.7474    | 1.6089    |
| 2    | 1.4209    | 1.4403    | 1.4937    | 1.5209    | 1.4982    | 1.6254    | 1.5802    |
| 3    | 1.3781    | 1.433     | 1.4579    | 1.4716    | 1.477     | 1.5424    | 1.5486    |
| 4    | 1.3976    | 1.4549    | 1.451     | 1.4647    | 1.4685    | 1.5554    | 1.5744    |
| 5    | 1.507     | 1.5859    | 1.5631    | 1.5573    | 1.7451    | 1.6339    | 1.6483    |
| 6    | 2.082     | 2.1201    | 2.0995    | 2.1574    | 1.9803    | 2.1784    | 2.1053    |
| 7    | 2.8894    | 2.9801    | 2.929     | 2.7652    | 2.5381    | 2.894     | 1.3877    |
| 8    | 3.0893    | 3.107     | 3.1725    | 2.9596    | 2.9001    | 2.9881    | 1.5752    |
| 9    | 1.5554    | 1.5318    | 1.6209    | 1.5082    | 1.4609    | 1.499     | 3.0331    |
| 10   | 1.4548    | 1.4426    | 1.5143    | 1.4601    | 1.5493    | 1.4883    | 1.5211    |
| 11   | 1.3596    | 1.3679    | 1.3847    | 1.3062    | 1.3817    | 1.3656    | 1.4365    |
| 12   | 1.2872    | 1.1782    | 1.2346    | 2.231     | 1.2666    | 1.1728    | 2.2984    |
| 13   | 1.1751    | 1.1416    | 1.1126    | 1.0928    | 1.1492    | 1.1271    | 1.1774    |
| 14   | 1.1439    | 1.0905    | 1.1134    | .9838     | 1.0517    | 1.1424    | 1.1446    |
| 15   | 1.0227    | 1.0524    | 1.0814    | .9183     | 1.0029    | 1.0936    | 1.0768    |
| 16   | 1.0494    | 1.0601    | 1.0943    | .9556     | .9785     | 2.0469    | .9882     |
| 17   | 2.1304    | 2.0706    | 2.2611    | 1.9837    | 1.0311    | 2.1553    | 1.0517    |
| 18   | 1.2887    | 1.2163    | 1.2506    | 1.0509    | 1.1332    | 2.3657    |           |
| 19   | 3.0525    | 2.9088    | 3.0018    | 2.7618    | 1.3656    | 2.915     |           |
| 20   | 1.6034    | 1.5318    | 1.6209    | 1.4502    | 1.4259    | 2.8796    | 1.4118    |
| 21   | 2.7641    | 1.3839    | 1.419     | 1.3275    | 2.6897    | 2.6844    |           |
| 22   |           | 1.39      | 2.6817    | 1.2673    | 2.5392    | 2.5415    |           |
| 23   | 1.0808    | 1.2201    | 1.2445    | 1.1683    | 2.2939    | 2.2539    |           |
| 24   | .5121     | 1.8221    | 1.8223    | 2.0275    | 1.8157    | 1.9477    | .8682     |
| Max  | 3.0893    | 3.107     | 3.1725    | 2.9596    | 2.9001    | 2.9881    | 3.0331    |
| Min  | .5121     | 1.0524    | 1.0814    | .9183     | .9785     | 1.0936    | .8682     |
| Avg  | 1.6407    | 1.6268    | 1.7168    | 1.6252    | 1.6384    | 1.9518    | 1.5282    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014162 / 33 KV Vidyut Bhavan

Feeder No / Name : 202 / Sarasnagar  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9271     | .4477     | 1.0132    | .993      | .4252     | 1.0372    | .5815     |
| 2    | .8722     | .4298     | .9793     | .9461     | .4252     | 1.0082    | .5617     |
| 3    | .8868     | .4252     | 1.0012    | .9686     | .4477     | .9987     | .5609     |
| 4    | .9133     | .9757     | 1.0391    | 1.0117    | .4656     | 1.0336    | .5845     |
| 5    | 1.0595    | 1.1286    | 1.1934    | 1.1667    | .6535     | 1.166     | .6607     |
| 6    | 1.6407    | 1.6849    | 1.797     | 1.792     | .7468     | 1.763     | .8962     |
| 7    | 2.2887    | 2.4234    | 2.247     | 2.2611    | .9709     | 2.3719    | 1.2544    |
| 8    | 2.5038    | 2.5453    | 2.3683    | 2.4076    | 1.1016    | 2.4413    | 1.39      |
| 9    |           | 1.2414    | 1.1904    | 1.2772    |           | 1.2064    | 2.1292    |
| 10   |           | 1.0143    | .9884     | 1.0494    |           | 1.0494    | .9938     |
| 11   |           | .868      | .82       | .897      |           | .8604     | .788      |
| 12   |           | .7148     | .6988     | 1.4363    | .9038     | .708      | .9328     |
| 13   |           | .6767     | .6333     | .7247     | .7034     | .7049     | .4001     |
| 14   |           | .6737     | .6135     | .6546     | .6638     | .6401     | .365      |
| 15   |           | .6508     | .583      | .6165     | .6424     | .6638     | .3681     |
| 16   |           | .6668     | .6051     | .6241     | .6401     | .6417     | .3294     |
| 17   | .6001     | 1.3088    | 1.3069    | 1.2796    | .7057     | 1.257     | .6762     |
| 18   |           | .8512     | .7895     | .791      | .807      | 1.5436    |           |
| 19   | .9259     | 1.9769    | 2.0005    | 1.9399    | 1.0799    | 1.9173    |           |
| 20   |           | 1.054     | 1.1065    | 1.0692    | 1.1104    | 1.9635    | .9671     |
| 21   | .8417     | 1.0075    | 1.1043    | 1.0105    | 1.888     | 1.8355    |           |
| 22   |           | .9473     | 1.8419    |           | 1.7307    | 1.6953    |           |
| 23   | .631      | .8368     | .8558     |           | 1.4705    | 1.4607    |           |
| 24   | .7499     | 1.1278    | 1.119     | .6135     | 1.0897    | 1.2152    | .3294     |
| Max  | 2.5038    | 2.5453    | 2.3683    | 2.4076    | 1.888     | 2.4413    | 2.1292    |
| Min  | .6001     | .4252     | .583      | .6135     | .4252     | .6401     | .3294     |
| Avg  | 1.1416    | 1.0699    | 1.1623    | 1.1605    | .8891     | 1.2993    | .7773     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014162 / 33 KV Vidyut Bhavan

Feeder No / Name : 205 / Station Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5304     |
| Max  | .5304     |
| Min  | .5304     |
| Avg  | .5304     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014164 / 33 KV KEDGAON

Feeder No / Name : 201 / DEVI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3841     |
| Max  | .3841     |
| Min  | .3841     |
| Avg  | .3841     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014164 / 33 KV KEDGAON

Feeder No / Name : 202 / Bhushan Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .462      |
| Max  | .462      |
| Min  | .462      |
| Avg  | .462      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 014164 / 33 KV KEDGAON

Feeder No / Name : 203 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .4294     |
| Max  | .4294     |
| Min  | .4294     |
| Avg  | .4294     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 202 / 11 kV Burudgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6859     |
| Max  | .6859     |
| Min  | .6859     |
| Avg  | .6859     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 203 / 11 kV Malhar Chowk  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2193    | 1.2117    | 1.2193    |
| 2    | 1.0517    | 1.0745    | 1.0898    |
| 3    | .9907     | 1.0059    | 1.0364    |
| 4    | .9297     | .9907     | 1.0288    |
| 5    | .9678     | 1.0288    | 1.0669    |
| 6    | 1.1812    | 1.1584    | 1.2422    |
| 7    | 1.7528    | 1.608     | 1.8442    |
| 8    | 2.0348    | 1.89      | 2.0881    |
| 9    | 2.0043    | 2.0119    | 1.989     |
| 10   | 1.989     | 2.0043    | 1.9433    |
| 11   | 1.8214    | 1.8366    | 1.7071    |
| 12   | 1.6766    | 1.6918    | 1.6385    |
| 13   | 1.5927    | 1.6232    | 1.5927    |
| 14   | 1.5851    | 1.6156    |           |
| 15   | 1.4937    | 1.5013    |           |
| 16   | 1.4861    | 1.5851    |           |
| 17   | 1.5699    | 1.608     |           |
| 18   | 1.608     | 1.6766    |           |
| 19   | 1.8519    | 1.9052    |           |
| 20   | 2.1338    | 2.1643    |           |
| 21   | 2.0119    | 2.0881    |           |
| 22   | 1.8976    | 1.9509    |           |
| 23   | 1.7909    | 1.8214    |           |
| 24   | 3.3124    | 1.5242    |           |
| Max  | 3.3124    | 2.1643    | 2.0881    |
| Min  | .9297     | .9907     | 1.0288    |
| Avg  | 1.6647    | 1.6074    | 1.4989    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 204 / 11 kV Arangaon Road  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3048     |           | .3048     |
| 2    | .3048     |           | .3048     |
| 3    | .3048     |           | .3048     |
| 4    | .3048     |           | .3048     |
| 5    | .3048     |           | .3048     |
| 6    | .6097     |           | .6097     |
| 7    | .9145     |           | .6097     |
| 8    | .9145     |           | .9145     |
| 9    | .9145     |           | .9145     |
| 10   | .9145     | .6097     | .9145     |
| 11   | .6097     | .6097     | .6097     |
| 12   | .9145     | .6097     | .6097     |
| 13   | .6097     | .6097     | .6097     |
| 14   |           | .6097     | .6097     |
| 15   |           | .6097     | .6097     |
| 16   |           | .6097     | .6097     |
| 17   |           | .6097     | .6097     |
| 18   |           | .6097     |           |
| 19   |           | .9145     |           |
| 20   |           | .9145     |           |
| 21   |           | .9145     |           |
| 22   |           | .6097     |           |
| 23   |           | .6097     |           |
| 24   | .6047     | .3048     |           |
| Max  | .9145     | .9145     | .9145     |
| Min  | .3048     | .3048     | .3048     |
| Avg  | .6093     | .6503     | .5738     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 206 / 11 kV Industrial  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3048     |           | .3048     |
| 2    | .3048     |           | .3048     |
| 3    | .3048     |           | .3048     |
| 4    | .3048     |           | .3048     |
| 5    | .3048     |           | .3048     |
| 6    | .3048     |           | .3048     |
| 7    | .3048     |           | .3048     |
| 8    | .3048     |           | .3048     |
| 9    | .3048     |           | .3048     |
| 10   | .4572     |           | .3048     |
| 11   | .4572     |           | .3048     |
| 12   | .4572     |           | .3048     |
| 13   | .4572     | .4572     | .3048     |
| 14   |           | .4572     | .3048     |
| 15   |           | .4572     | .3048     |
| 16   |           | .4572     | .3048     |
| 17   |           | .4572     | .3048     |
| 18   |           | .4572     |           |
| 19   |           | .3048     |           |
| 20   |           | .3048     |           |
| 21   |           | .3048     |           |
| 22   |           | .3048     |           |
| 23   |           | .3048     |           |
| 24   | .4294     | .3048     |           |
| Max  | .4572     | .4572     | .3048     |
| Min  | .3048     | .3048     | .3048     |
| Avg  | .3572     | .381      | .3048     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 207 / 11 kV Kedgaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7655     |
| Max  | .7655     |
| Min  | .7655     |
| Avg  | .7655     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 208 / 11 kV VRDE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 10   |           | .3048     |
| 11   | .3048     | .3048     |
| 12   | .3048     | .3048     |
| 13   | .3048     | .3048     |
| 14   | .3048     | .3048     |
| 15   | .3048     | .3048     |
| 16   |           | .3048     |
| 24   | .5041     |           |
| Max  | .5041     | .3048     |
| Min  | .3048     | .3048     |
| Avg  | .3380     | .3048     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 401 / 33 kV Sawedi

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 16.7307   |
| Max  | 16.7307   |
| Min  | 16.7307   |
| Avg  | 16.7307   |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 402 / 33 kV KINETIC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.4979    | 3.4979    | 3.4294    | 3.5322    | 3.9438    | 3.5665    | 3.4979    |
| 2    | 3.4637    | 3.4979    | 3.3951    | 3.4637    | 3.9438    | 3.4979    | 3.4637    |
| 3    | 3.3951    | 3.4294    | 3.3608    | 3.3951    | 3.8752    | 3.4637    | 3.4637    |
| 4    | 3.4637    | 3.3951    | 3.4637    | 3.4294    | 3.8752    | 3.4979    | 3.4294    |
| 5    | 3.4637    | 3.4637    | 3.4294    | 3.5322    | 3.9438    | 3.6008    | 3.4637    |
| 6    | 3.4979    | 3.6694    | 3.5322    | 3.6008    | 3.9781    | 3.7037    | 3.5322    |
| 7    | 3.7037    | 3.8409    | 3.7723    | 3.7037    | 4.0466    | 3.7723    | 3.738     |
| 8    | 3.5322    | 3.9438    | 3.8752    | 3.8752    | 4.0124    | 3.9095    | 3.7723    |
| 9    | 4.1495    | 4.4239    | 4.2181    | 3.738     | 4.1152    | 4.6639    | 4.6296    |
| 10   | 4.6639    | 4.6639    | 4.321     | 3.5322    | 4.2181    | 5.0412    | 4.2867    |
| 11   | 4.4582    | 4.7668    | 4.1495    | 3.5665    | 4.3896    | 4.561     | 4.2867    |
| 12   | 4.3553    | 4.6639    | 4.0124    | 3.7723    | 4.4239    | 4.5268    | 4.3896    |
| 13   | 4.0124    | 4.321     | 4.1495    | 3.7723    | 4.1838    | 4.6296    | 4.0466    |
| 14   | 4.6296    | 4.6296    | 4.7325    | 3.7723    | 4.561     | 5.3155    | 4.8697    |
| 15   | 4.6982    | 4.8354    | 4.7325    | 3.8409    | 4.2867    | 5.2812    | 4.9726    |
| 16   | 4.4239    | 4.0124    | 4.1495    | 4.0124    | 3.9438    | 4.6982    | 4.2867    |
| 17   | 4.0124    | 4.2867    | 4.2181    | 3.9438    | 3.9781    | 4.6639    | 4.7668    |
| 18   | 3.8066    | 4.321     | 3.9438    | 3.9095    | 3.6008    | 4.0466    | 4.6982    |
| 19   | 3.5322    | 3.6008    | 3.6694    | 3.8409    | 3.4979    | 4.1152    | 4.5953    |
| 20   | 3.3265    | 3.3608    | 3.3951    | 3.7723    | 3.3265    | 3.8066    | 4.0809    |
| 21   | 3.1893    | 3.2236    | 3.3265    | 3.738     | 3.1893    | 3.2922    | 3.6351    |
| 22   | 3.4294    | 3.155     | 3.3265    | 3.8066    | 3.3608    | 3.4979    | 4.1152    |
| 23   | 3.4979    | 3.0521    | 3.155     | 3.7723    | 3.6008    | 3.3265    | 3.738     |
| 24   | 4.6879    | 3.4979    | 3.6008    | 3.9095    | 3.6351    | 3.6008    | 4.1495    |
| Max  | 4.6982    | 4.8354    | 4.7325    | 4.0124    | 4.561     | 5.3155    | 4.9726    |
| Min  | 3.1893    | 3.0521    | 3.155     | 3.3951    | 3.1893    | 3.2922    | 3.4294    |
| Avg  | 3.8705    | 3.8980    | 3.8066    | 3.7180    | 3.9138    | 4.0866    | 4.0795    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 403 / 33kv Nalegaon

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 13.3562   |
| Max  | 13.3562   |
| Min  | 13.3562   |
| Avg  | 13.3562   |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 404 / 33 KV MIRI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 6.0728    |
| Max  | 6.0728    |
| Min  | 6.0728    |
| Avg  | 6.0728    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 405 / 33 kV MIRC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.4003    |
| Max  | 1.4003    |
| Min  | 1.4003    |
| Avg  | 1.4003    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 406 / 33 KV KOLGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 5.3772    |
| Max  | 5.3772    |
| Min  | 5.3772    |
| Avg  | 5.3772    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 408 / 33 KV BHALAVANI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 5.8528    |
| Max  | 5.8528    |
| Min  | 5.8528    |
| Avg  | 5.8528    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-I S/DN.[204] BU 4204

Substation No/ Name :- 017001 / 132 kV Kedgaon

Feeder No / Name : 409 / 33 KV Vidyut Bhavan  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 19.8903   | 20.096    |
| 2    |           | 18.1756   | 18.107    |
| 3    |           | 17.284    | 17.4897   |
| 4    |           | 17.284    | 17.0096   |
| 5    |           | 17.6269   | 17.284    |
| 6    |           | 21.262    | 21.4678   |
| 7    |           | ***       | ***       |
| 8    |           | ***       | ***       |
| 9    |           | ***       | ***       |
| 10   |           | ***       | ***       |
| 11   |           | ***       | ***       |
| 12   |           | ***       | ***       |
| 13   |           | ***       | ***       |
| 14   |           | 29.2867   | 29.1496   |
| 15   |           | 27.0919   | 26.5432   |
| 16   |           | 25.7888   |           |
| 17   |           | 26.5432   |           |
| 18   |           | 28.0522   |           |
| 19   |           | ***       |           |
| 20   |           | ***       |           |
| 21   |           | ***       |           |
| 22   |           | ***       |           |
| 23   |           | 28.738    |           |
| 24   | 13.9866   | 24.2113   |           |
| Max  | 13.9866   | 38.9575   | 39.7806   |
| Min  | 13.9866   | 17.284    | 17.0096   |
| Avg  | 13.9866   | 28.3951   | 27.8144   |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014034 / 33 KV SAWEDI

Feeder No / Name : 202 / 11 KV FAKIRWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    | 1.3073    | 1.3394    | 1.2536    | 1.1744    |
| 10   | .9955     | 1.3032    |           | 1.0387    |
| 11   | .9955     | 1.0974    |           |           |
| 12   | .9412     | 1.1888    |           |           |
| 13   | .9511     | 1.1888    |           |           |
| 14   | .8413     | 1.0608    |           |           |
| 15   | .695      | .7499     |           |           |
| 16   |           | .5853     |           |           |
| 22   |           |           |           | .8596     |
| 23   |           |           |           | .7499     |
| Max  | 1.3073    | 1.3394    | 1.2536    | 1.1744    |
| Min  | .695      | .5853     | 1.2536    | .7499     |
| Avg  | .9610     | 1.0642    | 1.2536    | .9557     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014034 / 33 KV SAWEDI

Feeder No / Name : 209 / 11KV MUKUND NAGAR  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    | 1.8625    | 1.8983    | 1.7372    | 1.9281    |
| 10   | 1.3032    | 1.8099    |           | 2.0058    |
| 11   | 1.3032    | 1.5927    |           |           |
| 12   | 1.267     | 1.7375    |           |           |
| 13   | 1.267     | 1.5364    |           |           |
| 14   | 1.0974    | 1.5729    |           |           |
| 15   | .8596     | 1.0059    |           |           |
| 16   |           | .7865     |           |           |
| 22   |           |           |           | 1.2071    |
| 23   |           |           |           | 1.0059    |
| Max  | 1.8625    | 1.8983    | 1.7372    | 2.0058    |
| Min  | .8596     | .7865     | 1.7372    | 1.0059    |
| Avg  | 1.2800    | 1.4925    | 1.7372    | 1.5367    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 201 / 11 kV Maliwada

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8672     | .8573     | .9046     | .8733     | .9046     | .9343     | .8794     |
| 2    | .8223     | .8131     | .8352     | .8208     | .868      | .8688     | .8291     |
| 3    | .8002     | .8086     | .8063     | .833      | .8459     | .8596     | .82       |
| 4    | .8162     | .9374     | .8436     | .98       | .8261     | 1.0075    | .8368     |
| 5    | .9534     | 1.1004    | .9671     | 1.105     | .9282     | 1.1454    | .9625     |
| 6    | 1.3466    | 1.4571    | 1.3847    | 1.3984    | 1.2109    | 1.4022    | 1.2978    |
| 7    | 1.6385    | 1.6514    | 1.7307    | 1.6072    | 1.4152    | 1.5996    | 1.5859    |
| 8    | 1.7871    | 1.7718    | 1.8854    | 1.7711    | 1.717     | 1.7878    | 1.7474    |
| 9    | 1.8557    | 1.9349    | 1.9624    | 1.8793    | 1.8115    | 1.8038    | 1.8816    |
| 10   | 1.8442    | 1.9006    | 1.9143    | 1.89      | 1.813     | 1.8671    | 1.8534    |
| 11   | 1.7932    | 1.6674    | 1.9403    | 1.6583    | 1.7543    | 1.7917    | 1.7787    |
| 12   | 1.7642    | 1.768     | 2.0027    | 1.563     | 1.7421    | 1.8054    | 1.768     |
| 13   | 1.6141    | 1.6956    | 1.9715    | 1.5356    | 1.6636    | 1.7429    | 1.6865    |
| 14   | 1.5775    | 1.5966    | 1.7657    | 1.512     | 1.496     | 1.6034    | .9831     |
| 15   | 1.5638    | 1.6446    | 1.6956    | 1.5966    | 1.4358    | 1.6217    | 1.2635    |
| 16   | 1.5874    | 1.6827    | 1.6827    | 1.608     | 1.3192    | 1.5722    | 1.8115    |
| 17   | 1.5524    | 1.6537    | 1.704     | 1.5874    | 1.3146    | 1.6735    | 1.7878    |
| 18   | 1.8145    | 1.9204    | 1.8785    | 1.8016    | 1.5432    | 1.877     | 1.909     |
| 19   | 2.095     | 2.1666    | 2.1574    | 2.0988    | 1.8191    | 2.1384    | 2.1704    |
| 20   | 1.9913    | 2.0774    | 2.063     | 2.0088    | 1.7795    | 2.0866    | 2.0782    |
| 21   | 1.7787    | 1.7711    | 1.7848    | 1.7505    | 1.6118    | 1.8282    | 1.8153    |
| 22   | 1.4731    | 1.4632    | 1.4914    | 1.4899    | 1.4472    | 1.4853    | 1.528     |
| 23   | 1.2666    | 1.2506    | 1.2437    | 1.2765    | 1.2864    | 1.2574    | 1.2803    |
| 24   | 2.4113    | 1.0562    | .9701     | 1.0227    | 1.0601    | 1.0151    | 1.0265    |
| Max  | 2.4113    | 2.1666    | 2.1574    | 2.0988    | 1.8191    | 2.1384    | 2.1704    |
| Min  | .8002     | .8086     | .8063     | .8208     | .8261     | .8596     | .82       |
| Avg  | 1.5423    | 1.5269    | 1.5661    | 1.4862    | 1.4006    | 1.5323    | 1.4825    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 202 / 11 KV LALTAKI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8145     |
| Max  | .8145     |
| Min  | .8145     |
| Avg  | .8145     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 203 / 11 KV GANESH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4123     | .4207     | .4298     | .4275     | .4283     | .3826     | .4207     |
| 2    | .4039     | .4138     | .4009     | .4054     | .4085     | .3849     | .426      |
| 3    | .394      | .4001     | .3925     | .3856     | .3963     | .3749     | .3986     |
| 4    | .3841     | .439      | .4024     | .4077     | .397      | .4176     | .4191     |
| 5    | .4512     | .5396     | .4595     | .5281     | .4694     | .5136     | .49       |
| 6    | .6653     | .8269     | .6523     | .7842     | .5845     | .7819     | .6501     |
| 7    | .8512     | .9663     | .8985     | .9198     | .7369     | .9145     | .8848     |
| 8    | .9534     | 1.0334    | .9541     | .9686     | .932      | 1.0029    | .9968     |
| 9    | .9747     | 1.0136    | .9777     | .961      | .9488     | .9915     | 1.028     |
| 10   | .8352     | .8581     | .8566     | .7865     | .8733     | .7895     | .8055     |
| 11   | .7545     | .7019     | .6821     | .6432     | .7735     | .6531     | .6767     |
| 12   | .6081     | .6211     | .6097     | .6249     | .6866     | .6158     | .6478     |
| 13   | .5883     | .602      | .6112     | .5929     | .6059     | .6036     | .599      |
| 14   | .5685     | .5723     | .554      | .567      | .5403     | .554      | .5594     |
| 15   | .5396     | .5342     | .5426     | .5411     | .4755     | .5731     | .5502     |
| 16   | .5472     | .5548     | .5411     | .5502     | .458      | .5456     | .5037     |
| 17   | .5693     | .5281     | .5906     | .5769     | .4847     | .5891     | .5761     |
| 18   | .7377     | .6965     | .7164     | .6577     | .6173     | .7125     | .7217     |
| 19   | .8391     | .7926     | .7941     | .791      | .7537     | .8406     | .8665     |
| 20   | .8535     | .7598     | .8291     | .8101     | .759      | .8154     | .8269     |
| 21   | .7903     | .7346     | .7857     | .7529     | .7202     | .8048     | .8078     |
| 22   | .7499     | .6722     | .7064     | .7148     | .6622     | .7377     | .6996     |
| 23   | .6226     | .5708     | .6059     | .5998     | .5586     | .5929     | .5868     |
| 24   | 1.7479    | .4778     | .474      | .4755     | .4489     | .4809     | .474      |
| Max  | 1.7479    | 1.0334    | .9777     | .9686     | .9488     | 1.0029    | 1.028     |
| Min  | .3841     | .4001     | .3925     | .3856     | .3963     | .3749     | .3986     |
| Avg  | .7017     | .6554     | .6445     | .6447     | .6133     | .6530     | .6507     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 204 / 11 KV Delhi gate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5761     | .5464     | .5571     | .5777     | .5578     | .6005     | .5617     |
| 2    | .5411     | .5243     | .5281     | .5472     | .5159     | .5662     | .5373     |
| 3    | .5373     | .5434     | .5251     | .567      | .5106     | .5822     | .5373     |
| 4    | .5784     | .7278     | .5723     | .772      | .5525     | .7926     | .5883     |
| 5    | .6904     | .8101     | .7034     | .849      | .6386     | .8505     | .695      |
| 6    | 1.1058    | 1.1469    | 1.0639    | 1.118     | .8291     | 1.1096    | 1.044     |
| 7    | 1.3977    | 1.374     | 1.3306    | 1.2849    | 1.1454    | 1.3725    | 1.3154    |
| 8    | 1.5203    | 1.5585    | 1.4998    | 1.4068    | 1.406     | 1.5051    | 1.4929    |
| 9    | 1.5013    | 1.5036    | 1.4914    | 1.4746    | 1.4586    | 1.5135    | 1.5112    |
| 10   | 1.3184    | 1.3298    | 1.2986    | 1.2811    | 1.3786    | 1.2955    | 1.2902    |
| 11   | 1.1622    | 1.1111    | 1.1187    | 1.0943    | 1.2315    | 1.1942    | 1.1431    |
| 12   | 1.0425    | 1.0082    | 1.0745    | .1905     | 1.1195    | 1.0631    | 1.0143    |
| 13   | .9793     | .9877     | 1.0189    |           | 1.0768    | .9991     | .9877     |
| 14   | .9358     | .9244     | .9206     | .253      | .9358     | .9526     | .9297     |
| 15   | .8634     | .8589     | .884      | 1.3009    | .8063     | .8954     | .9023     |
| 16   | .8299     | .8756     | .8764     | 1.1027    | .7667     | .8802     | .8848     |
| 17   | .9191     | .9084     | .9534     | 1.0692    | .8116     | .932      | .9381     |
| 18   | 1.1759    | 1.217     | 1.2323    | 1.2757    | 1.0928    | 1.1949    | 1.2155    |
| 19   | 1.3336    | 1.3725    | 1.3565    | 1.39      | 1.2376    | 1.3207    | 1.3984    |
| 20   | 1.2734    | 1.2757    | 1.3253    | 1.3626    | 1.2209    | 1.3024    | 1.3588    |
| 21   | 1.1507    | 1.1782    | 1.1888    | 1.2003    | 1.1317    | 1.2193    | 1.2201    |
| 22   | 1.0661    | 1.0448    | 1.0555    | 1.0448    | 1.0128    | 1.0296    | 1.0669    |
| 23   | .881      | .8672     | .8711     | .852      | .8642     | .8246     | .8718     |
| 24   | .6592     | .6386     | .6752     | .6478     | .6691     | .6295     | .6668     |
| Max  | 1.5203    | 1.5585    | 1.4998    | 1.4746    | 1.4586    | 1.5135    | 1.5112    |
| Min  | .5373     | .5243     | .5251     | .1905     | .5106     | .5662     | .5373     |
| Avg  | 1.0016    | 1.0139    | 1.0051    | .9853     | .9571     | 1.0261    | 1.0072    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 205 / 11 KV CIVIL HOSPITAL  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0518     | .0533     | .0533     | .0533     | .0533     | .0507     | .0511     |
| 2    | .0503     | .0495     | .048      | .0526     | .0518     | .0507     | .0503     |
| 3    | .0492     | .0492     | .0484     | .0503     | .0503     | .0499     | .0503     |
| 4    | .048      | .0499     | .0465     | .0533     | .0495     | .0492     | .0484     |
| 5    | .0511     | .0484     | .0453     | .0488     | .053      | .0499     | .0476     |
| 6    | .0514     | .0492     | .0488     | .0541     | .053      | .0503     | .0518     |
| 7    | .0507     | .0549     | .0518     | .0572     | .0522     | .0507     | .0503     |
| 8    | .0602     | .0591     | .0636     | .0739     | .0594     | .0583     | .0644     |
| 9    | .0888     | .0838     | .0937     | .0861     | .0774     | .0808     | .0941     |
| 10   | .0922     | .0895     | .0907     | .0869     | .0842     | .0892     | .0968     |
| 11   | .0789     | .0888     | .0945     | .0831     | .0716     | .085      | .0838     |
| 12   | .0754     | .0956     | .101      | .0888     | .0549     | .0842     | .0857     |
| 13   | .0815     | .0876     | .0857     | .0854     | .0541     | .0892     | .0861     |
| 14   | .0713     | .0739     | .0747     | .0823     | .0533     | .085      | .077      |
| 15   | .0671     | .0728     | .0648     | .0861     | .0537     | .0808     | .0796     |
| 16   | .0655     | .0865     | .0674     | .0701     | .0556     | .077      | .0648     |
| 17   | .0682     | .0777     | .0732     | .0644     | .0629     | .0812     | .0682     |
| 18   | .0663     | .0834     | .0762     | .0789     | .0553     | .0735     | .0629     |
| 19   | .0777     | .0766     | .0774     | .0834     | .0572     | .0621     | .0652     |
| 20   | .0732     | .0686     | .0682     | .0713     | .0602     | .0625     | .0598     |
| 21   | .0754     | .08       | .0621     | .0655     | .0671     | .0644     | .0579     |
| 22   | .0724     | .0713     | .0655     | .0644     | .0636     | .0648     | .0583     |
| 23   | .0526     | .0564     | .0629     | .0598     | .0629     | .0606     | .0541     |
| 24   | .0541     | .0541     | .0556     | .0545     | .053      | .0545     | .0537     |
| Max  | .0922     | .0956     | .101      | .0888     | .0842     | .0892     | .0968     |
| Min  | .048      | .0484     | .0453     | .0488     | .0495     | .0492     | .0476     |
| Avg  | .0656     | .0692     | .0675     | .0689     | .0587     | .0669     | .0651     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 207 / 11KV Shivaji Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2622     |           | .2774     | .2728     | .2728     | .2812     | .2705     |
| 2    | .2469     | .3246     | .2606     | .2583     | .2591     | .2599     | .2553     |
| 3    | .2423     | .2675     | .2538     | .2583     | .253      | .2561     | .2492     |
| 4    | .2477     | .2614     | .2561     | .2553     | .2553     | .2599     | .2484     |
| 5    | .2774     | .3125     | .3109     | .301      | .2888     | .2942     | .2743     |
| 6    | .4275     | .4572     | .4588     | .4298     | .3589     | .4291     | .4169     |
| 7    | .612      | .6562     | .6219     | .6219     | .4938     | .6203     | .6257     |
| 8    | .7026     | .7392     | .6432     | .6592     | .676      | .7499     | .7285     |
| 9    | .6645     | .6348     | .6059     | .6371     | .6904     | .6569     | .6539     |
| 10   | .5548     | .5205     | .5228     | .5426     | .628      | .5822     | .5533     |
| 11   | .4199     | .4306     | .4961     | .4618     | .5251     | .4481     | .442      |
| 12   | .4054     | .4153     | .4618     | .407      | .4664     | .4252     | .3704     |
| 13   | .3696     | .4115     | .4077     | .394      | .4839     | .4275     | .3894     |
| 14   | .346      | .3856     | .394      | .3719     | .4115     | .3909     | .3658     |
| 15   | .3406     | .3696     | .3849     | .41       | .4085     | .3605     | .349      |
| 16   | .3437     | .3673     | .3589     | .3894     | .3734     | .3254     |           |
| 17   | .3727     | .3894     | .3772     | .3795     | .4039     | .3452     |           |
| 18   | .4191     | .4146     | .4092     | .4412     | .4496     | .333      |           |
| 19   | .5685     | .5296     | .5807     | .5487     | .5662     | .5068     |           |
| 20   | .5708     | .5479     | .5754     | .5738     | .5883     | .5068     |           |
| 21   | .57       | .5197     | .5548     | .5556     | .5769     | .5014     |           |
| 22   | .5243     | .4984     | .5068     | .5075     | .519      | .4847     |           |
| 23   | .4588     | .4344     | .4275     | .423      | .4214     | .4085     |           |
| 24   | 1.4632    | .333      | .3216     | .3269     | .3239     | .3109     |           |
| Max  | 1.4632    | .7392     | .6432     | .6592     | .6904     | .7499     | .7285     |
| Min  | .2423     | .2614     | .2538     | .2553     | .253      | .2561     | .2484     |
| Avg  | .4754     | .4444     | .4362     | .4344     | .4456     | .4235     | .4128     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014035 / 33/11 KV NALEGAON

Feeder No / Name : 208 / 11KV Balikashram

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .932      | .9938     | .9534     | .9031     | .9587     | .9869     | .9648     |
| 2    | .8627     | .9153     | .9031     | .8406     | .9023     | .9343     | .8939     |
| 3    | .8406     | .8703     | .8749     | .82       | .881      | .9168     | .8703     |
| 4    | .836      | .8817     | .8909     | .833      | .8825     | .9206     | .8733     |
| 5    | .9732     | 1.0098    | .9899     | .9549     | .9755     | 1.0075    | .9633     |
| 6    | 1.3946    | 1.3641    | 1.4312    | 1.3443    | 1.3154    | 1.3588    | 1.4487    |
| 7    | 2.0637    | 1.909     | 2.0241    | 1.9204    | 1.6987    | 2.0348    | 1.9768    |
| 8    | 2.2016    | 2.1704    | 2.1056    | 2.095     | 2.1514    | 2.1849    | 2.1628    |
| 9    | 2.1148    | 2.1978    | 2.1666    | 2.0469    | 2.1559    | 2.13      | 2.2062    |
| 10   | 1.9281    | 1.9509    | 1.8397    | 1.864     | 2.0546    | 2.0134    | 2.0066    |
| 11   | 1.7017    | 1.7078    | 1.7162    | 1.8267    |           | 1.7093    | 1.6347    |
| 12   | 1.4914    | 1.5493    | 1.4876    | 1.5943    |           | 1.563     | 1.5508    |
| 13   | 1.3923    | 1.5409    | 1.3672    | 1.4144    |           | 1.4365    |           |
| 14   | 1.3695    | 1.4487    | 1.2879    | 1.4556    |           | 1.3794    |           |
| 15   | 1.3192    | 1.403     | 1.2826    | 1.3725    |           | 1.2826    |           |
| 16   | 1.3474    | 1.3382    | 1.3016    | 1.3481    |           | 1.2803    | 1.3382    |
| 17   | 1.3931    | 1.4205    | 1.3032    | 1.4335    |           | 1.3032    | 1.3603    |
| 18   | 1.5394    | 1.4883    | 1.4472    | 1.451     | 1.4838    | 1.4922    | 1.48      |
| 19   | 1.8511    | 1.8473    | 1.7955    | 1.7429    | 1.7307    | 1.7177    | 1.7894    |
| 20   | 1.858     | 1.8595    | 1.7467    | 1.7368    | 1.7261    | 1.7353    | 1.7749    |
| 21   | 1.7223    | 1.6811    | 1.6491    | 1.6552    | 1.611     | 1.6758    | 1.6629    |
| 22   | 1.5775    | 1.5927    | 1.5295    | 1.5341    | 1.5348    | 1.5424    | 1.5485    |
| 23   | 1.4098    | 1.3481    | 1.3413    | 1.3535    | 1.3603    | 1.3466    | 1.3557    |
| 24   | 1.1363    | 1.105     | 1.0692    | 1.1187    | 1.1195    | 1.1126    | 1.0844    |
| Max  | 2.2016    | 2.1978    | 2.1666    | 2.095     | 2.1559    | 2.1849    | 2.2062    |
| Min  | .836      | .8703     | .8749     | .82       | .881      | .9168     | .8703     |
| Avg  | 1.4690    | 1.4831    | 1.4377    | 1.4441    | 1.4437    | 1.4610    | 1.4736    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 201 / 11 KV L &amp; T

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0059    | 1.0517    |           |           |           | 1.2178    |           |
| 2    | 1.0288    | .9945     |           |           |           | 1.134     |           |
| 3    | .9945     | .9724     |           |           |           | 1.2178    |           |
| 4    | 1.0159    | .9945     |           |           |           | 1.134     |           |
| 5    | 1.0364    | .9175     |           |           |           | 1.1462    |           |
| 6    | 1.0623    | .9069     |           |           |           | 1.2308    |           |
| 7    | 1.0974    | .7255     |           |           |           | 1.1462    |           |
| 8    | 1.2437    |           | .9831     |           |           |           |           |
| 9    | 1.5089    | 1.2178    | 1.2826    |           | 1.1462    |           |           |
| 10   | 1.7353    | 1.5089    | 1.5844    |           | 1.6598    |           |           |
| 11   | 1.7353    | 1.4712    | 1.8484    |           | 1.6598    |           |           |
| 12   | 1.5844    | 1.5089    | 1.6975    |           | 1.6598    |           |           |
| 13   | 1.5844    | 1.3352    | 1.39      |           |           |           |           |
| 14   | 1.5684    | 1.6221    | 1.8107    |           |           |           |           |
| 15   | 1.5089    | 1.6975    |           |           |           |           |           |
| 16   | 1.5844    |           |           |           |           | 1.9805    |           |
| 17   | 1.6975    | 1.8861    | 1.7002    | .3887     | 1.8861    | 1.6975    | 1.8861    |
| 18   | 1.358     | 1.7353    | 1.6598    | .5533     | 1.7353    |           | 1.5844    |
| 19   | 1.3443    | 1.7918    | 1.5844    | .5213     | 1.4335    |           |           |
| 20   | 1.2048    | 1.2696    | 1.39      | .447      | 1.2696    |           |           |
| 21   | 1.1218    | 1.3443    | 1.2696    | .4443     | 1.358     |           |           |
| 22   | 1.2048    | 1.2696    |           |           | 1.2437    |           |           |
| 23   | 1.2048    | 1.3306    |           |           | 1.2437    |           |           |
| 24   | 1.0745    | 1.0517    | 1.1706    |           |           | 1.134     |           |
| Max  | 1.7353    | 1.8861    | 1.8484    | .5533     | 1.8861    | 1.9805    | 1.8861    |
| Min  | .9945     | .7255     | .9831     | .3887     | 1.1462    | 1.134     | 1.5844    |
| Avg  | 1.3127    | 1.3002    | 1.4901    | .4709     | 1.4814    | 1.3039    | 1.7353    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 202 / 11 KV SHAPE WELL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5959     | .6668     |           |           |           | .6493     |           |
| 2    | .5853     | .6767     |           |           |           | .6859     |           |
| 3    | .5258     | .631      |           |           |           | .6493     |           |
| 4    | .5944     | .5601     |           |           |           | .6859     |           |
| 5    | .6737     | .6203     |           |           |           | .6767     |           |
| 6    | .6737     | .6036     |           |           |           | .5697     |           |
| 7    | .5639     | .6455     |           |           |           | .4268     |           |
| 8    | .8048     |           | .7682     |           | .7926     |           |           |
| 9    | 1.1317    | .8962     | 1.2071    |           | .7865     |           |           |
| 10   | 1.358     | 1.643     | 1.1694    |           | 1.0562    |           |           |
| 11   | 1.2826    | 1.1317    | 1.5466    |           | 1.0562    |           |           |
| 12   | 1.4335    | 1.3957    | 1.0185    |           | .8589     |           |           |
| 13   | .8962     | .8413     | .7621     |           |           |           |           |
| 14   | .9431     | .9997     | 1.3203    |           |           |           |           |
| 15   | .9709     | 1.2449    |           |           |           |           |           |
| 16   | 1.358     |           |           |           |           | .9431     |           |
| 17   | 1.2071    | 1.2071    | .9709     |           | 1.1317    | 1.2449    | 1.3443    |
| 18   | 1.0456    | 1.2071    | .8962     | .2683     | 1.1317    |           | 1.2826    |
| 19   | .7461     | .8688     | .7377     | .2683     | .788      |           |           |
| 20   | .9922     | 1.1706    | .5792     | .2683     | .7407     |           |           |
| 21   | .6401     | .8954     | .8669     | .2431     | .6958     |           |           |
| 22   | .7773     | .8871     |           |           | .5944     |           |           |
| 23   | .5335     | .6401     |           |           | .6661     |           |           |
| 24   | .6767     | 1.0402    | .503      |           |           | .6401     |           |
| Max  | 1.4335    | 1.643     | 1.5466    | .2683     | 1.1317    | 1.2449    | 1.3443    |
| Min  | .5258     | .5601     | .503      | .2431     | .5944     | .4268     | 1.2826    |
| Avg  | .8754     | .9306     | .9497     | .262      | .8582     | .7172     | 1.3135    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 203 / 11 KV VAIBHAV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3803     | .3917     | .285      | .2698     | .2591     | .4089     | .2583     |
| 2    | .3673     | .3696     | .2728     | .2583     | .2622     | .4188     | .2553     |
| 3    | .3757     | .368      | .2713     | .2644     | .2637     | .3936     | .2583     |
| 4    | .3882     | .3847     | .2713     | .2652     | .2637     | .3862     | .2637     |
| 5    | .3837     | .3921     | .2766     | .269      | .2721     | .3858     | .2568     |
| 6    | .4085     | .4237     | .2759     | .2789     | .2736     | .3997     | .2599     |
| 7    | .3727     | .4441     | .2888     | .2759     | .2721     | .4759     | .2629     |
| 8    | .5555     | .3224     | .6817     | .2995     | .5807     | .3239     | .2926     |
| 9    | .6493     | .8189     | .8511     | .2904     | .7613     | .3605     | .3384     |
| 10   | .6719     | .8312     | .8344     | .2606     | .7369     | .3955     | .3628     |
| 11   | .6173     | .9237     | .8916     | .2622     | .7457     | .3849     | .3902     |
| 12   | .584      | .6905     | .8467     | .2553     | .7079     | .3513     | .3467     |
| 13   | .5906     | .6775     | .6124     | .2202     | .3818     | .3277     | .2926     |
| 14   | .6256     | .9        | .8505     | .1989     | .4344     | .3688     | .3483     |
| 15   | .6432     | .7836     | .881      | .2522     | .4473     | .381      | .3605     |
| 16   | .7076     | .8593     | .4443     | .2492     | .4146     | .7338     | .3528     |
| 17   | .631      | .6257     | .8242     | .346      | .7625     | .6927     | .6455     |
| 18   | .3208     | .7088     | .6047     | .3483     | .668      | .5593     | .3041     |
| 19   | .4721     | .6124     | .532      | .3415     | .5007     | .2812     | .2797     |
| 20   | .4047     | .5174     | .5129     | .3313     | .463      | .2751     | .2736     |
| 21   | .4333     | .4827     | .4318     | .3157     | .4808     | .2759     | .2667     |
| 22   | .3889     | .4721     | .2683     | .2858     | .4606     | .2751     | .266      |
| 23   | .4588     | .5136     | .2774     | .2652     | .4672     | .2705     | .2759     |
| 24   | .4007     | .4582     | .4789     | .2622     | .2835     | .4328     | .2743     |
| Max  | .7076     | .9237     | .8916     | .3483     | .7625     | .7338     | .6455     |
| Min  | .3208     | .3224     | .2683     | .1989     | .2591     | .2705     | .2553     |
| Avg  | .4930     | .5822     | .5319     | .2778     | .4651     | .3983     | .3119     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 204 / 11 KV BOLHEGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8131     | .8048     |           |           |           | .9511     |
| 2    | .7682     | .8131     |           |           |           | .9145     |
| 3    | .724      | .7468     |           |           |           | .9145     |
| 4    | .8413     | .8131     |           |           |           | .9979     |
| 5    | .961      | 1.0242    |           |           |           | 1.2197    |
| 6    | 1.8671    | 1.8461    |           |           |           | 1.8671    |
| 7    | 2.5652    | 2.4272    |           |           |           | 2.4646    |
| 8    | 2.5393    |           | 2.4646    |           | 2.5019    |           |
| 9    | 2.1622    | 2.1622    | 2.1253    |           | 2.4272    |           |
| 10   | 1.7375    | 1.6651    | 1.7556    |           | 2.0485    |           |
| 11   | 1.5043    | 1.3466    | 1.4548    |           | 1.5203    |           |
| 12   | 1.3112    | 1.2689    | 1.3496    |           | 1.5043    |           |
| 13   | 1.2346    | 1.2346    | .7202     |           |           |           |
| 14   | 1.2269    | 1.1233    | 1.1488    |           |           |           |
| 15   | 1.166     | 1.1831    |           |           |           |           |
| 16   | 1.2269    |           |           |           |           | 1.1393    |
| 17   | 1.387     | 1.3523    | 1.3176    | 1.5604    | 1.3717    | 1.2346    |
| 18   | 1.5074    | 1.4723    | 1.4723    | 1.7528    | 1.5089    |           |
| 19   | 2.0119    | 1.9753    | 1.9387    | 2.0271    | 2.0058    |           |
| 20   | 1.8656    | 1.9204    | 1.7741    | 1.8656    | 1.8461    |           |
| 21   | 1.6827    | 1.6632    | 1.6095    | 1.7558    | 1.6827    |           |
| 22   | 1.4266    | 1.4266    |           |           | 1.4266    |           |
| 23   | 1.086     | 1.0974    |           |           | 1.134     |           |
| 24   | .8779     | .8779     | .9511     |           | 1.0242    | 1.0242    |
| Max  | 2.5652    | 2.4272    | 2.4646    | 2.0271    | 2.5019    | 2.4646    |
| Min  | .724      | .7468     | .7202     | 1.5604    | 1.0242    | .9145     |
| Avg  | 1.4372    | 1.3748    | 1.5448    | 1.7923    | 1.6925    | 1.2728    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 206 / 11 kV PIPELINE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1827    | 1.2696    |           |           |           | 1.307     |           |
| 2    | 1.1088    | 1.1827    |           |           |           | 1.2567    |           |
| 3    | 1.1203    | 1.1088    |           |           |           | 1.2696    |           |
| 4    | 1.2567    | 1.2696    |           |           |           | 1.3443    |           |
| 5    | 1.39      | 1.3169    |           |           |           | 1.5089    |           |
| 6    | 2.2177    | 2.2916    |           |           |           | 2.3152    |           |
| 7    | 3.1367    | 3.0178    |           |           |           | 2.9874    |           |
| 8    | 3.1367    |           | 3.2861    |           | 3.062     |           |           |
| 9    | 2.9127    | 2.9127    | 2.9874    |           | 3.062     |           |           |
| 10   | 2.4394    | 2.2916    | 2.2177    |           | 2.6612    |           |           |
| 11   | 1.9753    | 1.8823    | 1.8823    |           | 2.4394    |           |           |
| 12   | 1.7558    | 1.6651    | 1.7375    |           | 2.0271    |           |           |
| 13   | 1.576     | 1.5043    | 1.576     |           |           |           |           |
| 14   | 1.5203    | 1.4685    | 1.5043    |           |           |           |           |
| 15   | 1.5043    | 1.5043    | 1.5581    |           |           |           |           |
| 16   | 1.5203    |           |           |           |           | 1.4842    |           |
| 17   | 1.6118    | 1.5203    | 1.576     | 1.6301    | 1.5927    | 1.5043    | 1.5927    |
| 18   | 1.97      | 1.7909    | 1.8625    | 1.8625    | 1.9547    |           | 1.9022    |
| 19   | 2.8829    | 2.6337    | 2.7069    | 2.809     | 2.7069    |           |           |
| 20   | 2.7351    | 2.7351    | 2.7633    | 2.809     | 2.5873    |           |           |
| 21   | 2.5873    | 2.5503    | 2.5873    | 2.5873    | 2.5133    |           |           |
| 22   | 2.2177    | 2.2177    | 2.2177    | 2.2916    | 2.0698    |           |           |
| 23   | 1.7002    | 1.7002    |           |           | 1.7924    |           |           |
| 24   | 1.3306    | 1.3306    | 1.3443    |           |           | 1.4563    |           |
| Max  | 3.1367    | 3.0178    | 3.2861    | 2.809     | 3.062     | 2.9874    | 1.9022    |
| Min  | 1.1088    | 1.1088    | 1.3443    | 1.6301    | 1.5927    | 1.2567    | 1.5927    |
| Avg  | 1.9496    | 1.8711    | 2.1205    | 2.3316    | 2.3724    | 1.6434    | 1.7475    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 207 / 11 KV Om Sai

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.4571    | 1.5886    | .9473     | .9793     | .8109     | 1.544     | .9595     |
| 2    | 1.4449    | 1.5881    | .9419     | .9747     | .8512     | 1.502     | .932      |
| 3    | 1.4662    | 1.5341    | .9465     | .98       | .8733     | 1.5131    | .9038     |
| 4    | 1.4647    | 1.5279    | .9381     | .961      | .8695     | 1.4678    | .9107     |
| 5    | 1.4975    | 1.611     | .9709     | .9617     | .8916     | 1.4457    | .9275     |
| 6    | 1.5166    | 1.6324    | .9625     | .9816     | .8962     | 1.4472    | .9564     |
| 7    | 1.534     | 1.5722    | .9694     | .9427     | .8848     | 1.5272    | .929      |
| 8    | 1.7414    | 1.0875    | 1.6735    | .8947     | 1.5394    | .9518     | .9877     |
| 9    | 2.3083    | 2.3678    | 2.1369    | .8307     | 2.0385    | 1.2041    | 1.2285    |
| 10   | 2.3556    | 2.5049    | 2.6916    | .8101     | 2.6764    | 1.3428    | 1.3001    |
| 11   | 2.6616    | 2.6452    | 2.713     | .8238     | 2.7976    | 1.3649    | 1.275     |
| 12   | 2.3761    | 2.5728    | 2.3663    | .7933     | 2.5659    | 1.2879    | 1.2422    |
| 13   | 2.2192    | 2.1399    | 2.05      | .6607     | 1.2734    | 1.1927    | 1.0288    |
| 14   | 2.3708    | 2.6345    | 2.3342    | .7583     | 1.39      | 1.3817    | 1.1888    |
| 15   | 2.4119    | 2.7271    | 2.3823    | .788      | 1.3725    | 1.3329    | 1.2178    |
| 16   | 2.5545    | 1.3016    | 1.3649    | .788      | 1.4944    | 2.7047    | 1.246     |
| 17   | 2.2154    | 2.3936    | 2.3076    | 1.1371    | 2.7344    | 2.6044    | 2.3365    |
| 18   | 2.0287    | 2.0332    | 2.114     | 1.1355    | 2.5926    | 2.4577    | 2.2558    |
| 19   | 1.9342    | 1.9669    | 2.0515    | 1.1515    | 2.2451    | 1.2308    | 1.1561    |
| 20   | 2.0416    | 1.5645    | 1.7566    | 1.1538    | 2.1842    | 1.0951    | 1.0951    |
| 21   | 1.7642    | 1.4632    | 1.5843    | 1.1515    | 1.6621    | .964      | .9221     |
| 22   | 1.7139    | 1.5394    | .9282     | .775      | 1.5752    | .929      | .8604     |
| 23   | 1.8076    | 1.573     | .9846     | .8009     | 1.595     | .9396     | .9206     |
| 24   | 1.6408    | 1.5904    | 1.6179    | .8055     | .9153     | 1.5882    | .9099     |
| Max  | 2.6616    | 2.7271    | 2.713     | 1.1538    | 2.7976    | 2.7047    | 2.3365    |
| Min  | 1.4449    | 1.0875    | .9282     | .6607     | .8109     | .929      | .8604     |
| Avg  | 1.9386    | 1.8817    | 1.6556    | .9183     | 1.6137    | 1.4591    | 1.1538    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014036 / 33 KV L-BLOCK

Feeder No / Name : 208 / 11 kv 'M' Block  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2743     | .2652     |           |           |           | .2498     |           |
| 2    | .2835     | .2629     |           |           |           | .2389     |           |
| 3    | .2848     | .2804     |           |           |           | .2542     |           |
| 4    | .2926     | .2835     |           |           |           | .2431     |           |
| 5    | .2881     | .3096     |           |           |           | .2473     |           |
| 6    | .2972     | .3628     |           |           |           | .3064     |           |
| 7    | .317      | .3361     |           |           |           | .3368     |           |
| 8    | .3963     |           | .3574     |           | .3668     |           |           |
| 9    | .6348     | .6348     | .6154     |           | .5144     |           |           |
| 10   | .6413     | .679      | .724      |           | .5658     |           |           |
| 11   | .679      | .7733     | .7167     |           | .679      |           |           |
| 12   | .7545     | .7621     | .7621     |           | .7167     |           |           |
| 13   | .5975     | .6805     | .5847     |           |           |           |           |
| 14   | .6036     | .811      | .724      |           |           |           |           |
| 15   | .6859     | .8413     | .7621     |           |           |           |           |
| 16   | .7167     |           |           |           |           | .7545     |           |
| 17   | .7167     | .7167     | .679      | .2092     | .6413     | .7167     | .6478     |
| 18   | .6036     | .5658     | .5601     | .2058     | .6413     |           | .5601     |
| 19   | .5373     | .5014     | .5316     | .282      | .4755     |           |           |
| 20   | .4801     | .5201     | .4588     | .2782     | .5175     |           |           |
| 21   | .4161     | .4359     | .3395     | .2743     | .3704     |           |           |
| 22   | .3628     | .3864     |           | .1905     |           |           |           |
| 23   | .3467     | .3269     |           | .141      | .3467     |           |           |
| 24   | .2972     | .2905     | .2905     |           |           | .2389     |           |
| Max  | .7545     | .8413     | .7621     | .282      | .7167     | .7545     | .6478     |
| Min  | .2743     | .2629     | .2905     | .141      | .3467     | .2389     | .5601     |
| Avg  | .4795     | .5012     | .5790     | .2259     | .5305     | .3587     | .6040     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014152 / 33/11 Kv G Block

Feeder No / Name : 201 / Chaitnya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.1294    |           | 1.1561    |           |           | 1.1873    |
| 2    |           | 1.1004    |           | 1.1561    |           |           | 1.1873    |
| 3    |           | 1.1004    |           | 1.1561    |           |           | 1.1873    |
| 4    |           | 1.1004    |           | 1.1523    |           |           | 1.2163    |
| 5    |           | 1.1004    |           | 1.1523    |           |           | 1.278     |
| 6    |           | 1.1888    |           | 1.1203    |           |           | 1.4403    |
| 7    |           | 1.2193    |           | .8535     |           |           | 1.4403    |
| 8    |           | 1.2811    |           | .7773     |           |           | 1.5775    |
| 9    | 1.7918    | 1.9239    | 1.8484    | .8048     | 1.8861    | 2.1691    | 1.9427    |
| 10   | 1.7737    | 2.037     | 2.1691    | .756      | 2.0748    | 2.2822    | 2.1879    |
| 11   | 1.9239    | 2.037     | 1.9616    | .8299     | 2.2634    | 2.1879    | 2.2634    |
| 12   | 1.9805    | 2.0748    | 2.1502    |           | 2.3388    | 2.0182    | 2.1502    |
| 13   | 1.6827    | 1.5775    |           |           | 1.6827    | 1.6289    | 1.6655    |
| 14   | 1.8107    | 1.7375    |           |           | 2.1691    | 2.1691    | 2.2634    |
| 15   | 1.7918    | 2.0748    |           |           | 1.9805    | 1.9427    | 2.1125    |
| 16   | 1.8861    | 2.1691    | 2.0538    |           | 2.037     | 2.0748    | 2.2257    |
| 17   | 1.9239    | 1.9427    | 1.9404    |           | 2.0182    |           |           |
| 18   | 1.7551    | 1.6804    | 1.7375    |           | 1.8484    |           |           |
| 19   | 1.5402    | 1.5384    | 1.6301    |           | 1.5893    | 1.7002    |           |
| 20   | 1.6478    | 1.4746    | 1.4413    |           | 1.4723    |           | 1.5074    |
| 21   | 1.5089    | 1.3592    | 1.4403    |           | 1.406     |           |           |
| 22   | 1.3108    |           | 1.406     |           |           |           | 1.4089    |
| 23   | 1.1584    |           | 1.3413    |           |           | 1.2498    | 1.3599    |
| 24   |           | 1.1294    |           | 1.1431    |           |           | 1.1561    |
| Max  | 1.9805    | 2.1691    | 2.1691    | 1.1561    | 2.3388    | 2.2822    | 2.2634    |
| Min  | 1.1584    | 1.1004    | 1.3413    | .756      | 1.406     | 1.2498    | 1.1561    |
| Avg  | 1.6991    | 1.5444    | 1.76      | 1.0048    | 1.9051    | 1.9423    | 1.6379    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014152 / 33/11 Kv G Block

Feeder No / Name : 202 / Suraj

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .4733     |           | .4557     |           |           | .5121     |
| 2    |           | .4938     |           | .4557     |           |           | .4908     |
| 3    |           | .4938     |           | .4557     |           |           | .3506     |
| 4    |           | .5121     |           | .4382     |           |           | .3506     |
| 5    |           | .567      |           | .4031     |           |           | .3067     |
| 6    |           | .6584     |           | .3353     |           |           | .4954     |
| 7    |           | .6584     |           | .3506     |           |           | .5975     |
| 8    |           | .7514     |           | .2858     |           |           | .6379     |
| 9    | .8029     | .9175     | .8745     | .2477     | .6935     | 1.1694    | .8848     |
| 10   | .985      | 1.0745    | 1.0974    | .2774     | .759      | 1.1043    | .9114     |
| 11   | .9015     | .9602     | .9671     |           | .8987     | .8916     | .929      |
| 12   | .9259     | 1.1706    | 1.0117    |           | .7526     | .8848     | .8817     |
| 13   | .7095     | .6563     |           |           | .9602     | .5152     | .5811     |
| 14   | .7811     | .7133     |           |           | .8402     | .8139     | 1.0029    |
| 15   | .8745     | .8669     |           |           | .9412     | .9134     | .9214     |
| 16   | .8322     | 1.1104    | 1.307     |           | .9922     | .8002     | 1.1946    |
| 17   | .8785     | 1.0974    | 1.3169    |           | .8048     |           |           |
| 18   | .8848     | .9326     | 1.1641    |           | .7748     |           |           |
| 19   | .7034     | .6316     | .9114     |           | .5601     |           |           |
| 20   | .5243     | .482      | .6516     |           | .5114     |           | .6554     |
| 21   | .5365     | .4881     | .4481     |           | .4081     |           |           |
| 22   | .5533     |           | .503      |           |           |           | .5182     |
| 23   | .5533     |           | .5258     |           |           | .695      | .5281     |
| 24   |           | .4191     |           | .4733     |           |           | .4938     |
| Max  | .985      | 1.1706    | 1.3169    | .4733     | .9922     | 1.1694    | 1.1946    |
| Min  | .5243     | .4191     | .4481     | .2477     | .4081     | .5152     | .3067     |
| Avg  | .7631     | .7331     | .8982     | .3799     | .7613     | .8653     | .6622     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014152 / 33/11 Kv G Block

Feeder No / Name : 203 / ITI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .7842     |           | .7522     |           |           | .7316     |
| 2    |           | .7522     |           | .7522     |           |           | .7164     |
| 3    |           | .7164     |           | .7522     |           |           | .6447     |
| 4    |           | .7164     |           | .6805     |           |           | .6447     |
| 5    |           | .7164     |           | .6661     |           |           | .6516     |
| 6    |           | .7442     |           | .6173     |           |           | .6805     |
| 7    |           | .7442     |           | .5658     |           |           | .6805     |
| 8    |           | .7087     |           | .5658     |           |           | 1.0185    |
| 9    | .8299     | .7842     | .9431     | .6348     | 1.1317    | 1.2637    | 1.1694    |
| 10   | .9431     | 1.0185    | 1.4003    | .2515     | .9242     | 1.226     | 1.5089    |
| 11   | 1.0374    | 1.094     | 1.531     |           | 1.4937    | 1.0374    | 1.419     |
| 12   | 1.1128    | 1.094     | 1.3817    |           | 1.419     | 1.2071    | 1.3957    |
| 13   | .9054     | .8676     |           |           | 1.1883    | 1.1317    | 1.1506    |
| 14   | .9431     | .9431     |           |           | 1.3203    | 1.3769    | 1.3014    |
| 15   | 1.0185    | 1.1506    |           |           | 1.4937    | 1.4523    | 1.3392    |
| 16   | 1.1317    | 1.1128    | 1.4712    |           | 1.5089    | 1.5497    | 1.2826    |
| 17   | 1.1128    | 1.094     | 1.3203    |           | 1.3203    |           |           |
| 18   | .9054     | .9242     | .9619     |           | .9054     |           |           |
| 19   | .9997     | .8676     | .8676     |           | 1.3203    |           |           |
| 20   | .7468     | .7059     | .7282     |           | .7095     |           | .7842     |
| 21   | .7842     | .7842     | .7842     |           | .7922     |           |           |
| 22   | .8215     |           | .7842     |           |           |           | .7842     |
| 23   | .8215     |           | .8299     |           |           | .7682     | .724      |
| 24   |           | .8029     |           | .7682     |           |           | 1.3014    |
| Max  | 1.1317    | 1.1506    | 1.531     | .7682     | 1.5089    | 1.5497    | 1.5089    |
| Min  | .7468     | .7059     | .7282     | .2515     | .7095     | .7682     | .6447     |
| Avg  | .9409     | .8694     | 1.0836    | .6370     | 1.1944    | 1.2237    | .9965     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014152 / 33/11 Kv G Block

Feeder No / Name : 204 / Akash

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .2012     |           | .1463     |           |           |
| 2    |           | .1829     |           | .1463     |           |           |
| 3    |           | .1829     |           | .1372     |           |           |
| 4    |           | .1677     |           | .1372     |           |           |
| 5    |           | .1928     |           | .1257     |           |           |
| 6    |           | .2103     |           | .0838     |           |           |
| 7    |           | .2378     |           | .0838     |           |           |
| 8    |           | .3269     |           | .0657     |           |           |
| 9    | .4287     | .6447     | .3361     | .0762     | .4049     | .6535     |
| 10   | .4409     | .6348     | .463      | .0914     | .443      | .6036     |
| 11   | .5373     | .6878     | .4049     | .096      | .4557     | .3814     |
| 12   | .427      | .5201     | .6154     |           | .4527     | .7282     |
| 13   | .591      | .3572     |           |           | .3715     | .4012     |
| 14   | .5544     | .4428     |           |           | .4207     | .6161     |
| 15   | .4578     | .4578     |           |           | .5544     |           |
| 16   | .5316     | .5853     | .6024     |           | .6036     |           |
| 17   | .5121     | .5121     | .5658     |           | .6468     |           |
| 18   | .3374     | .591      | .5079     |           | .3353     |           |
| 19   | .2515     | .5935     | .4062     |           | .3506     |           |
| 20   | .2641     | .1981     | .3269     |           | .2641     |           |
| 21   | .2515     | .3067     | .2347     |           | .2629     |           |
| 22   | .2263     |           | .218      |           |           |           |
| 23   | .2286     |           | .2096     |           |           |           |
| 24   |           | .1829     |           | .16       |           |           |
| Max  | .591      | .6878     | .6154     | .16       | .6468     | .7282     |
| Min  | .2263     | .1677     | .2096     | .0657     | .2629     | .3814     |
| Avg  | .4027     | .3826     | .4076     | .1125     | .4282     | .564      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 014152 / 33/11 Kv G Block

Feeder No / Name : 205 / Link Road

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .2561     |           | .1638     |           |           | .2561     |
| 2    |           | .2561     |           | .1638     |           |           | .2614     |
| 3    |           | .2561     |           | .16       |           |           | .2614     |
| 4    |           | .2949     |           | .16       |           |           | .2641     |
| 5    |           | .2949     |           | .16       |           |           | .2829     |
| 6    |           | .4915     |           | .2058     |           |           |           |
| 7    |           | .6226     |           | .2715     |           |           |           |
| 8    |           | .6706     |           | .2686     |           |           |           |
| 9    | .6299     | .5441     | .5468     | .2149     | .2614     |           |           |
| 12   |           |           |           |           |           | .5407     | .6958     |
| 13   |           |           |           |           |           | .5376     | .6249     |
| 14   |           |           |           |           |           | .5851     | .6642     |
| 15   |           |           |           |           |           | .4218     | .6325     |
| 16   | .2241     | .2772     | .2829     |           | .2263     | .4321     | .6401     |
| 17   | .2452     | .2987     | .5658     |           | .2263     |           |           |
| 18   | .3772     | .2987     | .6036     |           | .3361     |           |           |
| 19   | .4338     | .3734     | .7544     |           | .3772     |           |           |
| 20   | .3584     | .3772     | .9054     |           | .3772     |           | .415      |
| 21   | .3395     | .3395     | .679      |           | .3395     |           |           |
| 22   | .3395     |           | .3395     |           |           |           | .3395     |
| 23   | .2641     |           | .3395     |           |           | .2801     | .3018     |
| 24   |           | .2591     |           | .2949     |           |           | .2507     |
| Max  | .6299     | .6706     | .9054     | .2949     | .3772     | .5851     | .6958     |
| Min  | .2241     | .2561     | .2829     | .16       | .2263     | .2801     | .2507     |
| Avg  | .3569     | .3694     | .5574     | .2063     | .3063     | .4662     | .4207     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 201 / 11 KV CHAKAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.829     |
| Max  | 1.829     |
| Min  | 1.829     |
| Avg  | 1.829     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 202 / 11 KV MAHINDRA  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.9909    |
| Max  | 1.9909    |
| Min  | 1.9909    |
| Avg  | 1.9909    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 203 / 11 KV BANBRO

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.4632    |
| Max  | 1.4632    |
| Min  | 1.4632    |
| Avg  | 1.4632    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 204 / 11 KV BALAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.0119    |
| Max  | 2.0119    |
| Min  | 2.0119    |
| Avg  | 2.0119    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 205 / 11 KV CROMPTON  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.0119    |
| Max  | 2.0119    |
| Min  | 2.0119    |
| Avg  | 2.0119    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 206 / 11 KV GARWARE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1719    |
| Max  | 2.1719    |
| Min  | 2.1719    |
| Avg  | 2.1719    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 207 / 11 KV WATER SUPPLY  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .602      | .5525     |
| 2    |           | .5373     | .5487     |
| 3    |           | .5487     | .5258     |
| 4    |           | .5487     | .5487     |
| 5    |           | .5563     | .5944     |
| 6    |           | .5792     | .6135     |
| 7    |           | .6059     | .644      |
| 8    |           | .7392     | .743      |
| 9    |           | .7468     | .8002     |
| 10   |           | .7659     | .8269     |
| 11   |           | .8535     | .8612     |
| 12   |           | .8192     | .8612     |
| 13   |           | .8269     | .602      |
| 14   |           | .8002     | .7735     |
| 15   |           | .7888     | .7621     |
| 16   |           | .823      | .6897     |
| 17   |           | .7506     | .6821     |
| 18   |           | .6859     | .6744     |
| 19   |           | .6325     | .6059     |
| 20   |           | .6897     | .6059     |
| 21   |           | .6211     | .583      |
| 22   |           | .6059     | .6059     |
| 23   |           | .6783     | .6592     |
| 24   | 1.4632    | .6478     | .6821     |
| Max  | 1.4632    | .8535     | .8612     |
| Min  | 1.4632    | .5373     | .5258     |
| Avg  | 1.4632    | .6856     | .6686     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 208 / 11 kv Nav Nagapur

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.1812    | 1.166     |
| 2    |           | 1.1279    | 1.1126    |
| 3    |           | 1.0898    | 1.0822    |
| 4    |           | 1.105     | 1.0974    |
| 5    |           | 1.1736    | 1.1965    |
| 6    |           | 1.4861    | 1.5089    |
| 7    |           | 2.0576    | 2.2405    |
| 8    |           | 2.6139    | 2.6825    |
| 9    |           | 2.713     | 2.713     |
| 10   |           | 2.5835    | 2.5072    |
| 11   |           | 2.4539    | 2.2939    |
| 12   |           | 1.9433    | 2.0424    |
| 13   |           | 1.9052    | 1.8976    |
| 14   |           | 1.8442    | 1.7756    |
| 15   |           | 1.6766    | 1.7223    |
| 16   |           | 1.6766    |           |
| 17   |           | 1.7833    |           |
| 18   |           | 1.9052    |           |
| 19   |           | 1.8366    |           |
| 20   |           | 2.111     |           |
| 21   |           | 2.0576    |           |
| 22   |           | 1.8519    |           |
| 23   |           | 1.5927    |           |
| 24   | 2.1948    | 1.3565    |           |
| Max  | 2.1948    | 2.713     | 2.713     |
| Min  | 2.1948    | 1.0898    | 1.0822    |
| Avg  | 2.1948    | 1.7969    | 1.8026    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 210 / 11 KV CIVIL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.448     |
| Max  | 1.448     |
| Min  | 1.448     |
| Avg  | 1.448     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 211 / 11 KV GULMOHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.547     | 1.5546    | 1.5775    |
| 2    |           | 1.3413    | 1.3489    | 1.3489    |
| 3    |           | 1.2651    | 1.2574    | 1.2651    |
| 4    |           | 1.2346    | 1.2269    | 1.2422    |
| 5    |           | 1.2346    | 1.2269    | 1.2193    |
| 6    |           | 1.4251    | 1.4251    | 1.4251    |
| 7    |           | 1.9052    | 2.0652    | 1.9966    |
| 8    |           | 2.1262    | 2.4158    | 2.4539    |
| 9    |           | 2.5149    | 2.5301    | 2.5453    |
| 10   |           | 2.5911    | 2.4844    | 2.6368    |
| 11   |           | 2.4691    | 2.3929    | 2.5453    |
| 12   |           | 2.3167    | 2.271     | 2.2939    |
| 13   |           | 2.1643    | 2.111     | 2.1338    |
| 14   |           | 2.0271    | 2.0119    |           |
| 15   |           | 1.7604    | 1.8747    |           |
| 16   |           | 1.7375    | 1.9204    |           |
| 17   |           | 1.7375    | 1.9433    |           |
| 18   |           | 1.8442    | 1.9814    |           |
| 19   |           | 2.0576    | 2.3091    |           |
| 20   |           | 2.6444    | 2.8426    |           |
| 21   |           | 2.6597    | 2.8045    |           |
| 22   |           | 2.5606    | 2.6063    |           |
| 23   |           | 2.3167    | 2.3396    |           |
| 24   | 1.9909    | 1.989     | 1.9738    |           |
| Max  | 1.9909    | 2.6597    | 2.8426    | 2.6368    |
| Min  | 1.9909    | 1.2346    | 1.2269    | 1.2193    |
| Avg  | 1.9909    | 1.9779    | 2.0382    | 1.8987    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 401 / 33kv Sunpharma

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 5.9728    |
| Max  | 5.9728    |
| Min  | 5.9728    |
| Avg  | 5.9728    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 403 / 33 KV Vambori

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 7.2017    |
| Max  | 7.2017    |
| Min  | 7.2017    |
| Avg  | 7.2017    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 404 / 33 KV HOGANAS

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 6.0357    |
| Max  | 6.0357    |
| Min  | 6.0357    |
| Avg  | 6.0357    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 405 / 33 KV AMBIKA

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | 25.583    | 26.4747   | 24.6914   |
| 2    | 25.1715   | 26.2689   | 25.8574   |
| 3    | 25.8574   | 25.4459   | 25.3087   |
| 4    | 24.2799   | 26.1317   | 26.4747   |
| 5    | 25.6516   | 24.8286   | 24.76     |
| 6    | 24.9657   | 26.4061   | 26.4747   |
| 7    |           | 26.5432   | 26.4747   |
| 8    |           | 26.749    | 27.2291   |
| 9    |           | 26.4061   | 26.4747   |
| 10   |           | 26.4747   | 25.1029   |
| 11   |           | 26.5432   | 24.9657   |
| 12   |           | 25.5144   | 26.0631   |
| 13   |           | 25.1715   | 25.8574   |
| 14   |           | 25.4459   |           |
| 15   |           | 25.3087   |           |
| 16   |           | 26.5432   |           |
| 17   |           | 25.8574   |           |
| 18   |           | 26.2003   |           |
| 19   |           | 25.6516   |           |
| 20   |           | 25.1029   |           |
| 21   |           | 24.2799   |           |
| 22   |           | 25.2401   |           |
| 23   |           | 23.7998   |           |
| 24   | 6.5158    | 24.9657   |           |
| Max  | 25.8574   | 26.749    | 27.2291   |
| Min  | 6.5158    | 23.7998   | 24.6914   |
| Avg  | 22.5750   | 25.7231   | 25.8257   |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 406 / 33 kv RAMDAS

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3315     |           | .4115     | .3429     | .3887     | .3887     | .3658     |
| 2    | .3201     |           | .4001     | .3086     | .3887     | .4001     | .3429     |
| 3    | .3315     |           | .4115     | .3772     | .3658     | .3658     | .3544     |
| 4    | .3201     |           | .3887     | .3315     | .3772     | .4344     | .3315     |
| 5    | .3201     | .4115     | .3658     | .3315     | .3772     | .423      | .3201     |
| 6    | .3086     | .423      | .4001     | .3429     | .3658     | .3887     | .3315     |
| 7    | .3201     | .3887     | .3544     | .3201     | .3772     | .3887     | .3772     |
| 8    | .3086     | .3315     | .3201     | .3429     | .3658     | .3429     | .3201     |
| 9    | .3086     | .3429     | .3315     | .4001     | .3086     | .3544     |           |
| 10   | .3086     | .3201     | .3315     | 1.2003    | .3201     | .3315     |           |
| 11   | .3086     | .3201     | .3544     | 3.3951    | .3315     | .3429     |           |
| 12   | .3429     | .3429     | .3658     | 3.4179    | .3429     | .3429     |           |
| 13   | .3544     | .3544     | .3544     | 3.5437    | .3315     | .3658     |           |
| 14   | .3544     | .3544     | .3315     | 3.4979    | .3429     | .3772     |           |
| 15   | .3544     | .3544     | .3429     | 3.5208    | .3429     | .3658     |           |
| 16   | .3429     | .3544     | .3429     | 3.1779    | .3429     | .3315     | .3544     |
| 17   | .3658     | .3429     | .3544     | 3.4751    | .3315     | .3201     | .3429     |
| 18   | .3658     | .3772     | .3429     | 3.5094    | .3315     | .3315     | .3315     |
| 19   | .3887     | .3658     | .3544     | .3772     | .3429     | .3086     | .3429     |
| 20   | .3887     | .3887     | .3544     | .4001     | .3772     | .3315     | .3429     |
| 21   | .4572     | .3544     | .3887     | .3887     | .3887     | .3315     | .3201     |
| 22   | .4344     | .3544     | .3772     | .4001     | .3887     | .3315     | .3544     |
| 23   | .4115     | .3658     | .3544     | .3887     | .3658     | .3201     | .3658     |
| 24   | 4.9383    | .423      | .3544     | .3772     | .3658     | .3544     | .4115     |
| Max  | 4.9383    | .423      | .4115     | 3.5437    | .3887     | .4344     | .4115     |
| Min  | .3086     | .3201     | .3201     | .3086     | .3086     | .3086     | .3201     |
| Avg  | .5411     | .3635     | .3620     | 1.4237    | .3567     | .3572     | .3476     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 407 / 33 kV L &amp; T

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 2.9835    | 3.8409    |
| 2    |           | 2.9835    | 3.7894    |
| 3    |           | 2.9664    | 3.6694    |
| 4    |           | 2.9664    | 3.6008    |
| 5    |           | 2.9664    | 3.5665    |
| 6    |           | 2.9664    | 3.6351    |
| 7    |           | 3.035     | 3.8066    |
| 8    |           | 3.7894    | 4.1324    |
| 9    |           | 4.4239    | 4.8011    |
| 10   |           | 4.8697    | 5.1612    |
| 11   |           | 5.0926    | 5.6242    |
| 12   |           | 5.2641    | 5.5041    |
| 13   |           | 5.2469    | 5.2984    |
| 14   |           | 5.024     | 5.2298    |
| 15   |           | 5.7099    | 5.727     |
| 16   |           | 5.6584    |           |
| 17   |           | 6.0357    |           |
| 18   |           | 5.8985    |           |
| 19   |           | 5.1097    |           |
| 20   |           | 5.024     |           |
| 21   |           | 4.8183    |           |
| 22   |           | 4.5268    |           |
| 23   |           | 4.4753    |           |
| 24   | 6.0357    | 4.3896    |           |
| Max  | 6.0357    | 6.0357    | 5.727     |
| Min  | 6.0357    | 2.9664    | 3.5665    |
| Avg  | 6.0357    | 4.4260    | 4.4925    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 409 / 33 KV Exide

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 4.8868    |
| Max  | 4.8868    |
| Min  | 4.8868    |
| Avg  | 4.8868    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 410 / 33 KV G Block

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 3.5883    |           | 3.2648    |           |           | 3.0464    |
| 2    |           | 3.5048    |           | 3.1093    |           |           | 2.9995    |
| 3    |           | 3.4568    |           | 3.1093    |           |           | 2.8807    |
| 4    |           | 3.4568    |           | 3.0178    |           |           | 2.8807    |
| 5    |           | 3.5391    |           | 3.0178    |           |           | 2.7195    |
| 6    |           | 3.9323    |           | 2.8978    |           |           | 2.8978    |
| 7    |           | 4.1289    |           | 2.8721    |           |           | 2.8235    |
| 8    |           | 4.4239    |           | 3.0636    |           |           | 3.6523    |
| 9    | 4.8731    | 5.3755    | 5.036     | 2.7492    | 4.9851    | 5.5453    | 4.357     |
| 10   | 4.425     | 5.0926    | 5.4887    | ***       | 4.6399    | 5.5453    | 4.9228    |
| 11   | 4.6965    | 5.1492    | 5.2058    | 2.3011    | 5.5453    | 4.8097    | 4.9228    |
| 12   | 4.8097    | 5.2058    | 5.5453    |           | 5.4887    | 5.8282    | 5.6019    |
| 13   | 4.3244    | 3.7792    |           |           | 4.5668    | 4.9411    | 4.8171    |
| 14   | 4.4702    | 4.1152    |           |           | 4.8663    | 5.9414    | 5.6584    |
| 15   | 4.5268    | 4.9228    |           |           | 5.3189    | 5.036     | 5.4321    |
| 16   | 5.036     | 5.5453    | 6.0545    |           | 5.715     | 5.2624    | 5.715     |
| 17   | 5.036     | 5.2058    | 5.8282    |           | 5.3755    |           |           |
| 18   | 4.6091    | 4.6639    | 5.1492    |           | ***       |           |           |
| 19   | 4.4593    | 4.561     | 4.7531    |           | 4.8663    |           |           |
| 20   | 3.9609    | 3.5528    | 4.2798    |           | 3.8489    |           | 3.7466    |
| 21   | 3.9095    | 3.6374    | 3.8066    |           | 3.5883    |           |           |
| 22   | 3.7723    |           | 3.8066    |           |           |           | 3.3951    |
| 23   | 3.4979    |           | 3.8066    |           |           | 3.2442    | 3.2922    |
| 24   | 6.0357    | 3.2922    |           | 3.4568    |           |           | 3.1687    |
| Max  | 6.0357    | 5.5453    | 6.0545    | 297.2112  | 47.2749   | 5.9414    | 5.715     |
| Min  | 3.4979    | 3.2922    | 3.8066    | 2.3011    | 3.5883    | 3.2442    | 2.7195    |
| Avg  | 4.5277    | 4.2786    | 4.8967    | 27.5059   | 8.1600    | 5.1282    | 3.9465    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 411 / 33 KV L Block

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 6.0357    |
| Max  | 6.0357    |
| Min  | 6.0357    |
| Avg  | 6.0357    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

AHMEDNAGAR U-IIS/DN.[200] BU 4200

Substation No/ Name :- 017009 / 132 MIDC

Feeder No / Name : 703 / 132KV ISMT

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 21.9479   |
| Max  | 21.9479   |
| Min  | 21.9479   |
| Avg  | 21.9479   |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014045 / 33/11 KV PARNER

Feeder No / Name : 201 / Punewadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4252     | .4062     | .3879     | .3993     | .3795     | 1.6789    | 2.4097    |
| 2    | .4222     | .4207     | .3925     | .4108     | .3803     | 1.6796    | 2.3762    |
| 3    | .4321     | .4306     | .4092     | .4359     | .4016     | 1.6987    | 2.3632    |
| 4    | .4656     | .4572     | .4397     | .4694     | .4473     | 1.8115    | 2.4341    |
| 5    | .5601     | .5937     | .5319     | .5822     | .5304     | 2.0591    | 2.6612    |
| 6    | .6325     | .692      | .6981     | .8253     | .7095     | 2.3327    | 3.0765    |
| 7    |           | .3818     | .5624     | .8871     | .4397     | 3.1459    | 3.5307    |
| 8    |           |           |           |           |           | 3.6671    | 3.9095    |
| 9    | .5685     | .4748     | .6325     |           | .5799     | 3.5208    | 3.5551    |
| 10   | 2.8982    | 2.8753    | 2.7625    |           | 2.0881    |           |           |
| 11   | 2.9896    | 2.7519    | 2.4082    |           | 2.6985    |           |           |
| 12   | 2.8487    | 1.9052    | 2.4089    |           | 2.838     |           |           |
| 13   | 2.7084    | 2.1232    | 2.2344    |           | 2.7077    |           |           |
| 14   | 2.5751    | 2.1613    | 2.175     | .2256     | 2.6017    |           |           |
| 15   | 2.6193    | 2.2893    | 1.6126    | 2.0454    | 3.2739    |           |           |
| 16   | 2.7305    | 2.3967    | 2.1666    | 2.226     | 3.488     |           |           |
| 17   | 2.7031    | 2.3167    | 2.2542    | 2.1818    | 3.581     |           |           |
| 18   | 2.5156    | 2.1529    | 1.8549    | 2.1491    | 3.3676    | .1684     | .1257     |
| 19   | 2.2237    | 2.0927    | 2.0096    | 2.1582    | 3.2343    | .6325     | .5723     |
| 20   | .7834     | 1.3314    | .6577     | .7499     | .6943     | .7179     | .6417     |
| 21   | .7346     | .6744     | .66       | .7026     | .6813     | .6752     | .6219     |
| 22   | .6356     | .618      | .5761     | .5921     | .631      | .6264     | .5685     |
| 23   | .5274     | .5731     | .5266     | .5403     | .5609     | .8246     | .9701     |
| 24   | 2.8292    | .4169     | .3948     | .3894     | 1.5684    | 2.505     | 2.3792    |
| Max  | 2.9896    | 2.8753    | 2.7625    | 2.226     | 3.581     | 3.6671    | 3.9095    |
| Min  | .4222     | .3818     | .3879     | .2256     | .3795     | .1684     | .1257     |
| Avg  | 1.6286    | 1.3277    | 1.2503    | .9984     | 1.6471    | 1.7340    | 2.0122    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014045 / 33/11 KV PARNER

Feeder No / Name : 202 / Diksal AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014045 / 33/11 KV PARNER

Feeder No / Name : 203 / PARNER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8573     |
| Max  | .8573     |
| Min  | .8573     |
| Avg  | .8573     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014045 / 33/11 KV PARNER

Feeder No / Name : 204 / Wadner AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0983     | .0907     |           | .109      | .0998     | .1036     | .1044     |
| 2    | .0998     | .0899     |           | .1151     | .1052     | .1166     | .1067     |
| 3    | .1135     | .1044     |           | .1212     | .1128     | .1235     | .1105     |
| 4    | .1395     | .1433     |           | .1463     | .1341     | .1486     | .1471     |
| 5    | .1745     | .1707     |           | .1738     | .1768     | .205      | .1867     |
| 6    | .2385     | .189      |           | .2423     | .25       | .2408     | .218      |
| 7    | .2614     |           |           | .1303     | .2515     |           |           |
| 9    |           |           |           |           |           | .8055     | .9198     |
| 10   |           |           |           |           |           | 1.2041    | 1.39      |
| 11   |           |           |           |           |           | 1.2993    | 1.3344    |
| 12   |           |           |           |           |           | 1.3954    | 1.3489    |
| 13   |           |           |           |           |           | 1.3672    | 1.3679    |
| 14   |           |           |           |           |           | 1.307     | 1.3016    |
| 15   | .0503     | .0556     |           | .1341     | .535      | 1.2917    | 1.1827    |
| 16   | 1.4937    | 1.342     | 1.339     | 1.4952    | 1.5638    | 1.2376    | 1.3192    |
| 17   | 1.6781    | 1.3496    | 1.5036    | 1.7276    | 1.624     | 1.0578    | 1.3397    |
| 18   | 1.5097    | 1.1149    | 1.419     | 1.6629    | 1.5066    | .093      | .1196     |
| 19   | .4367     | .9968     | 1.3725    | 1.5463    | 1.4609    | .176      | .1966     |
| 20   | .8078     | .9023     | .9328     | 1.0227    | 1.2711    | .1585     | .1928     |
| 21   | .8368     | .8886     | .8672     | 1.0982    | 1.2551    | .1517     | .157      |
| 22   | .8391     | .1379     | .8794     | 1.0913    | 1.1347    | .1318     | .1463     |
| 23   | .7918     |           | .5159     | .964      | .5716     | .1189     | .1235     |
| 24   | 2.8681    |           | .1174     | .0975     | .5121     | .1044     | .1151     |
| Max  | 2.8681    | 1.3496    | 1.5036    | 1.7276    | 1.624     | 1.3954    | 1.39      |
| Min  | .0503     | .0556     | .1174     | .0975     | .0998     | .093      | .1044     |
| Avg  | .7316     | .5411     | .9941     | .6987     | .7391     | .5835     | .6104     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014045 / 33/11 KV PARNER

Feeder No / Name : 205 / Panoli AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3009    | 1.2178    | 1.1972    | 1.2993    | 1.2475    | .2683     | .2644     |
| 2    | 1.3108    | 1.2414    | 1.1698    | 1.2894    | 1.262     | .2858     | .2789     |
| 3    | 1.3199    | 1.3679    | 1.3039    | 1.387     | 1.2384    | .3277     | .2972     |
| 4    | 1.4319    | 1.4716    | 1.4601    | 1.5455    | 1.3786    | .3909     | .3856     |
| 5    | 1.6278    | 1.7772    | 1.7749    | 1.8793    | 1.5158    | .5197     | .5403     |
| 6    | 2.0241    | 2.1681    | 2.0119    | 2.1956    | 1.9685    | .4405     | .5129     |
| 7    | 2.3746    | 2.681     | 2.684     | 2.6116    | 2.3922    |           |           |
| 8    | 2.2276    | 2.0599    | 2.505     | 1.97      | 1.6423    |           |           |
| 9    |           |           |           |           |           | 1.9959    | 1.9121    |
| 10   |           |           |           |           |           | 1.9997    | 2.0995    |
| 11   |           |           |           |           |           | 2.0134    | 1.9578    |
| 12   |           |           |           |           |           | 1.5325    | 2.0226    |
| 13   |           |           |           |           |           | 1.9342    | 1.579     |
| 14   |           |           |           |           |           | 1.9448    | 1.8168    |
| 15   |           |           |           |           |           | 1.8656    | 1.8267    |
| 16   |           |           |           |           |           | 1.3405    | 1.9692    |
| 17   |           |           |           |           |           | 1.3085    | 1.5745    |
| 18   | .3772     | .3041     | .0541     | .2187     | .3513     | .2782     | .2462     |
| 19   | .5571     | .5007     | .5335     | .4771     | .5136     | .5007     | .4839     |
| 20   | .5655     | .503      | .5373     | .5418     | .5258     | .4961     | .4801     |
| 21   | .4763     | .41       | .4512     | .4077     | .4397     | .4321     | .4496     |
| 22   | .365      | .4031     | .3719     | .3635     | .4031     | .4054     | .3788     |
| 23   | 1.0494    | .9107     | 1.1431    | .9229     | .3323     | .3307     | .2904     |
| 24   | 3.6309    | 1.1751    | 1.2727    | 1.2879    | .2637     | .2644     | .25       |
| Max  | 3.6309    | 2.681     | 2.684     | 2.6116    | 2.3922    | 2.0134    | 2.0995    |
| Min  | .365      | .3041     | .0541     | .2187     | .2637     | .2644     | .2462     |
| Avg  | 1.3759    | 1.2128    | 1.2314    | 1.2265    | 1.0317    | .9489     | .9826     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014045 / 33/11 KV PARNER

Feeder No / Name : 206 / PUNEWADI + PANOLI GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5144     |
| Max  | .5144     |
| Min  | .5144     |
| Avg  | .5144     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014045 / 33/11 KV PARNER

Feeder No / Name : 207 / Diskal gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5144     |
| Max  | .5144     |
| Min  | .5144     |
| Avg  | .5144     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014046 / 33/11 KV WADZIRE

Feeder No / Name : 201 / Kalas AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014046 / 33/11 KV WADZIRE

Feeder No / Name : 202 / Karkhana Exp

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .905      |
| Max  | .905      |
| Min  | .905      |
| Avg  | .905      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014046 / 33/11 KV WADZIRE

Feeder No / Name : 203 / Sangvisurya AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.4291    |
| Max  | 2.4291    |
| Min  | 2.4291    |
| Avg  | 2.4291    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014046 / 33/11 KV WADZIRE

Feeder No / Name : 204 / 11 KV WADZIRE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2672    |
| Max  | 2.2672    |
| Min  | 2.2672    |
| Avg  | 2.2672    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014046 / 33/11 KV WADZIRE

Feeder No / Name : 205 / Wadzire GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6859     |
| Max  | .6859     |
| Min  | .6859     |
| Avg  | .6859     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014046 / 33/11 KV WADZIRE

Feeder No / Name : 206 / Kalas GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8573     |
| Max  | .8573     |
| Min  | .8573     |
| Avg  | .8573     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014046 / 33/11 KV WADZIRE

Feeder No / Name : 207 / Sangvisurya GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6859     |
| Max  | .6859     |
| Min  | .6859     |
| Avg  | .6859     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014046 / 33/11 KV WADZIRE

Feeder No / Name : 208 / Darodi AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 201 / 11 KV NIGHOJ Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1309    | 1.1126    | 1.3603    | 1.2338    | 1.7002    | .1882     | .1768     |
| 2    | 1.1416    | 1.0661    | 1.3702    | 1.2048    | 1.7299    | .1928     | .1859     |
| 3    | 1.105     | 1.0661    | 1.2894    | 1.1896    | 1.7193    | .1981     | .2012     |
| 4    | 1.169     | 1.15      | 1.3085    | 1.2361    | 1.6941    | .2035     | .2157     |
| 5    | 1.3763    | 1.3725    | 1.4975    | 1.3496    | 1.8534    | .218      | .2195     |
| 6    | 1.6514    | 1.7238    | 1.7391    | 1.5851    | 1.624     | .2256     | .2187     |
| 7    | 2.1171    | 2.1491    | 2.5027    | .1882     | 2.2321    |           | .2248     |
| 8    | .9717     | 2.4181    | 1.3717    | .2431     | 1.31      |           | .1943     |
| 9    | 2.207     | 1.6057    | 2.3266    | .2263     | 2.4935    |           |           |
| 11   |           |           |           |           |           |           | .9229     |
| 12   |           |           |           |           |           |           | 2.9523    |
| 13   |           |           |           |           |           | 1.1538    |           |
| 14   |           |           |           |           |           | 3.0956    | 3.0331    |
| 15   |           |           |           |           |           | 3.3852    | 3.0293    |
| 16   |           |           |           |           |           | 3.2266    | 2.8875    |
| 17   |           |           | .0175     | .0511     | .0107     | 2.931     | 2.6619    |
| 18   |           |           | .0373     | .1501     | .1212     | 2.8121    | 2.3876    |
| 19   | .0686     | .0526     | .0945     | .2187     | .2126     | 2.2786    | 2.0652    |
| 20   | .2218     | .2042     | .2141     | .2644     | .2606     | .2332     | .202      |
| 21   | .2149     | .2111     | .2195     | .2454     | .2804     | .2416     | .2111     |
| 22   | .2027     | .205      | .2111     | .2423     | .2522     | .25       | .2149     |
| 23   | .439      | .4123     | .4725     | .6348     | .2279     | .2134     | .2134     |
| 24   | 2.8636    | 1.2879    | 1.2765    | 1.6568    | .1814     | .1707     | .1959     |
| Max  | 2.8636    | 2.4181    | 2.5027    | 1.6568    | 2.4935    | 3.3852    | 3.0331    |
| Min  | .0686     | .0526     | .0175     | .0511     | .0107     | .1707     | .1768     |
| Avg  | 1.1254    | 1.0691    | 1.0182    | .7012     | 1.0531    | 1.1788    | 1.0769    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 202 / 11 KV KUND Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2672    |
| Max  | 2.2672    |
| Min  | 2.2672    |
| Avg  | 2.2672    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 203 / Jawala AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2202     | .2088     | .1997     | .2317     | .1943     | .4283     | .7217     |
| 2    | .2301     | .2157     | .1997     | .2401     | .1989     | .4336     | .6866     |
| 3    | .2393     | .2248     | .2134     | .234      | .205      | .4077     | .692      |
| 4    | .2439     | .2233     | .2286     | .2446     | .2134     | .3864     | .6752     |
| 5    | .2484     | .2522     | .234      | .2667     | .2286     | .4306     | .7301     |
| 6    | .2698     | .2835     | .2599     | .2804     | .2705     | .5525     | .881      |
| 7    | .1585     | .1616     | .2492     | .2119     | .2964     | .7194     | 1.0616    |
| 8    |           |           |           |           | .2507     | 1.2384    | 1.5646    |
| 9    |           |           |           |           | .1151     | 1.2224    | 1.4563    |
| 12   | 1.2887    | 1.3352    | 1.3809    |           | 1.07      |           |           |
| 13   | 1.6781    | 1.6309    | 1.6659    |           | 1.5394    |           |           |
| 14   | 1.7238    | 1.5783    | 1.7604    | 1.0219    | 1.5684    |           |           |
| 15   | 1.1378    | 1.028     | .9724     | 1.6941    | 1.0402    |           |           |
| 16   | 1.31      | 1.2109    | 1.2559    | 1.7063    | 1.1683    |           |           |
| 17   | 1.5028    | 1.4739    | 1.4327    | 1.6324    | 1.3778    |           |           |
| 18   | 1.3977    | 1.3923    | 1.4106    | 1.3245    | 1.1873    |           |           |
| 19   | .3467     | .865      | 1.0982    | .8802     | .8863     | .1341     |           |
| 20   | .5022     | .6455     | .5845     | .5571     | .3498     | .2622     | .2721     |
| 21   | .3033     | .2644     | .2667     | .2759     | .2637     | .2743     | .2721     |
| 22   | .3109     | .2774     | .2964     | .2896     | .2919     | .2835     | .2698     |
| 23   | .2827     | .3086     | .3117     | .3003     | .2804     | .2858     | .2698     |
| 24   | 1.8838    | .2835     | .2919     | .2622     | .423      | .6333     | .25       |
| Max  | 1.8838    | 1.6309    | 1.7604    | 1.7063    | 1.5684    | 1.2384    | 1.5646    |
| Min  | .1585     | .1616     | .1997     | .2119     | .1151     | .1341     | .25       |
| Avg  | .7639     | .6932     | .7156     | .6474     | .6100     | .5128     | .7002     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 204 / Wadner AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    |           | 2.4387    |
| 2    |           | 2.4387    |
| 3    |           | 2.4387    |
| 4    |           | 2.4387    |
| 5    |           | 2.7435    |
| 6    |           | 3.0483    |
| 7    |           | 3.0483    |
| 8    |           | 3.0483    |
| 9    |           | 2.1338    |
| 10   |           | .3048     |
| 24   | 1.6194    |           |
| Max  | 1.6194    | 3.0483    |
| Min  | 1.6194    | .3048     |
| Avg  | 1.6194    | 2.4082    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 205 / Nighoj GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5144     |
| Max  | .5144     |
| Min  | .5144     |
| Avg  | .5144     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 206 / MALGANGA EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .905      |
| Max  | .905      |
| Min  | .905      |
| Avg  | .905      |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 207 / Jawala GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4344     | .5418     | .5068     | .5335     | .349      | .6043     | .4824     |
| 2    | .4801     | .5601     | .551      | .5403     | .3605     | .5601     | .5083     |
| 3    | .5045     | .5952     | .5838     | .5617     | .3963     | .5784     | .6158     |
| 4    | .5761     | .6219     | .6722     | .6394     | .471      | .6752     | .6584     |
| 5    | .6965     | .8002     | .7072     | .7164     | .5929     | .8009     | .7346     |
| 6    | .9107     | .8581     | .8086     | .8269     | .8269     | .7964     | .8474     |
| 7    | .9488     | .8779     | .7705     | .8459     | .8482     | .8429     | .8863     |
| 8    | .8322     | .7758     | .7285     | .7522     | .8192     | .7293     | .7796     |
| 9    | .7064     | .7346     | .6767     | .567      | .7011     | .6356     | .6409     |
| 10   | .5769     | .5396     | .5312     |           | .676      | .5007     | .538      |
| 11   | .4885     | .3429     | .4969     |           | .5319     | .3757     | .3734     |
| 12   | .3277     | .3307     | .3643     |           | .2774     | .3628     | .2622     |
| 13   | .4092     | .2606     | .3475     | .3742     | .2545     | .2743     | .2401     |
| 14   | .3193     | .2507     | .3696     | .5144     | .2347     | .3125     | .2538     |
| 15   | .317      | .25       | .3338     | .4969     | .2301     | .2904     | .2385     |
| 16   | .3254     | .2789     | .2827     | .4816     | .2294     | .2576     | .2599     |
| 17   | .2881     | .3696     | .3909     | .3605     | .2728     | .3376     | .3414     |
| 18   | .4374     | .4458     | .381      | .4024     | .3849     | .3909     | .3597     |
| 19   | .7849     | .7324     | .7103     | .8208     | .7697     | .7758     | .676      |
| 20   | .7758     | .7468     | .8078     | .8154     | .7377     | .8566     | .692      |
| 21   | .7316     | .6912     | .7164     | .8078     | .6341     | .8688     | .6447     |
| 22   | .6729     | .6615     | .5807     | .6615     | .5693     | .6104     | .583      |
| 23   | .5982     | .5396     | .4694     | .5731     | .5479     | .5129     | .4733     |
| 24   | 2.1536    | .5167     | .506      | .4199     | .6005     | .4938     | .4161     |
| Max  | 2.1536    | .8779     | .8086     | .8459     | .8482     | .8688     | .8863     |
| Min  | .2881     | .25       | .2827     | .3605     | .2294     | .2576     | .2385     |
| Avg  | .6373     | .5551     | .5539     | .6053     | .5132     | .5602     | .5211     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 208 / 11 kv Gunore AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8097     |
| Max  | .8097     |
| Min  | .8097     |
| Avg  | .8097     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014047 / 33/11 KV NIGHOJ

Feeder No / Name : 209 / Devibhoyare Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 201 / Takali AG

SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 18   |           |           |           | 2.5911    |
| 20   |           | .9297     |           |           |
| 22   |           |           | .8535     |           |
| 24   | 2.4291    |           |           |           |
| Max  | 2.4291    | .9297     | .8535     | 2.5911    |
| Min  | 2.4291    | .9297     | .8535     | 2.5911    |
| Avg  | 2.4291    | .9297     | .8535     | 2.5911    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 202 / Pokari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 20   |           | .0914     |           |
| 22   |           |           | .0762     |
| 24   | .7468     |           |           |
| Max  | .7468     | .0914     | .0762     |
| Min  | .7468     | .0914     | .0762     |
| Avg  | .7468     | .0914     | .0762     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 203 / 11 KV dhotre-dhoki Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 204 / Karjule(H) AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4923     | .5495     | .0053     | .6843     | .5479     |           | .0343     |
| 2    | .4992     | .5586     | .0069     | .679      | .5845     |           |           |
| 3    | .5152     | .5495     | .013      | .6798     | .5822     |           |           |
| 4    | .5586     | .5959     | .0008     | .7285     | .6363     |           |           |
| 5    | .6523     | .7171     | .0008     | .8497     | .7346     |           | .0114     |
| 6    | .8177     | .881      | .1036     | .9922     | .8909     |           | .0777     |
| 7    | .9747     | 1.1713    | .1463     | 1.2376    | 1.0829    |           |           |
| 8    | .3269     | .3719     | .0579     | .8474     | .3536     | 1.1309    | .9823     |
| 9    |           |           |           |           |           | 1.1782    | 1.1469    |
| 10   |           |           |           |           |           | 1.1675    |           |
| 11   |           |           |           |           |           | 1.2559    | 1.0067    |
| 12   |           |           |           |           |           | 1.2079    | 1.0783    |
| 13   |           |           |           |           |           | 1.1264    | 1.1233    |
| 14   |           |           |           |           |           | 1.1325    | 1.1294    |
| 15   |           |           |           |           |           | 1.0654    | 1.0555    |
| 16   |           |           |           |           |           | .3292     | .4359     |
| 18   |           |           | .0305     |           |           |           |           |
| 19   |           |           |           | .0236     | .0328     | .0511     | .0366     |
| 20   |           | .1524     |           | .0023     |           | .0838     | .0899     |
| 21   |           |           |           |           |           | .0876     | .0831     |
| 22   |           |           | .1372     |           |           | .0892     | .0876     |
| 23   |           |           |           |           |           | .0876     | .0892     |
| 24   | .7316     | .0114     | .6135     | .5136     |           | .077      | .0846     |
| Max  | .9747     | 1.1713    | .6135     | 1.2376    | 1.0829    | 1.2559    | 1.1469    |
| Min  | .3269     | .0114     | .0008     | .0023     | .0328     | .0511     | .0114     |
| Avg  | .6187     | .5559     | .1014     | .658      | .6051     | .6713     | .5031     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 205 / 11 KV TAKALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .5335     |           |
| 2    |           |           |           | .5335     |           |
| 3    |           |           |           | .5716     |           |
| 4    |           |           |           | .6478     |           |
| 5    |           |           |           | .8002     |           |
| 6    |           |           |           | .9907     |           |
| 7    |           |           |           | .381      |           |
| 10   |           |           |           | .9907     |           |
| 11   |           |           |           | .8002     |           |
| 12   |           |           |           | .6478     |           |
| 13   |           |           |           | .6478     |           |
| 14   |           |           |           | .6097     |           |
| 18   |           |           |           |           | .6516     |
| 20   |           | .7888     |           |           |           |
| 22   |           |           | .6344     |           |           |
| 24   | .4801     |           |           |           |           |
| Max  | .4801     | .7888     | .6344     | .9907     | .6516     |
| Min  | .4801     | .7888     | .6344     | .381      | .6516     |
| Avg  | .4801     | .7888     | .6344     | .6795     | .6516     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014048 / 33/11 KV TAKALI DHOKESHWAR

Feeder No / Name : 206 / 11 KV MANDOHAL NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 11 / OUTGOING UTILITY

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    |           |           |           |           | .0381     |
| 18   |           |           |           | .1524     |           |
| 20   |           | .1715     |           |           |           |
| 22   |           |           | .181      |           |           |
| 24   | .1048     |           |           |           |           |
| Max  | .1048     | .1715     | .181      | .1524     | .0381     |
| Min  | .1048     | .1715     | .181      | .1524     | .0381     |
| Avg  | .1048     | .1715     | .181      | .1524     | .0381     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014049 / 33/11 KV KHADAKWADI

Feeder No / Name : 201 / Palshi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.4291    |
| Max  | 2.4291    |
| Min  | 2.4291    |
| Avg  | 2.4291    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014049 / 33/11 KV KHADAKWADI

Feeder No / Name : 202 / Vankute AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.4291    |
| Max  | 2.4291    |
| Min  | 2.4291    |
| Avg  | 2.4291    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014049 / 33/11 KV KHADAKWADI

Feeder No / Name : 203 / Mandve AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.4291    |
| Max  | 2.4291    |
| Min  | 2.4291    |
| Avg  | 2.4291    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014049 / 33/11 KV KHADAKWADI

Feeder No / Name : 204 / Vankute GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8573     |
| Max  | .8573     |
| Min  | .8573     |
| Avg  | .8573     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014049 / 33/11 KV KHADAKWADI

Feeder No / Name : 205 / Kamatwadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.4291    |
| Max  | 2.4291    |
| Min  | 2.4291    |
| Avg  | 2.4291    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 201 / Ranjangaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 9    |           | .6838     |
| 24   | 1.1336    |           |
| Max  | 1.1336    | .6838     |
| Min  | 1.1336    | .6838     |
| Avg  | 1.1336    | .6838     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 202 / Kadus AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2667     | .2492     | .2698     | .2401     | .2545     | .1029     | .0884     |
| 2    | .2804     | .2683     | .2652     | .25       | .2614     | .1075     | .0945     |
| 3    | .2896     | .282      | .2675     | .2599     | .2797     | .1097     | .096      |
| 4    | .3178     | .3216     | .3018     | .3025     | .3025     |           |           |
| 5    | .3711     | .3818     | .3917     | .3871     | .3795     |           |           |
| 6    | .4656     | .5396     | .5449     | .5235     | .5098     |           |           |
| 7    | .7423     | .8238     | .7872     | .7743     | .8101     |           |           |
| 8    | .9305     | .9579     | .9808     | .9991     | .9694     |           |           |
| 9    | .916      | .897      | 2.6208    | 1.0288    | .9556     |           |           |
| 11   |           |           |           |           |           | .4984     | .4115     |
| 12   |           |           |           |           |           | .8901     | .7842     |
| 13   |           |           |           |           |           | .9556     | .7865     |
| 14   |           |           |           |           |           | .9183     | .8017     |
| 15   |           |           |           |           |           | .8634     | .8246     |
| 16   |           |           |           |           |           | .8551     | .791      |
| 17   |           |           |           |           |           | .8322     | .8185     |
| 18   | .0724     | .0876     | .0876     | .0831     | .1014     | .7781     | .7064     |
| 19   | .1707     | .1562     | .1578     | .1623     | .1677     | .7392     | .6889     |
| 20   | .1684     | .1608     | .1616     | .1638     | .1715     | .1623     | .1417     |
| 21   | .1478     | .144      | .1517     | .141      | .1524     | .1334     | .1334     |
| 22   | .1265     | .1242     | .1235     | .1135     | .144      | .1204     | .1105     |
| 23   | .1799     | .1928     | .1677     | .1677     | .1105     | .1059     | .0968     |
| 24   | 1.8648    | .2683     | .2401     | .2385     | .1029     | .0838     | .0854     |
| Max  | 1.8648    | .9579     | 2.6208    | 1.0288    | .9694     | .9556     | .8246     |
| Min  | .0724     | .0876     | .0876     | .0831     | .1014     | .0838     | .0854     |
| Avg  | .4569     | .3659     | .4700     | .3647     | .3546     | .4857     | .4388     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 203 / Ranjangaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .205      | .2096     | .208      | .2157     | .208      | .2202     | .2164     |
| 2    | .2004     | .2035     | .2111     | .2111     | .2073     | .2126     | .2004     |
| 3    | .2202     | .2119     | .2225     | .2172     | .2248     | .2271     | .2164     |
| 4    | .2782     | .2683     | .2736     | .2667     | .2873     | .2766     | .253      |
| 5    | .4222     | .4199     | .4351     | .4473     | .4748     | .455      | .423      |
| 6    | .6821     | .6714     | .7049     | .6988     | .7026     | .836      | .7042     |
| 7    | .7964     | .8566     | .7994     | .8314     | .7651     | .9069     | .7987     |
| 8    | .7918     | .8909     | .8711     | .868      | .7849     | .7705     | .8672     |
| 9    | .7606     | .7987     | 1.3977    | .7941     | .679      | .7415     | .7385     |
| 10   | .5731     | .5853     | .6333     | .6127     | .6089     | .6569     | .5975     |
| 11   | .5792     | .5335     | .5296     | .3582     | .5068     | .5327     | .5235     |
| 12   | .4946     | .5197     | .5266     | .5007     | .3757     | .4207     | .5647     |
| 13   | .4138     | .4839     | .4641     | .5007     | .3528     | .3826     | .4496     |
| 14   | .3757     | .349      | .426      | .4336     | .3025     | .317      | .3986     |
| 15   | .4862     | .3818     | .5136     | .2027     | .2423     | .365      | .4862     |
| 16   | .4306     | .5738     | .5289     | .4885     | .3948     | .4306     | .4885     |
| 17   | .4367     | .5418     | .6264     | .5807     | .4009     | .5373     | .5205     |
| 18   | .5053     | .4641     | .5175     | .5639     | .4443     | .4572     | .4504     |
| 19   | .6569     | .5952     | .6447     | .6318     | .6348     | .6241     | .6203     |
| 20   | .618      | .5769     | .6249     | .618      | .6051     | .6196     | .5982     |
| 21   | .4748     | .4687     | .4527     | .4504     | .4496     | .455      | .4717     |
| 22   | .3597     | .3399     | .3292     | .349      | .3498     | .3498     | .3559     |
| 23   | .269      | .2522     | .253      | .2561     | .2561     | .2576     | .2614     |
| 24   | 1.8495    | .2195     | .2301     | .2164     | .2317     | .2271     | .2233     |
| Max  | 1.8495    | .8909     | 1.3977    | .868      | .7849     | .9069     | .8672     |
| Min  | .2004     | .2035     | .208      | .2027     | .2073     | .2126     | .2004     |
| Avg  | .5367     | .4757     | .5177     | .4714     | .4371     | .4700     | .4762     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 204 / Waghunde GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 9    |           | .7095     |
| 24   | .4858     |           |
| Max  | .4858     | .7095     |
| Min  | .4858     | .7095     |
| Avg  | .4858     | .7095     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 205 / 11 KV WALAVANE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014050 / 33/11 KV SUPA OLD

Feeder No / Name : 206 / 11 KV BABURDI AG

Feeder KV- 11 / INCOMING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8097     |
| Max  | .8097     |
| Min  | .8097     |
| Avg  | .8097     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014051 / 33/11 KV BHALWANI

Feeder No / Name : 201 / 11 KV BHALWANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4039     | .3521     | .3178     | .3102     | .3277     | .4443     | .5228     |
| 2    | .41       | .3559     | .3147     | .3216     | .3262     | .4481     | .5296     |
| 3    | .4329     | .3734     | .3391     | .3406     | .3368     | .4512     | .5487     |
| 4    | .4351     | .3803     | .3361     | .3437     | .3559     | .458      | .5517     |
| 5    | .4999     | .4153     | .3864     | .3917     | .3841     | .49       | .586      |
| 6    | .7064     | .6226     | .6493     | .6226     | .5723     | .6752     | .8109     |
| 7    | .9038     | .8772     | .8307     | .8855     | .8269     | 1.0128    | 1.1713    |
| 8    | .7225     | .8337     | .1539     | .3338     | .4512     | 1.5592    | 1.6331    |
| 9    |           |           |           |           |           | 1.659     | 1.7307    |
| 10   | .8063     | .7735     | .7819     | .8009     | .8451     | .3368     | .6158     |
| 11   | .7628     | .7004     | .6379     | .7903     | .7293     |           |           |
| 12   | .868      | .8147     | .7827     | .9092     | .7087     |           |           |
| 13   | .9214     | .8893     | .8878     | .9351     | .9214     |           |           |
| 14   | .9412     | .8154     | .9008     | .8711     | .9907     |           |           |
| 15   | .7971     | .8436     | .7705     | .7552     | .8787     |           |           |
| 16   | .836      | .7872     | .8208     | .8017     | .8185     | .2591     | .2995     |
| 17   | .865      | .8185     | .8954     | .7628     | .868      | .3155     | .298      |
| 18   | .9419     | .7499     | .8535     | .7606     | .8528     | .3765     | .3544     |
| 19   | .8413     | .852      | .8672     | .8284     | .8573     | 1.0555    | .4626     |
| 20   | .6714     | .6577     | .7125     | .711      | .6059     | .6386     | .6562     |
| 21   | .6356     | .5632     | .5418     | .5868     | .5548     | .6196     | .6562     |
| 22   | .5754     | .5258     | .503      | .4931     | .5182     | .522      | .567      |
| 23   | .4771     | .4534     | .4283     | .4557     | .442      | .4626     | .5129     |
| 24   | 2.7903    | .3506     | .3437     | .3658     | .4908     | .5281     | .4748     |
| Max  | 2.7903    | .8893     | .9008     | .9351     | .9907     | 1.659     | 1.7307    |
| Min  | .4039     | .3506     | .1539     | .3102     | .3262     | .2591     | .298      |
| Avg  | .7933     | .6437     | .6111     | .6251     | .6375     | .6480     | .6833     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014051 / 33/11 KV BHALWANI

Feeder No / Name : 202 / 11 KV DHAWALPURI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014051 / 33/11 KV BHALWANI

Feeder No / Name : 203 / 11 KV BHANGADEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 19   |           | .3201     |
| 24   | 1.6194    |           |
| Max  | 1.6194    | .3201     |
| Min  | 1.6194    | .3201     |
| Avg  | 1.6194    | .3201     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014051 / 33/11 KV BHALWANI

Feeder No / Name : 204 / 11 KV JAMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 19   |           | 1.3056    |
| 24   | 2.4291    |           |
| Max  | 2.4291    | 1.3056    |
| Min  | 2.4291    | 1.3056    |
| Avg  | 2.4291    | 1.3056    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014051 / 33/11 KV BHALWANI

Feeder No / Name : 205 / 11 KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 19   |           | 2.5337    |
| 24   | 2.4291    |           |
| Max  | 2.4291    | 2.5337    |
| Min  | 2.4291    | 2.5337    |
| Avg  | 2.4291    | 2.5337    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014051 / 33/11 KV BHALWANI

Feeder No / Name : 206 / Bhalwani GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8573     |
| Max  | .8573     |
| Min  | .8573     |
| Avg  | .8573     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014052 / 22/11 KV NARAYANGAWHAN

Feeder No / Name : 201 / RALEGAN SIDDHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014052 / 22/11 KV NARAYANGAWHAN

Feeder No / Name : 202 / KOHAKADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014052 / 22/11 KV NARAYANGAWHAN

Feeder No / Name : 203 / 11 KV NARAYANGAWHAN AG      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.4291    |
| Max  | 2.4291    |
| Min  | 2.4291    |
| Avg  | 2.4291    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014052 / 22/11 KV NARAYANGAWHAN

Feeder No / Name : 204 / 11 KV JATEGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.2388    |
| Max  | 3.2388    |
| Min  | 3.2388    |
| Avg  | 3.2388    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014052 / 22/11 KV NARAYANGAWHAN

Feeder No / Name : 205 / Devdaithan AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .9717     |
| Max  | .9717     |
| Min  | .9717     |
| Avg  | .9717     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014052 / 22/11 KV NARAYANGAWHAN

Feeder No / Name : 206 / Ralegansiddhi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .724      |
| Max  | .724      |
| Min  | .724      |
| Avg  | .724      |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014052 / 22/11 KV NARAYANGAWHAN

Feeder No / Name : 207 / 11 KV NARAYANG.+JATEGAON  
GFSS Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014092 / 33/11 KV SUPA MIDC

Feeder No / Name : 201 / 11 KV MIDC Supa

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7716     |
| Max  | .7716     |
| Min  | .7716     |
| Avg  | .7716     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014092 / 33/11 KV SUPA MIDC

Feeder No / Name : 203 / 11 KV HANGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2        |
| Max  | .2        |
| Min  | .2        |
| Avg  | .2        |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014092 / 33/11 KV SUPA MIDC

Feeder No / Name : 204 / Hanga GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1219     |           | .0762     | .0762     | .0914     | .0762     | .0914     |
| 2    | .1067     |           | .0762     | .0762     | .0762     | .0762     | .0914     |
| 3    | .1067     |           | .0762     | .0762     | .0762     | .0762     | .0914     |
| 4    | .1219     |           | .0914     | .0762     | .0914     | .0762     | .0914     |
| 5    | .1524     |           | .1219     | .1372     | .1067     | .1219     | .1372     |
| 6    | .2439     |           | .1524     | .1981     | .1829     | .1981     | .1677     |
| 7    | .3048     |           | .1829     | .2896     | .2286     | .2286     | .1677     |
| 8    | .2591     |           | .2743     | .2286     | .2896     | .1829     | .2286     |
| 9    | .1981     |           | .2134     | .1677     | .2591     | .2286     | .2134     |
| 10   | .2134     |           | .1981     | .1981     | .1981     | .2134     | .2134     |
| 11   | .1829     |           | .1829     | .1829     | .2134     | .1524     | .1677     |
| 12   | .1219     |           | .1219     | .1524     | .1372     | .1372     | .0914     |
| 13   | .1067     |           | .0762     | .0914     | .0914     | .1067     |           |
| 14   | .1067     | .1067     | .0914     | .0914     | .0914     | .0914     |           |
| 15   | .0914     | .0914     | .0914     | .0914     | .0762     |           | .0762     |
| 16   | .0914     | .1067     | .0762     | .0914     | .0762     | .0914     |           |
| 17   | .0914     | .1067     | .061      | .0914     | .0762     | .1067     |           |
| 18   | .1219     | .1219     | .1372     | .1219     | .1067     | .1372     |           |
| 19   | .1981     | .1677     | .1829     | .1677     | .1677     | .1677     |           |
| 20   | .2439     | .1829     | .1829     | .2134     | .1829     | .2134     |           |
| 21   | .1981     | .1677     | .1829     | .1981     | .1677     | .1981     |           |
| 22   | .1677     | .1677     | .1524     | .1677     | .1524     | .1677     |           |
| 23   | .1219     | .1219     | .1219     | .1219     | .1219     | .1219     |           |
| 24   | .1067     | .0914     | .0914     | .0914     | .0914     | .1067     |           |
| Max  | .3048     | .1829     | .2743     | .2896     | .2896     | .2286     | .2286     |
| Min  | .0914     | .0914     | .061      | .0762     | .0762     | .0762     | .0762     |
| Avg  | .1575     | .1302     | .1340     | .1416     | .1397     | .1425     | .1407     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014092 / 33/11 KV SUPA MIDC

Feeder No / Name : 205 / 11 KV SUPA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3963     |           | .3963     | .3963     |           |
| 2    | .3658     |           | .3658     | .3658     |           |
| 3    | .3353     |           | .3658     | .3658     |           |
| 4    | .3353     |           | .3353     | .3658     |           |
| 5    | .3658     |           | .3963     | .3963     |           |
| 6    | .5792     |           | .5487     | .5792     |           |
| 7    | .884      |           | .884      | .9145     |           |
| 8    | 1.0364    |           | 1.0059    | .9755     |           |
| 9    | 1.0059    |           | .9755     | .945      |           |
| 10   | .823      |           | .7926     | .8535     |           |
| 11   | .6706     |           | .7011     | .7316     |           |
| 12   | .6097     |           | .6097     | .6401     |           |
| 13   | .5792     |           | .5487     | .6097     |           |
| 14   | .5182     | .5487     |           | .5792     |           |
| 15   | .5182     | .5487     | .4877     |           |           |
| 16   | .5487     | .5487     | .5487     | .5792     |           |
| 17   | .5792     | .5182     | .5182     | .6097     |           |
| 18   | .5792     | .5792     | .5487     | .5792     |           |
| 19   | .7316     | .7011     | .6706     |           | .7316     |
| 20   | .7926     | .7926     | .7926     |           | .823      |
| 21   | .7316     | .7621     | .7621     |           | .7621     |
| 22   | .7011     | .6706     | .7011     |           | .6706     |
| 23   | .6097     | .5792     | .5792     |           | .5487     |
| 24   | 1.1926    | .4572     | .4572     |           | .4877     |
| Max  | 1.1926    | .7926     | 1.0059    | .9755     | .823      |
| Min  | .3353     | .4572     | .3353     | .3658     | .4877     |
| Avg  | .6454     | .6097     | .6083     | .6168     | .6706     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014092 / 33/11 KV SUPA MIDC

Feeder No / Name : 206 / Chairon Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6478     | .6478     | .6478     | .6478     | .6859     | .6478     | .6478     |
| 2    | .6097     | .6478     | .6097     | .6478     | .6478     | .6097     | .6097     |
| 3    | .6097     | .6478     | .6097     | .6478     | .6478     | .6478     | .6478     |
| 4    | .6478     | .6478     | .6097     | .6478     | .6478     | .6097     | .6478     |
| 5    | .6097     | .6478     | .6097     | .6478     | .6478     | .6097     | .5716     |
| 6    | .6478     | .6478     | .6478     | .6478     | .6478     | .6097     | .6097     |
| 7    | .6478     | .8383     | .7621     | .6859     | .6859     | .724      | .9145     |
| 8    | .6478     | .7621     | .6478     | .6097     | .6859     | .724      | .9145     |
| 9    | .6478     | .724      | .6097     | .6478     | .6859     | .8383     | .7621     |
| 10   | .6478     | .6478     | .6478     | .6859     | .6478     | .6478     | .6859     |
| 11   | .6478     | .6478     | .9145     | .724      | .6478     | .6478     | .6478     |
| 12   | .6478     | .6478     | .8383     | .6859     | .6478     | .6478     | .6859     |
| 13   | .6478     | .6097     | .6097     | .6859     | .6478     | .7621     | .6859     |
| 14   | .6478     | .6097     | .6478     | .6859     | .6097     | .6097     | .6478     |
| 15   | .6478     | .9907     | .6478     | .6859     | .6097     | .6859     | .7621     |
| 16   | .6478     | .8764     | .6478     | .6478     | .6478     | .6478     | .8383     |
| 17   | .6478     | .6478     | .8383     | .6859     | .6097     | .6859     | .6478     |
| 18   | .6478     | .6478     | .6859     | 1.0669    | .6478     | .8383     | .6097     |
| 19   | .6859     | .6478     | .724      | .7621     | .6097     | .724      | .6097     |
| 20   | .6478     | .6478     | .724      | .7621     | .6478     | .6859     | .6478     |
| 21   | .6478     | .6478     | .6859     | .724      | .6478     | .6097     | .6478     |
| 22   | .6478     | .6478     | .6859     | .724      | .6478     | .6478     | .6478     |
| 23   | .6478     | .6478     | .6478     | .724      | .6478     | .6478     | .6097     |
| 24   | 1.3718    | .6478     | .6478     | .724      | .6478     | .6478     | .6478     |
| Max  | 1.3718    | .9907     | .9145     | 1.0669    | .6859     | .8383     | .9145     |
| Min  | .6097     | .6097     | .6097     | .6097     | .6097     | .6097     | .5716     |
| Avg  | .6748     | .6843     | .6811     | .7002     | .6478     | .6732     | .6811     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014092 / 33/11 KV SUPA MIDC

Feeder No / Name : 207 / Mungshi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014092 / 33/11 KV SUPA MIDC

Feeder No / Name : 208 / Hanga MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0974    |
| Max  | 1.0974    |
| Min  | 1.0974    |
| Avg  | 1.0974    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014092 / 33/11 KV SUPA MIDC

Feeder No / Name : 209 / C Block

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .06       |
| Max  | .06       |
| Min  | .06       |
| Avg  | .06       |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014098 / 33/11 KV ALKUTI

Feeder No / Name : 201 / Alkuti AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014098 / 33/11 KV ALKUTI

Feeder No / Name : 202 / MHASKEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014098 / 33/11 KV ALKUTI

Feeder No / Name : 203 / Alkuti GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8573     |
| Max  | .8573     |
| Min  | .8573     |
| Avg  | .8573     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014098 / 33/11 KV ALKUTI

Feeder No / Name : 204 / Shirapur AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.4291    |
| Max  | 2.4291    |
| Min  | 2.4291    |
| Avg  | 2.4291    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014098 / 33/11 KV ALKUTI

Feeder No / Name : 206 / Padali Ale AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014098 / 33/11 KV ALKUTI

Feeder No / Name : 207 / Maskewadi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014099 / 33/11 KV KANHUR PATHAR

Feeder No / Name : 201 / Kinni AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.4291    |
| Max  | 2.4291    |
| Min  | 2.4291    |
| Avg  | 2.4291    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014099 / 33/11 KV KANHUR PATHAR

Feeder No / Name : 202 / Kanur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014099 / 33/11 KV KANHUR PATHAR

Feeder No / Name : 203 / 11 KV KANHUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8573     |
| Max  | .8573     |
| Min  | .8573     |
| Avg  | .8573     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014099 / 33/11 KV KANHUR PATHAR

Feeder No / Name : 205 / Muktidham AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014099 / 33/11 KV KANHUR PATHAR

Feeder No / Name : 207 / 11 Kv Kinh GFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8573     |
| Max  | .8573     |
| Min  | .8573     |
| Avg  | .8573     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014103 / 33/11 KV RALEGAN THERPAL

Feeder No / Name : 201 / MHASE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5337    |
| Max  | 1.5337    |
| Min  | 1.5337    |
| Avg  | 1.5337    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014103 / 33/11 KV RALEGAN THERPAL

Feeder No / Name : 202 / KOHKADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014103 / 33/11 KV RALEGAN THERPAL

Feeder No / Name : 203 / JAWALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.1336    |
| Max  | 1.1336    |
| Min  | 1.1336    |
| Avg  | 1.1336    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014103 / 33/11 KV RALEGAN THERPAL

Feeder No / Name : 204 / Pimpalner AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .8097     |
| Max  | .8097     |
| Min  | .8097     |
| Avg  | .8097     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014103 / 33/11 KV RALEGAN THERPAL

Feeder No / Name : 206 / Kurund AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014103 / 33/11 KV RALEGAN THERPAL

Feeder No / Name : 207 / 11KV Kurund GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014124 / 33/11kv Palaspur

Feeder No / Name : 201 / Nandur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3921     |
| Max  | .3921     |
| Min  | .3921     |
| Avg  | .3921     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014124 / 33/11kv Palaspur

Feeder No / Name : 202 / Palaspur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.1379    |
| Max  | 3.1379    |
| Min  | 3.1379    |
| Avg  | 3.1379    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014124 / 33/11kv Palaspur

Feeder No / Name : 203 / Pokhari GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .168      |
| Max  | .168      |
| Min  | .168      |
| Avg  | .168      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014163 / 33/11 KV DHAWALPURI

Feeder No / Name : 201 / Durgadevi SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6194    |
| Max  | 1.6194    |
| Min  | 1.6194    |
| Avg  | 1.6194    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014163 / 33/11 KV DHAWALPURI

Feeder No / Name : 202 / 11 KV Sutarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1267     |           | .1267     | .362      | .362      |
| 2    | .1267     |           | .1267     | .3658     | .362      |
| 3    | .1448     |           | .1463     | .4024     | .3658     |
| 4    | .1646     |           | .1663     | .4344     | .3982     |
| 5    | .1646     |           | .1867     | .4706     | .4298     |
| 6    | .2054     |           | .2378     | .4835     | .443      |
| 7    | .3361     |           | .2801     | .5068     | .7186     |
| 8    | .3361     |           | .3326     | .5611     | .7628     |
| 9    | .3109     | .2172     |           | .5853     | .7545     |
| 10   | .1772     |           | .2279     | .4163     | .2353     |
| 11   |           | .176      | .197      | .128      |           |
| 12   |           | .6722     | .7888     | .1402     |           |
| 13   |           | .8002     | .8322     | .1734     |           |
| 14   |           | .7773     | .823      | .1715     |           |
| 15   |           | .6964     | .7969     | .1696     |           |
| 16   |           | .664      | .7209     | .1886     |           |
| 17   |           | .6401     | .5967     | .1907     | .197      |
| 18   |           | .5376     | .4694     | .1865     | .2218     |
| 19   |           | .4843     | .4748     | .3086     | .2801     |
| 20   |           | .2481     | .2629     | .333      | .2587     |
| 21   |           | .2279     | .3544     | .3155     | .2058     |
| 22   |           | .2103     | .3224     | .3224     | .1829     |
| 23   |           | .1907     | .2534     | .2534     | .1663     |
| 24   | .1433     |           | .1463     | .3467     | .362      |
| Max  | .3361     | .8002     | .8322     | .5853     | .7628     |
| Min  | .1267     | .176      | .1267     | .128      | .1663     |
| Avg  | .2033     | .4673     | .3857     | .3257     | .3726     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014163 / 33/11 KV DHAWALPURI

Feeder No / Name : 203 / Kalu Dam SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2483    |           | 1.3279    | .1254     | .1254     |
| 2    | 1.2483    |           | 1.3279    | .1267     | .1254     |
| 3    | 1.2803    |           | 1.3603    | .1448     | .124      |
| 4    | 1.3279    |           | 1.4091    | .197      | .2126     |
| 5    | 1.3441    |           | 1.4918    | .2629     | .2229     |
| 6    | 1.5249    |           | 1.5203    | .2804     | .2543     |
| 7    | 1.7404    |           | 1.7695    | .3155     | .3258     |
| 8    | 1.9113    |           | 1.989     | .3258     | .3294     |
| 9    | 1.749     | 1.9433    |           | .4161     | .4801     |
| 10   | .2572     |           | .2743     | .3155     | .4298     |
| 11   |           | .1718     | .3224     | .3658     |           |
| 12   |           | .1677     | .2126     | 1.989     |           |
| 13   |           | .2105     | .1928     | 2.2382    |           |
| 14   |           | .2012     | .1715     | 2.1963    |           |
| 15   |           | .1844     | .218      | 1.989     |           |
| 16   |           | .2058     | .1823     | 2.1795    |           |
| 17   |           | .2058     | .1966     | 2.2382    | 2.0972    |
| 18   |           | .2267     | .2652     | 1.989     | 2.0885    |
| 19   |           | .2591     | .4527     | 1.933     | 1.9826    |
| 20   |           | .298      | .4458     | .4115     | .2818     |
| 21   |           | .298      | .4382     | .3988     | .2713     |
| 22   |           | .2774     | .3544     | .4031     | .2561     |
| 23   |           | .2454     | .3224     | .3366     | .197      |
| 24   | 1.2003    |           | 1.2955    | 2.1795    | .2743     |
| Max  | 1.9113    | 1.9433    | 1.989     | 2.2382    | 2.0972    |
| Min  | .2572     | .1677     | .1715     | .1254     | .124      |
| Avg  | 1.3484    | .3497     | .7626     | .9732     | .5599     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014165 / 33/11 Kv Goregaon

Feeder No / Name : 201 / 11 KV Goregawan GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .0526     | .0362     | .0543     | .0543     | .0509     | .032      | .0373     |
| Max  | .0526     | .0362     | .0543     | .0543     | .0509     | .032      | .0373     |
| Min  | .0526     | .0362     | .0543     | .0543     | .0509     | .032      | .0373     |
| Avg  | .0526     | .0362     | .0543     | .0543     | .0509     | .032      | .0373     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014165 / 33/11 Kv Goregaon

Feeder No / Name : 202 / 11 Kv Goreshwar AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .2454     | .2534     | .2507     | .2172     | .2374     | .8002     | .8583     |
| Max  | .2454     | .2534     | .2507     | .2172     | .2374     | .8002     | .8583     |
| Min  | .2454     | .2534     | .2507     | .2172     | .2374     | .8002     | .8583     |
| Avg  | .2454     | .2534     | .2507     | .2172     | .2374     | .8002     | .8583     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 014165 / 33/11 Kv Goregaon

Feeder No / Name : 203 / 11 Kv Hiwre -Padali SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .8097     | .3258     | .3258     | .112      | .112      | .1433     |
| Max  | .8097     | .3258     | .3258     | .112      | .112      | .1433     |
| Min  | .8097     | .3258     | .3258     | .112      | .112      | .1433     |
| Avg  | .8097     | .3258     | .3258     | .112      | .112      | .1433     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

AHMEDNAGAR URBAN DIVISION[572]

PARNER NGR RSD (I)[203] BU 6718

Substation No/ Name :- 017012 / 132/33 KV SUPA

Feeder No / Name : 405 / 33 KV JAPFA FEEDER

SHEDDABLE RURAL

Feeder KV- 33 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 5.4298    |
| Max  | 5.4298    |
| Min  | 5.4298    |
| Avg  | 5.4298    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014058 / 33/11KV KOLGAON

Feeder No / Name : 202 / 11KV GHARGAON 1  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014058 / 33/11KV KOLGAON

Feeder No / Name : 204 / 11KV GHARGAON 2  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014070 / 33/11KV BELWANDI

Feeder No / Name : 201 / 11KV LONI I

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014070 / 33/11KV BELWANDI

Feeder No / Name : 202 / 11KV BELWANDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 20   | .4062     |           |
| 24   | .4062     | 1.656     |
| Max  | .4062     | 1.656     |
| Min  | .4062     | 1.656     |
| Avg  | .4062     | 1.656     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014070 / 33/11KV BELWANDI

Feeder No / Name : 203 / 11KV YELAPANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.5055    |
| Max  | 3.5055    |
| Min  | 3.5055    |
| Avg  | 3.5055    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014070 / 33/11KV BELWANDI

Feeder No / Name : 204 / 11KV LONI II

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014070 / 33/11KV BELWANDI

Feeder No / Name : 205 / 11KV GHOTAVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014070 / 33/11KV BELWANDI

Feeder No / Name : 206 / 11KV Belwandi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 20   | 1.1203    |           |
| 24   |           | .5601     |
| Max  | 1.1203    | .5601     |
| Min  | 1.1203    | .5601     |
| Avg  | 1.1203    | .5601     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014070 / 33/11KV BELWANDI

Feeder No / Name : 207 / 11 KV Belwandi -II

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    |           | 1.6766    |
| 2    |           | 1.829     |
| 3    |           | 1.9814    |
| 4    |           | 1.9814    |
| 5    |           | 2.1338    |
| 6    |           | 2.5911    |
| 7    |           | 3.3532    |
| 8    |           | 3.8104    |
| 9    |           | 3.9628    |
| 10   |           | .1524     |
| 20   | .3241     |           |
| 24   |           | 1.1883    |
| Max  | .3241     | 3.9628    |
| Min  | .3241     | .1524     |
| Avg  | .3241     | 2.2419    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014070 / 33/11KV BELWANDI

Feeder No / Name : 208 / 11 KV GHOTAVI- II  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | 4.1152    |
| 2    |           |           | 4.5725    |
| 3    |           |           | 4.5725    |
| 4    |           |           | 2.4387    |
| 8    |           |           | .7621     |
| 9    |           |           | 4.5725    |
| 10   |           |           | 2.2862    |
| 20   | .3768     |           |           |
| 24   |           | .2622     |           |
| Max  | .3768     | .2622     | 4.5725    |
| Min  | .3768     | .2622     | .7621     |
| Avg  | .3768     | .2622     | 3.3314    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014079 / PIMPRI KOLANDAR

Feeder No / Name : 203 / 11KV DHAVALGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 03-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 1    | .3048     |
| 10   | 2.5149    |
| 11   | 2.6673    |
| 12   | 2.5149    |
| 14   | 2.3624    |
| 15   | 2.5911    |
| 16   | 2.4387    |
| Max  | 2.6673    |
| Min  | .3048     |
| Avg  | 2.1992    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014079 / PIMPRI KOLANDAR

Feeder No / Name : 205 / 11 KV Pimpri Kolander

GAOTHAN FEEDER

(GFSS) Feeder KV- 11 /

OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7621     |
| Max  | .7621     |
| Min  | .7621     |
| Avg  | .7621     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014079 / PIMPRI KOLANDAR

Feeder No / Name : 209 / 11 KV UKKADGOAN  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014079 / PIMPRI KOLANDAR

Feeder No / Name : 210 / 11 KV ARANGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014087 / 33/11KV CHIMBHALE

Feeder No / Name : 202 / 11KV HANGEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.8959    |
| Max  | 2.8959    |
| Min  | 2.8959    |
| Avg  | 2.8959    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014087 / 33/11KV CHIMBHALE

Feeder No / Name : 203 / 11KV CHIMBHALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.8197    |
| Max  | 2.8197    |
| Min  | 2.8197    |
| Avg  | 2.8197    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014089 / 33/11 kV PARGAON

Feeder No / Name : 205 / 11 K V Bhanali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0178    |
| Max  | 3.0178    |
| Min  | 3.0178    |
| Avg  | 3.0178    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014089 / 33/11 kV PARGAON

Feeder No / Name : 207 / 11 KV Surodi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014090 / 33/11KV VISAPUR

Feeder No / Name : 203 / 11KV UKKHALGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014090 / 33/11KV VISAPUR

Feeder No / Name : 205 / 11 KV VISAPUR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

BELWANDI S/DN.[759] BU 4759

Substation No/ Name :- 014090 / 33/11KV VISAPUR

Feeder No / Name : 207 / 11 kv Chambhurdi GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.0483    |
| Max  | 3.0483    |
| Min  | 3.0483    |
| Avg  | 3.0483    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 201 / JAMKHED U-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    |           | 1.0562    |           |           |           | 1.0185    |           |
| 7    |           |           |           |           |           | 1.773     |           |
| 9    | 1.7353    |           | 1.6975    | 1.6244    | 1.9427    | 1.7924    | 1.7737    |
| 12   |           |           |           | 1.1949    |           |           |           |
| 15   | 1.0456    |           | 1.2323    |           |           |           |           |
| 17   |           |           | 1.419     |           |           |           |           |
| 20   | 1.6804    |           |           |           |           |           |           |
| 21   | 1.386     |           |           |           |           |           |           |
| 24   | .8775     |           |           | 1.4784    |           | .8962     | .9149     |
| Max  | 1.7353    | 1.0562    | 1.6975    | 1.6244    | 1.9427    | 1.7924    | 1.7737    |
| Min  | .8775     | 1.0562    | 1.2323    | 1.1949    | 1.9427    | .8962     | .9149     |
| Avg  | 1.3450    | 1.0562    | 1.4496    | 1.4326    | 1.9427    | 1.3700    | 1.3443    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 202 / SAKAT AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    |           | 1.2186    |           |           |           | .4054     |           |
| 7    |           |           |           |           |           | .5937     |           |
| 9    | 1.6575    |           | 1.5729    | 1.387     | 1.4251    | .5792     |           |
| 12   |           |           |           | .6706     |           |           |           |
| 15   | .9556     |           | .788      |           |           |           |           |
| 17   |           |           | .8048     |           |           |           |           |
| 20   | .1143     |           |           |           |           |           |           |
| 21   | .1334     |           |           |           |           |           |           |
| 24   | 1.2163    |           |           | .2096     |           | .2629     | .6249     |
| Max  | 1.6575    | 1.2186    | 1.5729    | 1.387     | 1.4251    | .5937     | .6249     |
| Min  | .1143     | 1.2186    | .788      | .2096     | 1.4251    | .2629     | .6249     |
| Avg  | .8154     | 1.2186    | 1.0552    | .7557     | 1.4251    | .4603     | .6249     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 203 / PADALI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    |           | .9907     |           |           |           | .0572     |           |
| 9    | 1.6766    |           | 1.7909    | 1.6956    | 1.829     |           | .0572     |
| 17   |           |           | .0381     |           |           |           |           |
| 20   | .0762     |           |           |           |           |           |           |
| 21   | .0953     |           |           |           |           |           |           |
| 24   | .7621     |           |           | .0572     |           | .0572     | .0572     |
| Max  | 1.6766    | .9907     | 1.7909    | 1.6956    | 1.829     | .0572     | .0572     |
| Min  | .0762     | .9907     | .0381     | .0572     | 1.829     | .0572     | .0572     |
| Avg  | .6526     | .9907     | .9145     | .8764     | 1.829     | .0572     | .0572     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 204 / RAJURI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    |           | .0972     |           |           | 1.3123    |           |
| 7    |           |           |           |           | 1.9113    |           |
| 9    |           |           |           |           | 1.6604    | 2.2801    |
| 12   |           |           |           | 2.649     |           |           |
| 15   | 3.152     |           | 3.083     |           |           |           |
| 17   |           |           | 2.9843    |           |           |           |
| 20   | .0869     |           |           |           |           |           |
| 21   | .0812     |           |           |           |           |           |
| 24   | .0937     |           |           | .0945     | 1.1111    | 1.4083    |
| Max  | 3.152     | .0972     | 3.083     | 2.649     | 1.9113    | 2.2801    |
| Min  | .0812     | .0972     | 2.9843    | .0945     | 1.1111    | 1.4083    |
| Avg  | .8535     | .0972     | 3.0337    | 1.3718    | 1.4988    | 1.8442    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 205 / JAMKHED U - 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    |           | .6979     |           |           |           | .8589     |           |
| 7    |           |           |           |           |           | 1.358     |           |
| 9    | 1.2071    |           |           | 1.1203    | 1.2696    | 1.2803    | 1.2323    |
| 12   |           |           |           | .8688     |           |           |           |
| 15   | .7796     |           | .7762     |           |           |           |           |
| 17   |           |           | .8779     |           |           |           |           |
| 20   | 1.1458    |           |           |           |           |           |           |
| 21   | 1.0608    |           |           |           |           |           |           |
| 24   | .7095     |           |           | 1.086     |           | .7682     | .7655     |
| Max  | 1.2071    | .6979     | .8779     | 1.1203    | 1.2696    | 1.358     | 1.2323    |
| Min  | .7095     | .6979     | .7762     | .8688     | 1.2696    | .7682     | .7655     |
| Avg  | .9806     | .6979     | .8271     | 1.0250    | 1.2696    | 1.0664    | .9989     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 206 / SAKAT GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    |           | .7842     |           |           |           | .7655     |           |
| 9    | 1.0082    |           | .7964     | 1.1888    | 1.2883    | .8402     | 1.1576    |
| 12   |           |           |           | .4066     |           |           |           |
| 15   | .4382     |           | .2587     |           |           |           |           |
| 17   |           |           | .4435     |           |           |           |           |
| 20   | 1.0082    |           |           |           |           |           |           |
| 21   | .4251     |           |           |           |           |           |           |
| 24   | .2054     |           |           | .5304     |           | .2926     | .3142     |
| Max  | 1.0082    | .7842     | .7964     | 1.1888    | 1.2883    | .8402     | 1.1576    |
| Min  | .2054     | .7842     | .2587     | .4066     | 1.2883    | .2926     | .3142     |
| Avg  | .6170     | .7842     | .4995     | .7086     | 1.2883    | .6328     | .7359     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 207 / RAJURI + PADALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    |           | .8299     |           |           |           | .5731     |           |
| 9    | .961      |           | .9055     | .6287     | .3544     | .6121     | .6097     |
| 11   |           |           |           |           | .3544     |           |           |
| 12   |           |           |           | .2138     |           |           |           |
| 15   |           |           | .2957     |           |           |           |           |
| 17   |           |           | .3326     |           |           |           |           |
| 20   | .8686     |           |           |           |           |           |           |
| 21   | .5914     |           |           |           |           |           |           |
| 24   | 1.9166    |           |           |           |           | .216      | .2521     |
| Max  | 1.9166    | .8299     | .9055     | .6287     | .3544     | .6121     | .6097     |
| Min  | .5914     | .8299     | .2957     | .2138     | .3544     | .216      | .2521     |
| Avg  | 1.0844    | .8299     | .5113     | .4213     | .3544     | .4671     | .4309     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014054 / 33 KV JAMKHED

Feeder No / Name : 208 / BHUTWADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 5    |           | .1334     |           |           |           |           |
| 9    | .0953     |           |           |           |           |           |
| 15   | 2.5774    |           | 2.1365    |           |           |           |
| 17   |           |           | 2.2382    |           |           |           |
| 20   | .1905     |           |           |           |           |           |
| 21   | .1905     |           |           |           |           |           |
| 24   | .0953     |           |           | .112      | .3201     | .8069     |
| Max  | 2.5774    | .1334     | 2.2382    | .112      | .3201     | .8069     |
| Min  | .0953     | .1334     | 2.1365    | .112      | .3201     | .8069     |
| Avg  | .6298     | .1334     | 2.1874    | .112      | .3201     | .8069     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 201 / JAWALA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1143     | .1326     | .1303     | .1311     | .1303     |           |           |
| 2    | .1143     | .1326     | .1286     | .1296     | .1303     |           |           |
| 3    | .1158     | .1311     | .1448     | .1311     | .1448     |           |           |
| 4    | .1448     | .1638     | .1738     | .1781     |           |           |           |
| 5    |           | .1943     | .1858     | .2105     | .1738     |           |           |
| 6    | .2172     | .2591     | .2143     | .2591     | .2172     |           |           |
| 9    |           | .3563     | .1715     | .3239     |           | .2286     | .3113     |
| 10   |           |           |           |           |           | .1966     | .2172     |
| 11   | .1981     |           |           |           | .2134     | .1638     | .1882     |
| 12   |           |           |           |           |           | .1638     | .1738     |
| 13   | .1524     |           |           |           |           | .1296     | .1448     |
| 14   |           | .1524     |           |           |           | .1296     | .1429     |
| 15   | .1524     |           |           |           |           | .1134     | .1448     |
| 16   | .1524     | .1219     | .1219     |           | .1524     | .1134     |           |
| 17   | .1619     | .1448     | .1619     |           |           | .1296     |           |
| 18   | .1943     | .1738     | .1943     |           |           | .1134     |           |
| 19   | .2984     | .2027     | .213      |           |           | .2429     |           |
| 20   |           | .2172     |           |           |           |           | .2286     |
| 21   |           | .2        |           |           |           |           |           |
| 22   |           | .1882     |           |           |           |           |           |
| 23   | .1638     | .1715     |           |           | .1829     | .1134     | .1829     |
| 24   | .2362     | .1326     | .2838     | .1715     | .1448     |           |           |
| Max  | .2984     | .3563     | .2838     | .3239     | .2172     | .2429     | .3113     |
| Min  | .1143     | .1219     | .1219     | .1296     | .1303     | .1134     | .1429     |
| Avg  | .1726     | .1809     | .177      | .1919     | .1655     | .1532     | .1927     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 202 / NANAJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5432    |
| Max  | 1.5432    |
| Min  | 1.5432    |
| Avg  | 1.5432    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 203 / JAWALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           |           |           | 1.6004    | 2.1862    |
| 13   | 1.6671    |           |           |           |           |           |
| 14   |           | 1.6004    |           |           |           |           |
| 15   | 1.6004    |           |           |           |           |           |
| 16   | 1.7528    | 1.6004    | 1.6004    | 1.6671    |           |           |
| 17   | 2.1052    | 1.8823    | 2.4291    |           |           |           |
| 18   | 1.7814    | 1.8099    | 2.2672    |           |           |           |
| 19   | 1.8023    | 1.8099    | 2.1052    |           |           |           |
| 20   |           |           |           |           |           | .1524     |
| 23   | .1677     |           | .1619     | .1524     | .1457     | .1334     |
| 24   | .1524     |           |           | .1158     |           |           |
| Max  | 2.1052    | 1.8823    | 2.4291    | 1.6671    | 1.6004    | 2.1862    |
| Min  | .1524     | 1.6004    | .1619     | .1158     | .1457     | .1334     |
| Avg  | 1.3787    | 1.7406    | 1.7128    | .6451     | .8731     | .824      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 204 / HALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           |           |           |           | 2.672     |
| 13   | 2.1338    |           |           |           |           |           |
| 14   |           | 1.7337    |           |           |           |           |
| 15   | 1.7337    |           |           |           |           |           |
| 16   | 1.8004    | 1.8004    | 1.8004    | .3048     |           |           |
| 17   | 1.5384    | .2896     | 2.0243    |           |           |           |
| 18   | 1.6804    | 2.0995    | 1.9433    |           |           |           |
| 19   | 1.9433    | 1.8823    | 1.4575    |           |           |           |
| 20   |           |           |           |           |           | .1524     |
| 23   | .1326     |           | .1296     | .1524     | .1296     | .1334     |
| 24   | .1067     |           |           | .1014     |           |           |
| Max  | 2.1338    | 2.0995    | 2.0243    | .3048     | .1296     | 2.672     |
| Min  | .1067     | .2896     | .1296     | .1014     | .1296     | .1334     |
| Avg  | 1.3837    | 1.5611    | 1.4710    | .1862     | .1296     | .9859     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 205 / NANNAJ GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3144     | .3605     | .3144     | .3605     | .3185     |           |           |
| 2    | .3185     | .3605     | .3144     | .3605     | .3185     |           |           |
| 3    | .0343     | .3605     | .3429     | .3605     | .0357     |           |           |
| 4    | .4001     | .426      | .4633     | .426      | .4054     |           |           |
| 5    | .4633     | .4858     | .4572     | .4915     | .5068     |           |           |
| 6    | .5068     | .5735     | .543      | .5668     | .5792     |           |           |
| 9    |           | .4858     | .4287     | .5735     |           | .5335     | .5668     |
| 10   |           |           |           |           |           | .4858     | .4344     |
| 11   |           |           | .4572     |           | .4572     | .421      | .2896     |
| 12   |           |           |           |           |           | .3887     | .2896     |
| 13   | .3048     |           |           |           |           | .3563     | .3185     |
| 14   |           | .3048     |           |           |           | .3239     | .3765     |
| 15   | .3048     |           |           |           |           | .3239     | .3475     |
| 16   |           |           | .3048     |           | .3048     |           |           |
| 17   | .3563     | .2858     | .3605     |           |           |           |           |
| 18   | .4049     | .362      | .4049     |           |           |           |           |
| 19   | .5735     | .4001     |           |           |           |           |           |
| 20   |           | .5068     |           |           |           |           | .5335     |
| 21   |           | .543      |           |           |           |           |           |
| 22   |           | .5001     |           |           |           |           |           |
| 23   | .3647     | .4344     |           |           | .4572     | .3887     | .4572     |
| 24   | .3429     | .3605     | .3605     | .3605     | .3185     |           |           |
| Max  | .5735     | .5735     | .543      | .5735     | .5792     | .5335     | .5668     |
| Min  | .0343     | .2858     | .3048     | .3605     | .0357     | .3239     | .2896     |
| Avg  | .3607     | .4219     | .3960     | .4375     | .3702     | .4027     | .4015     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 206 / AGHI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .0335     | .0286     | .0332     | .029      |           |           |
| 2    |           | .0335     |           | .0328     |           |           |           |
| 3    | .0434     | .0335     |           | .0332     | .0286     |           |           |
| 4    |           | .0328     | .0429     | .0328     |           |           |           |
| 5    |           | .0328     |           | .0332     |           |           |           |
| 6    | .0434     | .0791     | .0429     | .0797     | .0739     |           |           |
| 9    |           | .0492     | .0286     | .0486     |           | .0457     | .0497     |
| 10   |           |           |           | .0305     | .0305     | .0332     | .0739     |
| 11   |           |           |           |           | .0305     | .0332     | .029      |
| 12   |           |           |           |           |           | .0332     | .029      |
| 13   | .0305     |           |           |           |           | .0332     | .029      |
| 14   |           | .0305     |           |           |           | .0332     | .029      |
| 15   | .0305     |           |           |           |           | .0328     | .029      |
| 16   |           | .0305     | .0305     |           | 7.8037    | .0328     |           |
| 17   | .0332     |           | .0332     |           |           | .0328     |           |
| 18   | .0332     |           | .0328     |           |           | .0328     |           |
| 19   | .0497     | .0429     | .0324     |           |           | .0492     |           |
| 20   |           |           | .061      | .061      |           | .061      | .0457     |
| 21   |           | .0734     | .0305     | .061      |           | .0305     |           |
| 22   |           |           | .0305     |           |           |           |           |
| 23   | .0335     | .0434     | .0324     |           | .0305     | .0328     | .0305     |
| 24   | .029      | .0335     | .0286     | .0332     | .029      |           |           |
| Max  | .0497     | .0791     | .061      | .0797     | 7.8037    | .061      | .0739     |
| Min  | .029      | .0305     | .0286     | .0305     | .0286     | .0305     | .029      |
| Avg  | .0363     | .0422     | .0350     | .0436     | 1.0070    | .0369     | .0383     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014065 / 33/11 KV JAWALA S/STN

Feeder No / Name : 207 / PARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2896     | .4144     | .6081     | .6554     | .6516     |           |           |
| 2    | .2896     | .4144     | .6081     | .6554     | .6661     |           |           |
| 3    | .3144     | .4096     | .6516     | .6554     | .695      |           |           |
| 4    | .4054     | .4915     | .695      | .8907     | .743      |           |           |
| 5    | .5068     | .5735     | .7529     | .9717     | .8688     |           |           |
| 6    | .5716     | .6478     | .8688     | 1.2146    | .9412     |           |           |
| 7    | .724      | .9717     | 1.286     | 1.7204    | 1.3032    |           |           |
| 8    | .8573     | .8907     | 1.5718    |           | 1.6651    |           |           |
| 9    |           | .8097     | 1.5003    | 1.7204    |           |           |           |
| 12   |           |           |           |           |           | 1.3765    | 1.286     |
| 13   |           |           |           |           |           | 1.7814    | 1.5927    |
| 14   |           |           |           |           |           | 1.7814    | .181      |
| 15   |           |           |           |           |           | 1.6194    | 1.5003    |
| 16   |           |           |           |           |           | 1.6194    |           |
| 17   |           |           |           |           |           | 1.7204    |           |
| 18   |           |           |           |           |           | 1.6194    |           |
| 19   |           |           |           |           |           | 1.4575    |           |
| 20   |           |           |           |           |           |           | .1524     |
| 23   | .0663     |           | .0983     |           | .1334     | .1311     | .1334     |
| 24   | .2606     | .4144     | .5716     | 1.9433    | .6001     |           |           |
| Max  | .8573     | .9717     | 1.5718    | 1.9433    | 1.6651    | 1.7814    | 1.5927    |
| Min  | .0663     | .4096     | .0983     | .6554     | .1334     | .1311     | .1334     |
| Avg  | .4286     | .6038     | .8375     | 1.1586    | .8268     | 1.4563    | .8076     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 201 / KHARDA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3117     | .2949     | .3163     | .3117     | .298      | .2957     | .3041     |
| 2    | .3216     | .2911     | .3125     | .3048     | .3086     | .2987     | .3094     |
| 3    | .3277     | .3056     | .3254     | .3269     | .3125     | .3147     | .3193     |
| 4    | .3871     | .346      | .3574     | .3597     | .3467     | .3567     | .3643     |
| 5    | .4984     | .4694     | .4832     | .4885     | .4672     | .4915     | .4572     |
| 6    | .8215     | .8109     | .7918     | .772      | .7773     | .7796     | .8109     |
| 7    | .929      | .9701     | .9572     | .9465     | .9496     | .9762     | .9755     |
| 8    | .9389     | .9983     | .9556     | 1.7665    | 1.8747    | 1.8991    | .9747     |
| 9    | .8749     | .9153     | .9092     | .8451     | .8924     | .8779     | .9046     |
| 10   | .7636     | .7514     | .7872     | .7354     | .8032     | .7712     | .7575     |
| 11   | .5838     | .6135     | .599      | .5838     | .6622     |           | .5998     |
| 12   | .4679     | .49       | .4786     | .5037     | .4633     |           | .4496     |
| 13   | .4115     | .4031     | .4809     | .4534     | .4451     | .6104     | .4207     |
| 14   | .4054     | .4146     | .4176     | .3856     | .3742     | .538      | .3978     |
| 15   | .3925     | .4054     | .3948     | .3704     | .3506     | .4313     | .3551     |
| 16   | .4001     | .4146     | .4138     | .3887     | .3536     | .4565     | .3521     |
| 17   | .8078     | .4359     | .4504     | .8513     | .4611     | .49       | .7596     |
| 18   | .5426     | .4496     | .4976     | .5975     | .5335     | .5563     | .5053     |
| 19   | 1.5592    | .8238     | .7819     | .775      | .7522     | .807      | .7537     |
| 20   | .7849     | .7948     | .8002     | .7667     | .7362     | .7179     | .7781     |
| 21   | .6226     | .6615     | .6302     | .6165     | 1.1186    | .6409     | .6531     |
| 22   | .5319     | 1.0593    | .5319     | .5075     | .4908     | .5502     | .5121     |
| 23   | .4054     | .4169     | .4123     | .4054     | .3955     | .3986     | .4222     |
| 24   | .7598     | .3445     | .6188     | .333      | .6195     | .3224     | .3277     |
| Max  | 1.5592    | 1.0593    | .9572     | 1.7665    | 1.8747    | 1.8991    | .9755     |
| Min  | .3117     | .2911     | .3125     | .3048     | .298      | .2957     | .3041     |
| Avg  | .6187     | .5784     | .5710     | .5998     | .6161     | .6173     | .5610     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 202 / SATEFAL GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .2591     |           | .2439     | .2591     |
| 2    |           |           |           | .2743     |           | .2286     | .2743     |
| 3    |           |           |           | .2743     |           | .2439     | .2743     |
| 4    |           |           |           | .3048     | .3048     | .2896     | .3048     |
| 5    |           |           |           | .381      | .381      | .3658     | .381      |
| 6    |           |           |           | .6249     | .5944     | .5335     | .6097     |
| 7    |           |           |           | .8078     | .7773     | .7773     | .6554     |
| 8    |           |           |           | 1.4037    | 1.6065    | 1.4236    |           |
| 9    |           |           |           | .6859     | .7926     | .7011     |           |
| 10   |           |           | .1677     | .5792     | .6859     |           | .5487     |
| 11   |           |           |           |           | .4877     |           |           |
| 12   |           |           | .2591     | .3506     | .381      |           |           |
| 13   |           |           | .2743     |           | .2439     | 3.8866    |           |
| 14   |           |           | .2896     |           | .2286     | .2439     |           |
| 15   |           |           | .2896     |           | .2286     | .2743     |           |
| 16   |           |           | .2591     |           | .2134     | .2439     |           |
| 17   |           |           | .3506     | .2957     | .2591     | .2591     | .2103     |
| 18   |           |           | .3658     |           | .3353     | .4115     |           |
| 19   | .6653     |           | .3658     |           | .3963     | .503      |           |
| 20   |           |           | .6097     |           | .6249     | .6706     |           |
| 21   |           |           | .5792     |           | .8863     | .5487     |           |
| 22   |           | .4161     | .4115     |           | .3658     | .4115     |           |
| 23   |           |           | .3353     |           | .3048     | .3353     |           |
| 24   |           |           | .5022     |           | .442      | .2591     |           |
| Max  | .6653     | .4161     | .6097     | 1.4037    | 1.6065    | 3.8866    | .6554     |
| Min  | .6653     | .4161     | .1677     | .2591     | .2134     | .2286     | .2103     |
| Avg  | .6653     | .4161     | .3614     | .5201     | .5019     | .6121     | .3908     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 204 / SONEGON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 17   | 2.4034    | 2.9835    |
| 19   | 1.8067    |           |
| 24   | 1.5432    |           |
| Max  | 2.4034    | 2.9835    |
| Min  | 1.5432    | 2.9835    |
| Avg  | 1.9178    | 2.9835    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 205 / TELANGSHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    |           |           | 3.0967    |           |
| 8    |           | 3.3998    |           |           |
| 17   |           |           |           | 1.8747    |
| 24   | 2.0873    |           | 1.873     |           |
| Max  | 2.0873    | 3.3998    | 3.0967    | 1.8747    |
| Min  | 2.0873    | 3.3998    | 1.873     | 1.8747    |
| Avg  | 2.0873    | 3.3998    | 2.4849    | 1.8747    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 206 / SATEFAL AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 17   |           | 2.2939    |
| 19   | 1.8233    |           |
| 24   | 1.5432    |           |
| Max  | 1.8233    | 2.2939    |
| Min  | 1.5432    | 2.2939    |
| Avg  | 1.6833    | 2.2939    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 207 / JATEGON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 8    | 1.25      | 2.2211    |           |
| 17   |           |           | 2.1759    |
| 24   |           | .9448     |           |
| Max  | 1.25      | 2.2211    | 2.1759    |
| Min  | 1.25      | .9448     | 2.1759    |
| Avg  | 1.25      | 1.5830    | 2.1759    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 208 / LONI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 17   |           | 3.0167    |           |
| 19   | 2.7183    |           |           |
| 21   |           |           | 1.3916    |
| 24   | 1.5432    |           |           |
| Max  | 2.7183    | 3.0167    | 1.3916    |
| Min  | 1.5432    | 3.0167    | 1.3916    |
| Avg  | 2.1308    | 3.0167    | 1.3916    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014075 / 33 KV KHARDA

Feeder No / Name : 209 / ANANDWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 19   | 1.6243    |           |           |           |
| 22   |           | .9568     |           |           |
| 24   | 1.5432    |           | .7442     | .9055     |
| Max  | 1.6243    | .9568     | .7442     | .9055     |
| Min  | 1.5432    | .9568     | .7442     | .9055     |
| Avg  | 1.5838    | .9568     | .7442     | .9055     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014083 / 33 KV ARANGAOAN

Feeder No / Name : 201 / PATODA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 2.1338    | 2.2862    | 2.3148    | 1.8519    | .2401     | .2572     |
| 24   | 1.5432    |           |           |           |           |           |           |
| Max  | 1.5432    | 2.1338    | 2.2862    | 2.3148    | 1.8519    | .2401     | .2572     |
| Min  | 1.5432    | 2.1338    | 2.2862    | 2.3148    | 1.8519    | .2401     | .2572     |
| Avg  | 1.5432    | 2.1338    | 2.2862    | 2.3148    | 1.8519    | .2401     | .2572     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014083 / 33 KV ARANGAOAN

Feeder No / Name : 202 / ARANGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2572     | .2134     | .2229     | .2229     | .2401     | .0857     | 2.8978    |
| 24   | 3.0864    |           |           |           |           |           |           |
| Max  | 3.0864    | .2134     | .2229     | .2229     | .2401     | .0857     | 2.8978    |
| Min  | .2572     | .2134     | .2229     | .2229     | .2401     | .0857     | 2.8978    |
| Avg  | 1.6718    | .2134     | .2229     | .2229     | .2401     | .0857     | 2.8978    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014083 / 33 KV ARANGAOAN

Feeder No / Name : 203 / ARANGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1543     | .1715     | .1524     | .181      | .1543     | .1715     | .1715     |
| Max  | .1543     | .1715     | .1524     | .181      | .1543     | .1715     | .1715     |
| Min  | .1543     | .1715     | .1524     | .181      | .1543     | .1715     | .1715     |
| Avg  | .1543     | .1715     | .1524     | .181      | .1543     | .1715     | .1715     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014083 / 33 KV ARANGAOAN

Feeder No / Name : 204 / PATODA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1867     |
| Max  | .1867     |
| Min  | .1867     |
| Avg  | .1867     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014083 / 33 KV ARANGAOAN

Feeder No / Name : 205 / PIMPARKHED AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .3018     | .3018     | .2896     | .2743     | 2.3663    |
| 12   | 2.4215    |           |           |           |           |           |
| Max  | 2.4215    | .3018     | .3018     | .2896     | .2743     | 2.3663    |
| Min  | 2.4215    | .3018     | .3018     | .2896     | .2743     | 2.3663    |
| Avg  | 2.4215    | .3018     | .3018     | .2896     | .2743     | 2.3663    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198] BU 5711

Substation No/ Name :- 014083 / 33 KV ARANGAOAN

Feeder No / Name : 206 / DHONARA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3734     |
| Max  | .3734     |
| Min  | .3734     |
| Avg  | .3734     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014120 / 33/11 KV RAJURI

Feeder No / Name : 201 / RAJURI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0191     | .0191     | .0191     | .0191     | .0179     | .0179     | .0175     |
| 2    | .0191     | .0191     | .0191     | .0179     | .0177     | .0173     | .0181     |
| 3    | .0191     | .0191     | .0191     | .0191     | .0191     | .0177     | .0185     |
| 4    | .0191     | .0191     | .0191     | .0191     | .0179     | .0173     | .0187     |
| 5    | .0191     | .0191     | .0191     | .0179     | .0191     |           | .0187     |
| 6    | .0191     | .0191     | .0191     | .0185     | .0191     | .0191     | .0191     |
| 7    | .0191     | .0191     | .0191     | .0185     | .0381     | .0187     | .0187     |
| 8    | .0191     | .0191     | .0191     | .0179     | .0366     | .0185     | .0179     |
| 9    | .0191     | .0191     | .0191     | .0177     | .0185     | .0191     | .0373     |
| 10   | .0191     | .0191     | .0191     | .0179     | .0185     | .0183     | .0181     |
| 11   | .0191     | .0191     | .0191     | .0179     | .0185     | .0181     | .0171     |
| 12   | .0191     | .0191     | .0191     | .0181     | .0191     | .0179     | .0179     |
| 13   | .0191     | .0191     | .0191     | .0179     | .0191     | .0191     | .0181     |
| 14   | .0191     | .0191     | .0191     |           | .0191     |           | .0191     |
| 15   | .0191     | .0191     | .0191     | .0175     | .0175     |           | .0177     |
| 16   | .0191     | .0191     |           | .0191     | .0191     | .0191     | .0179     |
| 17   | .0191     | .0191     | .0177     | .0171     | .0171     | .0191     | .0177     |
| 18   | .0191     | .0191     | .0183     | .0191     | .0171     | .0181     | .0179     |
| 19   | .0191     | .0191     | .0185     | .0183     | .0171     | .0166     | .0177     |
| 20   | .0191     | .0191     | .0185     | .0191     | .0173     | .0168     | .0177     |
| 21   | .0191     | .0191     | .1048     | .0173     | .0162     | .0173     | .0162     |
| 22   | .0191     | .0191     | .0191     | .0191     | .0171     | .0171     | .0162     |
| 23   | .0191     | .0191     | .0191     | .0177     | .0175     | .0175     | .0168     |
| 24   | .3677     | .0191     | .0191     | .0179     | .0191     | .0179     | .0185     |
| Max  | .3677     | .0191     | .1048     | .0191     | .0381     | .0191     | .0373     |
| Min  | .0191     | .0191     | .0177     | .0171     | .0162     | .0166     | .0162     |
| Avg  | .0336     | .0191     | .0227     | .0182     | .0197     | .0180     | .0187     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014120 / 33/11 KV RAJURI

Feeder No / Name : 202 / RAJURI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1334     | .1143     | .1143     | .1143     |           | .2896     | .2429     |
| 2    | .1334     | .1143     | .1143     | .1143     | .1143     | .2896     | .2743     |
| 3    |           | .1334     | .1334     | .1334     | .1143     | .3395     | .4167     |
| 4    |           |           |           |           |           | .4049     | .4938     |
| 5    |           |           |           |           |           | .4725     | .6249     |
| 6    |           |           |           |           |           | .5693     | .9259     |
| 7    |           |           |           |           |           | .9804     | 1.2654    |
| 8    |           |           |           |           |           | 1.6356    | 1.6213    |
| 9    |           |           |           |           |           | 1.3272    | 1.6129    |
| 12   | 1.8343    | 1.5466    | 1.2654    | 1.2037    | 1.3546    |           |           |
| 13   | 1.9433    | 1.6404    | 1.5623    | 1.4506    | 1.6091    |           |           |
| 14   | 1.7654    | 1.656     | 1.5779    | 1.406     | 1.6406    |           |           |
| 15   | 1.7185    | 1.4661    | 1.4198    | .8078     | 1.448     |           |           |
| 16   | 1.5895    | 1.4506    | 1.3413    | 1.4548    | 1.4327    |           |           |
| 17   | 1.3717    | 1.0364    | 1.2742    | 1.4175    | 1.2498    |           |           |
| 18   | .9482     | 1.1736    | 1.1126    | 1.1584    | 1.2498    |           |           |
| 19   | .8173     | 1.0084    | .8509     | .8383     | .9783     | .1905     | .1334     |
| 20   | .2096     | .1524     | .2286     | .1905     |           | .2096     | .2096     |
| 21   | .1715     | .1905     | .1715     | .1524     | .2096     | .1524     | .1334     |
| 22   | .1524     | .1524     | .1715     | .1524     | .1143     | .1524     | .1143     |
| 23   | .1143     | .1143     | .1334     | .1143     | .1143     | .0185     | .0953     |
| 24   | .5144     | .1143     | .1143     | .1143     | .1143     | .3077     | .2286     |
| Max  | 1.9433    | 1.656     | 1.5779    | 1.4548    | 1.6406    | 1.6356    | 1.6213    |
| Min  | .1143     | .1143     | .1143     | .1143     | .1143     | .0185     | .0953     |
| Avg  | .8945     | .754      | .7241     | .6764     | .8389     | .4893     | .5595     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

JAMKHED[198]

BU 5711

Substation No/ Name :- 014120 / 33/11 KV RAJURI

Feeder No / Name : 203 / GHODEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .8383     | .8642     | .7011     | .7562     | .0924     | .0876     |
| 2    | .8078     | .8535     | .8642     | .7164     | .7773     | .0905     | .0886     |
| 3    | .823      | .8796     | .8951     | .7562     | .8488     | .0914     | .0924     |
| 4    | .8535     | .9105     | .9172     | .7907     | .9172     |           |           |
| 5    | .9181     | 1.0155    | .9717     | .8223     | .9922     |           |           |
| 6    | 1.0031    | 1.2186    | 1.1385    | .9332     | 1.1174    |           |           |
| 7    | 1.6933    | 1.6164    | 1.6484    | 1.4083    | 1.3413    |           |           |
| 8    | 1.6004    | 1.7497    | 1.7924    | 1.5655    | 1.5352    |           |           |
| 9    | 1.6004    | 1.7236    | 1.1561    | .5792     | 1.3546    |           |           |
| 12   |           |           |           |           |           | 1.6518    | 1.7004    |
| 13   |           |           |           |           |           | 1.917     | 1.9334    |
| 14   |           |           |           |           |           | 1.8138    | 1.9109    |
| 15   |           |           |           |           |           | 1.9364    | 1.8785    |
| 16   |           |           |           |           |           | 1.9685    | 1.7004    |
| 17   |           |           |           |           |           | 1.0974    | 1.7695    |
| 18   |           |           |           |           |           | 1.6032    | 1.7204    |
| 19   | .1143     | .0953     | .1307     | .1494     | .1063     | 1.6032    | 1.5223    |
| 20   | .1524     | .0953     | .1478     | .168      | .1063     | .1063     | .1227     |
| 21   | .1334     | .1143     | .1866     | .1267     | .1109     | .0924     | .0905     |
| 22   | .1143     | .0953     | .0895     | .1063     | .1063     | .1097     | .0914     |
| 23   | .0953     | .0762     | .0914     | .0709     | .1086     | .1097     | .0924     |
| 24   | 1.1202    | .8592     | .8642     | .6944     | .7164     | .0953     | .0905     |
| Max  | 1.6933    | 1.7497    | 1.7924    | 1.5655    | 1.5352    | 1.9685    | 1.9334    |
| Min  | .0953     | .0762     | .0895     | .0709     | .1063     | .0905     | .0876     |
| Avg  | .7878     | .8094     | .7839     | .6392     | .7263     | .8987     | .9307     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 201 / KARJAT URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .5487     | .543      | .5544     | .5258     | .543      | .5487     |
| Max  | .5487     | .543      | .5544     | .5258     | .543      | .5487     |
| Min  | .5487     | .543      | .5544     | .5258     | .543      | .5487     |
| Avg  | .5487     | .543      | .5544     | .5258     | .543      | .5487     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 202 / BABULGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .362      | .3189     | .3294     | .3189     | .3258     |
| Max  | .362      | .3189     | .3294     | .3189     | .3258     |
| Min  | .362      | .3189     | .3294     | .3189     | .3258     |
| Avg  | .362      | .3189     | .3294     | .3189     | .3258     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 203 / DURAGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .8573     | .8383     | .8383     | 1.0174    | 1.0174    | 1.7147    |
| Max  | .8573     | .8383     | .8383     | 1.0174    | 1.0174    | 1.7147    |
| Min  | .8573     | .8383     | .8383     | 1.0174    | 1.0174    | 1.7147    |
| Avg  | .8573     | .8383     | .8383     | 1.0174    | 1.0174    | 1.7147    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 204 / NANADGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .4382     | .4382     | .4287     | .3814     | .4334     | .4161     |
| Max  | .4382     | .4382     | .4287     | .3814     | .4334     | .4161     |
| Min  | .4382     | .4382     | .4287     | .3814     | .4334     | .4161     |
| Avg  | .4382     | .4382     | .4287     | .3814     | .4334     | .4161     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 205 / KOREGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.829     |
| Max  | 1.829     |
| Min  | 1.829     |
| Avg  | 1.829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 206 / CHAPADGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1829     |
| Max  | .1829     |
| Min  | .1829     |
| Avg  | .1829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 207 / MAHIJALGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .116      | .0972     | .1187     | .0995     | .0857     | .6203     |
| Max  | .116      | .0972     | .1187     | .0995     | .0857     | .6203     |
| Min  | .116      | .0972     | .1187     | .0995     | .0857     | .6203     |
| Avg  | .116      | .0972     | .1187     | .0995     | .0857     | .6203     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 208 / CHAPADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .6562     | .5468     | .5312     | .4744     | .5937     | .1562     |
| Max  | .6562     | .5468     | .5312     | .4744     | .5937     | .1562     |
| Min  | .6562     | .5468     | .5312     | .4744     | .5937     | .1562     |
| Avg  | .6562     | .5468     | .5312     | .4744     | .5937     | .1562     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 209 / KOREGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .1715     | .1696     | .1696     | .1526     | .1715     | .4287     |
| Max  | .1715     | .1696     | .1696     | .1526     | .1715     | .4287     |
| Min  | .1715     | .1696     | .1696     | .1526     | .1715     | .4287     |
| Avg  | .1715     | .1696     | .1696     | .1526     | .1715     | .4287     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 210 / NANDGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | 1.3565    | 1.5089    | 1.3413    | 1.4918    | 1.3108    | .5087     |
| Max  | 1.3565    | 1.5089    | 1.3413    | 1.4918    | 1.3108    | .5087     |
| Min  | 1.3565    | 1.5089    | 1.3413    | 1.4918    | 1.3108    | .5087     |
| Avg  | 1.3565    | 1.5089    | 1.3413    | 1.4918    | 1.3108    | .5087     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 212 / BABHULGAON PURE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .2172     | .181      | .1829     | .1696     | .1629     | .5853     |
| Max  | .2172     | .181      | .1829     | .1696     | .1629     | .5853     |
| Min  | .2172     | .181      | .1829     | .1696     | .1629     | .5853     |
| Avg  | .2172     | .181      | .1829     | .1696     | .1629     | .5853     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014053 / KARJAT

Feeder No / Name : 213 / ALSUNDA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 201 / Mirjagaon GFFS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.0566    |           |           | 1.0808    |           | .985      | 1.0745    |
| 7    | 1.2715    | 1.2656    |           |           |           |           | 1.2403    |
| 8    | 1.3253    | 1.1641    |           | 1.1871    |           | 1.2934    | 1.2894    |
| 9    |           |           |           |           | 1.2178    |           | 1.267     |
| 10   |           |           |           |           | 1.0745    |           |           |
| 11   |           |           |           |           | .9593     |           | .8238     |
| 12   |           |           |           |           | .8688     |           | .8326     |
| 13   |           |           |           |           | .724      |           | .823      |
| 14   |           |           |           |           | .6516     |           | .5359     |
| 15   |           |           |           |           | .724      |           | .6697     |
| 16   |           |           |           |           | .6878     |           | .823      |
| 17   | .8954     | .8688     | .8954     |           | .8596     | .8775     |           |
| 18   | .8238     | .9134     | 1.0387    |           |           | .985      |           |
| 19   | 1.1163    | .9492     | 1.1403    |           | 1.1946    | .9955     |           |
| 20   | .9134     | .8954     | .8688     |           | .9412     | 1.0566    |           |
| 21   | .8596     | .8059     | .8596     |           | 1.2226    | .8775     |           |
| 22   | .6154     |           | .7316     |           | .7164     | .5792     |           |
| 23   | .5487     |           | .6036     |           | .567      | .5792     |           |
| 24   | .4938     |           |           | .543      |           | .4805     | .543      |
| Max  | 1.3253    | 1.2656    | 1.1403    | 1.1871    | 1.2226    | 1.2934    | 1.2894    |
| Min  | .4938     | .8059     | .6036     | .543      | .567      | .4805     | .5359     |
| Avg  | .9018     | .9803     | .8769     | .9370     | .8864     | .8709     | .9020     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 202 / BELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .9526     |           |           | .9526     |           | 1.6385    | 1.7147    |
| 7    |           | .9526     |           |           |           |           | 2.915     |
| 8    |           |           |           |           |           | 2.4691    | 2.572     |
| 10   |           |           |           |           | .381      |           |           |
| 11   |           |           |           |           | .381      |           |           |
| 12   |           |           |           |           | 2.7435    |           |           |
| 13   |           |           |           |           | 2.7435    |           |           |
| 14   |           |           |           |           | 2.572     |           |           |
| 15   |           |           |           |           | 2.7435    |           |           |
| 16   |           |           |           |           | 2.572     |           |           |
| 17   | 2.6882    | 3.0102    | 3.0864    |           | 2.2405    | .381      |           |
| 18   | 2.6882    | 2.9321    | 2.7435    |           | 1.5261    |           |           |
| 19   | 2.2672    | 2.2939    | 2.4006    |           | 1.9433    | .9526     |           |
| 20   | .9526     | .5716     | .7621     |           | .7621     | .7621     |           |
| 21   | .7621     | .5716     | .5716     |           | .7621     | .5716     |           |
| 22   | .5716     |           | .381      |           | .381      | .5716     |           |
| 23   | .381      | .381      | .381      |           | .381      | .381      |           |
| 24   | .7621     |           |           | .381      |           | .6706     | .8573     |
| Max  | 2.6882    | 3.0102    | 3.0864    | .9526     | 2.7435    | 2.4691    | 2.915     |
| Min  | .381      | .381      | .381      | .381      | .381      | .381      | .8573     |
| Avg  | 1.3362    | 1.5304    | 1.4752    | .6668     | 1.5809    | .9331     | 2.0148    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 203 / OLD KOMBHLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .6859     |           |           | .5716     |           | .7042     | .9774     |
| 7    |           | .724      |           |           |           |           | 1.6804    |
| 8    |           |           |           |           |           | 1.6766    | 1.5775    |
| 9    |           |           |           |           |           |           | 1.6933    |
| 10   |           |           |           |           | .3429     |           |           |
| 11   |           |           |           |           | .3048     |           | .1905     |
| 12   |           |           |           |           | 1.406     |           | .1905     |
| 13   |           |           |           |           | 1.4575    |           | .1905     |
| 14   |           |           |           |           | 1.4403    |           | .1905     |
| 15   |           |           |           |           | 1.286     |           | .1905     |
| 16   |           |           |           |           | 1.3375    |           | .1905     |
| 17   | 1.5927    | 1.576     | 1.5604    |           | 1.3077    | .1905     |           |
| 18   | 1.4582    | 1.3413    | 1.3717    |           | 1.0402    |           |           |
| 19   | 1.3203    | 1.2209    | 1.0802    |           | 1.1401    | .5144     |           |
| 20   | .6478     | .4001     | .6097     |           | .6097     | .6097     |           |
| 21   |           | .5525     | .5525     |           | .4954     | .5335     |           |
| 22   | .4572     |           | .4763     |           | .4382     | .4191     |           |
| 23   | .4191     | .4001     | .4001     |           | .4001     | .362      |           |
| 24   | .362      |           |           | .3429     |           | .3506     | .4287     |
| Max  | 1.5927    | 1.576     | 1.5604    | .5716     | 1.4575    | 1.6766    | 1.6933    |
| Min  | .362      | .4001     | .4001     | .3429     | .3048     | .1905     | .1905     |
| Avg  | .8679     | .8878     | .8644     | .4573     | .9290     | .5956     | .6818     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 204 / OLD Malthan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.9376    |           |           | 1.8519    |           | .7811     | .8002     |
| 7    | 2.6749    | 2.7027    |           |           |           |           |           |
| 8    | 3.0693    | 2.6726    |           | 2.8045    |           |           |           |
| 9    |           |           |           |           | 2.7263    |           |           |
| 10   |           |           |           |           | .3048     |           |           |
| 11   |           |           |           |           | .3429     |           | .4191     |
| 12   |           |           |           |           |           |           | 2.2725    |
| 14   |           |           |           |           |           |           | 2.4486    |
| 15   |           |           |           |           |           |           | 2.8858    |
| 16   |           |           |           |           | .2286     |           |           |
| 17   |           | .3239     | .3048     |           | .2858     | 2.6063    |           |
| 18   | .4572     | .4001     | .5716     |           | .381      |           |           |
| 19   | .8002     | .7621     | .7811     |           | .8002     | 1.9719    |           |
| 20   | .724      | .6478     | .6668     |           | .6668     | .8002     |           |
| 21   | .5906     | .6097     | .5716     |           | .5525     | .6859     |           |
| 22   | .4954     |           | .5335     |           | .4572     | .5716     |           |
| 23   | .4001     |           | .4001     |           | .1905     | .4954     |           |
| 24   | 1.3546    |           |           | 1.3717    |           | .4001     | .381      |
| Max  | 3.0693    | 2.7027    | .7811     | 2.8045    | 2.7263    | 2.6063    | 2.8858    |
| Min  | .4001     | .3239     | .3048     | 1.3717    | .1905     | .4001     | .381      |
| Avg  | 1.2504    | 1.1598    | .5471     | 2.0094    | .6306     | 1.0391    | 1.5345    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 205 / NEW KOMBHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .9526     |           |           | .9526     |           | 1.4918    | 1.8861    |
| 7    |           | .9526     |           |           |           |           | 2.572     |
| 8    |           |           |           |           |           | 2.5606    | 2.4006    |
| 9    |           |           |           |           |           |           | 2.13      |
| 10   |           |           |           |           | .1905     |           |           |
| 11   |           |           |           |           | .1905     |           | .1905     |
| 12   |           |           |           |           | 2.4006    |           | .1905     |
| 13   |           |           |           |           | 2.2291    |           | .1905     |
| 14   |           |           |           |           | 2.4006    |           | .1905     |
| 15   |           |           |           |           | 2.4006    |           | .1905     |
| 16   |           |           |           |           | 2.4006    |           | .1905     |
| 17   | 2.2939    | 2.4006    | 2.2291    |           | 2.2043    | .1905     |           |
| 18   | 2.13      | 2.4006    | 2.0576    |           | 1.3413    |           |           |
| 19   | 1.8442    | 1.9662    | 1.8861    |           | 1.4918    | .9526     |           |
| 20   | .9526     | .7621     | .7621     |           | .7621     | .9526     |           |
| 21   | .7621     | .7621     | .7621     |           | .7621     | .7621     |           |
| 22   | .724      |           | .7621     |           | .5716     | .5716     |           |
| 23   | .5716     |           | .5716     |           | .5716     | .381      |           |
| 24   | .5716     |           |           | .381      |           | .6935     | .8573     |
| Max  | 2.2939    | 2.4006    | 2.2291    | .9526     | 2.4006    | 2.5606    | 2.572     |
| Min  | .5716     | .7621     | .5716     | .381      | .1905     | .1905     | .1905     |
| Avg  | 1.2003    | 1.5407    | 1.2901    | .6668     | 1.4227    | .9507     | .999      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 206 / NEW MALTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.3717    |           |           | 1.2003    |           | .2858     | .381      |
| 7    | 2.0576    | .0191     |           |           |           |           |           |
| 8    | 2.4006    | 2.13      |           | 1.829     |           |           |           |
| 9    |           |           |           |           | 1.7147    |           |           |
| 10   |           |           |           |           | .1905     |           |           |
| 11   |           |           |           |           | .1905     |           | .1905     |
| 12   |           |           |           |           |           |           | 1.6575    |
| 14   |           |           |           |           |           |           | 1.6766    |
| 15   |           |           |           |           |           |           | 2.1548    |
| 16   |           |           |           |           | .1905     |           |           |
| 17   |           | .1905     | .1905     |           | .1905     | 1.7147    |           |
| 18   | .1905     | .1905     |           |           | .1905     |           |           |
| 19   | .1905     | .381      | .1905     |           | .1905     | 1.2003    |           |
| 20   | .2858     | .381      | .1905     |           | .2858     | .381      |           |
| 21   | .2858     | .2858     | .1905     |           | .2858     | .1905     |           |
| 22   | .1905     |           | .1905     |           | .1905     | .1905     |           |
| 23   | .1905     |           | .1905     |           | .1905     | .1905     |           |
| 24   | .8573     |           |           | .8573     |           | .1905     | .1905     |
| Max  | 2.4006    | 2.13      | .1905     | 1.829     | 1.7147    | 1.7147    | 2.1548    |
| Min  | .1905     | .0191     | .1905     | .8573     | .1905     | .1905     | .1905     |
| Avg  | .8021     | .5111     | .1905     | 1.2955    | .3464     | .5430     | 1.0418    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 207 / Water supply Mirajgaon  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 03-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 18   |           | .0381     |
| 19   | .0381     | .0381     |
| Max  | .0381     | .0381     |
| Min  | .0381     | .0381     |
| Avg  | .0381     | .0381     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 208 / kalptaru cotton

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .112      |           |           | .112      |           | .0191     | .0943     |
| 7    | .1307     | .0191     |           |           |           | .0114     | .1307     |
| 8    | .0191     | .1143     |           | .0191     |           | .0095     | .0191     |
| 9    |           |           |           | .0191     | .1132     |           | .1067     |
| 10   |           |           |           |           | .112      |           | .1143     |
| 11   |           |           |           |           | .112      |           | .0191     |
| 12   |           |           |           |           | .132      |           | .1143     |
| 13   |           |           |           |           | .132      |           | .1143     |
| 14   |           |           |           |           | .1307     |           | .1143     |
| 15   |           |           |           |           | .1509     |           | .0953     |
| 16   |           |           |           |           | .1307     |           | .1143     |
| 17   | .0095     | .1334     | .1307     |           | .1334     | .1132     |           |
| 18   | .0114     | .1143     | .1307     |           | .1143     | .112      |           |
| 19   | .0095     | .1143     | .1307     |           | .1143     | .1132     |           |
| 20   | .0114     | .1143     | .112      |           | .0191     | .1132     |           |
| 21   | .0191     | .1143     | .112      |           | .0191     | .112      |           |
| 22   | .0191     |           | .1132     |           | .0191     | .112      |           |
| 23   | .0191     | .1334     | .1132     |           | .0191     | .112      |           |
| 24   | .112      |           |           | .1132     |           | .0191     | .1132     |
| Max  | .1307     | .1334     | .1307     | .1132     | .1509     | .1132     | .1307     |
| Min  | .0095     | .0191     | .112      | .0191     | .0191     | .0095     | .0191     |
| Avg  | .0430     | .1072     | .1204     | .0659     | .0968     | .0770     | .0958     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014057 / MIRAJGAON

Feeder No / Name : 421 / 33kv incomer-1

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    | 4.5725    | 3.2007    |
| 2    | 4.5725    | 3.658     |
| 3    | 4.5725    | 3.658     |
| 4    | 4.5725    | 3.658     |
| 5    | 5.0297    | 4.5725    |
| 6    | 5.9442    | 5.487     |
| 7    | 6.4015    | 7.316     |
| 8    | 8.2305    | 10.0595   |
| 9    |           | 10.5167   |
| 10   |           | 6.8587    |
| 11   |           | 1.829     |
| 12   |           | 5.9442    |
| 13   |           | 7.316     |
| Max  | 8.2305    | 10.5167   |
| Min  | 4.5725    | 1.829     |
| Avg  | 5.4870    | 5.6980    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014060 / GHOGARGAON

Feeder No / Name : 202 / MANDALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | 1.5242    |
| Avg  | 1.5242    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014060 / GHOGARGAON

Feeder No / Name : 203 / NIMGAON -G-

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6097     |
| Max  | .6097     |
| Min  | .6097     |
| Avg  | .6097     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014060 / GHOGARGAON

Feeder No / Name : 208 / Kohinoor

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 201 / LIFT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     |           |           | .1638     | .1638     | 1.6194    | 1.6194    |
| 2    | .1715     |           | .1638     | .1638     | .1638     | 1.6385    | 1.6385    |
| 3    | .1715     |           | .1638     | .1638     | .1638     | 1.6385    | 1.6385    |
| 4    | .1715     |           | .1638     | .1638     | .1619     | 1.1469    | 1.7718    |
| 5    | .1715     |           | .1619     | .1638     | .1619     | 1.1336    | 1.8023    |
| 6    | .1715     | .1656     | .1638     | .1619     | .1638     | 1.1469    | 1.7814    |
| 7    | .1715     | .1638     | .1619     | .1638     | .1638     | 1.2146    |           |
| 8    | .1715     | .1638     |           | .1638     | .1619     | 1.2803    | 2.1052    |
| 9    | .1638     | .1715     |           | .1619     | .1619     | 1.1469    | 1.8842    |
| 12   |           |           | 2.4577    | 2.3758    | 2.3148    |           |           |
| 13   |           | 2.4863    | 2.2939    |           | 2.4006    |           |           |
| 14   |           | 2.4863    | 2.2119    |           | 2.3148    |           |           |
| 15   |           | 2.4863    | 2.2351    |           | 2.4863    |           |           |
| 16   |           | 2.4006    | 2.3179    | 2.5662    | 2.572     |           |           |
| 17   |           | 2.3148    |           | 2.4863    |           |           |           |
| 18   |           | 2.4006    | 2.4006    | 2.4006    |           | .1654     | .1619     |
| 19   |           | 2.3148    | 2.2119    | 2.3148    |           | .1652     | .1638     |
| 20   |           | 2.3148    | .1694     | .1715     | .1638     |           | .1638     |
| 21   |           | .1715     | .1619     | .1715     |           |           | .1638     |
| 22   |           | .1638     | .1638     | .1638     | .1638     | .1638     | .1638     |
| 23   |           | .1638     | .1619     | .1638     | .1638     | .1638     | .1638     |
| 24   | .1715     | .1638     | .1638     | .1638     | 1.6385    |           | 1.6385    |
| Max  | .1715     | 2.4863    | 2.4577    | 2.5662    | 2.572     | 1.6385    | 2.1052    |
| Min  | .1638     | .1638     | .1619     | .1619     | .1619     | .1638     | .1619     |
| Avg  | .1707     | 1.2833    | .9960     | .7604     | .8714     | .9711     | 1.1240    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 202 / BHAMBORA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.9005    | 2.8776    | 2.8883    |           | 2.9005    | 2.902     | 2.9157    |
| 2    | 2.9035    | 2.8715    | 2.8944    |           | 2.8929    | 2.8974    | 2.9157    |
| 3    | 2.9035    | 2.8761    | 2.9005    |           | 2.9066    | 2.8822    | 2.905     |
| 4    | 2.9066    | 2.8883    | 2.9066    |           | 2.9096    | 2.8776    | 2.9111    |
| 5    | 2.9477    | 2.9294    | 2.931     |           | 2.9218    | 2.9127    | 2.902     |
| 6    | 3.03      | 2.9889    | 3.0361    |           | 2.9142    | 2.9752    | 2.9569    |
| 7    | 2.9401    | 2.966     | 2.995     |           | 2.9538    | 2.995     | 2.9538    |
| 8    | 2.9553    | 2.9477    | 2.9523    |           | 2.8121    | 3.0148    | 2.9675    |
| 9    | 2.9874    | 2.9371    | 2.9142    | 1.989     | 2.9477    | 3.0148    | 2.7465    |
| 10   | 2.8807    | 1.1645    | 2.87      | 2.8944    | 2.1582    | 2.8502    | 2.8639    |
| 11   | .407      | .4847     | 2.8471    | 2.9081    | .3551     | 2.8487    | 2.8715    |
| 12   | 2.9492    | .3323     | 2.902     | 2.9645    | 2.9904    | 2.9447    | 2.9279    |
| 13   | 2.873     | .6264     | 2.8807    | 2.9797    | 2.8776    | 2.9477    | 2.9096    |
| 14   | .0793     | .6417     | 2.018     | 2.9645    | 2.8563    | 2.9249    | 2.8929    |
| 15   | 1.8077    | .3475     | 1.2651    | 2.9706    | 2.8487    | 2.9203    | 2.9081    |
| 16   | 2.9279    | .3688     | 2.899     | 2.9538    | 2.8456    | 2.8929    | 2.8624    |
| 17   | 2.9127    | 2.2237    | 1.672     | 2.9477    | 2.8502    | .3932     | 2.8776    |
| 18   | 1.3596    | 3.0407    | .3948     | 2.9233    | 2.8166    | .6615     | 2.8807    |
| 19   | .4405     | .2591     | .4435     | 2.963     | 2.6475    | .6843     | 2.5895    |
| 20   | 2.9005    | .4405     | .4984     | 2.8746    | .2088     | .756      | .6965     |
| 21   | 2.8807    | 1.4815    | .4999     | 2.8502    | 1.1233    | .4329     | .5213     |
| 22   | 2.8441    | 2.8822    | 1.9707    | 1.233     | 2.8685    | 2.6688    | 2.8715    |
| 23   | 2.8502    | 2.8791    | 2.8624    | 2.8822    | 2.8624    | 2.6261    | 2.8654    |
| 24   | 5.0038    | 2.8944    | 2.8883    | 2.9264    | 2.9005    | 2.8273    | 2.9111    |
| Max  | 5.0038    | 3.0407    | 3.0361    | 2.9797    | 2.9904    | 3.0148    | 2.9675    |
| Min  | .0793     | .2591     | .3948     | 1.233     | .2088     | .3932     | .5213     |
| Avg  | 2.5663    | 1.9312    | 2.3054    | 2.7641    | 2.5570    | 2.4105    | 2.6927    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 203 / Baradgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     |           |           | 2.4577    | 2.2939    | 2.13      | 1.9662    |
| 2    | .1715     |           | 2.1052    | 2.4577    | 2.4577    | 2.13      | 1.9662    |
| 3    | .1715     |           | 2.13      | 2.4577    | 2.4291    | 2.13      | 1.9662    |
| 4    | .1715     |           | 2.2939    | 2.6216    | 2.5911    | 2.2672    | 2.6216    |
| 5    | .1715     |           | 2.4577    | 2.7854    | 2.753     | 2.4291    | 2.6216    |
| 6    | .1715     | .3807     | 2.5396    | 3.1579    | 3.0312    | 2.5911    | 2.915     |
| 7    | .1715     | .3807     | 2.5911    | 2.5911    |           | 2.9607    |           |
| 8    | .1715     | .3807     | 2.6216    |           | 3.0836    | 3.0464    | 3.4008    |
| 9    | .1905     |           | 2.753     | 2.7035    | 3.1131    | 2.6406    | 3.0769    |
| 14   |           | 3.7723    |           |           |           |           |           |
| 18   |           | .1715     | .1903     | .1715     |           |           | .1905     |
| 19   |           | .1715     | .3807     | .1715     |           |           |           |
| 20   |           | .1715     | .3795     | .1715     | .381      |           | .381      |
| 21   |           | .1715     | .381      | .1715     |           |           | .381      |
| 22   |           | .381      | .2858     | .381      | .2858     |           | .381      |
| 23   |           | .381      | .2858     | .2858     | .2858     | .381      | .2858     |
| 24   | .1715     | .3807     | 2.1052    | 2.4577    | 2.0481    |           | 1.9662    |
| Max  | .1905     | 3.7723    | 2.753     | 3.1579    | 3.1131    | 3.0464    | 3.4008    |
| Min  | .1715     | .1715     | .1903     | .1715     | .2858     | .381      | .1905     |
| Avg  | .1734     | .6130     | 1.5667    | 1.6695    | 2.0628    | 2.2706    | 1.7229    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 204 / JALALAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     |           |           | 2.4291    | 2.4577    | .1638     | .1638     |
| 2    | .1715     |           | 2.2939    | 2.4577    | 2.4577    | .1638     | .1638     |
| 3    | .1715     |           | .1619     | 2.4291    | 2.4291    | .1638     | .1638     |
| 4    | .1715     |           | .1638     | 2.6216    | 2.4006    | .1638     | .1638     |
| 5    | .1715     |           | .1638     | 2.6216    | 2.5606    | .1619     | .1638     |
| 6    | .1715     | 3.658     | .1638     | 2.9492    | 2.6216    | .1619     | .1638     |
| 7    | .1715     | 3.8009    | .1638     | 2.915     | 3.0769    | .1638     |           |
| 8    | .1715     | 3.658     | .1638     | 3.1131    | 3.1131    |           |           |
| 9    | .1638     | 2.7435    | .1638     | 3.0769    | 2.6216    |           |           |
| 12   |           |           |           |           |           | 2.9264    | 3.1093    |
| 13   |           |           |           |           |           | 3.1093    | 3.4751    |
| 14   |           |           |           |           |           | 3.1093    | 3.4751    |
| 15   |           |           |           |           |           | 3.1093    | 3.4751    |
| 16   |           |           |           |           |           |           | 3.2922    |
| 18   |           | .1715     | .1829     |           |           | 2.9264    | 2.4577    |
| 19   |           | .1715     | .1829     | .1715     |           | 3.1093    | 2.2939    |
| 20   |           | .1715     | .1829     | .1715     | .1829     |           | .1638     |
| 21   |           | .1715     | .1638     | .1715     |           |           | .1638     |
| 22   |           | .1638     | .1638     | .1638     | .1638     | .1638     | .1638     |
| 23   |           | .1638     | .1638     | .1638     | .1638     | .1638     | .1638     |
| 24   | .1715     | 3.1093    | 2.2672    | 2.4577    | .1638     |           | .1638     |
| Max  | .1715     | 3.8009    | 2.2939    | 3.1131    | 3.1131    | 3.1093    | 3.4751    |
| Min  | .1638     | .1638     | .1619     | .1638     | .1638     | .1619     | .1638     |
| Avg  | .1707     | 1.6348    | .4497     | 1.8609    | 1.8779    | 1.3174    | 1.2989    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 205 / sidhtek gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.829     |
| Max  | 1.829     |
| Min  | 1.829     |
| Avg  | 1.829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 206 / Berdi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0857     |           |           | 1.3927    | 1.4746    | .0819     | .0819     |
| 2    | .0857     |           | 1.6385    | 1.3927    | 1.4746    | .0819     | .0819     |
| 3    | .0857     |           | 1.6385    | 1.4746    | 1.4746    | .0819     | .0819     |
| 4    | .0857     |           | 1.4746    | 1.4746    | 1.4746    | .0819     | .0819     |
| 5    | .0857     |           | 1.4746    | 1.4746    | 1.4575    | .0819     | .0819     |
| 6    | .0857     | 1.7939    | 1.4746    | 1.6385    | 1.5565    | .0819     | .0581     |
| 7    | .0857     | 1.9776    | 1.5565    | 1.6385    | 1.8023    | .0819     |           |
| 8    |           | 1.9776    | 1.8023    | 1.6385    | 1.8623    |           |           |
| 9    |           | 1.9719    | 1.8023    | 1.7204    | 1.8023    |           |           |
| 12   |           |           |           |           |           | 2.1424    | 2.4463    |
| 13   |           |           |           |           |           | 2.2832    | 2.5278    |
| 14   |           |           |           |           |           | 2.3125    | 2.4463    |
| 15   |           |           |           |           |           | 2.4463    | 2.2832    |
| 16   |           |           |           |           |           |           | 2.4463    |
| 18   |           | .0857     | .0819     |           |           | 2.2325    | 2.2119    |
| 19   |           | .0857     | .0815     | .0857     |           | 2.1474    | 2.13      |
| 20   |           | .0857     |           | .0857     | .0863     |           | .0819     |
| 21   |           | .0857     | .0819     | .0857     |           |           | .0819     |
| 22   |           | .0819     | .0819     | .0848     | .0819     | .0819     | .0819     |
| 23   |           | .0819     | .0819     | .0819     | .0819     | .0819     | .0819     |
| 24   | .0857     | 1.3862    | 1.6385    | 1.4089    | .0819     |           | .0819     |
| Max  | .0857     | 1.9776    | 1.8023    | 1.7204    | 1.8623    | 2.4463    | 2.5278    |
| Min  | .0857     | .0819     | .0815     | .0819     | .0819     | .0819     | .0581     |
| Avg  | .0857     | .8740     | 1.0650    | 1.0452    | 1.1316    | .9534     | .9649     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 207 / baradgaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3429     |           |           | .2658     | .2658     | .2658     | .2658     |
| 2    | .3429     |           | .2429     | .2658     | .2658     | .2658     | .2658     |
| 3    | .3429     |           | .2658     | .2658     | .2658     | .2658     | .2658     |
| 4    | .3429     |           | .3544     | .3544     | .3544     | .3544     | .3544     |
| 5    | .4287     |           | .443      | .443      | .443      | .443      | .443      |
| 6    | .4287     | .5487     | .6201     | .6201     | .6201     | .6201     | .5316     |
| 7    | .5144     | .543      | .6201     | .6201     | .6201     | .6201     |           |
| 8    | .5144     | .5487     |           | .5316     | .6201     | .443      | .5316     |
| 9    | .5316     |           |           | .5316     | .5316     | .443      | .5373     |
| 10   | .5316     |           | .3658     |           | .5144     |           | .1829     |
| 11   | .3544     | .3429     | .3658     | .3658     | .5144     |           | .1829     |
| 12   |           |           | .3658     | .1829     |           | .1829     | .1829     |
| 13   |           | .3429     | .3658     |           |           | .1829     | .1829     |
| 14   |           | .3429     | .1829     |           | .3429     | .1829     | .1829     |
| 15   |           | .3429     |           | 2.4777    | .3429     | .1829     | .1829     |
| 16   |           | .3429     |           | .1829     | .3429     |           | .1829     |
| 17   |           | .3429     |           |           |           |           |           |
| 18   |           | .4287     | .3658     | .5144     |           | .1829     | .3544     |
| 19   |           | .5144     | .5487     | .5144     |           | .3658     | .5316     |
| 20   |           | .5144     | .5487     | .5144     | .5487     |           | .5316     |
| 21   |           | .5144     | .5316     | .5144     |           |           | .443      |
| 22   |           | .443      | .443      | .443      | .3544     | .3544     | .3544     |
| 23   |           | .2658     | .2658     | .2658     | .2658     | .2658     | .3544     |
| 24   | .4287     | .1829     | .2658     | .2658     | .2658     |           | .2658     |
| Max  | .5316     | .5487     | .6201     | 2.4777    | .6201     | .6201     | .5373     |
| Min  | .3429     | .1829     | .1829     | .1829     | .2658     | .1829     | .1829     |
| Avg  | .4253     | .4101     | .3979     | .5070     | .4155     | .3307     | .3323     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 208 / Sidhatek Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0857     |           |           | 1.065     | .9831     | .081      | .0819     |
| 2    | .0857     |           | .9717     | 1.0526    | .9717     | .0819     | .0819     |
| 3    | .0857     |           | .9831     | 1.065     | .9717     | .0819     | .0819     |
| 4    | .0857     |           | .9717     | 1.0526    | .9717     | .0819     | .0819     |
| 5    | .0857     |           |           | 1.0526    | 1.0526    | .0819     | .0819     |
| 6    | .0857     | .9785     | 1.1336    | 1.1336    |           | .0819     | .0819     |
| 7    | .0857     | 1.3047    | 1.1336    | 1.1336    | 1.2955    | .0819     |           |
| 8    | .0857     | 1.4678    | 1.2146    | 1.3108    | 1.3603    |           |           |
| 9    | .081      | 1.5432    | 1.3108    | 1.2955    | .9831     |           |           |
| 12   |           |           |           |           |           | 2.13      | 2.4463    |
| 13   |           |           |           |           |           | 2.1176    | 2.2351    |
| 14   |           |           |           |           |           | 2.1201    | 2.1201    |
| 15   |           |           |           |           |           | 1.957     | 2.1424    |
| 16   |           |           |           |           |           |           | 1.957     |
| 18   |           | .0857     | .0815     |           |           | 1.9845    | 1.7004    |
| 19   |           | .0857     | .0824     | .0857     |           | 2.13      | 1.6385    |
| 20   |           | .0857     | .0857     | .0857     | .0861     |           | .0819     |
| 21   |           | .0857     | .081      | .0857     |           |           | .0819     |
| 22   |           | .0819     | .081      | .0838     | .0819     | .0819     | .0819     |
| 23   |           | .081      | .0819     | .0819     | .0819     | .0819     | .0819     |
| 24   | .0857     | .824      | .9831     | 1.065     | .0819     |           | .0819     |
| Max  | .0857     | 1.5432    | 1.3108    | 1.3108    | 1.3603    | 2.13      | 2.4463    |
| Min  | .081      | .081      | .081      | .0819     | .0819     | .081      | .0819     |
| Avg  | .0852     | .6022     | .6568     | .7766     | .7435     | .8784     | .8412     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 209 / Ganeshwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     |           |           | 1.6385    | 1.5565    | .1905     | .1905     |
| 2    | .1715     |           | 1.6194    | 1.6385    | 1.6385    | .1905     | .1905     |
| 3    | .1715     |           | 1.6385    | 1.6385    | 1.6194    | .1905     | .1905     |
| 4    | .1715     |           | 1.6385    | 1.6385    | 1.6194    | .1905     | .1905     |
| 5    | .1715     |           | 1.6385    | 1.6385    | 1.6194    | .1905     | .1905     |
| 6    | .1715     | 1.7939    | 1.7204    | 1.7204    | 1.7204    | .1905     | .1905     |
| 7    | .1715     | 2.2016    | 1.6385    | 1.6385    | 2.0481    | .1905     |           |
| 8    | .1715     | 2.3647    | 2.2119    | 2.2119    | 2.2405    | .1905     |           |
| 9    |           | 2.3148    | 2.2119    | 2.13      | 2.0481    |           |           |
| 12   |           |           |           |           |           | 2.3647    | 2.5249    |
| 13   |           |           |           |           |           | 2.3125    | 2.4463    |
| 14   |           |           |           |           |           | 2.5219    | 2.6063    |
| 15   |           |           |           |           |           | 2.472     | 2.6368    |
| 16   |           |           |           |           |           |           | 2.9264    |
| 18   |           | .1715     | .1903     | .1715     |           | 2.3125    | 2.3758    |
| 19   |           | .1715     | .1648     | .1715     |           | 2.1424    | 2.13      |
| 20   |           | .1715     | .1903     | .1715     | .1898     |           | .1905     |
| 21   |           | .1715     | .1905     | .1715     |           |           | .1905     |
| 22   |           | .1905     | .1905     | .1905     | .1905     | .1905     | .1905     |
| 23   |           | .1905     | .1905     | .1905     | .1905     | .1905     | .1638     |
| 24   | .1715     | 1.4746    | 1.6385    | 1.6385    | .1905     |           | .1905     |
| Max  | .1715     | 2.3647    | 2.2119    | 2.2119    | 2.2405    | 2.5219    | 2.9264    |
| Min  | .1715     | .1715     | .1648     | .1715     | .1898     | .1905     | .1638     |
| Avg  | .1715     | 1.0197    | 1.1382    | 1.1624    | 1.2978    | 1.0019    | 1.0953    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 210 / Nilkanth Agro  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | 1.5242    |
| Avg  | 1.5242    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014069 / BHAMBORA

Feeder No / Name : 211 / Dudhodi Ag

Feeder KV- 11 / INCOMING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     |           |           | .1638     | .1638     | 1.6385    | 1.6385    |
| 2    | .1715     |           |           | .1638     | .1658     | 1.6575    | 1.6385    |
| 3    | .1715     |           | .1638     | .1638     | .1658     | 1.6575    | 1.6385    |
| 4    | .1715     |           | .1638     | .1638     | .1658     | 1.6575    | 1.6385    |
| 5    | .1715     |           | .1638     | .1638     | .1658     | 1.8233    | 1.8233    |
| 6    | .1715     | .1656     | .1638     | .1638     | .1658     | 1.8233    | 1.8233    |
| 7    | .1715     | .1656     | .1638     | .1638     | .1658     | 2.1052    |           |
| 8    |           | .1656     |           | .1638     | .1638     |           | 1.9662    |
| 9    |           | .1715     |           | .1638     | .1638     | 2.1548    | 1.9062    |
| 12   |           |           | 2.5662    | 2.6429    | 2.7435    |           |           |
| 13   |           | 2.8292    | 2.5662    |           | 2.8292    |           |           |
| 14   |           | 2.8292    | 2.4834    |           | 2.7435    |           |           |
| 15   |           |           | 2.4834    | 2.649     | 2.8292    |           |           |
| 16   |           | 2.915     | 2.4006    | 2.7255    | 2.8292    |           |           |
| 17   | 2.3758    | 2.7435    |           | 2.7435    |           |           |           |
| 18   |           | 2.7435    | 2.2351    | 2.7435    |           | .1656     | .1638     |
| 19   |           | 2.7435    | 2.1523    | 2.4863    |           | .1656     | .1638     |
| 20   |           | .1715     | .1665     | .1715     | .1656     |           | .1638     |
| 21   |           | .1715     | .1638     | .1715     |           |           | .1638     |
| 22   |           | .1638     | .1638     | .1638     | .1638     | .1658     | .1658     |
| 23   |           | .1638     | .1638     | .1638     | .1638     | .1638     | .1638     |
| 24   | .1715     | .1656     | .1638     | .1638     | 1.6194    |           | .1658     |
| Max  | 2.3758    | 2.915     | 2.5662    | 2.7435    | 2.8292    | 2.1548    | 1.9662    |
| Min  | .1715     | .1638     | .1638     | .1638     | .1638     | .1638     | .1638     |
| Avg  | .4164     | 1.2206    | 1.0899    | .9150     | .9763     | 1.2649    | 1.0149    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014123 / 33/11 Kv Kumbhali Sub  
stationFeeder No / Name : 202 / Kumbhali SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.829     |
| Max  | 1.829     |
| Min  | 1.829     |
| Avg  | 1.829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197]

BU 5720

Substation No/ Name :- 014150 / 33/11 kv Patewadi

Feeder No / Name : 201 / Patewadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 07-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 1    | .381      |
| 2    | .381      |
| 3    | .381      |
| 4    | .381      |
| 5    | .7621     |
| 6    | .7621     |
| 12   | 5.3346    |
| 13   | 6.0966    |
| Max  | 6.0966    |
| Min  | .381      |
| Avg  | 1.8099    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014151 / 33/11 Kv Khed

Feeder No / Name : 201 / Khed

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.829     |
| Max  | 1.829     |
| Min  | 1.829     |
| Avg  | 1.829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014151 / 33/11 Kv Khed

Feeder No / Name : 203 / Akhoni

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.9814    |
| Max  | 1.9814    |
| Min  | 1.9814    |
| Avg  | 1.9814    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014151 / 33/11 Kv Khed

Feeder No / Name : 204 / KHED GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.0576    |
| Max  | 2.0576    |
| Min  | 2.0576    |
| Avg  | 2.0576    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014151 / 33/11 Kv Khed

Feeder No / Name : 206 / Shimpora Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.829     |
| Max  | 1.829     |
| Min  | 1.829     |
| Avg  | 1.829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

KARJAT[197] BU 5720

Substation No/ Name :- 014151 / 33/11 Kv Khed

Feeder No / Name : 207 / SHIMPORA NO 2

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6097     |
| Max  | .6097     |
| Min  | .6097     |
| Avg  | .6097     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014073 / 33/11KV TAKALI K

Feeder No / Name : 201 / 11KV TAKALI K

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.7528    |
| Max  | 1.7528    |
| Min  | 1.7528    |
| Avg  | 1.7528    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014073 / 33/11KV TAKALI K

Feeder No / Name : 202 / 11KV CHANDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6766    |
| Max  | 1.6766    |
| Min  | 1.6766    |
| Avg  | 1.6766    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014073 / 33/11KV TAKALI K

Feeder No / Name : 203 / 11 KV GHODEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0669    |
| Max  | 1.0669    |
| Min  | 1.0669    |
| Avg  | 1.0669    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014073 / 33/11KV TAKALI K

Feeder No / Name : 204 / 11 KV SHEDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014073 / 33/11KV TAKALI K

Feeder No / Name : 205 / 11 KV CHANDGAON TAK SHED

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014073 / 33/11KV TAKALI K

Feeder No / Name : 206 / 11 KV PEDGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.4575    |
| Max  | 1.4575    |
| Min  | 1.4575    |
| Avg  | 1.4575    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014073 / 33/11KV TAKALI K

Feeder No / Name : 207 / HIRADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 201 / 11KV WANGDARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | 1.5242    |
| Avg  | 1.5242    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 202 / 11KV KAUTHA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 10   |           | 3.1207    |
| 24   | .1524     |           |
| Max  | .1524     | 3.1207    |
| Min  | .1524     | 3.1207    |
| Avg  | .1524     | 3.1207    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 203 / 11KV KASHTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.1431    |
| Max  | 1.1431    |
| Min  | 1.1431    |
| Avg  | 1.1431    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 204 / 11 KV LAHAREPAT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 10   |           | 2.6452    |           |
| 24   | .2286     |           | 2.8045    |
| Max  | .2286     | 2.6452    | 2.8045    |
| Min  | .2286     | 2.6452    | 2.8045    |
| Avg  | .2286     | 2.6452    | 2.8045    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 205 / 11KV WANGDARI GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 10   |           | .6767     |           |
| 19   |           |           | .8962     |
| 24   | .499      |           |           |
| Max  | .499      | .6767     | .8962     |
| Min  | .499      | .6767     | .8962     |
| Avg  | .499      | .6767     | .8962     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 206 / 11 KV SAIKRUPA IND EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0949     | .0968     | .0995     | .1151     | .0991     | .1208     | .1002     |
| 2    | .0903     | .096      | .0991     | .1014     | .0964     | .1094     | .0975     |
| 3    | .0941     | .0953     | .0998     | .0953     | .096      | .1071     | .0972     |
| 4    | .0922     | .0956     | .0987     | .0949     | .0975     | .1071     | .0968     |
| 5    | .0937     | .0941     | .0975     | .0991     | .0972     | .1101     | .0945     |
| 6    | .0987     | .0934     | .0911     | .0991     | .0968     | .1101     | .0972     |
| 7    | .0991     | .0972     | .0884     | .088      | .101      | .0995     | .0949     |
| 8    | .1006     | .0987     | .0941     | .0895     | .0911     | .101      | .1002     |
| 9    | .0949     | .0983     | .0956     | .0945     | .093      | .096      | .0953     |
| 10   | .1177     | .2255     | .1147     | .0831     | .0903     | .1067     | .112      |
| 11   | .1589     | .1273     | .1734     | .0899     | .1094     | .1227     | .1235     |
| 12   | .101      | .1383     | .1638     | .112      | .1257     | .1532     | .1494     |
| 13   | .0972     | .1901     | .2004     | .1002     | .1185     | .1326     | .1562     |
| 14   | .1726     | .2107     | .2206     | .1924     | .1673     | .1989     | .1993     |
| 15   | .1745     | .2343     | .2206     | .1936     | .1894     | .1901     | .2145     |
| 16   | .1764     | .2145     | .1821     | .1551     | .1837     | .1196     | .2111     |
| 17   | .1501     | .1524     | .1482     | .1475     | .1669     | .1787     | .1402     |
| 18   | .1566     | .1231     | .1677     | .1219     | .1242     | .1787     | .1147     |
| 19   | .1692     | .1376     | .1345     | .1345     | .1284     | .1497     | .1501     |
| 20   | .1707     | .1318     | .117      | .1303     | .1353     | .1776     | .1551     |
| 21   | .16       | .1181     | .1757     | .1193     | .141      | .1189     | .144      |
| 22   | .1181     | .1528     | .1684     | .1021     | .1257     | .1109     | .1318     |
| 23   | .1162     | .1181     | .1261     | .1006     | .1193     | .1135     | .1246     |
| 24   | .2071     | .1078     | .1231     | .1048     | .12       | .1132     | .1181     |
| Max  | .2071     | .2343     | .2206     | .1936     | .1894     | .1989     | .2145     |
| Min  | .0903     | .0934     | .0884     | .0831     | .0903     | .096      | .0945     |
| Avg  | .1294     | .1353     | .1375     | .1152     | .1214     | .1303     | .1299     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 207 / 11 KV KASHTI GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 10   |           | .9511     |
| 24   | .8029     |           |
| Max  | .8029     | .9511     |
| Min  | .8029     | .9511     |
| Avg  | .8029     | .9511     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 208 / DHAWALEWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 19   |           | .2743     |
| 24   | .2134     |           |
| Max  | .2134     | .2743     |
| Min  | .2134     | .2743     |
| Avg  | .2134     | .2743     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014076 / 33/11KV KASHTI

Feeder No / Name : 209 / JANGALEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 19   |           | .0762     |
| 24   | 1.1622    |           |
| Max  | 1.1622    | .0762     |
| Min  | 1.1622    | .0762     |
| Avg  | 1.1622    | .0762     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 201 / 11KV ADHALGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 18   |           | 1.8976    |
| 20   | .743      |           |
| 21   | .695      |           |
| 22   | .724      |           |
| 24   | 1.5242    |           |
| Max  | 1.5242    | 1.8976    |
| Min  | .695      | 1.8976    |
| Avg  | .9216     | 1.8976    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 202 / 11KV PISORA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | 1.5242    |
| Avg  | 1.5242    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 204 / 11 KV ADHALGAON GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 12   |           | .2149     |
| 18   |           | .2686     |
| 20   | .394      |           |
| 21   | .3544     |           |
| 22   | .3189     |           |
| 24   | 1.5242    |           |
| Max  | 1.5242    | .2686     |
| Min  | .3189     | .2149     |
| Avg  | .6479     | .2418     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 205 / 11 KV BHAWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 18   |           | 3.022     |
| 20   | .4755     |           |
| 21   | .5281     |           |
| 22   | .4633     |           |
| 24   | 1.3717    |           |
| Max  | 1.3717    | 3.022     |
| Min  | .4633     | 3.022     |
| Avg  | .7097     | 3.022     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 206 / 11 KV TAKALI LONAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 18   |           | 2.4371    |
| 20   | 1.379     |           |
| 21   | 1.2323    |           |
| 22   | 1.1296    |           |
| 24   | 1.3717    |           |
| Max  | 1.379     | 2.4371    |
| Min  | 1.1296    | 2.4371    |
| Avg  | 1.2782    | 2.4371    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 207 / 11 KV PISORA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 18   |           | .3012     |
| 20   | .4477     |           |
| 21   | .3898     |           |
| 22   | .3189     |           |
| 24   | 1.7814    |           |
| Max  | 1.7814    | .3012     |
| Min  | .3189     | .3012     |
| Avg  | .7345     | .3012     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 208 / 11 KV KOKANGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 18   |           | .0762     |
| 21   | .2317     |           |
| 22   | .2317     |           |
| 24   | 1.3717    |           |
| Max  | 1.3717    | .0762     |
| Min  | .2317     | .0762     |
| Avg  | .6117     | .0762     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014085 / 33/11KV TANDALI D

Feeder No / Name : 210 / 11 KV Tandali dumala  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 20   | .176      |
| 21   | .1882     |
| 22   | .1882     |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | .176      |
| Avg  | .5192     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014107 / 33/11 KV ANGARE

Feeder No / Name : 201 / 11 KV ANGARE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0669    |
| Max  | 1.0669    |
| Min  | 1.0669    |
| Avg  | 1.0669    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 014107 / 33/11 KV ANGARE

Feeder No / Name : 202 / 11 KV KAUTHA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | 1.5242    |
| Avg  | 1.5242    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014107 / 33/11 KV ANGARE

Feeder No / Name : 203 / 11 KV AJNUJ

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | 1.5242    |
| Avg  | 1.5242    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 014107 / 33/11 KV ANGARE

Feeder No / Name : 204 / BHIM NADI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014107 / 33/11 KV ANGARE

Feeder No / Name : 205 / KAUTHA GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014111 / 33/11 KV SHRIGONDA

Feeder No / Name : 206 / MAKHARE WADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014111 / 33/11 KV SHRIGONDA

Feeder No / Name : 209 / AUTIWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.3717    |
| Max  | 1.3717    |
| Min  | 1.3717    |
| Avg  | 1.3717    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014111 / 33/11 KV SHRIGONDA

Feeder No / Name : 210 / SHENDGEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014111 / 33/11 KV SHRIGONDA

Feeder No / Name : 211 / 11 KV LIMPANGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.3717    |
| Max  | 1.3717    |
| Min  | 1.3717    |
| Avg  | 1.3717    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 014111 / 33/11 KV SHRIGONDA

Feeder No / Name : 212 / BALAJI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7621     |
| Max  | .7621     |
| Min  | .7621     |
| Avg  | .7621     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 201 / 11KV MADHEWADGAON

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.829     |
| Max  | 1.829     |
| Min  | 1.829     |
| Avg  | 1.829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 202 / 11KV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | 1.5242    |
| Avg  | 1.5242    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 203 / 11KV SHEDGAON

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | 1.5242    |
| Avg  | 1.5242    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 204 / 11KV SHRIGONDA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | 1.5242    |
| Avg  | 1.5242    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 205 / 11KV KASHTI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.7528    |
| Max  | 1.7528    |
| Min  | 1.7528    |
| Avg  | 1.7528    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 207 / 11KV VELU

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.7528    |
| Max  | 1.7528    |
| Min  | 1.7528    |
| Avg  | 1.7528    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 422 / 33 KV BHAMBORA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 23.1482   |
| Max  | 23.1482   |
| Min  | 23.1482   |
| Avg  | 23.1482   |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 423 / 33 kv KASHTI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 19.2902   |
| Max  | 19.2902   |
| Min  | 19.2902   |
| Avg  | 19.2902   |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 424 / 33 KV KOLGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 21.605    |
| Max  | 21.605    |
| Min  | 21.605    |
| Avg  | 21.605    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196]

BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 425 / 33 KV MADHEWADGAON  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 16.9753   |
| Max  | 16.9753   |
| Min  | 16.9753   |
| Avg  | 16.9753   |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

KARJAT (R) DIVISION[574]

SHRIGONDA[196] BU 5762

Substation No/ Name :- 017010 / 132KV SHRIGONDA

Feeder No / Name : 426 / 33 KV SHRIGONDA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 20.5762   |
| Max  | 20.5762   |
| Min  | 20.5762   |
| Avg  | 20.5762   |



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 201 / 11 KV Kalas Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2591     | 1.8519    |           |           |           |           | 1.9204    |
| 2    | .2591     | 1.8004    |           | 1.7833    | 2.0062    |           | 1.8861    |
| 3    | .2591     | .2591     | .3856     |           |           | .3506     | .381      |
| 4    | .2896     | .2896     |           | .3048     | .3201     |           | .381      |
| 5    | .3353     | .3048     |           |           |           |           | .381      |
| 6    | .4115     | .3506     | .4334     | .381      | .3963     | .4207     | .4115     |
| 7    | .5144     | .4115     | .4287     | .4115     | .4115     |           | .442      |
| 8    | .4115     | .3963     |           | .4508     |           |           | .4115     |
| 9    |           |           | .2286     |           | .4382     | .3048     | .3048     |
| 10   | .2774     |           | .2134     |           |           | .2286     | .2439     |
| 11   | .2254     | .2286     | .2286     |           |           | .2286     | .2134     |
| 12   |           |           | .1981     |           | .3506     |           | .2134     |
| 13   | .2454     |           | .2134     |           |           |           | .1829     |
| 14   |           |           | .2286     |           |           |           | .1829     |
| 15   | .2279     | .2286     | .1981     |           | .2601     |           |           |
| 16   |           | .1981     | .2134     |           |           | .2134     |           |
| 17   |           |           | .2286     |           | .1829     |           | .1829     |
| 18   | .1981     | .2427     | .2286     |           | .1981     | .2629     | .2134     |
| 19   | 3.3436    |           | 3.6523    |           | 3.9438    |           | 3.3608    |
| 20   | 2.8292    |           | 3.1722    | .4268     | 3.5665    | 3.4294    | 3.1207    |
| 21   | 2.5206    | 2.7435    |           | 3.2922    |           | 3.0178    | 2.7435    |
| 22   | 2.4006    |           | 2.5034    |           | 3.0182    | 2.572     | 2.4863    |
| 23   | 2.0576    |           |           | .3353     |           | 2.0748    | 2.1434    |
| 24   | .2591     | 1.8861    | 1.9418    | 2.0062    | 2.0405    | 2.3663    | 1.9547    |
| Max  | 3.3436    | 2.7435    | 3.6523    | 3.2922    | 3.9438    | 3.4294    | 3.3608    |
| Min  | .1981     | .1981     | .1981     | .3048     | .1829     | .2134     | .1829     |
| Avg  | .9118     | .7994     | .8645     | 1.0435    | 1.3179    | 1.2892    | 1.0801    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 202 / 11 KV Akole Urban Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0288    | .9259     |           |           |           |           | .8916     |
| 2    | 1.0288    | .9431     |           | 1.0136    | 1.086     |           | .8745     |
| 3    | 1.0288    | .8916     | .9231     |           |           | 1.1765    | .9431     |
| 4    | 1.166     | 1.0288    |           | 1.0498    | 1.1765    |           | 1.4575    |
| 5    | 1.2174    | 1.1831    |           |           |           |           | 1.749     |
| 6    | 1.869     | 1.5604    | 1.6289    | 1.8823    | 1.7737    | 1.7372    | 1.8519    |
| 7    | 1.989     | 1.9547    | 1.9004    | 2.1176    | 2.0452    |           | 1.9376    |
| 8    | 2.0062    | 1.8861    |           | 2.2081    | 2.009     |           | 1.9204    |
| 9    |           |           | 1.8861    | 1.8099    | .3045     | 1.9033    | 2.0633    |
| 10   | 1.6289    |           | 1.8176    |           |           | 1.9376    | 1.6832    |
| 11   | 1.5043    | 1.4299    | 1.5775    |           |           | 1.7147    | 1.4661    |
| 12   |           | 1.3032    | 1.4403    |           | 1.3969    | 1.5089    |           |
| 13   |           |           | 1.3717    |           |           | 1.4575    |           |
| 14   |           |           | 1.2689    |           |           | 1.3546    | 1.2127    |
| 15   | 1.1584    | 1.0679    | 1.2517    |           | 1.3394    | 1.3717    | 1.3756    |
| 16   | 1.1765    | 1.1765    | 1.286     |           |           | 1.406     |           |
| 17   |           |           | 1.5565    |           | 1.5927    |           | 1.4575    |
| 18   | 1.4842    | 1.5927    | 1.5203    |           | 1.5746    | 1.5023    | 1.5089    |
| 19   | 1.8823    |           | 2.0814    |           | 1.9547    |           | 1.8347    |
| 20   | 1.8099    |           | 1.9004    | 2.4434    | 2.0271    | 1.8004    | 1.7147    |
| 21   | 1.5927    | 1.6832    |           | 2.1538    | 1.5927    | 1.7147    | 1.5775    |
| 22   | 1.3889    |           | 1.6289    |           | 1.7194    | 1.4575    | 1.4918    |
| 23   | 1.0974    |           |           | 1.4661    |           | 1.2346    | 1.2003    |
| 24   | 1.0802    | .9259     | 1.0059    | 1.1403    |           | 1.2254    | 1.0288    |
| Max  | 2.0062    | 1.9547    | 2.0814    | 2.4434    | 2.0452    | 1.9376    | 2.0633    |
| Min  | 1.0288    | .8916     | .9231     | 1.0136    | .3045     | 1.1765    | .8745     |
| Avg  | 1.4283    | 1.3035    | 1.5321    | 1.7285    | 1.5423    | 1.5314    | 1.4877    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 203 / 11 KV Tambhol Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1524     | .1524     |           |           |           |           | .1524     |
| 2    | .1524     | .1524     |           | .1524     | .1524     |           | .1524     |
| 3    | .1524     | .1524     | .1753     |           |           | .1734     | .1524     |
| 4    | .1524     | .1524     |           | .1677     | .1829     |           | .1524     |
| 5    | .1524     | .1829     |           |           |           |           | .2286     |
| 6    | .1829     | .2286     | .208      | .2439     | .2439     | .1734     | .2286     |
| 7    | .2286     | .1829     | .208      | .2439     | .2591     |           | .2286     |
| 8    | .1829     | .1524     |           | .2601     | .2058     |           | .1829     |
| 9    |           |           | .1524     | .208      | .1734     | .1524     | .1829     |
| 10   | .1387     |           | .1524     |           |           | .1524     | .1524     |
| 11   | 3.5608    | 3.4294    | 3.4979    |           |           | 3.3951    | 3.858     |
| 12   |           | 3.4979    | 3.4294    |           | 4.1152    | 3.2922    |           |
| 13   | 3.4355    |           | 3.3608    |           |           | 3.0864    |           |
| 14   |           |           | 3.2922    |           |           | 3.0178    | 3.7723    |
| 15   | 3.7723    | 3.1893    | 3.0864    |           | 3.4979    | 3.4294    | 3.6351    |
| 16   | 3.0483    | 3.0864    | 3.155     |           |           | 3.4294    |           |
| 17   |           |           | 3.155     |           | 3.5665    |           | 3.6351    |
| 18   | 2.1262    | 2.7435    | 2.7435    |           | 3.2236    | 3.155     | 3.0864    |
| 19   | .2439     |           | .2439     |           | .2439     |           | .2286     |
| 20   | .2286     |           | .2286     | 2.7435    | .2286     | .1829     | .1829     |
| 21   | .2134     | .2103     |           | .2439     |           | .1829     | .1829     |
| 22   | .1829     |           | .1829     |           | .2103     | .1524     | .1524     |
| 23   | .1524     |           |           | .1829     |           | .1524     | .1524     |
| 24   | .1524     | .1524     | .1753     | .1829     | .1829     | .1753     | .1524     |
| Max  | 3.7723    | 3.4979    | 3.4979    | 2.7435    | 4.1152    | 3.4294    | 3.858     |
| Min  | .1387     | .1524     | .1524     | .1524     | .1524     | .1524     | .1524     |
| Avg  | .9306     | 1.1777    | 1.6145    | .4629     | 1.1776    | 1.5189    | .9930     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 204 / 11 KV Kumbhefal Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2743     | .3353     |           |           |           |           | .2743     |
| 2    | .2743     | .3353     |           | .2439     | .3048     |           | .3048     |
| 3    | .2743     | .2896     | .3121     |           |           | .3121     | .3048     |
| 4    | .3048     | .2896     |           | .2743     | .3353     |           | .3658     |
| 5    | .3201     | .3048     |           |           |           |           | .4268     |
| 6    | .381      | .381      | .4508     | .442      | .4572     | .4908     | .4572     |
| 7    | .4725     | .4725     | .4733     | .4572     | .4572     |           | .503      |
| 8    | .4268     | .4115     |           | .4681     |           |           | .4877     |
| 9    |           |           | .5182     |           | .3856     | .6097     | .2134     |
| 10   | .5201     |           | .5487     |           |           | .6401     | .4572     |
| 11   | 4.0695    | 4.5268    | 4.3381    |           |           | 4.1152    | 4.4582    |
| 12   |           | 1.3717    | 4.3038    |           | 4.6121    | 4.3724    |           |
| 13   | 4.9726    |           | 4.1838    |           |           | 4.4067    |           |
| 14   |           |           | 4.0466    |           |           |           | 4.7497    |
| 15   | 4.7817    | 4.1152    | 4.0638    |           | 4.4086    |           |           |
| 16   |           | 4.2867    | 4.201     |           |           |           |           |
| 17   |           |           | 4.1152    |           | 4.4582    |           | 4.2353    |
| 18   |           | 4.0466    | 3.7551    |           | 4.1152    | 4.1838    | 4.2867    |
| 19   | .4572     | .4508     | .4268     |           | .4268     |           | .4268     |
| 20   | .381      |           | .381      | 3.0864    | .3506     | .3658     | .381      |
| 21   | .3353     | .4508     |           | .3353     |           | .3353     | .3353     |
| 22   | .381      |           | .381      |           | .4031     | .3048     | .3048     |
| 23   | .381      |           |           | .3658     |           | .2743     | .2591     |
| 24   | .2591     | .3353     | .3681     | .2439     | .2591     | .2774     | .2439     |
| Max  | 4.9726    | 4.5268    | 4.3381    | 3.0864    | 4.6121    | 4.4067    | 4.7497    |
| Min  | .2591     | .2896     | .3121     | .2439     | .2591     | .2743     | .2134     |
| Avg  | 1.0704    | 1.4002    | 2.1687    | .6574     | 1.6134    | 1.5914    | 1.1738    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 205 / 11 KV Induri Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1524     | 1.5432    |           |           |           |           | 1.8861    |
| 2    | .1524     | 1.5089    |           | 1.5089    | 1.3717    |           | 1.9033    |
| 3    | .1524     | .1524     | .1753     |           |           | .1753     | .1829     |
| 4    | .1524     | .1524     |           | .2286     | .2134     |           | .1829     |
| 5    | .1829     | .1829     |           |           |           |           | .1829     |
| 6    | .2286     | .2286     | .2103     | .2439     | .2439     | .2103     | .2286     |
| 7    | .2286     | .1829     | .208      | .2591     | .2591     |           | .2286     |
| 8    | .1829     | .1524     |           | .2774     |           |           | .1829     |
| 9    |           |           | .2134     | .1772     | .1734     | .1829     | .2439     |
| 10   | .208      |           | .2439     |           |           | .1829     | .2286     |
| 11   | .1753     | .1524     | .1524     |           |           | .1524     | .1829     |
| 12   |           | .1219     | .1524     |           | .1734     | .1219     | .1677     |
| 13   | .1387     |           | .1524     |           |           | .1524     | .1372     |
| 14   |           |           | .1524     |           |           | .1524     | .1219     |
| 15   | .1402     | .1219     | .1524     |           | .1753     | .1524     |           |
| 16   |           | .1219     | .1524     |           |           | .1524     |           |
| 17   |           |           | .1829     |           | .1524     |           | .1524     |
| 18   | .1219     | .1402     | .2134     |           | .1677     | .1753     | .1524     |
| 19   | 2.5377    |           | 3.0864    |           | 3.0864    |           | 3.0864    |
| 20   | 2.4006    |           | 2.572     | .2743     | 2.7435    | 2.7435    | 2.7778    |
| 21   | 2.0576    | 2.0576    |           | 2.2634    |           | 2.5377    | 2.7092    |
| 22   | 1.9204    |           | 2.0576    |           | 2.332     | 2.4006    | 2.2634    |
| 23   | 1.6461    |           |           | .2439     |           | 2.0576    | 1.7833    |
| 24   | .1524     | 1.5775    | 1.7147    | 1.5775    | 1.5089    | 1.8519    | 1.9204    |
| Max  | 2.5377    | 2.0576    | 3.0864    | 2.2634    | 3.0864    | 2.7435    | 3.0864    |
| Min  | .1219     | .1219     | .1524     | .1772     | .1524     | .1219     | .1219     |
| Avg  | .6806     | .5598     | .6937     | .7054     | .9693     | .8376     | .9503     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 206 / 11 KV Karkhana Express      SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder Feeder KV- 11 / OUTGOING      STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1372     | .12       |           |           |           |           | .1029     |
| 2    | .1372     | .12       |           | .1524     | .1086     |           | .1029     |
| 3    | .1372     | .12       | .1227     |           |           | .1753     | .1029     |
| 4    | .1543     | .12       |           | .1524     | .1448     |           | .12       |
| 5    | .1715     | .1372     |           |           |           |           | .12       |
| 6    | .1886     | .1543     | .1772     | .1829     | .1448     | .2103     | .1543     |
| 7    | .1886     | .1543     | .1595     | .2172     | .1267     |           | .1543     |
| 8    | .1715     | .12       |           | .1433     |           |           | .1543     |
| 9    |           |           | .1372     |           | .1387     | .1372     | .181      |
| 10   | .1578     |           | .1372     |           |           | .1029     | .1448     |
| 11   | .1578     | .1267     | .12       |           |           | .1029     | .1267     |
| 12   |           | .1267     | .1543     |           | .1417     | .1029     | .1086     |
| 13   | .1753     |           | .1372     |           |           | .1029     | .1086     |
| 14   |           |           | .1029     |           |           | .1029     | .1086     |
| 15   | .1595     | .1267     | .1029     |           | .124      | .12       |           |
| 16   |           | .1267     | .1029     |           |           | .12       |           |
| 17   |           |           | .1086     |           | .1086     |           | .1029     |
| 18   |           | .1227     | .1086     |           | .1086     | .1086     | .1029     |
| 19   | .1448     |           | .181      |           | .1086     |           | .1372     |
| 20   | .1629     |           | .2172     | .1448     | .1448     | .1372     |           |
| 21   | .1448     | .1227     |           | .1448     |           | .1372     |           |
| 22   | .1372     |           | .181      |           | .1753     | .12       | .1372     |
| 23   | .1372     |           |           | .1086     |           | .12       | .1372     |
| 24   | .1372     | .1372     | .1417     | .2172     | .1448     | .1949     | .1372     |
| Max  | .1886     | .1543     | .2172     | .2172     | .1753     | .2103     | .181      |
| Min  | .1372     | .12       | .1029     | .1086     | .1086     | .1029     | .1029     |
| Avg  | .1556     | .1290     | .1407     | .1626     | .1323     | .1310     | .1272     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 207 / 11 KV Washere Gfss Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0171     | .0171     |           |           |           |           |           |
| 2    | .0171     | .0171     |           | .0181     | .0181     |           | .0171     |
| 3    | .0171     | .0171     | .0175     |           |           | .0175     | .0171     |
| 4    | .0171     | .0171     |           | .0181     | .0181     |           | .0171     |
| 5    | .0171     | .0171     |           |           |           |           | .0171     |
| 6    | .0343     | .0343     | .0532     | .0543     | .056      | .0351     | .0343     |
| 7    | .0343     | .0343     | .0351     | .0362     | .0362     |           | .0514     |
| 8    | .0171     | .0171     |           | .0351     |           |           | .0343     |
| 9    |           |           | .0343     | .0351     | .0351     | .0343     | .0362     |
| 10   | .0351     |           | .0343     |           |           | .0171     | .0362     |
| 11   | .0351     | .0362     | .0171     |           |           | .0171     | .0362     |
| 12   |           | .0181     | .0171     |           | .0175     | .0171     | .0181     |
| 13   | .0351     |           | .0171     |           |           | .0171     | .0181     |
| 14   |           |           | .0171     |           |           | .0171     | .0181     |
| 15   | .0351     | .0181     | .0171     |           | .0351     | .0171     |           |
| 16   | .0362     | .0181     | .0171     |           |           | .0171     |           |
| 17   |           |           | .0181     |           | .0362     |           | .0171     |
| 18   | .0362     | .0351     | .0362     |           | .0362     | .0351     | .0343     |
| 19   | .0362     |           | .0362     |           | .0543     |           | .0343     |
| 20   | .0362     |           | .0362     | .0362     | .0362     | .0171     | .0343     |
| 21   | .0362     | .0351     |           | .0362     |           | .0171     | .0343     |
| 22   | .0171     |           | .0181     |           | .0351     | .0171     | .0171     |
| 23   | .0171     |           |           | .0181     |           | .0171     | .0171     |
| 24   | .0171     | .0171     | .0177     | .0181     | .0181     | .0351     | .0171     |
| Max  | .0362     | .0362     | .0532     | .0543     | .056      | .0351     | .0514     |
| Min  | .0171     | .0171     | .0171     | .0181     | .0175     | .0171     | .0171     |
| Avg  | .0272     | .0233     | .0259     | .0306     | .0332     | .0216     | .0265     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 208 / 11 KV Kumbhefal Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1543     | .1372     |           |           |           |           | .1372     |
| 2    | .1543     | .1372     |           | .1267     | .1448     |           | .1372     |
| 3    | .1543     | .1372     | .1448     |           |           | .1629     | .1372     |
| 4    | .1886     | .1715     |           | .1448     | .181      |           | .2058     |
| 5    | .2229     | .2058     |           |           |           |           | .2058     |
| 6    | .3086     | .2572     | .3077     | .3801     | .3439     | .2896     | .3258     |
| 7    | .3772     | .3258     | .3292     | .3801     | .362      |           | .3429     |
| 8    | .3601     | .2915     |           | .3258     | .2926     |           | .3772     |
| 9    |           |           | .2915     | .3109     | .3258     | .3429     | .362      |
| 10   | .2896     |           | .2572     |           |           | .2743     | .3258     |
| 11   | .1991     | .2715     | .1543     |           |           | .2572     | .1991     |
| 12   |           | .181      | .1543     |           | .2172     | .1886     |           |
| 13   |           |           | .1029     |           |           | .1715     |           |
| 14   |           | .181      | .0857     |           |           | .1543     | .1991     |
| 15   | .1629     | .181      | .1029     |           | .128      | .1372     | .181      |
| 16   | .1629     | .3077     | .1029     |           |           | .1372     |           |
| 17   |           |           | .1448     |           | .181      |           | .2058     |
| 18   | .1991     | .1991     | .1991     |           | .1991     | .2172     | .2572     |
| 19   | .3439     |           | .3077     |           | .362      |           | .3772     |
| 20   | .3077     |           | .2715     | .4163     | .3258     | .3429     | .3086     |
| 21   | .2534     | .2534     |           | .2715     | .2926     | .2401     | .2572     |
| 22   | .1886     |           | .1991     |           | .2353     | .1715     | .1715     |
| 23   | .1715     |           |           | .1629     |           | .1372     | .1372     |
| 24   | .1372     | .1372     | .1448     | .1448     | .1629     | .1267     | .1372     |
| Max  | .3772     | .3258     | .3292     | .4163     | .362      | .3429     | .3772     |
| Min  | .1372     | .1372     | .0857     | .1267     | .128      | .1267     | .1372     |
| Avg  | .2282     | .2110     | .1941     | .2664     | .2503     | .2095     | .2375     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 209 / 11 KV Washere Ag

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2003    | .1981     |           |           |           |           | .1981     |
| 2    | 1.2003    | .1981     |           | .1981     | .1981     |           | .1981     |
| 3    | 1.2003    | 1.0117    | 1.0631    |           |           | 1.3717    | 2.3148    |
| 4    | 1.2003    | 1.286     |           | 1.1145    | 1.6461    |           | 2.1948    |
| 5    | 1.2003    | 1.3717    |           |           |           |           | 2.2291    |
| 6    | 1.4746    | 1.7833    | 2.6063    | 2.4006    | .3963     | 2.5377    | 2.2291    |
| 7    | 1.9376    | 2.8121    | 3.3913    | 3.2236    | .442      |           | 3.0693    |
| 8    | 2.692     |           |           | 3.6626    |           |           | 3.4637    |
| 9    |           |           | 3.4294    |           | 3.5947    | 3.3093    | 3.7894    |
| 10   | 2.0919    |           | 2.8635    |           |           | 3.2922    | 2.4863    |
| 11   | .2103     | .2286     | .1524     |           |           | .1829     | .1677     |
| 12   |           |           | .1677     |           | .2103     |           | .1372     |
| 13   | .1578     |           | .1524     |           |           |           | .1372     |
| 14   |           |           | .1067     |           |           |           | .1219     |
| 15   | .1402     | .1524     | .1219     |           | .1578     |           |           |
| 16   |           | .1524     | .1219     |           |           | .1524     |           |
| 17   |           |           | .1372     |           | .1372     |           | .1372     |
| 18   |           | .2454     | .1524     |           | .1677     | .2629     | .1829     |
| 19   | .3963     |           | .381      |           | .3963     |           | .4115     |
| 20   | .381      |           | .381      | .4115     | .3658     | .381      | .381      |
| 21   | .3658     | .4207     |           | .381      |           | .381      | .3353     |
| 22   | .3201     |           | .3048     |           | .3988     | .3048     | .3048     |
| 23   | .2591     |           |           | .2591     |           | .2286     | .2743     |
| 24   | 1.2174    | .2134     | .2454     | .2134     | .2134     | .2454     | .1981     |
| Max  | 2.692     | 2.8121    | 3.4294    | 3.6626    | 3.5947    | 3.3093    | 3.7894    |
| Min  | .1402     | .1524     | .1067     | .1981     | .1372     | .1524     | .1219     |
| Avg  | .9803     | .7749     | .9281     | 1.3183    | .6403     | 1.0542    | 1.1346    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014026 / 33 / 11 KV AKOLE SUB STATION

Feeder No / Name : 210 / 11 KV Tambhol GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0686     | .0686     |           |           |           |           | .0686     |
| 2    | .0686     | .0857     |           | .0724     | .0543     |           | .0686     |
| 3    | .0686     | .0686     | .0724     |           |           | .1734     | .0686     |
| 4    | .1029     | .0686     |           | .0905     | .0905     |           | .1029     |
| 5    | .1029     | .1029     |           |           |           |           | .12       |
| 6    | .1372     | .12       | .1267     | .1448     | .1267     | .1254     | .1543     |
| 7    | .1715     | .1372     | .1463     | .1991     | .1448     |           | .1715     |
| 8    | .1543     | .12       |           | .1448     | .1433     |           | .1715     |
| 9    |           |           | .1715     | .1448     | .1629     | .12       | .1448     |
| 10   | .1433     |           | .2572     |           |           | .2401     | .1991     |
| 11   | .3258     | .181      | .1886     |           |           | .2058     | .1991     |
| 12   |           | .181      | .0857     |           | .0549     | .1715     |           |
| 13   | .0362     |           | .1029     |           |           | .1372     |           |
| 14   |           |           | .1715     |           |           | .1715     | .181      |
| 15   | .1448     | .181      | .1715     |           | .0905     | .0857     | .181      |
| 16   | .1629     | .1629     | .1715     |           |           | .1886     |           |
| 17   |           |           | .181      |           | .0905     |           | .1886     |
| 18   | .1086     | .1791     | .1086     |           | .0905     | .1086     | .0857     |
| 19   | .1629     |           | .1991     |           | .1629     |           | .1372     |
| 20   | .1448     |           | .1629     |           | .1629     | .1372     | .12       |
| 21   | .1086     | .1463     |           | .1448     |           | .12       | .0857     |
| 22   | .1029     |           | .0905     |           | .1463     | .0857     | .0686     |
| 23   | .0686     |           |           | .0724     |           | .0686     | .0686     |
| 24   | .0686     | .0686     | .0732     | .1448     | .0543     | .0549     | .0686     |
| Max  | .3258     | .181      | .2572     | .1991     | .1629     | .2401     | .1991     |
| Min  | .0362     | .0686     | .0724     | .0724     | .0543     | .0549     | .0686     |
| Avg  | .1226     | .1248     | .1459     | .1287     | .1125     | .1371     | .1264     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014027 / 33 / 11 KV SAMSHERPUR SUB

STAT

Feeder No / Name : 201 / 11 KV Deothan Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1294     | 1.8214    | 3.407     | 1.8915    | 3.8554    | 3.8661    | 4.5039    |
| 2    | .1109     | 1.6065    | 3.1762    | 1.7955    | 3.5787    | 3.629     | 3.7684    |
| 3    | .1109     |           | .1294     |           | .1334     | .1334     | .1334     |
| 4    | .1294     |           | .1294     |           | .1334     | .1334     | .1294     |
| 5    | .1294     |           | .1109     |           | .2904     | .1334     | .1294     |
| 6    | .3109     | .1539     | .291      | .1738     | .3216     | .2248     | .1949     |
| 7    | .3892     | .1783     | .3307     | .1783     | .298      | .3026     | .3093     |
| 8    | .2054     | .233      | .1431     | .1614     | .0823     | .1761     | .308      |
| 9    | .1294     | .1294     | .1294     |           | .1441     | .141      | .1995     |
| 10   |           | .1294     | .137      |           |           | .138      | .1425     |
| 11   |           | .0185     | .0185     |           |           | .0572     |           |
| 14   |           | .0185     |           |           |           |           |           |
| 15   |           | .037      |           |           |           | .0191     |           |
| 16   |           | .0185     |           |           |           |           | .0396     |
| 17   |           |           |           |           | .0381     |           | .0457     |
| 18   | 2.1536    | 2.5629    | 2.428     |           | 2.5873    | 2.7755    | 2.3167    |
| 19   | 2.7252    | 5.5156    | 2.7359    | 5.0633    | 5.49      | 3.2236    | 4.8468    |
| 20   | 2.4996    | 5.1612    | 2.3929    | 5.8695    | 5.4367    | 2.7846    | 5.2042    |
| 21   | 2.3457    | 4.3791    | 2.3929    | 5.5837    | 4.8583    | 2.6825    | 2.2969    |
| 22   | 2.1872    | 3.995     | 2.0607    | 4.8667    | 4.3919    | 2.3884    | 4.004     |
| 23   | 2.0073    | 3.7593    | 2.0256    | 4.4551    | 4.116     | 2.2756    | 3.9667    |
| 24   | 4.1001    | 1.858     | 3.7298    | 2.0988    | 4.0619    | 4.8537    | 4.5062    |
| Max  | 4.1001    | 5.5156    | 3.7298    | 5.8695    | 5.49      | 4.8537    | 5.2042    |
| Min  | .1109     | .0185     | .0185     | .1614     | .0381     | .0191     | .0396     |
| Avg  | 1.2290    | 1.7542    | 1.4316    | 2.9216    | 2.3422    | 1.5757    | 1.9498    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014027 / 33 / 11 KV SAMSHERPUR SUB

STAT

Feeder No / Name : 203 / 11 KV Samsherpur Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7621     |
| Max  | .7621     |
| Min  | .7621     |
| Avg  | .7621     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014027 / 33 / 11 KV SAMSHERPUR SUB

STAT

Feeder No / Name : 204 / 11 KV Khirwire Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014027 / 33 / 11 KV SAMSHERPUR SUB

STAT

Feeder No / Name : 205 / 11 Kv Deothan GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0537     |           | .0549     |           | .0724     | .0537     | .0739     |
| 2    | .0543     |           | .0543     |           | .0537     | .0537     | .1254     |
| 3    | .0537     |           | .0543     |           | .0549     | .0537     | .128      |
| 4    | .0716     |           | .0924     |           | .056      | .056      | .1646     |
| 5    | .1417     |           | .1848     |           | .0934     | .112      | .1612     |
| 6    | .197      |           | .1829     |           | .1949     | .197      | .197      |
| 7    | .2507     |           | .2353     |           | .2534     | .2957     | .2804     |
| 8    | .2126     | .2481     | .2254     | .2303     | .2481     | .2865     | .2454     |
| 9    | .1865     | .2481     | .1492     |           | .2103     | .1875     | .1865     |
| 10   |           | .1457     | .144      |           |           | .1475     | .1619     |
| 11   | .1492     | .1357     | .1311     |           |           | .1067     | .1187     |
| 12   |           | .1017     | .08       |           |           | .104      | .112      |
| 13   |           | .0838     | .0972     |           |           | .0829     | .1174     |
| 14   |           | .0838     | .08       |           |           | .0983     | .096      |
| 15   |           | .0838     | .08       |           |           | .0949     | .096      |
| 16   |           | .08       | .1219     |           | .1187     | .1406     | .1311     |
| 17   |           | .1265     | .1204     |           | .1526     | .181      | .1311     |
| 18   |           | .1389     |           |           | .1886     |           | .125      |
| 19   |           | .1753     |           | .2713     | .1254     |           | .1907     |
| 20   |           | .1772     |           | .208      | .1254     |           | .1949     |
| 21   |           | .1063     |           | .1448     | .1052     |           | .156      |
| 22   |           | .0895     |           | .1097     | .0867     |           | .1372     |
| 23   | .1097     | .0709     |           | .0732     | .0716     |           | .0709     |
| 24   | .0732     |           | .0532     |           | .0732     | .0537     | .0537     |
| Max  | .2507     | .2481     | .2353     | .2713     | .2534     | .2957     | .2804     |
| Min  | .0537     | .0709     | .0532     | .0732     | .0537     | .0537     | .0537     |
| Avg  | .1295     | .1310     | .1190     | .1729     | .1269     | .1281     | .1440     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014027 / 33 / 11 KV SAMSHERPUR SUB

STAT

Feeder No / Name : 206 / 11 KV samsherpur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1372     |
| Max  | .1372     |
| Min  | .1372     |
| Avg  | .1372     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 201 / 11 KV Virgaon Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2058     |           | .2058     |           |           |           |
| 2    | .12       |           |           | .2058     |           | .2058     |
| 3    |           | .2401     |           |           | .2058     |           |
| 4    |           |           | .2401     | .2103     |           |           |
| 6    |           |           |           |           | .3086     | .1357     |
| 7    |           |           | .3772     | .3429     |           |           |
| 8    |           | .3429     | .3086     | .3429     | .3429     | .1715     |
| 9    | .2401     | .2058     |           |           |           |           |
| 11   |           |           |           | 3.0933    |           |           |
| 12   |           | 2.8704    |           | 2.5911    | 3.2769    |           |
| 13   | 2.7435    |           |           |           |           | 3.3196    |
| 14   |           |           |           |           | 2.9492    |           |
| 16   |           | 2.5911    | 2.8837    | 3.0178    |           |           |
| 17   | 2.774     |           |           |           |           |           |
| 18   |           |           | 1.4746    |           |           | 2.6216    |
| 19   |           | .3086     |           |           |           |           |
| 20   | .3429     |           |           | .3429     |           | .2743     |
| 21   |           | .3155     |           |           |           |           |
| 22   |           |           |           | .2401     |           |           |
| 23   | .2743     |           |           |           |           |           |
| 24   | .2058     | .2401     | 2.9058    | .2058     | .2058     | 1.065     |
| Max  | 2.774     | 2.8704    | 2.9058    | 3.0933    | 3.2769    | 3.3196    |
| Min  | .12       | .2058     | .2058     | .2058     | .2058     | .1357     |
| Avg  | .8633     | .8893     | 1.1994    | 1.0593    | 1.2149    | 1.1134    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 203 / 11 KV Ganore Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6882     |           | .1372     |           |           |           |
| 2    | .6706     |           |           | .1696     |           | .1696     |
| 3    |           | .7011     |           |           | .7011     |           |
| 4    |           |           | .6706     | .8718     |           |           |
| 6    |           |           |           |           | 1.1279    | 1.1469    |
| 7    |           |           | 1.7985    | 1.9662    |           |           |
| 8    |           |           | 2.2253    | 2.0081    | 2.2862    | 2.4577    |
| 9    | 2.2939    |           |           |           |           |           |
| 11   |           |           |           | .1029     |           |           |
| 12   |           | .0686     |           | .0686     | .0351     | .0671     |
| 13   | .0343     |           |           |           |           | .0678     |
| 14   |           |           |           |           | .0671     |           |
| 16   |           | .0686     | .0701     | .0686     |           |           |
| 17   | .0686     |           |           |           |           |           |
| 18   |           |           | .2058     |           |           | .1029     |
| 19   |           | .2401     |           |           |           |           |
| 20   | .2743     |           |           | .2401     |           | .2713     |
| 21   |           | .2401     |           |           |           |           |
| 22   |           |           |           | .2058     |           |           |
| 23   | .2058     |           |           |           |           |           |
| 24   | .7202     | .2058     | .0701     | .1638     | .1715     | .1715     |
| Max  | 2.2939    | .7011     | 2.2253    | 2.0081    | 2.2862    | 2.4577    |
| Min  | .0343     | .0686     | .0701     | .0686     | .0351     | .0671     |
| Avg  | .6195     | .2541     | .7397     | .5866     | .7315     | .5569     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 204 / 11 KV Ganore Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0943     |           | .0953     |           |           |           |
| 2    | .112      |           |           | .0934     |           | .1132     |
| 3    |           | .1143     |           |           | .1143     |           |
| 4    |           |           | .12       | .1132     |           |           |
| 6    |           |           |           |           | .2229     | .2641     |
| 7    |           |           | .2572     | .2801     |           |           |
| 8    |           |           | .2401     | .2858     | .2477     | .2427     |
| 9    | .2241     |           |           |           |           |           |
| 11   |           |           |           | .2096     |           |           |
| 12   |           | .1143     |           | .1143     | .1132     | .1132     |
| 13   | .1524     |           |           |           |           | .0754     |
| 14   |           |           |           |           | .0914     |           |
| 16   |           | .1334     | .112      | .0953     |           |           |
| 17   | .1524     |           |           |           |           |           |
| 18   |           |           | .1867     |           |           | .2054     |
| 19   |           | .2401     |           |           |           |           |
| 20   | .2477     |           |           | .2667     |           | .2641     |
| 21   |           | .1905     |           |           |           |           |
| 22   |           |           |           | .1524     |           |           |
| 23   | .1143     |           |           |           |           |           |
| 24   | .0934     | .1143     | .0943     | .1132     | .1143     | .1463     |
| Max  | .2477     | .2401     | .2572     | .2858     | .2477     | .2641     |
| Min  | .0934     | .1143     | .0943     | .0934     | .0914     | .0754     |
| Avg  | .1488     | .1512     | .1579     | .1724     | .1506     | .1781     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 205 / 11 KV Gardani GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0747     |           | .0762     |           |           |           |           |
| 2    | .0747     |           |           | .0747     | .0732     |           | .0747     |
| 3    |           | .0953     |           |           |           | .0762     |           |
| 4    |           |           | .1143     |           | .0747     |           |           |
| 6    |           |           |           |           |           | .12       | .1494     |
| 7    |           |           | .12       |           | .112      |           |           |
| 8    |           | .1029     | .1334     |           | .1294     | .1029     | .1097     |
| 9    | .1478     | .12       |           |           |           |           |           |
| 11   |           |           |           |           | .0762     |           |           |
| 12   |           | .0762     |           |           | .0572     | .0747     | .056      |
| 13   | .0381     |           | .056      |           |           |           | .0549     |
| 14   |           |           |           |           |           | .056      |           |
| 16   |           | .0381     | .056      |           | .0572     |           |           |
| 17   | .0514     |           |           |           |           |           |           |
| 18   |           |           | .0554     |           |           |           | .0739     |
| 19   |           | .0762     |           |           |           |           |           |
| 20   | .0762     |           |           |           | .12       | .1097     | .0934     |
| 21   |           | .0953     |           |           |           |           |           |
| 22   |           |           |           |           | .0953     |           |           |
| 23   | .0762     |           |           |           |           |           |           |
| 24   | .0934     | .0762     | .0762     |           | .0747     | .0762     | .0914     |
| Max  | .1478     | .12       | .1334     | .0747     | .1294     | .12       | .1494     |
| Min  | .0381     | .0381     | .0554     | .0747     | .0572     | .056      | .0549     |
| Avg  | .0791     | .0850     | .0859     | .0747     | .0870     | .0880     | .0879     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 206 / 11 KV Tambhol Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2797     | 1.0052    | 2.0812    | 1.1325    | 1.3481    | 1.2315    | 1.0433    |
| 2    | .2671     | .948      | 1.1126    | 1.0501    | 2.2672    | 1.1713    | 1.8359    |
| 3    | .1501     | .2881     | .1471     | .1372     | .1593     | .2919     | .1357     |
| 4    | .1585     | .1593     | .2724     | .1501     | .2927     | .1585     | .1372     |
| 5    | .1654     | .1753     | .1669     | .16       | .1844     | .1814     | .1539     |
| 6    | .1951     | .1936     | .1753     | .1806     | .2012     | .3658     | .3387     |
| 7    | .2195     | .2012     | .3479     | .1829     | .3966     | .2042     | .1951     |
| 8    | .1905     | .3288     | .3117     | .157      | .3317     | .3357     | .3346     |
| 9    | .2721     | .2114     | .1425     | .1196     | .1417     | .1364     | .1128     |
| 10   | .1021     | .0899     | .1021     |           | .1219     | .1135     | .0884     |
| 11   | .0122     | .0815     | .061      |           | .1044     | .0937     |           |
| 12   | .0091     | .0099     | .0434     |           | .0998     | .0884     | .0259     |
| 13   | .0008     | .0046     |           |           | .093      | .0846     | .0107     |
| 14   | .0091     | .003      |           |           | .0876     | .0838     | .0533     |
| 15   | .003      | .0114     | .0244     |           | .0914     | .0838     | .0732     |
| 16   | .0069     | .0152     | .0038     |           | .0671     | .0831     | .0533     |
| 17   | .08       | .0168     | .0457     |           | .0274     | .0724     | .0655     |
| 18   | 1.8656    | 1.9166    | 2.0325    | .1052     | 2.0759    | 2.0271    | 1.981     |
| 19   | 2.2077    | 4.5108    | 2.1422    | 1.8397    | 2.742     | 2.3259    | 2.6528    |
| 20   | 3.2137    | 2.2169    | 1.8237    | 2.351     | 4.2486    | 2.2367    | 4.3027    |
| 21   | 1.4716    | 3.2636    | 1.7558    | 2.1978    | 2.1232    | 1.861     | 1.861     |
| 22   | 1.3702    | 1.669     | 1.6065    | 1.9563    | 3.1772    | 1.6362    | 1.6911    |
| 23   | 2.146     | 1.4487    | 1.3611    | 1.6065    | 1.6179    | 1.3237    | 1.4434    |
| 24   | 1.2064    | 2.1537    | 2.2497    | 1.4685    | 2.4349    | 2.1879    | 2.3316    |
| Max  | 3.2137    | 4.5108    | 2.2497    | 2.351     | 4.2486    | 2.3259    | 4.3027    |
| Min  | .0008     | .003      | .0038     | .1052     | .0274     | .0724     | .0107     |
| Avg  | .6501     | .8718     | .8186     | .9247     | 1.0181    | .7658     | .9096     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 208 / 11 kv Hivergaon feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1372     |           | .1715     |           |           |           |
| 2    | .1372     |           |           | .2572     |           | .1715     |
| 3    |           | .2229     |           |           | .2401     |           |
| 4    |           |           | .2401     | .3086     |           |           |
| 6    |           |           |           |           | .2229     | .3086     |
| 7    |           |           | .3086     | .3258     |           |           |
| 8    |           |           | .2743     | .2515     | .2743     | .3467     |
| 9    | .3121     |           |           |           |           |           |
| 11   |           |           |           | 1.9608    |           |           |
| 12   |           | 1.6964    |           | 2.0119    | 1.704     | 1.704     |
| 13   | 2.0729    |           |           |           |           | 1.6712    |
| 14   |           |           |           |           | 1.587     |           |
| 16   |           | 1.6766    | 1.6385    | 1.5242    |           |           |
| 18   |           |           | .9172     |           |           | 1.4251    |
| 19   |           | .3772     |           |           |           |           |
| 20   | .4287     |           |           | .4115     |           | .4458     |
| 21   |           | .3429     |           |           |           |           |
| 22   |           |           |           | .3086     |           |           |
| 23   | .2743     |           |           |           |           |           |
| 24   | .1372     | .2058     | 1.6129    | .2058     | .2058     | .2401     |
| Max  | 2.0729    | 1.6964    | 1.6385    | 2.0119    | 1.704     | 1.704     |
| Min  | .1372     | .2058     | .1715     | .2058     | .2058     | .1715     |
| Avg  | .4999     | .7536     | .7376     | .7566     | .7057     | .7891     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014028 / 33 / 11 KV VIRGAON SUB

STATION

Feeder No / Name : 209 / 11 kv pimpalgaon Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .583      |           |           |           |           |           |
| 2    | .5243     |           |           |           |           |           |
| 3    |           | .6081     |           |           | .6401     |           |
| 4    |           |           | .5487     | .7907     |           |           |
| 6    |           |           |           |           | .945      | 1.0486    |
| 7    |           |           | 1.2193    | 1.7078    |           |           |
| 8    |           | 1.829     | 1.6766    | 2.0972    | 2.0729    | 2.079     |
| 9    | 1.8107    | 1.5851    |           |           |           |           |
| 19   |           | .1543     |           |           |           |           |
| 20   | .1715     |           |           | .1543     | .1311     | .1886     |
| 21   |           | .1543     |           |           |           |           |
| 22   |           |           |           | .1372     |           |           |
| 23   | .1448     |           |           |           |           |           |
| 24   | .6036     |           |           |           |           |           |
| Max  | 1.8107    | 1.829     | 1.6766    | 2.0972    | 2.0729    | 2.079     |
| Min  | .1448     | .1543     | .5487     | .1372     | .1311     | .1886     |
| Avg  | .6397     | .8662     | 1.1482    | .9774     | .9473     | 1.1054    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014094 / 33 / 11 KV KELI SANGAVI SUB

ST

Feeder No / Name : 201 / 11 KV Kombhalne Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0655     | .6097     | .6859     | .7373     | .7621     | .7621     | .8029     |
| 2    | .0819     | .6097     | .6859     | .7373     | .7316     | .7164     | .7537     |
| 3    | .0819     | .1067     |           | .0819     | .1372     | .0762     | .0819     |
| 4    | .0791     | .0762     | .061      | .0819     | .1219     | .0762     | .0819     |
| 5    | .0983     | .0762     | .0914     | .0983     | .1067     | .0762     | .0819     |
| 6    | .1311     | .1067     | .1219     | .1475     | .1219     | .1067     | .1311     |
| 7    | .1638     | .1219     | .1524     | .1802     | .1372     | .1524     | .1739     |
| 8    | .1147     | .1067     | .1067     | .1311     | .1219     | .1219     | .1475     |
| 9    | .1311     | .1067     |           | .1147     | .1219     | .0914     | .1147     |
| 10   | .0762     | .1067     | .0983     |           | .0762     | .0983     | .0914     |
| 11   | .0762     | .061      | .0655     |           | .061      | .0819     | .0762     |
| 12   | .0457     | .061      | .0655     |           | .0457     | .0655     | .061      |
| 13   | .0457     | .0305     | .0492     |           | .0457     | .0655     | .0457     |
| 14   | .0457     | .0305     | .0492     |           | .0457     | .0655     | .0457     |
| 15   | .0305     | .0457     | .0328     |           | .0457     | .0655     | .0305     |
| 16   | .0457     | .0457     | .0492     |           | .0457     | .0492     | .061      |
| 17   | .0457     | .0914     | .0655     |           | .0457     | .0655     | .061      |
| 18   | .0762     | .1067     | .0983     |           | .061      | .0655     | .061      |
| 19   | .9602     | 1.0974    | 1.1469    | 1.2803    | 1.2498    | 1.2944    | .9145     |
| 20   | .9145     | 1.0669    |           | 1.2041    | 1.1279    | 1.1469    | 1.0974    |
| 21   | .8535     | 1.0059    | .9667     | 1.1736    | .9755     | 1.1961    | .9755     |
| 22   | .6554     | .8993     | .9175     | 1.0212    | .9145     | 1.0322    | .8993     |
| 23   |           | .7468     | .8356     | .884      | .8688     | .9831     | .8383     |
| 24   | .0655     | .1067     | .6859     | .8029     | .8078     | .7926     | .8848     |
| Max  | .9602     | 1.0974    | 1.1469    | 1.2803    | 1.2498    | 1.2944    | 1.0974    |
| Min  | .0305     | .0305     | .0328     | .0819     | .0457     | .0492     | .0305     |
| Avg  | .2124     | .3093     | .3348     | .5784     | .3658     | .3853     | .3547     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014094 / 33 / 11 KV KELI SANGAVI SUB

ST

Feeder No / Name : 202 / 11 KV Tirde Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014094 / 33 / 11 KV KELI SANGAVI SUB

ST

Feeder No / Name : 203 / 11 KV Ekdara Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.1431    |
| Max  | 1.1431    |
| Min  | 1.1431    |
| Avg  | 1.1431    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014094 / 33 / 11 KV KELI SANGAVI SUB  
STFeeder No / Name : 204 / 11 KV Kombalane GFSS  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1829     |
| Max  | .1829     |
| Min  | .1829     |
| Avg  | .1829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014102 / 33 / 11 KV RUMBHODI AMBAD

SUB

Feeder No / Name : 201 / 11 KV Ambad Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1829     | .2229     | .1829     | .2134     | .2401     | .2134     | .2134     |
| 2    | .1829     | .2915     | .1829     | .2134     | .2401     | .2134     | .2134     |
| 3    | .1829     | .2229     | .2134     | .2134     | .2401     | .2401     | .2134     |
| 4    | .1829     | .2743     | .2743     | .2134     | .2743     | .2134     | .2134     |
| 5    | .2743     | .3772     | .3048     | .2439     | .7202     | .2743     | .2134     |
| 6    | .3353     | .4287     | .381      | .3048     | .4801     | .3048     | .2439     |
| 7    | .3963     | .4973     | .3963     | .381      | .5144     | .3658     | .3353     |
| 8    |           |           | .3353     | .2896     |           | .3048     | .3048     |
| 9    |           |           | .2743     | .2439     |           | .2439     | .2439     |
| 10   | .2286     | .2439     | .3086     |           | .2401     | .1829     | .1981     |
| 11   | 2.6216    | 2.2862    | 2.713     |           | 3.493     | 2.5911    | 2.2405    |
| 12   | 2.5453    | 2.4082    | 2.5434    |           | 3.0483    | 2.5606    | 2.2862    |
| 13   | 2.5911    | 2.271     | 2.2043    |           | 2.8045    | 1.829     | 2.713     |
| 14   | 2.5606    | 2.2253    | 2.4756    |           | 2.713     | 2.2862    | 2.713     |
| 15   | 2.5149    | 2.0424    | 2.5434    |           | 2.5606    | 2.21      | 2.5434    |
| 16   | 2.4691    | 2.21      | 2.5434    |           | 2.4996    | 2.1795    | 2.3739    |
| 17   | 2.4996    | 2.2558    | 2.4078    |           | 2.3472    | 2.3167    | 2.3061    |
| 18   | 2.5434    | 1.7985    | 1.829     |           | 2.0729    | 1.9814    | 2.1195    |
| 19   | .823      | .2591     | .2439     | 2.8147    | .2743     | .2743     | .3086     |
| 20   | .823      | .3048     | .3963     | .3429     | .3658     | .3353     | .3086     |
| 21   | .3086     | .2743     | .3963     | .2743     | .3658     | .2743     | .2743     |
| 22   | .2743     | .2439     | .3658     | .2743     | .2439     | .2439     | .2401     |
| 23   | .2401     | .2286     | .2439     | .2401     | .2439     | .2439     | .2401     |
| 24   | .2401     |           | .1829     | .2401     |           | .2134     | .2401     |
| Max  | 2.6216    | 2.4082    | 2.713     | 2.8147    | 3.493     | 2.5911    | 2.713     |
| Min  | .1829     | .2229     | .1829     | .2134     | .2401     | .1829     | .1981     |
| Avg  | 1.1373    | 1.0175    | .9976     | .4335     | 1.2372    | .9207     | .9709     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014102 / 33 / 11 KV RUMBHODI AMBAD

SUB

Feeder No / Name : 202 / 11 KV Ambad GFSS Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0457     | .0514     | .0686     | .0514     | .0686     | .0514     | .0686     |
| 2    | .0686     | .0514     | .0686     | .0514     |           | .0514     | .0514     |
| 3    | .0686     | .0686     | .0686     | .0514     | .0686     | .0514     | .0514     |
| 4    | .0686     | .0857     | .1029     | .0686     | .0857     | .0514     | .0514     |
| 5    | .1029     | .1029     | .1029     | .0686     | .1029     | .0514     | .0514     |
| 6    | .12       | .12       | .1372     | .12       | .12       | .0762     | .0857     |
| 7    | .1372     | .1372     | .1715     | .1029     | .1372     | .1372     | .1543     |
| 8    | .1372     | .12       | .1715     | .12       | .12       | .1372     | .1372     |
| 9    | .1372     | .12       | .12       | .0914     | .1029     | .12       | .1372     |
| 10   | .1029     | .1029     |           |           | .12       | .1067     | .1029     |
| 11   | .0686     | .0686     |           |           | .0686     | .0857     | .0857     |
| 12   | .0686     | .0514     |           |           | .0457     | .0514     | .0514     |
| 13   | .0686     | .0514     |           |           | .0514     | .0514     | .0514     |
| 14   | .0343     | .0343     |           |           | .0457     | .0343     | .0343     |
| 15   | .0343     | .0343     | .0514     |           | .0514     | .0343     | .0343     |
| 16   | .0343     | .0343     | .0514     |           | .0343     | .0514     | .0514     |
| 17   | .0686     | .0343     | .0686     |           | .0514     | .0343     | .0686     |
| 18   | .0857     | .0686     | .0686     |           | .0762     | .0857     | .0857     |
| 19   | .1372     | .1372     | .12       | .1372     | .1029     | .12       | .1372     |
| 20   | .12       | .1715     | .1543     | .1372     | .1372     | .1372     | .1372     |
| 21   | .0857     | .1372     | .1372     | .1372     | .1372     | .0857     | .1029     |
| 22   | .0686     | .1372     | .1372     | .12       | .0857     | .0857     | .0857     |
| 23   | .0686     | .1029     | .0857     | .1029     | .0857     | .0686     | .0686     |
| 24   | .0514     |           | .0686     | .0857     |           | .0686     | .0686     |
| Max  | .1372     | .1715     | .1715     | .1372     | .1372     | .1372     | .1543     |
| Min  | .0343     | .0343     | .0514     | .0514     | .0343     | .0343     | .0343     |
| Avg  | .0826     | .0880     | .1029     | .0964     | .0863     | .0762     | .0814     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014102 / 33 / 11 KV RUMBHODI AMBAD

SUB

Feeder No / Name : 203 / 11 kv Induri Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0364    | 1.2003    | .9907     | 1.1584    | 1.4582    | 1.0669    | 1.0669    |
| 2    | .9145     | 1.2003    | .9145     | 1.1279    | 1.153     | 1.0669    | 1.0669    |
| 3    | .1829     | .2058     | .1829     | .2134     | .2058     | .2134     | .2134     |
| 4    | .1829     | .2572     | .1829     | .2134     | .2058     | .2134     | .2134     |
| 5    | .2439     | .2915     | .2134     | .2134     | .2401     | .2134     | .2134     |
| 6    | .2743     | .3258     | .2439     | .2439     | .2743     | .2743     | .2743     |
| 7    | .3048     | .3772     | .2743     | .3048     | .3429     | .3048     | .3048     |
| 8    | .2439     | .3086     | .2743     | .2743     | .2743     | .2743     | .2743     |
| 9    | .1829     | .2401     | .2439     | .2439     | .2058     | .2439     | .2439     |
| 10   | .1524     | .1829     | .2401     |           | .1372     | .2439     | .2439     |
| 11   | .1219     | .1219     | .1372     |           | .1372     | .1524     | .1829     |
| 12   | .1219     | .1219     | .12       |           | .1067     | .1219     | .1219     |
| 13   | .1219     | .1219     | .12       |           | .1219     | .1219     | .1372     |
| 14   | .1067     | .1067     | .12       |           | .1219     | .1219     | .1372     |
| 15   | .1067     | .1067     | .12       |           | .1219     | .1219     | .12       |
| 16   | .1067     | .1219     | .12       |           | .1219     | .1219     | .12       |
| 17   | .1219     | .1067     | .1372     |           | .1219     | .1219     | .12       |
| 18   | .1372     | .1524     | 2.2253    | 2.572     | .1372     | .1829     | .1372     |
| 19   | 2.1365    | 2.1338    | 2.2253    | 2.5434    | 2.3472    | 2.1948    | 2.4417    |
| 20   | 2.0348    | 1.829     | 1.9509    | 2.3739    | 1.9204    | 1.9814    | 2.3739    |
| 21   | 1.6956    | 1.5242    | 1.6766    | 2.0576    | 1.5242    | 1.5242    | 2.0348    |
| 22   | 1.5261    | 1.448     | 1.5242    | 1.8652    | 1.3717    | 1.2193    | 1.6956    |
| 23   | 1.3565    | 1.3717    | 1.4632    | 1.5939    | 1.2803    | 1.1584    | 1.3565    |
| 24   | 1.1869    |           | 1.1584    | 1.5261    |           | 1.1584    | 1.1869    |
| Max  | 2.1365    | 2.1338    | 2.2253    | 2.572     | 2.3472    | 2.1948    | 2.4417    |
| Min  | .1067     | .1067     | .12       | .2134     | .1067     | .1219     | .12       |
| Avg  | .6083     | .6025     | .7025     | 1.1578    | .6057     | .6008     | .6784     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014102 / 33 / 11 KV RUMBHODI AMBAD

SUB

Feeder No / Name : 204 / 11 KV Induri GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .061      | .0686     | .0686     | .061      | .0686     | .0686     | .0686     |
| 2    | .0686     | .0686     | .0686     | .0686     | .0686     | .0686     | .0686     |
| 3    | .0686     | .0686     | .0686     | .0686     | .0686     | .0686     | .0686     |
| 4    | .0686     | .0857     | .1029     | .0686     | .0857     | .0686     | .0686     |
| 5    | .1029     | .12       | .1029     | .1029     | .1372     | .0857     | .0686     |
| 6    | .1372     | .1543     | .1372     | .1372     | .1715     | .12       | .1029     |
| 7    | .1715     | .2058     | .1715     | .2058     | .2058     | .1543     | .1543     |
| 8    | .1715     | .1715     | .1715     | .1715     | .1372     | .1372     | .1543     |
| 9    | .1219     | .1372     | .12       | .1524     | .1372     | .12       | .1372     |
| 10   | .1029     | .1029     | .12       |           | .1029     | .0686     | .1029     |
| 11   | .0686     | .0686     | .0857     |           | .0857     | .0686     | .1029     |
| 12   | .0686     | .0686     | .0686     |           | .0686     | .0686     | .061      |
| 13   | .0686     | .0686     | .0514     |           | .0514     | .0686     | .0857     |
| 14   | .12       | .0457     | .0343     |           | .0514     | .0686     | .0686     |
| 15   | .0343     | .0514     | .0686     |           |           | .0514     | .0686     |
| 16   | .0343     | .0686     | .0686     |           | .061      | .0514     | .0686     |
| 17   | .0686     | .0514     | .0686     |           | .0762     | .0686     | .0686     |
| 18   | .0857     | .0686     | .1029     | .1372     | .1029     | .1029     | .0686     |
| 19   | .1543     | .1372     | .1219     | .1372     | .12       | .1372     | .1372     |
| 20   | .1372     | .1715     | .1524     | .12       | .1543     | .1715     | .1543     |
| 21   | .1029     | .1372     | .1715     |           | .1543     | .12       | .1372     |
| 22   | .0857     | .1372     | .1543     |           | .12       | .0857     | .12       |
| 23   | .0857     | .1029     | .12       | .0857     | .0762     | .0762     | .0857     |
| 24   | .0686     |           | .0686     | .0857     |           | .0857     | .0686     |
| Max  | .1715     | .2058     | .1715     | .2058     | .2058     | .1715     | .1543     |
| Min  | .0343     | .0457     | .0343     | .061      | .0514     | .0514     | .061      |
| Avg  | .0941     | .1026     | .1029     | .1145     | .1048     | .0911     | .0954     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014102 / 33 / 11 KV RUMBHODI AMBAD

SUB

Feeder No / Name : 205 / 11 KV MEHENDURI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1431    | 1.2689    | .9907     | 1.0669    | 1.2689    | 1.0669    | 1.0669    |
| 2    | 1.1279    | 1.2689    | .945      | 1.0669    | 1.2003    | 1.0669    | 1.0669    |
| 3    | .1829     | .2915     | .1829     | .1829     | .2058     | .1829     | .1829     |
| 4    | .1829     | .3429     | .1829     | .2743     | .2058     | .1829     | .1829     |
| 5    | .2134     | .3429     | .1829     | .3048     | .3086     | .1829     | .1829     |
| 6    | .2743     | .4801     | .2439     | .3658     | .4115     | .2439     | .2439     |
| 7    | .381      | .583      | .2743     | .3048     | .5144     | .3048     | .3048     |
| 8    |           |           | .2439     | .2743     |           | .2439     | .2439     |
| 9    |           |           | .2134     | .2439     |           | .2134     | .2134     |
| 10   | .1524     | .2134     | .2058     |           | .2058     | .2134     | .2134     |
| 11   | .1219     | .1524     | .1543     |           | .1715     | .1524     | .1524     |
| 12   | .1219     | .1715     | .1372     |           | .1219     | .1829     | .1219     |
| 13   | .1219     | .1219     | .1372     |           | .1219     | .1219     | .1372     |
| 14   | .1067     | .1219     | .12       |           | .1219     | .1219     | .1372     |
| 15   | .1067     | .1219     | .1886     |           | .1219     | .1067     | .1372     |
| 16   | .1067     | .1219     | .1886     |           | .1219     | .1067     | .1372     |
| 17   | .1219     | .2438     | .2058     |           | .1219     | .1067     | .1372     |
| 18   | .1372     | .1524     | .1524     |           | .1219     | .1524     | .1372     |
| 19   | 2.1704    | 1.9814    | 2.0729    | 2.1026    | 2.3472    | 2.4387    | 2.5774    |
| 20   | 2.0348    | 1.7071    | 1.89      | 2.0348    | 1.829     | 2.21      | 2.2043    |
| 21   | 1.933     | 1.5242    | 1.5242    | 1.8519    | 1.5242    | 1.6766    | 1.8652    |
| 22   | 1.6956    | 1.2955    | 1.3413    | 1.5432    | 1.2803    |           | 1.6956    |
| 23   | 1.5939    | 1.1431    | 1.2193    | 1.5432    | 1.1888    | 1.0974    | 1.4922    |
| 24   | 1.4327    |           | 1.0669    | 1.3565    |           | 1.1279    | 2.4234    |
| Max  | 2.1704    | 1.9814    | 2.0729    | 2.1026    | 2.3472    | 2.4387    | 2.5774    |
| Min  | .1067     | .1219     | .12       | .1829     | .1219     | .1067     | .1219     |
| Avg  | .7029     | .6500     | .5860     | .9678     | .6436     | .5871     | .7191     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014112 / 33/11 KV LINGDEO SUBSTATION

Feeder No / Name : 201 / 11 KV LAHIT FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3048     | .4382     | .4572     | .4382     | 2.3015    | .4382     | .4191     |
| 2    | .3048     | .4382     | .4572     | .4382     | 2.1795    | .4382     | .4191     |
| 3    | .2858     | .4382     | .4572     | .4572     | .2858     | .4191     | .4191     |
| 4    | .3429     | .4572     | .4572     | .5144     | .3048     | .4382     | .4191     |
| 5    | .4001     | .4763     | .4763     | .5144     | .3429     | .4572     | .4191     |
| 6    | .4763     | .4763     | .4954     | .5335     | .4001     | .4572     | .4382     |
| 7    | .4763     | .4763     | .5335     | .5335     | .4763     |           | .4954     |
| 8    | .4191     | .4763     | .4763     |           | .4191     | .4572     |           |
| 9    |           |           | .3048     | .3239     |           | .3429     |           |
| 10   | .2286     | .2477     | .2286     |           | .2286     | .2286     | .2477     |
| 11   |           |           | 2.8197    |           | 2.8349    | .2286     | 3.0788    |
| 12   | 3.3532    | 3.4332    | 3.0331    |           | 2.9874    | .2286     | 3.2769    |
| 13   | 3.3684    | 3.8104    | 2.9874    |           | 3.094     | 3.3448    | 2.8959    |
| 14   | 3.3989    | 3.1493    | 2.9416    |           | 2.8807    | 3.3684    | 2.6978    |
| 15   | 3.3836    | 3.1459    | 2.8654    |           | 2.8197    | 3.3448    | 2.7282    |
| 16   | 2.9111    | 3.1255    | 2.8045    |           | 2.6063    | 3.504     | 2.774     |
| 17   | 3.0483    | 2.9959    | 2.6673    |           | 2.5911    | 3.4537    | 2.8349    |
| 18   | 2.7282    | 2.7692    | 2.4234    |           | 2.1948    | 3.1017    | 3.1398    |
| 19   | .5144     | .4954     | .4954     |           | .5144     | .4763     | .4763     |
| 20   | .5335     | .5144     | .4763     | .4572     | .4954     | .4763     | .4572     |
| 21   | .5144     | .5144     | .4763     | .4191     | .4954     |           | .4382     |
| 22   | .4954     | .4954     | .4763     | .4572     | .4572     |           | .4191     |
| 23   | .4763     | .4763     | .4572     | 2.4387    | .4382     |           | .4191     |
| 24   | .3429     | .4382     | .4763     | .4572     | 2.4234    | .4382     | .4191     |
| Max  | 3.3989    | 3.8104    | 3.0331    | 2.4387    | 3.094     | 3.504     | 3.2769    |
| Min  | .2286     | .2477     | .2286     | .3239     | .2286     | .2286     | .2477     |
| Avg  | 1.2867    | 1.3313    | 1.2393    | .6141     | 1.4683    | 1.2821    | 1.3333    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014112 / 33/11 KV LINGDEO SUBSTATION

Feeder No / Name : 202 / 11 KV CHASS FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9814    | .362      | .362      | .381      | .3239     | .3429     | .3429     |
| 2    | 2.0729    | .362      | .362      | .362      | .3239     | .3429     | .3429     |
| 3    | 2.1643    | 1.9951    | 2.431     | 2.2405    | 2.0729    | 2.5606    | 2.5149    |
| 4    | 2.271     | 2.0454    | 2.7161    | 2.2862    | 2.3472    | 2.6978    | 2.7999    |
| 5    | 2.3777    | 2.2801    | 2.8837    | 2.6368    | .381      | 2.8197    | 3.2047    |
| 6    | 2.5911    | 2.5652    | 3.219     | 2.8197    | .4572     | 2.9264    | 3.3913    |
| 7    | 2.8654    | 3.4202    | 3.5208    | 2.9721    | .4763     |           | 3.5208    |
| 8    | 3.0788    | 2.8837    | 3.3867    | 3.1398    | .4191     | .7621     | 3.4873    |
| 9    |           | 3.5376    | 3.1398    |           | 3.2617    | .7164     | 3.1093    |
| 10   | 2.4691    | 3.3699    | 2.8197    |           | 2.8349    | 2.6063    | 2.8349    |
| 11   | .1905     |           | .2667     |           | .1905     | 2.7692    | .2096     |
| 12   | .1715     | .2096     | .2477     |           | .2096     |           |           |
| 13   | .1715     | .1905     | .2477     |           | .2477     | .1905     | .1905     |
| 14   |           | .1905     | .2667     |           | .2477     | .2096     | .1905     |
| 15   | .1715     | .1905     | .2858     |           | .2477     | .2286     | .1715     |
| 16   | .2286     | .1905     | .2858     |           | .2477     | .2286     | .1715     |
| 17   | .2286     | .2286     | .2858     |           | .2286     | .2286     | .1715     |
| 18   | .3048     | .4954     | .2286     |           | .2286     | .2286     | .2286     |
| 19   | .4572     | .4954     | .4763     |           | .4763     | .4191     | .4954     |
| 20   | .5335     | .5144     | .4763     | .4382     | .5144     | .4763     | .4954     |
| 21   | .5144     | .4954     | .4572     | .4382     | .4572     |           | .4763     |
| 22   | .4763     | .4763     | .4382     | .4191     | .381      |           | .4572     |
| 23   | .4191     | .4191     | .4191     | .3239     | .3429     |           | .4191     |
| 24   | 2.1293    | .362      | .362      | .4191     | .3239     | .3429     | .3429     |
| Max  | 3.0788    | 3.5376    | 3.5208    | 3.1398    | 3.2617    | 2.9264    | 3.5208    |
| Min  | .1715     | .1905     | .2286     | .3239     | .1905     | .1905     | .1715     |
| Avg  | 1.2668    | 1.1861    | 1.2327    | 1.4520    | .7184     | 1.1104    | 1.2856    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

AKOLE[209]

BU 5789

Substation No/ Name :- 014112 / 33/11 KV LINGDEO SUBSTATION

Feeder No / Name : 203 / 11 KV LINGDEO GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0857     | .0905     | .0857     | .0857     | .0857     | .0905     |
| 2    | .0686     | .0905     | .0686     | .0857     | .0857     | .0905     |
| 3    | .0686     | .0905     | .0857     | .0857     | .0857     | .0905     |
| 4    | .0857     | .0905     | .0857     | .1029     | .1029     | .0905     |
| 5    | .12       | .1267     | .12       | .1372     | .1372     | .1086     |
| 6    | .1543     | .1629     | .1372     | .1715     | .1715     | .181      |
| 7    | .2058     | .2172     | .1543     | .2058     |           | .2172     |
| 8    | .2229     | .2172     |           | .2058     | .2229     | .181      |
| 9    |           | .2229     | .1886     |           | .2058     | .1543     |
| 10   | .1715     | .1715     |           | .2743     | .1543     | .1029     |
| 11   | .12       | .1372     |           | .1886     | .1629     | .0686     |
| 12   | .1029     | .1029     |           | .1543     | .1629     |           |
| 13   | .1029     | .0686     |           | .12       | .0905     | .12       |
| 14   | .1029     | .0857     |           | .1372     | .0905     | .1029     |
| 15   | .1029     | .0857     |           | .12       | .0905     | .0857     |
| 16   | .1029     | .0857     |           | .1372     | .1086     | .1029     |
| 17   | .1029     | .12       |           | .1029     | .1334     | .12       |
| 18   | .1372     | .12       |           | .1372     | .1448     | .1715     |
| 19   | .1886     | .1886     |           | .2229     | .1829     | .2058     |
| 20   | .1715     | .1715     | .2401     | .2058     | .181      | .2058     |
| 21   | .1543     | .1372     | .2058     | .1543     |           | .1543     |
| 22   | .12       | .1029     | .1715     | .1372     |           | .12       |
| 23   | .1029     | .0857     | .12       | .1029     |           | .12       |
| 24   | .0905     | .0905     | .0857     | .1029     | .0857     | .0905     |
| Max  | .2229     | .2229     | .2401     | .2743     | .2229     | .2172     |
| Min  | .0686     | .0686     | .0686     | .0857     | .0857     | .0686     |
| Avg  | .1255     | .1276     | .1345     | .1469     | .1343     | .1293     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 201 / 11 Kv Shingve

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3658     | .4115     | .3772     | .3814     |           | .3467     |           |
| 2    | .3658     | .4115     | .3772     | .3814     |           | .3467     |           |
| 3    | .3658     | .4287     | .3944     | .3814     |           | .3467     |           |
| 4    | .4024     | .4287     | .4287     | .4161     |           | .3467     |           |
| 5    | .4024     | .4458     | .4287     | .4334     |           | .3467     |           |
| 6    | .439      | .4458     | .463      | .4334     |           | .3814     |           |
| 7    | .439      |           | .4801     | .4681     |           | .4161     |           |
| 8    |           | .4115     |           | .4161     |           | .3814     |           |
| 16   | 2.2634    |           | 2.2634    |           |           | 2.915     | 2.1262    |
| 17   | 2.0062    | 2.452     | 2.2805    | 1.9547    | 3.0007    |           |           |
| 18   | 2.0405    | 2.2977    | 2.2291    | 2.7435    | 2.8635    |           | 1.9376    |
| 19   | 2.1434    | 2.1434    | 2.2119    | 2.6235    | 2.8635    |           | 1.5261    |
| 20   |           | .3814     | .4287     |           |           | .463      | .2229     |
| 21   |           | .4115     | .4458     |           |           |           | .2229     |
| 22   |           | .4508     | .4458     |           |           |           | .2058     |
| 23   |           | .4161     | .4287     |           |           |           | .1886     |
| 24   | 2.0424    | .3814     | .3944     |           | .3294     | .3772     | 1.6289    |
| Max  | 2.2634    | 2.452     | 2.2805    | 2.7435    | 3.0007    | 2.915     | 2.1262    |
| Min  | .3658     | .3814     | .3772     | .3814     | .3294     | .3467     | .1886     |
| Avg  | 1.1063    | .7945     | .8799     | .9666     | 2.2643    | .6061     | 1.0074    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 202 / 11 Kv Kanhegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5609     | .583      | .583      | .583      | .5144     | .5487     |           |
| 2    | .5609     | .5658     | .583      | .583      | .5487     | .5487     |           |
| 3    | .5959     | .5658     | .6344     | .6516     | .5487     | .5487     |           |
| 4    | .6661     | .5316     | .6687     | .6516     | .5487     | .5487     |           |
| 5    | .8589     | .7373     | .9088     | .8059     | .823      | .7888     |           |
| 6    | .964      | .823      | 1.166     | .9945     | 1.2003    | 1.166     |           |
| 7    | 1.1919    |           | 1.286     | 1.286     | 1.5775    | 1.2689    |           |
| 8    | 1.4723    | 1.3546    | 1.6118    | 1.5089    | 1.7147    | 1.4746    |           |
| 16   | .0857     |           | .1029     |           |           |           | .0686     |
| 17   | .0857     | .104      | .0857     | .1214     | .104      | .0686     | .1029     |
| 18   | .1372     | .1907     | .2229     | .1387     | .1387     | .1372     | .12       |
| 19   | .2572     | .2427     | .2401     | .2427     | .2254     | .2401     | .2743     |
| 20   | .2401     | .2427     | .2572     | .2254     | .2427     | .2401     | .3086     |
| 21   | .2229     | .208      | .2401     | .208      | .1907     | .2058     | .2915     |
| 22   | .1886     | .1734     | .2401     | .1734     | .1734     | .2058     | .2572     |
| 23   | .1543     | .156      | .1543     | .156      | .1387     | .1543     | .2229     |
| 24   | .4001     | .583      | .3429     | .5144     | .5144     | .5487     | .2058     |
| Max  | 1.4723    | 1.3546    | 1.6118    | 1.5089    | 1.7147    | 1.4746    | .3086     |
| Min  | .0857     | .104      | .0857     | .1214     | .104      | .0686     | .0686     |
| Avg  | .5084     | .4708     | .5487     | .5528     | .5753     | .5434     | .2058     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 203 / 11 Kv Appegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5609     | .5487     | .6001     | .6001     | .6001     | .6001     |           |
| 2    | .5609     | .5487     | .6001     | .6001     | .6001     | .6001     |           |
| 3    | .5959     | .5487     | .6344     | .6001     | .6001     | .6001     |           |
| 4    | .7011     | .5487     | .6687     | .7202     | .6001     | .6344     |           |
| 5    | .7712     | .6344     | .7373     | .7545     | .7202     | .7373     |           |
| 6    | .8764     | .7202     | .8916     | .9602     | .9259     | .9945     |           |
| 7    | .9465     |           | .9774     | 1.0974    | 1.0974    | 1.0631    |           |
| 8    | 1.0166    | 1.0974    | 1.166     | 1.2346    | 1.2003    | 1.3203    |           |
| 9    |           |           |           |           |           | 1.1393    | .9991     |
| 10   |           |           |           |           |           | .1829     | .1829     |
| 11   |           |           |           |           |           | .1097     |           |
| 12   |           |           |           |           |           | .1097     |           |
| 13   |           |           |           |           |           | .0732     |           |
| 14   |           |           |           |           |           | .0732     |           |
| 15   |           |           |           |           |           | .0732     |           |
| 16   | .0857     |           | .0686     |           |           | .1029     | .1029     |
| 17   | .0857     | .0693     | .0686     | .104      | .0867     | .1029     | .1029     |
| 18   | .12       | .1734     | .1715     | .1387     | .1214     | .1029     | .1029     |
| 19   | .2401     | .2601     | .2229     | .2427     | .2427     | .2401     | .2229     |
| 20   | .2572     | .2601     | .2572     | .2601     | .2601     | .2401     | .2572     |
| 21   | .2572     | .2254     | .2229     | .2254     | .2427     | .2572     | .2572     |
| 22   | .1886     | .1734     | .1715     | .208      | .1907     | .2229     | .2743     |
| 23   | .12       | .1387     | .1372     | .1387     | .1387     | .1543     | .2229     |
| 24   | .2915     | .6001     | .583      | .6344     | .6068     | .5316     | .2229     |
| Max  | 1.0166    | 1.0974    | 1.166     | 1.2346    | 1.2003    | 1.3203    | .9991     |
| Min  | .0857     | .0693     | .0686     | .104      | .0867     | .0732     | .1029     |
| Avg  | .4515     | .4365     | .4811     | .5325     | .5146     | .4278     | .2680     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 204 / 11 Kv Puntamba

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0732     | .1029     | .1029     | .104      | .1214     | .1214     |           |
| 2    |           | .12       | .1029     | .104      | .1214     | .1214     |           |
| 3    | .0732     | .12       | .1029     | .104      | .1214     | .1214     |           |
| 4    | .1097     | .12       | .12       | .1214     | .1214     | .1214     |           |
| 5    | .1097     | .1372     | .12       | .1214     | .1214     | .1214     |           |
| 6    | .1097     | .1372     | .12       | .1214     | .1387     | .1387     |           |
| 7    | .1463     |           | .12       | .156      | .156      | .1734     |           |
| 8    | .1097     | .12       | .1029     | .156      | .156      | .1734     |           |
| 9    |           |           |           |           |           | .1463     |           |
| 10   |           |           |           |           |           | .1463     |           |
| 11   |           |           |           |           |           | .0732     |           |
| 16   | 1.8004    |           | 1.9204    |           |           | 2.1262    | 2.2291    |
| 17   | 1.6975    | 1.8004    | 1.8347    | 2.0919    | 2.1605    | 2.0576    | 1.8861    |
| 18   | 1.5432    | 1.8004    | 1.8004    | 1.989     | 2.1262    | 2.1091    | 1.7661    |
| 19   |           | 1.7661    | 1.7661    | 1.9376    | 1.9719    | 1.9376    | 1.8861    |
| 20   | .1543     | .1214     | .12       | .1734     | .1387     | .1543     | .1372     |
| 21   | .1372     | .1387     | .12       | .156      | .1214     | .12       | .12       |
| 22   | .1029     | .1214     | .1029     | .1387     | .1387     | .12       | .0686     |
| 23   | .1029     | .104      | .12       | .1387     | .1387     | .1372     | .0686     |
| 24   | 1.0155    | .104      | .1029     | .1214     | .1214     | .1029     | 1.7833    |
| Max  | 1.8004    | 1.8004    | 1.9204    | 2.0919    | 2.1605    | 2.1262    | 2.2291    |
| Min  | .0732     | .1029     | .1029     | .104      | .1214     | .0732     | .0686     |
| Avg  | .4857     | .4542     | .5164     | .4834     | .4985     | .5162     | 1.1050    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 205 / Savantsar GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1494     | .1494     | .1698     | .168      | .1494     | .1509     |           |
| 2    | .1494     | .1494     | .168      | .168      | .1494     | .1509     |           |
| 3    | .2054     | .1494     | .2054     | .168      | .1494     | .1509     |           |
| 4    | .2641     | .168      | .2427     | .2054     | .2054     | .2054     |           |
| 5    | .3395     | .2427     | .3174     | .2801     | .2801     | .2614     |           |
| 6    | .3772     | .3547     | .3921     | .3734     | .3395     | .3395     |           |
| 7    | .415      |           | .4108     | .3961     | .3961     | .4294     |           |
| 8    | .3772     | .3772     | .3395     | .2641     | .3772     | .3772     |           |
| 16   | .2012     |           | .1646     |           |           | .2012     | .2033     |
| 17   | .1991     | .2149     | .181      | .2172     | .1848     | .2149     | .2195     |
| 18   | .2303     | .3475     | .2402     | .2987     | .2402     | .2353     | .2195     |
| 19   | .3982     | .4066     | .3584     | .4108     | .3881     | .362      | .3801     |
| 20   | .3475     | .3734     | .3547     | .3547     | .3395     | .3658     | .3174     |
| 21   | .3142     | .2614     | .3174     | .2772     | .2829     | .2896     | .2801     |
| 22   | .2218     | .2241     | .2572     | .2402     | .2263     | .2572     | .2218     |
| 23   | .1867     | .1698     | .1595     | .1848     | .1886     | .168      | .2033     |
| 24   | .1734     | .1698     | .168      | .168      | .1698     | .1494     | .1848     |
| Max  | .415      | .4066     | .4108     | .4108     | .3961     | .4294     | .3801     |
| Min  | .1494     | .1494     | .1595     | .168      | .1494     | .1494     | .1848     |
| Avg  | .2676     | .2506     | .2616     | .2609     | .2542     | .2535     | .2478     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014011 / 33/11 KV WARI SUBSTATION

Feeder No / Name : 401 / Sommaya Chemical Exp NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2801     |
| Max  | .2801     |
| Min  | .2801     |
| Avg  | .2801     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 201 / 11 Kv Ukkadgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9175     | 1.1453    | .3856     | 1.278     | 1.3927    | 1.3375    | 1.0978    |
| 2    | 1.0322    | .1179     | .4024     | 1.3927    | 1.4091    | 1.4403    | 1.1469    |
| 3    | 1.0978    | 1.2631    | .4191     | 1.6057    | 1.4419    |           | 1.1797    |
| 4    | 1.1469    | 1.3474    | .4527     | 1.7368    | 1.4746    |           | 1.2452    |
| 5    | 1.0822    | 1.5326    | .503      | 1.8023    | 1.5729    | 1.6461    | 1.3108    |
| 6    | 1.4918    | 1.7516    | .5801     | 1.9006    | 1.749     |           | 1.5223    |
| 7    | 1.9334    |           | .7373     | 2.1136    | 2.3967    |           |           |
| 8    | 2.2939    |           | 1.6194    | 2.1136    | 2.6882    | 3.0007    |           |
| 9    | 1.7368    |           | 1.6518    | 1.5729    | 2.0729    | 2.0062    | 2.2119    |
| 16   | .2997     |           | .5258     | .4481     |           | .3361     | .3944     |
| 17   | .2997     |           | .5144     | .5601     | .5144     | .3921     | .4287     |
| 18   | .3996     | .132      | .5144     | .5601     | .5144     | .5601     | .4287     |
| 19   | .621      |           | .5144     | .5601     | .5144     | .5601     | .5144     |
| 20   | .5875     | .2427     | .5144     | .5601     | .5144     | .5601     | .5144     |
| 21   | .4532     | .1524     | .5144     | .5601     | .4801     | .5415     | .5144     |
| 22   | .4196     | .1334     | .5144     | .5716     |           | .5281     | .5144     |
| 23   | .3861     | .1334     | .4801     | .4572     | .3944     | .5335     | .5144     |
| 24   | .3201     | 1.1322    | .3856     | 1.1633    | 1.3927    | 1.2689    | 1.065     |
| Max  | 2.2939    | 1.7516    | 1.6518    | 2.1136    | 2.6882    | 3.0007    | 2.2119    |
| Min  | .2997     | .1179     | .3856     | .4481     | .3944     | .3361     | .3944     |
| Avg  | .9177     | .757      | .6239     | 1.1643    | 1.2827    | 1.0508    | .9127     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 202 / 11 Kv Dahgaon Bolka

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2622     | .4721     | .4641     | .4801     | .4024     | .4115     | .4024     |
| 2    | .2949     | .4721     | .4641     | .4915     | .4024     | .4115     | .4359     |
| 3    | .3277     | .5058     | .4973     | .5243     | .4359     |           | .4359     |
| 4    | .3605     | .5396     | .4973     | .5898     | .4694     |           | .5228     |
| 5    | .3658     | .607      | .5304     | .6554     | .6036     | .6516     | .5304     |
| 6    | .823      | .7419     | .852      | .852      | .7956     |           | .852      |
| 7    | .9831     |           | 1.3108    | 1.2452    | 1.1797    |           |           |
| 8    | 1.3763    |           | 1.6194    | 1.5729    | 1.6194    | 1.6461    |           |
| 9    | 1.0486    |           | 1.2452    | 1.2452    | 1.2452    | 1.2346    | 1.1797    |
| 16   | .5058     | .5601     | .4908     | .3734     |           | .5228     | .2804     |
| 17   | .5064     |           | .4801     | .5228     | .5144     | .5601     | .0876     |
| 18   | .5064     | .5601     | .5144     | .5228     | .5144     | .5228     | .5144     |
| 19   | .5064     |           | .5144     | .5601     | .5144     | .5601     | .5144     |
| 20   | .5058     |           | .4801     | .3734     | .5144     | .4481     | .4115     |
| 21   | .4384     | .5716     | .3429     | .3734     | .4458     | .4481     | .4801     |
| 22   | .4047     | .381      | .3086     | .381      |           | .3772     | .4115     |
| 23   | .3368     | .3048     | .0686     | .3048     | .3429     | .3048     | .3429     |
| 24   | .5468     | .4721     | .5335     | .3932     | .4024     | .4115     | .4024     |
| Max  | 1.3763    | .7419     | 1.6194    | 1.5729    | 1.6194    | 1.6461    | 1.1797    |
| Min  | .2622     | .3048     | .0686     | .3048     | .3429     | .3048     | .0876     |
| Avg  | .5611     | .5157     | .623      | .6367     | .6501     | .6079     | .4878     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 203 / 11Kv Padhegaon SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3277     | .4051     | .5967     | .4752     | .3856     | .4287     |           |
| 2    | .3605     | .4389     | .6299     | .5079     | .4191     | .463      |           |
| 3    | .463      | .4721     | .663      | .6001     | .4527     |           |           |
| 4    | .4572     | .5058     | .7293     | .6062     | .503      |           |           |
| 5    | .4877     | .607      | .8356     | .639      | .6299     | .7202     |           |
| 6    | .6706     | .7934     | 1.1469    | .9339     | .8848     |           |           |
| 7    | 1.065     |           | 1.6842    | 1.6057    | 1.4575    |           |           |
| 8    | 1.5074    |           | 1.7814    | 1.8187    | 1.7976    | 1.8519    |           |
| 9    | 1.1305    |           | 1.2616    | 1.1797    | 1.3435    | 1.2517    | 1.2289    |
| 16   | .2026     | .1867     | .2103     | .1886     |           | .2263     | .1578     |
| 17   |           | .2614     | .2401     | .2614     | .2401     | .2452     | .2229     |
| 18   | .2363     | .3174     | .2743     | .3361     | .2401     | .2801     | .2785     |
| 19   | .4215     | .5228     | .463      |           | .4115     | .4108     | .4801     |
| 20   | .4215     | .4481     | .4115     | .4668     | .3944     | .4294     | .463      |
| 21   | .3541     | .381      | .4458     | .3921     | .3086     | .3361     | .4382     |
| 22   | .2866     | .2858     | .2572     | .3048     |           | .3018     | .4287     |
| 23   | .2023     | .2477     | .2058     | .2286     | .1886     | .2477     | .4115     |
| 24   | .3113     | .3878     | .5801     | .4424     | .3856     | .3944     | .4024     |
| Max  | 1.5074    | .7934     | 1.7814    | 1.8187    | 1.7976    | 1.8519    | 1.2289    |
| Min  | .2023     | .1867     | .2058     | .1886     | .1886     | .2263     | .1578     |
| Avg  | .5239     | .4174     | .6898     | .6463     | .6277     | .5420     | .4512     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 204 / Ukkadgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0914     | .0953     | .0953     | .0914     | .1143     | .1029     | .0953     |
| 2    | .0983     | .1334     | .1143     | .1097     | .1143     | .12       | .1143     |
| 3    | .1463     | .1524     | .1334     | .1646     | .1524     |           | .1334     |
| 4    | .1715     | .1698     | .1715     | .2195     | .1715     |           | .1524     |
| 5    | .2058     | .1867     | .2286     | .2378     | .2096     | .2058     | .2096     |
| 6    | .2229     | .2378     | .2477     | .2743     | .3048     |           | .2667     |
| 7    | .2572     |           | .2858     | .2743     | .2286     |           |           |
| 8    | .2195     |           | .2427     | .2012     | .2667     | .1715     |           |
| 9    | .1715     | .1829     | .1905     | .1829     | .2054     | .1543     | .2012     |
| 10   |           | .1663     | .2012     | .2772     | .12       | .1307     | .2378     |
| 11   |           |           | .2378     | .2149     |           | .2561     | .2195     |
| 12   | .0724     | .1848     | .2241     | .2218     | .2103     | .2172     |           |
| 13   | .0543     | .2149     | .2012     | .1294     | .1907     | .2012     | .2012     |
| 14   |           | .197      | .2012     | .0747     |           | .2012     | .0732     |
| 15   | .0549     | .197      | .1949     | .0934     | .1907     | .2012     | .0549     |
| 16   | .0732     | .2241     | .2012     | .0747     |           | .2012     | .0549     |
| 17   | .104      | .112      | .1829     | .1307     | .1928     | .2195     | .0709     |
| 18   | .1402     | .1663     | .1772     | .168      | .2572     | .2715     | .128      |
| 19   | .2629     | .2587     | .2378     | .2614     | .2103     | .2054     | .2378     |
| 20   | .2218     | .2402     | .1867     | .2054     | .1907     | .2402     | .2378     |
| 21   | .1663     | .1715     | .1646     | .1886     | .1543     | .2054     | .1829     |
| 22   | .1494     | .1524     | .1307     | .1524     |           | .1509     | .1646     |
| 23   | .0943     | .1143     | .1097     | .1334     | .1052     | .1334     | .128      |
| 24   | .0934     | .0953     | .0953     | .0857     | .1143     | .0876     | .1143     |
| Max  | .2629     | .2587     | .2858     | .2772     | .3048     | .2715     | .2667     |
| Min  | .0543     | .0953     | .0953     | .0747     | .1052     | .0876     | .0549     |
| Avg  | .1463     | .1740     | .1857     | .1736     | .1852     | .1839     | .1561     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 205 / Dahegaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0732     | .0762     | .0762     | .0732     | .0762     | .0686     |           |
| 2    | .0732     | .0953     | .0762     | .0686     | .0953     | .0857     |           |
| 3    | .0914     | .1143     | .0953     | .0914     | .0953     |           | .1143     |
| 4    | .12       | .132      | .1334     | .128      | .1334     |           | .1334     |
| 5    | .1543     | .1509     | .1905     | .1867     | .1715     | .1543     | .1524     |
| 6    | .1494     | .2054     | .1715     | .1646     | .2477     |           | .2096     |
| 7    | .1029     |           | .1334     | .1097     | .2286     |           |           |
| 8    | .2012     |           | .2096     | .1829     | .2096     | .1214     |           |
| 9    | .1463     | .2241     | .2096     | .1646     | .1867     | .1372     | .1646     |
| 10   |           | .112      | .1463     | .1307     | .1029     | .1307     | .128      |
| 11   |           | .0934     | .0914     | .0924     |           | .0934     | .0732     |
| 12   | .0739     | .0747     | .0549     | .0754     | .0686     | .0924     |           |
| 13   | .0739     | .056      | .0732     | .0754     | .0526     | .0554     | .0549     |
| 14   |           | .0747     | .0747     | .0754     |           | .0747     | .0732     |
| 15   | .0747     | .0934     | .0549     | .0934     | .0857     | .0747     | .0549     |
| 16   | .0732     | .0924     | .0732     | .112      |           | .0747     | .0732     |
| 17   | .0905     | .1478     | .128      | .1307     | .1214     | .1307     | .0914     |
| 18   | .1086     | .1478     | .1829     | .1494     | .12       | .1109     | .1097     |
| 19   | .2172     | .2218     | .1715     | .2241     | .2058     | .2587     | .1646     |
| 20   | .2054     | .2218     | .168      | .2054     | .1715     | .1867     | .1829     |
| 21   | .1494     | .1524     | .1372     | .168      | .12       | .168      | .1646     |
| 22   | .1307     | .1334     | .112      | .1143     |           | .132      | .128      |
| 23   | .0762     | .0953     | .0747     | .0953     | .0686     | .0953     | .0914     |
| 24   | .0747     | .0762     | .0762     | .0686     | .0953     | .0514     | .0762     |
| Max  | .2172     | .2241     | .2096     | .2241     | .2477     | .2587     | .2096     |
| Min  | .0732     | .056      | .0549     | .0686     | .0526     | .0514     | .0549     |
| Avg  | .1172     | .1269     | .1215     | .1242     | .1328     | .1148     | .1179     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 206 / 11Kv Kasali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3429     | .4051     | .4572     | .3944     | .4572     | .3601     | .4382     |
| 2    | .3429     | .4047     | .4572     | .3944     | .4572     | 1.4403    | .4572     |
| 3    | .3601     | .422      | .4763     | .4115     | .4763     |           | .4763     |
| 4    | .3772     | .422      | .4954     | .4287     | .4954     |           | .4954     |
| 5    | .3944     | .421      | .5335     | .4287     | .5335     | .4801     | .5335     |
| 12   | 1.9074    | 1.3599    | 1.5402    | 1.4255    | 1.3889    | 1.1633    |           |
| 13   | 1.6374    | 1.166     | 1.6712    | 1.3108    | 1.3546    | 1.1142    | 1.2125    |
| 14   |           | 1.085     | 1.7368    | 1.2125    |           | 1.1142    | 1.0486    |
| 15   | 1.2491    |           | 1.3763    | 1.1142    | 1.0631    | .9995     | 1.0159    |
| 16   | 1.3335    |           | 1.3435    | 1.1797    |           | 1.0978    | 1.1469    |
| 17   | 1.3504    |           | 1.2452    | 1.1797    | 1.2003    | 1.2289    | 1.278     |
| 18   | 1.1647    |           | 1.1797    | 1.2289    | 1.1145    | 1.1633    | 1.065     |
| 19   | .8946     | 1.1797    | .9831     | 1.065     | .8916     | .9503     | .8848     |
| 20   | .4716     | .5228     | .4973     | .5228     | .4287     | .5228     | .3772     |
| 21   | .4547     | .5716     | .4458     | .4854     | .3944     | .5228     | .3429     |
| 22   | .4547     | .5716     | .4115     | .4572     |           | .5093     | .2743     |
| 23   | .4215     | .5335     | .3772     | .4954     | .3944     | .5144     | .2229     |
| 24   | .703      | .421      | .4763     | .3772     | .4763     | .3601     | .4763     |
| Max  | 1.9074    | 1.3599    | 1.7368    | 1.4255    | 1.3889    | 1.4403    | 1.278     |
| Min  | .3429     | .4047     | .3772     | .3772     | .3944     | .3601     | .2229     |
| Avg  | .8153     | .6776     | .8724     | .784      | .7418     | .8463     | .6909     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014012 / 33/11 KV DAHGAON BOLKA

Feeder No / Name : 207 / 11Kv Talegaon Male SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3429     | .4047     | .381      | .3429     | .4572     | .3429     | .381      |
| 2    | .3429     | .4047     | .381      | .3429     | .4572     | .3772     | .381      |
| 3    | .3772     | .4384     | .4191     | .3772     | .4763     |           | .4191     |
| 4    | .3944     | .4721     | .4572     | .3944     | .4954     |           | .4572     |
| 5    | .4115     | .4726     | .4572     | .4115     | .5335     | .4801     | .4572     |
| 12   | 2.4476    | 2.2024    | 1.9989    | 1.749     | 1.8176    | 1.6194    |           |
| 13   | 2.6839    |           | 1.8842    | 1.7328    | 1.9448    | 1.5546    | 1.7695    |
| 14   |           |           | 1.7368    | 1.7166    |           | 1.4575    | 1.4582    |
| 15   | 2.0087    | 1.9919    | 1.7204    | 1.6057    | 1.5261    | 1.3272    | 1.3763    |
| 16   | 2.2282    | 2.1862    | 1.7368    | 1.3599    |           | 1.3108    | 1.4746    |
| 17   | 1.8906    | 2.2024    | 1.6057    | 1.4575    | 1.4746    | 1.3435    | 1.5074    |
| 18   | 1.8399    | 1.9757    | 1.491     | 1.3279    | 1.5089    | 1.247     | 1.2125    |
| 19   | 1.0803    | 1.4815    | 1.1633    |           | 1.0974    | 1.0486    | .9831     |
| 20   | .4732     | .5228     | .5144     | .4481     | .4115     | .4481     | .4115     |
| 21   | .4721     | .5335     | .4801     | .4481     | .3772     | .4481     | .3429     |
| 22   | .4721     | .4572     | .4458     | .4572     |           | .4527     | .2743     |
| 23   | .4047     | .4572     | .4115     | .4572     | .3601     | .4572     | .2058     |
| 24   | .3429     | .3709     | .381      | .3429     | .4572     | .3429     | .4191     |
| Max  | 2.6839    | 2.2024    | 1.9989    | 1.749     | 1.9448    | 1.6194    | 1.7695    |
| Min  | .3429     | .3709     | .381      | .3429     | .3601     | .3429     | .2058     |
| Avg  | 1.0714    | 1.0359    | .9814     | .8807     | .893      | .8911     | .7959     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 201 / 11Kv Ravanda GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .2452     |           |           |           |
| 7    | .2263     |           |           | .2075     |
| 8    | .1886     |           |           | .1886     |
| 9    | .1478     |           |           | .1494     |
| 10   | .12       |           |           | .124      |
| 13   |           |           | .0554     |           |
| 14   |           | .0554     | .0549     |           |
| 15   |           | .056      |           |           |
| 16   |           | .0732     | .0895     |           |
| 17   |           | .0924     | .0724     |           |
| 18   |           | .1646     | .0747     |           |
| 19   |           | .1991     | .1663     |           |
| 20   |           | .1867     | .1886     |           |
| 21   |           | .1494     | .1494     |           |
| 22   |           | .1334     | .1132     |           |
| 23   |           | .1132     | .0943     |           |
| 24   | .0943     |           | .0754     | .0762     |
| Max  | .2452     | .1991     | .1886     | .2075     |
| Min  | .0943     | .0554     | .0549     | .0762     |
| Avg  | .1704     | .1223     | .1031     | .1491     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 202 / 11Kv Dhamori  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    | 2.4352    |           |           |           |
| 8    | 2.3403    |           |           |           |
| 9    | 2.3245    |           |           | 2.3644    |
| 10   | .2688     |           |           | .2915     |
| 13   |           |           | .1457     |           |
| 14   |           | .1265     | .1296     |           |
| 15   |           | .1423     | .1296     |           |
| 16   |           | .1423     | .1619     |           |
| 17   |           | .1423     | .1619     |           |
| 18   |           | .2214     | .1781     |           |
| 19   |           | .2846     |           |           |
| 20   |           | .3953     | .2591     |           |
| 21   |           | .3795     | .3725     |           |
| 22   |           | .3637     | .3725     |           |
| 23   |           | .3321     | .3401     |           |
| 24   | 1.9292    |           | 2.1506    | 1.9433    |
| Max  | 2.4352    | .3953     | 2.1506    | 2.3644    |
| Min  | .2688     | .1265     | .1296     | .2915     |
| Avg  | 1.8596    | .253      | .4001     | 1.5331    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 203 / 11Kv Sangvi Bhusar  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    | .3048     |           |           |           |
| 8    | .2858     |           |           |           |
| 9    | .2477     |           |           | .2477     |
| 10   | .1905     |           |           | .1905     |
| 13   |           |           | 1.989     |           |
| 15   |           | 1.0562    |           |           |
| 16   |           | 1.587     |           |           |
| 17   |           | 1.8679    |           |           |
| 18   |           | 1.7444    | 2.2939    |           |
| 19   |           | 1.5935    | 2.2348    |           |
| 20   |           | .2477     | .2858     |           |
| 21   |           | .2286     | .2477     |           |
| 22   |           | .2286     | .2096     |           |
| 23   |           | .1905     | .2096     |           |
| 24   | .2667     |           | .1715     | .1905     |
| Max  | .3048     | 1.8679    | 2.2939    | .2477     |
| Min  | .1905     | .1905     | .1715     | .1905     |
| Avg  | .2591     | .9716     | .9552     | .2096     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 204 / 11Kv Sangvi + Dhamori  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    | .2452     |           |           |           |
| 8    | .1886     |           |           |           |
| 9    | .1698     |           |           | .168      |
| 10   | .1341     |           |           | .124      |
| 13   |           |           | .0754     |           |
| 14   |           | .0747     | .0747     |           |
| 15   |           | .0943     | .0732     |           |
| 16   |           | .0747     | .0754     |           |
| 17   |           | .1463     | .128      |           |
| 18   |           | .2218     | .1949     |           |
| 19   |           | .2561     | .2054     |           |
| 20   |           | .2241     | .2427     |           |
| 21   |           | .2033     | .2033     |           |
| 22   |           | .1886     | .168      |           |
| 23   |           | .1494     | .1494     |           |
| 24   | .1143     |           | .1334     | .1509     |
| Max  | .2452     | .2561     | .2427     | .168      |
| Min  | .1143     | .0747     | .0732     | .124      |
| Avg  | .1704     | .1633     | .1437     | .1476     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 205 / 11Kv Ravanda AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    | 1.1271    |           |           |           |
| 8    | 1.3108    |           | 1.4575    | 1.4899    |
| 9    | .9804     |           |           | 1.0802    |
| 10   | .1905     |           |           | .2286     |
| 13   |           |           | .1524     |           |
| 14   |           | .1143     | .1143     |           |
| 15   |           | .1524     |           |           |
| 16   |           | .1905     | .1143     |           |
| 17   |           | .1524     |           |           |
| 18   |           | .2667     | .1905     |           |
| 19   |           | .3048     | .2667     |           |
| 20   |           | .3429     | .3048     |           |
| 21   |           | .3429     | .2667     |           |
| 22   |           | .2667     | .2286     |           |
| 23   |           | .2286     | .2286     |           |
| 24   | .4687     |           | .5418     | .5792     |
| Max  | 1.3108    | .3429     | 1.4575    | 1.4899    |
| Min  | .1905     | .1143     | .1143     | .2286     |
| Avg  | .8155     | .2362     | .3515     | .8445     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014013 / 33/11KV RAVANDA

Feeder No / Name : 206 / 11Kv Malegaon Thadi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3201     |
| Max  | .3201     |
| Min  | .3201     |
| Avg  | .3201     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 201 / 11Kv Wadgaon (Velapur) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2401     |
| Max  | .2401     |
| Min  | .2401     |
| Avg  | .2401     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 202 / 11Kv Chas (Karwadi) SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4321     | .6009     |           |           |           |           |           |
| 2    | .4321     | .6009     |           |           |           |           |           |
| 3    | .4374     | .6009     |           |           |           |           |           |
| 4    | .4902     | .6722     |           |           |           |           |           |
| 5    | .5668     | .7935     |           |           |           |           |           |
| 6    | .6718     | .9667     |           |           |           |           |           |
| 7    | .9717     |           |           |           |           |           |           |
| 8    | 1.3108    |           |           |           |           |           |           |
| 9    |           |           |           | 1.1683    | 1.7604    | 1.8404    |           |
| 10   |           |           |           |           | .132      | .0762     |           |
| 11   |           |           |           |           | .0943     | .0762     |           |
| 12   |           |           |           |           | .0754     |           | .0943     |
| 17   |           |           |           | .0934     |           |           |           |
| 18   |           |           |           | .0943     |           |           |           |
| 19   |           |           |           | .1509     |           |           |           |
| 20   |           |           |           | .1698     |           |           |           |
| 21   |           |           |           | .1886     |           |           |           |
| 22   |           | .1132     |           | .1698     |           |           |           |
| 23   |           |           |           | .1698     |           |           |           |
| 24   | .3943     | .7748     | .9442     |           | 1.0595    |           |           |
| Max  | 1.3108    | .9667     | .9442     | 1.1683    | 1.7604    | 1.8404    | .0943     |
| Min  | .3943     | .1132     | .9442     | .0934     | .0754     | .0762     | .0943     |
| Avg  | .6341     | .6404     | .9442     | .2756     | .6243     | .6643     | .0943     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 203 / 11Kv Suregaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1334     | .132      |           |           |           |           |           |
| 2    | .1334     | .132      |           |           |           |           |           |
| 3    | .1334     | .132      |           |           |           |           |           |
| 4    | .1334     | .132      |           |           |           |           |           |
| 5    | .1524     | .1509     |           |           |           |           |           |
| 6    | .1524     | .1509     |           |           |           |           |           |
| 7    | .1334     |           |           |           |           |           |           |
| 8    | .1334     |           |           |           |           |           |           |
| 9    |           |           |           | .0943     | .0953     |           |           |
| 12   |           |           |           |           | 1.8564    | 1.7736    | 1.6244    |
| 13   |           |           |           |           | 1.7072    | 1.7901    | 1.8896    |
| 14   |           |           |           |           | 1.6385    | 1.8023    | 1.7901    |
| 15   |           |           |           |           | 1.5729    | 1.7695    | 1.5746    |
| 16   |           |           |           |           | 1.5402    |           | 1.7404    |
| 17   |           |           | 1.704     | 1.7368    |           |           |           |
| 18   |           |           |           | 1.4563    |           |           |           |
| 19   |           |           |           | 1.1717    |           |           |           |
| 20   |           |           |           | .1143     |           |           |           |
| 21   |           |           |           | .132      |           |           |           |
| 22   |           | .1509     |           | .132      |           |           |           |
| 23   |           | .1509     | .132      | .1132     |           |           |           |
| 24   | .5535     | .132      | .1132     |           | .1132     |           |           |
| Max  | .5535     | .1509     | 1.704     | 1.7368    | 1.8564    | 1.8023    | 1.8896    |
| Min  | .1334     | .132      | .1132     | .0943     | .0953     | 1.7695    | 1.5746    |
| Avg  | .1843     | .1404     | .6497     | .6188     | 1.2177    | 1.7839    | 1.7238    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 204 / 11Kv Hingni

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6859     |
| Max  | .6859     |
| Min  | .6859     |
| Avg  | .6859     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 205 / 11 Kv Kolpewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0953     | .0953     |           |           |           |           |           |
| 2    | .0953     | .0953     |           |           |           |           |           |
| 3    | .0953     | .0953     |           |           |           |           |           |
| 4    | .0953     | .0953     |           |           |           |           |           |
| 5    | .1143     | .0953     |           |           |           |           |           |
| 6    | .1143     | .1143     |           |           |           |           |           |
| 7    | .1334     |           |           |           |           |           |           |
| 8    | .0953     |           |           |           |           |           |           |
| 9    |           |           |           |           | .0953     |           |           |
| 12   |           |           |           |           | 2.0517    | 2.2043    | 1.9281    |
| 13   |           |           |           |           | 2.2382    | 2.2213    | 2.2131    |
| 14   |           |           |           |           | 2.0622    | 2.1293    | 2.2213    |
| 15   |           |           |           |           | 1.9951    | 2.1704    | 2.2213    |
| 16   |           |           |           |           | 1.95      |           | 2.2043    |
| 17   |           |           | 2.2131    | 2.0178    |           |           |           |
| 18   |           |           |           | 1.7859    |           |           |           |
| 19   |           |           |           | 1.6221    |           |           |           |
| 20   |           |           |           | .1334     |           |           |           |
| 21   |           |           |           | .1334     |           |           |           |
| 22   |           | .1143     |           | .1334     |           |           |           |
| 23   |           | .0953     | .0953     | .1143     |           |           |           |
| 24   | .3201     | .0953     | .0953     |           | .0953     |           |           |
| Max  | .3201     | .1143     | 2.2131    | 2.0178    | 2.2382    | 2.2213    | 2.2213    |
| Min  | .0953     | .0953     | .0953     | .1143     | .0953     | 2.1293    | 1.9281    |
| Avg  | .1287     | .0995     | .8012     | .8486     | 1.4983    | 2.1813    | 2.1576    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206]

BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 206 / 11 KV Kolpewadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5847     | .6036     |           |           |           |           |           |
| 2    | .5847     | .6036     |           |           |           |           |           |
| 3    | .679      | .6979     |           |           |           |           |           |
| 4    | .9619     | .9808     |           |           |           |           |           |
| 5    | 1.2637    | 1.3203    |           |           |           |           |           |
| 6    | 1.5089    | 1.5655    |           |           |           |           |           |
| 7    | 1.8861    |           |           |           |           |           |           |
| 8    | 1.6975    |           |           |           |           |           |           |
| 9    |           |           |           | 1.307     | 1.4563    | 1.3256    |           |
| 10   |           |           |           |           | .9877     | .9593     |           |
| 11   |           |           |           |           | .905      | .8871     |           |
| 12   |           |           |           |           | .7655     | .8871     | 1.3717    |
| 13   |           |           |           |           | .7095     | .7282     | 1.0791    |
| 14   |           |           |           |           | .6535     | .6161     | .7762     |
| 15   |           |           |           |           | .7095     | .7282     | .9145     |
| 16   |           |           |           |           | .7133     | .8779     | .9694     |
| 17   |           |           | .9492     | .8962     |           |           |           |
| 18   |           |           |           | 1.0317    |           |           |           |
| 19   |           |           |           | 1.0903    |           |           |           |
| 20   |           |           |           | 1.1706    |           |           |           |
| 21   |           |           |           | 1.1157    |           |           |           |
| 22   |           | .8962     |           | .9145     |           |           |           |
| 23   |           | .7023     | .6602     | .7392     |           |           |           |
| 24   | .6001     | .6036     | .6036     |           | .6036     |           |           |
| Max  | 1.8861    | 1.5655    | .9492     | 1.307     | 1.4563    | 1.3256    | 1.3717    |
| Min  | .5847     | .6036     | .6036     | .7392     | .6036     | .6161     | .7762     |
| Avg  | 1.0852    | .8860     | .7377     | 1.0332    | .8338     | .8762     | 1.0222    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014014 / 33/11 KV KOLPEWADI

Feeder No / Name : 207 / 11 Kv Sarthak Agro Express NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0018     | .0019     |           |           |           |           |           |
| 2    | .0018     | .0018     |           |           |           |           |           |
| 3    | .0018     | .0018     |           |           |           |           |           |
| 4    | .0018     | .0018     |           |           |           |           |           |
| 5    | .0018     | .0018     |           |           |           |           |           |
| 6    | .0018     | .0018     |           |           |           |           |           |
| 7    | .0018     |           |           |           |           |           |           |
| 8    | .0018     |           |           |           |           |           |           |
| 9    |           |           |           | .0018     | .0018     | .0018     |           |
| 10   |           |           |           |           | .0018     | .0073     |           |
| 11   |           |           |           |           | .0018     | .0073     |           |
| 12   |           |           |           |           | .0018     | .0073     | .0073     |
| 13   |           |           |           |           | .0018     | .0073     | .011      |
| 14   |           |           |           |           | .0018     | .0073     | .0091     |
| 15   |           |           |           |           | .0018     | .011      | .0091     |
| 16   |           |           |           |           | .0018     |           | .0091     |
| 17   |           | .0073     | .0055     | .0018     |           |           |           |
| 18   |           |           |           | .0018     |           |           |           |
| 19   |           |           |           | .0018     |           |           |           |
| 20   |           |           |           | .0018     |           |           |           |
| 21   |           |           |           | .0018     |           |           |           |
| 22   |           | .0091     |           | .0018     |           |           |           |
| 23   |           | .0073     | .0073     | .0018     |           |           |           |
| 24   | .0189     | .0073     | .0091     |           | .0018     |           |           |
| Max  | .0189     | .0091     | .0091     | .0018     | .0018     | .011      | .011      |
| Min  | .0018     | .0018     | .0055     | .0018     | .0018     | .0018     | .0073     |
| Avg  | .0037     | .0042     | .0073     | .0018     | .0018     | .0070     | .0091     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014015 / 33/11 KV CHAS

Feeder No / Name : 201 / Manjur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7621     |
| Max  | .7621     |
| Min  | .7621     |
| Avg  | .7621     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014015 / 33/11 KV CHAS

Feeder No / Name : 202 / Manjur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5546    |
| Max  | 1.5546    |
| Min  | 1.5546    |
| Avg  | 1.5546    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014015 / 33/11 KV CHAS

Feeder No / Name : 203 / Wadgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.086     |           | 1.5089    | 1.4661    | 1.3717    | 1.448     |
| 5    |           |           |           |           |           | 1.7147    |
| 7    | 2.2462    |           |           |           |           |           |
| 8    | 2.572     |           | 3.276     | 2.8635    | 2.7778    | 2.8807    |
| 24   | 1.086     | 1.3957    | 1.5203    | 1.448     | 1.3032    | 1.448     |
| Max  | 2.572     | 1.3957    | 3.276     | 2.8635    | 2.7778    | 2.8807    |
| Min  | 1.086     | 1.3957    | 1.5089    | 1.448     | 1.3032    | 1.448     |
| Avg  | 1.7476    | 1.3957    | 2.1017    | 1.9259    | 1.8176    | 1.8729    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014015 / 33/11 KV CHAS

Feeder No / Name : 204 / Wadgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0377     |           | .0377     | .0377     | .0189     | .0377     |
| 5    |           |           |           |           |           | .0566     |
| 7    | .0566     |           |           |           |           |           |
| 8    | .0377     |           | .0189     | .0377     | .0189     | .0377     |
| 24   |           | .0189     | .0189     | .0377     | .0189     | .0377     |
| Max  | .0566     | .0189     | .0377     | .0377     | .0189     | .0566     |
| Min  | .0377     | .0189     | .0189     | .0377     | .0189     | .0377     |
| Avg  | .044      | .0189     | .0252     | .0377     | .0189     | .0424     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014015 / 33/11 KV CHAS

Feeder No / Name : 205 / 11Kv Baktarpur  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1886     |           | .1886     | .1886     | .1509     | .1886     |
| 5    |           |           |           |           |           | .2263     |
| 7    | .1698     |           |           |           |           |           |
| 8    | .132      |           | .1509     | .132      | .132      | .132      |
| 24   | .1886     | .1886     | .1886     | .1886     | .1509     | .1886     |
| Max  | .1886     | .1886     | .1886     | .1886     | .1509     | .2263     |
| Min  | .132      | .1886     | .1509     | .132      | .132      | .132      |
| Avg  | .1698     | .1886     | .1760     | .1697     | .1446     | .1839     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014108 / 33/11KV KUMBHARI

Feeder No / Name : 201 / 11Kv Kumbhari  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .112      | .112      | .112      | .132      | .112      | .1494     |
| 2    |           | .112      | .112      | .112      | .132      | .1132     | .1307     |
| 3    |           | .112      | .112      | .112      | .1509     | .1132     | .1307     |
| 4    |           | .112      | .1478     | .1494     | .1509     | .1307     | .1307     |
| 5    |           | .1307     | .1829     | .168      | .168      | .1494     | .1494     |
| 6    |           | .1478     | .197      | .168      | .168      | .168      | .168      |
| 7    |           |           | .197      | .1663     | .168      | .1867     | .1848     |
| 8    |           |           |           | .1294     | .1307     | .1494     | .1494     |
| 9    | .0857     |           |           | .1029     | .1029     |           |           |
| 10   | .0857     |           |           | .0857     | .0857     |           |           |
| 11   |           |           | .0857     | .0857     | .0514     |           |           |
| 12   | 1.3032    |           | 2.9321    | 2.8292    | 3.2922    |           |           |
| 13   | 1.3375    | 2.7949    | 2.9835    | 2.8807    | 3.0178    |           |           |
| 14   | 2.7778    |           | 3.0178    | 3.0007    | 3.2922    |           |           |
| 15   | 2.7092    | 2.915     | 3.0007    | 2.9664    | 2.9492    |           |           |
| 16   | 2.7778    | 2.9321    | 3.0521    | 2.9492    | 2.8464    |           |           |
| 17   |           |           |           |           |           |           | 2.7606    |
| 18   |           |           |           |           |           |           | 2.7606    |
| 19   |           |           |           |           |           |           | 2.5892    |
| 20   |           |           |           |           |           |           | .1543     |
| 21   |           |           |           |           |           |           | .1543     |
| 22   |           |           |           |           |           |           | .1372     |
| 23   |           |           |           |           |           |           | .12       |
| 24   | .1029     |           |           |           |           |           |           |
| Max  | 2.7778    | 2.9321    | 3.0521    | 3.0007    | 3.2922    | .1867     | 2.7606    |
| Min  | .0857     | .112      | .0857     | .0857     | .0514     | .112      | .12       |
| Avg  | 1.3975    | 1.0409    | 1.2410    | 1.0011    | 1.0524    | .1403     | .6580     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014108 / 33/11KV KUMBHARI

Feeder No / Name : 202 / 11Kv Mahegaon Deshmukh  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.6461    | 1.6766    | 1.6156    | 1.6004    | 1.5546    | 1.6309    |
| 2    |           | 1.6461    | 1.6644    | 1.6004    | 1.6309    | 1.6156    | 1.6309    |
| 3    |           | 1.7071    | 1.7008    | 1.6872    | 1.6918    | 1.6156    | 1.6461    |
| 4    |           | 1.7238    | 1.7528    | 1.8343    | 1.8576    | 1.6857    | 1.6766    |
| 5    |           | 1.7433    | 1.7231    | 2.0921    | 2.0168    | 1.7086    | 1.709     |
| 6    |           | 1.8138    | 1.9332    | 2.3777    | 2.0416    | 1.9433    | 1.752     |
| 7    |           |           | .4801     | 2.5434    | 2.2497    | 2.372     | 2.1072    |
| 8    |           |           |           | 2.4143    | 2.4272    | 2.3594    | 2.3739    |
| 9    | 3.0521    |           |           | 2.5549    | 2.7092    |           |           |
| 10   | .1372     |           |           | .1372     | .1715     |           |           |
| 11   |           |           | .012      | .12       | .12       |           |           |
| 12   | .0686     |           | .12       | .0514     | .12       |           |           |
| 13   | .0686     | .1039     | .0514     | .0514     | .0686     |           |           |
| 14   | .0686     | .0686     | .0514     | .0514     | .0686     |           |           |
| 15   | .0514     | .0343     | .0514     | .0686     | .0857     |           |           |
| 16   | .0514     | .0686     | .0514     | .0686     | .0686     |           |           |
| 17   |           |           |           |           |           |           | .0693     |
| 18   |           |           |           |           |           |           | .12       |
| 19   |           |           |           |           |           |           | .2743     |
| 20   |           |           |           |           |           |           | .1886     |
| 21   |           |           |           |           |           |           | .2915     |
| 22   |           |           |           |           |           |           | .3086     |
| 23   |           |           |           |           |           |           | .2743     |
| 24   | .9031     |           |           |           |           |           |           |
| Max  | 3.0521    | 1.8138    | 1.9332    | 2.5549    | 2.7092    | 2.372     | 2.3739    |
| Min  | .0514     | .0343     | .012      | .0514     | .0686     | 1.5546    | .0693     |
| Avg  | .5501     | 1.0556    | .8668     | 1.2043    | 1.1830    | 1.8569    | 1.0702    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014108 / 33/11KV KUMBHARI

Feeder No / Name : 203 / Kumbhari GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .1132     | .112      | .1132     | .112      | .112      | .112      |
| 2    |           | .112      | .112      | .1132     | .112      | .112      | .112      |
| 3    |           | .112      | .112      | .1132     | .1494     | .112      | .112      |
| 4    |           | .1307     | .128      | .1307     | .168      | .1494     | .1307     |
| 5    |           | .1494     | .1612     | .1867     | .1867     | .168      | .1494     |
| 6    |           | .1848     | .2218     | .2241     | .2218     | .1848     | .2218     |
| 7    |           |           | .2686     | .2427     | .2772     | .2218     | .2534     |
| 8    |           |           |           | .2218     | .2218     | .1848     | .2195     |
| 9    | .1715     |           |           | .1886     | .1715     |           |           |
| 10   | .1372     |           |           | .1543     | .1715     |           |           |
| 11   |           |           | .1886     | .12       | .1372     |           |           |
| 12   | .1029     |           | .1543     | .1029     | .1029     |           |           |
| 13   | .1029     | .12       | .12       | .0857     | .0686     |           |           |
| 14   | .0686     | .0857     | .1029     | .0686     | .0686     |           |           |
| 15   | .0686     | .1029     | .0857     | .0686     | .0514     |           |           |
| 16   | .0686     | .0857     | .0857     | .0857     | .0686     |           |           |
| 17   |           |           |           |           |           |           | .1372     |
| 18   |           |           |           |           |           |           | .1543     |
| 19   |           |           |           |           |           |           | .2229     |
| 20   |           |           |           |           |           |           | .2401     |
| 21   |           |           |           |           |           |           | .2058     |
| 22   |           |           |           |           |           |           | .1543     |
| 23   |           |           |           |           |           |           | .12       |
| 24   | .3086     |           |           |           |           |           |           |
| Max  | .3086     | .1848     | .2686     | .2427     | .2772     | .2218     | .2534     |
| Min  | .0686     | .0857     | .0857     | .0686     | .0514     | .112      | .112      |
| Avg  | .1286     | .1196     | .1425     | .1388     | .1431     | .1556     | .1697     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014108 / 33/11KV KUMBHARI

Feeder No / Name : 204 / 11Kv Dharangaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .112      | .112      | .112      | .112      | .1132     | .1132     |
| 8    |           |           |           | .1848     | .2033     | .168      | .2218     |
| 9    | .2058     |           |           | .1372     | .1715     |           |           |
| 11   |           |           | .12       |           |           |           |           |
| 13   |           | .1029     |           |           |           |           |           |
| 16   | .0514     | .0686     | .0866     | .1029     | .0857     |           |           |
| 17   |           |           |           |           |           |           | .0857     |
| 24   | .0343     |           |           |           |           |           |           |
| Max  | .2058     | .112      | .12       | .1848     | .2033     | .168      | .2218     |
| Min  | .0343     | .0686     | .0866     | .1029     | .0857     | .1132     | .0857     |
| Avg  | .0972     | .0945     | .1062     | .1342     | .1431     | .1406     | .1402     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014108 / 33/11KV KUMBHARI

Feeder No / Name : 205 / 11 Kv Dharangaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | 1.5546    | 1.5394    | 1.5546    | 1.5546    | 1.6156    | 1.6347    |
| 8    |           |           |           | 1.7071    | 2.0271    | 1.8534    | 1.7695    |
| 9    | 1.9204    | .2058     |           | 2.0886    | 2.0233    |           |           |
| 11   |           |           | .1029     |           |           |           |           |
| 13   |           | .2058     |           |           |           |           |           |
| 16   | .1732     |           | .2915     | .1372     | .1715     |           |           |
| 17   |           |           |           |           |           |           | .2401     |
| 24   | .8916     |           |           |           |           |           |           |
| Max  | 1.9204    | 1.5546    | 1.5394    | 2.0886    | 2.0271    | 1.8534    | 1.7695    |
| Min  | .1732     | .2058     | .1029     | .1372     | .1715     | 1.6156    | .2401     |
| Avg  | .9951     | .6554     | .6446     | 1.3719    | 1.4441    | 1.7345    | 1.2148    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014113 / 33/11KV KHIRDI

GANESH(YESGAON)

Feeder No / Name : 201 / 11Kv Yesgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3429     | .381      | .3429     | .3429     | .381      | .381      | .381      |
| 2    | .3429     | .381      | .3429     | .3429     | .3429     | .381      | .381      |
| 3    | .3429     | .381      | .3429     | .3429     | .3429     | .381      | .381      |
| 4    | .381      | .381      | .3429     | .3429     | .3429     | .4191     | .381      |
| 5    | .4191     | .4191     | .381      | .381      | .4191     | .4572     | .4191     |
| 6    | .4572     | .4191     | .4191     | .4191     | .5335     | .5335     | .4572     |
| 7    | .4954     |           | .5335     | .4954     | .381      | .5335     | .4954     |
| 8    | .4572     |           | .3048     | .4191     | .4954     | .4954     | .4954     |
| 9    | .381      | .3048     | .3429     | .4191     | .4954     | .4954     | .4572     |
| 10   | .381      | .3048     | .3429     | .381      | .4191     | .381      | .4191     |
| 11   | .2667     | .2286     | .2286     | .3429     | .381      | .3048     | .3429     |
| 12   | 1.8519    | 1.8027    | 2.0165    | 2.17      | 2.0805    | 2.0485    | 1.866     |
| 13   | 1.9608    | 1.8343    | 1.9845    | 2.0241    | 1.9925    | 2.0165    | 2.0557    |
| 14   | 1.9925    | 1.8435    | 1.9524    | 1.9685    | 1.906     | 1.7604    | 1.9608    |
| 15   | 1.8122    | 1.9109    | 2.21      | 1.8747    | 1.8122    | 1.6004    | 1.7078    |
| 16   | 1.8435    |           | 1.866     | 1.6248    | 1.6975    | 1.5181    | 1.6248    |
| 17   | 1.8122    |           | 1.9109    | 1.7497    | 1.5741    | 1.406     | 1.5623    |
| 18   | 1.6049    |           | 1.5546    | 1.5623    | 1.531     | 1.2803    | 1.3375    |
| 19   | 1.4815    | 1.3672    | 1.5242    | 1.4373    | 1.406     |           | 1.3108    |
| 20   | .381      | .4572     | .4572     | .4572     | .381      | .4191     | .381      |
| 21   | .4954     | .4572     | .4191     | .4954     | .4572     | .4191     | .4572     |
| 22   | .4572     | .4572     | .4191     | .5716     | .4191     | .4191     | .4191     |
| 23   | .4191     | .381      | .381      | .4191     | .4191     | .4191     | .3429     |
| 24   | .6773     | .381      | .3429     | .3429     | .381      | .381      | .3429     |
| Max  | 1.9925    | 1.9109    | 2.21      | 2.17      | 2.0805    | 2.0485    | 2.0557    |
| Min  | .2667     | .2286     | .2286     | .3429     | .3429     | .3048     | .3429     |
| Avg  | .8774     | .7417     | .8735     | .8720     | .8580     | .8022     | .8325     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014113 / 33/11KV KHIRDI

GANESH(YESGAON)

Feeder No / Name : 202 / 11Kv Nategaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8619     | 1.0837    | 1.2186    | 1.1279    | 1.0669    | 1.0364    | 1.0402    |
| 2    | .8916     | 1.0536    | 1.2186    | 1.1584    | 1.0669    | 1.0364    | 1.07      |
| 3    | .8916     | 1.0837    | 1.2811    | 1.2186    | 1.0669    | 1.0669    | 1.0837    |
| 4    | 1.0105    | 1.1888    | 1.2483    | 1.3443    | 1.1279    | 1.1728    | 1.1439    |
| 5    | 1.1439    | 1.2193    | 1.3847    | 1.4899    | 1.2654    | 1.2346    | 1.2193    |
| 6    | 1.2643    | 1.2963    | 1.6667    | 1.6575    | 1.4506    | 1.2811    | 1.2803    |
| 7    | 1.5546    |           | 1.9372    | 1.8138    | 1.7284    | 1.6762    | 1.8519    |
| 8    | 1.8976    |           | 1.906     | 2.0622    | 1.9685    | 2.0165    |           |
| 9    | 1.7604    | 1.656     | 1.8122    | .1852     | 1.6507    | 1.5851    | 1.5546    |
| 10   | .381      | .2286     | .3429     | .3048     | .3429     | .2667     | .2286     |
| 11   | .3429     | .3429     | .4191     | .3429     | .381      | .3048     | .2667     |
| 12   | .381      | .381      | .3429     | .3048     |           | .4191     | .2667     |
| 13   | .381      | .5335     | .4191     | .2667     | .3429     | .3429     | .3048     |
| 14   | .4191     | .4191     | .4572     | .3429     | .4191     | .381      | .3048     |
| 15   | .3048     | .381      | .4572     | .4191     | .4572     | .381      | .3429     |
| 16   | .3429     | .3048     | .4954     | .4572     | .4191     | .381      | .3429     |
| 17   | .381      | .3429     | .4954     | .4954     | .4191     | .3429     | .381      |
| 18   | .4572     | .2286     | .4572     | .5335     | .4572     | .3429     | .2667     |
| 19   | .4954     | .381      | .4191     | .381      | .4954     | .381      | .3048     |
| 20   | .4572     | .381      | .4191     | .3429     | .4191     | .4572     | .3429     |
| 21   | .4191     | .3429     | .381      | .3429     | .381      | .4191     | .4191     |
| 22   | .3429     | .3429     | .3429     | .3048     | .3429     | .3429     | .4191     |
| 23   | .3048     | .2667     | .3429     | .3048     | .3048     | .2667     | .381      |
| 24   | 1.0978    | 1.0536    | 1.174     | .1235     | 1.0669    | 1.0059    | 1.0402    |
| Max  | 1.8976    | 1.656     | 1.9372    | 2.0622    | 1.9685    | 2.0165    | 1.8519    |
| Min  | .3048     | .2286     | .3429     | .1235     | .3048     | .2667     | .2286     |
| Avg  | .7410     | .6596     | .8600     | .7219     | .8105     | .7559     | .6894     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014113 / 33/11KV KHIRDI

GANESH(YESGAON)

Feeder No / Name : 203 / 11Kv Yesgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2096     | .2858     | .2286     | .2477     | .2477     | .2667     | .2477     |
| 2    | .2096     | .2477     | .2286     | .2286     | .2477     | .2477     | .2477     |
| 3    | .2286     | .2477     | .2286     | .2286     | .2477     | .2477     | .2477     |
| 4    | .2667     | .2858     | .2477     | .2667     | .2858     | .2858     | .2858     |
| 5    | .381      | .3429     | .3048     | .3048     | .3429     | .3429     | .3429     |
| 6    | .4382     | .4191     | .4191     | .4191     | .4001     | .4191     | .4191     |
| 7    | .4954     |           | .5144     | .4954     | .4572     | .4763     | .4954     |
| 8    | .4001     |           | .4572     | .4481     | .4763     | .4572     | .4481     |
| 9    | .3658     | .4294     | .3475     | .4294     | .4435     | .4108     | .4108     |
| 10   | .3841     | .3582     | .4251     | .3475     | .3658     | .3511     | .3658     |
| 11   | .3292     | .3547     | .443      | .4024     | .3658     | .3658     | .3658     |
| 12   | .3109     | .3475     | .4344     | .3439     | .3511     | .3258     | .3142     |
| 13   | .2896     | .3326     | .362      | .3475     | .3326     | .3326     | .3658     |
| 14   | .2896     | .2772     | .3292     | .2957     | .3658     | .3326     | .2957     |
| 15   | .2926     | .3547     | .3658     | .3142     | .3658     | .3734     | .3361     |
| 16   | .3142     | .2587     | .3292     | .3174     | .3258     | .2987     | .3174     |
| 17   | .3326     | .2835     | .3801     | .3258     | .2896     | .2402     | .2587     |
| 18   | .4251     | .4075     | .4024     | .3475     | .3658     | .2957     | .3012     |
| 19   | .5228     | .5121     | .4525     | .4294     | .462      |           | .4252     |
| 20   | .4668     | .4854     | .4904     | .4481     | .4805     | .5144     | .4572     |
| 21   | .4481     | .3921     | .4108     | .4294     | .5041     | .4954     | .4481     |
| 22   | .3429     | .3429     | .3361     | .362      | .362      | .381      | .3547     |
| 23   | .362      | .2858     | .2858     | .2667     | .3048     | .2858     | .2667     |
| 24   | .2096     | .3048     | .2286     | .2667     | .2667     | .2858     | .2667     |
| Max  | .5228     | .5121     | .5144     | .4954     | .5041     | .5144     | .4954     |
| Min  | .2096     | .2477     | .2286     | .2286     | .2477     | .2402     | .2477     |
| Avg  | .3465     | .3435     | .3605     | .3464     | .3607     | .3492     | .3452     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014117 / 33/11Kv Karanji

Feeder No / Name : 201 / 11Kv Karanji  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    | 2.7263    |           | 2.9843    | 3.0178    | 3.2065    | 3.0521    | 2.9675    |
| 9    | 2.2455    |           |           |           |           |           |           |
| 10   | .4763     |           |           |           |           |           |           |
| 11   | .381      | .4191     |           |           |           |           |           |
| 12   | .381      | .3048     |           |           |           |           |           |
| 13   | .381      | .3048     |           |           |           |           |           |
| 14   | .362      | .3429     |           |           |           |           |           |
| 15   | .362      |           |           |           |           |           |           |
| 16   | .381      | .362      | .3429     | .2572     | .362      |           | .4001     |
| 23   | .381      |           |           |           |           |           |           |
| 24   | 2.2005    | .362      | 1.4937    | 1.2489    | 1.1317    | 1.4175    | 1.2136    |
| Max  | 2.7263    | .4191     | 2.9843    | 3.0178    | 3.2065    | 3.0521    | 2.9675    |
| Min  | .362      | .3048     | .3429     | .2572     | .362      | 1.4175    | .4001     |
| Avg  | .9343     | .3493     | 1.6070    | 1.5080    | 1.5667    | 2.2348    | 1.5271    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014117 / 33/11Kv Karanji

Feeder No / Name : 202 / 11Kv Ogadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    | .2096     |           | .2477     | .1715     | .2286     | .1524     | .2667     |
| 9    | .2477     |           |           |           |           |           |           |
| 10   | .1905     |           |           |           |           |           |           |
| 11   | .1905     | .1715     |           |           |           |           |           |
| 12   | .8592     | .6602     |           |           |           |           |           |
| 13   | .9722     | .5858     |           |           |           |           |           |
| 14   | .7716     | .5841     |           |           |           |           |           |
| 15   | .7042     |           |           |           |           |           |           |
| 16   | .6161     |           | .6062     | .4934     | .5287     | .5001     | .4012     |
| 23   | .1905     |           |           |           |           |           |           |
| 24   | .5335     | .543      | .1334     | .1524     | .1334     | .1524     | .1715     |
| Max  | .9722     | .6602     | .6062     | .4934     | .5287     | .5001     | .4012     |
| Min  | .1905     | .1715     | .1334     | .1524     | .1334     | .1524     | .1715     |
| Avg  | .4987     | .5089     | .3291     | .2724     | .2969     | .2683     | .2798     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014117 / 33/11Kv Karanji

Feeder No / Name : 203 / Karanji GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    | .3206     |           | .3584     | .2402     | .2987     | .3018     | .2452     |
| 9    | .2614     |           |           |           |           |           |           |
| 10   | .1646     |           |           |           |           |           |           |
| 11   | .1463     | .1109     |           |           |           |           |           |
| 12   | .1294     | .112      |           |           |           |           |           |
| 13   | .112      | .112      |           |           |           |           |           |
| 14   | .0934     | .0924     |           |           |           |           |           |
| 15   | .0914     |           |           |           |           |           |           |
| 16   | .0934     |           |           | .112      | .1294     | .1267     | .1097     |
| 23   | .1143     |           |           |           |           |           |           |
| 24   | .3429     | .0934     | .1132     | .1132     |           | .1143     | .1143     |
| Max  | .3429     | .112      | .3584     | .2402     | .2987     | .3018     | .2452     |
| Min  | .0914     | .0924     | .1132     | .112      | .1294     | .1143     | .1097     |
| Avg  | .1700     | .1041     | .2358     | .1551     | .2141     | .1809     | .1564     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (R)[206] BU 0795

Substation No/ Name :- 014117 / 33/11Kv Karanji

Feeder No / Name : 204 / 11Kv Anchalgaoon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8    | .3395     |           | .3395     | .3206     | .3547     | .3206     | .3206     |
| 9    | .3395     |           |           |           |           |           |           |
| 10   | .2614     |           |           |           |           |           |           |
| 11   | .2402     | .2587     |           |           |           |           |           |
| 12   | .9414     | .8471     |           |           |           |           |           |
| 13   | 1.0185    |           |           |           |           |           |           |
| 14   | .9145     |           |           |           |           |           |           |
| 15   | .8509     |           |           |           |           |           |           |
| 16   | .8322     |           | .7145     | .7859     | .7754     | .7371     | .6748     |
| 23   | .3206     |           |           |           |           |           |           |
| 24   | .3906     | .3018     | .2829     | .3206     | .3018     | .3395     | .3018     |
| Max  | 1.0185    | .8471     | .7145     | .7859     | .7754     | .7371     | .6748     |
| Min  | .2402     | .2587     | .2829     | .3206     | .3018     | .3206     | .3018     |
| Avg  | .5863     | .4692     | .4456     | .4757     | .4773     | .4657     | .4324     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (U) S/DIV.[210] BU 0744

Substation No/ Name :- 014109 / 33/11 KV INDUSTRIAL ESTATE

Feeder No / Name : 201 / 11 KV Sanjiwani

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4519     | .4397     | .3429     | .2858     |           | .381      |
| 2    | .4473     | .3818     | .3429     | .2286     |           | .381      |
| 3    | .4473     | .4389     | .381      | .2858     |           | .381      |
| 4    | .4465     | .4389     | .381      | .2858     |           | .381      |
| 5    | .4854     | .4763     | .381      | .3429     |           | .3429     |
| 6    | .4488     | .4785     | .381      | .3429     |           | .3429     |
| 7    | .4542     | .1029     | .381      | .3429     |           | .3429     |
| 8    | .4915     | .5365     |           |           |           |           |
| 9    | .1006     | .1036     |           |           |           |           |
| 10   | .1135     |           |           |           |           |           |
| 11   | .109      | .0343     |           |           |           |           |
| 12   | .1669     | .1181     |           |           |           |           |
| 13   | .128      | .1257     |           |           |           |           |
| 14   | .1242     | .1219     |           |           |           |           |
| 15   | .1296     | .1174     |           |           |           |           |
| 16   | .5441     |           |           |           | .381      |           |
| 17   | .557      |           |           |           | .381      |           |
| 18   | .5456     |           |           |           | .4191     |           |
| 19   | .5982     |           |           |           | .4191     |           |
| 20   | .6097     |           |           |           | .381      | .381      |
| 21   | .5838     |           |           |           | .381      | .381      |
| 22   | .5227     |           |           |           | .3429     | .3429     |
| 23   | .1052     |           |           |           |           |           |
| 24   | .394      | .3429     | .3429     | .2858     |           | .381      |
| Max  | .6097     | .5365     | .381      | .3429     | .4191     | .381      |
| Min  | .1006     | .0343     | .3429     | .2286     | .3429     | .3429     |
| Avg  | .3752     | .2838     | .3667     | .3001     | .3864     | .3671     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (U) S/DIV.[210] BU 0744

Substation No/ Name :- 014109 / 33/11 KV INDUSTRIAL ESTATE

Feeder No / Name : 202 / 11 KV Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3336    | 1.3336    | 1.3336    | 1.0479    |           | 1.1431    |
| 2    | 1.4289    | 1.3336    | 1.3336    | 1.0479    |           | 1.1431    |
| 3    | 1.4289    | 1.3336    | 1.4289    | 1.0479    |           | 1.1431    |
| 4    | 1.3336    | 1.2384    | 1.4289    | .9526     |           | 1.2384    |
| 5    | 1.2955    | 1.2384    | 1.3336    | .8573     |           | 1.2384    |
| 6    | 1.3336    | 1.1431    | 1.3336    | .7621     |           | 1.3336    |
| 7    | 1.4289    |           | 1.3336    | .6668     |           | 1.3336    |
| 8    | 1.3336    | 1.0479    |           |           |           |           |
| 16   | 1.6766    |           |           |           | 1.5242    |           |
| 17   | 1.6194    |           |           |           | 1.5242    |           |
| 18   | 1.7147    |           |           |           | 1.4289    |           |
| 19   | 1.8099    |           |           |           | 1.4289    |           |
| 20   | 1.7147    |           |           |           | 1.3336    | 1.3336    |
| 21   | 1.6194    |           |           |           | 1.2384    | 1.3336    |
| 22   | 1.5242    |           |           |           | 1.2384    | 1.2384    |
| 24   | 1.4289    | 1.3336    | 1.3336    | 1.0479    |           | 1.1431    |
| Max  | 1.8099    | 1.3336    | 1.4289    | 1.0479    | 1.5242    | 1.3336    |
| Min  | 1.2955    | 1.0479    | 1.3336    | .6668     | 1.2384    | 1.1431    |
| Avg  | 1.5015    | 1.2503    | 1.3574    | .9288     | 1.3881    | 1.2384    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (U) S/DIV.[210] BU 0744

Substation No/ Name :- 017004 / 132/11 KV KOPERGAON

Feeder No / Name : 202 / 11KV KOKAMTHAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5329     |
| Max  | .5329     |
| Min  | .5329     |
| Avg  | .5329     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (U) S/DIV.[210] BU 0744

Substation No/ Name :- 017004 / 132/11 KV KOPERGAON

Feeder No / Name : 205 / 11 KV KOPERGAON URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 24   | 4.035     | 3.2166    |
| Max  | 4.035     | 3.2166    |
| Min  | 4.035     | 3.2166    |
| Avg  | 4.035     | 3.2166    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (U) S/DIV.[210] BU 0744

Substation No/ Name :- 017004 / 132/11 KV KOPERGAON

Feeder No / Name : 211 / 11 KV Kokamthan Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .083      |
| Max  | .083      |
| Min  | .083      |
| Avg  | .083      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (U) S/DIV.[210] BU 0744

Substation No/ Name :- 017004 / 132/11 KV KOPERGAON

Feeder No / Name : 404 / 33Kv Dahegaon Bolka

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2634    |
| Max  | 2.2634    |
| Min  | 2.2634    |
| Avg  | 2.2634    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

KOPARGAON (U) S/DIV.[210] BU 0744

Substation No/ Name :- 017004 / 132/11 KV KOPERGAON

Feeder No / Name : 405 / 33Kv Chasnali (Yeola) NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.5149    |
| Max  | 2.5149    |
| Min  | 2.5149    |
| Avg  | 2.5149    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 201 / Puntamba

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.7635    | 1.989     | 2.0919    | 2.1033    | 2.1605    | 2.0405    | 1.7772    |
| 2    | 1.6956    | 1.989     | 2.0348    | 2.1033    | 2.1498    | 2.0972    | 1.7772    |
| 3    | 1.7147    | 2.1365    | 2.0348    | 2.1498    | 2.2291    | 2.1136    | 1.8442    |
| 4    | 1.7974    | 2.1365    | 2.1605    | 2.1948    | 2.2721    | 2.1052    | 2.0348    |
| 5    | 1.9669    | 2.4006    | 2.3663    | 2.7496    | 2.4143    | 1.9845    | 2.1874    |
| 6    | 2.4143    |           | 2.6155    | 3.0514    | 2.652     | 2.5888    | 2.4863    |
| 7    |           |           | 2.8841    | 3.0514    | 3.0639    | 3.3196    | 3.1017    |
| 8    |           | 4.1152    | 3.7555    | 3.5778    | 3.3753    | 3.7685    | 3.5627    |
| 9    |           |           | 3.2442    | 2.9887    |           | 3.0361    | 2.5301    |
| 18   |           |           |           |           |           |           | .5801     |
| 19   |           | 1.251     | .7459     |           | .8288     | .8383     | .7459     |
| 20   | 1.1949    | 1.2955    | 1.3676    | 1.2696    | 1.307     | 1.2803    |           |
| 21   |           | 1.1431    | 1.2197    | 1.2136    | 1.1763    | 1.2071    |           |
| 22   | 1.1128    | .9709     | .961      | .9896     | 1.0374    |           |           |
| 23   | .8215     | .7842     | .7316     | .8589     | .7733     |           |           |
| 24   | 1.166     | 2.0348    |           | 2.1033    | 1.307     | 2.1125    |           |
| Max  | 2.4143    | 4.1152    | 3.7555    | 3.5778    | 3.3753    | 3.7685    | 3.5627    |
| Min  | .8215     | .7842     | .7316     | .8589     | .7733     | .8383     | .5801     |
| Avg  | 1.5648    | 1.8539    | 2.0152    | 2.1718    | 1.9105    | 2.1917    | 2.0571    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 202 / Rahata

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3395     |
| Max  | .3395     |
| Min  | .3395     |
| Avg  | .3395     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 203 / Astagaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | 1.8884    | 2.1125    | 2.1605    | 2.3472    | 2.3739    |
| 2    |           |           | 1.9204    |           | 2.1605    | 2.4034    | 2.3739    |
| 3    |           |           | 1.9204    | 2.0687    | 2.2539    | 2.4291    | 2.3739    |
| 4    |           |           | 2.0729    | 2.3579    | 2.3838    | 2.5911    | 2.4587    |
| 5    |           |           | 2.2138    | 2.4478    | 2.6292    | 1.8976    | 2.572     |
| 6    |           | 2.5911    | 2.5286    |           | .3353     | 2.6216    | 2.2939    |
| 7    |           | 3.2007    | 3.1131    | 3.315     | .57       | 3.0664    | 3.315     |
| 8    | 1.2803    |           | 2.9492    | 1.3108    |           | 2.9835    | 2.9835    |
| 9    |           |           | 2.9492    | 1.286     |           | 2.6246    | ***       |
| 17   |           |           |           |           |           | .3292     |           |
| 18   |           | .3018     |           |           |           |           |           |
| 19   |           | .4191     |           |           |           |           |           |
| 20   | .6036     | .5041     | .4904     | .6602     | .4904     | .4527     |           |
| 21   |           | .4527     | .4527     | .6036     | .4527     | .4338     |           |
| 22   | .4435     | .415      | .3772     | .4904     | .415      |           |           |
| 23   | .3734     | .3772     | .3734     | .4527     | .3772     |           |           |
| 24   | .6516     | 2.1437    |           | 2.2291    | 2.5274    | 2.3739    |           |
| Max  | 1.2803    | 3.2007    | 3.1131    | 3.315     | 2.6292    | 3.0664    | 24.2194   |
| Min  | .3734     | .3018     | .3734     | .4527     | .3353     | .3292     | 2.2939    |
| Avg  | .6705     | 1.1562    | 1.7884    | 1.6112    | 1.3963    | 2.0426    | 4.9960    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 204 / Pimpalas

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5487     | .5487     | .6241     | .7468     | .6588     | .679      |           |
| 2    | .5426     | .5087     | .6653     | .7392     | .6661     | .7167     |           |
| 3    | .5959     | .5144     | .7095     | .8131     | .7011     | .7733     |           |
| 4    | .6516     | .583      | .7682     | .8962     | .788      | .8488     |           |
| 5    | .8886     | .9602     | .9671     | 1.0374    | .9816     |           |           |
| 12   |           | 2.2131    | 2.1879    |           | 2.079     |           | 2.1434    |
| 13   |           | 2.0719    | 2.3703    |           | 2.0454    |           |           |
| 14   |           | 2.1051    | 2.1714    |           | 1.9784    |           |           |
| 15   |           | 2.0405    | 2.0719    |           | 1.4922    |           |           |
| 16   |           | 1.8564    | 1.6575    |           | 1.6907    |           |           |
| 17   |           | 1.7436    | 1.8399    |           | 1.6385    | 1.5402    | 1.5565    |
| 18   |           | .5788     | 1.6712    |           | 1.3117    | 1.2616    | 1.2163    |
| 19   |           | .9242     | 1.442     |           | 1.21      | 1.2125    | 1.0774    |
| 20   | .8478     | .9149     | .9896     |           | .9522     | 1.0269    |           |
| 21   |           | .8402     | .9522     |           | .9149     | .9896     |           |
| 22   | .8139     | .9145     | .8413     | .8573     | .8775     |           |           |
| 23   | .6859     | .724      | .7762     | .7888     | .8402     |           |           |
| 24   | .583      | .6241     |           | .7468     | .6859     | .7167     |           |
| Max  | .8886     | 2.2131    | 2.3703    | 1.0374    | 2.079     | 1.5402    | 2.1434    |
| Min  | .5426     | .5087     | .6241     | .7392     | .6588     | .679      | 1.0774    |
| Avg  | .6842     | 1.1481    | 1.3356    | .8282     | 1.1951    | .9765     | 1.4984    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 205 / Ganeshnagar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3258     |
| Max  | .3258     |
| Min  | .3258     |
| Avg  | .3258     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 206 / Saibaba

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3887     | .4062     | .5201     | .5373     | .4999     | .4572     | .6219     |
| 2    | .3887     | .3841     | .5144     | .5316     | .506      | .4715     | .6219     |
| 3    | .426      | .3795     | .6036     | .583      | .5376     | .5001     | .6219     |
| 4    | .4588     | .4801     | .5636     | .6371     | .5937     | .5216     | .6401     |
| 5    | .4999     | .6249     | .6401     | .7293     | .6562     | .4793     |           |
| 6    | .6249     | .7274     | .8848     | .852      | .8223     | .7099     |           |
| 7    | .8025     | .945      | 1.094     | 1.0562    | .9998     | .9962     |           |
| 8    | .8688     | 1.0185    | 1.1728    | 1.2346    |           | 1.247     |           |
| 9    |           |           | 1.0494    | 1.0957    |           |           | 1.0494    |
| 16   |           |           | .2778     | .2778     | .2984     |           |           |
| 17   |           |           | .3142     | .2623     | .3109     | .3292     | .2587     |
| 18   | .2972     | .3241     | .3881     | .3395     | .3511     | .3361     | .3696     |
| 19   |           | .4938     | .5601     | .5093     | .5601     | .5041     | .5041     |
| 20   |           | .6348     | .6161     | .4999     | .5975     | .5975     |           |
| 21   |           | .5601     | .5788     | .4687     | .5544     | .5228     |           |
| 22   | .4012     | .5544     | .5487     | .4012     | .4805     |           |           |
| 23   | .3125     | .394      | .4298     | .3749     | .3881     |           |           |
| 24   | .4161     | .463      |           | .5731     | .5556     | .4451     | .6024     |
| Max  | .8688     | 1.0185    | 1.1728    | 1.2346    | .9998     | 1.247     | 1.0494    |
| Min  | .2972     | .3241     | .2778     | .2623     | .2984     | .3292     | .2587     |
| Avg  | .4904     | .5593     | .6327     | .6091     | .5445     | .5798     | .5878     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 207 / Upasani Baba

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9054     | .9313     | .9979     | .9877     | 1.0136    | 1.0164    |           |
| 2    | .8951     | .8954     | 1.0082    | .9877     | 1.0136    | 1.0719    |           |
| 3    | .9602     | .9568     | 1.0349    | 1.1088    | 1.0745    | 1.1203    |           |
| 4    | 1.0288    | 1.0136    | 1.0974    | 1.1706    | 1.1462    | 1.2136    |           |
| 5    | 1.267     | 1.2308    | 1.3756    | 1.3213    | 1.2536    | 1.4003    |           |
| 6    | 1.5729    | 1.8088    | 2.2565    | 1.7924    | 1.6516    | 1.8673    |           |
| 7    | 2.2177    |           | 2.2565    | 2.1216    | 2.0953    | 2.2445    |           |
| 8    | 2.5503    | 2.4072    | 2.4874    | 2.5606    |           | 2.4272    |           |
| 9    |           | 2.1948    | 2.4326    | 2.3228    | 2.2805    |           | 2.2443    |
| 10   |           | 2.2131    | 2.1091    | 2.2721    | 2.2624    |           |           |
| 11   |           | 1.7857    | 2.0633    |           | 2.1538    |           |           |
| 12   |           | 1.5729    | 1.8267    | 1.8461    | 1.9547    |           |           |
| 13   |           | 1.6278    | 1.7375    | 1.6832    | 1.6651    |           |           |
| 14   |           | 1.4632    | 1.5746    | 1.6832    | 1.6832    |           |           |
| 15   |           | 1.5565    | 1.5402    |           | 1.6651    |           |           |
| 16   |           | 1.6278    | 1.6461    |           | 1.5927    |           |           |
| 17   |           | 1.7896    | 1.8088    | 2.4072    | 1.7551    | 1.8088    | 1.6476    |
| 18   | 1.9366    | 2.0995    | 1.9909    |           | 1.9163    | 2.0058    | 1.8461    |
| 19   |           | 2.4025    | 2.347     |           | 2.3101    | 2.4209    | 2.384     |
| 20   |           |           | 2.2624    |           | 2.009     | 1.9163    |           |
| 21   |           | 1.8665    | 2.0144    |           | 1.7909    | 1.7372    |           |
| 22   | 1.5565    | 1.5729    | 1.5023    | 1.6651    | 1.5061    |           |           |
| 23   | 1.267     | 1.267     | 1.267     | 1.2536    | 1.2403    |           |           |
| 24   | .5487     | .9877     |           | .7164     | 1.086     | 1.0534    |           |
| Max  | 2.5503    | 2.4072    | 2.4874    | 2.5606    | 2.3101    | 2.4272    | 2.384     |
| Min  | .5487     | .8954     | .9979     | .7164     | 1.0136    | 1.0164    | 1.6476    |
| Avg  | 1.3922    | 1.6032    | 1.7668    | 1.6412    | 1.6574    | 1.6646    | 2.0305    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014006 / 33/11 KV RAHATA

Feeder No / Name : 208 / 11kv Ganeshnagar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .4938     |
| Max  | .4938     |
| Min  | .4938     |
| Avg  | .4938     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014007 / 33/11 KV NIMGAON S/S

Feeder No / Name : 201 / 11 KV MALHAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .8535     | 1.0857    |           |           | 1.1235    | 1.1346    | 1.0987    |
| 2    | .8881     | 1.119     |           |           | 1.0887    | .6165     | 1.1202    |
| 3    | .9092     | 1.1034    | .3841     |           | 1.1443    | .6249     | 1.103     |
| 4    | .0023     | 1.1379    | 1.219     |           | .5075     | .6371     | 1.1238    |
| 5    |           | 1.1552    |           |           |           | .6401     | 1.149     |
| 6    | .0412     | 1.1706    |           | .0556     | .0107     | .6409     | 1.1797    |
| 7    | .0091     | .5944     |           |           |           | .6904     | 1.1566    |
| 8    | .9585     | .4062     |           |           | 1.0883    | .618      | 1.151     |
| 9    | .8688     | .2766     | .2446     |           | .5053     | .5838     | 1.03      |
| 10   | .861      | .5601     | .9663     |           | 1.0122    | .5075     | .7815     |
| 11   | 2.0693    | .4717     | 2.5917    | 1.9425    | 2.3482    | 1.7383    | 1.7821    |
| 12   | 4.6098    | 2.5888    | 5.6584    | 5.8005    | 5.3293    | 2.9066    | 4.8764    |
| 13   | 4.3698    |           | 5.6603    | 5.5418    | 5.3963    | 2.8616    | 4.8779    |
| 14   | 4.5392    | .0511     | 5.516     | 5.3917    | 4.9081    | 2.7656    | 4.4738    |
| 15   | 4.2409    |           | 5.256     | 5.2782    | 4.737     | 2.6414    | 4.2581    |
| 16   | 4.6068    |           | 5.3498    | 4.6388    | 4.7554    | 1.1141    | 4.1966    |
| 17   | 4.7472    | .0137     | 5.2279    | 4.7645    | 4.6982    | 2.743     | 4.2522    |
| 18   | 2.3419    | 1.4335    | 4.9802    | 4.5675    | 4.5321    | 3.9312    | 4.0975    |
| 19   | 4.2379    | 1.4007    | 4.2501    | 4.4191    | 4.1122    | 4.0199    | 2.7168    |
| 20   | .426      | .3582     | .0015     | .0152     | .0274     | .003      | 1.1711    |
| 21   | .9987     | .5144     | .0549     | .5403     | 1.2608    | .0602     | 1.1198    |
| 22   | .9707     | .0678     |           | .6165     | .6965     | .4443     | 1.0655    |
| 23   | 1.1625    | .0366     | .0373     | 1.1563    | 1.1907    | 1.2023    | 1.7206    |
| 24   | 1.1065    | .4871     |           | .6363     | 1.1545    | 1.2003    | 2.0283    |
| Max  | 4.7472    | 2.5888    | 5.6603    | 5.8005    | 5.3963    | 4.0199    | 4.8779    |
| Min  | .0023     | .0137     | .0015     | .0152     | .0107     | .003      | .7815     |
| Avg  | 1.9921    | .7635     | 2.9624    | 3.0243    | 2.3467    | 1.4302    | 2.2304    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014007 / 33/11 KV NIMGAON S/S

Feeder No / Name : 202 / 11 KV JAGDAMBA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3258     |
| Max  | .3258     |
| Min  | .3258     |
| Avg  | .3258     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014007 / 33/11 KV NIMGAON S/S

Feeder No / Name : 203 / 11 KV SHRINATH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.122     | 2.7161    | 2.9957    | 3.013     | 2.9863    | 1.4548    | 2.699     |
| 2    | 2.1315    | 2.7352    | 3.1638    | 2.9506    | 2.984     | 1.4449    | 2.7318    |
| 3    | 2.135     | 2.7033    | 3.0672    | 3.1775    | 3.0788    | 1.4952    | 2.744     |
| 4    | 2.2582    | 2.8697    | 3.1904    | 3.1737    | 3.049     | 1.4594    | 2.7252    |
| 5    | 2.4085    | 3.0689    | 3.5105    | 3.3017    | 3.1737    | 1.5752    | 2.8715    |
| 6    | 2.844     | 3.7998    | 4.0271    | 3.6503    | 3.7121    | 1.8785    | 3.3362    |
| 7    | 3.8186    | 2.2923    | 5.1131    | 5.1973    | 5.2157    | 2.6566    | 4.998     |
| 8    | 4.4474    | 2.0668    | 5.6142    | 5.847     | 5.9819    | 3.0476    | 5.6188    |
| 9    | 3.9757    | .1204     | 5.1403    | 5.3291    | 5.3902    | 2.8921    | 5.0418    |
| 10   | .5306     | .4982     | .3251     | .4431     | .4573     | .2462     | .3546     |
| 11   | .3483     | .3999     | .3795     | .4103     | .4481     | .173      | .2817     |
| 12   | .3186     | .0053     | .2921     | .3313     | .3765     | .1486     | .2718     |
| 13   | .3109     |           | .2746     | .2688     | .3401     | .1417     | .3043     |
| 14   | .3003     | .061      | .2558     | .2581     | .3134     | .1471     | .2883     |
| 15   | .314      | .0145     | .234      | .2545     | .2827     | .1524     | .2824     |
| 16   | .3186     |           | .2363     | .2627     | .2682     | .2703     | .2786     |
| 17   | .3231     |           | .2553     | .2377     | .2929     | .2772     | .3317     |
| 18   | .4204     | .1128     | .3339     | .3717     | .4223     | .3316     | .4118     |
| 19   | .5908     | .7346     | .5076     | .6395     | .6235     | .6039     | .6361     |
| 20   | .6751     | .3704     | .5755     | .6245     | .6376     | .6323     | .68       |
| 21   | .6648     | .6824     | .5625     | .5496     | .5907     | .576      | .6383     |
| 22   | .5679     | .6512     | .5526     | .5389     | .5572     | .5171     | .6339     |
| 23   | 1.1409    | 1.0805    | 1.3536    | 1.3734    | 1.1245    | 1.0121    | .5758     |
| 24   | 2.4287    | 2.8187    | 2.8738    | 3.0313    | 2.7488    | 2.8829    | 1.5384    |
| Max  | 4.4474    | 3.7998    | 5.6142    | 5.847     | 5.9819    | 3.0476    | 5.6188    |
| Min  | .3003     | .0053     | .234      | .2377     | .2682     | .1417     | .2718     |
| Avg  | 1.4747    | 1.4191    | 1.8681    | 1.8848    | 1.8773    | 1.0840    | 1.6781    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014007 / 33/11 KV NIMGAON S/S

Feeder No / Name : 205 / 11KV BABA FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3601     |
| Max  | .3601     |
| Min  | .3601     |
| Avg  | .3601     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014007 / 33/11 KV NIMGAON S/S

Feeder No / Name : 206 / 11kv Godavari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3809     | .8104     | .2915     | .3968     | .2785     |           | .2804     |
| 2    | .3763     | .8283     | .3609     | .4578     | .2984     |           | .2743     |
| 3    | .3761     | .7749     | .39       | .4578     | .3779     |           | .2814     |
| 4    | .5959     | .8907     | .5695     | .5514     | .3978     |           | .2606     |
| 5    | .896      | .9829     | .7322     | .5494     | .4774     |           | .4032     |
| 6    | .9784     | 1.1789    | .9797     | .6433     | .5171     |           | .4476     |
| 7    | 1.4478    | .692      | 1.1103    | 1.4092    | .7956     |           | .853      |
| 8    | 2.3572    | 2.5947    | 1.6328    | 1.1213    | .9746     |           | .975      |
| 9    | 2.2674    | 2.8343    | 1.3157    | .9014     | .8354     |           | .9282     |
| 10   | 1.0772    | 1.5435    | .1375     | .0463     | .0497     |           | .0555     |
| 11   | .2905     | .2748     | .0762     | .0457     | .0053     |           | .0555     |
| 12   | .1697     | .1044     | .0762     | .0467     | .0723     |           | .0557     |
| 13   | .127      |           | .0763     | .047      | .0723     |           | .0558     |
| 14   | .1271     |           | .0764     | .0471     | .0723     |           | .0559     |
| 15   | .1273     |           | .0764     | .0472     | .0723     |           | .0559     |
| 16   | .1658     |           | .0764     | .047      | .0723     | .0522     | .0559     |
| 17   | .2359     |           | .0765     | .047      | .0723     | .0418     | .0561     |
| 18   | .2511     |           | .0918     | .0575     | .0771     | .0629     | .0898     |
| 19   | .2907     |           | .1227     | .096      | .0964     | .0947     | .0898     |
| 20   | .3456     |           | .1227     | .0972     | .0964     | .1052     | .1015     |
| 21   | .3441     | .1606     | .1382     | .0873     | .0972     | .0957     | .1019     |
| 22   | .301      | .1608     | .1536     | .0972     | .0972     | .0855     | .1134     |
| 23   | .2905     | .1288     | .1541     | .0893     | .0873     | .075      | .1139     |
| 24   | .9341     | .3598     |           | .3387     | .2795     | .0418     | .2789     |
| Max  | 2.3572    | 2.8343    | 1.6328    | 1.4092    | .9746     | .1052     | .975      |
| Min  | .127      | .1044     | .0762     | .0457     | .0053     | .0418     | .0555     |
| Avg  | .6147     | .8950     | .3842     | .3219     | .2614     | .0728     | .2516     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014008 / 33/11 KV PUNTAMBA

Feeder No / Name : 201 / Rastapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0829     |           |           | .0838     |           | .169      | .1006     |
| 2    | .0829     |           |           |           | .0838     | .169      | .1006     |
| 3    | .1058     | .0472     | .0229     |           |           | .1736     | .1143     |
| 4    | .1975     | .0854     | .0793     | .1867     |           | .2591     | .2141     |
| 5    | .2448     | .1227     | .1128     | .1097     |           | .2837     | .2515     |
| 6    | .2972     | .173      | .1585     | .2919     | .1174     | .3224     | .3155     |
| 7    | .1898     | .1715     | .173      | .1738     |           | .1859     | .1806     |
| 8    |           |           | .1776     |           |           | .061      |           |
| 12   | 3.4241    |           | 4.2814    | 4.603     |           | 4.8544    | 4.769     |
| 13   | 4.3812    |           | 4.6754    | 2.8029    |           | 2.8616    | 2.2634    |
| 14   | 4.5747    |           | 4.7775    |           |           | 4.9265    | 2.3472    |
| 15   | 5.0671    |           | 5.1707    | 2.0957    |           | 5.1097    | 2.431     |
| 16   | 4.9482    | 2.3274    | 5.1036    |           |           | 4.8712    | 2.2634    |
| 17   | 5.0373    |           | 5.1079    |           |           | 4.8979    | 2.1795    |
| 18   | 4.5184    |           | 4.7447    | 2.1293    |           | 5.0099    | 2.2131    |
| 19   | 2.3891    |           | 2.5111    |           |           | 2.9599    | 1.8442    |
| 20   | 2.5324    |           | 1.9982    |           |           | 2.5026    | .1006     |
| 21   | .1303     |           | .1113     |           |           | .2461     | .1006     |
| 22   | .2149     |           | .1075     |           |           | .0922     | .1006     |
| 23   | .1936     |           | .096      | .1006     |           | .0975     | .1006     |
| 24   | .567      | .0838     | .0625     | .0838     |           | .1677     | .1014     |
| Max  | 5.0671    | 2.3274    | 5.1707    | 4.603     | .1174     | 5.1097    | 4.769     |
| Min  | .0829     | .0472     | .0229     | .0838     | .0838     | .061      | .1006     |
| Avg  | 1.9590    | .4301     | 2.0775    | 1.1510    | .1006     | 1.9153    | 1.1046    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014008 / 33/11 KV PUNTAMBA

Feeder No / Name : 202 / Changdev

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2642     | .2568     | .208      | .2454     |           | .243      | .1734     |
| 2    | .2597     | .2622     | .1997     | .4352     | .2254     | .2603     | .1734     |
| 3    | .2726     | .2667     | .1806     | .2324     |           | .2603     | .1734     |
| 4    | .273      | .2888     | .1791     | .2439     |           | .3124     | .1907     |
| 5    | .3045     | .2667     | .2126     | .2705     |           | .3471     | .208      |
| 6    | .3978     | .3262     | .2743     | .7285     | .3641     | .3992     | .2254     |
| 7    | .5121     | .4085     | .3574     | .4275     |           | .4166     | .4334     |
| 8    | .2286     | .4809     | .4481     | .9099     |           | .486      | .4334     |
| 9    | .6714     | .631      | .8157     | .4839     |           | .1215     | .3814     |
| 10   | .4024     | .5731     | .4199     | .3788     |           |           |           |
| 16   | .144      |           | .246      | .1214     |           |           | .0347     |
| 17   | .1608     |           | .2862     |           |           |           | .104      |
| 18   | .1753     |           | .3437     |           |           |           | .1387     |
| 19   | .2343     |           | .1829     |           |           | .2256     | .2774     |
| 20   | .3485     |           | .4249     | .208      |           | .2256     | .208      |
| 21   | .2835     |           | .3804     |           |           | .1736     | .208      |
| 22   | .2515     |           | .2164     |           |           |           | .1387     |
| 23   | .1987     |           | .1829     | .1214     |           |           | .104      |
| 24   | .607      | .1448     | .2401     | .208      |           | .2083     | .2083     |
| Max  | .6714     | .631      | .8157     | .9099     | .3641     | .486      | .4334     |
| Min  | .144      | .1448     | .1791     | .1214     | .2254     | .1215     | .0347     |
| Avg  | .3153     | .3551     | .3052     | .3582     | .2948     | .2830     | .2119     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014008 / 33/11 KV PUNTAMBA

Feeder No / Name : 204 / 11 KV PNTB GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1867     |           |           | .2507     |           | .296      | .2829     |
| 2    | .1867     |           |           |           | .2641     | .2963     | .2829     |
| 3    | .2241     |           |           |           |           | .37       |           |
| 4    |           |           |           |           |           | .407      | .3395     |
| 5    |           |           |           |           |           | .4272     | .415      |
| 6    |           |           |           | .5194     | .5281     | .4472     | .4904     |
| 7    | .5601     |           |           |           |           | .5415     | .5847     |
| 8    |           |           |           | .5194     |           | .5601     | .5658     |
| 9    | .6224     |           | .4889     |           |           | .4472     | .4715     |
| 10   | .3961     |           | .3721     |           |           |           | .3734     |
| 11   | .3584     |           | .3186     |           |           | .2963     | .3547     |
| 12   | .3206     |           |           | .2926     |           | .333      | .3326     |
| 13   | .3395     |           | .3696     |           |           | .2993     | .2957     |
| 14   | .3206     |           | .3511     |           |           | .2806     | .3142     |
| 15   | .3018     |           | .3142     |           |           | .3193     | .2926     |
| 16   | .3018     |           |           | .2926     |           | .3368     | .2743     |
| 17   | .3772     |           | .3696     |           |           | .3742     | .3475     |
| 18   | .4338     |           | .4074     | .3801     |           | .4124     | .4251     |
| 19   | .5847     |           | .5398     |           |           | .5818     | .5228     |
| 20   |           |           | .4805     |           |           | .5021     | .4668     |
| 21   | .3961     |           | .4426     |           |           | .098      | .3734     |
| 22   |           |           |           | .3511     |           |           | .3395     |
| 23   | .2772     |           |           |           |           |           | .2641     |
| 24   | .5093     | .2587     |           | .2507     |           | .3333     | .2769     |
| Max  | .6224     | .2587     | .5398     | .5194     | .5281     | .5818     | .5847     |
| Min  | .1867     | .2587     | .3142     | .2507     | .2641     | .098      | .2641     |
| Avg  | .3721     | .2587     | .4049     | .3571     | .3961     | .3790     | .3777     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014008 / 33/11 KV PUNTAMBA

Feeder No / Name : 205 / 11KV BAJARANG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0785     | .0069     |           | .0152     |           | .0829     | .0663     |
| 2    | .1097     |           | .003      | .0693     | .0663     | .0829     | .0663     |
| 3    | .1273     | .077      | .0175     | .08       |           | .0663     | .0663     |
| 4    | .1981     | .0838     | .0815     | .0838     |           | .0995     | .0995     |
| 5    | .2591     | .1097     | .0892     | .0854     |           | .0995     | .1326     |
| 6    | .3444     | .1456     | .1341     | .2984     | .1492     | .116      | .1658     |
| 7    | .1867     | .1852     | .189      | .1875     |           |           |           |
| 8    |           | .1486     | .1867     |           |           |           |           |
| 12   | .8143     |           | 1.378     | 1.3885    |           | .7625     | .8288     |
| 13   | 1.6829    | .9198     | 1.8469    | .9328     |           | .779      | .8356     |
| 14   | 1.7145    | .9168     | 1.9268    | .9785     |           | .779      | .9012     |
| 15   | 1.7425    | .8909     | 1.8892    | 2.1969    |           | .6796     | .8951     |
| 16   | 1.7799    | .8863     | 1.8351    |           |           | .5636     | .8453     |
| 17   | 1.563     |           | 1.813     |           |           | .6962     | 1.0111    |
| 18   | 1.5706    |           | 1.0494    |           |           | .8288     | .8951     |
| 19   | 1.4893    |           | 1.9398    | .8453     |           | .7293     | .8619     |
| 20   | .7766     |           | 1.1127    |           |           | .149      | .1492     |
| 21   | .2573     |           | .2903     |           |           |           | .0829     |
| 22   | .128      |           | .144      |           |           |           | .0829     |
| 23   | .1715     |           | .1021     | .0655     |           |           | .0663     |
| 24   | .0854     | .0497     | .0861     | .0655     |           | .0829     | .0662     |
| Max  | 1.7799    | .9198     | 1.9398    | 2.1969    | .1492     | .8288     | 1.0111    |
| Min  | .0785     | .0069     | .003      | .0152     | .0663     | .0663     | .0662     |
| Avg  | .7540     | .3684     | .8057     | .5209     | .1078     | .4123     | .4273     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014008 / 33/11 KV PUNTAMBA

Feeder No / Name : 206 / 11kv Railway Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1075     |
| Max  | .1075     |
| Min  | .1075     |
| Avg  | .1075     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014008 / 33/11 KV PUNTAMBA

Feeder No / Name : 207 / 11kv RAMPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6602     |
| Max  | .6602     |
| Min  | .6602     |
| Avg  | .6602     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014009 / 33/11 KV POHEGAON

Feeder No / Name : 201 / 11 KV SAVALIVIHIR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3361     |
| Max  | .3361     |
| Min  | .3361     |
| Avg  | .3361     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014009 / 33/11 KV POHEGAON

Feeder No / Name : 202 / 11KV MANEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 17   | 1.4175    |           |
| 18   |           | 1.4327    |
| 19   | 1.086     |           |
| 24   | .3258     |           |
| Max  | 1.4175    | 1.4327    |
| Min  | .3258     | 1.4327    |
| Avg  | .9431     | 1.4327    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014009 / 33/11 KV POHEGAON

Feeder No / Name : 203 / Madhi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6979     |
| Max  | .6979     |
| Min  | .6979     |
| Avg  | .6979     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014009 / 33/11 KV POHEGAON

Feeder No / Name : 204 / Korhale

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    | .6335     | 1.1641    |
| 2    | .6135     |           |
| 3    | .6135     |           |
| 4    | .7011     |           |
| 5    | 1.0631    |           |
| 6    | 1.4175    |           |
| 7    | 1.7528    |           |
| 24   | .6335     | 1.1393    |
| Max  | 1.7528    | 1.1641    |
| Min  | .6135     | 1.1393    |
| Avg  | .9286     | 1.1517    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014009 / 33/11 KV POHEGAON

Feeder No / Name : 205 / 11 KV Mayureshwar GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .299      | .2987     |           |           |
| 2    | .2957     |           |           |           |
| 3    | .2987     |           |           |           |
| 4    | .4668     |           |           |           |
| 5    | .5544     |           |           |           |
| 6    | .5544     |           |           |           |
| 7    | .7316     |           |           |           |
| 8    | .6468     |           |           |           |
| 12   |           |           |           | .2987     |
| 17   | .2987     |           |           |           |
| 18   |           |           | .3734     |           |
| 19   | .5228     |           |           |           |
| 24   | .2987     | .2987     |           |           |
| Max  | .7316     | .2987     | .3734     | .2987     |
| Min  | .2957     | .2987     | .3734     | .2987     |
| Avg  | .4516     | .2987     | .3734     | .2987     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014009 / 33/11 KV POHEGAON

Feeder No / Name : 208 / 11KV SONEWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5415     |
| Max  | .5415     |
| Min  | .5415     |
| Avg  | .5415     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014010 / 33/11 KV RANGANGAON

Feeder No / Name : 201 / Javalka

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3429     | .381      | .381      | .2667     | .381      | .381      | .2858     |
| 2    | .362      | .381      | .381      | .3048     | .381      | .4001     | .3429     |
| 3    | .4001     | .4191     | .4191     | .3429     | .4191     | .4382     | .4001     |
| 4    | .4572     | .4763     | .4572     | .381      | .4572     | .4382     | .4572     |
| 5    | .4572     | .4904     | .4954     | .381      | .4572     | .4715     | .4763     |
| 6    | .4954     | .4904     | .4954     | .4191     |           | .4715     | .4954     |
| 12   | 2.7681    |           | 2.8344    | 2.4143    | 2.4478    | 2.3304    | 2.34      |
| 13   |           |           | 2.6235    | 2.2447    | 2.2377    | 2.0388    | 2.1956    |
| 14   |           | 2.8487    | 2.6355    | 2.1464    | 2.0885    | 2.1051    | 2.1795    |
| 15   | 3.0167    | 3.0167    | 2.3703    | 2.1548    | 2.0222    | 1.9393    | 2.1195    |
| 16   | 3.1493    | 3.1493    | 2.1795    | 2.0481    | 2.0222    | 1.9393    | 2.1795    |
| 17   | 2.7846    | 1.757     | 1.7328    | 2.0008    | 2.0553    | 1.9784    | 2.1963    |
| 18   | 1.7238    | .5525     | 1.6842    | 1.7974    | 1.587     | 1.7404    | 1.7204    |
| 19   | 1.757     | .5335     | 1.7404    | 1.5089    | 1.3283    | 1.4899    | 1.5581    |
| 20   | .5525     | .4763     | .1905     | .5144     | .547      | .3048     | .4763     |
| 21   | .5525     | .5335     | .2286     | .5144     | .547      | .4572     | .5144     |
| 22   | .5335     | .5335     | .3048     | .4954     | .5335     | .4954     | .381      |
| 23   | .4763     |           | .362      | .4954     | .5144     | .4763     | .3429     |
| 24   | .381      | .4572     | .4191     | .4191     | .381      | .4572     | .2804     |
| Max  | 3.1493    | 3.1493    | 2.8344    | 2.4143    | 2.4478    | 2.3304    | 2.34      |
| Min  | .3429     | .381      | .1905     | .2667     | .381      | .3048     | .2804     |
| Avg  | 1.1888    | 1.0310    | 1.1545    | 1.0973    | 1.1337    | 1.0712    | 1.1022    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014010 / 33/11 KV RANGANGAON

Feeder No / Name : 204 / 11kv Kakadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0381     | .0953     | .0762     | .0381     | .0953     | .0953     | .0381     |
| 2    | .0381     | .0953     | .0953     | .0381     | .0953     | .0953     | .0381     |
| 3    | .1143     | .0953     | .0953     | .0572     | .1143     | .0953     | .0762     |
| 4    | .1334     | .1143     | .1143     | .0762     | .1334     | .1143     | .1524     |
| 5    | .1334     | .1334     | .1524     | .1334     | .1334     | .1334     | .1524     |
| 6    | .1524     | .1524     | .1715     | .1524     | .1334     | .1524     | .1715     |
| 7    | .1905     |           | .1715     | .1715     | .1334     | .1715     | .1715     |
| 8    | .1715     |           | .1524     | .1334     | .1334     | .1715     | .1524     |
| 9    | .1143     | .1715     | .1715     | .1143     | .0953     | .1334     | .1143     |
| 10   | .0762     |           | .0838     | .0762     | .0762     | .0886     | .0572     |
| 11   | .0572     |           | .0474     | .0762     | .0886     | .0335     | .0381     |
| 12   | .0381     |           | .0381     | .0381     | .0953     | .0381     | .0572     |
| 13   | .0381     |           |           | .0381     | .0572     | .0381     | .0381     |
| 14   | .0381     |           | .0381     | .0381     | .0572     | .0381     | .0381     |
| 15   | .0572     |           | .0381     | .0572     | .0572     | .0381     | .0381     |
| 16   | .0572     |           | .0572     | .0762     | .0572     | .0572     | .0381     |
| 17   | .0762     |           | .0509     | .0762     | .0762     | .0762     | .0572     |
| 18   | .0953     |           | .1143     | .0953     | .1063     | .1143     | .0953     |
| 19   | .1524     |           | .1334     | .1334     | .1646     | .1524     | .1524     |
| 20   | .1448     | .1334     | .1715     | .1334     | .1448     | .1334     | .1334     |
| 21   | .1334     | .1334     | .1524     | .1334     | .1307     | .1334     | .4954     |
| 22   | .1143     | .0953     | .1334     | .1143     | .1143     | .1143     | .0953     |
| 23   | .0953     | .0953     | .1143     | .0953     | .0953     | .0953     | .0762     |
| 24   | .0762     | .0953     | .0762     | .0953     | .0762     | .0953     | .0762     |
| Max  | .1905     | .1715     | .1715     | .1715     | .1646     | .1715     | .4954     |
| Min  | .0381     | .0953     | .0381     | .0381     | .0572     | .0335     | .0381     |
| Avg  | .0973     | .1175     | .1065     | .0913     | .1027     | .1004     | .1064     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014010 / 33/11 KV RANGANGAON

Feeder No / Name : 205 / 11kv GOPAJIBABA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2286     | .2286     | .2286     | .1905     | .2286     | .2858     | .2096     |
| 2    | .2096     | .2286     | .2286     | .1905     | .2286     | .2858     | .2667     |
| 3    | .2667     | .2667     | .2667     | .2096     | .2667     | .3429     | .3048     |
| 4    | .3048     | .3048     | .3048     | .2286     | .3048     | .3429     | .3429     |
| 5    | .3429     | .3048     | .3048     | .2286     | .3048     | .381      | .362      |
| 6    | .3429     | .362      | .3429     | .2477     | .362      | .381      | .381      |
| 12   | 1.1934    |           | 1.0688    | .8745     | 1.1012    | .852      | .8848     |
| 13   | .9069     |           | 1.0277    | .9069     | .9069     | .8002     | .7956     |
| 14   |           |           | .8124     | .7811     | .7449     | .6562     | .7373     |
| 15   | 1.0395    |           | .7716     | .7865     | .7449     | .6722     | .7125     |
| 16   | 1.1736    |           | .8322     | .7865     | .7125     | .7042     | .6722     |
| 17   | 1.012     |           | .8333     | .7625     | .8097     | .7362     | .7865     |
| 18   | .6081     |           | .8124     | .6802     | .7274     | .7202     | .7625     |
| 19   | .7125     |           | .8192     | .7209     | .7727     | .7274     | .7537     |
| 20   | .4191     | .2667     | .1143     | .3429     | .4001     | .2858     | .381      |
| 21   | .4191     | .4572     | .2858     | .381      | .381      | .381      | .4191     |
| 22   | .381      | .4001     | .4001     | .381      | .381      | .4382     | .3048     |
| 23   | .381      | .381      | .3429     | .381      | .381      | .4191     | .2477     |
| 24   | .2984     | .3048     | .2667     | .362      | .2286     | .3429     |           |
| Max  | 1.1934    | .4572     | 1.0688    | .9069     | 1.1012    | .852      | .8848     |
| Min  | .2096     | .2286     | .1143     | .1905     | .2286     | .2858     | .2096     |
| Avg  | .5689     | .3187     | .5297     | .4970     | .5257     | .5134     | .5180     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014010 / 33/11 KV RANGANGAON

Feeder No / Name : 206 / 11KV BAJARANG(KAKADI)

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1736    | 1.1431    | .9012     | 1.5242    | 1.0402    | 1.1812    | 1.1393    |
| 2    | 1.073     | 1.2384    | 1.0174    | 1.8099    | 1.0898    | 1.2955    | 1.2094    |
| 3    | 1.1694    | 1.2384    | 1.1022    | 2.0957    | 1.0774    | 1.448     | 1.4937    |
| 4    | 1.1888    | 1.3336    | 1.1736    | 2.3815    | 1.1469    | 1.419     | 1.587     |
| 5    | 1.251     | 1.3443    | 1.2289    | 2.4196    | 1.4003    | 1.531     | 1.6804    |
| 6    | 1.2696    | 1.587     | 1.7147    | 2.5149    | 1.7147    | 1.587     | 1.7177    |
| 7    | 2.0725    |           | 2.7054    | 2.572     | 2.3815    | 2.572     | 2.6863    |
| 8    | 2.0386    |           | 2.4196    | 2.3624    |           | 2.3815    | 2.2445    |
| 18   | .1715     |           | .2286     | .2667     | .1677     | .3224     | .2286     |
| 19   | .4382     |           | .4382     | .381      | .2143     | .4557     | .381      |
| 20   | .394      | .2667     | .3572     | .4191     | .443      | .4287     | .4191     |
| 21   | .3429     | .3429     | .3858     | .4572     | .381      | .3812     | .4572     |
| 22   | .3277     | .381      | .3572     | .4191     | .3144     | .3658     | .4191     |
| 23   | .2298     | .381      | .3353     | .381      | .3144     | .3353     | .381      |
| 24   | .3189     | 1.2384    | .9259     | 1.3032    | .9012     |           | 1.0059    |
| Max  | 2.0725    | 1.587     | 2.7054    | 2.572     | 2.3815    | 2.572     | 2.6863    |
| Min  | .1715     | .2667     | .2286     | .2667     | .1677     | .3224     | .2286     |
| Avg  | .8973     | .9541     | 1.0194    | 1.4205    | .8991     | 1.1217    | 1.1367    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014095 / 33/11 KV SHIRDI

Feeder No / Name : 201 / Dwarka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.003     | 3.5021    | 3.1641    | 3.4751    | 1.7918    | 1.7918    | 1.6975    |
| 2    | 2.762     | 3.1851    | 2.8488    | 3.243     | 1.6975    | 1.6095    | 1.6598    |
| 3    | 2.7376    | 3.0294    | 2.91      | 3.1885    | 1.6975    | 1.5089    | 1.6975    |
| 4    | 2.8654    | 3.1597    | 3.2018    | 3.3815    | 1.7918    | 1.6032    | 1.7541    |
| 5    | 3.1249    | 3.396     | 3.4309    | 3.7912    | 1.9239    | 1.6975    | 1.8296    |
| 6    | 3.3891    | 3.7057    | 3.6852    | 4.0451    | 2.1125    | 2.0748    | 1.8484    |
| 7    | 4.039     | 2.0485    | 4.3282    | 4.4656    | 2.2445    | 2.2257    | 2.0936    |
| 8    | 4.3572    | 4.1133    | 4.7127    | 4.9998    | 2.4143    | 2.3011    | 2.1691    |
| 9    | 4.12      | 4.4147    | 4.7495    | 5.2545    | 2.4143    | 2.2634    | 2.1879    |
| 10   | 3.9415    | 4.4151    | 4.448     | 4.8611    | 2.1879    | 1.9805    | 2.0182    |
| 11   | 3.6704    | 4.3549    | 4.1303    | 4.7405    | 2.2068    | 1.8484    | 2.0748    |
| 12   | 3.8022    | 2.0774    | 3.8126    | 4.667     | 2.1313    | 2.0182    | 1.9427    |
| 13   | 3.7575    | 3.1253    | 4.032     | 4.4553    | 2.0748    | 1.9805    | 1.9616    |
| 14   | 3.7488    | 3.3949    | 4.0088    | 4.4364    | 2.1125    | 1.8107    | 1.8296    |
| 15   | 3.7374    | 3.5726    | 4.0209    | 4.6022    | 2.0559    | 1.8861    | 1.8861    |
| 16   | 3.7445    | 3.3991    | 4.0846    | 2.2634    | 1.9993    | 1.905     | 1.9427    |
| 17   | 1.7863    | 1.7918    | 4.1847    | 2.32      | 2.037     | 1.9427    | 2.0748    |
| 18   |           | 2.2257    | 4.233     | 2.3011    | 2.452     | 1.9993    | 2.3011    |
| 19   | 2.5674    | 2.4331    | 4.8055    | 2.7161    | 2.452     | 2.3765    | 2.6029    |
| 20   | 5.0903    |           | 5.1328    | 2.6406    | 2.3577    | 2.2634    | 2.3577    |
| 21   | 4.8026    | 2.2822    | 5.025     | 2.584     | 2.3011    | 2.3388    | 2.2634    |
| 22   | 4.4572    | 2.1125    | 4.7569    | 2.3954    | 2.2257    | 2.1125    | 2.1125    |
| 23   | 4.5119    | 1.7918    | 4.5194    | 2.037     | 1.9805    | .4715     | 2.0748    |
| 24   | 1.9814    | 1.9204    | 3.6391    | 1.9239    | 1.7918    | 1.9239    | 1.6975    |
| Max  | 5.0903    | 4.4151    | 5.1328    | 5.2545    | 2.452     | 2.3765    | 2.6029    |
| Min  | 1.7863    | 1.7918    | 2.8488    | 1.9239    | 1.6975    | .4715     | 1.6598    |
| Avg  | 3.5651    | 3.0196    | 4.0777    | 3.5328    | 2.1023    | 1.9139    | 2.0032    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014095 / 33/11 KV SHIRDI

Feeder No / Name : 202 / Shriram

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.0456    | 1.5546    | 1.0829    | 1.2012    | 1.2136    | 1.3717    | 1.1643    |
| 2    | 1.0456    | 1.4266    | .9335     | 1.2803    | 1.2136    | 1.1888    | 1.1763    |
| 3    | 1.0829    | 1.3169    | .9149     | 1.3717    | 1.2696    | 1.2437    | 1.1949    |
| 4    | 1.2136    | 1.4632    | 1.1203    | 1.5546    | 1.307     | 1.3169    | 1.2136    |
| 5    | 1.3817    | 1.6095    | 1.3256    | 1.6461    | 1.3443    | 1.6598    | 1.2883    |
| 6    | 1.531     | 1.7375    | 1.531     | 1.7375    | 1.5684    | 1.6461    | 1.5123    |
| 7    | 1.7737    |           | 1.9044    | 1.829     | 1.9044    | 1.7375    | 1.7551    |
| 8    | 2.0165    | 2.0302    | 2.1068    | 2.1765    | 2.0698    | 1.957     | 2.0883    |
| 9    | 1.957     | 2.0119    | 2.0302    | 2.1216    | 2.1253    | 2.0119    | 1.9936    |
| 10   | 1.8656    | 1.8839    | 1.8473    | 1.9022    | 2.1807    | 2.0302    | 1.9753    |
| 11   | 1.7924    | 1.8473    | 2.0302    | 1.957     | 2.0513    | 2.0302    | 1.957     |
| 12   | 1.7375    | 1.7741    | 1.6095    | 1.9204    | 1.922     | 1.8107    | ***       |
| 13   | 1.6461    | 1.6278    | 1.5912    | 1.7558    | 2.0144    | 1.6278    | 1.5912    |
| 14   | 1.6095    | 1.5181    | 1.4815    | 1.5181    | 1.6448    | 1.4449    | 1.4083    |
| 15   | 1.5546    | 1.134     | 1.4266    | 1.4998    | 1.4784    | 1.4266    | 1.4266    |
| 16   | 1.4998    | 1.1523    | 1.5912    | 1.6278    | 1.5708    | 1.4998    | 1.5181    |
| 17   | 1.7924    | 1.4815    | 1.6278    | 1.6278    | 1.7002    | 1.6278    | 1.5729    |
| 18   | 1.8656    | 1.6632    | 1.701     | 1.7193    | 1.7924    | 1.701     | 1.7375    |
| 19   | 1.9022    | 1.5708    | 1.7924    | 1.8656    | 1.885     | 1.9204    | 1.829     |
| 20   | 1.9753    |           | 1.6461    | 1.7924    | 1.7556    | 1.7558    | 1.7558    |
| 21   | 1.8656    | 1.6263    | 1.6095    | 1.7741    | 1.7002    | 1.6827    | 1.6461    |
| 22   | 1.8107    | 1.4563    | 1.4266    | 1.6263    | 1.6095    | 2.1582    | 1.6095    |
| 23   | 1.8473    | 1.2323    | 1.2803    | 1.3491    | 1.4632    | 1.2567    | 1.3717    |
| 24   | .3584     | 1.5546    | 1.1694    | 1.2437    | 1.251     | 1.4266    | 1.2012    |
| Max  | 2.0165    | 2.0302    | 2.1068    | 2.1765    | 2.1807    | 2.1582    | 17.7961   |
| Min  | .3584     | 1.134     | .9149     | 1.2012    | 1.2136    | 1.1888    | 1.1643    |
| Avg  | 1.5904    | 1.5760    | 1.5325    | 1.6707    | 1.6681    | 1.6472    | 2.2410    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014095 / 33/11 KV SHIRDI

Feeder No / Name : 203 / VIRBHADRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.531     | 1.829     | 1.587     | 1.848     | 1.8671    | 1.8111    | 1.7737    |
| 2    | 1.531     | 1.7002    | 1.4563    | 1.8111    | 1.8298    | 1.6632    | 1.7551    |
| 3    | 1.531     | 1.5708    | 1.4937    | 1.6632    | 1.8298    | 1.5708    | 1.7551    |
| 4    | 1.6057    | 1.6263    | 1.6991    | 1.7556    | 1.9044    | 1.6263    | 1.7924    |
| 5    | 1.7551    | 1.885     | 1.9978    | 2.0328    | 2.0538    | 1.8111    | 1.8858    |
| 6    | 2.1658    | 2.1807    | 2.1845    | 2.2546    | 2.4272    | 2.1253    | 2.1807    |
| 7    | 2.6326    |           | 2.4764    | 2.4025    | 2.6427    | 2.4579    | 2.347     |
| 8    | 2.1472    | 2.5873    | 2.6612    | 2.5503    | 2.9938    | 2.552     | 2.4579    |
| 9    | 2.3655    | 2.6797    | 2.8715    | 2.9199    | 2.9199    | 2.7536    | 2.347     |
| 10   | 2.3101    | 2.6242    | 2.6886    | 2.7721    | 2.7536    | 2.7618    | 2.4949    |
| 11   |           | 1.7926    |           | 2.7351    | 2.7351    | 2.5423    | 2.6427    |
| 12   |           | 1.848     | 2.4508    | 2.6057    | 2.7721    | 2.268     | 2.3777    |
| 13   | 2.384     | 1.4045    | 1.7924    | 2.3101    | 2.4897    | 2.2497    | 2.1437    |
| 14   | 2.2546    | 1.4415    | 1.829     | 2.2361    | 2.4025    | 2.1399    | 2.1622    |
| 15   | 2.2862    | 1.4969    | 1.701     | 2.1253    | 2.3101    | 2.0119    | 2.1437    |
| 16   | 2.3285    | 1.3676    | 2.2497    | 2.2177    | 2.4025    | 2.2497    | 2.0328    |
| 17   | 2.4025    | 1.6263    | 2.2497    | 2.5318    | 2.2546    | 2.4691    | 2.0936    |
| 18   | 2.4394    | 1.9035    | 2.5133    | 2.6703    | 2.4394    | 2.3777    | 2.4143    |
| 19   | 2.2546    | 2.1068    | 2.7349    | 2.8898    | 2.7351    | 2.6337    | 2.9447    |
| 20   | 2.1992    |           | 2.5873    | 2.7435    | 2.6242    | 2.5423    | 2.6886    |
| 21   | 2.1992    | 2.4209    | 2.4209    | 2.5318    | 2.4764    | 2.3777    | 2.5972    |
| 22   | 2.1437    | 2.3285    | 2.2314    | 2.4209    | 2.4025    | 2.1807    | 2.3777    |
| 23   | 2.0328    | 1.8671    | 2.1807    | 2.1807    | 2.1807    | 1.9044    | 2.0725    |
| 24   | 1.4937    | 1.9753    | 1.6804    | 1.9959    | 1.9418    | 1.9404    | 1.7737    |
| Max  | 2.6326    | 2.6797    | 2.8715    | 2.9199    | 2.9938    | 2.7618    | 2.9447    |
| Min  | 1.4937    | 1.3676    | 1.4563    | 1.6632    | 1.8298    | 1.5708    | 1.7551    |
| Avg  | 2.0906    | 1.9210    | 2.1625    | 2.3419    | 2.3912    | 2.2092    | 2.2189    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014095 / 33/11 KV SHIRDI

Feeder No / Name : 204 / STP Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0189     | .0945     | .0311     | .0726     | .0183     | .0181     | .0183     |
| 2    | .0189     | .0612     | .0181     | .0772     | .0183     | .0181     | .0183     |
| 3    | .0189     | .1065     | .0181     | .0787     | .0183     | .0181     | .0183     |
| 4    | .0189     | .0876     | .0181     | .0634     | .0183     | .0181     | .0732     |
| 5    | .0762     | .0747     | .0181     | .0737     | .0183     | .0181     | .0914     |
| 6    | .0953     | .093      | .0181     | .1778     | .0914     | .1448     | .0732     |
| 7    | .1539     | .0545     | .1448     | .1526     | .128      | .1086     | .0914     |
| 8    | .2427     | .33       | .2387     | .1187     | .1463     | .0181     | .1886     |
| 9    | .2315     | .2528     | .1229     | .2229     | .0914     | .1086     | .1646     |
| 10   | .2523     | .2242     | .1589     | .1981     | .0732     | .128      | .0183     |
| 11   | .2719     | .2492     | .2286     | .2542     | .0732     | .128      | .0183     |
| 12   | .2096     | .1581     | .2818     | .237      | .0732     | .0914     | .0732     |
| 13   | .153      | .1591     | .2414     | .2507     | .0732     | .1646     | .1646     |
| 14   | .2048     | .0181     | .2037     | .1901     | .0549     | .0914     | .0732     |
| 15   | .1362     |           | .1707     | .1875     | .0183     | .1097     | .1097     |
| 16   | .2955     | .0234     | .1759     | .0905     | .0732     | .1097     | .1097     |
| 17   | .1216     |           | .2557     | .0905     | .0914     | .128      | .1097     |
| 18   | .0682     |           | .1934     | .0181     | .1267     | .0914     | .1629     |
| 19   | .0181     |           | .0612     | .0724     | .1448     | .0914     | .0181     |
| 20   | .0543     |           | .0669     | .0183     | .0181     | .0732     | .0181     |
| 21   | .0181     | .0183     | .0227     | .0732     | .0905     | .0732     | .0905     |
| 22   | .0547     | .1086     | .1099     | .1109     | .0724     | .0914     | .0905     |
| 23   | .0831     | .0905     | .0714     | .0914     | .0181     | .0183     | .0181     |
| 24   | .0781     | .0183     | .0707     | .0724     | .0183     | .0181     | .0183     |
| Max  | .2955     | .33       | .2818     | .2542     | .1463     | .1646     | .1886     |
| Min  | .0181     | .0181     | .0181     | .0181     | .0181     | .0181     | .0181     |
| Avg  | .1206     | .1170     | .1225     | .1247     | .0653     | .0783     | .0763     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014095 / 33/11 KV SHIRDI

Feeder No / Name : 401 / Hotel Country Inns  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5093     |
| Max  | .5093     |
| Min  | .5093     |
| Avg  | .5093     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014106 / 33/11kv Astagaon S/Stn

Feeder No / Name : 201 / 11kv Renuka

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6584     | .5935     | .5801     | .6979     |           |           | .6104     |
| 2    | .679      | .5935     | .4144     | .679      |           |           | .6104     |
| 3    | .679      | .5868     | .5801     | .6908     |           |           | .6443     |
| 4    | .6979     | .6036     | .5967     | .7095     |           |           | .6783     |
| 5    | .7167     | .6036     | .6062     | .7282     |           |           | .6783     |
| 11   |           |           |           |           |           |           | 2.2131    |
| 12   | 2.4587    | 1.9757    | 2.2542    | 2.0972    | 2.2775    | 1.9662    | 1.989     |
| 13   | 2.2939    | 1.9334    | 1.9725    | 2.0645    | 2.1464    | 1.8461    |           |
| 14   | 2.13      |           | 1.873     | 1.9334    | 1.989     | 1.6518    | 1.2929    |
| 15   | 2.0081    | 1.8067    | 1.7604    | 1.6518    | 1.7204    | 1.6194    | 1.704     |
| 16   | 2.0243    | 1.9826    | 1.9113    | 1.7652    | 1.7814    | 1.7204    |           |
| 17   | 2.0081    | 1.9498    | 1.1736    | ***       | 1.8947    | 1.7328    | 1.8233    |
| 18   |           | 1.8564    | 1.7901    | 1.4746    | 1.8842    | 1.749     | 1.8351    |
| 19   |           | 1.8233    | 1.8067    | 1.6356    | 1.7404    | 1.749     | 1.8023    |
| 20   |           | .6874     | .7922     | .664      | .6706     | .7842     |           |
| 21   |           | .6539     | .7356     | .639      |           | .7655     |           |
| 22   |           | .6706     | .7167     |           |           | .7655     |           |
| 23   |           | .5801     | .6979     | .5992     |           |           |           |
| 24   | .679      | .6104     | .5801     | .6979     |           |           | .6344     |
| Max  | 2.4587    | 1.9826    | 2.2542    | 18.7205   | 2.2775    | 1.9662    | 2.2131    |
| Min  | .6584     | .5801     | .4144     | .5992     | .6706     | .7655     | .6104     |
| Avg  | 1.4194    | 1.1477    | 1.1579    | 2.2028    | 1.7894    | 1.4864    | 1.2704    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014106 / 33/11kv Astagaon S/Stn

Feeder No / Name : 202 / 11kv Saishakti

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9784    | 2.2043    | 2.0972    | 2.323     | 2.1195    |           | 2.4006    |
| 2    | 2.079     | 2.1795    | 2.13      | 2.34      | 2.1704    |           | 2.4006    |
| 3    | 2.1795    | 2.2891    | 2.1956    | 2.3304    | 2.1795    |           | 2.4417    |
| 4    | 2.2874    | 2.2969    | 2.2611    | 2.7999    | 2.2131    |           | 2.713     |
| 5    | 2.2874    | 2.7161    | 2.3266    | 2.8012    | 2.2119    |           |           |
| 6    | 2.2939    | 2.934     | 2.8018    | 2.9984    |           |           | 2.7978    |
| 7    | 2.2939    | 3.3532    | 3.0148    | 2.8346    |           |           | 2.8487    |
| 8    | 2.7044    |           | 3.1093    | 2.9656    |           |           | 2.9843    |
| 9    | 2.5857    | 2.915     |           |           | 3.0476    | 2.4669    | 2.7328    |
| 10   |           |           |           |           | 3.1131    |           |           |
| 11   |           |           |           |           | 2.7854    |           |           |
| 16   | .2622     | .3978     | .4668     |           | .2818     | .2987     | .2622     |
| 17   | .3441     | .426      | .4481     |           | .285      | .3734     | .3277     |
| 18   |           | .4641     | .5093     |           | .5243     | .5041     | .4641     |
| 19   |           | .6203     | .5847     |           |           | .5975     | .5182     |
| 20   |           | .5304     | .5415     |           | .503      |           |           |
| 21   |           | .4973     | .5093     |           |           |           |           |
| 22   |           | .4641     | .4715     |           |           |           |           |
| 23   |           | .431      | .4527     |           |           |           |           |
| 24   | 1.9669    | 1.8652    | 1.8842    | 2.0405    | 1.9669    |           | 2.323     |
| Max  | 2.7044    | 3.3532    | 3.1093    | 2.9984    | 3.1131    | 2.4669    | 2.9843    |
| Min  | .2622     | .3978     | .4481     | 2.0405    | .2818     | .2987     | .2622     |
| Avg  | 1.9386    | 1.5638    | 1.5179    | 2.6037    | 1.8001    | .8481     | 1.9396    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014106 / 33/11kv Astagaon S/Stn

Feeder No / Name : 203 / 11kv Astagaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2829     |
| Max  | .2829     |
| Min  | .2829     |
| Avg  | .2829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014106 / 33/11kv Astagaon S/Stn

Feeder No / Name : 204 / 11kv Mothe Baba

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6952     | .78       | .7459     | .8573     |           |           | .9088     |
| 2    | .7291     | .78       | .779      | .8916     | .8817     |           | .9602     |
| 3    | .7545     | .8383     | .7956     | .9259     | .9156     |           | 1.0802    |
| 4    | .8383     | .9054     | .8848     | .8817     | .9389     |           | 1.1022    |
| 5    | .8453     | 1.0059    | .9995     | .9389     | .9665     |           | 1.0898    |
| 6    | .8684     | 1.0395    | 1.0322    | 1.0277    | 1.1361    |           | 1.1401    |
| 7    | 1.065     | 1.2071    | 1.2452    | 1.2266    | 1.4754    |           | 1.1736    |
| 8    | 1.3765    | 1.4754    | 1.3599    | 1.4419    | 1.4251    |           | 1.5927    |
| 9    | 1.3927    |           |           |           | 1.4083    | 1.3443    | 1.3757    |
| 16   | .1457     | .1658     | .168      |           | .1619     | .1867     | .1638     |
| 17   | .1619     | .1802     | .168      |           | .1943     | .1494     | .1966     |
| 18   |           | .2155     | .2054     |           | .3353     | .2427     | .2785     |
| 19   |           | .2984     | .3206     |           | .3521     | .3361     | .3277     |
| 20   |           | .2984     | .3361     |           | .3353     | .3584     |           |
| 21   |           | .2785     |           |           |           | .3361     |           |
| 22   |           | .2652     | .2829     |           |           | .3018     |           |
| 23   |           | .1844     | .2452     |           |           |           |           |
| 24   | .6952     | .763      | .6962     | .823      | .78       |           | .8059     |
| Max  | 1.3927    | 1.4754    | 1.3599    | 1.4419    | 1.4754    | 1.3443    | 1.5927    |
| Min  | .1457     | .1658     | .168      | .823      | .1619     | .1494     | .1638     |
| Avg  | .7973     | .6283     | .6415     | 1.0016    | .8076     | .4069     | .8711     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAHATA[205]

BU 5771

Substation No/ Name :- 014106 / 33/11kv Astagaon S/Stn

Feeder No / Name : 206 / 11KV M.S.A.M.B.EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1387     |
| Max  | .1387     |
| Min  | .1387     |
| Avg  | .1387     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 202 / 11 KV NILWANDE FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 17   |           | .1448     |           |           |           |
| 18   |           | .2896     |           |           |           |
| 24   | 1.0288    |           | 1.0288    | 1.0288    | 1.0631    |
| Max  | 1.0288    | .2896     | 1.0288    | 1.0288    | 1.0631    |
| Min  | 1.0288    | .1448     | 1.0288    | 1.0288    | 1.0631    |
| Avg  | 1.0288    | .2172     | 1.0288    | 1.0288    | 1.0631    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 203 / 11 KV SHENDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.315     | 8.5734    | 9.4117    | ***       | 8.1924    | 8.6877    | 6.8968    |
| 2    | 3.3913    | 8.1543    | 9.0688    | ***       | 7.6589    | 8.4591    | 6.8587    |
| 3    | 3.3532    | 3.4294    | 2.9721    | 3.0864    | 3.3913    | 3.1626    | 3.0864    |
| 4    | 3.3913    | 3.3913    | 2.8959    | 3.0483    | 3.315     | 3.0864    | 3.0483    |
| 5    | 3.3913    | 3.3913    | 2.8578    | 2.9721    | 3.8485    | 3.0864    | 3.1626    |
| 6    | 3.6199    | 3.315     | 3.1626    | 3.4675    | 4.1152    | 3.2388    | 3.3532    |
| 7    | 4.1152    | 4.1152    | 3.6199    | 3.8485    | 4.2295    | 4.1152    | 4.1533    |
| 8    | 3.7723    | 3.658     | 3.6199    | 3.5437    | 4.0009    | 3.658     | 3.3913    |
| 9    | 3.4294    | 2.8578    | 2.8197    | 2.7435    | 3.1245    | 2.7435    | 2.8197    |
| 10   | 2.9721    | 2.6292    | 3.3913    |           | 3.0864    | 2.8197    | 2.8959    |
| 11   | 2.5149    | 2.1719    | 2.5149    |           | 2.5911    | 2.7816    | 2.5911    |
| 12   | 1.7909    | 1.6385    | 1.8671    |           | 1.7909    | 1.7147    | 1.6766    |
| 13   | 1.4861    | 1.6766    | 1.7147    |           | 1.9814    | 1.829     | 1.6766    |
| 14   | 1.5242    | 1.5623    | 1.829     |           | 1.9814    | 1.9814    | 1.6385    |
| 15   | 1.448     | 1.5242    | 1.4861    |           | 1.9052    | 1.7528    | 1.5623    |
| 16   | 1.4861    | 1.5623    | 1.6004    |           | 1.8671    | 1.6766    | 1.4861    |
| 17   | 2.0957    | 1.105     | 2.3175    |           | 2.2862    | 1.7528    | 1.7147    |
| 18   | 2.7435    | 2.9721    | 5.9351    |           | 3.0483    | 3.5056    | 3.315     |
| 19   | 9.5641    | ***       | 6.9349    | 7.1254    | 9.4117    | ***       | 8.7258    |
| 20   | 8.9925    | 5.0678    | 6.7825    | 8.8782    | ***       | ***       | 9.0306    |
| 21   | ***       | 5.0297    | 6.1728    | 6.592     | ***       | ***       | ***       |
| 22   | ***       | 5.6013    | 6.0585    | 4.9535    | ***       | ***       | ***       |
| 23   | 9.7546    | ***       | ***       | 7.6589    | 9.8308    | 8.5734    | ***       |
| 24   | ***       | 9.7546    | ***       | 9.9452    | 9.2593    | 8.6343    | 9.907     |
| Max  | 10.7072   | 10.25     | 11.8884   | 10.4786   | 11.4693   | 11.355    | 12.5362   |
| Min  | 1.448     | 1.105     | 1.4861    | 2.7435    | 1.7909    | 1.6766    | 1.4861    |
| Avg  | 4.5804    | 4.3185    | 4.6877    | 5.9137    | 5.1694    | 5.0037    | 4.8630    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 204 / 11 KV AMBIT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 9.1831    | 2.1338    | 1.9814    | 2.0195    | 2.0576    | 2.0957    | 2.0576    |
| 2    | 8.7639    | 3.9247    | 3.2769    | 5.2202    | 2.0195    | 4.2295    | 4.4201    |
| 3    | 8.5353    | 8.078     | 9.9832    | ***       | 1.9433    | ***       | ***       |
| 4    | 8.3448    | 8.5353    | ***       | ***       | 2.0576    | ***       | ***       |
| 5    | 8.2686    | 9.2212    | ***       | ***       | 2.21      | ***       | ***       |
| 6    | 8.5734    | 9.8308    | ***       | ***       | 2.5911    | ***       | ***       |
| 7    | 8.802     | ***       | ***       | ***       | 2.7054    | ***       | ***       |
| 8    | 9.6784    | ***       | 7.5446    | ***       | ***       | ***       | ***       |
| 9    | ***       | ***       | ***       | ***       | ***       | ***       | ***       |
| 10   | ***       | 9.4498    | 6.7063    |           | 7.8494    | ***       | ***       |
| 11   | 1.6385    | 1.2574    | 1.2955    |           | 1.3336    | 1.3717    | 1.3717    |
| 12   | 1.1431    | 1.105     | 1.2955    |           | 1.3336    | 1.1812    | 1.1812    |
| 13   | 1.0669    | .9907     | 1.3336    |           | 1.2193    | 1.0669    | 1.1431    |
| 14   | 1.105     | .9526     | 1.3336    |           | 1.2193    | 1.1431    | 1.0669    |
| 15   | 1.1812    | .9145     | 1.3717    |           | 1.3717    | 1.1812    | 1.0669    |
| 16   | 1.1812    | 1.0669    | 1.3336    |           | 1.3336    | 1.2193    | 1.105     |
| 17   | 1.1812    | 1.0669    | 1.406     |           | 1.5242    | 1.1812    | 1.2193    |
| 18   | 1.5623    | 1.4098    | 1.8618    |           | 1.5623    | 1.5623    | 1.5623    |
| 19   | 2.7054    | 2.7054    | 2.6673    | 1.8671    | 2.8959    | 2.553     | 2.5149    |
| 20   | 3.1245    | 2.8578    | 2.9721    | 3.0102    | 3.2388    | 3.1626    | 2.934     |
| 21   | 3.0864    | 2.7816    | 2.8959    | 3.0483    | 3.0102    | 2.9721    | 2.8959    |
| 22   | 2.8959    | 2.6292    | 2.7054    | 2.7816    | 2.934     | 2.7816    | 2.5911    |
| 23   | 2.5149    | 2.2481    | 2.3624    | 2.3243    | 2.5149    | 2.4387    | 2.2862    |
| 24   | 2.5834    | 1.9814    | 2.0957    | 2.3319    | 2.5567    | 2.4767    | 2.0576    |
| Max  | 10.5167   | 12.0028   | 12.46     | 13.3745   | 12.3457   | 13.9461   | 13.4888   |
| Min  | 1.0669    | .9145     | 1.2955    | 1.8671    | 1.2193    | 1.0669    | 1.0669    |
| Avg  | 4.9056    | 4.6011    | 4.8150    | 7.2987    | 3.1056    | 5.7362    | 5.3552    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 205 / 11 KV RAJUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 17   |           | .4239     |           |           |           |
| 18   |           | .5087     |           |           |           |
| 24   | .3429     |           | .4115     | .2743     | .3772     |
| Max  | .3429     | .5087     | .4115     | .2743     | .3772     |
| Min  | .3429     | .4239     | .4115     | .2743     | .3772     |
| Avg  | .3429     | .4663     | .4115     | .2743     | .3772     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 206 / 11 KV PIMPARKANE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 7    |           |           |           |           | .0686     |
| 17   |           | .0724     |           |           |           |
| 18   |           | .0724     |           |           |           |
| 24   | .0686     |           | .0686     | .0686     | .0686     |
| Max  | .0686     | .0724     | .0686     | .0686     | .0686     |
| Min  | .0686     | .0724     | .0686     | .0686     | .0686     |
| Avg  | .0686     | .0724     | .0686     | .0686     | .0686     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014029 / 33/11 KV RAJUR

Feeder No / Name : 207 / Vitha GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 17   |           | .056      |           |           |           |
| 18   |           | .0085     |           |           |           |
| 24   | .1372     |           | .1029     | .1372     | .1029     |
| Max  | .1372     | .056      | .1029     | .1372     | .1029     |
| Min  | .1372     | .0085     | .1029     | .1372     | .1029     |
| Avg  | .1372     | .0323     | .1029     | .1372     | .1029     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 201 / 11 KV KOTUL U GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .12       |
| Max  | .12       |
| Min  | .12       |
| Avg  | .12       |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 202 / 11 KV DHAMANGAON PAT  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           |           |           | .1715     |
| 10   |           |           |           |           | .2401     |
| 11   |           |           |           |           | 3.0521    |
| 15   |           | 2.5549    |           |           |           |
| 24   | 3.3436    |           | .2229     | .1715     |           |
| Max  | 3.3436    | 2.5549    | .2229     | .1715     | 3.0521    |
| Min  | 3.3436    | 2.5549    | .2229     | .1715     | .1715     |
| Avg  | 3.3436    | 2.5549    | .2229     | .1715     | 1.1546    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 203 / 11 KV KOTUL -R-

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.8176    |           |           |           |
| 9    |           |           |           | 3.1207    |
| 10   |           |           |           | 2.8978    |
| 11   |           |           |           | .2058     |
| 24   | 1.9547    | .2229     | .3429     |           |
| Max  | 1.9547    | .2229     | .3429     | 3.1207    |
| Min  | 1.8176    | .2229     | .3429     | .2058     |
| Avg  | 1.8862    | .2229     | .3429     | 2.0748    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 204 / NACHANTHAV

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           | 1.5432    |
| 10   |           |           | 1.1488    |
| 11   |           |           | .1543     |
| 15   | .2229     |           |           |
| 24   |           | .2401     |           |
| Max  | .2229     | .2401     | 1.5432    |
| Min  | .2229     | .2401     | .1543     |
| Avg  | .2229     | .2401     | .9488     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 205 / DHAMANGAONPAT GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           | .2286     |
| 10   |           |           | .3429     |
| 15   | .1715     |           |           |
| 24   |           | .2743     |           |
| Max  | .1715     | .2743     | .3429     |
| Min  | .1715     | .2743     | .2286     |
| Avg  | .1715     | .2743     | .2858     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 206 / AMBHOL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           | .2058     |
| 10   |           |           | .3429     |
| 15   | .2229     |           |           |
| 24   |           | 1.989     |           |
| Max  | .2229     | 1.989     | .3429     |
| Min  | .2229     | 1.989     | .2058     |
| Avg  | .2229     | 1.989     | .2744     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014030 / 33/11 KV KOTUL

Feeder No / Name : 207 / ABIT KHIND

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 9    |           |           | .4287     |
| 10   |           |           | .3601     |
| 15   | .2229     |           |           |
| 24   |           | .8402     |           |
| Max  | .2229     | .8402     | .4287     |
| Min  | .2229     | .8402     | .3601     |
| Avg  | .2229     | .8402     | .3944     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014031 / 33/11 KV BRAHMANWADA

Feeder No / Name : 201 / 11 KV KALAMB

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.2579    |
| Max  | 3.2579    |
| Min  | 3.2579    |
| Avg  | 3.2579    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014031 / 33/11 KV BRAHMANWADA

Feeder No / Name : 202 / 11KV BELAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 3.1722    |
| Max  | 3.1722    |
| Min  | 3.1722    |
| Avg  | 3.1722    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014031 / 33/11 KV BRAHMANWADA

Feeder No / Name : 203 / KALAMB GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6859     |
| Max  | .6859     |
| Min  | .6859     |
| Avg  | .6859     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014031 / 33/11 KV BRAHMANWADA

Feeder No / Name : 204 / CHAITANYAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.915     |
| Max  | 2.915     |
| Min  | 2.915     |
| Avg  | 2.915     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014093 / 33/11 KV KOHANE

Feeder No / Name : 203 / 11 KV MECHKARWADI AG

SINGLE PHASING

FEEDER Feeder KV- 11 /  
OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0566     |           | .0566     | .0566     | .0566     | .0566     | .0566     |
| 2    | .0566     |           | .0566     | .0566     | .0566     | .0566     | .0754     |
| 3    | .0566     |           | .0566     | .0566     | .0566     | .0566     | .0754     |
| 4    | .0566     |           | .0566     | .0566     | .0566     | .0566     | .0566     |
| 5    | .0566     |           | .0566     | .0566     | .0566     | .0754     | .0754     |
| 6    | .0754     |           | .0754     | .0754     | .0943     | .0943     | .0943     |
| 7    | .0754     |           | .0943     | .0943     | .0754     | .0754     | .0943     |
| 8    | .0566     |           | .0377     | .0754     | .0377     | .0566     | .0754     |
| 9    | .0377     |           |           |           | .0377     |           |           |
| 10   | .0377     |           |           |           | .0377     |           |           |
| 11   | .8718     |           |           |           | .9665     |           |           |
| 12   | 1.0898    |           |           |           | 1.1736    |           |           |
| 13   | 1.0059    |           |           |           | 1.1568    |           |           |
| 14   | 1.1568    |           |           |           | 1.1568    |           |           |
| 15   | 1.2071    |           |           |           | 1.1022    |           |           |
| 16   | 1.1065    |           |           |           | 1.096     |           |           |
| 17   | .9774     | .9945     | 1.0117    |           | 1.0117    | 1.0117    |           |
| 18   | .8573     | .9774     | .9431     |           | .7888     | .8573     |           |
| 19   | .0754     | .0943     | .0943     |           | .0754     | .0754     |           |
| 20   | .0566     | .0754     | .0943     | .0943     | .0943     | .0943     |           |
| 21   | .0566     | .0754     | .0943     | .0754     | .0754     | .0943     |           |
| 22   | .0566     | .0754     | .0754     | .0754     | .0754     | .0754     |           |
| 23   | .0566     | .0754     | .0566     | .0566     | .0566     | .0566     |           |
| 24   | .0566     | .0566     | .0566     | .0566     | .0566     | .0566     | .0566     |
| Max  | 1.2071    | .9945     | 1.0117    | .0943     | 1.1736    | 1.0117    | .0943     |
| Min  | .0377     | .0566     | .0377     | .0566     | .0377     | .0566     | .0566     |
| Avg  | .3832     | .3031     | .1823     | .0682     | .3938     | .1781     | .0733     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014097 / 33/11 KV SHENDI

Feeder No / Name : 201 / 11 KV DEVGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3429     |           | .3086     |
| 2    | .3086     |           | .2915     |
| 3    | 1.0288    |           | .7716     |
| 4    | 1.0974    |           | .823      |
| 5    | 1.166     |           | .8916     |
| 6    | 1.166     |           | .9602     |
| 7    | 1.166     |           | .8573     |
| 8    | 1.1317    |           | .9431     |
| 9    | .7716     |           |           |
| 10   | .7716     |           |           |
| 11   | .4115     |           |           |
| 12   | .4115     |           |           |
| 13   | .3772     |           |           |
| 14   | .3772     |           |           |
| 15   | .3944     |           |           |
| 17   | .3601     | .3601     |           |
| 18   | .3601     | .3258     |           |
| 19   | .4801     | .3429     |           |
| 20   | .463      | .3601     |           |
| 21   | .4458     | .3772     |           |
| 22   | .4287     | .3429     |           |
| 23   | .4287     | .3429     |           |
| 24   | 2.572     | .3944     | .3086     |
| Max  | 2.572     | .3944     | .9602     |
| Min  | .3086     | .3258     | .2915     |
| Avg  | .7157     | .3558     | .6839     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014097 / 33/11 KV SHENDI

Feeder No / Name : 202 / 11 KV GHATGHAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2743     |           | .2572     |
| 2    | .2743     |           | .2572     |
| 3    | .5144     |           | .6859     |
| 4    | .5144     |           | .7202     |
| 5    | .4801     |           | .7716     |
| 6    | .5487     |           | .823      |
| 7    | .583      |           | .7202     |
| 8    | .5144     |           | .8573     |
| 9    | .4458     |           |           |
| 10   | .4115     |           |           |
| 11   | .2915     |           |           |
| 12   | .2915     |           |           |
| 13   | .3086     |           |           |
| 14   | .3086     |           |           |
| 15   | .2915     |           |           |
| 17   | .2572     | .3086     |           |
| 18   |           | .2915     |           |
| 19   | .3601     | .3086     |           |
| 20   | .3601     | .3429     |           |
| 21   | .3258     | .3429     |           |
| 22   | .3086     | .3086     |           |
| 23   | .2915     | .2915     |           |
| 24   | .2743     | .2743     | .2743     |
| Max  | .583      | .3429     | .8573     |
| Min  | .2572     | .2743     | .2572     |
| Avg  | .3741     | .3086     | .5963     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014097 / 33/11 KV SHENDI

Feeder No / Name : 203 / 11 KV RATANWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3086     |           | .3772     |
| 2    | .3086     |           | .3429     |
| 3    | .3429     |           | .3429     |
| 4    | .3429     |           | .3086     |
| 9    | .3601     |           |           |
| 10   | .3601     |           |           |
| 11   | 1.2517    |           |           |
| 12   | .1423     |           |           |
| 13   | 1.5089    |           |           |
| 14   | 1.5432    |           |           |
| 15   | 1.6461    |           |           |
| 17   | 1.5775    | 1.166     |           |
| 18   | 1.5775    | 1.0288    |           |
| 19   | .4458     | .3772     |           |
| 20   | .4287     | .4115     |           |
| 21   | .4115     | .4287     |           |
| 22   | .3772     | .4115     |           |
| 23   | .3601     | .4115     |           |
| 24   | 2.7435    | .3429     | .3772     |
| Max  | 2.7435    | 1.166     | .3772     |
| Min  | .1423     | .3429     | .3086     |
| Avg  | .8441     | .5723     | .3498     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

RAJUR[584]

BU 6742

Substation No/ Name :- 014097 / 33/11 KV SHENDI

Feeder No / Name : 204 / 11 KV S P Valley

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0514     | .0514     | .0514     |
| 2    | .0514     | .0514     | .0514     |
| 3    | .0514     |           | .0514     |
| 4    | .0514     |           | .0514     |
| 5    | .0514     |           | .0514     |
| 6    | .0514     |           | .0514     |
| 7    | .0343     |           | .0343     |
| 8    | .0343     |           | .0343     |
| 9    | .0343     |           |           |
| 10   | .0343     |           |           |
| 11   | .0343     |           |           |
| 12   | .0343     |           |           |
| 13   | .0343     |           |           |
| 14   | .0343     |           |           |
| 15   | .0343     |           |           |
| 17   | .0343     | .0343     |           |
| 18   | .0343     | .0343     |           |
| 19   | .0514     | .0514     |           |
| 20   | .0514     | .0514     |           |
| 21   | .0514     | .0514     |           |
| 22   | .0514     | .0514     |           |
| 23   | .0514     | .0514     |           |
| 24   | .0857     | .0514     | .0514     |
| Max  | .0857     | .0514     | .0514     |
| Min  | .0343     | .0343     | .0343     |
| Avg  | .0447     | .0480     | .0476     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014016 / 33/11 KV PIMPARNE SUB-STATION

Feeder No / Name : 201 / 11 KV Pimparne  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9054     | 1.2605    | 2.2965    | 1.2567    | 1.2864    | 1.3047    | 2.2275    |
| 2    | .9572     | 1.2391    | 2.3536    | 1.3504    | 1.278     | 1.3527    | 2.2626    |
| 3    | .9762     | 1.2772    | 2.3605    | 1.3641    | 1.2879    | 1.4167    | 2.2862    |
| 4    | .9808     | 1.3984    | 2.5548    | 1.355     | 1.2986    | 1.5036    | 2.4847    |
| 5    | 1.0936    | 1.5257    | 2.947     | 1.4883    | 1.4952    | 1.6895    | 2.8181    |
| 6    | 1.4548    | 1.8351    | 3.6188    | 1.9098    | 1.9624    | 2.0576    | 3.5138    |
| 7    | 2.005     | 2.3472    | 3.9324    | 2.2984    | 2.2306    | 2.2664    | 4.1985    |
| 8    | 2.4265    | 2.6437    | 3.9182    | 1.5501    | 1.1759    | 2.9721    | 2.6825    |
| 9    | 5.4253    | 3.0476    | 5.7068    | 3.1718    | 5.6398    | 3.0689    | 5.4199    |
| 10   | .6889     | .3315     | .7446     | .346      | .7224     | .8177     | .6545     |
| 11   | .3124     | .1593     | .1463     | .1661     | .3048     | .1738     | .3178     |
| 12   | .0366     | .0076     | .0168     | .0076     | .0358     |           | .1539     |
| 18   | .1143     | .2485     | .0213     | .1379     | .1372     | .1486     | .1357     |
| 19   | .2378     | .4843     | .2683     | .2515     | .2591     | .4773     | .2454     |
| 20   | .2987     | .5224     | .2919     | .2904     | .2942     | .5044     | .2812     |
| 21   | .2827     | .5125     | .2759     | .2881     | .2759     | .5087     | .2743     |
| 22   | .2743     | .4595     | .2629     | .2667     | .2576     | .41       | .445      |
| 23   | .2347     | .378      | .2233     | .2286     | .2317     | .362      | .4199     |
| 24   | 3.504     | 1.1835    | 2.1045    | 1.2186    | 3.6553    | 1.2353    | 1.0384    |
| Max  | 5.4253    | 3.0476    | 5.7068    | 3.1718    | 5.6398    | 3.0689    | 5.4199    |
| Min  | .0366     | .0076     | .0168     | .0076     | .0358     | .1486     | .1357     |
| Avg  | 1.1689    | 1.0980    | 1.7918    | .9972     | 1.2541    | 1.2372    | 1.6768    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014016 / 33/11 KV PIMPARNE SUB-  
STATION

Feeder No / Name : 204 / Jorva

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.4387    |
| Max  | 2.4387    |
| Min  | 2.4387    |
| Avg  | 2.4387    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014016 / 33/11 KV PIMPARNE SUB-STATION

Feeder No / Name : 205 / Digras

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .3353     |           |           | .2515     |
| 2    |           |           | .3353     |           |           | .2515     |
| 3    |           |           | .3353     |           |           | .2515     |
| 4    |           |           | .3353     |           |           | .2515     |
| 5    |           |           | .3353     |           |           | .2515     |
| 6    |           |           | .3353     |           |           | .3391     |
| 7    |           |           | .4191     |           |           | .3391     |
| 8    |           |           | .3521     |           |           | .3561     |
| 9    | .3315     |           | .3906     | .3048     | .381      | .4239     |
| 10   | .3812     |           |           | .3125     | .3201     | .2743     |
| 11   | .2858     |           |           | .2515     |           | .2743     |
| 12   | 2.4863    |           |           | 1.7966    |           | 2.5101    |
| 13   | 2.6558    | 2.652     |           |           |           |           |
| 14   | 2.7854    | 2.6825    |           |           |           |           |
| 15   | 2.8841    | 2.3624    |           |           | 2.1338    |           |
| 16   | 2.8837    | 2.3434    |           |           | 2.652     |           |
| 17   |           | 2.4453    |           |           |           |           |
| 18   |           | 2.1862    |           |           | 2.2969    |           |
| 19   |           | 2.0325    |           |           | 1.9685    |           |
| 20   |           | .4801     |           |           | .4801     |           |
| 21   |           | .503      |           |           | .4801     |           |
| 22   |           | .4973     |           |           | .4344     | .4115     |
| 23   |           | .503      |           |           | .2515     | .4115     |
| 24   | 1.829     |           | .3353     |           |           | .2515     |
| Max  | 2.8841    | 2.6825    | .4191     | 1.7966    | 2.652     | 2.5101    |
| Min  | .2858     | .4801     | .3353     | .2515     | .2515     | .2515     |
| Avg  | 1.8359    | 1.6989    | .3509     | .6664     | 1.1398    | .4566     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014016 / 33/11 KV PIMPARNE SUB-

STATION

Feeder No / Name : 206 / rayate gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .1829     |           |           | .1791     |
| 2    |           |           |           |           |           | .1791     |
| 3    |           |           | .1829     |           |           | .1791     |
| 4    |           |           | .2195     |           |           | .2149     |
| 5    |           |           | .2926     |           |           | .2583     |
| 6    |           |           | .3921     |           |           | .3772     |
| 7    |           |           | .4108     |           |           | .4108     |
| 8    |           |           | .3982     |           |           | .4572     |
| 9    | .3772     |           | .3481     | .3647     | .3149     | .3814     |
| 10   | 1.283     |           |           | .2629     | .2486     | .2774     |
| 11   | .1734     |           |           | .2658     |           | .208      |
| 12   | .1886     |           |           | .1417     |           | .1844     |
| 13   | .1715     | .1326     |           |           |           |           |
| 14   | .1715     | .1638     |           |           |           |           |
| 15   | .1823     | .1638     |           |           | .2785     |           |
| 16   | .1638     | .1943     |           |           | .2204     |           |
| 17   |           | .2229     |           |           | .2486     |           |
| 18   |           | .2652     |           |           | .2984     |           |
| 19   |           | .3856     |           |           | .463      |           |
| 20   |           | .3681     |           |           | .4075     |           |
| 21   |           | .2507     |           |           | .3045     |           |
| 22   |           | .2195     |           |           | .2149     | .2926     |
| 23   |           | .2012     |           |           | .1791     | .2926     |
| 24   | .381      |           | .1829     |           |           | .1829     |
| Max  | 1.283     | .3856     | .4108     | .3647     | .463      | .4572     |
| Min  | .1638     | .1326     | .1829     | .1417     | .1791     | .1791     |
| Avg  | .3436     | .2334     | .29       | .2588     | .2889     | .2717     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 201 / Chandanapuri

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 3.0483    |           | 4.3275    | 3.6199    | 3.8485    | 3.9628    | .8145     |
| 2    | 3.0483    |           | 4.3449    | 4.3688    | 3.8866    | 3.9247    | .8326     |
| 3    | 3.1626    | .6935     | 4.3849    | 3.658     | 3.6961    | 4.7597    | .8507     |
| 4    | 3.315     |           | 4.7078    | 4.7135    | 3.9247    | 4.2295    | .823      |
| 5    | 3.6199    |           | 5.5185    | 4.7249    | 4.6106    | 4.763     | 1.0136    |
| 6    | 6.2545    | 1.1096    | 7.5312    | 7.6589    | 6.592     | 6.0966    | 1.1946    |
| 7    | 8.1162    |           | 8.8401    | ***       | 9.7927    | ***       |           |
| 8    | ***       |           | ***       | ***       | ***       | ***       |           |
| 9    | 9.4498    | 2.713     | ***       | ***       | ***       | 9.7546    | 2.4756    |
| 15   |           |           | 1.3717    | 1.4098    | 1.6004    | 7.2017    |           |
| 16   |           |           | 2.0957    | 2.6996    | 2.0957    | 2.7621    |           |
| 17   |           | .5533     | 2.6444    | 2.0195    | 2.6566    | 2.7492    | .5487     |
| 18   |           | .5087     | 2.6825    | 2.2481    | 2.21      | 2.793     | .5658     |
| 19   |           | .6443     | 2.8197    | 2.8197    | 2.6292    | 3.4427    |           |
| 20   |           | .7373     | 3.6637    | 2.8959    | 2.8578    | 3.4997    | .7545     |
| 21   |           | .6415     | 2.553     | 2.7435    | 2.6292    | 3.4294    | .6859     |
| 22   |           | .5895     | 2.9865    | 2.553     | 2.5149    | 3.2027    |           |
| 23   | .6135     | .5548     | 2.553     | 2.8959    | 3.0483    | 3.3189    | .6173     |
| 24   | 2.2862    | .583      | 4.4037    | 4.4624    | 4.0009    | 4.2334    | 3.1551    |
| Max  | 10.2119   | 2.713     | 12.9554   | 14.209    | 13.6993   | 12.9896   | 3.1551    |
| Min  | .6135     | .5087     | 1.3717    | 1.4098    | 1.6004    | 2.7492    | .5487     |
| Avg  | 4.8297    | .8480     | 4.8468    | 4.9740    | 4.6349    | 5.2302    | 1.1025    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 202 / hiwargaon pawsa SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .6097     |           |           |           | .6554     |
| 2    |           |           | .6097     | .5182     |           |           | .6706     |
| 3    |           | .4877     | .6249     |           |           | .6706     | 1.0059    |
| 4    |           |           | .6249     | .6401     |           |           | 1.0822    |
| 5    |           |           | .7011     |           |           |           | 1.0059    |
| 6    | .8535     | .9297     | 1.0059    | 1.1279    |           |           | 1.0822    |
| 7    |           |           | 1.3108    | 1.6461    |           | 1.8595    | 1.5699    |
| 8    |           |           |           | 1.9814    | 2.1186    | 2.0576    |           |
| 9    |           | 1.4632    | 1.4327    | 1.5242    | 1.829     |           | 1.9052    |
| 16   | .1524     |           |           | .2134     |           | .1677     |           |
| 17   |           | .1829     | .1677     |           | .2439     | .2439     | .2134     |
| 18   |           | .1981     | .1829     |           |           | .2439     | .2286     |
| 19   |           | .3506     |           |           |           | .4115     |           |
| 20   |           | .4115     | .4115     |           |           | .3963     | .4115     |
| 21   |           | .3506     |           |           |           | .3506     | .381      |
| 22   |           | .3048     | .3201     |           |           | .3353     |           |
| 23   | .2743     | ***       |           |           |           | .3048     | .2896     |
| 24   | .503      | .4268     | .5944     | .5335     |           | .5487     | .381      |
| Max  | .8535     | 78.3418   | 1.4327    | 1.9814    | 2.1186    | 2.0576    | 1.9052    |
| Min  | .1524     | .1829     | .1677     | .2134     | .2439     | .1677     | .2134     |
| Avg  | .4458     | 7.5862    | .6613     | 1.0231    | 1.3972    | .6325     | .7773     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 203 / shirapur SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .4877     |           |           |           |           |
| 2    |           |           | .5182     | .442      |           |           | .5639     |
| 3    |           | .4458     | .5335     |           |           | .5487     | .6097     |
| 4    |           |           | .5639     | .5182     |           |           | .6401     |
| 5    |           |           | .6401     |           |           |           | .7316     |
| 6    | .7164     | .8916     | .7926     | .8535     |           |           | .8383     |
| 7    |           |           | 1.2498    | 1.4022    |           | 1.5699    |           |
| 8    |           |           |           | 1.6766    | 1.2498    | 1.8595    |           |
| 9    |           | 1.4784    | 1.4918    | 1.4784    | 1.4327    |           | 1.448     |
| 16   | .1524     |           |           | .1067     |           |           |           |
| 17   |           | .1677     | .1677     |           | .1677     |           | .1372     |
| 18   |           | .1372     | .1981     |           |           | .1829     | .1677     |
| 19   |           | .2439     |           |           |           | .2591     |           |
| 20   |           | .3201     | .3048     |           |           | .3201     | .2743     |
| 21   |           | .2896     |           |           |           | .3048     | .2439     |
| 22   |           | .2439     | .2286     |           |           | .2896     |           |
| 23   | .2134     | .2134     |           |           |           | .2439     | .2134     |
| 24   | .3658     | .3429     | .4725     | .4572     |           | .5144     | .2439     |
| Max  | .7164     | 1.4784    | 1.4918    | 1.6766    | 1.4327    | 1.8595    | 1.448     |
| Min  | .1524     | .1372     | .1677     | .1067     | .1677     | .1829     | .1372     |
| Avg  | .362      | .4340     | .5884     | .8669     | .9501     | .6093     | .5093     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 204 / zole SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .5182     |           |           |           | .4877     |
| 2    |           |           | .5182     | .503      |           |           | .503      |
| 3    |           | .6097     | .5335     |           |           | .5182     | .5182     |
| 4    |           |           | .6706     | .5944     |           |           | .5335     |
| 5    |           |           |           |           |           |           | .7621     |
| 6    | .8535     | 1.0212    |           | .9145     |           | .9602     | .9907     |
| 12   | 3.3532    | 3.4598    | 3.8104    |           | 3.5056    |           |           |
| 13   | 3.2769    |           |           |           |           |           | 3.4294    |
| 14   | 3.3532    |           |           | 3.3836    | 3.658     |           |           |
| 15   | 3.4294    |           | 3.7799    | 2.3472    | 3.3989    |           |           |
| 16   | 3.8104    |           |           | 3.3227    |           |           |           |
| 17   |           | 3.6885    | 2.9264    |           |           |           | 3.3836    |
| 18   |           | 3.0026    | 2.6368    |           |           |           | 3.094     |
| 19   |           | 2.9111    |           |           |           | 3.2007    |           |
| 20   |           | .7316     | .7316     |           |           | .7621     | .7164     |
| 21   |           | .7316     |           |           |           | .6859     | .6706     |
| 22   |           | .6859     | .6859     |           |           | .6401     |           |
| 23   | .6097     | .6097     |           |           |           | .6249     | .5639     |
| 24   | .5182     | .5792     | .4725     | .5182     |           | .5182     | .6706     |
| Max  | 3.8104    | 3.6885    | 3.8104    | 3.3836    | 3.658     | 3.2007    | 3.4294    |
| Min  | .5182     | .5792     | .4725     | .503      | 3.3989    | .5182     | .4877     |
| Avg  | 2.4006    | 1.6392    | 1.5713    | 1.6548    | 3.5208    | .9888     | 1.2557    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 205 / channapuri gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .1334     |           |           |           | .1715     |
| 2    |           |           | .1334     | .1143     |           |           | .1715     |
| 3    |           | .1334     | .1334     |           |           | .132      | .1524     |
| 4    |           |           | .1334     | .1143     |           |           | .1524     |
| 5    |           |           | .1524     |           |           |           | .1524     |
| 6    | .1334     | .1715     | .1524     | .1334     |           |           | .1524     |
| 7    |           |           |           | .1905     |           | .1886     |           |
| 8    |           |           | .1905     |           | .2096     | .1715     |           |
| 9    |           |           | .2286     | .1715     |           |           | .2096     |
| 10   |           |           |           | .1715     |           |           |           |
| 11   |           |           |           | .1143     |           |           |           |
| 12   | .1334     |           | .0953     |           | .1524     |           |           |
| 13   | .168      |           |           | .0762     |           |           |           |
| 14   | .1334     |           |           |           | .1143     |           |           |
| 15   | .0953     |           | .1524     | .0762     | .0762     |           |           |
| 16   | .0953     |           |           | .0953     |           | .1143     |           |
| 17   |           | .1715     | .1143     |           |           | .1334     | .1715     |
| 18   |           | .1715     | .1334     |           |           | .1334     | .1715     |
| 19   |           | .2286     |           |           |           | .2286     |           |
| 20   |           | .2286     | .2286     |           |           | .2715     | .2858     |
| 21   |           | .1715     |           |           |           | .2286     | .2096     |
| 22   |           | .1524     | .1524     |           |           | .1905     |           |
| 23   | .1219     | .1334     |           |           |           | .1715     | .1905     |
| 24   | .1715     | .132      | .1334     | .1334     |           | .1698     | .1905     |
| Max  | .1715     | .2286     | .2286     | .1905     | .2096     | .2715     | .2858     |
| Min  | .0953     | .132      | .0953     | .0762     | .0762     | .1143     | .1524     |
| Avg  | .1315     | .1694     | .1512     | .1264     | .1381     | .1778     | .1832     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014017 / 33/11 KV HIWARGAON PAVASA

Feeder No / Name : 207 / Savargaon Tal

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .2401     |           |           |           | .2353     |
| 2    |           |           | .2229     | .208      |           |           | .2534     |
| 3    |           | .2883     | .2572     |           |           | .2641     | .2715     |
| 4    | 2.0576    |           | .2896     | .3086     |           |           | .2896     |
| 5    |           |           | .362      |           |           |           | .362      |
| 6    | .421      | .4409     |           | .4115     |           | .4904     | .4115     |
| 7    |           |           |           |           | .4207     |           |           |
| 12   | 2.7149    |           | 2.5857    | 2.2291    | 2.2634    |           |           |
| 13   | 2.8807    |           |           |           |           |           | 2.431     |
| 14   |           |           |           | 2.4348    | 2.0576    |           |           |
| 15   | 1.8861    |           | 2.5149    | 1.989     | 1.989     |           |           |
| 16   | 2.572     |           |           | 2.4691    |           | 2.4291    |           |
| 17   |           | 2.3922    | 2.2634    |           | 1.9845    | 2.6749    | 2.0972    |
| 18   |           | 1.7368    | 1.9204    |           |           | 2.17      | 1.9662    |
| 19   |           | 1.5424    |           |           |           | 1.9547    |           |
| 20   |           | .373      | .4115     |           |           | .4572     | .3605     |
| 21   |           | .3429     |           |           |           | .362      | .3277     |
| 22   |           |           | .3121     |           |           | .3258     |           |
| 23   | .218      | .3429     |           |           |           | .2801     | .2401     |
| 24   | .2401     | .2204     | .2401     | .2427     |           | .2286     | .2477     |
| Max  | 2.8807    | 2.3922    | 2.5857    | 2.4691    | 2.2634    | 2.6749    | 2.431     |
| Min  | .218      | .2204     | .2229     | .208      | .4207     | .2286     | .2353     |
| Avg  | 1.6238    | .8533     | .9683     | 1.2866    | 1.7430    | 1.0579    | .7303     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014018 / 33/11 KV TALEGAON SUBSTATION

Feeder No / Name : 201 / Chincholi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.7528    |
| Max  | 1.7528    |
| Min  | 1.7528    |
| Avg  | 1.7528    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014018 / 33/11 KV TALEGAON SUBSTATION

Feeder No / Name : 202 / Nimon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1338    |
| Max  | 2.1338    |
| Min  | 2.1338    |
| Avg  | 2.1338    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014018 / 33/11 KV TALEGAON SUBSTATION

Feeder No / Name : 203 / Vadzari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.7528    |
| Max  | 1.7528    |
| Min  | 1.7528    |
| Avg  | 1.7528    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014018 / 33/11 KV TALEGAON SUBSTATION

Feeder No / Name : 205 / Vadzari Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .061      | .061      | .0762     | .061      |           |           | .061      |
| 2    | .061      | .061      | .061      | .0457     |           |           | .061      |
| 3    | .0457     | .0457     | .061      | .061      |           |           | .061      |
| 4    | .061      | .0762     | .0762     | .061      |           |           | .0762     |
| 5    | .0914     | .0914     | .1067     | .0914     |           |           | .1067     |
| 6    | .1372     | .1219     | .1372     | .1372     |           |           | .1524     |
| 7    | .1981     | .1829     | .1677     | .1829     |           |           | .1829     |
| 8    | .1372     | .1524     | .1067     | .1372     |           |           |           |
| 9    |           | .2439     | .1372     | .1372     | .1677     |           |           |
| 10   |           | .1829     | .1067     | .1219     | .1524     |           |           |
| 11   |           |           | .0457     | .1067     | .061      |           |           |
| 12   |           | .061      | .0305     | .0457     | .0914     |           |           |
| 13   |           | .0305     | .0457     | .061      | .0305     |           |           |
| 14   |           | .0305     | .0457     | .0305     | .0305     |           |           |
| 15   |           |           | .0762     | .0457     |           |           |           |
| 16   |           | .0305     |           | .0305     |           |           |           |
| 17   |           | .0305     |           |           |           | .0914     |           |
| 18   |           | .0762     |           |           |           | .1067     |           |
| 19   |           | .1372     |           |           |           | .1677     |           |
| 20   | .1372     | .1219     |           |           |           | .1372     |           |
| 21   | .1067     | .1219     |           |           |           | .1219     |           |
| 22   | .0914     | .1067     | .1524     |           |           | .1067     |           |
| 23   | .0762     | .1067     | .1219     |           |           | .0914     |           |
| 24   | .5792     | .061      | .0762     | .061      |           |           | .0762     |
| Max  | .5792     | .2439     | .1677     | .1829     | .1677     | .1677     | .1829     |
| Min  | .0457     | .0305     | .0305     | .0305     | .0305     | .0914     | .061      |
| Avg  | .1372     | .0970     | .0906     | .0834     | .0889     | .1176     | .0972     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014018 / 33/11 KV TALEGAON SUBSTATION

Feeder No / Name : 206 / chincholi 2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1338    |
| Max  | 2.1338    |
| Min  | 2.1338    |
| Avg  | 2.1338    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014018 / 33/11 KV TALEGAON SUBSTATION

Feeder No / Name : 207 / vadzari 2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2743     | .2743     | .2896     | .2572     |           |           | .2743     |
| 2    | .2743     | .2743     | .2743     | .2572     |           |           | .2743     |
| 3    | .2743     | .2743     | .2743     | .2572     |           |           | .2591     |
| 4    | .2915     | .2915     | .2591     | .2743     |           |           | .2591     |
| 5    | .3258     | .3086     | .2591     | .2915     |           |           | .2591     |
| 6    | .3601     | .3429     | .2743     | .3429     |           |           | .2743     |
| 12   |           | 1.326     | 1.1431    | 1.3413    | 1.2346    |           |           |
| 13   |           | 1.2955    | .4801     | .7926     | 1.0822    |           |           |
| 14   |           | 1.2041    | 1.2193    | .7316     | 1.0212    |           |           |
| 15   |           |           | 1.1584    | .7011     | .0305     |           |           |
| 16   |           | 1.2193    |           | 1.1431    |           |           |           |
| 17   |           | 1.1736    |           |           |           | 1.3413    |           |
| 18   |           | 1.0364    |           |           |           | 1.2803    |           |
| 19   |           | 1.0669    |           |           |           | .9907     |           |
| 20   | .3353     | .3658     |           |           |           | .3506     |           |
| 21   | .3353     | .381      |           |           |           | .3201     |           |
| 22   | .3201     | .381      | .4458     |           |           | .3353     |           |
| 23   | .2743     | .381      | .3429     |           |           | .3048     |           |
| 24   | .2591     | .2591     | .3353     | .2572     |           |           | .2743     |
| Max  | .3601     | 1.326     | 1.2193    | 1.3413    | 1.2346    | 1.3413    | .2743     |
| Min  | .2591     | .2591     | .2591     | .2572     | .0305     | .3048     | .2591     |
| Avg  | .3022     | .6586     | .5197     | .5539     | .8421     | .7033     | .2678     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014018 / 33/11 KV TALEGAON SUBSTATION

Feeder No / Name : 208 / CHINCHOLI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .4115     | .4287     | .4458     | .4287     |           |           | .4801     |
| 2    | .4115     | .4115     | .4115     | .4287     |           |           | .4458     |
| 3    | .4115     | .4115     | .4115     | .4287     |           |           | .4458     |
| 4    | .4458     | .4458     | .4115     | .4801     |           |           | .4801     |
| 5    | .5658     | .583      | .5144     | .5658     |           |           | .583      |
| 6    | .7545     | .823      | .823      | .7888     |           |           | .8573     |
| 7    | 1.0631    | .7926     | .9945     | .884      |           |           | .9602     |
| 8    | 1.0288    | .9145     | .9602     | .8745     |           |           |           |
| 9    |           | .7773     | .8916     | .7202     | .8535     |           |           |
| 10   |           | .6859     | .7202     | .6859     | .6687     |           |           |
| 11   |           |           | .583      | .6173     | .5144     |           |           |
| 12   |           | .5144     | .4801     |           | .4801     |           |           |
| 13   |           | .3772     |           |           | .3772     |           |           |
| 14   |           | .4458     | .4287     | .583      | .3772     |           |           |
| 15   |           |           | .4115     | .5144     | .4458     |           |           |
| 16   |           | .4115     |           | .4268     |           |           |           |
| 17   |           | .4115     |           |           |           | .6173     |           |
| 18   |           | .5144     |           |           |           | .7545     |           |
| 19   |           | .9259     |           |           |           | 1.0288    |           |
| 20   | .8573     | .823      |           |           |           | .8916     |           |
| 21   | .6859     | .6859     |           |           |           | .7202     |           |
| 22   | .583      | .5487     | .6173     |           |           | .6173     |           |
| 23   | .4801     | .5144     | .4801     |           |           | .5144     |           |
| 24   | .4458     | .4458     | .4458     | .4458     |           |           | .4801     |
| Max  | 1.0631    | .9259     | .9945     | .884      | .8535     | 1.0288    | .9602     |
| Min  | .4115     | .3772     | .4115     | .4268     | .3772     | .5144     | .4458     |
| Avg  | .6265     | .5860     | .5900     | .5915     | .5310     | .7349     | .5916     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014019 / 33/11 KV JAWALE KADLAG

Feeder No / Name : 203 / Ganore

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .0762     |           |           |
| 2    |           |           |           | .0762     |           |           |
| 3    |           |           |           | .0762     |           |           |
| 4    |           |           |           | .0762     |           |           |
| 5    |           |           |           | .0762     |           |           |
| 6    |           |           |           | .1143     |           |           |
| 7    |           | .0914     |           |           | .112      |           |
| 8    |           | .0914     |           | .1334     |           |           |
| 9    |           | .0762     |           | .0953     |           | .0953     |
| 10   |           | .0572     | .0762     |           |           | .0953     |
| 11   |           | 1.1488    | .0762     | .0572     |           | .0762     |
| 12   |           | 1.1871    |           | 1.1812    |           | 1.2193    |
| 13   |           | 1.2403    |           | 1.2193    |           | 1.0098    |
| 14   |           | 1.0808    |           | 1.086     |           | .9335     |
| 15   |           | 1.0631    |           | .9145     |           | .8192     |
| 16   |           |           |           | .9907     |           | .8764     |
| 17   |           |           | 1.0288    |           | .9134     |           |
| 18   | 1.086     |           | .9391     |           | .8507     |           |
| 19   |           |           | .7522     |           | .6468     |           |
| 20   |           |           | .1334     |           | .1524     |           |
| 21   |           |           | .1524     |           | .1334     |           |
| 22   |           |           | .1143     |           |           |           |
| 23   |           |           | .1143     |           |           |           |
| 24   |           |           | .0762     |           |           |           |
| Max  | 1.086     | 1.2403    | 1.0288    | 1.2193    | .9134     | 1.2193    |
| Min  | 1.086     | .0572     | .0762     | .0572     | .112      | .0762     |
| Avg  | 1.086     | .6707     | .3463     | .4409     | .4681     | .6406     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014019 / 33/11 KV JAWALE KADLAG

Feeder No / Name : 204 / JAWALE KADLAG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .2096     |           |           |
| 2    |           |           |           | .2096     |           |           |
| 3    |           |           |           | .2096     |           |           |
| 4    |           |           |           | .2096     |           |           |
| 5    |           |           |           | .2286     |           |           |
| 7    |           | .1734     |           |           | .3395     |           |
| 8    |           | .3395     |           | .4954     |           |           |
| 9    |           | .381      |           | .3429     |           | .362      |
| 10   |           | .2667     | .2858     |           |           | .362      |
| 11   |           | 1.4251    | .2477     | .3239     |           | .3048     |
| 12   |           | 1.4575    |           | 3.1245    |           | 3.1055    |
| 13   |           | 2.3167    |           | 3.2007    |           | 3.4103    |
| 14   |           | 2.3015    |           | 3.1626    |           |           |
| 15   |           | 2.3167    |           | 3.0102    |           | 3.296     |
| 16   |           |           |           | 3.1245    |           | 3.2769    |
| 17   |           |           | 2.4539    |           | 2.4539    |           |
| 18   | 2.9912    |           | 2.3624    |           | 2.3015    |           |
| 19   |           |           | 1.9109    |           | 2.0833    |           |
| 20   |           |           | .381      |           | .381      |           |
| 21   |           |           | .3048     |           | .3239     |           |
| 22   |           |           | .2667     |           |           |           |
| 23   |           |           | .2477     |           |           |           |
| 24   |           | .3858     | .2096     |           |           |           |
| Max  | 2.9912    | 2.3167    | 2.4539    | 3.2007    | 2.4539    | 3.4103    |
| Min  | 2.9912    | .1734     | .2096     | .2096     | .3239     | .3048     |
| Avg  | 2.9912    | 1.1364    | .8671     | 1.3732    | 1.3139    | 2.0168    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014019 / 33/11 KV JAWALE KADLAG

Feeder No / Name : 205 / JAWALE KADLAG GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .0953     |           |           |
| 2    |           |           |           | .0953     |           |           |
| 3    |           |           |           | .0953     |           |           |
| 4    |           |           |           | .0953     |           |           |
| 5    |           |           |           | .0953     |           |           |
| 6    |           |           |           | .1143     |           |           |
| 7    |           | .1734     |           |           | .1907     |           |
| 8    |           | .1214     |           | .1143     |           |           |
| 9    |           | .1905     |           | .1715     |           | .1905     |
| 10   |           | .1334     | .1143     |           |           | .1143     |
| 11   |           | .0762     |           | .1143     |           | .0953     |
| 12   |           | .0572     |           | .0953     |           | .0762     |
| 13   |           | .0572     |           | .0953     |           | .0572     |
| 14   |           | .0762     |           | .0953     |           | .0762     |
| 15   |           | .0762     |           | .0953     |           | .0572     |
| 16   |           |           |           | .0762     |           | .0953     |
| 17   |           |           | .0953     |           | .0762     |           |
| 18   | .1524     |           | .1334     |           | .1334     |           |
| 19   |           |           | .2096     |           | .2096     |           |
| 20   |           |           | .1905     |           | .1905     |           |
| 21   |           |           | .1715     |           | .1715     |           |
| 22   |           |           | .1524     |           |           |           |
| 23   |           |           | .0953     |           |           |           |
| 24   |           |           | .0953     |           |           |           |
| Max  | .1524     | .1905     | .2096     | .1715     | .2096     | .1905     |
| Min  | .1524     | .0572     | .0953     | .0762     | .0762     | .0572     |
| Avg  | .1524     | .1069     | .1397     | .1035     | .1620     | .0953     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014019 / 33/11 KV JAWALE KADLAG

Feeder No / Name : 207 / Chikani Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .7392     |           |           |
| 2    |           |           |           | .724      |           |           |
| 3    |           |           |           | .724      |           |           |
| 4    |           |           |           | .724      |           |           |
| 5    |           |           |           | .8573     |           |           |
| 6    |           |           |           | 1.2309    |           |           |
| 7    |           | 1.531     |           |           | 1.6872    |           |
| 8    |           | 2.5777    |           | 1.6478    |           |           |
| 9    |           | 2.0271    |           | 1.4861    |           | 2.3053    |
| 10   |           | .2667     | .3048     |           |           | .362      |
| 11   |           | .1905     |           | .3239     |           | .2667     |
| 12   |           | .1905     |           | .1715     |           | .1334     |
| 13   |           | .1715     |           | .1334     |           | .1334     |
| 14   |           | .1334     |           | .1334     |           | .2286     |
| 15   |           | .1334     |           | .1334     |           | .1524     |
| 16   |           |           |           | .1334     |           | .1524     |
| 17   |           |           | .1334     |           | .0953     |           |
| 18   | .2667     |           | .1715     |           | .1524     |           |
| 19   |           |           | .381      |           | .4191     |           |
| 20   |           |           | .381      |           | .381      |           |
| 21   |           |           | .3429     |           | .3239     |           |
| 22   |           |           | .3048     |           |           |           |
| 23   |           |           | .2667     |           |           |           |
| 24   |           |           | .7392     |           |           |           |
| Max  | .2667     | 2.5777    | .7392     | 1.6478    | 1.6872    | 2.3053    |
| Min  | .2667     | .1334     | .1334     | .1334     | .0953     | .1334     |
| Avg  | .2667     | .8024     | .3361     | .6545     | .5098     | .4668     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014096 / 33/11 KV NIMON SUB STATION

Feeder No / Name : 201 / 11 K V Pimpale  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .583      | .3944     |           |
| 2    | .5144     | .3944     |           |
| 3    | .5144     | .4287     |           |
| 4    | .5144     | .5144     |           |
| 5    | .5144     | .6344     |           |
| 6    | .8916     | .8402     |           |
| 7    | 1.0631    | 1.0631    |           |
| 8    | 1.1584    | 1.3413    | 1.1279    |
| 9    | .884      | 1.2193    |           |
| 16   | .2743     |           |           |
| 17   | .2743     |           |           |
| 18   | .3086     |           |           |
| 19   | .463      |           |           |
| 20   | .4458     |           |           |
| 21   | .4287     |           | .4904     |
| 22   | .3944     |           |           |
| 23   | .3772     |           |           |
| 24   | .4801     | .4115     |           |
| Max  | 1.1584    | 1.3413    | 1.1279    |
| Min  | .2743     | .3944     | .4904     |
| Avg  | .5602     | .7242     | .8092     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014096 / 33/11 KV NIMON SUB STATION

Feeder No / Name : 202 / 11 K V Karhe

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     | .2058     |           |
| 2    | .1715     | .2058     |           |
| 3    | .1715     | .2058     |           |
| 4    | .1543     | .2058     |           |
| 5    | .1543     | .2229     |           |
| 12   | 1.6766    | 1.6461    |           |
| 13   | 1.829     | 1.387     |           |
| 14   | 1.7985    | 1.2003    |           |
| 15   | 1.7147    | 1.1203    |           |
| 16   | 1.6461    |           |           |
| 17   | 1.3565    |           |           |
| 18   | 1.1431    |           |           |
| 19   | .9774     |           |           |
| 20   | .3429     |           |           |
| 21   | .3086     |           | .3206     |
| 22   | .2572     |           |           |
| 23   | .2229     |           |           |
| 24   | .2401     | .2058     |           |
| Max  | 1.829     | 1.6461    | .3206     |
| Min  | .1543     | .2058     | .3206     |
| Avg  | .7965     | .6606     | .3206     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014096 / 33/11 KV NIMON SUB STATION

Feeder No / Name : 204 / pimpale gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0857     | .0857     |           |
| 2    | .0857     | .0686     |           |
| 3    | .0857     | .0686     |           |
| 4    | .1029     |           |           |
| 5    | .1029     | .0686     |           |
| 6    | .1715     | .12       |           |
| 7    | .2058     | .1886     |           |
| 8    | .1886     | .1543     | .1886     |
| 9    | .2134     | .1372     |           |
| 10   | .2058     | .1543     |           |
| 11   | .1543     | .1715     |           |
| 12   | .2572     | .1715     |           |
| 13   | .1715     | .1715     |           |
| 14   | .1543     | .1715     |           |
| 15   | .1715     | .0857     |           |
| 16   | .1886     | .1543     |           |
| 17   | .1543     |           |           |
| 18   | .1715     |           |           |
| 19   | .1886     |           |           |
| 20   | .1715     |           |           |
| 21   | .1372     |           | .1372     |
| 22   | .1029     |           |           |
| 23   | .0857     |           |           |
| 24   | .0857     | .0857     |           |
| Max  | .2572     | .1886     | .1886     |
| Min  | .0857     | .0686     | .1372     |
| Avg  | .1518     | .1286     | .1629     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014096 / 33/11 KV NIMON SUB STATION

Feeder No / Name : 205 / palaskhede gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0686     | .0857     |           |
| 2    | .0686     | .0686     |           |
| 3    | .0686     | .0686     |           |
| 4    | .0686     |           |           |
| 5    | .0686     |           |           |
| 6    | .1372     |           |           |
| 7    | .1372     | .12       |           |
| 8    | .3506     | .12       | .1715     |
| 9    | .5335     | .2743     |           |
| 10   | .2286     | .3086     |           |
| 11   | .5487     | .2915     |           |
| 12   | .5487     | .2915     |           |
| 13   | .2572     | .3086     |           |
| 14   | .3086     | .2915     |           |
| 15   | .3258     | .2743     |           |
| 16   | .2572     |           |           |
| 17   | .1886     |           |           |
| 18   | .2572     |           |           |
| 19   | .1543     |           |           |
| 20   | .0154     |           |           |
| 21   | .1372     |           | .12       |
| 22   | .1372     |           |           |
| 23   | .0857     |           |           |
| 24   | .0686     | .0857     |           |
| Max  | .5487     | .3086     | .1715     |
| Min  | .0154     | .0686     | .12       |
| Avg  | .2092     | .1991     | .1458     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014105 / 33/11 KV PADMANAGAR

Feeder No / Name : 201 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 1    |           | .4024     |
| 2    |           | .4066     |
| 3    |           | .4668     |
| 4    |           | .5093     |
| 5    |           | .5601     |
| 6    |           | .6767     |
| 7    |           | .9511     |
| 8    |           | .9242     |
| 9    |           | .7207     |
| 10   |           | .7265     |
| 11   |           | .691      |
| 12   |           | .6697     |
| 24   | .439      | .4435     |
| Max  | .439      | .9511     |
| Min  | .439      | .4024     |
| Avg  | .439      | .6268     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014105 / 33/11 KV PADMANAGAR

Feeder No / Name : 202 / 11KV PRAVARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE       | 01-FEB-17     | 07-FEB-17     |
|------------|---------------|---------------|
| HR         | Load (MW)     | Load (MW)     |
| 1          |               | .591          |
| 2          |               | .543          |
| 3          |               | .5853         |
| 4          |               | .6468         |
| 5          |               | .7133         |
| 6          |               | .8954         |
| 7          |               | 1.3432        |
| 8          |               | 1.4998        |
| 9          |               | 1.4118        |
| 10         |               | 1.2517        |
| 11         |               | 1.046         |
| 12         |               | 1.1393        |
| 24         | 2.8468        | 1.2517        |
| <b>Max</b> | <b>2.8468</b> | <b>1.4998</b> |
| <b>Min</b> | <b>2.8468</b> | <b>.543</b>   |
| <b>Avg</b> | <b>2.8468</b> | <b>.9937</b>  |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014105 / 33/11 KV PADMANAGAR

Feeder No / Name : 401 / 33 KV TALEGAON & HIWARGAON NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
SS Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING

| DATE | 01-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 11   |           | 1.3272    |
| 12   |           | 10.8139   |
| 24   | 5.9271    | 5.6036    |
| Max  | 5.9271    | 10.8139   |
| Min  | 5.9271    | 1.3272    |
| Avg  | 5.9271    | 5.9149    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014145 / 33/11 KV MIDC GHULEWADI

Feeder No / Name : 201 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3772     | .3812     | .4607     | .4557     | .1907     | .4024     | .4607     |
| 2    | .4115     | .3944     | .4207     | .4557     | .2258     | .4024     | .3856     |
| 3    | .3353     | .3988     | .4287     | .4161     | .2347     | .3506     | .3506     |
| 4    | .3988     | .4075     | .3647     | .3269     | .2469     | .333      | .4298     |
| 5    | .394      | .4207     | .3772     | .3612     | .2683     | .333      | .6036     |
| 6    | .4287     | .5258     | .543      | .4163     | .4382     | .4294     | .5847     |
| 7    | .5041     | .543      | .6401     | .4557     | .4525     | .4481     | .6413     |
| 8    | .5792     | .7842     | .7602     | .2896     | .5601     | .7282     | .7167     |
| 9    | .7577     | .811      | .9149     | .2267     | .6979     | .8299     | .8299     |
| 10   | 1.0185    | 1.094     | .9808     | .2804     | 1.1317    | .9619     | 1.094     |
| 11   | .9808     | 1.0374    | 1.1506    | .2469     | .9808     | 1.0562    | 1.226     |
| 12   | .9242     | 1.1506    | 1.1694    | .2469     | 1.3392    | 1.2449    | 1.1317    |
| 13   | .8299     | 1.1506    | 1.0751    | .2315     | 1.1694    | .9997     | .9997     |
| 14   | .8589     | .9997     | 1.1317    | .1981     | 1.1317    | 1.0374    | 1.0374    |
| 15   | .9431     | .9997     | 1.1883    | .1981     | 1.1694    | 1.1506    | 1.1694    |
| 16   | .9431     | 1.0751    | .9619     |           | 1.1694    | 1.3014    | 1.2071    |
| 17   | 1.0374    | 1.094     | 1.2637    |           | 1.1883    | 1.3203    | .9808     |
| 18   | .8676     | 1.0185    | 1.1506    | .2481     | 1.1506    | 1.1317    | .9808     |
| 19   | .9054     | .9997     | 1.2826    | .2481     | 1.2071    | 1.2071    | .9431     |
| 20   | .679      | .7167     | .7922     | .2321     | .7922     | .811      | .811      |
| 21   | .6283     | .6413     | .5792     | .2187     | .415      | .5658     | .6653     |
| 22   | .4607     | .6224     | .5601     | .2105     | .415      | .4904     | .439      |
| 23   | .4607     | .5544     | .5121     | .2315     | .4108     | .5093     | .5093     |
| 24   | .4382     | .5138     | .439      | .5228     | .2258     | .4481     | .4481     |
| Max  | 1.0374    | 1.1506    | 1.2826    | .5228     | 1.3392    | 1.3203    | 1.226     |
| Min  | .3353     | .3812     | .3647     | .1981     | .1907     | .333      | .3506     |
| Avg  | .6734     | .7639     | .7978     | .3053     | .7171     | .7705     | .7769     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014145 / 33/11 KV MIDC GHULEWADI

Feeder No / Name : 202 / 11 KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6602     | .679      | .679      | .7545     | .7733     | .7167     | .7545     |
| 2    | .5914     | .6979     | .6413     | .7167     | .7167     | .7167     | .679      |
| 3    | .5601     | .6979     | .5544     | .7167     | .7167     | .6979     | .7167     |
| 4    | .679      | .6413     | .5068     | .5544     | .7167     | .7167     | .5975     |
| 5    | .5359     | .6036     | .6413     | .5975     | .7167     | .7167     | .7356     |
| 6    | .6468     | .8865     | .7733     | .6979     | .7167     | .7545     | .8865     |
| 7    | .9619     | .7545     | 1.0185    | .7655     | .7545     | .811      | .7733     |
| 8    | .811      | .7356     | .8865     | 1.1016    | .679      | .811      | .8299     |
| 9    | .9619     | .679      | .811      | .9522     | .8865     | .9997     | .9808     |
| 10   | 1.1694    | 1.0751    | 1.0751    | .9431     | .9054     | 1.094     | 1.1883    |
| 11   | 1.0374    | 1.0185    | 1.1694    | 1.0562    | .6979     | 1.0562    | 1.0751    |
| 12   | .679      | .8299     | .8676     | .9619     | 1.0185    | 1.094     | .9808     |
| 13   | .9431     | .7356     | .9242     | .8488     | .9431     | .8865     | .6602     |
| 14   | 1.0562    | .9054     | .9808     |           | .811      | .7356     | .8488     |
| 15   | 1.2071    | .9997     | .8676     | .6602     | 1.0751    | 1.0751    | .7922     |
| 16   | .9619     | .7545     | .8676     | .6224     | .8865     | 1.1763    | .9054     |
| 17   | .7922     | .8299     | .8488     | .7733     | .8676     | .9808     | .7733     |
| 18   | .7545     | .7733     | .7922     | .6602     | .5658     | .811      | .7356     |
| 19   | .8488     | .8676     | .8488     | .7922     | .7922     | .9242     | .7922     |
| 20   | .7545     | .7356     | .7356     | .7922     | .8299     | .8299     | .679      |
| 21   | .8299     | .679      | .7922     | .8299     | .811      | .811      | .7733     |
| 22   | .8488     | .6036     | .6602     | .8865     | .8488     | .8299     | .7733     |
| 23   | .811      | .7167     | .7356     | .6979     | .6224     | .6161     | .6224     |
| 24   | .6602     | .7922     | .811      | .7733     | .8865     | .7356     | .7922     |
| Max  | 1.2071    | 1.0751    | 1.1694    | 1.1016    | 1.0751    | 1.1763    | 1.1883    |
| Min  | .5359     | .6036     | .5068     | .5544     | .5658     | .6161     | .5975     |
| Avg  | .8234     | .7788     | .8120     | .7894     | .8016     | .8582     | .8061     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014145 / 33/11 KV MIDC GHULEWADI

Feeder No / Name : 203 / 11 KV MALDAD GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1254     | .1132     | .1387     | .1372     | .1629     | .1646     | .1433     |
| 2    | .1254     | .132      | .1214     | .1387     | .1463     | .1646     | .1463     |
| 3    | .124      | .132      | .128      | .1463     | .1463     | .1463     | .128      |
| 4    | .128      | .132      | .128      | .1509     | .1463     | .1463     | .1448     |
| 5    | .1463     | .1334     | .1494     | .1867     | .1629     | .1646     | .1886     |
| 6    | .2427     | .2075     | .2263     | .2587     | .2402     | .2195     | .2452     |
| 7    | .2926     | .3018     | .2987     | .3361     | .2957     | .2801     | .3174     |
| 8    | .3142     | .2896     | .3109     | .3077     | .2218     | .2743     | .2987     |
| 9    | .2743     | .2896     | .2353     | .2534     | .2926     | .2328     | .2987     |
| 10   | .2561     | .2896     | .2454     | .1949     | .2865     | .2686     | .2715     |
| 11   | .2561     | .2149     | .2507     | .197      | .2865     | .2126     | .2126     |
| 12   | .2507     | .2328     | .2715     | .2149     | .1928     | .2126     | .2241     |
| 13   | .2353     | .2126     | .1629     | .1791     | .1578     | .1753     | .208      |
| 14   | .2126     | .1612     | .2328     | .1791     | .1753     | .2254     | .1865     |
| 15   | .2481     | .2149     | .197      | .1433     | .1753     | .2427     | .1989     |
| 16   | .2149     | .2835     | .1402     | .1612     | .1928     | .2279     | .2103     |
| 17   | .2429     | .2401     | .2713     | .1402     | .2303     | .2401     | .2515     |
| 18   | .2486     | .2481     | .2713     | .2401     | .2715     | .2347     | .253      |
| 19   | .3012     | .2713     | .3224     | .3077     | .3045     | .3109     | .3224     |
| 20   | .2561     | .2507     | .2629     | .2715     | .2715     | .2896     | .2896     |
| 21   | .2218     | .2149     | .2328     | .2561     | .2195     | .2587     | .2926     |
| 22   | .2033     | .1949     | .2126     | .2218     | .2195     | .2402     | .2427     |
| 23   | .168      | .1663     | .1848     | .1991     | .1867     | .1867     | .1867     |
| 24   | .1463     | .132      | .1463     | .1629     | .1646     | .1646     | .1509     |
| Max  | .3142     | .3018     | .3224     | .3361     | .3045     | .3109     | .3224     |
| Min  | .124      | .1132     | .1214     | .1372     | .1463     | .1463     | .128      |
| Avg  | .2181     | .2108     | .2142     | .2077     | .2146     | .2202     | .2255     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 014145 / 33/11 KV MIDC GHULEWADI

Feeder No / Name : 422 / 33 KV NIMON OUTGOING NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9831     | 1.0174    | 1.0402    | 1.1317    | 1.1163    | 1.1568    | 1.0745    |
| 2    | 1.0288    | 1.1191    | 1.0402    | 1.1317    | 1.0517    | 1.1568    | 1.0402    |
| 3    | 1.1065    | 1.1065    | 1.0288    | 1.0402    | 1.0517    | 1.0517    | 1.1443    |
| 4    | 1.0082    | 1.1191    | .823      | .8322     | 1.1317    | 1.0402    | 1.1317    |
| 5    | 1.1797    | 1.4243    | .9054     | 1.2346    | 1.4243    | 1.3523    | 1.2483    |
| 6    | 1.4752    | 1.5604    | 1.4563    | 1.5261    | 1.7295    | 1.6278    | 1.5775    |
| 7    | 2.2085    | 2.4691    | 2.6452    | 2.6155    | 2.5149    | 2.6852    | 2.6155    |
| 8    | 3.2442    | 3.4408    | 3.4808    | 3.5803    | 4.0306    | 3.5803    | 3.4408    |
| 9    | 2.9492    | 3.0121    | 2.9835    | 3.0178    | 3.5391    | 2.9058    | 3.1824    |
| 10   | .8962     | .4481     | .4481     |           | .5658     |           | .6516     |
| 11   | .679      | .4527     |           |           | .5658     |           | .5658     |
| 12   | 2.3137    | 2.0119    |           | 1.166     | 2.0348    | 1.1065    | 1.5089    |
| 13   | 2.3137    | 1.8107    |           | 1.4403    | 1.6598    | 1.278     | 1.5912    |
| 14   | 2.0885    | 1.5546    | .9259     | 1.3443    | 1.3077    | 1.166     | 1.5912    |
| 15   | 1.9113    | 1.6518    | 1.9839    | 1.4998    | 2.4143    | 1.1191    | 1.4918    |
| 16   | 2.1125    | 1.749     | 2.1125    | 1.5935    | 1.7604    | 1.4403    | 1.7101    |
| 17   | 2.1628    | 1.6712    | 2.34      | 1.7284    | 1.7101    | 1.4752    | 1.7101    |
| 18   | 1.9662    | 1.6278    | 2.0119    | 1.5364    | 1.5261    | 1.2717    | 1.7901    |
| 19   | 1.8267    | 1.6644    | 1.6644    | 1.5775    | 1.4243    | 1.4118    | 1.5775    |
| 20   | 1.0185    | 1.1431    | 1.0288    | 1.0185    | .9145     | .9054     | 1.0288    |
| 21   | .9054     | 1.0185    | .9054     | .9054     | .8573     | .8402     | .8488     |
| 22   | .7922     | .6722     | .7922     | .7922     | .6859     | .7282     | .7842     |
| 23   | .6584     | .5601     | .6722     | .679      | .5601     | .6722     | .679      |
| 24   | .9831     | 1.0288    | 1.0174    | 1.0682    | 1.1163    | 1.0802    | 1.0317    |
| Max  | 3.2442    | 3.4408    | 3.4808    | 3.5803    | 4.0306    | 3.5803    | 3.4408    |
| Min  | .6584     | .4481     | .4481     | .679      | .5601     | .6722     | .5658     |
| Avg  | 1.5755    | 1.4722    | 1.4908    | 1.4754    | 1.5289    | 1.4114    | 1.459     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 201 / 11 KV SAYKHINDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1338    |
| Max  | 2.1338    |
| Min  | 2.1338    |
| Avg  | 2.1338    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 202 / 11 KV CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2862    |
| Max  | 2.2862    |
| Min  | 2.2862    |
| Avg  | 2.2862    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGAMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 204 / 11 KV WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2193    |           | 1.2193    |           | 1.5242    |
| 2    | 1.2193    |           | 1.2193    |           | 1.5242    |
| 3    | 1.2193    |           | 1.2193    |           | 1.2193    |
| 4    | 1.2193    |           | 1.2193    |           | 1.2193    |
| 5    | 1.2193    |           | 1.2193    |           | 1.5242    |
| 6    | 1.5242    |           | 1.5242    |           | 1.829     |
| 7    | 2.1338    |           | 2.1338    |           | 2.1338    |
| 8    | 2.7435    |           | 2.7435    |           | 2.7435    |
| 9    | 2.7435    |           | 2.7435    |           | 2.7435    |
| 10   | 2.4387    |           | 2.4387    |           | 2.4387    |
| 11   | 2.1338    |           | 2.1338    |           | 2.4387    |
| 12   | 2.1338    |           | 2.1338    |           |           |
| 13   | 2.1338    |           | 2.1338    |           |           |
| 14   | 1.829     |           | 1.5242    |           | 2.1338    |
| 15   | 1.829     |           | 1.829     |           | 2.1338    |
| 16   | 1.829     |           | 1.829     | 2.1338    |           |
| 17   | 1.829     |           | 1.829     | 2.1338    |           |
| 18   | 2.1338    |           | 2.1338    | 2.1338    |           |
| 19   | 2.4387    |           |           | 2.7435    |           |
| 20   | 2.4387    | 1.5242    |           | 2.7435    |           |
| 21   | 2.4387    | 2.4387    |           | 2.7435    |           |
| 22   | 2.1338    | 2.1338    |           | 2.4387    |           |
| 23   |           | 2.1338    |           | 2.1338    |           |
| 24   | 2.2862    | 1.5242    |           | 1.829     |           |
| Max  | 2.7435    | 2.4387    | 2.7435    | 2.7435    | 2.7435    |
| Min  | 1.2193    | 1.5242    | 1.2193    | 1.829     | 1.2193    |
| Avg  | 1.9682    | 1.9509    | 1.8459    | 2.3370    | 1.9697    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 205 / MIRZAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0953     | .0876     |           | .0838     |           | .0724     |           |
| 2    | .0991     | .0876     |           | .0838     |           | .0762     | .0076     |
| 3    | .0991     | .0914     |           | .0876     | .0076     | .08       | .0762     |
| 4    | .1029     | .0914     |           | .0838     | .0724     | .08       | .08       |
| 5    | .1029     | .0914     |           | .0838     | .0762     | .08       | .0762     |
| 6    | .0953     | .0914     |           | .0876     | .061      | .0762     | .0419     |
| 7    | .1067     |           |           | .0876     |           |           | .08       |
| 8    | .0991     |           |           |           |           |           |           |
| 12   | .9488     | 1.2689    |           | 1.3184    | 1.0898    |           | 1.2879    |
| 13   | 1.4289    | 1.5242    |           | 1.7909    | 1.8138    |           | 1.688     |
| 14   | 1.547     | 1.5013    |           | 1.8442    | 1.768     | 1.6309    | 1.7947    |
| 15   | 1.6994    | 1.6347    |           | 1.7985    | 1.6728    | 1.6766    | 1.6575    |
| 16   | 1.6461    | 1.7071    |           | 1.8366    | 1.7185    | 1.768     | 1.6499    |
| 17   | 1.5966    | 1.7185    |           | 1.7795    | 1.6994    | 1.7909    | 1.7071    |
| 18   | 1.627     | 1.7071    |           | 1.8138    | 1.7109    | 1.7909    | 1.7299    |
| 19   | 1.627     |           | .202      | 1.768     |           | 1.7833    | 1.6766    |
| 20   | 1.6537    |           | 1.6766    | 1.7642    |           | 1.7337    | 1.6651    |
| 21   | .1029     |           | .1219     | .0914     | .1029     | .1067     | .0914     |
| 22   | .0991     |           | .1257     | .0838     | .1067     | .1029     | .0953     |
| 23   | .1029     |           | .1219     | .0838     | .1029     | .1029     | .0914     |
| 24   | 2.0767    |           | .1029     | .08       | .0953     | .0953     | 1.0288    |
| Max  | 2.0767    | 1.7185    | 1.6766    | 1.8442    | 1.8138    | 1.7909    | 1.7947    |
| Min  | .0953     | .0876     | .1029     | .08       | .0076     | .0724     | .0076     |
| Avg  | .8075     | .8925     | .3918     | .8326     | .8065     | .7675     | .8698     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 208 / 11 KV KURAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1338    |
| Max  | 2.1338    |
| Min  | 2.1338    |
| Avg  | 2.1338    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 209 / nagarpalika waterworks  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .9145     |
| Max  | .9145     |
| Min  | .9145     |
| Avg  | .9145     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER (U) S/DIV.[207] BU 0787

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 403 / 33 KV PARIS ISPAT  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.0576    |
| Max  | 2.0576    |
| Min  | 2.0576    |
| Avg  | 2.0576    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014020 / 33/11 KV GHARGAON

Feeder No / Name : 201 / GHARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1338    |
| Max  | 2.1338    |
| Min  | 2.1338    |
| Avg  | 2.1338    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014020 / 33/11 KV GHARGAON

Feeder No / Name : 202 / AKALAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2862    |
| Max  | 2.2862    |
| Min  | 2.2862    |
| Avg  | 2.2862    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014020 / 33/11 KV GHARGAON

Feeder No / Name : 203 / BELAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2862    |
| Max  | 2.2862    |
| Min  | 2.2862    |
| Avg  | 2.2862    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014020 / 33/11 KV GHARGAON

Feeder No / Name : 208 / Bota GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.7435    |
| Max  | 2.7435    |
| Min  | 2.7435    |
| Avg  | 2.7435    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 201 / SAKUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           |           | .1772     |
| 4    |           |           |           | .1772     |
| 6    |           |           |           | .1772     |
| 8    |           |           |           | .1772     |
| 9    |           | .1772     |           |           |
| 11   |           | .1772     |           |           |
| 13   |           | 3.7723    |           |           |
| 15   |           | 3.7723    |           |           |
| 16   |           | 3.7723    |           |           |
| 17   |           |           | 3.7723    |           |
| 19   |           |           | 3.7723    |           |
| 21   |           |           | .1772     |           |
| 23   |           |           | .1772     |           |
| 24   | 1.829     |           |           | .1772     |
| Max  | 1.829     | 3.7723    | 3.7723    | .1772     |
| Min  | 1.829     | .1772     | .1772     | .1772     |
| Avg  | 1.829     | 2.3343    | 1.9748    | .1772     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 202 / MANDAVE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           |           | .2658     |
| 4    |           |           |           | 1.8861    |
| 6    |           |           |           | 2.572     |
| 8    |           |           |           | 2.915     |
| 9    |           | 3.0864    |           |           |
| 11   |           | 3.0864    |           |           |
| 19   |           |           | .2658     |           |
| 21   |           |           | .2658     |           |
| 23   |           |           | .2658     |           |
| 24   | 1.829     |           |           | .2658     |
| Max  | 1.829     | 3.0864    | .2658     | 2.915     |
| Min  | 1.829     | 3.0864    | .2658     | .2658     |
| Avg  | 1.829     | 3.0864    | .2658     | 1.5809    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 203 / RANKHAMB AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 4    |           |           | .8573     |
| 6    |           |           | .1772     |
| 8    |           |           | .1772     |
| 9    | .1772     |           |           |
| 11   | .3189     |           |           |
| 19   |           | .1772     |           |
| 21   |           | 1.2003    |           |
| 23   |           | .8573     |           |
| 24   |           |           | .8573     |
| Max  | .3189     | 1.2003    | .8573     |
| Min  | .1772     | .1772     | .1772     |
| Avg  | .2481     | .7449     | .5173     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 204 / JAMBUT AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | .1772     |
| 4    |           |           | .1772     |
| 6    |           |           | .1772     |
| 8    |           |           | .1772     |
| 9    | .1772     |           |           |
| 11   | .1772     |           |           |
| 13   | 3.0864    |           |           |
| 15   | 3.7723    |           |           |
| 16   | 3.7723    |           |           |
| 17   |           | 3.7209    |           |
| 19   |           | 3.6008    |           |
| 21   |           | .1772     |           |
| 24   |           |           | .1772     |
| Max  | 3.7723    | 3.7209    | .1772     |
| Min  | .1772     | .1772     | .1772     |
| Avg  | 2.1971    | 2.4996    | .1772     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 205 / KAUTHE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | .1772     |
| 4    |           |           | 1.3717    |
| 6    |           |           | 1.7147    |
| 8    |           |           | 2.4006    |
| 9    | 2.572     |           |           |
| 11   | 2.572     |           |           |
| 19   |           | .1772     |           |
| 21   |           | .1772     |           |
| 23   |           | .1772     |           |
| 24   |           |           | .1772     |
| Max  | 2.572     | .1772     | 2.4006    |
| Min  | 2.572     | .1772     | .1772     |
| Avg  | 2.572     | .1772     | 1.1683    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 206 / 11 KV SAKUR G.F.S.S

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE       | 03-FEB-17    | 04-FEB-17    | 05-FEB-17    |
|------------|--------------|--------------|--------------|
| HR         | Load (MW)    | Load (MW)    | Load (MW)    |
| 2          |              |              | .1715        |
| 4          |              |              | .1772        |
| 6          |              |              | .3544        |
| 8          |              |              | .443         |
| 9          | .3506        |              |              |
| 11         | .3544        |              |              |
| 13         | .1772        |              |              |
| 15         | .1772        |              |              |
| 16         | .1772        |              |              |
| 17         |              | .3544        |              |
| 19         |              | .443         |              |
| 21         |              | .443         |              |
| 23         |              | .3544        |              |
| 24         |              |              | .3544        |
| <b>Max</b> | <b>.3544</b> | <b>.443</b>  | <b>.443</b>  |
| <b>Min</b> | <b>.1772</b> | <b>.3544</b> | <b>.1715</b> |
| <b>Avg</b> | <b>.2473</b> | <b>.3987</b> | <b>.3001</b> |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 208 / Jambut GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | .0354     |
| 4    |           |           | .0354     |
| 6    |           |           | .0709     |
| 8    |           |           | .0709     |
| 9    | .0086     |           |           |
| 11   | .0886     |           |           |
| 13   | .0354     |           |           |
| 15   | .0354     |           |           |
| 16   | .0354     |           |           |
| 17   |           | .0886     |           |
| 19   |           | .0886     |           |
| 21   |           | .0886     |           |
| 23   |           | .0532     |           |
| 24   |           |           | .0532     |
| Max  | .0886     | .0886     | .0709     |
| Min  | .0086     | .0532     | .0354     |
| Avg  | .0407     | .0798     | .0532     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 209 / Rankham GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | .1772     |
| 4    |           |           | .1772     |
| 6    |           |           | .1772     |
| 8    |           |           | .1772     |
| 9    | .1772     |           |           |
| 11   | .1772     |           |           |
| 13   | .1772     |           |           |
| 15   | .1772     |           |           |
| 16   | .1772     |           |           |
| 17   |           | .1772     |           |
| 19   |           | .1772     |           |
| 21   |           | .1772     |           |
| 23   |           | .1772     |           |
| 24   |           |           | .1772     |
| Max  | .1772     | .1772     | .1772     |
| Min  | .1772     | .1772     | .1772     |
| Avg  | .1772     | .1772     | .1772     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014021 / 33/11 KV SAKUR

Feeder No / Name : 210 / Jambut AG 2  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | 2.915     |
| 4    |           |           | .1772     |
| 6    |           |           | .1772     |
| 8    |           |           | .1772     |
| 9    | .1772     |           |           |
| 11   | .1772     |           |           |
| 17   |           | .1772     |           |
| 19   |           | .1715     |           |
| 21   |           | 3.4294    |           |
| 23   |           | 2.915     |           |
| 24   |           |           | 2.915     |
| Max  | .1772     | 3.4294    | 2.915     |
| Min  | .1772     | .1715     | .1772     |
| Avg  | .1772     | 1.6733    | 1.2723    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 201 / SANGHVI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7621     |
| Max  | .7621     |
| Min  | .7621     |
| Avg  | .7621     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 202 / PEMGIRI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5242    |
| Max  | 1.5242    |
| Min  | 1.5242    |
| Avg  | 1.5242    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 203 / NIMAJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .2286     | .1619     | .1905     |           | .1475     | .2286     |
| 2    |           | .2477     | .1475     | .1715     |           | .1457     | .2477     |
| 3    |           | .3239     | .1638     | .2096     |           | .1619     | .2477     |
| 4    |           | .4001     | .1943     | .2286     |           | .1966     | .3048     |
| 5    |           | .362      | .3277     | .2667     |           | .2429     | .3239     |
| 6    |           | .3429     | .4049     | .3048     |           | .3239     | .362      |
| 7    |           | .362      | .4534     | .3429     |           | .4096     | .4191     |
| 8    |           | .4382     | .4372     | .4001     |           | .3725     | .4382     |
| 9    |           | .381      | .2591     | .3429     |           |           | .3048     |
| 10   | .2286     | .2286     | .1905     |           | .2858     | .1905     | .2477     |
| 11   | .1334     | .1334     | .1334     |           | .1524     | .1334     | .1905     |
| 12   | .1143     | .1334     | .1334     |           | .1334     | .1334     | .1524     |
| 13   | .1334     | .1143     | .1334     |           | .1143     | .1143     |           |
| 14   | .1143     | .1334     | .1334     |           | .0953     | .1334     |           |
| 15   | .1334     | .1143     | .2477     |           | .1334     | .1334     |           |
| 16   | .1334     | .1334     | .2096     |           | .1334     | .1334     |           |
| 17   | 3.0864    | 1.7328    | 3.0864    |           | 3.5437    | 4.0009    | 3.3916    |
| 18   | 3.0483    | 2.8018    | 3.0102    |           | 2.8826    | 3.9057    | 3.2388    |
| 19   | 3.0102    | 2.672     | 2.7244    |           | 2.7854    | 3.8295    | 3.0803    |
| 20   | 2.7054    | 2.6216    | 2.6101    |           | 2.6871    | 3.7532    | 2.753     |
| 21   | 2.6292    | 1.9433    | 2.4958    |           |           | 2.6482    | 2.4291    |
| 22   | 2.2672    | 1.4746    | 2.4387    |           | 2.2672    | 2.5339    | 2.2045    |
| 23   | 1.7528    | 1.3927    | 2.1148    |           | 2.0317    | 2.4387    | 1.9662    |
| 24   | .7621     | 1.4575    | .1619     | 1.7718    | 1.8842    |           | 1.7204    |
| Max  | 3.0864    | 2.8018    | 3.0864    | 1.7718    | 3.5437    | 4.0009    | 3.3916    |
| Min  | .1143     | .1143     | .1334     | .1715     | .0953     | .1143     | .1524     |
| Avg  | 1.3502    | .8406     | .9322     | .4229     | 1.3664    | 1.1856    | 1.2126    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 204 / NIMGAONPAGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2862    |
| Max  | 2.2862    |
| Min  | 2.2862    |
| Avg  | 2.2862    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 205 / 11 KV SANGHVI G.F.S.S

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .1524     | .1086     | .1524     |           | .1086     | .1143     |
| 2    |           | .1905     | .1267     | .1905     |           | .128      | .1334     |
| 3    |           | .2286     | .128      | .2286     |           | .1448     | .1715     |
| 4    |           | .2286     | .1629     | .2286     |           | .181      | .1905     |
| 5    |           | .2477     | .2172     |           |           | .2172     | .2667     |
| 6    |           | .3048     | .2926     | .3048     |           | .2896     | .3048     |
| 7    |           | .3429     | .3077     | .2477     |           | .3258     | .3429     |
| 8    |           | .2477     | .3258     | .3429     |           | .3801     | .2667     |
| 9    |           | .2096     | .2534     | .3048     |           |           | .2477     |
| 10   | .2096     | .3048     | .2286     |           | .3239     | .1905     | .1715     |
| 11   | .1905     | .2096     | .1905     |           | .1524     | .1905     | .1905     |
| 12   | .1905     | .1334     | .1143     |           | .1143     | .1143     | .1524     |
| 13   | .1334     | .0953     | .1143     |           | .1334     | .1334     |           |
| 14   | .1143     | .1334     | .1334     |           | .1143     | .1334     |           |
| 15   | .1334     | .1143     | .1334     |           | .2096     | .1143     |           |
| 16   | .1334     | .0953     | .1524     |           | .1905     | .1334     |           |
| 17   | .1334     | .1086     | .1334     |           | .1524     | .1334     |           |
| 18   | .1524     | .2534     | .1905     |           | .2172     | .2096     | .2896     |
| 19   | .1715     | .2715     | .1715     |           | .823      | .2477     | .3439     |
| 20   | .2477     | .2172     | .1524     |           | .2896     | .3239     | .2772     |
| 21   | .2286     | .181      | .1715     |           | .2534     | .4001     | .2195     |
| 22   | .2286     | .1646     | .1524     |           | .181      | .381      | .1629     |
| 23   | .2096     | .1109     | .1334     |           | .1267     | .3239     | .1448     |
| 24   |           | .1097     |           | .1334     | .1086     |           | .1086     |
| Max  | .2477     | .3429     | .3258     | .3429     | .823      | .4001     | .3439     |
| Min  | .1143     | .0953     | .1086     | .1334     | .1086     | .1086     | .1086     |
| Avg  | .1769     | .1940     | .1780     | .2371     | .2260     | .2184     | .2158     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 206 / 11KV NIMAJ GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2926     | .6173     | .5914     | .6203     | .3399     | .6182     | .6535     |
| 2    | .2881     | .6352     | .6026     | .6565     | .338      | .639      | .6809     |
| 3    | .3102     | .7437     | .6138     | .7339     | .3746     | .6866     | .7651     |
| 4    | .3673     | .8585     | .6676     | .8326     | .439      | .816      | .8566     |
| 5    | .4988     | 1.1241    | .9008     | 1.0951    | .5761     | 1.0315    | 1.0711    |
| 6    | .6847     | 1.3828    | 1.2845    | 1.2415    | .7343     | 1.3851    | 1.4228    |
| 7    | .7324     | 1.5699    | 1.4482    |           | .8897     | 1.5821    | 1.5809    |
| 8    | .7472     | 1.6522    | 1.6292    | .8139     | .8993     | 1.476     | 1.7749    |
| 9    | .684      | 1.2959    | 1.4952    | 1.5158    | .8669     | .7053     | 1.531     |
| 10   | 1.2829    | 1.2296    | 1.3043    |           | 1.7188    | 1.3847    | 1.3481    |
| 11   | 1.158     | 1.265     | 1.1523    |           | 1.259     | 1.1088    | 1.1195    |
| 12   | .8859     | .9777     | 1.0753    |           | .9247     | 1.0246    | 1.0593    |
| 13   | .6066     | .7175     | .8829     |           | .8151     | .7274     | .4698     |
| 14   | .6203     | .5929     | .8559     |           | .748      | .6447     | .4169     |
| 15   | .6497     | .6253     | .8189     |           | .9381     | .7202     | .2972     |
| 16   | .831      | .783      | .8573     |           | .8493     | .8337     | .3666     |
| 17   | .7914     | .7737     | .7872     |           | .8097     | .82       | .7064     |
| 18   | .9651     | .8932     | .833      | .5956     | .9187     | 1.5074    | .7971     |
| 19   | 1.0772    | 1.174     | .9689     | .7701     | 1.1298    | 1.1       | 1.0576    |
| 20   | 1.0761    | 1.1285    | 1.0357    | .764      | 1.1325    | 1.0239    | 1.0818    |
| 21   | 1.0799    | 1.0219    | .9785     | .7122     | 1.0793    | 1.0524    | .9595     |
| 22   | .847      | .7884     | .8504     | .5697     | .8273     | .8314     | .8067     |
| 23   | .7384     | .6455     | .7484     | .4165     | .595      | .6999     | .6847     |
| 24   | .3185     | .5971     | .3083     | .6557     | .6209     | .3067     | .6133     |
| Max  | 1.2829    | 1.6522    | 1.6292    | 1.5158    | 1.7188    | 1.5821    | 1.7749    |
| Min  | .2881     | .5929     | .3083     | .4165     | .338      | .3067     | .2972     |
| Avg  | .7306     | .9622     | .9454     | .7996     | .826      | .9469     | .9217     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014022 / 33/11 KV DHANDERFAL

Feeder No / Name : 207 / RAMESHWAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2862    |
| Max  | 2.2862    |
| Min  | 2.2862    |
| Avg  | 2.2862    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 201 / SHIBALAPUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.829     |
| Max  | 1.829     |
| Min  | 1.829     |
| Avg  | 1.829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 204 / UMBARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.175     | 2.2786    | 2.2359    | 2.3762    | 2.3411    | 2.1628    | 2.1765    |
| 2    | 2.1704    | 2.2817    | 2.2466    | 2.332     | 2.2878    | 2.1353    | 2.178     |
| 3    | 2.1856    | 2.2725    | 2.1887    | 2.3365    | 2.2923    | 2.1689    | 2.1597    |
| 4    | 2.2268    | 2.2984    | 2.2146    | 2.399     | 2.2756    | 2.2085    | 2.1689    |
| 5    | 2.3746    | 2.3289    | 2.3198    | 2.4569    | 2.2893    | 2.3289    | 2.21      |
| 6    | 2.5682    | 2.5697    | 2.6368    | 2.7938    | 2.6063    | 2.6155    | 2.5789    |
| 7    | 3.0681    | 3.12      | 3.3425    | 3.4141    | 3.3821    | 3.1291    | 3.1977    |
| 8    | 3.2724    | 3.3196    | 3.6443    | 3.8089    | 3.7083    | 3.4827    | 3.501     |
| 9    | 1.0913    | 2.146     | 1.2224    | 1.2102    | 1.2056    | 1.169     | 1.2925    |
| 17   |           |           |           |           |           |           | .0046     |
| 18   | .1692     | .0777     | .1082     | .0244     | .1097     | .0869     | .1707     |
| 19   | .2545     | .3048     | .2408     | .2119     | .2286     | .2195     | .2683     |
| 20   | .2545     | .2195     | .2347     | .2134     | .2271     | .2225     | .2713     |
| 21   | .2256     | .2149     | .2042     | .2012     | .2042     | .221      | .2591     |
| 22   | .218      | .1936     | .1799     | .1875     | .1844     | .1997     | .2301     |
| 23   | 2.2283    | 2.1064    | 2.2801    | 2.2893    | 2.0774    | 1.9829    | .1951     |
| 24   | 3.0255    | 2.146     | 2.3929    | 2.2908    | 2.1338    | 2.1125    | .1875     |
| Max  | 3.2724    | 3.3196    | 3.6443    | 3.8089    | 3.7083    | 3.4827    | 3.501     |
| Min  | .1692     | .0777     | .1082     | .0244     | .1097     | .0869     | .0046     |
| Avg  | 1.7193    | 1.7424    | 1.7308    | 1.7841    | 1.7221    | 1.6529    | 1.3559    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 205 / KANOLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2027     | .2012     | .2164     | .2119     | .2042     | .2073     | .2012     |
| 2    | .2058     | .2027     | .2119     | .2149     | .2103     | .2073     | .2058     |
| 3    | .2088     | .2103     | .2119     | .218      | .2164     | .2103     | .2088     |
| 4    | .221      | .032      |           | .0594     | .2149     |           | .0107     |
| 5    | .2286     |           |           |           | .2119     |           |           |
| 6    | .2362     |           |           |           | .0899     |           |           |
| 7    | .2378     |           |           |           |           |           |           |
| 8    |           |           |           | .0015     |           |           |           |
| 11   | .2759     |           | .5243     | .4054     | .6005     | .3003     |           |
| 12   | 2.5987    | 2.6703    | 2.9721    | 2.9249    | 2.8517    | 2.4417    | 2.9203    |
| 13   | 2.9874    | 2.9965    | 3.1276    | 3.0361    | 2.9279    | 2.7221    | 2.899     |
| 14   | 2.8685    | 2.8822    | 2.995     | 2.9919    | 2.8837    | 2.8441    | 2.8487    |
| 15   | 2.9447    | 2.8166    | 3.0453    | 3.0239    | 2.8837    | 2.9782    | 3.0864    |
| 16   | 2.8791    | 2.8532    | 2.9706    | 3.0133    | 2.6947    | 2.9874    | 3.0879    |
| 17   | 2.7161    | 2.8456    | 2.8395    | 2.8532    | 2.8243    | .3338     | 3.0011    |
| 18   | 2.5545    | 2.5895    | 2.7679    | 2.7282    | 2.6978    | 2.6444    | 2.8456    |
| 19   | 2.5652    | 2.5606    | 2.5697    | 2.5591    | 2.5682    | 2.7481    | 2.5072    |
| 20   | .3704     | .3307     | .2987     | .285      | .3292     | .2926     | .2225     |
| 21   | .2804     | .3307     | .3003     | .2774     | .3216     | .2881     | .3094     |
| 22   | .2804     | .3003     | .2774     | .2622     | .2926     | .2881     | .2835     |
| 23   | .253      | .2652     | .2576     | .2545     | .2484     | .2652     | .3033     |
| 24   | .2027     | .2195     | .3928     | .3592     | .3688     | .2317     | 3.192     |
| Max  | 2.9874    | 2.9965    | 3.1276    | 3.0361    | 2.9279    | 2.9874    | 3.192     |
| Min  | .2027     | .032      | .2119     | .0015     | .0899     | .2073     | .0107     |
| Avg  | 1.2056    | 1.4298    | 1.5282    | 1.3516    | 1.2820    | 1.2936    | 1.6549    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 206 / NIMGAONJALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1349     | .141      | .1318     | .1478     | .1204     | .1456     | .1448     |
| 2    | .1341     | .1463     | .1326     | .1532     | .1296     | .1425     | .141      |
| 3    | .1425     | .1494     | .1257     | .1524     | .1303     | .1456     | .1486     |
| 4    | .1539     | .0396     |           | .0602     | .1349     |           | .0251     |
| 5    | .1593     |           |           |           | .1318     |           |           |
| 6    | .1859     |           |           |           | .0747     |           |           |
| 7    | .1966     |           |           |           |           |           |           |
| 11   | .0107     |           | .1105     | .0587     | .1646     | .0023     |           |
| 12   | 1.8541    | 2.3327    | 1.9906    | 2.034     | 1.7795    | 1.9502    | 2.005     |
| 13   | 2.3685    | 2.6376    | 2.2931    | 2.1719    | 1.8732    | 1.9143    | 2.3091    |
| 14   | 2.5453    | 2.6688    | 1.8404    | 2.1933    | 1.6202    | 1.9265    | 2.4211    |
| 15   | 2.5492    | 2.5728    | .2423     | 2.1171    | 1.8755    | 2.0088    | 2.3929    |
| 16   | 2.2131    | 2.5149    | 2.0515    | 2.1239    | 2.1742    | 1.5066    | 2.069     |
| 17   | .2347     | 2.3785    | 2.0348    | 2.0386    | 2.2001    | 1.7147    | 2.303     |
| 18   | 2.1285    | 1.8419    | 1.973     | 1.9707    | 2.0927    | 1.861     | 2.3518    |
| 19   | 2.1849    | 1.5424    | 1.8976    | 1.8099    | 1.9319    | 1.7093    | 2.0386    |
| 20   | .3285     | .1974     | .2294     | .1959     | .208      | .1936     | .2042     |
| 21   | .1989     | .1898     | .2119     | .1981     | .2012     | .1981     | .2012     |
| 22   | .1799     | .1806     | .1913     | .1799     | .1913     | .189      | .1814     |
| 23   | .1684     | .1707     | .176      | .1616     | .1745     | .1821     | .1875     |
| 24   | .1448     | .1379     | 1.9079    | 1.9199    | 1.6807    | .1585     | 2.501     |
| Max  | 2.5492    | 2.6688    | 2.2931    | 2.1933    | 2.2001    | 2.0088    | 2.501     |
| Min  | .0107     | .0396     | .1105     | .0587     | .0747     | .0023     | .0251     |
| Avg  | .8675     | 1.1672    | 1.0318    | 1.0937    | .9445     | .9382     | 1.2721    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 207 / PIMPRI LAUKI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | 1.8415    | 1.6606    | 1.708     | 1.7695    |
| Max  | 1.8415    | 1.6606    | 1.708     | 1.7695    |
| Min  | 1.8415    | 1.6606    | 1.708     | 1.7695    |
| Avg  | 1.8415    | 1.6606    | 1.708     | 1.7695    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 208 / CHANEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1338    |
| Max  | 2.1338    |
| Min  | 2.1338    |
| Avg  | 2.1338    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 209 / 11 KV NIMGAONJALI G.F. S.S

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3151     | .3185     | .3544     | .3608     | .3597     | .3216     | .346      |
| 2    | .3094     | .3102     | .3487     | .3502     | .3536     | .3185     | .338      |
| 3    | .322      | .3125     | .3509     | .349      | .3559     | .3185     | .3368     |
| 4    | .3334     | .3292     | .3692     | .3509     | .3582     | .3334     | .3403     |
| 5    | .386      | .3601     | .4039     | .3978     | .3803     | .3681     | .3803     |
| 6    | .5205     | .4904     | .5388     | .5312     | .5117     | .4908     | .5003     |
| 7    | .6836     | .6603     | .7255     | .7183     | .6923     | .6668     | .7293     |
| 8    | .6508     | .6443     | .7621     | .7484     | .7674     | .7411     | .7651     |
| 9    | .578      | .5948     | .703      | .6668     | .7343     | .692      | .6973     |
| 10   | .5342     | .5738     | .5963     | .5845     | .6249     | .5822     | .6219     |
| 11   | .3887     | .4043     | .4633     | .4767     | .5049     | .4717     | .5152     |
| 12   | .3166     | .3749     | .3662     | .4557     | .4412     | .4165     | .4431     |
| 13   | .2347     | .3391     | .354      | .4298     | .3879     | .2995     | .2191     |
| 14   | .3166     | .2797     | .3285     | .397      | .3925     | .3304     | .3346     |
| 15   | .274      | .2446     | .3296     | .3334     | .357      | .3658     | .4157     |
| 16   | .3216     | .2637     | .3456     | .3285     | .3445     | .3433     | .3826     |
| 17   | .3307     | .3868     | .3368     | .3738     | .3746     | .4047     | .3467     |
| 18   | .4153     | .4443     | .4363     | .4572     | .4424     | .3982     | .4576     |
| 19   | .5872     | .6699     | .6596     | .6348     | .6295     | .6615     | .5963     |
| 20   | .7213     | .7228     | .6592     | .7156     | .6885     | .7316     | .7099     |
| 21   | .6539     | .6805     | .623      | .6367     | .6127     | .6607     | .6264     |
| 22   | .5281     | .5441     | .5281     | .5514     | .5274     | .5235     | .5064     |
| 23   | .4378     | .4611     | .4424     | .4633     | .442      | .4492     | .4363     |
| 24   | .3525     | .3883     | .7199     | .821      | .7593     | .7537     | .6592     |
| Max  | .7213     | .7228     | .7621     | .821      | .7674     | .7537     | .7651     |
| Min  | .2347     | .2446     | .3285     | .3285     | .3445     | .2995     | .2191     |
| Avg  | .438      | .4499     | .4894     | .5055     | .5018     | .4851     | .4877     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 211 / PANODI EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7621     |
| Max  | .7621     |
| Min  | .7621     |
| Avg  | .7621     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 212 / HANGEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .1819     | 2.0005    | 1.7718    | 2.4463    | 2.0005    |
| Max  | .1819     | 2.0005    | 1.7718    | 2.4463    | 2.0005    |
| Min  | .1819     | 2.0005    | 1.7718    | 2.4463    | 2.0005    |
| Avg  | .1819     | 2.0005    | 1.7718    | 2.4463    | 2.0005    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 213 / Chanegaon / Kanoli GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | .061      | .0434     | .0386     |
| Max  | .061      | .0434     | .0386     |
| Min  | .061      | .0434     | .0386     |
| Avg  | .061      | .0434     | .0386     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014023 / 33/11 KV ASHWI KH

Feeder No / Name : 215 / 11 KV PLA / S PUR (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .21       | .2233     | .2115     | .2355     | .2359     | .2374     | .1947     |
| 2    | .2077     | .2214     | .1966     | .2301     | .2248     | .2313     | .2039     |
| 3    | .2092     | .2241     | .1802     | .2321     | .2336     | .2305     | .176      |
| 4    | .2084     | .2389     | .1875     | .2431     | .2321     | .2282     | .1993     |
| 5    | .2351     | .2576     | .2221     | .2614     | .2416     | .2557     | .2465     |
| 6    | .3631     | .3479     | .3235     | .309      | .3307     | .3506     | .338      |
| 7    | .4748     | .4691     | .4664     | .4332     | .4512     | .4622     | .4675     |
| 8    | .4954     | .5026     | .5056     | .4588     | .5247     | .1219     | .4683     |
| 9    | .4439     | .4599     | .4877     | .4001     | .5026     | .4428     | .4592     |
| 10   | .3304     | .4226     | .4435     | .4195     | .3765     | .4694     | .418      |
| 11   | .3742     | .3022     | .3795     | .3365     | .346      | .3277     | .3193     |
| 12   | .2321     | .2016     | .2591     | .2054     | .2522     | .2119     | .2042     |
| 13   | .1886     | .1985     | .0023     | .1955     | .1886     | .1974     | .1551     |
| 14   | .1779     | .184      | .2172     | .2103     | .2206     | .1547     | .1715     |
| 15   | .0998     | .2157     | .2218     | .1703     | .2077     | .1783     | .192      |
| 16   | .2054     | .2004     | .2119     | .2138     | .1779     | .1898     | .1917     |
| 17   | .2301     | .2671     | .2618     | .2458     | .2503     | .2568     | .221      |
| 18   | .2964     | .2763     | .3086     | .3246     | .3227     | .3673     | .3117     |
| 19   | .4946     | .5125     | .4805     | .4793     | .471      | .4961     | .4386     |
| 20   | .5677     | .5251     | .5354     | .5769     | .5918     | .4832     | .5277     |
| 21   | .381      | .394      | .4428     | .4538     | .4024     | .4256     | .4115     |
| 22   | .322      | .3079     | .3342     | .3498     | .3178     | .29       | .3151     |
| 23   | .2793     | .2587     | .3006     | .3086     | .2755     | .2442     | .29       |
| 24   | .2347     | .226      | .2454     | .4743     | .4055     | .2077     | .1928     |
| Max  | .5677     | .5251     | .5354     | .5769     | .5918     | .4961     | .5277     |
| Min  | .0998     | .184      | .0023     | .1703     | .1779     | .1219     | .1551     |
| Avg  | .3026     | .3099     | .3094     | .3237     | .3243     | .2942     | .2964     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014024 / 33/11 KV KOKANGAON

Feeder No / Name : 202 / KOLHEWADI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2862    |
| Max  | 2.2862    |
| Min  | 2.2862    |
| Avg  | 2.2862    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014024 / 33/11 KV KOKANGAON

Feeder No / Name : 205 / 11 KV RAHIMPUR G.F.S.S

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .7621     |
| Max  | .7621     |
| Min  | .7621     |
| Avg  | .7621     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014024 / 33/11 KV KOKANGAON

Feeder No / Name : 209 / Mendhavan AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2862    |
| Max  | 2.2862    |
| Min  | 2.2862    |
| Avg  | 2.2862    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014025 / 33/11 KV KARJULEPATHAR

Feeder No / Name : 202 / DOLASNE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2862    |
| Max  | 2.2862    |
| Min  | 2.2862    |
| Avg  | 2.2862    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014025 / 33/11 KV KARJULEPATHAR

Feeder No / Name : 203 / PIMPALGAON DEPA AG      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.2862    |
| Max  | 2.2862    |
| Min  | 2.2862    |
| Avg  | 2.2862    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014100 / 33/11 KV NIMBALA

Feeder No / Name : 201 / Jorwa AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2125    | 1.2146    | 1.1984    | 1.0753    | 1.1265    | 1.1265    | 1.3441    |
| 2    | 1.2289    | 1.1174    | 1.1984    | .9962     | 1.1574    | 1.1265    | 1.2651    |
| 3    | 1.2125    | .9686     | 1.1984    | 1.1336    | 1.1574    | 1.1265    | 1.2018    |
| 4    | 1.2631    | 1.1523    | 1.2308    | 1.1984    | 1.1126    | 1.1574    | 1.1336    |
| 5    | 1.3603    | 1.3923    | 1.2955    | 1.2955    | 1.1584    | 1.2654    | 1.4413    |
| 6    | 1.5384    | .8907     | 1.4251    | 1.4074    | 1.2346    | 1.3889    | 1.5546    |
| 7    |           | .8907     | 1.2955    | 1.6194    | .503      | 1.4661    | 1.6518    |
| 8    | 1.6164    | 1.6518    | 1.7166    | 1.5061    | .442      | 1.6356    | 1.7328    |
| 9    | 1.5813    |           | 1.5223    | 1.5223    | .5506     |           | 1.5655    |
| 10   | .4954     | .4382     | .4763     | .5144     | .5144     | .4954     | .5335     |
| 11   | .381      |           | .3429     | .381      | .3429     |           | .3429     |
| 12   |           |           |           | .3239     | .2667     |           |           |
| 13   |           |           |           | .3239     | .2667     |           |           |
| 14   |           |           |           | .3239     |           |           |           |
| 15   | .381      |           |           | .3429     | .3429     | .4191     |           |
| 16   | .3429     | .3239     |           | .2858     | .3048     | .4001     | .3239     |
| 17   | .3239     | .381      | .381      | .3239     | .2858     | .4763     | .362      |
| 18   | .4572     | .4191     | .5525     | .362      | .4382     | .4191     | .4191     |
| 19   | .7621     | .7049     | .6478     | .724      |           | .7621     | .724      |
| 20   | .724      | .8002     | .724      | .7621     | .8192     | .8573     | .8002     |
| 21   | .6859     | .6859     | .6859     | .7049     | .724      | .8002     | .724      |
| 22   | .6097     | .5906     | .5716     | .6478     | .5716     | .724      | .5716     |
| 23   | .5335     | .4763     | .4954     | .4954     | .4763     | .6097     | .4191     |
| 24   | 1.2289    | 1.247     | 1.1984    | 1.1069    | 1.1227    | 1.1265    | 1.3441    |
| Max  | 1.6164    | 1.6518    | 1.7166    | 1.6194    | 1.2346    | 1.6356    | 1.7328    |
| Min  | .3239     | .3239     | .3429     | .2858     | .2667     | .4001     | .3239     |
| Avg  | .8969     | .8525     | .9556     | .8074     | .6781     | .9149     | .9728     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014100 / 33/11 KV NIMBALA

Feeder No / Name : 202 / NIMBALA AG SINGLE PHASING  
Feeder KV- 11 / OUTGOING

| DATE | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2483    | 1.3603    | 1.2483    | 1.3123    |
| 2    | 1.1843    | 1.3603    | 1.2483    | 1.2163    |
| 3    | 1.1203    | 1.3603    | 1.2483    | 1.1523    |
| 4    | 1.2003    | 1.3923    | 1.3763    | 1.4083    |
| 5    | 1.4243    | 1.4723    | 1.4883    | 1.5844    |
| 6    | 1.6324    | 1.5684    | 1.7124    | 1.9204    |
| 7    | 1.6004    | 2.0165    | 1.8564    | 2.1125    |
| 8    | 2.0645    | 2.1445    | 2.0645    | 2.0645    |
| 9    | 2.0165    | 2.1125    | .1698     | 1.6644    |
| 10   | 1.8404    | 2.2885    | 2.2085    | 2.3365    |
| 11   | 1.9044    | 2.2405    |           | 2.1605    |
| 12   | 2.0805    | 1.9364    |           | 2.1445    |
| 13   | 2.1125    | 2.2085    |           | 2.1445    |
| 14   | 2.0805    | 2.1605    |           | 2.0805    |
| 15   | .16       | .176      |           |           |
| 16   | .176      | .176      | .2401     | .192      |
| 17   | 2.0165    | 1.7991    | 2.0165    | 2.1285    |
| 18   | 2.1125    | 2.2405    | 2.2085    | 2.1605    |
| 19   | 2.1605    | 2.2565    | 2.2405    | 1.7604    |
| 20   | .4961     | .5281     | .5601     | .4961     |
| 21   | .4641     | .4161     | .5281     | .4641     |
| 22   | .4161     | .3681     | .4744     | .4001     |
| 23   | .3841     | .3041     | .4111     | .3521     |
| 24   | 1.9044    | 1.3603    | 2.0645    | .4641     |
| Max  | 2.1605    | 2.2885    | 2.2405    | 2.3365    |
| Min  | .16       | .176      | .1698     | .192      |
| Avg  | 1.4083    | 1.4686    | 1.3350    | 1.4661    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014100 / 33/11 KV NIMBALA

Feeder No / Name : 203 / TALEGAON WATERWORK  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0947     | .1217     | .096      | .1097     | .0934     | .0934     | .1467     |
| 2    | .0947     | .1353     | .096      | .1097     | .0934     | .0934     | .1467     |
| 3    | .096      | .1372     | .096      | .096      | .0934     | .0934     | .1334     |
| 4    | .096      | .1235     | .096      | .096      | .0934     | .0934     | .1334     |
| 5    | .096      | .1235     | .096      | .0947     | .0934     | .0934     | .1467     |
| 6    | .096      | .1509     | .096      | .0947     | .0934     | .0934     | .1467     |
| 7    |           | .096      | .0549     | .1082     | .0934     | .0934     | .16       |
| 8    | .096      | .1669     | .0686     | .0947     | .0934     | .0934     | .16       |
| 9    | .096      | .2086     | .1372     | .2195     | .0934     | .12       | .16       |
| 10   | .096      | .1947     | .1372     | .1217     | .0934     | .1334     | .2        |
| 11   | .096      | .1646     | .1097     | .1082     | .0947     |           | .1623     |
| 12   | .096      | .1646     | .1097     | .1082     | .0541     |           | .1623     |
| 13   | .1097     | .1646     | .096      | .096      | .0947     |           | .1623     |
| 14   | .1097     | .1646     | .096      | .096      | .0947     |           | .1623     |
| 15   | .1097     | .1646     | .096      | .096      | .0947     | .0947     | .1623     |
| 16   | .1082     | .1646     | .096      | .1097     | .0947     | .1067     | .1623     |
| 17   | .1082     | .1646     | .0947     | .0533     | .0947     | .1067     | .0541     |
| 18   | .1217     | .1646     | .1217     | .1067     | .0947     | .1067     | .1623     |
| 19   | .1082     | .1669     | .1353     | .0934     | .1217     | .1467     | .1623     |
| 20   | .1082     | .153      | .1488     | .0934     | .1217     | .16       | .1623     |
| 21   | .1082     | .1669     | .1372     | .0934     | .1082     | .1467     | .1353     |
| 22   | .0947     | .153      | .1235     | .0934     | .0947     | .1334     | .1353     |
| 23   | .096      | .153      | .1235     | .0934     | .0934     | .12       | .1353     |
| 24   | .0934     | .1488     | .0947     | .1097     | .0934     | .0934     | .1353     |
| Max  | .1217     | .2086     | .1488     | .2195     | .1217     | .16       | .2        |
| Min  | .0934     | .096      | .0549     | .0533     | .0541     | .0934     | .0541     |
| Avg  | .1013     | .1549     | .1065     | .1040     | .0952     | .1108     | .1496     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014100 / 33/11 KV NIMBALA

Feeder No / Name : 204 / Kolhewadi AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1143     | .1143     | .1334     | .1143     | .1143     | .1334     | .1334     |
| 2    | .1143     | .1143     | .1334     | .1143     | .1143     | .1334     | .1334     |
| 3    | .1143     | .0953     | .1334     | .0953     | .1143     | .1334     | .1143     |
| 4    | .1334     | .1334     | .1524     | .1524     | .1334     | .1524     | .1715     |
| 5    | .1524     | .1905     | .1905     | .2286     | .1715     | .1905     | .2667     |
| 6    | .1905     | .2667     | .2667     | .2667     | .2286     | .2858     | .2858     |
| 7    |           | .1905     | .3048     | .2667     | .3429     | .3239     | .2667     |
| 8    | .2667     | .2667     | .2286     | .2477     | .2667     | .2477     | .2858     |
| 9    | .2096     | .2286     | .1905     | .2096     | .2286     | .1905     | .2286     |
| 10   | 1.6872    | 2.1872    | 2.3482    | 2.0622    | 2.2653    | 2.3746    | 2.198     |
| 11   | 2.0466    | 2.2653    | 2.3205    | 2.2653    | 2.3434    |           | 2.2885    |
| 12   | 2.2184    | 2.3746    | 2.2497    | 2.2497    | 2.0309    |           | 2.3525    |
| 13   | 2.2184    |           |           |           |           |           |           |
| 14   | 2.1872    |           |           |           |           |           |           |
| 15   |           | 2.1872    |           | 2.1872    | 2.3434    | 1.7394    | 2.3087    |
| 16   |           | 2.2862    | 2.0679    | 2.3434    | 2.4059    | 2.6086    | 2.2297    |
| 17   |           | 2.3167    | 2.0622    | 2.1795    | 2.4215    | 2.4215    | 2.2138    |
| 18   | 2.0622    | 2.3167    | 2.234     | 2.1795    |           | 2.4777    | 2.2613    |
| 19   | 1.9528    | 2.21      | 2.0309    | 2.0881    |           | 2.0873    | 2.1822    |
| 20   | .1905     | .2286     | .2667     | .2286     | .2286     | .2858     | .1905     |
| 21   | .2667     | .1905     | .2477     | .1715     | .16       | .2667     | .1524     |
| 22   | .2477     | .1715     | .2286     | .1524     | .1524     | .2286     | .1334     |
| 23   | .1905     | .1524     | .1334     | .1334     | .1334     | .1715     | .1143     |
| 24   | .1334     | .1334     | .1334     | .1334     | .1143     | .1334     | .1334     |
| Max  | 2.2184    | 2.3746    | 2.3482    | 2.3434    | 2.4215    | 2.6086    | 2.3525    |
| Min  | .1143     | .0953     | .1334     | .0953     | .1143     | .1334     | .1143     |
| Avg  | .8349     | .9373     | .8599     | .9123     | .8157     | .8293     | .9384     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014110 / 33/11 KV RAHIMPUR

Feeder No / Name : 201 / Dongre B/F

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1715     | .1524     | .1715     | .1524     | .1715     | .1715     | .1715     |
| 2    | .168      | .1715     | .1715     | .1715     | .1715     | .1524     | .1715     |
| 3    | .1715     | .1715     | .1524     | .1715     | .1715     | .1715     | .1715     |
| 4    | .1905     | .1715     | .1715     | .1905     | .1905     | .1905     | .1905     |
| 5    | .2286     | .1905     | .1905     | .1905     | .2667     | .2667     | .2286     |
| 6    | .2667     | .2286     | .2477     | .2477     | .2667     | .2858     | .2477     |
| 7    | .2858     | .2667     | .2667     | .2667     | .2477     | .2667     | .2667     |
| 8    | .2667     | .2667     | .2858     | .2286     |           | .2667     | .2667     |
| 9    | .2667     | .1905     | .1715     | .2096     | .2477     | .2286     | .2096     |
| 10   | .1905     | .1715     | .1715     | .1905     | .1905     | .1905     | .1524     |
| 11   | .1715     | .1334     | .1524     | .1334     |           | .1334     | .1143     |
| 12   | 2.572     | 2.6513    | 2.8959    | 2.8578    | 2.6101    |           | 2.2862    |
| 13   |           | 2.6673    | 2.8578    | 2.9721    | 2.6101    | 2.2462    | 2.0233    |
| 14   | 2.3411    | 2.2977    | 2.915     | 2.8387    | 2.5911    | 2.4387    | 2.0748    |
| 15   | 2.2862    | 2.4006    | 2.6863    | 2.6673    | 2.6292    | 2.332     | 2.1434    |
| 16   | 2.5158    | 2.4863    | 2.6292    | 2.572     | 2.5911    | 2.0748    | 2.2119    |
| 17   | 2.7054    | 2.2805    | 2.4577    | 2.553     | 2.4577    | 2.1605    | 2.0748    |
| 18   | 2.6673    | 2.1948    | 2.4196    | 2.4768    | 2.4196    | 2.1262    | 2.0233    |
| 19   | 2.5149    | 2.0919    | 2.5339    | 2.4196    | 2.3053    | 2.0233    | 1.9719    |
| 20   | .2286     | .2286     | .2286     | .2286     | .2286     | .2286     | .2286     |
| 21   | .1905     | .2477     | .2477     | .2667     | .1905     | .1905     | .1905     |
| 22   | .1715     | .1715     | .1715     | .1715     | .1715     | .1715     | .1715     |
| 23   | .1715     | .1715     | .1524     | .1715     | .1715     | .1715     | .1524     |
| 24   | .1715     | .1715     | .1715     | .1524     | .1715     | .1524     | .1715     |
| Max  | 2.7054    | 2.6673    | 2.915     | 2.9721    | 2.6292    | 2.4387    | 2.2862    |
| Min  | .168      | .1334     | .1524     | .1334     | .1715     | .1334     | .1143     |
| Avg  | .9093     | .924      | 1.0217    | 1.0209    | 1.0487    | .8105     | .8298     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014110 / 33/11 KV RAHIMPUR

Feeder No / Name : 202 / Biroba B/F

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0953     | .0953     | .0953     | .0953     | .0953     | .1143     | .1143     |
| 2    | .1143     | .1143     | .1143     | .1143     | .1143     | .1143     | .1143     |
| 3    | .1143     | .1143     | .1143     | .1143     | .1143     | .1334     | .1143     |
| 4    | .1143     | .1143     | .1334     | .1334     | .1524     | .1524     | .1334     |
| 5    | .1524     | .1524     | .1524     | .1524     | .1905     | .1905     | .1524     |
| 6    | .2286     | .1905     | .1905     | .1715     | .2286     | .2096     | .2096     |
| 7    | .2477     | .2286     | .2286     | .2286     | .2477     | .2286     | .2477     |
| 8    | .2477     | .2286     | .2286     | .2286     |           | .2477     | .2667     |
| 9    | .2477     | .1715     | .1905     | .1905     | .2286     | .1715     | .1715     |
| 10   | .1715     | .1715     | .2096     | .0953     | .1905     | .1905     | .1334     |
| 11   | .1524     | .1524     | .1524     | .1143     |           | .1143     | .0953     |
| 12   | 1.0288    | 1.1812    | 1.1812    | 1.1431    | 1.0288    | .9774     | 1.0098    |
| 13   |           | 1.1812    | 1.1431    | 1.2003    | .8916     | 1.1431    | .8573     |
| 14   | 1.0098    | 1.1622    | 1.1812    | 1.2574    | 1.0479    | 1.0631    | .8916     |
| 15   | .9717     | 1.1622    | 1.1431    | 1.1431    | 1.1622    | 1.1016    | .9431     |
| 16   | .9088     | 1.1431    | 1.105     | 1.0669    | 1.105     | 1.105     | .9088     |
| 17   | 1.0082    | 1.086     | .9526     | 1.0479    | .9907     | .8916     | .8573     |
| 18   | 1.0288    | .9526     | 1.0098    | .9526     | .9526     | .7373     | .7888     |
| 19   | .8573     | .8192     | .8573     | .8192     | .8002     | .7621     | .6859     |
| 20   | .1524     | .1524     | .1334     | .1524     | .1524     | .1524     | .1524     |
| 21   | .1334     | .1524     | .1524     | .1905     | .1334     | .1905     | .1334     |
| 22   | .1143     | .1143     | .1143     | .1143     | .1143     | .1334     | .1143     |
| 23   | .1143     | .1143     | .1143     | .1143     | .1143     | .1143     | .0953     |
| 24   | .0953     | .0953     | .1143     | .0953     | .0953     | .1143     | .1143     |
| Max  | 1.0288    | 1.1812    | 1.1812    | 1.2574    | 1.1622    | 1.1431    | 1.0098    |
| Min  | .0953     | .0953     | .0953     | .0953     | .0953     | .1143     | .0953     |
| Avg  | .4048     | .4604     | .4588     | .4557     | .4614     | .4314     | .3877     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014114 / 33/11 KV KHALI S/STN

Feeder No / Name : 201 / 11 KV KHAMBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2472     | .2472     | .2637     |           | .2966     | .2637     | .2637     |
| 2    | .2307     | .2307     | .2637     |           | .2966     | .2637     | .2637     |
| 3    | .2472     | .2307     | .2637     |           | .2966     | .2802     | .2637     |
| 4    | .2637     | .2802     | .3461     |           | .2966     | .2966     | .2966     |
| 5    | .2802     | .3296     | .3626     |           | .3296     | .3296     | .3296     |
| 9    | 2.439     | 2.505     | 2.8016    |           |           |           |           |
| 10   | 2.472     | 2.5379    | 2.5379    |           |           |           |           |
| 11   | 2.505     | 2.4061    | 2.6368    |           |           |           |           |
| 12   | 2.2413    | 2.3072    |           | 2.4061    |           |           |           |
| 13   |           | 2.3072    |           | 2.472     |           |           |           |
| 14   |           | 2.3072    |           | 2.505     |           |           |           |
| 15   |           | 2.3731    |           | 1.8458    |           |           |           |
| 16   | 2.2413    | 2.3731    |           | 2.472     |           |           | 2.2742    |
| 18   |           |           |           |           |           |           | .0824     |
| 20   |           | .3626     |           | .3296     | .3626     | .3626     | .0824     |
| 21   |           | .3461     |           | .3626     | .3955     | .2966     | .0659     |
| 22   |           | .3296     |           | .3296     | .3296     | .2966     | .0824     |
| 23   |           | .2966     |           | .2966     | .2966     | .2637     | .0659     |
| 24   | 1.4832    | .2472     | .2802     |           | .2966     | .2637     | .0659     |
| Max  | 2.505     | 2.5379    | 2.8016    | 2.505     | .3955     | .3626     | 2.2742    |
| Min  | .2307     | .2307     | .2637     | .2966     | .2966     | .2637     | .0659     |
| Avg  | 1.3319    | 1.2232    | 1.0840    | 1.4466    | .3197     | .2917     | .3447     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014114 / 33/11 KV KHALI S/STN

Feeder No / Name : 202 / 11KV ZAREKATHI AG SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.4215    | 1.5927    | 1.7562    |           | 1.6824    | 1.6042    | 1.7688    |
| 2    | 1.3267    | 1.4813    | 1.7083    |           | 1.6503    | 1.5721    | 1.7205    |
| 3    | 1.3425    | 1.4972    | 1.7243    |           | 1.6183    | 1.4438    | 1.3668    |
| 4    | 1.3899    | 1.5927    | 1.7881    |           | 1.5542    | 1.4598    | 1.4472    |
| 5    | 1.4215    | 1.6565    | 1.8999    |           | 1.5222    | 1.4919    | 1.4954    |
| 6    | 1.8953    | 2.0706    | 2.1554    |           | 2.083     | 2.1656    | 2.0421    |
| 7    | 2.2901    | 2.7236    | 2.9217    |           | 2.7239    | 2.8554    | 2.6853    |
| 8    | 2.3375    | 2.5643    | 2.7141    |           | 2.6758    | 2.5186    | 2.4924    |
| 15   |           | .1433     |           | .1758     |           |           |           |
| 16   | .143      | .1593     |           | .1758     |           |           | .1769     |
| 17   |           | .1433     |           | .2078     | .1923     | .1927     | .1608     |
| 18   |           | .1752     |           | .1918     | .1763     | .2088     | .1769     |
| 19   |           | .3663     |           | .3357     | .3365     | .3694     | .3538     |
| 20   |           | .3504     |           | .3676     | .3365     | .3855     | .3698     |
| 21   |           | .3345     |           | .3517     | .3205     | .3377     | .3698     |
| 22   |           | .3185     |           | .3205     | .3048     | .3055     | .3216     |
| 23   |           | 1.8266    |           | 2.0509    | 1.925     | 2.0261    | 1.7527    |
| 24   | 1.5162    | 1.5927    | 1.7945    |           | 1.8426    | 1.7325    | 1.8653    |
| Max  | 2.3375    | 2.7236    | 2.9217    | 2.0509    | 2.7239    | 2.8554    | 2.6853    |
| Min  | .143      | .1433     | 1.7083    | .1758     | .1763     | .1927     | .1608     |
| Avg  | 1.5084    | 1.1438    | 2.0514    | .4642     | 1.3090    | 1.2919    | 1.2098    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014114 / 33/11 KV KHALI S/STN

Feeder No / Name : 203 / 11KV PIMPRI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5952     | .9156     | .8699     |           | .8862     | .7945     | .8251     |
| 2    | .6257     | .8699     | .8699     |           | .8557     | .7487     | .7945     |
| 3    | .2442     | .2747     | .2442     |           | .2445     | .2445     | .2445     |
| 4    | .2747     | .29       | .2747     |           | .2598     | .275      | .2598     |
| 5    | .3052     | .3052     | .3052     |           | .275      | .2903     | .2903     |
| 12   | .1221     | .1221     |           |           |           |           |           |
| 13   |           | .1068     |           |           |           |           |           |
| 14   |           | .1068     |           |           |           |           |           |
| 15   |           | .1221     |           | .1221     |           |           |           |
| 16   | .1068     | .1221     |           | .1526     |           |           | .107      |
| 17   |           | 1.7092    |           | 1.5718    | 1.528     | 1.6196    | 1.5433    |
| 18   |           | 1.4345    |           | 1.4955    | 1.5127    | 1.5433    | 1.4057    |
| 19   |           | 1.4803    |           | 1.3735    | 1.3446    | 1.3446    | 1.3752    |
| 20   |           | 1.2514    |           | 1.2514    | 1.2224    | 1.1918    | 1.2224    |
| 21   |           | 1.0988    |           | 1.1445    | .9473     | 1.1307    | 1.0849    |
| 22   |           | 1.0377    |           | 1.0849    | .9321     | 1.0085    | .9779     |
| 23   |           | .8546     |           | 1.0543    | .8862     | .9626     | .7945     |
| 24   | .2442     | .9614     | .8546     |           | .9626     | .8557     | .9321     |
| Max  | .6257     | 1.7092    | .8699     | 1.5718    | 1.528     | 1.6196    | 1.5433    |
| Min  | .1068     | .1068     | .2442     | .1221     | .2445     | .2445     | .107      |
| Avg  | .3148     | .7257     | .5698     | 1.0278    | .9121     | .9238     | .8469     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014115 / 33/11 KV PEMGIRI

Feeder No / Name : 201 / PREMGIRI SHIRGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    | 3.4736    |           |           | 3.3589    |
| 10   |           |           |           | 3.195     |
| 11   |           |           |           | 2.9504    |
| 21   |           | .4763     |           |           |
| 24   |           |           | .362      |           |
| Max  | 3.4736    | .4763     | .362      | 3.3589    |
| Min  | 3.4736    | .4763     | .362      | 2.9504    |
| Avg  | 3.4736    | .4763     | .362      | 3.1681    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014115 / 33/11 KV PEMGIRI

Feeder No / Name : 202 / SAVARCHOL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 9    | .3239     |           |           |           |
| 10   |           |           |           | .2477     |
| 11   |           |           |           | .2667     |
| 21   |           | .4001     |           |           |
| 24   |           |           | .2667     |           |
| Max  | .3239     | .4001     | .2667     | .2667     |
| Min  | .3239     | .4001     | .2667     | .2477     |
| Avg  | .3239     | .4001     | .2667     | .2572     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014115 / 33/11 KV PEMGIRI

Feeder No / Name : 203 / Pemgiri GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 06-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 11   | .0191     |
| Max  | .0191     |
| Min  | .0191     |
| Avg  | .0191     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014119 / 33/11 KV ASHWI BK

Feeder No / Name : 201 / Nimgaonjali AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | 3.0476    |           |
| 9    |           | 2.5396    |           |
| 16   | .1905     | .1334     |           |
| 17   |           | .1905     |           |
| 22   |           |           | .3239     |
| 23   |           |           | .2667     |
| Max  | .1905     | 3.0476    | .3239     |
| Min  | .1905     | .1334     | .2667     |
| Avg  | .1905     | 1.4778    | .2953     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014119 / 33/11 KV ASHWI BK

Feeder No / Name : 202 / Nimgaonjali GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 8    |           | .3395     |           |
| 9    |           | .5041     |           |
| 10   |           | .4917     |           |
| 11   |           | .4607     |           |
| 12   | .3658     | .3734     |           |
| 13   |           | .3206     |           |
| 14   |           | .4066     |           |
| 15   |           | .415      |           |
| 16   | .2772     | .499      |           |
| 17   |           | .3982     |           |
| 22   |           |           | .2667     |
| 23   |           |           | .2829     |
| Max  | .3658     | .5041     | .2829     |
| Min  | .2772     | .3206     | .2667     |
| Avg  | .3215     | .4209     | .2748     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 014119 / 33/11 KV ASHWI BK

Feeder No / Name : 203 / Umbri AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

| DATE | 03-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 12   | 3.1468    | 3.2007    |           |
| 13   |           | 3.0803    |           |
| 15   |           | 2.9165    |           |
| 16   | 2.9927    | 2.8509    | 3.0167    |
| 17   |           | 2.7206    | 2.556     |
| 18   |           |           | 2.2834    |
| 19   |           |           | 2.1628    |
| 20   |           |           | .1715     |
| 23   |           |           | .1143     |
| Max  | 3.1468    | 3.2007    | 3.0167    |
| Min  | 2.9927    | 2.7206    | .1143     |
| Avg  | 3.0698    | 2.9538    | 1.7175    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SANGEMNER DIVISION[573]

SANGAMNER - II[208] BU 5797

Substation No/ Name :- 017007 / 132/11 KV SANGAMNER

Feeder No / Name : 207 / MANGALAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0183     | .013      | .016      | .016      | .0076     |           | .0168     |
| 2    | .0191     | .016      | .016      | .016      | .016      |           | .0168     |
| 3    | .0198     | .0168     | .0168     | .0168     | .016      |           | .0175     |
| 4    | .0198     | .0183     | .0175     | .0168     | .0168     |           | .0183     |
| 5    | .0198     | .0183     | .0191     | .0198     | .0191     |           | .0198     |
| 6    | .0229     | .0061     | .0069     | .0221     |           |           | .0221     |
| 7    | .0282     |           |           | .0023     |           |           | .0122     |
| 8    | .0053     |           |           |           |           |           |           |
| 12   | .298      | .3254     | .3132     | .3277     | .3353     |           | .3452     |
| 13   | .3391     | .3391     | .3513     | .3422     | .349      | .0472     | .3605     |
| 14   | .3437     | .333      | .3559     | .3277     | .3391     | .3506     | .3612     |
| 15   | .3445     | .3132     | .3376     | .3254     | .3315     | .3688     | .3544     |
| 16   | .33       | .3201     | .3246     | .3201     | .3384     | .381      | .3559     |
| 17   | .3201     | .3079     | .3086     | .3231     | .2172     | .3658     | .3498     |
| 18   | .3102     | .3018     | .3208     | .3185     |           | .3582     | .3536     |
| 19   | .2926     |           | .218      | .3003     |           | .317      | .3353     |
| 20   | .1029     | .0183     | .1288     | .112      |           | .1113     | .1128     |
| 21   | .0236     | .0274     | .0267     | .0236     |           | .0251     | .0221     |
| 22   | .0229     | .0251     | .0259     | .0221     |           | .0236     | .0206     |
| 23   | .0213     | .0244     | .0251     | .0198     |           | .0221     | .0191     |
| 24   | .0145     | .0175     | .0183     | .0137     |           | .0183     | .2149     |
| Max  | .3445     | .3391     | .3559     | .3422     | .349      | .381      | .3612     |
| Min  | .0053     | .0061     | .0069     | .0023     | .0076     | .0183     | .0122     |
| Avg  | .1389     | .1357     | .1498     | .1443     | .1805     | .1991     | .1664     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 201 / PMT

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .4715     | .152      |           |           |           |           |
| 2    | .6268     | .4382     | .5888     | .4715     | .4944     | .4527     | .4753     |
| 3    |           | .4382     |           |           |           |           |           |
| 4    | .4563     |           | .4753     | .4527     | .4753     | .4715     | .4753     |
| 5    |           | .4954     |           |           |           |           |           |
| 6    | .5324     |           | .5514     | .4904     | .5134     | .5658     | .4563     |
| 7    | .5704     | .5847     | .5894     | .547      |           | .5658     | .4944     |
| 8    | .6275     | .5906     | .6275     | .6036     | .433      | .5847     | .5514     |
| 9    | .7218     | .7085     | .7028     | .7167     | .6084     | .7167     | .6655     |
| 10   |           |           |           | .7545     |           | .724      | .679      |
| 11   | .6838     | .6566     | .7028     | .7545     | .5324     | .7167     |           |
| 12   | .7408     |           | .7788     | .743      |           | .7811     | .6036     |
| 13   |           | .121      | .5875     | .6287     | .5324     | .679      |           |
| 14   |           |           | .5357     |           | .4944     | .6668     | .7167     |
| 15   | .7028     | .6214     | .6394     | .6602     | .4373     | .7167     |           |
| 16   | .679      |           |           |           | .4563     | .7621     | .8488     |
| 17   | .6668     | .7035     | .6224     | .5144     | .4527     | .7225     | .6602     |
| 18   | .547      | .5514     | .5847     |           | .547      | .6275     |           |
| 19   | .6036     | .6084     | .6036     | .6478     | .6036     | .6465     | .679      |
| 20   | .5906     |           | .5658     |           | .5281     | .5894     | .5658     |
| 21   | .5716     | .5704     | .5847     | .547      | .5093     | .5704     | .547      |
| 22   | .5281     |           | .5281     |           | .5281     | .5514     | .5658     |
| 23   |           | .4563     | .5281     |           | .4904     | .5324     | .547      |
| 24   | .4373     | .71       | .4563     | .5093     | .5093     | .4715     | .4944     |
| Max  | .7408     | .71       | .7788     | .7545     | .6084     | .7811     | .8488     |
| Min  | .4373     | .121      | .152      | .4527     | .433      | .4527     | .4563     |
| Avg  | .6051     | .5454     | .5703     | .6028     | .5081     | .6245     | .5897     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 202 / 11 KV Gogalgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .9998     | .1964     |           |           |           |           |
| 2    | .18       | .8048     | 1.0262    | 1.065     | 1.2054    | .2294     | .2769     |
| 3    |           | 1.3077    |           |           |           |           |           |
| 4    | 1.2217    |           | 1.2543    | 1.3108    | 1.4823    | .2785     | .2932     |
| 5    |           | 1.406     |           |           |           |           |           |
| 6    | 1.8244    |           | 1.8244    | 1.7204    | 2.1176    | .4588     | .4235     |
| 7    | 2.2479    | 2.1715    | 2.1013    | 2.4413    |           | .5407     | .5538     |
| 8    | 2.4108    | 2.4074    | 2.6226    | 2.6707    | 2.5574    | .4096     | .4561     |
| 9    | 2.2094    | 2.2085    | 2.2421    | 2.2119    | 1.6452    | .3113     | .3584     |
| 10   |           |           |           | .3932     |           | .3185     | .3185     |
| 11   | .18       | .2607     | .2946     | .2949     | .3095     | .3185     |           |
| 12   | .18       |           | .18       | .285      |           | 2.0934    | 2.0481    |
| 13   |           | .1687     | .1843     | .2683     | .1955     | 2.1605    |           |
| 14   |           |           |           |           | .1955     | 2.364     | 2.1628    |
| 15   | .18       | .1687     | .1687     | .2347     | .2118     | 2.1605    |           |
| 16   | .1966     |           |           |           | .1792     | 2.1914    | 2.2939    |
| 17   | .2294     |           | .213      |           | .213      | 2.2642    | 2.0645    |
| 18   | .3688     | .3258     | .1718     |           | .2785     | 1.6615    |           |
| 19   | .3521     | .4072     | .426      | .3856     | .5243     | 1.3357    | 1.6712    |
| 20   | .3688     |           | .4588     |           | .4096     | .4398     | .426      |
| 21   | .3647     | .4072     | .4424     | .4024     | .4096     | .4072     | .426      |
| 22   | .3688     |           | .3932     |           | .3768     | .3747     | .3768     |
| 23   |           | .3421     | .3441     |           | .3277     | .3421     | .3113     |
| 24   | .9774     | .2332     | .18       | .9995     | .8097     | .2458     | .2932     |
| Max  | 2.4108    | 2.4074    | 2.6226    | 2.6707    | 2.5574    | 2.364     | 2.2939    |
| Min  | .18       | .1687     | .1687     | .2347     | .1792     | .2294     | .2769     |
| Avg  | .8153     | .9080     | .7750     | 1.0488    | .7471     | .9955     | .8679     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 203 / 11 kv Sadatpur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .2012     | 1.9982    |           |           |           |           |
| 2    | .1166     | .2012     | 1.865     | .1989     | .1955     | .9282     | .9774     |
| 3    |           | .2012     |           |           |           |           |           |
| 4    | .1792     |           | .2118     | .2321     | .1792     | 1.0774    | 1.0588    |
| 5    |           | .2347     |           |           |           |           |           |
| 6    | .2662     |           | .2932     | .2984     | .2606     |           | 1.4009    |
| 7    | .2932     | .3185     | .3258     | .2984     |           | 1.8896    | 1.8244    |
| 8    | .2443     | .2683     | .2443     | .2652     | .2281     | 2.1714    | 2.2317    |
| 9    | .1832     | .1845     | .1832     | .2155     | .2118     | 2.0553    | 1.8733    |
| 10   |           |           |           | .1823     |           | .1341     | .1341     |
| 11   | .1332     | .1076     | .1332     | .116      | .1303     | .1174     |           |
| 12   | .1166     |           | 1.9815    | 1.7497    |           | .0838     | .0829     |
| 13   |           | 2.091     | 1.845     | 1.7284    | 1.7918    | .0838     |           |
| 14   |           |           | 1.722     |           | 1.743     | .0848     | .0663     |
| 15   | .0666     | 1.8618    | 1.7527    | 1.6667    | 1.6615    | .0838     |           |
| 16   | 1.7747    |           |           |           | 1.7104    | .0838     | .0829     |
| 17   | 1.8982    |           | 1.8233    | 1.7747    | 1.8896    | .0814     | .0829     |
| 18   | 1.7747    |           | 1.9393    |           | 1.7736    | .114      |           |
| 19   | 1.6204    | 1.7267    | 1.7404    | 1.4969    | 1.4255    | .1955     | .2155     |
| 20   | .218      |           | .2818     |           | .2486     | .2606     | .431      |
| 21   | .2652     | .2443     | .2486     | .285      | .2486     | .2443     | .2486     |
| 22   | .2515     |           | .2155     |           | .1989     | .2118     | .2155     |
| 23   |           | .2443     | .2155     |           | .1823     | .1792     | .1823     |
| 24   | .1955     | .1845     | .2118     | .1989     | .2204     | 1.2763    | .8959     |
| Max  | 1.8982    | 2.091     | 1.9982    | 1.7747    | 1.8896    | 2.1714    | 2.2317    |
| Min  | .0666     | .1076     | .1332     | .116      | .1303     | .0814     | .0663     |
| Avg  | .5645     | .5764     | .9616     | .7138     | .7944     | .5678     | .7061     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 204 / 11 kv Engr Collage

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .1132     | .1521     |           |           |           |           |
| 2    | .1901     | .1132     | .1141     | .1132     | .0951     | .1132     | .0951     |
| 3    |           | .1132     |           |           |           |           |           |
| 4    | .1141     |           | .1331     | .132      | .0951     | .1132     | .0951     |
| 5    |           | .1509     |           |           |           |           |           |
| 6    | .1901     |           | .1521     | .1886     | .1521     | .1698     | .1711     |
| 7    | .2282     | .2263     | .2092     | .1698     |           | .1886     | .1901     |
| 8    | .2282     | .2452     | .2282     | .2075     | .1711     | .2075     | .2092     |
| 9    | .2092     | .1732     | .2282     | .2075     | .1521     | .2075     | .1141     |
| 10   |           |           |           | .2452     |           | .2075     | .1509     |
| 11   | .2092     | .1559     | .2092     | .1886     | .1521     | .2075     |           |
| 12   | .2282     |           | .2092     | .1886     |           | .1886     | .1886     |
| 13   |           | .1559     | .1384     | .1509     | .1331     | .1886     |           |
| 14   |           |           | .1557     |           | .1331     | .1698     | .1698     |
| 15   | .2092     | .1038     | .173      | .1509     | .1331     | .1886     |           |
| 16   | .1509     |           |           | .1509     | .1141     | .2075     | .1886     |
| 17   | .132      |           | .1509     | .1509     | .132      | .1711     | .1509     |
| 18   | .132      | .1521     | .1509     |           | .132      | .1331     |           |
| 19   | .1509     | .1711     | .1698     | .1509     | .1509     | .1331     | .1509     |
| 20   | .1509     |           | .1698     |           | .132      | .1521     | .1509     |
| 21   | .1509     | .1559     | .132      | .132      | .132      | .1331     | .1698     |
| 22   | .1509     |           | .1509     |           | .132      | .1331     | .1509     |
| 23   |           | .1331     | .132      |           | .132      | .1331     | .132      |
| 24   | .1141     | .1732     | .1711     | .132      | .0943     | .132      | .1141     |
| Max  | .2282     | .2452     | .2282     | .2452     | .1711     | .2075     | .2092     |
| Min  | .1141     | .1038     | .1141     | .1132     | .0943     | .1132     | .0951     |
| Avg  | .1729     | .1557     | .1665     | .1662     | .1316     | .1656     | .1525     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 205 / 11 kv Dudheshwar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .8697     | .1877     |           |           |           |           |
| 2    | .1564     | .8697     | 1.0179    | 1.1717    | 1.1589    | .25       | .2506     |
| 3    |           | 1.1544    |           |           |           |           |           |
| 4    | 1.2059    |           | 1.2215    | 1.3279    | 1.5661    | .3125     | .2662     |
| 5    |           | 1.4998    |           |           |           |           |           |
| 6    | 1.4251    |           | 1.7383    | 1.8747    | 2.0516    |           | .3747     |
| 7    | 1.848     | 1.8442    | 2.1299    | 2.1872    |           | .4531     | .4072     |
| 8    | 2.1299    | 2.1795    |           | 2.2653    | 2.2708    | .3906     | .3759     |
| 9    | 1.9396    | 1.8183    |           | 1.9216    | 1.9106    | .3281     | .3132     |
| 10   |           |           |           | .25       |           | .2984     | .3018     |
| 11   | .1721     | .2139     |           | .2031     | .2193     | .2321     |           |
| 12   | .1721     |           | .219      | .1638     |           | 2.0319    | 2.1091    |
| 13   |           | .1528     | .1834     | .1823     | .1566     | 1.8814    |           |
| 14   |           |           | .1681     |           | .1629     | 1.7833    | 2.2653    |
| 15   | .1408     | .1375     | .0421     | .1658     | .1566     | 1.1591    |           |
| 16   | .1509     |           |           |           | .1723     | 1.9566    | 2.1403    |
| 17   | .1677     |           | .1718     | .1677     | .1718     | 2.1299    | .0625     |
| 18   | .218      |           |           |           | .2031     | 1.9419    |           |
| 19   | .3688     | .3132     | .3281     | .3353     | .3593     | 1.9873    | 1.7341    |
| 20   | .3391     |           | .3437     |           | .3437     | .3289     | .3593     |
| 21   | .3222     | .2976     | .3437     | .3521     | .3437     | .3132     | .3281     |
| 22   | .3222     |           | .3281     |           | .2968     | .2819     | .2968     |
| 23   |           | .2662     | .2812     |           | .2968     | .2662     | .2656     |
| 24   | 1.1432    | 1.8183    | .1721     | 1.2811    | .9282     | .4062     | .2506     |
| Max  | 2.1299    | 2.1795    | 2.1299    | 2.2653    | 2.2708    | 2.1299    | 2.2653    |
| Min  | .1408     | .1375     | .0421     | .1638     | .1566     | .2321     | .0625     |
| Avg  | .7189     | .9597     | .5548     | .9233     | .7094     | .9366     | .7118     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014130 / Loni

Feeder No / Name : 206 / Adgaon Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .0566     | .057      |           |           |           |           |
| 2    | .038      | .0566     | .038      | .0377     | .038      | .0377     | .038      |
| 3    |           | .0566     |           |           |           |           |           |
| 4    | .057      |           | .057      | .0377     | .038      | .0566     | .057      |
| 5    |           | .0754     |           |           |           |           |           |
| 6    | .0761     |           | .0761     | .0754     | .0761     |           | .0951     |
| 7    | .0951     | .132      | .1141     | .1132     |           | .1132     | .1141     |
| 8    | .1141     | .0943     | .1141     |           | .0761     | .0943     | .0951     |
| 9    | .0761     | .0866     | .0951     | .0754     | .1521     | .0754     | .0951     |
| 10   |           |           |           | .0566     |           | .0754     | .0566     |
| 11   | .038      | .0519     | .038      | .0566     | .0761     | .0754     |           |
| 12   | .038      |           | .057      | .0566     |           | .0566     | .0377     |
| 13   |           | .0519     | .0519     | .0566     | .038      | .0566     |           |
| 14   |           |           | .0346     |           | .038      | .0566     | .0377     |
| 15   | .019      | .0346     | .0346     | .0377     | .038      | .0377     |           |
| 16   | .0566     |           |           |           | .038      | .0377     | .0377     |
| 17   | .0566     |           | .0754     | .0754     | .0943     | .057      | .0754     |
| 18   | .1132     |           | .0754     |           | .0943     | .0951     |           |
| 19   | .1509     | .1331     | .132      | .132      | .1509     | .1521     | .1132     |
| 20   | .1509     |           | .1132     |           | .1132     | .1141     | .1132     |
| 21   | .1509     | .0761     | .0754     | .0754     | .0754     | .0761     | .0754     |
| 22   | .0754     |           | .0754     |           | .0754     | .0761     | .0566     |
| 23   |           | .057      | .0566     |           | .0566     | .057      | .0754     |
| 24   | .057      | .0866     | .0546     | .0566     | .0566     | .0943     | .057      |
| Max  | .1509     | .1331     | .132      | .132      | .1521     | .1521     | .1141     |
| Min  | .019      | .0346     | .0346     | .0377     | .038      | .0377     | .0377     |
| Avg  | .0802     | .0750     | .0713     | .0674     | .0736     | .0748     | .0724     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014132 / 33/11KV Dadh Substation

Feeder No / Name : 201 / 11KV Pratappur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .9431     |
| Max  | .9431     |
| Min  | .9431     |
| Avg  | .9431     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014132 / 33/11KV Dadh Substation

Feeder No / Name : 202 / 11KV Chinchpur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.1317    |
| Max  | 1.1317    |
| Min  | 1.1317    |
| Avg  | 1.1317    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014132 / 33/11KV Dadh Substation

Feeder No / Name : 203 / 11KV DADH GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .9431     |
| Max  | .9431     |
| Min  | .9431     |
| Avg  | .9431     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014135 / 33/11KV Hasnapur Substation

Feeder No / Name : 201 / 11 kv chinchpur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .1143     |           | .1143     | .9536     | 1.2323    |
| 2    |           | .1334     |           | .1334     | .1143     | .9536     | 1.1523    |
| 3    |           |           | .1143     |           | .1143     | .9682     | 1.3375    |
| 4    |           | .1334     |           | .1334     | .1334     | .9682     |           |
| 5    |           |           | .1334     |           | .1334     | 1.0122    |           |
| 6    |           | .1715     |           | .1524     | .1905     | 1.0269    |           |
| 7    | .2286     |           | .1524     | .1715     | .1905     | 1.5927    |           |
| 8    |           | .1905     |           | .1715     | .1524     | 1.8814    |           |
| 9    |           |           |           | .1715     | .1334     | 1.8827    | 2.0005    |
| 10   | .0953     | .1143     | .1334     | .1334     | .1524     | .1524     | .1143     |
| 11   |           |           |           | .1334     | .1143     | .1143     | .0953     |
| 12   |           | 2.0805    | 2.2405    | 2.0805    | 2.2531    | .0762     | .0762     |
| 13   |           |           | 2.1125    | 2.1925    | 2.2222    | .0572     | .0572     |
| 14   |           | 2.0485    |           | 2.2085    | 2.2068    | .0572     |           |
| 15   |           |           | 2.1925    | 2.1605    | 2.1605    | .0572     |           |
| 16   |           |           |           | 2.1925    | 2.1142    | .0762     | .0572     |
| 17   | 1.8595    |           |           | 2.1925    | 2.0062    | .0762     | .0572     |
| 18   |           |           |           | 1.9766    | 1.8673    | .1143     |           |
| 19   | 1.3998    |           |           | 1.7764    | 1.5699    | .1524     |           |
| 20   |           |           |           | .1905     |           | .1905     | .1905     |
| 21   | .1905     |           |           | .1905     |           | .1905     | .1905     |
| 22   |           |           |           | .1524     |           | .2096     | .1905     |
| 23   |           |           |           | .1524     | .1524     | .1715     | .1715     |
| 24   | .0953     |           |           |           | .1143     |           | 1.2963    |
| Max  | 1.8595    | 2.0805    | 2.2405    | 2.2085    | 2.2531    | 1.8827    | 2.0005    |
| Min  | .0953     | .1143     | .1143     | .1334     | .1143     | .0572     | .0572     |
| Avg  | .6448     | .6960     | .8992     | .9333     | .8671     | .5624     | .5480     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014135 / 33/11KV Hasnapur Substation

Feeder No / Name : 202 / 11KV Pratappur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.1584    |
| Max  | 1.1584    |
| Min  | 1.1584    |
| Avg  | 1.1584    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014135 / 33/11KV Hasnapur Substation

Feeder No / Name : 203 / 11KV Hanumantgaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 2    |           | .1524     |
| 4    |           | .1715     |
| 6    |           | .2096     |
| 7    | .3429     |           |
| 8    |           | .3239     |
| 10   | .1905     | .2096     |
| 12   |           | 2.1925    |
| 14   |           | 2.1765    |
| 17   | 1.9566    |           |
| 19   | 1.9416    |           |
| 21   | .2667     |           |
| 24   | .1905     |           |
| Max  | 1.9566    | 2.1925    |
| Min  | .1905     | .1524     |
| Avg  | .8148     | .7766     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014135 / 33/11KV Hasnapur Substation

Feeder No / Name : 204 / 11KV Chandrapur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | 1.1883    |           | 1.4937    | .2477     | .2286     |
| 2    |           | 1.247     |           | 1.0425    | 1.4937    | .2477     | .2286     |
| 3    |           |           | 1.2029    |           | 1.5242    | .2477     | .2286     |
| 4    |           | 1.3375    |           | 1.0709    | 1.6613    | .2667     |           |
| 5    |           |           | 1.3375    |           | 1.6613    | .2667     |           |
| 6    |           | 1.5699    |           | 1.1888    | 1.821     | .2858     |           |
| 7    | 2.0671    |           | 2.0833    | 1.9357    |           | .3048     |           |
| 8    |           | 1.8212    |           | 2.372     | 1.8976    | .3086     |           |
| 9    |           |           |           | 2.2377    | 2.3365    | .2667     | .2477     |
| 10   | .2096     | .2096     | .2477     | .2096     | .2667     | .2477     | .2477     |
| 11   |           |           |           | .2096     | .2286     | .2096     | .2286     |
| 12   |           | .1334     | .1524     | .1334     | .1905     | 2.3845    |           |
| 13   |           |           | .1524     | .1143     | .1524     | 2.3403    | 2.3122    |
| 14   |           | .1143     |           | .1334     | .1524     | 2.4006    |           |
| 15   |           |           | .1143     | .1334     | .1524     | 2.4806    |           |
| 16   |           |           |           | .1334     | .1334     | 2.2138    |           |
| 17   | .1334     |           |           | .1334     | .1524     | 2.2455    | 2.0005    |
| 18   |           |           |           | .1524     | .1715     | 1.5813    |           |
| 19   | .2667     |           |           | .2858     | .3048     | 1.8185    |           |
| 20   |           |           |           | .362      |           | .3429     | .4191     |
| 21   | .3239     |           |           | .362      |           | .3429     | .4001     |
| 22   |           |           |           | .3429     |           | .362      | .362      |
| 23   |           |           |           | .3048     | .2667     | .3048     | .3429     |
| 24   | 1.4632    |           |           |           | 1.5123    |           | .2286     |
| Max  | 2.0671    | 1.8212    | 2.0833    | 2.372     | 2.3365    | 2.4806    | 2.3122    |
| Min  | .1334     | .1143     | .1143     | .1143     | .1334     | .2096     | .2286     |
| Avg  | .7440     | .9190     | .8099     | .6429     | .8787     | .9442     | .5750     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014135 / 33/11KV Hasnapur Substation

Feeder No / Name : 205 / 11KV HASNAPUR GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .0572     |           | .0762     | .0762     | .0572     |
| 2    |           | .0762     |           | .0762     | .0762     | .0762     | .0572     |
| 3    |           |           | .0572     |           | .0953     | .0762     | .0762     |
| 4    |           | .0762     |           | .0762     | .0953     | .0762     |           |
| 5    |           |           | .0762     |           | .1143     | .0953     |           |
| 6    |           | .1143     |           | .1143     | .1143     | .1143     |           |
| 7    | .1524     |           | .1143     | .1334     | .1334     | .1334     |           |
| 8    |           | .1524     |           | .1524     | .1524     | .1286     |           |
| 9    |           |           |           | .1334     | .1334     | .1158     | .1334     |
| 10   | .0953     | .1334     | .1143     | .1143     | .1524     | .1334     | .1143     |
| 11   |           |           |           | .0953     | .1334     | .1143     | .0953     |
| 12   |           | .0572     | .1143     | .0953     | .1143     | .0953     | .0953     |
| 13   |           |           | .1143     | .1143     | .0953     | .0762     | .0762     |
| 14   |           | .0572     |           | .0762     | .0953     | .0762     |           |
| 15   |           |           | .0762     | .0953     | .0762     | .0762     |           |
| 16   |           |           |           | .0953     | .0762     | .0572     |           |
| 17   | .0762     |           |           | .0953     | .0953     | .0762     | .0953     |
| 18   |           |           |           | .1143     | .1334     | .1143     |           |
| 19   | .1334     |           |           | .1334     | .1334     | .1524     |           |
| 20   |           |           |           | .1143     |           | .1334     | .1143     |
| 21   | .1143     |           |           | .0953     |           | .1334     | .0953     |
| 22   |           |           |           | .0953     |           | .0953     | .0762     |
| 23   |           |           |           | .0762     | .0762     | .0762     | .0572     |
| 24   | .0572     |           |           |           | .0762     |           | .0762     |
| Max  | .1524     | .1524     | .1143     | .1524     | .1524     | .1524     | .1334     |
| Min  | .0572     | .0572     | .0572     | .0762     | .0762     | .0572     | .0572     |
| Avg  | .1048     | .0953     | .0905     | .1048     | .1071     | .1001     | .0871     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014135 / 33/11KV Hasnapur Substation

Feeder No / Name : 206 / 11KV DURGAPUR GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           | .0381     |           | .0381     | .0381     | .0572     |
| 2    |           | .0381     |           | .0381     | .0381     | .0381     | .0572     |
| 3    |           |           | .0381     |           | .0381     | .0381     | .0572     |
| 4    |           | .0572     |           | .0572     | .0381     | .0381     |           |
| 5    |           |           | .0572     |           | .0381     | .0572     |           |
| 6    |           | .1143     |           | .0953     | .0762     | .0572     |           |
| 7    | .0953     |           | .0953     | .1143     | .0953     | .1143     |           |
| 8    |           | .1143     |           | .0953     | .0953     | .0953     |           |
| 9    |           |           |           | .0762     | .1143     | .1143     | .1143     |
| 10   | .0572     | .0953     | .0572     | .0381     | .0953     | .0762     | .1144     |
| 11   |           |           |           | .0381     | .0381     | .0572     | .0572     |
| 12   |           | .0572     | .0381     | .0381     | .0381     | .0381     | .0381     |
| 13   |           |           | .0381     | .0381     | .0381     | .0381     | .0381     |
| 14   |           | .0572     |           | .0381     | .0381     | .0381     | .0381     |
| 15   |           |           | .0381     | .0381     | .0381     | .0381     |           |
| 16   |           |           |           | .0572     | .0381     | .0572     | .0572     |
| 17   | .0381     |           |           | .0572     | .0572     | .0762     | .0572     |
| 18   |           |           |           | .0762     | .0762     | .0762     |           |
| 19   | .1143     |           |           | .1143     | .0953     | .0953     |           |
| 20   |           |           |           | .0953     |           | .0953     | .0953     |
| 21   | .0572     |           |           | .0572     |           | .0953     | .0572     |
| 22   |           |           |           | .0572     |           | .0572     | .0381     |
| 23   |           |           |           | .0381     | .0381     | .0572     | .0381     |
| 24   | .0381     |           |           |           | .0381     |           | .0572     |
| Max  | .1143     | .1143     | .0953     | .1143     | .1143     | .1143     | .1144     |
| Min  | .0381     | .0381     | .0381     | .0381     | .0381     | .0381     | .0381     |
| Avg  | .0667     | .0762     | .0500     | .0629     | .0572     | .0646     | .0608     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014137 / 33/11kv Mamdapur substation

Feeder No / Name : 201 / Mamdapur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | 1.448     | 1.5242    | 1.6004    | 1.3413    | .2286     | .1981     |
| Max  | 1.448     | 1.5242    | 1.6004    | 1.3413    | .2286     | .1981     |
| Min  | 1.448     | 1.5242    | 1.6004    | 1.3413    | .2286     | .1981     |
| Avg  | 1.448     | 1.5242    | 1.6004    | 1.3413    | .2286     | .1981     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014137 / 33/11kv Mamdapur substation

Feeder No / Name : 202 / Yadav Mala

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | 1.2193    | 1.4937    | 1.5242    | 1.3717    | .2134     | .1981     |
| Max  | 1.2193    | 1.4937    | 1.5242    | 1.3717    | .2134     | .1981     |
| Min  | 1.2193    | 1.4937    | 1.5242    | 1.3717    | .2134     | .1981     |
| Avg  | 1.2193    | 1.4937    | 1.5242    | 1.3717    | .2134     | .1981     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014137 / 33/11kv Mamdapur substation

Feeder No / Name : 203 / Fattyabad SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .2286     | .2439     | .2439     | .1981     | .2134     | 1.2193    | 1.1888    |
| Max  | .2286     | .2439     | .2439     | .1981     | .2134     | 1.2193    | 1.1888    |
| Min  | .2286     | .2439     | .2439     | .1981     | .2134     | 1.2193    | 1.1888    |
| Avg  | .2286     | .2439     | .2439     | .1981     | .2134     | 1.2193    | 1.1888    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014137 / 33/11kv Mamdapur substation

Feeder No / Name : 204 / Nandur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .2439     | .2743     | .2591     | .2134     | .1372     | .7621     | 1.0059    |
| Max  | .2439     | .2743     | .2591     | .2134     | .1372     | .7621     | 1.0059    |
| Min  | .2439     | .2743     | .2591     | .2134     | .1372     | .7621     | 1.0059    |
| Avg  | .2439     | .2743     | .2591     | .2134     | .1372     | .7621     | 1.0059    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014137 / 33/11kv Mamdapur substation

Feeder No / Name : 205 / Khandala

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .2134     | .1981     | .2286     | .1981     | .1829     | 1.2955    | 1.3108    |
| Max  | .2134     | .1981     | .2286     | .1981     | .1829     | 1.2955    | 1.3108    |
| Min  | .2134     | .1981     | .2286     | .1981     | .1829     | 1.2955    | 1.3108    |
| Avg  | .2134     | .1981     | .2286     | .1981     | .1829     | 1.2955    | 1.3108    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014137 / 33/11kv Mamdapur substation

Feeder No / Name : 206 / 11KV MAMADAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .1524     | .1524     | .1524     | .1829     | .1829     | .1677     | .1677     |
| Max  | .1524     | .1524     | .1524     | .1829     | .1829     | .1677     | .1677     |
| Min  | .1524     | .1524     | .1524     | .1829     | .1829     | .1677     | .1677     |
| Avg  | .1524     | .1524     | .1524     | .1829     | .1829     | .1677     | .1677     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 201 / 11 kv Satral

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.7284    |           |           |           |           |           |
| 2    | 1.7284    |           | 1.7263    |           |           |           |
| 3    | 1.7284    |           |           |           |           |           |
| 4    | 1.8404    |           | 1.8382    |           |           |           |
| 5    | 1.9204    |           |           |           |           |           |
| 6    | 2.1125    |           | 2.2059    |           | .1718     |           |
| 7    | 2.5606    |           |           |           | .2031     |           |
| 8    | 2.8166    |           | 3.165     | 2.6673    | .1718     |           |
| 9    | 1.367     |           |           | 2.6277    | .2564     | .16       |
| 10   | .1015     |           |           | .2884     | .2564     |           |
| 11   | .0781     |           |           | .2083     | .1763     |           |
| 12   | .0547     |           |           | .1442     | 2.7559    | 1.4175    |
| 13   |           |           |           | .1442     |           |           |
| 14   |           |           |           | .1282     | 2.4194    |           |
| 15   |           |           |           | .1122     | 2.7399    | 1.387     |
| 16   |           |           |           | .1282     | 2.5957    | 1.2879    |
| 17   | .1067     | .1119     | .1758     | .0703     | 2.713     |           |
| 18   |           |           | .2286     | .0781     |           |           |
| 19   |           | .3357     |           | .164      |           |           |
| 20   |           |           |           | .1562     |           | .3201     |
| 21   |           | .3037     |           |           |           |           |
| 23   |           | .2078     |           |           |           |           |
| 24   | 1.7284    |           | 1.7263    | 1.6613    | .1015     | .1677     |
| Max  | 2.8166    | .3357     | 3.165     | 2.6673    | 2.7559    | 1.4175    |
| Min  | .0547     | .1119     | .1758     | .0703     | .1015     | .16       |
| Avg  | 1.4194    | .2398     | 1.5809    | .6128     | 1.2134    | .7900     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 202 / Dhanore

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1932     |           |           |           |           |           |
| 2    | .1932     |           | .1959     |           |           |           |
| 3    | .1932     |           |           |           |           |           |
| 4    | .2415     |           | .2449     |           |           |           |
| 5    | .322      |           |           |           |           |           |
| 6    | .3864     |           | .4245     |           | 1.2803    |           |
| 7    | .4508     |           |           |           | 1.451     |           |
| 8    |           |           | .3919     | .3048     | 1.5577    |           |
| 9    |           |           |           | .3588     | 2.4137    | 1.6615    |
| 10   | .149      |           |           | .2936     | .2609     |           |
| 11   | .1139     |           |           | .212      | .212      |           |
| 12   | 1.2971    |           |           | 2.5767    | .1305     | .0977     |
| 13   |           |           |           | 2.6094    | .1305     |           |
| 14   |           |           |           | 2.6094    | .1142     |           |
| 15   |           |           |           | 2.6257    | .1305     | .076      |
| 16   |           |           |           | 2.4952    | .1142     | .113      |
| 17   | 2.0729    | 2.4818    | 2.4691    | 1.6537    | .1219     |           |
| 18   |           |           | 2.3777    | 1.6324    |           |           |
| 19   |           | 2.4165    |           | 1.4937    |           |           |
| 20   |           |           |           | .2881     |           | .3919     |
| 21   |           | .3755     |           |           |           |           |
| 23   |           | .2449     |           |           |           |           |
| 24   | .2093     |           | .2123     | .1524     | 1.1203    |           |
| Max  | 2.0729    | 2.4818    | 2.4691    | 2.6257    | 2.4137    | 1.6615    |
| Min  | .1139     | .2449     | .1959     | .1524     | .1142     | .076      |
| Avg  | .4852     | 1.3797    | .9023     | 1.3790    | .6952     | .4680     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 203 / Nimbhere

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 2    |           |           | .3605     |           |           |           |
| 4    |           |           | .4096     |           |           |           |
| 6    |           |           | .6554     |           | 1.4746    |           |
| 7    |           |           |           |           | 1.9776    |           |
| 8    |           |           |           |           | 2.2062    |           |
| 9    |           |           |           |           | 2.982     | 2.1033    |
| 10   | .2103     |           |           | .3605     | .2949     |           |
| 11   | .192      |           |           | .2936     | .1966     |           |
| 12   | 1.893     |           |           | 3.1131    | .1475     |           |
| 13   | 1.8198    |           |           | 2.6216    | .1311     |           |
| 14   |           |           |           | 2.7854    | .1475     |           |
| 15   |           |           |           | 2.8182    | .1802     |           |
| 16   |           |           |           | 2.8607    |           | .213      |
| 17   | 2.8807    | 3.0511    | 2.6673    | 1.9776    | .1524     |           |
| 18   |           |           | 2.4844    | 2.0005    |           |           |
| 19   |           | 2.8509    |           | 1.7604    |           |           |
| 20   |           |           |           | .3772     |           | .5243     |
| 21   |           | .4915     |           |           |           |           |
| 23   |           | .3932     |           |           |           |           |
| 24   |           |           | .3605     | .3201     | 1.1088    |           |
| Max  | 2.8807    | 3.0511    | 2.6673    | 3.1131    | 2.982     | 2.1033    |
| Min  | .192      | .3932     | .3605     | .2936     | .1311     | .213      |
| Avg  | 1.3992    | 1.6967    | 1.1563    | 1.7741    | .9166     | .9469     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 204 / Kanadgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9755    |           |           |           |           |           |
| 2    | 1.9755    |           | 1.9731    |           |           |           |
| 3    | 1.9755    |           |           |           |           |           |
| 4    | 2.0879    |           | 2.0854    |           |           |           |
| 5    | 2.2806    |           |           |           |           |           |
| 6    | 2.6822    |           | 2.6629    |           | .2721     |           |
| 7    | 3.3888    |           |           |           | .2801     |           |
| 8    | 3.3728    |           | 3.449     | 3.5208    |           |           |
| 9    | 3.2407    |           |           | 3.2084    |           | .2376     |
| 10   | .2315     |           |           | .2406     | .2888     |           |
| 11   | .1852     |           |           | .1444     | .2085     |           |
| 12   | .1543     |           |           | .2085     | 3.2886    | 1.7286    |
| 13   |           |           |           | .1925     |           |           |
| 14   |           |           |           | .1604     | 3.2886    |           |
| 15   |           |           |           | .1604     | 3.3367    | 1.745     |
| 16   |           |           |           | .1925     |           | 2.9713    |
| 17   | .1829     | .2085     | .1981     | .112      | 1.9204    |           |
| 18   |           |           | .3048     | .128      |           |           |
| 19   |           | .5775     |           | .2721     |           |           |
| 20   |           |           |           | .2561     |           | .4497     |
| 21   |           | .5294     |           |           |           |           |
| 23   |           | .369      |           |           |           |           |
| 24   | 1.9755    |           | 1.9731    | 1.7375    | .16       |           |
| Max  | 3.3888    | .5775     | 3.449     | 3.5208    | 3.3367    | 2.9713    |
| Min  | .1543     | .2085     | .1981     | .112      | .16       | .2376     |
| Avg  | 1.8364    | .4211     | 1.8066    | .7524     | 1.4493    | 1.4264    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 206 / SHERAKHAWALI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0486     |           |           |           |           |           |
| 2    | .0486     |           | .0483     |           |           |           |
| 3    | .0486     |           |           |           |           |           |
| 4    | .0649     |           | .0644     |           |           |           |
| 5    | .0973     |           |           |           |           |           |
| 6    | .1459     |           | .1449     |           | .0716     |           |
| 7    | .1783     |           |           |           | .1075     |           |
| 8    |           |           | .2093     | .1829     | .1075     |           |
| 9    |           |           |           | .2429     | .2421     | .1578     |
| 10   | .1143     |           |           | .1943     | .2098     |           |
| 11   | .0953     |           |           | .1452     | .1775     |           |
| 12   | .0762     |           |           | .0968     | .113      | .0701     |
| 13   |           |           |           | .0968     |           |           |
| 14   |           |           |           | .0968     | .0968     |           |
| 15   |           |           |           | .9844     | .113      | .0613     |
| 16   |           |           |           | .0969     |           | .1128     |
| 17   | .1372     | .1771     | .1219     | .0716     | .0914     |           |
| 18   |           |           | .1677     | .0895     |           |           |
| 19   |           | .2898     |           | .1343     |           |           |
| 20   |           |           |           | .1075     |           | .2257     |
| 21   |           | .1771     |           |           |           |           |
| 23   |           | .1288     |           |           |           |           |
| 24   | .0649     |           | .0644     | .061      | .0448     |           |
| Max  | .1783     | .2898     | .2093     | .9844     | .2421     | .2257     |
| Min  | .0486     | .1288     | .0483     | .061      | .0448     | .0613     |
| Avg  | .0933     | .1932     | .1173     | .1858     | .125      | .1255     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 014139 / 33/11kv Satral substation

Feeder No / Name : 207 / MHASOBA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .184      |           |           |           |           |           |
| 2    | .184      |           | .1821     |           |           |           |
| 3    | .184      |           |           |           |           |           |
| 4    | .2209     |           | .2186     |           |           |           |
| 5    | .2761     |           |           |           |           |           |
| 6    | .3497     |           | .3278     |           | .2058     |           |
| 7    | .4417     |           |           |           | .2743     |           |
| 8    | .4601     |           | .4553     | .3658     | .2858     |           |
| 9    | .2515     |           |           | .3658     | .4024     | .2441     |
| 10   | .2389     |           |           | .3292     | .3658     |           |
| 11   | .2138     |           |           | .3109     | .3109     |           |
| 12   | 1.861     |           |           | .2926     | .1646     | .1511     |
| 13   |           |           |           | .2743     | .1646     |           |
| 14   |           |           |           | .2561     | .1829     |           |
| 15   |           |           |           | .2378     | .2012     | .1395     |
| 16   |           |           |           | .2561     | .2378     | .2743     |
| 17   | .2915     | .3096     | .2572     | .1943     | .2401     |           |
| 18   |           |           | .3258     | .2286     |           |           |
| 19   |           | .5282     |           | .3429     |           |           |
| 20   |           |           |           | .2858     |           | 4.5908    |
| 21   |           | .3643     |           |           |           |           |
| 23   |           | .255      |           |           |           |           |
| 24   | .2024     |           | .2004     | .1524     | .1372     |           |
| Max  | 1.861     | .5282     | .4553     | .3658     | .4024     | 4.5908    |
| Min  | .184      | .255      | .1821     | .1524     | .1372     | .1395     |
| Avg  | .3828     | .3643     | .2810     | .2780     | .2441     | 1.0800    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 201 / Project

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .0762     |
| Max  | .0762     |
| Min  | .0762     |
| Avg  | .0762     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 202 / Loni

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.5384    |
| Max  | 1.5384    |
| Min  | 1.5384    |
| Avg  | 1.5384    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 203 / Lohgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .5182     |
| Max  | .5182     |
| Min  | .5182     |
| Avg  | .5182     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 205 / Dadh

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2955    |
| Max  | 1.2955    |
| Min  | 1.2955    |
| Avg  | 1.2955    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 206 / Tambewadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.3717    |
| Max  | 1.3717    |
| Min  | 1.3717    |
| Avg  | 1.3717    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 207 / Tisgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2286     |
| Max  | .2286     |
| Min  | .2286     |
| Avg  | .2286     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 208 / Pimpri Nirmal

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.4937    |
| Max  | 1.4937    |
| Min  | 1.4937    |
| Avg  | 1.4937    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 209 / Rajuri

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.0974    |
| Max  | 1.0974    |
| Min  | 1.0974    |
| Avg  | 1.0974    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 211 / AMRUTESHWAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3353     |
| Max  | .3353     |
| Min  | .3353     |
| Avg  | .3353     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 212 / BIROBA GOATHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .4268     |
| Max  | .4268     |
| Min  | .4268     |
| Avg  | .4268     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 403 / 33 KV LONI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 4.2067    |
| Max  | 4.2067    |
| Min  | 4.2067    |
| Avg  | 4.2067    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

BABHALESHWAR S/DN.[840] BU 4840

Substation No/ Name :- 018003 / 220kv Babhaleshwar

Feeder No / Name : 404 / 33 KV PROJECT

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .0914     |
| Max  | .0914     |
| Min  | .0914     |
| Avg  | .0914     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014004 / 33/11 KV Pathare Sub-Station

Feeder No / Name : 201 / 11 KV Musalwadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | 1.1984    | 1.0883    | 1.1203    | 1.2346    |
| 8    | 1.3603    |           |           |           |
| 9    |           | 1.3603    | 1.4723    |           |
| 12   | .0829     |           |           |           |
| 23   |           | .0848     |           |           |
| Max  | 1.3603    | 1.3603    | 1.4723    | 1.2346    |
| Min  | .0829     | .0848     | 1.1203    | 1.2346    |
| Avg  | .8805     | .8445     | 1.2963    | 1.2346    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014004 / 33/11 KV Pathare Sub-Station

Feeder No / Name : 202 / 11 KV Tilapur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .081      | .081      | .081      | .124      |
| 8    | .08       |           |           |           |
| 9    |           |           | .096      |           |
| 12   | 3.7289    |           |           |           |
| 13   |           | 3.5208    |           |           |
| 14   |           |           | 3.6488    |           |
| 16   | 3.5688    |           |           |           |
| 19   | 3.3768    |           | 3.2808    |           |
| 23   |           | .0848     |           |           |
| Max  | 3.7289    | 3.5208    | 3.6488    | .124      |
| Min  | .08       | .081      | .081      | .124      |
| Avg  | 2.1671    | 1.2289    | 1.7767    | .124      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014004 / 33/11 KV Pathare Sub-Station

Feeder No / Name : 203 / 11 KV Manjari A

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 4    | .1134     | .128      |
| 8    | .128      |           |
| 12   | 3.0361    |           |
| 13   |           | 3.0407    |
| 16   | 3.3288    | 2.7206    |
| 19   | 2.6566    | 2.4806    |
| Max  | 3.3288    | 3.0407    |
| Min  | .1134     | .128      |
| Avg  | 1.8526    | 2.0925    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014004 / 33/11 KV Pathare Sub-Station

Feeder No / Name : 204 / 11 KV Manjari B

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 4    | 1.1523    | 1.0242    |
| 9    | 1.3603    | 1.6263    |
| 12   | .016      |           |
| 19   |           | .0497     |
| 20   | .032      |           |
| Max  | 1.3603    | 1.6263    |
| Min  | .016      | .0497     |
| Avg  | .6402     | .9001     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014004 / 33/11 KV Pathare Sub-Station

Feeder No / Name : 205 / 11 KV Mahaduk Centre

GAOTHAN FEEDER

Gaonthan Feeder KV- 11 /  
OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .2172     | .1663     | .1478     | .2126     |
| 7    | .3045     | .2772     |           |           |
| 12   | .1791     | .1848     | .2218     |           |
| 16   | .1629     |           | .1478     |           |
| 19   |           | .2587     |           |           |
| 20   | .2507     |           |           |           |
| 21   |           |           | .2587     |           |
| 23   | .1433     | .1478     |           |           |
| Max  | .3045     | .2772     | .2587     | .2126     |
| Min  | .1433     | .1478     | .1478     | .2126     |
| Avg  | .2096     | .2070     | .1940     | .2126     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014004 / 33/11 KV Pathare Sub-Station

Feeder No / Name : 206 / 11 KV Manjari Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .4435     | .3696     |           | .4835     |
| 7    |           | .6154     | .5729     |           |
| 12   | .3439     |           |           |           |
| 13   |           |           | .4066     |           |
| 16   | .3258     | .3077     |           |           |
| 19   | .5552     | .5729     |           |           |
| 20   |           |           | .6154     |           |
| 23   |           |           | .4251     |           |
| 24   |           |           | .3142     |           |
| Max  | .5552     | .6154     | .6154     | .4835     |
| Min  | .3258     | .3077     | .3142     | .4835     |
| Avg  | .4171     | .4664     | .4668     | .4835     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014004 / 33/11 KV Pathare Sub-Station

Feeder No / Name : 207 / 11 KV Pathare AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 4    | .081      | .1296     | .0972     | .124      |
| 8    | .1134     |           |           |           |
| 12   | 3.0152    |           | 3.1047    |           |
| 13   |           | 3.0407    |           |           |
| 14   | 3.4682    |           |           |           |
| 15   |           |           | 3.2007    |           |
| 16   |           | 3.1527    |           |           |
| 19   | 3.0567    | 2.9927    | 2.8327    |           |
| 23   |           |           | .1134     |           |
| Max  | 3.4682    | 3.1527    | 3.2007    | .124      |
| Min  | .081      | .1296     | .0972     | .124      |
| Avg  | 1.9469    | 2.3289    | 1.8697    | .124      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 201 / 11 KV Papermill Feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .1372     | .12       | .1029     | .1387     | .1372     | .1372     |           |
| 9    |           |           |           |           |           | .1372     | .1715     |
| 11   |           |           |           |           |           | .1886     | .1886     |
| 14   | .2229     | .1543     | .1372     | .1387     | .2058     |           |           |
| 18   | .1372     | .1387     | .0857     | .1029     | .1543     |           |           |
| 23   |           |           |           |           |           | .1543     | .1543     |
| 24   |           |           |           |           |           | .1372     |           |
| Max  | .2229     | .1543     | .1372     | .1387     | .2058     | .1886     | .1886     |
| Min  | .1372     | .12       | .0857     | .1029     | .1372     | .1372     | .1543     |
| Avg  | .1658     | .1377     | .1086     | .1268     | .1658     | .1509     | .1715     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 202 / 11 KV Morwadi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .2743     | .2743     | .2915     | .3052     | .2915     |           |           |
| 9    |           |           |           |           |           | 1.1065    | 1.3413    |
| 11   |           |           |           |           |           | .156      | .1543     |
| 14   | 1.7736    | 1.7101    | 1.7147    | 1.7604    | 1.7295    |           |           |
| 18   | 1.5927    | 1.4089    | 1.6804    | 1.1065    | 1.5089    |           |           |
| 23   |           |           |           |           |           | .12       | .1715     |
| Max  | 1.7736    | 1.7101    | 1.7147    | 1.7604    | 1.7295    | 1.1065    | 1.3413    |
| Min  | .2743     | .2743     | .2915     | .3052     | .2915     | .12       | .1543     |
| Avg  | 1.2135    | 1.1311    | 1.2289    | 1.0574    | 1.1766    | .4608     | .5557     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
Station

Feeder No / Name : 203 / 11 KV Kangar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           |           |           |           |           | .4458     | .4115     |
| 9    | .0514     | 2.7515    | 3.1161    | .2743     | 2.6993    |           |           |
| 11   | .0686     | .1886     | .2818     | .0343     | .2229     |           |           |
| 14   |           |           |           |           |           |           | 2.8178    |
| 18   |           |           |           |           |           | 3.3482    | 1.2239    |
| 23   | .2743     | .2401     | .3086     | .2915     | .2915     |           |           |
| Max  | .2743     | 2.7515    | 3.1161    | .2915     | 2.6993    | 3.3482    | 2.8178    |
| Min  | .0514     | .1886     | .2818     | .0343     | .2229     | .4458     | .4115     |
| Avg  | .1314     | 1.0601    | 1.2355    | .2000     | 1.0712    | 1.897     | 1.4844    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 204 / 11 KV Deolali  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .3086     | .3258     | .3086     | .3258     | .3429     |           |           |
| 9    |           |           |           |           |           | 1.5089    | 1.576     |
| 11   |           | .3601     |           |           |           |           |           |
| 14   | 1.9281    |           | 2.0233    | 1.7939    | 1.8778    |           |           |
| 18   | 1.7436    |           | 1.6804    | 1.5927    | 1.7269    |           |           |
| 23   |           | .3086     |           |           |           |           | .2743     |
| Max  | 1.9281    | .3601     | 2.0233    | 1.7939    | 1.8778    | 1.5089    | 1.576     |
| Min  | .3086     | .3086     | .3086     | .3258     | .3429     | 1.5089    | .2743     |
| Avg  | 1.3268    | .3315     | 1.3374    | 1.2375    | 1.3159    | 1.5089    | .9252     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 206 / 11 KV DEOLALI-PRAVARA (G)  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .7202     | .8059     | .763      | .8059     | .7545     |           |           |
| 9    |           |           |           |           |           | .7545     | .9088     |
| 11   |           |           |           |           |           | .6859     | .7202     |
| 14   | .5658     | .5144     | .5487     | .4973     | .4973     |           |           |
| 18   | .6516     | .6068     | .6173     | .6001     | .6344     |           |           |
| 23   |           |           |           |           |           | .4115     | .5895     |
| Max  | .7202     | .8059     | .763      | .8059     | .7545     | .7545     | .9088     |
| Min  | .5658     | .5144     | .5487     | .4973     | .4973     | .4115     | .5895     |
| Avg  | .6459     | .6424     | .643      | .6344     | .6287     | .6173     | .7395     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 207 / 11 KV RAHURY FACTORY (G)  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .7975     | .7202     | .7969     | .8745     | .7716     |           |           |
| 9    |           |           |           |           |           | 1.0117    | .9259     |
| 11   |           |           |           |           |           | .7888     | .8059     |
| 14   | .703      | .6133     | .6859     | .7373     | .7122     |           |           |
| 18   | .7716     | .763      | .823      | .8059     | .763      |           |           |
| 23   |           |           |           |           |           | .463      | .7628     |
| Max  | .7975     | .763      | .823      | .8745     | .7716     | 1.0117    | .9259     |
| Min  | .703      | .6133     | .6859     | .7373     | .7122     | .463      | .7628     |
| Avg  | .7574     | .6988     | .7686     | .8059     | .7489     | .7545     | .8315     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014134 / 33 /11 KV Deolali Sub-  
StationFeeder No / Name : 208 / 11 KV AMBIKA(DEOLALI SEPARATED AG FEEDERS HAVING SPECIAL  
BANGALA) Feeder KV- 11 / DESIGN TRANSFORMER  
OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    |           | 1.6409    |           |           |           | .3086     | .3944     |
| 9    | 1.6078    | 1.6409    | 1.6575    | 1.5261    | 1.4754    |           |           |
| 14   |           |           |           |           |           | 1.576     | 1.873     |
| 18   |           |           |           |           |           | 1.7269    | 1.8233    |
| 23   |           | .2743     |           |           |           |           |           |
| 24   |           | 1.6409    |           |           |           |           |           |
| Max  | 1.6078    | 1.6409    | 1.6575    | 1.5261    | 1.4754    | 1.7269    | 1.873     |
| Min  | 1.6078    | .2743     | 1.6575    | 1.5261    | 1.4754    | .3086     | .3944     |
| Avg  | 1.6078    | 1.2993    | 1.6575    | 1.5261    | 1.4754    | 1.2038    | 1.3636    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014136 / 33 /11 KV Tharabad

Feeder No / Name : 201 / 11 KV Daradgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 02-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .0949     |
| Max  | .0949     |
| Min  | .0949     |
| Avg  | .0949     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014136 / 33 /11 KV Tharabad

Feeder No / Name : 202 / 11 KV Mahisgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | 1.3923    | 1.5203    | 1.4842    | 1.1717    | 1.531     | 1.2498    |
| Max  | 1.3923    | 1.5203    | 1.4842    | 1.1717    | 1.531     | 1.2498    |
| Min  | 1.3923    | 1.5203    | 1.4842    | 1.1717    | 1.531     | 1.2498    |
| Avg  | 1.3923    | 1.5203    | 1.4842    | 1.1717    | 1.531     | 1.2498    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014136 / 33 /11 KV Tharabad

Feeder No / Name : 203 / 11 KV TAHARABAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | 1.0623    | 1.1561    | 1.1431    | 1.0084    | .1219     | .1852     |
| Max  | 1.0623    | 1.1561    | 1.1431    | 1.0084    | .1219     | .1852     |
| Min  | 1.0623    | 1.1561    | 1.1431    | 1.0084    | .1219     | .1852     |
| Avg  | 1.0623    | 1.1561    | 1.1431    | 1.0084    | .1219     | .1852     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014136 / 33 /11 KV Tharabad

Feeder No / Name : 204 / GFSS TAHARABAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24   | .08       | .0937     | .0949     | .0772     | .0937     | .0937     |
| Max  | .08       | .0937     | .0949     | .0772     | .0937     | .0937     |
| Min  | .08       | .0937     | .0949     | .0772     | .0937     | .0937     |
| Avg  | .08       | .0937     | .0949     | .0772     | .0937     | .0937     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 201 / 11 KV Ambi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .144      |
| 2    |           |           |           | .144      |
| 3    |           |           |           | .144      |
| 4    |           |           |           | .144      |
| 5    |           |           |           | .16       |
| 6    |           |           |           | .192      |
| 7    |           |           |           | .2241     |
| 8    | 2.0165    | 2.2245    | 2.0805    | .2401     |
| 9    | 2.0805    | 2.0485    | 2.0005    | .208      |
| 10   | .208      | .192      | .2561     | .192      |
| 11   | .144      | .192      | .1923     | .192      |
| 12   | .112      | .096      | .16       | 2.6886    |
| 13   | .096      | .096      | .112      | 2.6566    |
| 14   | .096      | .096      | .112      | 2.6406    |
| 15   | .096      | .096      | .112      | 2.6246    |
| 16   | .096      | .112      | .112      | 2.4806    |
| 17   | .112      |           |           | 2.3365    |
| 18   | .112      |           |           | 2.2245    |
| 19   |           |           |           | 2.0965    |
| 24   | 1.6804    | 1.7604    |           | .16       |
| Max  | 2.0805    | 2.2245    | 2.0805    | 2.6886    |
| Min  | .096      | .096      | .112      | .144      |
| Avg  | .5708     | .6913     | .5708     | 1.0946    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 202 / 11 KV Ganeshwadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | 1.2651    |
| 2    |           |           |           | 1.2651    |
| 3    |           |           |           | 1.2651    |
| 4    |           |           |           | 1.2651    |
| 5    |           |           |           | 1.5023    |
| 6    |           |           |           | 1.6604    |
| 7    |           |           |           | 1.8185    |
| 8    | .3479     | .3163     | .3163     | 2.2138    |
| 9    | .3163     | .2846     | .2688     | 2.0557    |
| 10   | .2372     | .1581     | .2214     | .2241     |
| 11   | .1423     | .1265     | .1581     | .1898     |
| 12   | 2.0715    | 2.0005    | 2.0083    | .1581     |
| 13   | 1.9608    | 1.8185    | 1.9292    | .1265     |
| 14   | 1.9134    | 1.7394    | 1.8976    | .1116     |
| 15   | 1.8818    | 1.8185    | 1.8818    | .1107     |
| 16   | 1.8501    | 1.8185    | 1.8501    |           |
| 17   | 1.8343    |           |           | .1107     |
| 18   | 1.7711    |           |           |           |
| 19   |           |           |           | .2217     |
| 24   | .1581     | .1423     |           | 1.2651    |
| Max  | 2.0715    | 2.0005    | 2.0083    | 2.2138    |
| Min  | .1423     | .1265     | .1581     | .1107     |
| Avg  | 1.2071    | 1.0223    | 1.1702    | .9350     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 203 / 11 KV Wakanphata

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | 1.2003    |
| 2    |           |           |           | 1.2003    |
| 3    |           |           |           | 1.2003    |
| 4    |           |           |           | 1.2003    |
| 5    |           |           |           | 1.2803    |
| 6    |           |           |           | 1.4403    |
| 7    |           |           |           | 1.6004    |
| 8    | .3201     | .3201     | .3369     | 1.6004    |
| 9    | .2401     | .3201     | .2721     |           |
| 10   | .2401     | .192      | .2241     | .048      |
| 11   | .176      | .128      | .16       | .048      |
| 12   | 1.9685    | 1.7604    | 1.8084    | .048      |
| 13   | 1.7924    | 1.8404    | 1.6804    | .112      |
| 14   | 1.7284    | 1.6804    | 1.6324    | .096      |
| 15   | 1.6164    | 1.6004    | 1.5524    | .08       |
| 16   | 1.5524    | 1.6004    | 1.4723    | .112      |
| 17   | 1.6164    |           |           | .128      |
| 18   | 1.6164    |           |           | .176      |
| 19   |           |           |           | .2401     |
| 24   | .176      | .128      |           | 1.2003    |
| Max  | 1.9685    | 1.8404    | 1.8084    | 1.6004    |
| Min  | .176      | .128      | .16       | .048      |
| Avg  | 1.0869    | .9570     | 1.0154    | .6848     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 204 / 11 KV KARANJGAON AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .1526     |
| 2    |           |           |           | .1526     |
| 3    |           |           |           | .1526     |
| 4    |           |           |           | .1526     |
| 5    |           |           |           | .1696     |
| 6    |           |           |           | .2713     |
| 7    |           |           |           | .3222     |
| 8    | 2.6621    | 2.8317    | 2.6282    | .2883     |
| 9    | 2.713     | 2.4417    | 2.3739    | .2204     |
| 10   | .2374     | .2035     | .2713     | .2035     |
| 11   | .1526     | .1696     | .1865     | .1865     |
| 12   | .1357     | .1357     | .1526     | 3.086     |
| 13   | .0848     | .1187     | .1357     | 3.0521    |
| 14   | .0848     | .0848     | .1187     | 3.0013    |
| 15   | .1017     | .1017     | .1017     | 2.9504    |
| 16   | .1017     | .1187     | .0848     | 2.8487    |
| 17   | .1017     |           |           | 2.7469    |
| 18   | .1187     |           |           | 2.6282    |
| 19   |           |           |           | 2.1365    |
| 24   | 2.2891    | 2.2552    |           | .1526     |
| Max  | 2.713     | 2.8317    | 2.6282    | 3.086     |
| Min  | .0848     | .0848     | .0848     | .1526     |
| Avg  | .7319     | .8461     | .6726     | 1.2437    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 205 / Dawangaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .0526     |
| 2    |           |           |           | .0526     |
| 3    |           |           |           | .0526     |
| 4    |           |           |           | .0526     |
| 5    |           |           |           | .0876     |
| 6    |           |           |           | .1052     |
| 7    |           |           |           | .1052     |
| 8    | .1227     | .0876     | .0876     | .1052     |
| 9    | .1052     | .1052     | .0876     | .1052     |
| 10   | .1052     | .1052     | .0701     | .0876     |
| 11   | .1052     | .0526     | .0526     |           |
| 12   | .0526     | .0351     | .0526     | .0526     |
| 13   | .0526     | .0351     | .0526     |           |
| 14   | .0351     | .0351     | .0526     | .0526     |
| 15   | .0351     | .0351     | .0526     | .0526     |
| 16   |           | .0351     | .0526     | .0526     |
| 17   | .0876     |           |           | .0526     |
| 18   | .0526     |           |           | .0701     |
| 19   |           |           |           | .1052     |
| 24   | .0526     | .0526     |           | .0526     |
| Max  | .1227     | .1052     | .0876     | .1052     |
| Min  | .0351     | .0351     | .0526     | .0526     |
| Avg  | .0733     | .0579     | .0623     | .0721     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014142 / 33/11 KV Ambi Sub-Station

Feeder No / Name : 206 / Karajgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           | .0554     |
| 2    |           |           |           | .0554     |
| 3    |           |           |           | .0554     |
| 4    |           |           |           | .0554     |
| 5    |           |           |           | .0739     |
| 6    |           |           |           | .1478     |
| 7    |           |           |           | .1848     |
| 8    | .1848     | .1848     | .1848     | .1663     |
| 9    | .1848     | .1478     | .1478     | .168      |
| 10   | .1663     | .1294     | .1109     | .1294     |
| 11   | .1478     | .0924     | .0739     | .0924     |
| 12   | .1294     | .0739     | .0739     |           |
| 13   | .0739     | .0739     | .0739     | .0924     |
| 14   | .0739     |           | .0739     |           |
| 15   | .0739     | .0739     | .0739     | .0739     |
| 16   | .0739     | .0924     | .0924     |           |
| 17   | .1109     |           |           | .0739     |
| 18   | .1109     |           |           | .0739     |
| 19   |           |           |           | .1109     |
| 24   | .0739     | .0554     |           | .0554     |
| Max  | .1848     | .1848     | .1848     | .1848     |
| Min  | .0739     | .0554     | .0739     | .0554     |
| Avg  | .1170     | .1027     | .1006     | .0979     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014144 / 33 / 11 KV Talkalimiya

Feeder No / Name : 201 / 11 KV Talkalimiya

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9846     | .9808     | .945      | .9783     | .9511     | .061      | .061      |
| 2    | .9846     | .9808     | .945      | .9065     | .9633     | .061      | .0648     |
| 3    | .9991     | 1.0235    | 1.0031    | .8802     | .9907     | .0617     | .0648     |
| 4    | .9991     | 1.0536    | 1.0936    | .8655     | 1.0059    | .0838     | .0857     |
| 5    | 1.0709    | 1.0974    | 1.1728    | .9362     | 1.0802    | .124      | .1075     |
| 6    | 1.189     | 1.1431    | 1.1888    | 1.1149    | 1.2498    | .128      | .1075     |
| 7    | 1.3245    | 1.3117    | 1.2631    | 1.4506    | 1.3279    | .1612     | .1448     |
| 8    | 1.4022    | 1.5278    | 1.3146    | 1.5466    | 1.3413    | .1612     | .1629     |
| 9    | 1.2887    | 1.5089    | 1.3443    | 1.387     | 1.286     | .0914     | .1252     |
| 10   | .0806     | .0737     | .0972     | .0874     | .101      | .0737     | .0895     |
| 11   | .0533     | .0507     | .0686     | .056      | .061      | .0518     | .0793     |
| 12   | .064      | .0343     | .061      | .0381     | .052      | 1.4937    | 1.4998    |
| 13   | .0671     | .0366     | .0406     | .0442     | .0474     | 1.5242    | 1.4861    |
| 14   | .0497     | .0372     | .0377     | .0396     | .0366     | 1.4784    | 1.6204    |
| 15   | .0486     | .0377     | .0383     | .0465     | .0349     | 1.4815    | 1.4815    |
| 16   | .0463     | .0377     | .0383     | .0511     | .04       | 1.5123    | 1.5123    |
| 17   | .0594     | .0526     | .0476     | .0572     | .0349     | 1.3717    | 1.4148    |
| 18   | .0465     | .0743     | .0543     | .0606     | .0686     | 1.2146    | 1.3289    |
| 19   | .0947     | .1094     | .1094     | .0667     | .1115     | 1.1831    | 1.1984    |
| 20   | .12       | .0762     | .1162     | .0953     | .1162     | .1048     | .1067     |
| 21   | .0909     | .101      | .1048     | .0914     | .0876     | .0876     | .0819     |
| 22   | .0667     | .0895     | .0934     | .0701     | .0876     | .0857     | .0686     |
| 23   | .0537     | .0747     | .0655     | .06       | .0867     | .0667     | .06       |
| 24   | .9991     | .9659     | .945      | 1.0385    | .9511     | .0602     | .0594     |
| Max  | 1.4022    | 1.5278    | 1.3443    | 1.5466    | 1.3413    | 1.5242    | 1.6204    |
| Min  | .0463     | .0343     | .0377     | .0381     | .0349     | .0518     | .0594     |
| Avg  | .5076     | .5200     | .5078     | .4987     | .5047     | .5301     | .5422     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014144 / 33 / 11 KV Talkalimiya

Feeder No / Name : 202 / 11 KV Lakh  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.5623    | 1.6604    | 1.4899    | 1.6129    | 1.5935    | .132      | .132      |
| 2    | 1.5432    | 1.6604    | 1.5074    | 1.5466    | 1.5432    | .132      | .132      |
| 3    | 1.5278    | 1.7124    | 1.5061    | 1.531     | 1.5432    |           | .132      |
| 4    | 1.5394    | 1.7284    | 1.4864    | 1.4969    | 1.6248    | .132      | .132      |
| 5    | 1.6204    | .176      | 1.5023    | 1.5466    | 1.7185    | .1509     | .1509     |
| 6    | 1.7553    | 1.8461    | 1.5023    | 1.6358    | 1.8884    | .1886     | .2075     |
| 7    | 1.9766    | 2.0243    | 2.1862    | 2.0081    | 1.9524    | .2452     | .2263     |
| 8    | 2.1765    | 2.3158    | 2.0309    | 2.1862    | 2.0729    | .1886     | .2096     |
| 9    | 2.1664    | 2.0153    | 1.9528    | 2.1376    | 2.0557    | .1509     | .1524     |
| 10   | .1509     | .132      | .1509     | .1509     | .1886     | .1509     | .132      |
| 11   | .0377     | .0943     | .1509     |           | .132      | .1132     | .0943     |
| 12   | .0377     | .0377     | .0566     | .0566     | .0377     | 2.1506    | 2.2348    |
| 13   | .0191     | .0377     | .0381     | .0566     | .0381     | 2.2245    | 2.2297    |
| 14   | .0191     | .0381     | .0381     | .0377     | .0381     | 2.2297    | 2.2725    |
| 15   | .0191     |           | .0377     | .0572     | .0377     | 2.2672    | 2.2565    |
| 16   | .0191     | .0381     | .056      | .0572     | .0381     | 2.3967    | 2.2565    |
| 17   | .0381     | .0953     | .056      | .0572     | .0377     | 2.2405    | 2.2138    |
| 18   | .0381     | .0953     | .056      | .0191     | .0747     | .5468     | 2.0988    |
| 19   | .1886     | .2075     | .2054     | .1715     | .1886     | 2.0062    | 1.9372    |
| 20   | .1886     | .1886     | .1886     | .1886     | .2075     | .2075     | .2263     |
| 21   | .1886     | .1698     | .1698     | .1698     | .2075     | .1886     | .1886     |
| 22   | .1509     | .1509     | .1509     | .1509     | .1698     | .1698     | .1698     |
| 23   | .132      | .132      | .132      | .132      | .132      | .132      | .1509     |
| 24   | 1.5623    | 1.6288    | 1.4899    | 1.6446    | 1.6324    | .132      | .132      |
| Max  | 2.1765    | 2.3158    | 2.1862    | 2.1862    | 2.0729    | 2.3967    | 2.2725    |
| Min  | .0191     | .0377     | .0377     | .0191     | .0377     | .1132     | .0943     |
| Avg  | .7774     | .7907     | .7559     | .8109     | .7980     | .8033     | .8362     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014144 / 33 / 11 KV Talkalimiya

Feeder No / Name : 203 / 11 KV TAKALIMIYA GAVATHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2507     | .2507     | .2743     | .2715     | .2715     | .2658     | .2686     |
| 2    | .2534     | .2534     | .2743     | .2743     | .2801     | .2715     | .2689     |
| 3    | .2534     | .2743     | .2772     | .2743     | .2801     | .2926     | .2715     |
| 4    | .3109     | .3109     | .3326     | .3142     | .3292     | .3292     | .3475     |
| 5    | .3881     | .462      | .4854     | .4481     | .462      | .4481     | .4572     |
| 6    | .6979     | .6908     | .6908     | .6722     | .6908     | .6979     | .8589     |
| 7    | .9242     | .8589     | .8688     | .9149     | .8962     | .8402     | .8589     |
| 8    | .8402     | .7468     | .7343     | .8402     | .8764     | .8402     | .8775     |
| 9    | .7602     | .7265     | .8238     | .7682     | .8309     | .7468     | .8421     |
| 10   | .6203     | .5201     | .5506     | .5256     | .6316     | .5556     | .5944     |
| 11   | .5533     | .4534     | .4999     | .5256     | .5571     | .4816     | .4843     |
| 12   | .5014     | .4382     | .443      | .463      | .4887     | .3856     | .407      |
| 13   | .4477     | .3898     | .3898     | .4458     | .443      | .373      | .3932     |
| 14   | .4344     | .4031     | .4382     | .373      | .4075     | .3856     | .3944     |
| 15   | .4525     | .3814     | .3988     | .3814     | .3856     | .3772     | .39       |
| 16   | .4784     | .4031     | .3988     | .3988     | .4382     | .4161     | .3772     |
| 17   | .5138     | .5548     | .4694     | .4458     | .4334     | .4334     | .4694     |
| 18   | .463      | .6135     | .5868     | .5138     | .4973     | .4681     | .5138     |
| 19   | .7011     | .6733     | .691      | .7545     | .6962     |           | .6556     |
| 20   | .6001     | .5316     | .5967     | .5365     | .5898     | .5182     | .5596     |
| 21   | .502      | .4062     | .4902     | .426      | .4725     | .4268     | .506      |
| 22   | .4161     | .3572     | .3961     | .3239     | .4108     | .3814     | .4001     |
| 23   | .2915     | .3041     | .3161     | .3437     | .3149     | .2949     | .3286     |
| 24   | .2507     | .2534     | .2715     |           | .2686     | .2835     | .2804     |
| Max  | .9242     | .8589     | .8688     | .9149     | .8962     | .8402     | .8775     |
| Min  | .2507     | .2507     | .2715     | .2715     | .2686     | .2658     | .2686     |
| Avg  | .4961     | .4691     | .4874     | .4885     | .4980     | .4571     | .4919     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI FACTORY S/DN.[841] BU 4841

Substation No/ Name :- 014144 / 33 / 11 KV Talkalimiya

Feeder No / Name : 204 / 11 KV JATAP AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0886     | .0895     | .0905     | .1063     | .1052     | .9659     | .8916     |
| 2    | .0886     | .1086     | .0905     | .1075     | .1063     | .9659     | .9145     |
| 3    | .0886     | .1086     | .0914     | .1075     | .1063     | 1.0084    | .9145     |
| 4    | .0886     | .1097     | .0914     | .1075     | .1227     | 1.0364    | .9755     |
| 5    | .1086     | .1307     | .1097     |           | .1433     | 1.0669    | 1.0802    |
| 6    | .1494     | .1494     | .1494     |           | .1646     | 1.1111    | 1.142     |
| 7    | .2054     | .2054     | .1829     |           | .2054     | 1.3272    | 1.4043    |
| 8    | .168      | .1867     | .1829     |           | .2378     | 1.5123    | 1.5623    |
| 9    | .1848     | .1389     | .1991     |           | .2353     | 1.4861    | 1.3575    |
| 10   | .132      | .1067     | .1372     |           | .1315     | .0943     | .1143     |
| 11   | .1014     | .0709     | .0827     | .1        | .1052     | .0774     | .0709     |
| 12   | 1.7966    | 1.906     | 1.8244    | 1.8747    | 1.7976    | .0686     | .052      |
| 13   | 1.8976    | 2.0005    | 1.8185    | 1.8591    | 1.6446    | .0838     | .064      |
| 14   | 1.9919    | 2.0081    | 1.8185    | 1.768     | 1.656     | .0633     | .0857     |
| 15   | 1.9757    | 1.9524    | 1.7654    | 1.821     | 1.5586    | .0848     | .0829     |
| 16   | 1.9433    | 1.9292    | 1.7497    | 1.6857    | 1.5779    | .1029     | .0838     |
| 17   | 1.917     | 1.7985    | 1.7223    | 1.5804    | 1.5089    | .0867     | .0663     |
| 18   | 1.6975    | 1.4575    | 1.5653    | 1.4817    | 1.448     | .0886     | .08       |
| 19   | 1.4914    | 1.467     | 1.2176    | 1.2631    | 1.3203    | .1677     | .1254     |
| 20   | .1551     | .16       | .1614     | .16       | .1429     | .16       | .1429     |
| 21   | .141      | .1467     | .1467     | .1467     | .1143     | .1238     | .1238     |
| 22   | .1113     | .12       | .1181     | .1238     | .1048     | .1029     | .1181     |
| 23   | .1067     | .0991     | .1006     | .1063     | .0987     | .1082     | .1012     |
| 24   | .1063     | .0895     | .0905     | .1063     | .1052     | .9389     | .8573     |
| Max  | 1.9919    | 2.0081    | 1.8244    | 1.8747    | 1.7976    | 1.5123    | 1.5623    |
| Min  | .0886     | .0709     | .0827     | .1        | .0987     | .0633     | .052      |
| Avg  | .6973     | .6892     | .6461     | .8059     | .6142     | .5347     | .5171     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 201 / 11 KV Khadamba

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 4    | 1.8898    |
| 8    | 3.3951    |
| 9    | 3.0687    |
| 24   | 1.4582    |
| Max  | 3.3951    |
| Min  | 1.4582    |
| Avg  | 2.4530    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 204 / 11 KV Gunjale

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 4    | 1.1568    |
| 8    | 1.9281    |
| 9    | 1.7878    |
| 24   | .7545     |
| Max  | 1.9281    |
| Min  | .7545     |
| Avg  | 1.4068    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 205 / Gunjale GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 4    | .6653     |
| 8    | .8779     |
| 9    | .9511     |
| 24   | .5228     |
| Max  | .9511     |
| Min  | .5228     |
| Avg  | .7543     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 206 / Kukkadvedhe GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 4    | .2587     |
| 8    | .4024     |
| 9    | .4525     |
| 24   | .2195     |
| Max  | .4525     |
| Min  | .2195     |
| Avg  | .3333     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 207 / Morewadi Ag

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 4    | .2572     |           |           |
| 8    | .4161     |           |           |
| 9    | .3601     |           |           |
| 10   |           |           | .2591     |
| 24   | .1932     | 1.0288    |           |
| Max  | .4161     | 1.0288    | .2591     |
| Min  | .1932     | 1.0288    | .2591     |
| Avg  | .3067     | 1.0288    | .2591     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 208 / Katrad Ag

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 4    | 1.3321    |           |
| 8    | 2.7778    |           |
| 9    | 2.5377    |           |
| 24   | .9602     | .3772     |
| Max  | 2.7778    | .3772     |
| Min  | .9602     | .3772     |
| Avg  | 1.9020    | .3772     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014133 / 33/11 KV Vambori S/S

Feeder No / Name : 209 / 11 Kv Gorakshanath LIS PURELY LIS FEEDERS  
Satge Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 4    | .0373     |
| 8    | .0754     |
| 9    | .0747     |
| Max  | .0754     |
| Min  | .0373     |
| Avg  | .0625     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 201 / Mokalohal

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1928     | .1991     | .2149     | .1928     | .1991     | .9335     | 1.5779    |
| 2    | .1928     | .1991     | .2149     | .1928     | .1991     | 1.0669    |           |
| 3    | .1991     | .1991     |           | .1949     | .1991     | 1.0669    |           |
| 4    | .1991     | .2195     |           | .1991     | .2957     | 1.0669    |           |
| 5    | .2743     | .2957     |           | .2926     |           | 1.0822    |           |
| 6    | .3547     | .4108     |           | .4294     |           |           |           |
| 7    |           | .4715     |           | .4904     |           | 1.5242    |           |
| 8    | .4338     | .4715     | .4338     | .4481     | .4287     | 1.829     | 2.2862    |
| 9    | .1698     | .3814     | .39       | .39       | .3658     | 1.8138    |           |
| 10   | .2591     | .2343     | .2439     | .2343     |           | .2591     |           |
| 11   | .1806     | .2134     | .1974     |           |           | .2202     |           |
| 12   | 2.2138    | 2.2024    | 2.2565    |           | 1.9662    | .12       |           |
| 13   | 2.3158    | 2.4129    | 2.4006    |           | 2.0271    |           |           |
| 14   | 2.3158    | 2.2405    | 2.3482    |           |           | .12       |           |
| 15   | 2.2245    | 2.1445    | 2.119     |           |           |           |           |
| 16   | 1.9919    | 2.1925    | 2.1925    | 1.9444    | 1.89      |           |           |
| 17   | 1.9925    | 2.119     | 2.1125    | 2.0083    | 1.8747    |           |           |
| 18   | 1.7497    | 1.8747    | 1.9841    | 1.713     | 1.7071    |           |           |
| 19   | 1.5009    | 1.2342    | 1.6091    | 1.3523    |           |           |           |
| 20   | .2439     | .2915     |           | .2846     | .2591     |           |           |
| 21   |           | .2591     |           | .2753     |           |           |           |
| 22   | .2107     | .2286     |           | .2561     |           |           |           |
| 23   |           | .2229     |           | .2372     |           |           |           |
| 24   | .1928     | .197      | .2126     | .1928     | .2172     | .9335     | 1.5278    |
| Max  | 2.3158    | 2.4129    | 2.4006    | 2.0083    | 2.0271    | 1.829     | 2.2862    |
| Min  | .1698     | .197      | .1974     | .1928     | .1991     | .12       | 1.5278    |
| Avg  | .9242     | .8715     | 1.262     | .5962     | .8945     | .9259     | 1.7973    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 202 / Umbre

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.595     | 1.8004    | 1.9765    | 1.8778    | 1.9938    | .2058     | .1187     |
| 2    | 1.6126    | 1.8004    | 1.9547    | 1.8778    | 1.9938    | .2058     |           |
| 3    | 1.6126    | 1.8004    |           | 1.9204    | 1.9719    | .2058     |           |
| 4    | 1.6126    | 1.8204    |           | 1.9204    | 1.9719    | .2058     |           |
| 5    | 1.8204    | 2.0157    |           | 2.0458    | 2.0233    | .2172     |           |
| 6    | 2.1152    | 2.3137    |           | 2.2291    |           |           |           |
| 7    | 2.4792    | 2.5591    |           | 2.6006    |           | .2572     |           |
| 8    | 2.7913    |           | 2.8086    | 2.8607    | 2.8978    | .2743     | .3086     |
| 9    | 2.5659    | 2.4813    | 2.6406    | 2.4646    | 2.2862    | .2743     |           |
| 10   | .1947     | .2115     | .168      | .2258     |           | .16       |           |
| 11   | .1509     | .1947     | .161      |           |           | .1715     |           |
| 12   | .0335     | .1086     | .0701     |           | .1029     | 2.915     |           |
| 13   | .0838     | .1097     | .104      |           | .1029     |           |           |
| 14   |           | .1017     | .12       |           |           | 3.2236    |           |
| 15   |           | .112      | .12       |           |           |           |           |
| 16   |           | .1174     | .1214     | .112      | .12       |           |           |
| 17   |           | .1147     | .116      | .12       | .12       |           |           |
| 18   |           | .2126     | .1492     | .208      | .1829     |           |           |
| 19   | .2915     | .2515     | .2865     | .2753     |           |           |           |
| 20   | .3005     | .2439     |           | .2743     | .2267     |           |           |
| 21   |           | .1947     |           | .2408     |           |           |           |
| 22   | .2201     | .1659     |           | .1867     |           |           |           |
| 23   |           | .1467     |           | .1692     |           |           |           |
| 24   | 1.5777    | 1.8204    |           | 1.8138    | 1.8138    | .2058     | .1187     |
| Max  | 2.7913    | 2.5591    | 2.8086    | 2.8607    | 2.8978    | 3.2236    | .3086     |
| Min  | .0335     | .1017     | .0701     | .112      | .1029     | .16       | .1187     |
| Avg  | 1.2387    | .8999     | .7712     | 1.2328    | 1.2720    | .6555     | .182      |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 203 / Bramhani

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .2401     | .2328     | .2353     | .2629     | .2686     | 1.9052    | 2.0062    |
| 2    | .2401     | .2328     | .2353     | .2629     | .2686     | 1.9052    |           |
| 3    | .2401     | .2353     |           | .2629     | .2686     | 1.9052    |           |
| 4    | .2507     | .2353     |           | .2715     | .2715     | 1.9052    |           |
| 5    | .3292     | .3142     |           | .3658     | .4024     | 1.9357    |           |
| 6    | .4481     | .5228     |           | .5041     |           |           |           |
| 7    | .5788     | .679      |           | .5658     |           | 2.5911    |           |
| 8    | .5601     | .5415     | .5975     | .5601     | .5144     | 2.8959    | 2.8654    |
| 9    | .4435     | .4334     | .4681     | .5201     | .4268     | 2.6368    |           |
| 10   | .3239     | .3113     | .3401     | .3277     |           | .3506     |           |
| 11   | .3185     | .25       | .2721     |           |           | .3001     |           |
| 12   | 3.255     | 3.5303    | 3.5141    |           | 3.1245    | .2229     |           |
| 13   | 3.2065    | 3.4332    | 3.5141    |           | 2.7892    |           |           |
| 14   | 3.4494    |           | 3.6761    |           |           | .1886     |           |
| 15   | 3.255     | 3.3522    | 3.0769    |           |           |           |           |
| 16   | 3.4979    | 3.255     | 3.336     |           | 3.0788    |           |           |
| 17   | 3.5465    | 3.3198    | 3.2007    | 3.6113    | 1.5546    |           |           |
| 18   | 2.9447    | 3.2007    | 3.0727    | 3.2167    | 2.7587    |           |           |
| 19   | 2.6408    | 2.5453    | 2.7496    | 2.8006    |           |           |           |
| 20   | .4801     | .4908     |           | .4801     | .463      |           |           |
| 21   | .4144     | .3768     |           | .407      |           |           |           |
| 22   |           | .3281     |           | .3361     |           |           |           |
| 23   |           | .3041     |           | .3041     |           |           |           |
| 24   | .2374     | .2328     | 2.7496    | .2629     | .2686     | 1.9052    | 1.9444    |
| Max  | 3.5465    | 3.5303    | 3.6761    | 3.6113    | 3.1245    | 2.8959    | 2.8654    |
| Min  | .2374     | .2328     | .2353     | .2629     | .2686     | .1886     | 1.9444    |
| Avg  | 1.4046    | 1.2329    | 2.0692    | .8513     | 1.1756    | 1.5883    | 2.272     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 204 / Chedgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.4118    | 1.5741    | 1.5851    | 1.5158    | 1.6404    | .2058     | .1526     |
| 2    | 1.4118    | 1.5741    | 1.5851    | 1.5158    | 1.6404    | .2058     |           |
| 3    | 1.448     | 1.5741    |           | 1.5546    | 1.6404    |           |           |
| 4    | 1.448     | 1.6404    |           | 1.5546    | 1.6667    | .2058     |           |
| 5    | 1.6667    | 1.7711    |           | 1.6975    | 1.7966    |           |           |
| 6    | 1.866     | 2.0165    |           | 1.906     |           |           |           |
| 7    | 2.5587    | 2.6707    |           | 2.6379    |           | .2743     |           |
| 8    | 2.7854    | 2.7854    | 2.556     | 2.8837    | 2.6368    | .3258     | .3258     |
| 9    | 2.7199    | .535      | 2.3765    | 2.2125    | 1.9738    | .3258     |           |
| 10   | .2086     | .2641     | .2538     | .2086     |           | .2286     |           |
| 11   | .1128     | .2107     | .1623     |           |           | .1334     |           |
| 12   | .1187     | .1214     | .1254     |           | .1715     | 2.4996    |           |
| 13   | .1187     | .1187     | .1187     |           | .12       |           |           |
| 14   | .0857     |           | .081      |           |           | 2.652     |           |
| 15   | .081      | .081      | .08       |           |           |           |           |
| 16   | .12       | .112      | .0983     |           | .1067     |           |           |
| 17   | .12       | .1341     | .1017     |           | .1067     |           |           |
| 18   | .1326     | .1509     | .1715     |           | .1543     |           |           |
| 19   | .3018     | .3321     | .2846     | .301      |           |           |           |
| 20   | .2572     | .3161     |           | .2824     | .2934     |           |           |
| 21   | .2267     | .2298     |           | .2042     |           |           |           |
| 22   |           | .1943     |           | .2008     |           |           |           |
| 23   |           | .1915     |           | .1947     |           |           |           |
| 24   | 1.3969    | 1.5432    | 1.5804    | 1.5158    |           | .2058     | .1526     |
| Max  | 2.7854    | 2.7854    | 2.556     | 2.8837    | 2.6368    | 2.652     | .3258     |
| Min  | .081      | .081      | .08       | .1947     | .1067     | .1334     | .1526     |
| Avg  | .9362     | .8757     | .7440     | 1.2741    | 1.0729    | .6602     | .2103     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 205 / Bramhani GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .112      | .1132     | .1132     | .132      | .1132     | .1029     | .1307     |
| 2    | .112      | .1132     | .112      | .132      | .1132     | .1029     |           |
| 3    | .1132     | .1132     |           | .1307     | .1132     | .1029     |           |
| 4    | .1132     | .132      |           | .1307     | .1132     | .12       |           |
| 5    | .1509     | .1867     |           | .168      | .1509     | .1698     |           |
| 6    | .2263     | .2641     |           | .2263     |           |           |           |
| 7    |           | .3018     |           | .3395     |           | .2401     |           |
| 8    | .2829     | .2829     | .3206     | .3018     | .2743     | .2743     | .2743     |
| 9    | .2263     | .2896     | .2715     | .2402     | .2743     | .2572     |           |
| 10   | .1612     | .2126     | .2103     | .197      |           | .1886     |           |
| 11   | .1448     | .1753     | .1543     |           |           | .1524     |           |
| 12   | .112      | .1494     | .1132     |           | .12       | .1543     |           |
| 13   | .1132     | .1494     | .1143     |           | .1029     |           |           |
| 14   | .0943     | .112      | .1132     |           |           | .12       |           |
| 15   | .1132     | .1307     | .1143     |           |           |           |           |
| 16   | .1307     | .1109     | .132      | .1417     | .1543     |           |           |
| 17   | .1663     | .1829     | .1698     | .1629     | .1543     |           |           |
| 18   | .1315     | .168      | .1646     | .1629     | .1543     |           |           |
| 19   | .2218     | .2587     | .2614     | .2402     |           |           |           |
| 20   | .2241     | .2218     |           | .2241     | .2058     |           |           |
| 21   |           | .1867     |           | .2241     |           |           |           |
| 22   | .168      | .1448     |           | .1663     |           |           |           |
| 23   |           | .1132     |           | .1294     |           |           |           |
| 24   | .3206     | .1132     | .1143     | .1307     | .1143     | .1029     |           |
| Max  | .3206     | .3018     | .3206     | .3395     | .2743     | .2743     | .2743     |
| Min  | .0943     | .1109     | .112      | .1294     | .1029     | .1029     | .1307     |
| Avg  | .1637     | .1761     | .1653     | .1884     | .1542     | .1606     | .2025     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014138 / 33/11KV BRAMHANI

Feeder No / Name : 206 / Mokalohal GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1629     | .1698     | .1905     | .1698     | .1886     | .1715     | .1905     |
| 2    | .1463     | .1494     | .1698     | .1698     | .1698     | .1372     |           |
| 3    | .1463     | .1494     |           | .1494     | .1509     | .1372     |           |
| 4    | .1463     | .1494     |           | .1494     | .1494     | .1543     |           |
| 5    | .1448     | .1629     |           | .1478     | .1478     | .1629     |           |
| 6    | .1629     | .181      |           | .1867     |           |           |           |
| 7    | .1612     | .181      |           | .2241     |           | .1886     |           |
| 8    | .1848     | .1054     | .2263     | .1867     | .2401     | .1886     |           |
| 9    | .2033     | .2054     | .2378     | .2012     | .2058     | .2096     |           |
| 10   | .2195     | .2658     | .2481     | .2427     |           | .2058     |           |
| 11   | .1698     | .2033     | .168      |           |           | .2401     |           |
| 12   | .1698     | .081      | .1663     |           | .1886     | .1543     |           |
| 13   | .1612     | .1698     | .1715     |           | .1543     |           |           |
| 14   | .1463     |           | .168      |           |           | .1543     |           |
| 15   | .1433     | .1372     | .1433     |           |           |           |           |
| 16   | .168      | .1372     | .1698     | .1886     | .1543     |           |           |
| 17   | .2477     | .2075     | .1698     | .1905     | .1886     |           |           |
| 18   | .2452     | .2263     | .1715     | .1886     | .2286     |           |           |
| 19   | .2263     | .2427     | .2263     | .2427     |           |           |           |
| 20   | .2427     | .2054     |           | .2241     | .2058     |           |           |
| 21   | .1886     | .2195     |           | .2075     |           |           |           |
| 22   |           | .1698     |           | .1886     |           |           |           |
| 23   |           | .1715     |           | .2241     |           |           |           |
| 24   | .1629     | .1886     | .2263     | .1698     | .2096     | .1715     | .2075     |
| Max  | .2477     | .2658     | .2481     | .2427     | .2401     | .2401     | .2075     |
| Min  | .1433     | .081      | .1433     | .1478     | .1478     | .1372     | .1905     |
| Avg  | .1796     | .1774     | .1902     | .1922     | .1844     | .1751     | .199      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014141 / 33/11KV BARAGAON NANDUR

Feeder No / Name : 201 / Jambhali

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9826    | 2.1795    | 2.3061    |           |           | .0686     | .108      |
| 2    | 2.0957    | 2.1795    | 2.34      |           |           | .0686     | .108      |
| 3    | 2.1216    | 2.1795    | 2.3137    |           |           | .0857     | .1067     |
| 4    | 2.1795    | 2.1795    | 2.5149    |           |           | .0867     | .108      |
| 5    | 2.3908    | 2.1963    | 2.7161    |           |           | .0867     | .1067     |
| 6    | 2.431     | 2.3472    | 2.7349    |           |           | .0886     | .116      |
| 7    | 2.6825    | 3.0476    | 2.8841    | 1.5769    |           | .144      | .1254     |
| 8    | 2.9338    | 2.8502    | 3.0001    | 1.7126    |           | .1094     | .12       |
| 9    | 2.6155    |           | 2.3205    |           |           | .0987     | .1128     |
| 10   | .0903     |           | .1174     |           | .1075     | .1147     | .0705     |
| 11   |           |           | .0734     |           | .0819     | .0947     | .0564     |
| 12   | .0572     | .1214     | .0446     |           |           | 2.9835    | 2.8826    |
| 13   | .0667     |           | .0412     |           |           |           | 3.3589    |
| 14   | .0648     |           | .0406     |           | .096      | 2.9007    | 3.4311    |
| 15   | .081      |           | .0429     |           | .0894     | 3.3261    | 3.3753    |
| 16   | .0709     | .0972     | .04       | .0937     | .0934     | 3.0996    | 3.1352    |
| 17   | .1036     | .116      | .0518     |           | .0947     | 3.1493    | 3.4808    |
| 18   | .0894     | .0974     | .0899     |           | .096      | 2.9835    | 3.1327    |
| 19   | .1257     | .161      | .1027     |           | .1372     |           | 2.6155    |
| 20   | .144      | .1627     | .1069     |           | .2458     |           | .092      |
| 21   | .144      | .1574     | .108      |           | .2458     |           | .0777     |
| 22   | .1515     | .1543     | .0869     |           | .1166     |           | .0693     |
| 23   | .1288     | .1252     | .0854     |           | .1115     | .1158     | .096      |
| 24   | 1.7394    | 2.0454    | 2.2542    |           | 2.2801    | .0848     | .108      |
| Max  | 2.9338    | 3.0476    | 3.0001    | 1.7126    | 2.2801    | 3.3261    | 3.4808    |
| Min  | .0572     | .0972     | .04       | .0937     | .0819     | .0686     | .0564     |
| Avg  | 1.0648    | 1.2443    | 1.1007    | 1.1277    | .2920     | 1.0363    | 1.1247    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014141 / 33/11KV BARAGAON NANDUR

Feeder No / Name : 202 / Kuranwadi

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0655     | .0619     | .0619     | .0474     |           | .4382     | .8036     |
| 2    | .0655     | .0619     | .0619     | .0486     |           | .4382     | .6767     |
| 3    | .0671     | .0619     | .061      | .0389     |           | .4199     | .6344     |
| 4    | .0648     | .0619     | .0591     | .0383     |           | .4199     | .5975     |
| 5    | .0619     | .072      | .0686     | .0472     |           | .3978     | .543      |
| 6    | .06       | .0827     | .0838     | .0572     |           | .4243     | .6455     |
| 7    | .0686     | .1086     | .0943     | .0162     |           | .9393     | .9069     |
| 8    | .0663     | .0975     | .0926     | .1174     | .1236     | 1.122     | 1.1801    |
| 9    | .0724     |           | .0914     |           |           | 1.7086    | .9393     |
| 10   | .0579     |           | .0739     |           | .1267     |           | .0309     |
| 11   |           |           | .0526     |           | .104      | .0791     |           |
| 12   | .5415     | 2.2634    | 1.8233    |           | 1.8564    | .0762     |           |
| 13   | 1.7086    |           | 1.8004    |           | 1.4232    | .0791     |           |
| 14   | 2.0332    |           | 1.7814    |           | 2.4587    | .0724     |           |
| 15   | 2.1672    |           | 1.8136    |           | 1.6644    |           |           |
| 16   | 2.0972    | 1.5074    | 1.708     | 1.5364    | 1.6766    |           | .0663     |
| 17   | 2.1365    | 1.1843    | 1.6661    |           | 1.6446    | .0564     |           |
| 18   | 1.7593    | 1.8097    | 1.1561    |           | 1.07      |           | .1029     |
| 19   | 1.1067    | 1.6461    | 1.2239    |           | .4938     |           | .1214     |
| 20   | .1829     | .1715     | .0583     |           | .1886     |           | .1402     |
| 21   | .1829     | .156      | .0572     |           | .1886     | .1595     | .1448     |
| 22   | .1663     | .1463     | .0434     |           | .1646     |           | .1494     |
| 23   | .1494     | .0834     | .0389     | .1334     | .0995     | .0892     | .0762     |
| 24   | .0648     | .0648     | .0619     | .0463     | .1149     | .5083     | .7825     |
| Max  | 2.1672    | 2.2634    | 1.8233    | 1.5364    | 2.4587    | 1.7086    | 1.1801    |
| Min  | .0579     | .0619     | .0389     | .0162     | .0995     | .0564     | .0309     |
| Avg  | .6498     | .5356     | .5847     | .1934     | .8374     | .4370     | .4745     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014141 / 33/11KV BARAGAON NANDUR

Feeder No / Name : 204 / Chinchale GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .056      | .0537     | .056      | .056      |           | .056      | .056      |
| 2    | .0549     | .0537     | .056      | .0549     |           | .056      | .056      |
| 3    | .0537     | .0537     | .056      | .0549     |           | .056      | .056      |
| 4    | .0693     | .0537     | .056      | .0554     |           | .056      | .056      |
| 5    | .0701     | .0716     | .056      | .0739     |           | .056      | .056      |
| 6    | .0905     | .0724     | .056      | .0554     |           | .056      | .056      |
| 7    | .0716     | .0554     | .0914     | .0724     |           | .0724     | .0914     |
| 8    | .0724     | .0686     | .1075     | .0709     | .0905     | .0732     | .0905     |
| 9    | .0686     |           | .0648     |           |           | .0724     | .0983     |
| 10   | .0514     |           | .081      |           | .0648     | .08       | .0678     |
| 11   |           |           | .0671     |           | .0532     |           | .0509     |
| 12   | .0554     | .0532     | .0514     |           | .0537     | .0526     | .0463     |
| 13   | .0526     |           | .0486     |           | .052      |           | .0514     |
| 14   | .0532     |           | .0486     |           | .0514     | .0514     | .0509     |
| 15   | .0526     |           | .0463     |           | .0514     | .0514     | .0514     |
| 16   | .052      | .0537     | .0625     | .056      | .0514     | .0503     | .0339     |
| 17   | .0514     | .0509     | .0463     |           | .0497     | .0492     | .0492     |
| 18   | .0819     | .0503     | .0648     |           | .0743     | .0633     | .0781     |
| 19   | .08       | .0867     | .0762     |           | .0926     | .0829     | .0949     |
| 20   | .0686     | .0701     | .0791     |           | .0693     | .0857     | .116      |
| 21   | .0686     | .056      | .1052     |           | .052      | .0537     | .0905     |
| 22   | .0532     | .0543     | .0724     |           | .0543     | .0549     | .0532     |
| 23   | .0526     | .0554     | .0732     | .056      | .0554     | .056      | .056      |
| 24   | .0554     | .0537     | .056      | .0554     | .0554     | .056      | .056      |
| Max  | .0905     | .0867     | .1075     | .0739     | .0926     | .0857     | .116      |
| Min  | .0514     | .0503     | .0463     | .0549     | .0497     | .0492     | .0339     |
| Avg  | .0624     | .0593     | .0658     | .0601     | .0607     | .0610     | .0651     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014141 / 33/11KV BARAGAON NANDUR

Feeder No / Name : 205 / Nandur GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1698     | .1886     | .1867     | .1698     |           | .1698     | .1867     |
| 2    | .168      | .1886     | .1867     | .1698     |           | .1698     | .1867     |
| 3    | .168      | .1886     | .1867     | .1698     |           | .1698     | .2263     |
| 4    | .2054     | .1886     | .2241     | .1663     |           | .1698     | .2427     |
| 5    | .2829     | .2263     | .1932     | .2241     |           | .1886     | .2641     |
| 6    | .415      | .3206     | .3395     | .3395     |           | .3395     | .3395     |
| 7    | .4527     | .4527     | .4527     | .4338     |           | .4481     | .4338     |
| 8    | .4854     | .4715     | .4668     | .4481     | .4527     | .4481     | .4481     |
| 9    | .4435     |           | .3982     |           |           | .3475     | .3921     |
| 10   | .2454     |           | .2601     |           | .2481     |           | .3734     |
| 11   | .2454     |           | .2229     |           | .2507     |           |           |
| 12   | .2103     | .2328     | .2195     |           | .1991     | .197      |           |
| 13   | .1991     |           | .2012     |           | .1991     | .2103     | .1734     |
| 14   | .2149     |           | .2033     |           | .181      | .2149     | .2103     |
| 15   | .2103     |           | .2012     |           | .1629     | .1433     | .2103     |
| 16   | .2103     | .2229     | .2035     | .2303     | .181      | .1097     | .1949     |
| 17   | .2427     | .2601     | .2374     |           | .2126     |           | .2401     |
| 18   | 2.2382    | .257      | .4024     |           | .333      | .3982     | .3467     |
| 19   | .4706     | .3666     | .4207     |           | .4298     | .4207     | .4344     |
| 20   | .3921     | .4207     | .462      |           | .3881     | .4207     | .4572     |
| 21   | .3921     | .4251     | .415      |           | .3361     | .3326     | .4024     |
| 22   | .2614     | .1848     | .2801     |           | .2772     | .2772     | .2587     |
| 23   | .1848     | .2218     | .2054     | .2263     | .2241     | .2033     | .2033     |
| 24   | .1698     | .1698     | .1486     | .1867     | .1886     | .1698     | .1867     |
| Max  | 2.2382    | .4715     | .4668     | .4481     | .4527     | .4481     | .4572     |
| Min  | .168      | .1698     | .1486     | .1663     | .1629     | .1097     | .1734     |
| Avg  | .3616     | .2771     | .2799     | .2513     | .2665     | .2642     | .2914     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014141 / 33/11KV BARAGAON NANDUR

Feeder No / Name : 206 / 11 Kv Hanumanwadi Ag

SHEDDABLE RURAL

Feeder KV- 11 / INCOMING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .016      | .0008     | .0191     | .0295     |           | 1.5947    | 1.6617    |
| 2    | .0166     | .0008     | .0181     | .0162     |           | 1.5947    | 1.6617    |
| 3    | .0154     | .0008     | .0145     | .016      |           | 1.5947    | 1.6448    |
| 4    | .0063     | .0008     | .0122     | .0221     |           | 1.5947    | 1.6263    |
| 5    | .0097     | .0008     | .0099     | .0063     |           | 1.5947    | 1.6095    |
| 6    | .0057     | .0076     | .0099     | .0074     |           | 1.5939    | 1.6617    |
| 7    | .0051     | .0223     | .0251     | .0297     |           | 1.8482    | 1.8143    |
| 8    | .0221     | .0177     | .0236     | .0166     | .0175     | 1.989     | 1.7465    |
| 9    | .004      |           | .012      |           |           | 1.7901    | 1.6787    |
| 10   | .0238     |           | .0295     |           | .0514     | .0829     | .0171     |
| 11   | .0238     |           | .0229     |           | .0263     | .0427     | .0166     |
| 12   | 2.5095    | 2.4006    | 2.2634    |           | 2.0517    | .0274     | .0177     |
| 13   | 2.2891    |           | 2.2462    |           | 2.2119    |           | .0063     |
| 14   | 2.0687    |           | 2.2018    |           | 2.1365    | .0097     | .0086     |
| 15   | 2.1195    |           | 2.1605    |           | .0894     | .0143     | .016      |
| 16   | 2.2552    | 2.0062    | 2.0008    | 2.1365    | 1.95      | .0463     | .0114     |
| 17   | 2.34      | 2.1434    | 1.8991    |           | 1.95      | .0069     | .0097     |
| 18   | 2.2382    | 1.9062    | 1.8652    |           | 1.8143    |           | .0063     |
| 19   | 2.0454    | 1.8842    | 1.8313    |           | 1.6876    |           | .0006     |
| 20   | .0644     | .0743     | .0705     |           | .072      | .0747     | .0295     |
| 21   | .0669     | .0747     | .0532     |           | .0857     | .0747     | .0105     |
| 22   | .0644     | .0854     | .0671     |           | .0857     |           | .0286     |
| 23   | .0514     | .0572     | .065      | .0307     | .061      | .0463     | .0221     |
| 24   | .0177     | .0076     | .0229     | .0488     | .0124     | 1.5769    | 1.6617    |
| Max  | 2.5095    | 2.4006    | 2.2634    | 2.1365    | 2.2119    | 1.989     | 1.8143    |
| Min  | .004      | .0008     | .0099     | .0063     | .0124     | .0069     | .0006     |
| Avg  | .7616     | .5940     | .7060     | .2145     | .8940     | .8599     | .7070     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014143 / BABHULGAON

Feeder No / Name : 201 / Babhulgaon  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6309    |
| Max  | 1.6309    |
| Min  | 1.6309    |
| Avg  | 1.6309    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014143 / BABHULGAON

Feeder No / Name : 202 / VARVANDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           |           | .0949     |
| 2    |           |           |           |           |           | .1107     |
| 3    |           |           |           |           |           | .1107     |
| 4    |           |           |           |           |           | .1107     |
| 5    |           |           |           |           |           | .1265     |
| 6    |           |           |           |           |           | .1423     |
| 7    |           |           |           |           |           | .1581     |
| 8    |           |           |           |           |           | .1739     |
| 17   | .1265     | .0949     | .1107     | .1423     | .1423     |           |
| 18   | .1423     | .1265     | .1423     | .1581     | .1581     |           |
| 19   | .1423     | .2214     | .2372     | .1581     | .1739     |           |
| 20   | .1898     | .2214     | .253      | .1898     | .2056     |           |
| 21   | .2214     | .2214     | .2372     | .2056     | .2372     |           |
| 22   | .1898     | .2056     | .2056     | .1739     | .2214     |           |
| 23   | .1898     | .1107     | .1581     | .1581     | .1898     |           |
| 24   | 1.4937    | 1.5971    | 1.6762    | 1.8976    | .1581     |           |
| Max  | 1.4937    | 1.5971    | 1.6762    | 1.8976    | .2372     | .1739     |
| Min  | .1265     | .0949     | .1107     | .1423     | .1423     | .0949     |
| Avg  | .3370     | .3499     | .3775     | .3854     | .1858     | .1285     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014143 / BABHULGAON

Feeder No / Name : 203 / Khadakwadi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .2915     |
| Max  | .2915     |
| Min  | .2915     |
| Avg  | .2915     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 014143 / BABHULGAON

Feeder No / Name : 204 / 11 Kv Gorakshanath LIS

PURELY LIS FEEDERS

Stage - Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0596     | .0596     | .0618     | .0611     | .0603     | .0589     | .0613     |
| 2    | .0593     | .0595     | .0618     | .0606     | .0599     | .0588     | .061      |
| 3    | .0594     | .0592     | .0618     |           | .06       | .0584     | .0609     |
| 4    | .0593     | .0594     | .0617     |           | .0601     | .0586     | .0609     |
| 5    | .0598     | .06       | .0624     |           | .0604     | .0591     | .0612     |
| 6    | .0607     | .0612     | .0645     |           | .061      | .0603     | .0628     |
| 7    | .0607     | .0633     | .0633     | .0628     | .0623     | .0612     | .0609     |
| 8    | .0628     | .0631     | .0631     | .0629     | .0611     | .0607     | .0621     |
| 9    | .0623     | .0609     | .0629     | .0623     | .0606     | .0605     | .0613     |
| 10   | .0585     | .0585     | .0597     | .0583     | .0581     | .0574     | .0581     |
| 11   | .0588     | .0585     | .0591     | .0586     | .058      | .0577     | .0582     |
| 12   | .0639     | .0635     | .0616     | .0601     | .0615     | .0614     | .0627     |
| 13   | .0627     | .0629     | .0618     | .0594     | .0616     | .0613     | .0609     |
| 14   | .0634     | .0613     | .0615     | .059      | .0601     | .0609     | .0611     |
| 15   |           |           | .0609     |           |           |           | .0597     |
| 22   | .0524     | .0444     |           |           | .0531     | .0534     | .0288     |
| 23   | .0581     | .0581     | .058      | .0581     | .0578     | .0579     | .0579     |
| 24   | .4029     | .0619     | .0609     | .0609     | .0588     | .0612     | .0613     |
| Max  | .4029     | .0635     | .0645     | .0629     | .0623     | .0614     | .0628     |
| Min  | .0524     | .0444     | .058      | .0581     | .0531     | .0534     | .0288     |
| Avg  | .0803     | .0597     | .0616     | .0603     | .0597     | .0593     | .0590     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 014143 / BABHULGAON

Feeder No / Name : 205 / 11 Kv NDDB Dairy

Feeder KV- 11 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .3429     |
| Max  | .3429     |
| Min  | .3429     |
| Avg  | .3429     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 201 / Mula dam

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.3717    |
| Max  | 1.3717    |
| Min  | 1.3717    |
| Avg  | 1.3717    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 202 / Railway S/tn

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.9814    |
| Max  | 1.9814    |
| Min  | 1.9814    |
| Avg  | 1.9814    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 203 / Pimpari Awghad

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.9052    |
| Max  | 1.9052    |
| Min  | 1.9052    |
| Avg  | 1.9052    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 204 / Jogeshwari

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.9814    |
| Max  | 1.9814    |
| Min  | 1.9814    |
| Avg  | 1.9814    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 205 / Rahuri Town-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.0271    |
| Max  | 2.0271    |
| Min  | 2.0271    |
| Avg  | 2.0271    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 206 / Rahuri Town-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.9204    |
| Max  | 1.9204    |
| Min  | 1.9204    |
| Avg  | 1.9204    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 207 / Malharwadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.2193    |
| Max  | 1.2193    |
| Min  | 1.2193    |
| Avg  | 1.2193    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 208 / Nandur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.829     |
| Max  | 1.829     |
| Min  | 1.829     |
| Avg  | 1.829     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 209 / Varvandi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.7071    |
| Max  | 1.7071    |
| Min  | 1.7071    |
| Avg  | 1.7071    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 401 / 33 KV Taharabad tap  
(Baragaon Feeder KV- 33 /  
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.4632    |
| Max  | 1.4632    |
| Min  | 1.4632    |
| Avg  | 1.4632    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842] BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 404 / 33KV Old Sonai

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(NON CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .6859     |
| Max  | .6859     |
| Min  | .6859     |
| Avg  | .6859     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 407 / 33 KV Bramhani

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 1.6004    |
| Max  | 1.6004    |
| Min  | 1.6004    |
| Avg  | 1.6004    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

RAHURI S/DN.[842]

BU 4842

Substation No/ Name :- 017002 / 132/33/11 KV RAHURI

Feeder No / Name : 410 / 33 KV MSSK CO-GEN  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(NON CONTINUOUS PROCESS)(NO  
STAGGERING)

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | 2.1948    |
| Max  | 2.1948    |
| Min  | 2.1948    |
| Avg  | 2.1948    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 201 / VADALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1928     | .1578     |           | .1372     | .1109     | 2.0328    | 1.5851    |
| 2    | .1928     | .1402     |           | .1372     | .1294     | 2.1033    | 1.6156    |
| 3    | .2103     | .1578     |           | .1578     | .1478     | 2.1582    | 1.7071    |
| 4    | .2454     | .1753     |           | .1753     | .1646     | 2.1765    | 1.7985    |
| 5    |           | .1928     |           | .1928     | .1646     | 2.2862    | 1.89      |
| 6    |           | .2103     |           | .2103     | .2012     | 2.4691    | 2.0729    |
| 7    |           | .2454     |           | .1886     | .2218     | 2.652     | 2.4234    |
| 8    |           |           |           |           |           |           | 2.8502    |
| 9    |           |           |           |           |           | 3.2922    | 3.3288    |
| 10   | .2378     | .128      |           | .1463     | .1448     | .1097     | .1097     |
| 11   | .1829     | .1097     |           | .1267     | .1267     | .0914     | .0914     |
| 12   |           | 3.6946    |           | 3.5837    | 3.5475    |           |           |
| 13   | 3.6961    |           | 3.658     | 3.7466    | 3.5113    |           |           |
| 14   | 3.6222    | 3.6214    | 3.6595    | 3.7104    | 3.4027    |           |           |
| 15   | 3.5117    |           | 3.5482    | 3.5848    | 3.5117    |           |           |
| 16   | 4.0969    | 3.9323    | 3.7494    | 3.6031    | 3.4202    |           |           |
| 17   | 3.4494    | 2.9573    | 3.8775    | 3.658     | 3.4751    |           |           |
| 18   | 3.3608    | 2.8235    | 3.7494    | 3.3653    | 3.3288    |           |           |
| 19   | 3.0769    | 2.4817    | 3.1642    | 3.2341    | 2.963     | .1457     | .1646     |
| 20   | .4207     | .1753     | .2454     | .2378     | .1829     | .1578     | .1829     |
| 21   | .3506     | .1753     | .2103     | .1829     | .1829     | .1753     | .1829     |
| 22   | .1715     | .1753     | .1753     | .1646     | .1646     | .1578     | .1478     |
| 23   | .1753     |           | .1543     | .1294     | .1478     | .1402     | .128      |
| 24   | .3506     | .1578     |           | .1402     | .1097     | 1.8107    | 1.531     |
| Max  | 4.0969    | 3.9323    | 3.8775    | 3.7466    | 3.5475    | 3.2922    | 3.3288    |
| Min  | .1715     | .1097     | .1543     | .1267     | .1097     | .0914     | .0914     |
| Avg  | 1.5303    | 1.1427    | 2.3810    | 1.4006    | 1.3345    | 1.3724    | 1.2829    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 202 / GONDEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.9204    | 1.9616    | 2.0729    | 1.9204    | 1.848     | .2195     | .1753     |
| 2    | 1.9814    | 1.9913    | 2.0805    | 1.9509    | 1.8656    | .2195     | .1753     |
| 3    | 2.0424    | 2.1948    | 2.2558    | 2.1338    | 1.9387    | .2378     | .1886     |
| 4    | 2.3167    | 2.2142    | 2.3472    | 2.3167    | 2.0485    | .2587     | .2103     |
| 5    | 2.8045    | 2.8045    | 2.5286    | 2.9172    | 2.1948    | .3292     | .3155     |
| 6    | 3.2099    | 3.0316    | 2.9569    | 3.219     | 3.2922    | .439      | .4115     |
| 7    | 3.2099    | 3.3288    | 3.5056    | 3.3288    | 4.0287    | .5487     | .5144     |
| 8    | 3.504     | .9957     | 3.2693    | 3.3882    | 4.1267    | 3.4202    |           |
| 9    |           | 1.1157    |           | 3.9095    | 3.8958    |           |           |
| 10   | .2926     | .2743     |           | .2715     | .2743     | .2896     | .2926     |
| 11   | .2743     | .3292     |           | .2743     | .2743     | .2896     | .2926     |
| 12   | .2743     |           |           |           |           | 3.7285    | 4.2433    |
| 13   | .2195     |           | .2195     |           |           | 4.3439    | 4.2981    |
| 14   | .2772     |           | .2743     |           |           | 4.2067    | 4.0238    |
| 15   |           |           |           |           |           | 4.3896    | 4.0238    |
| 16   |           |           |           |           |           | 4.3896    | 4.0604    |
| 17   |           |           |           |           |           | 3.4625    | 4.0787    |
| 18   |           |           | .2926     | .2402     | .2926     | 3.1356    | 3.786     |
| 19   | .3988     | .4207     | .2926     | .3326     | .3292     | 2.7844    | 3.2007    |
| 20   | .4287     | .333      | .3086     | .3326     | .3292     | .3086     | .3292     |
| 21   | .3429     | .333      | .2743     | .2926     | .2561     | .2401     | .6036     |
| 22   | .3155     | .3086     | .2401     | .2561     |           | .2058     | .3658     |
| 23   | .2804     | .2804     | .2401     | .2378     | .2218     | .1715     | .3292     |
| 24   | 4.6578    | .3506     | 2.0424    | 1.89      | 2.0328    | .2378     | .1753     |
| Max  | 4.6578    | 3.3288    | 3.5056    | 3.9095    | 4.1267    | 4.3896    | 4.2981    |
| Min  | .2195     | .2743     | .2195     | .2378     | .2218     | .1715     | .1753     |
| Avg  | 1.5132    | 1.3099    | 1.4824    | 1.6229    | 1.7205    | 1.6459    | 1.6406    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 203 / Sutgirani Town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .6722     | .8215     | .8962     | .8589     | 1.0974    | 1.1888    | 1.0082    |
| 2    | .6722     | .8589     | .8589     | .8215     | 1.1458    | 1.1888    | 1.0456    |
| 3    | .7842     | .9709     | .8962     | .8962     | 1.2437    | 1.2752    | 1.1576    |
| 4    | 1.0082    | .1494     | 1.0082    | 1.1576    | 1.2936    | 1.3306    | 1.3817    |
| 5    | 1.2696    | 1.5684    | 1.1949    | 1.4632    | 1.2936    | 1.46      | 1.5684    |
| 6    | 1.4632    | 1.7193    | 1.5684    | 1.7193    | 1.6263    | 1.5546    | 1.2071    |
| 7    | 1.4937    | 1.9185    | 2.0119    | 1.9605    | 1.7926    | 1.9387    | 1.9605    |
| 8    |           | 2.0814    | 2.396     | 1.9204    | 2.0302    | 2.1253    | 2.3045    |
| 9    |           | 2.0119    |           | 2.0814    | 2.1253    | 1.848     | 2.009     |
| 10   | 1.4937    | 1.9791    |           | 2.0271    | 1.9004    | 1.5927    | 1.7375    |
| 11   | 1.419     | 1.7924    |           | 1.957     | 1.5746    | 1.6289    | 1.6832    |
| 12   | 1.2986    |           |           | 1.9204    | 1.7013    | 1.7013    | 1.647     |
| 13   | 1.3443    |           |           | 1.701     | 1.6289    | 1.6095    | 1.5912    |
| 14   | 1.419     |           |           | 1.6827    | 1.5384    | 1.5565    | 1.4998    |
| 15   | 1.5364    | 1.2936    |           | 1.5546    | 1.5384    | 1.5565    | 1.4266    |
| 16   | 1.5684    | 1.39      | 1.6827    | 1.6827    | 1.5565    | 1.6108    | 1.5364    |
| 17   | 1.0867    | 1.8107    | 1.8656    | 1.7372    | 1.7013    | 1.7924    | 1.5364    |
| 18   | 1.7187    | 1.9404    | 1.8473    | 1.9204    | 1.8099    | 1.9044    | 1.6289    |
| 19   | 1.8404    | 2.1033    | 1.7924    | 1.8665    | 1.9387    | 1.9418    | 1.7918    |
| 20   | 1.8671    | 1.9044    | 1.7193    | 1.829     | 1.7926    | 1.7924    | 1.6817    |
| 21   | 1.4937    | 1.6244    | 1.5546    | 1.5123    | 1.5546    | 1.4998    | 1.4632    |
| 22   | 1.3256    | 1.4003    | 1.3443    | 1.6095    | 1.4784    | 1.3443    | 1.3169    |
| 23   | 1.1576    | 1.3443    | 1.2696    | 1.2071    | 1.2071    | 1.1389    | .2195     |
| 24   | .7095     | .9877     | 1.0082    | .9335     | 1.1576    | 1.2437    | 1.0082    |
| Max  | 1.8671    | 2.1033    | 2.396     | 2.0814    | 2.1253    | 2.1253    | 2.3045    |
| Min  | .6722     | .1494     | .8589     | .8215     | 1.0974    | 1.1389    | .2195     |
| Avg  | 1.3019    | 1.5081    | 1.4656    | 1.5842    | 1.5720    | 1.5760    | 1.4755    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 204 / 11 kv DIGHI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .056      | .0549     | .0549     | .056      | .0554     | .0549     | .056      |
| 2    | .056      | .0549     | .056      | .056      | .0554     | .0549     | .0549     |
| 3    | .0739     | .0732     | .0732     | .0739     | .0739     | .0549     | .0549     |
| 4    | .0732     | .0914     | .1097     | .1478     | .0924     | .0914     | .0914     |
| 5    | .2012     | .2012     | .1463     | .1829     | .1109     | .1109     | .1097     |
| 6    | .2561     | .1829     | .1829     | .2195     | .1478     | .1663     | .1518     |
| 7    | .2561     | .2328     | .2195     | .2378     | .2033     | .2195     | .2195     |
| 8    | .2149     | .2012     | .2012     | .2195     | .2402     | .2012     | .2378     |
| 9    |           | .1463     |           | .1867     | .2218     | .1463     | .168      |
| 10   | .1463     | .1097     |           | .1307     | .1494     | .112      | .1494     |
| 11   | .1097     | .128      |           | .112      | .0934     | .0934     | .112      |
| 12   | .0914     | .0914     |           | .0747     | .0934     | .0747     | .0934     |
| 13   | .0732     |           | .0732     | .0747     | .0747     | .0747     | .0739     |
| 14   | .0732     | .0732     | .0732     | .0747     | .0747     | .056      | .0739     |
| 15   |           | .0732     | .0549     | .0747     | .0747     | .056      | .0739     |
| 16   | .0549     | .0732     | .0732     | .0747     | .0747     | .056      | .0739     |
| 17   | .0701     | .0732     | .0724     | .0924     | .0747     | .0732     |           |
| 18   | .1052     |           | .1097     | .1109     | .112      | .1097     | .0924     |
| 19   | .1402     | .1646     | .1463     | .1463     | .168      | .1463     | .1663     |
| 20   | .1848     | .1463     | .1463     | .1646     | .1463     | .128      | .1646     |
| 21   | .128      | .128      | .128      | .128      | .128      | .1097     | .128      |
| 22   | .1097     | .0914     | .1109     | .0914     | .1097     | .112      | .0914     |
| 23   | .0732     | .0732     | .0934     | .0732     | .0549     | .1097     | .0739     |
| 24   | .1108     | .0914     | .056      | .0747     | .0554     | .0554     | .0747     |
| Max  | .2561     | .2328     | .2195     | .2378     | .2402     | .2195     | .2378     |
| Min  | .0549     | .0549     | .0549     | .056      | .0549     | .0549     | .0549     |
| Avg  | .1208     | .1162     | .1091     | .1199     | .1119     | .1028     | .1124     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 205 / 11KV SUBHEDAR WASTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .5121     | .5487     | .5304     | .5853     | .5914     | .5544     | .5487     |
| 2    | .5487     | .5853     | .5487     | .5487     | .6468     | .5487     | .5487     |
| 3    | .6219     | .7133     | .6219     | .5853     | .6838     | .5487     | .5487     |
| 4    | .7316     | .7316     | .8048     | .7316     | .7133     | .695      | .6584     |
| 5    | .9511     | .9877     | 1.0242    | .8413     | .7392     | .8962     | 1.5364    |
| 6    | 1.4083    | 1.2803    | 1.2803    | .9694     | 1.1458    | 1.134     | 1.2071    |
| 7    | 1.4083    | 1.5402    | 1.4998    | 1.2254    | 1.39      | 1.4415    | 1.4998    |
| 8    | 1.4815    | 1.5402    | 1.6827    | 1.39      | 1.4815    | 1.5364    | 1.5546    |
| 9    |           | 1.4632    |           | 1.3717    | 1.4998    | 1.4266    | 1.5384    |
| 10   | 1.1157    | 1.262     |           | 1.3717    | 1.3575    | 1.1946    | 1.2308    |
| 11   | 1.1523    | 1.0974    |           | 1.0498    | 1.267     | 1.1403    | 1.1222    |
| 12   | 1.0425    | .9328     |           | .905      | 1.1765    | .9412     | .9412     |
| 13   | .9145     |           |           | .7964     | 1.0498    | .8688     | .9328     |
| 14   | .7762     | 1.1888    |           | .7059     | .8507     | .7316     | .695      |
| 15   | .6036     | .7682     |           | .6154     | .7316     | .6767     | .695      |
| 16   | .5304     | .6767     | .6401     | .6154     | .695      | .6584     | .6219     |
| 17   | .6733     | .823      | .7316     | .7682     | .695      | .6767     | .7316     |
| 18   | .8328     | .8413     | .8962     | .8779     | .7682     | .9145     | .8413     |
| 19   |           | .9694     | 1.0974    | 1.1157    | 1.0425    | 1.0242    | 1.0791    |
| 20   |           | .9694     | 1.1706    | 1.1088    | 1.0349    | 1.0974    | 1.0242    |
| 21   | .9145     | .9511     | 1.1523    | .961      | .9511     | .9511     | .9328     |
| 22   | .8048     | .8413     | .9877     | .8501     | .8413     | .8048     |           |
| 23   | .6767     | .6584     | .7316     | .7207     | .6767     | .6767     | .6401     |
| 24   | 1.1645    | .5853     | .5853     | .6219     | .5914     | .5853     | .5853     |
| Max  | 1.4815    | 1.5402    | 1.6827    | 1.39      | 1.4998    | 1.5364    | 1.5546    |
| Min  | .5121     | .5487     | .5304     | .5487     | .5914     | .5487     | .5487     |
| Avg  | .8983     | .9546     | .9403     | .8889     | .9425     | .9052     | .9441     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 206 / WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1568    | 1.2346    | 1.3375    | 1.3717    | 1.6461    | 1.5181    | 1.406     |
| 2    | 1.1145    | 1.2346    | 1.3226    | 1.3375    | 1.6644    | 1.5339    | 1.3717    |
| 3    | 1.166     | 1.2887    | 1.4403    | 1.4403    | 1.7193    | 1.5546    | 1.4746    |
| 4    | 2.6063    | 1.4403    | 1.6118    | 1.5432    | 1.7375    | 1.6095    | 1.5261    |
| 5    | 2.0233    | 1.749     | 1.8861    | 1.8652    | 1.7375    | 2.4508    | 1.6118    |
| 6    | 2.7778    | 2.2382    | 2.2721    | 2.1365    | 2.1948    | 2.4508    | 2.0919    |
| 7    | 2.7778    | 2.3777    | 2.7808    | 2.5943    | 2.7801    | 2.9995    | 2.8121    |
| 8    | 2.6791    | 2.8669    | 2.8487    | 2.7328    | 3.1232    | 3.1459    | 2.8166    |
| 9    |           | 2.6703    |           | 2.8166    | 3.1093    | 2.9813    | 2.7873    |
| 10   | 2.524     | 2.4143    |           | 2.7435    | 2.9813    | 2.7252    | 2.6425    |
| 11   | 2.2862    | 2.2497    |           | 2.4874    | 2.5789    | 2.5789    | 2.5158    |
| 12   | 2.0302    | 2.1948    |           |           | 2.4143    | 2.2497    | 2.1357    |
| 13   | 1.8656    |           |           |           | 2.1582    | 2.1399    | 2.0633    |
| 14   | 1.6827    | 2.0119    |           |           | 1.9387    | 2.009     | 2.0633    |
| 15   | 1.6095    | .2926     |           |           | 1.8656    | 1.9366    | 1.9547    |
| 16   | 1.7737    |           | 1.701     |           | 1.7924    | 1.9728    | 1.9185    |
| 17   | 1.825     | 1.8347    | 1.8473    | 2.6886    | 2.0633    | 1.9376    | 1.9728    |
| 18   | 2.0058    | 1.9839    | 2.0119    | 2.6612    | 2.0995    | 1.8861    | 2.0995    |
| 19   | 2.3819    | 2.2382    | 2.3411    | 2.9127    | 2.4977    | 2.0919    | 2.4615    |
| 20   | 2.3834    | 2.0517    | 2.0919    | 2.7721    | 2.5606    | 2.0233    | 2.4874    |
| 21   | 2.1434    | 2.0517    | 1.9669    | 2.3045    | 2.1948    | 1.9719    | 2.1216    |
| 22   | 1.7635    | 1.5775    | 1.749     | 1.7558    | 2.0119    | 1.749     | 2.0119    |
| 23   | 1.5604    | 1.56      | 1.6118    | 1.701     | 1.6095    | 1.5432    | 1.5364    |
| 24   | 2.9996    | 1.3904    | 1.3717    | 1.4403    | 1.6461    | 1.5154    | 1.4403    |
| Max  | 2.9996    | 2.8669    | 2.8487    | 2.9127    | 3.1232    | 3.1459    | 2.8166    |
| Min  | 1.1145    | .2926     | 1.3226    | 1.3375    | 1.6095    | 1.5154    | 1.3717    |
| Avg  | 2.0494    | 1.8614    | 1.8937    | 2.1740    | 2.1719    | 2.1073    | 2.0551    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 207 / 11 KV Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0373     | .0373     | .0373     | .0373     | .1109     | .0732     | .112      |
| 2    | .0373     | .0373     | .0373     | .0373     | .0366     | .0732     | .112      |
| 3    | .0373     | .0373     | .0373     | .0373     | .0366     | .0732     | .1463     |
| 4    | .1829     | .1494     | .0747     | .0373     | .0554     | .1097     | .2195     |
| 5    | .2926     | .1829     | .1829     | .0373     | .0549     | .2218     | .2195     |
| 6    | .2743     | .2587     | .2378     | .0373     | .1848     | .2353     | .2614     |
| 7    | .2743     | .2926     | .2561     | .0373     | .2743     | .2743     | .2743     |
| 8    | .2743     | .2926     | .2378     | .0373     | .2195     | .2195     | .2195     |
| 9    |           | .2561     |           | .037      | .2402     | .2012     | .2241     |
| 10   | .2195     | .2743     |           | .2957     | .2587     | .2801     | .2801     |
| 11   | .2926     | .2743     |           | .2987     | .2587     | .2614     | .2801     |
| 12   | .2772     | .2926     |           | .2614     | .2218     | .2241     | .2241     |
| 13   | .2614     |           |           | .2614     | .2772     | .2987     | .2218     |
| 14   | .2378     | .2195     |           | .2241     | .2772     | .2987     | .2957     |
| 15   | .2195     | .2743     |           | .2218     | .2801     | .2987     | .3142     |
| 16   | .2195     | .2926     | .2926     | .2218     | .2054     | .2427     | .2402     |
| 17   | .2353     | .2957     | .2926     | .1848     | .112      | .1463     | .1478     |
| 18   | .1629     | .2378     | .1097     | .2402     | .1494     | .128      | .1829     |
| 19   | .2534     | .2378     | .0366     | .2218     | .2241     | .2561     | .2402     |
| 20   | .2378     | .2378     | .0373     | .2195     | .1829     | .2561     | .2195     |
| 21   | .2195     | .2378     | .0373     | .2378     | .1829     | .2561     | .2378     |
| 22   | .2195     | .2218     | .0373     | .2378     | .2195     | .2561     | .2195     |
| 23   | .2195     | 1.5775    | .0373     | .2195     | .1463     | .2378     | .2195     |
| 24   | .4087     | .2012     | .1478     | .0373     | .1829     | .1478     | .1829     |
| Max  | .4087     | 1.5775    | .2926     | .2987     | .2801     | .2987     | .3142     |
| Min  | .0373     | .0373     | .0366     | .037      | .0366     | .0732     | .112      |
| Avg  | .2215     | .2791     | .1253     | .1550     | .1830     | .2113     | .2206     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014001 / 33/11 kv sutgirani

Feeder No / Name : 208 / SHIRSGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1829     |           | .1829     | .1646     | .1646     | .1646     | .1646     |
| 2    | .1829     | .1829     | .1829     | .1646     | .1829     | .1663     | .1646     |
| 3    | .2012     | .2012     | .2012     | .1646     | .2218     | .2012     | .1829     |
| 4    | .2561     | .2561     | .2195     | .2058     | .2743     | .2402     | .2149     |
| 5    |           | .2926     | .2561     | .3292     | .2926     | .2772     | .2561     |
| 6    | .567      | .3658     | .4024     | .4382     | .3547     | .3292     | .3856     |
| 7    | .567      | .4207     | .5487     | .4908     | .4805     | .5359     | .5258     |
| 8    | .5258     | .4557     | .4557     | .4908     | .4938     | .5359     | .4938     |
| 9    |           | .439      |           | .4854     | .4805     | .4755     | .4294     |
| 10   | .3841     | .3511     |           | .3547     | .3547     | .3174     | .3361     |
| 11   | .3511     | .3475     |           | .3174     | .3361     | .3174     | .2801     |
| 12   | .2378     | .2587     |           | .2427     | .2987     | .2614     | .2427     |
| 13   | .2195     | .2561     |           | .2241     | .2427     | .2427     | .2218     |
| 14   | .2378     |           |           | .2427     | .2427     | .2241     | .2402     |
| 15   | .2561     | .2561     | .2561     | .2801     | .2614     | .2427     | .2772     |
| 16   | .2926     | 3.9323    | .3326     | .2987     | .2801     | .3361     | .2957     |
| 17   | .3012     | .3224     | .3109     | .2772     | .3174     | .3109     | .3142     |
| 18   | .3366     | .3681     | .3292     | .3326     | .3547     | .3658     | .3326     |
| 19   | .3898     | .4031     | .3658     |           | .4108     | .4207     | .3881     |
| 20   | .439      | .394      | .3292     |           | .3658     | .3658     | .3841     |
| 21   | .3475     | .3475     | .3109     |           | .3292     | .3109     | .3841     |
| 22   | .2195     | .2378     | .2561     |           | .2561     | .2743     | .2561     |
| 23   | .2378     | .2378     | .2012     |           | .2012     | .2012     | .1829     |
| 24   | .4207     | .2012     | .2012     | .1829     | .2033     | .1646     | .1848     |
| Max  | .567      | 3.9323    | .5487     | .4908     | .4938     | .5359     | .5258     |
| Min  | .1829     | .1829     | .1829     | .1646     | .1646     | .1646     | .1646     |
| Avg  | .3252     | .4785     | .2968     | .2993     | .3084     | .3034     | .2974     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 201 / 11 Kv Kesapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .1492     | 1.5083    | 1.6206    |
| 6    |           |           |           | .2818     | .2818     | 1.7238    | 1.8708    |
| 8    |           |           |           |           |           | 2.1714    | 2.2542    |
| 9    |           |           | .1823     |           |           | 1.9559    |           |
| 10   |           |           | .1658     |           |           |           | .1147     |
| 11   |           |           | .1326     |           |           |           |           |
| 12   |           |           | 2.3137    |           | 2.2542    |           |           |
| 13   | 2.3102    |           |           | 2.2211    |           |           |           |
| 15   |           | 2.431     | 2.2377    |           |           |           |           |
| 16   |           |           |           |           | 2.1879    |           |           |
| 17   |           | 2.3137    | 2.1879    |           | 2.1216    |           |           |
| 18   |           |           |           |           | 2.2211    |           |           |
| 19   |           |           |           | 2.1051    | 1.9227    |           |           |
| 20   |           | .3018     | .2486     |           |           | .2652     |           |
| 24   |           |           |           | .1492     | 1.4586    |           |           |
| Max  | 2.3102    | 2.431     | 2.3137    | 2.2211    | 2.2542    | 2.1714    | 2.2542    |
| Min  | 2.3102    | .3018     | .1326     | .1492     | .1492     | .2652     | .1147     |
| Avg  | 2.3102    | 1.6822    | 1.0669    | 1.1893    | 1.5746    | 1.5249    | 1.4651    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 202 / 11 KV VALADGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .4668     |
| Max  | .4668     |
| Min  | .4668     |
| Avg  | .4668     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 203 / 11 KV CHANDEGAON AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

| DATE | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.8233    |           |           | 2.0317    | .1475     | .1638     |
| 6    |           |           | 2.2447    | 2.2283    | .2458     | .2785     |
| 7    |           |           | 2.4741    | 2.5069    |           |           |
| 8    |           |           |           | 2.5396    |           |           |
| 9    |           | .3932     | 2.5396    | 2.4741    |           |           |
| 10   |           | .1638     |           |           |           | .1802     |
| 11   |           | .0983     |           |           |           |           |
| 12   |           |           |           |           | 2.4939    | 2.6379    |
| 14   |           |           |           |           |           | 2.6379    |
| 16   |           |           |           |           | 2.5425    | 2.5232    |
| 17   |           |           |           |           | 2.3967    | 2.4741    |
| 18   |           |           |           |           | 2.5101    | 2.4413    |
| 19   |           |           |           |           | ***       | 2.3758    |
| 20   | .1823     | .2294     |           |           | .2591     |           |
| 24   |           |           | 1.9826    | .1475     |           |           |
| Max  | 1.8233    | .3932     | 2.5396    | 2.5396    | 23.2063   | 2.6379    |
| Min  | .1823     | .0983     | 1.9826    | .1475     | .1475     | .1638     |
| Avg  | 1.0028    | .2212     | 2.3103    | 1.9880    | 4.2252    | 1.7459    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 204 / 11 KV MALUNJA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | 2.0153    | .1715     | .1524     |
| 6    |           |           |           | 2.3922    | 2.2834    | .2858     | .2858     |
| 7    |           |           |           | 2.9984    | 2.6852    |           |           |
| 8    |           |           |           |           | 3.0333    |           |           |
| 9    |           | 2.8182    | 2.7035    | 2.7854    | 2.8178    |           |           |
| 10   |           |           | .1802     |           |           |           | .1475     |
| 11   |           |           | .1334     |           |           |           |           |
| 12   |           |           |           |           |           | 3.0148    | 3.0607    |
| 13   | 2.6707    |           |           |           |           |           |           |
| 14   |           |           |           |           |           |           | 2.8502    |
| 15   |           | .0953     |           |           |           |           |           |
| 16   |           |           |           |           |           | 2.9984    | 2.8502    |
| 17   |           | .0762     |           |           |           | 2.9165    | 2.8988    |
| 18   |           |           |           |           |           | 2.7526    | 2.6707    |
| 19   |           |           |           |           |           | 2.3266    | 2.3158    |
| 20   |           | .2477     | .2477     |           |           | .2667     |           |
| 24   |           |           |           | 1.9662    | .1905     |           |           |
| Max  | 2.6707    | 2.8182    | 2.7035    | 2.9984    | 3.0333    | 3.0148    | 3.0607    |
| Min  | 2.6707    | .0762     | .1334     | 1.9662    | .1905     | .1715     | .1475     |
| Avg  | 2.6707    | .8094     | .8162     | 2.5356    | 2.1709    | 1.8416    | 1.9147    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 205 / 11 KV BELAPUR TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .4119     | .4119     | .3769     |
| 6    |           |           |           | .6433     | .6626     | .6805     | .6427     |
| 7    |           |           |           | 1.0566    | .985      |           |           |
| 8    |           |           |           |           | 1.0924    | 1.1283    | 1.1247    |
| 9    |           | .9214     | .9745     | .8417     | 1.0387    | .9134     |           |
| 10   |           |           |           |           |           |           | .8775     |
| 11   |           |           | .7442     |           |           |           |           |
| 12   |           |           | .7265     |           | .7343     | .7164     | .6984     |
| 13   | .7888     |           |           | .6089     |           |           |           |
| 14   |           |           |           |           |           |           | .6447     |
| 15   |           | .9214     | .5847     |           |           |           |           |
| 16   |           |           |           | .5552     | .6268     | .5731     | .5731     |
| 17   |           | .7265     | .6201     | .6805     | .6984     | .6805     | .6805     |
| 18   |           |           |           | .6984     | .7164     | .7522     | .7522     |
| 19   |           |           |           | .8238     | .8059     | .8238     | .8059     |
| 20   |           | .8859     | .7701     |           |           | .7701     |           |
| 24   |           |           | .7973     | .4298     | .4298     |           |           |
| Max  | .7888     | .9214     | .9745     | 1.0566    | 1.0924    | 1.1283    | 1.1247    |
| Min  | .7888     | .7265     | .5847     | .4298     | .4119     | .4119     | .3769     |
| Avg  | .7888     | .8638     | .7453     | .7042     | .7457     | .7450     | .7177     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 206 / 11 KV WALADGAON GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .1334     | .1307     | .128      |
| 6    |           |           |           | .1715     | .2096     | .1715     | .2286     |
| 7    |           |           |           | .2477     | .2667     |           |           |
| 8    |           |           |           |           | .2667     | .2477     | .2075     |
| 9    |           | .2858     | .2477     | .2667     | .3239     | .2096     |           |
| 10   |           |           | .2096     |           |           |           | .2204     |
| 11   |           |           | .1715     |           |           |           |           |
| 12   |           |           | .1524     |           | .2096     | .2896     | .2865     |
| 13   | .3429     |           |           | .2427     |           |           |           |
| 14   |           |           |           |           |           |           | .2507     |
| 15   |           | .1905     | .1524     |           |           |           |           |
| 16   |           |           |           | .2774     | .2286     | .2353     | .2507     |
| 17   |           | .2667     | .1715     | .2481     | .3239     | .3224     | .3224     |
| 18   |           |           |           | .1949     | .2667     | .1905     | .197      |
| 19   |           |           |           | .2303     | .2667     | .2477     | .2507     |
| 20   |           | .2858     | .2328     |           |           | .2507     |           |
| 24   |           |           |           | .1254     | .1296     |           | .3224     |
| Max  | .3429     | .2858     | .2477     | .2774     | .3239     | .3224     | .3224     |
| Min  | .3429     | .1905     | .1524     | .1254     | .1296     | .1307     | .128      |
| Avg  | .3429     | .2572     | .1911     | .2227     | .2387     | .2296     | .2423     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 207 / 11 KV UKKALGAON GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .2328     | .2587     | .2402     |
| 6    |           |           |           | .4024     | .3841     | .439      | .4024     |
| 7    |           |           |           | .5068     | .5175     |           |           |
| 8    |           |           |           |           | .5729     | .5487     | .5121     |
| 9    |           | .3801     | .3841     | .4207     |           | .5068     |           |
| 10   |           |           | .4024     |           |           |           | .3121     |
| 11   |           |           | .2534     |           |           |           |           |
| 12   |           |           | .2667     |           |           | .2454     | .2658     |
| 13   |           |           |           | .2534     |           |           |           |
| 14   |           |           |           |           |           |           | .2328     |
| 15   |           | .3045     | .2858     |           |           |           |           |
| 16   |           |           |           | .2715     |           | .298      | .2481     |
| 17   |           | .3224     | .2658     | .2715     | .3801     | .3045     | .2686     |
| 18   |           |           |           | .3982     | .4344     | .4344     | .3761     |
| 19   |           |           |           | .4887     | .4706     | .4525     | .4656     |
| 20   |           | .4706     | .4477     |           |           | .4477     |           |
| 24   | .3982     |           |           | .2427     | .2715     |           | .2686     |
| Max  | .3982     | .4706     | .4477     | .5068     | .5729     | .5487     | .5121     |
| Min  | .3982     | .3045     | .2534     | .2427     | .2328     | .2454     | .2328     |
| Avg  | .3982     | .3694     | .3294     | .3618     | .4080     | .3936     | .3266     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 208 / 11 KV PADHEGAON GAO

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .2427     | .2614     | .2587     |
| 6    |           |           |           | .4668     | .4207     | .4525     | .4763     |
| 7    |           |           |           | .5121     | .499      |           |           |
| 8    |           |           |           |           | .5228     | .5304     | .5175     |
| 9    |           | .4525     | .439      | .4805     | .4435     | .4706     |           |
| 10   |           |           | .3511     |           |           |           | .2543     |
| 11   |           |           | .2896     |           |           |           |           |
| 12   |           |           | .2587     |           | .2812     | .2279     | .2454     |
| 13   | .4706     |           |           | .2103     |           |           |           |
| 14   |           |           |           |           |           |           | .2279     |
| 15   |           | .2865     | .2667     |           |           |           |           |
| 16   |           |           |           | .3366     | .2968     | .2303     | .2629     |
| 17   |           | .3761     | .3366     | .3366     | .3801     | .3224     | .3403     |
| 18   |           |           |           | .3982     | .4525     | .4163     | .394      |
| 19   |           |           |           | .4706     | .4887     | .4706     | .5014     |
| 20   |           | .124      | .4298     |           |           | .4119     |           |
| 24   |           |           |           | .2328     | .2743     |           |           |
| Max  | .4706     | .4525     | .439      | .5121     | .5228     | .5304     | .5175     |
| Min  | .4706     | .124      | .2587     | .2103     | .2427     | .2279     | .2279     |
| Avg  | .4706     | .3098     | .3388     | .3827     | .3911     | .3794     | .3479     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 209 / 11 KV UKKALGAON Ag      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | .1524     | 1.4746    | 1.5565    |
| 6    |           |           |           | .2286     | .1905     | 1.7166    | 1.6842    |
| 8    |           |           |           |           |           | 2.3205    | 2.2211    |
| 9    |           | .1524     | .1905     |           |           | 2.2542    |           |
| 10   |           |           | .1524     |           |           |           | .1143     |
| 11   |           |           | .1143     |           |           |           |           |
| 12   |           |           | 2.4741    |           | 2.4249    |           |           |
| 13   | .0762     |           |           | 2.4249    |           |           |           |
| 15   |           | 2.304     | 2.536     |           |           |           |           |
| 16   |           |           |           | 2.3758    | 2.4577    |           |           |
| 17   |           | 2.4863    | 2.3537    | 2.0972    | 2.1464    |           |           |
| 18   |           |           |           | 2.304     | 2.2775    |           |           |
| 19   |           |           |           | 2.0222    | 2.2283    |           |           |
| 20   |           | .1989     | .2286     |           |           | .2096     |           |
| 24   | .607      |           |           | .1715     | 1.4091    |           |           |
| Max  | .607      | 2.4863    | 2.536     | 2.4249    | 2.4577    | 2.3205    | 2.2211    |
| Min  | .0762     | .1524     | .1143     | .1715     | .1524     | .2096     | .1143     |
| Avg  | .3416     | 1.2854    | 1.1499    | 1.6606    | 1.6609    | 1.5951    | 1.3940    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014002 / 33/11 belapur Sub Station

Feeder No / Name : 210 / 11 KV RAMGAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           |           |           |           | 1.0608    | .1492     | .1492     |
| 6    |           |           |           | 1.3094    | 1.2266    | .1823     | .1658     |
| 7    |           |           |           | 1.5912    | 1.5912    |           |           |
| 8    |           |           |           |           | 1.7238    |           |           |
| 9    |           | 1.6907    | 1.5581    | 1.4918    | 1.6078    |           |           |
| 10   |           |           | .116      |           |           |           | .1677     |
| 11   |           |           | .1029     |           |           |           |           |
| 12   |           |           |           |           |           | 1.9227    | 1.8107    |
| 13   | 1.5083    |           |           |           |           |           |           |
| 14   |           |           |           |           |           |           | 1.8778    |
| 15   |           | .0829     |           |           |           |           |           |
| 16   |           |           |           |           |           | 1.8233    | ***       |
| 17   |           | .0829     |           |           |           | 1.7901    | 1.7772    |
| 18   |           |           |           |           |           | 1.6244    | 1.6766    |
| 19   |           |           |           |           |           | 1.5581    | 1.4419    |
| 20   |           | .1989     | .2155     |           | .2155     | .2155     |           |
| 24   |           |           |           | 1.0277    | .1658     |           |           |
| Max  | 1.5083    | 1.6907    | 1.5581    | 1.5912    | 1.7238    | 1.9227    | 17.1011   |
| Min  | 1.5083    | .0829     | .1029     | 1.0277    | .1658     | .1492     | .1492     |
| Avg  | 1.5083    | .5139     | .4981     | 1.3550    | 1.0845    | 1.1582    | 2.9076    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 201 / BHOKAR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | 1.0402    | .1406     | 2.6246    |
| Max  | 1.0402    | .1406     | 2.6246    |
| Min  | 1.0402    | .1406     | 2.6246    |
| Avg  | 1.0402    | .1406     | 2.6246    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 202 / KAMALPUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | .144      | 2.2028    | .1718     |
| Max  | .144      | 2.2028    | .1718     |
| Min  | .144      | 2.2028    | .1718     |
| Avg  | .144      | 2.2028    | .1718     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 203 / 11 KV MALWADGAON  
(KHANAPUR) Feeder KV- 11 /  
OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | .1562     | .1875     | .1875     |
| Max  | .1562     | .1875     | .1875     |
| Min  | .1562     | .1875     | .1875     |
| Avg  | .1562     | .1875     | .1875     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 204 / GHUMANDEV GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 | 02-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | .181      | .2149     | .181      |
| Max  | .181      | .2149     | .181      |
| Min  | .181      | .2149     | .181      |
| Avg  | .181      | .2149     | .181      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 206 / VADALA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 |
|------|-----------|-----------|
| HR   | Load (MW) | Load (MW) |
| 24   | 1.8976    | .125      |
| Max  | 1.8976    | .125      |
| Min  | 1.8976    | .125      |
| Avg  | 1.8976    | .125      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 207 / KHOKAR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | .0949     | 1.8435    | .125      |
| Max  | .0949     | 1.8435    | .125      |
| Min  | .0949     | 1.8435    | .125      |
| Avg  | .0949     | 1.8435    | .125      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 208 / KAREGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | 3.0623    | 1.9372    | .125      |
| Max  | 3.0623    | 1.9372    | .125      |
| Min  | 3.0623    | 1.9372    | .125      |
| Avg  | 3.0623    | 1.9372    | .125      |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014003 / 33/11 KV BHOKAR

Feeder No / Name : 209 / WADALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) |
| 24   | .4298     | .4706     | .4557     |
| Max  | .4298     | .4706     | .4557     |
| Min  | .4298     | .4706     | .4557     |
| Avg  | .4298     | .4706     | .4557     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014125 / MIDC SUBSTATION

Feeder No / Name : 201 / 11 Kv MIDC feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.1317    | .9526     | .9145     | 1.6975    | .4763     | 1.094     | 1.226     |
| 2    | 1.1317    | .9145     | .9907     | 1.6032    | .4763     | 1.0562    | 1.1317    |
| 3    | 1.1317    | .8573     | 1.086     | 1.5089    | .4572     | 1.0185    | 1.1317    |
| 4    | 1.226     | .9335     | 1.1622    | 1.5089    | .4954     | 1.0185    | 1.1317    |
| 5    | 1.3203    | .9526     | 1.2003    | 1.5089    | .5906     | 1.0562    | 1.1317    |
| 6    | 1.0374    | .9717     | 1.2955    | 1.4146    | .6287     | 1.094     | 1.0374    |
| 7    | 1.0374    | 1.0098    | 1.3146    | .9431     | .743      | 1.1506    | 1.1317    |
| 8    | 1.1317    | 1.086     | .6668     | .7545     | .7049     | 1.2826    | 1.3203    |
| 9    | 1.4146    | 1.3527    | 1.3717    | .7545     | 1.1622    | 1.4146    | 1.4146    |
| 10   | 1.7918    | 1.773     | 1.7918    | .5716     | 1.4523    | 1.8861    | 2.0005    |
| 11   | 1.9805    | 2.0748    | 1.9805    | .6287     | 2.1691    | 2.0748    | 2.0957    |
| 12   | 1.8107    | 2.1691    |           | .5525     | 1.905     | 2.0748    | 1.9814    |
| 13   | 1.773     | 2.0559    | 2.0748    |           | 2.3011    | 2.0748    | 1.6004    |
| 14   | 1.6787    | 1.9616    | 2.2634    | .724      | 2.2634    | 1.8861    | 1.5623    |
| 15   | 1.8296    | 2.0748    | 2.0748    | .6478     | 2.2257    | 1.8861    | 1.5813    |
| 16   | 1.905     | 2.1313    | 2.0748    | .5906     | 2.1691    | 2.0748    | 1.6956    |
| 17   | 1.773     | 1.9805    | 2.3577    | .5716     | 1.9805    | 1.8861    | 1.7718    |
| 18   | 1.6221    | 1.5844    | 2.0748    |           | 1.5466    | 1.6975    | 1.4289    |
| 19   | 1.3957    | 1.4335    | 2.0748    | .5906     | 1.4146    | .9431     | 1.3146    |
| 20   | 1.3203    | 1.3014    | 1.8861    |           | 1.3014    | 1.6975    | 1.2955    |
| 21   | 1.0185    | 1.2071    | 1.8861    | .6668     | 1.2826    | 1.3203    | 1.2765    |
| 22   | .9717     | 1.2765    | 1.7918    | .5906     | 1.226     | 1.226     | 1.2071    |
| 23   | 1.0098    | 1.0479    | 1.7918    | .5144     | 1.1694    | 1.226     | 1.0185    |
| 24   | 1.9986    | .9907     | .9526     | 1.7918    | .4763     | 1.1317    | 1.226     |
| Max  | 1.9986    | 2.1691    | 2.3577    | 1.7918    | 2.3011    | 2.0748    | 2.0957    |
| Min  | .9717     | .8573     | .6668     | .5144     | .4572     | .9431     | 1.0185    |
| Avg  | 1.4351    | 1.4206    | 1.6121    | .9588     | 1.2757    | 1.4696    | 1.4047    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014125 / MIDC SUBSTATION

Feeder No / Name : 202 / 11 KV WAKADI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0924     | .1143     | .1334     | .0924     | .1334     | .0895     | .0924     |
| 2    | .0924     | .1143     | .1334     | .0924     | .1334     | .0895     | .0924     |
| 3    | .0924     | .1143     | .1143     | .0924     | .1143     | .0895     | .0924     |
| 4    | .0924     | .1143     | .1143     | .1294     | .0953     | .0895     | .0924     |
| 5    | .0924     | .1143     | .0953     | .1294     | .0953     | .1075     | .0924     |
| 6    | .0924     | .1143     | .0953     | .1294     | .1524     | .1254     | .1478     |
| 7    | .0924     | .1143     | .1143     | .0924     | .1715     | .1612     | .0924     |
| 8    | .0924     | .1143     | .1143     | .0924     | .1905     | .1867     | .0924     |
| 9    | .0924     | .1905     | .2096     | .0924     | .1905     | .1867     | .0924     |
| 10   | .0895     | .2149     | .2772     | .2096     | .2328     | .3696     | .2858     |
| 11   | .1075     | .2507     | .1848     | .1524     | .2507     | .2772     | .381      |
| 12   | .0716     | .2865     | .2772     | 1.6575    | .1433     | .3696     | .3239     |
| 13   | .0895     | .2149     | .1848     | .0572     | .2149     | .3696     | .3048     |
| 14   | .1075     | .1075     | .2218     | .0762     | .2865     | .2772     | .3048     |
| 15   | .1075     | .1433     | .1848     | .1143     | .2507     | .2772     | .3048     |
| 16   | .1254     | .2378     | .1848     | .0953     | .2149     | .1848     | .3048     |
| 17   | .1433     | .2263     | .1848     | .1143     | .2328     | .1715     | .2858     |
| 18   | .1791     | .2075     | .2772     | .1334     | .2507     | .1848     | .2667     |
| 19   | .2149     | .2263     | .3696     | .1524     | .2149     | .1848     | .362      |
| 20   | .2507     | .2829     | .462      |           | .1254     | .1886     | .2096     |
| 21   | .2149     | .2641     | .2772     | .1524     | .1075     | .2772     | .1334     |
| 22   | .2286     | .2477     | .1848     | .1524     | .0895     | .1848     | .1307     |
| 23   | .1143     | .1715     | .0924     | .1524     | .0716     | .1848     | .1494     |
| 24   | .2772     | .1143     | .1334     | .0924     | .1334     | .2772     | .1478     |
| Max  | .2772     | .2865     | .462      | 1.6575    | .2865     | .3696     | .381      |
| Min  | .0716     | .1075     | .0924     | .0572     | .0716     | .0895     | .0924     |
| Avg  | .1314     | .1792     | .1925     | .1850     | .1707     | .2044     | .1993     |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014125 / MIDC SUBSTATION

Feeder No / Name : 203 / INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2936    | 1.2384    | 1.2193    | 1.386     | 1.3717    | 1.3014    | 1.386     |
| 2    | 1.2936    | 1.2765    | 1.1622    | 1.2936    | 1.3336    | 1.2826    | 1.386     |
| 3    | 1.2936    | 1.5051    | 1.448     | 1.386     | 1.2955    | 1.2637    | 1.2936    |
| 4    | 1.386     | 1.6385    | 1.6956    | 1.2536    | 1.5051    | 1.2449    | 1.4784    |
| 5    | 1.5708    | 2.0576    | 1.8861    | 1.4784    | 1.7528    | 1.2826    | 1.6032    |
| 6    | 1.7556    | 2.2291    | 2.1338    | 1.6632    | 1.9814    | 1.7353    | 1.8861    |
| 7    | 2.4025    | 2.3243    | 2.4196    | 2.2177    | 2.1719    | 2.3011    | 1.848     |
| 8    | 2.4949    | 2.4387    | 2.5339    | 2.3101    | 2.4387    | 2.2068    | 2.4949    |
| 9    | 2.1253    | 2.4387    | 2.1529    | 2.2177    | 2.191     | 2.0748    | 2.2177    |
| 10   | 1.9805    | 1.8484    | 2.0883    | 2.0195    | 2.0182    | 2.0328    | 2.0957    |
| 11   | 1.8296    | 1.8484    | 1.9404    | 1.9243    | 1.9239    | 1.9404    | 2.0005    |
| 12   | 1.8673    | 1.8673    | 1.848     | 1.8671    | 1.8484    | 1.848     | 2.0957    |
| 13   | 1.7353    |           | 1.9404    | 1.8099    | 1.8107    | 1.848     | 1.829     |
| 14   | 1.6221    |           | 1.7556    | 1.7528    | 1.773     | 1.848     | 1.7909    |
| 15   | 1.5844    | 2.0748    | 1.7556    | 1.8671    | 1.7353    | 1.848     | 1.7718    |
| 16   | 1.6032    | 1.905     | 1.6632    | 1.829     | 1.773     | 1.9404    | 1.848     |
| 17   | 1.6221    | 1.9239    | 1.7918    | 2.0005    | 1.8296    | 1.9404    | 1.9814    |
| 18   | 1.9805    | 1.9993    | 1.848     | 2.191     | 1.8861    | 2.0328    | 2.0767    |
| 19   | 2.3577    | 2.2634    | 2.5463    | 2.3434    | 2.1691    | 2.1253    | 2.4196    |
| 20   | 2.1691    | 2.1502    | 2.4949    |           | 1.9616    | 1.848     | 2.1529    |
| 21   | 1.8861    | 1.8861    | 2.2177    | 1.8861    | 1.7164    | 1.848     | 1.9243    |
| 22   | 1.6575    | 1.6956    | 1.7556    | 1.6385    | 1.5844    | 1.5708    | 1.6975    |
| 23   | 1.3717    | 1.3717    | 1.6632    | 1.5051    | 1.4335    | 1.4784    | 1.4146    |
| 24   | 1.2936    | 1.2955    | 1.2384    | 1.386     | 1.4289    | 1.358     | 1.386     |
| Max  | 2.4949    | 2.4387    | 2.5463    | 2.3434    | 2.4387    | 2.3011    | 2.4949    |
| Min  | 1.2936    | 1.2384    | 1.1622    | 1.2536    | 1.2955    | 1.2449    | 1.2936    |
| Avg  | 1.7574    | 1.8762    | 1.8833    | 1.7925    | 1.7889    | 1.7584    | 1.8366    |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014125 / MIDC SUBSTATION

Feeder No / Name : 204 / NEW TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2536    | 1.2955    | 1.105     | 1.3432    | 1.2955    | 1.2894    | 1.2536    |
| 2    | 1.1641    | 1.2384    | 1.1812    | 1.2536    | 1.2384    | 1.2536    | 1.2536    |
| 3    | 1.1641    | 1.3527    | 1.2384    | 1.1641    | 1.4861    | 1.2178    | 1.2536    |
| 4    | 1.1641    | 1.5623    | 1.448     | 1.1643    | 1.5813    | 1.2178    | 1.1641    |
| 5    | 1.3432    | 1.7718    | 1.6575    | 1.3073    | 1.6575    | 1.3253    | 1.2536    |
| 6    | 1.5223    | 2.0005    | 1.8671    | 1.4864    | 1.8671    | 1.5581    | 1.5223    |
| 7    | 2.2386    | 2.21      | 2.0767    | 1.8804    | 1.9624    | 2.0416    | 1.5223    |
| 8    | 2.3282    | 2.191     | 2.2672    | 2.1491    | 2.1148    | 2.0774    | 2.2386    |
| 9    | 2.0595    | 2.191     | 2.0005    | 2.1491    | 2.0576    | 1.8625    | 1.97      |
| 10   | 1.8804    | 1.8625    | 1.7909    | 1.848     | 1.773     | 1.97      | 2.0005    |
| 11   | 1.9342    | 1.7909    | 1.7013    | 1.7909    | 1.7193    | 1.7013    | 1.9052    |
| 12   | 1.8625    | 1.7193    | 1.7909    | 1.6575    | 1.6834    | 1.7013    | 1.7528    |
| 13   | 1.6834    | 1.773     | 1.8804    | 1.5623    | 1.5223    | 1.7013    | 1.6385    |
| 14   | 1.5043    | 1.5043    | 1.7013    | 1.5242    | 1.3253    | 1.6118    | 1.6004    |
| 15   | 1.5402    | 1.6118    | 1.6118    | 1.5813    | 1.3073    | 1.6975    | 1.5623    |
| 16   | 1.5939    | 1.6834    | 1.6118    | 1.6004    | 1.3611    | 1.5432    | 1.6385    |
| 17   | 1.6834    | 1.7193    | 1.7013    | 1.7528    | 1.4506    | 1.7013    | 1.7718    |
| 18   | 1.8446    | 1.8804    | 1.7909    | 2.1148    | 1.5223    | 1.7013    | 1.848     |
| 19   | 2.2207    | 2.1312    | 2.1491    | 2.2862    | 2.1132    | 2.2386    | 2.3434    |
| 20   | 2.1491    | 2.0416    | 2.4177    |           | 1.9342    | 1.97      | 2.0576    |
| 21   | 1.6834    | 1.7193    | 2.1491    | 1.8671    | 1.6834    | 1.7013    | 1.9052    |
| 22   | 1.6194    | 1.6194    | 1.7013    | 1.6956    | 1.5223    | 1.5223    | 1.5581    |
| 23   | 1.3336    | 1.2193    | 1.6118    | 1.4861    | 1.4327    | 1.3073    | 1.2715    |
| 24   | 1.2536    | 1.3336    | 1.1241    | 1.3432    | 1.4098    | 1.3611    | 1.2894    |
| Max  | 2.3282    | 2.21      | 2.4177    | 2.2862    | 2.1148    | 2.2386    | 2.3434    |
| Min  | 1.1641    | 1.2193    | 1.105     | 1.1641    | 1.2384    | 1.2178    | 1.1641    |
| Avg  | 1.6677    | 1.7259    | 1.7323    | 1.6525    | 1.6259    | 1.6364    | 1.6490    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014125 / MIDC SUBSTATION

Feeder No / Name : 205 / Prabhat  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .9431     | .8002     | 1.105     | 1.0374    | 1.105     | 1.0562    | 1.226     |
| 2    | .9431     | .7621     | 1.0479    | 1.226     | 1.0479    | 1.0185    | 1.226     |
| 3    | 1.0374    | .8192     | .9526     | 1.3203    | 1.1241    | 1.0185    | 1.3203    |
| 4    | 1.0374    | .8954     | 1.6956    | 1.3203    | 1.2765    | 1.0562    | 1.3203    |
| 5    | .9431     | .9526     | 1.0098    | 1.3203    | 1.4289    | 1.0751    | 1.4146    |
| 6    | 1.0374    | 1.0098    | 1.086     | 1.4146    | 1.5051    | 1.1317    | 1.4146    |
| 7    | 1.0374    | 1.0479    | 1.1241    | 1.5089    | 1.448     | 1.3392    | 1.4146    |
| 8    | 1.1317    | .9717     | .724      | 1.3203    | 1.3717    | 1.4712    | 1.4003    |
| 9    | 1.226     | .9717     | 1.1431    | 1.5089    | 1.6385    | 1.8296    | 1.6032    |
| 10   | 1.2449    | 1.2071    | 1.1317    | 1.4289    | 1.2826    | 1.8861    | 1.4289    |
| 11   | 1.2826    | 1.3392    | 1.1317    | 1.5051    | 1.4712    | 1.6032    | 1.2384    |
| 12   | 1.2826    | 1.3392    | 1.1317    | 1.4098    | .8488     | 1.6975    | 1.5051    |
| 13   | 1.2071    | 1.3957    | 1.0374    | 1.3908    | 1.2826    | 1.5089    |           |
| 14   | 1.1317    |           | 1.1317    | 1.3336    | 1.2071    | 1.5089    | .8192     |
| 15   | 1.1128    | 1.2071    | 1.3203    | 1.2955    | 1.226     | 1.4146    | 1.0479    |
| 16   | 1.094     | 1.3957    | 1.3203    | 1.0669    | 1.2826    | 1.3203    | 1.086     |
| 17   | 1.0562    | 1.3957    | 1.3203    | 1.2955    | 1.2449    | 1.226     | 1.1431    |
| 18   | 1.0374    | 1.3769    | .9431     | 1.2384    | 1.226     | 1.226     | 1.1812    |
| 19   | 1.0185    | 1.2826    | .9431     | 1.2193    | 1.1694    | 1.226     | 1.2955    |
| 20   | .9431     | 1.2071    | .924      |           | 1.094     | 1.1317    | 1.1812    |
| 21   | .9054     | 1.2449    | 1.0164    | 1.4289    | 1.0562    | 1.1317    | 1.1241    |
| 22   | .8383     | 1.0669    | .9431     | 1.3336    | 1.094     | 1.226     | 1.0185    |
| 23   | .8954     | 1.0479    | 1.0374    | 1.1812    | 1.0562    | 1.226     | .8676     |
| 24   | .9431     | .8573     | 1.086     | 1.0374    | 1.1431    | 1.0751    | 1.226     |
| Max  | 1.2826    | 1.3957    | 1.6956    | 1.5089    | 1.6385    | 1.8861    | 1.6032    |
| Min  | .8383     | .7621     | .724      | 1.0374    | .8488     | 1.0185    | .8192     |
| Avg  | 1.0554    | 1.1128    | 1.0961    | 1.3105    | 1.2346    | 1.3085    | 1.2392    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 201 / TAKALIBHAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.5423    | 1.9845    | 2.4874    | 1.4723    | 2.1445    |           | .2204     |
| 2    | 2.5972    | 1.9845    | 2.4714    | 1.5203    |           |           | .208      |
| 3    | 2.6337    | 2.0805    | 2.5072    |           | 2.1765    |           | .208      |
| 4    | 2.7069    | 2.2725    | 2.561     | 1.7444    | 2.2405    |           | .2241     |
| 5    | 2.7618    | 2.4006    | 2.6863    | 2.0805    | 2.4326    |           | .2241     |
| 6    | 2.9447    | 2.5301    | 3.0266    | 2.451     | 2.4827    |           |           |
| 7    | 3.0361    | 2.5777    | 2.8296    | 2.8464    | 2.4996    |           | .2241     |
| 8    | 3.9872    | 3.3432    | 3.3471    | 3.0464    | 3.3745    |           |           |
| 9    | 3.4568    |           | 3.6214    | 2.9683    | 3.1714    |           |           |
| 10   | .1865     |           |           |           |           |           | 3.4631    |
| 11   | .1865     |           |           |           |           |           | 3.4888    |
| 12   |           |           |           |           |           |           | 3.3998    |
| 14   |           |           |           |           |           |           | 3.5932    |
| 15   |           |           |           |           |           |           | 3.5932    |
| 16   |           |           |           |           |           |           | 3.558     |
| 17   |           |           |           |           |           | 3.8775    |           |
| 18   |           |           |           |           |           | .1357     |           |
| 19   | .2267     |           |           |           |           | .2204     |           |
| 20   | .2561     |           | .208      |           | .2241     | .2713     |           |
| 21   | .2401     |           | .2267     | .192      | .192      | .2543     |           |
| 22   | .208      |           | .2241     | .192      | .2401     | .2374     |           |
| 23   | .192      |           | .2241     | .208      | .2401     | .2374     |           |
| 24   | 2.4508    |           |           |           |           | .192      | .2204     |
| Max  | 3.9872    | 3.3432    | 3.6214    | 3.0464    | 3.3745    | 3.8775    | 3.5932    |
| Min  | .1865     | 1.9845    | .208      | .192      | .192      | .1357     | .208      |
| Avg  | 1.8008    | 2.3967    | 2.0324    | 1.7020    | 1.7849    | .6783     | 1.7404    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 202 / PUNATGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.3535    | 1.0631    | 1.2689    | 1.1469    | .192      | .0474     | .0848     |
| 2    | 1.3717    | 1.0631    | 1.3176    | 1.1961    |           | .0474     | .08       |
| 3    | 1.3535    | 1.0974    | 1.4083    |           | 1.1702    |           | .08       |
| 4    | 1.3535    | 1.1317    | 1.4449    | 1.278     | 1.2018    |           | .08       |
| 5    | 1.3352    | 1.166     | 1.4083    | 1.3441    | 1.2334    | .0633     | .08       |
| 6    | 1.4083    | 1.2003    | 1.5364    | 1.4251    | 1.3283    | .0633     | .08       |
| 7    | 1.5729    | 1.4232    | 1.6461    | 1.5546    | 1.5339    | .0474     |           |
| 8    | 1.6461    | 1.6289    | 1.7924    | 1.6804    | 1.5935    |           |           |
| 9    | 1.701     | 1.6289    | 1.9204    | 1.4403    | 1.5623    |           |           |
| 10   |           | .0686     | .0469     |           | .0848     |           | .08       |
| 11   |           | .0514     | .0324     |           | .0509     |           | .08       |
| 12   |           |           |           |           |           |           | 2.0005    |
| 14   |           |           | 2.0405    |           |           |           | 1.9845    |
| 15   |           |           |           |           |           |           | 1.9524    |
| 16   |           |           |           |           |           |           | 1.6804    |
| 17   |           |           |           |           |           | 2.1948    |           |
| 18   |           |           |           |           |           | 2.1765    |           |
| 19   | .0857     |           |           |           |           | 1.8656    |           |
| 20   | .1029     |           | .1134     |           | .1107     | .1357     |           |
| 21   | .0857     |           | .0972     | .0949     | .0949     | .1187     |           |
| 22   | .0686     |           | .081      |           | .0791     | .1187     |           |
| 23   | .0514     |           | .081      | .0791     | .0633     | .1187     |           |
| 24   | 1.2986    |           | 2.0405    |           |           |           | .0848     |
| Max  | 1.701     | 1.6289    | 2.0405    | 1.6804    | 1.5935    | 2.1948    | 2.0005    |
| Min  | .0514     | .0514     | .0324     | .0791     | .0509     | .0474     | .08       |
| Avg  | .9859     | 1.0475    | 1.0751    | 1.1240    | .7357     | .5831     | .6421     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 203 / PACHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 2.6155    | .0678     | 2.0805    | 2.1765    | .112      | .1526     |
| 2    | 2.5972    |           | 2.1445    |           | .112      | .144      |
| 3    | 2.6337    | .0509     |           | 2.2085    |           |           |
| 4    | 2.6886    | .0509     | 2.3685    | 2.2405    |           | .144      |
| 5    | 2.7252    | .1017     | 2.4352    | 2.3205    | .128      | .16       |
| 6    | 2.8715    | .1187     | 2.6092    | 2.6092    | .1406     | .176      |
| 7    | 3.4934    | .1696     | 2.8121    | 2.8902    | .16       |           |
| 8    | 3.6214    | 2.9264    | 3.0407    | 3.0152    |           |           |
| 9    | 3.3471    | 3.8409    | 3.0464    | 2.734     |           |           |
| 10   |           | .112      |           | .1067     |           | .112      |
| 11   |           | .112      |           | .1187     |           | 3.4789    |
| 14   |           | 2.9635    |           |           |           | 3.6008    |
| 16   |           |           |           |           |           | 3.2026    |
| 17   |           |           |           |           | 3.4385    |           |
| 18   |           |           |           |           | 3.53      |           |
| 19   | .112      |           |           | .112      | 2.9447    |           |
| 20   | .176      | .144      |           | .144      |           |           |
| 21   | .16       | .144      | .144      |           | .2035     |           |
| 22   | .16       | .144      | .144      | .128      | .1696     |           |
| 23   | .144      | .112      | .128      | .112      | .1696     |           |
| 24   | 2.5972    |           |           |           |           | .1526     |
| Max  | 3.6214    | 3.8409    | 3.0464    | 3.0152    | 3.53      | 3.6008    |
| Min  | .112      | .0509     | .128      | .1067     | .112      | .112      |
| Avg  | 1.9962    | .7372     | 1.9048    | 1.494     | 1.0099    | 1.1324    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 204 / 11 KV WANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .112      | .1526     | .144      | .096      | 2.0005    | 2.6703    |
| 2    | .1174     | .112      | .1526     | .144      |           | 2.0485    | 2.4646    |
| 3    | .1174     |           | .1543     |           | .096      | 2.0805    | 2.4806    |
| 4    | .1174     | .1107     | .1526     | .144      | .096      |           | 2.5286    |
| 5    | .1174     | .128      | .1526     | .16       | .112      | 2.3685    | 2.5459    |
| 6    | .1174     | .128      | .1696     | .144      | .112      | 2.5617    |           |
| 7    |           |           | .1865     |           |           | 2.8464    | 2.8902    |
| 8    |           |           |           |           |           | 2.8902    | 2.8746    |
| 9    |           |           |           |           |           | 2.6558    | 2.5777    |
| 10   |           |           | .16       |           | .1526     |           |           |
| 11   | .128      |           |           |           | .1187     |           | .112      |
| 12   | 2.9447    | 2.3122    | 3.0152    |           |           |           |           |
| 13   | 2.9527    | 2.359     | 2.9371    |           | 2.8487    |           |           |
| 14   | 3.1245    | 2.3122    | 2.8902    |           | 3.086     |           |           |
| 15   | 2.9839    | 2.5152    | 2.8121    |           |           |           |           |
| 16   | .2812     | 2.3122    | 2.9995    |           | 3.2895    |           |           |
| 17   |           | 2.2028    | 2.8121    |           | 3.3105    |           |           |
| 18   | 2.609     |           |           |           | 3.1626    | .1187     |           |
| 19   | 2.4215    |           |           |           | 2.6882    | .1526     |           |
| 20   | .192      |           | .176      |           | .192      |           |           |
| 21   | .176      |           | .176      | 2.1091    | 2.1091    | .1865     |           |
| 22   | .16       |           | .16       | 2.1091    | .16       | .1696     |           |
| 23   | .144      |           | .16       | 2.1285    | .144      | .1357     |           |
| 24   | .1187     |           |           |           |           |           | 2.6703    |
| Max  | 3.1245    | 2.5152    | 3.0152    | 2.1285    | 3.3105    | 2.8902    | 2.8902    |
| Min  | .1174     | .1107     | .1526     | .144      | .096      | .1187     | .112      |
| Avg  | 1.0457    | 1.3277    | 1.0788    | .8853     | 1.2808    | 1.5550    | 2.3815    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 205 / KAREGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .144      | .1526     | .144      | .128      | 1.6804    | 2.0119    |
| 2    | .1509     | .144      |           | .144      |           | 1.7284    | 1.7924    |
| 3    | .1509     | .144      | .1526     |           | .128      | 1.7924    | 1.8244    |
| 4    | .1509     | .144      | .1526     | .144      | .128      |           | 1.8404    |
| 5    | .1509     | .16       | .1526     | .16       | .144      | 2.0165    |           |
| 6    | .1509     | .16       | .1526     | .16       | .144      | 2.0873    |           |
| 7    |           |           | .1526     |           |           | 2.1872    | 2.2184    |
| 8    |           |           |           |           |           | 2.9729    | 2.5934    |
| 9    |           |           |           |           |           | 2.734     | 2.6715    |
| 10   |           |           | .16       |           | .1187     |           | .064      |
| 11   | .112      |           |           |           |           |           | .064      |
| 12   | 2.5309    | 2.8433    | 2.9683    |           | 3.2007    |           |           |
| 13   | 2.6558    | 2.8277    | 3.0464    |           | 3.4751    |           |           |
| 14   | 2.6871    | 2.8589    |           |           | 3.219     |           |           |
| 15   | 2.8746    | 2.9995    | 2.7496    |           |           |           |           |
| 16   | 2.6558    | 2.7808    | 2.8121    |           |           |           |           |
| 17   |           | 2.6715    | 2.7808    |           | 3.091     |           |           |
| 18   | 2.5621    |           |           |           | 2.9607    | .0678     |           |
| 19   | 2.2184    |           |           |           | 2.5286    | .1357     |           |
| 20   | .208      |           | .176      |           | .192      |           |           |
| 21   | .192      |           | .176      | 2.1822    |           | .1357     |           |
| 22   | .176      |           | .16       | 2.2497    | .144      | .1187     |           |
| 23   | .16       |           | .16       | 2.0778    | .112      | .1017     |           |
| 24   | .1357     |           |           |           |           |           | 2.0119    |
| Max  | 2.8746    | 2.9995    | 3.0464    | 2.2497    | 3.4751    | 2.9729    | 2.6715    |
| Min  | .112      | .144      | .1526     | .144      | .112      | .0678     | .064      |
| Avg  | 1.1068    | 1.4898    | 1.0066    | .9077     | 1.3143    | 1.3661    | 1.7092    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 206 / GHOGARGAON GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .3052     | .3292     | .3222     | .3658     | .4024     |           | .1387     |
| 2    | .3052     | .3292     | .3391     | .3658     |           |           | .3841     |
| 3    | .3052     | .3292     | .373      |           | .4024     |           | .4024     |
| 4    | .4748     | .3658     |           | .4572     | .4938     |           | .4755     |
| 5    | .5256     | .5304     | .5765     | .5121     | .5487     |           | .6036     |
| 6    | .7122     | .7133     | .6783     | .6401     | .823      |           |           |
| 7    | .6783     | .7682     | .7122     | .8048     | .7865     |           | .7783     |
| 8    |           |           | .5765     | .7316     |           |           |           |
| 10   | .5765     |           |           |           |           |           | .4525     |
| 11   | .4748     |           |           |           |           |           | .4163     |
| 12   | .373      | .3258     | .5792     |           |           |           | .2715     |
| 13   | .2713     | .2534     | .543      |           |           |           |           |
| 14   | .3052     | .1991     |           |           |           |           | .2896     |
| 15   | .3391     | .197      | .362      |           |           |           |           |
| 16   | .4938     | .2328     |           |           |           |           |           |
| 17   |           | .3258     |           |           |           | .407      |           |
| 18   | .4938     |           |           |           | .8048     | .4409     |           |
| 19   | .6219     |           |           |           | .823      | .7461     |           |
| 20   | .6219     |           | .7682     |           | .823      | .7291     |           |
| 21   | .5121     |           | .7316     | .695      | .695      | .1187     |           |
| 22   | .439      |           | .5853     | .7682     | .6401     | .1187     |           |
| 23   | .3658     |           | .3841     | .6036     | .5487     | .4748     |           |
| 24   | .3222     |           |           |           |           |           | .39       |
| Max  | .7122     | .7682     | .7682     | .8048     | .823      | .7461     | .7783     |
| Min  | .2713     | .197      | .3222     | .3658     | .4024     | .1187     | .1387     |
| Avg  | .4532     | .3769     | .5379     | .5944     | .6493     | .4336     | .4184     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 207 / GUJARWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / INCOMING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    |           | .1227     |           | .1578     | .1052     | .1578     | .1526     |
| 2    | .1187     | .1227     | .1526     | .1578     |           | .1578     | .1578     |
| 3    | .1187     | .1227     | .1526     |           | .1052     | .1753     | .1578     |
| 4    | .1696     | .2279     | .2374     | .1753     | .1578     |           | .1928     |
| 5    | .2543     |           |           | .2279     | .1928     | .2804     | .2804     |
| 6    | .3222     | .2804     | .3222     | .2743     | .2629     | .3086     |           |
| 7    | .39       | .3601     | .39       | .3944     | .3944     | .3429     | .3772     |
| 8    | .3222     |           | .3222     | .3429     | .4287     |           | .3086     |
| 9    | .2713     | .2743     |           |           |           |           | .2572     |
| 10   |           | .2229     | .2229     |           | .3052     |           | .2401     |
| 11   | .1715     | .1715     | .2058     |           | .2374     |           |           |
| 12   | .1715     | .1543     | .1715     |           | .1017     |           | .1886     |
| 13   | .12       |           | .1372     |           | .1865     |           |           |
| 14   | .12       |           | .1029     |           |           |           | .1715     |
| 15   | .12       |           | .1029     |           |           |           | .1715     |
| 16   | .1372     |           | .1543     |           |           |           | .1715     |
| 17   |           | .2058     | .2058     |           |           | .2035     |           |
| 18   | .1886     |           |           |           | .3155     | .2204     |           |
| 19   | .2804     |           |           |           | .3856     | .2883     |           |
| 20   | .2629     |           | .2804     |           | .4031     | .2713     |           |
| 21   | .2103     |           | .2454     | .333      | .333      | .2543     |           |
| 22   | .1578     |           | .2103     | .298      | .2103     | .1865     |           |
| 23   | .1227     |           | .1753     | .1928     | .1578     | .1696     |           |
| 24   | .1357     |           |           |           |           |           | .1526     |
| Max  | .39       | .3601     | .39       | .3944     | .4287     | .3429     | .3772     |
| Min  | .1187     | .1227     | .1029     | .1578     | .1017     | .1578     | .1526     |
| Avg  | .1984     | .2059     | .2107     | .2554     | .2519     | .2321     | .2129     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014126 / 33/11 KV TAKALIBHAN

Feeder No / Name : 209 / JAINPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1341     | .144      | .1509     | .16       | .16       | 3.2808    | 2.5972    |
| 2    | .1174     | .144      | .1509     | .16       |           | 3.1207    | 2.2405    |
| 3    | .1174     | .144      | .1509     |           | .16       | 3.1687    | 2.2725    |
| 4    | .1341     | .144      | .1844     | .16       | .16       |           | 2.2725    |
| 5    | .1677     | .16       | .1865     | .176      | .176      | 3.5932    | 2.2455    |
| 6    | .2035     |           | .2035     | .192      | .192      | 3.7182    |           |
| 7    |           |           | .2035     |           |           | 3.7494    | 2.3746    |
| 8    |           |           |           |           |           |           | 2.4996    |
| 9    |           |           |           |           |           |           | 2.1559    |
| 10   |           | 3.4473    | 3.7807    |           | 3.6946    |           |           |
| 11   | .1187     | 3.6212    | 3.4682    |           | 3.7677    |           |           |
| 12   | 2.9081    | 3.1943    | 1.4842    |           | 3.6214    |           |           |
| 13   | 3.1093    | 3.1245    | 1.5935    |           | 3.8409    |           |           |
| 14   | 2.8349    | 3.1245    | 3.1245    |           | 3.53      |           |           |
| 15   | 3.1642    | 3.1245    | 3.0308    |           |           |           |           |
| 16   |           | 3.0464    | 3.5932    |           |           |           |           |
| 17   |           | 3.1245    | 3.7494    |           |           |           |           |
| 18   | 2.2613    |           |           |           |           | .373      |           |
| 19   | 2.451     |           |           |           | .192      | .0848     |           |
| 20   | .2401     |           | .2429     |           | .208      | .1526     |           |
| 21   | .208      |           | .2429     | .2401     | .2401     | .1187     |           |
| 22   | .208      |           | .2401     |           | .192      | .2374     |           |
| 23   | .176      |           | .192      | .2401     | .192      |           |           |
| 24   | .1187     |           |           |           |           |           | 2.5972    |
| Max  | 3.1642    | 3.6212    | 3.7807    | .2401     | 3.8409    | 3.7494    | 2.5972    |
| Min  | .1174     | .144      | .1509     | .16       | .16       | .0848     | 2.1559    |
| Avg  | 1.0374    | 2.0418    | 1.367     | .1897     | 1.3551    | 1.9634    | 2.3617    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014127 / 33/11 kV HAREGAON

Feeder No / Name : 201 / MALWADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .7202     |           | .7545     | 2.2405    |           | 2.3491    |
| 2    | .7202     |           | .7545     | 2.2405    |           | 2.0881    |
| 3    | .7716     |           | .7545     | 2.2862    |           | 2.1491    |
| 4    | .7716     |           | .7716     | 2.2862    |           | 2.1795    |
| 5    | .7888     |           | .7716     | 2.3167    |           | 2.21      |
| 6    | .7888     |           | .7888     | 2.3472    |           | 2.3167    |
| 7    |           |           | .7373     | 2.4082    |           | 2.4539    |
| 8    | .7545     |           |           | 2.4691    |           | 2.5301    |
| 9    | .7716     |           |           | 2.0881    |           | 2.1795    |
| 10   |           | .7373     | .6859     |           | .6859     | .7373     |
| 11   |           | .7545     | .6554     |           | .6706     | .7545     |
| 12   |           | 2.8464    | 2.7435    |           |           |           |
| 13   |           | 2.8121    | 2.713     |           |           | .703      |
| 14   |           | 2.8292    | 2.7435    |           |           | .703      |
| 15   |           | 2.8978    | 2.8045    |           |           | .703      |
| 16   |           | 3.1207    | 2.7587    |           |           | .3258     |
| 17   |           | 3.0521    | 2.6978    |           |           | .3429     |
| 18   |           | 3.1207    | 2.5911    |           | .7011     | .3601     |
| 19   |           | 2.7435    | 2.5453    |           | .6859     | .4287     |
| 20   |           | .7545     | .7011     |           | .7011     | .4287     |
| 21   |           | .7716     | .7011     |           | .7011     | .4115     |
| 22   |           | .7888     | .6859     |           | .7011     | .4115     |
| 23   |           | .8059     | .6554     |           | .7011     | .4115     |
| 24   | .7716     | 3.1207    | .7716     | 2.2405    |           | 2.0424    |
| Max  | .7888     | 3.1207    | 2.8045    | 2.4691    | .7011     | 2.5301    |
| Min  | .7202     | .7373     | .6554     | 2.0881    | .6706     | .3258     |
| Avg  | .7621     | 2.0771    | 1.4448    | 2.2923    | .6935     | 1.2704    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014127 / 33/11 kV HAREGAON

Feeder No / Name : 202 / UNDIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2689    |           | 1.2003    | .1981     |           | .2134     |
| 2    | 1.2689    |           | 1.2003    | .1981     |           | .2134     |
| 3    | 1.3717    |           | 1.2689    | .2286     |           | .2591     |
| 4    | 1.5089    |           | 1.3717    | .2591     |           | .2743     |
| 5    | 1.6461    |           | 1.4746    | .2591     |           | .2896     |
| 6    | 1.8176    |           | 1.6118    | .3201     |           | .3353     |
| 7    | 2.2119    |           | 2.1776    | .4115     |           | .4268     |
| 8    | 2.332     |           | 2.1434    | .3658     |           | .381      |
| 9    | 2.1605    |           | 2.0233    | .2896     |           | .3353     |
| 10   |           | .2058     | .1886     |           | .1981     | .1543     |
| 11   |           | .1886     | .1372     |           | .2286     | .1543     |
| 12   |           | .1715     | .1219     |           | 1.9357    | 1.9719    |
| 13   |           | .1372     | .0914     |           | 1.9814    | 2.3491    |
| 14   |           |           | .0914     |           | 2.0881    | 2.1434    |
| 15   |           | .1029     | .0762     |           | 2.0729    | 2.1434    |
| 16   |           | .1029     | .1067     |           | 2.1033    | 2.2291    |
| 17   |           | .1543     | .1219     |           | 2.1338    | 2.1605    |
| 18   |           | .1886     | .1829     |           | 2.0119    | 2.0919    |
| 19   |           | .3258     | .3048     |           | 1.768     | 1.9547    |
| 20   |           | .3258     | .3201     |           | .2591     |           |
| 21   |           | .2572     | .2743     |           | .2591     |           |
| 22   |           | .2401     | .2439     |           | .2286     |           |
| 23   |           | .2058     | .1829     |           | .1829     |           |
| 24   | 1.2003    |           | 1.2003    | .2134     |           | .1829     |
| Max  | 2.332     | .3258     | 2.1776    | .4115     | 2.1338    | 2.3491    |
| Min  | 1.2003    | .1029     | .0762     | .1981     | .1829     | .1543     |
| Avg  | 1.6787    | .2005     | .7549     | .2743     | 1.2465    | 1.0132    |

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014127 / 33/11 kV HAREGAON

Feeder No / Name : 203 / TEXTILE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | 1.2346    |           | 1.166     | .1829     |           | .1677     |
| 2    | 1.2346    |           | 1.166     | .1829     |           | .1677     |
| 3    | 1.3032    |           | 1.2689    | .1981     |           | .1677     |
| 4    | 1.4403    |           | 1.3717    | .1981     |           | .1981     |
| 5    | 1.6289    |           | 1.5089    | .1981     |           | .1981     |
| 6    | 1.7661    |           | 1.6804    | .2134     |           | .2286     |
| 7    | 2.1948    |           | 2.2634    | .2591     |           | .2743     |
| 8    | 2.452     |           | 2.1948    | .2743     |           | .2439     |
| 9    | 2.1605    |           | 2.1605    | .2134     |           | .1829     |
| 10   |           | .1715     | .1524     |           | .2286     | .2229     |
| 11   |           | .1543     | .1524     |           | .2134     | .2401     |
| 12   |           | .1372     | .1524     |           | 2.0271    | 2.3148    |
| 13   |           | .12       | .0914     |           | 2.1338    | 2.6235    |
| 14   |           |           | .0914     |           | 2.1948    | 2.4863    |
| 15   |           | .1029     | .0914     |           | 2.1643    | 2.2291    |
| 16   |           | .12       | .1524     |           | 2.1338    | 2.1262    |
| 17   |           | .12       | .1829     |           | 2.0119    | 2.1262    |
| 18   |           | .12       | .1981     |           | 1.9357    | 2.1091    |
| 19   |           | .3258     | .1981     |           | 1.768     | 1.9547    |
| 20   |           | .2743     | .2134     |           | .2896     |           |
| 21   |           | .2572     | .2134     |           | .2591     |           |
| 22   |           | .2401     | .2134     |           | .2134     |           |
| 23   |           | .2229     | .1981     |           | .1677     |           |
| 24   | 1.2003    |           | 1.166     | .1524     |           | .1677     |
| Max  | 2.452     | .3258     | 2.2634    | .2743     | 2.1948    | 2.6235    |
| Min  | 1.2003    | .1029     | .0914     | .1524     | .1677     | .1677     |
| Avg  | 1.6615    | .1820     | .7603     | .2073     | 1.2672    | 1.0215    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014127 / 33/11 kV HAREGAON

Feeder No / Name : 204 / 11 KV HAREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .1372     |           | .1372     | .1715     |           | .1715     |
| 2    | .1372     |           | .1372     | .1715     |           | .1715     |
| 3    | .1715     |           | .1372     | .1715     |           | .2229     |
| 4    | .2058     |           | .1715     | .2229     |           | .2572     |
| 5    | .2401     |           | .1829     | .2401     |           | .2572     |
| 6    | .3086     |           | .2743     | .2915     |           | .3086     |
| 7    | .3772     |           | .4115     | .4115     |           | .4287     |
| 8    | .3772     |           |           | .3772     |           | .3601     |
| 9    | .3086     |           |           | .2743     |           | .3086     |
| 10   |           | .2572     | .2229     |           | .3429     | .2743     |
| 11   |           | .2401     | .1715     |           | .2743     | .2229     |
| 12   |           | .2058     | .1715     |           | .2572     |           |
| 13   |           | .1886     | .1715     |           | .2229     | .2058     |
| 14   |           | .1886     | .1715     |           | .1886     | .1543     |
| 15   |           | .1886     | .1543     |           | .2058     | .1372     |
| 16   |           | .1886     | .1715     |           | .2401     | .1372     |
| 17   |           | .2229     | .2058     |           | .2743     | .1543     |
| 18   |           | .2915     | .2401     |           | .2743     | .1886     |
| 19   |           | .3429     | .2572     |           | .2915     | .3086     |
| 20   |           | .3429     | .2743     |           | .3086     |           |
| 21   |           | .2572     | .2229     |           | .2743     |           |
| 22   |           | .2058     | .2058     |           | .2401     |           |
| 23   |           | .1715     | .1715     |           | .1886     |           |
| 24   | .1372     |           | .1372     | .1715     |           | .1886     |
| Max  | .3772     | .3429     | .4115     | .4115     | .3429     | .4287     |
| Min  | .1372     | .1715     | .1372     | .1715     | .1886     | .1372     |
| Avg  | .2401     | .2352     | .2001     | .2504     | .2560     | .2346     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014127 / 33/11 kV HAREGAON

Feeder No / Name : 205 / MALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1    | .0857     |           | .0857     | .0857     |           | .1029     |
| 2    | .0857     |           | .0857     | .0857     |           | .1029     |
| 3    | .12       |           | .12       | .1543     |           | .1543     |
| 4    | .1715     |           | .1543     | .1543     |           | .2229     |
| 5    | .2572     |           | .2058     | .2229     |           | .3258     |
| 6    | .4115     |           | .2915     | .2401     |           | .4287     |
| 7    |           |           | .3429     | .3086     |           |           |
| 8    | .3086     |           |           |           |           |           |
| 9    | .2915     |           |           |           |           |           |
| 10   |           | .12       | .2058     |           | .2058     | .1372     |
| 11   |           | .1029     | .12       |           | .1886     | .1372     |
| 12   |           | .1029     | .12       |           | .12       | .12       |
| 13   |           | .1029     | .1029     |           | .12       | .0857     |
| 14   |           |           | .1029     |           | .1029     | .0857     |
| 15   |           | .0857     | .1029     |           | .1029     | .0857     |
| 16   |           | .1372     | .1029     |           | .1029     | .0857     |
| 17   |           | .1715     | .1715     |           | .1372     | .12       |
| 18   |           | .1886     | .2058     |           | .1886     | .1886     |
| 19   |           | .2915     | .2058     |           | .2915     | .2915     |
| 20   |           | .2572     | .2229     |           | .2743     |           |
| 21   |           | .2058     | .1715     |           | .2058     |           |
| 22   |           | .1715     | .1543     |           | .2572     |           |
| 23   |           | .12       | .12       |           | .1029     |           |
| 24   | .1029     |           | .0857     | .1029     |           | .1029     |
| Max  | .4115     | .2915     | .3429     | .3086     | .2915     | .4287     |
| Min  | .0857     | .0857     | .0857     | .0857     | .1029     | .0857     |
| Avg  | .2038     | .1583     | .1582     | .1693     | .1715     | .1634     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 201 / MATULTHAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1457     |
| Max  | .1457     |
| Min  | .1457     |
| Avg  | .1457     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 202 / NAUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1187     |
| Max  | .1187     |
| Min  | .1187     |
| Avg  | .1187     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 203 / 11KV KHAIRI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .1204     |
| Max  | .1204     |
| Min  | .1204     |
| Avg  | .1204     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 204 / GONDEGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .0549     |
| Max  | .0549     |
| Min  | .0549     |
| Avg  | .0549     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 205 / 11 KV RAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .0549     |
| Max  | .0549     |
| Min  | .0549     |
| Avg  | .0549     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014128 / 33/11 kV NAIGAON

Feeder No / Name : 206 / 11 KV NIMGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 |
|------|-----------|
| HR   | Load (MW) |
| 24   | .0747     |
| Max  | .0747     |
| Min  | .0747     |
| Avg  | .0747     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 201 / 11 KV MATAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .3681     | .4294     | .3401     | .3856     | .3401     | 1.8343    |           |
| 7    |           |           |           |           |           | 2.0241    |           |
| 8    |           |           |           |           |           | 2.2653    |           |
| 9    |           |           |           |           |           | 2.1506    |           |
| 10   | .2534     | .3401     | .2949     |           | .4024     |           |           |
| 11   | .2195     | .2267     | .3113     | .2105     | .2743     |           |           |
| 12   | 2.1125    | 2.1765    | 2.2138    |           | 2.4006    |           |           |
| 13   |           | 2.1765    | 2.372     |           |           |           |           |
| 14   | 2.2996    | 2.1605    | 2.1822    |           | 2.3434    |           |           |
| 15   |           | 2.1605    | 2.1872    |           |           |           |           |
| 16   | 2.0679    |           | 2.0778    |           | 2.5606    |           |           |
| 17   |           |           |           |           | 2.3434    |           | .0486     |
| 18   | 1.9204    | 1.9524    | 2.1956    |           | 2.2184    |           |           |
| 19   | 2.0153    | 1.8724    | 2.0005    |           | 2.0271    |           | .2753     |
| 20   |           | .3887     |           |           |           |           |           |
| 21   |           | .3277     | .3391     |           |           |           |           |
| 22   | .2896     |           |           | .3887     | .2686     |           |           |
| 23   | .2353     | .1943     | .2534     | .2267     | .2561     |           | .2429     |
| 24   | .1372     | .2105     | .1943     | .1753     | .1619     |           | 1.5203    |
| Max  | 2.2996    | 2.1765    | 2.372     | .3887     | 2.5606    | 2.2653    | 1.5203    |
| Min  | .1372     | .1943     | .1943     | .1753     | .1619     | 1.8343    | .0486     |
| Avg  | 1.0835    | 1.1243    | 1.3048    | .2774     | 1.2997    | 2.0686    | .5218     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 202 / 11 KV BHERDAPUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 2.0729    | 2.2672    | 2.1605    | 2.4371    | 2.2405    | .3584     |           |
| 7    | 2.3179    | 2.5263    | 2.6246    | 2.6698    | 2.5926    |           |           |
| 8    | .7701     | 2.7044    | 2.7526    | 2.556     | 2.6886    |           |           |
| 9    | .7701     |           |           |           |           |           |           |
| 10   | .3801     | .3239     | .3077     |           | .3658     |           |           |
| 11   | .2303     | .2591     | .2896     | .1943     | .2926     |           |           |
| 12   |           |           |           |           |           |           | 2.6886    |
| 15   |           |           |           |           |           |           | 3.0407    |
| 16   |           |           |           |           |           |           | 2.7526    |
| 17   |           |           |           |           |           |           | 2.8807    |
| 18   |           |           |           |           |           |           | 2.7526    |
| 19   | .3696     | .3239     | .3005     |           | .3841     |           | 2.4646    |
| 20   |           | .3401     |           |           |           |           |           |
| 21   |           | .2949     | .3353     |           |           |           |           |
| 22   | .2804     |           |           | .3239     | .3258     |           |           |
| 23   | .2534     | .2267     | .2743     | .2105     | .2926     |           | .2429     |
| 24   | 1.6918    | 1.7924    | 1.8404    | 1.7654    | 1.8404    |           | .2267     |
| Max  | 2.3179    | 2.7044    | 2.7526    | 2.6698    | 2.6886    | .3584     | 3.0407    |
| Min  | .2303     | .2267     | .2743     | .1943     | .2926     | .3584     | .2267     |
| Avg  | .9137     | 1.1059    | 1.2095    | 1.451     | 1.2248    | .3584     | 2.1312    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 203 / 11 KV LADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .4588     | .4096     | .421      | .4359     | .4372     | 1.5777    |           |
| 7    |           |           |           |           |           | 2.0062    |           |
| 8    |           |           |           |           |           | 2.0553    |           |
| 9    |           |           |           |           |           | 2.1216    |           |
| 10   | .4024     | .3887     | .3681     |           | .4163     |           |           |
| 11   | .3658     | .3239     | .3681     | .3239     | .362      |           |           |
| 12   | 2.2213    | 1.9845    | 2.2186    |           | 2.1365    |           |           |
| 13   |           | 1.9524    | 2.1628    |           |           |           |           |
| 14   | 2.3908    | 1.8564    | 1.7859    |           | 1.9227    |           |           |
| 15   |           | 1.8084    | 1.9109    |           |           |           |           |
| 16   | 1.9559    |           | 2.0481    |           | 2.1216    |           |           |
| 17   |           |           |           |           | 2.1216    |           |           |
| 18   | 2.0317    | 1.9204    | 2.0119    |           | 2.0287    |           |           |
| 19   | 1.7604    | 1.7124    | 1.8143    |           | 1.7553    |           |           |
| 20   |           | .4049     |           |           |           |           |           |
| 21   |           | .3768     | .4382     |           |           |           |           |
| 22   | .3898     |           |           | .3887     | .4024     |           |           |
| 23   | .3982     | .3401     | .3982     | .3563     | .3801     |           | .3563     |
| 24   | .3605     | .3401     | .3401     | .3856     | .3563     |           | 1.3603    |
| Max  | 2.3908    | 1.9845    | 2.2186    | .4359     | 2.1365    | 2.1216    | 1.3603    |
| Min  | .3605     | .3239     | .3401     | .3239     | .3563     | 1.5777    | .3563     |
| Avg  | 1.1578    | 1.0630    | 1.2528    | .3781     | 1.2034    | 1.9402    | .8583     |



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 204 / 11 KV KAREGAON AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | 1.8244    | 1.8724    |           | 1.8982    | 1.829     | .3584     |           |
| 7    | 2.1862    | 2.1862    | 2.5149    | 2.2809    | 2.4082    |           |           |
| 8    | 2.5465    | 2.7035    | 2.6368    | 2.3805    | 2.5301    |           |           |
| 9    | 2.5777    | 2.2405    |           |           |           |           |           |
| 10   | .439      | .4843     | .4207     |           | .5487     |           |           |
| 11   | .3658     | .3549     | .2804     | .2469     | .362      |           |           |
| 12   |           |           |           |           |           |           | 2.3303    |
| 15   |           |           |           |           |           |           | 2.5606    |
| 17   |           |           |           |           |           |           | 2.713     |
| 18   |           |           |           |           |           |           | 2.5606    |
| 19   | .2641     | .2623     | .2172     |           | .3109     |           | 2.3472    |
| 20   |           | .4167     |           |           |           |           |           |
| 21   |           | .3906     | .5068     |           |           |           |           |
| 22   | .439      |           |           | .3858     | .3841     |           |           |
| 23   | .3544     | .3549     | .4557     | .2623     | .3439     |           | .3437     |
| 24   | 1.4289    | 1.4043    | 1.448     | 1.5154    | 1.448     |           | .2315     |
| Max  | 2.5777    | 2.7035    | 2.6368    | 2.3805    | 2.5301    | .3584     | 2.713     |
| Min  | .2641     | .2623     | .2172     | .2469     | .3109     | .3584     | .2315     |
| Avg  | 1.2426    | 1.1519    | 1.0601    | 1.2814    | 1.1294    | .3584     | 1.8696    |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 205 / 11KV MATAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .1928     | .1848     | .1781     | .1753     | .1457     | .2218     |           |
| 7    | .2454     | .2218     | .1943     | .2204     | .1943     | .2353     |           |
| 8    | .2103     | .2353     | .1943     | .1677     | .2105     | .2103     |           |
| 9    | .1928     | .2105     |           |           |           | .208      |           |
| 10   | .1402     | .2105     | .1684     | .2429     | .2601     |           |           |
| 11   | .2126     | .1619     | .1446     | .1619     | .208      |           |           |
| 12   | .128      | .1296     | .1147     |           | .0829     |           | .081      |
| 13   |           | .1296     | .0983     |           |           |           |           |
| 14   | .0972     | .1134     | .0838     |           | .0762     |           |           |
| 15   |           | .0972     | .0983     |           |           |           | .1134     |
| 16   | .108      |           | .1296     |           | .0995     |           | .1134     |
| 17   |           |           |           |           | .1543     |           | .1296     |
| 18   | .1581     | .1619     | .1638     |           | .144      |           | .1296     |
| 19   | .1629     | .1457     | .1753     |           | .1509     |           | .2105     |
| 20   |           | .1781     |           |           |           |           |           |
| 21   |           | .1475     | .2353     |           |           |           |           |
| 22   | .1595     |           |           | .2105     | .1387     |           |           |
| 23   | .1214     | .1134     | .1578     | .1296     | .1214     |           | .1296     |
| 24   | .0556     | .081      | .081      | .1086     | .0814     |           | .0972     |
| Max  | .2454     | .2353     | .2353     | .2429     | .2601     | .2353     | .2105     |
| Min  | .0556     | .081      | .081      | .1086     | .0762     | .208      | .081      |
| Avg  | .1561     | .1576     | .1478     | .1771     | .1477     | .2189     | .1255     |

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-FEB-17 and 07-FEB-17

NASIK ZONE[057]

A' NAGAR CIRCLE[570]

SHRIRAMPUR DIVISION[576]

SHRIRAMPUR S/DN.[839] BU 4839

Substation No/ Name :- 014129 / MATAPUR

Feeder No / Name : 206 / 11 KV BHERDAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 01-FEB-17 | 02-FEB-17 | 03-FEB-17 | 04-FEB-17 | 05-FEB-17 | 06-FEB-17 | 07-FEB-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR   | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 6    | .2572     | .2229     | .2401     | .2401     | .2601     | .2401     |           |
| 7    | .2915     | .2743     | .2915     | .2743     | .3052     | .2543     |           |
| 8    | .3258     | .2572     | .3086     | .2915     | .3391     | .2543     |           |
| 9    | .2915     | .2915     |           |           |           | .2743     |           |
| 10   | .2126     | .2774     | .2572     |           | .2126     |           |           |
| 11   | .1772     | .2279     | .2229     | .2254     | .2279     |           |           |
| 12   | .1753     | .1734     | .1886     |           | .1526     |           | .1357     |
| 13   |           | .1734     | .1715     |           |           |           |           |
| 14   | .1734     | .156      | .1715     |           | .2035     |           |           |
| 15   |           | .156      | .1886     |           |           |           | .1526     |
| 16   | .1734     |           | .2058     |           | .1865     |           | .1865     |
| 17   |           |           |           |           | .2572     |           | .1865     |
| 18   | .2229     | .2427     | .2401     |           | .2374     |           | .2035     |
| 19   | .2743     | .2774     | .2915     |           | .2915     |           | .2883     |
| 20   |           | .2804     |           |           |           |           |           |
| 21   |           | .2454     | .2743     |           |           |           |           |
| 22   | .156      |           |           | .298      | .1949     |           |           |
| 23   | .1417     | .1372     | .1715     | .1928     | .1417     |           | .1526     |
| 24   | .1372     | .1402     | .1372     | .1543     | .1578     |           | .1357     |
| Max  | .3258     | .2915     | .3086     | .298      | .3391     | .2743     | .2883     |
| Min  | .1372     | .1372     | .1372     | .1543     | .1417     | .2401     | .1357     |
| Avg  | .215      | .2208     | .2241     | .2395     | .2263     | .2558     | .1802     |