

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 201 / KIRPE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0735	.0785	1.2966	1.4876	1.4026	.0347	.0751
2	.0724	.0758	1.2715	1.4381	1.4304	.0343	.0732
3	.0568	.0758	1.2433	1.3977	1.3931	.0343	.0728
4	.0541	.0751	1.2486	1.3851	1.3821	.0343	.072
5	.0747	.0774	1.2971	1.4289	1.3569	.0385	.0762
6	.0873	.0884	1.4228	1.5009	1.4856	.096	.1013
7	.12	.1498	1.7391	1.768	1.749	.1051	.1391
8	.1169	.1482	2.0504	1.9524	1.9041	.1055	.1276
9	2.0877	2.0858	.9983	1.1286	.9259	2.2066	2.2992
10	2.6836	2.2668	.0629	.077	.0808	1.8496	2.5073
11	2.5172	2.4227	.0358	.0804	.0838	1.3618	2.6372
12	2.4905	2.4958	.0412	.0735	.0831	2.0809	2.5938
13	2.2878	2.4847	.0454	.0781	.1063	2.4623	2.5736
14	2.1159	2.3868	.0572	.0777	.1105	2.5621	2.4059
15	1.9422	2.3476	.0575	.0793	.0979	1.3729	2.3003
16	1.965	1.2334	.0617	.0781	.0876	2.4981	2.2336
17	.9305		.0922	.0777	.0819	1.1443	1.1248
18	.0602	.0918	.117	.0892	.1101	.0514	.0846
19	.1357	.1433	.1265	.1002	.1311	.0804	.0926
20	.1471	.157	.1318	.109	.136	.115	.1056
21	.1291	.1749	.1326	.0922	.1192	.1204	.1048
22	.1261	.1261	.125	.0945	.115	.1215	.0983
23	.1075	1.3755	1.1016	1.3684	.0838	.0956	.0857
24	.0812	.8135	1.4239	1.4804	.6478	.0827	.0789
Max	2.6836	2.4958	2.0504	1.9524	1.9041	2.5621	2.6372
Min	.0541	.0751	.0358	.0735	.0808	.0343	.072
Avg	.8526	.9293	.6742	.7268	.6294	.7787	.9193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 202 / CHACHEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.0343	.0343	.0343	.0343
3	.0343	.0343	.0343	.0343	.0343	.0343	.0343
4	.0343	.0343	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0343	.0343	.0343	.0343
8	.0343	.0343	.0343	.0343	.0343	.0343	.0343
9	.0343	.0343	.0343	.0343	.0343	.0343	.0343
10	.0343	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	.0343	.0343	.0343	.0343	.0343	.0343
12	.0343	.0343	.0343	.0343	.0343	.0343	.0343
13	.0343	.0343	.0343	.0343	.0343	.0343	.0343
14	.0343	.0343	.0343	.0343	.0343	.0343	.0343
15	.0343	.0343	.0343	.0343	.0343		.0343
16	.0343		.0343	.0343	.0343	.0343	.0343
17	.0343		.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0343	.0343	.0343	.0343	.0343	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 203 / DHEBEWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3772	.2915	.3086	.3429	.2915	.2743
2	.2572	.3429	.2743	.3086	.3086	.2743	.2743
3	.2572	.3086	.2572	.3086	.3086	.2572	.2743
4	.2572	.2915	.2743	.3086	.3086	.2743	.2915
5	.3086	.2915	.3086	.3429	.3086	.3429	.2915
6	.4115	.4458	.4458	.4115	.4115	.4115	.4287
7	.6173	.6516	.6516	.583	.5658	.583	.583
8	.5658	.5658	.583	.5487	.5487	.5487	.5144
9	.4801	.4458	.5144	.4115	.4801	.583	.4801
10	.463	.3944	.4973	.4458	.4115	.6516	.5316
11	.463	.4115	.583	.4287	.5487	.583	.5487
12	.5487	.4115	.4115	.4973	.4801	.4801	.5487
13	.4287	.3772	.4801	.4287	.4115	.3601	.4801
14	.4115	.3429	.463	.4115	.3944	.3429	.3429
15	.4115	.4458	.4973	.4458	.4973		.4287
16	.4973		.4801	.5144	.5487	.6001	.5658
17	.5487		.5316	.6001	.5487	.6516	.5144
18	.6001	.583	.6001	.6173	.7202	.583	.6001
19	.8059	.823	.6516	.6097	.7545	.7545	.5658
20	.8059	.8402	.7545	.6706	.7373	.7545	.6554
21	.7202	.7545	.7888	.6687	.6687	.6859	.6516
22	.6344	.6687	.6859	.6516	.5316	.583	.5144
23	.2572	.4458	.4458	.4115	.3429	.3944	.4801
24	1.5089	.3772	.3086	.3772	.3772	.3258	.2915
Max	1.5089	.8402	.7888	.6706	.7545	.7545	.6554
Min	.2572	.2915	.2572	.3086	.3086	.2572	.2743
Avg	.5223	.4817	.4908	.4713	.4815	.4920	.4638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 204 / KOLE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1543	.1372	.1543	.1372	.12
2	.12	.12	.1372	.1372	.1372	.1372	.1029
3	.12	.12	.1543	.1372	.1372	.1372	.1029
4	.1372	.1372	.1372	.1372	.1372	.1372	.12
5	.1715	.1372	.1372	.1715	.1715	.1715	.12
6	.2229	.2058	.2401	.2058	.2058	.2058	.2229
7	.3086	.3258	.3429	.2743	.3086	.3086	.2915
8	.2915	.2915	.2915	.2401	.3086	.2915	.2572
9	.2401	.2401	.2229	.2058	.2743	.2401	.2572
10	.2572	.2229	.2229	.2058	.2401	.2058	.2401
11	.2401	.2058	.2058	.2401	.2572	.2401	.2058
12	.2401	.2058	.2229	.2743	.2915	.2229	.2058
13	.2229	.2058	.2401	.2572	.2572	.2229	.2058
14	.2229	.2058	.2401	.2572	.2572	.2058	.2229
15	.1886	.2058	.2401	.2572	.2572		.1886
16	.2229		.2229	.2401	.2572	.2401	.2058
17	.2401		.2572	.2572	.2743	.1886	.2058
18	.2743	.3429	.2743	.2572	.2572	.2743	.2058
19	.3429	.4287	.3429	.3772	.3429	.3772	.2743
20	.3601	.3944	.3772	.3601	.3429	.3772	.3258
21	.3429	.3429	.3429	.3258	.3258	.3429	.3258
22	.3086	.3086	.2743	.3086	.2743	.2743	.3086
23	.1886	.2058	.1715	.1886	.1715	.1715	.1886
24		.1543	.1715	.1715	.1715	.1543	.1372
Max	.3601	.4287	.3772	.3772	.3429	.3772	.3258
Min	.12	.12	.1372	.1372	.1372	.1372	.1029
Avg	.2348	.2338	.2343	.2344	.2422	.2289	.2101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 205 / CHACHEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.948	.9495	.0343	.0343	.0343	.7407	.7979
2	.8741	.9396	.0343	.0343	.0343	.679	.7659
3	.8764	.9031	.0343	.0343	.0343	.6691	.721
4	.8764	.8924	.0343	.0343	.0343	.6668	.7149
5	.9053	.9435	.0343	.0343	.0343	.6957	.7019
6	.9355	1.0044	.0343	.0343	.0343	.7133	.727
7	1.2555	.6562	.0343	.0343	.0343	1.0197	1.0586
8	1.4685	1.1842	.0343	.0343	.0343	1.1294	1.1889
9	.7179	.6356	1.0033	.9366	1.1111	.5937	.5769
10	.0343	.0343	1.3366	1.3291	1.3428	.0343	.0343
11	.0343	.0343	1.4994	1.3016	1.3375	.0343	.0343
12	.0343	.0343	1.454	1.2994	1.1743	.0343	.0343
13	.0343	.0343	1.4175	1.2033	1.0205	.0343	.0343
14	.0343	.0343	1.387	1.15	.9664	.0343	.0343
15	.0343	.0343	1.2921	1.118	1.012		.0343
16	.0343		1.2331	1.1576	1.137	.0343	.0343
17	.0343		.6219	.6142	.5929	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.8246	.0343	.0343	.0343	.7209	.788	.7983
24	.9137	.442	.0343	.0343	.4763	.8242	.8025
Max	1.4685	1.1842	1.4994	1.3291	1.3428	1.1294	1.1889
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.4601	.4074	.4900	.4427	.4724	.3883	.3875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254002 / KOLEWADI

Feeder No / Name : 206 / TALMAVALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.2286	1.6461	1.5546	.0343	.0343
2	.0343	.0343	1.1279	1.6461	1.4937	.0343	.0343
3	.0343	.0343	1.1279	1.4632	1.4937	.0343	.0343
4	.0343	.0343	1.1431	1.4632	1.4937	.0343	.0343
5	.0343	.0343	1.1431	1.4632	1.5394	.0343	.0343
6	.0343	.0343	1.3108	1.5546	1.7985	.0343	.0343
7	.0343	.0343	1.6766	1.8595	1.9814	.0343	.0343
8	.0343	.0343	1.7985	2.4006	2.1643	.0343	.0343
9	2.692	2.2862	.0343	.0343	.0343	2.3472	3.155
10	2.8292	2.4387	.0343	.0343	.0343	1.1584	2.9835
11	2.572	2.4387	.0343	.0343	.0343	1.2803	3.3265
12	2.3491	2.3777	.0343	.0343	.0343	2.8654	3.2579
13	2.1948	1.9509	.0343	.0343	.0343	2.8959	3.1722
14	1.9547	1.768	.0343	.0343	.0343	2.774	3.0864
15	1.9376	1.7071	.0343	.0343	.0343		3.155
16	1.9547		.0343	.0343	.0343	2.7892	3.1379
17			.0343	.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	1.2193	1.8176	1.6461	.0343	.0343	.0343
24	3.4637	.0343	1.1888	1.749	1.6156	.0343	.0343
Max	3.4637	2.4387	1.8176	2.4006	2.1643	2.8959	3.3265
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.9751	.7576	.5435	.7238	.6521	.7243	1.0760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 201 / YELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6468	.759	.7011	.7253	.547	.5281
2	.5281	.6722	.759	.6622	.7186	.5281	.4904
3	.5093	.6348	.6895	.6622	.6773	.5281	.4904
4	.5281	.6535	.7253	.6836	.6773	.547	.5281
5	.6036	.6908	.7407	.743	.9659	.547	.5658
6	.9054	.8962	.8025	.9808	1.0002	.8488	.8676
7	1.0185	.961	1.2654	1.829	1.7311	1.1203	.9431
8	1.1317	.9877	1.4815	1.9509	1.5289	1.0456	.9054
9	2.2497	1.7833	.6838	.7023	.9145	2.2184	2.1247
10	2.2377	1.829	.6516	.7023	.7682	1.9218	2.0988
11	2.1872	1.5851	.6401	.7023	.724	1.8576	1.8595
12	2.0062	1.5851		.7207	.6805	1.7147	1.4937
13	1.9841	1.5851	.7133	.7207	.7265	1.5962	1.5546
14	1.9766	1.5851	.7059	.7392		1.3344	1.4632
15	1.8747	1.7071	.7316	.2012	.4961	1.5676	1.5242
16	1.7654	1.5935	.6697	.6626		1.4335	1.5089
17	.6626	.1612	.6154	.5847	.5895	.6762	.567
18	1.0631	.7619	.6805	.6464	.7265	.7842	.6135
19	1.4175	1.475	1.4146	1.2803	1.6078	1.4563	1.1888
20	1.8296	1.8858	1.8484	1.7558	1.9044	1.8484	1.7741
21	1.7741	1.8107	1.7353	1.647	1.7177	1.6975	1.7002
22	1.4045	1.5089	1.358	1.4864	1.3957	1.226	1.386
23	.8589	.8223	.8535	.7716	.6979	.7167	.7468
24	.6036	.6653	.7907	.7316	.7562	.5847	.6036
Max	2.2497	1.8858	1.8484	1.9509	1.9044	2.2184	2.1247
Min	.5093	.1612	.6154	.2012	.4961	.5281	.4904
Avg	1.3203	1.1870	.9268	.9278	.9877	1.1811	1.1469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 202 / YEWATI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7307	1.9505	.9057	.8673	.8871	1.0993	1.547
2	1.598	1.8181	.863	.8261	.8467	1.0471	1.4396
3	1.4754	1.7078	.86	.8048	.8193	.9976	1.3718
4	1.531	1.731	.8486	.8208	.801	1.0083	1.3375
5	1.7498	1.765	.9124	.9511	.9343	1.1275	1.4167
6	2.4074	2.2146	1.1763	1.3443	1.3464	1.9397	1.9536
7	3.879	3.5432	1.4742	1.5881	1.6293	3.1017	3.389
8	3.8088	3.7188	1.5051	1.5059	1.6186	3.1246	3.4896
9	.8595	1.3093	2.9821	3.5071	3.7837	1.2326	1.2598
10	.9875	.9355	4.4895	3.7872	3.7993	.9221	.9335
11	.8912	.788	4.1868	3.5591	3.7506	.8204	.8156
12	.8766	.8405	3.9727	3.3127	3.6222	.8405	.8093
13	.9048	.7895	3.7104	3.0374	3.0377	.8524	.7991
14	.9084	.852	3.4995	2.9298	2.8677	.8276	.8217
15	.9168	.913	3.501	2.9641	2.9091	.7346	.8433
16	.9171	.8443	3.1398	3.0057	2.8273	.7967	.8581
17	1.0067	.839	1.1604	.9694	.9733	.8785	.7684
18	1.1902	1.0342	1.0304	1.0667	.9919	.9732	.8833
19	1.9784	1.8058	1.9494	2.0485	1.986	1.7757	1.6628
20	2.15	2.242	2.2375	2.2222	2.26	2.1365	2.1758
21	2.1323	2.1712	2.0889	2.1683	2.1544	2.0904	2.0382
22	1.8391	1.8594	1.8046	1.8995	1.8665	1.7074	1.7326
23	2.2579	1.2504	1.1827	1.2222	1.4493	1.9761	2.2186
24	2.1193	1.5316	.9414	.9526	1.1254	1.5655	1.9052
Max	3.879	3.7188	4.4895	3.7872	3.7993	3.1246	3.4896
Min	.8595	.788	.8486	.8048	.801	.7346	.7684
Avg	1.6715	1.6023	2.1009	1.9734	2.0120	1.399	1.5196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254007 / UNDALE

Feeder No / Name : 203 / UNDALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6908	.7579	.9511	1.0031	.5658	.6036
2	.5281	.6722	.743	.9214	.9722	.547	.5658
3	.5281	.6602	.7335	.9482	.9686	.547	.5281
4	.5658	.679	.7188	.9808	.9907	.5658	.5658
5	.6413	.7167	.743	1.0136	1.0957	.6036	.6413
6	.9808	.9431	.9065	1.086	1.1589	.9054	.9054
7	1.2071	1.1949	1.3546	1.768	1.6651	1.1389	1.2826
8	1.0185	.9979	1.5804	1.8427	1.599	1.0829	1.0562
9	1.6667	1.6975	.7023	.8131	.9412	1.6049	1.6049
10	1.7438	1.6049	.7682	.7392	.8871	1.6644	1.5242
11	1.7341	1.4083	.8131	.7947	.7682	1.4914	1.2431
12	1.7284	1.419	.8596	.7392	.7964	1.4624	1.1561
13	1.7394	1.2239	.8869	.7762	.8059	1.3032	1.0822
14	1.5813	1.2125	.905	.8131	.8596	1.1305	1.0802
15	1.2811	1.286	.9328	.8596	.8238	1.1437	1.2039
16	1.3435	1.2357	.9412	.9134	.8596	1.1744	1.1831
17	.7265	.7712	.9231	.6201	.8764	.7888	.7362
18	.9745	.6556	.9214	.8951	.9391	.8859	.567
19	1.3289	1.3676	1.3957	1.2803	1.4784	1.3817	1.3491
20	1.5684	1.6804	1.5844	1.4083	1.587	1.5844	1.531
21	1.419	1.4523	1.419	1.3937	1.475	1.5089	1.3256
22	1.251	1.2826	1.2071	1.1765	1.226	1.1694	1.1576
23	.8488	.8322	1.0997	1.0936	.7545	.7922	.7922
24	.6036	.6908	.743	1.0059	1.0467	.6224	.679
Max	1.7438	1.6975	1.5844	1.8427	1.6651	1.6644	1.6049
Min	.5281	.6556	.7023	.6201	.7545	.547	.5281
Avg	1.1489	1.0990	.9850	1.0347	1.0658	1.0694	1.0152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 201 / TAMBVE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2748	2.4859	.7163	.6538	.6645	1.2112	2.6452
2	2.2458	2.2763	.6828	.6378	.6455	1.9219	2.5217
3	2.1536	2.1795	.6531	.6264	.6371	1.9281	2.4226
4	2.1346	2.1452	.6531	.6234	.6272	2.0119	2.3898
5	2.2161	2.1787	.7933	.7667	.698	2.1208	2.4226
6	2.4676	2.5667	1.1446	1.1645	1.0501	2.4379	2.5339
7	3.2404	3.2586	1.438	1.3367	.7479	3.2137	3.3669
8	3.8515	3.584	1.214	1.1919	1.2674	3.6405	3.5414
9	1.6145	1.4983	4.2318	4.6411	4.3808	1.5471	1.7223
10	.7568	.6759	4.606	4.7943	2.5294	.8017	.7872
11	.6249	.6401	4.3496	4.5291	4.4978	.7072	.5884
12	.6256	.6172	3.9921	4.1656	4.2691	.7232	.3959
13	.6386	.6531	3.7627	3.6215	3.7372	.7651	.4497
14	.7159	.6942	3.4487	3.3501	3.5593	.7972	.4283
15	.7235	.7041	3.4145	3.2709	3.4289	.4824	.4512
16	.7182	.3612	3.3962	3.5079	3.6008	.7811	.3025
17	.7891		1.3447	1.435	1.4469	.7735	.9636
18	.8924	1.2651	.7255	.8589	.9167	.7872	.9069
19	1.5207	1.576	1.4289	1.4472	1.4289	1.4038	1.48
20	1.7516	1.8107	1.6826	1.7779	1.6994	1.5714	1.7574
21	1.7032	.9837	1.5935	1.6766	.9434	.8322	1.6842
22	2.1125	1.6019	1.5325	1.5585	1.547	1.4944	1.6088
23	2.8345	1.1301	1.0738	1.1568	2.4478	1.5493	3.0826
24	3.8684	1.6653	.7636	.9236	1.5607	1.5982	2.8639
Max	3.8684	3.584	4.606	4.7943	4.4978	3.6405	3.5414
Min	.6249	.3612	.6531	.6234	.6272	.4824	.3025
Avg	1.7698	1.5892	2.0267	2.0715	2.0138	1.4625	1.7215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 202 / SAJUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.403	1.5493	.2305	.2316	.1931	1.4929	1.5036
2	1.3386	1.5074	.2072	.2263	.1889	1.4403	1.4438
3	.7309	1.4635	.1958	.224	.1859	1.3729	1.3889
4	.761	1.5119	.195	.2217	.5396	.9617	1.3847
5	1.0631	1.5359	.2354	.232	.2015	1.4606	1.3966
6	1.5958	1.6999	.338	.3635	.2995	1.5551	1.4819
7	1.0952	1.8617	.4035	.41	.4051	1.7158	1.7882
8	2.1342	1.9307	.3803	.357	.3711	1.853	1.9376
9	.8946	.7449	2.0919	2.6765	2.3594	.8082	.9091
10	.3273	.2358	2.1739	2.7759	2.4749	.256	.2362
11	.2393	.0789	2.2999	2.6783	1.3793	.2354	.2679
12	.2393	.0183	.956	2.473	2.3346	.2568	.2477
13	.2297	.2656	2.1098	2.2607	2.3499	.2507	.1986
14	.2271	.2671	2.042	2.3671	2.1582	.2579	.1997
15	.2637	.2736	1.9212	2.2755	2.1068	.1467	.2271
16	.2984	.1539	1.9605	2.2317	2.1274	.2598	.1177
17	.2835		.7545	.7708	.8287	.2629	.2424
18	.3129	.2126	.2663	.2621	.298	.3041	.2431
19	.4919	.5285	.4439	.4005	.3826	.4706	.3833
20	.5331	.5674	.5282	.5228	.5022	.5259	.4828
21	.5058	.5392	.4893	.4794	.4767	.281	.4672
22	.4275	.4984	.466	.4161	.9439	.258	.4088
23	1.5241	.3463	.3452	.2815	1.5817	1.4926	1.499
24	1.6362	.9088	.2656	.2442	.9213	1.5607	1.4751
Max	2.1342	1.9307	2.2999	2.7759	2.4749	1.853	1.9376
Min	.2271	.0183	.195	.2217	.1859	.1467	.1177
Avg	.7732	.8130	.8875	1.0576	1.0671	.8117	.8305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 203 / AREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7598	.6599	.1631	.1555	.1547	.5091	.4191
2	.7545	.628	.1563	.1517	.1448	.4793	.7057
3	.7232	.6082	.1532	.1479	.1418	.4687	.6935
4	.6783	.5922	.1486	.1151	.0945	.519	.7004
5	.6897	.6074	.1563	.1022	.1509	.5974	.7171
6	.4538	.6828	.1813	.2172	.2057	.6722	.7827
7	1.089	1.0616	.2637	.2659	.2842	.9922	1.1165
8	1.259	1.2247	.2271	.2027	.2766	1.1599	1.2308
9	.5998	.5899	1.0745	1.3024	1.0925	.6675	.7085
10	.1208	.1828	1.3622	1.4765	1.4388	.1113	.0719
11	.0899	.0671	1.4342	1.4586	1.5086	.0618	.1827
12	.1402	.1067	1.0528	1.3032	1.4152	.1386	.1911
13	.1894	.176	1.286	.7327	1.1961	.192	.1668
14	.1978	.1593	1.2372	1.0859	1.0201	.192	.1722
15	.1753	.2095	1.1663	1.0486	.9176	.1067	.1955
16	.1978	.0983	1.0372	.9442	.9534	.2804	.1036
17	.2031		.5319	.4755	.453	.2217	.1852
18	.2077	.3605	.1928	.2339	.2478	.2797	.2156
19	.4047	.4222	.3193	.1882	.4069	.4039	.3425
20	.4957	.4847	.4428	.4466	.4801	.4664	.4466
21	.4717	.2711	.3963	.4474	.4569	.4596	.4047
22	.3946	.3932	.3719	.3528	.4679	.4169	.3809
23	.6516	.2812	.2446	.2735	.5487	.737	.8916
24	.7644	.3902	.1692	.17	.3727	.6573	.833
Max	1.259	1.2247	1.4342	1.4765	1.5086	1.1599	1.2308
Min	.0899	.0671	.1486	.1022	.0945	.0618	.0719
Avg	.4880	.4460	.5737	.5541	.6012	.4496	.4941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254009 / TAMBVE

Feeder No / Name : 204 / TAMBAVE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.2572	.4096	.4096	.3475	.3734
2	.0549	.2572	.426	.4096	.6401	.3582
3	.0549	.2572	.4588	.4096	.6401	.8779
4	.0549	.2743	.4588	.426	.8779	1.0242
5	.0549	.6584	.4588	.4588	.9511	1.0608
6	.0549	.6584	.4752	.8779	1.2437	1.0974
7	.567	1.0608	.3441	1.1888	1.1706	1.0242
8	.9145	1.0974	.9012	1.0791	1.1888	1.0242
9	1.1523	1.0486	1.0159	1.2071	1.267	1.0974
10	1.1157	1.0159	.9995	1.2178	1.4083	1.0608
11	1.1157	.9995	.9995	1.1641	1.448	1.0608
12	1.0974	.9995	.9831	1.134	1.3213	1.0974
13	1.0791	1.0974	1.0159	1.0608	1.267	1.0974
14	1.0791	1.0974	.9667	1.0608	1.267	1.0608
15	.6584	.9831	.9667	1.0745	1.267	
16	.4755		.426	.4572	.5487	
24				.4588		
Max	1.1523	1.0974	1.0159	1.2178	1.448	1.0974
Min	.0537	.2572	.3441	.4096	.3475	.3582
Avg	.5989	.7842	.7066	.8291	1.0534	.9511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254056 / 33/11 KV KALE

Feeder No / Name : 202 / PACHWAD

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0722	.8333	1.1843	1.1843	.9804	1.1248
2	1.0722	1.0185	1.1843	1.1843	1.1544	1.1248
3	1.0722	1.0185	1.1843	1.1843	1.1544	1.1248
4	1.0595	1.0185	1.1843	1.1843	1.1544	1.1248
5	1.0722	1.0185	1.1843	1.1843	1.1544	1.1248
6	1.0722	1.0185	1.1405	1.1822	1.1544	1.1248
7	1.0311	1.0185	1.1683	1.1405	1.1544	1.1248
8	1.0185	1.0437	1.1683	1.1702	1.1248	1.1248
9		1.0688	1.1984	1.1984	1.1984	1.2003
10	1.085	1.0688	1.1984	1.1984	1.1683	1.2003
11	1.1142	1.2308	1.1984	1.2146	1.1843	1.2146
12	1.0467	1.1843	1.1822	1.2003	1.2003	1.1843
13	1.0311	1.2003	1.1523	1.1717	.2031	1.1702
14	1.1012	1.2003	1.1683	1.186	.1981	1.1702
15	1.1174		1.1822	1.1717	1.1717	1.1702
16	.0086	.016	.0086	.012	.0183	.0107
Max	1.1174	1.2308	1.1984	1.2146	1.2003	1.2146
Min	.0086	.016	.0086	.012	.0183	.0107
Avg	.9983	.9972	1.1055	1.1105	.9609	1.0825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254064 / 33/11 KV WING

Feeder No / Name : 201 / 11 KV Wing AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0873	2.2977	.1578	.1509	.1509	2.4394	2.3838
2	1.906	2.2977	.1595	.1509	.1509	2.4949	2.3838
3	1.906	2.2466	.1595	.1509	.1509	2.5019	2.3487
4	1.906	2.4006	.1595	.1698	.1509	2.4691	2.3487
5	1.9528	2.4034	.1772	.1698	.1509	2.4394	2.3405
6	2.0934	2.431	.1949	.1886	.1698	2.4394	2.4539
7	2.4827	2.6282	.2126	.2452	.2452	2.8753	2.826
8	2.5152	2.7435	.2126	.2452	.2103	2.9687	2.8921
9	.1698	.128	2.7463	2.5926	2.9058	.1772	.1734
10	.1227	.1509	3.0727	2.9767	3.3665	.1886	.128
11	.1387	.1509	3.0887	2.9127	3.2602	.1886	.128
12	.1402	.1509	3.0445	2.878	3.1361	.1886	.1494
13	.1214	.1698	2.9287	2.8647	3.1361	.1698	.1509
14	.1387	.1698	2.7831	2.7206	3.1539	.1886	.1463
15	.1578	.1509	2.7206	2.6408	3.083	.1698	.1698
16	.1578	.1886	2.6886	2.7206	3.0298	.1698	.0934
17	.1578	.2263	.1509	.1886	.1753	.2263	.1886
18	.1595	.1907	.2012	.2075	.2195	.1928	.2054
19	.2378	.2279	.2772	.2075	.2195	.2454	.2641
20	.2378	.2454	.2561	.2263	.2241	.2658	.2263
21	.2378	.2254	.2241	.2452	.2012	.2658	.2263
22	.2195	.2303	.1829	.2075	.2075	.2279	.2075
23	2.2862	.1772	.1578	.1886	2.0805		1.6204
24	2.0271	2.2466	.156	.1509	.1509	2.3891	2.4188
Max	2.5152	2.7435	3.0887	2.9767	3.3665	2.9687	2.8921
Min	.1214	.128	.1509	.1509	.1509	.1698	.0934
Avg	.9817	1.0199	1.0880	1.0583	1.2471	1.1253	1.1031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254064 / 33/11 KV WING

Feeder No / Name : 202 / 11 KV Wing Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2254	.2103	.2328	.2328	.2454	.2454	.2328
2	.2254	.2195	.2328	.2328	.2279	.2279	.2328
3	.2254	.2629	.2328	.2279	.2254	.2303	.2328
4	.2427	.3012	.2328	.2629	.2254	.2126	.2328
5	.2601	.3155	.3045	.3155	.2774	.2865	.2865
6	.3681	.3898	.394	.3544	.333	.333	.3761
7	.4961	.4961	.5194	.5138	.4607	.4508	.5373
8	.5138	.5083	.4835	.5083	.5194	.4508	.4656
9	.5028	.4784	.4298	.4334	.4835	.4075	.4477
10	.4835	.4458	.4287	.4239	.4656	.4287	.4908
11	.4835	.4239	.3944	.39	.4477	.4287	.4557
12	.4656	.39	.3856	.4557	.394	.4024	.4207
13	.4477	.3601	.3812	.3856	.4656	.3856	.3814
14	.3761	.3467	.3277	.3277	.3761	.3086	.3898
15	.4298	.3429	.2949	.3441	.394	.3391	.3721
16	.4298	.3521	.3481	.3647	.394	.3521	.3641
17	.4835	.3812	.3887	.4144	.394	.4239	.3856
18	.5316	.4835	.4784	.4475	.4207	.4656	.4144
19	.5847	.5373	.5316	.4733	.5083	.5731	.5083
20	.5847	.5373	.5493	.5373	.5201	.5552	.567
21	.4557	.4656	.4908	.4835	.4508	.5014	.4784
22	.4252	.394	.3641	.4075	.3988	.5014	.4298
23	.3155	.3045	.3109	.3544	.2804	.3045	.3189
24	.2454	.2629	.2507	.2328	.2804	.2427	.2507
Max	.5847	.5373	.5493	.5373	.5201	.5731	.567
Min	.2254	.2103	.2328	.2279	.2254	.2126	.2328
Avg	.4084	.3837	.3745	.3802	.3829	.3774	.3863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 201 / 11 KV Kasarshirambe Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.112	.7202	.9945	1.0631	.0857	.0876
2	.1029	.112	.6859	.9945	1.0288	.0857	.0867
3	.104	.112	.7202	.9774	1.0288	.0857	.0867
4	.1214	.112	.7716	1.0117	1.0288	.0857	.0867
5	.12	.1307	.8573	1.0288	1.0288	.1029	.0867
6	.1372	.1494	.9431	1.046	1.0288	.12	.104
7	.1372	.168	1.6461	1.8296	1.6804	.12	.0857
8	.1715	.2054	1.5604	1.7187		.1029	.1372
9	1.8004	1.9427	.104	.1387		1.8839	1.9387
10	1.9022	1.9427	.1132	.0857	.1029	1.7661	2.0485
11	1.8473	1.9805	.0943	.0943	.0857	2.1216	1.9387
12	1.829	1.8296	.0754	.0857	.0857	2.0302	1.829
13	1.701	1.6975	.0943	.0857	.0857	1.7741	1.829
14	1.5546	1.4575	.0943	.0857	.12	1.7375	1.6804
15	1.5181	.12	.1132	.112	.1029	1.6644	1.4632
16	1.7558	1.286	.1132	.112	.0857	1.829	
17	.1097	.104	.1063	.12	.1029	.0924	
18	.0857	.0686	.104	.1029	.1029	.1214	.1629
19	.2012	.181	.1848	.181	.1791	.1494	.1867
20	.2012	.2033	.2241	.2033	.1829	.1886	.2012
21	.1867	.2054	.2075	.168	.2054	.1698	.2012
22	.2054	.1698	.1886	.1867	.1886	.1698	.168
23	.0146	.7888	1.046	1.046	.1509	.132	.1494
24	.1029	.1307	.7373	.9945	1.0802	.0943	.0943
Max	1.9022	1.9805	1.6461	1.8296	1.6804	2.1216	2.0485
Min	.0146	.0686	.0754	.0857	.0857	.0857	.0857
Avg	.6672	.6337	.4794	.5585	.4886	.6964	.6660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105] BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 202 / 11 KV Malkhed

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.3601	1.0288	.823	1.0288	1.4022
2	1.1789	.823	1.3717	1.0631	1.6804	1.491
3	1.2136	.8573	1.3889	1.2003	1.6975	1.491
4	1.2003	.8573	1.3889	1.2003	1.6975	1.5083
5	1.3146	.8573	1.4232	1.2174	1.7147	1.543
6	1.3032	.9088	1.4232	1.2174	1.7147	1.543
7	1.3375	.9088	1.5524	1.2003	1.6975	1.7318
8	1.5432	.8916	1.5524	1.2003	1.7318	1.7833
9	1.406	1.283	1.543	1.2174	1.9204	1.9204
10	1.5729	1.8484	1.8004	1.2174	1.9753	1.9387
11	1.9204	2.1879	2.0559	1.2174	1.8656	2.0485
12	1.9022	2.1502	2.037	1.1831	2.0485	2.0119
13	1.9936	1.9805	1.5432	1.1831	2.0302	1.8671
14	1.9936	1.905	1.869	1.5947	2.0119	1.9387
15	2.0302	1.9993	1.9589	1.6804	2.0302	1.8671
16	1.9936	1.9616	1.8484	1.6632	2.0119	
24	.2744	.2401	.2744	.2572	.2572	.1509
Max	2.0302	2.1879	2.0559	1.6804	2.0485	2.0485
Min	.2744	.2401	.2744	.2572	.2572	.1509
Avg	1.4828	1.2953	1.5329	1.1962	1.7126	1.6398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 254069 / Kalawade

Feeder No / Name : 203 / 11KV Kalawade Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0747	.0857	.0857	.0857	.0686	.0876
2	.0693	.0747	.0857	.0857	.0857	.0686	.0867
3	.0693	.0747	.0857	.0857	.0857	.0686	.0867
4	.0867	.0747	.0857	.0857	.1029	.0686	.0867
5	.104	.0934	.1029	.0857	.1029	.0857	.0867
6	.12	.112	.1029	.1029	.1029	.1029	.104
7	.12	.1494	.1029	.1478	.1372	.1543	.1543
8	.1372	.168	.1372	.1294	.1715	.1372	.1372
9	.12	.1132	.1387	.1214	.1372	.1097	.1463
10	.128	.1132	.132	.12	.12	.1097	.1097
11	.128	.132	.132	.1132	.1029	.1097	.1097
12	.1097	.1132	.1132	.1132	.1029	.1097	.112
13	.1097	.1132	.1132	.1029	.12	.1097	.0934
14	.128	.1029	.1132	.0857	.12	.0914	.1097
15	.1097	.12	.1132	.1294	.12	.0914	.1463
16	.128	.1029	.132	.132	.1029	.128	
17	.128	.0867	.1417	.12	.12	.0924	
18	.1372	.1029	.1734	.12	.1372	.1387	
19	.2195	.181	.2402	.181	.197	.168	.2012
20	.2195	.2218	.2241	.2033	.2195	.2263	.2195
21	.1867	.2054	.1886	.1867	.1867	.2075	.2012
22	.168	.1698	.1698	.1494	.1698	.1698	.1848
23	.1307	.1029	.1029	.12	.132	.1132	.112
24	.0686	.0934	.0857	.0857	.1029	.0754	.0943
Max	.2195	.2218	.2402	.2033	.2195	.2263	.2195
Min	.0686	.0747	.0857	.0857	.0857	.0686	.0867
Avg	.1248	.1207	.1293	.1205	.1277	.1169	.1271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 203 / NANDGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4904	.8993	1.0669	1.1126	.4338	.4527
2	.4527	.4715	.8535	1.0364	1.0364	.4338	
3	.4338	.4715	.8688	1.0059	1.0364	.415	.3961
4	.4527	.4715	.8688	1.0059	1.0364	.415	.3772
5	.4904	.5281	1.0185	1.0059	1.0648	.5093	.4191
6	.6224	.7356	1.358	1.3565	1.4403	.679	.6224
7	.8215	.8865	2.0153	2.1822	2.2497	.8402	.8029
8	.6653	.7392	1.9599	2.2771	2.1506	.7207	.6722
9	2.0485	1.9845	.5601	.499		2.1445	2.1925
10	2.2348	2.0399	.4572	.4755	.462	2.4166	2.2725
11	2.0645	2.0241	.439	.439	.462	2.3434	1.9528
12	1.768	1.8982	.4755	.4656	.4344	2.1091	1.7284
13	.5487	1.7438	.4024	.4706	.4755	1.929	1.6004
14	1.5895	1.5895	.4572	.4887	.4938	1.6975	1.475
15	1.6248	1.5278	.462	.5068	.5068	1.7284	1.448
16	1.6872	1.5653	.4908	.5201	.5552	1.6644	1.5352
17	.2865	.4572	.4887	.4525	.5316	.4961	.4119
18	.5973	.6099	.5373	.5373	.5373	.5373	.4784
19	.8962	.8686	.8871	.8029	.7888	.8316	.8316
20	.9896	.9149	.9709	.9522	.9896	.9709	.9149
21	.9335	.9149	.8775	.8865	.8865	.8962	.8676
22	.811	.7922	.7733	.7922	.7922	.7922	.7922
23	.6413	1.0311	1.2809	1.3757	.5847	.5658	.5281
24	.4904	.5093	.9755	1.2193	1.2809	.4715	.4715
Max	2.2348	2.0399	2.0153	2.2771	2.2497	2.4166	2.2725
Min	.2865	.4572	.4024	.439	.4344	.415	.3772
Avg	.9835	1.0527	.8491	.9092	.9091	1.0851	1.0106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 205 / RETHARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5906	1.6244	1.643	1.5424	.5525	
2	.5144	.5716	1.5581	1.5912	1.442	.5335	
3	.4954	.5525	1.4255	1.5415	1.4255	.5144	.2641
4	.4954	.5525	1.442	1.4918	1.4089	.4954	.2477
5	.5335	.5906	1.5089	1.5592	1.4754	.5525	.2641
6	.6979	.7049	1.7939	1.8399	1.6933	.6979	.3772
7	.8676	.8488	2.1628	2.1963	2.1051	.9054	.415
8	.7655	.7545	2.2283	2.2283	2.2377	.8029	.3547
9	2.5029	2.536	.6283	.6722		2.3371	.7407
10	2.5819	2.6023	.6468	.5914	.6468	2.6023	2.7018
11	2.6023	2.6155	.5359	.5914	.6283	2.7328	2.7349
12	2.4034	2.4034	.5415	.5914	.6036	2.6686	2.5029
13	2.3594	2.2775	.6161	.6468	.5544	2.5396	2.4086
14	2.2775	2.1956	.6219	.6283	.5914	2.4413	2.251
15	2.4034	2.2119	.6099	.5729	.4715	2.3158	2.1862
16	2.3266	2.4086	.5973	.5973	.6219	2.3045	2.1925
17	.6401	.6036	.6036	.6283	.6335	.6401	.5973
18	.6584	.6099	.6099	.6697	.5788	.4572	.6154
19	1.0456	.8775	1.0082	1.0082	.9896	.6535	.9709
20	1.1506	1.1694	1.1763	1.1883	1.1576	1.1949	1.1128
21	1.0751	1.1128	1.1128	1.1506	1.0751	1.1203	1.1317
22	1.0562	.9242	1.0185	1.0374	1.0374	1.0185	1.0562
23	.7733	1.7974	1.6644	1.7465	.7356	.7733	.7356
24	.5906	.6287	1.6933	1.7772	1.6263	.5906	.6036
Max	2.6023	2.6155	2.2283	2.2283	2.2377	2.7328	2.7349
Min	.4954	.5525	.5359	.5729	.4715	.4572	.2477
Avg	1.3055	1.3392	1.1429	1.1745	1.0992	1.3102	1.2030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD -I S/DN[105]

BU 0990

Substation No/ Name :- 256005 / 110 KV KALE

Feeder No / Name : 206 / KALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7049	.811	2.1125	2.1125	2.1376	.7356	.7167
2	.7049	.7922	2.0083	1.9766	2.0325	.7356	
3	.6859	.7922	1.945	1.9134	1.9845	.7167	.724
4	.6859	.811	1.9925	1.9292	1.9919	.6979	.7049
5	.8299	.8488	1.9766	2.1214	1.9524	.811	.811
6	1.1317	1.1883	2.4129	2.3205	2.2283	1.1128	1.094
7	1.3203	1.3203	2.8182	2.7854	2.6073	1.358	1.3014
8	1.1576	1.1576	2.9473	2.8327	2.6882	1.0829	1.1203
9	3.8649	3.5555	.8871	.8871		2.6886	.4207
10	3.7029	3.5555	.6908	.7095	.7947	3.5141	
11	3.5719	3.5391	.7023	.6283	.7207	3.7357	2.9001
12	3.5227	3.5391	.6653	.6584	.7133	3.5627	3.7193
13	3.4656	3.3684	.6653	.7282	.6767	3.6437	3.4656
14	3.2388	3.2874	.7023	.7282	.7947	3.4888	3.4888
15	3.3589	3.2226	.7207	.7499	.7964	3.4088	3.2968
16	3.2648	3.0836	.7133	.7421	.7682	3.1402	3.1784
17	.7602	.7682	.6767	.7133	.6697	.6697	.6584
18	.8326	.823	.7421	.8145	1.6834	.788	.7133
19	.4481	1.4563	1.307	1.2323	1.2517	1.2883	1.307
20	1.6244	1.5684	1.5497	1.5123	1.6244	1.5123	1.531
21	1.531	1.5466	1.5466	1.5278	1.5466	1.5466	1.5089
22	1.4712	1.4523	1.4146	1.3769	1.3769	1.4146	1.4335
23	1.094	2.2996	2.2024	2.2939	.9997	.9431	1.0185
24	.7733	.8488	2.1925	2.1605	2.17	.7733	.7545
Max	3.8649	3.5555	2.9473	2.8327	2.6882	3.7357	3.7193
Min	.4481	.7682	.6653	.6283	.6697	.6697	.4207
Avg	1.8228	1.9015	1.483	1.4773	1.4874	1.8070	1.6303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 201 / 11 KV NAGARPALIKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4571	1.5836	1.4998	1.4898	1.5699	1.4739	1.4945
2	1.3352	1.4869	1.4114	1.3954	1.467	1.3687	1.4488
3	1.2933	1.4602	1.3824	1.3794	1.4457	1.3398	1.4305
4	1.2826	1.4488	1.4297	1.3481	1.4137	1.3931	1.4114
5	1.4221	1.4777	1.4465	1.3748	1.4526	1.4815	1.4434
6	1.4983	1.6369	1.5615	1.6225	1.5242	1.598	1.5455
7	1.7993	1.9738	1.7413	1.9356	1.6674	1.7977	1.7695
8	2.0268	1.9897	1.9867	1.9304	1.9205	1.8976	1.9349
9	1.8808	1.8983	1.8457	1.8367	1.8614	1.7963	1.816
10	1.8511	1.7646	1.9304	1.8115	1.8252	1.7177	1.6857
11	1.9098	1.9311	2.0591	1.9327	1.9357	1.7322	1.6803
12	1.845	1.9837	2.0904	1.9372	1.954	1.8626	1.6575
13	1.9266	2.0119	2.0934	1.9837	1.9494	1.9982	1.6758
14	1.986	1.9685	2.0287	1.8839	1.8793	1.8946	1.6064
15	1.9578	1.8785	1.9639	1.9487	1.8275	1.8542	1.6209
16	1.9578	1.9098	1.957	1.9487	1.8024	1.7512	1.5516
17	1.986	1.8975	1.9593	2.0469	.7849	1.9715	1.5234
18	2.2604	2.1994	2.2642	2.1003	2.3182	2.069	1.637
19	3.0769	1.8774	2.8647	2.9356	2.8883	2.9919	2.2718
20	3.3292	3.1573	3.1893	3.0471	3.0925	3.1573	2.3922
21	2.9393	2.6978	2.6696	2.5903	2.6391	2.681	2.2603
22	2.3815	2.3358	2.3088	2.2432	2.2077	2.2999	2.1148
23	2.029	2.0172	1.9822	1.9958	1.9463	2.0516	1.9349
24	1.6834	1.7734	1.6774	1.656	1.7482	1.6515	1.6606
Max	3.3292	3.1573	3.1893	3.0471	3.0925	3.1573	2.3922
Min	1.2826	1.4488	1.3824	1.3481	.7849	1.3398	1.4114
Avg	1.9631	1.9317	1.9726	1.9323	1.8800	1.9096	1.7320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 202 / 11 KV KRISHNA GHAT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6531	.6992	.6652	.7217	.737	.7072	.6977
2	.5742	.6733	.6664	.6584	.6725	.634	.6786
3	.5636	.6695	.6029	.6485	.6656	.5891	.6641
4	.5575	.6626	.634	.6393	.6535	.6149	.6565
5	.6424	.7011	.6584	.6348	.6748	.6515	.6489
6	.8029	.8482	.727	.7682	.7393	.775	.7507
7	.9503	.9877	.8893	.9103	.8344	.9442	.8349
8	1.0128	.9541	.9587	.8989	.908	.9907	.9225
9	.9568	.8901	.8985	.9007	.9484	.9427	.8985
10	.9465	.9088	.9571	.9343	.9549	1.0471	.9449
11	.935	.9206	.9495	.9434	.9145	.9282	.9449
12	.8436	.9092	.9381	.9602	.9206	.9244	.8223
13	.9114	.8566	.9152	.919	1.5043	.9297	.8543
14	.8939	.8947	.9228	.9228	.7979	.8977	.6996
15	.9099	.8855	.9007	.8832	.8169	.9153	.6402
16	.8093	.8322	.8985	.8832	.7857	.8208	.6333
17	.903	.8687	.8893	.9046	.8863	.8847	.7331
18	1.0174	.9907	.9998	.9259	.9442	.8992	.9503
19	1.294	1.3024	1.2194	1.2422	1.2285	1.2673	.9732
20	1.3645	1.3657	1.4007	1.3344	1.3702	1.3725	1.2079
21	1.2171	1.1843	1.0364	1.1717	1.1302	1.2232	1.1225
22	1.0844	1.0753	1.0627	1.0661	.9907	1.0467	.9853
23	.964	.964	.9747	.9678	.9533	.9396	.8992
24	.8009	.8205	.8078	.8154	.8231	.8085	.7835
Max	1.3645	1.3657	1.4007	1.3344	1.5043	1.3725	1.2079
Min	.5575	.6626	.6029	.6348	.6535	.5891	.6333
Avg	.9004	.9110	.8989	.9023	.9106	.9064	.8311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 203 / 11 KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6408	1.7086	1.557	1.6896	1.6514	1.5379	1.6453
2	1.544	1.6187	1.5089	1.5699	1.56	1.4518	1.5501
3	1.5143	1.5905	1.5532	1.5539	1.5135	1.4975	1.5356
4	1.5097	1.5851	1.6065	1.544	1.5143	1.5843	1.5211
5	1.5421	1.6575	1.7146	1.5699	1.5829	1.6666	1.5356
6	1.736	1.81	1.8701	1.7898	1.7101	1.8648	1.7223
7	2.2783	2.3967	2.1574	2.2672	2.236	2.207	2.1536
8	2.3244	2.3548	2.2016	2.2458	2.3045	2.1407	2.1993
9	2.1293	2.2291	2.0675	2.1102	2.194	1.957	1.9738
10	2.1171	2.1594	2.2131	2.082	2.1529	2.0096	1.9738
11	2.1331	2.2604	2.2496	2.1178	2.242	2.1384	2.0271
12	2.1453	2.348	2.2435	2.3091	2.1506	2.162	1.9898
13	2.0995	2.2329	2.1734	2.2443	2.1079	2.114	1.9982
14	2.1178	2.2939	2.2085	2.1399	2.1125	2.1475	1.8839
15	2.1453	2.3335	2.1376	2.1948	2.0934	2.1254	1.7825
16	2.146	2.4044	2.2443	2.2382	2.1026	2.1978	1.2254
17	2.239	2.2763	2.175	2.2306	2.0911	2.146	1.9929
18	2.3552	2.425	2.5278	2.2604	2.1087	2.3541	1.9654
19	3.2278	3.1885	3.2061	2.8616	3.0216	3.1093	2.3945
20	3.0811	3.1047	3.1573	2.931	3.049	3.1489	2.5949
21	2.7358	2.8228	2.7401	2.6117	2.7793	2.8021	2.5416
22	2.4776	2.5583	2.4798	2.3441	2.537	2.476	2.3701
23	2.1895	2.2778	2.1861	2.146	2.2276	2.1674	2.1376
24	1.861	1.9372	1.8184	1.8785	1.8656	1.7505	1.8534
Max	3.2278	3.1885	3.2061	2.931	3.049	3.1489	2.5949
Min	1.5097	1.5851	1.5089	1.544	1.5135	1.4518	1.2254
Avg	2.1371	2.2323	2.1666	2.1221	2.1212	2.1149	1.9403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 204 / 11 KV HIGH WAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5754	.6272	.5624	.5822	.5769	.5075	.5693
2	.4877	.5815	.5182	.5273	.5274	.4656	.5194
3	.4805	.5537	.4782	.5201	.5224	.4553	.5098
4	.4767	.5525	.4724	.5132	.5148	.4843	.5026
5	.5098	.551	.5037	.5102	.5499	.5228	.538
6	.5929	.5937	.5647	.5597	.5944	.5601	.5849
7	.6676	.6695	.6527	.711	.6638	.642	.6596
8	.743	.7286	.6969	.7286	.692	.6596	.6878
9	.6908	.7194	.6695	.7098	.6851	.6607	.6775
10	.7717	.7373	.8532	.7869	.6999	.7671	.6965
11	.8993	.8505	.9031	.9023	.796	.7964	.7667
12	.8939	.8989	.9115	.9256	.8269	.8178	.7762
13	.9039	.865	.9099	.9271	.8242	.8136	.7907
14	.8981	.9012	.8372	.918	.8079	.8223	.7819
15	.8166	.8924	.9035	.9122	.7194	.8185	.777
16	.8989	.8509	.8357	.9157	.711	.8917	.7652
17	.9149	.8375	.8376	.8479	.7163	.8265	.7808
18	.8962	.8756	.8756	1.0483	.759	.8932	.6615
19	1.1819	1.0224	1.1126	1.046	.9801	1.1165	.8265
20	1.0898	1.0033	1.0966	1.0677	.9968	1.0403	.8604
21	1.0402	.9061	.9077	.9724	.8276	.9183	.8577
22	.8337	.7937	.8193	.8273	.7396	.8013	.7754
23	.793	.69	.7145	.7579	.6424	.7057	.6904
24	.849	.6832	.618	.6463	.6253	.5719	.6325
Max	1.1819	1.0224	1.1126	1.0677	.9968	1.1165	.8604
Min	.4767	.551	.4724	.5102	.5148	.4553	.5026
Avg	.7877	.7660	.7606	.7860	.7083	.7316	.6953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 205 / 11 KV WAKHAN ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6218	.7606	.7247	.708	.6411	.5122	.6253
2	.5605	.6451	.6721	.6439	.6055	.4649	.6169
3	.5483	.6375	.596	.6417	.5994	.4596	.6162
4	.5392	.6367	.5945	.6329	.5956	.4916	.6108
5	.5407	.6291	.6607	.6325	.588	.5297	.6101
6	.6021	.7251	.8131	.7004	.5963	.618	.6358
7	.8196	.937	1.1439	.8337	.3772	.7163	.7705
8	.7827	1.0532	1.0867	.9564	.9244	.7422	.7267
9	.7	.9473	.9655	.9941	.8814	.7826	.6394
10	.7796	.8886	.9389	.9381	.9198	.8169	.6219
11	.7522	.8505	.9228	.887	.9297	.8009	.5137
12	.6638	.8612	.9198	.9122	.9076	.8047	.4977
13	.8185	.897	.9076	.9038	.8169	.804	.4901
14	.7987	.9	.9107	.9015	.8908	.7933	.4977
15	.8809	.8284	.9084	.9099	.9007	.7735	.5708
16	.8924	.8284	.9107	.8977	.8078	1.5379	.4969
17	.9282	.8184	.9305	.4633	.7453	.8901	.5815
18	.9545	.9107	.9678	.7998	.868	.8273	.5784
19	1.1679	1.118	.9907	1.0121	.9777	1.0746	.7483
20	1.1542	1.073	1.0814	1.0685	1.0257	1.1328	.8604
21	1.0738	1.0532	1.07	1.0002	.9823	1.0867	.8405
22	1.0071	1.0425	1.0048	.9374	.9625	1.0033	.7704
23	.9496	.9762	.8966	.8859	.8657	.8928	.7049
24	.7857	.8958	.8497	.8269	.7827	.6942	.7011
Max	1.1679	1.118	1.1439	1.0685	1.0257	1.5379	.8604
Min	.5392	.6291	.5945	.4633	.3772	.4596	.4901
Avg	.8051	.8714	.8945	.8370	.7997	.8021	.6386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 206 / 11 KV COTTAGE HOSPITAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5859	1.6933	1.6911	1.6796	1.733	1.544	1.7101
2	1.4449	1.5615	1.5242	1.5607	1.6423	1.4807	1.621
3	1.4045	1.515	1.4701	1.5241	1.5988	1.483	1.5905
4	1.4045	1.4814	1.4282	1.4898	1.5744	1.5181	1.5554
5	1.3939	1.5211	1.5143	1.4921	1.6095	1.5622	1.5455
6	1.749	1.7246	1.7055	1.7676	1.7649	1.7627	1.6979
7	2.0775	2.1651	2.0225	2.1331	2.0401	2.0652	2.0736
8	2.2238	2.3091	2.2054	2.1662	2.1956	2.1407	2.2222
9	2.1038	2.22	2.1353	2.2036	2.2512	2.085	2.178
10	2.2931	2.3057	2.3464	2.1902	2.3776	2.4036	2.2092
11	1.6265	2.4829	2.4767	2.6048	2.4272	2.5095	2.2794
12	2.4371	2.4707	2.3822	2.5895	2.3533	2.5858	2.1902
13	2.5271	2.3473	2.4295	2.4668	2.2672	2.5194	2.2519
14	2.4455	2.2618	2.4439	2.5949	2.2047	2.4851	2.0302
15	2.3365	2.3831	2.3197	2.4462	2.1856	2.3799	2.0744
16	2.4104	2.3838	2.303	2.4439	2.082	2.5141	2.0767
17	2.3342	2.3274	2.3236	2.4721	2.1613	2.5613	1.9799
18	2.473	2.3503	2.3777	2.4965	2.2184	2.7366	1.8892
19	3.1378	3.0148	2.9592	2.9127	2.828	3.2754	2.3487
20	3.2342	3.0285	3.1268	2.985	2.9043	3.2571	2.4981
21	2.9142	2.7351	2.7233	2.8052	2.5896	2.8829	2.3388
22	2.5217	2.4448	2.4722	2.5202	2.3152	2.5057	2.2123
23	2.2604	2.3564	2.2367	2.2436	2.1025	2.1871	1.9997
24	1.8435	1.9319	1.8632	1.8678	1.8869	1.7376	1.8229
Max	3.2342	3.0285	3.1268	2.985	2.9043	3.2754	2.4981
Min	1.3939	1.4814	1.4282	1.4898	1.5744	1.4807	1.5455
Avg	2.1743	2.2090	2.1867	2.2357	2.1381	2.2576	2.0165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 207 / 11 KV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5202	.5273	.4737	.5209	.2381	.4714	.5231
2	.2896	.5297	.4382	.5232	.2207	.4367	.4859
3	.1894	.4142	.295	.4794	.2389	.3056	.3948
4	.189	.3441	.3285	.5221	.3376	.2664	.3422
5	.1928	.367	.3552	.5205	.3231	.2938	.3426
6	.527	.4614	.5183	.5244	.4935	.426	.4679
7	.5297	.442	.519	.4718	.5342	.5103	.53
8	.5209	.4538	.5137	.5297	.5224	.5057	.5311
9	.4312	.4587	.5106	.5411	.5308	.5103	.5342
10	.5388	.4771	.5354	.5183	.5324	.5312	.5777
11	.5396	.5339	.5628	.543	.5312	.6455	.6108
12	.5415	.567	.6123	.5403	.5023	.6859	.6516
13	.5384	.5319	.6043	.5404	.5354	.6013	.5739
14	.5377	.5167	.5274	.5388	.5324	.5369	.4591
15	.5312	.5231	.5407	.3407	.5331	.6181	.2385
16	.5281	.53	.5404	.314	.5312	.6146	.2393
17	.5255	.5064	.5343	.2607	.5266	.6116	.3685
18	.4092	.3967	.3948	.1742	.4375	.5685	.1783
19	.3555	.4116	.4253	.3715	.4702	.5258	.1924
20	.4595	.5194	.487	.4161	.5171	.4919	.2805
21	.5151	.516	.5274	.5289	.5099	.5334	.5122
22	.5361	.5175	.5289	.5308	.5068	.5311	.4946
23	.538	.5186	.5293	.4557	.4733	.5361	.4881
24	.5274	.5315	.5087	.452	.2945	.5057	.4976
Max	.5415	.567	.6123	.543	.5354	.6859	.6516
Min	.189	.3441	.295	.1742	.2207	.2664	.1783
Avg	.4588	.4832	.4921	.4649	.4531	.5110	.4381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254001 / 33/11 KV Karad SS

Feeder No / Name : 208 / 11 KV Chawadi Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2195	.2058	.1848	.2195	.2058	.2195
2	.2012	.2241	.1715	.1848	.1829	.1886	.2012
3	.2012	.1829	.1715	.1848	.1829	.1715	.1829
4	.2012	.1829	.1886	.1848	.1829	.1715	.1829
5	.2012	.1829	.2058	.1848	.1829	.2058	.1829
6	.2353	.2561	.2229	.2772	.2195	.2229	.2195
7	.2353	.3475	.2572	.3511	.2561	.2792	.2743
8	.2715	.2926	.2915	.3142	.2926	.2572	.2743
9	.3077	.3109	.2915	.2957	.3109	.2743	.2743
10	.3511	.3077	.3142	.3696	.3142	.3511	.2772
11	.3881	.3841	.4066	.3881	.4251	.4251	.2957
12	.3696	.394	.4066	.3881	.3881	.3696	.2772
13	.3696	.394	.4066	.4066	.4251	.3696	.2772
14	.3881	.394	.3881	.4066	.3881	.3326	.2772
15	.4066	.3761	.3881	.4066	.3696	.3881	.2402
16	.3696	.3582	.4066	.4435	.3881	.4066	.2218
17	.3511	.3601	.3881	.3881	.3326	.3326	.2402
18	.4572	.3772	.439	.4572	.3944	.439	.2572
19	.5729	.6001	.567	.695	.6344	.6219	.2915
20	.567	.5333	.567	.5853	.5487	.567	.3086
21	.4572	.4115	.3801	.3841	.3772	.4572	.3086
22	.3292	.3258	.3258	.3292	.3086	.3475	.2915
23	.2926	.2743	.2896	.2561	.2572	.2926	.2229
24	.2743	.2195	.2229	.2195	.2195	.2401	.2195
Max	.5729	.6001	.567	.695	.6344	.6219	.3086
Min	.2012	.1829	.1715	.1848	.1829	.1715	.1829
Avg	.3349	.3296	.3293	.3452	.3250	.3299	.2508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 254059 / 33/11 KV Oglewadi SS

Feeder No / Name : 207 / 11 KV Vadoli AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0343	.6859	.7373	.6001	.0514	.0343
2	.0514	.0343	.6516	.0703	.6173	.0514	.0343
3	.0514	.0343	.6173	.703	.583	.0514	.0343
4	.0514	.0343	.6173	.703	.5487	.0514	.0343
5	.0686	.0514	.6859	.7373	.6516	.0514	.0343
6	.0686	.0514	.7545	.7888	.7202	.0514	.0343
7	.0686	.0686	.8402	.0874	.7716	.0514	
8	.0686	.0514	.0514	.9259	.823	.0514	.0343
9	1.3032	1.2689	.0514	.0514	.0343	1.1488	.8573
10	1.2689	1.2517	.0514	.0514	.0343	1.0631	1.0288
11	1.2174	1.2689	.0514	.0514	.0343	.9945	.9945
12	1.2003	1.2003	.0514	.0514	.0343	.8059	.9088
13	1.2003	1.0631	.0514	.0343	.0343	.9431	.8916
14	1.1831	1.0288	.0686	.0343	.0343	.8573	.8745
15	1.1831	1.0117	.0514	.0343	.2683	.7888	.8573
16	1.0288	.9945	.0514	.0343	.2374	.7716	.823
17	.0514	.0514	.0514	.0343	.0514	.0686	
18	.0514	.0686	.0343	.0514	.0514	.0857	
19	.0514	.0514	.0514	.0514	.0514	.0343	
20	.0514	.0051	.0514	.0051	.0514	.0034	.0343
21	.0514	.0514	.0343	.0051	.0514	.0343	
22	.0514	.0514	.0514	.0514	.0514	.0343	
23	.0514	.7545	.7888	.6859	.0343	.0343	
24	.0514	.0514	.7202	.8059	.6344	.0514	.0343
Max	1.3032	1.2689	.8402	.9259	.823	1.1488	1.0288
Min	.0514	.0051	.0343	.0051	.0343	.0034	.0343
Avg	.4365	.4389	.2965	.2828	.2918	.3388	.4438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 258001 / 220/33KV Ogalewadi SS

Feeder No / Name : 204 / Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3281	.3273	.3071	.3319	.3605	.3643	.3029
2	.3304	.3323	.3048	.3338	.3319	.3342	.3045
3	.3311	.341	.3037	.3288	.3334	.3319	.3037
4	.333	.3406	.3071	.3296	.3372	.3353	.3037
5	.333	.338	.3086	.3395	.3376	.3395	.3121
6	.3285	.3365	.3086	.3368	.3342	.338	.3174
7	.3334	.3418	.3201	.3357	.3437	.3418	.3205
8	.3216	.3403	.3155	.3395	.3452	.3445	.3086
9	.3727	.4386	.5117	.4934	.5011	.4485	.2808
10	.4774	.5716	.6501	.5864	.612	.5895	.2736
11	.5437	.6455	.6642	.6752	.6908	.6276	.2519
12	.5605	.6729	.6642	.6889	.7324	.6619	.2591
13	.3948	.4569	.463	.4713	.4683	.4409	.2881
14	.5319	.6047	.6546	.6592	.6318	.5815	.2831
15	.479	.559	.6039	.6447	.599	.6158	.2884
16	.5026	.6017	.6302	.6634	.6001	.5677	.2004
17	.4763	.5605	.5975	.6173	.5754	.5769	.0495
18	.3753	.4214	.4816	.5022	.4188	.4668	.2812
19	.3685	.3929	.4233	.4119	.4207	.4028	.3056
20	.3387	.3688	.3749	.4077	.4096	.3948	.3075
21	.3182	.3372	.373	.394	.4157	.3715	.3102
22	.325	.3266	.3631	.3898	.3986	.37	.3121
23	.3098	.3208	.3509	.3951	.3963	.3795	.3125
24	.3288	.314	.3445	.3723	.3795	.3559	.3212
Max	.5605	.6729	.6642	.6889	.7324	.6619	.3212
Min	.3098	.314	.3037	.3288	.3319	.3319	.0495
Avg	.3893	.4288	.4428	.4604	.4572	.4409	.2833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD URBAN[104]

BU 0922

Substation No/ Name :- 258001 / 220/33KV Ogalewadi SS

Feeder No / Name : 403 / 33 KV KARAD TOWN

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7311	3.8803	.3755	3.786	3.6145	.3549	3.8146
2	3.2922	3.5614	3.4465	2.9321	3.4551	3.3436	3.5997
3	3.1824	3.5082	3.3951	2.963	3.4551	3.2922	3.546
4	3.1824	3.546	3.6008	2.9321	3.5082	3.7037	3.5997
5	3.4019	3.4019	4.0124	3.3665	3.6677	4.0638	3.6534
6	4.2353	4.1993	4.4239	4.181	3.9866	4.4753	3.8683
7	4.8868	5.3189	4.8354	5.0497	4.6205	4.9383	4.7279
8	4.9954	4.9429	4.9383	5.1006	4.8903	4.6811	4.7308
9	4.7239	4.8903	4.8354	5.1006	4.9434	4.5268	4.5713
10	4.9897	5.104	5.3778	5.2115	5.2669	5.156	4.8234
11	5.2115	5.4298	5.5441	5.7105	5.3778	5.5996	4.8234
12	5.1006	5.4801	5.655	5.5441	5.3224	5.5996	4.768
13	5.4332	5.3727	5.655	5.4332	5.2669	5.4887	4.8234
14	5.3224	5.3727	5.4332	5.4887	5.156	5.4332	4.3244
15	5.3224	5.4298	5.3778	5.2115	5.2115	5.3224	3.8809
16	5.3778	5.3727	5.3224	5.3224	5.0452	5.4332	3.6591
17	5.4887	5.2469	5.4887	4.9897	4.2135	5.5441	4.2135
18	5.8471	5.6584	5.8562	5.156	.535	5.695	4.1152
19	7.7618	7.6132	7.3525	7.1228	7.5103	7.2291	5.4527
20	7.2822	6.893	7.2428	6.9102	6.9959	7.1759	5.6584
21	6.5381	6.1214	6.19	6.0065	5.9156	6.2723	5.4527
22	5.6344	5.607	5.7013	5.5281	5.4012	5.475	5.0926
23	4.8377	4.8868	5.0497	4.7308	4.5268	4.784	4.4239
24	4.2798	4.1993	4.0638	4.3896	4.0398	3.9095	4.1461
Max	7.7618	7.6132	7.3525	7.1228	7.5103	7.2291	5.6584
Min	3.1824	3.4019	.3755	2.9321	.535	.3549	3.546
Avg	5.0025	5.0432	4.9656	4.9236	4.6636	4.8957	4.4071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 201 / KRISHNA HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2401	.3018	.2641	.2641	.2401	.2572
2	.2641	.2401	.3018	.2641	.2641	.2401	.2572
3	.2641	.2401	.3018	.2263	.2263	.2427	.2572
4	.2641	.2401	.3018	.2263	.2263	.2401	.2572
5	.3018	.2743	.3018	.2641	.2263	.2774	.3086
6	.3961	.3395	.3395	.3584	.2263	.3429	.3429
7	.4715	.415	.4338	.4338	.2452	.4115	.415
8	.4527	.4715	.5281	.4481	.3395	.5144	.4527
9	.5281	.5658	.6413	.5144	.415	.5847	.5658
10	.6036	.6036	.679	.6161	.415	.6413	.6224
11	.547	.6602	.6036	.6161	.4338	.679	.6224
12	.547	.6036	.6979	.6348	.3018	.6036	.6224
13	.5121	.5847	.5658	.5175	.3018	.6036	.5847
14	.4904	.4904	.5281	.4854	.2452	.4904	.547
15	.5847	.6224	.6036	.5281	.3395		.6224
16	.547		.547	.4527	.3395	.5658	.6036
17	.4801		.5093		.3258	.4801	.5658
18	.4458	.4904	.4904	.4481	.3429	.4458	.3961
19	.4115	.4904	.4338	.4481	.3429	.4458	.415
20	.3772	.4527	.4338	.4481	.3772	.4115	.415
21	.3772	.4527	.3772	.4481	.3429	.3772	.415
22	.3429	.3772	.3395	.3361	.3086	.3429	.3772
23	.3429	.3206	.3109		.2743	.3086	.3395
24	.3018	.2743	.3206	.3018	.3018	.6036	.2743
Max	.6036	.6602	.6979	.6348	.4338	.679	.6224
Min	.2641	.2401	.3018	.2263	.2263	.2401	.2572
Avg	.4224	.4295	.4538	.4218	.3094	.4388	.4390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106]

BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 202 / MALKAPUR Gaonthan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.0288	1.2449	1.226	1.2071	1.1317	1.0288
2	1.1317	1.0288	1.1694	1.1694	1.2071	1.1317	1.0288
3	1.1317	1.0288	1.1694	1.1694	1.1694	1.1317	1.0288
4	1.1317	1.0288	1.1317	1.1317	1.1694	1.1317	1.0288
5	1.358	1.166	1.2071	1.2826	1.2071	1.1831	1.2003
6	1.9616	1.8107	1.5089	1.5655	1.358	1.5089	1.406
7	2.037	2.0748		1.9616	1.8107	1.8861	1.9239
8	1.922	2.037	2.4897	1.9616	1.8484	1.8176	1.9993
9	1.7551	1.905	2.0748	1.9959	1.9239	1.8861	1.8861
10	1.848	2.0936	2.3011	2.3655	2.1879	1.8861	1.7353
11	1.7372	1.8861	2.2257	1.4784	1.9805	2.0936	1.6598
12	1.6461	1.773	1.9616	1.9959	1.9239	1.8861	1.6975
13	1.6289	1.905	1.8673	1.922	1.9239	1.7353	1.6032
14	1.5023	1.8861	1.7164	1.8671	1.8673	1.6598	1.5466
15	1.6095	1.8673	1.8107	1.7741	1.7541		1.4146
16	1.7558		1.9185	2.1437	1.8484	2.2068	1.7164
17	1.6461		2.0995	1.8673	1.6804	1.9376	1.6221
18	1.6804	2.3388	1.848	1.8298	1.6461	1.9033	1.5844
19	1.7833	2.3765	2.2177	2.2405	1.749	1.8861	1.8861
20	1.8519	2.2634	1.9035	2.1125	1.8176	1.9719	1.9239
21	1.749	2.1125	1.9605	1.9418	1.7833	1.8176	1.6975
22	1.6118	1.8861	1.7737	1.7177	1.6461	1.7147	1.5844
23	1.406	1.5089	1.5497		1.3717	1.3889	1.358
24	2.3152	1.0288	1.358	1.3203	1.2826	1.2003	1.0974
Max	2.3152	2.3765	2.4897	2.3655	2.1879	2.2068	1.9993
Min	1.1317	1.0288	1.1317	1.1317	1.1694	1.1317	1.0288
Avg	1.6388	1.7289	1.7612	1.7409	1.6402	1.6564	1.5274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 203 / Goleshwar Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0514	.3206	.2321	.3018	.0514	.061
2	.0526	.0514	.3206	.2401	.3018	.0514	.061
3	.0537	.0514	.3206	.2229	.3018	.0457	.061
4	.0537	.0514	.3206	.2452	.3018	.0514	.061
5	.0532	.0486	.3206	.2641	.3206	.0457	.0762
6	.0526	.0566	.3206	.3395	.3206	.0514	.0914
7	.0686	.0754	.3772	.3961	.3584	.0686	.1132
8	.0857	.0943	.415	.3961	.3772	.0857	.1132
9	.463	.4904	.0943	.0554	.0754	.4904	.0943
10	.4115	.5658	.0754	.0566	.0754	.6224	
11	.5735	.6036	.0754	.0566	.0754	.6602	.679
12	.5735	.6036	.0754	.0566	.0566	.5093	.679
13	.5729	.547	.0754	.0566	.0566	.3395	.6413
14	.4973	.5281	.0754	.0739	.0566	.5658	.6224
15	.4973	.4904	.0754	.0754	.0754		.6036
16	.4801		.0526	.0566	.0754		.6036
17	.0514		.0537	.0566	.0633		.0566
18	.0509		.0724	.056	.061	.0633	.0754
19	.0686	.0754	.1086	.0934	.061		.0943
20	.0857	.0754	.1097	.0747	.0768	.0914	.1132
21	.0686	.0754	.0716	.0747	.061	.0914	.1132
22	.0686	.0943	.0716	.0747	.0686	.0762	.0943
23	.0457	.3395	.2572		.0457	.0762	.0754
24	.0566	.0514	.3206	.2652	.3206	.0457	.0678
Max	.5735	.6036	.415	.3961	.3772	.6602	.679
Min	.0457	.0486	.0526	.0554	.0457	.0457	.0566
Avg	.2099	.2391	.1825	.1530	.1620	.2042	.2283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 204 / Goleshwar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3086	.3772	.3658	.3772	.3086	.3086
2	.3292	.3086	.3395	.3547	.3772	.3086	.3086
3	.3326	.3086	.3395	.3511	.3584	.3086	.3086
4	.3326	.3086	.3395	.3584	.3584	.3086	.3086
5	.4066	.3772	.415	.415	.415	.3601	.3772
6	.5544	.7545	.5658	.6224	.5281	.6173	.5316
7	.7392	.7545	.7545	.8299	.7545	.703	.7545
8	.6653	.7356	.679	.6468	.679	.6516	.7545
9	.5914	.547	.5281	.5544	.6413	.547	.6036
10	.4835	.5281	.5658	.4805	.3772	.4527	.4715
11	.4252	.4715	.5658	.5041	.4904	.4338	.415
12	.3841	.4527	.4527	.4338	.4527	.415	.415
13	.4344	.4338	.4715	.4481	.4715	.3772	.415
14	.439	.415	.4527	.4715	.4338	.3961	.3584
15	.394	.4527	.4904	.4481	.4715		.3584
16	.4163		.4525	.4668	.4338		.3772
17	.4115		.5121	.4481	.4115		.3772
18	.4458		.5304	.4481	.4458		.415
19	.5487	.679	.695	.7167	.0549		.6036
20	.6859	.8299	.7499	.679	.6859	.823	.6413
21	.583	.7545	.695	.6348	.6173	.6859	.6036
22	.5144	.679	.6283	.5975	.5144	.6001	.5281
23	.4115	.5281	.5175		.4115	.4801	.4527
24	.3772	.3429	.4527	.4251	.415	.3429	.3429
Max	.7392	.8299	.7545	.8299	.7545	.823	.7545
Min	.3292	.3086	.3395	.3511	.0549	.3086	.3086
Avg	.4681	.5224	.5238	.5087	.4657	.4800	.4596

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 205 / AAGASHIVNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8573	.9808	1.0185	1.0185	.8573	.5487
2	.7167	.8573	.9431	.9145	.9431	.8573	.5487
3	.7167	.8573	.9054	.9431	.9431	.8573	.5487
4	.695	.8573	.9054	.9242	.9431	.8573	.5487
5	.7762	.8916	.9054	.9619	.9808	.9602	.6516
6	.9979	1.3957	1.1317	1.2071	1.0562	1.166	.7545
7	1.0349	1.4335	1.4335	1.4712	1.2071	1.3546	1.1317
8	1.1827	1.2826	1.6598	1.5339	1.3957	1.3032	1.1317
9	1.4784	1.4335	1.6598	1.6221	1.5844	1.4335	.9808
10	1.4045	1.4712	1.5655	1.5154	1.5466	1.094	.9054
11	1.3213	1.4901	1.5466	1.4969	1.5844	1.5466	.7545
12	1.3535	1.3957	1.4146	1.2936	1.4335	1.3014	.6036
13	1.267	1.4335	1.4901	1.0349	1.4523	1.4335	.7167
14	1.2894	1.4523	.9728	1.0903	1.4335	1.3957	.679
15	1.0679	1.0562	1.4335	1.5154	1.4523		.6224
16	1.3352		1.4266	1.587	1.4146	1.4335	.6224
17	1.2689		1.4632	1.4784	1.2689	1.3375	.679
18	1.3032	1.2826	1.3575	1.3443	1.3032	1.3032	.7545
19	1.3889	1.8107	1.7372	1.7924	1.3717	1.3032	.6036
20	1.4746	1.8107	1.7002	1.7177	1.4403	1.406	1.2071
21	1.3717	1.6598	1.6617	1.643	1.3717	1.2689	1.1317
22	1.3032	1.5089	1.4003	1.419	1.3032	1.166	1.0562
23	1.2003	1.2071	1.1949		1.0974	.9259	.9054
24	.7545	.8573	1.0562	1.0829	1.0185	1.3014	.6001
Max	1.4784	1.8107	1.7372	1.7924	1.5844	1.5466	1.2071
Min	.695	.8573	.9054	.9145	.9431	.8573	.5487
Avg	1.1440	1.2865	1.3311	1.3308	1.2735	1.2115	.7786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 206 / Koyana Industrial Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2058	.2378	.2452	.2452	.2058	.2401
2	.2263	.2058	.2263	.2263	.2263	.2058	.2401
3	.2263	.2058	.2263	.2263	.2263	.2058	.2401
4	.2263	.2058	.2263	.2263	.2263	.2058	.2401
5	.2263	.2058	.2263	.2263	.2263	.2058	.2401
6	.2263	.2263	.2263	.2263	.2263	.2058	.2229
7	.2263	.2452	.2263	.2263	.2452	.2401	.2452
8	.2452	.2452	.2263	.2241	.2829	.2572	.2452
9	.2641	.2641	.3395	.2987	.3018	.3772	.2452
10	.3395	.3772	.3772	.3326	.3772	.3772	.2263
11	.3772	.3772	.415	.4108	.415	.3772	.2641
12	.3395	.3395	.3395	.3361	.3395	.3395	.2641
13	.3018	.3395	.3395	.3361	.3395	.3018	.2263
14	.3018	.3772	.3772	.3361	.3772	.3772	.2263
15	.3018	.3772	.415	.3734	.3395		.2263
16	.3658		.415	.3734	.415	.3772	.2263
17	.3086		.415	.4108	.3429	.3429	.2641
18	.2915	.3395	.3772	.3734	.3086	.3086	.2075
19	.2743	.3395	.3018	.2987	.2743	.2743	.2263
20	.2572	.3018	.3018	.2987	.2401	.2401	.2263
21	.2401	.2829	.3018	.2801	.2401	.2401	.2263
22	.2401	.2641	.3018	.2614	.2229	.2401	.2263
23	.2229	.2641	.2829		.2229	.2401	.2263
24	.2263	.2058	.2641	.2641	.2641	.2058	.2401
Max	.3772	.3772	.415	.4108	.415	.3772	.2641
Min	.2229	.2058	.2263	.2241	.2229	.2058	.2075
Avg	.2701	.2816	.3078	.2962	.2886	.2761	.2359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254004 / MALKAPUR

Feeder No / Name : 207 / 11 KV Malkapur water works NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1372	.132	.1494	.132	.1372	.12
2	.132	.1372	.132	.1294	.132	.12	.1372
3	.132	.12	.132	.132	.132	.1372	.12
4	.132	.12	.132	.1509	.132	.12	.1543
5	.132	.12	.132	.132	.132	.12	.1543
6	.0189	.1509	.132	.132	.0189	.12	.1372
7	.1509	.1509	.1509	.132	.0377	.1372	.1509
8	.1307	.132	.132	.132	.132	.1543	.132
9	.1478	.1509	.132	.1698	.1509	.132	.1886
10	.0549	.1509	.0943	.1848	.1698	.1698	.2075
11	.2012	.1886	.1698	.2033	.1509	.2075	.2075
12	.1629	.1698	.2075	.1294	.132	.1886	.1698
13	.181	.1886	.132	.1478	.132	.132	
14	.1646	.1509	.132	.1294	.1509	.132	.0189
15	.128	.1509	.132	.1698	.132		.132
16	.1294		.132	.1478	.132	.1509	.1509
17	.1494		.1448	.1478	.12	.1372	.132
18	.1372	.1509	.128	.1494	.1372	.12	.1132
19	.1372	.1698	.1646	.1307	.1372	.1372	.1132
20	.1372	.1698	.128	.1307	.1543	.12	.1132
21	.1372	.132	.1294	.1494	.1372	.12	.1132
22	.1372	.132	.1294	.1307	.12	.12	.132
23	.1543	.132	.0366	.0377	.1372	.12	.132
24	.132	.1372	.132	.1294	.132	.1372	.12
Max	.2012	.1886	.2075	.2033	.1698	.2075	.2075
Min	.0189	.12	.0366	.0377	.0189	.12	.0189
Avg	.1355	.1474	.1333	.1407	.1281	.1378	.1370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 201 / Supane AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.626	3.7777	.3292	.2567	.125	4.2444	3.7975
2	3.5695	3.5856	.3162	.2355	.125	4.0513	3.6393
3	3.5086	3.4711	.333	.237	.1235	3.9173	3.5111
4	3.4758	3.4549	.3155	.237	.2019	3.9213	3.4134
5	3.5093	3.5844	.3277	.2347	.2164	3.9444	3.4473
6	3.9948	3.7392	.3608	.3071	.2332	4.0969	3.758
7	2.3388	4.1635	.3835	.3406	.2941	4.8345	4.6403
8	3.2647	4.4235	.4282	.4153	.4229	5.2356	5.0155
9	1.1565	1.9707	4.7386	6.0976	4.2379	1.7909	2.1567
10	.2198	.2751	6.0501	3.5078	6.5257	.3421	.3193
11	.2511	.2502	6.214	4.0574	7.0447	.0366	.3139
12	.2797	.2435	6.403	6.304	5.9717	.016	.3452
13	.2656	.2873	3.4004	4.1007	6.6941	.0465	.4275
14	.255	.2934	5.4954	1.1164	6.5707	.3299	.4313
15	.195	.2511	5.9099	5.9541	5.8901	.3254	.413
16		.2595	6.1157	6.2732	5.8497	.3421	.4168
17	.032	.3136	2.5066	2.319	2.3376	.3261	.4042
18	.3985	.3551	.3753	.288	.357	.3117	.404
19	.3947	.4139	.4184	.3802	.3799	.2987	.394
20	.4801	.445	.3814	.4039	.3974	.304	.4177
21	.4382	.4305	.333	.3254	.3578	.285	.3833
22	.4321	.4092	.3269	.2949	.3562	.2606	.3711
23	3.8729	.3749	.3217	.2606	4.3378	4.0997	4.337
24	3.8493	1.9322	.3048	.2599	2.5126	4.2684	4.2307
Max	3.9948	4.4235	6.403	6.304	7.0447	5.2356	5.0155
Min	.032	.2435	.3048	.2347	.1235	.016	.3139
Avg	1.7308	1.6127	2.1704	1.8420	2.5651	1.9846	1.9578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 202 / Khodashi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.724	.7922	.8488		.724	.7356
2	.743	.724	.7545	.7316		.724	.6413
3	.6859	.7167	.7167	.6081	.695	.724	.6413
4	.724	.7167	.7167	.6081	.695	.724	.6413
5	.7621	.7922	.8299	.7392	.7682	.8002	.7545
6	1.0098	.9808	1.0185	.961	.8413	.9526	.9808
7	1.2384	1.226	1.3392	1.2437	1.2071	1.226	1.1883
8	1.307	1.3769	1.2696	1.2437	1.1706	1.2826	1.2826
9	1.2826	1.2567	1.0242	1.1088	1.1706	1.3169	1.0562
10	1.2696	1.0924	1.0974	1.0242	1.0974	1.1157	.9511
11	1.1203	1.1041	1.0974	1.0974	1.0242	1.0242	.7682
12	1.0456	1.0387	.9877	.8779	1.0185	1.0791	.7602
13	1.0642	.9231		.8962	.8779	.8779	.724
14	1.0829	.8954	.8869	.8413	.8413	.8779	.724
15	1.0642	.9412	.9412	.8869	.8779	.9412	.724
16	.9997	1.0808	1.086	.9709	.8413	.9593	.7964
17	1.0402	1.1694	1.1584	1.0402	.905	1.0136	.8215
18	1.0745	1.2071	1.2536	1.1096	.9991	1.0402	.8962
19	1.4632	1.226	1.39	1.3535	1.3535	1.3535	
20	1.4377	1.4377	1.423	1.3306	1.4415	1.4784	1.4335
21	1.3203	1.2637	1.2323	1.2323	1.2696	1.2323	1.2826
22	1.358	1.3957	1.3203	1.358	1.3443	1.2323	1.226
23	.9619	1.1317	1.0751	1.1506	1.094	1.0185	.9997
24	.811	.8002	.9054	.9054	.8865	.9145	.8676
Max	1.4632	1.4377	1.423	1.358	1.4415	1.4784	1.4335
Min	.6859	.7167	.7167	.6081	.695	.724	.6413
Avg	1.0694	1.0509	1.0572	1.007	1.0191	1.0264	.9086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 203 / SAHYADRI HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0754	.0754	.0754		.0943	.0754
2	.0566	.0754	.0754	.0754		.0566	.0754
3	.0566	.0754	.0754	.0754		.0754	.0754
4	.0566	.0754	.0754	.0566	.0566	.0754	.0754
5	.0566	.0754	.0754	.0566	.0754	.0754	.0754
6	.0566	.0732	.0754	.0754	.0754	.0754	.0754
7	.0754	.0754	.0754	.0943	.0754	.0754	.0943
8	.132	.1886	.1698	.1698	.1698	.2075	.132
9	.1886	.2075	.1698	.1886	.1698	.1886	.132
10	.1132	.1132	.1132	.0943	.0189	.1132	.132
11	.132	.132	.1132	.1132	.132	.132	.0943
12	.1132	.2263	.132	.1132	.0943	.1698	.1132
13	.1698		.2075	.1698	.0754	.1886	.1132
14	.132	.1132	.2075	.2452	.0754	.1132	.1132
15	.1132	.1132	.1132	.1132	.0754	.0943	.1698
16	.1132	.1132	.1132	.1132	.0943	.1132	.0943
17	.0943	.1132	.1132	.1132	.0754	.1132	.132
18	.0943		.1132	.0762	.0754	.1132	
19	.132	.0754	.1132	.1132	.1886	.2263	.2075
20	.1886	.1698	.2075	.1886	.1698	.132	.0754
21	.0754	.0754	.0754	.0754	.0566	.0754	.0754
22	.0943	.0754	.0943	.0754	.0754	.0943	.0754
23	.0754	.0754	.0754	.0754	.0754	.0943	.0754
24	.0566	.0754	.0754	.0943	.0566	.0566	.0754
Max	.1886	.2263	.2075	.2452	.1886	.2263	.2075
Min	.0566	.0732	.0754	.0566	.0189	.0566	.0754
Avg	.1014	.1088	.1140	.1101	.0934	.1147	.1025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 204 / WARUNJI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4725	.503	.0358	.0362		.5182	.442
2	.4572	.5182	.0362	.0324		.503	.442
3	.4572	.5182	.0366	.0324	.0324	.5182	.4572
4	.4268	.5335	.037	.0324	.0324	.503	.4572
5	.442	.5182	.037	.0324	.0324	.5335	.4572
6	.4725	.5792	.0554	.0486	.048	.5487	.4725
7	.5792	.6706	.0554	.0486	.064	.6706	.5944
8	.6249	.6706	.0716	.0648	.064	.7011	.6401
9	.0724	.0617	1.2803	1.0822	1.1363	.0486	.0469
10	.0543	.0732	1.0242	1.3123	1.3283	.0648	.0829
11	.0747	.0732	1.3283	1.2963	1.2963	.0486	.0486
12	.056	.0543	1.3603	1.2483	1.2483	.064	.048
13	.0354	.0543	1.2803	1.2323	1.1544	.048	.0474
14	.0354	.0362	1.186	1.1363	1.0279	.032	.0362
15	.0362	.0526	1.1702	1.1683	.9488	.048	.0362
16	.0351	.0532	1.012	1.0957	.9172	.0316	.0362
17	.061	.0537	.0724	.0514	.0343	.0316	.0469
18	.0543	.0358	.0724	.0532	.0469	.0526	.0503
19	.048	.0537	.0724	.0701	.032	.0526	.0351
20	.0474	.0532	.0543	.0526	.0335	.0351	.0335
21		.0537	.0532	.052	.0514	.0316	.0335
22	.0457	.0532	.0514	.0514	.0343	.0312	.0324
23	.4877	.0358	.0362	.0343	.5312	.4268	.4877
24	.503	.5335	.0358	.0362	.4557	.5658	.4572
Max	.6249	.6706	1.3603	1.3123	1.3283	.7011	.6401
Min	.0351	.0358	.0358	.0324	.032	.0312	.0324
Avg	.2426	.2435	.4356	.4292	.4795	.2546	.2301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 205 / Sangam LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2263	.1886	.2075		.2075
2		.1886	.3584	.2075		.2075
3	.2075	.1886	.3584	.2075	.1886	.2075
4	.3395	.1886	.3584	.2075	.1886	.2075
5	.3584	.1886	.3584	.2075	.1886	.2054
6	.3584	.3018	.3584	.3206	.1886	.2263
7	.3772	.3961	.3772	.3772	.3772	.3584
8	.3772	.3772	.3772	.3584	.3584	.3772
9	.3772	.3772	.3772	.3772	.3772	.3584
10	.3772	.3584	.3772	.3772	.3772	.3584
11	.3772	.3772	.3772	.3772	.3961	.3772
12	.3584	.3772	.3772	.3772	.3772	.3584
13	.3584	.3772	.3206	.3584	.3584	.3584
14	.3584	.3584	.3395	.3584	.3584	.3584
15	.3772		.3395	.3772	.3584	.3584
16	.2075		.2075	.2075	.2075	.3584
Max	.3772	.3961	.3772	.3772	.3961	.3772
Min	.2075	.1886	.1886	.2075	.1886	.2054
Avg	.3436	.3058	.3407	.3065	.3072	.3052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254005 / MUNDHE

Feeder No / Name : 206 / Supane Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4163	.3944	.4119	.4207		.3921	.3149
2	.3801	.3601	.3658	.3481		.3734	.2984
3	.362	.3601	.3841	.3481	.3113	.3511	.2984
4	.3601	.3601	.3841	.3481	.3113	.3696	.2984
5		.3988	.4572	.4973	.3605	.3841	.3353
6	.4973	.5375	.6036	.4973	.4096	.5304	.4917
7	.6687	.7973	.7783	.7127	.6554	.7973	.6344
8	.7373	.7619	.7888	.7293	.7865	.7202	.7362
9	.6539	.7373	.6882	.6344	.7865	.7537	.691
10	.6371	.6009	.6554	.6062	.6882	.6718	.5967
11	.5407	.639	.6062	.639	.6062	.6554	.5243
12	.5407	.6133	.5243	.5571	.5898	.5735	.5079
13	.57	.5801	.5898	.5898	.5898	.5079	.5243
14	.57	.5636	.6226	.5571	.5243	.5243	.5243
15	.6203	.5898	.5407	.5571	.5407	.5079	.5243
16	.6036	.6068	.5735	.6019	.5898	.6062	.5898
17	.6401	.5376	.5792	.5864	.6554	.5898	.5335
18	.6405	.6642	.6327	.6401	.602	.5792	.6401
19	.9465	.9015	.8192	.8745	.8551	.8916	.8939
20	.9568	.8954	.8288	.9465	.9088	.9412	.9036
21	.8939	.7888	.823	.8063	.8238	.8495	.7545
22	.7545	.7186	.8145	.7282	.7316	.7202	.695
23	.5316	.5375	.567	.5144	.5359	.4917	.4755
24	.4572	.4458	.4835	.4755	.4458	.4294	.3521
Max	.9568	.9015	.8288	.9465	.9088	.9412	.9036
Min	.3601	.3601	.3658	.3481	.3113	.3511	.2984
Avg	.6078	.5996	.6051	.5923	.6049	.5921	.5474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 201 / VAHAGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.387	.0543	.0514		1.1022	1.5813
2	1.2929	1.3717	.0354	.0549		1.1269	1.5813
3	1.2631	1.3717	.0347	.0514		1.1269	1.5546
4	1.2631	1.3717	.0362	.0514		1.1269	1.4723
5	1.2631	1.3565	.0532	.0543		1.1145	1.5497
6	1.2803	1.3565	.0686	.0514		1.1869	1.5813
7	1.3123	1.4083	.0686			1.1736	1.7814
8	1.3889	1.4403	.0509	.0514	.0543	1.8233	1.7394
9	.0532	.0716	2.0645	2.915	2.8509	.0716	.0716
10	.0532	.0314	2.5396	3.0521	2.9473	.0543	.0716
11	.0526	.0372	2.652	3.1855	3.2358	.0543	.0716
12	.052	.0343	2.6216	2.8292	3.0769	.0554	.0716
13	.0514	.0343	2.5652	3.0864	2.7349	.0514	.0537
14	.052	.0343	2.4577	2.8502	2.4326	.0514	.0532
15	.0509	.0343	2.5194	2.6825	2.4291		.0532
16	.052	.0514	2.2708	2.713	2.2996	.0514	.0532
17	.0537	.0532	.0532	.0716	.0716	.0514	.0537
18	.0716	.0532	.0514	.0701	.0716	.0526	.0543
19	.0886	.0724	.0514	.0886	.0886	.0724	.0732
20	.0895	.0724	.0514	.0686	.0895	.0732	.0701
21	.0905	.0732	.0514	.0543	.0724	.0905	.0724
22	.0716	.0732	.0514	.0543	.0716	.0724	.0701
23	1.3565	.0549	.0514	.0543	1.6956	1.7004	1.5893
24		1.387	.0549	.0514		1.6956	1.6518
Max	1.3889	1.4403	2.652	3.1855	3.2358	1.8233	1.7814
Min	.0509	.0314	.0347	.0514	.0543	.0514	.0532
Avg	.5484	.5513	.8546	1.0519	1.5139	.6078	.7073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 202 / Vahagaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.3224	.3696	.2915	.2772	.2865	.3326
2	.3142	.3224	.3696	.2915	.2561	.2686	.3326
3	.3142	.3224	.3326	.2915	.2587	.2715	.2957
4	.3326	.3224	.3326	.2915	.2957	.2686	.2957
5	.3696	.3258	.3696		.3658	.2715	.3326
6	.4066	.4298	.4435	.4115	.4572	.4252	.4435
7	.5175	.5014	.5175	.4973	.4755	.4784	.5175
8	.5304	.5138	.4755	.4801	.5121	.4784	.462
9	.462	.5194	.462	.4115	.4207	.4119	.394
10	.3881	.3086	.4435	.4119	.3658	.3511	.3189
11	.4066	.3086	.4066	.4298	.3658	.3881	.3403
12	.3696	.2743	.3696	.4075	.3326	.3511	.3012
13	.3696	.2743	.3511	.394	.3326	.3258	.2507
14	.3326	.2743	.3511	.3582	.2957	.3258	.2507
15	.3511	.3086	.3881	.3403	.3326		.2865
16	.3511		.4066	.3721	.3841	.4066	.3045
17	.3224	.4066	.4066	.3224	.3721	.3696	.3224
18	.4298	.4435	.3467	.4435	.4298	.4024	.3109
19	.567	.5544	.6068	.6584	.6024	.5487	.5914
20	.5316	.7023	.5721	.6767	.5493	.695	.6348
21	.5373	.5175	.5721	.5914	.5552	.6036	.5729
22	.4835	.462		.4805	.4784	.5175	.5359
23	.394	.4435	.3467	.3696	.3761	.3658	.3511
24	.394	.3224	.4066	.2947	.3142	.2865	.3658
Max	.567	.7023	.6068	.6767	.6024	.695	.6348
Min	.3142	.2743	.3326	.2915	.2561	.2686	.2507
Avg	.4079	.3992	.4194	.4138	.3919	.3956	.3810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 203 / ALFA-LAVAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0027	.003	.0027	.0021		.003	.0027
2	.0027		.0027				.0027
3	.0027		.0027				.0027
4	.0027		.0027				.0027
5	.0027	.003	.0027				.0027
6	.0027		.0027			.0031	.0027
7	.0027		.0027	.0021			.0027
8	.0027	.0031	.0027		.0027	.003	.0027
9	.0027	.0031	.0021		.0027		
10	.0027		.002	.0031	.0027		.0031
11	.0027		.0018		.0027	.0021	.003
12	.0027		.0019		.0027	.0019	
13	.0027		.0019		.0027		
14	.0027		.0019		.0027		
15	.0027	.0025	.0018				
16	.0027	.0021	.0019		.0027	.0034	
17		.0027	.0021	.0032	.0032	.0019	.003
18	.0032	.0027	.0032	.0019	.0032	.0027	.0019
19		.0027		.0019		.0027	.0015
20		.0027		.0019		.0027	.0021
21		.0027	.0032	.002		.0027	.0021
22		.0027	.0032	.0019		.0027	.0021
23	.0032	.0027	.0032	.0019	.003	.0027	.0019
24		.0032	.0027	.0032		.0032	.0027
Max	.0032	.0032	.0032	.0032	.0032	.0034	.0031
Min	.0027	.0021	.0018	.0019	.0027	.0019	.0015
Avg	.0028	.0028	.0025	.0023	.0028	.0027	.0025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 204 / Taswade East

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.181	.1698	.1372		.1791	.2241
2	.1509	.1267	.1509	.1372		.1254	.1867
3	.1509	.0732	.1509	.1029	.1696	.1267	.1867
4	.1509	.1254	.132	.1029		.1254	.132
5	.1509	.1267	.1132	.1029		.1254	.1509
6	.1509	.1267	.1509	.1372		.128	.1509
7	.1509	.1254	.1509	.1219		.181	.1132
8	.1886	.1267	.1886	.1715	.3018	.1791	.1132
9	.2263	.1791	.3395	.583	.2263	.3224	.1433
10	.3018	.3658	.3361	.5373	.2641	.5228	.1791
11	.415	.3605	.5228	.5373	.4668	.5601	.181
12	.3772	.3563	.4527	.4525	.5041	.5144	.1791
13	.3395	.3725	.3395	.3982	.3395	.4287	.181
14	.3772	.3887	.4527	.5068	.4715	.4024	.2686
15	.3395	.3086	.3772	.3582	.0027		.1791
16	.3772	1.0288	.3734	.3224	.415	.4287	.1791
17	.3258	.3395	.3361	.4525	.3224	.3734	.1267
18	.3292	.1886	.3086	.3018	.3224	.2987	.1372
19	.2686	.3395	.2401	.3258	.2686	.3734	
20	.2715	.2987	.2058	.2641	.1791	.3361	.1829
21	.181	.1509	.2058	.2103	.1254	.2241	.1505
22	.1791	.3018	.1715	.3506	.1791	.3395	.1505
23	.181	.3018	.1715	.3506	.2686	.3395	.1389
24		.181	.2263	.1715		.1791	.2801
Max	.415	1.0288	.5228	.583	.5041	.5601	.2801
Min	.1509	.0732	.1132	.1029	.0027	.1254	.1132
Avg	.2493	.2697	.2611	.2974	.2839	.2962	.1702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 205 / Taswade West

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.8954	.7468	.6859		.8954	.7545
2	.1132	.724	.8215	.4801	.8413	.724	.7095
3	.1132	.7164	.7468	.4801	.7362	.7164	.6535
4	.1132	.724	.7167	.4801		.724	.5658
5	.1132	.7164	.6602	.4801	.6878	.7164	.6036
6	.1132	.6878	.6413	.4801	.6722	.7164	.6036
7	.132	.6878	.7468	.5144	.7468	.7164	.4854
8	.3772	.6878	.7468	.6173	.7468	.7164	.5281
9	.7167	.7602	.9054	.8573	.961	.7164	.4477
10	.8589	1.0974	1.0562	1.086	1.1949	1.0719	.5316
11	.9335	1.134	1.094	1.2536	1.0562	1.2567	.5373
12	.8962	1.1523	1.2826	1.2536	1.2136	1.0974	.5373
13	.9709	1.1706	.9808	1.086	1.0082	.9431	.6335
14	1.2071	.7926	1.094	1.0387	1.2696	1.0974	.5373
15	1.1949	1.1706	1.1694	1.267	1.1949		.1791
16	1.1576		1.2826	1.0745	1.1203	1.0288	.6401
17	1.2178	1.0829	1.2071	1.0745	1.0745	1.1317	.6268
18	.985	.9709	1.0288	1.1317	.9568	1.0562	.6036
19	.7522	1.0829	.8573	1.1203	.8954	1.0082	
20	.724	.9709	.7716	.9709	.8954	1.0082	.679
21	.7164	.8402	.6859	.8871	.8859	.8215	.679
22	.8954	.9335	.6859	.924	.8954	.9335	.5658
23	.905	.9808	.6859	.8962	1.0745	.9709	.6722
24		.8954	.8676	.8573	.8962	.8954	.7468
Max	1.2178	1.1706	1.2826	1.267	1.2696	1.2567	.7545
Min	.1132	.6878	.6413	.4801	.6722	.7164	.1791
Avg	.6661	.9076	.8951	.8749	.9556	.9114	.5879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 206 / 11 KV Talbid Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0537	1.1401	1.3717		.0543	.0543
2	.0543	.0543	1.1142	1.3717		.0358	.0543
3	.0537	.0537	1.0526	1.3546		.0362	.0543
4	.0549	.0537	1.0526	1.3546		.0358	.0543
5	.0543	.0543	1.1271	1.3717		.0358	.0543
6	.0543	.0537	1.166	1.406		.0537	.0709
7	.0716	.0716	1.2955			.0716	.0724
8	.0709	.0716	1.4083	1.406	1.2955	.0716	.0724
9	1.6907	1.6124	.0848	.0514	.0709	1.6263	1.7604
10	1.7166	1.6004	.0876	.0537	.0532	1.8067	1.8896
11	1.7004	1.5384	.0701	.0537	.0526	1.9559	
12	1.6324	1.4746	.0514	.0532	.0709	1.9791	1.6975
13	1.6194		.0526	.0724	.0709	1.8004	1.5432
14	1.6194	.9667	.0532	.0716	.0709	1.6289	1.5432
15	1.5581	.9012	.0709	.0716	.052		1.5089
16	1.4586	.9431	.0701	.0724	.0693	1.5432	1.4586
17	.0895	.052	.0701	.0724	.0716	.0701	.0537
18	.0716	.0886	.0747	.0857	.0716	.0709	.0701
19	.1075	.0886	.0747	.1227	.1075	.1052	.0857
20	.1075	.1267	.0747	.1063	.0895	.1267	.0876
21	.0905	.1063	.0747	.1029	.0905	.1086	.0686
22	.0716	.0905	.0747	.0848	.0895	.1075	.0857
23	.0537	1.21	1.5497	1.1469	.0716	.0724	.0686
24		.0537	1.1603	1.5123		.0537	.0716
Max	1.7166	1.6124	1.5497	1.5123	1.2955	1.9791	1.8896
Min	.0537	.052	.0514	.0514	.052	.0358	.0537
Avg	.6111	.4922	.5438	.5813	.1499	.5848	.5426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 207 / MIDC-III

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7579	1.054	1.1622	.6561	.8718	.9636	.9922
2	.7503	.9884	.9511	.6188	.8779	.7156	.8204
3	.7434	.9739	.9021	.3147	.6846	.7457	.7961
4	.7465	.9705	.7922	.5845	.6701	.6714	.7496
5	.7857	.9762	.7953	.5982	.7177	.6745	.6869
6	.828	1.0252	.8414	.7095	.7661	.7278	.6741
7	.9522	1.1378	.9458	.8466	.9366	.7392	.6371
8	1.0875	1.1412	.9562	.4489	.7735	.7446	.6121
9	1.2243	1.2437	1.1416	.9998	1.044	1.1698	.5635
10	1.5737	.9496	1.4457	1.1782	1.6073	1.4312	.5871
11	1.6335	1.4403	1.5714	1.5772	1.7086	1.6651	.6016
12	1.5847	1.4659	1.5394	1.5531	1.571	1.5627	.6402
13	1.4754	1.5653	1.5409	1.3885	1.4566	1.4193	.5277
14	1.5916	1.5455	1.5905	1.1755	1.427	1.4282	.5239
15	1.7374	1.8137	1.7017	1.5084	1.5626	.7926	.5453
16	1.6385	1.7787	1.6049	1.3828	1.6358	1.48	.5601
17	1.7017	1.6865	1.5402	1.2849	1.5341	1.4213	.5392
18	1.4464	1.4508	1.3812	1.1576	1.3367	1.2826	.5441
19	1.2837	1.1275	1.2589	.9426	1.3119	1.0737	.5075
20	.9697	1.1386	1.2913	.873	1.3378	1.092	.4786
21	1.0562	1.1738	1.2258	.7918	1.1938	1.1183	.4671
22	1.0531	1.2232	.6653	.8192	1.259	1.1374	.6256
23	1.1096	1.27	.6512	1.0875	1.174	1.1195	.6325
24	.5609	1.1576	.961	.8581	.9699	1.1188	.8779
Max	1.7374	1.8137	1.7017	1.5772	1.7086	1.6651	.9922
Min	.5609	.9496	.6512	.3147	.6701	.6714	.4671
Avg	1.1788	1.2624	1.1857	.9731	1.1845	1.0956	.6329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 208 / MIDC- IV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4492	.5316	.5938	.5609	.5849	.6024	.6051
2	.4538	.5186	.5607	.575	.5964	.5723	.5854
3	.45	.534	.541	.5426	.6114	.5727	.5369
4	.4462	.5074	.525	.4923	.5862	.5399	.4862
5	.4447	.5081	.5682	.4878	.5937	.5296	.4877
6	.4576	.574	.5532	.5361	.6437	.5757	.5552
7	.4991	.5532	.6226	.5564	.5645	.5609	.5832
8	.4968	.5658	.5908	.5777	.5651	.5471	.5575
9	.6108	.6318	.6672	.73	.6813	.6204	.5426
10	.8308	.8215	.9145	.8627	.9063	.8574	.5091
11	.8608	.791	1.0338	.9473	.9729	.9111	.5456
12	.7996	.7773	1.0044	.9156	.9469	.8669	.518
13	.7259	.7647	.8779	.8322	.8184	.7887	.4915
14	.7544	.6973	1.012	.9149	.7971	.8261	.5289
15	.7152	.7971	1.029	.8686	.8252	.4268	.5266
16	.7701	.4275	1.0278	.8185	.8517	.8585	.5056
17	.7577	.7556	1.0179	.7922	.7354	.6531	.5334
18	.6007	.6398	.7575	.7011	.6268	.5926	.5522
19	.6073	.556	.5788	.5447	.6379	.6596	.54
20	.5944	.5144	.5495	.531	.6371	.6516	.5279
21	.5879	.5264	.5335	.5205	.5628	.6356	.5392
22	.5422	.5842	.543	.5409	.5357	.6333	.5089
23	.5377	.6432	.666	.6561	.6154	.5941	.5384
24	.2843	.5864	.6289	.639	.6009	.6337	.5557
Max	.8608	.8215	1.0338	.9473	.9729	.9111	.6051
Min	.2843	.4275	.525	.4878	.5357	.4268	.4862
Avg	.5949	.6170	.7249	.6727	.6874	.6546	.5359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254008 / TALBID

Feeder No / Name : 401 / HINDUSTAN

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9384	3.6969	3.5665	3.4979		3.1602	3.4374
2	2.9384	3.3265	3.4019	3.3436		3.0807	3.1824
3	2.9384	3.0807	3.3665	2.9835		2.9384	3.0178
4	3.0247	3.1927	3.3265	2.9835		2.9687	2.9938
5	2.9938	3.1047	2.9938	2.9835		2.9687	2.8829
6	3.0493	2.9938	3.1047			2.9687	2.963
7	3.1367	3.4928	3.4751			2.9384	3.1602
8	3.4019	3.4168	3.5117	3.7037	3.4568	2.9384	2.8829
9	3.4751	4.269	4.0009		3.8552	3.77	3.3819
10	3.4019		4.0741	3.6037	3.8255	3.8066	2.8829
11	3.6591	3.5294	4.2867	4.4353	4.0181	4.5833	3.1047
12	3.5665	3.9506	4.1152	3.8089	4.0724	3.8809	2.9687
13	3.8255	3.3013	4.2867	3.6591	3.9506	3.6008	3.1276
14	3.8009	4.0186	4.401	3.6591	3.6037	4.0175	3.271
15	3.8409	4.2353	4.401	4.201	3.6923		3.2156
16	3.9363	3.5494	4.0741	3.8809	3.6214	3.7037	2.9384
17	3.8649	3.6763	3.7912	3.5482	3.4168	3.8295	2.8006
18	3.7146	3.5117	3.7311	3.7151	3.1047	3.6037	2.7435
19	3.8809	3.8552	3.5665	3.8866	3.1047	3.9638	2.999
20	3.3819	3.7311	3.6214	3.6008	3.1367	3.5482	2.999
21	3.5482	3.5837	3.6214	3.7151	3.1047	3.6591	2.9721
22	3.8649	3.9095	1.701	4.0581	3.0493	3.5848	3.2007
23	4.257	4.1267	4.0604		3.3819	4.0181	3.0293
24		3.8649	3.7146	3.8958		3.3265	3.5117
Max	4.257	4.269	4.401	4.4353	4.0724	4.5833	3.5117
Min	2.9384	2.9938	1.701	2.9835	3.0493	2.9384	2.7435
Avg	3.4974	3.6269	3.6748	3.6582	3.5247	3.5156	3.0695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching

Station

Feeder No / Name : 201 / KARVE Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1886	1.2346	1.2793	1.2483	.1698	.1698
2	.1509	.1698	1.2191	1.2334	1.2029	.1698	.1698
3	.1509	.1698	1.2346	1.2176	1.1717	.1698	.1698
4	.1698	.2075	1.2498	1.2323	1.1431	.1698	.1886
5	.2263	.2452	1.387	1.3203	1.2163	.1886	.2452
6	.3018	.3206	1.5432	1.419	1.4083	.3206	.3206
7	.3395	.3961	1.821	1.7284	1.467	.3772	.3584
8	.2829	.3206	1.7833	1.6941	1.5653	.3395	.3395
9	1.9357	1.9372	.2075	.1886	.2641	1.9528	1.8827
10	2.0679		.2075	.1886	.2452		2.0873
11	2.0119	1.9372	.1698	.1509	.2263		1.9528
12	1.9052		.2075	.1509	.2075	2.1822	1.9136
13	1.9136		.2263	.1698	.2075	2.1142	1.8362
14	1.8138	1.6918	.2263	.2075	.2075	2.0729	1.7457
15	1.8519	1.8982	.132	.1886	.1886	1.8061	1.7017
16	1.9136	1.829	.2452	.2263	.2075		1.6217
17	.1886	.1886	.2075	.2641	.2641	.1886	.2452
18	.2075		.2641	.2829	.2829	.2263	.2452
19	.3018		.3018	.3206	.3584	.2641	.3018
20	.3395		.2829	.3395	.3772	.3018	.3206
21	.3206	.3018	.3018	.3206	.3018	.3206	.2829
22	.2829	.2829	.2829	.2641	.3018	.2829	.1886
23	.2075	1.174	1.3565	1.3245	.2075	.1886	
24	.1698	.1886	1.2346	1.3226	1.2616	.1886	.1698
Max	2.0679	1.9372	1.821	1.7284	1.5653	2.1822	2.0873
Min	.1509	.1698	.132	.1509	.1886	.1698	.1698
Avg	.8002	.7471	.7220	.7098	.6472	.6664	.8025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching

Station

Feeder No / Name : 202 / TEMBHU LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1003	1.1736	1.1574	1.9292	1.4998	.7676
2	1.0715	1.1584	1.1431	1.8747	1.5432	.743
3	1.0715	1.1883	1.1431	1.8747	1.6248	.7827
4	1.0433	1.1736	1.1288	1.9134	1.6204	.743
5	1.0288	1.1736	1.1288	1.8673	1.6358	.743
6	1.0002	1.2037	1.1149	1.9372	1.5604	.7526
7	1.8364	1.4815	1.7869	1.9766	1.89	.7526
8	1.9357	1.8122		2.1664	1.9867	.9602
9	2.1091	1.8056	1.8501	2.1091	2.1348	.9414
10	2.2531	1.821	1.866	2.2138		1.5971
11	2.21	1.8591	1.0936	2.3045	1.656	1.9766
12	2.1759	1.7747	1.7394	2.2565	1.8056	2.3245
13	2.1872	.9755	2.2929	2.234	2.0622	2.2685
14	2.1451	1.8138	2.2028	2.2068	2.0216	2.21
15	2.1872	1.8903	2.1872	2.1914	2.1451	2.2377
16	.7613	.5468	1.6049	.9297		.7895
Max	2.2531	1.8903	2.2929	2.3045	2.1451	2.3245
Min	.7613	.5468	1.0936	.9297	1.4998	.743
Avg	1.6323	1.4282	1.5627	1.9991	1.7990	1.2869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254067 / 11KV Tembhu Switching

Station

Feeder No / Name : 206 / 11 KV Karve Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3174	.3395	.3018	.3018	.2801	.2829
2	.2829	.3018	.3206	.3018	.2829	.2829	.2801
3	.2829	.2801	.3174	.2829	.2829	.3018	.2829
4	.2987	.3018	.3395	.3018	.2829	.3174	.2987
5	.5415	.4904	.5041	.4481	.2987	.3772	.6413
6	.7842	.7468	.7842	.7095	.7095	.679	.7468
7	.8775	.9055	.9149	.8402	.8589	.8962	.8775
8	.7023	.7316	.7602	.6468	.7682	.695	.695
9	.5014	.5014	.5316	.4477	.5731	.543	.5847
10	.3988	.3721	.4334	.3681	.4252		.3988
11	.3561	.373	.4239	.3018	.3772	.3944	.4161
12	.3429		.39	.3856	.3688	.3391	.3391
13	.3294		.3561	.3772	.3521	.3391	.3185
14	.3121	.132	.3294	.3506	.3258	.3294	.3086
15	.3294	.1132	.3467	.3506	.3429	.3294	.3222
16	.2947	.1132	.3086	.3681	.3222	.3294	.2915
17	.3185	.0943	.3258	.39	.3441	.3113	.3086
18	.3688		.3401	.4191	.4024	.3481	.3812
19	.5609		.5493	.567	.6024	.5493	.5784
20	.6401		.6154	.6516	.6697	.6516	.6401
21	.6283	.7964	.6036	.6219	.6401	.6219	.6099
22	.5359	.6584	.5415	.5415	.5544	.5359	.3361
23	.3961	.5121	.3772	.3921	.3841	.3511	.3361
24	.3395	.3206	.3734	.3361	.3361	.2987	.2987
Max	.8775	.9055	.9149	.8402	.8589	.8962	.8775
Min	.2829	.0943	.3086	.2829	.2829	.2801	.2801
Avg	.4469	.4243	.4636	.4459	.4503	.4392	.4406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254073 / 33/11 KV VADGAON H

Feeder No / Name : 201 / 11 KV VADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2743	.2926	.2561	.2743	.2957	.2896
2	.2926	.2801	.2926	.2561	.2743	.2957	.2743
3	.2926	.2772	.2926	.2561		.2957	.2743
4	.3292	.3361	.3511	.2957		.3109	.3109
5	.4251	.4294	.4251	.4066		.3475	.4066
6	.5601	.5415	.5359	.5359		.4024	.5914
7	.6036	.5487	.6036	.5544		.4119	.6219
8	.4706	.4298	.4344	.3982	.4887	.3898	.4525
9	.3506	.3155	.3429	.2774	.3506	.3052	.3641
10	.2984	.2591	.285	.2652	.3521	.2949	.3391
11	.2622	.2591	.2785	.1989	.3149	.2561	.2949
12	.2401	.2721	.2458	.2652	.3041	.2343	.2915
13	.2294	.2688	.2721	.2753	.2743	.2846	.2622
14	.2652	.2241	.2458	.2785	.2785	.2401	.2543
15	.2012	.2458	.2155	.2294	.2622	.2652	.2056
16	.2267	.253	.2401	.2458	.2753	.2785	.2267
17	.2561	.2561	.144	.2753	.2949	.3077	.2429
18	.2591	.3077	.2753	.3481	.3277	.3401	.2915
19	.3681	.4161	.3898	.4161	.3988	.4382	.3814
20	.443	.4557	.4075	.4382	.3856	.4784	.443
21	.443	.4607	.4298	.4382	.4607	.4656	.4252
22	.4207	.4477	.3982	.4163	.4656	.4477	.4024
23	.362	.362	.3475	.3582	.3109	.3801	.3439
24	.2926	.2743	.3109	.2743	.2896	.3109	.2896
Max	.6036	.5487	.6036	.5544	.4887	.4784	.6219
Min	.2012	.2241	.144	.1989	.2622	.2343	.2056
Avg	.3410	.3415	.3357	.3316	.3360	.3366	.3450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 254073 / 33/11 KV VADGAON H

Feeder No / Name : 202 / 11 KV VADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	.8535	.8025	.7876	.0943	.0953
2	.1334	.1143	.8535	.7727	.7727	.0943	.0953
3	.1334	.1143	.8429	.7628		.0943	.0953
4	.1334	.1143	.8429	.7628		.0943	.0953
5	.1334	.1334	.8471	.7977		.1132	.1143
6	.1524	.1334	.873	.8278		.132	.1143
7	.1524	.1334	.9755	.945		.1509	.1334
8	.1715	.1509	.9755	.9065	.8322	.1509	.1334
9	.945	1.0212	.1132	.1132	.1132	1.065	1.0494
10	1.0364	1.0402	.132	.0943	.132	1.034	1.1111
11	1.1279	1.0669	.128	.1267	.1478	1.0059	1.0669
12	1.0822	.9957	.1848	.1463	.1509	1.0402	1.0536
13	1.0385	.9829	.1848	.1132	.1829	1.0536	.9783
14	.9957	.9536	.1509	.1132	.1509	1.0084	1.0212
15	.9934	.9808	.1663	.1132	.1509	.9783	.9934
16	1.0402	.9846	.1509	.132	.1494	.9682	.9536
17	.0953	.1509	.132	.1132	.1886	.1307	.0943
18	.1509	.132	.1663	.132	.1663	.1463	.1478
19	.1524	.132	.168	.1698	.132	.1663	.1494
20	.1663	.132	.1524	.1509	.132	.1494	.1494
21	.168	.132	.1524	.132	.132	.1663	.1478
22	.1494	.132	.1334	.1143	.1132	.1494	.1478
23	.1143	.7773	.8688	.823	.1132	.0953	.1143
24	.1334	.1143	.8471	.1132	.8025	.0943	.0953
Max	1.1279	1.0669	.9755	.945	.8322	1.065	1.1111
Min	.0953	.1143	.1132	.0943	.1132	.0943	.0943
Avg	.4389	.4474	.4540	.3866	.2816	.4240	.4229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256011 / 110 KV TEMBHU

Feeder No / Name : 204 / TEMBHU Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.1646	.168	.1848	.1646	.1829
2	.1663	.168	.1663	.168	.1991	.1629	.1612
3	.168	.168	.1646	.168	.1848	.1646	.1772
4	.2033	.1848	.1848	.2033	.2012	.181	.1928
5	.2561	.2353	.2561	.2561	.2534	.2172	.3012
6	.362	.3982	.3658	.3224	.3224	.3224	.394
7	.443	.4557	.4075	.3544	.3721	.4075	.3856
8	.3772	.3978	.3391	.2652	.3856	.4191	.3688
9	.3391	.373	.2155	.2652	.3688	.3391	.3185
10	.2486	.2812	.3077	.2915	.2458	.2846	.2347
11	.2561	.2343	.2721	.2458	.2846	.2187	.2056
12	.253	.25	.2372	.3401	.2372	.2688	.192
13	.16	.1875	.213	.2785	.2372	.2187	.2006
14	.1781	.208	.176	.3077	.208	.1981	.1718
15	.2652	.2321	.2753	.2949	.2372	.25	.1898
16	.2915	.3201	.2688	.3201	.3479	.2949	.2561
17	.3321	.3201	.3041	.3637	.3201	.3239	.2721
18	.3563	.3749	.2743	.3795	.3593	.3681	.2812
19	.5138	.4915	.3688	.3812	.4748	.4527	.3521
20	.39	.3772	.3641	.407	.5144	.3561	.3155
21	.333	.3641	.3366	.3601	.3258	.298	.2686
22	.3012	.2804	.3403	.3224	.3155	.2896	.168
23	.2378	.2378	.2561	.2658	.2378	.1848	.168
24	.1848	.1848	.181	.1991	.2012	.1791	.181
Max	.5138	.4915	.4075	.407	.5144	.4527	.394
Min	.16	.168	.1646	.168	.1848	.1629	.1612
Avg	.2834	.2879	.2683	.2887	.2925	.2735	.2475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256012 / 110 KV Rethare

Feeder No / Name : 201 / Rethare Gaonthan

GAOTHAN FEEDER

(Karkhana) Feeder KV- 11 /
OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256012 / 110 KV Rethare

Feeder No / Name : 203 / RETHARE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256012 / 110 KV Rethare

Feeder No / Name : 204 / SHENOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17
HR	Load (MW)
24	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

KARAD-II S/DN.[106] BU 5916

Substation No/ Name :- 256012 / 110 KV Rethare

Feeder No / Name : 209 / Rethare LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 201 / MUNDHA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	1.7909	1.97	1.7193	.1075	.0716
2	.0514	.0514	1.7909	1.97	1.7193	.1075	.0701
3	.0514	.0514	1.8099	1.949	1.7193	.1075	.0701
4	.0686	.0514	1.7909	1.97	1.7193	.1075	.0701
5	.0686	.0514	1.7909	1.97		.1052	.0701
6	.1029	.0514	1.7909	2.0595	1.7528	.1052	.0701
7	.0686	.0514	2.0774	2.1384	1.9547	.1227	.0701
8	.0686	.0857	2.1209	2.1132	2.0405	.1227	.0343
9	2.1948	2.2253		.0762	.0762	2.1186	2.6063
10	2.4234	2.332	.0457	.0762	.1067	2.3167	2.4539
11	2.4082	2.3624	.0914	.0762	.1372	2.4234	2.4387
12	2.4234	2.271	.061	.0762	.1219	2.3167	
13	2.3167	2.1795	.1219	.0762	.1372	2.2862	2.3015
14	2.1948	2.1795	.061	.0914	.1677	2.21	
15	2.1795	2.1186	.061	.0457	.1219	2.1795	2.1948
16	1.6918	1.89	.0457	.061	.1524	2.271	
17	.0762	.0914	.1219	.0762	.1219	.0876	
18	.1075	.1067	.1219	.0762	.1433	.0709	
19	.1075	.1067	.1219	.0762	.197	.0701	.12
20	.1075	.0914	.1219	.0762	.1612	.0701	.12
21	.1075	.0914	.1219	.0914	.1612	.0716	.12
22	.0716	.061	.1219	.0914	.1433	.0716	.12
23	.0716	1.448	1.5242	1.3717	.1433	.0701	.1029
24	1.9738	.0716	1.7909	1.97	1.7193	.1254	.0716
Max	2.4234	2.3624	2.1209	2.1384	2.0405	2.4234	2.6063
Min	.0514	.0514	.0457	.0457	.0762	.0701	.0343
Avg	.8745	.8363	.8477	.8562	.7146	.8186	.6935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 202 / LIS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.2579				.7233	.6791
2	.5114	.2602				.7484	.6791
3	.5114	.2602				.7492	.6699
4	.53	.2663				.7415	.6669
5	.5506	.2587				.7522	.6989
6	.6337	.295				.7636	.7087
7	.7582	.4215				1.076	.918
8	.9511	.5483				1.0917	.9861
9	.4656	.2766		1.06	1.1173	.5129	.4542
10			1.1805	1.4639	1.3138		
11			1.3291	1.32	1.3192		
12			1.2003	1.3032	1.3314		
13			1.131	1.2575	1.2673		
14			1.233	1.2498	1.2643		
15			1.2117	1.2346	1.1095		
16			1.1317	1.1919	1.0615		
17			.5091	.5952	.4824		
23	.2797				.6349	.5712	.7175
24	.7354	.1254			.3574	.6775	.7415
Max	.9511	.5483	1.3291	1.4639	1.3314	1.0917	.9861
Min	.2797	.1254	.5091	.5952	.3574	.5129	.4542
Avg	.5859	.2970	1.1158	1.1862	1.0235	.7643	.7200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 204 / MARALI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.2507	.2686		.2353	.2328
2	.2058	.2401	.2507	.2686	.2149	.2328	.2328
3	.2058	.2401	.2507	.2686	.2149	.2328	.2328
4	.2401	.2401	.2507	.2686	.2149	.2328	.2328
5	.2401	.3429	.3224	.2686	.2149	.2328	.2279
6	.3429	.3772	.3856	.394	.3429	.3582	.3506
7	.3772	.4287	.4801	.4382	.4031	.4557	.4961
8	.4287	.463	.4458	.4382	.4382	.4382	.4458
9	.4287	.4115		.3772	.3944	.3944	.3772
10	.3772	.3772	.3601	.3772	.3772	.4287	.3601
11	.3429	.3429	.3772	.3772	.3772	.3601	.3601
12	.3429	.3429	.4458	.3772	.3601	.3772	.3601
13	.3944	.3601	.4287	.3601	.3429	.3258	.3429
14	.3944	.3772	.3944	.3601	.3772	.3601	.2743
15	.4115	.3944	.4115	.3772	.3353	.3601	.3601
16	.3944	.4287	.4458	.3944	.3506	.3772	
17	.3944	.4287	.463	.3944	.3772	.3601	
18	.4477	.4458	.4115	.4801	.394	.4458	
19	.6268	.6344	.5658	.583	.6268	.5959	.7202
20	.6447	.583	.583	.6859	.6268	.7011	.7545
21	.591	.5144	.5316	.5487	.5373	.5731	.583
22	.4835	.463	.4458	.3772	.5014	.4477	.4801
23	.3582	.3601	.3429	.2915	.3224	.3224	.3086
24	.2058	.2686	.2686	.2686		.2328	.2328
Max	.6447	.6344	.583	.6859	.6268	.7011	.7545
Min	.2058	.2401	.2507	.2686	.2149	.2328	.2279
Avg	.3807	.3877	.3962	.3851	.3793	.3784	.3793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254022 / MALHARPETH

Feeder No / Name : 206 / SOMAIDEVI LIS EXPRESS

PURELY LIS FEEDERS

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.7537	.7994	.5757	.9092	1.3355
2	.0343	.7796	.8048	.6085	.9008	1.334
3	.0343	.778	.8048	.6085	.9762	1.3392
4	.0343	.778	.8048	.6085	.9465	1.3325
5	.0343	.7788	.8017	.6687	.8894	1.3184
6	.0343	.8146	.7995	.7483	.8924	1.3588
7	1.5097	1.893	1.88	1.6248	1.967	2.1788
8	2.1205	2.5568	2.5408	2.5195	2.0355	2.5053
9	2.1399	2.5339	1.3618	2.5034	2.0279	2.4501
10	2.1658	2.5332	2.1994	2.5362	1.7345	2.3342
11	2.1719	2.5881	2.4608	2.5438	2.3785	2.2222
12	2.1681	1.8411	1.6248	2.4783	2.4707	2.3678
13	2.1483	2.3945	1.9555	2.4516	2.4204	2.4737
14	2.1285	2.5431	1.9471	2.457	2.4097	2.3068
15	2.1567	2.5712	1.9494	2.4188	1.5036	2.3076
16	1.9882	2.4471	1.9318	2.2908	1.0006	2.3061
24	.0076	.0442	.0419	.1783		
Max	2.1719	2.5881	2.5408	2.5438	2.4707	2.5053
Min	.0076	.0442	.0419	.1783	.8894	1.3184
Avg	1.2301	1.6841	1.4534	1.6365	1.5914	1.9669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 201 / 11 KV Kalgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.316	.3108	.3148	.3037	.3098	.3067	.2907
2	.321	.3213	.3208	.3178	.3185	.2972	.2812
3	.3229	.3151	.3189	.3201	.3166	.3151	.2839
4	.3256	.3181	.32	.3182	.3144	.3144	.2846
5	.3726	.3444	.3578	.3506	.3543	.3345	.3166
6	.517	.5132	.5421	.4727	.5003	.4637	.5304
7	.7743	.777	.8166	.8417	.7735	.8086	.8288
8	.8613	.807	.9063	.7903	.4515	.836	.8223
9	.804	.753	.9133	.7079	.8371	.7386	.7167
10	.6992	.6298	.7668	.6676	.714	.6207	.6417
11	.6012	.5078	.5705	.5561	.6257	.5312	.4858
12	.5119	.5018	.5454	.5264	.5385	.4679	.4565
13	.474	.4746	.5129	.5079	.5693	.4881	.397
14	.4535	.4573	.4957	.4359	.5178	.4136	.3947
15	.4283	.4336	.4664	.4355	.5228	.2606	.4103
16	.4904	.2248	.4874	.4828	.6017	.5457	.4149
17	.5007		.623	.6463	.6714	.6407	.4089
18	.6121	.7648	.6792	.6228	.736	.7638	.4506
19	.8607	1.07	.9183	.9259	.9956	.8966	.7324
20	1.0848	1.1477	1.0829	1.1157	1.1024	1.1826	1.1138
21	1.0208	1.0112	1.0885	1.0292	1.0332	1.0925	1.0414
22	.8387	.8394	.8486	.8353	.8551	.8823	.8341
23	.5096	.4902	.5461	.5278	.5304	.5331	1.0601
24	.3334	.32	.3353	.3336	.3429	.333	.3372
Max	1.0848	1.1477	1.0885	1.1157	1.1024	1.1826	1.1138
Min	.316	.2248	.3148	.3037	.3098	.2606	.2812
Avg	.5848	.5797	.6157	.5863	.6055	.5861	.5639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 202 / 11 KV Jinti Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0829	.0819	.0937	.0781	.08	.0903
2		.0819	.08	.0937	.0781	.0937	.0903
3		.096	.08	.0937	.0781	.0937	.0903
4		.096	.08	.0937	.0781	.0937	.0903
5		.096	.0829	.1006	.0819	.0762	.1094
6		.1075	.0886	.1214	.0876	.12	.1227
7		.1791	.1791	.2012	.1791	.181	.197
8		.1753	.1595	.1772	.1772	.1772	.1907
9		.1417	.1402	.124	.1433	.1417	.1578
10		.1214	.1387	.0905	.1227	.1029	.1526
11		.1214	.116	.1017	.104	.1029	.104
12	.1387	.1029	.0972	.0867	.1029	.1052	.1029
13	.12	.1017	.0995	.0848	.1147	.1029	.0838
14	.1029	.0678	.0983	.0995	.125	.1134	.096
15	.1006	.0848	.0972	.0983	.1423		.096
16	.12		.1265	.1296	.125	.0983	.0972
17			.1389	.1635	.1467		.1143
18	.1457	.192	.1698	.2054	.1543	.1581	.1505
19	.2303	.2328	.2279	.2303	.208	.1928	.1753
20	.2561	.2378	.2715	.2534	.2534	.2353	.2378
21	.2353	.2378	.2534	.1991	.2172	.2172	.2195
22	.1991	.181	.1753	.1612	.1791	.1629	.1629
23	.1063	.104	.1097	.12	.1029	.1187	.12
24		.0838	.0829	.0972	.096	.096	.0937
Max	.2561	.2378	.2715	.2534	.2534	.2353	.2378
Min	.1006	.0678	.08	.0848	.0781	.0762	.0838
Avg	.1595	.1330	.1323	.1342	.1323	.1302	.1311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 203 / SANBUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1457	.1326	.1475	.125		.128	.1204
2	.1457	.1311	.144	.125		.125	.1204
3	.1457	.144	.144	.125		.125	.1204
4	.1457	.144	.144	.125		.1406	.1204
5	.1886	.144	.1823	.1677		.1372	.1406
6	.2865	.2507	.2658	.2774		.2401	.2279
7	.4656	.4298	.4477	.4207		.4525	.4119
8	.4607	.4382	.4607	.3898	.4607	.443	.4161
9	.4252	.4075	.4382	.3898	.4298	.4252	.3856
10	.3856	.3294	.3641	.362	.3506	.3429	.2543
11	.3155	.2947	.3481	.3561	.3121	.2743	.208
12	.2947	.2572	.2915	.3294	.2915	.298	.2058
13	.2572	.2374	.2486	.2883	.2785	.2401	.2012
14	.2572	.2374	.213	.2321	.2343	.1943	.176
15	.1844	.1696	.2105	.2458	.2372		.176
16	.2401		.2214	.2429	.2187	.2294	.1781
17	.2753		.2778	.2824	.2201	.2778	.2
18	.3401	.3521	.3086	.2934	.2469	.3005	.2408
19	.443	.5731	.4207	.4784	.4334	.4031	.3856
20	.5121	.4572	.4887	.5249	.5068	.5249	.4938
21	.4706	.4572	.4382	.4706	.4887	.4706	.4572
22	.3734	.362	.333	.3761	.394	.3439	.362
23	.2126	.1907	.2012	.2401	.2058	.1865	.2401
24	.1509	.1509	.1492	.1457		.144	.125
Max	.5121	.5731	.4887	.5249	.5068	.5249	.4938
Min	.1457	.1311	.144	.125	.2058	.125	.1204
Avg	.2968	.2859	.2870	.2922	.3318	.2803	.2487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 204 / TALMAVALE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.392	.4336	.4367	.439	.2408	.4023	.3889
2	.3852	.405	.4054	.426	.2218	.3859	.3805
3	.3882	.3985	.4001	.4245	.221	.3859	.382
4	.3867	.3947	.3924	.4192	.2141	.3798	.3767
5	.4142	.4244	.4464	.4854	.2263	.3902	.4138
6	.589	.6802	.6236	.6474	.3079	.6299	.6386
7	.8657	.8802	.9088	.9038	.4146	.9189	.9183
8	.9076	.9404	.9384	.9061	.8998	.9528	.9214
9	.8101	.8478	.9298	.8798	.9377	.8701	.852
10	.8307	.85	.937	.7842	.9328	.8123	.8495
11	.7941	.8249	.8114	.7124	.8153	.7907	.8794
12	.7796	.7571	.7175	.6956	.793	.7674	.7952
13	.6965	.6956	.6324	.6377	.6786	.6889	.6737
14	.6714	.6657	.626	.6512	.6177	.6588	.5625
15	.6767	.6796	.6137	.6626	.6518	.378	.548
16	.7472	.3475	.7343	.7242	.6531	.6874	.547
17	.7876		.7503	.8597	.6581	.7931	.5902
18	.7991	.9884	.671	.8477	.7432	.8329	.6706
19	.976	1.2155	.958	1.0075	1.0142	1.0083	.8665
20	1.1149	1.2872	1.0883	1.1759	1.1965	1.1344	1.0936
21	1.0216	1.1667	1.0115	1.0356	1.0803	1.0147	1.0067
22	.9221	.9503	.9237	.8516	.8718	.8888	.8852
23	1.2058	.7077	.6934	.6416	.6344	.6376	.6454
24	.4511	.5106	.4929	.4818	.269	.4557	.4573
Max	1.2058	1.2872	1.0883	1.1759	1.1965	1.1344	1.0936
Min	.3852	.3475	.3924	.4192	.2141	.378	.3767
Avg	.7339	.7414	.7143	.7209	.6372	.7027	.6810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 205 / Sanbur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2294	.25			
2			.2241	.25			
3			.2401	.25			
4			.2401	.25			
5			.2818	.2683			
6			.3366	.2601			
7			.4477	.4207			
8			.443	.3544	.4784		
9	.7087	.6556				.6201	.4733
10	.6859	.7108				.5316	.5256
11	.3856	.6588				.5144	.4681
12	.5548	.583				.5609	.4287
13	.583	.5256				.5144	.4024
14	.5658	.5087				.4696	.3201
15	.4359	.4917					.3201
16	.4973					.3932	.3401
23		.2601	.3475	.2229			
24			.2321	.2753			
Max	.7087	.7108	.4477	.4207	.4784	.6201	.5256
Min	.3856	.2601	.2241	.2229	.4784	.3932	.3201
Avg	.5521	.5493	.3022	.2802	.4784	.5149	.4098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

MALHAR PETH S/DN[109] BU 5941

Substation No/ Name :- 254025 / 33/11 KV DHEBEWADI

Feeder No / Name : 206 / 11 KV Kalgaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.1989				.16	.1505
2	.2267	.1802				.1562	.1505
3	.1781	.176				.1562	.1505
4	.1781	.176				.1562	.1656
5	.1886	.192				.1372	.1718
6	.2507	.2328				.2058	.1928
7	.3582	.3403				.2896	.2686
8	.3544	.2804				.3012	.2774
9			.5784	.2303	.5373		
10			.5895	.3258	.6661		
11			.5801	.2883	.6068		
12			.502	.6415	.5487		
13			.4973	.5765	.4915		
14			.4588	.5801	.4843		
15			.4534	.5079	.4586		
16			.4111	.6335	.4374		
23	.2126				.2058	.1865	.2743
24	.2515	.2012				.176	.1718
Max	.3582	.3403	.5895	.6415	.6661	.3012	.2774
Min	.1781	.176	.4111	.2303	.2058	.1372	.1505
Avg	.2426	.2198	.5088	.4730	.4929	.1925	.1974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 201 / 11 KV Mandure Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16		.1791	.16	.3224	.1433	.1989
2	.125	.1772	.1433	.125	.1772	.1433	.16
3	.125	.1772	.1433	.125	.1772	.1433	.16
4	.125	.1753	.1433	.125	.1753	.1433	.16
5	.16	.1753	.1791	.16	.1772	.1791	.1989
6	.2347		.2507	.1989	.2103	.2149	.2347
7	.3506	.3544	.3582	.3506	.3224	.3224	.3506
8	.3506	.3544	.3582	.3506	.2896	.3582	.3506
9	.3506	.3189		.3086	.3224	.3224	.3086
10	.3224	.2507	.2683	.2865	.3224	.2683	.3224
11	2.4806	.2507	.2683	.2481	.2149	.2347	.2865
12	.2507	.2149	.2347	.2507	.2865	.2347	.2507
13	.2481		.2347	.2149	.2507	.1989	.2507
14	.2481		.1989	.2149		.2683	.2149
15	.2865		.1989	.2481	.1433	.16	.2126
16	.3189		.2347	.3224	.2507	.1989	
17	.4252	.394	.3086	.0362	.2865	.2683	
18	.4961	.4298	.3506	.4656	.3224	.3506	
19	.5373	.5731	.5316	.543	.5731	.5731	
20	.6379	.6089	.6154	.6154	.5731	.6516	.6447
21	.5373	.5731	.5731	.5731	.4656	.6154	.5731
22	.4607	.394	.4252	.4298	.3582	.4656	.4656
23	.3155	.2507	.2347		.2149	.2683	.3189
24	.1772	.2126	.1791	.16	.2481	.1791	.1989
Max	2.4806	.6089	.6154	.6154	.5731	.6516	.6447
Min	.125	.1753	.1433	.0362	.1433	.1433	.16
Avg	.4052	.3270	.2875	.2831	.2906	.2878	.2931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 202 / LIS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3412	4.1762				4.933	4.2113
2	4.0474	4.0676				4.7333	4.0063
3	3.9769	2.0088				4.3941	3.9434
4	4.0013	3.9568				4.2935	3.8962
5	3.9297	2.0073				4.2722	3.8794
6	4.0387	4.236				4.3591	3.9312
7	4.2798	4.6864				5.0594	4.4147
8	4.3461	4.8636				5.013	4.4799
9	1.2193	1.39	2.7008	5.7197	6.2334	1.198	1.2346
10			6.1861	6.7291	6.7017		
11			6.6952	6.9624	6.499		
12			6.2217	6.3268	2.5804		
13			6.0205	5.9915	.4786		
14			5.8764	6.0867	2.9218		
15			6.1419	6.0688	3.892		
16			6.0014	5.8848	3.6229		
17			5.0907	1.4891	5.131		
18			1.233		.8871		
23	3.9559				4.5679	3.9971	4.3363
24	4.3073	1.9631			2.6795	4.7509	4.4467
Max	4.3461	4.8636	6.6952	6.9624	6.7017	5.0594	4.4799
Min	1.2193	1.39	1.233	1.4891	.4786	1.198	1.2346
Avg	3.8585	3.3356	5.2168	5.6954	3.8496	4.2731	3.8891

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 203 / ADUL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9679	1.0616	.9442	.9114	.9465	.8821	.9073
2	.9076	1.0116	.8878	.8554	.8936	.8311	.8474
3	.8924	.9773	.8234	.8501	.8814	.8181	.8311
4	.9759	.9869	.8276	.8897	.865	.8322	.8627
5	1.1649	1.1131	1.0403	1.0989	1.02	1.0883	1.0041
6	1.5547	1.3078	1.4114	1.5512	1.4202	1.4209	1.3649
7	2.1636	2.2089	2.0249	2.2531	2.037	1.9502	2.1083
8	2.2432	2.2957	2.199	2.298	2.2409	1.9551	2.2055
9	2.0668	2.2416	1.1157	2.3491	2.3015	1.741	2.2237
10	1.9033	2.3179	2.2047	2.3107	2.0424	1.7143	1.9608
11	1.8721	2.3072	2.3709	2.1681	2.154	1.9772	1.8812
12	1.7825	1.7703	2.1529	2.2165	2.042	2.1049	1.7185
13	1.6762	.9835	1.935	1.9917	.7301	1.8881	1.4117
14	1.4358	.9381	1.7509	1.0219	.6706	1.7886	1.2449
15	1.4682	1.0951	1.7333	1.3382	1.7596	1.6083	1.4277
16	1.7193	1.0418	1.8275	1.5512	1.9136	1.861	.6421
17	1.8255	1.9502	1.4285	1.9597	1.9292	1.7806	
18	2.0474	1.0296	1.9551	2.2223	2.031	1.9079	
19	2.3164	2.487	2.4623	2.4463	2.5381	2.4047	2.9324
20	2.8319	2.8171	2.8167	2.7832	2.7004	2.7774	2.9885
21	2.5595	2.5324	2.4844	2.5016	2.4985	2.5503	2.6993
22	2.1624	2.2059	2.122	2.2924	2.1571	2.1399	2.3107
23	1.6839	1.5242	1.4324	.9633	1.5577	1.528	1.5257
24	1.1508	1.1473	1.0672	1.1043	1.1004	.9343	1.0425
Max	2.8319	2.8171	2.8167	2.7832	2.7004	2.7774	2.9885
Min	.8924	.9381	.8234	.8501	.6706	.8181	.6421
Avg	1.7238	1.6397	1.7091	1.7470	1.6846	1.6869	1.6428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 204 / HELWAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0201	.769	.6271	.7255	.7286	.6874	.6553
2	.9343	.7164	.6241	.6768	.719	.6363	.5799
3	.8966	.7088	.5746	.6722	.7088	.6432	.5815
4	.876	.7118	.5829	.6463	.7179	.6493	.5799
5	.916	.775	.6425	.6158	.7568	.7392	.6615
6	1.1477	.4481	.8253	.8459	.9488	.8718	.8314
7	1.8976	1.5942	1.3427	1.3866	1.4625	1.2932	1.3321
8	2.0835	1.6922	1.5585	1.4281	1.6926	1.7352	1.6846
9	2.287	1.8015	.8528	1.8233	1.818	1.7581	1.8298
10	2.1727	1.6667	1.8427	1.9277	1.9959	1.5002	1.7596
11	1.8869	1.5181	1.7326	2.0622	1.9981	1.0875	1.7269
12	1.6544	1.3862	1.5444	1.8343	1.717	1.611	1.6012
13	1.198	.7423	1.4312	1.5512	1.5684	1.5203	1.5494
14	1.1652	.7308	1.2018	1.5703	.8787	1.4636	1.4532
15	1.1842	.6965	1.5005	1.6095	1.5852	1.2711	1.4182
16	1.4007	.8109	1.5539	1.877	1.6171	1.5147	.8101
17	1.7116	1.6415	1.6248	2.0885	1.88	1.5676	
18	1.8297	1.8984	1.8198	2.2051	1.9906	1.7802	
19	2.0999	2.1903	2.3747	2.3998	2.3845	2.3537	2.4383
20	2.2924	2.4889	2.5636	2.508	2.4059	2.5453	2.6063
21	2.127	2.1796	2.226	2.2032	2.1293	2.2893	2.2885
22	1.7696	1.6713	1.7265	1.714	1.6369	1.8229	1.9875
23	1.2449	1.0951	1.153	.6661	1.1058	1.1428	1.3359
24	.9914	.8139	.7713	.7636	.7903	.7301	.8032
Max	2.2924	2.4889	2.5636	2.508	2.4059	2.5453	2.6063
Min	.876	.4481	.5746	.6158	.7088	.6363	.5799
Avg	1.5328	1.2811	1.3624	1.4917	1.4682	1.3839	1.3870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 205 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.5075	.4447	.5205	.4706	.4291	.4896
2	.3398	.4557	.4028	.4931	.4054	.4051	.4051
3	.3459	.4199	.4009	.4786	.3955	.4058	.3967
4	.3433	.4153	.402	.4374	.3951	.3902	.3951
5	.3662	.418	.3944	.439	.3982	.4165	.3959
6	.4001	.4313	.4176	.4546	.4142	.4344	.3925
7	.5164	.4904	.522	.5411	.4797	.4793	.4858
8	.5414	.5372	.5262	.604	.527	.5608	.5822
9	.7053	.7495	.229	.7636	.6931	.6916	.6713
10	.7587	.9396	.7789	.879	.7012	.6653	.7267
11	.876	1.1127	1.0848	1.0231	.8349	.9972	.7651
12	1.052	1.1911	1.126	1.0871	.9815	1.0746	.8813
13	1.0234	1.0939	1.0334	1.0128	.9522	1.0105	.8425
14	.8371	.887	.9042	.8158	.4649	.8158	.6638
15	.8688	.897	.8158	.6493	.8131	.8208	.5811
16	.7773	.8432	.7239	.7396	.7556	.8017	.2763
17	.6295	.6683	.6855	.6775	.6749	.6881	
18	.538	.5289	.5853	.5956	.5079	.53	
19	.4451	.4047	.4332	.5453	.4793	.394	.3929
20	.4134	.3864	.3879	.4675	.4161	.4553	.3932
21	.4104	.3917	.3951	.4443	.415	.4527	.4363
22	.4435	.4854	.4904	.482	.4809	.5544	.495
23	.5372	.639	.5987	.2999	.5369	.6127	.5175
24	.5468	.6435	.6256	.6261	.538	.5354	.5578
Max	1.052	1.1911	1.126	1.0871	.9815	1.0746	.8813
Min	.3398	.3864	.229	.2999	.3951	.3902	.2763
Avg	.5898	.6474	.6003	.6282	.5721	.6092	.5338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 206 / 11 KV Mandure Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2454		.0053		.4115	.3658
2	.2149	.2103		.0057		.3772	.3258
3	.2149	.2149		.0057		.3429	.2896
4	.2149	.2103		.0061		.3429	.2896
5	.2507			.0053		.3429	.3258
6	.2896	.2835		.0053		.3429	.3292
7	.3582	.2804		.0057		.4115	.3582
8	.3292	.3189		.0065		.4298	.3982
9	.0103			.9568	.9465		.0114
10			.8238	.8764	1.0288	.0099	
11			.9671	.815	.8573	.0099	
12			.9313	.815	.8573	.0095	
13			.8954	.7796	.7888	.0088	
14			.815	.7442		.0057	
15			.8238	.7087	.583	.0042	
16			.7602	.6805	.583	.0038	
17			.008			.0038	
18			.0042			.0057	
19			.0065			.0111	
20			.0065			.0095	
21			.0061			.0084	
22			.0061			.0076	
23	.2126		.0061		.4115	.3292	.2103
24	.2481	.2481		.0053		.4458	.3658
Max	.3582	.3189	.9671	.9568	1.0288	.4458	.3982
Min	.0103	.2103	.0042	.0053	.4115	.0038	.0114
Avg	.2361	.2515	.4329	.3781	.7570	.1685	.2972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 207 / 11 KV Helwak Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1871	.208	4.0916	4.6373	4.281	.1715	.2294
2	.1883	.2111	3.959	4.5195	3.8157	.1707	.2313
3	.1898	.2134	3.9171	4.3454	3.5254	.1707	.2321
4	.1898	.2134	3.7228	4.1854	3.4629	.1722	.2309
5	.1902	.2134	3.6991	4.1747	3.3825	.173	.2317
6	.1887	.2134	3.7502	4.2243	3.3589	.173	.2306
7	.1932	.2119	4.4719	4.6952	3.8028	.173	.2309
8	.2016	.2126	4.3118	4.4726	3.9079	.16	.2355
9	4.6022	5.0022	2.2451	1.7132	1.5005	.3353	5.3551
10	4.9253	1.3283	.1798	.1616	.1799	.1585	5.5369
11	5.3033	3.8897	.1791	.1661	.1799	.0617	3.3234
12	5.4428	5.4763	.1798	.1791	.1974	5.2347	2.9271
13	5.7732	5.5289	.1791	.1684	.0945	5.8009	5.4641
14	5.7015	5.1836	.1795	.1631	.2134	5.7454	5.5532
15	5.7864	5.311	.1787	.1608	.2454	5.0564	5.5472
16	3.1321	5.397	.1784	.1623	.1494	5.583	2.7778
17	.1806	4.5023	.1646	.1898	.1532	5.3566	
18	.1128	1.6027	.1738	.1959	.1463	2.2032	
19	.1585	.2309	.1833	.1852	.1814	.1677	.2355
20	.2126	.2157	.1894	.1669	.1669	.2275	.2286
21	.2126	.2187	.1901	.1837	.1661	.2294	.2294
22	.2119	.2263	.194	.2103	.1684	.2306	.2332
23	.2119	4.3667	4.1023	2.1948	.173	.2313	.234
24	.2096	2.3708	2.2908	4.5702	2.2992	.2256	.0046
Max	5.7864	5.5289	4.4719	4.6952	4.281	5.8009	5.5532
Min	.1128	.208	.1646	.1608	.0945	.0617	.0046
Avg	1.8211	2.1895	1.7880	1.9177	1.4897	1.5922	1.7956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 208 / Patan Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3898	.3544	.3582	.3898	.3582	.3582	.3898
2	.3506	.3224	.3582	.3506	.3224	.3582	.3506
3	.3506	.3224	.3582	.3506	.3224	.3582	.3506
4	.3506	.3582	.3582	.3898	.3224	.3582	.4252
5	.4252	.4298	.4298	.4252	.3982	.4298	.5014
6	.5731	.4298	.5731	.6089	.5731	.5373	.5731
7	.8326	.815	.8596	.8688	.7522	.7522	.7964
8	.7602	.7712	.788	.724	.181	.6805	.7602
9	.6878	.6733		.6516	.6878	.5731	.6089
10	.5373	.5373	.5731	.6447	.5731	.5373	.5731
11	.5373	.5731	.5373	.5731	.5014	.5014	.5373
12	.543	.5731	.5731	.5792	.5014	.5731	.5014
13	.5373	.5373	.5373	.5731	.5014	.5373	.5014
14	.5373	.5373	.5373	.5731		.5373	.5014
15	.543	.5373	.5731	.5792	.5373	.5373	.5373
16	.5373	.5731	.5731	.5792	.5373	.5731	
17	.5731	.5731	.6089	.6154	.5373	.5373	
18	.7164	.6805	.6089	.724	.6447	.6089	
19	.8688	.8596	.8688	.8326	.8596	.8326	.8688
20	.8688	.8596	.8326	.8688	.8238	.8688	.8954
21	.7964	.7522	.7602	.7602	.7164	.7602	.788
22	.6024	.6805	.5731	.6878	.6089	.6516	.7164
23	.5014	.5014	.5014		.4656	.4656	.5373
24	.394	.394	.394	.4252	.394	.394	.3898
Max	.8688	.8596	.8688	.8688	.8596	.8688	.8954
Min	.3506	.3224	.3582	.3506	.181	.3582	.3506
Avg	.5756	.5686	.5711	.5989	.5270	.5551	.5764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254021 / PATAN

Feeder No / Name : 402 / MARALI

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.2058			
9	.3155				.2058	.2058
10	.3086	.3086		.3086	.7202	.2103
11	.3086	.7202		.7282	.7202	.3121
12	.3052	.7202		.7282	.7202	.3155
13	.3086	.7202		.7362	.7202	.3155
14	.3086	.7202		.7282		.3121
15		.7202		.7442		
16				.7282		
Max	.3155	.7202	.2058	.7442	.7202	.3155
Min	.3052	.3086	.2058	.3086	.2058	.2058
Avg	.3092	.6516	.2058	.6717	.6173	.2786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 201 / Rasati Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1629	.1437	.1947	.124	.1612	.2164
2		.1648	.1448	.16	.1271	.1631	.216
3		.1721	.1433	.1589	.1236	.1646	.1863
4		.1764	.1444	.1608	.1284	.1676	.1878
5		.1911	.1486	.2023	.1288	.1669	.1947
6		.1986	.2363	.269	.1412	.2328	.2561
7		.2737	.3517	.341	.2377	.447	.4001
8		.3224	.3514	.4313	.3071	.5327	.535
9		.6436	.141	.5434	.6199	.5152	.5536
10		.6066	.2565	.62	.623	.3693	.5091
11		.581	.3906	.1997	.6313	.3738	.3834
12	.1656	.5906	.5155	.2714	.5925	.434	.3239
13	.2057	.4828	.4755	.2869	.5421	.4493	.3178
14	.2021	.4024	.2942	.2962	.2812	.3932	.2964
15	.279	.4478	.4001	.2935		.3677	.373
16	.3188	.3994	.4992	.2594	.2945	.3133	
17	.3681	.4466	.4592	.3219	.485	.3254	
18	.6565	.5087	.5079	.3282	.5678	.3677	.2206
19	.3931	.5438	.6092	.3707	.6553	.3628	.6039
20	.3719	.4931	.6279	.372	.6698	.6043	.6055
21	.3791	.4626	.6089	.3462	.6135	.546	.4641
22	.3114	.3372	.418	.2539	.399	.4587	.3353
23	.2081	.1909	.3007	.1614	.2366	.3273	.2203
24	.4119	.0991	.1814	.2176	.116	.1867	.2184
Max	.6565	.6436	.6279	.62	.6698	.6043	.6055
Min	.1656	.0991	.141	.1589	.116	.1612	.1863
Avg	.3173	.3708	.3479	.2942	.3759	.3513	.3463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 202 / KOYANA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1883	.1932	.1951	.1671	.1898	.2134
2		.1984	.1726	.173	.1713	.1757	.197
3		.2124	.1719	.1768	.1697	.1787	.1981
4		.2135	.1989	.1772	.1709	.2012	.197
5		.2063	.1981	.1768	.1709	.2001	.2248
6		.1899	.2237	.2328	.1733	.2214	.2412
7		.2181	.3117	.3582	.2189	.3269	.3319
8		.2383	.3577	.3631	.2427	.3684	.3627
9		.2199	.1261	.4675	.3787	.3216	.3327
10		.2433	.2884	.2984	.3433	.2416	.2987
11		.3354	.2538	.3452	.3018	.234	.3421
12	.1283	.3769	.3056	.222	.3479	.3315	.2915
13	.1515	.3422	.2115	.2132	.3788	.3471	.2824
14	.1477	.3201	.2378	.2243	.2031	.3014	.2835
15	.1561	.3075	.2588	.2254		.3532	.2347
16	.253	.3688	.3174	.2442	.2519	.3555	
17	.3428	.5056	.4126	.3633	.418	.4676	
18	.3503	.4953	.4462	.3726	.49	.5277	.1486
19	.4092	.5773	.6584	.354	.6013	.6637	.6595
20	.4214	.5922	.6588	.3971	.6474	.6745	.6496
21	.3925	.5395	.583	.3551	.5342	.6002	.5994
22	.3306	.4393	.4287	.3272	.4537	.4603	.5079
23	.2269	.2374	.2988	.2203	.2614	.3106	.325
24	.4253	.1271	.2088	.2686	.1309	.2176	.2499
Max	.4253	.5922	.6588	.4675	.6474	.6745	.6595
Min	.1283	.1271	.1261	.173	.1309	.1757	.1486
Avg	.2874	.3205	.3134	.2813	.3142	.3446	.3260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

PATAN S/DN.[112]

BU 5959

Substation No/ Name :- 254024 / RASATI

Feeder No / Name : 203 / Rasati Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0057	.8296	.8291	.5044		
2		.0091	.801	.8139	.4953		
3		.0099	.7953	.8181	.502		
4		.0137	.8082	.799	.4894		
5		.0084	.7987	.7949	.4822		
6		.0221	.8547	.812	.4897		
7		.0221	.9716	.8547	.5314	.0008	
8		.037	.8581	1.0136	.5646	.0008	.0008
9		.4914	.4207	.4237	.4005	.8223	.9952
10		.7024	.0004			.9983	1.1572
11		1.3836				1.1077	1.1847
12	.1372	1.4392				1.1786	1.2876
13	.4994	1.3089				1.2098	1.1683
14	.6274	1.3862				1.1195	1.2342
15	.707	1.4026				1.188	1.2406
16	.736	1.2814			.0004	1.2243	.6843
17	.6866	.519		.0366		.5163	
18	.0911			.0149		.0453	
19						.0171	
20			.0263				
21	.0191		.0297				
22	.0084	.0004					
23	.0061	.7857	.6915	.237			
24	.2641	.4733	.8147	.8592	.0407		
Max	.736	1.4392	.9716	1.0136	.5646	1.2243	1.2876
Min	.0061	.0004	.0004	.0149	.0004	.0008	.0008
Avg	.3439	.5651	.6215	.6390	.4091	.7253	.9948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 201 / CHAFAL

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1029	.0857	.0857	.0857	.1029	.1029
2	.0953	.1029	.0857	.0857	.0857	.1029	.1029
3	.0953	.1029	.0857	.0857	.0857	.1029	.1029
4	.0953	.1029	.1029	.0857	.0857	.1029	.1029
5	.1143	.1029	.12	.1029	.0857	.1372	.1029
6	.1334	.12	.1372	.1372	.1029	.1372	.12
7	.1905	.1372	.1715	.1543	.1715	.1715	.1543
8	.1715	.1543	.1524	.1715	.1715	.1715	.1715
9	.1715	.1543		.1543	.1715	.1543	.1543
10	.1715	.1372	.1715	.1543	.1715	.1543	.1372
11	.1715	.1524	.1715	.1543	.1543	.1543	.1372
12	.1715	.1524	.1715	.1543	.1543	.1543	.1372
13	.1715	.1524	.1715	.1543	.1543	.1543	.1372
14	.1715	.1524	.1715	.1543	.1543	.1372	.1543
15	.1715	.1524	.1715	.1543	.1543	.1372	.1543
16	.1715	.1334	.1715	.1543	.1543	.1372	.1543
17	.1715	.1372	.1715	.1543	.1543	.1372	.1543
18	.1715	.1715	.1905	.1715	.1715	.1715	.1543
19	.6173	.2058	.2286	.2058	.2058	.1886	.2058
20	.2229	.2058	.2667	.2229	.2058	.2229	.2058
21	.1886	.1715	.1905	.2058	.1715	.2058	.2058
22	.1543	.1372	.1524	.1543	.1372	.1715	.1715
23	.12	.1029	.1143	.1029	.1372	.12	.1029
24	.0953	.1029	.0857	.0857	.0857	.1029	.1029
Max	.6173	.2058	.2667	.2229	.2058	.2229	.2058
Min	.0953	.1029	.0857	.0857	.0857	.1029	.1029
Avg	.1710	.1395	.1540	.1436	.1422	.1472	.1429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 202 / MASUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6173	.5144	.6516	.583	.5144	.6001
2	.6859	.6173	.5144	.6516	.583	.5144	.6001
3	.6859	.6173	.5144	.6516	.583	.5144	.6001
4	.6859	.6173	.5144	.6516	.583	.5144	.6001
5	.6859	.6173	.6859	.6173	.583	.5144	.6001
6	.9526	.7888	.7716	.823	.7202	.6859	.7545
7	1.1431	1.0631	.9431	.823	1.0669	1.0288	1.0288
8	1.1431	1.0631	.9526	.9945	1.105	.9431	.9945
9	1.0669	.8916		.8916	1.0669	.8916	.8573
10	.9145	.8916	1.0669	.8916	1.0288	.8916	.8573
11	.9145	.9526	.9526	.823	.8573	.7888	.7888
12	.9526	.9526	.9145	.823	.8764	.823	.6516
13	.8383	.9526	.8002	.8573	.9145	.7888	.7202
14	.8383	.8764	.8002	.7888	.7888	.823	.6859
15	.8002	.8764	.8002	.7888	.7202	.8059	.6859
16	.8764	.8383	.8383	.823	.7888	.8573	.7202
17	.9526	.8916	.9526	.823	.823	.8573	.7202
18	.9602	.9602	1.0669	.9602	.8916	.9602	.8573
19	1.2346	1.0288	1.3336	1.166	1.0288	1.2346	1.2003
20	1.2346	1.2003	1.3717	1.2003	1.2003	1.2346	1.2003
21	1.1317	1.0288	1.2193	1.0631	1.0288	1.0974	1.0288
22	.9945	.9431	1.105	.9259	.8573	.9945	.8573
23	.7888	.8573	.9145	.7545	.6859	.7888	.6859
24	.6173	.6516	.6859	.6859	.6516	.6001	.6516
Max	1.2346	1.2003	1.3717	1.2003	1.2003	1.2346	1.2003
Min	.6173	.6173	.5144	.6173	.583	.5144	.6001
Avg	.9077	.8665	.8797	.8388	.8340	.8195	.7895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 203 / PAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.166	1.3717	1.5242	1.2003	1.2003	1.3032
2	1.1431	1.166	1.3717	1.5242	1.2003	1.2003	1.3032
3	1.1431	1.166	1.3717	1.5242	1.2003	1.2003	1.3032
4	1.1431	1.166	1.3717	1.5242	1.2003	1.2003	1.3032
5	1.1431	1.166	1.5432	1.5242	1.2003		1.3032
6	1.2193	1.166	1.5432	1.3717	1.2346		1.3032
7	1.5242	1.3717	1.5432	1.7147	1.5242		1.5089
8	1.6385	1.4746	1.7147	1.7147	1.5623		1.5775
9	1.9814	2.0919		2.21	2.0957		1.9547
10	2.0957	2.1948	2.21	2.0576	2.4006	2.1262	2.2634
11	2.5911	2.4387	2.4768	2.2291	2.332	2.1605	2.3663
12	2.553	2.5149	2.4006	2.1262	2.2291	2.332	2.3663
13	2.4768	2.3243	2.2481	1.2689	1.9547	2.2291	2.2291
14	2.4006	2.2862	2.2481	1.9547	1.8861	2.1605	2.1262
15	2.4006	2.2862	2.3243	2.0233	1.7833	1.989	2.0576
16	2.3243	2.2862	2.1719	1.8861	1.7147	1.8519	
19	.0343	.0514	.0953	.0343	.0514	.0514	.0343
20	.0343	.0514	.0953	.0343	.0514	.0514	.0343
21	.0343	.0514	.0953	.0343	.0514	.0514	.0343
22	.0343	.0514	.0953	.0343	.0514	.0514	.0343
23	1.1317	1.4575	1.5242	1.2003	1.2003	1.3032	1.3717
24	1.1431	1.166	1.4575	1.5242	1.9547	1.2003	1.3375
Max	2.5911	2.5149	2.4768	2.2291	2.4006	2.332	2.3663
Min	.0343	.0514	.0953	.0343	.0514	.0514	.0343
Avg	1.4242	1.4134	1.4892	1.4109	1.3672	1.3153	1.3865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 204 / PERLE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2572	.2572	.2401	.2401	.2572	.2401
2	.2477	.2572	.2572	.2401	.2401	.2572	.2401
3	.2477	.2572	.2572	.2401	.2401	.2572	.2401
4	.2477	.2572	.3429	.2401	.2401	.2572	.2401
5	.3239	.2915	.4287	.3086	.2743	.2572	.2401
6	.4954	.4458	.5144	.4458	.4115	.5144	.3772
7	.6478	.5487	.5144	.6173	.6097	.6859	.5144
8	.6859	.6173	.5716	.5487	.6097	.5144	.5144
9	.4954	.4801		.4458	.5335	.4801	.3086
10	.381	.4115	.381	.3429	.381	.3772	.2743
11	.381	.381	.381	.3429	.4191	.3429	.3429
12	.381	.3429	.381	.3086	.3429	.3429	.3429
13	.4191	.381	.381	.2743	.3429	.3086	.3086
14	.4191	.381	.3429	.3086	.3429	.3086	.3086
15	.4191	.381	.3429	.3429	.3429	.3086	.2743
16	.381	.381	.381	.3429	.3086	.3086	.2743
17	.381	.3772	.4191	.2743	.3429	.3429	.3086
18	.4458	.3772	.4572	.4115	.4458	.4115	.3429
19	.6173	.6859	.7621	.6516	.6859	.5144	.5144
20	.6173	.6859	.724	.6516	.6859	.6516	.6001
21	.5487	.5144	.5716	.5487	.6859	.5487	.6859
22	.4115	.4287	.4954	.4458	.5144	.4458	.5144
23	.3086	.3429	.381	.3086	.2572	.3429	.3429
24	.2477	.2572	.2572	.2401	.2401	.2572	.2401
Max	.6859	.6859	.7621	.6516	.6859	.6859	.6859
Min	.2477	.2572	.2572	.2401	.2401	.2572	.2401
Avg	.4166	.4059	.4262	.3801	.4057	.3872	.3579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 205 / VARADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0343	1.0288	.8573	.9259	.0343	.0343
2	.0381	.0343	1.0288	.8573	1.0288	.0343	.0343
3	.0381	.0343	1.0288	.8573	1.0288	.0343	.0343
4	.0381	.0343	1.0288	.8573	1.0288	.0343	.0343
5	.0343	.0343	1.0288	.8573	1.0288	.0343	.0343
6	.0381	.0343	1.2003	.9602	1.0669	.0343	.0343
7	.0381	.0343	1.2003	1.0631	1.1431	.0343	.0343
8	.0381	.0343	.1905	1.1317	1.2574	.0343	.0343
9	1.448	1.5432		.0343	.0381	1.5089	1.4746
10	1.829	1.6461	.0381	.0343	.0381	1.6461	1.6461
11	1.829	1.8671	.0381	.0343	.0343	1.6461	1.6461
12	1.8671	1.7909	.0381	.0343	.9945	1.7147	1.5089
13	1.829	1.7528	.0381	.0343	.0343	1.6461	1.6461
14	1.829	1.7147	.0381	.0343	.0343	1.5432	1.5775
15	1.7528	1.7147	.0381	.0343	.0343	1.4403	1.5775
16	1.7528	1.448	.0343	.0343	.0343	1.4746	
17	.0381	.0343	.0381	.0343	.0343	.0343	
18	.0343	.0343	.0381	.0343	.0343	.0343	
19	.0343	.0343	.0381	.0343	.0343	.0343	.0343
20	.0343	.0343	.0381	.0343	.0343	.0343	.0343
21	.0343	.0343	.0381	.0343	.0343	.0343	.0343
22	.0343	.0343	.0381	.0343	.0343	.0343	.0343
23	.0343	1.0288	.9907	.9602	.0343	.0343	.0343
24	.0381	.0343	1.0288	.8573	.9602	.0343	.0343
Max	1.8671	1.8671	1.2003	1.1317	1.2574	1.7147	1.6461
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.6133	.6259	.4455	.4058	.4563	.5487	.5503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 206 / CHAFAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.823	.0514	.7621	.0572	.6859	.6859
2	.8383	.823	.0514	.0514	.0572	.6859	.6516
3	.8383	.823	.0514	.0514	.0572	.6859	.6173
4	.8383	.823	.0514	.0514	.0572	.6859	.6173
5	.8383	.823	.0514	.0686	.0572	.6859	.6173
6	.8383	.8573	.0514	.0857	.0953	1.0288	.6173
7	1.2193	1.0288	.0514	.0857	.0953	1.0288	.9945
8	1.2193	1.2346	.0572	.0857	.0953	1.0288	1.0974
9	.0953	.0514		1.3717	1.5623	.0686	.0857
10	.0953	.0514	1.7528	1.4746	1.7528	.0514	.0514
11	.0762	.0572	1.829	1.5089	1.5089	.0514	.0514
12	.0572	.0572	1.829	1.4746	1.105	.0514	.0514
13	.0572	.0572	1.7528	1.3375	1.3375	.0514	.0514
14	.0572	.0572	1.6385	1.2689	1.406	.0514	.0514
15	.0572	.0572	1.5242	1.2346	1.3375	.0051	.0514
16	.0572	.0572	1.5242	1.166	1.2346	.0514	.0514
17	.0572	.0343	.0572	.0514	.0514	.0514	.0514
18	.0686	.0686	.0762	.0514	.0857	.0857	.0514
19	.12	.0686	.1334	.1029	.0514	.12	.0514
20	.12	.0686	.1334	.1029	.0514	.12	.0514
21	.1029	.0686	.1143	.1029	.0514	.1029	.0514
22	.0857	.0514	.0953	.0857	.0514	.0857	.0514
23	.8573	.0514	.0762	.0686	.7716	.7545	.5716
24	.8764	.8573	.0514	.0514	.0572	.6859	.7545
Max	1.2193	1.2346	1.829	1.5089	1.7528	1.0288	1.0974
Min	.0572	.0343	.0514	.0514	.0514	.0051	.0514
Avg	.4296	.3729	.5654	.529	.5412	.3710	.3324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254003 / UMBRAJ

Feeder No / Name : 401 / UMESHWAR LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0827	.0729	2	1.7116	1.6048	1.9713	
2	.0861	.0777	2.2005	2.1363	1.3921	2.0134	
3	.0889	.2371	2.4544	2.1329	1.3867	2.2673	
4	1.0901	.8238	2.7106	2.1348	1.7381	2.257	
5	2.6141	2.7033	2.9709	2.9848	2.1495	2.2591	
6	2.9508	2.5906	2.9791	2.9959	2.3129	2.4735	
7	3.2811	2.761	3.0493	3.2739	2.6642	2.4764	
8	3.0998	2.8415	3.1244	3.0446	2.7916	2.9686	
9	3.0533	2.9798	1.3728	2.8092	3.0927	2.8803	
10	3.3009	2.1984	2.9509	2.6761	3.1039	2.9275	
11	2.9993	2.277	1.5674	2.7367	3.0121	2.9465	
12	2.3377	2.4474	2.8506	2.6696	2.916	2.9127	
13	1.6786	2.3272	2.9055	2.5878	2.9024	2.8716	
14	.8546	2.4471	3.0711	2.6163	2.931	2.8129	
15	1.5783	2.3057	2.9511	2.4873	2.9052	2.8052	
16	1.2871	1.8657	2.1909	1.6315	1.9781	1.7668	1.8067
17							1.7174
18							1.6059
19							.0601
24	.0716	.6304	1.8219	.5497	.5817		.2121
Max	3.3009	2.9798	3.1244	3.2739	3.1039	2.9686	1.8067
Min	.0716	.0729	1.3728	.5497	.5817	1.7668	.0601
Avg	1.7915	1.8580	2.5395	2.4223	2.3214	2.5381	1.0804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 201 / shamgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9521	3.4366	.0152	.0175		3.3805	1.4456
2	3.887	3.2693	.0154	.0171		3.2507	1.4243
3	3.8272	3.2275	.0158	.0175		3.2434	1.3885
4	3.802	3.1398	.017	.0175	.0179	3.0903	1.2872
5	3.7087	3.123	.0168		.0181	3.0295	1.2856
6	3.6024	3.1272	.0183	.0181	.0179	2.9515	1.2932
7	3.7716	3.1064	.0187	.0183	.0183	2.886	1.5181
8	3.9807	3.7725	.0177	.0181	.0998	3.0171	1.8795
9	2.0193	2.0633	4.428	4.67	4.6018	1.5457	.9903
10	.0181	.0131	4.8994	5.0312	4.5512	.0171	.0152
11	.0178	.017	5.2115	5.5327	4.8918	.017	.017
12	.0183	.0172	5.2797	5.4934	4.8552	.016	.0168
13	.017	.0154	5.253	5.2875	5.012	.017	.0143
14	.017	.0189	5.4363	5.1073	4.9559	.0152	.0147
15	.0173	.0158	5.3563	4.9939	4.6791	.0156	.0143
16	.0181	.0152	5.1402	4.9718	4.4951	.017	.017
17	.0328	.0171	2.6605	2.6368	2.3621	.0196	.017
18	.0234	.0156	.0154	.0198	.0171	.0179	.0162
19	.0204	.0423	.0168	.0179	.0198	.0353	.0166
20	.0181	.0173	.017	.0173	.0581	.0171	.0166
21	.0183	.0175	.017	.0171	.0171	.0168	.0168
22	.0185		.0179	.0183	.0173	.0177	.017
23	3.5372	.0242	.0181	.0185	3.2632	1.5474	1.8991
24	3.7148	1.5893	.0158	.0175	1.8425	2.4253	1.7338
Max	3.9807	3.7725	5.4363	5.5327	5.012	3.3805	1.8991
Min	.017	.0131	.0152	.0171	.0171	.0152	.0143
Avg	1.6691	1.3088	1.8299	1.9120	2.1815	1.2753	.6814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 202 / Helgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1371	.1432	2.3899	2.5774	1.5478	.061	.0868
2	.1364	.1441	2.2416	2.3441	1.4129	.061	.1357
3	.157	.144	2.3526	2.2938	1.3512	.0617	.1387
4	.1554	.16	2.4322	2.156	2.2801	.0633	.1448
5	.16	.1646	2.5953	2.1583	2.2763	.0717	.1501
6	.1577	.1661	2.9545	2.2116	1.322	.0602	.1494
7	.0876	.1586	3.7428	3.248	3.187	.109	.1517
8	.1303	.1494	3.8161	3.5814	3.685	.1189	.1509
9	3.6014	3.7174	1.2726	1.0814	1.2544	3.7669	3.1303
10	4.2093	4.7134	.083	.0731	.1478	4.2412	3.4468
11	4.1697	4.4864	.0663	.067	.1448	4.3732	3.0304
12	3.8996	4.1457	.0709	.0755	.1486	4.1	2.8334
13	3.8066	3.7525	.1357	.0945	.1722	3.8298	2.5564
14	3.6061	3.5269	.1487	.157	.1882	3.4122	2.6143
15	3.6008	3.4514	.1303	.1357	.1845	3.1657	2.5667
16	3.4186	3.3771	.1479	.1593	.1524	3.022	2.5789
17	1.3291	1.1919	.1486	.1151	.1486	1.1355	.8551
18	.1547	.1616	.1364	.0854	.1311	.1685	.1502
19	.1524	.1707	.1509	.1349	.1029	.1578	.1578
20	.1205	.1615	.1547	.1448	.1463	.1501	.1555
21	.1471	.1493	.1455	.1371	.1494	.1448	.1585
22	.1547	.1029	.1448	.0648	.0907	.1357	.1631
23	.1501	2.6197	2.7682	3.1375	.0876	.0663	.1585
24	.1143	1.4388	2.6665	2.8555	1.3435	.1402	.1509
Max	4.2093	4.7134	3.8161	3.5814	3.685	4.3732	3.4468
Min	.0876	.1029	.0663	.0648	.0876	.0602	.0868
Avg	1.4065	1.5999	1.2873	1.2121	.9023	1.3590	1.0756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 203 / KONEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1591	.9846	.0406	.0377		1.0402	1.0669
2	1.174	.9717	.0282	.0373		1.1584	1.2041
3	1.2191	.9587	.0267	.0362		1.0669	1.2041
4	1.2492	.9602	.0267	.0362	.0358	1.1683	1.1591
5	1.2651	1.0014	.0274	.0362	.0366	1.1797	1.1145
6	1.2041	1.0574	.0514	.0362	.0362	1.2742	1.1145
7	1.1888	1.2929	.0532	.0543	.0362	1.3203	1.358
8	1.3032	1.3226	.0503	.0497	.0324	1.3937	1.5813
9	.0328	.0332	1.669	1.8747	2.0241	.0343	.0709
10	.0324	.0492	2.3061	2.1445	2.3061	.0168	.0617
11	.2294	.0503	2.3061	2.1285	2.3102	.0164	.0693
12	.0168	.0457	2.2542	2.0805	2.0309	.0332	.1006
13	.0316	.0474	2.037	1.9052	1.9136	.0206	.0983
14	.0173	.0492	1.9136	1.821	1.8442	.009	.0876
15	.0351	.0457	1.9433	2.0178	1.3413	.0131	.013
16	.0526	.0633	1.8056	1.8027	.9976	.0158	.012
17	.0701	.0492	.0633	.0316	.0343	.016	.012
18	.0351	.0648	.0112	.0339	.0339	.0171	.0274
19	.0316	.0503	.0152	.0358	.0328	.0181	.0324
20	.0324	.0509	.0158	.0362	.0312	.0362	.0351
21	.0332	.052	.0351	.0347	.0339	.0347	.0343
22	.032	.0457	.0537	.0347	.0351	.0351	.0347
23	.6716	.0316	.0358	.032	1.0269	1.2963	1.2342
24	1.1443	1.001	.0297	.0351	.0332	1.0425	1.2342
Max	1.3032	1.3226	2.3061	2.1445	2.3102	1.3937	1.5813
Min	.0168	.0316	.0112	.0316	.0312	.009	.012
Avg	.5109	.4283	.7000	.6822	.7717	.5107	.5400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 204 / Shahapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0133	.0143			
2			.0141	.0143			
3			.0149	.0143			
4			.0145	.0141	.0137		
5			.0147	.0141	.0137		
6			.0152	.0141	.0137		
7			.0154	.0145	.0137		
8			.0152	.0137	.0137		
9	.0137	.0137				.0149	.0149
10	.0149	.0141					.0145
11	.0141	.0139				.0149	.0873
12	.0143	.0139				.0153	.055
13	.0137	.0133				.0126	.0122
14	.013	.0141				.0147	.0135
15	.0128	.0139				.0137	.0152
16	.0131	.0128				.0375	.0135
23		.0133	.0151	.0137			
24			.0131		.0137		
Max	.0149	.0141	.0154	.0145	.0137	.0375	.0873
Min	.0128	.0128	.0131	.0137	.0137	.0126	.0122
Avg	.0137	.0137	.0146	.0141	.0137	.0177	.0283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 205 / MASUR VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.6398	.5395	.7255	.341	.5125	.6242
2	.5117	.6211	.5292	.6718	.3292	.4942	.6063
3	.5022	.6138	.5205	.6661	.3208	.4877	.5986
4	.4934	.6173	.5171	.6649	.314	.4847	.5925
5	.6245	.6786	.5418	.7316	.631	.5536	.6592
6	.8264	.9042	.7735	.9053	.7846	.7366	.8433
7	1.1374	1.1188	1.1671	1.193	1.0707	1.1096	1.1762
8	1.1961	1.2189	1.2052	1.2543	1.1489	1.1835	1.2315
9	1.0688	1.1507	1.105	1.1294	1.1534	1.1153	1.1381
10	.9983	1.0101	1.041	.9979	.929	1.0547	.9195
11	.8921	.8627	.8615	.8059	.892	.8695	.8661
12	.8886	.9183	.9484	.9366	.9404	.9057	.9591
13	.8993	.868	.9039	.9449	.9412	.8509	.9949
14	.8737	.8471	.9572	.9084	.9735	.8071	.77
15	.8814	.8631	.9073	.8627	1.017	.8413	.8261
16	.9332	.8817	.8955	.8661	.9366	.9019	.7906
17	.9504	.916	.9903	.8764	.961	.9533	.8395
18	1.145	1.126	1.0836	1.0703	.9854	1.0364	.9194
19	1.4464	1.4243	1.4644	1.4883	1.4286	1.3801	1.2026
20	1.5966	1.5051	1.5005	1.4834	1.4144	1.3908	1.3291
21	1.3828	1.3935	1.3017	1.3162	1.2829	1.2544	1.004
22	1.2655	1.2353	1.1942	1.2201	1.1633	1.1804	1.1549
23	1.0368	1.0265	1.0139	.9895	.9419	.937	.9282
24	.7384	.7832	.7472	.7674	.6367	.6813	.668
Max	1.5966	1.5051	1.5005	1.4883	1.4286	1.3908	1.3291
Min	.4934	.6138	.5171	.6649	.314	.4847	.5925
Avg	.9503	.9677	.9462	.9782	.8974	.9051	.9017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 206 / Kalgaon Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.2103	.1581	.2641		.16	.2267
2	.1524	.208	.1638	.2641		.1543	.2401
3	.1505	.2058	.1638	.2641		.16	.2401
4	.1543	.1852	.1581	.2561	.2058	.1581	.2401
5	.216	.1875	.1734	.2561	.2427	.216	.2481
6	.1677	.2774	.3018	.2926	.2835	.2881	.2835
7	.3544	.3898	.439	.4108	.3898	.3521	.4024
8	.3467	.3688	.3582	.3429	.3563	.3841	.362
9	.2743	.3277	.3086	.3125	.3048	.3201	.2743
10	.3052	.2743	.3052	.2915	.3201	.253	.253
11		.2561	.2984	.25	.2774		.2195
12	.2622	.2846	.3125	.2743	.2846	.2812	.1787
13	.2408	.3688	.2713	.2606	.3391	.2591	.2724
14	.2743	.2778	.2675	.2709	.2347	.2503	.2606
15	.2591	.25	.2846	.2713	.2641	.2984	.2347
16	.2241	.2667	.2984	.2561	.2214	.2622	.2591
17	.2743	.2641	.3052	.2187	.2134	.144	.2469
18	.2743	.4207	.3201	.3048	.2439	.3048	.2317
19	.4801	.5201	.4557	.4508	.4207	.4458	.4854
20	.5316	.5144	.5014	.5014	.4161	.5258	.4481
21	.4656	.5014	.4344	.4706	.4252	.4344	.4298
22	.394	.4298	.4252	.362	.3982	.4252	.3814
23	.2683	.3121	.2865	.2401	.2743	.2683	.2683
24	.2241	.2241	.2591	.2641	.2241	.1943	.2267
Max	.5316	.5201	.5014	.5014	.4252	.5258	.4854
Min	.1505	.1852	.1581	.2187	.2058	.144	.1787
Avg	.2804	.3136	.3021	.3063	.3019	.2843	.2881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 207 / Satyam Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.1143	.1334	.0754		.0191	.0189
2	.0183	.0943	.1334	.0754		.0189	.0189
3	.0187	.0943	.1334	.0189		.0187	.0189
4	.0185	.0943	.1334	.0191		.0185	.0189
5	.0189	.1143	.1334	.0191	.0373	.0183	.0189
6	.0187	.1143	.1334	.0191	.037	.0183	.0189
7	.0183	.1132	.1334	.0189	.037	.0183	.0179
8	.0183	.1132	.1334	.0181	.0366	.0183	.0183
9	.0183	.1143	.1334	.0183	.0366	.0183	.0185
10	.0183	.0943	.1524	.0185	.0366	.0185	.074
11	.0183	.0943	.1334	.0381	.0187	.037	.0183
12	.0185	.132	.1334	.0362	.0183	.0366	.0183
13	.0185	.1132	.1334	.0181	.0181	.0181	.0532
14	.0185	.1132	.1334	.0185	.037	.0554	.0181
15	.0181	.1132	.1143	.0366	.0183	.0362	.0187
16	.0189	.1132	.1143	.0183	.037	.037	.0187
17	.0943	.132	.132	.0185	.0187	.0351	.037
18	.0943	.132	.1254	.0366	.0179	.0179	.0183
19	.1143	.1334	.0953	.0381	.0189	.0189	.0171
20	.1143	.1334	.0953	.0191	.0189	.0377	.0189
21	.1143	.1524	.0953	.0381	.0189	.0381	.0191
22	.1334	.1524	.0953	.0377	.0189	.0189	.0189
23	.1334	.1334	.0943	.0377	.0191	.0377	.0377
24	.0183	.1143	.1334	.0181	.0381	.0191	.0189
Max	.1334	.1524	.1524	.0754	.0381	.0554	.074
Min	.0181	.0943	.0943	.0181	.0179	.0179	.0171
Avg	.0464	.1176	.1242	.0296	.0269	.0262	.0239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254006 / MASUR

Feeder No / Name : 208 / kharade ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0754	1.2963	1.2651		.0526	.0533
2	.0358	.0892	1.3435	1.2651		.0526	.0533
3	.0366	.0823	1.4403	1.2334		.0549	.0549
4	.0381	.0526	1.4022	1.2334	1.2803	.0541	.0549
5	.0381	.0469	1.4506	1.2163	1.2654	.0518	.0549
6	.0366	.0754	1.5497	1.2163	1.3123	.0495	.0564
7	.0366	.0812	1.6518	1.4918	1.4998	.0511	.061
8	.0427	.072	1.8023	1.5364	1.5813	.0488	.0293
9	2.5149	2.5484	.0587	.0472	.0789	2.0885	1.7604
10	2.7808	2.6825	.061	.0686	.0594	2.0553	1.6762
11	2.9843	2.6825	.0594	.0663	.0533	1.9559	1.7238
12	2.8464	2.42	.0594	.0709	.0495	2.0645	1.6244
13	2.6452	2.3868	.0914	.0892	.0823	2.0348	1.576
14	2.5434	2.1628	.08	.0945	.1067	.6371	1.4918
15	2.3205	2.2211	.0777	.0686	.0884	1.7238	1.5424
16	2.332	1.9372	.0457	.0914	.0594	1.576	1.4548
17	.061	.0488	.08	.0709	.0892	.0442	.0518
18	.072	.0503	.0663	.0686	.08	.0465	.0312
19	.0732	.0541	.0594	.0846	.0789	.0572	.0412
20	.0812	.0556	.08	.0823	.0533	.0823	.0381
21	.08	.0533	.0754	.0823	.0572	.0541	.0419
22	.08	.0549	.0549	.0823	.0617	.0594	.0495
23	.0663	1.4232	1.4251	1.5043	.0579	.0549	.0434
24	.0351	.0617	1.3443	1.3283		.0518	.0472
Max	2.9843	2.6825	1.8023	1.5364	1.5813	2.0885	1.7604
Min	.0351	.0469	.0457	.0472	.0495	.0442	.0293
Avg	.9090	.8924	.6523	.5983	.3998	.6251	.5672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 204 / BAMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4251	1.3441	1.1984		
2			1.4089	1.3117	1.1984		
3			1.4089	1.3117	1.1984		
4			1.4089	1.3117	1.1984		
5			1.4089	1.3117	1.1984		
6			1.4251	1.3117	1.1984		
7			1.5546	1.4575	1.3441		
8			1.6032	1.5384			
9	1.7814	.9717				1.491	1.5061
10	2.2996	2.0729				1.9109	1.3117
11						2.1052	1.8461
12	2.1125	2.2348				1.9757	1.9334
13	2.364	2.2672				1.8785	1.9757
14	2.1293	2.1862				1.9757	1.8515
15	2.0957					1.9757	1.704
16	2.0287	1.9433				1.6842	1.8299
23		1.1822	1.2955	1.1984			
24			1.4899	1.3117	1.1984		
Max	2.364	2.2672	1.6032	1.5384	1.3441	2.1052	1.9757
Min	1.7814	.9717	1.2955	1.1984	1.1984	1.491	1.3117
Avg	2.1159	1.8369	1.4429	1.3409	1.2166	1.8746	1.7448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254023 / TARALE

Feeder No / Name : 205 / TARALE -AG-

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4089	1.4091				1.4737	1.4255
2	1.4091	1.3763				1.4737	1.3927
3	1.3765					1.4575	1.3279
4	1.3765					1.4575	1.3279
5	1.3441	1.2944				1.4413	1.3279
6	1.3279	1.3435				1.4413	1.3279
7	1.3279	1.491				1.4413	1.5546
8	1.5546	1.6356				1.8138	1.6842
9			1.7328	1.7976	2.0081		
10			2.1376	2.0729	2.2996		
11			2.1376	2.0243	2.3482		
12			2.2672	2.0891	2.3908		
13			2.2348	1.9919	2.3061		
14			2.1376	2.0891	2.323		
15			1.9433	2.0567	2.1534		
16			1.8461	1.9595	2.1365		
23	1.4255				1.3279	1.4413	1.2793
24	1.4419	1.4419				1.5238	1.4089
Max	1.5546	1.6356	2.2672	2.0891	2.3908	1.8138	1.6842
Min	1.3279	1.2944	1.7328	1.7976	1.3279	1.4413	1.2793
Avg	1.3993	1.4274	2.0546	2.0101	2.1437	1.4965	1.4057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 201 / 11kv CHORE VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.7392	.8589	1.0608	.8688	.7964	.7468
2	.6584	.6878	.7316	1.0029	.8954	.788	.7095
3	.7545	.6805	.7316	.9774	.9979	.7682	.7095
4	.8048	.7442	.9511	1.1462	1.1088	.7682	.8589
5	1.0829	1.0059	1.0608	1.4266	1.2437	.8688	.961
6	1.1949	1.1222	1.2437	1.848	1.4563	1.2567	1.1576
7	1.3756	1.8099	1.4998	1.97	1.7013	1.7741	1.3394
8	1.5927	1.6289	1.7364	1.7737	1.6095	1.6263	1.6057
9	1.7013	1.382	1.5364	1.6476	1.5565	1.4842	1.307
10	1.5592	1.2269	1.4937	1.6461	1.5402	1.4842	1.134
11	1.5424	1.4373	1.2003	1.5565	1.3672	1.3672	1.1706
12	1.2536	1.2136	1.1145	1.4998	1.3672		1.0974
13	1.1584	.8764	1.0288	1.2437	1.0985	1.0288	.8326
14	1.2757	1.0631	1.1145	1.2308	1.0867	1.0974	.8048
15	1.2894	1.2269	1.2003	1.3535	1.2483	1.134	.8131
16	1.3611	1.2757	1.3717	1.5203	.8131	1.1946	.961
17	1.267	1.4883	.1372	1.3611	1.2136	1.3169	.9877
18	1.5203	1.4175	1.3717	1.5729	1.4022	1.39	1.2197
19	2.1807	2.1262	1.8861	2.1719	2.0328	2.0271	1.7924
20	2.1357	2.4646	1.8861	2.1437	2.1437	2.2634	1.9387
21	1.7551	1.9616	1.7147	1.8461	1.8484	1.8671	1.7002
22	1.5565	1.7193	1.3717	1.6095	1.4784	1.6057	1.4045
23	1.1462	1.0829	1.0974	1.1706	1.0349	1.0082	.8871
24	.6878	.8131	.9335	1.0288	.9511	.8589	.7842
Max	2.1807	2.4646	1.8861	2.1719	2.1437	2.2634	1.9387
Min	.6584	.6805	.1372	.9774	.8131	.7682	.7095
Avg	1.3130	1.2998	1.2197	1.4920	1.3360	1.2945	1.1218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 202 / 11kv VADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2811	1.1561	.0347		.0362	1.5223	1.3603
2	1.3108	1.1702	.0328		.0362	1.4899	1.3565
3	1.3763	1.0936	.0366		.0362	1.4232	1.3279
4	1.3927	1.0802	.0351		.037	1.406	1.3435
5	1.4419	1.0562	.0347		.0358	1.4251	1.4419
6	1.4232	1.0242	.0328		.0366	1.3916	1.4746
7	1.6712	1.4685	.0328		.0358	1.6975	1.6057
8	1.7368	1.5074	.0328		.0354	1.7924	1.6644
9	.0373	.0328	1.9997	2.0557	1.9925	.0305	.0347
10	.0362	.0324	2.4291	2.1872	2.3403	.0312	.037
11	.0354	.0324	2.6063	2.0934	2.42	.0328	.0354
12	.0655	.0316	2.572	2.2024	2.3967	.0328	.037
13	.032	.0328	2.4006	2.2024	2.332	.0316	.0366
14	.0324	.0328	2.3663	2.2283	2.2085	.0343	.0362
15	.0316	.0324	2.2634	2.1445	2.2348	.0328	.037
16	.0316	.0351	2.2291	2.2024	2.1376	.0343	.0366
17	.0316	.0354	.0686	.0366	.0312	.0351	.037
18	.0312	.0373	.0686	.0362	.0312	.0354	.0366
19	.0316	.0366	.0686	.0366	.0312	.0351	.037
20	.0312	.0373	.0686	.0362	.0312	.0354	.037
21	.0312	.037		.037	.0316	.0377	.0366
22	.0316	.0373		.0362	.0312	.0354	.0366
23	1.2811	.0328		.0366	1.587	1.3927	1.3279
24	1.3763	1.2631	.0354		.0366	1.5181	1.4091
Max	1.7368	1.5074	2.6063	2.2283	2.42	1.7924	1.6644
Min	.0312	.0316	.0328	.0362	.0312	.0305	.0347
Avg	.6159	.4723	.9261	1.1714	.8401	.6472	.6176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254055 / 33/11 Pal

Feeder No / Name : 203 / 11kv SHIRGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0934	1.6057	1.7497	1.5623	.112	.1097
2	.1097	.0934	1.4998	1.7711	1.4998	.112	.1086
3			1.5402	1.8244	1.5497		
4			1.531	1.8564	1.5364		
5			1.6712	1.8976	1.587		
6			1.6248	1.8976	1.6385		
7			1.906	1.8976	1.8343		
8			2.13	1.9997	1.8343		
9	2.4615	1.9372				2.3685	2.7808
10	2.7526	2.0873				2.753	2.8147
11	2.8182	2.0317				2.878	2.5232
12	2.5934	2.0934				2.6216	2.5606
13	2.4966	2.7206				2.8487	2.5301
14	2.372	2.5263				2.7206	2.5606
15	2.3967	2.4059	.0686	.0732	.0914	2.6235	2.4352
16	2.332	2.4577	.0686	.0724	.0914	2.7435	2.4006
17	.0943	.112	.0686	.0732	.0377	.1086	.0373
18	.0943	.112	.0686	.0739	.0362	.0709	.0373
19	.0754	.112	.0686	.1086	.112	.1086	.0366
20	.0934	.112	.1029	.112	.112	.112	.037
21	.0943	.112	.1029	.1097	.112	.1097	.0732
22	.0943	.1052	.1029	.112	.112	.1132	.0724
23	.0934	1.5181	1.8861	1.7711	.1109	.1052	.0739
24	.1097	.0934	1.6804	.192	1.6129	.112	.112
Max	2.8182	2.7206	2.13	1.9997	1.8343	2.878	2.8147
Min	.0754	.0934	.0686	.0724	.0362	.0709	.0366
Avg	1.1772	1.1513	.9848	.9773	.8595	1.2568	1.1835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 201 / Charegaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8817	.8848	.0754	.0754	.0747	.6226	.6802
2	.8478	.8684	.0754	.0754	.0747	.6062	.6802
3	.8573	.8421	.0754	.0754	.056	.6062	.6802
4	.7716	.8356	.0754	.0754	.056	.6226	.6401
5	.7716	.8097	.0943	.0754	.056	.6299	.7042
6	.763	.8097	.1132	.0943	.056	.6554	.7682
7	.9835	.8907	.132	.1132	.0747	.8288	.8539
8	1.0059	1.0322	.1132	.132	.112	.9831	.9488
9	.1307	.0377		1.4089	1.4899	.112	.1494
10	.1307	.0377	1.6129	1.5415	1.5565	.1132	.1132
11	.1132	.0377	1.6244	1.5402	1.5384	.1132	.1132
12	.1132	.0943	1.5581	1.4251	1.4746	.132	.132
13	.1132	.0943	1.4255	1.3279	1.3765	.0924	.0754
14	.112		1.2944	1.3108	1.1498	.0943	.0566
15	.112		1.278	1.2631	.9717	.0943	.0566
16	.112	.1132	1.2163	1.1336	.9717	.0943	
17	.112	.132	.1307	.0943	.1132	.0943	
18	.1132	.1307	.112	.132	.1132	.1509	
19	.112	.1307	.1494	.1132	.1132	.1307	.132
20	.112	.1307	.1307	.1132	.1132	.1494	.0943
21	.112	.132	.1307	.0754	.1132	.1307	.0943
22	.0943	.132	.1132	.0754	.132	.1132	.0943
23	.8907	.1132	.0754	.0754	.6154	.6962	.9503
24	.8987	.8802	1.6244	.0754	.0754	.6154	.7209
Max	1.0059	1.0322	1.6244	1.5415	1.5565	.9831	.9503
Min	.0943	.0377	.0754	.0754	.056	.0924	.0566
Avg	.4277	.4168	.5752	.5176	.5199	.3534	.4161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 202 / charegaon vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2774	.3506	.3511	.298	.3258	.362	.3511
2	.2774	.3086	.3326	.2915	.2957	.3258	.3547
3	.2774	.2835	.3142	.2915	.2896	.2896	.3326
4	.2774	.2835	.3142	.2915	.3258	.2896	.3511
5	.3467	.3681	.3881	.3429	.362	.3544	.4066
6	.4458	.443	.4755	.4681	.5068	.4733	.543
7	.7716	.5895	.7421	.7282	.7522	.6733	.6626
8	.78	.7888	.7602	.5548	.8326	.823	.7265
9	.6274	.6379		.4681	.7011	.5493	.6036
10	.4917		.5853	.4458	.5316	.543	.6036
11	.4207	.0543	.4409	.4161	.4961	.5853	.4572
12	.4252	.0566	.39	.4458	.362	.462	.4115
13	.3898	.5611	.4191	.4854	.362	.3696	.4161
14	.3898	.5544	.4359	.3772	.5194	.3734	.4161
15	.4119	.4854	.373	.4115	.4961	.4435	.4161
16	.4344	.4805	.4359	.4458	.5373	.4805	
17	.5068	.5729	.4752	.5144	.5552	.4805	
18	.6516	.8238	.5533	.6413	.6805	.5914	
19	.8779	.9036	.7682	.8322	.8238	.7619	.8764
20	.8507	.8859	.8686	.905	.8688	.8682	.9602
21	.8238	.724	.8131	.8048	.7964	.7796	.8322
22	.6241	.6401	.6653	.6379	.6024	.6447	.6935
23	.4031	.4755	.4031	.4656	.4298	.3982	.4458
24	.2947	.3681	.3696	.3086	.362	.3801	.3696
Max	.8779	.9036	.8686	.905	.8688	.8682	.9602
Min	.2774	.0543	.3142	.2915	.2896	.2896	.3326
Avg	.5032	.5061	.5076	.4947	.5340	.5126	.5348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254065 / 33/11 kv urul

Feeder No / Name : 203 / Mazgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0758	.0754	1.7356	2.3061	2.412	.0754	.0758
2	.0758	.0758	1.5615	2.2317	2.2702	.0758	.0758
3	.0758	.0758	1.4853	2.1841	2.1871	.0754	.0758
4	.0758	.0754	1.4952	2.1808	2.1612	.0758	.0758
5	.0758	.0758	1.5261	2.1241	2.0938	.0758	.0758
6	.0758	.0758	1.5489	2.1622	2.1819	.0758	.0758
7	.0758	.0758	1.8313	2.6757	2.6474	.0754	.0758
8	.0754	.083	2.1001	2.7014	2.772	.083	.0758
9	4.3545	4.1896	1.0136	.6016	.5178	3.8971	4.185
10	4.9332	4.3896	.0606	.0682	.0682	4.2372	4.611
11	4.8935	4.6472	.0602	.0682	.0678	4.2247	4.4616
12	4.6822	4.3614	.0678	.0682	.0682	4.0291	4.2067
13	4.5029	3.943	.0678	.0682	.0529	4.0367	4.0067
14	4.3324	3.5714	.0754	.0682	.0758	3.7719	3.7904
15	4.0962	3.1232	.0754	.0682	.0758	3.6717	3.5285
16	3.9095	3.0365	.0941	.0682	.0682	3.5246	
17	.807	.6474	.0834	.0758	.0758	.7845	
18	.0678	.0758	.0834	.0758	.0758	.0758	
19	.0754	.1017	.1023	.0901	.0834	.0758	.0834
20	.083	.1017	.1023	.0834	.1017	.0754	.0758
21	.0758	.0758	.0758	.0754	.1023	.0754	.0758
22	.0758	.0758	.0758	.0758	.0834	.0758	.0758
23	.0754	2.316	2.4882	2.4844	.0834	.0758	.0758
24	.0758	1.2646	2.4455	2.4752	1.1584	.0758	.0682
Max	4.9332	4.6472	2.4882	2.7014	2.772	4.2372	4.611
Min	.0678	.0754	.0602	.0682	.0529	.0754	.0682
Avg	1.5686	1.5222	.8440	1.0450	.8952	1.3883	1.4215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 201 / Shahapur Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2477	.2667	.2096	.2477	.2477	.2477
2	.2286	.2286	.2667	.1905	.1905	.2286	.2286
3	.2286	.2286	.2286	.1905	.1905	.2286	.2286
4	.2286	.2477	.2667	.1905	.2667	.2286	.2286
5	.1334	.3429	.3429	.2286	.3239	.2858	.2667
6	.4382	.4763	.4191	.2096	.4191	.4191	.3921
7	.5906	.6036	.4527	.6224	.4527	.547	.5359
8	.5175	.4668	.4938	.4805	.4854	.499	.4755
9	.439	.4024	.3841	.3841	.3841	.4024	.3841
10	.3696	.3511	.3696	.3326	.3292	.3511	.3881
11	.2957	.2957	.3142	.2402	.2896	.3511	.2957
12	.2772	.2587	.2772	.2587	.2865	.2772	.2587
13	.2587	.2772	.2587	.2587	.2743	.2587	.2096
14	.2402	.2772	.3012	.2402	.2587	.2686	.2286
15	.2587	.3258	.3224	.2587	.2743	.2896	.2587
16	.2587	.3439	.3258	.3077	.3439	.2715	.3511
17	.3077	.3258	.3258	.3881	.373	.3258	.2587
18	.3258	.3841	.4207		.3982	.362	.462
19	.6584	.6283	.6219	.5175	.5853	.567	.6348
20	.6653	.7023	.7207	.5544	.7023	.6908	.6161
21	.5975	.5975	.6348	.6161	.5658	.5788	.5228
22	.3961	.5144	.5228	.4854	.5144	.4715	
23	.3429	.3429	.3429	.3206	.3239	.3429	.3429
24	.2858	.2858	.3048	.2858	.2858	.2858	.2667
Max	.6653	.7023	.7207	.6224	.7023	.6908	.6348
Min	.1334	.2286	.2286	.1905	.1905	.2286	.2096
Avg	.3579	.3815	.3827	.3379	.3652	.3658	.3514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 202 / Shahapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8471	.9374	.0762	.0381	.0572	.9031	.7628
2	.7754	.9014	.0762	.0381	.0572	.8471	.7529
3	.7674	.8179	.0762	.0381	.0572	.7977	.724
4	.7727	.8436	.0572	.0381	.0572	.7727	.6144
5	.743	.8592	.0572	.0381	.0572	.7385	.724
6	.8642	.9172	.0762	.0381	.0572	.8471	.8109
7	1.034	1.0494	.0762	.0572	.0762	.9957	.8768
8	1.0494	1.1405	.0953	.0762	.0762	1.0084	.9145
9	.0572	.0572	1.4232	1.4074	1.5623	.0762	.0762
10		.0381	1.668	1.6194	1.6604	.1334	.0572
11	.0762	.0572	1.7204	1.6446	1.7604	.1143	.0762
12	.1143	.0953	1.6876	1.5971	1.7284	.0953	.0762
13	.1143	.1143	1.531	1.5339	1.5466	.1524	.0572
14	.1334	.1143	1.4883	1.4217	1.4706	.1524	.0762
15	.1334	.0953	1.358	1.358	1.3426	.1524	.0762
16		.0953	1.3272	1.2483	1.3077	.1524	.0953
17	.0572	.0953	.0762	.0572	.1143	.1524	.0762
18	.0953	.1143	.0953		.1143	.1334	.0762
19	.1143	.1143	.0953		.1143	.1524	.0953
20	.1143	.1143	.0953	.0762	.1143	.1715	.1143
21	.1143	.1143	.0572	.0762	.0953	.1524	.1143
22	.1143	.1143	.0572	.0572	.0762	.1334	.0953
23	1.0155	.0953	.0572	.0572	1.012	.8619	.7727
24	1.012	1.012	.0953	.0572	.0572	.9332	.8215
Max	1.0494	1.1405	1.7204	1.6446	1.7604	1.0084	.9145
Min	.0572	.0381	.0572	.0381	.0572	.0762	.0572
Avg	.4600	.4128	.5593	.5715	.6072	.4429	.3724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

KARAD DIVISION[512]

UMBRAJ S/DN.[108]

BU 5932

Substation No/ Name :- 254066 / Shahapur

Feeder No / Name : 203 / Riswad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.7682	.9488	.8539	.0762	.0953
2	.0572	.0572	.7274	.9172	.8322	.0762	.0762
3	.0572	.0572	.7274	.8749	.8905	.0762	.0762
4	.0572	.0572	.7186	.8436	.9172	.0762	.0762
5	.0572	.0762	.759	.9172	1.1498	.0762	.0762
6	.0572	.0762	.8097	.9602	1.2125	.0762	.0762
7	.0762	.0572	1.3763	1.4083	1.3927	.0953	.0953
8	.0762	.0762	1.3916	1.5935	1.5893	.0953	.0762
9	1.5708	.0762	.0762	.0953	.0572	1.5223	1.587
10	1.7532	.0572	.0762	.0953	.0762	1.6876	1.7236
11	1.3599	1.587	.0762	.0572	.0762	1.8233	1.6288
12	1.6032	1.5546	.0762	.0762	.0762	1.9227	1.4373
13	1.6032	1.4198	.0953	.0572	.0762	1.9951	1.0997
14	1.6194	1.3889	.0953	.0762	.0762	1.7072	1.3889
15	1.6194	1.358	.0953	.0762	.0762	1.7859	1.4529
16	.9877	1.3108	.0953	.0953	.0762	1.4403	1.5023
17	.0572	.0953	.0953	.0953	.0762	.0762	.0572
18	.0953	.0953	.0953		.0953	.0953	.0762
19	.0762	.0953	.0762	.0762	.0953	.0953	.0953
20	.0762	.0762	.0762	.0762	.0762	.0953	.0953
21	.0762	.0953	.0762	.0762	.0762	.0953	.0762
22	.0572	.0762	.0762	.0762	.0762	.0953	.0762
23	.0572	.7935	.9762	.9442	.0572	.0953	.0762
24	.0572	.0572	.7773	.8907	.8907	.0762	.0953
Max	1.7532	1.587	1.3916	1.5935	1.5893	1.9951	1.7236
Min	.0572	.0572	.0762	.0572	.0572	.0762	.0572
Avg	.5485	.4438	.4255	.4925	.453	.6357	.5465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 301 / WING

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.2614	.2587	.2241		.2149	.2587
2	.1448	.2241	.2241	.2241		.2149	.2218
3	.1448	.2241	.2218	.2241		.2149	.2218
4	.1448	.2614	.2218	.2614		.1753	.2218
5	.1448	.2587	.2587	.2614		.2103	.2587
6	.2195	.2957	.2587	.2987		.2103	.2587
7	.4024	.3734	.4481	.4108	.3696	.3856	.3326
8	.4066	.4108	.4435	.4481	.5014	.3696	.4805
9	.5175	.5228	.5228	.4854	.6283	.4854	.4435
10	.6348	.6283	.6722	.5228	.695	.5601	.5914
11	.6348	.6283	.6722	.6283	.7316	.5228	.5544
12	.6348	.6283	.6722	.6283	.7316	.5975	.5544
13	.6348	.6348	.6348	.5914	.6584	.5975	.5914
14	.6348	.5975	.5975	.5544	.6653	.5914	.5544
15	.6283	.6348	.6348	.5914	.6283	.4805	.5544
16	.6722	.6348		.5601	.6219	.5175	.5601
17	.6722	.6653	.6722	.6348	.6653	.5601	.5601
18	.6722	.6722	.5601	.5975	.5914	.5228	.5228
19	.6348	.5601	.4481	.5228	.5068	.5175	.5228
20	.5601	.5228	.3734	.4481	.4706	.4435	.4854
21	.4481	.4108	.3361	.3696	.4706	.4435	.4854
22	.4108	.2987		.2957	.362	.3734	.4108
23	.2987	.2614	.2987	.2241	.2058	.2614	.2241
24	.1402	.2587	.2614	.2241		.2103	.2587
Max	.6722	.6722	.6722	.6348	.7316	.5975	.5914
Min	.1402	.2241	.2218	.2241	.2058	.1753	.2218
Avg	.4408	.4529	.4405	.4263	.5591	.4034	.4220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 302 / SHINDEWADI

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.1494	.1867	.1867		.1791	.1867
2	.1448	.1494	.1867	.1867		.1791	.1494
3	.1448	.112	.1867	.1867		.1791	.1494
4	.1448	.112	.1848	.1867		.2103	.1478
5	.1448	.1478	.2218	.1867		.2103	.1867
6	.2195	.1848	.2241	.1867		.2103	.1848
7	.2195	.1867	.2218	.1867	.1848	.2103	.1867
8	.2218	.1867	.1848	.1867	.2149		.1848
9	.2218	.1867	.2241	.1867	.2218	.2241	.1848
10	.1494	.2218	.2241	.1867	.2561	.2241	.1848
11	.1494	.1867	.2241	.1478	.2195	.1867	.1478
12	.1867	.2218	.1867	.1848	.2195	.1867	.1848
13	.1494	.2218	.1867	.1478	.2195	.1867	.1848
14	.1867	.2218	.1867	.1848	.2218	.1867	.1478
15	.1848	.1867	.1867	.1109	.2218	.1867	.1848
16	.1867	.2241	.1494	.1494	.1829	.1848	.1867
17	.2241	.2241	.1494	.2614	.2218	.1867	.1867
18	.2614	.2241	.2241	.2614	.1848	.1848	.2614
19	.2987	.2587	.2987	.2987	.2534	.2241	.2241
20	.2987	.2614	4.1076	.2987	.2896	.2614	.2614
21	.2241	.2614	4.3317	.2218	.2534	.2587	.2614
22	.1867	.2241	.2614	.1848	.2172	.1848	.2614
23	.1867	.1867	.2241	.1494	.1715	.1867	.1494
24	.1402	.1478	.1867	.1867		.2218	.1867
Max	.2987	.2614	4.3317	.2987	.2896	.2614	.2614
Min	.1402	.112	.1494	.1109	.1715	.1791	.1478
Avg	.1925	.1954	.5396	.1940	.2208	.2023	.1906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 303 / INDUSTRIAL

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7221	4.4063	3.9548	4.481		1.6118	1.848
2	2.8959	4.1076	4.0329	4.4437		1.6118	1.885
3	3.0407	4.1823	4.0703	4.5184		1.5402	1.922
4	3.2217	3.7715	4.1076	4.4063		1.5775	1.9589
5	3.2579	3.8439	4.0287	4.481		1.5775	1.848
6	3.6946	4.1027	4.0329	4.4063		1.5775	1.7924
7	3.3653	3.9956	3.8836	4.1076	1.6263	1.7528	1.848
8	3.4743	4.145	3.9956	4.2943	1.6118	1.7372	1.7741
9	4.0657	4.5557	4.3317	2.838	1.885	2.2405	1.9959
10	3.8836	5.0038	5.1532	2.8006	1.9753	2.2779	2.0698
11	2.0165	5.1532	4.9291	2.9199	1.8656	2.4646	1.8111
12	4.5931	4.8544	4.481	2.6612	2.0119	2.3525	1.848
13	4.4063	4.481	4.4437	2.7721	1.9022	2.2405	1.8111
14	4.9291	2.95	4.8544	2.7721	2.0698	2.4646	2.2546
15	4.9528	3.3608	4.9291	2.846	2.1068	2.3655	2.2916
16	4.9291	2.6139	4.2943	2.9874	2.0851	2.4764	2.0538
17	4.145	3.8462	4.4063	2.9127	2.1807	1.9959	1.8298
18	4.4063	4.257	4.5184	2.1285	1.8111	2.0911	1.9418
19	3.8836	4.3317	4.1076	2.1285	1.7375	1.9418	1.7551
20	4.1076	3.9956	4.1076	1.9418	1.9909	1.7372	1.9044
21	4.5557	3.9582	4.3317	2.1437	1.8099	1.8671	2.0538
22	4.2943	3.807	4.4063	1.848	1.7375	1.8298	1.8298
23	4.0329	4.0604	4.7051	1.9418	1.5432	1.9418	1.7551
24	2.8352	4.4723	3.9548	4.5931		1.5775	1.885
Max	4.9528	5.1532	5.1532	4.5931	2.1807	2.4764	2.2916
Min	2.0165	2.6139	3.8836	1.848	1.5432	1.5402	1.7551
Avg	3.8212	4.0940	4.3359	3.2239	1.8794	1.9521	1.9153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 304 / TUBE

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7207	1.6583	1.4125	2.6939	1.6918	1.7741	3.3863
2	1.7261	1.6735	1.454	2.9538	2.5682	1.7741	3.2632
3	1.688	1.7108	1.5988	2.758	2.9111	1.6567	3.2369
4	1.7185	1.6964	1.598	2.7565	2.7664	1.64	3.9434
5	1.7261	1.6911	1.598	2.8471	2.1872	1.7101	3.5894
6	1.7238	1.7128	1.6361	2.7343	3.3658	1.7101	4.113
7	1.7086	1.7032	1.5752	2.601	3.1668	1.7756	3.5879
8	1.6922	1.7116	1.5703	2.4021	2.4661	2.3895	3.818
9	1.6389	1.6956	1.432	2.2855	1.8946	2.8952	3.8706
10	1.6812	1.6225	1.6194	2.4669	1.8519	3.4004	3.7597
11	1.6202	1.6278	1.8244	2.5114	1.826	3.994	3.6008
12	1.6431	1.5997	1.8175	2.5999	1.9266	3.7106	3.6747
13	1.6354	1.6431	1.9464	2.8806	1.8976	4.3743	3.8851
14	1.6431	1.6507	2.236	3.3741	1.8499	4.3873	4.2864
15	1.6149	1.3024	2.0446	3.5273	1.8347	3.8328	3.8771
16	1.6431	1.0745	1.5546	3.1977	1.8366	4.0326	4.9459
17	1.605	.8535	2.707	3.6054	1.8499	4.3923	4.2631
18	1.6431	1.2415	2.0668	3.3097	1.8576	4.4505	3.4324
19	1.6507	1.2231	2.7938	3.6824	1.8995	4.5344	4.4811
20	1.6804	1.2525	2.5324	3.4652	1.8404	4.2159	4.4864
21	1.6812	1.283	2.4539	3.1124	1.81	3.7174	4.2791
22	1.6583	1.2567	2.5355	3.0536	1.7795	4.5573	4.5069
23	1.7108	1.272	2.6276	2.4386	1.7375	4.2532	4.1511
24	1.6415	1.3634	2.2356	2.4074	1.2727	2.7694	3.5029
Max	1.7261	1.7128	2.7938	3.6824	3.3658	4.5573	4.9459
Min	1.605	.8535	1.4125	2.2855	1.2727	1.64	3.2369
Avg	1.6706	1.4800	1.9529	2.9027	2.0870	3.2478	3.9142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 402 / GODREJ

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3432	1.6244	1.5123	1.7364		.1612	1.6632
2	1.3575	1.5684	1.4563	1.4563		.1612	1.7187
3	1.4118	1.6804	1.5524	1.6804		.2686	1.6804
4	1.4661	1.5123	1.5684	1.5684		.3681	1.6244
5	1.6832	1.386	1.5684	1.4563		.5258	1.6078
6	1.262	1.2197	1.6244	1.5123	1.2197	.5784	1.6078
7	1.262	1.1203	1.3443	1.4563	.7762	.7362	1.4563
8	2.3285	2.2405	2.2965	2.2405	.5373	1.9959	2.2177
9	2.5503	2.2405	2.2965	2.1285	.3881	2.3525	1.9959
10	2.4646	2.4646	2.2965	2.5766	.439	2.3525	2.7721
11	2.5206	2.3285	2.4646	1.9404	.5487	2.5766	2.4949
12	1.9605	2.4086	1.9044	1.885	.3292	1.9959	1.8296
13	2.2405	2.2965	1.9044	2.4394	.439	2.2965	1.1643
14	2.1285	2.1285	2.2965	2.2731	.3881	2.0165	2.0513
15	2.0513	2.2405	1.9605	2.1622	.3326	1.9959	1.885
16	2.1845	2.0513	1.0642	1.1203	.2743	1.9204	1.885
17	1.7924	1.4563	1.1763	.8962	.3326		1.0642
18	1.0642	1.1088	1.1203	1.0082	.1663	1.1643	1.0082
19	1.1763	1.2752	1.0642	.8402	.1629	1.1763	1.0082
20	1.1203	1.1203	.8962	.8402	.1629	1.1643	1.0082
21	.8962	1.1763	1.0082	.7762	.1629	1.0534	1.0642
22	1.5684	1.4563	1.5684	1.4969	.1629	1.5524	1.4563
23	1.6804	1.5524	1.7364	1.7364	.1543	1.9044	1.4003
24	1.4198	1.4969	1.4969	1.5684		.1578	1.7364
Max	2.5503	2.4646	2.4646	2.5766	1.2197	2.5766	2.7721
Min	.8962	1.1088	.8962	.7762	.1543	.1578	1.0082
Avg	1.7055	1.7147	1.6324	1.6165	.3876	1.3250	1.6417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 403 / SUSSEN ASIA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3432	1.6244	1.4563	1.2883		.3224	1.3306
2	1.3575	1.5684	1.4003	1.3443		.3224	1.2752
3	1.3032	1.2323	1.4415	1.1763		.3224	1.2883
4	1.2489	1.3443	1.4563	1.3443		.3155	1.2197
5	1.3575	1.2752	1.4415	1.4003		.3681	1.2752
6	1.262	1.386	1.386	1.2883	.9979	.3681	1.2197
7	1.4815	1.5684	1.5123	1.6804	.6653	1.1568	1.4969
8	1.7741	1.5684	1.4415	1.5123	.5373	1.386	1.4415
9	1.7187	1.5684	1.5684	1.4563	.499	1.4563	1.3306
10	1.7924	1.4969	1.6804	1.3443	.4938	1.5123	1.4415
11	1.3443	1.4969	1.2883	1.2197	.4938	1.5684	1.3306
12	1.6244	1.6078	1.4563	1.3306	.3841	1.4563	1.3306
13	1.6244	1.7364	1.6804	1.4415	.439	1.4563	1.3306
14	1.5684	1.5684	1.6804	1.3306	.499	1.5123	1.5524
15	1.386	1.4563	1.5684	1.2197	.3881	1.3443	1.3306
16	1.6804	1.4415	1.5684	1.4003	.3841	1.4969	1.5684
17	1.6804	1.4563	1.5684	1.4003	.3881	1.5123	1.4563
18	1.6244	1.4969	1.5123	1.5123	.3326	1.5123	1.5123
19	1.5684	1.6804	1.5123	1.5684	.4344	1.5684	1.4563
20	1.4003	1.2883	1.3443	1.3443	.3801	1.2752	1.4563
21	1.6244	1.6078	1.4563	1.386		1.3443	1.5684
22	1.5123	1.5684	1.5684	1.4415	.3258	1.6244	1.6804
23	1.4563	1.386	1.2883	1.3443	.3086	1.4003	1.4003
24	1.3672	1.6078	1.4415	1.1763	.3258	.3155	1.4415
Max	1.7924	1.7364	1.6804	1.6804	.9979	1.6244	1.6804
Min	1.2489	1.2323	1.2883	1.1763	.3086	.3155	1.2197
Avg	1.5042	1.5013	1.4883	1.3730	.4598	1.1216	1.4056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254045 / SHINDEWADI

Feeder No / Name : 404 / UMICORE

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7058	.7242	.7088	.7173	.3601	.6384	1.0585
2	.7053	.7088	.6453	.7699	.3532	.6367	1.2774
3	.7036	.7139	.6528	.7105	.3515	.6384	1.2089
4	.707	.6511	.6505	.7088	.3567	.6847	1.1139
5	.7019	.7024	.711	.7665	.3498	.6847	1.1088
6	.7115	.7059	.7173	.7716	.5767	.6847	1.1259
7	.6927	.6425	.659	.7699	.5819	1.2072	1.1225
8	.587	.5876	.5887	.7785	.5681	1.3843	1.1259
9	.6544	.5905	.6013	.7699	.5767	1.2031	1.1397
10	.8042	.6282	.7579	.7733	.5676	1.1106	1.1722
11	.7956	.7436	.8351	.775	.5744	1.3026	1.2209
12	.8539	.7465	.8231	.6316	.5762	1.2586	1.4472
13	.7842	.7002	.8179	.5853	.5624	1.2569	1.2689
14	.7671	.7127	.7528	.5939	.5647	1.4157	1.3049
15	.671	.7196	.7596	.5819	.6956	1.3934	1.2014
16	.6985	.5047	.8214	.5876	.6961	1.262	1.274
17	.6848	.6602	.8522	.579	.6973	1.426	1.378
18	.8008	.8488	.7956	.5722	.6922	1.014	1.274
19	.8076	.8299	.7991	.6185	.7053	1.1842	1.2163
20	.7956	.8128	.8076	.6436	.6847	1.2655	1.1871
21	.7853	.7367	.7939	.5767	.6973	1.1431	1.1888
22	.7259	.7316	.7751	.5802	.6847	1.1854	1.2123
23	.7853	.7276	.7785	.5842	.679	1.0534	1.1814
24	.5642	.7179	.7162	.7116	.427	.8888	1.2214
Max	.8539	.8488	.8522	.7785	.7053	1.426	1.4472
Min	.5642	.5047	.5887	.5722	.3498	.6367	1.0585
Avg	.7289	.7020	.7425	.6732	.5658	1.0801	1.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 301 / AHIRE

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.1132	1.166	1.3717	1.2689	.1132	.0686
2	.0686	.1132	1.3375	1.3032	1.2689	.1132	.1029
3	.1029	.1132	1.3375	1.3032	1.2689	.1132	.0686
4	.0686	.112	1.3375	1.4403	1.2689	.1132	.0686
5	.0686	.1132	1.3375	1.3717	1.2689	.1509	.0686
6	.0686	.1132	1.3375	1.6804	1.3032	.112	.0686
7	.0686	.1132	1.7147	2.0233		.1132	.1029
8	.112	.112	1.989	2.2977		.112	.0686
9	2.4272	2.0576	.0686	.0686	.112	1.989	1.8861
10	2.9874	2.4691	.0686		.112	2.2977	2.4691
11	2.7435	2.4006	.0686	.0686	.112	2.332	2.0919
12	2.7633	2.1605	.0686	.0686	.112	2.3663	2.0919
13	2.726		.1029	.0686	.1132	2.2977	2.0576
14	2.6886	2.1948	.0686	.0686	.1132	2.332	.7545
15	2.5766	.1269	.1029	.0686	.112	2.3663	.216
16	2.5393	2.4348	.0686	.0686	.1132	2.332	2.332
17	.1132	.0686			.1132	.0686	.0686
18	.1132	.0686	.0686		.112	.1029	.0686
19	.112	.0686	.0686		.112	.1029	.0686
20	.1132	.0686	.0686	.0686	.1132	.1029	.0686
21	.1132		.1029	.0686	.112	.1029	.0686
22	.1132	.0686	.1029		.1132	.1029	.0686
23	.1132	.0686			.1132	.1029	.0686
24	.0686	.1132	.0686	1.3717	1.2003	1.4563	.0686
Max	2.9874	2.4691	1.989	2.2977	1.3032	2.3663	2.4691
Min	.0686	.0686	.0686	.0686	.112	.0686	.0686
Avg	.9558	.6942	.5752	.8211	.4789	.8915	.6277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 302 / KHANDALA

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.2936	1.3717	1.0974	1.3375	.8589	1.3717
2	1.3717	1.307	1.3032	1.1317	1.3717	.8962	1.3717
3	1.3032	1.2323	1.3717	1.0974	1.3375	1.0082	1.3032
4	1.3032	1.307	1.3717	1.2003	1.3032	1.0719	1.3032
5	1.406	1.3676	1.3375	1.3717	1.3717	1.1949	1.406
6	1.406	1.4937	1.3375	1.4746	1.5089	1.307	1.5089
7	1.4403	2.4025	1.4403	1.6461	1.5089	1.643	1.6804
8	1.419	2.2405	2.1262	1.5775		1.8671	1.4403
9	1.307	2.2291	1.3032	1.8519	2.2546	1.8176	2.332
10	1.307	1.8519	1.3375	1.9547	1.4784	1.9204	2.0576
11	1.3443	1.8519	1.7833	1.5775	2.0538	1.9204	2.0233
12	1.1576	1.7833	1.6461	1.8176	1.4937	1.7147	1.5089
13	1.4937	1.0288	1.3717	1.6804	1.3676	1.1317	1.3717
14	1.8671	1.3032	1.7147	1.6461	1.1203	1.7147	1.3717
15	1.8671	1.749	2.0233	1.4746	1.307	2.1262	1.5432
16	1.4937	1.406	1.6118	1.4746	1.6057	2.0576	1.3375
17	2.0328		1.4403	1.4746	1.4937	2.1605	1.6461
18	2.1068	1.3032	1.3717	1.8519	1.4937	1.6461	2.332
19	2.1285	.144	1.4746	1.8519	1.419	1.8176	1.4746
20	1.8671	1.7147	2.0576	1.6804	1.5684	1.5775	1.989
21	1.848	1.4403	1.7147	1.5432	1.307	1.3032	1.4746
22	1.8298	1.3717	1.7833		1.1203	1.2689	1.3717
23	1.6804	1.3717			1.0456	1.5775	1.7833
24	1.3032	1.531	1.3375	1.2689	1.3717	.8871	1.4746
Max	2.1285	2.4025	2.1262	1.9547	2.2546	2.1605	2.332
Min	1.1576	.144	1.3032	1.0974	1.0456	.8589	1.3032
Avg	1.5690	1.5097	1.5492	1.5339	1.4452	1.5204	1.6032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 303 / LOHOM

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.2936	1.166	1.3717	1.3717	.8131	1.3717
2	1.0631	1.3306	1.2346	1.3032	1.3032	.8962	1.2689
3	1.0631	1.3676	1.2003	1.2003	1.3375	.9335	1.2689
4	1.1317	1.4563	1.2346	1.2003	1.2689	1.0082	1.166
5	.9945	1.5524	1.166	1.2689	1.2346	1.1576	1.2689
6	1.0631	1.6632	1.3375	1.2689	1.0631	1.2323	1.166
7	.8573	1.6632	1.2003	1.3717	1.0631	.9709	1.0288
8	1.1203	1.4937	.1235	1.3717		.9335	.8916
9	1.2323	2.0233	1.0974	1.3032	1.3817	1.3717	1.0288
10	1.6804	2.0233	1.7147	1.5432	1.307	1.4746	.9602
11	1.8671	2.0576	1.8519	1.4403	1.4937	1.5089	1.0974
12	1.8671	2.2634	1.6804	1.8861	1.4937	1.3032	1.0974
13	1.307	1.8519	1.3717	1.7833	1.4045	.9945	1.0974
14	1.6804	1.989	1.406	1.7147	1.1203	1.6461	.823
15	1.7924	2.1605	1.4746	1.6804	1.4937	1.8176	.9945
16	1.307	1.989	1.8519	1.5432	1.0082	1.989	1.1317
17	1.4937	1.7147	1.6461		1.1203	2.0576	.8916
18	1.6057	1.6461	1.6461	1.6118	1.1949	1.8519	1.1317
19	1.6057	1.6118	1.5775	1.5775	1.5684	1.5775	1.3032
20	1.7924	1.6118	1.3375	1.406	1.2323	1.166	1.0631
21	1.6804	.1578	1.4746	1.3375	1.307	1.3032	1.0288
22	1.531	1.5775	1.406		1.1088	1.406	.9259
23	1.4563	1.3717			1.1317	1.3717	.9259
24	1.2003	1.2936	1.3032	1.3375	1.3717	.7842	1.4403
Max	1.8671	2.2634	1.8519	1.8861	1.5684	2.0576	1.4403
Min	.8573	.1578	.1235	1.2003	1.0082	.7842	.823
Avg	1.3954	1.6318	1.3697	1.4534	1.2774	1.3154	1.0988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 304 / TBK

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.1509	.1715	.1715	.0686	.0566	.1372
2	.3277	.1509	.1715	.1715	.0686	.0566	.1372
3	.2896	.1509	.1715	.1372	.0686	.0566	.1372
4	.2896	.1509	.1715	.1715	.0686	.056	.1029
5	.2515	.1509	.1715	.1372		.0566	.1029
6	.2896	.1509	.1372	.1372		.0566	.1029
7	.2896	.1509	.583	.1372	.0686	.0566	.1029
8	.301	.0747	.5144	.1029		.112	.1029
9	.3772	.2401	.2058	.2058	.0754	.1715	.2058
10	.3772	.2058	.1715		.0747	.1715	.2401
11	.3772	.2058	.1715	.1715	.0754	.2401	.2058
12	.3772	.2058	.1715	.1029	.0747	.2401	.1372
13	.3772	.2058	.1715	.1715	.0566	.2401	.1715
14	.3772	.2401	.1715	.1715	.0566	.2401	.1715
15	.4146	.2058	.1715	.0171	.0566	.2401	.1715
16	.4146	.1715	.1715		.0566	.2401	.1715
17	.1886	.1372	.2401	.2401	.0566	.2058	.0171
18	.1494	.1372	.2058	.1715	.0566	.1715	.1715
19	.1867	.1372	.1715	.2058	.056	.1372	.2058
20	.1494		.2058	.1715	.056	.1372	.1372
21	.1509	.1372	.2058	.2058	.056	.1715	.1715
22	.1509		.2058		.056	.1715	.1715
23	.1509	.1715			.056	.1372	.1372
24	.1715	.1509	.1715	.1715	.1715	.0566	.1372
Max	.4146	.2401	.583	.2401	.1715	.2401	.2401
Min	.1494	.0747	.1372	.0171	.056	.056	.0171
Avg	.2830	.1674	.2132	.1586	.0683	.1450	.1479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 305 / HITECH PLAST

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5228	.5487	.6859		.6348	.4801
2	.5144	.5228	.5487	.6173		.5975	.4801
3	.5144	.4854	.5487	.6173		.5975	.4801
4	.5487	.5228	.5487	.6173		.5975	.5487
5	.5487	.5975	.5487	.583		.5975	.4115
6	.583	.6722	.6516	.6173		.5975	.4115
7	.583	.5601	.0583	.583		.4854	.3772
8	.4854	.5228	.5144	.5487		.4481	.4115
9	.2614	.583	.583	.6173	.5228	.6173	.583
10	.2987	.823	.6173		.4854	.6173	.5487
11	.4481	.7202	.7545		.5601	.6173	
12	.7468	.6516	.7202		.4854	.6173	.6173
13	.7095	.6516	.7202		.4481	.6173	.5487
14	.5601		.6859		.4294	.583	.5487
15	.8215		.7888		.5975	.6173	
16	.583		.583		.4481	.2401	
17	.6036	.6516	.7888	.5487	.4481	.4115	.6173
18	.5601	.6516	.6859	.4458	.4481	.4801	.4458
19	.7095	.6516	.583	.5144	.5228	.4801	.7545
20	.5601	.583	.6173	.6516	.5975	.583	.5144
21	.5601		.583	.5487	.5601	.4801	.6516
22	.5975	.5144	.6173		.6722	.583	.5487
23	.5601	.5487			.5975	.5487	.5487
24	.583	.5601	.5487	.583		.7095	.583
Max	.8215	.823	.7888	.6859	.6722	.7095	.7545
Min	.2614	.4854	.0583	.4458	.4294	.2401	.3772
Avg	.5606	.5998	.6019	.5853	.5215	.5566	.5291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819]

BU 4819

Substation No/ Name :- 254052 / Mhavashi

Feeder No / Name : 401 / Panache Alluminium

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2263	.2572	.2572	.9774	.2801	.1029
2	.3086	.2263	.2572	.2572	.9774	.2801	.1029
3	.2572	.2829	.2572	.3086	.9774	.2801	.1029
4	.2572	.2829	.2572	.3601	.9774	.2801	.1543
5	.2058	.2241	.2572	.3086	1.0802	.2801	.1029
6	.2058	.2241	.3601	.3601	1.0802	.2801	.1029
7	.2572	.3921	.3086	.3601		.2241	.1543
8	.2801	.3361	.3086	.3086		.3921	.1543
9	.2801		.3601	.3086	.2801	.3601	.2572
10	.2801	.3086	.3601		.2241	.3086	.2058
11	.2241	.2572	.3086		.2801	.3601	.036
12	.2801	.2572	.463		.2241	.3601	.4115
13	.2241	.4115	.3086		.2263	.3086	.4115
14	.3361	.3086	.3601		.2263	.3086	.2058
15	.2572		.3601		.2241	.2572	.2572
16	.2572		.3601		.168	.2572	.3601
17	.3921	.2572	.3086	.5144	.2801	.2058	.3601
18	.3395	.3601	.3086	.3601	.2801	.1543	.3086
19	.3361	.2572	.3601	.3086	.2829	.1543	.3086
20	.2801	.2572	.3601	.5144	.2241	.1029	.2572
21	.2829		.3601	.463	.3361	.1543	.2572
22	.2801	.2572	.2572		.2801	.1543	.3086
23	.2801	.0257			.2801	.1543	.2058
24	.2572	.2801	.2572	.5144	.9774	.2801	.1543
Max	.3921	.4115	.463	.5144	1.0802	.3921	.4115
Min	.2058	.0257	.2572	.2572	.168	.1029	.036
Avg	.2778	.2716	.3198	.3669	.4938	.2574	.2201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 301 / wai

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17
HR	Load (MW)
24	.6413
Max	.6413
Min	.6413
Avg	.6413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 302 / KHANDALA

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17
HR	Load (MW)
24	1.7353
Max	1.7353
Min	1.7353
Avg	1.7353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 303 / SHIRWAL-INDUSTRIAL
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17
HR	Load (MW)
24	3.9609
Max	3.9609
Min	3.9609
Avg	3.9609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 304 / SHIRWAL

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	1.2826
Max	1.2826
Min	1.2826
Avg	1.2826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 305 / LAWKIM

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	1.8484
Max	1.8484
Min	1.8484
Avg	1.8484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 306 / 22KV BHADE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17
HR	Load (MW)
24	.415
Max	.415
Min	.415
Avg	.415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 307 / Jawale Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	1.0562
Max	1.0562
Min	1.0562
Avg	1.0562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 308 / 22KV WATHAR COLONY GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	1.5843
Max	1.5843
Min	1.5843
Avg	1.5843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 401 / SHINDEWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17
HR	Load (MW)
24	6.394
Max	6.394
Min	6.394
Avg	6.394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 402 / CAPSUL

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	4.4702
Max	4.4702
Min	4.4702
Avg	4.4702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 403 / MHAVASHI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17
HR	Load (MW)
24	4.357
Max	4.357
Min	4.357
Avg	4.357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 404 / Asian Paint

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	2.32
Max	2.32
Min	2.32
Avg	2.32

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 405 / THERMAX BABCOCK

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.7356
Max	.7356
Min	.7356
Avg	.7356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 407 / HELVOET FARMA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	1.9239
Max	1.9239
Min	1.9239
Avg	1.9239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

KHANDALA S/DN.[819] BU 4819

Substation No/ Name :- 257013 / SHIRWAL

Feeder No / Name : 408 / FINOLEX

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.1698
Max	.1698
Min	.1698
Avg	.1698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 301 / 22 KV MUKUND EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.4904	.6722	.5658	.5544	.5658	.5601
2	.6722	.6413	.6348	.6036	.5975	.5281	.5228
3	.5601	.6036	.5975	.4904	.5175	.6413	.4481
4	.5228	.679	.6348	.5121		.5658	.5544
5	.4854	.6036	.5228	.5658		.6036	.4854
6	.5228	.6036	.5975	.5487	.5975	.5281	.4066
7	.4854	.5281	.5914	.2957	.4066	.4527	.4108
8	.3361	.3361	.4854	.4108	.3326	.5281	.5175
9	.4904	.4904	.4066	.4066	.3696	.4527	.4854
10	.415	.4527	.4904	.3361	.4481	.4527	.4904
11	.5658	.4108	.6283	.4854	.4435	.4024	.5658
12	.3772	.415	.5658	.4854	.4435	.3772	.4904
13	.2218	.4904	.1867	.4854	.4805	.4527	.3772
14	.3395	.439	.4066	.6036	.5228	.3772	.3018
15	.3018	.4108	.4481	.4108	.4481	.3395	.3772
16	.3395	.679	.6413	.5975	.6413	.4904	.4904
17	.2263	.6036	.679	.5601	.5658	.415	.3772
18	.6413	.5601	.7545	.5975	.5228	.5175	.5281
19	.6413	.5975	.7167	.6722	.6413	.5228	.6036
20	.5658	.5601	.7167	.6722	.679	.4854	.6413
21	.7167	.5975	.679	.5975		.4481	.679
22		.6348	.5281	.5228	.034	.4108	.4904
23	.5281	.6348	.6413	.4854	.1132	.5228	.5658
24	.5228	.6036	.4481	.7167	.4481	.3772	.6348
Max	.7167	.679	.7545	.7167	.679	.6413	.679
Min	.2218	.3361	.1867	.2957	.034	.3395	.3018
Avg	.4832	.5444	.5697	.5262	.4670	.4774	.5002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 302 / 22 KV ANDHURI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3427	4.0809	.2587	.3018		3.8729	4.2764
2	4.4422	3.8409	.2957	.3018		4.1133	4.3096
3	4.4753	3.7129	.2957	.2987		4.0162	4.3096
4	4.6411	3.5738	.3734	.2957		3.7319	4.4422
5	4.9726	3.8218	.4481	.3361		3.8409	4.5222
6	5.2046	4.0634	.5228	.3696	.4108	4.1617	4.6411
7	5.4035	4.7843	.5975	.4435	.4066	5.4035	5.3041
8	5.8345	5.0465	.5601	.2987	.3772	5.538	5.3041
9	.3658	.4527	5.6687	6.2323	5.8253	.2987	.2987
10		.2263	6.6301	5.9671	7.2428	.2263	.2641
11	.2195	.1867	6.6632	7.2931	6.829	.2263	.3018
12	.2263	.1494	6.8621	7.0611	4.0809	.2263	.1886
13	.2263	.1509	6.1214	6.4312	6.0623	.2172	.2241
14	.1886	.1448	5.7339	6.1607	6.0951	.2218	.2263
15	.1886	.1829	6.1934	6.1328	5.8253	.2172	.1886
16	.2263	.2218	6.3317	6.0334	5.2183	.2641	.2263
17	.3696	.2218	.2614	.1848	.2614	.2263	.2534
18	.4108	.2614	.2987	.2957	.3734	.4108	.3018
19	.3772	.4108	.415	.3734	.415	.3361	.415
20	.3772	.4108	.4527	.3734	.4527	.3734	.415
21	.3395	.3734	.3772	.3361	.3772	.3326	.5281
22		.3734	.3772	.3326	.3772	.3361	.3395
23	4.3911	4.0444	.3395	.2957	.3018	4.3096	4.3077
24	4.2764	4.3911	3.9118	.3018	.2987	.3395	4.3096
Max	5.8345	5.0465	6.8621	7.2931	7.2428	5.538	5.3041
Min	.1886	.1448	.2587	.1848	.2614	.2172	.1886
Avg	2.3409	1.8803	2.4996	2.3521	2.6964	1.8017	2.0791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 303 / 22 KV LONAND MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.9816	1.1203	1.1568		1.2536	1.1203
2	.8215	1.0056	1.1949	1.1218		1.1568	1.1949
3	.7468	.9816	1.1576	1.134		1.1218	1.1203
4	.8215	.9362	1.1203	1.1694		1.0867	1.2826
5	.7842	.9015	1.0829	1.1576		1.2178	1.307
6	.8131	.9114	1.1203	1.2449	1.3817	1.4045	1.2696
7	.7842	.9816	1.0829	1.1576	1.2323	1.3817	1.307
8	.8589	1.0631	1.0829	1.1949	1.182	1.2689	1.419
9	1.094	1.3443	1.1949	1.3817	1.1949	1.5466	1.3817
10	1.1317	1.3957	1.3203	1.3443	1.5684	1.4335	1.5089
11	1.0185	1.4632	1.3957	1.4937	1.5524	1.6598	1.3535
12	.9054	1.4632	1.358	1.6057	1.5684	1.5844	1.3957
13	1.0562	1.4335	1.3169	1.5684	1.267	1.4712	1.358
14	1.094	1.4712	1.0562	1.8107	1.2178	1.358	1.5089
15	1.0562	1.4842	1.2826	1.8671	1.2197	1.5089	1.5089
16	1.094	1.3957	1.2449	2.0538	1.1694	1.4335	1.6598
17	1.0562	1.5089	1.2826	1.8671	1.134	1.4712	1.4784
18	.9568	1.4563	1.1222	1.5684	1.0867	1.3817	1.4937
19	1.0277	1.5684	1.0985	1.7924	1.2536	1.419	1.4563
20	.9465	1.1949	1.2048	1.8298	1.134	1.2323	1.4784
21	.9465	1.3817	1.2803	1.8298	1.2048	1.419	1.4045
22		1.3443	1.1462	1.6057	.4854	1.307	1.3394
23	.8669	1.307	1.0985	1.6057	.3898	1.1088	1.1946
24	.8215	.9362	1.1949	1.134	1.643	1.0867	1.1949
Max	1.1317	1.5684	1.3957	2.0538	1.643	1.6598	1.6598
Min	.7468	.9015	1.0562	1.1218	.3898	1.0867	1.1203
Avg	.9342	1.2463	1.1900	1.4873	1.2045	1.3464	1.3640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 253003 / 22 KV MIDC SWITCHING STATION

Feeder No / Name : 304 / 22 KV KHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3772	.3696	.3772		.3395	.3361
2	.3361	.3772	.3734	.3772		.3395	.3361
3	.3361	.3772	.3734	.3734		.3361	.3361
4	.3734	.4527	.4854	.4527		.3734	.3734
5	.4854	.6036	.6722	.5544		.4904	.4854
6	.6722	.7545	.8215	.7468	.7468	.679	.6722
7	.8962	.9808	.9335	.8962	.8589	.9431	.8215
8	.8215	.7922	.7468	.7468	.8299	.7545	.7468
9	.5914	.5658	.6348	.5975	.6413	.5281	.5975
10	.4755	.4805	.543	.5601	.4904	.4805	.5281
11	.415	.4435	.5281	.4435	.4481	.415	.4527
12	.3772	.3772	.4527	.4108	.3734	.4108	.3395
13	.3772	.2957	.3772	.4108	.3696	.3772	.3326
14	.3696	.362	.3326	.4108	.3696	.3772	.3395
15	.3772	.415	.3018	.4481	.4108	.3734	.4435
16	.3772	.3395	.3772	.4108	.3361	.3658	.415
17	.4344	.362	.3018	.4854	.4108	.4527	.4024
18	.4481	.5601	.4854	.5228	.4854	.4854	.5281
19	.7545	.7468	.7842	.7095	.7545	.6348	.7545
20	.8299	.8589	.9054	.8215	.8299	.8215	.8676
21	.6036	.8215	.7922	.7468	.7167	.7468	.7167
22		.6348	.6413	.5975	.5658	.5975	.6036
23	.4527	.4854	.4527	.4481	.4527	.4108	.4527
24	.3326	.415	.4108	.415	.3734	.3772	.3326
Max	.8962	.9808	.9335	.8962	.8589	.9431	.8676
Min	.3326	.2957	.3018	.3734	.3361	.3361	.3326
Avg	.4988	.5366	.5457	.5402	.5507	.5046	.5089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 301 / 22 KV PADEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3395	.3395	.3395	.3395	.3395	.3395	.3018
12	.3018	.2263	.3395	.2263	.2641	.2263	.2641
18	.2641	.3018	.3395	.2641	.3018	.2641	.2641
23	.2641	.2641	.2641	.2641	.2263	.2641	.3018
24	.2641	.2263	.2263	.2641	.2263	.2263	.2641
Max	.3395	.3395	.3395	.3395	.3395	.3395	.3018
Min	.2641	.2263	.2263	.2263	.2263	.2263	.2641
Avg	.2867	.2716	.3018	.2716	.2716	.2641	.2792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 302 / 22KV LONAND URBAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9808	1.0562	1.0185	1.0185	.9431	1.1317	.9808
12	1.1317	1.2071	1.2071	1.2449	1.2449	1.2071	1.094
18	1.2071	1.1694	1.2826	1.3203	1.1317		1.0562
23	1.0185	1.0562	.9808	1.0185	.9808	1.0562	.9808
24	.7922	.8676	.8676	.8676	.8676	.9054	.8676
Max	1.2071	1.2071	1.2826	1.3203	1.2449	1.2071	1.094
Min	.7922	.8676	.8676	.8676	.8676	.9054	.8676
Avg	1.0261	1.0713	1.0713	1.0940	1.0336	1.0751	.9959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 303 / 22KV TARADGAON AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3018	.3018	3.5837	3.6969	3.4705	.1886	.1132
12	6.1866	5.8471	.2263	.0754	.1509	3.5082	6.0357
18	.1886		.0754	.1509	.1509	.0754	.1509
23	.1886	.1509	3.3573	3.3196		.0754	.1132
24	.4527	.2641		3.4705	3.2819	2.6406	.0754
Max	6.1866	5.8471	3.5837	3.6969	3.4705	3.5082	6.0357
Min	.1886	.1509	.0754	.0754	.1509	.0754	.0754
Avg	1.4637	1.6410	1.8107	2.1427	1.7636	1.2976	1.2977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 304 / 22 KV TAMBAVE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4527	.415	4.7531	5.2435	4.9794	.4904	.4904
12	8.2991	7.4623	.3395		.415	7.9973	7.9595
18	.1509		.2641	.3018	.3018	.1886	.4904
23	.3018	.3395	4.8285	4.3004		.3395	.3772
24	.3018	.3018		5.2435	5.1303	3.9986	.3018
Max	8.2991	7.4623	4.8285	5.2435	5.1303	7.9973	7.9595
Min	.1509	.3018	.2641	.3018	.3018	.1886	.3018
Avg	1.9013	2.1297	2.5463	3.7723	2.7066	2.6029	1.9239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

LONAND[115]

BU 5983

Substation No/ Name :- 258003 / 220/132 KV LONAND

Feeder No / Name : 307 / 22KV TARADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.1694	1.1694	1.1694	1.1694	1.094	1.2826	1.1694
12	.8299	.7922	.9054	.7545	.9054	.8299	.9054
18	.8676	.8299	1.0562	.8676	.8676	.8299	.4527
23	.9431	.9054	.8676	.9808	.9054	.9054	.8676
24	.7167	.7922	.7545	.7922	.7922	.7922	.7167
Max	1.1694	1.1694	1.1694	1.1694	1.094	1.2826	1.1694
Min	.7167	.7922	.7545	.7545	.7922	.7922	.4527
Avg	.9053	.8978	.9506	.9129	.9129	.928	.8224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 306 / SM Spining

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5106	.4611	.3582	.3887	.4039	.3544	.3887
2	.5106	.4687	.3658	.3887	.3963	.3925	.3925
3	.5144	.4839	.3734	.381	.3963	.3963	.3963
4	.5144	.4839	.3658	.381	.3887	.3963	.3963
5	.5182	.4839	.3658	.3849	.3887	.3963	.3963
6	.5144	.4801	.3658	.3849	.3887	.3849	.3887
7	.5068	.4649	.3734	.3963	.3887	.3849	.3849
8	.503	.4611	.381	.3887	.381	.3963	.3963
9	.5106	.4649	.3696	.3658	.3925	.3048	.3963
10	.4877	.4725	.3658	.3582	.3696	.3772	.3887
11	.4725	.4801	.3734	.3658	.3544	.3925	.3887
12	.4572	.4801	.3772	.381	.3582	.4001	.3772
13	.4534	.4839	.3696	.3582	.3734	.3925	.381
14	.4572	.4458	.3772	.3772	.3544	.3887	.3887
15	.4687	.362	.3734	.3772	.3772	.381	.3925
16	.4649	.362	.3696	.3734	.3772	.3772	.3963
17	.4687	.362	.3696	.3772	.3696	.3887	.3963
18	.4496	.3544	.3658	.3696	.3658	.3925	.3963
19	.4458	.3429	.381	.381	.3467	.4001	.3925
20	.4839	.3696	.3849	.4001	.3658	.4001	.3887
21	.4839	.3696	.381	.3925	.3658	.3925	.3887
22	.4877	.3696	.3887	.3887	.3734	.3887	.3963
23	.4839	.3734	.3849	.3887	.3734	.4001	.3963
24	.4725	.3696	.3849	.4039	.362	.3849	.3887
Max	.5182	.4839	.3887	.4039	.4039	.4001	.3963
Min	.4458	.3429	.3582	.3582	.3467	.3048	.3772
Avg	.4850	.4271	.3736	.3814	.3755	.3860	.3914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 301 / 22 KV SOMANTHALI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.4801	.7202	.4458		.7202	.6173
2	.6173	.4801	.6173	.2401		.6859	.6173
3	.6173	.4801	.5487	.2401		.7202	.6173
4	.5487	.4801	.5487	.2743	.583	.6859	.6173
5	.5144	.5144	.583	.2743	.5487	.7545	.6173
6	.6173	.583	.6516	.3772	.6173	.6859	.7202
7	.6859	.6173	.6859	.4458	.724	.7888	.7545
8	.6859	.5144	.7545	.583	.724	.6859	.6173
9	.724		.7545		.6097	.6859	.583
10	.6859	.6859	.6173		.6097	.7621	.6859
11	.6516	.6097	.6173		.5144	.7621	.6859
12	.5487	.6097	.583		.5144	.724	.6173
13	.5487	.6859	.2401		.6859	.8002	.583
14	.583	.6478	.3086		.6859	.6859	.6173
15	.6516	.6478	.3086		.6859	.724	.6173
16		.6478	.3086		.5487	.6859	.5487
17	.2401	.6173	.4115		.583	.6097	.6516
18	.6516	.6516	.3772	.6478	.583	.6173	.6516
19	.7202	.823	.4458	.8002	.6859	.7545	.7545
20	.7545	.7202	.4458	.8002	.6859	.7545	.7202
21	.6859	.9259	.7545	.9145	.8916	.8573	.7545
22	.6516	.8916	.6859	.8002	.7545	.7888	.6859
23	.5487	.6859	.3429	.8002	.6516	.7202	.7202
24	.823	.5144	.7888	.583	.8383	.6859	.7202
Max	.823	.9259	.7888	.9145	.8916	.8573	.7545
Min	.2401	.4801	.2401	.2401	.5144	.6097	.5487
Avg	.6249	.6310	.5458	.5484	.6536	.7227	.6573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 302 / 22 KV KAMBALESHWAR

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989	1.5089	.1715	.1715	.2401		2.0576
2	1.989	1.5089	.1715	.1715	.2401		1.989
3		1.5089	.1715	.1372	.2401	1.8861	1.989
4		1.5089	.1715	.1715	.2743	1.8519	1.989
5		1.5089	.2401	.1715	.2743	1.8519	2.0576
6	2.1948	1.7833	.2743	.3429	.3429	1.8176	2.1948
7	2.7816	2.2977	.3086	.3772	.4572	2.0576	2.4691
8	2.8578	1.749	.2743	.3086	.381	2.2977	2.6406
9	.2667	.2058	2.6063		3.0864		.2743
10	.2058	.1905	2.7435		3.3532	.4191	.2058
11	.2058	.1905	2.7435		2.9835	.2286	.1715
12	.2058	.1905	2.8807		2.915	.1905	.2058
13	.1715	.2286	2.8121		2.8464	.1905	.1715
14	.2743	.2286	2.6406		2.8464	.1905	.2058
15	.1715	.2286	2.7092		2.7435	.2286	.2058
16	.2058	.2286	2.7092		2.6406	.2286	.2058
17	.2058	.2058	.2401		.2058	.2667	.2058
18	.2401	.2401	.3086	.2667	.2401	.2401	.2743
19	.3772	.3772	.3429	.381	.3086	.3429	.3429
20	.3086	.3772	.3429	.381	.3086	.3429	.3429
21	.3086	.3429	.3086	.3429	.2743	.3086	.3429
22	.2743	.3086	.3086	.3048	.2743	.2743	.3086
23	1.5775	1.749	.1715	.2667	.2401	2.0919	2.0233
24	2.1338	2.2977	1.6804	.1715	.2667	.2058	2.0576
Max	2.8578	2.2977	2.8807	.381	3.3532	2.2977	2.6406
Min	.1715	.1905	.1715	.1372	.2058	.1905	.1715
Avg	.9022	.8735	1.1388	.2644	1.1660	.8339	1.0388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 303 / 22 KV SASTEWADI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	1.6804	1.3717	1.8176		.4115
2	.3429	.3086	1.7147	1.3717	1.7833		.4115
3	.3429	.2743	1.7833	1.3717	1.749		.4115
4	.3772	.2743	1.8519	1.4403	1.8176	.4115	.4458
5		.3086	1.989	1.6118	1.8519		.4458
6	.5144	.3086	2.3663	2.0233	2.1605		.583
7	.6859	.583	3.3265	1.1317	3.2769		.6173
8	.6478	.4115	3.7723	3.1207		.5487	.4801
9	3.8485	3.4637	.3429				2.8464
10	4.2867	3.0483	.1715		.381	4.2295	4.1495
11	4.3896		.1715		.3429	4.1152	4.1152
12		4.4201	.2743		.3086	4.4582	3.9438
13	3.6694	4.4963	.3086		.3429	4.3058	3.738
14	3.3951	4.3058	.3086		.3772	4.4582	3.6694
15	3.4294	4.2676	.3086		.3772	4.3058	3.6694
16	3.6008	4.3058	.2058		.3772	4.3439	3.6694
17	.3429	.0686	.3086		.3772	.381	.3429
18	.4801	.0686	.0686	.4572	.4115	.3772	.0686
19	.6516	.7888	.0686	.6478	.5487	.6173	.6173
20	.6173	.7202	.7202	.6859	.6516	.6859	.6173
21	.583	.6859	.6173	.6478	.583	.6173	.583
22	.4801	.5487	.5487	.5335	.5144	.5144	.5487
23	.3772	.4458	1.406	2.0195	1.8176	.4458	.4115
24	.3429	.3086	.3772	1.3717	2.0195	1.6804	.4115
Max	4.3896	4.4963	3.7723	3.1207	3.2769	4.4582	4.1495
Min	.3429	.0686	.0686	.4572	.3086	.3772	.0686
Avg	1.5340	1.5096	1.0288	1.3204	1.0858	2.1468	1.5504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 304 / 22 KV SANGAVI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.4403	.2058	.1715	.2058	1.0974	1.3717
2	1.3032	1.406	.2058	.1715	.2058	1.0974	1.3717
3	1.3032	1.4403	.2058	.1715	.2058	1.0974	1.4403
4	1.3717	1.4403	.2058	.1715	.2401	1.2346	1.4403
5		1.5089	1.5089	.2743	.2743	1.3717	1.5775
6	1.7833	1.8519	1.8519	.3429	.3772	1.6461	1.7147
7	2.6673	2.332	2.332	.4801	.5335	2.4006	2.6063
8	3.0483	2.6063	2.6063	.3429		2.7435	2.7435
9	.381	.2743	.2743			.3086	.2743
10	.2401	.2667	2.4006		3.315	.2667	.2058
11	.1372	.2286	2.4006		3.155	.2286	.1372
12	.2058	.2286	3.0864		2.9492	.2286	.1372
13	.1372	.1524	3.0864		2.9492	.1905	.2058
14	.1372	.1905	2.5377		2.9492	.1905	.1372
15	.1372	.1905	2.8121		2.9492	.1905	.2058
16	.2058	.2286	2.7435		2.8121	.2286	.2058
17	.2743	.2058			.2743	.2667	.2058
18	.2743	.2743	.3429	.3429	.2743	.2743	.2743
19	.4115	.4115	.4115	.4572	.3772	.4115	.1715
20	.3429	.4115	.4115	.4191	.4115	.4115	.3429
21	.2743	.3429	.3429	.3429	.3429	.2743	.2743
22	.2743	.2743	.2743	.3048	.3086	.2743	.2743
23	1.4403	1.166	.1715	.2286	.2401	1.3717	1.2346
24	1.3032	1.4403	1.2346	.2058	.2286	.1715	1.3717
Max	3.0483	2.6063	3.0864	.4801	3.315	2.7435	2.7435
Min	.1372	.1524	.1715	.1715	.2058	.1715	.1372
Avg	.8242	.8464	1.3762	.2952	1.1627	.7490	.8302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 305 / 22 KV SOMANTHALI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2058	1.166	1.0288	1.3717		.2743
2	.2401	.2058	1.2346	.9945	1.3375		.2743
3	.2401	.2058	1.2346	.9945	1.3375		.2743
4	.2743	.2058	1.3032	1.0288	1.3717	.2743	.2743
5	.3086	.2743	1.3717	1.0974	1.406		.3429
6	.4115	.4115	1.6461	1.6461	1.6118		.4115
7	.5716	.4801	2.1262	2.1948	2.2862		.5487
8	.4954	.4115	2.1948			.4458	2.0576
9	2.3624	2.0576	.2743			1.7833	2.0576
10	2.4348	2.0576	.2743		.381	2.21	2.4691
11	2.332	2.4387	.2743		.2743	2.4006	2.332
12	2.1262	2.3243	.2743		.2058	2.4768	2.2634
13	2.0576	2.3624	.2058		.2058	2.4768	2.1948
14	1.9204	2.2481	.1372		.2058	2.2862	2.1262
15	2.7778	2.4006	.2058		.2058	2.2481	2.1262
16	1.9204	2.3243	.2058		.2743	2.3624	2.1262
17	.1372	.2743	.2743		.2743	.3048	.2058
18	.1372	.3429	.3429	.381	.3429	.2743	.3429
19	.4801	.4801	.3429	.4954	.4801	.4801	.2058
20	.3429	.4801	.4801	.4954		.4801	.4115
21	.3429	.4115	.3429	.4572	.4115	.4115	.3429
22	.3429	.4115	.3429	.381	.3772	.3429	.3429
23	.2743	.3429	1.0288	1.5623	1.166	.2743	.2743
24	.2401	.2058	.3429	.2058	1.5623	1.166	.2743
Max	2.7778	2.4387	2.1948	2.1948	2.2862	2.4768	2.4691
Min	.1372	.2058	.1372	.2058	.2058	.2743	.2058
Avg	.9588	.9818	.7344	.9259	.8138	1.2610	1.0231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 254061 / 33/22 KV SOMANTHALI

Feeder No / Name : 306 / 22 KV somawar peth

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.0343	.0343	.0343		.0343
2		.0343	.0343	.0343	.0343		.0343
3	.0343	.0343	.0343	.0343	.0343		.0343
4		.0343	.0343	.0343	.0343		.0343
5		.0343	.0343	.0343	.0343		.0343
6	.0343	.0343	.0343	.0343	.0343		.0343
7	.0381	.0343	.0343	.0343	.0381		.0343
8	.0381	.0343	.0343	.0343	.0381	.0343	.0343
9	.0381		.0343		.0381		.0343
10	.0343	.0381	.0343		.0381	.0381	.0343
11	.0343	.0381	.0343		.0343	.0381	.0343
12	.0343	.0381	.0343		.0343	.0381	.0343
13	.0343	.0381	.0343		.0343	.0381	.0343
14	.0343	.0381	.0343		.0343	.0381	.0343
15	.0343		.0343		.0343	.0381	.0343
16	.0343	.0381	.0343		.0343	.0381	.0343
17	.0343	.0343	.0343		.0343		.0343
18	.0343	.0343	.0343	.0381	.0343		.0343
19	.0343	.0343	.0343	.0381	.0343		.0343
20	.0343	.0343	.0343	.0381	.0343	.0343	.0343
21	.0343	.0343	.0343	.0381	.0343	.0343	.0343
22	.0343	.0343	.0343	.0381	.0343	.0343	.0343
23	.0343	.0343	.0343	.0381	.0343	.0343	.0343
24	.0305	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0381	.0381	.0343	.0381	.0381	.0381	.0343
Min	.0305	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0347	.0353	.0343	.0358	.0349	.0363	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114] BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 301 / 22KV PHALTAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			1.9547		
12		1.6385		1.4746	1.5242
20		2.1948			2.2634
24	2.1338				
Max	2.1338	2.1948	1.9547	1.4746	2.2634
Min	2.1338	1.6385	1.9547	1.4746	1.5242
Avg	2.1338	1.9167	1.9547	1.4746	1.8938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 302 / 22KV Y. C. HIGHSCHOOL

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9355	2.966	3.1459	3.2465	3.0575	3.1337	3.0239
2	2.8106	2.8746	3.0178	3.1001	2.9081	2.9904	2.8898
3	2.774	2.8319	2.9447	3.03	2.8319	2.9294	2.8197
4	2.7557	2.8471	2.9325	2.9935	2.8258	2.9233	2.8045
5	2.8624	2.9599	3.0117	3.0514	2.8898	3.0056	2.8898
6	3.2038	3.2861	3.3288	3.3532	3.091	3.3166	3.1763
7	3.5391	3.6092	3.6824	3.7311	3.2068	3.6397	3.6366
8	3.7738	3.8561	6.0852	3.8714	3.5543	3.9049	3.8439
9	3.661	3.6549	3.7982	3.7311	3.594	3.6885	3.6854
10	3.6549	3.6488	3.8348	3.9232	3.7281	3.7799	3.7433
11	3.9994	3.9293	4.3621	4.3378	3.9476	4.0665	4.0451
12	3.9933	6.3923	4.3682	4.2585	6.041	6.752	4.0787
13	3.7342	3.9903	4.292	3.6915	4.0329	3.9933	3.7342
14	3.4446	3.8074	4.1244	3.4324	3.7342	3.6427	3.2251
15	3.6397	3.9506	4.1975	3.9689	3.6976	3.9628	3.6031
16	3.8287	4.0787	4.1671	3.9781	3.7952	4.1	3.6184
17	4.0421	4.0543	3.6305	3.9659	3.8317	4.2524	3.6062
18	3.9537	4.0817	4.0268	3.9476	3.8074	4.161	3.7647
19	4.3774	4.417	4.2707	3.911	4.2006	4.1945	4.2737
20	4.9596	7.7077	5.048	4.5755	4.923	7.4455	5.4595
21	4.6365	4.6273	4.8163	4.4505	4.795	4.7859	4.92
22	4.1518	4.2524	4.3317	4.2128	4.3682	4.289	4.4353
23	3.9049	3.9262	4.0268	3.9171	3.9689	3.9384	4.0817
24	5.5357	3.4476	3.5056	3.3928	3.2617	3.3897	3.4568
Max	5.5357	7.7077	6.0852	4.5755	6.041	7.4455	5.4595
Min	2.7557	2.8319	2.9325	2.9935	2.8258	2.9233	2.8045
Avg	3.7572	3.9666	3.9562	3.7530	3.7538	4.0119	3.7007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114] BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 303 / 22 KV SAINAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.2401		
12		.1143		.1715	.1905
20		.2058			.2058
24	.7621				
Max	.7621	.2058	.2401	.1715	.2058
Min	.7621	.1143	.2401	.1715	.1905
Avg	.7621	.1601	.2401	.1715	.1982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN (U)[114]

BU 5975

Substation No/ Name :- 257004 / 132 KV PHALTAN

Feeder No / Name : 305 / 22 KV MORAYA MILK FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.7545		
12		.8002		.6859	.6097
20		1.0288			.8916
24	.1219				
Max	.1219	1.0288	.7545	.6859	.8916
Min	.1219	.8002	.7545	.6859	.6097
Avg	.1219	.9145	.7545	.6859	.7507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 301 / SAKHARWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5301	2.5606		.0034	.0034	2.1948	
2	2.4996	2.5606		.0034	.0034	2.1948	
3	2.8121	2.5301		.0034	.0034	2.1643	
4	2.7778	2.4691		.0034	.0034	2.2253	
5	2.4996	2.4691		.0034	.0034	2.2862	
6	2.4996	2.5911		.0034	.0034	2.4691	
7	3.0788	3.0788		.0034	.0034	2.9874	
8	3.3836	3.2007		.0034		3.2617	
9		.003	3.5056	3.9933		.0034	.003
10		.0034		4.4201		.0034	.003
11		.0034	4.2372	4.3591		.0034	.003
12		.0034	4.7859	4.2676		.0034	.003
13		.0034	4.6334	4.2067		.003	.003
14		.0034	4.6639	4.1152		.0034	.003
15		.0034	4.5115	3.9628		.0034	.003
16		.0034	3.9323	3.8409		.0034	.003
17		.0034	.0034	.0034		.0034	.003
18		.0034	.0034	.0034		.0034	.003
19		.0034	.0034	.0034		.0034	.003
20	.003	.0034	.0034	.0034	.003		.0034
21	.003		.0034	.0034	.003		.0034
22	.003		.0034	.0034	.003		.0034
23	2.4996		.0034	.0034	.003		2.5911
24	2.5301	2.5911		.0137	.0034	.003	
Max	3.3836	3.2007	4.7859	4.4201	.0034	3.2617	2.5911
Min	.003	.003	.0034	.0034	.003	.003	.003
Avg	2.0861	1.1472	2.1638	1.3846	.0033	.9912	.1756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 303 / NIMBHORE AG FEEDER

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2743		1.89	1.829	.2743	
2	.3086	.2743		1.8595	1.829	.2743	
3	.2743	.2439		1.829	1.768	.2439	
4	.2743	.2439		1.829	1.768	.2743	
5	.3429	.3048		1.829	1.768	.2743	
6	.4458	.3658		1.9509	1.89	.3353	
7	.4801	.3963		2.3167	2.1948	.4268	
8	.4458	.3963	.4458	2.6216		.3048	.4954
9		2.652	.3772	.3429		.2401	2.713
10		3.2312	.3429	.3429		.3048	3.3836
11		3.2007	.3429			3.2922	3.4141
12		3.1703	.3429	.3086		3.3836	3.2617
13		3.1398	.3086	.3086		3.4141	3.2312
14		3.0178	.3086	.3429		3.2617	3.1703
15		2.9874	.3429	.3086		3.2922	3.1398
16		2.9874	.3086	.3086		3.1398	3.1703
17		.3086	.3429	.3429		.3086	.2439
18		.3429	.3086	.3429		.3429	.3048
19		.4458	.4115	.4115		.4458	.3963
20	.3963	.4458	.4458	.4115	.3963		.4458
21	.3963		.4458	.3772	.3963		.4458
22	.3353		.3772	.3429	.3353		.4115
23	.3048		1.89	1.8595	1.6461		.3429
24	.3086	.2743		1.89	1.89	1.6156	
Max	.4801	3.2312	1.89	2.6216	2.1948	3.4141	3.4141
Min	.2743	.2439	.3086	.3086	.3353	.2401	.2439
Avg	.3555	1.3668	.4589	1.0594	1.4759	1.2725	1.7857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 304 / WATHAR -NIMBLAK- AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.003		2.6216	2.3777	.003	
2	.0034	.003		2.5606	2.3777	.003	
3	.0034	.003		2.4996	2.3777	.003	
4	.0034	.003		2.4996	2.3777	.003	
5	.0034	.003		2.4996	2.3777	.003	
6	.0034	.003		3.5056	2.6825	.003	
7	.0034	.003		3.5056	3.6275	.003	
8	.0034	.003	.0038	3.8104		.003	
9		3.7494	.0034	.0034		3.7494	3.9018
10		4.3591	.0034	.0034		4.3896	4.6639
11		4.3591	.0034	.0034		4.6639	4.7249
12		4.6639	.0034	.0034		4.5725	4.6334
13		4.4505	.0034	.0034		4.3286	4.4505
14		4.2067	.0034	.0034		3.1703	4.1457
15		3.9628	.0034	.0034		3.5056	4.1152
16		3.8104	.0034	.0034		4.0238	3.6885
17		.0034	.0034	.0034		.0034	.003
18		.0034	.0034	.0034		.0034	.003
19		.0034	.0034	.0034		.0034	.003
20	.003	.0034	.0034	.0034			.0034
21	.003		.0034	.0034	.003		.0034
22	.003		.0034	.0034	.003		.0034
23	.003		2.4691	2.3777	1.9814		.0034
24	.0034	.003		2.652	2.3777	1.8595	
Max	.0034	4.6639	2.4691	3.8104	3.6275	4.6639	4.7249
Min	.003	.003	.0034	.0034	.003	.003	.003
Avg	.0033	1.6001	.1575	1.1908	2.0512	1.7149	2.2898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 305 / SWARAJ EXPRESS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4572		.4572	.4572	.4191	
2	.4572	.381		.4572	.5335	.4572	
3	.6859	.381		.4191	.6097	.4572	
4	.724	.3429		.4191	.6097	.4191	
5	.6859	.3429		.4191	.6859	.4191	
6	.6859	.381		.381	.6478	.381	
7	.724	.381		.4191	.6859	.4191	
8	.6859	.3429		.3429		.4572	
9		.3048	.6478	.381		.4191	.4572
10		.381	.6478	.4191		.4191	.4954
11		.3048	.6097	.381		.4191	.7621
12		.3048	.4191	.381		.4191	.6478
13		.2667	.4191	.3048		.3429	.6478
14		.2667	.4191	.2286		.3429	.6859
15		.2667	.4191	.3048		.3048	.7621
16		.2667	.4191	.3048		.3429	.6097
17		.2667	.4191	.2667		.3429	.6097
18		.3048	.381	.2667		.3048	.6478
19		.3048	.4191	.381		.2667	.6097
20	.4191	.3048	.4191	.2667	.381		.5335
21	.4191		.3429	.4191	.381		.4954
22	.381		.3048	.5335	.3429		.4954
23	.4191		.381	.4954	.381		.4572
24	.3429	.4572		.4572	.4191	.381	
Max	.724	.4572	.6478	.5335	.6859	.4572	.7621
Min	.3429	.2667	.3048	.2286	.3429	.2667	.4572
Avg	.5393	.3338	.4445	.3794	.5112	.3867	.5944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 307 / 22 KV SAKHARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4458		.4801	.4801	.4458	
2	.4115	.4115		.4115	.4115	.4458	
3	.4115	.4115		.4115	.4115	.4801	
4	.4458	.4458		.4115	.4801	.4801	
5	.583	.5487		.583	.5144	.5487	
6	.7545	.7545		.823	.7545	.7545	
7	.823	.8573		.8573	.823	.8573	
8	.823	.7888		.7202		.7545	
9		.6516	.583	.6516		.7202	.6516
10		.5144		.5487		.6173	.5487
11		.4458	.6173	.6173		.5487	.5487
12		.6173	.5487	.6173		.5487	.5144
13		.6173	.583	.6516		.6516	.5487
14		.5144	.5487	.5487		.6173	.5487
15		.6516	.6516	.583		.6516	.6173
16		.7202	.6516	.6859		.6173	.6859
17		.6859	.7202	.6516		.6516	.6516
18		.6173	.7202	.6859		.7202	.6516
19		.8916	.8573	.8916		.8573	.8573
20	.8916	.8573	.8916	.9259	.8916		.823
21	.7888		.823	.823	.7888		.7888
22	.7202		.7545	.7202	.7202		.7202
23	.5487		.583	.583	.583		.5487
24	.4801	.5144		.5144	.5144	.4801	
Max	.8916	.8916	.8916	.9259	.8916	.8573	.8573
Min	.4115	.4115	.5487	.4115	.4115	.4458	.5144
Avg	.6252	.6173	.6810	.6416	.6144	.6224	.6470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 308 / 22 KV NANDAL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372		.1372	.1372	.1372	
2	.1372	.1372		.1372	.1372	.1372	
3	.1372	.1372		.1372	.1372	.1372	
4	.1372	.1372		.1372	.1372	.1372	
5	.1715	.1715		.1715	.1715	.1715	
6	.2058	.2058		.2058	.2058	.2058	
7	.2401	.2401		.2401	.2401	.2401	
8	.2058	.2286		.2058		.2401	
9		.2667	.1715	.2058		.2058	.2058
10		.2401	.2401	.1715		.2058	.2058
11		.2058	.1029	.2058		.2058	.1715
12		.1715	.1715	.2058		.1715	.1372
13		.1372	.1372	.1372		.1372	.1372
14		.2058	.2058	.1715		.1372	
15		.2058	.2401	.2401		.1715	.1715
16		.2401	.1372	.2401		.2401	.2058
17		.2058	.1715	.2401		.2058	.2058
18		.2401	.2058	.2058		.1715	.2401
19		.2743	.2743	.3429		.2058	.2743
20	.2401	.2401	.2743	.2743	.2401		.3086
21	.2058		.2401	.2743	.2058		.2743
22	.1715		.2058	.2058	.2058		.2058
23	.1715		.1715	.1715	.1715		.1715
24	.1372	.1372		.1372	.1372	.1372	
Max	.2401	.2743	.2743	.3429	.2401	.2401	.3086
Min	.1372	.1372	.1029	.1372	.1372	.1372	.1372
Avg	.1768	.1983	.1966	.2001	.1772	.1801	.2082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 309 / 22 KV NIMBHORE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058		.2058	.2058	.2058	
2	.2058	.2058		.2058	.2058	.2058	
3	.2058	.2058		.2058	.2058	.2058	
4	.2058	.2058		.2058	.2058	.2058	
5	.2401	.2058		.2058	.2058	.2401	
6	.2743	.2743		.2743	.2401	.2743	
7	.3429	.3086		.2743	.2743	.2743	
8	.3086	.3086		.2401		.2401	
9		.2401	.2058	.2401		.2058	.2401
10		.2058	.2058	.2058		.2058	.1715
11		.2058	.1715	.0343		.1715	.1715
12		.2058	.2058	.2401		.1715	.2058
13		.2058	.1715	.2058		.2401	.2058
14		.2058	.2058	.2058		.2058	.2058
15		.2401	.2401	.2401		.2058	.2058
16		.2743	.1715	.2401		.2058	.2401
17		.2401	.2058	.2743		.2401	.2743
18		.2743	.2743	.2743		.2743	.2743
19		.3429	.3772	.3429		.3772	.3429
20	.3429	.3429	.3086	.3429	.3086		.3429
21	.3429		.3086	.3429	.3086		.3429
22	.2743		.2743	.3086	.3048		.3086
23	.2401		.2401	.2743	.2401		.2743
24	.2401	.2058		.2401	.2058	.2058	
Max	.3429	.3429	.3772	.3429	.3086	.3772	.3429
Min	.2058	.2058	.1715	.0343	.2058	.1715	.1715
Avg	.2638	.2433	.2378	.2429	.2426	.2281	.2538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 403 / cummines india limited

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2858		.2858	.2858	.2858	
2	.3429	.2858		.2858	.2858	.2858	
3	.3429	.2858		.2858	.2858	.2858	
4	.3429	.2858		.2858	.2858	.2858	
5	.3429	.2858		.2858	.2858	.2858	
6	.3429	.3429		.3429	.3429	.2858	
7	.5144	.3429		.3429	.2858	.2858	
8	.4572	.4001	.3429	.4001		.2858	
9		.4001	.3429	.3429		.2858	.3429
10		.4572	.4572	.4572		.4572	.4001
11		.5144	.5716	.4572		.5144	.4572
12		.4572	.4572	.4572		.4572	.4001
13		.6287	.5144	.5144		.4572	.4572
14		.6287	.5716	.5144		.5144	.4572
15		.5144	.5716	.4572		.4572	.4001
16		.5144	.6287	.5144		.4572	.6287
17		.4572	1.6004	.4572		.5144	.5144
18		.4001	.4001	.4001		.4001	.4572
19		.5144	.4001	.4001		.4001	.4572
20	.4572	.4001	.3429	3.4294	.3429		.3429
21	.4001		.4001	.3429	.3429		.4001
22	.3429		.3429	.2858	.2858		.2858
23	.2858		.2858	.2858	.2858		.3429
24	.3429	.2858		.2858	.2858	.2858	
Max	.5144	.6287	1.6004	3.4294	.3429	.5144	.6287
Min	.2858	.2858	.2858	.2858	.2858	.2858	.2858
Avg	.3737	.4137	.5144	.5049	.3001	.3744	.4229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254043 / SURAWADI

Feeder No / Name : 404 / tata cumines ltd

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.321	4.1895	3.5837	4.6811	4.8982	1.3717	3.6523
2	4.2696	3.9152	3.6523	4.7325	4.4239	1.3889	3.4465
3	4.7154	4.6811	2.7778	3.5437	3.6237	1.3889	2.7263
4	4.8011	4.5496	2.7606	3.5894	3.458	1.3889	2.7263
5	3.6351	3.4008	2.5892	3.538	3.3493	1.3717	2.692
6	4.6297	4.1381	3.3951	4.784	3.3208	2.9378	3.7037
7	5.2069	5.5041	4.0124	5.7385	3.3436	4.9955	4.0124
8	5.4241	5.3898	5.8071	5.2698	2.5206	5.2526	4.2524
9	4.8868	7.053	6.3215	6.2814	2.3491	6.4701	5.1726
10	5.0755	6.8815	6.4072	6.6358	2.2291	6.9844	6.9501
11	5.3155	6.693	6.3329	6.7387	2.2805	6.9387	7.0245
12	5.2984	6.853	6.5444	6.23	2.3148	7.173	7.1045
13	5.0583	6.6187	6.5215	6.2414	2.3148	6.6416	7.0416
14	4.9554	6.35	6.2929	6.0071	2.0405	6.6815	6.9788
15	4.8697	6.3729	6.4758	6.4929	1.5604	6.7216	7.0187
16	5.0583	6.7044	6.7216	6.5615	1.6118	6.9158	7.0016
17	5.0583	6.4872	6.6301	6.3157	1.7147	6.8015	6.8873
18	5.1612	6.8073	7.0016	6.7559	1.8004	6.8988	6.9501
19	5.2298	6.9102	7.0816	6.9044	1.8004	7.0188	7.3102
20	7.0016	6.9158	7.1274	6.8244	2.2805	5.4184	7.1559
21	6.813	5.1955	7.0416	6.6701	2.2291	5.3327	6.7273
22	6.3329	5.1097	6.6872	6.4358	2.252	5.1612	6.8244
23	5.1326	4.2181	5.5327	5.1269	1.406	4.0124	5.7042
24	5.0468	5.0183	3.8923	4.9497	2.3606	4.1838	4.5268
Max	7.0016	7.053	7.1274	6.9044	4.8982	7.173	7.3102
Min	3.6351	3.4008	2.5892	3.538	1.406	1.3717	2.692
Avg	5.1374	5.6649	5.4663	5.7104	2.5618	4.9771	5.5663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 301 / 22KV Barad ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	1.0185	.5658	.2263	.2641	.3018	1.0185
2	.8299	.9808	.4904	.2263	.2263	.3018	.9431
3	.8299	.9808	.4904	.2263	.2263	.3018	.9431
4	.8676	.9808	.3772	.3018	.2641	.3018	.8299
5	.9808	1.0562	.5658	.3395	.2641	.3395	1.0185
6	1.0562	1.1317	.7922	.3772	.3018	.3772	1.2071
7	1.7353	1.6598	.7922	.3772	.3772	.415	1.8107
8	1.5089	1.5089	.9431	.3018	.3395	.3772	1.6975
9	.2263	.2743	.9431	1.5844	1.3203	.3018	.2263
10	.2263	.2263	.9808	1.6221	1.4712	.2263	.1886
11	.2641	.3018	1.1694	1.5466	1.4335	.1886	.1509
12	.1886	.2263	1.5089	1.4335	1.2826	.1886	.1509
13	.2263	.2263	1.3203	1.4335	1.0562	.1886	.1509
14	.2263	.2263	1.1317	1.2826	1.1694	.2263	.1509
15	.2263	.2263	1.1317	1.2826	1.1694	.1886	.2263
16	.1509		1.094	1.2826	1.2826	.1886	.1509
17	.1509		.1886	.1509	.2263	.1886	.1509
18	.1509	.2263	.2641	.1886	.2263	.1886	.1886
19	.3772	.3018	.3772	.2641	.3772	.3395	.2641
20	.415	.3772	.415	.3395	.415	.415	.3395
21	.3772	.3395	.415	.3395	.3772	.3395	.3395
22	.3395	.3395	.3395	.3018	.3395	.3395	.3018
23	1.0185	.6036	.2641	.3018	.3018	1.1694	.9431
24	.5144	1.0185	.5658	.2641	.2641	.3018	1.094
Max	1.7353	1.6598	1.5089	1.6221	1.4712	1.1694	1.8107
Min	.1509	.2263	.1886	.1509	.2263	.1886	.1509
Avg	.5747	.6469	.7136	.6664	.624	.3206	.6036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 302 / MUNJAWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4705	3.6591	3.2065	.4527	.4527	.4527	3.546
2	3.3573	3.6214	3.0933	.4527	.4527	.4527	3.4328
3	3.3951	3.6214	3.0178	.4527	.4527	.4527	3.3573
4	3.5082	3.6214	2.9424	.4904	.4904	.5658	3.2442
5	3.6969	4.0364	3.1687	.6036	.6413	.679	3.6214
6	3.8477	4.1872	3.3951	.7922	.7922	.7922	3.9232
7	5.0172	4.9794	4.2627	.9054	.9054	.9808	4.7154
8	4.9794	5.0926	4.5645	.8299	.9054	.8676	5.3189
9	.6036	.6036	4.904	5.1303	5.3189	.6413	.6036
10	.4527	.4527	5.5076	5.8471	5.7339	.4904	.4527
11	.3772	.4527	4.7154	5.7339	6.1488	.1509	.3395
12	.3395	.415	5.168	5.8471	5.9602	.2263	.3018
13	.3018	.415	5.2058	5.6962		.415	.3018
14	.3018		3.7723	4.8285	5.3944	.415	.1886
15	.3395		4.4513	5.5076	4.9417	.3772	.3018
16	.3772		4.904	5.5453	5.2812	.415	.3018
17	.415	.1886	.3772	.3395	.415	.1886	.2641
18	.4527	.5281	.4527	.5281	.5281	.2641	.3018
19	.7922	.7922	.679	.8676	.7922	.7922	.7167
20	.7922	.7545	.7922	.7922	.7545	.7922	.7545
21	.6036	.6413	.6413	.6413	.6413	.679	.6413
22	.4904	.4904	.5658	.5658	.5658	.5658	.4904
23	3.4328	3.131	.4904	.4904	.4527	3.6214	3.5837
24	.5144	3.6591	3.2065	.4527	.4904	.4527	3.6591
Max	5.0172	5.0926	5.5076	5.8471	6.1488	3.6214	5.3189
Min	.3018	.1886	.3772	.3395	.415	.1509	.1886
Avg	1.7441	2.1592	3.0619	2.2414	2.1092	.6554	1.8484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 303 / ANDHRUD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5281	.4904	3.6591	3.4328	3.0178	.4527
2	.5281	.5281	.4904	3.546	3.3951	3.0178	.4527
3	.6036	.5281	.4904	3.546	3.4705	3.0556	.3772
4	.679	.6413	.6413	3.5082	3.5837	3.131	.679
5	.8299	.8299	.7922	3.7723	3.7723	3.2065	.8299
6	1.0185	1.0562	.9808	4.0741	3.9609	3.2819	1.0185
7	.9808	1.0185	1.0185	5.3189	5.0926	3.81	.9808
8	.8299	.8299	.8299	5.168	4.904	4.1872	.8299
9	4.4136	4.904	.5658	.5658	.679	4.9417	4.489
10	5.4698	5.5076	.4904	.4904	.4904	4.9794	4.9417
11	5.3189	5.6584	.3772	.3018	.1509		4.8285
12	5.168	5.2058	.3772	.3395	.1886	4.4513	4.3759
13	5.0926	4.904		.4527		4.4136	4.7531
14	4.6399	4.225	.3772	.3395	.415	4.2627	3.8477
15	4.6022	4.6776	.415	.415	.415	4.3381	4.3759
16	4.6776	4.4136	.415	.415	.3395	4.3759	4.225
17	.3395	.3772	.4527	.415	.415	.2641	.3772
18	.2263	.5281	.5281	.5281	.4527	.415	.5281
19	.8299	.8299	.8299	.8676	.7922	.7922	.8676
20	.8676	.8676	.9054	.9431	.8676	.9431	.8676
21	.7167	.7545	.8299	.7545	.7922	.7922	.7922
22	.6413	.679	.679	.6413	.6413	.679	.7167
23	.6036	.6036	3.9609	3.5837	3.0556	.6036	.6036
24	.4115	.5281	.5658	3.9986	3.5082	4.4136	.5658
Max	5.4698	5.6584	3.9609	5.3189	5.0926	4.9794	4.9417
Min	.2263	.3772	.3772	.3018	.1509	.2641	.3772
Avg	2.0840	2.1093	.7610	1.9852	1.9485	2.9293	1.9490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 304 / Barad Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8027	1.2185	1.4243	1.2609	1.2986	1.2849	1.174
2	1.757	1.1888	1.3752	1.2552	1.2334	1.2689	1.1203
3	1.8027	1.2185	1.318	1.246	1.2632	1.2586	1.126
4	2.0668	1.398	1.4129	1.3615	1.4597	1.4254	1.2082
5	2.8053	1.8461	1.8844	1.7798	1.6987	1.8564	1.6666
6	3.8797	2.5366	2.6818	2.6623	2.3457	2.5229	2.4486
7	4.1301	2.7675	2.8635	2.7218	2.4589	2.8292	2.5971
8	3.714	2.4257	2.4555	2.3354	2.2462	2.38	2.3331
9	2.8361	1.7295	1.8565	1.7615	1.8267	1.8599	1.6735
10	2.2062	1.4369	1.5101	1.4129	1.5215	1.5295	1.3158
11	2.0427	1.2929	1.2506	1.4221	1.3477	1.3466	1.3352
12	2.117	1.3809	1.2963	1.3752	1.4107	1.3432	1.254
13	2.0142	1.3981	1.4015	1.3901	1.3661	1.246	1.3032
14	1.9296	1.3466	1.3111	1.3066	1.3683	1.1934	1.3546
15	2.0084	1.3809	1.3866	1.4015	1.0917	1.3135	1.4049
16	2.1856	1.3558	1.5032	1.4415	1.134	1.3158	1.59
17	.7899	1.6335	1.3958	1.4963	1.7513	1.4244	1.4746
18	1.3352	1.7889	1.7501	1.7672	1.7684	1.5364	1.5364
19	2.3571	2.7297	2.4349	2.5812	2.5834	2.4303	2.5434
20	2.4612	2.7206	2.4177	2.6223	2.508	2.4852	2.5743
21	2.1879	2.3812	2.1891	2.3045	2.2462	2.2245	2.3011
22	1.9353	2.0942	1.9685	1.9078	1.9879	1.893	1.9936
23	1.5089	1.6712	1.5821	1.557	1.6347	1.4552	1.6289
24	1.2917	1.3511	1.3923	1.3741	1.3478	1.2998	1.3534
Max	4.1301	2.7675	2.8635	2.7218	2.5834	2.8292	2.5971
Min	.7899	1.1888	1.2506	1.246	1.0917	1.1934	1.1203
Avg	2.2152	1.7622	1.7526	1.7394	1.7041	1.6968	1.6796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 305 / 22 KV GUNAWARE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3772	.415	.3772	.3772	.415	.3772
2	.3772	.3772	.3772	.3772	.3772	.415	.3772
3	.415	.3772	.3772	.3772	.3395	.4527	.415
4	.4527	.4904	.415	.4527	.4904	.4527	.415
5	.5658	.6036	.6036	.4904	.5658	.5658	.5658
6	.7167	.7167	.7167	.679	.679	.7167	.679
7	.9054	.9054	.9054	.9054	.8299	.8676	.8676
8	.8676	.7922	.8299	.8299	.679	.7922	.7545
9	.679	.6413	.6036	.7167	.5658	.6413	.5658
10	.6413	.5658	.5658	.6036	.6036	.4904	.5281
11	.5281	.4904	.415	.4527	.5281	.2263	.3018
12	.4527	.4527	.415	.5658	.5658	.415	.3772
13	.4527	.4527	.415	.5281	.415	.3772	.3395
14	.4527	.415	.415	.3772	.3772	.3772	.3018
15	.4527	.415	.4527	.4527	.4527	.4527	.3772
16	.4527	.4527	.4527	.5281	.6036	.4904	.3772
17	.4904	.5281	.5281	.4904	.6036	.1886	.5281
18	.5658	.6036	.6413	.5281	.6036	.2263	.4904
19	.7922	.8676	.8299	.7922	.8676	.8676	.8299
20	.7922	.7922	.7922	.8299	.7922	.9054	.7545
21	.6413	.679	.6413	.6413	.679	.7167	.6413
22	.4904	.5281	.5281	.5281	.5281	.5658	.5281
23	.415	.4527	.4527	.4527	.4527	.4527	.415
24	.415	.3772	.415	.415	.3772	.415	.3772
Max	.9054	.9054	.9054	.9054	.8676	.9054	.8676
Min	.3772	.3772	.3772	.3772	.3395	.1886	.3018
Avg	.5596	.5564	.5501	.5580	.5564	.5203	.5077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 306 / 22 KV Rajuri Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.3875	.4634	.4252	.4013	.4043	.4999
2	.4344	.3815	.415	.3815	.3875	.4028	.3246
3	.3967	.3738	.4089	.3723	.3708	.3952	.471
4	.4405	.4329	.4573	.407	.4237	.4481	.4923
5	.527	.527	.5875	.5011	.4603	.5514	.5879
6	.7137	.6881	.7488	.6893	.6485	.7259	.7022
7	.8341	.8143	.8296	.8871	.8052	.8916	.8646
8	.8009	.7826	.5975	.8585	.7765	.8238	.8222
9	.684	.6641	.6891	.6733	.6219	.6382	.6428
10	.6626	.5971	.5659	.5274	.45	.5742	.5304
11	.562	.6016	.3616	.4074	.4496	.4573	.4607
12	.5803	.5986	.3906	.4131	.3982	.4089	.3952
13	.5651	.5639	.386	.3936	.2652	.4146	.3693
14	.5076	.4736	.3555	.3147	.3433	.4786	.3586
15	.4557	.5559	.3418	.2705	.2888	.4028	.3403
16	.4496	.4969	.3251	.3113	.2568	.3693	.3281
17	.4451	.5514	.3388	.3296	.2613	.2378	.3342
18	.3741	.5289	.3677	.3281	.3068	.3521	.3281
19	.5311	.5692	.5601	.5388	.4584	.665	.5052
20	.807	.7064	.6744	.7003	.679	.9252	.714
21	.743	.6927	.6398	.6881	.655	.8161	.7277
22	.6321	.6169	.5895	.6001	.594	.7003	.6382
23	.5365	.6001	.5304	.5289	.5502	.6337	.626
24	.474	.4683	.471	.4771	.4816	.5278	.5319
Max	.8341	.8143	.8296	.8871	.8052	.9252	.8646
Min	.3741	.3738	.3251	.2705	.2568	.2378	.3246
Avg	.5663	.5697	.5040	.5010	.4722	.5519	.5248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254046 / 33/22 kv BARAD

Feeder No / Name : 307 / 22 KV Nimblak AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2263	.2263	2.4897	2.6406	2.3011	.1886
2	.1886	.2263	.2263		2.6406	2.3011	.1509
3	.1886	.2263	.2641	2.4143	2.5274	2.2634	.1509
4	.1886	.2641	.2641	2.4897	2.6406	2.2634	.2263
5	.2263	.3018	.3018	2.7161	2.7161	2.2634	.3018
6	.3018	.3018	.3018	3.0933	2.7915	2.2634	.3018
7	.3395	.3395	.3772	3.7346	3.6214	2.6406	.3395
8	.3018	.2641	.3395	3.7346	3.3951	3.2065	.3018
9	3.546	3.2065	.2263	.3018	.1886	3.4328	3.81
10	3.9609	3.9609	.2263	.2263	.2263	3.6969	4.1495
11	4.1872	4.3381	.1509	.2263	.1886	3.4328	3.8855
12	3.6591	3.5082	.1886	.2263	.1886	3.4705	3.7346
13	3.5837	4.0364	.1886	.2263		3.4328	3.8855
14	3.5837	3.7723		.2263	.1509	3.131	3.131
15	3.7346	3.5837	.1886	.1886	.1886	3.3951	3.5837
16	3.7723	3.5082	.1509	.2263	.1886	3.3573	3.4705
17		.1886	.1886	.1886	.1886	.2641	.1886
18		.2263	.2641	.2263	.2263	.2263	.2263
19	.3395	.2641	.2641	.3018	.3018	.3395	.2641
20	.3395	.3395	.3018	.2641	.2641	.2641	.3018
21	.3018	.2641	.2641	.2263	.2263	.2641	.2641
22	.2641	.2641	.2641	.2263	.2263	.2641	.2263
23	.2263	.1886	2.6029	2.6406	2.3011	.1886	.1886
24	.1886	.2263	.2263	2.6783	2.5652	2.3011	.1886
Max	4.1872	4.3381	2.6029	3.7346	3.6214	3.6969	4.1495
Min	.1886	.1886	.1509	.1886	.1509	.1886	.1509
Avg	1.5278	1.4178	.3477	1.2727	1.3301	2.1235	1.3942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 301 / ADARKI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.6173	.9602		.0686	.0686
2	.0343	.0343	.6173	.8916		.0343	.0343
3	.0343	.0343	.6173	.823		.0343	.0343
4	.0343	.0343	.6173	.823		.0343	.0343
5	.0343	.0686	.6859	.823		.0686	.0686
6	.0343	.0686	.8916	1.2003		.0686	.0686
7	.0686	.1029	1.4746	1.6804		.0686	.0686
8	.0686	.1029	1.6804	1.749		.1029	.0686
9	1.4403	1.5775	.0686	.1029		1.6461	1.3717
10	1.7147	1.9204	.0686	.0686	.0343	1.9204	1.7147
11	2.0233	1.9204	.0686	.0343	.0686	1.989	1.6118
12	1.9204	1.8176	.0686	.0686	.0686	1.8519	1.6461
13	1.6804	1.7147	.0686	.0686	.0686	1.8176	1.6118
14	1.6804	1.6118	.1029	.0686	.0686	1.6118	1.2003
15	1.6804	1.6461	.1029	.0686	.0686	1.7147	1.2346
16	1.8176	1.4746	.1029	.0343	.1029	1.5775	1.6804
17	.0686	.0686	.1029	.0686	.0686	.0343	.0686
18	.1029	.0686	.1372	.0686	.1029	.0686	.0686
19	.1029	.1029	.1372	.0686	.1029	.1029	.1029
20	.1029	.1029	.1372	.1029	.1029	.1029	.1029
21	.1029	.0686	.1029	.1029	.1029	.1029	.0686
22	.0686	.0686	.1029	.0686	.1029	.1029	.0686
23	.0686	.0686	.9945	.8916	1.0288	.0686	.0343
24	.7545	.0686	.0686	1.0288		.9602	.0686
Max	2.0233	1.9204	1.6804	1.749	1.0288	1.989	1.7147
Min	.0343	.0343	.0686	.0343	.0343	.0343	.0343
Avg	.6530	.6159	.4015	.4944	.1494	.6730	.5459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 302 / BIBI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.5487	.0034	.0034		.3429	.583
2	.6173	.5487	.0034	.0034		.3772	.583
3	.6173	.5487	.0034	.0034		.4115	.583
4	.6516	.5487	.0034	.0034		.4458	.583
5	.6516	.6173	.0034	.0034		.6173	.583
6	.7202	.8573	.0034	.0034		.7545	.7888
7	1.0974	1.1317	.0034	.0034		1.0288	1.2003
8	1.0631	1.1317	.0034	.0034		1.166	1.2346
9	.0034	.0034	1.166	1.0631		.0034	.0034
10	.0034	.0034	1.4403	1.2346	1.2689	.0034	.0034
11	.0034	.0034	1.406	1.2689	1.4746	.0034	.0034
12	.0034	.0034	1.2346	1.166	1.4403	.0034	.0034
13	.0034	.0034	1.3717	1.3032	1.3032	.0034	.0034
14	.0034	.0034	1.2689	1.166	1.166	.0034	.0034
15	.0034	.0034	1.2346	1.0631	1.2003	.0034	.0034
16	.0034	.0034	1.166		1.166	.0034	.0034
17	.0034	.0034	.0034		.0034	.0034	.0034
18	.0034	.0034	.0034	.0034	.0034	.0034	.0034
19	.0034	.0034	.0034	.0034	.0034	.0034	.0034
20	.0034	.0034	.0034	.0034	.0034	.0034	.0034
21	.0034	.0034	.0034	.0034	.0034	.0034	.0034
22	.0034	.0034	.0034	.0034	.0034	.0034	.0034
23	.583	.6173	.0034	.0034	.0034	.6173	.583
24	.6173	.5487	.583	.0034		.0034	.583
Max	1.0974	1.1317	1.4403	1.3032	1.4746	1.166	1.2346
Min	.0034	.0034	.0034	.0034	.0034	.0034	.0034
Avg	.3035	.2978	.4551	.3780	.6459	.2422	.3063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 303 / MULIKWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4801	.0034	.0034		.3772	.4458
2	.3772	.4458	.0034	.0034		.3772	.4458
3	.3772	.4458	.0034	.0034		.3772	.4458
4	.3772	.4458	.0034	.0034		.3772	.4458
5	.3772	.583	.0034	.0034		.4115	.4458
6	.4458	.6859	.0034	.0034		.4801	.5144
7	.7545	.823	.0034	.0034		.7202	.8573
8	.7202	.8916	.0034	.0034	.0034	.7545	.5144
9	.0034	.0034	.7545	.7545		.0034	.0034
10	.0034	.0034	1.0288	.8573	.8573	.0034	.0034
11	.0034	.0034	1.0974	.8573	.9259	.0034	.0034
12	.0034	.0034	.9945	.7545	.8916	.0034	.0034
13	.0034	.0034	.8573	.823	.7545	.0034	.0034
14	.0034	.0034	.8916	.7202	.7202	.0034	.0034
15	.0034	.0034	.823	.583	.6516	.0034	.0034
16	.0034	.0034	.7888	.6859	.6859	.0034	.0034
17	.0034	.0034	.0034	.0034	.0034	.0034	.0034
18	.0034	.0034	.0034	.0034	.0034	.0034	.0034
19	.0034	.0034	.0034	.0034	.0034	.0034	.0034
20	.0034	.0034	.0034	.0034	.0034	.0034	.0034
21	.0034	.0034	.0034	.0034	.0034	.0034	.0034
22	.0034	.0034	.0034	.0034	.0034	.0034	.0034
23	.5487	.4801	.0034	.0034	.0034	.583	.4801
24	.4115	.5487	.4458	.0034		.0034	.4458
Max	.7545	.8916	1.0974	.8573	.9259	.7545	.8573
Min	.0034	.0034	.0034	.0034	.0034	.0034	.0034
Avg	.2006	.2449	.3222	.2538	.3676	.1879	.2120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 304 / ADARKI GOANTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.1372		.1715	.1372
2	.1372	.1372	.1372	.1372		.1372	.1372
3	.1372	.1372	.1372	.1372		.1372	.1029
4	.1372	.1372	.1372	.1372		.1372	.1029
5	.1029	.1372	.1372	.1372		.1372	.1029
6	.1372	.1715	.1715	.1715		.1715	.1372
7	.1715	.1715	.2058	.1715		.2058	.1715
8	.1715	.1715	.1372	.1372		.2058	.1372
9	.2058	.2401	.1715	.1715		.2058	.1715
10	.2401	.2743	.2058	.2058	.2058	.2058	.2401
11	.2743	.2401	.2058	.1715	.2743	.2401	.2401
12	.2401	.2743	.1715	.2058	.2401	.2401	.2401
13	.2058	.2401	.2058	.2058	.2743	.2401	.1715
14	.1715	.1715	.1715	.1372	.2401	.2058	.1372
15	.2058	.1715	.1715	.1715	.2058	.1715	.2058
16	.2058	.2058	.1715	.1715	.2401	.1715	.2401
17	.2743	.1715	.1715	.1715	.2058	.1715	.2058
18	.2401	.1715	.1715	.2058	.2401	.1715	.2401
19	.2743	.2743	.2401	.2743	.2743	.2401	.2743
20	.3086	.2743	.2743	.2743	.2743	.3086	.2743
21	.2743	.2401	.2743	.2058	.2743	.2743	.2743
22	.2401	.2058	.2401	.2401	.2401	.2058	.2058
23	.1715	.1715	.1715	.1715	.2058	.2058	.1715
24	.1372	.1372	.1372	.1715		.1715	.1715
Max	.3086	.2743	.2743	.2743	.2743	.3086	.2743
Min	.1029	.1372	.1372	.1372	.2058	.1372	.1029
Avg	.2001	.1944	.1815	.1801	.2425	.1972	.1872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 305 / BIBI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1029	.1372		.1029	.1029
2	.1029	.1029	.1029	.1372		.1029	.1029
3	.1029	.1029	.1029	.1372		.1029	.1029
4	.1029	.1029	.1029	.1372		.1029	.1029
5	.1029	.1029	.1029	.1372		.1029	.1029
6	.1372	.1372	.1715	.1715		.1715	.1372
7	.2058	.1372	.2058	.2058		.2058	.2058
8	.2058	.2058	.2401	.2058		.2058	.2743
9	.2401	.1715	.2058	.2743		.2058	.2058
10	.3086	.4115	.2401	.2743	.1372	.4115	.2058
11	.3086	.4115	.3429	.2058	.1029	.4115	.1715
12	.1372	.4115	.4801	.2743	.1029	.2058	.3429
13	.1372	.2743	.1715	.2743	.1715	.1715	.1372
14	.1715	.3086	.1029	.2058	.1715	.1029	.1715
15	.2743	.3429	.3772	.3086	.1715	.2743	.1715
16	.2401	.3772	.4801	.3429	.1029	.2743	.1715
17	.2058	.3429	.3429	.2058	.1029	.3429	.2058
18	.2743	.3429	.1372	.1372	.1029	.1029	.1715
19	.1715	.2058	.1715	.2401	.1715	.2058	.2058
20	.2401	.2058	.2058	.2401	.2058	.2401	.2058
21	.2058	.1715	.2058	.2058	.1715	.2058	.1715
22	.1715	.1715	.1715	.1715	.1715	.1715	.1715
23	.1372	.1029	.1372	.1372	.1372	.1029	.1372
24	.1029	.1372	.1029	.1372		.1029	.1029
Max	.3086	.4115	.4801	.3429	.2058	.4115	.3429
Min	.1029	.1029	.1029	.1372	.1029	.1029	.1029
Avg	.1829	.2243	.2086	.2043	.1446	.1929	.1701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254047 / KAPASHI

Feeder No / Name : 306 / Siddhivinayak Bio-Energy NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.0034	.0034	.0034	.0034	.0034	.0034
2	.0034	.0034	.0034	.0034	.0034	.0034	.0034
3	.0034	.0034	.0034	.0034	.0034	.0034	.0034
4	.0034	.0034	.0034	.0034		.0034	.0034
5	.0034	.0034	.0034	.0034		.0034	.0034
6	.0034	.0034	.0034	.0034		.0034	.0034
7	.0034	.0034	.0034	.0034		.0034	.0034
8	.0034	.0034	.0034	.0034		.0034	.0034
9	.0034	.0034	.0034	.0034		.0034	.0034
10	.0034	.0034	.0034	.0034	.0034	.0034	.0034
11	.0034	.0034	.0034	.0034	.0034	.0034	.0034
12	.0034	.0034	.0034	.0034	.0034	.0034	.0034
13	.0034	.0034	.0034	.0034	.0034	.0034	.0034
14	.0034	.0034	.0034	.0034	.0038	.0034	.0034
15	.0034	.0034	.0034	.0034	.0034	.0034	.0034
16	.0034	.0034	.0034	.0034	.0034	.0034	.0034
17	.0034	.0034	.0034	.0034	.0034	.0034	.0034
18	.0034	.0034	.0034	.0034	.0034	.0034	.0034
19	.0034	.0034	.0034	.0034	.0034	.0034	.0034
20	.0034	.0034	.0034	.0034	.0034	.0034	.0034
21	.0034	.0034	.0034	.0034	.0034	.0034	.0034
22	.0034	.0034	.0034	.0034	.0034	.0034	.0034
23	.0034	.0034	.0034	.0034	.0034	.0034	.0034
24	.0034	.0034	.0034	.0034	.0034	.0034	.0034
Max	.0034	.0034	.0034	.0034	.0038	.0034	.0034
Min	.0034	.0034	.0034	.0034	.0034	.0034	.0034
Avg	.0034	.0034	.0034	.0034	.0034	.0034	.0034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 301 / GOKHALI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17
HR	Load (MW)
24	.4115
Max	.4115
Min	.4115
Avg	.4115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 302 / ASU AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1622	1.2117	.2058	.2629		1.1317	
2		1.2041	.2134	.2667	.2591	1.1241	1.4289
3	1.1698	1.2155	.2172	.2782		1.1469	1.448
4		1.2841	.221	.301	.3048	1.2269	1.5242
5	1.2727	1.3527	.2896	.3315	.381	1.6918	1.6385
6		1.5394	.3467	.3849	.4191	1.6918	1.7909
7	2.0576	1.8404	.3925	.4382	.4306	2.21	2.2862
8	2.1834	2.0462	.362	.3544	.3544	2.3015	
9	.2553	.221	1.7032	2.713	2.1719	.2629	
10	.2324	.202	2.492		2.7664	.202	.2401
11	.2058	.1677	2.793	2.4387	2.7625	.202	.2286
12	.2058	.1715		2.7435	2.774	.202	.1829
13	.221	.1715		2.7435	2.6254	.202	.1981
14		1.5623	2.7016	2.7054	2.4729	.1981	.1981
15	.1981	.1372	2.7016	2.5911	2.431	.2096	.2439
16	.202	.2096	2.4806	2.4768	2.3282	.2172	.1981
17	.2172	.2096	.1829		.1905	.2286	
18	.2515	.2705	.2324		.2362		
19	.3429	.2896	.2934		.3734	.362	
20	.3506	.2477	.3544		.3734	.3163	.3315
21	.3506	.2858			.3582	.301	.3125
22	.3086	.2782	.3201		.3277	.2782	.2934
23		1.044	.2705		.282	1.3794	1.3489
24		1.2041	1.0479	.2705	.2667	.2629	1.4098
Max	2.1834	2.0462	2.793	2.7435	2.774	2.3015	2.2862
Min	.1981	.1372	.1829	.2629	.1905	.1981	.1829
Avg	.6215	.7653	.9439	1.3313	1.1313	.7543	.8501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 303 / 22 KV GOKHALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1067	.0953	.0991			.0991
2		.1067	.0953	.0991	.0991	.1029	.2934
3	.0991	.0991	.0991	.0991			
4	.1181	.1181	.1029	.1029	.1029	.1029	
5	.1867	.1296	.1753		.1486	.1562	.1715
6	.2401	.2058	.2286	.2134	.1943	.2134	.2286
7	.1905	.221	.2401	.2286	.2096	.2324	.2324
8	.16	.1486	.1638	.1486	.1181	.1219	.141
9	.0724	.0876	.0762		.0991	.061	
10	.0724	.08	.1067		.1029	.0876	.0953
11	.0419	.0572	.0914		.0838	.08	.0686
12	.0457	.061	.0838		.0724	.0724	
13	.0953	.0762	.0953		.08	.0762	.0648
14	.0572	.0648	.0953		.0724	.0762	
15	.0762	.08	.0838		.08	.08	.0762
16	.0762	.0686	.1029		.0838	.0838	.0762
17	.0991	.0953	.1029		.1181	.1219	
18	.0876	.0876	.1219		.0953	.0991	.0991
19	.1981	.1448	.1753		.1677	.1677	.1715
20	.1867	.1867	.16		.2058		.1981
21	.1638	.1638			.1867	.1753	.1677
22	.1334	.1524					.1524
23		.1181	.1105			.1105	.1105
24	.0991	.1105	.0991	.1067	.1105	.1029	.1029
Max	.2401	.221	.2401	.2286	.2096	.2324	.2934
Min	.0419	.0572	.0762	.0991	.0724	.061	.0648
Avg	.1180	.1154	.1230	.1372	.1216	.1162	.1416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 304 / 22 KV ASU GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.221	2.0195	.2058		.1981	.1981
2	.1677	.2172	.1943	.2058	.2058	.1943	.1943
3	.1715	.2172	.3506	.2096		.1981	.1981
4	.2401	.2362	.2324		.221	.2401	.2248
5	.2705	.2324	.2743	.2972	.2972	.282	.2972
6	.3772	.3506	.381	.3582	.362	.3315	.3734
7	.2743	.4382	.4725	.4954	.4839	.4534	.3163
8	.3086	.4001	.4268	.4001	.3887	.4115	
9	.2972	.2629	.3201	.301	.381	.3391	
10	.2934	.2705	.2553	.282	.2858	.2591	
11	.2058	.2286	.2134	.2058	.2705	.2248	.2477
12	.221	.1905	.2439		.2401	.1981	.2477
13	.1829	.1981	.1829		.202	.1905	.1981
14	.1715	.1867	.2058		.1867	.1791	.1981
15	.1905	.202	.1753		.1943	.1905	.2401
16	.1867	.2096	.202		.202	.202	.2248
17		.2324	.2667		.2553	.2553	
18	.3086		.2591		.2705	.2705	.282
19	.4077	.4992	.3315		.4382	.4191	.4001
20	.4001	.4725	.4077		.4077		.4191
21	.3429	.3734			.3658		.381
22	.3048	.3239			.3163		.3125
23		.2401	.2629		.2401		.2362
24	.0686	.2248	.1905	.2134	.2096	.202	.2058
Max	.4077	.4992	2.0195	.4954	.4839	.4534	.4191
Min	.0686	.1867	.1753	.2058	.1867	.1791	.1943
Avg	.2527	.2795	.3577	.2886	.2920	.2620	.2698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254048 / BEDAKEWASTI

Feeder No / Name : 305 / 22 KV Sarade AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 301 / Wathar- N Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.0038	1.1694	1.5089	1.5466	.0034	.0038
2	.0034	.0038	1.1694	1.5089	1.5089	.0034	.0038
3	.0034	.0038	1.2071	1.2826	1.5089	.0034	.0038
4	.0034	.0038	1.2826	1.2826	1.5089	.0034	.0038
5	.0034	.0038	1.3957	1.4335	1.4712	.0034	.0038
6	.0034	.0377	1.5844	1.0562	1.4335	.0034	.0038
7	.0034	.0038	2.452	2.3011		.0034	.0038
8	.0034	.0038	2.5652	2.6406	2.7915	.0034	.0038
9	2.1502	2.1502	.0038	.0038	.0038	2.3663	2.3765
10	2.6029	2.6406	.0038	.0038	.0038	2.6749	2.7161
11	2.6406	2.6406	.0038	.0038	.0034	2.9424	2.7161
12	2.5274	2.6783	.0038	.0038	.0034	2.9047	2.5274
13	2.452		.0038	.0038	.0034	2.6783	
14	2.2634	2.452	.0038	.0038	.0034	2.6406	1.8107
15	2.2634	2.452	.0038	.0038	.0034	2.5274	2.3011
16	2.1879		.0038	.0038	.0034	2.5274	2.6406
17	.0038		.0038	.0038	.0034	.0038	.0038
18	.0038	.0038	.0038	.0038	.0034	.0038	.0038
19	.0038	.0038	.0038	.0038	.0034	.0038	.0038
20	.0038	.0038	.0038	.0038	.0034	.0038	.0038
21	.0038	.0038	.0038	.0038	.0034	.0038	.0038
22	.0038	.0038	.0038	.0038	.0034	.0038	.0038
23	.0038	.0038	1.4712	1.4712	1.406	.0038	.0038
24	.0034	.0038	.0038	.0038	1.5844	1.3375	.0038
Max	2.6406	2.6783	2.5652	2.6406	2.7915	2.9424	2.7161
Min	.0034	.0038	.0038	.0038	.0034	.0034	.0038
Avg	.7977	.7193	.5981	.6059	.6438	.9439	.7456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 302 / Upalwe Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4746	1.7353	.3772	.415		1.0631	1.5089
2	1.406	1.6975	.3772	.415		1.0631	1.4712
3	1.406	1.6975	.3772	.4527		1.0974	1.4712
4	1.4746	1.6975	.5281	.4527		1.2003	1.5089
5	1.5432	1.7353	.679	.7922		1.406	1.8861
6	2.0576	1.8107		.7922		1.7147	2.9424
7	2.7778	2.9424				2.6749	2.9047
8	2.8121	2.6783				2.6406	2.8292
9	.4527	.4531	2.8669	2.7161	2.7161	.4115	.4904
10	.3772	.3395	2.9047	2.9424	2.2291	.3086	.3772
11	.2641	.2641	2.9047	2.8292	2.2634	.2641	.3018
12	.2641	.1886	1.8861	2.6783	2.3663	.3395	.3018
13	.2641	.2263	2.6406	2.6406	2.2977	.3018	.2263
14	.2641	.2263	2.4897	2.5652	2.332	.2263	.2641
15	.2641	.2641	2.1502	2.5274	2.2977		.3018
16	.3395	.2641	2.9801	2.4143	2.2977	.2641	.3018
17	.3395	.2641	.3018	.2641	.3086	.2641	.3018
18	.415	.3395	.3772	.3395	.3429	.2641	.415
19	.7545	.7167	.7922	.679	.6516	.7922	.5658
20	.7922	.7167	.7545	.7545	.6859	.7922	.7922
21	.7167	.7167	.7167	.7545	.6173	.7545	.7167
22	.7167	.6036	.7167	.6036	.5487	.7167	.6413
23	1.773	1.773	.4904	.4527	.4115	1.5466	1.6221
24	1.6118	1.773	1.6221	.415	.3772	.3772	1.5089
Max	2.8121	2.9424	2.9801	2.9424	2.7161	2.6749	2.9424
Min	.2641	.1886	.3018	.2641	.3086	.2263	.2263
Avg	1.0234	1.0468	1.3778	1.3135	1.4215	.8906	1.0688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 303 / Tathawada Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3018	.9808	1.1317		.2058	.2641
2	.2743	.3018	.9808	1.0562		.2058	.2641
3	.2743	.3018	.9808	1.0562	1.1317	.2058	.2641
4	.2743	.3018	1.0562	1.0562		.2401	.3018
5	.3429	.3772	1.1694	1.1317		.2743	.3395
6	.4458	.4527	1.3203	1.3957		.3772	.415
7		.4527	1.8484	1.9239	1.773	.4458	.4904
8	.4115	.415	1.9616	2.037	1.8861	.3772	.3018
9	2.1125	2.0748	.3018	.3395	.3018	1.9204	2.0748
10	2.4897	2.1502	.2263	.2263	.2401	2.0576	2.4143
11	2.452	2.4143	.3018	.2641	.2401	2.3011	2.5652
12	2.3765	2.3765	.3018	.3018	.2401	2.452	2.3011
13	2.2634	2.3388	.3018	.2641	.2743	2.3765	2.0748
14	2.2257	2.2634	.2641	.2641	.2401	2.3011	2.2257
15	2.2634	2.0748	.3018	.2641	.2058	2.1879	2.1502
16	2.1502	1.9993	.3018	.2641	.2401	2.0748	2.1879
17	.3018	.2641	.3018	.3018	.2401	.3018	.2263
18	.3018	.3018	.3018	.2641	.2743	.3018	.2641
19	.4527	.415	.415	.3395	.3429	.4527	.415
20	.415	.415	.4527	.415	.3772	.415	.4527
21	.415	.415	.415	.415	.3429	.415	.415
22	.3772	.3395	.3772	.3772	.3086	.3772	.3772
23	.2641	.3018	1.2449	1.3203	1.2003	.3395	.2641
24	.2743	.3018	.2641	1.2449	1.2071	1.166	.3018
Max	2.4897	2.4143	1.9616	2.037	1.8861	2.452	2.5652
Min	.2641	.2641	.2263	.2263	.2058	.2058	.2263
Avg	1.0188	.9730	.6822	.7356	.5825	.9905	.9730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 304 / Wathar-N Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1509	.1886	.1886		.1715	.1886
2	.1372	.1509	.1886	.1886		.1715	.1886
3	.1372	.1509	.1886	.1886		.1715	.1886
4	.1372	.1509	.1886	.1886		.1715	.1886
5	.1715	.1886	.1886	.1886		.1715	.2263
6	.2058	.2263	.2641	.2263		.2058	.2641
7	.2743	.2263	.2263	.2263		.2401	.2263
8	.2401	.2263	.2263	.1886	.2263	.1715	.1509
9	.1886	.1886	.2263	.1886	.2263	.1715	.1886
10	.1509	.1886	.1886	.2263	.2401	.1715	.1886
11	.1886	.1886	1.3203	.2263	.2058	.1509	.1886
12	.1886	.1509	.1886	.2263	.2058	.1509	.1886
13	.1886	.1509	.1886	.1886	.1715	.1509	.1886
14	.1886	.1509	.1509	.1886	.2058	.1509	.1886
15	.1886	.1509	.2263	.1886	.2058	.1509	.1886
16	.1886	.1509	.1509	.1509	.2058	.1509	.1509
17	.1886	.1509	.1886	.1132	.1372	.1509	.1509
18	.1886	.1886	.2263	.1509	.1715	.1509	.1886
19	.3395	.3018	.2641	.3018	.2743	.3018	.2641
20	.3395	.3395	.3772	.3395	.3086	.3018	.3018
21	.3018	.3395	.3018	.3018	.2743	.3018	.3018
22	.2641	.3018	.2641	.2263	.2401	.2263	.2263
23	.1886	.2263	.2263	.2263	.2058	.1886	.1886
24	.1372	.1509	.1886	.1886	.1886	.1715	.1886
Max	.3395	.3395	1.3203	.3395	.3086	.3018	.3018
Min	.1372	.1509	.1509	.1132	.1372	.1509	.1509
Avg	.2025	.1996	.2641	.2090	.2173	.1882	.2043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 305 / Upalawe Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0754	.0377	.0377		.0343	.0377
2	.0343	.0754	.0377	.0377		.0343	.0377
3	.0343	.0754	.0377	.0377		.0343	.0377
4	.0343	.0754	.0754	.0377		.0686	.0754
5	.0686	.1132	.0754	.1132		.0686	.0754
6	.1372	.1509	.1509	.1509		.1372	.1509
7	.1715	.1509	.1509	.1886		.1372	.1509
8	.1372	.1509	.1886	.1132	.1132	.1029	.1132
9	.1132	.1509	.1132	.0754	.0754	.1372	.0754
10	.1132	.1132	.1509	.1132	.0686	.0686	.1132
11	.1132	.0754	.1132	.1509	.0686	.0754	.1132
12	.1132	.0377	.1509	.1509	.0686	.0754	.0754
13	.1132	.1132	.1509	.0377	.0686	.0754	.0377
14	.1132	.1132	.1509	.1132	.0343	.1132	.1132
15	.1132	.0754	.0377	.0754	.0686	.1509	.1132
16	.1132	.0377	.1132	.0754	.0343	.1509	.1132
17	.1132	.0377	.1132	.0754	.0343	.1509	.1509
18	.1132	.0754	.0754	.0377	.0686	.1509	.0754
19	.1132	.0754	.1132	.0754	.1029	.1132	.1132
20	.1132	.1132	.1509	.1132	.1029	.1132	.1509
21	.1132	.1132	.0754	.1132	.1029	.1132	.1509
22	.1132	.1132	.0754	.0754	.1029	.0754	.1132
23	.0754	.0754	.0754	.0377	.0686		.0754
24	.0343	.0754	.0377	.0754	.0377	.0343	.0377
Max	.1715	.1509	.1886	.1886	.1132	.1509	.1509
Min	.0343	.0377	.0377	.0377	.0343	.0343	.0377
Avg	.0978	.0943	.1022	.0880	.0718	.0963	.0959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254051 / WAKHARI

Feeder No / Name : 306 / Tathawada Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1132	.1132	.1132		.1029	.1132
2	.0686	.1132	.1132	.1132		.1029	.1132
3	.0686	.1132	.1132	.1132		.1029	.1132
4	.1029	.1509	.1509	.1132		.1029	.1509
5	.1372	.1886	.1509	.1886		.1372	.2263
6	.2058	.2641	.2641	.2641		.2401	.2641
7	.2401	.1132	.2641	.3018		.2058	.2641
8	.1715		.1886	.2641	.1886	.2058	.1509
9	.1509	.1509	.1132	.1886	.1132	.1372	.1132
10	.0754	.1132	.0754	.1132	.1029	.1029	.0754
11	.1132	.0754	.1132	.0754	.1029	.1132	.0754
12	.1132	.1132	.1132	.1132	.1029	.1132	.0754
13	.1132	.1132	.1132	.1132	.1029	.1132	.0754
14	.1132	.0754	.0754	.0754	.0686	.1132	.0754
15	.1132	.0754	.0754	.0754	.0686	.0754	.0754
16	.1132	.0754	.0754	.0754	.0686	.0754	.0754
17	.1132	.0754	.0754	.0754	.1029	.0754	.1132
18	.1132	.1132	.1509	.1132	.1372	.0754	.1509
19	.2263	.1886	.2263	.1886	.2058	.1886	.1886
20	.2641	.1886	.2641	.1886	.2743	.2263	.2263
21	.2641	.2263	.2263	.1886	.2058	.2641	.2263
22	.1886	.1886	.1886	.1886	.1715	.1886	.1886
23	.1509	.1509	.1509	.1132	.1372	.1509	.1509
24	.1029	.1132	.1132	.1132	.1132	.1372	.1132
Max	.2641	.2641	.2641	.3018	.2743	.2641	.2641
Min	.0686	.0754	.0754	.0754	.0686	.0754	.0754
Avg	.1428	.1345	.1462	.1446	.1334	.1396	.1415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 301 / 22 Kv Giravi Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058		1.1458	1.4403		.2743
2	.2058		1.1458	1.3717		.2743
3	.2058		1.1949	1.3717		
4	.2401		1.7177	1.3717		
5	.2743		2.1879	1.5089		
6	.4458		2.6406	1.6804		
7	.4458		3.131	2.572		
8	.3429			2.7435		
9	2.5034		.415			2.6063
10	2.5377		.4108			2.6063
11		2.5652	.3429		.3086	
12		2.5393	.3086		.3086	
13		2.5274	.3086			2.4348
14		2.4897	.3086			2.2634
15		2.4394	.2401			2.332
16		2.5652	.3086		.2743	1.8519
17		.3326	.3429		.3429	
18		.4435	.3772		.3772	.3086
19		.5544	.4801		.4801	.4458
20		.5487	.5144		.5144	.4115
21		.5228	.4801		.4801	.4115
22		.4481	.4115		.4115	.0343
23		.3696	1.4746		1.4403	.2743
24	.4115		.2587	1.4746		.2743
Max	2.5377	2.5652	3.131	2.7435	1.4403	2.6063
Min	.2058	.3326	.2401	1.3717	.2743	.0343
Avg	.7108	1.4112	.8759	1.7261	.4938	1.1202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 303 / 22 Kv Giravi Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1448	.1715			
2	.1715		.1494	.1715			
3			.1448	.1715			
4	.1715		.1829	.1715			
5	.1715		2.809				
6	.3086		.3658				
7	.3772		.3361				
8	.2401		.2987				.2401
9	.2058		.2241				.2058
10	.2058		.2241				.1715
11		.1867	.1715		.1029		
12		.1867	.1715		.1372		.1715
13		.1478	.2058		.1372		.1372
14		.1478	.1372		.1372		.1372
15		.1478	.1715		.1372		.1372
16		.1478	.1715		.1715		.1372
17		.1848	.2058		.1715		
18		.2587	.2058		.2058		.2058
19		.3696	.3086		.0309		.3086
20		.3696	.3429		.3086		.3086
21			.3086		.0274		.3429
22		.2614	.2743		.2401		.3086
23		.181	.2058		.1715		.2058
24	.1715		.1478	.1715		.1372	
Max	.3772	.3696	2.809	.1715	.3086	.1372	.3429
Min	.1715	.1478	.1372	.1715	.0274	.1372	.1372
Avg	.2195	.2158	.3295	.1715	.1522	.1372	.2156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 304 / 22 KV Wadale AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573		.2587	.3429		
2	.823		.2614	.3429		
3	.823		.2614	.3429		
4	.1715			.3429		
5	.1715					
6	.3429		.5228			
7	.4115					
8	2.2634		.4854			
9	.2743		1.9993			.3086
10	.2743		1.9547			.2743
11			1.9547		1.8176	.2743
12		.2218	1.6804		1.7147	.3086
13		.2957	1.3717		1.5432	.2058
14		.2957			1.3717	.2058
15		.2561	1.5432		1.3375	.2058
16			1.166		1.3375	.2401
17		.2957	.3086		.2743	.2401
18		.4066	.3086		.2058	.2401
19		.4435	.4115		.4115	.4801
20		.4854	.4458		.4458	.4801
21		.4435	.4458		.4115	.4115
22		.3734	.3772		.2743	
23		.9808	.3086		.2743	
24	.8573		.9054	.3429		
Max	2.2634	.9808	1.9993	.3429	1.8176	.4801
Min	.1715	.2218	.2587	.3429	.2058	.2058
Avg	.6609	.4089	.8486	.3429	.8784	.2981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 305 / 22 KV Dudhebavi AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058		.1494				
2	.2058		.1086	.1372			.2058
3	.2401		.1109	.1372			.2058
4			.1097	.1372			.2401
5	.2743		.1867				.3086
6	.3772		.2587				.3429
7	.6859		.2957				.6516
8	.7545						.7545
9	.1715		.5601				.1372
10	.1372		.5658				.1372
11			.3429		.3429		.1372
12		.1097	.3429		.3429		.1372
13		.1086	.3086		.3086		.1029
14		.1109	.2743		.2401		.1372
15		.1086	.3086		.3429		.1029
16		.1086	.3772		.4458		
17		.1109	.1029		.1372		.1029
18		.1478	.1372		.1715		.1372
19			.2401		.1715		.2058
20			.2401		.2058		.2058
21			.2058		.1715		.2058
22		.2241	.1715		.1372		
23		.2587	.1372		.1029		.2401
24	.2058		.2241	.1372		.1029	
Max	.7545	.2587	.5658	.1372	.4458	.1029	.7545
Min	.1372	.1086	.1029	.1372	.1029	.1029	.1029
Avg	.3258	.1431	.2504	.1372	.2401	.1029	.2349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254058 / 33/22 KV Saskal

Feeder No / Name : 306 / 22 KV Dudhebavi Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715			.1715			
2	.1715			.1715			
3				.1715			
4			.1867	.1715			
5				.3772			
7				.3772			
8							.2401
9	.2743						.1715
10	.2058		.1867				.1715
11			.2058				.2058
12		.2195	.1715		.1715		.2058
13		.2172	.1715		.1715		
14		.2241	.1715		.1372		.1715
15		.1867	.2058		.2058		.1715
16		.1867	.1715		.2058		.1715
17		.2987	.2058		.2058		.2058
18		.2987	.2058		.1372		.2058
19		.4108	.3429		.3086		.3429
20		.3696	.3429		.3772		.3429
21		.3361	.3086		.2058		.3086
22		.2507	.2743		.2743		.2743
23		.1867	.2058		.2058		.2401
24	.1715		.181	.1715		.1715	
Max	.2743	.4108	.3429	.3772	.3772	.1715	.3429
Min	.1715	.1867	.1715	.1715	.1372	.1715	.1715
Avg	.1989	.2655	.2211	.2303	.2172	.1715	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 301 / JANAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4394	2.2986	.2893	.2457	.2428	2.2301	2.7485
2	2.4391	2.2402	.286	.241	.2205	2.2303	2.6679
3	2.4185	2.2125	.2835	.24	.2362	2.2458	2.6188
4	2.4832	2.1806	.2986	.2425	.2498	2.3155	2.694
5	2.5676	2.3232	.3134	.2785	.2601	2.494	2.759
6	2.8668	2.9725	.3643	.3424	.3424	3.1619	3.0446
7	3.7502	3.6098	.4001	.378	.1463	3.8006	3.8553
8	3.9162	3.8253	.3895	.3348	.3857	4.0255	4.0357
9	1.5788	1.2735	3.5558	3.4877	3.7531	1.4725	1.4238
10	.3918	.2473	4.1981	4.4376	4.6727	.0861	.253
11	.351	.2429	4.2784	4.2216	4.8464	.2536	.1903
12	.3243	.1675	4.3796	4.6792	4.484	.2181	.1525
13	.3173	.1736	3.9868	4.6978	4.0624	.231	.2463
14	.3198	.1583	4.3239	4.3911	3.8841	.2111	.2428
15	.3213	.1263	4.0796	4.0836	2.7564	.2257	
16	.3127	.228	1.6217	1.5104	3.1315	.061	.1338
17	.1242	.2319	.753	1.0448	1.1911	.2295	.2239
18	.2405	.2124	.3085	.242	.2566	.3183	.3089
19	.3263	.336	.354	.3739	.4084	.4303	.4218
20	.3764	.3602	.3751	.3928	.4265	.4532	.4004
21	.3692	.3485	.3611	.3738	.3745	.4033	.4062
22	.355	.3252	.3568	.3389	.3246	.3368	.3975
23	2.1263	2.4054	.3038	.2713	.2784	2.5876	2.5838
24	2.392	2.365	1.5792	.2472	.281	1.2149	2.7476
Max	3.9162	3.8253	4.3796	4.6978	4.8464	4.0255	4.0357
Min	.1242	.1263	.2835	.24	.1463	.061	.1338
Avg	1.3795	1.2860	1.5600	1.5457	1.5506	1.3015	1.5025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 302 / SATE PHATTA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3633	.3273	2.599	3.1253	2.0822	.4262	.4416
2	.36	.4009	2.5591	3.1097	3.0777	.4196	.4302
3	.3771	.4244	2.5704	3.0612	3.0216	.4458	.4675
4	.4483	.4344	2.6365	3.0794	3.0129	.4614	.5064
5	.5592	.5593	2.9812	3.279	3.1184	.525	.5861
6	.7004	.685	3.2466	3.7715	3.5385	.6733	.7084
7	.7948	.7817	4.1396	4.779	2.3396	.7695	.8726
8	.7483	.7369	4.3649	4.9169	2.4478	.7309	.7217
9	4.5438	4.5542	2.1525	2.1021	1.9677	4.1158	4.4161
10	5.1535	5.2192	.5017	.4287	.5785	5.4931	5.1907
11	5.2132	4.9922	.4112	.3576	.4915	5.4641	5.5811
12	5.3009	3.8699	.3994	.3852	.449	5.1391	5.3572
13	5.2785	3.9119	.4052	.4056	.4151	3.0381	4.9093
14	5.0288	4.5369	.4302	.4685	.4034	4.9014	4.5439
15	5.0178	4.8285	.4077	.4492	.4519	4.952	4.0925
16	5.044	4.8337	.4179	.4325	.5173	4.4871	4.0311
17	2.6597	2.809	.3924	.2225	.482	1.7587	1.8456
18	.4685	.4786	.4154	.6023	.5156	.4431	.6381
19	.6832	.4009	.6707	.6165	.6846	.6538	.6834
20	.6367	.6409	.6835	.9977	.7173	.6604	.9631
21	.5832	.6163	.574	.6603	.6487	.6166	.6255
22	.5167	.5619	.5312	.6081	.5663	.535	.5565
23	.4067	.4588	3.0392	3.088	2.5516	.4944	.4671
24	.3467	.5697	1.8985	1.9649	2.8924	1.4172	.4268
Max	5.3009	5.2192	4.3649	4.9169	3.5385	5.4931	5.5811
Min	.3467	.3273	.3924	.2225	.4034	.4196	.4268
Avg	2.1347	1.9847	1.6012	1.7880	1.5405	2.0259	2.0443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 254074 / 33/22 KV Rajale

Feeder No / Name : 303 / RAJALE GAON

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2633	.6648	.6572	.6549	.3384	.6077	.6629
2	.2569	.647	.6187	.6646	.6421	.5692	.6412
3	.2824	.6493	.6777	.6615	.6483	.5716	.6421
4	.3026	.6982	.707	.7406	.7666	.6223	.6899
5	.3527	.9197	.8439	.9014	.8831	.856	.7908
6	.4427	1.1471	1.1038	1.1365	1.1688	1.0546	1.1926
7	.4308	1.2953	1.2613	1.2993	.6775	1.3302	1.4071
8	.3598	1.2726	1.1526	1.2427	1.3238	1.1779	1.2242
9	.2961	.9738	.8825	.9323	.948	.7925	.9196
10	.2573	.7833	.6943	.7549	.7823	.6252	.7674
11	.2399	.7593	.6223	.6191	.7088	.6	.6928
12	.2315	.7214	.6347	.6474	.6708	.6209	.6903
13	.2073	.6606	.5772	.6177	.6646	.3163	.6919
14	.1901	.6991	.4803	.6183	.5705	.5672	.6643
15	.1795	.7192	.5196	.6057	.633	.6152	.6953
16	.2044	.6662	.5352	.5883	.7288	.5874	.6525
17	.1082	.6839	.5824	.3224	.7978	.7373	.6409
18	.7822	.7788	.6704		.9265	.7921	.695
19	1.1686	.9431	1.0175	.4952	1.1209	.9903	1.1668
20	1.2252	1.269	1.1719	.7095	1.2307	1.0347	.6531
21	1.1824	1.197	1.1327	1.2067	1.1413	.9752	1.1182
22	1.0704	1.1204	1.082	1.0643	1.0232	.8724	.9884
23	.7888	.8826	.8451	.818	.8365	.7637	.847
24	.4837	.7254	.7016	.6777	.6837	.6995	.7258
Max	1.2252	1.2953	1.2613	1.2993	1.3238	1.3302	1.4071
Min	.1082	.647	.4803	.3224	.3384	.3163	.6409
Avg	.4711	.8699	.7988	.7817	.8298	.7658	.8275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 258024 / 220 kv surawadi EHV

Feeder No / Name : 402 / 33 kv tata cumines ltd

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 258024 / 220 kv surawadi EHV

Feeder No / Name : 405 / 33 kv cummins india ltd NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

PHALTAN DIVISION[513]

PHALTAN[113]

BU 5967

Substation No/ Name :- 258024 / 220 kv surawadi EHV

Feeder No / Name : 406 / 33 KV CUMMINES Technology NON SHEDDABLE EXPRESS HV FEEDERS
indi Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 201 / KATHAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.0111	4.6327	.2789	.0381	.1044	3.9514	3.6839
2	4.8995	4.4373	.2599	.0381	.1044	3.6534	3.6481
3	4.7108	4.2901	.157		.0046	3.4808	3.7045
4	4.2734	4.0955				3.3973	3.4218
5	4.2227	4.0185				3.2423	3.4248
6	4.2071	3.9697				3.0933	3.0381
7	4.6483	4.4349				3.4644	3.5955
8	5.0382	4.569				3.7795	3.6557
9	2.5972	2.4051	5.1006	5.1849	4.827	2.0149	1.8595
10			6.3107	1.1203	6.5254		
11			6.4449	3.3669	5.772		
12			5.996	3.6245	6.4506		
13			5.4687	3.4842	6.275		
14			6.0597	2.9416	6.0151		
15	.1349	.1547	5.4763	2.8182	5.3319	.0343	.0781
16	.1761	.2873	5.256	3.3379	4.4185	.0633	.0781
17	.1406	.2698	2.7824	3.2316	1.6084	.0381	.0857
18	.0937	.82	.1143	.0918	.0781	.125	.149
19	.0937	.1555	.1334	.123	.0937	.2149	.277
20	.0937	.1829	.1334	.1867	.1364	.1173	.2831
21	.0937	.2408	.1143	.1639	.1531	.1189	.2675
22	.1013	.2774	.1143	.2416	.1196	.2103	.1364
23	4.51	.2806	.1143	.1684	3.9567	3.7171	3.5704
24	4.9211	2.3633	.0995	.1319	2.3206	3.9796	3.6069
Max	5.0382	4.6327	6.4449	5.1849	6.5254	3.9796	3.7045
Min	.0937	.1547	.0995	.0381	.0046	.0343	.0781
Avg	2.6298	2.2045	2.6534	1.6830	2.8577	2.0366	2.0297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 202 / EKAMBE -SANGVI- AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2686	.0469	2.8818	3.1158	3.1337	.0781	.1143
2	.1661	.0469	2.8106	3.0358	3.046	.0781	.0953
3	.1585		2.7645	2.9748	2.9286		
4			2.6718	2.9363	2.8562		
5			2.6376	2.9431	2.7995		
6			2.6452	3.046	2.8175		
7			3.3387	3.8108	3.5688		
8			4.0622	4.2078	3.9564		
9	4.566	3.7502	2.1445	2.1597	2.0774	3.437	3.2983
10	5.6227	5.1623				4.5862	4.6853
11	5.9076	5.6981				5.4039	4.6647
12	5.7689	5.6093				5.1708	4.3377
13	5.2355	5.2774				4.7493	4.1435
14	4.8613	4.9452				4.6174	3.9007
15	4.467	4.6319	.1029		.0953	4.4719	3.7205
16	4.2524	4.5325	.1943		.0625	4.2841	3.6778
17	2.0512	2.332	.2484	.0872	.064	2.3045	2.0165
18	.0469	.0953	.1661	.0857	.0781	.1143	.1029
19	.0469	.0953	.1326	.1029	.0781	.1143	.1075
20	.0469	.0953	.125	.112	.0781	.1509	.1029
21	.0469	.0953	.1143	.1029	.1345	.2225	.1029
22	.0469	.0953	.0953	.0857	.0781	.2667	.1029
23	.0469	2.6948	2.8605	3.1215	.0781	.0949	.0857
24	.0857	1.6107	2.962	3.1634	1.4918	.0781	.0949
Max	5.9076	5.6981	4.0622	4.2078	3.9564	5.4039	4.6853
Min	.0469	.0469	.0953	.0857	.0625	.0781	.0857
Avg	2.2996	2.6008	1.7346	2.0642	1.5486	2.2346	1.9641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 203 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0566	.0373	.0343	.0514	.0566	.0373
2	.0171	.0377	.0373	.0343	.0343	.0377	.0373
3	.0171	.0189	.0187	.0171	.0171	.0189	.0187
4	.0343	.0189	.0373	.0343	.0171	.0189	.0373
5	.0514	.0377	.0187	.0171	.0343	.0566	.056
6	.0343	.0554	.0373	.0343	.0343	.0554	.056
7	.0343	.0366	.0187	.0171	.0514	.0549	.056
8	.0171	.0366	.0373	.0171	.0373	.0549	.0934
9	.056	.0171	.0343		.0373	.0343	.0366
10	.056	.0514	.0514		.056	.0857	.0183
11	.0747	.1886	.1372	.1097	.0747	.0686	.0183
12	.0747	.2058	.1715		.0187	.0857	.1463
13	.1307	.2401	.1372	.2012	.0747	.1715	.1646
14	.0373	.2401	.12		.0747	.1543	.1646
15	.056	.2229	.0514		.056	.1715	.1463
16	.056	.1715	.0686		.0732	.1715	.1097
17	.0549	.2801	.0514	.1543	.0366	.1867	.1029
18	.0739	.2241	.0514	.2229	.0739	.2241	.1715
19	.0739	.2614	.1543	.2058	.0754	.0934	.0686
20	.0566	.0934	.0514	.0686	.0754	.0747	.0514
21	.0566	.0373	.0514	.0514	.0754	.0373	.0343
22	.0566	.0373	.0171	.0343	.0566	.056	.0171
23	.0566	.0373	.0343	.0514	.0754	.0373	.0171
24	.0747	.0566	.0373	.0171	.0514	.0754	.0373
Max	.1307	.2801	.1715	.2229	.0754	.2241	.1715
Min	.0171	.0171	.0171	.0171	.0171	.0189	.0171
Avg	.0535	.1110	.0610	.0735	.0526	.0867	.0707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 204 / EKAMBE -SANGVI- VLG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4328	.4556	.4779	.4412	.4493	.4717	.4493
2	.4051	.426	.4294	.4131	.4207	.4441	.4069
3	.4016	.4222	.4642	.3921	.4157	.4411	.3978
4	.418	.4483	.5015	.4005	.4401	.4614	.4417
5	.5144	.5592	.612	.5342	.5129	.5666	.5384
6	.7853	.7895	.8562	.8597	.7518	.8467	.8128
7	1.1317	1.1519	1.2258	1.2479	1.0841	1.2754	1.1439
8	1.1569	1.1229	1.1587	1.1976	1.198	1.267	1.1096
9	.9667	.903	.9095	.5594	1.0467	.9138	.7986
10	.7118	.6661	.6767	.3685	.7963	.6683	.6832
11	.5799	.5324	.6245	.3597	.5719	.5392	.6143
12	.5087	.5848	.5404	.3216	.6172	.5087	.5655
13	.498	.479	.4542	.2858	.5563	.527	.5552
14	.5076	.4558	.5041	.2389	.5239	.4741	.4855
15	.4813	.4393	.5312	.2778	.5193	.4458	.4744
16	.5023	.5193	.5335	.2919	.5064	.4618	.4885
17	.551	.5334	.5658	.4904	.6462	.5639	.4939
18	.6511	.687	.7232	.6687	.7232	.6939	.6923
19	.996	.9777	1.0437	1.0814	1.0775	.9053	.9861
20	1.1559	1.1614	1.225	1.1995	1.2069	.6961	1.1359
21	1.0684	1.1027	1.1115	1.0951	1.1186	1.0463	1.1108
22	.9599	.9625	1.0205	.9656	.9821	.9453	.9873
23	.6959	.5697	.6771	.6664	.6914	.5316	.6603
24	.4855	.5144	.5205	.479	.5011	.5028	.4474
Max	1.1569	1.1614	1.2258	1.2479	1.2069	1.2754	1.1439
Min	.4016	.4222	.4294	.2389	.4157	.4411	.3978
Avg	.6902	.6860	.7245	.6182	.7232	.6749	.6867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 205 / 11KV KATAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7239	.6896	.5689	.5308	.7771	.6635	.7171
2	.6515	.6515	.5311	.493	.7201	.6066	.6416
3	.6515	.6344	.4553	.5119	.7201	.6066	.6409
4	.7201	.703	.5308	.5685	.7579	.682	.6043
5	.8611	.844	.7198	.7571	.8525	.7956	.8664
6	1.3165	1.3165	1.1434	1.1559	1.2935	1.3264	1.3013
7	1.7337	1.2479	1.5867	1.5276	1.736	1.7438	1.7166
8	1.7756	1.1965	1.515	1.326	1.6446	1.6446	1.5486
9	1.5661	.945	1.291	1.1401	1.4022	1.3622	1.3276
10	1.2003	.9279	.9923	.9542	1.1965	1.1108	1.1035
11	1.0174	.7963	.7681	.8032	1.0106	.9069	
12	.9412	.6725	.7849	.7087	.9161	.8173	.8763
13	.7487	.5791	.6919	.8478	.8596	.7411	.8398
14	.6344	.562	.5791	.6721	.7651	.7411	.8215
15	.3048	.6992	.6523	.727	.6904	.6649	.6721
16	.8859	.8649	.727	.8748	.381	.682	.7636
17	1.0308	.9412	.8017	.9892	1.0075	.8859	.7963
18	1.086	1.0456	1.0313	1.2011	1.1877	1.131	1.0651
19	1.6232	1.4969	1.4023	1.6863	1.6675	1.5269	1.6023
20	1.848	1.7252	1.5735	1.7633	1.8768	2.7824	1.7547
21	1.6347	1.5358	1.4034	1.6305	1.7067	1.6793	1.6175
22	1.4175	1.2706	1.1948	1.2902	1.3845	1.3782	1.2765
23	1.0212	.9296	.8538	.9862	1.0054	.8875	.8898
24	.762	.6687	.6447	.7401	.8152	.7586	.7738
Max	1.848	1.7252	1.5867	1.7633	1.8768	2.7824	1.7547
Min	.3048	.562	.4553	.493	.381	.6066	.6043
Avg	1.0898	.9560	.9351	.9952	1.0989	1.0886	1.0529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254013 / KORAGAON

Feeder No / Name : 206 / Shirambe-Ag

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7661	1.6385	.0572	.0381	.0343	1.2944	1.5074
2	1.749	1.6057	.0572	.0343	.0343	1.2289	1.4746
3	1.7147	1.5729				1.1305	1.4746
4	1.5775	1.4746				1.0159	1.5074
5	1.6289	1.4746				1.1797	1.3435
6	1.5947	1.4419				1.3763	1.2289
7	1.9719	1.7695				1.8515	1.6876
8	2.0233	1.9006				1.9006	1.704
9			2.4177		2.1464		
10			2.8121	2.6707	2.556		
11			2.915	2.5724	2.4741		
12			2.8121	2.4249	2.5888		
13			2.572		2.5953		
14			2.4006	2.0317	2.1956		
15	.0572	.0572	2.332	1.7532	2.0809	.0343	.0469
16	.0572	.0572	2.1948		1.9334	.0343	.0469
17	.0469	.0381	.0381	.0857	.0312	.0381	.0514
18	.0469	.0762	.0343	.0686	.0469	.0762	.0343
19	.0469	.0572	.0343	.0514	.0469	.0762	.0514
20	.0469	.0762	.0343	.0514	.0469	.0762	.0514
21	.0469		.0343	.0514	.0469	.0572	.0343
22	.0469	.0762	.0343	.0343	.0469	.0572	.0343
23	1.704	.0492	.0343	.0343	1.5074	1.5565	1.6461
24	1.7833	.0762	.0492	.0381	.0343	1.3763	1.5238
Max	2.0233	1.9006	2.915	2.6707	2.5953	1.9006	1.704
Min	.0469	.0381	.0343	.0343	.0312	.0343	.0343
Avg	.9950	.7907	1.1591	.7960	1.1359	.7978	.8583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 201 / 11KV CHIMANGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6805	.6878	.7164		.6335		.7164
2	.6626	.6516	.6805	.7164	.6154		.7164
3	.6516	.6335	.6516	.7164	.5792		.7164
4	.6447	.7059	.6516	.7442	.6154		.8507
5	.8775	.8775	.8596	.8417	.8688		.9774
6	1.134	1.2048	1.1694	.9568	1.2226		1.3253
7	1.4883	1.3998	1.5415	1.6126			1.4022
8	1.6655	1.5238	1.6124	1.4352			1.5061
9	1.2757	1.3112	1.4373	1.2757		1.2226	1.2757
10	1.0745		1.3969	1.286	1.2536	1.0566	.8417
11	1.0745		1.2894	1.4148	1.0985	.8775	.8417
12	1.0387		1.0288	1.1283	.9922	.788	1.0029
13	.8238		1.0745	1.0208	.9568	.703	.985
14	.9313			.0895	1.0517	.7164	.9671
15	.9671		1.0745	.9313	1.1163	.7164	.9671
16	.9671		1.1462	.9671	1.0277	1.0208	1.0387
17	1.0566		.9492	1.0208	1.2226	.7164	.9492
18	1.2757	.985	1.0454	.724	1.182	1.0454	1.0808
19	1.5769	1.4175	1.5043	1.4529		1.3672	1.5947
20	1.5415	1.7541	1.701	1.6478		1.5238	1.5592
21	1.5238	1.5581	1.5203			1.3434	1.5061
22	1.2357	1.2715	1.1871			1.1999	1.2178
23	.7701	1.0454				.7796	.7522
24	.6984	.724	.7522		.6697		.7442
Max	1.6655	1.7541	1.701	1.6478	1.2536	1.5238	1.5947
Min	.6447	.6335	.6516	.0895	.5792	.703	.7164
Avg	1.0682	1.1095	1.1359	1.0517	.9441	1.0051	1.0640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 202 / 11 KV CHIMANGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2717	1.2971	.0924	.1448	.0732	1.0004	1.2178
2	1.1869	1.2269	.0924	.1448	.0732	.9774	1.1641
3	1.1317	1.2048				.9602	1.1641
4	1.0974	1.1694				.9431	1.1517
5	1.0173	1.1163				.9496	1.1999
6	1.1191	1.0277				.9835	1.2536
7	1.2763	1.3112				1.1736	1.382
8	1.3923	1.5061				1.2929	1.4723
9			1.6907	1.9136			
10		2.7092	1.7661	1.8519	1.8229		
11			1.8004	1.8861			
12			1.749	1.5604			
13		2.6749	1.6804	1.5432	1.7703		
14			1.5432	1.5432	1.8755		
15	.0075	2.6578	1.4746	1.3375	1.9845	.168	.112
16	.0934	2.8121	1.3375	1.2689	1.8861	.1494	.112
17	.1494	.1307	.1494	.168	1.4529	.0747	.1307
18	.0914	.0739	.1448		1.3077	.1086	.1097
19	.0914	.0914	.1417		.0924	.1086	.1097
20	.0914	.0914	.1433		.0924	.1086	.0914
21	.0914	.0924	.1448		.0924	.1097	.0914
22	.0914	.0924	.1433		.0924	.1086	.0914
23	1.3146	.0924			.9724	1.2934	1.258
24	1.291	1.3203	.0924	.1463	.0914	1.0059	1.2536
Max	1.3923	2.8121	1.8004	1.9136	1.9845	1.2934	1.4723
Min	.0075	.0739	.0924	.1448	.0732	.0747	.0914
Avg	.7114	1.1349	.8345	1.1257	.9120	.6398	.7425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 203 / 11 KV Khed Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
1			1.3828
2			1.2967
3			1.2784
4			1.2925
5			1.6141
6			2.359
7			3.1592
8			3.1505
9			1.5516
10	1.2536		
11	1.1999		
12	1.0924		
13	.9134		
14	.8417		
15	.8059		
16	.7522		
19		2.0164	
20		3.2629	
21		3.0799	
22		2.774	
23		2.207	
24		.913	.6984
Max	1.2536	3.2629	3.1592
Min	.7522	.913	.6984
Avg	.9799	2.3755	1.7783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 204 / 11 KV Khed Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1022	1.134	.0554	.1086	.0732	.9665	1.0745
2	1.0682	1.1694	.0554	.1097	.0732	.9496	1.0277
3	1.0631	1.134				.9431	1.0387
4	1.046	1.0985				.9259	1.0745
5	1.0682	1.0387				.9774	1.0745
6	1.1191	1.1104				1.0395	1.1517
7	1.326	1.3672				1.2742	1.3112
8	1.3426	1.4575				1.4089	1.5592
9			1.5415	1.7364			
10		1.8861	1.7318	1.7147	1.9105		
11		2.0576	2.2462	2.1434	2.0332		
12		2.1948	1.9033	1.989	2.0683		
13		1.8004	1.8861	1.8861			
14		1.7833	.1852	1.8519			
15	.0747	1.8519	1.8004	1.5432	1.858	.0934	.112
16	.0747		1.7318	1.406	1.893	.0934	.112
17	.0934	.0934	.112	.0747	1.9909	.0747	.0934
18	.0732	.0739	.1086	.0732	1.4922	.0724	.0732
19	.0732	.0739	.1075	.0732	.0554	.0724	.1097
20	.0732	.0739	.1063	.0732	.0739	.0709	.1097
21	.0732	.0739	.1063	.0732	.0739	.069	.0914
22	.0732	.0554	.1086	.0732	.0554	.0724	.0914
23	1.0277			.0732	.9389	1.1694	1.2403
24	1.1233	1.0808	.0554	.1097	.0732	.9724	1.1104
Max	1.3426	2.1948	2.2462	2.1434	2.0683	1.4089	1.5592
Min	.0732	.0554	.0554	.0732	.0554	.069	.0732
Avg	.6608	1.0766	.8142	.8396	.9775	.6248	.6920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 205 / 11KV Shendurjane AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.0732	1.3226	1.4175	1.5775	.1478	.1448
2	.1478	.0732	1.2717	1.4175	1.6301	.1478	.1448
3			1.2346	1.4175	1.5415		
4			1.2346	1.5043	1.5061		
5			1.2717	1.5249	1.4883		
6				1.6126	1.5415		
7			1.861	2.073			
8			2.1714	1.2403			
9	1.873	2.1628				2.1051	2.2148
10	2.0748					2.6749	2.3148
11	2.3491					.2743	2.4863
12	2.4348					2.5377	2.3491
13	2.2462					2.3148	2.1776
14	2.2291					2.2291	2.1434
15	.2212	.0934	.0747	.0747	.0886	2.1776	2.0062
16	2.1776	.112	.0747	.0934	.0905	2.0919	2.0405
17	.0747	.0934	.056	.0747	.0905	.0934	.0934
18	.0554	.1294	.0905		.2587	.1379	.0914
19	.0554	.1663	.0886		.2033	.1433	.0549
20	.0554	.1663	.1448			.1448	.0554
21	.0554	.1663	.1629		.1663	.1448	.0554
22	.0554	.1663		.0554	.1663	.1448	.0554
23	.0732	1.3077		1.6301	.1463	.1463	.0554
24	.1478	.0732	1.326	1.4506	1.5769	.1478	.1448
Max	2.4348	2.1628	2.1714	2.073	1.6301	2.6749	2.4863
Min	.0554	.0732	.056	.0554	.0886	.0934	.0549
Avg	.9152	.3680	.8257	1.1133	.8048	.9891	1.0349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

KOREGAON[119]

BU 0949

Substation No/ Name :- 254062 / 33/11KV WADACHIWADI S/STN

Feeder No / Name : 206 / 11KV Bhatamwadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0914	.7969	.9036	1.0387	.0924	.1075
2	.0924	.0914	.78	.8859	.9671	.0924	.1063
3			.7716	.8954	.9313		
4			.7716	.9313	.8954		
5			.78	.9671	.815		
6			.8139	1.0454	.8505		
7			.9724	1.2269			
8			1.094	1.3112			
9	1.1437	1.2226				1.2929	1.3112
10	1.8861					1.4746	1.286
11	1.5089					1.3889	1.3375
12	1.6804					1.406	1.3375
13	1.1831					1.4232	1.3032
14	1.166					1.4403	1.3032
15	1.166	.1867	.0934	.0934	.1612	1.2517	1.286
16	1.1488	.2427	.112	.112	.1254	1.0288	1.286
17	.0934	.0934	.1307	.1494	.1267	.112	.112
18	.1463	.1109	.124	.1448	.1341	.1075	.1463
19	.1448	.128	.124	.1448	.1294	.1086	.181
20	.1448	.128	.1254	.1448	.1109	.1075	.181
21	.128	.1109	.1267	.1629	.1109	.1086	.181
22	.128	.1109	.1254	.1629	.1109	.1063	.1646
23	.128	.7712		1.0454	.1097	.1097	.128
24	.0924	.0914	.8048		.9922	.0924	.1075
Max	1.8861	1.2226	1.094	1.3112	1.0387	1.4746	1.3375
Min	.0924	.0914	.0934	.0934	.1097	.0924	.1063
Avg	.6708	.2600	.5028	.6075	.4756	.6524	.6592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 201 / TARAGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1619	1.2146	1.4373	1.1574	.144	.1619
2	.1698	.1457	1.166	1.3435	1.0669	.144	.1619
3	.1698	.1457	1.1336	1.2342	1.0364	.144	.1457
4	.1698	.1457	1.1203	1.2342	1.0212	.144	.1457
5	.1886	.1619	1.1683	1.3123	1.0648	.176	.1943
6	.3018	.2429	1.3603	1.4723	1.2651	.2401	.2753
7	.3772	.3077	1.668	1.6872	1.4706	.3201	.3239
8	.4961	.2915	1.587	1.6716	1.5524	.3361	.2591
9	2.1052	2.1956	.2241	.208	.2721	1.8564	2.0243
10	2.3482	2.1445	.176	.208	.16		2.1538
11	2.2565	2.0645	.192	.176	.032	2.1628	2.1376
12	2.0153	1.8976	.176	.176	.16	1.9364	2.0729
13	1.8591	1.7341	.192	.208	.2881	1.8724	1.9595
14	1.7185	1.7604	.208	.2561	.2561	1.8947	1.8623
15	1.6716	1.7604	.2401	.2401	.2241	1.7652	1.749
16	1.6872	1.656	.2743	.2561	.208	1.7604	1.8299
17	.2561	.2591	.2743	.2865	.208	.2753	.2012
18	.2401	.2591		.2926	.144	.1943	.2218
19	.4001	.4372	.5041	.4338	.4481	.421	.4715
20	.4961	.4858	.5658	.5847	.4961	.5182	.5847
21	.4801	.4588	.5281	.5281	.4641	.502	.547
22	.3841	.3887	.4338	.4527	.3841	.3725	.4338
23	.2267	1.2955	1.5524	1.4089	.2241	.2267	.2641
24	.2075	.1781	1.2955	1.5023	1.2492	.16	.1781
Max	2.3482	2.1956	1.668	1.6872	1.5524	2.1628	2.1538
Min	.1698	.1457	.176	.176	.032	.144	.1457
Avg	.8506	.8574	.7502	.7754	.6189	.7638	.8483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 202 / KIROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.773	1.8099	.1646	.1524	.1509	1.6118	1.2894
2	1.6476	1.7375	.1646	.1524	.132	1.4148	1.2536
3	1.5939	1.6832	.1629	.1524	.132	1.3611	1.182
4	1.576	1.6651	.1629	.1524	.132	1.3073	1.1641
5	1.6297	1.647	.181	.1509	.1698	1.2715	1.1283
6	1.7375	1.7375	.2715	.3239	.2452	1.3969	1.1584
7	1.8983	1.9728	.4207	.4715	.4338	1.6118	1.3394
8	2.0271	2.0814	.4207	.3772	.3961	1.7013	1.3937
9	.3018	.2829	2.1719	2.7938	2.6505	.2149	.2353
10	.1698	.2075	2.8054	2.9371	3.152		.2149
11	.132	.168	2.914	.2507	2.8475	.1791	.1791
12		.2054	3.0407	2.758	2.9191	.1509	.2328
13		.1867	2.7692		2.6505		.2328
14	.1698	.2054	2.9683	2.5789	2.7221		.2328
15	.1307	.2054	2.8416	2.3998	2.0774		.2149
16	.2452	.2054	.2195	2.3461	1.8804	.2743	.197
17	.2172	.2378	.2195	.2033	.2149	.2534	.2033
18	.2534	.2353	.2534	.2402	.2328	.2353	.2402
19	.4207	.4344	.4294	.4338	.4119	.3982	.4338
20	.4887	.5068	.4715	.5093	.5014	.4706	.4715
21	.4706	.4525	.4338	.4715	.4656	.4525	.4715
22	.3982	.4207	.3584	.415	.394	.362	.415
23	2.1357	.2561	.2286	.2075	2.0058	1.4506	1.39
24	1.9163	2.0814	.1829	.1715	.1698		1.4506
Max	2.1357	2.0814	3.0407	2.9371	3.152	1.7013	1.4506
Min	.1307	.168	.1629	.1509	.132	.1509	.1791
Avg	.9697	.8594	1.0107	.8978	1.1286	.8483	.6969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 203 / WATHAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3772	2.3807	2.3371	2.3703	.3395	.3395
2	.3395	.3772	2.3137	2.2542	2.3205	.3395	.3395
3	.3395	.3772	2.2377	2.0645	2.2874	.3395	.3224
4	.3395	.3772	2.1548	2.0243	2.2542	.3395	.3395
5	.415	.4527	2.1714	2.0645	2.4034	.3961	.3772
6	.6036	.6224	2.3205	2.1714	2.5652	.5847	.6224
7	.7167	.7733	2.6686	2.4577	2.769	.7545	.7167
8	.6224	.6224	2.4697	2.4905	2.8509		.6602
9	3.0178	3.0346	.4854	.5041	.5415	2.3371	2.1548
10	3.1017	3.1017	.4854	.4668	.5041		2.42
11	2.9675	3.0803	.5041	.1494	.4854	2.6852	2.3537
12	2.5232	2.8346	.4294	.168	.462	2.6355	2.4034
13	2.6322	2.4741	.5041	.5041	.4805	2.2775	2.3371
14	3.1017	3.0001	.4481	.499	.5175	2.4034	2.0388
15		2.8837	.5041	.499	.5304	2.1464	2.0388
16	2.7854	2.8018	.4854	.5228	.5121	2.0056	2.1051
17	.4755	.6224	.4938	.499	.4435	.4854	.4572
18	.439	.5093	.5121	.4251	.499	.4904	.439
19	.8048	.811	.8488	.8488	.8316	.7922	.7922
20	.8779	.9619	.9997	.9808	.9979	.9242	.9431
21	.7611	.9431	.9054	.8488	.9055	.8488	.8676
22	.6802	.7356	.7545	.7356		.7167	.7356
23	.4715	2.4366	2.6155	2.7469	.7947	.4527	.4715
24	.3584	.3961	2.431	2.5526	2.5987	.3772	.3772
Max	3.1017	3.1017	2.6686	2.7469	2.8509	2.6852	2.42
Min	.3395	.3772	.4294	.1494	.4435	.3395	.3224
Avg	1.2484	1.4419	1.3385	1.2840	1.3446	1.1214	1.1105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 204 / ARVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2616	1.3413	.2829	.2858	.2641	.9054	1.1603
2	1.1012	1.0059	.2641	.2858	.2641	.8619	1.0277
3	1.0526	.9997	.2641	.2667	.2641	.8288	.8288
4	1.0202	.9389	.3018	.2667	.2641	.8215	.7956
5	1.0364	1.1317	.3018		.2829	.8619	.8122
6	1.2742	1.2407	.4715		.4527		1.094
7	1.6933	1.6766	.547			1.4089	1.5074
8	1.7772	1.643	.4527		.4527		1.5581
9	.415	.3961	1.9616	1.7404	1.643	.3734	.3641
10	.3018	.3206	2.1293	1.9227	1.7939		.2801
11	.2829	.3018	2.1963	1.9559	1.7436	.3206	.2641
12	.3206	.3018	1.9616	1.6907	1.6409	.3018	.2452
13	.3206	.2829	1.9281	1.5238	1.4752	.2829	.2829
14	.3395	.3395	1.8107	1.5729	1.4089	.2829	.2829
15		.3206	1.6263	1.5402	1.2431	.3206	.3018
16	.3395	.3206	1.6598	1.5249	1.2763	.3395	.2829
17	.3018	.3772	.3547	.3696	.3109	.3326	.2801
18	.3961	.3584	.3547	.3547	.2561	.3395	.2987
19	.6602	.4715	.6979	.6602	.6219	.6224	.6224
20	.7167	.5847	.7356	.7922	.6767	.7922	.7733
21	.7356	.547	.6979	.6979	.695	.7733	.6979
22	.6036	.5658	.5658	.5847	.567	.5847	.6036
23	1.4754	.3772	.3772	.3584	1.073	1.3923	1.4752
24	1.3426	.3961	.3018	.3048	.2829	.9945	1.3426
Max	1.7772	1.6766	2.1963	1.9559	1.7939	1.4089	1.5581
Min	.2829	.2829	.2641	.2667	.2561	.2829	.2452
Avg	.8160	.6767	.9269	.9350	.8240	.6544	.7159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254011 / TARGAON

Feeder No / Name : 205 / PWV EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0895	.052	.0678	.052	.0554	.0526
2	.0895	.0895	.052	.0678	.0514	.052	.0526
3	.1398	.0895	.0514	.0678	.0514	.052	.0526
4	.089	.1276	.0514	.0514	.0514		.0526
5	.089	.1448	.0686	.0514	.0189	.052	.052
6	.0895	.1276	.0514	.0189	.0189	.052	.052
7	.0895	.0895	.0503	.0185	.0185	.052	.0514
8	.1433	.1067	.0187	.0185	.0509		.0503
9	.1448	.144	.0686	.0514	.0693		.0514
10	.0895	.144	.0686	.0514	.052		.0514
11	.144	.0728	.0354	.0343	.0351	.0532	.0343
12	.0486	.0728	.0354	.0351	.0351	.0678	.0343
13	.0076	.0351	.0354	.0156	.0351	.0678	.0158
14	.0076	.0187	.0354	.0171	.0351	.0354	.0158
15		.0187	.0343	.0076	.0351	.0158	.0173
16	.0076	.0187	.0082	.037	.0168	.0158	.0173
17	.0156	.0162	.0082	.0354	.0076	.0133	.0069
18	.0156	.0021	.0076	.0354	.0076	.0135	.0065
19	.0076	.0038	.0076	.0358	.0076	.0057	.0048
20	.0076	.0057	.0076	.0091	.0076	.0055	.0053
21	.0076	.0048	.0076	.0042	.0173	.0048	.0038
22	.0076	.0059	.0076	.0048	.0171	.004	.005
23	.037	.0187	.0526	.0189	.037	.0373	.0532
24	.0457	.0554	.0526	.0678	.0189	.0554	.0526
Max	.1448	.1448	.0686	.0678	.0693	.0678	.0532
Min	.0076	.0021	.0076	.0042	.0076	.004	.0038
Avg	.0614	.0626	.0362	.0343	.0312	.0355	.0330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 201 / PIMPARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.128	.8855	1.1843	1.2003	.1107	.0686
2	.0857	.128	.8855		1.3032	.1107	.0686
3			.8962	1.1961	1.2689		
4			.9069	1.1961	1.3375		
5			.9393	1.21	1.406	.1334	
6			1.3927	1.1822	1.6118		
7			1.4746	1.6091	1.7318		
8			1.6057	1.8244	1.9719		
9	2.0919	1.7924				1.8185	1.8023
10	2.2805	1.8084				1.945	1.9559
11	1.9989	1.9109				2.2291	1.9271
12	1.7204	1.7604			.1524	2.1262	1.6129
13	1.5402	1.4723				1.9204	1.5384
14	1.4746					1.7833	1.3125
15	1.4251	1.4918	.0686	.0791	.1029	1.6118	1.2334
16	1.3443	1.3763	.0857	.1265	.12	1.4232	1.2492
17	.1029	.2267	.1372	.1423	.1715	.1543	.0633
18	.1029	.125	.1543	.1581	.12	.1029	.0633
19	.128	.1372	.0972	.1372	.128		.1029
20	.128	.1387	.1311	.1372	.1423	.1029	.12
21	.128	.1372	.112	.1029	.1265	.0857	.1372
22	.144	.1029	.1006	.12	.1265	.0867	.1543
23	.128	.9488	1.1385	1.3375	.1107	.0686	.12
24	.1029	.1387	1.2125	1.1405	1.3717	.1107	.0686
Max	2.2805	1.9109	1.6057	1.8244	1.9719	2.2291	1.9559
Min	.0857	.1029	.0686	.0791	.1029	.0686	.0633
Avg	.834	.8132	.6791	.7579	.7634	.8847	.7555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 202 / BRAMHAPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.5175	.5014	.4588		.4706	.4656
2	.4115	.4755	.4961	.4481		.4477	.4656
3	.3772	.4755	.4961	.4694	.5144	.443	.4607
4	.4458	.567	.5068	.4755	.5144	.5609	.4706
5	.5487	.6653	.543	.6167	.6193	.6447	.5014
6	.823	.9055	.724	.7773	.8573	.8316	.695
7	.9602	1.0719	.9145	.8962	.9774	1.0679	.7964
8	1.0288	.9774		.8745	.9774	1.0029	.8779
9	.8573	.8775	.9431	.7907	.9088	.8954	.724
10	.823	.7796	.9145	.7042	.8745	.815	.724
11	.6379	.7973	.7888	.7186	.823	.7373	.5731
12		.7712	.7888	.7619	.7888	.6344	.6697
13	.6733	.7087	.8573	.7442	.7545	.6173	.591
14	.6733		.7373	.7888	.6859	.583	.5144
15	.6805	.7796	.7545	.788	.7202	.5658	.5609
16	.7087	.7975	.7545	.6661	.6859	.6001	.6516
17	.8238	.703	.6859	.6554	.7545	.6859	.7042
18	.8688	.6783	.6516	.7209	.7545	.6859	.779
19	1.2127	1.0029	1.0682	1.046	1.0387	1.0974	1.1145
20	1.0974		1.0526	1.0974	1.086	1.1458	1.1831
21	1.0059		.8749	.9774	1.0136	1.0608	1.1317
22	.9328	1.0164	.7935	.8745	.8507	.9145	.9088
23	.6535	.7316	.5693	.6516	.6283	.6516	.6516
24	.463	.7362	.4744			.5121	.5068
Max	1.2127	1.0719	1.0682	1.0974	1.086	1.1458	1.1831
Min	.3772	.4755	.4744	.4481	.5144	.443	.4607
Avg	.7443	.7636	.7344	.7392	.8013	.7363	.6967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 203 / SAP

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.2944	.0686	.0648	.0686	.7926	1.1385
2	1.4746	1.1843	.0686		.0686	.6984	1.1203
3	1.4746	1.0936				.6859	1.1336
4	1.5432	1.0185				.6472	1.1336
5	1.6804	1.0185				.7628	1.1336
6	1.8861	1.1363				.8905	1.3763
7	2.0062	1.7004				1.358	1.5074
8	2.0062	1.5655				1.3735	1.6057
9			2.2611	2.0885	1.869		
10				2.2024	2.0233		
11			3.0521	1.9989	1.9204		
12			2.5206	1.7652	1.8176		
13			2.1948	1.5339	1.7147		
14			2.4006	1.3757	1.6461		
15	.1029	.0701	2.1948	1.4403	1.4403	.0686	.0934
16	.1029	.0693	1.9719	1.2651	1.3889	.0857	.0953
17	.1029	.0686	.0857	.132	.1029	.1029	.0943
18	.1029	.0848	.1029	.132	.1029	.1029	.0924
19	.1448		.081	.12	.1478		.0857
20	.1494	.0103	.08	.12	.1509	.104	.1029
21	.132	.104	.08	.1029	.132	.1029	.1029
22	.0943	.1029	.0633	.0857	.1132	.0867	.1029
23	1.5729	.1029	.0655	.0857	1.0402	1.2163	1.3546
24	1.5432	1.4419	.064	.0655	.0686	.9217	1.1385
Max	2.0062	1.7004	3.0521	2.2024	2.0233	1.3735	1.6057
Min	.0943	.0103	.0633	.0648	.0686	.0686	.0857
Avg	.9794	.7098	1.0209	.8576	.8787	.5883	.7451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 204 / SASURVE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0671	2.5149	2.4577	2.5034	.0663	.0693
2		.0671	2.4577	2.372	2.4348	.0829	.0686
3			2.4577	2.3122	2.4006		
4			2.4577	2.3482	2.4691		
5			2.5232	2.2405	2.572		
6			2.7199	2.3472	2.7092		
7			3.0514	2.5396	2.915		
8			3.219	2.6558	2.9835		
9		2.8166				2.7846	2.7526
10		2.9843				2.9504	2.7526
11		2.9492				3.0178	2.7035
12		2.8826				2.8121	1.5746
13	3.4408	2.6092				2.5377	2.1052
14	3.5208					2.2977	1.9725
15	3.4332	2.1862	.0686	.0663	.0686	2.0919	1.9062
16		2.0005	.0857	.0995	.1029	1.7833	1.873
17		.0791	.1029	.116	.1029	.0857	.0995
18	2.8502	.0655	.1029	.0995	.0857	.1029	.0497
19	.1017	.0857	.0819	.1029	.0983	.0671	.1029
20	.1017		.08	.1029	.0995	.0857	.1029
21	.0838		.0781	.0857	.0995	.0857	.1029
22	.1006	.0686	.0671	.0857	.0995	.0857	.1029
23	.0671	2.4939	2.4577	2.4691	.0663	.0686	.0857
24	.0857	2.4006	2.5911		2.5377	.0663	
Max	3.5208	2.9843	3.219	2.6558	2.9835	3.0178	2.7526
Min	.0671	.0655	.0671	.0663	.0663	.0663	.0497
Avg	1.2595	1.5837	1.5065	1.3236	1.3527	1.1707	1.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 205 / VELU

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.132	.1254	.096	.1029	.1132	.124
2	.1029	.132		.0937	.1029	.1132	.1254
3	.1029	.1307	.1254	.0972	.1029	.1038	.124
4	.12	.1294	.1433	.1326	.1029	.1307	.1254
5	.2058	.1663	.1448	.1581	.1543	.1494	.1448
6	.2743	.2614	.2378	.2401	.2401	.2801	.181
7	.3086	.3326	.3142	.2812	.2743	.3077	.2534
8	.3258	.2896	.3292	.253	.2915	.3012	.2926
9	.2401	.2328	.2353	.1966	.2229	.2328	.2195
10	.1715	.1772		.1718	.2229	.1612	.1612
11	.1595	.1646	.1372	.1417	.2058	.12	.1417
12	.1595	.1417	.1715	.1612	.1886	.1372	.128
13	.1595	.1629	.1372	.128	.1715	.1886	.1463
14	.1543		.1715	.1463	.1543	.1715	.1463
15	.1753	.1433	.1372	.1646	.1543	.1715	.1463
16	.1772	.1772	.1543	.1629	.1543	.1543	.1267
17	.1791	.1753	.1886	.1595	.1543	.1543	.1448
18	.2149	.1772	.1886	.2126	.1715	.1886	.1928
19	.3801		.4252	.3429	.3658	.3109	.3086
20	.3881	.439	.4119	.3944	.4207	.3841	.3772
21	.3696	.3841	.3734	.3258	.3511	.2896	.3258
22	.2829	.2926	.2641	.2401	.2801	.181	.2572
23	.1698	.1991	.1509	.1543	.1698	.1267	.1543
24	.12	.124	.116		.12	.132	.124
Max	.3881	.439	.4252	.3944	.4207	.3841	.3772
Min	.1029	.124	.116	.0937	.1029	.1038	.124
Avg	.2102	.2075	.2129	.1937	.2033	.1918	.1863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

RAHIMATPUR S/DN.[831] BU 4831

Substation No/ Name :- 254012 / RAHIMATPUR

Feeder No / Name : 206 / 11KV Dhamner Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.7976	.0417	.0316	.0267	1.7236	1.4864
2	2.0233	1.7814	.0417	.0324	.0267	1.6404	1.4548
3	2.0233	1.749				1.5432	1.4548
4	1.989	1.749				1.5089	1.4723
5	2.0233	1.7695				1.448	1.4899
6	2.0919	1.7652				1.6164	1.5402
7	2.1262	2.0553				1.8343	1.6057
8	2.1948	1.9498				1.7553	1.7635
9			2.556	2.556	2.8807		
10				2.5934	3.2922		
11			3.2579	2.9172	3.1893		
12			3.2922	2.9334	3.0178		
13			3.155	2.9843	2.9835		
14			.5144	3.0182	2.8807		
15		.0497	3.0521	2.9504	2.9321	.0343	.0314
16	.0514	.0492	2.9492	2.8334	2.8464	.04	.0343
17	.04	.081	.0572	.0947	.0572	.0343	.045
18	.052	.0492		.045	.0686	.0514	.045
19	.0412	.0417	.0633	.0686		.04	.04
20	.0309		.0617	.0762	.0541	.044	.0533
21	.0389		.0633	.0457	.0549	.04	.0457
22	.0358	.0417	.0648	.0381	.0638	.0406	.0572
23	2.1051	.0429	.0474	.0229	1.8679	.0412	1.8861
24	2.0919	1.8623	.0309		.0267	1.8299	1.4864
Max	2.1948	2.0553	3.2922	3.0182	3.2922	1.8343	1.8861
Min	.0309	.0417	.0309	.0229	.0267	.0343	.0314
Avg	1.2363	1.0522	1.2031	1.3671	1.5453	.8481	.8884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 301 / 22KV RAJWADA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.419	1.5684	1.4937	1.5684	1.6804	1.4937	1.4937
2	1.419	1.4937	1.4937	1.5684	1.5684	1.4563	1.4937
3	1.3817	1.4937	1.4937	1.5684	1.5684	1.4563	1.419
4	1.3817	1.4937	1.4937	1.6804	1.531	1.4563	1.419
5	1.4937	1.643	1.643	2.1879	1.531	1.6057	1.6804
6	2.3765	2.1285	2.2634	2.6406	1.9418	2.0538	2.1125
7	2.8292	2.8669	3.0178	2.8669	2.3525	2.9424	2.7538
8	3.0178	2.9874	3.0178	2.7538	2.7915	2.9424	2.9047
9	2.6139	2.5393	2.8006	2.5652	2.8292	2.5019	2.6406
10	2.3152	2.3152	2.4272	2.3388	2.6029	2.3152	2.1658
11	2.3152	2.3899	2.4272	2.1807	2.452	2.2546	2.1807
12	2.1068	2.2405	2.3285	2.2916	2.3011	2.2177	1.9959
13	2.1582	2.1437	2.2314	2.2177	2.0911	2.1357	1.9022
14	2.1807	2.0328	2.0485	2.1437	1.9418	1.9185	1.8656
15	2.0328	2.0328		2.0485	1.8656	1.9387	1.8656
16	2.0119	2.0119	2.268	1.9959	1.829	1.9547	1.829
17	2.1216	2.0851	2.2805	2.1437	1.8781	2.1948	1.9022
18	2.4143	2.4253	2.4615	2.4025	2.1262	2.268	2.1719
19	3.3265	3.0678	2.8959	2.9938	2.9995	3.1093	2.7435
20	3.1824	3.1047	3.1047	3.0308	3.0308	3.2556	3.0308
21	2.846	2.8753	2.809	2.7721	2.846	2.7069	2.6139
22	2.5766	2.6139	2.5873	2.4764	2.4025	2.4508	2.4394
23	2.1285	2.1285	2.0748	1.922	1.9044	1.8298	1.8671
24	1.6057	1.5684	1.7177	1.643	1.7177	1.6221	1.531
Max	3.3265	3.1047	3.1047	3.0308	3.0308	3.2556	3.0308
Min	1.3817	1.4937	1.4937	1.5684	1.531	1.4563	1.419
Avg	2.2190	2.2188	2.2774	2.2501	2.1576	2.1701	2.0843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 302 / 22KV SANGAM NAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9808	1.0562	.9431	.9808	.9431	.9808
2	.9054	.9431	1.0562	.9431	.9054	.9054	.9054
3	.9054	.9054	1.0562	.9431	.9054	.9054	.9054
4	.9054	.9054	1.0562	1.0185	.8676	.9054	.9054
5	.9054	.9431	1.0562	1.1317	.8676	.9054	.9054
6	.9431	1.0562	1.0562	1.2071	.9431	.9431	.9808
7	1.3203	1.3203	1.3203	1.2449	1.094	1.2071	1.2826
8	1.3203	1.358	1.3957	1.2449	1.2826	1.2071	1.358
9	1.3203	1.4335	1.358	1.2071	1.358	1.773	1.5089
10	1.5089	1.7353	1.5089	1.7353	1.2449	1.5844	1.4335
11	1.8107	1.3957	1.8107	1.8107	1.2071	1.7353	1.3203
12	1.7353	1.2449	1.8484	1.8861	1.1317	1.7353	1.3203
13	1.7353	1.9239	1.7924	1.8484	1.0562	1.6598	
14	1.6221	1.8107	1.7551	1.7353	1.0562	1.6975	1.4335
15	1.5844	1.8861		1.6598	1.0185	1.6221	1.358
16	1.773	1.9616	1.9044	1.7353	1.0562	1.6221	.9465
17	1.7551	1.8671	1.8671	1.6221	1.0562	1.6057	1.5466
18	1.6057	1.8671	1.6057	1.4335	1.1203	1.4937	1.5466
19	1.8107	1.7551	1.773	1.6221	1.1827	1.6598	1.5089
20	1.6598	1.6804	1.7353	1.4784	1.6057	1.6221	1.5089
21	1.4784	1.5089	1.5844	1.3817	1.3443	1.4335	1.4335
22	1.358	1.3957	1.2449	1.1949	1.2696	1.0185	1.358
23	1.2071	1.2071	1.0562	1.0829	1.1317	1.0562	1.1317
24	.9808	.9808	1.1317	.9431	.9808	.9808	.9808
Max	1.8107	1.9616	1.9044	1.8861	1.6057	1.773	1.5466
Min	.9054	.9054	1.0562	.9431	.8676	.9054	.9054
Avg	1.3789	1.4194	1.4361	1.3772	1.1111	1.3426	1.2417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 303 / 22KV PARANGE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.1203	1.1317	1.1317	1.1203	1.0562	1.1203
2	1.0456	1.0456	1.1317	1.1317	1.1203	1.0562	1.0456
3	1.0456	1.0456	1.1317	1.1317	1.0082	1.0562	1.0456
4	1.0456	1.0456	1.1317	1.2071	1.0082	1.0562	1.0456
5	1.1949	1.1949	1.1317	1.4335	1.0082	1.0562	1.1203
6	1.5844	1.5089	1.5089	1.8861	1.2696	1.3203	1.2071
7	2.0748	2.0748	2.0748	2.0748	1.773	2.0748	1.9616
8	2.0538	2.0165	1.9993	2.037	1.9239	2.0748	1.9993
9	1.6804	1.7177	1.6975	1.5844	1.8484	1.6057	1.7353
10	1.4784	1.4563	1.4937	1.5684	1.6975	1.4937	1.419
11	1.4937	1.4563	1.4415	1.4937	1.5466	1.3817	1.4045
12	1.4784	1.4563	1.4045	1.419	1.4712	1.3676	1.3306
13	1.3676	1.3676	1.3306	1.3306	1.3443	1.2936	1.2936
14	1.3306	1.3676	1.2567	1.3676	1.2696	1.2936	1.1827
15	1.2936	1.3306		1.3306	1.2437	1.2936	1.2197
16	1.2936	1.3306	1.5154	1.3306	1.2071	1.2936	1.2197
17	1.3535	1.2936	1.4632	1.3676	1.2071	1.3676	1.2567
18	1.4632	1.5203	1.5927	1.5154	1.3756	1.5154	1.267
19	2.0698	2.0328	1.8099	1.885	1.9387	1.9387	1.6263
20	2.0698	2.0538	2.0748	2.0328	1.922	2.0485	1.922
21	1.922	1.9044	2.2546	1.848	1.848	1.8111	1.7551
22	1.643	1.7924	1.7372	1.7002	1.643	1.6632	1.6804
23	1.3817	1.3957	1.3957	1.307	1.3203	1.2696	1.2323
24	1.0829	1.1203	1.1317	1.2071	1.2323	1.1317	1.1203
Max	2.0748	2.0748	2.2546	2.0748	1.9387	2.0748	1.9993
Min	1.0456	1.0456	1.1317	1.1317	1.0082	1.0562	1.0456
Avg	1.4789	1.4854	1.5148	1.5134	1.4311	1.4383	1.3838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 253001 / 22/22 KV POWAINAKA SWIT. STN

Feeder No / Name : 304 / 22KV CIVIL HOSPITAL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.1391
2	.0381	.0381	.0381	.0381	.0381	.0381	.1353
3	.0381	.0381	.0381	.0381	.0381	.0381	.1334
4	.0381	.0381	.0381	.0381	.0381	.0381	.1295
5	.0381	.0381	.0381	.0381	.0381	.0381	.1295
6	.0762	.0381	.0381	.0381	.0381	.0762	.1353
7	.0381	.0381	.0381	.0762	.0381	.0381	.1429
8	.0762	.0381	.0381	.0762	.0762	.0381	.141
9	.0762	.0762	.0762	.0762	.0762	.0762	.221
10	.0762	.1143	.1143	.0762	.0762	.0762	.2343
11	.0762	.0762	.0762	.0762	.0762	.0762	.24
12	.0762	.0762	.0762	.0762	.0762	.0762	.242
13	.0762	.0762	.0762	.0762	.0762	.0762	.1886
14	.0381	.0762	.0762		.0762	.0762	.1829
15	.0381	.0762			.0762	.0762	.2058
16	.0381	.0762	.0381		.0762	.0381	.1943
17	.0381	.0762	.0762	.0381	.0762	.0381	.1829
18	.0381	.0381	.0762	.0381	.0381	.0381	.1772
19	.0381	.0762	.0762	.0381	.0381	.0381	.1486
20	.0381	.0381	.0762	.0381	.0762	.0381	.1505
21	.0381	.0762	.0762	.0762	.0762	.0762	.1981
22	.0762	.0762	.0762	.0381	.0381	.0381	.2058
23	.0381	.0381	.0762	.0381	.0381	.0381	.1943
24	.0381	.0381	.0381	.0762	.0381	.0381	.1486
Max	.0762	.1143	.1143	.0762	.0762	.0762	.242
Min	.0381	.0381	.0381	.0381	.0381	.0381	.1295
Avg	.0508	.0587	.0613	.0544	.0572	.0524	.1750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 301 / 22KV OLD MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3765	.5258	.5316	.6036	.5959	.5487	.6447
2	.3384	.5373	.567	.5373		.5609	.6447
3	.3384	.4801	.567	.5373	.5487	.543	.6024
4	.3429	.5087	.5959	.4908		.5487	.6024
5	.3765	.5144	.5959	.4908		.5959	.5959
6	.4268	.567	.631	.5201		.6447	.5959
7	.4115	.631	.5895	.6733	.6661	.6348	.5975
8	.3841	.4801	.4744	.4858	.5506	.4374	.2835
9	.695	.695	.7392	.9431	.7842	.823	.4805
10	.8215	1.0288	1.105	.9431	1.0288	.8676	.4877
11	1.105	1.1317	1.2071	1.0562	1.094	1.094	.5487
12	1.0562	1.0562	1.0185	.9979	1.0562	1.0562	.5487
13	.8676	1.0185	1.0562	.8871	.9808	.9808	.4481
14	.8299	.9808	.9808	1.2193	.9431	.9431	.3963
15	1.0185	1.2449	1.0185	1.1694	.9431	1.0669	.4557
16	1.094	1.0669	1.094	.9054	.8299	.8676	.5144
17	.7922	.9145	1.0562	1.0829	.7545	.9054	.5792
18	.6036	.7842	.8215	.9431	.7545	.7545	.5121
19	.6413	.7842	.7922	.7095	.6722	.6089	.5853
20	.6413	.5316	.695	.679	.4706	.5373	.3749
21	.6413	.7164	.6219	.679	.6219	.6089	.431
22	.6413	.6219	.6283	.567	.6413	.6413	.5487
23	.5914	.5914	.8048	.695	.6516	.6878	.5144
24	.3765	.5548	.5316	.5853	.6584	.6089	.6447
Max	1.105	1.2449	1.2071	1.2193	1.094	1.094	.6447
Min	.3384	.4801	.4744	.4858	.4706	.4374	.2835
Avg	.6422	.7486	.7801	.7667	.7623	.7319	.5266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 302 / 22 KV KARMVEER NAGAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8131	.9054	.924	.8676	.9431	.8676	.8676
2	.7682	.8676	.9709	.8299	.9054	.8299	.8215
3	.7682	.8676	1.0082	.7468	.8676	.7922	.8589
4	.7682	.9431	1.094	.7468	.9431	.8299	.9709
5	.8131	1.094	1.1694	.8131	1.2071	1.0562	1.1317
6	1.1827	1.3957	1.2449	1.2936	1.358	1.3203	1.358
7	1.8111	1.8861	1.9418	1.9418	1.6221	1.9993	1.9418
8	1.7002	1.8107	1.7551	1.7177	1.8484	1.8861	1.8298
9	1.1949	1.4335	1.2449	1.3203	1.6804	1.3957	1.4712
10	1.0562	1.105	1.094	1.094	1.3306	1.1694	1.0562
11	.9431	.9808	.9431	1.0185	1.1706	.9431	.9335
12	.9054	.9431	.9431	.9335	1.0136	1.0562	.8676
13	.8299	.8676	.9431	.9335	.9511	.8676	.9054
14	.8589	.8676	.9431	.9335	.8779	.9054	.8299
15	.8589	.8676	.9431	.9054	.961	.9054	.7922
16	.9335	.9808	1.0185	1.0185	.9511	.9808	.8299
17	1.0185	.9431	1.0185	1.0185	1.0242	.9922	.8779
18	1.094	1.1317	1.0562	1.094	1.1088	1.0974	.9979
19	1.6975	1.6095	1.5089	1.7177	1.643	1.5203	1.1827
20	1.5844	1.6632	1.6598		1.7193	1.6461	1.5154
21	1.5466	1.5893	1.5466	1.6221	1.5154	1.5893	1.4998
22	1.5089	1.4712	1.4712	1.4335	1.4045	1.3535	1.3169
23	1.094	1.1576	1.1317	1.1694	1.094	1.094	1.0719
24	.8131	.9054	.961	.8676	.9808	.9054	.9054
Max	1.8111	1.8861	1.9418	1.9418	1.8484	1.9993	1.9418
Min	.7682	.8676	.924	.7468	.8676	.7922	.7922
Avg	1.1068	1.1786	1.1890	1.1321	1.2134	1.1668	1.1181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 303 / 22KV MAHARASHTRA SCOOTERS

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	1.2346	1.3032	1.4632	1.4415	1.4415	1.3032
2	.2462	1.2536	1.2308	1.4118	1.39	1.419	1.267
3	.2462	1.2696	1.1462	1.4118	1.262	1.2894	1.2803
4	.2606	1.2346	1.0745	1.4632	1.3611	1.3394	1.3169
5	.2743	1.4175	.9922	1.4632	1.4937	1.3717	1.3032
6	.3185	1.5524	.9214	1.5154	1.5154	1.5364	1.3394
7	.4755	1.3253	1.3169	1.3535	1.5729	1.4045	1.39
8	1.283	1.4118	.8333	1.448	1.4842	1.1789	1.1576
9	1.6827	1.8484	2.1125	1.7924	1.6057	2.037	.8871
10	2.2634	2.3243	2.037	2.1879	1.358	1.8484	.8642
11	1.9993	2.037	2.0957	2.3624	1.8861	2.1879	.6401
12	1.8298	1.9616	2.0748	1.3535	1.8107	2.1125	.7034
13	1.9616	1.9616	1.9616	1.4415	1.8107	1.8484	.57
14	1.8861	1.8107	2.037	1.8861	1.8671	2.1125	.6135
15	2.037	2.1879	2.0748	1.8107	1.6598	1.9239	.5784
16	1.8107	1.8861	1.6461	1.3032	1.5089	1.7177	.5304
17	1.6975	1.9814	1.6975	2.0851	1.6975	1.8861	.4611
18	1.6598	1.8107	1.7353	1.9044	1.6975	1.8107	.4481
19	1.9239	1.9239	1.8484	1.6632	1.6975	1.9239	.5304
20	1.8861	1.5089	1.5684	1.6057	1.5466	1.6598	.7331
21	1.8107	1.773	1.6804	1.5364	1.7353	1.7177	.5959
22	1.6598	1.8107	1.8107		1.5844	1.7924	1.2403
23	1.5524	1.6804	1.848	1.7177	1.5154	1.6263	.7926
24	.2515	1.3169	1.39	1.4632	1.5466	2.1125	1.3032
Max	2.2634	2.3243	2.1125	2.3624	1.8861	2.1879	1.39
Min	.2462	1.2346	.8333	1.3032	1.262	1.1789	.4481
Avg	1.3028	1.6885	1.6015	1.6367	1.5854	1.7208	.9104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254010 / 33/22 KV OLD MIDC SS

Feeder No / Name : 304 / 22KV DOBURG

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8777	7.9904	7.3796	9.1987	6.6213	7.1692	9.3328
2	3.1916	7.9142	8.7731	9.0718	7.7884	7.3906	7.5576
3	3.2373	8.3113	8.2156	9.0718	7.6216	7.9626	7.0263
4	3.2822	8.5856	8.1226	9.1091	6.9429	7.7484	6.7101
5	3.5151	8.3642	8.2663	8.3532	6.0936	8.3768	7.0188
6	4.1873	9.103	9.3469	9.1675	8.4987	9.0261	6.5653
7	6.0216	9.5062	10.0477	9.3301	9.6045	9.5122	7.2298
8	5.6851	9.6224	8.4476	7.5728	9.4692	7.1838	5.8231
9	6.9345	10.1418	10.3609	10.5518	10.0396	8.3821	4.3983
10	10.2709	11.1569	12.3552	12.7732	12.697	11.2174	3.1398
11	10.9263	12.5823	12.6902	12.6685	13.2232	11.4149	4.7096
12	11.1233	12.1662	11.8259	12.5632	12.1118	11.3082	4.619
13	11.2372	10.7625	11.097	11.5874	11.4293	9.7112	4.5275
14	11.9589	8.0171	11.1427	12.9474	12.6353	10.4851	4.4745
15	12.5454	12.0992	12.2619	13.3052	13.9366	11.0345	4.4513
16	12.1712	11.4217	12.3694	12.697	12.5606	10.7255	4.5043
17	11.2975	11.0296	11.2204	12.2218	11.8286	11.0715	4.5123
18	10.8482	9.6951	10.3128	11.4571	8.7369	11.5817	4.1343
19	9.1754	8.7502	8.3098	9.1712	8.6542	11.4365	3.8953
20	8.5448	8.5848	8.6199	8.9034	7.7286	11.3482	3.6995
21	8.1718	7.0146	7.9497	8.224	7.3709	9.5139	5.9599
22	7.6696	7.6814	7.4905	8.1448	6.9113	9.6891	5.7807
23	9.0127	8.171	9.4018	9.0139	8.7776	10.229	7.4714
24	7.0622	7.6978	8.1272	8.8325	7.3521	8.4785	8.2651
Max	12.5454	12.5823	12.6902	13.3052	13.9366	11.5817	9.3328
Min	2.8777	7.0146	7.3796	7.5728	6.0936	7.1692	3.1398
Avg	7.9562	9.4321	9.7556	10.2474	9.5264	9.6665	5.6586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 301 / 22KV KARANJE MIDC

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2422	1.2773	1.2612	1.185	1.1164	1.2498	1.1355
2	1.2269	1.2193	1.2422	1.1659	.9487	1.2269	1.1316
3	1.2422	1.2346	1.2117	1.1507	.964	1.2864	1.1164
4	1.2269	1.2712	1.2422	1.1736	.9487	1.2906	1.1355
5	1.044	1.2712	1.246	1.2155	.9487	1.3428	1.1507
6	1.0745	1.323	1.2955	1.2002	.9792	1.3535	1.1659
7	1.1202	1.4357	1.387	1.2803	1.0097	1.3412	1.2955
8	1.2117	1.4913	1.467	1.3603	1.0554	1.406	1.3565
9	1.5943	1.5577	1.608	1.4822	1.4357	1.5661	1.3908
10	1.4907	1.5881	1.7833	1.5737	1.5881	1.8138	1.3908
11	1.5943	1.5729	1.768	1.659	1.7528	2.0386	1.3908
12	1.5119	1.5218	1.749	1.5737	1.7314	1.9243	1.3565
13	1.5485	1.4712	1.7299	1.6194	1.64	1.7185	1.2155
14	1.6095	1.608	1.8404	1.7833	1.8107	1.8252	1.2155
15	1.1126	1.829	1.8595	1.6994	1.6186	1.8404	1.1659
16	1.579	1.8099	2.0005	1.6842	1.8541	1.8099	1.2307
17	1.4998	1.749	1.7833	1.6194	1.576	1.8061	1.105
18	1.6705	1.6728	1.768	1.4479	1.454	1.7726	1.1355
19	1.6247	1.1888	1.7185	1.3717	1.4456	1.6575	1.246
20	1.5881	1.6194	1.6042	1.406	1.4913	1.627	1.2726
21	1.4357	1.4822	1.4174	1.2612	1.3108	1.5165	1.1964
22	1.384	1.4975	1.4517	1.1964	1.2559	1.467	1.1964
23	1.4357	1.4975	1.4517	1.246	1.2307	1.4022	1.1812
24	1.3222	1.4297	1.4365	1.2841	1.1964	1.2726	1.1812
Max	1.6705	1.829	2.0005	1.7833	1.8541	2.0386	1.3908
Min	1.044	1.1888	1.2117	1.1507	.9487	1.2269	1.105
Avg	1.3913	1.4841	1.5551	1.4016	1.3485	1.5648	1.2233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 302 / 22KV PRATAPGANJ PETH

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4522	3.7677	3.7494	3.5741	3.9018	3.6123	3.7761
2	3.437	3.6397	3.6351	3.4446	3.8561	3.3493	3.4903
3	3.376	3.6458	3.6199	3.3989	3.7799	3.3806	3.3912
4	3.5894	3.8165	3.8447	3.5132	3.757	3.4537	3.5323
5	3.7419	3.8318	4.0733	3.8028	3.8637	3.7148	3.7646
6	4.4353	4.792	4.984	4.7516	4.3286	4.5309	4.4581
7	5.929	6.3496	6.2529	6.2719	5.1097	6.0471	5.7385
8	6.5005	7.0165	6.6682	6.4776	6.3062	6.7063	6.2377
9	6.2308	6.5691	6.4091	5.9176	6.3192	6.3863	6.0738
10	5.6424	5.5175	5.4374	5.2126	5.8345	5.3041	4.9498
11	4.603	4.5206	4.6182	4.6487	5.1974	4.523	4.3668
12	4.5634	4.43	4.5458	4.3096	4.7524	4.2715	3.9895
13	4.542	4.3759	4.5267	4.3591	4.7119	4.2738	3.6427
14	4.228	4.0657	4.321	4.3363	4.4159	4.0848	3.4065
15	4.1884	3.8676	4.0848	4.3133	4.2859	3.9171	3.3951
16	4.0695	3.8714	3.8371	4.3591	4.2097	4.081	3.4751
17	4.3409	4.1152	4.3895	4.4505	4.3743	4.3401	3.5056
18	4.8064	4.843	4.6906	4.782	4.6777	4.625	3.8219
19	6.2277	5.9366	5.6546	5.5556	5.9846	5.8489	5.2165
20	7.2794	7.1597	6.8359	6.9921	7.1925	7.0569	6.3252
21	7.0569	6.8396	6.5424	6.7291	6.877	6.8282	6.3214
22	6.755	6.4244	6.2834	6.1881	6.4716	6.4586	6.1462
23	5.8375	5.6584	5.4527	5.6394	5.5441	5.8452	5.3498
24	5.3643	4.4444	4.2943	4.2905	4.5115	4.3096	4.2258
Max	7.2794	7.1597	6.8359	6.9921	7.1925	7.0569	6.3252
Min	3.376	3.6397	3.6199	3.3989	3.757	3.3493	3.3912
Avg	5.0082	4.9791	4.9480	4.8883	5.0110	4.8729	4.5250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 303 / 22KV SUSHAMA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1659	1.3383	1.3069	1.3565	1.2269	1.3108	1.2117
2	1.1355	1.2773	1.2269	1.2612	1.1659	1.262	1.1659
3	1.105	1.2773	1.2117	1.2155	1.1507	1.2513	1.1507
4	1.2422	1.262	1.2803	1.3679	1.185	1.2731	1.2041
5	1.3413	1.329	1.4518	1.5166	1.3336	1.4118	1.3374
6	1.6995	1.7558	1.829	1.9281	1.5889	1.7193	1.6347
7	2.3776	2.7015	2.7358	2.6558	2.0691	2.7701	2.6483
8	2.4997	2.8098	2.9492	2.8387	2.7168	2.953	2.8997
9	3.1428	2.652	2.7702	2.6292	2.7008	2.7777	2.7207
10	2.5423	2.2223	2.412	2.3777	2.5362	2.2405	2.2672
11	2.2924	2.2421	2.2253	2.0233	2.1673	1.5401	1.7909
12	2.2801	2.0759	2.0805	2.1148	1.9784	1.9395	1.6918
13	2.1368	1.9388	2.0195	1.9738	1.9418	1.8099	1.6728
14	1.9418	1.7032	1.8747	1.7833	1.8321	1.6575	1.5318
15	1.9022	1.7985	1.909	1.829	1.8999	1.6575	1.5927
16	1.9083	1.6728	1.8785	1.8442	1.8999	1.7795	1.4327
17	1.9266	1.749	1.8481	1.7833	1.8504	1.8138	1.3755
18	2.0149	1.8938	1.8595	1.8785	1.8321	1.8176	1.4517
19	2.3442	2.2025	2.0576	2.1148	2.2474	2.0119	1.951
20	2.5057	2.6215	2.5568	2.4463	2.6246	2.5721	2.3053
21	2.332	2.393	2.3625	2.2558	2.4577	2.473	2.2215
22	2.1887	2.1681	2.1758	2.0957	2.1719	2.1148	2.0043
23	1.9052	1.9281	1.9319	1.89	1.9014	1.9166	1.7566
24	1.4136	1.5059	1.5089	1.5432	1.4594	1.4784	1.3527
Max	3.1428	2.8098	2.9492	2.8387	2.7168	2.953	2.8997
Min	1.105	1.262	1.2117	1.2155	1.1507	1.2513	1.1507
Avg	1.9727	1.9383	1.9776	1.9468	1.9141	1.8980	1.7655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 304 / 22 KV MANGALWAR TALE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3838	2.803	2.6498	2.4828	2.5499	2.7714	2.4852
2	2.3106	2.6749	2.4417	2.2123	2.4112	2.6429	2.3518
3	2.2939	2.6277	2.3792	2.2047	2.4051	2.5926	2.2695
4	2.4814	2.6445	2.505	2.4128	2.4753	2.6109	2.4455
5	2.6886	2.902	2.8814	2.8105	2.6277	2.8212	2.623
6	3.3867	3.7951	3.5849	3.6146	3.2038	3.3516	3.4454
7	4.3217	4.678	4.5229	4.462	3.8287	4.4703	4.2546
8	4.8118	4.9093	4.9109	4.635	4.3499	4.6929	4.7127
9	4.7348	4.795	4.7317	4.5412	4.6502	4.4894	4.4726
10	4.2616	4.369	4.42	4.1153	4.5389	4.1381	3.991
11	4.0786	4.116	4.2714	4.0711	4.5344	4.09	3.8097
12	4.1853	4.2196	4.1769	3.7571	4.3744	3.9598	3.6633
13	4.0481	4.0458	3.9651	3.7327	4.1473	3.7647	3.4484
14	3.7677	3.6976	3.7296	3.5018	4.4033	3.6069	3.3791
15	3.6854	3.6268	3.687	3.4522	3.7525	3.4118	3.1923
16	3.751	3.5017	3.6923	3.4492	3.661	3.5277	3.2609
17	3.8928	3.4369	3.7784	3.472	3.6641	3.6702	3.2884
18	4.1778	4.3408	4.1823	3.7883	4.1808	4.2417	3.6321
19	5.7506	5.8376	5.5289	4.8507	5.7682	5.5335	5.1783
20	6.1393	6.0426	5.7346	5.2812	6.0105	5.7362	5.4443
21	5.3696	5.8276	5.0671	4.7912	5.2934	4.9184	4.9352
22	4.4795	4.827	4.279	4.1442	4.3683	4.3316	4.1869
23	3.7647	3.8432	3.6778	3.7731	3.6549	3.6328	3.5917
24	3.7166	3.1001	3.0849	3.0293	3.0391	2.8815	2.8251
Max	6.1393	6.0426	5.7346	5.2812	6.0105	5.7362	5.4443
Min	2.2939	2.6277	2.3792	2.2047	2.4051	2.5926	2.2695
Avg	3.9367	4.0276	3.9118	3.6911	3.9122	3.8287	3.6203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254033 / 33/22 KV KARANJE SS

Feeder No / Name : 305 / 22 KV S. T. STAND

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2253	2.4189	2.3518	2.2009	2.2664	2.2702	2.258
2	2.1491	2.3594	2.2237	2.0949	2.2009	2.1643	2.1445
3	2.1231	2.2558	2.175	2.069	2.1536	2.2169	2.1308
4	2.284	2.2802	2.3251	2.319	2.3007	2.274	2.2169
5	2.5057	2.463	2.5605	2.6124	2.3991	2.5796	2.4334
6	2.8913	2.9172	2.9988	3.2861	2.7526	2.974	2.8829
7	3.7083	4.1122	3.7037	4.0961	3.2419	3.709	3.6999
8	4.1304	4.3416	4.0802	3.9613	4.1831	4.0345	4.1838
9	4.0025	4.0604	3.924	3.7243	4.0086	3.8851	3.7197
10	3.6	3.6291	3.4926	3.1656	3.7174	3.3249	3.3417
11	3.5254	3.4872	3.4118	3.3699	3.5102	3.2335	3.075
12	3.4065	3.5307	3.3707	3.1748	3.3562	3.1878	2.9257
13	3.3089	3.3497	3.3349	3.1306	3.2632	3.1214	2.9431
14	3.3158	3.1786	3.2015	3.0574	3.1573	3.0788	2.8075
15	3.2343	3.1999	3.2129	3.03	3.1002	3.0628	2.8913
16	3.3348	3.1245	3.206	3.065	3.0712	3.0528	2.8319
17	3.408	3.04	3.3547	3.0605	3.1231	3.0574	2.9157
18	3.626	3.4225	3.3859	3.219	3.1932	3.206	2.9431
19	4.4902	4.3195	4.2631	3.8775	4.1023	4.1602	3.8309
20	4.6639	4.4955	4.478	4.369	4.2494	4.4642	4.1167
21	4.2341	4.8278	4.1275	3.9095	3.7685	4.0025	3.9202
22	3.8424	4.305	3.7129	3.3866	3.594	3.6618	3.6069
23	3.2739	3.4179	3.2153	1.9692	3.0933	3.1839	3.126
24	3.0857	2.6688	2.6803	2.5438	2.4615	2.5034	2.521
Max	4.6639	4.8278	4.478	4.369	4.2494	4.4642	4.1838
Min	2.1231	2.2558	2.175	1.9692	2.1536	2.1643	2.1308
Avg	3.3487	3.3836	3.2830	3.1122	3.1778	3.1837	3.0611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254071 / 33/22 KV SADAR BAZAR

Feeder No / Name : 301 / 22 KV PIRWADI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.6584	.5853	.7316	.6219	.5853	.5853
2	.6584	.6584	.5853	.5853	.5853	.5487	.5853
3	.6219	.5853	.5853	.5853	.5853	.4755	.439
4	.6219	.5853	.5487	.5487	.6219	.4755	.439
5	.7682	.8048	.6584	.6219	.695	.4755	.7316
6	.7682	.8048	.8779	.7682	.7682	.6584	.8779
7	1.2071	1.2803	1.2437	1.1706	.9145	.9145	1.2071
8	1.2071	1.2071	1.134	1.1706	1.0974	1.0608	1.2071
9	.9877	1.0242		1.134	1.0974	1.0608	1.0608
10	.9877	.9145	1.0242	1.0608	1.0242	.9145	.8779
11	.8779	.9511	.8779	.9511	.9511	.9145	.7316
12	.0572	.8413	.9145	.8779	.8779	.9877	.7316
13	.8413	.8413	.8779	.8779	.8048	.8048	
14	.8413	.8048	.8048	.8413	.7316	.7682	.8048
15	.8048	.8048	.8048	.8048	.7316	.695	.7682
16	.8413	.7682	.8413	.8048	.7316	.7316	.7316
17	.8779	.8048	.8413	.8413	.7316	.8048	.7682
18	.9511	.8779	.8779	.8779	.8048	.8413	.8048
19	1.2071	1.1706	1.1706	.9877	1.0242	1.0608	1.0242
20	1.1706	1.2071	1.1706	1.134	1.0974	1.1706	1.0608
21	1.0974	1.0974	1.0974	1.0608	1.0974	1.0974	1.0608
22	1.0242	1.0608	1.0242	.9877	.9877	1.0242	.8048
23	.9145	.9145	.9145	.8779	.8048	.8048	.8048
24	.6584	.7682	.8048	.8413	.695	.7682	.6584
Max	1.2071	1.2803	1.2437	1.1706	1.0974	1.1706	1.2071
Min	.0572	.5853	.5487	.5487	.5853	.4755	.439
Avg	.8590	.8932	.8811	.8810	.8368	.8185	.8159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 254071 / 33/22 KV SADAR BAZAR

Feeder No / Name : 302 / 22 KV SADAR BAZAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.8048	.8048	.8048	.8413	.8048	.8048
2	.7682	.8048	.8048	.8048	.7682	.8048	.7796
3	.7682	.8048	.8048	.8048	.7682	.7316	.7316
4	.7682	.8413	.7682	.7316	.8413	.8413	.7316
5	.8048	.8779	.8048	.9145	.8779	.9145	.9145
6	1.0242	1.0608	1.0974	1.0608	1.0242	.9511	1.0242
7	1.4998	1.4266	1.5729	1.4266	1.2071	1.4632	1.5364
8	1.5364	1.5364	1.5729	1.6095	1.4632	1.5364	1.4998
9	1.39	1.3169		1.3535	1.4998	1.4632	1.2437
10	1.2071	1.0242	1.1706	1.2071	1.2071	1.1706	1.0974
11	1.0608	.9511	1.0608	1.0608	1.134	.9877	.9145
12	.9511	.8779	.9877	1.0242	1.0242	.9511	.9877
13	.9145	.8413	.9511	.9511	.9877	.9145	.8048
14	.8779	.8413	.8048	.8779	.9511	.8413	.8779
15	.8413	.9145	.9145	.9511	.9145	.695	.8413
16	.8779	.9145	.8779	.9511	.8413	.8048	.7682
17	.9145	.9145	.9145	.8413	.8779	.8413	.8779
18	1.0242	1.0974	1.0242	1.0608	1.0242	.9877	.8413
19	1.4632	1.4998	1.382	1.3535	1.39	1.4998	1.2803
20	1.4998	1.5729	1.4632	1.4998	1.5364	1.5364	1.39
21	1.4632	1.4998	1.4266	1.39	1.4266	1.4632	1.3535
22	1.3535	1.3535	1.3535	1.134	1.2803	1.3169	1.0242
23	.9511	.8413	1.2071	.9877	1.0608	1.0608	1.0242
24	.8413	.8413	.8413	.9145	.8779	.8779	.7682
Max	1.5364	1.5729	1.5729	1.6095	1.5364	1.5364	1.5364
Min	.7682	.8048	.7682	.7316	.7682	.695	.7316
Avg	1.0669	1.0608	1.0700	1.0715	1.0761	1.0608	1.0049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 302 / 22 KV POWAI NAKA

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 22 / OUTGOING

UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	14.5176	15.0434	15.295	14.9063	14.6319	14.4261	14.1061
2	13.5574	14.1061	14.3348	13.9918	13.6718	13.4888	13.2602
3	13.1687	13.6718	13.9232	13.5574	13.2602	13.1459	12.8944
4	12.963	13.4659	13.6946	13.306	13.0316	12.9173	12.6429
5	13.466	13.9004	14.1289	13.786	13.3517	13.3288	13.0544
6	16.8039	17.3297	17.4212	17.2611	15.7065	16.5981	16.4381
7	22.0622	22.6338	22.7938	22.4052	18.9072	21.7193	21.8793
8	24.3713	24.6686	24.6686	24.0055	22.3366	23.9141	24.0741
9	23.7997	23.6169	23.6855	22.9081	22.7938	23.5026	22.8852
10	21.6279	21.6736	21.8336	21.3535	21.8565	21.5364	20.5762
11	21.1705	21.4677	21.9479	21.3306	20.7133	21.102	19.6159
12	21.1477	21.6507	22.0393	21.6049	19.936	21.1935	19.273
13	20.9191	21.5821	21.2391	21.3534	19.1358	20.3932	18.61
14	20.439	21.1249	20.5991	20.4619	18.1756	19.8903	17.101
15	19.8903	20.3932	16.6438	19.5931	17.1011	19.0215	16.7352
16	20.0046	20.7362	23.251	19.5474	16.0036	19.273	16.8039
17	20.1875	20.8963	22.0851	19.8902	16.1866	19.6846	17.3754
18	20.942	20.9419	21.9936	20.279	17.4211	20.4619	17.4211
19	***	24.9429	***	23.1825	21.7879	23.8683	21.4449
20	***	***	***	***	24.8514	***	24.1427
21	***	***	***	24.3485	24.1656	***	23.6169
22	23.1367	23.8684	23.1825	22.3594	21.7193	23.0681	21.9479
23	21.0106	21.6278	20.9877	20.3932	20.1418	20.5991	19.9818
24	17.444	17.8327	17.2611	17.2382	17.0554	16.7124	16.3466
Max	27.1148	27.1834	27.1834	25.583	24.8514	26.6804	24.1427
Min	12.963	13.4659	13.6946	13.306	13.0316	12.9173	12.6429
Avg	20.0303	20.4314	20.4647	19.7769	18.4976	19.6855	18.4261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 303 / 22 KV RADHAKRISHNA

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.0466	8.0704	8.1847	9.3279	9.3279	9.808	7.3617
2	4.0009	8.0476	8.2991	8.9849	9.465	9.2364	7.2245
3	4.0238	8.2076	8.3905	8.7792	8.5277	8.7334	7.2474
4	3.9552	7.7046	8.0247	8.3676	8.6648	8.8935	6.9502
5	3.9552	7.5217	7.8418	8.5277	8.8935	8.4134	7.6589
6	4.0695	7.8647	8.2076	8.6191	8.9849	8.6877	7.0416
7	4.984	7.8189	8.5048	8.7792	8.0476	8.5734	6.8359
8	5.4413	7.3846	8.0018	8.8706	7.3846	7.0873	6.0357
9	7.1788	8.4134	9.0535	9.6022	8.8935	9.1907	4.7325
10	9.0992	10.1738	10.471	11.2483	9.7622	10.8139	4.6639
11	10.1509	10.7682	10.7453	15.2321	13.1974	11.5226	4.5496
12	10.3338	11.8668	11.2483	11.3169	10.2652	10.6767	4.321
13	9.1907	10.2195	4.2067	9.7165	10.471	9.5336	4.3896
14	9.6479	10.6082	9.9451	10.1509	10.1966	10.1052	4.3896
15	9.9451	10.8139	10.5396	10.6767	11.294	10.6996	4.3667
16	9.7394	10.9054	10.8825	10.974	11.1797	11.1569	4.321
17	9.6708	10.7911	10.0595	11.294	10.6767	10.2195	4.3439
18	9.2593	10.0595	10.0366	10.2881	10.2652	10.0366	4.5268
19	9.145	9.2593	8.9621	10.4481	9.465	9.9451	4.7782
20	8.5048	8.0247	9.0078	9.6479	9.2593	9.808	4.6411
21	8.2076	8.1847	9.3507	9.3279	9.0306	8.9163	4.5268
22	8.6191	8.802	9.2364	9.6022	9.7394	8.5734	4.3667
23	8.7106	9.0535	9.8308	9.7165	9.3507	8.9163	4.4582
24	9.9543	9.0078	9.8537	9.1221	9.0992	8.5048	4.5268
Max	10.3338	11.8668	11.2483	15.2321	13.1974	11.5226	7.6589
Min	3.9552	7.3846	4.2067	8.3676	7.3846	7.0873	4.321
Avg	7.5764	9.1488	9.1202	9.9425	9.6434	9.5022	5.3441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 304 / 22KV ARISTOCRAT

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.9992	9.2212	10.1357	9.7241	9.9832	8.9773	8.9925
2	5.0297	9.0688	9.7394	9.6327	9.6479	9.7394	9.0078
3	4.6944	9.2364	9.1602	8.9468	9.4346	9.1907	8.9621
4	4.6334	8.8249	9.6784	9.2974	8.4896	9.3736	8.9621
5	4.7249	7.6208	8.2152	7.8951	7.9409	9.1145	8.6877
6	5.1212	7.2093	8.0018	7.8647	8.3524	9.0078	8.4743
7	5.1212	7.8342	8.9163	8.1085	7.6665	9.0078	7.8799
8	7.2702	7.5751	8.3981	8.139	8.3219	8.6572	6.3557
9	8.3219	9.1754	9.6632	9.2669	9.0992	9.1602	5.1974
10	10.7758	10.7301	10.6082	10.9435	10.3643	10.4253	4.603
11	10.5319	11.5074	11.416	11.294	16.2978	10.7453	3.7952
12	11.2331	17.1087	11.7665	11.355	9.9375	10.9892	3.9781
13	10.2424	9.9375	10.5929	9.7241	9.145	9.2974	3.8256
14	10.6539	10.8825	11.294	9.9985	9.8156	10.029	3.6732
15	11.3398	11.4007	12.7115	10.5777	9.8156	10.2576	3.719
16	9.7089	10.6386	11.9494	11.5836	10.1357	10.9282	3.7494
17	9.7394	10.349	11.6751	11.858	10.3338	11.0349	4.6334
18	10.0137	9.587	10.0137	11.4922	9.9223	11.0197	4.7554
19	8.703	9.8613	10.3338	10.9587	9.4498	10.7911	4.9078
20		9.8156	9.7241	11.1873	9.3126	10.6386	5.2126
21	4.5268	9.1145	9.7394	10.4862	9.084	9.7394	5.4108
22	8.4743	9.526	9.6022	10.4253	9.0992	9.8918	5.487
23	8.5505	10.5929	10.349	9.9528	10.4253	9.9223	5.5784
24	11.9566	10.4253	10.0442	9.5108	9.4803	9.0078	5.5022
Max	11.9566	17.1087	12.7115	11.858	16.2978	11.0349	9.0078
Min	4.5268	7.2093	8.0018	7.8647	7.6665	8.6572	3.6732
Avg	8.1029	9.8851	10.1553	10.0093	9.6481	9.8728	5.8896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 305 / 22KV OKASA PHARMA

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	1.0669	1.0593	.9221	.381	.3734	.9983
2	1.0593	1.0745	1.1279	.945	.3734	.3658	.8688
3	1.0136	.9831	1.0669	.9526	.381	.3658	.8383
4	.9983	1.0136	1.166	.9069	.381	.3887	.8307
5	1.0136	.9907	1.1279	.8535	.3734	.381	.8154
6	.9831	.9831	1.0593	.8307	.381	.3734	.8002
7	1.1126	1.1203	1.1431	.7621	.3734	.7087	.945
8	1.4556	1.3717	1.4175	.4268	.3582	1.1355	1.2041
9	2.21	2.3015	2.2024	.381	.381	2.0119	2.0805
10	2.4158	2.6063	2.4691	.3887	.4039	2.4463	2.3015
11	2.4996	2.6749	2.5453	.4115	.5624	2.4463	2.3243
12	2.5987	3.8546	2.5758	.4725	.4191	2.4234	2.332
13	2.4844	2.5835	2.5987	.4725	.4191	2.3548	2.3472
14	2.6216	2.6139	2.553	.4572	.4344	2.3777	2.2405
15	2.6673	2.5377	2.6444	.4344	.4115	2.3929	2.2405
16	2.6368	2.5987	2.5606	.4344	.442	2.3167	2.2634
17	2.5149	2.4463	2.431	.4191	.4191	2.3091	2.1262
18	1.8747	1.8976	1.5165	.3734	.3734	1.8595	1.7452
19	1.5927	1.5242	1.3489	.381	.3582	1.5623	1.3336
20	1.4098	1.4708	1.166	.3658	.3734	1.2346	1.2269
21	1.387	1.3032	1.1507	.381	.381	1.1584	1.1812
22	1.3336	1.2269	1.0745	.381	.3734	1.1507	1.1355
23	1.3032	1.1965	1.0288	.3734	.3734	1.105	1.1507
24	1.6792	1.1355	.9297	.3734	.3658	.9907	1.0669
Max	2.6673	3.8546	2.6444	.9526	.5624	2.4463	2.3472
Min	.9831	.9831	.9297	.3658	.3582	.3658	.8002
Avg	1.7516	1.774	1.6651	.5458	.3956	1.4264	1.5165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 402 / 33KV SIDDHIVINAYAK

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	04-MAR-17	05-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11			9.7891	8.1482
12		9.8457		
24	1.5844			
Max	1.5844	9.8457	9.7891	8.1482
Min	1.5844	9.8457	9.7891	8.1482
Avg	1.5844	9.8457	9.7891	8.1482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA (U)[117]

BU 0914

Substation No/ Name :- 256016 / 220/132/33/22 KV NEW MIDC SS

Feeder No / Name : 406 / 33 KV COOPER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17	02-MAR-17	05-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
11			3.9769
12		1.4563	
24	.3961		
Max	.3961	1.4563	3.9769
Min	.3961	1.4563	3.9769
Avg	.3961	1.4563	3.9769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 201 / PARALI-SATARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4153	.4487	.487	.4735	.4816	.2641	.4073
2	.379	.4477	.4333	.4529	.4445	.2221	.3658
3	.3744	.4201	.4176	.0602	.4376	.2054	.3494
4	.3909	.4363	.4332		.4335	.2153	.3433
5	.4441	.5095	.5203		.4917	.2564	.4226
6	.6719	.7379	.7182		.6169	.354	.6409
7	1.0581	1.0344	.9524	.3054	.9741	1.081	.8334
8	1.0953	1.0786	1.0248	.3342	1.0925	1.1787	.4965
9	.5056	.8269	.9724	.3205	.8686	.9964	.8994
10	.9821	.9736	.8172	.3304	.5719	1.0539	.3521
11	.4954	.9549	.8181	.5235	1.0136	.9846	.8994
12	.4893	.9726	.8314	.6043	.9839	.8707	.9061
13	.8745	.8997	.7789	.4645	.8528	.8959	.4451
14	.9181	.7721	.831	.463	.8078	.8749	.7476
15	.8024	.7649	.8143	.3989	.8486	.7689	.7506
16	.6615	.7352	.8684	.5209	.8616	.7144	.6289
17	.5737	.7468	.9621	.8137	.5792	.9115	.5622
18	.202	.8025	.8697	.908	.5746	.8779	.73
19	.7381	1.1835	1.1092	1.2231	.583	1.1339	1.2215
20	1.3098	1.3424	1.2932	1.4536	.7533	1.1084	1.2022
21	.6577	1.2803	1.2563	1.3844	.7217	1.0178	1.1983
22	1.0471	1.1698	1.1576	1.174	1.0795	.8726	1.0974
23	.4504	.7121	.7739	.4565	.4592	.6703	.7
24	.502	.5497	.578	.542	.555	.4582	.4649
Max	1.3098	1.3424	1.2932	1.4536	1.0925	1.1787	1.2215
Min	.202	.4201	.4176	.0602	.4335	.2054	.3433
Avg	.6683	.8250	.8216	.6289	.7119	.7495	.6944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 202 / THOSEGHAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.132	.1698	.1509	.1509		.168
2	.1509	.132	.1509	.2263	.132		.1494
3	.1509	.132	.1509	.1509	.132		.1494
4	.1698	.1509	.1494		.1509		.1494
5	.1698	.1698	.168		.1698		.1867
6	.2452	.2641	.2801		.2263		.2054
7	.3961	.415	.4527		.3772	.3961	.3734
8	.3696	.4338	.415		.4108	.3961	.3547
9		.3395	.415		.3696	.2987	
10	.3395	.3174	.3696		.3734	.3174	
11		.2801	.2772		.3361	.3142	
12	.3395	.2587	.2743		.3206	.2957	
13	.3206	.2218	.2926		.3018	.2587	
14	.2829	.2033	.2402		.3018	.2987	.3018
15		.2218	.2772		.2829	.2614	.3018
16	.3206	.2587	.3326		.2641	.2772	.3584
17	.3206	.2614	.3326	.3018		.2926	.2587
18		.3547	.3511	.3547		.3174	.3734
19	.4904	.6224	.4854	.4854		.5228	.4854
20	.4904	.5847	.4854	.5041		.4854	.5601
21		.547	.4481	.4668		.4481	.4668
22	.3361	.4481	.3734	.3547	.3206	.2987	.3921
23		.2829	.2241			.2263	.2241
24	.1886	.2075	.2075	.1509	.3018	.1886	.168
Max	.4904	.6224	.4854	.5041	.4108	.5228	.5601
Min	.1509	.132	.1494	.1509	.132	.1886	.1494
Avg	.2917	.3017	.3051	.3147	.2735	.3275	.2962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 203 / Nitral Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0187	.0189	.0189		.0187
2	.0189	.0189	.0187	.0189	.0189		.0187
3	.0189	.0189	.0187	.0189	.0189		.0187
4	.0189	.0189	.0187	.0189	.0189		.0189
5	.0189	.0189	.0187	.0189	.0189		.0189
6	.0377	.0377	.0754	.0377	.0377		.0189
7	.0943	.0754	.0566	.0943	.0566	.0754	.0377
8	.0943	.0754	.0566		.0754	.0754	.0373
9		.0566	.0566		.0566	.0754	
10		.0189	.0377		.056	.0754	
11		.0377	.0377		.056	.0566	.0377
12	.0377	.0189	.0377		.056	.0747	.0377
13	.0377	.0377	.0377		.0373	.0747	
14	.0377	.0189	.0377		.0373	.0373	.0377
15		.0189	.0377		.0373	.0373	.0377
16	.0754	.0189	.0566		.0373	.056	.0754
17	.0754	.0377	.0566	.0566		.056	.0566
18		.0377	.0377	.0754		.0934	.0747
19	.0754	.0934	.0754	.0943		.112	.112
20	.1132	.0934	.0943	.0754		.0934	.112
21	.1132	.0747	.0943	.0754		.0747	.0934
22	.0943	.0373	.0754	.0566	.0566	.056	.0566
23		.0187	.0189			.056	.0377
24	.0189	.0189	.0187	.0189	.0189	.0189	.056
Max	.1132	.0934	.0943	.0943	.0754	.112	.112
Min	.0189	.0187	.0187	.0189	.0189	.0189	.0187
Avg	.0555	.0384	.0455	.0485	.0396	.0666	.0482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254014 / PARALI

Feeder No / Name : 204 / PARALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8848	.8029	.7045		
2			.852		.6483		
3			.8192	.7611	.6327		
4			.7865	.7274	.6401		
5			.7701	.7202	.6964		
6			.7865	.6718	.7701		
7			.9503	.9488	.8539		
8			1.0814		.8855		
9		1.3413				1.2239	
10	1.5844	1.3757				1.4586	
11		1.3435				1.6057	.3018
12	1.7541	1.3283				1.5565	.3018
13	1.5089	.9722				1.5565	
14	1.5844	1.2452				1.5565	1.6409
15		1.3117				1.5074	
16	1.1488	1.3123				1.4586	1.4335
23		.7545	.8356				
24			.9556	.7811	.6874		
Max	1.7541	1.3757	1.0814	.9488	.8855	1.6057	1.6409
Min	1.1488	.7545	.7701	.6718	.6327	1.2239	.3018
Avg	1.5161	1.2205	.8722	.7733	.7243	1.4905	.9195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 201 / 11 KV ANGAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1083	.0833	1.8089	1.7269	1.519	.105	.1515
2	.1102	.0869	1.7958	1.6876	1.4821	.1061	.1494
3			1.7761	1.6778	1.4452		
4			1.7846	1.7302	1.4217		
5			1.8202	1.7728	1.3815		
6			1.8429	1.7878	1.3413		
7			1.8908	1.838	1.4955		
8			1.8122	1.7895	1.4454		
9	2.5592	2.5551				2.0387	2.1338
10	2.8502	2.7316				2.3807	2.2801
11	2.8894	2.6959				2.3874	2.2834
12	2.6321	2.7831				2.2064	2.1759
13	2.6155	2.7295				2.3673	2.0851
14	2.6045	2.5752				2.1863	2.0841
15	2.5551	2.4531	.0597	.0686	.0448	2.1661	2.0119
16	2.1216	2.4001	.0616	.0638	.0732	2.146	2.119
17	.0892	.0747	.0803	.0766	.1003	.1244	.1139
18	.0892	.0691	.0971	.0803	.085	.1207	.1176
19	.1317	.1158	.1183	.0896	.1152	.1663	.1494
20	.1344	.0934	.1214	.1158	.1086	.1626	.1419
21	.1046		.1158	.0896	.0911	.1683	.1288
22	.1086	.1008	.1046	.0822	.0914	.1463	.127
23	.0797	1.8138	1.7004	1.5961	.1024	.1331	.1083
24	.1102	.0815	1.8351	1.7581	1.5492	.1063	.1344
Max	2.8894	2.7831	1.8908	1.838	1.5492	2.3874	2.2834
Min	.0797	.0691	.0597	.0638	.0448	.105	.1083
Avg	1.2163	1.3790	1.0459	1.0017	.7718	1.0677	1.0275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 202 / 11 KV ANGAPUR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1866	.197		.168	.1646	.1629	.1643
2	.1829	.1791		.1606	.161	.1448	.1552
3	.1885	.1791		.1568	.1536	.1524	.1494
4	.2268	.197		.1643	.1939	.1629	.1643
5	.2707	.248		.2128	.2597	.2012	.1885
6	.3347	.3548		.2651	.3109	.3437	.2726
7	.417	.4472		.4238	.3695	.4225	.3804
8	.439	.4525		.3873	.4145	.3982	.3326
9	.2521	.3031	.3	.3455	.3809	.3073	.3167
10	.295	.2128	.2725	.2927	.3142	.2597	.2959
11	.2402	.2048	.2396	.2569	.2838	.2561	.2521
12	.1922	.1979	.2359	.2349	.2414	.2213	.2791
13	.2278	.1939	.2305	.2298	.2231	.2268	.2743
14	.2033	.1942	.2378	.2109	.2241	.2451	.2401
15	.1979	.1959	.2012	.2209	.2315	.2615	.2572
16	.207	.1867	.2353	.2303	.2439	.2433	.2645
17	.2143	.1904	.2353	.2359	.2058	.2144	.2963
18	.3012	.1942	.3398	.2451	.2551	.3323	.2872
19	.362	.4705	.4084	.3274	.3898	.3859	.4042
20	.3841	.4462	.414	.3932	.3982	.4108	.4127
21	.3749	.3622	.3398	.3567	.3768	.3696	.342
22	.317	.2913	.2931	.2926	.3012	.292	.3
23	.2162	.2016	.1979	.203	.2172	.2091	.2012
24	.1902	.1984	.1699	.1736	.1664	.1683	.168
Max	.439	.4705	.414	.4238	.4145	.4225	.4127
Min	.1829	.1791	.1699	.1568	.1536	.1448	.1494
Avg	.2676	.2625	.2719	.2578	.2700	.2663	.2666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 204 / 11 KV JIHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.139	.1507	.1624	.1531	.15	.1402	.1441
2	.1317	.1417	.1587	.1494	.1463	.1402	.1419
3	.128	.1372	.1568		.1441	.1417	.14
4	.1536	.1254	.1718	.1755	.1866	.13	.1643
5	.1866	.181	.2016		.2268	.1543	.2054
6	.2615	.2926	.2651		.2707	.3224	.3025
7	.3951	.4158	.4537		.4152	.439	.4108
8	.3768	.3982	.3958	.3435	.3844	.3987	.3546
9	.3099	.3211	.3	.2896	.3622	.3054	.2561
10	.2754	.3056	.2506	.2743	.3395	.289	.2516
11	.2502	.2476	.2469	.2734	.3112	.2579	.1783
12	.239	.2829	.2506	.3224	.2987	.2451	.1543
13	.2278	.2353	.2707	.2915	.2698	.2048	.2058
14	.2218	.2414	.267	.2572	.2651	.2122	.2058
15	.2539	.2353	.2853	.2743	.2561	.2597	.2366
16	.2875	.2465	.2872	.291	.2743	.2378	.2572
17	.2401	.2726	.3305	.3658	.2949	.3062	.267
18	.312	.3062	.3809	.3603	.3366	.3211	.3
19	.503	.4817	.4892	.4463	.4706	.4657	.3439
20	.4528	.4854	.5116	.4883	.4941	.4938	.4344
21	.4108	.422	.422	.4134	.3982	.3807	.3859
22	.3189	.3137	.2987	.3164	.3292	.2987	.3182
23	.1949	.2147	.183	.1866	.2012	.1942	.1811
24	.1427	.1698	.1662	.1568	.1536	.161	.1463
Max	.503	.4854	.5116	.4883	.4941	.4938	.4344
Min	.128	.1254	.1568	.1494	.1441	.13	.14
Avg	.2672	.2760	.2878	.2915	.2908	.2708	.2494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 205 / 11 KV VIJAY NAGAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1166	.884				1.2561	1.1099
2	1.1099	.8688				1.1904	1.0831
3	1.1099	.8792				1.1126	1.0615
4	1.12	.8907				1.1126	1.0395
5	1.13	.8688				1.1431	1.0641
6	1.1434	1.0186				1.1654	1.1267
7	1.1635	1.0436				1.2681	1.1971
8	1.2172	1.0486				1.2894	1.153
9			1.7	1.7071	1.861		
10			2.0588	1.7253	2.168		
11			1.9918	1.8976	2.0719		
12			2.146	1.7497	2.0421		
13			1.9649	1.6461	2.0454		
14			2.0287	1.5546	2.0052		
15			1.9851	1.8275	1.9601		
16			1.9448	1.6766	1.8644		
23	.9488				1.3283	1.2071	1.0998
24	1.12	.9488	.1662			1.2779	1.177
Max	1.2172	1.0486	2.146	1.8976	2.168	1.2894	1.1971
Min	.9488	.8688	.1662	1.5546	1.3283	1.1126	1.0395
Avg	1.1179	.9390	1.7763	1.7231	1.9274	1.2023	1.1112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254016 / ANGAPUR

Feeder No / Name : 206 / Tasgaon Ag Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0328	1.0212	.0336	.028	.0224	.6554	.763
2	1.0127	1.0059	.0336	.028	.0224	.6009	.7325
3	.9925	1.0181				.6199	.7176
4	.9825	1.0059				.639	.7042
5	.9624	1.0467				.6341	.7393
6	.9523	1.0858				.7287	.8003
7	1.0931	1.2208				.8261	.959
8	1.1803	1.2498				.8459	.8139
9			1.5357	1.6766	1.4786		
10			1.804	1.7253	1.6821		
11			1.7973	1.5794	1.6565		
12			2.0991	1.5623	1.5396		
13				1.4403	1.5626		
14			1.6632	1.406	1.4243		
15	.0439	.0302	1.9918	1.3535	1.4888	.0411	.0686
16	.0523	.0299	1.9381	.9145	1.3791	.0411	.0709
17	.0561	.0261	.0299		.0425	.0299	.0336
18	.0669	.0187	.0448		.0358	.0672	.0373
19	.0354	.0453	.0485	.0187	.0362	.0739	.0448
20	.0362	.0373	.0373	.028	.0638	.0887	.0635
21	.0438	.0373	.0373	.0336	.0627	.0256	.0616
22	.0514	.0373	.0336	.0243	.0543	.0224	.0373
23	1.0595	.0373	.028	.0205	.68	.8207	.622
24	1.0462	1.0669	.0336	.028	.0187	.6718	.7981
Max	1.1803	1.2498	2.0991	1.7253	1.6821	.8459	.959
Min	.0354	.0187	.028	.0187	.0187	.0224	.0336
Avg	.5945	.5567	.7758	.7417	.7361	.4129	.4482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 201 / 11 KV VALASE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0446		1.0288	.8802	.0514	.0446
2	.0343	.0446		1.046	.8322	.0514	.0446
3				1.0631	.8322		
4				1.0631	.8907		
5				1.0974	.9069		
6				1.1488	.9555		
7				1.3032	1.1488		
8			1.4232	1.4918	1.2174		
9		1.6118				1.1831	1.442
10	1.7147	1.749				1.4575	1.7661
11	1.8176	1.8004				1.4403	1.9376
12	1.7833	1.7833				1.6632	1.8347
13	1.749	1.7833				1.5775	1.869
14	1.7833	1.8004				1.5432	1.869
15	1.8004	1.9033	.0514	.0514	.0514	1.4403	1.8176
16	1.8176	1.8519	.0514	.0514	.0686	1.6118	1.7661
17	.0514		.0514	.0686	.0686	.0297	.0514
18	.0446		.0686	.0594		.0446	.0514
19	.0594		.0686	.0594		.0446	.0514
20	.0594		.0686	.0594		.0594	.0514
21	.0594		.0686	.0587		.0594	.0514
22	.0594		.0686	.044		.0446	.0514
23	.0446		1.0117	.8802		.0446	.0514
24	.0343	.0446	1.3032	1.0288	.8962	.0686	.0446
Max	1.8176	1.9033	1.4232	1.4918	1.2174	1.6632	1.9376
Min	.0343	.0446	.0514	.044	.0514	.0297	.0446
Avg	.7616	1.3107	.3850	.6446	.7291	.6897	.8220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 203 / SUGARMILL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17
HR	Load (MW)
21	.1372
24	.1543
Max	.1543
Min	.1372
Avg	.1458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 204 / 11 KV SHENDRE-VECHALE AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6801	3.4347	.0358	.1528	.0899	3.6233	3.2895
2	3.6184	3.2042	.0251	.1139	.0701	3.5071	3.0436
3	3.7132	3.2194	.0137	.0061		3.4282	2.9578
4	3.749	3.1058		.0015		3.4019	2.929
5	3.7925	3.1032				3.453	2.9988
6	3.9586	3.1146				3.634	3.0845
7	4.1373	3.5839				4.0047	3.7052
8	2.3541	4.085				4.3195	4.1294
9	2.3442	2.1643	3.277	4.3046	4.0749	2.2702	2.2032
10			4.9856	5.6264	5.6321		
11			4.7138	5.5853	6.0726		
12			4.4548	5.6935	5.9389		
13			4.0241	5.41	5.5685		
14			5.1075	5.3208	5.3167		
15	.1032	.1501	5.1901	5.2316	5.04	.0686	.1052
16	.1711	.1959	5.1939	5.1551	4.891	.2073	.1794
17	.2119	.2088	2.6813	2.1593	2.5736	.2305	.184
18	.2237	.1242	.1982	.2275	.0998	.2229	.1974
19	.2496	.1562	.2172	.2435	.0937	.2176	.2279
20	.2659	.1562	.2462	.2534	.1128	.2438	.2492
21	.2415	.1318	.2347	.2393	.1212	.2271	.2302
22	.2336	.1273	.2264	.2227	.1075	.2176	.2126
23	3.0396	.1097	.2119	.21	1.3184	3.1475	3.1253
24	3.6355	1.712	.1718	.181	1.9166	3.8081	3.3581
Max	4.1373	4.085	5.1939	5.6935	6.0726	4.3195	4.1294
Min	.1032	.1097	.0137	.0015	.0701	.0686	.1052
Avg	2.0907	1.6888	2.1689	2.3169	2.7244	2.1175	1.9163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 205 / VALASE (GAONTHAN)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2534		.2229	.2172	.2058	.2172
2	.1886	.2172		.2058	.2172	.1886	.1991
3	.2058	.2172		.1886	.2012	.1715	.1991
4	.2229	.2772		.2401	.2195	.1886	.2172
5	.2743	.2957		.3258	.2957	.2401	.2561
6	.3429	.3696		.3772	.3734	.3429	.3696
7	.4801	.4481		.4287	.3772	.4287	.4481
8	.3944	.4854	.4115	.3601	.4115	.3944	.4854
9		.3734	.3601	.3429	.3258	.4287	.3326
10	.3429	.3601	.3601	.3944	.3772	.3944	.3258
11	.3601	.3258	.3944	.3429	.3772	.3601	.2915
12	.3772	.4115	.3772	.3429	.3429	.3429	.3429
13	.3086	.4115	.3601	.2229	.3429	.3429	.2915
14	.3086	.3258	.3429	.2401	.3429	.3086	.2915
15	.3086	.3258	.3429	.2915	.3086	.2572	.2743
16	.3086	.3258	.3258	.3429	.3086	.2915	.2743
17	.3258	.3601	.2743	.3258	.3601	.4024	.3258
18	.3696		.3258	.3696		.462	.3772
19	.5415		.4287	.4294		.5041	.4115
20	.5788		.4458	.5415		.5601	.3772
21	.5415		.4287	.5041		.5415	.3429
22	.462		.4115	.4066		.4435	.3086
23	.3511		.3258	.2987		.2957	.2743
24	.2743	.3292	.2915	.2401	.2587	.2401	.2534
Max	.5788	.4854	.4458	.5415	.4115	.5601	.4854
Min	.1886	.2172	.2743	.1886	.2012	.1715	.1991
Avg	.3525	.3396	.3651	.3327	.3143	.3473	.3120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254017 / SHENDRE

Feeder No / Name : 206 / 11 KV SHENDRE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.2715
Max	.2715
Min	.2715
Avg	.2715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 302 / LIMB

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3155	.4108	.415	.415	.3772	.4108
2	.2835	.3189	.3734	.3734	.3772	.3734	.3734
3	.2835	.3189	.3734	.3734	.3734	.3734	.3734
4	.2804	.3121	.3734	.3734	.3772	.415	.3734
5	.2774	.3121	.4108	.3734	.3734	.4527	.3734
6	.2804	.3189	.5228	.439	.4435	.4481	.4481
7	.4557	.3856	.5975	.5601	.5228	.5975	.5228
8	.4557	.3898	.6722	.5121	.5228	.6283	.5228
9	.5975	.7316	.4908	.6878	.5601	.8048	.4755
10	.6348	.7316	.9465	1.0082	1.0082	.9511	.4755
11	1.0456	.9145	1.0517	1.1584	.9335	.905	.4706
12	.9335	.9877	1.0517	1.0136	.9335	1.3169	.5014
13	.8962	1.134	1.0749	.9511	.9709	1.0242	.4344
14	1.1203	1.2178	1.2269	1.0136	1.1576	.8215	.4755
15	.9709	1.39	1.0166	1.134	.8589	1.2696	
16	1.0829	1.0242	1.1218	1.0242	.7842	1.2323	
17	.9816	1.0456	.8676	1.0185	.8238	1.0082	.2987
18	.631	.5601	.695	.6722	.5487	.6348	.4854
19	.4607	.4854	.4904	.4854	.4755	.4481	.4854
20	.4207	.4854	.4854	.4854	.4024	.4108	.4904
21	.4161	.4854	.4527	.4481	.3734	.4481	.4854
22	.3856	.5228	.4481	.4527	.4108	.4854	.4854
23	.3506	.4854	.4481	.4527	.3772	.4108	.4481
24	.5594	.3155	.4481	.4108	.4527	.3772	.4108
Max	1.1203	1.39	1.2269	1.1584	1.1576	1.3169	.5228
Min	.2774	.3121	.3734	.3734	.3734	.3734	.2987
Avg	.5883	.6329	.6688	.6599	.6032	.6756	.4464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 303 / 22 KV VARYE MIX

SHEDDABLE RURAL

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	1.0242	.9816	.9511	1.0456	1.0562	.9465
2	.9511	.9979	.9465	.8676	.8589	1.0456	.9114
3	.9412	.9877	.9465	.8589	.8676	1.0456	.8764
4	.9511	.9877	.9465	.8589	.8589	1.2071	.9114
5	.9979	1.0349	1.2269	.9709	.8589	1.4335	1.0166
6	1.2803	1.4266	1.5074	1.3169	1.2197	1.5684	1.262
7	1.9959	2.0485	1.9982	2.1285	1.9044	2.1285	1.7878
8	2.268	2.3045	2.2786	2.268	2.0683	2.3655	2.0332
9	2.2085	2.3411	2.3411	2.1216	2.0683	2.2314	2.1582
10	2.1735	2.0416	2.1216	2.0119	1.9631	1.9022	2.1582
11	2.0683	2.0633	2.0851	2.0328	1.9281	1.7558	1.9547
12	1.9281	1.9547	2.0119	1.9753	1.6476	1.7558	1.7909
13	1.8229	1.8656	2.0119	1.9387	1.7177	1.6095	1.7375
14	1.6126	1.8983	1.848	1.9022	1.6126	1.6804	1.5729
15	1.6476	1.9022	1.8656	1.9418	1.5074	1.7924	
16	1.8229	2.0485	1.9022	1.4632	1.6126	1.8298	
17	2.1216	2.0332	2.1879	1.7551	1.7909	1.9631	1.6804
18	2.3045	2.0332	2.3388	1.531	2.0119	1.9631	2.1879
19	2.4508	2.1384	2.5019	2.2779	2.268	2.0683	2.3152
20	2.268	2.0332	2.3525	2.2405	2.1582	2.0332	2.1285
21	2.1948	1.858	1.9418	2.0165	1.8671	1.7528	1.7177
22	1.7924	1.4723	1.6804	1.5844	1.643	1.4723	1.4937
23	1.3535	1.1218	1.358	1.307	1.094	1.1218	1.1576
24	1.0242	1.134	1.0517	1.0456	1.1317	1.0185	.9362
Max	2.4508	2.3411	2.5019	2.2779	2.268	2.3655	2.3152
Min	.9412	.9877	.9465	.8589	.8589	1.0185	.8764
Avg	1.7142	1.6980	1.7680	1.6403	1.5710	1.6584	1.5789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254035 / WADHE

Feeder No / Name : 304 / 22 KV RAMNAGAR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3495	2.2001	.1882	.2179	.2748	1.6857	1.2045
2	2.2169	2.0397	.1852	.2126	.2225	1.6232	1.1363
3	2.1167	1.7898	.0831	.0983	.1517	1.5516	1.076
4	1.9593	1.7799			.1669	1.6225	1.0707
5	1.9951	1.912			.1402	1.8663	1.1207
6	2.0149	1.9898			.0091	1.9921	1.1603
7	2.481	2.0256				2.4067	1.3249
8	2.6746	2.3281				2.7999	1.3504
9	.8657	.7872	3.5558		2.3438	.708	.4626
10			4.3138	.3406	2.7145		
11			4.1495	2.7504	2.6723		
12			4.3679	2.886	3.7159		
13			4.2688	4.3256	3.8081		
14			4.2239	4.518	3.7197		
15	.2214	.298	3.9864	4.6921	3.3874	.2278	.0358
16	.2428	.3193	3.8352	4.5961	3.0948	.1882	
17	.271	.3091	1.6972	1.6949	1.294	.2268	.3109
18	.3117	.3137	.3308	.3498	.3414	.2614	.327
19	.314	.2896	.3315	.3399	.3559	.3	.3239
20	.3086	.3262	.3399	.3559	.3551	.2939	.3391
21	.3018	.3091	.2953	.3491	.3087	.2789	.3346
22	.2603	.2921	.285	.3269	.253	.266	.33
23	2.1967	.2466	.2598	.2816	1.7055	1.8949	2.2764
24	2.3316	1.2228	.2245	.2286	.9564	1.8423	1.7502
Max	2.6746	2.3281	4.3679	4.6921	3.8081	2.7999	2.2764
Min	.2214	.2466	.0831	.0983	.0091	.1882	.0358
Avg	1.3386	1.0936	1.9433	1.5869	1.4542	1.1598	.8852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 201 / KOPARDE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9503		1.0185		
2			.9448		.9808		
3			.9339		.9808		
4			.9339		.9808		
5			.9339		.9808		
6			.9892		.8848		
7			1.073		.9175		
8			1.0814		1.0395		
9	1.4746	1.6975				.6979	1.643
10		1.8861				1.358	1.8296
11	1.5402	1.9239				1.7541	1.9231
12	1.6221					1.8861	1.9589
13	1.6385	1.8107				1.8484	1.922
14	1.6385	1.8296				1.8484	
15	1.6766	1.8296				1.8861	
16	1.6549	1.7353				1.8484	
23		.9503		1.0374			
24			.9503		1.0374		
Max	1.6766	1.9239	1.0814	1.0374	1.0395	1.8861	1.9589
Min	1.4746	.9503	.9339	1.0374	.8848	.6979	1.643
Avg	1.6065	1.7079	.9767	1.0374	.9801	1.6409	1.8553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 202 / VENEGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241		.1928		.2452	.1753	.1991
2	.2054		.1753		.2263	.1772	.1772
3	.1867		.1772		.2075	.1753	.1772
4	.1867		.181		.2075	.1791	.1772
5	.2614		.2454		.2641	.2195	.2103
6	.4294		.4252		.4557	.3681	.3761
7	.5914		.5611		.6154	.5258	.6154
8	.5316		.5249		.5973	.5434	.5493
9	.333	.547	.439		.4887	.4527	.5041
10	.3077	.3772	.3658		.3224	.3395	.3395
11	.2715	.3584	.3292		.2534	.3395	.2987
12	.2715		.2715		.2629	.2829	.3142
13	.2629	.3206	.2896		.2629	.2829	
14	.2454	.2829	.2896		.2629	.2829	
15	.2629	.2829	.2896		.2715	.2641	
16	.2454	.3018			.2835	.2829	
17		.2804	.2439	.2343	.2715	.2629	.2641
18		.3544	.3772	.3125	.3982	.4075	.3772
19		.5609	.4904	.5959	.5792	.5373	.6224
20		.6154		.6268	.591	.6154	.6602
21		.5847		.5853	.5731	.5552	.5847
22		.4607		.5121	.4607	.4252	.4527
23		.298		.3018	.2715	.2481	.3772
24	.2427		.2103		.2641	.2279	.2172
Max	.5914	.6154	.5611	.6268	.6154	.6154	.6602
Min	.1867	.2804	.1753	.2343	.2075	.1753	.1772
Avg	.2976	.4018	.3199	.4527	.3599	.3404	.3747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254036 / VENEGAON

Feeder No / Name : 203 / NANDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4646			1.7204	1.7695
2	2.4272			1.7204	1.7695
3	2.4272			1.7204	1.7368
4	2.4086			1.7204	1.757
5	2.4086			1.7859	1.7368
6	2.4086			1.8564	1.7901
7	2.5873			2.0153	1.9559
8	2.3266			2.0317	1.9559
9		2.963	2.7854		
10		3.2106	3.1017		
11		3.658	3.0148		
12		3.1312	2.9001		
13		3.6199	2.7854		
14		3.6561	2.7035		
15		3.5837	2.6216		
16			2.5724		
23			1.7532	1.8107	1.6975
24	2.4646			1.7204	1.7532
Max	2.5873	3.658	3.1017	2.0317	1.9559
Min	2.3266	2.963	1.7532	1.7204	1.6975
Avg	2.4359	3.4032	2.6931	1.8102	1.7922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 201 / 11 KV DEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0434	.0434	.9633	.9829	.8025	.0251	.0278
2	.0394	.0429	.9482	.9701	.7716	.0251	.0274
3			.9511	.9556	.7716		
4			.945	.9556	.7621		
5			.9065	.9065	.7621		
6			1.0822	.9633	.823		
7			1.2654	1.2191	1.0105		
8			1.2793	1.2967	1.0235		
9	1.749	1.9757				1.2018	1.3283
10	2.0165	2.2186				1.6288	1.6876
11	1.9595	2.13				1.6804	1.4899
12	2.0005	2.0243				1.6204	1.4899
13	1.8343	1.9364				1.6204	1.2191
14	1.8244	1.9364				1.5278	1.2334
15	1.8724	1.8564	.0591	.0947	.0686	1.3565	1.142
16	1.8084	1.7764	.0705	.0777	.0549	1.2037	1.3226
17	.048	.0892	.0709	.0427	.0488	.0549	.0457
18	.0503	.0533	.0974	.0354	.0495	.0372	.0686
19	.0695	.0734	.0686	.0695		.0406	.0734
20	.0834	.0572	.0714	.0695	.013	.0406	.0892
21	.0695	.0587	.0572	.0676	.0259	.0463	.0714
22	.0686	.0556	.0579	.0511	.0423	.0457	.0549
23	.0463	1.0311	1.0802	.8333	.0282	.0457	.0463
24	.0434		.9907	1.0105	.8025	.0236	.0282
Max	2.0165	2.2186	1.2793	1.2967	1.0235	1.6804	1.6876
Min	.0394	.0429	.0572	.0354	.013	.0236	.0274
Avg	.8682	1.0211	.6092	.5890	.4624	.6791	.6359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 202 / VARNE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.065	1.1736	.1867	.2378	.1715	.4784	.5898
2	1.065	1.0513	.1867	.2195	.1715	.4481	.5668
3	1.065	1.0682				.4372	.502
4	1.0486	1.0513				.4372	.4961
5	1.0322	1.0343				.421	.5407
6	1.0442	1.046				.4752	.5668
7	1.2431	1.1683				.6562	.7042
8	1.326	1.3125				.7773	.8539
9			1.4074	1.4083	.953		
10			1.5023	1.6766	1.1336		
11			1.6091	1.1934	1.0883		
12			1.5935	1.3763	.9922		
13			1.4864	1.4089	.8697		
14			1.4403	1.3592	.8002		
15	.208	.2195	1.3603	1.1961	.7274	.156	.1357
16	.1928	.2195	1.3603	1.0202	.7748	.1907	.2035
17	.2103	.2614	.2012	.2058	.1875	.2829	.2454
18	.2427	.2427	.2378	.2103	.216	.2614	.2254
19	.2401	.2614	.2587	.2507	.253	.2641	.2229
20	.2572	.2241	.2772	.2534	.2561	.2614	.2353
21	.2058	.2241	.2402	.2378	.2429	.1867	.2172
22	.1886	.2241	.2402	.2378	.2241	.2452	.1991
23	1.1437	.2054	.2378	.2103	.5335	.6718	.6401
24	1.1904		.2054	.2378	.2103	.5312	.664
Max	1.326	1.3125	1.6091	1.6766	1.1336	.7773	.8539
Min	.1886	.2054	.1867	.2058	.1715	.156	.1357
Avg	.7205	.6463	.7795	.7189	.5448	.399	.4338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 203 / DEGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2534	.2149	.218	.2229	.2172	.2195
2	.1865	.2378	.197	.2012	.2229	.2012	.2172
3	.1865	.2378	.2126	.2012	.2229	.2012	.197
4	.1865	.2378	.2126	.407	.2254	.2195	.2172
5	.2427	.2561	.2481	.3646	.2454	.2561	.2534
6	.3544	.4572	.3366	.3429	.3439	.439	.4344
7	.5014	.543	.5083	.4784	.5729	.6036	.5194
8	.5028	.5194	.4973	.4557	.5249	.4733	.5316
9	.3814	.4835	.4458	.815	.4835	.4382	.4854
10	.3681	.3601	.3258	.3761	.3721	.3429	.4119
11	.3814	.3429	.3258	.3582	.4207	.373	.298
12	.3601	.3052	.3429	.3898	.3898	.3561	.3761
13	.3294	.3222	.3391	.3898	.4075	.3391	.1715
14	.3155	.3222	.3258	.3681	.4075	.3222	.3506
15	.333	.2713	.3467	.3681	.3814	.3086	.156
16	.3012	.3391	.3467	.3506	.3856	.373	.3681
17	.3898	.3561	.39	.4031	.3856	.333	.3856
18	.3841	.3467	.407	.3544	.373	.3856	.4031
19	.5068	.4784	.567	.4908	.5552	.4908	.4458
20	.543	.5194	.543	.5068	.5731	.5731	.5249
21	.4887	.4887	.4755	.4525	.4656	.4887	.4706
22	.4525	.4163	.3658	.4163	.4075	.4572	.4344
23	.2896	.2658	.2572	.3086	.2896	.3326	.3045
24	.2659		.2658	.2601	.2774	.2353	.2303
Max	.543	.543	.567	.815	.5731	.6036	.5316
Min	.1865	.2378	.197	.2012	.2229	.2012	.156
Avg	.3517	.3635	.3541	.3866	.3815	.3650	.3503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 204 / 11 KV CHINCHNER GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1409	.1246	.1854	.172	.0796	.1198	.1398
2	.1399	.1208	.1635	.1509	.1483	.1191	.1387
3	.141	.1193	.1611	.149	.1471	.1178	.1357
4	.146	.1235	.1768	.1555	.1498	.1204	.1592
5	.1987	.1749	.2189	.2182	.1909	.1544	.2053
6	.3152	.2637	.3498	.3453	.2957	.2579	.3162
7	.4641	.3906	.4891	.4914	.4084	.3346	.4603
8	.4378	.3418	.4424	.4435	.381	.3181	.4071
9	.3666	.2961	.3613	.3589	.3354	.2606	.3472
10	.2957	.2572	.2532	.2217	.2652	.2396	.1917
11	.2404	.1924	.2267	.2142	.2048	.2206	.184
12	.2305	.1972	.2144	.2225	.3136	.2099	.2069
13	.2056	.1924	.2092	.1974	.2841	.2187	.1825
14	.2229	.1848	.1973	.1989	.2578	.2113	.1755
15	.2179	.1851	.1719	.1993	.2607	.2113	.1772
16	.0644	.1855	.1889	.1943	.2282	.2277	.1733
17	.21	.193	.1987	.2156	.1799	.2686	.1905
18	.2655	.2435	.2551	.2635	.2248	.2629	.277
19	.3468	.4174	.3902	.3795	.3319	.3675	.3864
20	.3303	.4489	.3837	.4005	.2999	.4275	.3978
21	.2827	.4233	.3803	.3605	.2686	.338	.346
22	.2313	.3365	.3353	.3006	.2176	.2975	.2932
23	.1566	.2431	.2524	.2245	.1794	.215	.2249
24	.1358	.1002	.205	.1955	.1608	.1509	.16
Max	.4641	.4489	.4891	.4914	.4084	.4275	.4603
Min	.0644	.1002	.1611	.149	.0796	.1178	.1357
Avg	.2411	.2398	.2671	.2614	.2422	.2362	.2449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254037 / NIGADI

Feeder No / Name : 205 / 11KV VARNE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1267	.0895	.1017	.1052	.128	.128
2	.1029	.1097	.1086	.1017	.0876	.1086	.1075
3	.1029	.1097	.1075	.1006	.0876	.0549	.1063
4	.1029	.1097	.1075	.1006	.0876	.1097	.1075
5	.1387	.1097	.1227	.1147	.104	.128	.1267
6	.1949	.2561	.2126	.2229	.208	.2195	.2328
7	.3224	.3801	.333	.3012	.3439	.3109	.3403
8	.2804	.3045	.3155	.298	.3045	.298	.3366
9	.2279	.2328	.2629	.2658	.3045	.2534	.2427
10	.2347	.1907	.1865	.2103	.218	.1509	.1949
11	.2035	.1715	.2058	.1387	.1658	.1509	.1791
12	.1543	.1543	.1844	.156	.1844	.1509	.1612
13	.156	.1543	.2058	.1612	.1543	.1658	.1204
14		.1543	.1715	.1387	.156	.1844	.1296
15	.12	.1543	.1543	.1734	.1509	.1357	.1543
16	.1372	.1543	.1734	.156	.1886	.1509	.1753
17	.1734	.2035	.1886	.1578	.1791	.128	.1886
18	.2195	.1907	.1907	.1928	.2229	.1772	.2454
19	.2896	.3086	.2481	.2865	.2507	.2915	.3189
20	.3109	.3403	.3439	.3475	.2686	.3045	.3475
21	.2896	.3258	.3109	.3142	.3045	.3258	.3109
22	.2378	.2896	.2561	.2587	.2303	.2715	.2353
23	.1463	.1086	.156	.156	.181	.1791	.1612
24	.1267	.3045	.1086	.1227	.1227	.128	.1267
Max	.3224	.3801	.3439	.3475	.3439	.3258	.3475
Min	.1029	.1086	.0895	.1006	.0876	.0549	.1063
Avg	.1902	.2060	.1977	.1907	.1921	.1878	.1991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 201 / 11 kv BHATMARALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.7865	.0381	.0343	.0343	.6516	.6173
2	.7202	.7362		.0343	.0343	.6485	.5959
3	.7373	.703				.6203	.5144
4	.7545	.6562				.6859	.5144
5	.7716	.7125				.6516	.5609
6	.7716	.7748				.8048	.7202
7	1.046	1.1305				.9774	.8573
8	1.2517	1.1873				1.1431	.9724
9			1.7147	1.2631	1.3272		
10			1.7147	1.406	1.5893		
11			1.7147	1.3599	1.5238		
12			1.749	1.4575	1.3441		
13			1.6289	1.2492	1.3108		
14			1.6289	1.2323	1.3203		
15	.0381	.0343	1.4575	1.1145	1.1984	.0343	.0328
16	.0366	.0343	1.3546	1.2517	1.1469	.0343	.0309
17	.0328	.0362	.0343	.0343	.0312	.0572	.0343
18	.0316	.0366	.0343	.0343	.0381	.0572	.0343
19	.0486	.0351	.0343	.0343	.0572	.0572	.0343
20	.0469	.0572	.0343	.0343	.0572	.0572	.0343
21	.0469	.0572	.0343	.0343	.0572	.0572	.0343
22	.048	.0572	.0343	.0343	.0572	.0572	.0514
23	.8097	.0572	.0343	.0343	.6859	.6344	.6516
24	.0343	.8356	.0381	.0343	.0343	.6661	.6036
Max	1.2517	1.1873	1.749	1.4575	1.5893	1.1431	.9724
Min	.0316	.0343	.0343	.0343	.0312	.0343	.0309
Avg	.4443	.4404	.7811	.5932	.6582	.4386	.3830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 202 / 11 KV KUSAVADE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2126	.1905	.2058	.1372	.2286	.1715
2	.1715	.2103	.2096	.1715	.1372	.1905	.1905
3	.1886	.1991	.1905	.1543	.1543	.1905	.1715
4	.2058	.1867	.1905	.1543	.1543	.1715	.1524
5	.2401	.2534	.2286	.2058	.2058	.2286	.1905
6	.2915	.3155	.3429	.4115	.2915	.3048	.3429
7	.4287	.4382	.4763	.4973	.4252	.4572	.4954
8	.3944	.4031	.4191	.3932	.4298	.4191	.4382
9	.3429	.3086	.2572	.4075	.3761	.2915	.3605
10	.3429	.3258	.2915	.3582	.3506	.2915	.3721
11	.3429	.3086	.3258	.333	.3506	.2743	.3366
12	.3429	.3258	.3258	.3155	.3189	.2572	.3224
13	.2286	.2401	.2915	.2987	.3155	.2401	.2835
14	.3429	.2572	.2572	.2835	.3012	.2743	.2279
15	.3239	.2743	.2572	.2572	.2835	.2915	.124
16	.3429	.2743	.3086	.2915	.3403	.2915	.1928
17	.3189	.3429	.3429	.3086	.3403	.3429	.2229
18	.4031	.362	.3772	.3772	.3048	.3429	.3086
19	.4578	.4954	.5487	.5144	.4954	.5144	.3601
20	.5493	.5335	.5487	.463	.5525	.5335	.4458
21	.4961	.4954	.4458	.4115	.4954	.4572	.4115
22	.4163	.4191	.4115	.3772	.4191	.3429	.3429
23	.3439	.2667	.2743	.0257	.2667	.2286	.2229
24	.1715	.2896	.1905	.2743	.1372	.2286	.1905
Max	.5493	.5335	.5487	.5144	.5525	.5335	.4954
Min	.1715	.1867	.1905	.0257	.1372	.1715	.124
Avg	.3289	.3224	.3209	.3121	.3160	.3081	.2866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 203 / 11 kv PADALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0838	.6878	.7716	.7202	.0953	.0953
2	.0343	.0819	.6001	.7545	.7373	.0953	.0953
3			.5658	.7202	.6859		
4			.5658	.7373	.6516		
5			.631	.7373	.6516		
6			.6859	.7373	.6516		
7			.7888	.8745	.823		
8			.9431	1.046	.9503		
9	1.8107	1.8519				1.6804	1.7859
10	1.9547	1.8519				1.9547	1.7695
11	1.9547	1.8519				2.0405	1.8351
12	1.8107	1.8347				2.0576	1.8785
13	1.858	1.8176				2.0576	1.8842
14	1.8004	1.8176				2.0405	1.8275
15	1.7772	1.8176	.0343	.0857	.1341	1.989	1.6057
16	1.8004	1.749	.0514	.0857	.1265	1.9376	1.5844
17	.0819	.0953	.0343	.0514	.1311	.0953	.0343
18	.128	.0953	.0343	.0514	.1524	.0953	.0343
19	.1296	.0953	.0514	.0034	.1524	.1143	.0514
20	.124	.0953	.0686	.1372	.1524	.1143	.0857
21	.1094	.0953	.1372	.1372	.1143	.1143	.0514
22	.1107	.0953	.0343	.0514	.1143	.0953	.0514
23	.1147	.6859	.7888	.8402	.0953	.0953	.0514
24	.0343	.0819	.6859	.7888	.7888	.0953	.0953
Max	1.9547	1.8519	.9431	1.046	.9503	2.0576	1.8842
Min	.0343	.0819	.0343	.0034	.0953	.0953	.0343
Avg	.8704	.8943	.4105	.4784	.4352	.9316	.8231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 254068 / BHATMARALI

Feeder No / Name : 204 / 11 KV NINAM GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1772	.1524	.1543	.1543	.1715	.1524
2	.1372	.1753	.1334	.1372	.1372	.1524	.1524
3	.1372	.1629	.1334	.1372	.1372	.1524	.1334
4	.1543	.1612	.1334	.1543	.1543	.1334	.1334
5	.2572	.2241	.1715	.2058	.2058	.1905	.1715
6	.2915	.2896	.3429	.3086	.2743	.3048	.3429
7	.3429	.4525	.4572	.4115	.407	.4572	.4763
8	.3429	.362	.8764	.4458	.4024	.381	.381
9	.8383	.3429	.2401	.4607	.4252	.4115	.3155
10	.8002	.463	.3258	.6556	.8688	.6344	.2454
11	.9526	.6859	.463	.8916	1.0164	.6859	.218
12	.9145	.5144	.5487	.8916	.7011	.8059	.1928
13	.6097	.3429	.6687	.823	.5552	.8059	.1753
14	.4954	.3429	.8402	.4115	.6697	.8059	.1595
15	.4191	.3429	.9602	.3772	.7712	.823	.181
16	.4191	.4287	.823	.5316	.7087	.8573	.2686
17	.5083		.6001	.3086	.5375	.6287	.2915
18	.3544	.3239	.6001	.7202	.9526	.8002	.3601
19	.4344	.4191	.463	1.0288	.4763	.8383	.3772
20	.4508	.4572	.4287	.8573	.4954	.5335	.4458
21	.4119	.4191	.3772	.3772	.4572	.4572	.4115
22	.3366	.3429	.3258	.3086	.3429	.3429	.3429
23	.2507	.2286	.1886	.1886	.2286	.2096	.1886
24	.3086	.1991		.1715	.1543	.1715	.1715
Max	.9526	.6859	.9602	1.0288	1.0164	.8573	.4763
Min	.1372	.1612	.1334	.1372	.1372	.1334	.1334
Avg	.4301	.3417	.4458	.4566	.4681	.4898	.2620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 201 / 11 KV KHOJEWADI SINGLE PH. SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.6143
10		5.2839	
24	.5975		
Max	.5975	5.2839	.6143
Min	.5975	5.2839	.6143
Avg	.5975	5.2839	.6143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 202 / 11 KV SATARA SINGLE PH. SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17
HR	Load (MW)	Load (MW)
10		3.8836
24	.8775	
Max	.8775	3.8836
Min	.8775	3.8836
Avg	.8775	3.8836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 203 / 11 KV UMBRAJ SINGLE PH.

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17
HR	Load (MW)	Load (MW)
10		3.9956
24	.8215	
Max	.8215	3.9956
Min	.8215	3.9956
Avg	.8215	3.9956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 204 / 11 KV KAY PULP

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17	02-MAR-17
HR	Load (MW)	Load (MW)
10		.2203
24	.9335	
Max	.9335	.2203
Min	.9335	.2203
Avg	.9335	.2203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 403 / 33 KV KIRLOSKAR EXPRESS

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	1.7204
Max	1.7204
Min	1.7204
Avg	1.7204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

SATARA[118]

BU 0931

Substation No/ Name :- 256008 / 110 KV ATIT

Feeder No / Name : 408 / 33 KV SHAHU LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-MAR-17	02-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				.056
10		.1008		
24	.056		.056	
Max	.056	.1008	.056	.056
Min	.056	.1008	.056	.056
Avg	.056	.1008	.056	.056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 301 / PIMPODE Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.096	.0983	.1715	1.2803	1.166	1.2346	.096
2	.096	.0983	.1372	1.2163	1.1984	1.0974	.096
3	.096	.0983	.1372	1.2163	1.2308	1.0974	.096
4	.096	.0983	.1372	1.2163	1.2631	1.166	.096
5	.128	.0983	.1372	1.2803	1.2955	1.2346	.16
6	.192	.1638	.2401	1.3443	1.3279	1.3717	.192
7	.192	.2622	.3086	1.9845	1.8785	1.6461	.192
8	.1966	.2294	.2401	2.2405	.1296	1.8176	.16
9	1.8351	1.9662	.2058	.2241		2.1262	1.7604
10	2.1052	2.332	.128	.2294		2.0165	1.8461
11	1.9757	2.2634	.096	.1966		1.9845	2.0405
12	1.8785	2.1948	.064	.1966	.2401	1.8564	1.9433
13	1.6518	1.989	.064	.2294	.2401	1.6644	1.8785
14	1.7166	1.989	.096	.0983	.2058	1.6004	1.6842
15	1.7814	1.9204	.096	.1638	.2058	1.6644	1.8138
16	1.8785	2.1262	.0983	.1966	.2058	1.7284	1.7166
17	.2267	.2058	.16	.2294	.2401	.192	.2267
18	.1943	.2401	.096	.2294		.128	.1943
19	.2591	.3086	.2241	.2622	.2743	.16	.2267
20	.2591	.3086	.2241	.2622	.2743	.16	.2267
21	.1966	.2743	.2241	.2294	.2401	.16	.2267
22	.1638	.2401	.128	.2294	.2401	.128	.2267
23	.1311	.1372	1.4403	1.2125	1.3032	.128	.1619
24	.128	.0983	.1715	1.3443	1.1797	1.2689	.096
Max	2.1052	2.332	1.4403	2.2405	1.8785	2.1262	2.0405
Min	.096	.0983	.064	.0983	.1296	.128	.096
Avg	.7281	.8225	.2094	.7214	.7170	1.1513	.7232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 302 / 22KV PIMPODE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1905	.1715	.1867	.2286	.2401	.1867
2	.1867	.2263	.1715	.1867	.1905	.2058	.1867
3	.1867	.3018	.1715	.1867	.2667	.2058	.1867
4	.2987	.3772	.2058	.2241	.3429	.2401	.2241
5	.3734	.4527	.2743	.3734	.4191	.3086	.3734
6	.5228	.5281	.4115	.5228	.4954	.4458	.5228
7	.4481	.6036	.4801	.5975	.4572	.6173	.5975
8	.4854	.4904	.4801	.4854	.4527	.4458	.4854
9	.4108	.415	.3772	.3734	.4481	.4115	.3734
10	.3734	.3086	.3361	.4024	.3086	.3734	.2667
11	.2957	.2743	.3361	.3326		.3361	.2587
12	.3326	.2743	.2987	.3326	.4115	.2987	.2987
13	.2987	.2401	.2987	.2957	.2743	.2241	.2987
14	.2987		.2614	.2587	.2401	.2241	.2614
15	.2614		.2614	.2587	.2743	.2241	.2172
16	.2614		.2614	.2957	.2743	.2614	.2218
17	.2987	.2743	.2987	.3658	.2743	.2987	.3121
18	.3734	.3429	.3361	.3506	.3429	.3361	.3155
19	.5544	.583	.5228	.5544	.5487	.5601	.5601
20	.6653	.6516	.6348	.6722	.6173	.6348	.6348
21	.5975	.5487	.5975	.6348	.583	.5975	.6036
22	.4527	.4458	.4854	.4904	.4458	.4481	.4904
23	.2667	.2743	.2987	.3018	.3086	.2614	.3018
24	.2241	.2286	.1715	.1867	.2286	.2058	.1867
Max	.6653	.6516	.6348	.6722	.6173	.6348	.6348
Min	.1867	.1905	.1715	.1867	.1905	.2058	.1867
Avg	.3606	.3825	.3393	.3696	.3667	.3502	.3485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 303 / SONKE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2286	.1715	.1867	.1905	.1715	.1867
2	.2241	.2641	.1715	.1867	.1905	.1715	.1867
3	.2241	.3395	.1715	.1867	.2286	.1715	.1867
4	.3734	.3772	.2058	.2614	.3048	.2058	.2241
5	.4481	.4527	.2401	.3734	.381	.2743	.2987
6	.5228	.5281	.4801	.4854	.4572	.4115	.4481
7	.7095	.679	.583	.6348	.6478	.5487	.5975
8	.6348	.5658	.5144	.5601	.6036	.4458	.5228
9	.4854	.4481	.3429	.4108	.4755	.3772	.3734
10	.3734	.3086	.2987	.2896	.3429	.2614	.2641
11	.2614	.3086	.2987	.2926	.2743	.2614	.2587
12	.2641	.3086	.2614	.2957	.2743	.2614	.2561
13	.2241	.2058	.2241	.2587	.2401	.2241	.2507
14	.2241	.2058	.2241	.2267	.2058	.1867	.2218
15	.2241	.2401	.2614	.2263	.2058	.1867	.2195
16	.2241	.2401	.2614	.1886	.2401	.2241	.2614
17	.2614	.2401	.3361	.2149	.2058	.2241	.2507
18	.3734	.3429	.2614	.2865	.2743	.0747	.2561
19	.5487	.4801	.5228	.5175	.5144	.4854	.4854
20	.6283	.4801	.5975	.5975	.5144	.5601	.5975
21	.5544	.4801	.5228	.5228	.4458	.4854	.5281
22	.415	.3429	.4481	.415	.3429	.3734	.4191
23	.3048	.2401	.2614	.2286	.2058	.2614	.2286
24	.2241	.2286	.1715	.2241	.2743	.1715	.1867
Max	.7095	.679	.5975	.6348	.6478	.5601	.5975
Min	.2241	.2058	.1715	.1867	.1905	.0747	.1867
Avg	.3730	.3557	.3263	.3363	.3350	.2925	.3212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 304 / 22 KV SONAKE AG FEEDER
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6226	.5182	.583	.2294	.2561	.2401	.6882
2	.5571	.5376	.5487	.1966	.3048	.2401	.6226
3	.5571	.5693	.5144	.1966	.2561	.2401	.7095
4	.5898	.5693	.5144	.2294	.2561	.2401	.6554
5	.6554	.6009	.5144	.2622	.2881	.2743	.6882
6	.7537	.6009	.6516	.2949	.2881	.3086	.7209
7	1.0159	.9175	.7888	.2949	.381	.3086	.9175
8	1.0159	1.0688	.8916	.2622	.3429	.3086	.9831
9	.2622	.2667	.8573	.9175	.8322	.2743	.2294
10	.3048	.2401	1.0159	1.004	1.0974	.2622	.3048
11	.3429	.2401	.9503	.9069	1.0974	.2622	.2667
12	.3048	.2401	.852	.8421	1.0974	.2949	.2667
13	.3048	.2743	.7865	.9069	1.0974	.2622	.3429
14	.3048	.2743	.8192	.9069	1.0288	.2622	.381
15	.3429	.3086	.8848	.8745	1.0288	.2622	.4572
16	.3429	.2743	.8192	.8745	.9259	.2622	.4572
17	.3048	.3429	.2949	.3429	.2743	.2622	.3429
18	.3429	.3429	.1966	.3429	.3086	.2949	.4527
19	.381	.4115	.3605	.3429	.3086	.3605	.415
20	.381	.3772	.2949	.3429	.3086	.3277	.3772
21	.3429	.3772	.2949	.3429	.3086	.3277	.3772
22	.3048	.3429	.2949	.3429	.2743	.2949	.3772
23	.6882	.6173	.2622	.3429	.2743	.7537	.6401
24	.6226	.6226	.583	.2294	.2561	.2401	.6882
Max	1.0159	1.0688	1.0159	1.004	1.0974	.7537	.9831
Min	.2622	.2401	.1966	.1966	.2561	.2401	.2294
Avg	.4852	.4556	.6073	.4929	.5372	.2985	.5151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 305 / 22 KV WATHAR (GAOTHAN)

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.4481	.4458	.2614	.3734	.4801	.4854
2	.2614	.4904	.4458	.2614	.4854	.4458	.4854
3	.2614	.5281	.4458	.2614	.4854	.4458	.4481
4	.2987	.5658	.4458	.3361	.4854	.4458	.4854
5	.4481	.6036	.4458	.4481	.5228	.4801	.5228
6	.5601	.679	.5487	.5601	.5228	.5144	.5975
7	.6722	.679	.6516	.6722	.6722	.6516	.6722
8	.5975	.6413	.583	.6348	.6348	.5487	.6348
9	.5228	.5281	.4115	.5601	.5601	.4458	.5228
10	.7922	.583	.4108	.5228	.4801	.5601	.7095
11	.7167	.5487	.4108	.4108	.5487	.7095	.5975
12	.7167	.583	.4108	.4108	.583	.5601	.5975
13	.3772	.3429	.4108	.3734	.583	.3734	.5228
14	.3772	.4801	.3734	.4108	.5487	.2949	.2987
15	.3395	.583	.3734	.4481	.5487	.3361	.5228
16	.3395	.5144	.3361	.3734	.4115	.6722	.5975
17	.415	.6516	.4108	.3734	.3429	.5975	.5975
18	.7545	.6516	.4108	.4481	.4115	.7468	.6722
19	.6722	.6516	.6722	.7468	.6859	.5601	.6348
20	.7095	.6516	.7095	.7842	.6859	.7842	.7842
21	.5975	.3086	.5975	.6348	.583	.6722	.6348
22	.7468	.2743	.5601	.5601	.6859	.7468	.5601
23	.5658	.5144	.3734	.5601	.5144	.5601	.5975
24	.4108	.4527	.4458	.2987	.2987	.5144	.4854
Max	.7922	.679	.7095	.7842	.6859	.7842	.7842
Min	.2614	.2743	.3361	.2614	.2987	.2949	.2987
Avg	.5173	.5398	.4721	.4730	.5273	.5478	.5695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 306 / 22 KV WATHAR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.2267	.2401	1.3108	1.3108	1.2346	.2622
2	.1966	.2294	.2401	1.2803	1.2452	1.166	.2622
3	.1966	.2622	.2401	1.3108	1.278	1.166	.2622
4	.1966	.2622	.2743	1.3108	1.3108	1.166	.2949
5	.2622	.2949	.2743	1.3108	1.3435	1.2346	.2949
6	.3277	.3277	.3429	1.3108	1.4091	1.3717	.3277
7	.3605	.3605	.4115	1.9662	1.9006	1.5775	.3605
8	.2949	.3277	.3086	2.0972	2.1376	1.7833	.3277
9	1.9662	1.9989	.3429	.3277	.2622	2.1262	1.5729
10	2.2283	2.4348	.2622	.2915	.2401	1.9662	1.9662
11	2.1956	2.4006	.2294	.2591	.2401	1.8351	1.9662
12	2.0972	2.3663	.2241	.2591	.2401	1.9662	1.8679
13		1.9547	.2294	.2591	.2743	1.8351	1.5402
14		1.989	.2949	.2591	.3086	1.704	1.587
15		2.0233	.2294	.2591	.2743	1.704	1.587
16		2.0919	.2294	.2267	.2743	1.704	1.6518
17		.2058	.2294	.2267		.2622	.192
18		.2401		.2267	.2743	.2949	.192
19	.2915	.3429	.3277	.3239	.2743	.3605	.3201
20	.3239	.3429	.3605	.3277	.3429	.3605	.3201
21	.2915		.3277	.2949	.3086	.3277	.3201
22	.2915		.2949	.2622	.2401	.2949	.3201
23	.2591	.2743	1.4419	1.3763	1.2689	.2949	.2561
24	1.5242	.2294	.2401	1.4419	1.3763	1.2346	.2622
Max	2.2283	2.4348	1.4419	2.0972	2.1376	2.1262	1.9662
Min	.1966	.2058	.2241	.2267	.2401	.2622	.192
Avg	.7500	.9630	.3303	.7716	.7885	1.2071	.7631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254034 / PIMPODA

Feeder No / Name : 307 / 22 KV Nandwal AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6303	.4946	.5471	1.6324	1.3679	1.3744	.6744
2	.5685	.5182	.5144	1.4937	1.2323	1.2791	.4763
3	.5685	.5551	.5052	1.2932	1.1309	1.2243	.4093
4	.6356	.5567	.4763	1.214	1.0882	1.1473	.4489
5	.7087	.6089	.4337	1.2346	1.1012	1.1031	.5556
6	.8459	.6608	.7788	1.5234	1.3809	1.2494	.6957
7	1.5036	1.2437	1.041	2.2123	2.037	1.6663	1.3222
8	1.563	1.4095	1.1766	2.5903	2.3259	1.9551	1.4121
9	1.9959	2.0668	.2522	3.0224	.7865	2.2584	1.877
10	2.4615	2.5701	.9595	.3025	.823	2.4592	2.2489
11	2.4135	2.6112	1.0524	1.2007	.8573	2.4729	2.3548
12	2.2702	2.5007	1.057	1.1484	1.0196	2.3838	2.3419
13	2.1712	2.327	1.0814	1.0829	1.1484	2.2108	2.2192
14	1.8724	2.2058	1.0205	1.0524	1.1057	1.9898	2.1788
15	1.9189	2.1334	1.0128	.772	1.1294	1.9913	1.9928
16	2.1864	2.2851	.9808	.8714	1.057	2.0675	2.1239
17	1.8176	2.1106	.2484	.2614	.2633	1.8625	1.6583
18	.2545	.2389	.2538	.2637	.2938	.2682	.2507
19	.2812	.3242	.2789	.2858	.2877	.2614	.2644
20	.3109	.341	.3185	.3223	.3227	.3185	.3094
21	.2934	.3265	.3223	.3071	.309	.3094	.2865
22	.2294	.3006	.3033	.2919	.2911	.2362	.2781
23	.8116	.7415	1.6781	1.2917	1.4224	.8215	.7232
24	.6439	.7156	2.114	1.4769	1.4769	.1543	.7423
Max	2.4615	2.6112	2.114	3.0224	2.3259	2.4729	2.3548
Min	.2294	.2389	.2484	.2614	.2633	.1543	.2507
Avg	1.2065	1.2436	.7670	1.1311	1.0108	1.3777	1.1602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 301 / 22KV Koregaon

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0974	1.0288	1.0631	.9755	1.0288	.9602
2	.884	1.166	.8916	1.1317	.9145	.9602	.9602
3	.9145	1.2346	.7888	1.0974	.9755	1.0288	.8916
4	.9755	1.2003	.7888	1.0631	1.0669	1.0974	.8916
5	1.4327	1.166	.9602	1.1317	1.1888	1.0631	.8573
6	1.6461	1.4403	1.6804	1.6804	1.4327	1.6804	1.0974
7	2.0729	2.2977	1.9204	2.2977	1.9814	2.332	2.1948
8	2.1033	2.332	2.332	2.1605	2.2291	2.2291	2.2291
9	2.1262	1.9547	1.9204	1.5546	1.9204	1.7833	1.7071
10	1.749	1.749	1.749	1.4632	1.749	1.5432	1.7071
11	1.7147	1.6804	1.6461	1.4022	1.4746	1.5089	1.3108
12	1.6461	1.4746	1.4746	1.3413	1.4403	1.5775	1.1584
13	1.5432	1.4403	1.406	1.3413	1.406	1.5775	1.1279
14	1.4403	1.406	1.4403	1.3413	1.4746	1.4403	1.1279
15	1.5089	1.4746	1.406	1.3717	1.4403	1.3032	1.1584
16	1.5775	1.4403	1.4746	1.4327	1.4746	1.2346	1.1888
17	1.6461	1.5432	1.6118	1.4937	1.4403	1.2346	1.5851
18	1.7833	1.5242	1.749	1.5242	1.6118	1.4403	1.4022
19	2.4348	2.4691	2.2291	2.1948	2.332	2.3663	1.89
20	2.4006	2.2977	2.4348	2.0729	2.4006	2.332	1.9204
21	2.2291	1.8519	2.1262	1.829	2.1948	1.7833	1.829
22	1.9204	1.9204	1.8176	1.6461	1.8176	1.5432	1.6156
23	1.4746	1.3717	1.5089	1.1888	1.406	1.3717	1.2193
24	2.4997	.1166	.1097	1.1317	1.0669	1.0974	1.0974
Max	2.4997	2.4691	2.4348	2.2977	2.4006	2.3663	2.2291
Min	.884	.1166	.1097	1.0631	.9145	.9602	.8573
Avg	1.6933	1.5687	1.5206	1.4981	1.5589	1.5232	1.3803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 303 / 22 KV DEURGAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2058	.2058	.1715	.1524	.1715	.1715
2	.1524	.1715	.2401	.2058	.1524	.2058	.1715
3	.1219	.1715	.2058	.1715	.1829	.1715	.1715
4	.1524	.1715	.1715	.2058	.1524	.1715	.1372
5	.2134	.1715	.2743	.1715	.2743	.2058	.1715
6	.3658	.2743	.3429	.2743	.3658	.3086	.2743
7	.4572	.5487	.3429	.5487	.4572	.5144	.5144
8	.4268	.4458	.3772	.4801	.4801	.5487	.4801
9	.4115	.4115	.3772	.3658	.3772	.4115	.3353
10	.3429	.2743	.2743	.3048	.2743	.3429	.3353
11	.4115	.2401	.2401	.2743	.2401	.2743	.2439
12	.3429	.2058	.2401	.2439	.2401	.2743	.2439
13	.3429	.2058	.2058	.2134	.2743	.2401	.2134
14	.3086	.2401	.2058	.2134	.2401	.2743	.1829
15	.3086	.2058	.1715	.2134	.2401	.2058	.2134
16	.3086	.2401	.2058	.2439	.2743	.2058	
17	.3086	.2743	.2743	.2743	.2058	.2401	.2743
18	.6173	.2743	.3772	.3048	.2743	.3429	.3048
19	.6859	.6859	.6173	.5792	.5487	.6859	.4877
20	.6173	.6173	.6516	.5182	.6173	.6173	.5487
21	.5487	.5487	.5487	.3658	.5487	.4801	.4572
22	.4115	.4801	.4458	.3658	.4115	.4115	.3963
23	.2743	.3429	.2743	.2134	.2401	.3429	.2743
24	.1829	.1715	.1715	.1715	.1829	.1715	.2058
Max	.6859	.6859	.6516	.5792	.6173	.6859	.5487
Min	.1219	.1715	.1715	.1715	.1524	.1715	.1372
Avg	.3528	.3158	.3101	.2956	.3086	.3258	.2961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 254070 / 22 KV Switching Station

Satara

Feeder No / Name : 304 / 22KV KINHAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.3429	.2743	.2743	.2439	.2401	.2743
2	.2134	.3429	.2401	.2401	.2439	.2743	.3086
3	.2743	.3429	.2058	.2743	.2743	.2401	.2743
4	.3658	.3772	.2743	.2401	.3658	.2401	.2401
5	.5792	.3429	.3429	.3086	.4572	.2743	.2743
6	.5792	.6173	.5487	.4458	.5792	.583	.3429
7	.7621	.823	.6173	.8573	.823	.7888	.7545
8	.6706	.7545	.6859	.7888	.7202	.8573	.6173
9	.6859	.583	.6173	.5487	.583	.7545	.5487
10	.3429	.5144	.4801	.4268	.4458	.6859	.4268
11	.3429	.4115	.4115	.3658	.4115	.6173	.3963
12	.3772	.4458	.4458	.3658	.3429	.4115	.3353
13	.4115	.3772	.3086	.3658	.3086	.4115	.3963
14	.3429	.4458	.3429	.3658	.3772	.4801	.3353
15	.3772	.3429		.3658	.3429	.5487	.3048
16	.3429	.3772		.3658	.4115	.4115	.3658
17	.4115	.4801		.4268	.4458	.4801	.3963
18	.6173	.6859	.6173	.4268	.5144	.6859	.4877
19	.7545	.9602	.8573	.6097	.7888	.823	.7316
20	.7888	.8916	.8916	.7926	.823	.7545	.7316
21	.6859	.6859	.7888	.6401	.7202	.6859	.6401
22	.5487	.5144	.583	.5182	.5487	.6173	.5182
23	.4115	.3429	.4115	.3353	.3772	.5144	.3353
24	.2743	.3086	.3086	.3429	.3048	.2743	.2743
Max	.7888	.9602	.8916	.8573	.823	.8573	.7545
Min	.2134	.3086	.2058	.2401	.2439	.2401	.2401
Avg	.4739	.5130	.4883	.4455	.4772	.5273	.4296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 301 / WATHAR i.e. 22KV KINHAI SEPARATED AG FEEDERS HAVING SPECIAL
 AG. Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		.2401	7.8532		7.3731		
24	5.3155	5.3498	.2058	.3429	.3467	4.3896	5.0755
Max	5.3155	5.3498	7.8532	.3429	7.3731	4.3896	5.0755
Min	5.3155	.2401	.2058	.3429	.3467	4.3896	5.0755
Avg	5.3155	2.7950	4.0295	.3429	3.8599	4.3896	5.0755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 303 / 22 KV COOPER

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		.4458	1.6804		.5144		
24	.4801	1.5089	.4115	1.0288	1.5257	1.3717	.3429
Max	.4801	1.5089	1.6804	1.0288	1.5257	1.3717	.3429
Min	.4801	.4458	.4115	1.0288	.5144	1.3717	.3429
Avg	.4801	.9774	1.0460	1.0288	1.0201	1.3717	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 304 / 22KV BHUINJ i.e. 22KV SEPARATED AG FEEDERS HAVING SPECIAL
 DEUR AG Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		7.0988	.4801		.3772		
24	.3086	.3429	4.1152	4.8011	4.8544	.3429	.4115
Max	.3086	7.0988	4.1152	4.8011	4.8544	.3429	.4115
Min	.3086	.3429	.4801	4.8011	.3772	.3429	.4115
Avg	.3086	3.7209	2.2977	4.8011	2.6158	.3429	.4115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 406 / 33KV WANGANA LIS

PURELY LIS FEEDERS

Feeder KV- 33 / INCOMING

DATE	02-MAR-17	03-MAR-17	05-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
12	.0514	.0514	.0514
Max	.0514	.0514	.0514
Min	.0514	.0514	.0514
Avg	.0514	.0514	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

SATARA DIVISION[516]

WATHAR[123]

BU 0981

Substation No/ Name :- 256002 / 110 KV SATARA-ROAD

Feeder No / Name : 407 / 33KV VASANA

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	02-MAR-17	03-MAR-17	05-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
12	.0514	.0514	.0514
Max	.0514	.0514	.0514
Min	.0514	.0514	.0514
Avg	.0514	.0514	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 201 / 11 KV Aundh Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056	.0686	.0747	.056	.056	.0701
2	.056	.056	.0686	.0747	.056	.056	.0701
3	.056	.056	.0686	.0747	.056	.056	.0701
4	.056	.056	.0686	.0747	.056	.056	.0701
5	.0747	.056	.0686	.0747	.056	.0747	.0701
6	.1086	.0945	.1532	.1204	.112	.0934	.125
7	.256	.2744	.234	.2309	.2408	.2294	.2386
8	.2344	.2686	.2043	.202	.2214	.2123	.208
9	.1863	.2115	.1745	.1844	.1581	.1776	.1593
10	.1292	.1471	.1707	.1402	.1444	.1421	.1631
11	.059	.0755	.0922	.0755	.136	.1471	.0861
12	.0613	.0686	.0876	.0712	.0613	.0709	.0861
13	.056	.0739	.0762	.0781	.0705	.112	.077
14	.056	.0701	.0846	.0577	.0751	.1608	.0861
15	.0679	.0838	.0724	.0735	.0987	.0831	.0937
16	.1093	.0785	.0762	.1193	.0804	.1151	.0808
17	.1029	.1296	.0876	.1535	.1219	.109	.109
18	.1864	.1745	.1818	.2092	.1398	.1692	.112
19	.2953	.2164	.2366	.2088	.2492	.2713	.2248
20	.3521	.3311	.3344	.2751	.3357	.3224	.3313
21	.3041	.2904	.2843	.2451	.3003	.3216	.3313
22	.2389	.2187	.2237	.2054	.2255	.2203	.2298
23	.1897	.1555	.1311	.1383	.1635	.1417	.1509
24	.056	.1494	.0686	.0747	.056	.0747	.0701
Max	.3521	.3311	.3344	.2751	.3357	.3224	.3313
Min	.056	.056	.0686	.0577	.056	.056	.0701
Avg	.1395	.1413	.1382	.1349	.1363	.1447	.1381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 202 / 11 KV Aundh AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0366	.0343	.421	.3521	.4001	.0351
2	.0373	.0373	.0343	.3795	.3563	.4049	.0351
3	.0373	.0373	.0343	.3887	.3563	.4049	.0351
4	.0373	.0373	.0343	.3637	.4049	.4001	.0351
5	.0373	.0373	.0343	.3479	.4428	.426	.0351
6	.0373	.0366	.0686	.5535	.506	.4372	.0701
7	.0373	.0373	.0686	.8065	.6325	.5506	.0351
8	.0373	.0373	.0343	.7116	.7116	.6478	.0351
9	.4858	.6167	.0343	.0373	.0373	.6478	.6516
10	.5937	.6554	.0362	.0373	.0373	.502	.6859
11	.6718	.6478	.0362	.0373	.0373	.5487	.5344
12	.6562	.6173	.0362	.0373	.0373	.5487	.5668
13	.6325	.6173	.0362	.0373	.0373	.4801	.4534
14	.6554	.6173	.0362	.0373	.0373	.5316	.421
15	.6325	.7202	.0362	.0373	.0373		.4858
16	.6554	.7202	.0362	.0373	.0373	.5316	.5182
17	.0373	.0343	.0362	.0373	.0373	.0351	.0362
18	.0373	.0343	.0362	.0373	.0373	.0343	.0362
19	.0373	.0343	.0362	.056	.0373	.0351	.0362
20	.0373	.0686	.0724	.056	.0373	.0701	.0724
21	.0373	.0686	.0724	.0373	.0373	.0701	.0724
22	.0373	.0686	.0362	.0373	.0373	.0701	.0362
23	.0373	.0686	.4049	.3953	.3795	.0351	.0362
24	.0373	.0373	.0686	.4372	.4001	.0351	.0351
Max	.6718	.7202	.4049	.8065	.7116	.6478	.6859
Min	.0373	.0343	.0343	.0373	.0373	.0343	.0351
Avg	.2325	.2468	.0581	.2235	.2110	.3412	.2081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 303 / BHOSARE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5827	.5827	.5766	5.7282	5.7282	5.2202	.5781
2	.5827	.5827	.5766	5.2202	5.2278	5.2202	.5781
3	.5827	.5827	.5766	5.2849	5.2202	4.7121	.5781
4	.5827	.0747	.5766	5.4145	5.3916	4.7121	.5781
5	.5827	.5827	.5766	5.2202	5.706	4.7121	.5781
6	.5827	.5827	.5766	6.0844	6.2273	4.7121	.5781
7	.5827	.5819	.5766	7.8353	7.392	5.4469	.5781
8	.5827	.5819	.5766	10.9483	8.9161	8.7542	1.0862
9	1.9878	3.6738	.5766	8.7114	8.7106	9.7436	4.2828
10	10.2783	9.7703	.5804	.5827	.5819	9.7836	10.956
11	7.2301	9.7703	.5804	.0747	.5819	9.837	10.2783
12	9.2623	8.8209	.5804	.0747	.5819	9.837	9.8027
13	9.7703	6.9881	.5804	.0747	.5819	9.8713	8.7542
14	9.2623	2.7587	.0724	.0747	.5819	9.837	8.7218
15	8.7542	9.8713	.0724	.0747	.5819	9.2947	8.657
16	9.7703	9.8713	.5804	.0747	.5827	9.2261	9.2623
17	8.7045	7.6892		.0747	.5819	7.6907	7.693
18	.5827	.5766	.0724	.0747	.0747	.5766	.5804
19	.5819	.5766	1.0885	1.0908	.0747	.5781	.5804
20	1.0908	.5766	1.0885	1.0908	1.0908	.5781	1.0885
21	1.0908	.5766	1.0885	1.0908	1.0908	.5781	.5804
22	1.0908	1.0847	.5804	1.8258	.5827	1.0862	1.0885
23	.5827	.5766	3.188	1.2205	4.6968	.5781	.5804
24	.5827	.5827	5.149	6.2686	5.2849	1.1558	.5781
Max	10.2783	9.8713	5.149	10.9483	8.9161	9.8713	10.956
Min	.5819	.0747	.0724	.0747	.0747	.5766	.5781
Avg	3.5535	3.2465	.8909	3.0923	3.1696	5.5726	3.6924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 304 / BHOSARE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.3361	.2743	.2896	.2241	.3361	.2743
2	.2241	.3361	.2743	.2896	.2241	.3361	.2743
3	.2241	.3361	.2743	.2896	.2241	.3361	.2743
4	.2241	.3658	.3429	.3734	.2241	.3361	.3506
5	.2987	.4481	.4115	.4854	.2987	.4481	.4115
6	.3734	.7468	.7545	.8215	.3734	.6722	.631
7	.5228	.8215	.8097	.8962	.5975	.9335	.7712
8	.5975	.7468	.583	.6722	.5601	.7468	.5258
9	.5601	.6653	.5068	.5975	.4481	.5601	.5144
10	.4486	.5487	.4344	.5228	.3734	.3734	.4115
11	.3734	.3734	.4344	.4108	.3734	.3429	.362
12	.3734	.3429	.362	.3734	.3734	.3429	.362
13	.3734	.3429	.362	.2987	.3696	.3429	.362
14	.3734	.3429	.3982	.2987	.3734	.3429	.362
15	.3734	.3429	.3982	.2987	.3734	.3429	.362
16	.3734	.3429	.362	.2987	.3734	.3429	.362
17	.3734	.4115		.2987	.3696	.3506	.362
18	.4481	.4115	.4344	.5601	.3734	.5121	.362
19	.7392	.6859	.724	.6722	.7468	.631	.6516
20	.8215	.7545	.7964	.7468	.8215	.7011	.724
21	.8215	.6859	.724	.6722	.7468	.631	.6516
22	.5601	.5487	.5792	.5601	.7468	.5609	.5792
23	.3734	.4115	.4344	.3734	.4481	.4207	.4344
24	.2241	.3361	.3429	.362	.2241	.3734	.3506
Max	.8215	.8215	.8097	.8962	.8215	.9335	.7712
Min	.2241	.3361	.2743	.2896	.2241	.3361	.2743
Avg	.4291	.4869	.4790	.4776	.4276	.4715	.4469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 305 / KHATAV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8291	.8894	.8367	.8794	.8828	.9747	.828
2	.8108	.8585	.8173	.8589	.852	.9495	.8062
3	.8074	.8448	.8116	.8406	.8417	.9244	.791
4	.8017	.8878	.8859	.9549	.8463	1.0059	.8687
5	.9918	1.07	1.0905	1.161	1.033	1.2174	1.0563
6	1.4567	1.7116	1.653	1.7105	1.3713	1.6519	1.6152
7	2.0686	2.2767	2.2359	2.2607	2.2584	2.3998	2.1212
8	2.1171	2.2352	2.1411	2.1312	2.1506	2.3297	2.0351
9	1.893	1.8496	1.6998	1.6731	1.8302	1.8526	1.717
10	1.4003	1.3146	1.2757	1.2529	1.4735	1.451	1.3134
11	1.1134	1.102	1.0582	.9964	1.3619	1.1351	1.1793
12	1.15	.927	1.0444	.9678	1.2844	.9865	1.1176
13	1.1252	1.0413	1.0239	.9541	1.257	.9396	1.0101
14	.442	1.0196	1.033	1.0273	1.1724	.8973	1.0067
15	1.2071	.8802	.969	1.097	1.2456	.9476	1.0113
16	1.2186	.8116	1.0604	1.1107	1.2684	.9373	.8272
17	1.2449	1.0105	1.0867	1.1496	1.2844	.8813	1.1336
18	.8196	1.2711	1.2521	1.4335	1.315	1.1671	1.1862
19	1.9616	1.8496	1.9201	1.9075	1.8915	1.6659	1.7174
20	2.644	2.4714	2.4307	2.4104	2.4047	2.3571	2.3206
21	2.3564	2.2931	2.3034	2.1677	2.3575	2.1525	2.1872
22	1.9148	1.869	1.8858	1.8393	2.0282	1.8873	1.9353
23	1.3866	1.3546	1.7768	1.3268	1.4445	1.3546	1.4438
24	.9446	1.0215	1.0116	1.0399	1.004	1.0635	1.0776
Max	2.644	2.4714	2.4307	2.4104	2.4047	2.3998	2.3206
Min	.442	.8116	.8116	.8406	.8417	.8813	.791
Avg	1.3627	1.3692	1.3877	1.3813	1.4525	1.3804	1.3461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254026 / 33/22/11 KV Bhosare

Feeder No / Name : 306 / KHATAV AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2672	2.2996	2.4006	.0724	.0747	.0747	2.4006
2	2.1052	2.2672	2.4006	.0724	.0747	.0747	2.4006
3	1.9433	2.2672	2.332	.0724	.0747	.0747	2.4006
4	1.9433	2.2672	2.1948	.0724	.0747	.0747	2.4006
5	2.4291	2.2672	2.1948	.0724	.0747	.0747	2.4006
6	2.915	2.5621	2.1948	.0724	.0747	.0747	2.5377
7	3.437	3.562	3.0178	.0724	.0747	.0747	3.9095
8	4.0619	4.0809	3.5665	.0747	.0747	.0747	4.1152
9	.0724	.0732	2.9492	1.9608	2.5911	.0747	.0686
10	.0732	.0732	3.6923	3.0121	3.2007	.0747	.0686
11	.0732	.0686	3.336	2.9683	3.5627	.0686	.0724
12	.0732	.0686	3.6923	3.2769	3.8866	.0686	.0724
13	.0732	.0686	3.6275	3.6046	3.8409	.0686	.0724
14		.0686	2.5911	3.4789	3.8866	.0686	.0724
15		.0686	2.6558	3.5627	3.7247	.0686	.0724
16		.0686	3.1093	3.4789	3.5627	.0686	.0724
17		.0686	.0724	.0747	.0747	.0686	.0724
18		.0686	.0724	.0747	.0747	.0686	.0724
19	.0732	.0686	.0724	.0747	.0747	.0701	.0724
20	.0747	.0686	.0724	.0747	.0747	.0701	.0724
21	.0747	.0686	.0724	.0747	.0747	.0701	.0724
22	.0747	.0686	.0724	.0747	.0747	.0701	.0724
23	2.332	2.4691	.0724	.0747	.0747	2.4006	.0724
24	2.5911	2.332	2.4006	.0724	.0747	.0747	2.4006
Max	4.0619	4.0809	3.6923	3.6046	3.8866	2.4006	4.1152
Min	.0724	.0686	.0724	.0724	.0747	.0686	.0686
Avg	1.4046	1.1393	2.0360	1.105	1.2271	.1688	1.0852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 301 / 22 KV R Kurle AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3647	.3406	.3875	4.4078	3.9529	3.2251	.319
2	.3418	.3406	.3875	4.2249	3.8843	3.1337	.319
3	.3418	.3406	.3875	3.8591	3.7014	3.0422	.319
4	.3418	.3635	.3875	3.8134	3.7014	2.9508	.319
5	.4024	.4466	.4252	3.8591	3.6786	2.9949	.3418
6	.5464	.5442	.615	4.3118	3.9955	3.1722	.4629
7	.8505	.9305	.8962	5.9701	4.1381	4.26	.7671
8	.8357	.916	.8962	6.8149	6.9997	5.8833	.7899
9	6.3786	6.15	.8128	3.6706	3.3356	6.5025	6.3077
10	7.8235	7.598	.615	.623	.5396	6.653	7.0187
11	7.9249	7.4051	.5921	.4024	.4252	6.3406	6.8313
12	7.7809	7.0355	.4333	.4024	.2515	6.3329	6.8645
13	7.3068	4.984	.2732	.4024	.1211	5.2393	6.9235
14	7.0812	6.7414	.4024	.4481	.2126	6.313	6.6625
15	6.7414	4.6868	.3795	.4481	.2354	4.4124	6.4289
16	6.5158	6.5844	.3647	.4481	.2812	6.483	6.0528
17	3.4659	3.9609	.4252	.4252	.2961	3.8923	3.7037
18	.5899	.5087	.5315	.471	.1372	.471	.5068
19	.6585	.7213	.6905	.6299	.5045	.5087	.6729
20	.7644	.7671	.7293	.7442	.8558	.6001	.7042
21	.6813	.7293	.7064	.6835	.7415	.6001	.7271
22	.6585	.6401	.6458	.623	.6813	.5396	.6439
23	.4466	.5167	4.7588	4.4856	3.3927	.4104	.4923
24	.3647	.3863	3.474	4.5153	3.7014	1.2345	.4104
Max	7.9249	7.598	4.7588	6.8149	6.9997	6.653	7.0187
Min	.3418	.3406	.2732	.4024	.1211	.4104	.319
Avg	2.8837	2.6516	.8424	2.3618	2.0735	3.5498	2.6912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 302 / 22 KV Pusesavali Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9115	.9541	1.0254	.6859	1.1009	1.0829	.9572
2	.82	.9084	.9187	.6554	1.0551	1.022	.8433
3	.7895	.8931	.8882	.6249	.9637	.961	.7671
4	.8048	.8169	.8882	.5487	.9637	.9373	.7671
5	.9107	.9373	.9187	.5792	1.0624	1.0882	.8657
6	1.3969	1.3527	1.4498	.9145	1.4803	1.5508	1.4274
7	2.2779	2.3457	2.3845	1.5851	2.4832	2.3998	2.415
8	2.4463	2.5217	2.4993	1.6918	2.5065	2.3476	2.4078
9	1.9071	1.9388	1.8236	1.2955	1.9978	1.9144	2.0065
10	1.5116	1.5806	1.5188	1.0669	1.8759	1.4963	1.5303
11	1.4274	1.3664	1.4963	.8688	1.6095	1.3977	1.3405
12	1.3143	1.0364	1.4354	.8993	1.5044	1.299	1.3694
13	1.124	1.1698	1.2757	.884	.884	1.2076	1.2864
14	1.2148	1.1393	1.2076	.7926	1.4274	1.3439	1.1881
15	1.3897	1.185	1.3592	.9602	1.5493	.884	1.1507
16	1.5036	.8688	1.5116	.9297	1.5116	1.4049	1.3084
17	1.4354	1.2685	1.6022	.8383	1.3672	1.3134	1.3999
18	1.6118	.5944	1.6022	1.0059	1.3611	1.5116	1.483
19	1.9593	2.0884	1.981	1.1888	1.8137	1.9055	1.7764
20	2.4066	2.3926	2.2561	1.6461	2.505	2.4303	2.2557
21	2.1948	2.3621	2.066	1.5851	2.2794	2.2256	2.2337
22	1.9456	2.1045	1.8766	1.448	1.9608	1.8613	1.954
23	1.3931	1.4891	1.4434	1.0974	1.4777	1.4514	1.4388
24	1.1016	1.0982	1.124	1.2002	1.1466	1.1507	1.1016
Max	2.4463	2.5217	2.4993	1.6918	2.5065	2.4303	2.415
Min	.7895	.5944	.8882	.5487	.884	.884	.7671
Avg	1.4916	1.4339	1.5230	1.0413	1.5786	1.5078	1.4698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 303 / 22 KV Vadgaon AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2982	3.597	3.5459	.2743	.5761	.5357	4.2982
2	4.161	3.3913	3.2876	.2743	.5761	.5357	4.1511
3	4.0924	3.3227	3.2647	.2972	.5761	.5357	3.9384
4	4.0238	3.2998	3.1436	.2972	.599	.5357	3.8142
5	4.2463	3.3242	3.1109	.3429	.6744	.5959	4.0268
6	4.5405	3.6751	3.5002	.3887	.8185	.791	4.5047
7	6.5272	4.8887	4.4818	.5258	.5487	1.1066	6.4449
8	7.1673	6.5882	6.5394	.5716	1.2814	.9705	7.2192
9	3.2568	2.8654	7.1636	3.0178	6.0197	.8871	3.3455
10	.8265	.6447	7.1216	3.9781	7.0134	.8265	.679
11	.743	.6287	6.8854	3.8409	6.9022	.6824	.4359
12	.8265	.7201	5.9671	3.6123	6.7154	.6744	.5959
13	.8265	.3429	3.1779	3.4751	6.5516	.6447	.2987
14	.743	.6219	4.0619	3.1779	6.2673	.3429	.5129
15	.743	.2972	6.0967	3.155	6.0776	.607	.6104
16	.6824	.6138	5.9385	3.155	5.6035	.6287	.6935
17	.6824	.7201	3.0292	2.4691	3.1448	.1829	.7019
18	.7995	.6973	.743	.0686	.3658	.4767	.4672
19	.6851	.9625	.9396	.1372	.8741	1.0608	.6973
20	.9426	1.0539	1.0768	.4801	.9282	1.2209	1.0798
21	.8596	.9934	1.0311	.4801	.8825	1.1602	1.1317
22	.7849	.8722	.9099	.4115	.7849	.9557	1.0112
23	3.7418	3.703	.6447	.3201	.6188	4.3873	4.0429
24	4.1548	3.8469	2.034	.2743	.5761	2.7991	4.305
Max	7.1673	6.5882	7.1636	3.9781	7.0134	4.3873	7.2192
Min	.6824	.2972	.6447	.0686	.3658	.1829	.2987
Avg	2.5148	2.1530	3.6540	1.4594	2.7073	.9643	2.4586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 304 / 22 KV Pusesavali AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6467	.6074	.6086	3.3913	2.9417	2.3205	.6467
2	.6467	.5692	.6086	2.7054	2.713	1.9395	.6467
3	.6086	.5692	.5704	2.5149	2.5606	1.8252	.6467
4	.6086	.5692	.5704	2.2862	2.5225	1.8252	.6467
5	.7225	.6448	.6432	2.1338	2.8136	2.0081	.8368
6	1.1408	1.0624	.8745	3.1626	3.8287	2.5606	1.1031
7	1.483	1.5942	1.4834	5.3727	7.037	4.3248	1.5592
8	1.5977	1.5965	1.5215	6.8587	8.4523	6.2796	1.4841
9	5.0335	5.3696	1.2932	6.2491	6.4377	6.8458	4.5333
10	7.8532	8.9004	1.1031	.6097	.8749	7.0744	7.2768
11	7.9729	8.7731	1.0273	.6097	.8368	6.448	6.8831
12	7.3686	6.3634	.7225	.8002	.7991	5.724	6.2826
13	6.6659	6.5135	.6467	.8383	.5716	5.2934	5.4489
14	6.2205	6.0669	.5704	.9526	.6463	5.2393	5.3681
15	5.3174	5.9419	.5326	.6859	.761	4.5694	5.1151
16	5.0183	6.1377	.6086	.8002	.5323	3.8866	5.5297
17	3.4286	4.8003	.6848	.6859	.7229	3.3523	4.0352
18	.6066	.5704	.4945	.724	.7972	.4564	.8353
19	.8726	.7987	.6463	.6097	.9869	.6848	1.1759
20	1.0639	.9892	.8749	.8383	1.1767	.9892	1.3672
21	.9115	.9511	.913	.8764	1.1774	.913	1.3672
22	.8734	.8753	.761	1.0288	.9115	.8749	1.3298
23	.6836	.6467	3.6633	2.6673	1.97	.7991	1.0639
24	.6086	.6074	4.2284	3.3913	2.8273	.9107	.8753
Max	7.9729	8.9004	4.2284	6.8587	8.4523	7.0744	7.2768
Min	.6066	.5692	.4945	.6097	.5323	.4564	.6467
Avg	2.8314	2.9799	1.0688	2.1164	2.2875	3.2144	2.7524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254053 / 33/22 KV Pusesavali

Feeder No / Name : 306 / 22 KV Vadgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1031	1.1774	1.1793	.9145	.9907	1.025	.6467
2	1.0269	1.025	1.1031	.9145	.9145	1.025	.6467
3	1.0269	1.025	1.0269	.8383	.9145	1.025	.5704
4	1.0269	1.025	1.0269	.8383	.9145	1.025	.5704
5	1.0646	1.1386	1.1031	.9145	.9145	1.1386	.6467
6	1.331	1.4807	1.4834	1.1431	1.0669	1.3283	.8368
7	2.13	2.1262	1.826	1.6004	1.7528	1.8637	1.1416
8	1.9022	2.1651	1.7121	1.5242	2.0923	1.9022	1.0654
9	1.3694	1.6721	1.2555	1.0669	1.5596	1.3694	.9115
10	1.0269	1.0269	.8753	.6859	.9892	1.0654	.7591
11	.913	.8368	.6844	.6097	.913	.9507	.1494
12	.7606	.7606	.5704	.6859	.8368	.8368	.9488
13	.8368	.7229	.7606	.6859	.8368	.7229	.1867
14	.7606	.7606	.7606	.6097	.8368	.6859	.9488
15	.7606	.8368	.7606	.6859	.913	.5335	1.025
16	.7606	.7606	.7606	.6097	.7606	.1132	.9115
17	.5704	.7229	.8368	.6859	.6844		.6829
18	.7964	.8745	.7983		.9115	1.1786	.9488
19	1.3656	1.7112	1.5203		1.7451	1.9014	1.2117
20	2.3922	2.2062	2.3202	2.21	2.4684	2.2824	2.3548
21	2.2786	2.3586	2.3586	2.21	2.3548	2.2824	2.2024
22	2.0127	2.0923	2.0161	1.9052	1.9753	1.9414	2.0127
23	1.5569	1.5218	1.6358	1.3717	1.4434	.9892	1.5569
24	1.2555	1.2536	1.2932	1.0669	.9907	.7964	1.1039
Max	2.3922	2.3586	2.3586	2.21	2.4684	2.2824	2.3548
Min	.5704	.7229	.5704	.6097	.6844	.1132	.1494
Avg	1.2512	1.3034	1.2362	1.0808	1.2408	1.2166	1.0017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 201 / Ladegaon High School

GAOTHAN FEEDER

Gaothan Feeder KV- 11 /
OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1105	.1707	.125	.1436	.12	.1435	.1109
2	.1074	.1497	.1227	.1227	.1124	.1397	.0979
3	.0846	.1497	.1208	.1211	.0964	.1374	.0758
4	.0785	.1497	.1201	.1204	.0956	.1412	.0674
5	.0763	.1707	.1385	.1406	.0827	.157	.0718
6	.1569	.1966	.196	.1963	.1593	.18	.1835
7	.1912	.2542	.301	.2316	.2343	.2454	.2147
8	.1722	.2254	.2126	.2029	.2382	.2246	.176
9	.2287	.1936	.1307	.2401	.1798	.1737	.1669
10	.225	.1905	.1353	.2175	.1783	.1501	.1425
11	.2	.1292	.1242	.1964	.173	.1581	.1624
12	.1692	.1372	.1745	.2033	.1768	.1486	.1258
13	.173	.1829	.1267	.1738	.173	.1892	.14
14	.1654	.128	.1429	.17	.1677	.1774	.1482
15	.1913	.1319	.1661	.17	.1585	.186	.1391
16	.1776	.173	.1699	.1783	.1816	.1555	.1269
17	.2037	.2507	.1839	.1829	.2225	.2046	.1707
18	.2351	.2118	.1916	.2176	.2277	.2225	.194
19	.2881	.3094	.3109	.2831	.2842	.269	.2271
20	.3405	.3666	.3596	.3216	.3353	.3418	.3064
21	.3269	.3422	.3024	.3269	.3231	.317	.3186
22	.2758	.2979	.2545	.2694	.2755	.2671	.2694
23	.2385	.2248	.2176	.1951	.2256	.208	.1996
24	.1642	.1715	.1372	.1669	.1535	.1669	.1474
Max	.3405	.3666	.3596	.3269	.3353	.3418	.3186
Min	.0763	.128	.1201	.1204	.0827	.1374	.0674
Avg	.1909	.2045	.1860	.1997	.1906	.1960	.1660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 202 / 11 KV Yeliv AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.0572	.6226	.5182		.0762
2	.0572	.0572	.0381	.6062	.4858	.4641	.0762
3	.0572	.0572	.0381	.6062	.4915	.4641	.0762
4	.0572	.0572	.0381	.6062	.4915	.4694	.0762
5	.0762	.0762	.0572	.6062	.4915	.5365	.0953
6	.0953	.0953	.0762	.6299	.5281	.5735	.1143
7	.1524	.1334	.1334	.9831	.8535	.7773	.1307
8	.0953	.1334	.0953	1.1142	.9633	.8029	.1132
9	1.1233	.8583	.0953	.0934	.0724	.852	.9779
10	1.0898	1.0322		.0953	.0732	.8122	.9448
11	1.0159	1.0202	.0953	.0953	.0762	.9054	.9779
12	1.0364	.9393	.0953	.0953	.0762	.9221	.9503
13	1.0159	.8907	.1143	.0953	.0953	.8886	.7625
14	.9995	.9172	.1143	.0953	.1143	.8619	.7956
15	1.0526	.9172	.0953	.0953	.1143	.8383	.7537
16	1.004	.9172	.0953	.0953	.1334	.8288	.8592
17	.0762	.0762	.1334	.0953	.1334	.0732	.0549
18	.0953	.0762	.1334	.1143	.1143	.0739	.0532
19	.1143	.1143	.1334	.132	.1143	.132	.0914
20	.1143	.1143	.1143	.132	.1334	.132	.128
21	.1143	.0953	.1334	.112	.1334	.132	.1109
22	.1143	.0953	.1334	.0934	.1143	.1132	.0934
23	.0762	.0762	.6464	.6226	.4696	.0953	.0747
24	.0953	.0762	.0572	.663	.5335	.4915	.0762
Max	1.1233	1.0322	.6464	1.1142	.9633	.9221	.9779
Min	.0572	.0572	.0381	.0934	.0724	.0732	.0532
Avg	.4085	.3701	.1184	.3542	.3052	.5322	.3526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 204 / Trimali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2195	.1715	.1886	.1905	.1905
2	.2096	.2286	.2012	.1524	.1698	.1905	.1905
3	.2096	.2096	.2012	.1524	.1698	.1905	.1905
4	.2096	.2096	.1829	.1524	.1698	.1905	.1905
5	.2477	.2477	.2195	.1905	.2075	.2286	.2286
6	.3048	.3048	.2743	.2667	.3018	.3048	.2667
7	.4001	.3921	.3109	.381	.3475	.381	.3429
8	.3429	.3326	.3109	.3239	.2534	.3174	.2641
9	.3048	.3109	.2926	.2896	.2865	.2715	.2328
10	.2587	.2561	.2561	.2507	.2534	.2715	.1886
11	.2353	.2743	.2033	.2561	.2507	.2218	.2075
12	.2172	.2195	.2012	.2195	.2534	.2402	.2263
13	.2328	.1646	.1848	.2378	.2378	.2218	.2263
14	.2126	.2195	.2033	.2378	.2195	.2195	.2263
15	.2303	.2195	.2218	.2195	.2353	.2172	.2263
16	.2303	.2378	.2218	.2195	.2715	.2353	.2263
17	.2715	.2195	.2149	.2378	.2743	.2195	.4338
18	.3292	.2378	.2561	.2561	.3142	.2534	.3018
19	.4207	.4207	.4108	.3475	.4066	.4108	.3961
20	.4344	.4572	.4527	.4163	.4435	.4338	.4338
21	.3982	.3841	.381	.3761	.3734	.3772	.3772
22	.3475	.3475	.3239	.3109	.2987	.3429	.3395
23	.2587	.2743	.2286	.2561	.2427	.2286	.2477
24	.2477	.2427	.2195	.1905	.2054	.2286	.2096
Max	.4344	.4572	.4527	.4163	.4435	.4338	.4338
Min	.2096	.1646	.1829	.1524	.1698	.1905	.1886
Avg	.2826	.2767	.2580	.2547	.2656	.2661	.2652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 205 / 11 KV Karkhana AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2423	.2002	.2185	1.1851	1.0871	.9334	.1836
2	.2225	.1813	.217	1.0576	1.0159	.8507	.1844
3	.225	.1829	.1958	1.0309	.9856	.8349	.1867
4	.225	.1829	.1958	1.0149	.9932	.8786	.2059
5	.2397	.2328	.2231	1.0909	1.0178	.9899	.2542
6	.3395	.3215	.3247	1.3428	1.196	1.2211	.3471
7	.5068	.442	.4781	2.6181	2.2935	1.7225	.514
8	.5218	.4316	.4863	2.9036	2.7428	2.0782	.4401
9	2.0279	2.0964	.3904	1.6089	1.4807	2.4017	2.0172
10	2.572	2.3884	.2986	.2947	.2903	2.3032	2.2496
11	2.4295	2.2222	.3254	.2531	.2593	2.2702	2.1088
12	2.1902	2.1354	.3102	.2432	.2806	2.0843	1.9753
13	1.9814	2.0946	.3052	.2508	.2781	1.9456	1.7688
14	1.8183	1.92	.317	.2162	.2758	1.9308	1.6366
15	1.8385	1.8618	.2926	.2101	.2841	1.7166	1.6514
16	1.986	1.9494	.2856	.224	.2849	1.709	1.7757
17	1.1515	1.2361	.2927	.2644	.3171	.9755	1.012
18	.2503	.2446	.2995	.2819	.33	.2507	.2202
19	.2743	.3422	.3422	.3811	.3704	.3369	.3216
20	.3917	.3985	.3856	.4382	.4626	.4001	.4041
21	.3692	.3963	.3719	.3595	.438	.3637	.3643
22	.3368	.3742	.3616	.3124	.3913	.3156	.3193
23	.2781	.3292	1.1538	1.1888	1.0257	.2697	.2524
24	.2438	.2207	.8402	1.2875	1.1317	.5571	.1989
Max	2.572	2.3884	1.1538	2.9036	2.7428	2.4017	2.2496
Min	.2225	.1813	.1958	.2101	.2593	.2507	.1836
Avg	.9443	.9327	.3713	.8358	.8014	1.2225	.8580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

AUNDH[571]

BU 6912

Substation No/ Name :- 254063 / 33/11 KV Gopuj SubStation

Feeder No / Name : 206 / 11 KV Kharsinge AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0566	.0381	.2584	.2797	.2881	.0381
2	.0377	.0377	.0381	.2673	.2591	.2524	.0381
3	.0377	.0377	.0381	.2726	.24	.2306	.0381
4	.0377	.0377	.0381	.2581	.2469	.2377	.0381
5	.0566	.0377	.0381	.2843	.2682	.2614	.0381
6	.0807	.0566	.0572	.3532	.3556	.3324	.0572
7	.1379	.0953	.1585	.8132	.9424	.5154	.1734
8	.1351	.1532	.1257	.9726	1.0378	.6051	.1753
9	.5296	.5721	.0762	.5447	.538	.6085	.4927
10	.5914	.7126	.0381	.0351	.1514	.6794	.4759
11	.6005	.6622	.0381	.0358	.0577	.6582	.4961
12	.6085	.6382	.0373	.0358	.0621	.6074	.5236
13	.5838	.5746	.0339	.0362	.056	.5403	.5948
14	.5724	.639	.0362	.0366	.056	.5328	.6021
15	.538	.6531	.0423	.0366	.1101	.5171	.628
16	.5403	.6472	.0377	.0653	.1253	.2919	.7012
17	.3174	.4161	.037	.0668	.072	.266	.3978
18	.0701	.0465	.037	.0905	.0769	.0556	.056
19	.1638	.1623	.128	.0899	.1351	.0191	.1037
20	.1934	.189	.1715	.1844	.1973	.2001	.1776
21	.1692	.2278	.1722	.1822	.1852	.109	.1783
22	.17	.1875	.1661	.1535	.1745	.1791	.1526
23	.0857	.0693	.237	.2911	.295	.0763	.0606
24	.0377	.0566	.1928	.3063	.29	.1235	.0381
Max	.6085	.7126	.237	.9726	1.0378	.6794	.7012
Min	.0377	.0377	.0339	.0351	.056	.0191	.0381
Avg	.2639	.2903	.0839	.2363	.2588	.3411	.2615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 201 / 11 KV VAR-MALAWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17
HR	Load (MW)
24	.1658
Max	.1658
Min	.1658
Avg	.1658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 202 / 11 KV SHENAWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4656	.8122	.9326	1.0974	.4435	.4344
2	.362	.4656	.7956	.9259	1.0974	.4251	.4024
3	.3982	.5068	.6299	.9945	1.1191	.4435	.3658
4	.4887	.5731	.7293	1.0288	1.2548	.4805	.4706
5	.543	.7164	.779	1.1317	1.3748	.5729	.5611
6	.7499	.7796	1.1271	1.3717	1.5424	.7023	.7964
7	.8417	.8413	2.0891	2.2466	2.5484	.8871	.8145
8	.6154	.5731	.8192	2.3472	2.3967	.6283	.5973
9	1.8778	1.6842	.4344	.4706	.4435	2.0348	1.6194
10	2.079	1.5708	.3688	.3224	.3696	2.2801	1.9109
11	1.4922		.3258	.2534	.3881	2.079	1.749
12	1.7436	1.6194	.362	.2896	.3326	1.9448	1.6356
13	1.7101	1.749	.4344	.362	.3696	1.8313	.8421
14	1.576	1.5546	.4344	.3258	.3881	1.7147	1.4899
15	1.7101	1.5546	.3077	.3292	.3511	1.6118	1.4899
16	1.6766	1.7814	.3258	.3292	.3696	1.5432	1.6518
17	.3224	.3109	.4706	.362	.3696	.3439	.3326
18	.4344	.3696	.362	.3224	.3696	.3982	.4251
19	.7964	.6468	.6878	.6516	.6468	.8326	.7023
20	.8954	.8686	.7783	.6805	.8131	.905	.8131
21	.8326	.7207	.6878	.724	.7577	.7421	.7207
22	.6516	.5359	.5611	.5853	.5729	.543	.5544
23	.5068	.8288	1.0682	1.1317	.499	.4706	.499
24	.3982	.5014	.8288	1.0117	1.1191	.462	.462
Max	2.079	1.7814	2.0891	2.3472	2.5484	2.2801	1.9109
Min	.3224	.3109	.3077	.2534	.3326	.3439	.3326
Avg	.9610	.9225	.6758	.7971	.8580	1.0133	.8892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 203 / 11 KV VAR-MALAWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0739	.0924	.0943	.0739	.0924	.0754
2	.0754	.0739	.0924	.0747	.0739	.0924	.0747
3	.0747	.0739	.0739	.0747	.0924	.0739	.056
4	.112	.0914	.0924	.112	.0914	.0924	.0747
5	.1307	.128	.1109	.1294	.1097	.1109	.0924
6	.1663	.1646	.1478	.1663	.1097	.1294	.128
7	.1663	.1646	.1478	.1663	.1097	.1294	.1109
8	.1109	.128	.1294	.1097	.0739	.1109	.0739
9	.0924	.0924	.0924	.1109	.0924	.0924	.0554
10	.0732	.0924	.0739	.0732	.0739	.0924	.0739
11	.0549	.0739	.0739	.0732	.0554	.0739	.056
12	.0554	.0739	.0554	.0739	.0739	.0554	.0554
13	.0554	.0554	.0554	.0732	.0187	.0554	.0554
14	.0549	.0554	.0554	.0554	.056	.0554	.0739
15	.0549	.0554	.0732		.0554	.0554	.056
16	.0554	.056	.0732	.0732	.0739	.0554	.056
17	.0732		.0739	.0732	.0739	.0554	.0554
18	.0739	.0554	.1109	.0739	.0739	.0739	.0739
19	.1663	.1663	.1646	.1109	.1294	.1478	.1294
20	.1848	.2033	.1848	.1663	.1663	.1494	.1663
21	.1478	.1663	.1663	.1478	.1294	.1267	.1294
22	.1109	.1294	.1494	.1109	.1294	.112	
23	.0739	.1109	.1132	.0924	.1109	.0943	.1109
24	.1132	.0739	.0924	.1132	.0739	.0924	.0943
Max	.1848	.2033	.1848	.1663	.1663	.1494	.1663
Min	.0549	.0554	.0554	.0554	.0187	.0554	.0554
Avg	.0988	.1025	.1040	.1021	.0884	.0925	.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 204 / 11 KV SHENAWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0739	.0739	.0754	.0924	.0924	.0566
2	.056	.0739	.0739	.0554	.0739	.0739	.0566
3	.056	.0732	.0739	.0554	.0732	.0739	.0747
4	.0934	.1097	.0739	.0739	.0914	.0924	.0924
5	.1307	.1848	.1109	.1294	.1463	.1109	.1294
6	.1848	.2012	.1663	.1829	.1829	.1848	.1867
7	.2033	.2195	.1663	.1829	.2378	.2033	.2218
8	.1646	.1646	.1663	.1646	.2033	.1848	.1478
9	.1463	.1109	.1294	.1294	.1663	.1294	.1294
10	.1097	.0924	.1294	.1097	.1109	.1294	.1294
11	.1097	.1109	.0924	.0732	.0924	.1097	.1109
12	.0924	.0924	.0924	.0732	.1109	.1109	.0739
13	.0739	.1109	.0924	.1109	.1109	.1294	.0554
14	.0924	.1109	.0924	.0914	.1294	.0924	.0924
15	.0914	.1109	.0914	.0924	.1109	.1109	.0924
16	.0914	.0924	.0924	.0914	.112	.1109	.0924
17	.0914	.0924	.0924	.128	.1294	.1109	.0924
18	.1097	.0924	.0924	.1109	.1109	.0934	.1109
19	.1848	.1109	.1463	.1109	.1663	.1478	.1294
20	.1848	.1294	.1478	.1848	.1848	.1867	.1848
21	.1663	.1478	.1097	.1663	.1663	.1478	.1663
22	.1109	.1109	.0934	.1294	.1478	.112	.1478
23	.0924	.0924	.0943	.1109	.1109	.0754	.0924
24	.0943	.0739	.0739	.0754	.1109	.0924	.0754
Max	.2033	.2195	.1663	.1848	.2378	.2033	.2218
Min	.056	.0732	.0739	.0554	.0732	.0739	.0554
Avg	.1169	.1159	.1070	.1128	.1322	.1211	.1142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254029 / 33/11 KV SHENAWADI

Feeder No / Name : 205 / 11 KV Jambhulni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.6095	.2218	.1991	.2172	1.3108	1.5604
2	1.1869	1.6448	.2033	.2012	.2012	1.3272	1.4922
3	1.2209	1.7436	.2033	.2195	.1991	1.278	1.4575
4	1.3565	1.7974	.2218	.2378	.2172	1.3108	1.5089
5	1.5089	1.8442	.2587	.2534	.2534	1.3599	1.6278
6	1.5424	1.8778	.3326	.3077	.3224	1.5708	1.9281
7	2.2131	2.5484	.3511	.3258	.3582	2.4291	2.2466
8	2.2131	2.2801	.2587	.2534	.2587	1.9757	2.079
9	.1629	.1848	1.9719	2.1605	2.1862	.1629	.2218
10	.1772	.1663	2.6825	2.5149	3.1417	.1646	.1663
11	.1791	.1663	2.4478	2.5819	2.4291	.1629	.168
12	.2149	.1848	2.6155	2.5149	1.3279	.1629	.168
13	.2172	.1663	2.3137	.8413	1.9271	.1629	.2033
14	.2172	.2033	2.8502	2.2043	2.2672	.181	.1848
15	.2149	.1848	2.6406	2.4143	1.7814	.2353	.2033
16	.2149	.2402	1.7147	2.3472	1.749	.2172	.1848
17	.2507		.2172	.2534	.2218	.2957	.2033
18	.2865	.1848	.2534	.2715	.2402	.2896	.2241
19	.3982	.3142	.362	.362	.2587	.362	.3326
20	.394	.3511	.3658	.3292	.3326	.3982	.3696
21	.394	.3511	.362	.3258	.3326	.3439	.3142
22	.2896	.2957	.2896	.2715	.3142	.2926	.2772
23	1.3375	.2402	.2172	.2534	1.1271	1.5089	1.3435
24	1.2209	1.5424	.2218	.2172	.2195	1.278	1.5432
Max	2.2131	2.5484	2.8502	2.5819	3.1417	2.4291	2.2466
Min	.1629	.1663	.2033	.1991	.1991	.1629	.1663
Avg	.7779	.8749	.9824	.9109	.9118	.7825	.8337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 201 / 11 KV DEVAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.8292	2.2977			.2804	
2		2.7435	3.9781			.2454	2.4348
3		2.7435	2.0233			.2481	2.4348
4		2.7435	2.0576			.2572	2.452
5		3.0007	2.4006			.4115	2.4691
6		3.0864	2.7435			.5144	2.7092
7		3.9781				.4801	3.8409
8		3.6523	2.6063			.4458	3.8409
9		.3086	2.915			.3429	.2915
10			3.2922		3.7037	.2915	.3121
11			2.8635				.2915
12	.2454		3.6866				.2743
13	.2401		4.1152				
14	2.0576		3.2922				
15	.2454	.2743	3.6523				.1715
16		.2401	3.5665			.1886	.3944
17		.2454				.1715	.2743
18		.333			.3429		.3429
19		.3506	.463		.4801	.4458	.4801
20		.5194			.5316	.5658	.5144
21	.3772	.4961			.5144	.4801	.4801
22	.4115	.3856				.3772	.3944
23	3.3608	2.4691			.3086	2.4006	2.3663
24		3.3608		.3258		.298	.2743
Max	3.3608	3.9781	4.1152	.3258	3.7037	2.4006	3.8409
Min	.2401	.2401	.463	.3258	.3086	.1715	.1715
Avg	.9911	1.7769	2.8721	.3258	.9802	.4692	1.2878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 202 / 11 KV DHULDEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.298			2.4691	.3429
2		.1715	.2804			2.4006	.3429
3		.1715	.2743			2.2291	.3429
4		.1715	.2572			2.2291	.3429
5		.2743	.3155			2.2634	
6		.3258	.3506			2.5034	.3601
7		.3601	.3429			3.1207	.3944
8		.2401	.3856			3.1893	.3944
9		2.8121	.3429			3.0007	2.8978
10			.3429		.12	3.3436	1.7147
11			.2229				2.0233
12	3.155		.3258				1.9204
13	2.0576		.3258				
14			.3258				
15	3.2922	3.0693	.3258				1.8861
16		3.5151	.3429			3.0864	
17		3.0178			.2401	.2058	2.8635
18			.4115		.2058		1.4746
19		.394	.4115		.2804	.3944	.2915
20		.2454	.463		.3429	.3944	.3258
21	1.6461	.3506			.3506	.3772	.3086
22	2.2977	.3582				.3429	.2915
23	.2743	.3582			2.4006	.3429	.2915
24		.2572	.3155	2.572		2.5034	.3429
Max	3.2922	3.5151	.463	2.572	2.4006	3.3436	2.8978
Min	.2743	.1715	.2229	2.572	.12	.2058	.2915
Avg	2.1205	.9036	.3330	2.572	.5629	1.9109	.9576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 203 / 11 kv Devapur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1307			.0943	2.4348
2			.1132			.0754	.1029
3			.1132			.0747	.1029
4			.1132			.0747	.1029
5			.1494			.112	.1029
6			.1494			.1307	.1372
7			.1478			.168	.1886
8			.1448			.1646	.1543
9		.1029	.1307			.1402	.0857
10					.0686		.1433
11							.1029
12	.1543						.1372
13	.1372						.1715
14	.124						.2058
15	.12	.12					.2058
16	.1334	.0857				.1372	.1372
17		.0857				.0857	
18		.12	.1029		.1402		
19		.1829	.1029		.2172	.1543	
20		.1791	.12		.2195	.1543	
21		.1829			.1991	.1543	
22		.1478			.1463	.12	
23		.1509			.112	.12	
24			.1494	.12		.0934	.1372
Max	.1543	.1829	.1494	.12	.2195	.168	2.4348
Min	.12	.0857	.1029	.12	.0686	.0747	.0857
Avg	.1338	.1358	.1283	.12	.1576	.1208	.2737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 204 / 11 kv Dhuldeo Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.12	.1307			.1307	.1372
2		.1029	.1307			.112	.1372
3		.12	.112			.112	.1372
4		.1372	.112			.112	.1372
5		.1372	.1494			.1494	.1372
6		.1543	.168			.168	.1886
7		.1886	.168			.1848	.2058
8		.1543	.0914			.1267	.1543
9		.1029	.128			.1254	.12
10			.1029		.0857	.1029	.1267
11			.1029				.1254
12	.1263		.0857				.124
13	.1433		.1372				
14	.1402		.0686				
15	.1075	.1372	.1029				.1029
16		.1372	.0857			.0857	.0857
17		.1402			.1227	.0514	.0857
18		.1402	.1543		.1086		.0857
19		.1791	.1543		.1612	.1543	.1543
20		.1791	.1715		.197	.2058	.1543
21	.1543	.181			.1646	.1715	.1543
22	.1715	.1646				.1372	.1372
23	.1715	.1307			.1494	.1372	.12
24		.12	.1307	.12		.1307	.1372
Max	.1715	.1886	.1715	.12	.197	.2058	.2058
Min	.1075	.1029	.0686	.12	.0857	.0514	.0857
Avg	.1449	.1435	.1243	.12	.1413	.1332	.1340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254030 / 33/11 KV MHASWAD

Feeder No / Name : 205 / 11 KV Mhaswad (U) Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.6348			.6348	.6001
2		.5144	.6348			.5975	.583
3		.6859	.5975			.5975	.583
4		.7545	.5601			.5601	.6001
5		.8573	.7095			.7468	.6516
6		.9259	.9335			.9709	.8402
7		1.0631	1.2696			1.1088	.9945
8		.9259	1.0608			1.0608	.9602
9		.6344	.9511			.8779	.8745
10			.7373	.788	.6859	.7373	.8596
11			.7373				.7712
12	1.0059		.7202				.7362
13	.8596		.703				
14	.9465		.6001				.823
15	.8764	.8402	.7202				.703
16		.9088	.7888			.7888	.7545
17		.9313			.7522		.6687
18		.8764	1.046		.8596		.703
19		1.3032	1.046		1.1104	1.0974	.9774
20		1.3535	1.2003		1.1584	1.166	1.0631
21	.9431	1.1765			1.0608	1.0802	.9602
22	1.1317	.9877			.9145	.8402	.8916
23	.7888	.7842			.7468	.6001	.6859
24		.8402	.6722	.6173		.6722	.6001
Max	1.1317	1.3535	1.2696	.788	1.1584	1.166	1.0631
Min	.7888	.5144	.5601	.6173	.6859	.5601	.583
Avg	.936	.8883	.8162	.7027	.9111	.8316	.7776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 201 / 11 KV KUKUDWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5761	.0549	.0732		.4816
2			.6226	.0549	.0732		.4816
3		.6802	.6554	.0554	.0739		.4816
4			.7377	.0554	.0924	.056	.4816
5			.7377	.0566	.0934		.5992
6		.7125	.7537	.0754	.1132	.0747	.6802
7			.7432	.1494	.1509		1.1142
8		1.1469	.8951	.1109	.1097	.0554	1.1961
9		.0739	.9231	1.004	.9831		.0732
10		.0724	.9393	1.0364	.9602	.0543	.0739
11		.0732	.759	.9717	.9172	.0554	.0693
12	.759	.0724	.8065	.9717	.9602	.0503	.0406
13		.0716	.7343	.6173	.9717	.0337	.0497
14		.1086	.7407	.7811	.8796	.032	.0474
15		.0724	.7186	.8436	.8993	.0503	.0625
16		.181	.8745	.8619	.08	.0316	.0492
17		.0857	.064	.0594	.08	.0753	.0671
18		.064	.1052	.0724	.0652	.0753	.061
19		.0895	.1097	.0701		.1063	.0895
20		.1052	.0876	.1052	.1029	.1029	.0905
21	.1052	.0867	.0905	.1052		.0876	.104
22		.0876	.0709	.0876	.0867	.0716	.0905
23			.0554	.0566		.6167	.6009
24	.1943	.7042	.5761	.0549	.056	.0549	.6093
Max	.759	1.1469	.9393	1.0364	.9831	.6167	1.1961
Min	.1052	.064	.0554	.0549	.056	.0316	.0406
Avg	.3528	.2493	.5574	.3463	.3725	.0936	.3206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 202 / 11 kv Kukudwad gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1478	.1307	.1463		.1307
2			.1829	.1307	.1494		.1307
3		.1494	.1829	.1307	.1494		.1307
4			.2241	.168	.1463	.1509	.1307
5			.2987	.2075	.2378		.2427
6		.2987	.3361	.4108	.3511	.2263	.3772
7			.4108	.4435	.4481		.4251
8		.2926	.3547	.3475	.3475	.2926	.3142
9		.2561	.2218	.2033	.2218		.1991
10		.2195	.1663	.1629	.1629	.1463	.1433
11		.1448	.1227	.0732	.1578	.1109	.124
12	.1612	.1448	.1063	.0914	.1267	.0914	.104
13		.1448	.1075	.0914	.128	.0886	.0972
14		.1433	.1187	.1052	.1075	.0905	.0724
15		.1063	.104	.1052	.1063	.0924	.1052
16		.1417	.1214	.1174	.1254	.0914	.0905
17		.0895	.0693	.108	.1311	.1147	.1147
18		.1341	.1029	.1509	.1372	.1147	.1509
19		.2686	.3109	.2328		.3224	.2658
20		.362	.3439	.3258	.2561	.3582	.3045
21	.3439	.3109	.2957	.3109		.2772	.2772
22		.2402	.2195	.1663	.2195	.2054	.2353
23			.1848	.1663		.1663	.1646
24		.1494	.1478	.1307	.1307	.1478	.1307
Max	.3439	.362	.4108	.4435	.4481	.3582	.4251
Min	.1612	.0895	.0693	.0732	.1063	.0886	.0724
Avg	.2526	.1998	.2034	.1880	.1899	.1716	.1859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 203 / 11 kv Diwad gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0914	.0943	.0914		.0762
2			.0914	.0943	.0914		.0762
3		.0747	.0924	.0953	.0924		.0762
4			.1294	.0953	.0924	.1109	.0953
5			.1663	.1524	.1307		.132
6			.2054	.1886	.1867	.2641	.1663
7			.2378	.2286	.2263		.2286
8		.1886	.1886	.1509	.1715	.1886	.1698
9		.168	.1307	.1132	.1494		.132
10		.128	.0943	.1143	.132	.132	.0724
11		.0905	.0914	.112	.0701	.0572	.0526
12	.1075	.0732		.0566	.0377	.0566	.0762
13		.0366		.0377	.0373	.056	.0566
14		.0663	.0709	.0554	.0532	.0537	.0566
15		.0543	.0543	.0526	.0543	.056	.0509
16		.0754	.0554	.056	.0566	.037	.0572
17		.0819	.0876	.0724	.0709		.0514
18		.1109	.1107	.0732	.081		.0709
19		.2033	.2241	.168		.1478	.0754
20		.2378	.2054	.1867	.2263	.2218	.2033
21	.2587	.1867	.168	.1867		.168	.1509
22		.1463	.1448	.1715	.1494	.132	.1143
23			.128	.112		.0953	.112
24		.0943	.0914	.1132	.0953	.0924	.0754
Max	.2587	.2378	.2378	.2286	.2263	.2641	.2286
Min	.1075	.0366	.0543	.0377	.0373	.037	.0509
Avg	.1831	.1186	.1300	.1159	.1093	.1168	.1012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 204 / 11 KV DIWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1478	.68	.6718		.1886
2			.1829	.6481	.6718		.1848
3		.1848	.1829	.6481	.6882		.1848
4			.7468	.6481	.7042	.5761	.1848
5			.3018	.759	.8192		.2641
6		.3361	.415	.9614	.9448	.6401	.3395
7			.4108	1.3592	1.326		.4294
8		.3734	.2987	1.4419	1.3603	1.004	.4481
9		1.0936		.2641	.2241		.9175
10		1.1336	.2614	.181	.2218	.9922	.8482
11		.9488	.2402	.1448	.1791	.9282	.8509
12	.9717	.9488	.1829	.1063	.1478	.7676	.8128
13		.9374	.1646	.1387	.1448	.743	
14		.9374	.1629	.1402	.1417	.8078	.7628
15		.9922	.1629	.1372	.1029	.7926	.6321
16		.9488	.156	.1372	.1086	.8333	.6401
17		.1402	.1844	.1989	.128		.1578
18		.208	.2401	.208	.1658		.1658
19		.208	.362	.3224		.2658	.2865
20		.3658	.3696	.3292	.3258	.362	.181
21	.3439	.3326	.3292	.3258		.2865	.2481
22		.2561	.2561	.2896	.2218	.2534	.2172
23			.759	.6958		.1867	.1886
24		.1886	.1509	.6958	.6562	.5441	.1886
Max	.9717	1.1336	.759	1.4419	1.3603	1.004	.9175
Min	.3439	.1402	.1478	.1063	.1029	.1867	.1578
Avg	.6578	.5852	.2900	.4775	.4740	.6240	.4053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 205 / 11 kv Naravane Ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2709	.0709	.0724		.4744
2			.3612	.0709	.0732		.4744
3		.6962	.4572	.0701	.0732		.4365
4			.5487	.0701	.0747	.0739	.4064
5			.6401	.1109	.112		.547
6		.7537	.7042	.1886	.1698	.1307	.6464
7			.7701	.2054	.1886		1.0774
8		1.2289	.8583	.168	.1294	.1463	1.0486
9		.0914	.68	.9614	.8619		.197
10		.0693	.8097	.9717	.9717	.0867	.0724
11		.0492	.8962	.9231	.933	.0701	.0648
12	.1187	.1326	.9282	.9717	.8259	.0579	.0602
13		.048	.9069	.933	.9231	.0404	.0587
14		.0671	.9014	.8223	.8697	.0394	.0472
15		.0514	.9122	.9014	.8179	.0412	.0625
16		.0497	.8488	.9339	.8421	.0434	.0429
17		.1052	.0734	.0937	.1	.0686	.0857
18		.096	.104	.1492	.088	.0709	.1134
19			.2012	.1492		.1326	.156
20		.2103	.1715	.1949	.1715	.1886	.1734
21	.2204	.1772	.156	.1526		.156	.1492
22		.1387	.12	.1387	.1326	.128	.1174
23			.0895	.0905		.5668	.5601
24		.7209	.5281	.0709	.0905	.0716	.5693
Max	.2204	1.2289	.9282	.9717	.9717	.5668	1.0774
Min	.1187	.048	.0734	.0701	.0724	.0394	.0429
Avg	.1696	.2756	.5391	.3922	.4058	.1174	.3184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 206 / 11 KV NARAWANE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9107	.684	.6992	.7221	.6592	.7274
2		.8326	.602	.7087	.6859	.6382	.7206
3		.8303	.5677	.6763	.6783	.6459	.7149
4		.7868	.6005	.6783	.7229	.6989	.6882
5		.9564	.74	.9482	.86	.7354	.887
6		1.4361	1.3317	1.491	1.3203	1.3713	1.5184
7		2.13	2.0858	2.3068	2.0653	1.97	2.2005
8		2.4779	2.3101	2.3659	2.4347	2.4043	2.2778
9		2.0934	1.8008	1.8992	1.8839	1.7566	1.8496
10		1.5444	1.2075	1.2014	1.288	1.1828	1.2113
11		1.049	.9088	1.033	.9604	.8526	.9536
12	1.2294	1.5613	.7362	.7299	.9265	.6455	.6893
13	1.1469	.7624	.6756	.6249	.7807	.587	.7078
14	.9678	.7356	.5944	.5369	.7617	.6125	.6409
15	.8707	.7174	.6283	.5987	.6463	.5533	.5285
16	.8554	.664	.7058	.7125	.6618	.5689	.6087
17		.6888	.7293	.7004	.7735	.6697	.6164
18		.5714	.7011	.8101	.7994	.8962	.7781
19		1.0012	.9446	1.066	.9583	.9301	.9797
20		2.0319	1.8069	1.8785	1.8393	1.8812	1.7528
21	1.7982	1.9886	1.9266	1.8272	1.6785	1.8968	1.741
22	2.0386	1.6234	1.6329	1.6729	1.6457	1.6034	1.5167
23	1.7356	1.1755	1.1908	1.1842	1.2746	1.1702	1.2742
24	1.0822	.895	.8916	.823	.8745	.8813	.9255
Max	2.0386	2.4779	2.3101	2.3659	2.4347	2.4043	2.2778
Min	.8554	.5714	.5677	.5369	.6463	.5533	.5285
Avg	1.3028	1.2277	1.0835	1.1322	1.1351	1.0755	1.1045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254041 / 33/11 KV VADJAL

Feeder No / Name : 207 / 11 KV KRUSHNA FERTILIZERS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0017	.0017	
2			.0017	.0017	
3		.0017	.0017	.0015	
4			.0013	.0015	
5			.0017	.0014	
6		.0018	.0018	.0013	
7			.0018	.0061	
8		.005	.0175	.0171	
9		.0007	.0549	.0532	
10		.0007	.0549	.0532	
11			.0549	.0532	
12	.0007		.0716	.0532	
13			.0537	.0537	
14			.056		
15			.0532	.0537	
16			.0554	.0537	.0566
17			.0543	.0543	
18			.0057		
19			.0009		
20		.001	.001		
21	.0011	.0015	.0015		
22		.0015	.0017		
23			.0018		
24		.0016	.0017	.0019	
Max	.0011	.005	.0716	.0543	.0566
Min	.0007	.0007	.0009	.0013	.0566
Avg	.0009	.0017	.0230	.0272	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 301 / 22 KV SHINGANAPUR AG
(SHINGNA Feeder KV- 22 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2037	2.9607	2.62	.5152	.4801	.506	3.5703
2	3.0925	2.7587	2.4874	.5152	.4649	.5045	3.4133
3	3.0064	2.7648	2.4204	.5152	.4618	.5106	3.2967
4	3.1169	2.8593	2.5537	.5441	.4893	.5853	3.1154
5	3.3664	3.155	2.7313	.6661	.6051	.7377	3.3326
6	4.2029	4.3194	3.2921	1.022	.8779	1.044	3.9422
7	6.4472	6.1515	4.6426	1.3717	1.5394	1.3672	6.7299
8	7.2619	6.1835	5.1059	1.1706	1.4098	1.2155	7.3655
9	4.7661	1.8397	3.9262	5.0145	4.9612	.8619	4.3805
10	.5762	.4938	5.3422	5.9937	5.8795	.5365	.5243
11	.1799	.3506	5.2004	6.1119	5.7728	.3948	.1967
12	.1494	.1433	4.4372	5.7598	5.7979	.2424	.3323
13	.1326	.2088	3.5208	5.2108	5.7872	.1798	.5624
14	.128		5.426	4.638	5.5358	.1448	.5457
15	.128	.1387	4.7874	5.0431	5.1121	.1326	.1539
16	.1296	.1402	5.5841	4.7006	5.4458	.1296	.2484
17	.221	.1463	3.3424	2.9168	3.6763	.2392	.1296
18	.522	.7316	.3612	.5472	.4832	.4176	.1296
19	.8657	1.0974	.8916	.9297	.8687	.9107	.8764
20	1.1088	1.3107	1.1126	1.0288	1.1393	1.1545	1.1431
21	.9846	1.0639	1.0059	.9907	1.0455	1.1507	.9221
22	.8558	.9541	.8863	.8338	.8619	.9846	.8101
23	3.2693	2.8944	.6554	.6078	.5989	3.4309	3.5482
24	3.3455	2.9798	1.2483	.5487	.5304	2.6978	3.6809
Max	7.2619	6.1835	5.5841	6.1119	5.8795	3.4309	7.3655
Min	.128	.1387	.3612	.5152	.4618	.1296	.1296
Avg	2.1275	1.9846	3.0659	2.3832	2.4927	.8366	2.2063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 302 / 22 KV MARDI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4847	.4695	.4695	2.5972	2.4805	2.3183	.4526
2	.4847	.4847	.4695	2.4905	2.3244	2.2336	.4679
3	.5	.5015	.4725	2.33	2.2862	2.3167	.5472
4	.5152	.5544	.5921	2.3948	2.3281	2.2984	.6889
5	.6661	.7213	.7925	2.6292	2.612	2.524	.8916
6	1.0478	1.0783	1.1393	3.3174	3.3703	2.8227	1.2148
7	1.3905	1.4963	1.4174	5.0343	4.9059	4.2082	1.5852
8	1.2163	1.3679	1.1888	5.9671	5.9595	4.4673	1.3869
9	3.6702	2.2962	.8207	3.1855	3.3531	4.3423	2.7252
10	4.0025	4.1747	.6081	.3186	.5762	3.8073	4.5146
11	3.8142	3.8698	.4877	.1463	.3033	3.5878	4.0162
12	3.8104	2.5751	.3628	.1494	.1935	3.3418	2.2207
13	3.5056	3.0118	.0152	.1509	.1494	3.2426	3.3851
14	3.3044	4.2219	.1524	.1494	.1966	1.7314	3.2449
15	3.3684	4.3454	.1524	.1494	.2576	.9145	3.0605
16	3.7631	4.4681	.2713	.1509	.4557	.8291	3.4922
17	2.7405	3.3059	.1524	.1524	.5899	.7117	2.3457
18	.6458	.5015	.1524	.4496	.6073	.1509	.471
19	.8962	.7316	.5487	.9754	.8383	.2134	.7445
20	1.0559	.9907	1.0212	1.1355	1.1278	.7468	1.0059
21	1.0182	.8207	.8687	.9983	1.0059	.8535	.884
22	.8116	.714	.724	.7697	.8055	.7468	.7221
23	.5762	.5578	2.6444	1.768	2.2641	.5883	.5731
24	.4695	.4847	2.0987	2.6124	2.4295	1.0143	.4801
Max	4.0025	4.4681	2.6444	5.9671	5.9595	4.4673	4.5146
Min	.4695	.4695	.0152	.1463	.1494	.1509	.4526
Avg	1.8233	1.8227	.7343	1.6676	1.7259	2.0838	1.7134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 303 / 22 KV SHINGANAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0366	.0366	.0366	.0366	.0366	.0366
2	.0366	.0183	.0366	.0366	.0377	.0366	.0366
3	.0366	.0183	.0366	.0366	.0366	.0366	.0366
4	.0366	.0366	.0366	.0366	.0366	.0549	.0549
5	.0549	.0549	.0549	.0549	.0549	.0549	.0549
6	.0732	.0732	.0732	.0732	.0732	.0732	.0732
7	.0914	.0914	.0914	.0914	.0914	.0914	.0914
8	.0732	.0732	.0549	.0549	.0732	.0732	.0732
9	.0732	.0732	.0549	.0732	.0549	.0549	.0543
10	.0549	.0549	.0549	.0549	.0549	.0914	.0549
11	.0549	.0732	.0732	.0914	.0549	.0543	.0549
12	.0732	.0732	.0732	.0732	.0549	.0732	.0549
13	.0732	.0549	.0732	.0732	.0732	.0732	.0732
14	.0549	.0732	.0549	.0732	.0732	.0549	
15	.0549	.0732	.0732	.0549	.0549		.0366
16	.0732	.0732	.0732	.0366	.0732	.0732	.0366
17	.0732	.0732	.0732	.0732	.0549	.0549	.0366
18	.0549	.0549	.0549	.0732	.0549	.0549	.0549
19	.0914	.0732	.0914	.0914	.0914	.0914	.0914
20	.0914	.0732	.0914	.0914	.0914	.0914	.0914
21	.0732	.0732	.0732	.0732	.0724	.0732	.0914
22	.0549	.0549	.0549	.0732	.1086	.0549	.0549
23	.0549	.0366	.0366		.0366	.0549	.0366
24	.0366	.0366	.0366	.0549	.0366	.0366	.0366
Max	.0914	.0914	.0914	.0914	.1086	.0914	.0914
Min	.0366	.0183	.0366	.0366	.0366	.0366	.0366
Avg	.0618	.0595	.0610	.0644	.0617	.0628	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254042 / 33/22 KV SHINGANAPUR

Feeder No / Name : 304 / 22 KV MARDI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2667	.2667	.2667	.2667	.2667
2	.2667	.2667	.2667	.2667	.2667	.2667	.2667
3	.3048	.2667	.3429	.3048	.3048	.3048	.2667
4	.381	.3429	.4572	.381	.3048	.381	.381
5	.4954	.4191	.6097	.5335	.5335	.5335	.5335
6	.724	.6859	.724	.6478	.6859	.724	.7621
7	.8383	.8764	.8383	.8002	.8764	.8764	.8764
8	.6097	.5716	.6097	.6097	.6478	.6097	.5716
9	.381	.4954	.381		.5716	.381	.381
10	.2667	.3048	.3048	.2667	.381	.3048	.3048
11	.2286	.1905	.1524	.2286	.3048	.3048	.2286
12	.2286	.1905	.1524	.2286	.2286	.2263	.2286
13	.1905	.1905		.2286	.2667	.1905	.2286
14	.1905	.1905	.2286	.1905	.2286	.1524	.1905
15	.1905	.1905	.1905	.1905	.2286	.1905	.1905
16	.2286	.1905	.2286	.2286	.1905	.1905	.1905
17	.3048	.2667	.2286	.2667	.2667	.2286	.2667
18		.3048	.3429	.3429	.3048	.3048	.3429
19	.4191	.6097	.6097		.6097	.6859	.5716
20	.5716	.724	.724	.6859	.724	.7621	.724
21	.6478	.6097	.6097	.5716	.6097	.6097	.6097
22	.4954	.4191	.4572	.3048	.4572	.4191	.4572
23	.3429	.3048			.3048	.3429	.3429
24	.3048	.2667	.2667	.2286	.2667	.2667	.2667
Max	.8383	.8764	.8383	.8002	.8764	.8764	.8764
Min	.1905	.1905	.1524	.1905	.1905	.1524	.1905
Avg	.386	.3810	.4087	.3701	.4096	.3968	.3937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 301 / 22 KV PARKANDI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.715	4.6183	4.542	.7598	.6477	.6916	4.6372
2	4.5573	4.5801	4.1259	.7068	.6477	.6763	4.3896
3	4.5268	4.5305	4.1099	.7221	.7011	.7118	4.2676
4	4.5831	4.4581	4.1434	.881	.7671	.8322	4.1884
5	4.9265	4.7676	4.42	1.0783	.9114	1.1233	4.4049
6	5.6082	5.3681	4.7447	1.6385	1.6103	1.6705	5.3612
7	8.1066	7.7419	6.816	2.3167	2.0066	2.1574	8.2457
8	8.7609	8.5658	7.098	1.9815	1.3717	1.8397	9.084
9	5.4588	5.4809	6.3344	5.1365	5.2858	1.1217	5.9035
10	.605	.8512	5.9625	6.2505	6.1485	.8055	.6844
11	.4847	.6683	5.4329	5.8212	6.0372	.6287	.5319
12	.4221	.6531	4.8179	5.6485	5.5266	.3353	.4862
13	.5982	.6234	4.6182	5.8901	3.8714	.5715	.3475
14	.6638	.6683	4.7874	5.7948	5.5273	.5849	.5769
15	.7271	.6988	5.4047	5.6454	6.0757	.6001	.6073
16	.7163	.7293	5.7095	6.5158	6.5874	.6683	.5015
17	.503	.775	4.068	4.5344	4.8301	.7293	.6988
18	.8687	.5152	.6909	.6706	.6966	.7118	.6988
19	1.1507	.2119	1.0173	.9907	.9458	.9796	1.0593
20	1.7452	1.6949	1.5116	1.5013	1.5573	1.595	1.5645
21	1.6309	1.6865	1.5268	1.4631	1.4586	1.0669	1.4739
22	1.4479	1.3831	1.3107	1.265	1.2765	1.2997	1.3527
23	5.0069	4.9085	.9805	.9373	.9957	4.9497	4.8148
24	4.9463	5.1974	1.925	.714	.7468	3.8074	4.8804
Max	8.7609	8.5658	7.098	6.5158	6.5874	4.9497	9.084
Min	.4221	.2119	.6909	.6706	.6477	.3353	.3475
Avg	3.0317	2.9740	4.0041	2.8693	2.7596	1.2566	2.9484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 302 / 22 KV BHANDAWALI AG
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.41	.4191	.4664	2.4105	2.7282	2.1605	.3948
2	.221	.2362	.4511	2.287	2.4386	2.0805	.3216
3	.4039	.1981	.2682	2.1338	2.2977	1.9395	.2484
4	.4934	.1509	.4526	2.0119	2.2668	1.9418	.2858
5	.5967	.5239	.4969	2.0958	2.4783	2.0424	.5525
6	.8391	.8139	.82	2.9675	3.1184	2.4413	.9153
7	1.3824	1.2864	1.2193	4.4764	4.4033	3.725	1.238
8	1.3222	1.2841	1.2384	6.2003	4.3439	5.109	1.185
9	3.4339	3.3836	.9252	4.5481	4.5721	5.2538	3.6641
10	5.1676	3.8256	.6005	.6116	.6386	4.8666	4.1122
11	5.0419	5.3963	.5335	.5304	.4717	4.9322	4.4048
12	4.9825	5.1349	.431	.4847	.4107	4.7752	4.5115
13	4.9028	5.0053	.4237	.3475	.4847	4.5512	4.5268
14	4.6822	4.8971	.1966	.4847	.5457	4.3134	4.1045
15	4.5786	4.9184	.1086	.4847	.5982	4.2188	3.9232
16	3.5894	5.6713	.1227	.4915	.5849	4.6647	4.2371
17	3.4598	4.1823	.4405	.5487	.6813	3.5536	3.2266
18	.7011	.679	.5304	.6706	.7118	.8596	.6226
19	.9068	1.0212	.9411	.9449	.8322	1.1088	.8505
20	1.2574	1.493	1.3565	1.3412	1.3062	1.352	1.2757
21	1.2193	1.4236	1.2917	1.2345	1.2533	.8993	1.2117
22	1.0212	1.2079	1.0151	1.0516	1.1065	1.185	1.0639
23	.7392	.8505	2.149	2.1887	1.9083	.7831	.788
24	.5015	.5182	2.0073	2.9203	2.5225	.9869	.4984
Max	5.1676	5.6713	2.149	6.2003	4.5721	5.2538	4.5268
Min	.221	.1509	.1086	.3475	.4107	.7831	.2484
Avg	2.1606	2.2717	.7703	1.8111	1.7793	2.9060	2.0068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 303 / 22 KV MALAWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0762	.0754	.1109	.0762	.0747	.1109
2	.0747	.0762	.0754	.0732	.0762	.0747	.0732
3	.0377	.0762	.0754	.1109	.0762	.0739	.1109
4	.0377	.0762	.0754	.1109	.0762	.0739	.1109
5	.0739	.1143	.1132	.1109	.0762	.1109	.1109
6	.1494	.1509	.1509	.1109	.1132	.1494	.1494
7	.1494	.1867	.1886	.1494	.1494	.1509	.1494
8	.1109	.1478	.1509	.1109		.112	.1109
9	.0747	.1494	.1509	.0732	.112	.112	.1109
10	.0754	.1509	.1109	.0739	.0747	.1109	.1132
11	.1494	.1132	.1097	.0747	.112	.0747	.1132
12	.1109	.1132	.1109	.1494	.0739	.0732	.1132
13	.1109	.0754	.0732	.112	.1109	.0732	.1132
14	.112	.0754	.0732	.1132	.1109	.0732	.1132
15	.112	.1132	.1494	.112	.112	.1097	.1132
16	.1143	.1132	.1109	.1132	.0739	.0732	.1132
17		.1132	.1109	.0762	.0739	.0732	.1132
18	.1143	.1509	.1494	.0762	.112	.0732	.1132
19	.1905	.2263	.1886	.1524	.1494	.1509	.2263
20	.2286	.2263	.1886	.1905	.1886	.1886	.2263
21	.1905	.1886	.1886	.1524	.1494		.1886
22	.1524	.1509	.1494	.1524	.1494	.1494	.1509
23	.1143	.1132	.1109	.1143	.1109	.1109	.1132
24	.1109	.1143	.1132	.1109	.0762	.0739	.1109
Max	.2286	.2263	.1886	.1905	.1886	.1886	.2263
Min	.0377	.0754	.0732	.0732	.0739	.0732	.0732
Avg	.1160	.1288	.1247	.1140	.1058	.1018	.1280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 304 / 22 KV KULAKJAI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0762	.0747	.0732	.0762	.0754	.0351
2	.0373	.0381	.0739	.0732	.0381	.0381	.0351
3	.0373	.0381	.0739	.0732	.0381	.0381	.0351
4	.0377	.0381	.0747	.0732	.0762	.0762	.0351
5	.0739	.1143	.1494	.1494	.1143	.1109	.0351
6	.1494	.1848	.1848	.1494	.1509	.1867	.1886
7	.2263	.2218	.2561	.2241	.2241	.2614	.1886
8	.1886	.1867	.1478	.1494	.1478	.1494	.1494
9	.1109	.1132	.112	.1494	.1494	.1478	.1109
10	.0747	.112	.0732	.112	.1109	.1109	.112
11	.0377	.1132	.0351	.0739	.0747	.0732	.112
12	.0373	.112	.0732	.1494	.0739	.0732	.112
13	.0373	.1109	.0732	.0377	.0381	.1097	.1097
14	.0373	.0747	.0351	.0377	.0381	.1109	.1109
15	.0377	.0747	.0351	.0373	.0754	.0732	.112
16	.0381	.0739	.0732	.0343	.0381	.0732	.1109
17		.0747	.0732	.0381	.0754	.0351	.112
18	.0381	.1109	.112	.0381	.0754	.0351	.1478
19	.1905	.1886	.1494	.1905	.1886	.1886	.1829
20	.2667	.2218	.2263	.2286	.2241	.2263	.2218
21	.1905	.1848	.1494	.1905	.1867		.1829
22	.1524	.1494	.1109		.1478	.1494	.1494
23	.1143	.1109	.0732		.1109	.0732	.1478
24	.0747	.0762	.0747	.0732	.0762	.0739	.0351
Max	.2667	.2218	.2561	.2286	.2241	.2614	.2218
Min	.0373	.0381	.0351	.0343	.0381	.0351	.0351
Avg	.0984	.1167	.1048	.1071	.1062	.1083	.1155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254044 / 33/22 KV ANDHALI

Feeder No / Name : 306 / 22 KV TONDALE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7042	.7621	.5898	.2263	.1905	.1886	.6882
2	.6859	.6859	.5636	.2263	.1905	.1886	.663
3	.6859	.7621	.5636	.2263	.2286	.2263	.6401
4	.7461	.7202	.6706	.2641	.2641	.3361	.6802
5	.8383	.7377	.7865	.3018	.2987	.3772	.7712
6	.9282	.9831	.8619	.5281	.4854	.5658	1.0159
7	1.5546	1.6575	1.1523	.6478	.6653	.679	1.6617
8	1.7814	1.9227	1.278	.3772	.5228	.6036	1.7436
9	.2987	.3292	1.2071	1.3413	1.4754	.2987	.3395
10	.2218	.2218	1.0814	1.2071	1.326	.2263	.1478
11	.1867	.1494	.8718	1.0486	1.2071	.1886	.1867
12	.1478	.1494	.9614	.8215	1.1934		.1478
13	.1494	.1494	.9175	.9614	1.1065	.1109	.1848
14	.1494	.1494	.8718	.9724	1.0059	.1494	.1494
15	.1494	.1478	.9175	.9724	1.0608	.1109	.1829
16	.2286	.1463	1.1469	1.1271	1.3108	.1494	.1848
17		.1867	.1886	.2286	.1886	.2263	.2987
18	.2286	.2587	.3772	.2667	.2987	.2263	.3292
19	.4572	.4108	.5658	.4191	.415	.1509	.5175
20	.4954	.4755	.5658	.5335	.5281	.4904	.6283
21	.4572	.4435	.4904	.4954	.4527		.5121
22	.381	.3361	.3772	.3429	.3395	.3772	.4435
23	.9145	.7377	.3018	.2286	.2241	.9156	.8048
24	.7377	.8002	.6104	.2641	.1905	.1867	.7209
Max	1.7814	1.9227	1.278	1.3413	1.4754	.9156	1.7436
Min	.1478	.1463	.1886	.2263	.1886	.1109	.1478
Avg	.5708	.5551	.7466	.5845	.6320	.3169	.5684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 201 / 11 KV PALASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.8817	.7964				
2	.8192	.8478					
3	.8192	.8478	.7964				
4	.8356	.8817	.8145	.3292			
5	.852	1.0174	1.086	.4525			
6		1.1869	1.3575	.6268			
7		1.7772	1.5927	.6984			
8	1.6004	1.7604	1.5203	.4835	.591	.5487	1.1469
9	.3045	.394	1.2803	1.3108	1.4091		
10	.2149	.1791	1.1203				
11	.1463	.1791	.8962				
12	.1097	.1791	.8802				
13	.12	.1086	.9282				
14	.12	.1086	.9175				
15	.12	.1448	.8848				
16	.128	.1448	.9175	1.065	1.2452	.1387	.1433
17	.12	.181	.1646				
18	.2149	.2534	.2743				
19	.4572	.4706	.4656				
20		.5068	.5304				
21		.362	.439				
22		.7964	.3292				
23	.8817	.7209	.3109	.3109	.3109	.8619	.8288
24	.8356	.9326	.7209	.2865	.2743	.2926	.6964
Max	1.6004	1.7772	1.5927	1.3108	1.4091	.8619	1.1469
Min	.1097	.1086	.1646	.2865	.2743	.1387	.1433
Avg	.5010	.6193	.8271	.6182	.7661	.4605	.7039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 202 / 11 KV DHAMANI Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2561	.2195	1.0402	1.073	.8848	.2454
2	.2195	.2378	.2743	1.0242	1.0395	.8848	.2454
3	.2561	.2378	.1829	1.0082	1.0395	.8848	.2481
4	.2926	.2561	.1829	1.0082	1.0898	.9012	.2835
5	.3292	.3475	.2195	1.0082	1.1904	.9175	.0354
6		.5121	.5487	1.3443	1.3077	1.1469	.4207
7		.6697	.5853	1.9524	1.8679	1.6057	.5959
8	.394	.4938	.4024	1.6004	.2458	1.5729	
9	1.5043	1.4419	.3292	.2686	.2743		
10	1.7532	1.829	.2686	.2149	.3045		1.6476
11	1.5893	1.829	.2328		.2507		1.6651
12	1.5729	1.829	.197	.197	.2507		1.5565
13		1.6461	.2149	.1791	.2195		1.5565
14	1.5402	1.6827	.2195	.1829	.2378		1.5384
15	1.5402	1.6827	.2378	.2012	.2195		1.5565
16	1.5074	.2195	.2378	.2378	.2561		1.5927
17	.1865	.2195	.2195	.2865	.2378		.2172
18		.2926	.2926	.3109	.3292		.2534
19		.439	.4298	.5121	.4938		.4706
20	.4298	.2926	.5121	.4938	.4938		.4344
21		.2926	.4755	.4572	.4024		.3982
22	.3224	.2561	.3658	.3841	.3658		.2896
23	.2865	.2561	.8642		.9339		.2534
24	.2561	.2715	.2195	1.0562	1.1401	.9012	.2804
Max	1.7532	1.829	.8642	1.9524	1.8679	1.6057	1.6651
Min	.1865	.2195	.1829	.1791	.2195	.8848	.0354
Avg	.7889	.7288	.3305	.6804	.6360	1.0778	.7175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 203 / 11 KV GONDAWALE GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2149	.2534	.2195	.2149	.3018	.1949
2	.2263	.197	.362	.2241	.197	.2829	.1772
3	.2263	.197	.4525	.2241	.197	.3018	.1753
4	.3018	.2507	.362	.2987	.2149	.3395	.2126
5	.3921	.3582	.543	.3921	.3403	.4481	.2804
6		.5552	.6335	.5373	.5194	.5729	.3856
7		.6984	.6154	.591	.6447	.6219	
8	.5544	.5731	.4887	.5014	.5373	.4938	.3856
9	.439	.3403	.3801	.3439	.4298		
10		.2328	.3582	.3077	.3761		.3189
11		.197	.2686	.2896	.3045		.2353
12	.197	.197	.197	.2715	.3109		.2353
13		.2149	.2686	.2865	.2743		.2353
14		.1991	.2926	.2865	.2926		.1991
15		.1791	.2743	.3403	.3109		.1991
16	.2058	.2686	.2926	.2865	.2926		.181
17	.197	.3403	.3109	.3544	.3658		.2896
18		.5194	.3658	.3582	.4207		.3801
19		.543	.5373	.5552	.5041		.6516
20	.591	.6154	.5304	.6089	.6535		.5973
21		.4572	.567	.591	.5601		.5249
22	.4477	1.086	.4024	.4298	.4668		.3439
23		1.086	.3224		.2987		.2534
24	.2561	.2328	.2534	.2378	.2328	.3395	.2103
Max	.591	1.086	.6335	.6089	.6535	.6219	.6516
Min	.197	.1791	.197	.2195	.197	.2829	.1753
Avg	.3276	.4064	.3888	.3711	.3733	.4114	.3030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 204 / 11 kv Mhaswad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1469	1.2452					1.2452
9				1.0486	1.1065	.0716	
16			1.0486	.9667	.9831		
23	.9556	.6554	.128			.9282	.7373
24	.852	1.0059	.4694	.1097	.0914	.0914	.8848
Max	1.1469	1.2452	1.0486	1.0486	1.1065	.9282	1.2452
Min	.852	.6554	.128	.1097	.0914	.0716	.7373
Avg	.9848	.9688	.5487	.7083	.727	.3637	.9558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254060 / 33/11 KV PALASHI

Feeder No / Name : 205 / 11 KV Gondawale Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.128	.1829				.1524
2	.1463	.128	.1829				.1524
3	.1463	.128	.1829				.1524
4	.1646	.1646	.1829				.1524
5	.2195	.1829	.1829				.2286
6	.2926	.3109	.1829				
7	.3475	.3658	.1829	1.7604	1.4091		
8	.2926	.2926	.2926	1.6324	1.491	1.3123	.3189
9	1.5729	1.4255	.2195			1.4083	1.4918
10	1.8023	1.829	.1829				
11	1.6876	1.9448	.1463				1.4251
12	1.4746		.128				
13	1.5402	1.6712	.1646				
14	1.4918	1.5402	.1463				
15	.2515	1.5074	.1829			1.1336	1.3603
16	.2515	1.5074	.1463			.9717	1.4251
17	.1463	.1463	.1646				
18	.2012	.0914	.2012				
19	.3109	.2561	.2926				
20	.3109	.2561	.3109				
21	.2561	.2195	.2561				
22	.2195	.1463	.2195				
23	.1463	.1463	1.1203	.9831	.8192	.1402	.1463
24	.1463	.1463	.1829	1.1363	1.0159	.8192	.1402
Max	1.8023	1.9448	1.1203	1.7604	1.491	1.4083	1.4918
Min	.1463	.0914	.128	.9831	.8192	.1402	.1402
Avg	.5652	.6319	.2349	1.3781	1.1838	.9642	.5955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 201 / 11 KV PINGALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.1402	.2648	.2564	.2904	.2557	.1402
2	.2416	.1379	.2564	.2473	.1486	.2465	.1303
3	.2416	.1349	.2564	.2458	.2797	.2465	.1311
4	.2625	.144	.258	.2473	.2797	.1288	.1257
5	.33	.1692	.3896	.3018	.3041	.3113	.1608
6	.5707	.2949	.6265	.5941	.5559	.5144	.3033
7	.8192	.4923	.9899	.9488	.8566	.7907	.4466
8	.7986	.487	.8452	.8215	.8181	.7605	.3544
9	.6364	.5575	.5426	.6123	.6451	.6089	.5075
10	.2355	.4313	.3879	.4291	.4733	.2644	.3818
11	.1623	.3422	.3319	.3506	.4005	.1997	.3016
12	.1562	.3117	.3071	.3186	.3742	.1753	.3078
13	.298	.2416	.3211	.3155	.3585	.1699	.2956
14	.2866	.2611	.3147	.3125	.338	.1684	.2641
15	.1547	.2957	.3094	.3094	.3288	.1448	.2934
16	.2576	.333	.2583	.2988	.3425	.1501	.2696
17	.1951	.3582	.3525	.357	.3707	.1471	.3325
18	.2149	.4073	.4136	.3864	.373	.189	.429
19	.3132	.6116	.5976	.6626	.6378	.33	.679
20	.426	.7539	.7743	.7559	.7739	.4252	.8526
21	.3864	.7652	.7205	.7282	.698	.3978	.7865
22	.3361	.6683	.6064	.6287	.5552	.3399	.6017
23	.2583	.4618	.4546	.4271	.4111	.2698	.4424
24	.266	.1806	.3201	.3277	.2957	.2945	.1783
Max	.8192	.7652	.9899	.9488	.8566	.7907	.8526
Min	.1547	.1349	.2564	.2458	.1486	.1288	.1257
Avg	.3373	.3742	.4541	.4535	.4546	.3137	.3632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 202 / 11 KV KIRAKSAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.0983	1.065	1.0159	.8848	
2	.0762		.0983	.9175	1.0159	.8848	
3	.0762		.0983	.9175	1.0159	.8848	
4	.0914		.0983	.9175	1.0159	.8848	
5	.1219		.1311	.9667	1.065	.9012	
6	.1829		.1781	1.247	1.3108	.9503	
7	.1829		.2267	1.7284	1.4746	1.3927	
8	.1524		.1619	1.7764	1.8023	1.4091	
9	1.6385	1.3717	.1296	.096	.1147	1.3927	1.1431
10		1.6518	.0972	.0762	.2058		1.4091
11		1.7166	.0648	.061	.0457		.6722
12		1.5384	.064	.061	.061		1.2163
13	.061	1.3927	.08	.061	.061		1.2483
14	.061	1.4575	.08	.061	.061		1.3283
15		1.5384	.08	.0762	.061		1.3603
16	1.5242	.0972	.08	.0476	.0762		1.4251
17		.0972	.08	.0762	.0914		.081
18		.1134	.096	.0914	.1067		.081
19		.1457	.128	.1219	.1524		.1457
20		.1619	.16	.1372	.1524		.1619
21		.1457	.176	.1372	.1524		.1781
22		.1457	.144	.1219	.1372		.1781
23		.0972	1.1012	1.0159	.8684		.1296
24	.0762		.0983	1.0978	1.0159	.8848	
Max	1.6385	1.7166	1.1012	1.7764	1.8023	1.4091	1.4251
Min	.061	.0972	.064	.0476	.0457	.8848	.081
Avg	.3324	.7781	.1563	.5365	.5450	1.047	.7172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 254072 / 33/11 KV PINGALI

Feeder No / Name : 401 / 33 KV MANDESHI SOOT GIRNI

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717		.8488	.9054	.9145	.9145	
2	.9717		.8488	.9054	.8573	.9145	
3	.9717		.9054	.8488	.8573	.9145	
4	.9717		.8488	.9054	.8573	.9145	
5	.8573		.9619	.9619	.8573	.9717	
6	.8002		.9619	.7922	.8573	.9717	
7	.8573		.9619	1.0185	.8002	.9717	
8	.8573		.8488	.9619	.9717	.9717	
9	.8573	.743	.7356	.8488	.9145	.9717	.9145
10		5.7716	.7922	.8002	.9145		.9619
11		.7922	.7922	.8573	.8573		.9619
12		.8488	.9054	.9145	.9145		.9054
13	.9145	.8488	.8488	.9145	.9717		.9619
14	.9145	.8488	.7922	.9145	.8573		.9619
15		.9054	.679	.8573	.9145		.9054
16	.8002	.9054	.7922	.8573	.9145		.9619
17		.9054	.7922	.9145	.9145		.8488
18		.9054	.8488	.9145	.9145		.8488
19		.8488	.7922	.9145	.9145		.7922
20		.9619	.8488	.9054	.9145		.7922
21		.9054	.7922	.9054	.9145		.691
22		.9054	.9054	.8573	.9145		.9054
23		.9619	.9619	1.0185	.743		.8488
24	.9717		.9054	.9619	1.0288	.8573	
Max	.9717	5.7716	.9619	1.0185	1.0288	.9717	.9619
Min	.8002	.743	.679	.7922	.743	.8573	.691
Avg	.9013	1.2039	.8488	.9023	.8954	.9374	.8841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 301 / 22 KV DAHIWADI

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.2197	1.2567	1.2567	1.2936	1.2567	1.2567	1.3306
Max	1.2197	1.2567	1.2567	1.2936	1.2567	1.2567	1.3306
Min	1.2197	1.2567	1.2567	1.2936	1.2567	1.2567	1.3306
Avg	1.2197	1.2567	1.2567	1.2936	1.2567	1.2567	1.3306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 302 / 22 KV BIDAL AG (DAHIWADI) SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.4904	.4904	.4904	.4374	1.1584	1.0837	.4527
Max	.4904	.4904	.4904	.4374	1.1584	1.0837	.4527
Min	.4904	.4904	.4904	.4374	1.1584	1.0837	.4527
Avg	.4904	.4904	.4904	.4374	1.1584	1.0837	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 303 / 22 KV SHINGANAPUR AG
(DAHIWADI Feeder KV- 22 /
OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.4403	1.3927	1.278	.3772	.2641	.3018	1.2803
Max	1.4403	1.3927	1.278	.3772	.2641	.3018	1.2803
Min	1.4403	1.3927	1.278	.3772	.2641	.3018	1.2803
Avg	1.4403	1.3927	1.278	.3772	.2641	.3018	1.2803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

DAHIWADI[116]

BU 5991

Substation No/ Name :- 257006 / 132/33/22 KV DAHIWADI

Feeder No / Name : 305 / 22 KV DEVAPUR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0366	.0724	.1886	1.1843	1.2483	1.0311	.0724
Max	.0366	.0724	.1886	1.1843	1.2483	1.0311	.0724
Min	.0366	.0724	.1886	1.1843	1.2483	1.0311	.0724
Avg	.0366	.0724	.1886	1.1843	1.2483	1.0311	.0724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 201 / 11 KV LALGUN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0377	.9114	1.0227	.9602	.0373	.0351
2	.0358	.0377	.8573	1.0227	.9332	.0373	.0351
3	.0351	.0373	.8383	1.0395	.9332	.0373	.0343
4	.0343	.0373	.852	1.0277	.9332	.0373	.0351
5	.0351	.0377	.9282	1.0608	1.0031	.037	.0358
6	.0358	.0377	1.1142	1.1271	1.2018	.0377	.0366
7	.0366	.0373	1.5927	1.5089	1.6518	.0351	.0358
8	.0373	.0351	1.704	1.7318	1.7166	.0377	.0366
9	1.869	1.6446	.0335	.0366	.0754	1.6644	1.5402
10	2.0809	1.9595	.0343	.0754	.0747	2.0153	1.7772
11	1.8976	2.0957	.0351	.0754	.0377	2.0119	1.2955
12	1.8084	1.9498	.0351	.0754	.0373	2.0576	1.2803
13	1.8084	1.8442	.0351	.0747	.0377	1.9616	1.7604
14	1.6876	1.7833	.0362	.0747	.0373	1.6632	1.7078
15	1.6288	1.8054	.0366	.0747	.0373	1.7101	1.6484
16	1.6604	1.8088	.0366	.0747	.0343	1.8519	1.7284
17	.0343	.0343	.0358	.0739	.0373	.0351	.0732
18	.0354	.0351	.0358	.0739	.037	.0343	.0739
19	.0347	.0358	.0358	.1132	.0377	.0351	.0754
20	.0377	.0351	.0358	.1132	.0373	.0343	.0754
21	.0347	.0358	.0358	.0754	.0377	.0351	.0754
22	.0351	.0366	.0351	.0754	.0377	.0358	.0754
23	.0377	.9054	1.1145	1.0437	.0377	.0366	.0377
24	.0358	.0377	.9774	1.0227	1.0031	.0377	.0358
Max	2.0809	2.0957	1.704	1.7318	1.7166	2.0576	1.7772
Min	.0343	.0343	.0335	.0366	.0343	.0343	.0343
Avg	.6255	.6810	.4744	.5289	.4571	.6465	.5644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 202 / 11 KV MANJARWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.1829	.2075	.2103	.4399	.4191	.1829
2	.1753	.1867	.197	.2103	.4247	.3944	.1829
3	.1715	.1848	.1928	.2103	.4133	.3906	.1753
4	.2454	.1848	.2058	.3155	.4133	.3887	.1791
5	.3582	.2054	.3506	.4287	.5134	.5163	.2926
6	.4382	.4207	.4477	.4973	.8071	.8011	.4294
7	.4973	.5729	.5121	.5434	1.1201	1.1138	.547
8	.4557	.4755	.4656	.4477	1.0928	1.0707	.5014
9	.3086	.3511	.3506	.3582	1.0335	.9153	.3841
10	.2804	.2896	.2865	.3547	.9004	.7232	.2686
11	.2587	.2328	.2328	.3174	.7891	.5818	.2641
12	.2587	.1928	.197	.2987	.6272	.5362	.2241
13	.2614	.197	.2534	.2801	.6035	.5091	.2353
14	.2772	.2103	.2427	.2987	.5697	.471	.2149
15	.2772	.2149	.2641	.3326	.6073	.4923	.2126
16	.2987	.2103	.2614	.2427	.6413	.3071	.2126
17	.3174	.2328	.2926	.3206	.658	.5818	.2561
18	.3547	.3155	.3292	.2987	.6584	.6127	.2987
19	.5304	.5014	.3582	.4715	.9099	.8501	.4527
20	.6161	.5609	.443	.6979	1.2993	1.2342	.6602
21	.5304	.5373	.567	.6224	1.2685	.3582	.5658
22	.4066	.4024	.6401	.4338	1.0509	.394	.439
23	.2614	.2507	.2572	.2641	.7777	.2103	.2829
24	.1753	.1867	.1928	.2103	.5276	.2012	.1791
Max	.6161	.5729	.6401	.6979	1.2993	1.2342	.6602
Min	.1715	.1829	.1928	.2103	.4133	.2012	.1753
Avg	.3306	.3042	.3228	.3611	.7561	.5864	.3184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 301 / Budh AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2117	1.2834	.0732	.0732	.0556	1.0517	1.3595
2	1.1812	1.3017	.0732	.0732	.0556	1.0745	1.3535
3	1.1888	1.262	.0716	.0732	.0556	1.0403	1.3657
4	1.2467	1.2666	.0701	.0732	.0556	1.006	1.3717
5	1.3991	1.3405	.0686	.0732	.0587	1.0921	1.4753
6	1.7338	1.515	.0701	.1494	.0617	1.2376	1.6217
7	2.7404	2.4165	.224	.3018	.4725	2.3682	2.4539
8	3.6313	2.7313	.2256	.3323	.3703	2.9218	3.4255
9	2.3868	2.1849	1.73	1.8168	1.7619	2.0005	2.3563
10	.0716	.0686	2.4295	2.5195	2.6597	.0655	.0716
11	.0732	.0701	2.6616	2.4653	2.7359	.0671	.0594
12	.0686	.0716	2.7892	2.3887	2.713	.0686	.0572
13	.0648	.0732	3.0513	2.5087	2.6642	.0701	.0587
14	.0526	.0716	2.8502	2.4104	2.3106	.0716	.0594
15	.0495	.0732	2.5911	2.3823	2.1522	.0732	.061
16	.0655	.0716	2.8045	2.4043	2.3735	.0716	.0633
17	.083	.0732	1.9632	1.6667	1.7299	.0732	.0625
18	.1181	.0747	.0732	.0724	.096	.0747	.0625
19	.3376	.0754	.0724	.0678	.1402	.0732	.061
20	.2088	.3628	.1943	.474	.2545	.285	.0655
21	.3833	.2271	.1638	.4154	.253	.4054	.0625
22	.064	.1516	.0724	.1798	.1874	.1021	.0625
23	.916	.0732	.0724	.0556	.743	.9907	.9359
24	1.2041	.3932	.0747	.1372	.8482	1.3146	1.0471
Max	3.6313	2.7313	3.0513	2.5195	2.7359	2.9218	3.4255
Min	.0495	.0686	.0686	.0556	.0556	.0655	.0572
Avg	.8534	.7180	1.0196	.9631	1.0337	.7333	.8156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 303 / Budh Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.506	.4847	.4862	.4755	.41	.431	.4816
2	.4816	.4679	.4816	.4603	.2271	.4157	.4634
3	.4786	.4526	.4695	.4603	.2576	.4016	.4603
4	.5273	.4298	.4847	.445	.1509	.2949	.4573
5	.7271	.5731	.6509	.6112	.6604	.6181	.5913
6	1.1466	1.0669	1.0822	1.1203	.9796	1.0097	1.0136
7	1.4083	1.3732	1.3778	1.3383	1.4761	1.3321	1.4145
8	1.3374	1.2796	1.3222	1.3474	1.4015	1.2948	1.3336
9	1.137	1.0425	1.1156	.9937	1.1035	1.1202	1.0547
10	.9206	.8596	.9168	.8173	.948	.7286	.855
11	.7248	.7126	.8353	.7617	.7576	.6897	.7423
12	.679	.6401	.692	.6554	.6592	.6234	.6767
13	.9023	.6135	.5091	.5426	.5609	.439	.6592
14	.3459	.5624	.5411	.5506	.5	.349	.4253
15	.5288	.583	.5243	.5525	.5152	.5167	.5239
16	.5304	.5273	.4176	.5304	.5106	.5578	.5392
17	.5373	.6116	.5502	.6097	.5121	.6211	.6611
18	.6509	.7644	.7773	.6592	.6463	.4969	.7225
19	.9983	1.0212	1.0547	.961	.9983	1.0288	1.0593
20	1.2491	1.3595	1.39	1.3778	1.3169	1.3143	1.4456
21	1.2536	1.2498	1.2727	1.2692	1.2803	1.2498	1.4236
22	.9084	1.0029	1.0974	1.0334	.9907	1.0303	1.1625
23	.7659	.7621	.7469	.754	.7354	.7468	.8817
24	.5396	.5982	.5457	.5335	.5487	.5457	.6005
Max	1.4083	1.3732	1.39	1.3778	1.4761	1.3321	1.4456
Min	.3459	.4298	.4176	.445	.1509	.2949	.4253
Avg	.8035	.7933	.8059	.7858	.7561	.744	.8187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254028 / BUDH

Feeder No / Name : 305 / 22 KV KATEWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0648	1.1317	1.2003	.9374	.0663	.0732
2	.0701	.0671	1.1065	1.1736	.9061	.0686	.0716
3	.0686	.0678	1.0814	1.1736	.9061	.0686	.0732
4	.0701	.0678	1.0562	1.1603	.9061	.0693	.0732
5	.0716	.0686	1.1012	1.2597	.9172	.0724	.0716
6	.0732	.0678	1.1142	1.3108	1.0364	.0754	.0701
7	.0716	.0686	1.576	1.7101	1.5223	.0709	.0716
8	.0732	.0747	1.749	1.7635	1.704	.0739	.0732
9	2.0317	2.0081	.0701	.0732	.0724	1.8138	1.7147
10	2.2801	2.3594	.0716	.0686	.0686	2.0645	1.6712
11	2.1216	2.079	.0716	.0724	.0693	2.1795	1.704
12	2.0241	2.2131	.0724	.0716	.0693	2.2283	1.7814
13	2.0645	2.1948	.0724	.0686	.0724	2.1125	1.6842
14	2.17	2.2085	.0724	.0701	.0701	2.0972	1.6644
15	1.9925	2.1262	.0732	.0686	.0671	2.1125	1.5497
16	1.9433	2.1735	.0732	.0701	.0686	2.1262	1.6324
17	.0655	.0671	.0747	.0678	.0701	.0686	.0739
18	.0739	.0686	.0747	.0686	.0709	.0701	.0732
19	.0732	.0701	.0732	.0732	.0678	.0716	.0724
20	.0732	.0686	.0732	.0732	.0747	.0701	.0724
21	.0724	.0701	.0732	.0732	.0739	.0686	.0716
22	.0701	.0716	.0732	.0724	.0716	.0686	.0724
23	.0671	1.1469	1.2003	1.1142	.0663	.0701	.0648
24	.0701	.0655	1.1401	1.2003	1.1012	.0648	.0716
Max	2.2801	2.3594	1.749	1.7635	1.704	2.2283	1.7814
Min	.0655	.0648	.0701	.0678	.0663	.0648	.0648
Avg	.7401	.8141	.5532	.5858	.4579	.7439	.6063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 201 / 11 KV Pusegaon gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7979	.8638	.8905	.8954	.8871	.8772	.8292
2	.7659	.8147	.8573	.8733	.8581	.8596	.8178
3	.7621	.8147	.8436	.8627	.8581	.8535	.7853
4	.7605	.8512	.8451	.8543	.8467	.8924	.7934
5	.7941	1.0403	.9694	.908	.8852	1.0634	.8437
6	1.4052	1.4399	1.3637	1.5527	1.3661	1.4407	1.1351
7	2.0237	1.9776	1.8709	2.0683	.9191	1.9981	1.7493
8	1.9494	2.0321	1.8404	2.0035	1.9532	1.9109	2.0039
9	1.7814	1.6914	1.5546	1.5661	1.744	1.5341	1.6457
10	1.6278	1.4575	1.462	1.4434	1.5573	1.3729	1.5127
11	1.5413	1.336	1.411	1.4598	1.4423	1.4728	1.5188
12	1.4194	.6752	1.3123	1.3531	1.4114	1.3717	1.3527
13	1.3386	1.5081	1.2955	1.4689	1.3603	1.227	1.1667
14	1.2392	1.4468	1.323	1.2887	1.2365	1.2002	1.1644
15	1.5021	1.4628	1.2281	1.2795	1.2902	1.2727	1.0822
16	1.5718	1.3859	1.1725	1.3539	1.3173	1.2342	.567
17	1.5706	1.6247	1.1915	1.6541	1.4297	1.2898	
18	1.6831	1.5539	1.5085	1.4411	1.4461	1.4601	
19	1.9547	1.912	1.898	1.8565	1.9444	1.851	
20	2.1094	2.0592	2.1102	2.0522	2.0718	2.1674	2.3194
21	1.832	1.8679	2.0885	1.9361	1.9003	1.9289	2.404
22	1.6194	1.6374	1.6918	1.7036	1.675	1.6727	1.9178
23	1.2769	1.2632	1.2921	1.3199	1.3146	.7324	1.4175
24	.9298	.9579	.9964	1.3584	.9701	.9995	.9778
Max	2.1094	2.0592	2.1102	2.0683	2.0718	2.1674	2.404
Min	.7605	.6752	.8436	.8543	.8467	.7324	.567
Avg	1.4273	1.4031	1.3757	1.4397	1.3619	1.3618	1.3335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 202 / 11 KV PUSEGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3876	1.3798	.0151	.0162	.0162	.9165	1.2923
2	1.3738	1.3506	.0151	.0162	.0162	.864	1.1867
3	1.3266	1.3041	.0151	.0162	.0162	.8508	1.1357
4	1.2668	1.3003	.0151	.0162	.0162	.8508	1.1029
5	1.2805	1.2653	.0151	.0162	.0162	.8927	1.0829
6	1.2843	1.3279	.0151	.0162	.0162	.9427	1.1521
7	1.9628	1.9797	.0174	.0189		1.7888	1.6135
8	2.3683	2.3927	.0151	.0162	.0162	1.9473	2.2372
9	.9734	.8995	2.3587	2.2941	2.1103	.6929	.9177
10	.0353	.0162	2.8909	2.7958	2.3573	.0162	.0154
11	.0162	.0151	2.973	2.8412	2.4318	.0162	.0154
12	.0162	.0151	2.9052	2.7214	2.2968	.0162	.0154
13	.02	.0151	2.8113	2.4842	2.2343	.0162	.0169
14	.0299	.0166	2.4783	2.0416	1.8682	.0162	.0154
15	.0162	.0151	2.1921	2.0028	1.575	.0162	
16	.0162	.0151	2.0186	1.9469	1.8071	.0162	.0154
17	.0162	.0151	.8431	.824	.8019	.02	.0162
18	.0162	.0151	.02	.0162	.0695	.0162	.0154
19	.0332	.0301	.0162	.0324	.0324	.0162	.0154
20	.0324	.0301	.017	.0324	.0667	.0162	.0309
21	.0162	.0301	.0162	.0324	.1056	.0162	.0309
22	.0162	.0151	.0162	.0324	.1086	.0162	.0154
23	1.5019	.0151	.0162	.0162	1.0551	1.4236	1.2576
24	1.4789	.6478	.0151	.0162	.5611	1.2568	1.2809
Max	2.3683	2.3927	2.973	2.8412	2.4318	1.9473	2.2372
Min	.0162	.0151	.0151	.0162	.0162	.0162	.0154
Avg	.6869	.5878	.9046	.8443	.8520	.5267	.6295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 203 / 11 KV VARDHANGAD AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0255	.0986	1.6682	1.9361	1.9201	.0666	.0308
2	.0979	.1139	1.5504	1.8472	1.8561	.0986	.0956
3	.1088	.1375	1.5105	1.7855	1.8149	.1124	.1032
4	.1124	.1573	1.5036	1.741	1.8111	.1146	.1032
5	.1124	.1467	1.5497	1.7463	1.787	.1146	.1009
6	.0514	.1025	1.608	1.8119	1.8164	.0834	.0461
7	.0819	.0369	2.0573	2.4024	1.2087	.0659	.1116
8	.1085	.0186	2.4676	2.8246	2.473	.1207	.1238
9	2.3564	2.1159	1.1907	1.4064	1.2029	2.1974	
10	3.0353	2.7976	.0171	.0826	.0278	2.8608	1.3976
11	3.1287	3.035	.0171	.0583	.072	3.1341	2.6711
12	3.0597	3.0254	.0171	.0522	.0171	3.0856	2.7408
13	2.9065	2.8582	.0224	.0323	.0636	2.9942	2.5461
14	2.7896	2.7568	.0339	.0179	.1101	2.9446	2.4196
15	3.0015	2.7797	.0209	.0186	.1116	3.0559	2.6262
16	3.0727	2.612	.0186	.0171	.0971	2.9531	2.6158
17	1.5588	1.2875	.0623	.059	.1634	1.4856	1.321
18	.0712	.0506	.07	.0712	.1839	.091	.1185
19	.1151	.0671	.0415	.0724	.1729	.0384	.1761
20	.1341	.1113	.0407	.1067	.129	.1108	.1722
21	.1192	.1158	.091	.0915	.12	.1162	.173
22	.1047	.1296	.1207	.1059	.1025	.1139	.1684
23	.0461	1.7108	1.8404	1.9212	.0936	.107	.1192
24	.0171	.9331	1.866	1.8682	1.0044	.0171	.0194
Max	3.1287	3.035	2.4676	2.8246	2.473	3.1341	2.7408
Min	.0171	.0186	.0171	.0171	.0171	.0171	.0194
Avg	1.0923	1.1333	.8077	.9199	.7650	1.0868	.8696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 301 / 22 KV Nidhal GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1973	.2126	.1749	.1901	.1749	.1596	.1749
2	.1973	.2126	.1749	.1749	.1749	.1596	.1596
3	.1973	.2126	.1596	.1749	.1749	.1596	.1596
4	.1973	.2126	.1596	.1749	.1749	.1596	.1596
5	.2126	.2504	.1749	.1901	.1901	.1973	.1901
6	.3418	.3948	.3723	.4252	.3571	.4028	.3497
7	.4485	.5167	.5167	.5167	.3658	.4862	.4333
8	.4485	.5167	.5167	.4638	.4333	.418	.3875
9	.4028	.3723	.3571	.2735	.3193	.3266	.3193
10	.2431	.2431	.2888	.2583	.2583	.2278	.2888
11	.2278	.1749	.2126	.2278	.2431	.1749	.1901
12	.2278	.2126	.2126	.2278	.2431	.2278	.1749
13	.2278	.1596	.2278	.2431	.2126	.2278	.2278
14	.2278	.2583	.2278	.2431	.2278	.2278	.1749
15	.2431	.2583	.2278	.2431	.2278	.2278	.2126
16	.2431	.2583	.2278	.2583	.2431	.2583	.1749
17	.2809	.2431	.2431	.2735	.2431	.2431	.1444
18	.2735	.3113	.2431	.2961	.2583	.2583	.2126
19	.41	.3948	.4252	.471	.471	.3266	.3571
20	.5319	.5319	.5472	.5624	.5472	.5319	.5472
21	.4485	.4638	.4485	.479	.4485	.4485	.4333
22	.3497	.3875	.4333	.3875	.3497	.3802	.3497
23	.2735	.2735	.2888	.2735	.2735	.2735	.2888
24	.2278	.2278	.1901	.1901	.1901	.1901	.1901
Max	.5319	.5319	.5472	.5624	.5472	.5319	.5472
Min	.1973	.1596	.1596	.1749	.1749	.1596	.1444
Avg	.2950	.3042	.2938	.3008	.2834	.2789	.2625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 302 / 22 KV DARUJ AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.1326	5.2332	.8128	.8433	.881	4.7177	5.4043
2	4.9497	5.109	.8128	.8433	.881	4.5626	5.2797
3	4.8278	4.9848	.8128	.8433	.881	4.5016	5.1273
4	4.8887	5.0153	.8128	.8433	.881	4.4711	4.9695
5	4.7668	4.9261	.9115	.8738	.9115	4.5043	4.9085
6	4.9848	5.0808	1.0783	1.1771	1.1161	4.7535	5.0583
7	5.7164	6.7749	1.3367	1.3744	.884	5.964	6.7352
8	8.2518	7.9706	1.3062	1.3367	1.3977	7.6951	8.0594
9	4.3793	5.4462	5.8886	7.2028	6.1164	5.0572	5.2938
10	.7213	.7518	8.4454	8.533	8.9087	1.0478	.7823
11	.6835	.7895	8.2839	8.7814	9.1221	1.0406	.7823
12	.7518	.8505	8.1345	8.5567	8.6477	1.0478	.7823
13	.7518	.7823	8.3768	8.533	8.1909	.9042	.82
14	.714	.7823	7.7961	7.9424	6.6651	.714	.8505
15	.7823	.7823	8.3844	8.0033	6.8831	.714	.8505
16	.82	.7895	8.049	7.8769	7.3777	.7518	.8128
17	.8505	.759	4.5244	5.4389	5.1109	.8505	.8128
18	.9492	.9796	.7967	.759	.8577	.9492	.7068
19	1.2902	1.1538	1.222	1.1001	1.0624	1.1466	.8954
20	1.6022	1.4049	1.595	1.4049	1.3672	1.3367	1.3062
21	1.595	1.238	1.5268	1.3672	1.2685	1.299	1.3367
22	1.3977	1.1088	1.2307	1.299	1.2002	1.1393	1.2685
23	4.4147	.9419	1.0711	1.0406	4.3626	5.1406	5.2583
24	5.3856	2.1544	.8738	.8433	3.7159	5.33	5.5593
Max	8.2518	7.9706	8.4454	8.7814	9.1221	7.6951	8.0594
Min	.6835	.7518	.7967	.759	.8577	.714	.7068
Avg	2.9420	2.7421	3.5035	3.6174	3.6954	2.9016	3.0692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

KHATAV S/DN.[830]

BU 4830

Substation No/ Name :- 254054 / 33/22 KV Shindewadi (Katgun)

Feeder No / Name : 303 / 22 KV Nidhal AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0754	.8848	1.0829	.9831	.1132	.0754
2	.1132	.0754	.8848	.9175	.9831	.0754	.0754
3	.1132	.0754	.852	.9175	.9831	.0754	.0754
4	.1132	.0754	.852	.8848	.9831	.0754	.0754
5	.1132	.1132	.9175	.8848	.9831	.1132	.0754
6	.1132	.1509	1.0159	1.0486	1.0486	.1509	.1132
7	.1132	.1886	1.4419	1.5074		.1509	.1509
8	.1132	.1132	1.4723	1.6385	1.5402	.1509	.1132
9	1.4419	1.4091	.1132	.1132	.1132	1.3923	1.3108
10	1.4746	1.5074	.0754	.1132	.1132	1.5074	1.4091
11	1.4419	1.5043	.1132	.1132	.1132	1.5402	1.4403
12	1.3763	1.5043	.1132	.1132	.0754	1.9334	1.4403
13	1.4746	1.4083	.1132	.1132	.0754	1.5074	1.4083
14	1.4746	1.3123	.1132	.1132	.0754	1.5074	1.4022
15	1.5729	1.3763	.1132	.1132	.0754	1.5074	1.3717
16	1.5729	1.4083	.1132	.1132	.0754	1.4746	1.3413
17	.1132	.1132	.1132	.0754	.0754	.0754	.0754
18	.1132	.0754	.1132	.1132	.0754	.1132	.0754
19	.1132	.1509	.1886	.1132	.1509	.1509	.1132
20	.1509	.1509	.1886	.1509	.1509	.1509	.1509
21	.1509	.1509	.1886	.1509	.1509	.1509	.1509
22	.1509	.1509	.1509	.1132	.1509	.1509	.1132
23	.1132	.9175	.9831	.9503	.1132	.0754	.1132
24	.1132	.1132	.9175	1.1203	.9831	.1132	.0754
Max	1.5729	1.5074	1.4723	1.6385	1.5402	1.9334	1.4403
Min	.1132	.0754	.0754	.0754	.0754	.0754	.0754
Avg	.5731	.5884	.5014	.5240	.4379	.5940	.5311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 201 / GOPUJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.7865	.0983	.1524		.2286	.9831
2	.7045		.0983	.1334	.1905	.2096	.9175
3	.6882	.8029	.0819	.1334		.2096	.8848
4	.7209		.0819	.1334		.1905	.8848
5	.8029	1.0159	.0819	.1334		.2096	.9175
6	.7701	1.0159	.1147	.1715	.3048	.3239	.852
7	1.3763	1.2452	.1966	.1905	.4191	.3048	1.6712
8	1.5074	1.6057		.2667	.3429	.4191	1.7204
9	.3048	.2667	.3768	.5571	1.4419	.3429	.1905
10	.3429	.2858			1.4746	.2858	.2667
11	.2096	.3239	1.3927	1.6385	1.5565	.2667	
12	.2858	.3429	1.5893	1.5729	1.6549	.3239	.2286
13		.3429	1.4746	1.5729	1.6385	.3048	.2667
14		.3048	.8684	1.5402	1.5729	.2858	
15		.3048	1.4419	1.3108	1.5402	.2858	
16		.362	1.5074	1.6057	1.3763	.3429	.2858
17		.362	.1715		.2286	.1905	.2858
18	.2286	.3429	.2286	.3048	.2667	.2667	.2286
19	.381	.3429	.3429	.3429	.381	.3429	.362
20		.3429	.3048		.381	.381	.362
21			.3048		.3048	.381	.3239
22			.2477		.2477		.2667
23	.852	.0983			.2667	1.0486	.9339
24	.7701	.7865	.0983	.1905	.3048	.2286	.2477
Max	1.5074	1.6057	1.5893	1.6385	1.6549	1.0486	1.7204
Min	.2096	.0983	.0819	.1334	.1905	.1905	.1905
Avg	.6677	.5641	.5287	.6639	.7947	.3206	.6229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 202 / VADUJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5356	.3932	1.6354	.3825	.4755	.4123	1.5973
2	1.4602	.1692	1.5691	.3749	.4336	.3894	1.512
3	1.4548	.3803	1.5115	.378	.3902	.192	1.4808
4	1.491	.1981	1.5039	.4085	.3902	.3833	1.5394
5	1.6289	.5174	1.5645	.445	.4481	.4146	1.6034
6	1.9639	.6569	1.8846	.6577	.5578	.5906	1.877
7	2.5507	.8497	2.5202	.887	.762	.759	2.9493
8	3.0331	.7567	2.8483	.8786	.8261	.8375	3.0095
9	1.4434	.0823	2.6783	2.3197	2.636	1.4244	1.3984
10	.5106	1.8374	2.7381	2.4017	1.5242	.5723	.5258
11	.5038	.6012	2.588	2.7454	2.8712	.538	.5121
12	.541	.5532	2.4527	2.5606	2.8757	.5655	.5548
13	.3712	.4679	2.3888	2.5648	2.777	.5525	.6036
14	.4024	.2446	2.2158	2.4132	2.4519	.4755	.3277
15	.3749		2.1689	2.3815	1.9144	.4199	.5937
16	.4458		2.2801	2.3853	2.2512	.6264	.6186
17	.2324		1.0235	.8741	1.1409	.5822	.6661
18	.5205	.4123	.4511	.5113	.4641	.5212	.7041
19	.6021	.8466	.6127	.6272	.6462	.6698	.6805
20	.333	.8223	.698	.3437	.6912	.7019	.7628
21	.3437	.6957	.6363	.3475	.6204	.7262	.7522
22	.2667	.6127	.5563	.3193	.5182	.2698	.7018
23	.3406	1.8347	.2469	.282	.5121	1.6301	1.5801
24	1.0204	1.1736	.9877	.4314	.4176	1.163	1.6728
Max	3.0331	1.8374	2.8483	2.7454	2.8757	1.6301	3.0095
Min	.2324	.0823	.2469	.282	.3902	.192	.3277
Avg	.9738	.6717	1.6567	1.1634	1.1915	.6424	1.1760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 203 / WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2545	.2526	.3879	.2458			.1341
2	.2538	.2138	.3227	.3186			.1326
3	.2869	.3273	.2584	.3212			.2031
4	.3281	.2126	.2587	.2713			.2038
5	.3277	.3216	.2984	.2515			.1513
6	.269	.2473	.3913	.2504			.2458
7	.2469	.3905	.3917	.3833			.197
8	.3902	.3898	.3898	.3205			.1364
9	.3909	.3917	.3879	.2473			.2309
10	.3913	.3913	.3006	.2351	3.2769		.2572
11	.3113	.3444	.3894	.1879			.2561
12	.0789	.3898	.3867	.2484			.2599
13		.306	.3867	.2031			.1738
14		.2854	.208				.0652
15		.2538	.2824				.0419
16		.2599	.2519				.2549
17		.394	.3909				.2572
18		.3928	.3882				.2576
19		.3837	.3867				.2553
20	.0046	.2538	.3875				.2545
21	.1665	.2568	.3894				.2553
22	.216	.2538	.322			.0591	.13
23	.2553	.3646	.1334			.1459	.1014
24	.2526	.3227	.3113	.1147		.0781	.0984
Max	.3913	.394	.3917	.3833	3.2769	.1459	.2599
Min	.0046	.2126	.1334	.1147	3.2769	.0591	.0419
Avg	.2603	.3167	.3334	.2571	3.2769	.0944	.1897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 204 / VADUJ GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5973	.905	.7059	.6878	.724	.7602	.724
2	.5792		.6878	.6516	.6878	.724	.6878
3	.5611	.8326	.6878	.6335	.6516	.6878	.6516
4	.5792		.6878	.6335	.6516	.6878	.6516
5	.6335	.8421	.7602	.6878	.8688	.7783	.724
6	.9774	1.0498	.9774	.9412	.9412	1.0136	1.086
7	1.2308	1.267	1.3756	1.3213	1.1584	1.3032	1.4118
8	1.2986	1.3032	1.3756	1.2308	1.3032	1.1946	1.3756
9	1.0974	1.086	1.086	1.086	1.1584	1.0136	1.0498
10	.9774	1.0498	1.086	.9412	1.0136	1.0136	1.0136
11	1.0136	1.0498	1.0136	1.0498	1.0136	1.0136	1.0498
12	1.0136	1.0136	.9412	1.0498	.9774	1.0136	.9412
13	.9412	.9412	1.0136	.9774	.9774	.9412	.8688
14	.9412	.9412	.9412	.9774	.8688	.8688	
15	.8326	.9412	.9774	.9774	.8238	.8326	.8688
16	.8688	.9412	1.086	1.0136	.9313	1.0136	.905
17		.9774	1.1222		.8326		.8688
18	.9412	1.086	1.1222	1.086	1.086		1.0136
19	1.448	1.3756	1.3756	1.448	1.4118	1.0136	1.267
20		1.448	1.3937		1.3394		1.3394
21		1.1765	1.2127		1.2308	1.5203	1.1765
22		1.1041	1.1222		1.1222		1.1222
23	.8688	.8507			1.0498	.905	.9231
24	.6335	.7602	.7421	.7421	.724	.7602	.7964
Max	1.448	1.448	1.3937	1.448	1.4118	1.5203	1.4118
Min	.5611	.7602	.6878	.6335	.6516	.6878	.6516
Avg	.9017	1.0428	1.0215	.9545	.9811	.9530	.9790

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 205 / GOPUJ GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0724	.0914	.0905	.0724	.0716	
2	.0905		.0914	.0724	.0537	.0724	
3	.0905	.0537	.0732	.0543	.0537	.0716	
4	.0905		.0732	.0549	.0543	.0716	
5	.1086	.0716	.0732	.0914	.0895	.0895	.1433
6	.181	.1086	.128	.1463	.1254	.0895	.1612
7	.2353	.1433	.1829	.1829	.197	.1254	.1791
8	.1991	.1254	.1646	.1463	.1612	.1791	.1612
9	.1267	.1267	.1097	.0732	.1267	.1848	.1463
10	.1463	.1294	.1097	.0739	.1463	.1848	.128
11	.1478	.156	.1097	.128	.1663	.181	.1294
12	.128	.1578	.1463	.1097	.2054	.2012	.1109
13	.128	.1433	.128	.128	.1663	.2054	.0934
14	.0732	.1267	.0549	.1097	.1867	.1307	
15	.1097	.0724	.0549	.1097		.1294	.1109
16	.0732		.0549	.0914	.1086	.0724	.0924
17		.0554	.0549		.0905	.0724	.1097
18	.0895	.0739	.0905	.0895	.1075	.0724	
19	.1075	.2195	.181	.1086	.197	.1433	.1829
20		.2195	.1991		.197	.1791	.2195
21		.1646	.181		.1254	.1791	.2195
22		.1646	.1629		.0716		.2012
23	.0905	.1463			.0716	.1433	.2858
24	.1448	.0554	.1097	.1086	.1949	.0716	.0895
Max	.2353	.2195	.1991	.1829	.2054	.2054	.2858
Min	.0732	.0537	.0549	.0543	.0537	.0716	.0895
Avg	.1235	.1232	.1141	.1036	.1291	.1270	.1536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254027 / VADUJ

Feeder No / Name : 206 / 11KV KUMTHE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.1905	1.1142		.9831	.2667
2	.1905		.1905	1.065	.6554	.9503	.2286
3	.1905	.1905	.1905	1.0322	.6554	.9503	.4191
4	.1905		.1905	1.0322		1.0814	
5	.2477	.2286	.2477	1.0486		1.1469	.3048
6	.381	.3048	.4001	1.3599	2.2939	1.1142	.3048
7	.4572	.381	.4572	1.6876	1.5074	1.3336	.4001
8	.4191	.381	.4001	1.7695	1.8351	1.5074	.3429
9	1.7604	1.8351	.3239	.2286	.2667	1.5912	1.5083
10	1.8947	1.9662	.2477	.3239	.3048	1.8067	1.6907
11	1.6518	1.7736	1.3927	.2858	.2858	1.7166	1.7404
12	1.6356	1.6804	.2096	.2858	.2667	1.6324	.2286
13	1.4575	1.6549	.1905	.2667	.2667	1.6164	1.5912
14	1.5223	1.704	.1905	.2667	.2096	1.4403	
15	1.5223	1.8023	.1905	.2286	.2477	1.6221	1.6409
16	1.5708	1.7368	.2096	.2667	.2667	1.704	.8848
17		.2477	.2667		.2667	.1905	.2286
18	.2286	.2667	.3048	.2667	.3048	.2667	
19	.3429	.4001	.4191	.381	.3429	.362	.3429
20		.362	.4572		.4001	.381	.4572
21		.3048	.4191		.3429	.381	.4001
22		.3048	.362		.2286		.3048
23	.852	.2477			.9503	.2286	.2858
24	.1905	.2667	.2096	1.1633	.6882	.9831	.2667
Max	1.8947	1.9662	1.3927	1.7695	2.2939	1.8067	1.7404
Min	.1905	.1905	.1905	.2286	.2096	.1905	.2286
Avg	.8448	.8295	.3331	.7407	.5994	1.0865	.6590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 201 / 11 KV BANPURI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	2.4006	2.572		.2286	.2858	
2	2.4006	2.4006	2.572		.2286	.2286	
3	2.3491	2.4006	2.572		.1905	.1905	2.7606
4	2.3491	2.4006	2.6578	.4572	.1905	.1905	
5	2.572	2.6406	2.7606		.2858	.1905	
6	2.8292	3.2065	2.8978		.4763	.2858	
7	3.4122	3.2579	2.915	.4954	.5144	.381	3.2407
8	2.7606	3.2407	1.1831		.4191	.4382	
9	.362	.3429	1.3889		1.6124	.362	
10	.3048	.3239	1.3717	1.848	1.7511	.3239	.3048
11	.3048	.3239	1.4232		1.7164		.3048
12	.381	.3239	1.3546		1.7164	.3239	.3048
13	.362	.3239			1.5777		
14	.3048	.3239	2.0576		2.2712	.362	.362
15	.3048	.2858			2.8197		
16	.3239	.2858					
17	.4001	.2858				.362	
18	.381	.3048					
19	.4763	.4001	.381				.381
20	.4763	.4191	.4954			.5144	
21	.4382	.381					
22	.362	.3239				.362	.381
23	2.3834	2.4691					
24	2.4006	2.4006	2.572	.3239	.2477	.3239	2.7606
Max	3.4122	3.2579	2.915	1.848	2.8197	.5144	3.2407
Min	.3048	.2858	.381	.3239	.1905	.1905	.3048
Avg	1.2933	1.3111	1.9484	.7811	1.0154	.3203	1.2000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 202 / 11 KV BARAGAON Water
Supply Feeder KV- 11 /
OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	05-MAR-17
HR	Load (MW)
3	.0572
Max	.0572
Min	.0572
Avg	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 203 / 11 KV Palasgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1715	.1715		.4334	.4334	
2	.1334	.1715	.1715		.5201	.4681	.1334
3	.1334	.1715	.1715	.463	.052	.4334	
4	.1334	.1715	.1715		.5201	.4334	
5	.1334	.1905	.1905		.7802	.4681	
6	.381	.4191	.381		.9536	.6935	.381
7			.381	1.0117	1.0402	.7802	
8			.362		.9189	.8149	
9	.823	.8916	.3239		.3048	.743	
10	.7545	.8402	.2286	.2286	.2858	.6935	.7545
11	.703	.7716	.1715		.1905		.6687
12	.6516	.7888	.1334		.1905	.4973	.6516
13	.6173	.7716			.1715		
14	.6516	.703	.1143		.0572	.583	.583
15	.7373	.8573			.1524		
16	.6687	.8573				.7202	
17	.1334	.2286					
18	.2096	.2286					
19	.4001	.381	.2667				.2667
20	.381	.4001	.4001			.4001	
21	.3048	.3239					
22	.2477	.2477				.2858	.2667
23	.1715	.1715					
24	.1524	.1715	.1715	.463	.4334	.3814	.1334
Max	.823	.8916	.4001	1.0117	1.0402	.8149	.7545
Min	.1334	.1715	.1143	.2286	.052	.2858	.1334
Avg	.3934	.4514	.2382	.5416	.4378	.5518	.4266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 301 / PIMPRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.4344	.1524	.3048	.4801	.1143	
2	.1143	.1143	.1524	.1219	.4801	.1143	
3	.1143	.1143	.1524	.3505	.1143	.1143	
4	.1143	.1143	.1524	.0457		.1143	.1524
5	.1524	.1524	.1524	.2134	.1143	.1143	
6	.5411	.6935	.5944	.3963	.4801	.4572	.442
7	.7773	.8154	.884	.8535	.7621	.7011	.6554
8	.8535	.8154	.8992	.5944	.7849	.7621	.8306
9	.6477	.7011	.823	.5944	.4877	.6478	.4572
10	.5487	.5106	.5944	.1067	.4649	.5106	.4115
11	.4725	.3963	.5258	.3353	.4649	.3353	.442
12	.4877	.4725	.4496	.3353	.4496	.3734	.4725
13	.4725	.3048	.3506	.3048	.3734	.2439	.3201
14	.381	.4267	.4877	.1981	.1905	.5258	.4877
15	.5334	.4572	.1067	.3658	.3429	.381	.3506
16	.5334	.4877	.3658	.381	.3201	2.7701	.3506
17	.5792	.2896	.2134	.3658	.3201	.442	.3201
18	.6096	.5487	.5487	.3658	.3201	.4877	.3963
19	.762	.8078	.8916	.4877	.4268	.5335	.6249
20	.884	.884	.9602	.6249	.6859	.7925	.6249
21	.884	.8992	.6401	.5639	.6401	.6249	.5792
22	.8002	.7849	.5944	.5487	.5335	.7163	.6859
23	.5715	.6706	.4877	.4268	.442	.4572	.4268
24	.823	.442	.5182	.5334	.2362	.4191	.4877
Max	.884	.8992	.9602	.8535	.7849	2.7701	.8306
Min	.1143	.1143	.1067	.0457	.1143	.1143	.1524
Avg	.5322	.5141	.4874	.3925	.4311	.5314	.4759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 302 / ENKUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762		.1143	.1143	
2	.0762	.0762	.0762		.1143	.1143	
3	.0762	.0762	.0762	.1524	.1143	.1143	
4	.0762	.0762	.0762		.1143	.1143	
5	.1143	.0762	.0762	.1524	.1143	.1143	.1524
6	.2819	.2057	.3429	.1219	.1524	.2438	.2286
7	.602	.6325	.6858	.442	.4115	.5944	.442
8	.5563	.7087	.7163	.442	.5868	.5715	.663
9	.4649	.5792	.6858	.5411	.4039	.5106	.503
10	.5411	.5792	.5487	.6554	.2515	.3124	.4191
11	.5106	.503	.4877	.4115	.1143	.3658	.4267
12	.2972	.4115	.3429	.4268	.1143	.381	.1981
13	.2667	.3124	.2743	.1677	.1143	.1372	.0914
14	.1143	.1143	.1829		.1143	.1143	.1524
15	.1143	.3429	.2591	.3658	.1143		
16	.1143	.4344	.3658	.3963		.2057	.2134
17	.2057	.4649	.3353	.442			.381
18	.1676	.4039	.3353	.2286			.3506
19	.4648	.5106	.2667	.0457		.3048	.4344
20	.602	.6249	.5868	.3506	.4115	.6249	.442
21	.5868	.6249	.4115	.3658	.4268	.4572	.4115
22	.4725	.4953	.3506	.2134	.2591	.5182	.503
23	.1524	.1524					
24	.9526	.1143	.1143	.1524	.1143	.1143	.1524
Max	.9526	.7087	.7163	.6554	.5868	.6249	.663
Min	.0762	.0762	.0762	.0457	.1143	.1143	.0914
Avg	.3286	.3582	.3336	.3197	.2190	.3014	.3425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 303 / MANDVE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762		.1143	.1143	
2	.0762	.0762	.0762		.1143	.1143	
3	.0762	.0762	.0762		.1143	.1143	.1524
4	.0762	.0762	.0762		.1143	.1143	
5	.1524	.0762	.0762		.1143	.1143	
6	.1524	.1524	.1524		.1524	.1524	
7	.1981	.1829	.2591	.0914	.3201	.1676	.0152
8	.1524	.1524	.2591	.0762	.1143	.1524	.1981
9	.1143	.1524	.1524		.1143	.1143	
10	.1143	.1143	.1143	.1524	.1143	.1143	.1524
11	.1143	.1143	.1143		.1143		.1524
12	.1143	.1143	.1143		.1143		.1143
13	.0762	.0762			.1143		
14	.0762	.0762	.1143		.1143	.1143	.1524
15	.0762	.0762			.1143		
16	.0762	.0762				.1143	
17	.0762	.0762					
18	.1143	.0762					
19	.1524	.1524	.1143				.1524
20	.1829	.2591	.381	.0914		.4191	
21	.4115	.2286	.1829	.1981	.2286	.3353	.1981
22	.1524	.1143		.0762		.2591	.7621
23	.1143	.1143					
24	.6478	.0762	.0762	.1143	.1143	.1143	.1524
Max	.6478	.2591	.381	.1981	.3201	.4191	.7621
Min	.0762	.0762	.0762	.0762	.1143	.1143	.0152
Avg	.1489	.1153	.1421	.1143	.1354	.1643	.2002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254038 / KATARKHATAV

Feeder No / Name : 306 / PEDGOAN AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.5335		.9709	1.4563	
2	.5335	.6097	.5335	1.5089	.9709	1.4563	
3	.5335	.6097	.5335		.9709	1.4563	
4	.5335	.6097	.5335		.9709	1.4563	
5	.9145	.6859	.6859		.9362	1.4563	.6859
6	1.1431	1.2193	1.0288		2.0805	1.7337	
7			1.2193	2.4006	2.774	2.0805	
8			.9145		2.7046	2.1845	.9907
9	2.2634	2.6749	.724		.6097	2.4272	
10	2.7435	2.7435	.6097	.6097	.4572	1.3523	2.1948
11	2.4691	2.4006	.5716		.5335		2.1262
12	2.1262	2.1948	.5335		.381	1.9204	2.0576
13	2.0576	2.0576			.381		
14	1.7833	2.0919	.6097		.381	1.7833	1.7833
15	1.7833	2.4691					
16	2.1262	2.5377				2.0576	
17	.4572	.5335					
18	.6097	.5335					
19	.9907	.9145	.8383				.6097
20	1.0669	1.1431	1.1431			.9907	
21	.9907	1.0669					
22	.8383	.9145				.7621	
23	.6859	.6859					
24	4.5725	.6097	.6097	1.5089	.0902	1.5257	.5335
Max	4.5725	2.7435	1.2193	2.4006	2.774	2.4272	2.1948
Min	.4572	.5335	.5335	.6097	.0902	.7621	.5335
Avg	1.4469	1.3598	.7264	1.5070	1.0142	1.6312	1.3727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 201 / AMBAWADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8535	.112	.1296	.1014	.9168	.916	1.6431
2	.8238	.112	.1311	.1067	.9076	.8276	1.6134
3	.8185	.1265	.1326	.1128	.8566	.8375	1.6179
4	.8314	.1303	.1334	.1143	.8627	.8078	1.5556
5	.9168	.1311	.1303	.109	.9328	.8322	1.7775
6	.9991	.1517	.1677	.1501	1.2033	.9838	2.1424
7	1.3138	.1943	.2431	.1913	1.8427	1.6644	3.1626
8	1.6987	.2149	.2507	.1966	3.8637	3.6892	3.8693
9	1.8534	1.3748	1.5569	.1837	1.6537	1.7657	2.0095
10	1.925	1.8084	2.0104	.1981	.1814	.1974	.3512
11	1.9387	1.8442	2.0599	.1707	.1692	.3773	.3835
12	1.9563	1.6209	3.7963	.1517	.1669	.1837	.3841
13	2.0081	2.0485	2.0767	.1608	.173	.2446	.3799
14	1.9227	2.0248	2.0279	.1707	.1562	.218	.385
15	1.8953	1.9128	2.0096	.1814	.1585	.1509	.3622
16	3.4934	1.8488	3.6365	.1631	.1524	.366	.3335
17	1.7231	1.8008	1.7116	.1806	.1532	.208	.3843
18	.1539	.1608	.1578	.1913	.1997	.2248	.2172
19	.0091	.1951	.1898	.1966	.2157	.2157	.4632
20	.1783	.1959	.1943	.205	.2073	.2073	.4351
21	.1555	.1852	.1791	.1989	.1989	.2263	.4018
22	.1326	.1738	.1539	.1684	.1837	.192	.3693
23	.1204	.1478	.1227	.8711	.884	.8947	1.3409
24	.8016	.1273	1.7694	.9221	1.7251	1.6808	1.0151
Max	3.4934	2.0485	3.7963	.9221	3.8637	3.6892	3.8693
Min	.0091	.112	.1227	.1014	.1524	.1509	.2172
Avg	1.1885	.7768	1.0405	.2249	.7485	.7463	1.1082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 204 / 11 KV MORALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0754
2							.0754
3							.0754
4							.0754
5							.0943
6	.0392	.0503	.0282	.0514	.0526	.0503	.1792
7	.0781	.072	.0648	.0716	.0701	.0808	.2506
8	.0846	.0762	.0735	.0732	.2462	.2217	.2124
9	.061	.0636	.0587	.0606	.0499	.0537	.1287
10	.0328	.013	.0065	.0011	.0248	.0065	.1502
11		.0034				.0739	.0815
12			.0701				.0754
13				.0004		.0095	.0705
14					.0038	.0019	.0701
15					.0008		.0701
16	.0754				.0011	.1132	.0701
17	.0027	.0019		.0004	.0229	.0088	.0705
18			.0023		.029	.0412	.0709
19	.0008	.0518	.0484	.0476	.0446	.0575	.1093
20	.0758	.0774	.0629	.069	.0667	.0758	.1394
21	.072	.0781	.0629	.0636	.0648	.0678	.141
22	.0621	.0575	.0522	.0526	.0617	.0587	.1273
23	.0431	.048	.0408	.0434	.0518	.0457	.1154
24	.0701	.0004	.0701		.0943	.1132	.0762
Max	.0846	.0781	.0735	.0732	.2462	.2217	.2506
Min	.0008	.0004	.0023	.0004	.0008	.0019	.0701
Avg	.0537	.0457	.0493	.0446	.0553	.0635	.1085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 207 / 11 KV Goregaon (N) AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	1.8922	1.8313	1.659	.1562	.1722	.3413
2	.1311	1.8496	1.7856	1.5821	.1532	.1753	.3436
3	.1379	1.8115	1.797	1.5447	.1532	.1684	.3428
4	.1448	1.8381	1.7825	1.5379	.1585	.1494	.3458
5	.1646	1.9753	1.8168	1.6606	.1738	.1265	.4305
6	.2256	2.1628	1.9738	1.7825	.2362	.1959	.5595
7	.3231	2.8174	2.4074	2.178	.3559	.3048	.7521
8	.3628	3.0575	2.8083	2.54	.663	.6443	.7417
9	.3064	2.617	2.6566	2.8548	2.5293	2.5728	5.2844
10	.2705		.25	3.0986	2.9249	3.0437	6.3701
11	.2271		.2324	3.1207	3.0872	5.863	1.263
12	.109		.3715	3.0803	3.2929	3.0384	5.7205
13	.1219		.221	3.0216	3.1603	.1349	6.0562
14	.1943		.218	2.9957	2.8243	.1036	6.2801
15	.2225		.2195	2.9012	2.9012		6.0783
16	.2355		.4009	2.8243	3.1139		6.081
17	.2652		.2294	2.066	2.3236		2.6426
18	.3147	.1692	.2454	.2088	.2241	.2111	.4563
19	.2919	.2766	.2462	.218	.25	.2431	.5435
20	.2713	.266	.2545	.2393	.2812	.2804	.5769
21	.2545	.2393	.2401	.2233	.2644	.2683	.5255
22	.1966	.189	.2042	.1905	.2416	.2355	.4048
23	1.7535	1.8465	1.5485	.1837	.2111	.1844	.3382
24	2.04	1.9212	3.0696	.1501	.2688	.301	.3475
Max	2.04	3.0575	3.0696	3.1207	3.2929	5.863	6.3701
Min	.109	.1692	.2042	.1501	.1532	.1036	.3382
Avg	.3625	1.5581	1.1171	1.7442	1.2479	.877	2.2011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 302 / MHASURNE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			1.3763	1.6644	
11				.3018	
12	1.3763	1.6194		.3018	.3018
16	1.0486	1.3443			.3018
22					.2641
24		.1886	.7362	.7773	1.0974
Max	1.3763	1.6194	1.3763	1.6644	1.0974
Min	1.0486	.1886	.7362	.3018	.2641
Avg	1.2125	1.0508	1.0563	.7613	.4913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 303 / NIMSOD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1509
2					.1509
3					.1509
4					.1509
5					.1886
6					.2641
7					.3772
8			.8676	.9808	.4527
9					1.6095
10					1.7901
11				1.9757	2.1365
12		.2641		1.9433	1.9757
13					1.9006
14					1.749
15					1.8138
16	.4904	.2641		1.9227	1.7814
22					.2263
24	.2641	1.1336	.4527	.4527	.1524
Max	.4904	1.1336	.8676	1.9757	2.1365
Min	.2641	.2641	.4527	.4527	.1509
Avg	.3773	.5539	.6602	1.4550	.9456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 305 / SHIRASWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.1219	.1677	.1067	.0152	.0305	.0762
7	.381	.4115	.4115	.3963	.3963	.3963	.3963
8	.4115	.4268	.4115	.381	.7061	.6835	.6154
9	.381	.2743	.2134	.2896		.4115	.3353
10	.1981	.3353	.1219				.0762
11	.0457					.1509	
12		.0152	.0754		.2896	.1509	.0754
13				.0305			
16	.0754	.0305	.0754			.1509	.0754
17		.2439					
18		.1372		.0152			.0152
19	.2286	.381		.0762	.3658	.1372	.381
20	.4572	.5182	.4877	.4725	.5335	.503	.5335
21	.4725	.4877	.4572	.4725	.5182	.4877	.503
22	.4268	.3963	.3963	.3963	.4572	.4115	.5479
23	.3506	.1829	.2896	.3353	.3048	.1677	.3201
24	.0754		.0754		.1509	.0754	.1143
Max	.4725	.5182	.4877	.4725	.7061	.6835	.6154
Min	.0457	.0152	.0754	.0152	.0152	.0305	.0152
Avg	.2920	.2831	.2653	.2702	.3738	.289	.2904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254039 / NIMSOD

Feeder No / Name : 306 / PUNWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4725	.4572	.442	.4572	.442	.4268
2	.3963	.4572	.4268	.4268	.4268	.4268	.4268
3	.3963	.442	.4268	.4115	.4115	.4268	.4268
4	.381	.442	.4268	.4115	.4115	.4115	.4268
5	.4877	.503	.5487	.5182	.503	.5335	.5335
6	.7621	.8383	.884	.823	.7926	.8688	.9145
7	1.2041	1.2346	1.2346	1.2346	1.2651	1.2346	1.1584
8	1.2346	1.1736	1.2346	1.2193	1.733	1.7555	1.725
9	.9145	.8535	.9297	.7926	.9602	.9907	.9145
10	.7011	.7468	.8078	.5335	.884	.8078	.7011
11	.6554	.5792	.6554	.442	.8078	.9716	.5182
12	.6401	.5639	1.0936	.3506	.7011	.7011	.6835
13	.6249	.6706	.6401	.381	.5944	.6706	.4268
14	.6554	.5487	.5335	.4115	.4877	.6706	.3963
15	.503	.6097	.4725	.4115	.6706	.6097	.4268
16	.6844	.6706	.9949	.6859	.6401	.9449	.7823
17	.6859	.7773	.6859	.6554	.6249	.5182	.5487
18	.8078	.8535	.7621	.7926	.5335	.7468	.6097
19	1.0517	1.0822	.9602	.8688	.9145	1.0059	.8688
20	1.1584	1.0669	1.0364	1.1736	1.2193	1.1888	1.0669
21	1.1126	1.0212	.9602	1.0517	1.1279	1.1736	1.0059
22	.8383	.823	.7926	.8383	.8688	.884	.9937
23	.6554	.6097	.6097	.6249	.6706	.5944	.6097
24	.503	.4877	.714	.503	.7366	.6683	.6706
Max	1.2346	1.2346	1.2346	1.2346	1.733	1.7555	1.725
Min	.381	.442	.4268	.3506	.4115	.4115	.3963
Avg	.7277	.7303	.7620	.6668	.7684	.8019	.7193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 301 / PACHWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0754	.0754	.0754	.0739	.0754	.0754
2	.0747	.0754	.0754	.0754	.0754	.0754	.0754
3	.0754	.0754	.0747	.0754	.0762	.0754	.0754
4	.0754	.0754	.0754	.0754	.0762	.0754	.0754
5	.1132	.1132	.0754	.1132	.1132	.1132	.0754
6	.1509	.1509	.0754	.1509	.1494	.1509	.1132
7	.1905	.1886		.2286		.1886	.1372
8	.1509	.1509		.1509	.1132	.1886	.1132
9	.112	.1132	.1132	.1132	.1132	.1509	.1132
10	.1132	.0754	.0739	.0747	.112	.0754	.0754
11	.1132	.0754	.0754	.0754	.1132	.0747	.0732
12	.1132		.0762	.0754	.0754	.0377	.0724
13	.0754	.0754	.0754	.1132	.0754	.0377	.0732
14	.0754	.0754	.0754	.0754	.0754	.0377	.0754
15	.0754	.0754	.0754	.0754	.0754	.0377	.0754
16	.0754	.0754	.0754	.0754	.0754	.0377	.0754
17	.0754	.0754	.0754	.0754	.0754	.0377	.0754
18	.1132	.0754	.0762	.1109	.1132	.0754	.1109
19	.1886	.1132	.1509	.1867	.1886	.0754	.1848
20	.1886	.1509	.2263	.1886	.2263	.1132	.1848
21	.1886	.1509	.1886	.1524	.1886	.112	.1886
22	.1509	.1524	.1509	.1509	.1509	.1143	.1509
23		.0754	.1509	.0754	.1132	.0754	.1132
24	.0739	.0754	.0754	.1132	.0754	.0754	.0754
Max	.1905	.1886	.2263	.2286	.2263	.1886	.1886
Min	.0739	.0754	.0739	.0747	.0739	.0377	.0724
Avg	.1147	.1017	.0994	.1115	.1098	.0880	.1024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 302 / PADAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0754	.0754	.0754	.0754	.0754	.0754
2	.0381	.0754	.0377	.0754	.0739	.0377	.0754
3	.037	.0754	.0377	.0377	.061	.0377	
4	.0373	.0754	.0377	.0377	.0701	.0754	.0747
5	.0739	.1509	.0747	.1132	.1132	.1132	.0754
6	.1509	.2263	.0754	.1886	.1509	.1524	.1509
7		.2641	.2263	.2641		.2641	.2241
8		.2263	.1509	.1905	.1886	.2263	.0754
9		.1509	.1132	.1509	.0762	.1509	.0754
10		.0754	.0754	.0747	.1143	.0754	.0754
11		.0754	.0377	.0762	.0747	.0747	.0381
12	.0754	.0754	.0381	.0747	.0377	.0754	.0377
13	.0754	.0377	.0754	.0377	.0377	.0377	.0377
14	.0754	.0377	.0732	.0377	.0377	.0377	.0377
15	.0754	.0377	.0366	.0373	.0754	.0377	.037
16	.0754	.0377	.0366	.0347	.0754	.0373	.0377
17	.0754	.0754	.0754	.0747	.0754	.0754	.0739
18	.0754	.0754	.0754	.0754	.0754	.0754	.0739
19	.1509	.1132	.1509	.1509	.1509	.1132	.1509
20	.1886	.1132	.1886	.1886	.2263	.1509	.1886
21	.1509	.1132	.1524	.1509	.1905	.112	.1524
22	.1132	.0754	.1132	.1132	.1143	.0754	.1132
23		.0747	.1132	.0732	.0754	.0754	.0732
24	.0351	.0754	.0754	.0754	.0762	.0754	.0754
Max	.1886	.2641	.2263	.2641	.2263	.2641	.2241
Min	.0351	.0377	.0366	.0347	.0377	.0373	.037
Avg	.0856	.1005	.0894	.1004	.0977	.0943	.0882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 303 / KALEDHON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1132	.1509	.1132	.1509	.1132	.112
2	.1132	.1132	.1494	.0762	.1143	.0754	.1132
3	.1143	.1132	.1132	.1132	.1143	.0754	.1132
4	.1109	.1132	.1132	.1132	.112	.1132	.1509
5	.1509	.1509		.1886	.1509	.1886	.1509
6	.2263	.2263	.1509	.2641	.2263	.2667	.2641
7	.3048	.415	.1886	.3395		.3395	.3361
8	.2263	.3395	.2263	.2667	.2641	.3018	.1886
9	.1905	.2263	.2263	.2263	.1886	.2641	.1867
10	.1886		.1886	.1509	.1524	.1448	.1509
11	.1886		.1509	.1075	.1509	.1132	.1509
12	.1886		.1509	.1143	.1132	.112	.1132
13	.1886		.1132	.1132	.1132	.1132	.1075
14	.1509		.1143	.1509	.1132	.112	.1132
15			.1524	.1509	.1132	.1132	.1132
16	.1509		.1143	.1463	.1132	.1509	.1086
17	.2263		.2263	.1478	.1478	.1494	.1524
18	.2641		.1829	.1509	.1867	.1886	.1848
19	.3018		.2587	.3018	.3018	.2614	.2641
20	.3018		.2641	.3018	.3018	.2641	.3018
21	.2641		.2641	.2286	.2641	.2641	.2286
22	.2263		.2263	.1867	.1886	.1886	.1886
23			.1886	.1886	.1509	.1132	.112
24	.1524	.1509		.1509	.1478	.1132	.1132
Max	.3048	.415	.2641	.3395	.3018	.3395	.3361
Min	.1109	.1132	.1132	.0762	.112	.0754	.1075
Avg	.1975	.1962	.1779	.1788	.1687	.1725	.1674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 304 / STATIONERY POINT

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6149	1.776	1.7844	1.3698	1.5207	.5609	.439
2	1.5429	1.7821	1.8172	1.4106	1.5413	.5057	.4542
3	1.5394	1.5882	1.8435	1.4106	1.526	.4545	.4237
4	1.5806	1.7101	1.7635	1.4502	1.472	.5323	.4714
5	1.6229	1.6945	1.7254	1.4335	1.2955	.5605	.4409
6	1.7135	1.8751	1.8416	1.4468	1.2079	.5815	.3497
7	1.587	1.8918	1.7867	1.4697	1.2365	.6596	.3574
8	1.4872	1.371	1.7406	1.2349	1.7734	.612	.3116
9	1.4807	1.2338	1.6613	1.6964	1.693	.7034	.2416
10	1.5379	1.7703	1.8766	1.6149	1.7112	.7163	.1802
11	1.3756	1.1546	1.7482	1.7235	1.7768	.8604	.1745
12	1.6941	1.3298	1.7512	1.8332	1.7402	1.0014	.1535
13	1.6636	1.4308	1.7597	1.6073	1.6026	.8036	.1516
14	1.5626	1.1888	1.4998	1.6369	1.4872	.7407	.144
15	1.5436	1.5337	1.7254	1.4422	1.3215	.8097	.1459
16	1.5931	1.5375	1.9399	1.6377	.95	.7152	.1459
17	1.8118	1.4403	1.8606	1.5905	.9743	.6829	.1459
18	1.994	1.4422	1.5321	1.6092	.8912	.5381	.1745
19	1.9578	1.4918	2.0001	1.4765	.8154	.5304	.1783
20	2.0893	1.4784	1.7406	1.3721	.7868	.4885	.1935
21	2.0154	1.2689	1.6454	1.2049	.6653	.5285	.1554
22	1.7699	1.3946	1.6644	1.35	.6124	.4752	.1478
23	1.3603	1.3851	1.6473	1.5596	.3631	.479	.1459
24	1.9136	1.797	1.2441	1.4956	.7987	.5415	.1478
Max	2.0893	1.8918	2.0001	1.8332	1.7768	1.0014	.4714
Min	1.3603	1.1546	1.2441	1.2049	.3631	.4545	.144
Avg	1.6688	1.5236	1.7333	1.5032	1.2401	.6284	.2448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 305 / GHARUDI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.9465	.8573	.3018	.3018	.3018	.7712
2	.7011	.9465	.8859	.3018	.3018	.3018	.7964
3	.6733	.9568	.9214	.3018	.3018	.2641	.788
4	.6859	.9671	.9313	.3395		.2641	.8238
5	.8139	1.0745	1.0498	.3772		.3395	.8859
6	.9724	1.576	1.2003	.7468		.3772	1.0749
7	1.7814		1.6297	.7468		.7167	2.1262
8	2.2405	2.364	1.7833	.6036	.5281	.679	2.0805
9	.415	.415	2.1152	1.6004	1.6461	.5281	.3772
10	.3772		1.182	1.5546	1.4022	.3772	.3395
11			1.2757	1.5684	1.6118	.3395	.3395
12	.3395		1.387	1.4083	1.5592	.3018	.3018
13	.3018		1.3672	1.3283	1.5592	.3018	.2263
14	.2641		1.2757	1.2597	1.5043	.2641	.2263
15	.2641		1.4746	1.2742	1.6766	.2641	.2263
16	.2641		1.56	.3018	.2641	.3018	.2263
17	.3395		.3395	.3772		.3018	.2641
18	.415		.3772		.2641	.3772	.2641
19	.5658		.4904	.5281	.5281		.5281
20	.6036		.6036	.5658	.6036	.5281	.5658
21	.5281		.5281	.5281	.4527	.5658	.4904
22	.4527		.3772	.3772	.415		.3772
23			.3018	.3395	.3018	.9145	.8413
24	.8669	.9465		.3018	.3018	.3018	.8048
Max	2.2405	2.364	2.1152	1.6004	1.6766	.9145	2.1262
Min	.2641	.415	.3018	.3018	.2641	.2641	.2263
Avg	.6621	1.1325	1.0397	.7406	.8171	.4051	.6561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 306 / KANERWADI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2263	.543	.4557	.5487	.2241
2	.2263	.2263	.2263	.543	.2507	.5487	.2263
3	.2263	.2263		.543	.181	.5853	.2263
4	.2641	.2263	.2286	.5373	.2172	.724	.2263
5	.3395	.2641	.2286	.6733		.7964	.2641
6	.4527	.3018	.2263	.8413		.8688	.4481
7	.5658		.6348	1.3375		1.0974	.4854
8	.5281	.5281	.4854	1.4243	1.1401	1.0974	.4904
9		1.0517	.3772	.2641	.3018	.9511	.8478
10			.3395	.1509	.3018	1.0395	.8916
11			.3395	.1886	.2641	.9602	.6379
12	.788		.2263	.2263	.1509	.8322	.7282
13	.9313		.2641	.1886	.2263	.823	.6661
14	1.0029		.2263	.2263	.1886	.7011	.6859
15	1.0745		.2263	.2263	.1509	.7362	.6588
16	1.0029		.2641	.2263	.2641	.815	.5959
17	.2641		.1886	.3018		.1509	.1509
18	.3395		.2263	.3018	.3018	.1886	.2263
19	.415		.4527	.4527	.4904	.5228	.4527
20	.415		.415	.4904	.4904	.4904	.4904
21	.3772		.415	.415	.4527	.415	.415
22	.3395		.3772	.3395	.415		.3772
23			.543	.4908	.543	.2641	.2641
24	4.763	.5281		.543	.4557	.5121	.2263
Max	4.763	1.0517	.6348	1.4243	1.1401	1.0974	.8916
Min	.2263	.2263	.1886	.1509	.1509	.1509	.1509
Avg	.7271	.3977	.3244	.4781	.3621	.6813	.4544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

VADUJ DIVISION[520]

VADUJ[107]

BU 5924

Substation No/ Name :- 254040 / 33/22 KV VIKHALE

Feeder No / Name : 307 / VIKHALE AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.2263		.4961	.5914	.1886
2	.1509	.1509	.2263	.7087	.5068	.5914	.1886
3	.1509	.1509	.2263	.7087	.543	.6219	.1886
4	.1509	.1509	.2641	.8413	.5121	.6584	.1886
5	.2263	.1886	.2641	1.0056		.724	.1886
6	.2641	.3018	.2987	1.2346		.8688	.2641
7	.3772	.3772	.4527	1.5939		1.0974	.3361
8	.2641	.3395	.415	1.6907	1.3077	1.2548	.3395
9	1.1218	1.2548	.3395	.2263	.2641	1.2003	1.0402
10	1.1568		.3772	.2263	.2263	1.2003	.9602
11			.3018	.2263	.1509	1.3394	.6379
12	1.2971		.2641	.1886	.2263	1.262	.6661
13			.2263	.1886	.2263	1.2346	.5014
14	1.2971		.2263	.1886	.1886	1.1462	.6024
15	1.2971		.3018	.1132	.2263	1.1789	.9259
16	1.2971		.1886	.1509	.2263	1.2136	1.1271
17	.2263		.1886	.2263	.2263	.1886	.1886
18	.2641		.2641	.2263	.1886	.2641	.3018
19	.3395		.2641	.3395	.3018	.2987	.415
20	.3772		.3395	.415	.3395	.2641	.415
21	.3395		.2641	.3018	.3395	.2241	.3395
22	.2641		.2641	.2641	.2641	.2641	.2263
23			.7087	.5895	.6447	.2263	.2263
24	.1509	.1509		.7087	.4908	.5853	.2263
Max	1.2971	1.2548	.7087	1.6907	1.3077	1.3394	1.1271
Min	.1509	.1509	.1886	.1132	.1509	.1886	.1886
Avg	.5316	.3216	.2997	.5375	.3760	.7708	.4451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 301 / MAHABALESHWAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.9145	.8764	.9526	.9907	.8383	.8764
2	.8002	.8764	.8383	.8764		.8002	.8002
3	.7621		.7621	.8383		.7621	.7621
4	.7621		.8764	.8383	1.0288	.7621	.8002
5	.8002		.9526	.9145	.9907	.8383	.9145
6	1.0669		.9907	1.0288		.9907	1.0669
7	1.3336	1.2574	1.3717	1.5242	1.7147	1.3717	1.448
8	1.2955	1.6385	1.7147	1.7909		1.6766	1.6766
9	1.6385	1.6004	1.6766	1.6766		1.5242	1.6385
10	1.1431	1.5242	1.6385	1.5242		1.3717	1.448
11		1.3336	1.448			1.3336	1.3336
12		1.2955	1.3336			1.2955	1.1431
13		1.2193	1.2955			1.2955	1.0288
14		1.1431	1.1431			1.1431	.9907
15	1.2193	1.1431	1.2574			1.1431	1.0288
16		1.1431	1.2574	1.2574		1.105	.9526
17		1.1431	1.3717			1.4098	1.0288
18		1.3336	1.5242			1.3717	1.1431
19	1.9052	1.829	1.9052			1.7909	1.7909
20		1.7528	1.7147	1.9052	1.829	1.829	1.7147
21		1.6004	1.6766			1.7147	1.5623
22		1.448	1.6004			1.4098	1.3717
23		1.1431	1.3336			1.1431	1.0669
24	.9907		.9145	1.0288		1.0288	.9526
Max	1.9052	1.829	1.9052	1.9052	1.829	1.829	1.7909
Min	.7621	.8764	.7621	.8383	.9907	.7621	.7621
Avg	1.1226	1.3336	1.3114	1.2428	1.3108	1.2479	1.1892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 302 / Moleshwar

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.0762	.0762		.0762	.0762
2	.0762	.0762	.0762	.0762		.0762	.0762
3	.0762	.0762	.0762	.0762		.0762	.0762
4	.0762		.0762	.0762		.0762	.0762
5	.0762		.0762	.0762		.0762	.0762
6	.1524		.0762	.1143		.0762	.1143
7	.6096	.3048	.3963	.3582	.3506	.4267	.5792
8	.9373	.503	.8687	.7316	.5944	.8306	.7392
9	.6097	.5335	.8002	.7011	.5487	.7849	.7849
10	.503	.6706	.7011	.6554	.5335	.7087	.6782
11	.1829	.762	.5868	.3963	.602	.4572	.4344
12	.2743	.4801	.4267		.1219	.3582	.0762
13	.0914	.0762	.2057		.1829	.0762	.0762
14		.0762	.1143			.0762	.0762
15		.0762	.1143	.2591		.0762	.0762
16		.0762	.1143			.1143	.0762
17		.1524	.3734	.1829	.061	.1524	.221
18	.4115	.503	.4496	.5715	.381	.5563	.5411
19	.442	.5411	.6554	.4725	.4725	.6249	.8078
20	.503	.6554	.6858	.5335	.7621	.7087	.7316
21	.442	.6173	.6706	.442	.442	.7163	.6325
22	.381	.5715	.5334	.442	.4572	.602	.5563
23	.2896	.381	.1448	.3201	.3201	.4039	.4801
24	.0762		.0762	.1143		.0762	.1143
Max	.9373	.762	.8687	.7316	.7621	.8306	.8078
Min	.0762	.0762	.0762	.0762	.061	.0762	.0762
Avg	.3143	.3754	.3490	.3338	.4164	.3420	.3407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 303 / Metgutad

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478		.6097			.5335	.5335
2	.6478		.5716			.4954	.4954
3	.5716	.4191	.5335		.6097	.4572	.4572
4	.5716	.4954	.5716			.4954	.4954
5	.6478		.6478			.5335	.5716
6	.7621	.7621	.7621		.7621	.6097	.724
7	.9526		.9907		1.0669	.9145	.9526
8	1.2574		1.1431			1.2574	1.1431
9			1.2193		1.3336	1.1431	1.1812
10		1.1431	1.1812			1.0669	1.1431
11		.9145	.8764			1.0669	.8002
12		.7621	.8383			.9145	.7621
13		.6097	.7621			.7621	.6478
14		.5716	.7621			.5716	.5716
15		.6478	.7621			.4954	.6097
16	.6859	.6478	.9145			.4954	.5716
17		.724	.7621			.6478	.6478
18		.8002	1.1431			.6859	.8383
19		.9526	1.1431			.9526	.9526
20		.9526	.9526			.9526	.9145
21		.8002	.9145			.8764	.7621
22		.7621	.8002			.724	.6859
23		.6097	.724			.8002	.5335
24	.5716	.4954	.6478	1.9052		.6097	.6097
Max	1.2574	1.1431	1.2193	1.9052	1.3336	1.2574	1.1812
Min	.5716	.4191	.5335	1.9052	.6097	.4572	.4572
Avg	.7316	.7261	.8431	1.9052	.9431	.7526	.7335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 304 / Venna Lake

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.5335	.4954	.4954		.4572	.4191
2	.4572	.4572	.4572	.4572		.4191	.381
3	.4191		.381			.4191	.381
4	.4191		.4572			.4954	.4191
5	.4191		.4954		.4954	.4954	.4572
6	.4572		.5335			.5335	.5335
7	.5716		.6478	.724		.5335	.5716
8	.7621		.8002			.8383	.7621
9			.8002			.7621	.7621
10		.7621	.8002			.7621	.8383
11		.8764	.8383			.7621	.7621
12	.7621	.8764	.7621			.7621	.7621
13		.7621	.8764			.7621	.7621
14		.7621	.7621			.7621	.6478
15		.7621	.8002			.6859	.6478
16		.7621	.8002			.724	.6859
17		.6478	.724			.6097	.6097
18		.7621	.7621			.6478	.6097
19		1.1431	1.2955		1.105	1.1431	1.0288
20		1.0288	1.2574			1.2193	1.0288
21		.9907	1.2193			1.105	1.0288
22		.8383	1.0669			.7621	.8383
23		.6097	.7621			.6097	.6097
24	.5716		.5335	.5716		.5335	.4572
Max	.7621	1.1431	1.2955	.724	1.105	1.2193	1.0288
Min	.4191	.4572	.381	.4572	.4954	.4191	.381
Avg	.5335	.7859	.7637	.5621	.8002	.7002	.6668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MAHABALESHWAR S/DN. 15[835] BU 4835

Substation No/ Name :- 254031 / MAHABALESHWAR

Feeder No / Name : 305 / Bramha Corp Hotels &
Resorts Feeder KV- 22 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.3048			.3429
2	.3429		.3048			.3048
3	.3048		.3048			.3048
4	.3048		.3048	.3429	.3429	.3048
5	.3429		.3048		.3048	.3429
6	.3429		.3048		.3429	.3429
7	.3429		.3048		.3429	.3048
8	.3429		.3429		.381	.3429
9			.381		.4954	.4572
10		.4191	.3429		.381	.4191
11		.381	.3429		.381	.381
12		.4191	.381		.4191	.4191
13		.3429	.381	.381	.4572	.381
14		.4191	.381		.381	.381
15		.3048	.4954		.4191	.381
16		.381	.4572		.4191	.4191
17		.3429	.4191		.381	.381
18		.3429	.4572		.3429	.381
19		.4191	.4954		.4191	.4572
20		.4572	.5335		.4572	.4572
21		.381	.4572		.4572	.4954
22		.381	.4191		.4191	.4572
23		.3429	.4191		.4191	.4572
24	.3048		.3048			.3429
Max	.3429	.4572	.5335	.381	.4954	.4954
Min	.3048	.3048	.3048	.3429	.3048	.3048
Avg	.3302	.381	.3810	.3620	.3982	.3858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 303 / TAPOLA

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0336	.0381	.0373	.0377	.0373	.0377
2	.0377	.0373	.0381	.037	.0373	.037	.0381
3	.0381	.0377	.0381	.0373	.037	.0373	.0381
4	.0381	.0377	.0381	.0373	.0373	.0336	.0377
5	.0377	.0739	.0381	.0754	.0754	.1509	.0377
6	.0747	.0739	.0377	.0754	.0762	.2241	.0747
7	.1109	.1494	.0747	.112	.1143	.3772	.1109
8	.1494	.1494	.0739	.1097	.1509	.3734	.1478
9	.112	.1097	.1109	.0732	.1132	.3658	.0724
10	.1109	.0732	.0747	.1132	.112	.3292	.1086
11	.0074	.0732	.0747		.1109	.2561	.0732
12	.0747	.0732	.0739	.0739	.1109	.2561	.0732
13	.0732	.0732	.0747	.0747	.1109	.0732	.0724
14	.0747	.0732	.0739	.0747	.112	.0732	.0732
15	.0739	.0732	.0739	.0739	.1109	.0732	.0732
16	.0747	.0732	.0747	.112	.112	.0732	.0732
17	.1109	.1463	.0739	.1132	.1478	.0732	.0732
18	.1494	.1463	.1494	.1132	.1494	.1463	.0739
19	.1848	.1829	.1848	.1867	.1848	.1848	.1494
20	.2241	.1848	.1867	.2263	.1867	.1848	.1867
21	.2263	.1494	.1478	.1867	.112	.1478	.1494
22	.1109	.112	.112	.1132	.1132	.112	.112
23	.0747	.0754	.0754	.0762	.0747	.0747	.0747
24	.0377	.0754	.0377	.0377	.0381	.0754	.0377
Max	.2263	.1848	.1867	.2263	.1867	.3772	.1867
Min	.0074	.0336	.0377	.037	.037	.0336	.0377
Avg	.0935	.0953	.0823	.0944	.1027	.1571	.0833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 304 / KELGHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5746	.5677	.6135	.583	.4831	.5152	.5152
2	.5609	.5152	.5472	.5304	.4664	.4862	.5015
3	.5426	.5136	.5472	.5319	.4603	.4679	.4862
4	.5411	.5152	.5167	.5319	.4649	.4085	.4862
5	.5754	.5724	.5899	.6051	.4992	.5419	.5239
6	.7464	.7255	.7834	.7834	.6486	.7102	.7186
7	1.1603	1.1317	1.1839	1.2316	1.0517	1.1538	1.1012
8	1.6195	1.6202	1.6613	1.5592	1.4411	1.4145	1.4662
9	1.7254	1.6606	1.7223	1.5779	1.4769	1.6431	1.4556
10	1.6812	1.5516	1.5455	1.6552	1.4494	1.5082	1.528
11	.8554	1.4602	1.4799	1.4556	1.3474	1.3732	1.5516
12	1.0593	1.2955	1.4777	1.3992	1.4282	1.2231	1.3626
13	1.2384	1.1584	1.1202	1.259	1.3542	.5578	1.076
14	1.0898	1.0974	1.1164	1.0388	1.073	.8962	1.0151
15	1.0631	1.0456	.9998	1.0692	1.086	1.0951	.9785
16	1.2254	1.195	1.1446	1.1782	1.2711	.8516	1.0456
17	1.6366	1.5485	1.4983	1.518	1.5745	1.3108	1.2079
18	1.8321	1.8808	1.8168	1.887	1.8229	1.6065	1.7589
19	2.2634	1.9997	2.2176	2.0595	1.983	2.1186	2.0897
20	2.2116	2.0759	2.3167	2.159	1.954	2.2134	2.2116
21	1.9151	1.8717	1.8283	1.7623	1.7169	1.813	1.9098
22	1.4746	1.576	1.5653	1.4083	1.4998	1.443	1.515
23	1.1024	1.137	1.0471	.9839	1.0189	1.054	1.0167
24	.703	.6916	.7576	.6154	.6535	.6988	.6439
Max	2.2634	2.0759	2.3167	2.159	1.983	2.2134	2.2116
Min	.5411	.5136	.5167	.5304	.4603	.4085	.4862
Avg	1.2249	1.2253	1.2541	1.2243	1.1760	1.1294	1.1736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 305 / NIZARE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.2218	.1494	.1478	.1494	.1867	.1494
2	.1132	.112	.1509	.1509	.1478	.1494	.1132
3	.1132	.112	.1509	.112	.1132	.1109	.1132
4	.112	.1848	.1509	.112	.112	.112	.112
5	.1494	.2218	.1509	.2218	.1109	.1848	.112
6	.1886	.2987	.2241	.2987	.1463	.2614	.1494
7	.2587	.2957	.2957	.3696	.2587	.3326	.2218
8	.4066	.4024	.3696	.4481	.3982	.3734	.4024
9	.4024	.4066	.439	.4755	.4435	.4755	.4854
10	.3734	.4066	.5175	.5544	.4854	.439	.5121
11	.4066	.439	.4805	.5121	.4805	.439	.439
12	.4854	.4024	.4481	.439	.4481	.5121	.4024
13	.4108	.4024	.439	.439	.4435	.439	.4024
14	.3696	.4755	.4481	.4066	.4481	.439	.4024
15	.4108	.439	.4805	.439	.4805	.439	.439
16	.4481	.439	.4854	.4344	.5228	.4024	.439
17	.4805	.4755	.4755	.5544	.5601	.439	.4805
18	.5228	.5487	.5175	.5914	.5914	.4755	.5175
19	.5601	.6653	.5975	.6283	.6653	.5487	.5601
20	.5601	.5544	.5658	.6283	.5228	.5175	.4854
21	.4904	.4805	.4854	.4481	.3772	.4805	.3734
22	.3361	.3696	.3395	.3326	.3361	.3361	.362
23	.2241	.2614	.2241	.2241	.2263	.1867	.2614
24	.1886	.1886	.1867	.1886	.1886	.1509	.1494
Max	.5601	.6653	.5975	.6283	.6653	.5487	.5601
Min	.112	.112	.1494	.112	.1109	.1109	.112
Avg	.3400	.3668	.3655	.3815	.3607	.3513	.3369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254032 / MEDHA

Feeder No / Name : 306 / BHANANG

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1867	.1886	.1867	.1848	.1867	.1886
2	.1494	.1494	.1509	.1478	.1463	.1848	.1509
3	.1509	.1509	.1509	.1494	.1494	.1478	.1509
4	.1494	.1886	.1509	.1867	.1509	.1509	.1509
5	.1509	.2614	.1886	.1848	.1886	.2241	.1509
6	.1886	.3326	.2614	.2987	.2241	.3018	.2614
7	.3734	.4024	.3696	.4066	.3326	.3734	.3326
8	.5175	.5175	.5175	.4854	.5068	.4066	.4755
9	.5121	.5121	.4755	.4755	.5487	.439	.5601
10	.4805	.4755	.4805	.4435	.5544	.439	.5121
11	.5228	.5487	.5228	.4755	.4854	.4024	.4755
12	.5121	.5487	.4805	.3982	.5175	.439	.439
13	.4481	.5121	.4805	.3658	.5175	.439	.439
14	.4527	.439	.4854	.4024	.5228	.439	.4435
15	.4527	.5121	.4854	.3982	.4805	.439	.439
16	.5975	.5121	.5175	.394	.5121	.4755	.439
17	.6722	.439	.5228	.4755	.5601	.5121	.5175
18	.6283	.5487	.5228	.5544	.5975	.5544	.5121
19	.7392	.6584	.6348	.5487	.6283	.6653	.6722
20	.5975	.6283	.5228	.5175	.5601	.5914	.5975
21	.5228	.4805	.4481	.4066	.3734	.4854	.439
22	.4066	.4066	.3772	.3658	.3772	.3361	.4024
23	.2614	.2987	.2614	.2587	.2241	.2263	.2561
24	.2263	.1886	.2263	.1886	.1867	.1886	.1886
Max	.7392	.6584	.6348	.5544	.6283	.6653	.6722
Min	.1494	.1494	.1509	.1478	.1463	.1478	.1509
Avg	.4124	.4124	.3926	.3631	.3971	.3770	.3831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254050 / TAPOLA

Feeder No / Name : 301 / GOGAVE

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0381	.061	.0648	.061	.0572	.0762
2	.0648	.0381	.0381	.061	.0381	.0572	.08
3	.061	.0381	.0381	.0572	.0381	.0572	.0724
4	.0686	.0381	.0572	.0648	.0381	.0686	.08
5	.0953	.0762	.0648	.0686	.0381	.0648	.0762
6	.0914	.1029	.0724	.0686	.061	.0724	.0838
7	.0991	.1105	.0953	.1105	.0953	.08	.1067
8	.16	.1296	.1257	.1486	.141	.0914	.1067
9	.1257	.1257	.16	.1638	.141	.1257	.1143
10	.1524	.1105	.0991	.0876		.1143	.1753
11	.1296	.1181	.1105	.1029	.1524	.1029	.1372
12	.0991	.1181	.0876	.1143	.1181	.0838	.1029
13	.0953	.08	.0991	.0876	.1105	.08	.0991
14	.08	.0991	.0876	.0876	.1029	.0724	.0838
15	.0953	.1029	.0991	.0838	.08	.0838	.0876
16	.1296	.08	.0914	.1296	.0953	.1029	.0724
17	.1562	.0914	.0991	.1791		.1257	.1372
18	.1677	.1143	.1334	.1867	.1677	.1372	.1638
19	.1334	.1905	.1943	.1943	.1943	.1638	.1829
20	.1715	.1677	.1981		.1867	.1943	.202
21	.141	.141	.16			.1638	.1638
22	.1105	.1181	.1029		.1219	.1486	.1296
23	.0724	.1105	.1029		.0762	.1029	.0838
24	.0724		.061	.0648	.0648	.061	.0724
Max	.1715	.1905	.1981	.1943	.1943	.1943	.202
Min	.061	.0381	.0381	.0572	.0381	.0572	.0724
Avg	.1100	.1017	.1016	.1063	.1011	.1005	.1121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254050 / TAPOLA

Feeder No / Name : 302 / SHINDI

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0686	.0648	.0648	.08	.0381	.0724
2	.0686		.061	.0648	.0724	.0381	.0762
3	.0648	.061	.0572	.061	.0686	.0381	.08
4	.0686	.0724	.0648	.0648	.0724	.0381	.08
5	.0914	.08	.0724	.08	.0724	.0381	.0838
6	.0876	.0838	.08	.08	.0876	.0724	.0838
7	.0914	.08	.1105	.0991	.1296	.0762	.1219
8	.0914	.0648	.1257	.1448	.1372	.0914	.141
9	.1029	.061		.1753	.1715	.0991	.1105
10	.0838	.0381	.1372	.0876	.1257	.0838	.1143
11	.0914	.0381	.1296	.0838	.1143	.0572	.1105
12		.0724	.1067	.0953	.1067	.1105	.1029
13		.0724	.1296	.0991	.1029	.1219	.1105
14		.0686	.1181	.0914		.0724	.0876
15	.08	.0686	.1219	.0991	.1143	.1029	.1219
16	.1524	.0686	.0648	.0876	.0838	.0991	
17		.1105	.1296	.1372		.1296	.1486
18	.2248	.1791	.1257	.1715	.1296	.1296	.16
19		.2477	.1829		.2591	.221	.2705
20	.1829	.2743	.2439		.2439		.2629
21	.2743	.1943	.1981				.2248
22	.1638	.141	.141		.1181	.16	.1486
23	.1105	.0838	.0991		.0381	.1448	.1029
24	.0838	.0762	.0648	.0724	.08	.0381	.0838
Max	.2743	.2743	.2439	.1753	.2591	.221	.2705
Min	.0648	.0381	.0572	.061	.0381	.0381	.0724
Avg	.1153	.1002	.1143	.0979	.1147	.0909	.1261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 301 / ANEWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.2957	.3048	.2865	.2401	.3048	.2957
2	.2507	.3326	.2667	.2507	.2401	.3048	.2957
3	.2507	.3326	.2667	.2507	.2743	.2667	.3326
4	.2507	.3696	.3048	.2507	.3086	.2667	.3658
5	.2865	.4435	.3429	.2865	.3429	.2667	.439
6	.394	.5121	.4191	.394	.4115	.4572	.5121
7	.4656	.5487	.5716	.5487	.4801	.6097	.5487
8	.5014	.6219	.5716	.5487	.5144	.6478	.5487
9	.5014	.4755	.5487	.6219	.5144	.6097	.5144
10	.4801	.3696	.4801	.3292	.6173	.4115	.4115
11	.4115	.4191	.4115	.4805	.4458	.4458	.4115
12	.4115	.4572	.3086	.3696	.4458	.4458	.3429
13	.3429	.4191	.3772	.3696	.3429	.3772	.3429
14	.3086	.381	.3429	.3696	.3772	.3772	.3429
15	.3429	.4191	.3086	.4024	.3772	.3429	.3086
16	.4115	.381	.3429	.3696	.3429	.4115	.3086
17	.3772	.4572	.3429	.4066	.4458	.4115	.3772
18	.5121	.4954	.4458	.4435	.5716	.4458	.3772
19	.6584	.6859	.6805	.6584	.6478	.6584	.6805
20	.724	.724	.7164	.695	.8002	.7316	.6805
21	.6878	.6859	.6447	.6584	.7621	.6584	.6089
22	.5853	.5335	.5014	.5487	.6097	.5487	.4656
23	.3326	.4191	.3224	.3696	.4191	.3696	.3582
24	.2865	.2957	.3048	.2865	.3326	.3429	.2987
Max	.724	.724	.7164	.695	.8002	.7316	.6805
Min	.2507	.2957	.2667	.2507	.2401	.2667	.2957
Avg	.4177	.4615	.4220	.4248	.4527	.4464	.4237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 302 / ANEWADI AGRICULTURE

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1462	.1372	.1372	.1433	.1372	1.2689	1.1401
2	1.182	.1372	.1029	.1433	.1372	1.0631	1.2209
3	1.1462	.1372	.1029	.1433	.1372	1.105	1.2742
4	1.0745	.1372	.1029	.1433	.1372	.9945	1.3413
5	1.1104	.1715	.1372	.1433	.1715	.9945	1.4083
6	1.2178	.2058	.2058	.2507	.1715	1.2003	1.4754
7	1.5043	.2058	.2401	.2507	.2058	1.6804	1.5424
8	1.8267	.2401	.2401	.2149	.2058	1.6461	1.4083
9	2.1132	1.8564	1.9204	1.7551	.2058	.2058	.1715
10	2.0233	2.146	2.332	1.6575		.1029	.1715
11	2.2291	2.0919	2.2291	1.989	.1715	.2058	.1715
12	2.0576	2.0919	2.0576	1.8107	.1715	.1715	.1715
13	2.0233	2.0576	1.9547	1.6575	.1715	.1715	.1715
14	2.0233	2.0576	1.8519	1.6766	.1029	.1372	.1715
15	1.9547	2.0233	1.7147	1.6278	.1029	.1715	.1715
16	1.9547	1.989	1.749	1.6575	.1372		.2058
17	.1029	.1715	.1372	.1715	.1715	.2401	.2058
18	.2058	.1715	.1791	.1715	.2401	.2058	.1372
19	.2058	.2058	.2865	.2058	.2401	.2743	.2865
20	.2401	.2401	.2865	.2401	.3086	.2743	.2865
21	.2401	.2401	.2507	.2058	.2743	.2743	.2865
22	.2058	.2058	.2149	.1715	.2401	.2058	.2865
23	.1372	.1372	.1791	.1715	1.406	1.1736	1.2536
24	1.182	.1372	.1372	.1433	.1372	1.2689	1.1401
Max	2.2291	2.146	2.332	1.989	1.406	1.6804	1.5424
Min	.1029	.1372	.1029	.1433	.1029	.1029	.1372
Avg	1.2128	.7998	.7812	.6977	.2341	.6537	.6708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 303 / Kudal Gaonthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5731	.4024	.6478	.5731	.583	.6097	.6283
2	.5373	.7316	.6097	.5373	.6173	.5716	.5914
3	.5373	.8779	.5716	.5373	.6859	.5335	.7392
4	.5373	1.0242	.5716	.5373	.8916	.5716	.8779
5	.6447	1.0974	.6859	.6089	.9259	.6097	1.0242
6	.9313	1.1706	.9526	.9313	.9602	.8764	1.1706
7	1.2536	1.3169	1.2955	1.2178	1.0974	1.1812	1.3169
8	1.2536	1.39	1.3336	1.2178	1.0974	1.2193	1.2803
9	1.2536	1.3169	1.2346	1.1706	1.166	.8383	1.1317
10	.583	1.2437	1.3032	.8871	1.166	.9602	1.1317
11	.6516	1.2193	.9602	1.0974	.9602	.9945	.9602
12	.6516	1.1812	.9259	1.0974	.9602	.8916	.8916
13	.9602	1.0288	.9602	.961	.9259	.8916	.823
14	.9259	1.0288	.9259	.961	.8916	.8573	.7888
15	.9945	1.0669	.9945	1.0974	.8916	.5487	.823
16	.9259	1.0669	.4458	1.0974	.8573	.6173	.8573
17	.9602	1.1431	.6173	1.134	.9259	.6516	.8573
18	1.0974	1.2193	.9259	1.1706	1.1431	1.1317	1.0631
19	1.5203	1.4861	1.4327	1.3535	1.3336	1.448	1.4327
20	1.5565	1.6004	1.4327	1.448	1.448	1.39	1.3611
21	1.3394	1.448	1.2178	1.1706	1.2955	1.2071	1.1462
22	1.134	1.1812	1.0387	.9979	1.105	1.0719	.9313
23	.8501	.8002	.6805	.7392	.7621	.7762	.6805
24	.5731	.6653	.6859	.5731	.5914	.5716	.5914
Max	1.5565	1.6004	1.4327	1.448	1.448	1.448	1.4327
Min	.5373	.4024	.4458	.5373	.583	.5335	.5914
Avg	.9269	1.1128	.9354	.9632	.9701	.8759	.9625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 304 / KUDAL AGRICULTURE

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	1.4083	1.2346	1.0745	1.0288	.0343	.0343
2	.1075	1.4754	1.166	1.0745	.9945	.1029	.0343
3	.1075	1.4754	1.0974	1.0745	.9602	.1029	.0343
4	.1075	1.6118	1.0974	.9313	.9602	.1029	.0343
5	.1075	1.5912	1.166	.9313	.9945	.1372	.0343
6	.1433	1.6575	1.2346	1.0029	1.0288	.1715	.0343
7	.1791	1.6907	1.6461	1.2407	1.0288	.1715	.0686
8	.1433	1.8233	1.7833	1.3565	1.2346	.1715	.0686
9	.1433	.0343	.1372	.0686	1.2003	1.7147	1.3717
10	.1029	.0343	.1029	.0686	2.2634	2.1262	.5487
11	.1029	.1715	.1372	.1029	2.2634	2.2634	2.4691
12	.1029	.1372	.1372	.1029	2.2634	2.2634	2.2634
13	.1372	.1372	.1029	.1029	2.332	2.2634	2.2634
14	.1372		.1372	.1029		1.6461	2.332
15	.1372		.1372	.1029		2.0576	2.1262
16	.1372	.1372	.1372	.1029	2.1262		2.1948
17	.1029	.2058	.1715	.1029	1.7147	1.5089	.1372
18	.0343	.1715	.1433	.0686	1.2346	.1029	.1372
19	.0686	.2058	.2149	.1029	.1715	.1029	.1791
20	.0686	.2058	.2149	.0686	.1715	.0686	.1791
21	.0686	.1715	.1791	.0686	.2058	.0686	.1791
22	.0343	.1715	.1433	.0686	.2058	.0686	.1433
23	1.3748	1.3717	1.2178	1.0174	.1715	.0343	.1433
24	.1075	1.3748	1.3717	1.1462	1.0631	.1372	.0343
Max	1.3748	1.8233	1.7833	1.3565	2.332	2.2634	2.4691
Min	.0343	.0343	.1029	.0686	.1715	.0343	.0343
Avg	.1610	.7847	.6296	.5035	1.1644	.7575	.7102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

MEDHA[122]

BU 0965

Substation No/ Name :- 254057 / SONGAON

Feeder No / Name : 305 / KARHAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.2561	.3048	.2865	.2401	.3048	.2587
2	.2507	.2926	.2667	.2507	.2743	.2667	.2587
3	.2507	.3326	.2667	.2507	.3086	.2667	.2957
4	.2507	.3326	.3048	.2507	.3429	.2667	.3292
5	.3224	.3658	.3429	.2507	.4115	.2667	.3696
6	.394	.439	.381	.3582	.4801	.381	.439
7	.5731	.5121	.5335	.5853	.5487	.5335	.5121
8	.6805	.6584	.6097	.6219	.6859	.6859	.6219
9	.7164	.7316	.6516	.6584	.6516	.6478	.6516
10	.6173	.8048	.6859	.4805	.7202	.6516	.6516
11	.6516	.7621	.6516	.695	.6859	.6859	.6173
12	.6516	.7621	.583	.5853	.6173	.5144	.5487
13	.5144	.6478	.5487	.6584	.6173	.583	.5487
14	.4801	.5716	.4458	.5853	.6173	.583	.4458
15	.5144	.6097	.5144	.5853	.6173	.4801	.4801
16	.583	.6478	.5487	.7023	.6173	.6859	.5487
17	.583	.6478	.7202	.8048	.6516	.7888	.7545
18	.9511	.8764	.7888	.8779	.8764	.8573	.8916
19	.9511	.9145	.9671	1.0608	.9526	.8779	.9671
20	.9412	1.0288	.9671	.9145	.8383	1.1584	.8238
21	.8048	.7621	.7164	.7316	.724	.7316	.788
22	.6584	.6478	.5373	.5487	.6097	.5487	.5014
23	.4435	.4191	.3224	.3696	.4191	.3326	.3582
24	.2865	.3326	.3048	.2865	.2957	.6859	.2614
Max	.9511	1.0288	.9671	1.0608	.9526	1.1584	.9671
Min	.2507	.2561	.2667	.2507	.2401	.2667	.2587
Avg	.5551	.5982	.5402	.5583	.5752	.5744	.5385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / PACHGANI

Feeder No / Name : 301 / BHILAR

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5544	.5544	.5975	.6722	.5601	.5544
2	.5175	.5228	.5487	.5601	.5975	.5487	.5658
3	.5228	.5281	.5601	.5658	.5914	.4527	.5228
4	.5175	.5281	.5121	.5658	.5975		.5175
5	.5544	.5914	.5121	.5914	.6584	.4481	.5853
6	.7023	.724	.7682	.905	.7392	.724	.6878
7	1.1706	1.2894	1.2048	1.3611	1.1706	1.1694	1.1706
8	1.7002	1.6651	1.701	1.8823	1.8111	1.5257	1.6263
9	1.6632	.6516	1.6827	1.6827	1.7558	1.7558	1.7002
10	1.0974	1.531	1.576	1.387	1.6632	1.4842	1.2689
11	1.2803	1.419	1.448		1.5154	1.3394	1.2403
12	1.1706	1.3306	1.2437		1.419	1.1946	1.0974
13	1.0498	1.1458	1.1458	1.134	1.2567	.362	1.0242
14	1.0498	1.0498	1.0456	1.2071	1.0829	.8688	.9145
15	1.0608	1.0136	1.1576		1.1458	1.0974	1.0288
16	1.448	1.267	1.2323	1.3169	1.419	1.1706	1.0288
17	1.4529	1.448	1.531	1.4998	1.5364	1.3394	1.39
18	1.5775	1.7193	1.7372	1.8111	1.5238	1.6827	1.6289
19	1.7193	1.7147	1.6263	1.8099	1.7193	1.6263	1.6651
20	1.4842	1.4883	1.4563	1.6289	1.4175	1.5524	1.5729
21	1.2803	1.2437	1.2936	1.4632	1.1694	1.3443	1.3169
22	1.0242	1.0608	1.0829	1.1706	1.0242	1.0829	1.0277
23	.7682	.695	.7922	.8779	.8413	.7842	.7682
24		.6219	.5316	.695		.5853	.5853
Max	1.7193	1.7193	1.7372	1.8823	1.8111	1.7558	1.7002
Min	.5175	.5228	.5121	.5601	.5914	.362	.5175
Avg	1.1026	1.0751	1.1227	1.1768	1.1882	1.0739	1.0620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / PACHGANI

Feeder No / Name : 302 / PACHGANI CITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	.924	.9145	.9709	.9335	.8048	.9431
2	.7392	.8871	.9145	.9431	.8501	.788	.9054
3	.7392	.8962	.8779	.9431	.8501	.8048	.8676
4	.7316	.9054	.8779	.8962	.924	.7964	.8413
5	.8779	.961	.8779	.8779	.9145	.7964	.905
6	1.1088	1.2437	1.1706	1.1104	1.1088	.905	1.1462
7	1.5364	1.6095	1.6461	1.576	1.3169	1.6057	1.5565
8	1.4998	1.6651	1.5947	1.6461	1.6263	1.5364	1.5364
9	1.39	1.5565	1.4266	1.4784	1.6476	1.4266	1.4784
10	1.086	1.5684	1.4118	1.4632	1.6095	1.39	1.5043
11	1.0242	1.4415	1.4118		1.4998	1.3169	1.3169
12	1.1584	1.3169	1.3032		1.3817	1.267	1.1694
13	1.2178	1.2197	1.2803	1.3535	1.2696	1.086	1.0277
14	1.1584	1.0498	1.2071	1.2071	1.0719	1.086	1.0608
15	1.134	1.134	1.2197		1.1203	1.0974	.9922
16	1.267	1.1706	1.2696	1.2308	1.2696	1.3756	1.0517
17	1.3253	1.182	1.307	1.3169	1.2936	1.1317	1.0631
18	1.3969	1.2757	1.3817	1.3535	1.3169	1.134	1.134
19	1.6289	1.6476	1.5524	1.5729	1.6461	1.5927	1.4632
20	1.6461	1.5947	1.7177	1.5565	1.6827	1.6095	1.5729
21	1.4632	1.5238	1.5684	1.5729	1.6095	1.5893	1.4266
22	1.39	1.3466	1.3443	1.3676	1.39	1.2696	1.3032
23	1.134	1.1949	1.1576	1.134	1.0745	1.0185	1.0349
24		.9877	.9877	1.0974		.9145	.8871
Max	1.6461	1.6651	1.7177	1.6461	1.6827	1.6095	1.5729
Min	.7316	.8871	.8779	.8779	.8501	.788	.8413
Avg	1.2018	1.2626	1.2675	1.2699	1.2786	1.1810	1.1745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

PACHGANI[120]

BU 0973

Substation No/ Name :- 254049 / PACHGANI

Feeder No / Name : 303 / WATER SUPPLY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0732	.112	.112	.112	.112	.1132
2	.0747	.0739	.1097		.112	.1097	.0754
3	.0739	.0747	.0747	.0754	.0739	.0747	.0754
4	.0739	.0754	.0739	.0747	.0739	.4527	.0732
5	.0739	.1109	.0747	.1097	.1109	.112	.1086
6	.1494	.1463	.2195	.2149	.1478	.1848	.1791
7	.2195	.2926	.2926	.2507	.2507	.2926	.2896
8	.3189	.3258		.3189	.3258	.3658	.3658
9	.2126	.3258	.3292	.2561	.3224	.3189	.2957
10	.181	.2507	.2896	.2926	.2926	.2149	.2926
11	.1463	.2149	.2534		.2561	.2481	.2561
12	.1448	.1772	.2172		.2241	.208	.1829
13	.1075	.1417	.1829	.1772	.1867	.1734	.1463
14	.1448	.1417	.1463	.1463	.1478	.1402	.1417
15	.1463	.1772	.1848	.1463	.1867	.1402	.181
16	.2172	.1417	.1867	.2195	.2241	.1753	.1772
17	.2865	.2743	.2614	.2561	.2587	.3086	.2561
18	.2865	.3658	.3361	.2865	.2561	.3189	.2774
19	.3258	.3898	.3326	.3814	.3898	.3258	.2865
20	.3292	.3326	.2987	.3856	.3658	.3292	.3224
21	.2926	.2926	.2987	.2987	.2926	.2957	.3224
22	.2561	.2957	.2241	.2534	.2614	.2241	.2957
23	.1463	.1463	.1867	.1867	.1848	.1886	.1848
24		.1097	.1109	.1097		.1463	.1463
Max	.3292	.3898	.3361	.3856	.3898	.4527	.3658
Min	.0732	.0732	.0739	.0747	.0739	.0747	.0732
Avg	.1861	.2063	.2085	.2168	.2199	.2275	.2102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254015 / 33 KV BALKAWADI GEN SS

Feeder No / Name : 403 / 33 KV BALKAWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	5.715
Max	5.715
Min	5.715
Avg	5.715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 301 / SURUR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4904	.0762	.0754	.0762	.0762	.6097
2	.5281	.415	.0762	.0754	.0762	.0762	.5716
3	.5281	.415	.0762	.0754	.0762	.0762	.4954
4	.5281	.4527	.0762	.0754	.0762	.0762	.4954
5	.5658	.4527	.0762	.0754	.0762	.0762	.4954
6	.6036	.4527	.0762	.0754	.0754	.0754	.8002
7	.9808	.7922	.0762	.0754	.0754	.0754	1.105
8	1.2826	.9808	.0762	.0754	.0754	.0754	1.3336
9	.0754	1.358	1.105	1.0562	1.1694	.0754	.0381
10	.0754	1.5242	1.358	1.2449	1.2826	.0762	.0381
11	.0754	1.448	1.358	1.3203	1.4335		.0754
12	.0754	1.3717	1.2071		1.2826		.0754
13	.0754	1.3717	1.2826	1.2826	1.2071		.0754
14	.0754	1.2955	1.2826	1.3203	1.1694		.0754
15	.0754	1.2574	1.3957	1.2826	1.2071	.0762	.0754
16	.0754	1.2193	1.39	1.3203	1.2826	.0762	.0754
17	.0754	.0762	.0754	.0754	.0754	.0762	.0754
18	.0754	.0762	.0754	.0754	.0754	.0762	.0754
19	.0754	.0762	.0754	.0754	.0754	.1143	.0754
20	.0754	.0762	.0754	.0754	.0754	.0762	.0754
21	.0754	.1143	.0754	.0754	.0754	.1143	.0754
22	.0754	.0762	.0754	.0754	.0754	.1143	.0754
23	.3772	.0762	.0754	.0754	.0754	.6478	.5281
24	.6036	.4904	.0762	.0754	.0754	.0762	.6478
Max	1.2826	1.5242	1.3957	1.3203	1.4335	.6478	1.3336
Min	.0754	.0762	.0754	.0754	.0754	.0754	.0381
Avg	.3159	.6816	.4830	.4362	.4685	.1103	.3360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 302 / NEW KENJAL AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0754	.0381	.7545	.7621	.4954	.0381
2	.0377	.0754	.0381	.679	.7621	.4572	.0381
3	.0377	.0754	.0381	.679	.6859	.4572	.0381
4	.0377	.0754	.0381	.679	.6097	.4954	.0381
5	.0377	.0754	.0381	.7167	.6097	.5335	.0381
6	.0377	.0754	.0381	.8299	.6036	.5281	.0381
7	.0377	.0377	.0381	1.0562	.9808	.6036	.0381
8	.0377	.0754	.0381	1.1317	1.094	.8299	.0381
9	1.2071	1.358	.0381	.0377	.0754	1.1317	1.1431
10	.0754	1.7909	.0377	.0377	.0754	1.2193	1.2955
11	1.094	1.448	.0377	.0377	.0754	1.1431	1.2826
12	1.094	1.2955	.0377	.0377	.0754	1.1431	1.1317
13	1.094	1.1431	.0377	.0377	.0754	1.0288	1.1694
14	1.0185	1.0669	.0377	.0377	.0754	.9907	1.1317
15	.9808	1.0669	.0377	.0377	.0754	.9907	1.0562
16	1.0562	1.1431	.0377	.0377	.0754	.9907	1.1317
17	.0754	.0381	.0377	.0377	.0754	.0381	.0754
18	.0754	.0381	.0377	.0377	.0754	.0381	
19	.0754	.0762	.0754	.0377	.0754	.0381	.0754
20	.0754	.0762	.0754	.0377	.7545	.0762	.0754
21	.0754	.0762	.0754	.0377	.0754	.0762	.0754
22	.0754	.0381	.0754		.0754	.0762	.0754
23	.0754	.0762	.9054	.9054	.5281	.0381	.0754
24	.0377	.0754	.0381	.7545	.7545	.5335	.0381
Max	1.2071	1.7909	.9054	1.1317	1.094	1.2193	1.2955
Min	.0377	.0377	.0377	.0377	.0754	.0381	.0381
Avg	.3536	.4739	.0803	.3772	.3802	.5814	.4407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 303 / NEW KENJAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.3048	.3018	.2667	.2286	.2667
2	.2263	.2263	.2667	.2641	.2667	.2286	.2286
3	.2263	.2263	.2667	.2641	.2286	.2286	.2286
4	.2263	.2263	.2667	.2641	.2667	.2667	.2667
5	.2641	.2641	.3048	.2641	.3048	.3048	.3048
6	.3395	.3772	.381	.3018	.3429	.3395	.3048
7	.5281	.6036	.4191	.3395	.415	.415	.381
8		.4527	.4191	.415	.415	.3772	.3429
9	.3395	.4527	.4191	.4527	.415	.415	.3048
10	.4527	.4191	.3772		.3395	.4954	.2667
11	.415	.3429	.3395		.2641	.3048	.2641
12	.3395	.3048	.3018		.2641	.1905	.2641
13	.2641	.2667	.2641		.2641	.2667	.2641
14	.2263	.1905	.2263		.2641	.1905	.2641
15	.3018	.2667	.2641		.3018	.2667	.2641
16	.2263	.2286	.2641		.3018	.3048	.2641
17	.2641	.3048	.2641		.3395	.2286	.2641
18	.3772	.3429	.3018		.3395	.2667	
19	.415	.4191	.3772		.3772	.4191	.3772
20	.4527	.4954	.4527		.4527	.4191	.4527
21	.4527	.4191	.415		.415	.4191	.415
22	.415	.381	.3772		.3772	.3429	.3772
23	.3395	.3048	.3018		.3018	.2667	.3018
24	.2641	.3018	.3048	.3018	.2641	.2667	.2667
Max	.5281	.6036	.4527	.4527	.4527	.4954	.4527
Min	.2263	.1905	.2263	.2641	.2286	.1905	.2286
Avg	.3313	.3367	.3283	.3169	.3245	.3105	.3015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 304 / SURUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.2551	1.4098	1.4456	1.2955	1.2955	1.2574
2	1.2174	1.1793	1.2193	1.2932	1.1812	1.2574	1.1431
3	1.1793	1.1412	1.2193	1.2932	1.105	1.1812	1.105
4	1.217	1.1793	1.1812	1.2932	1.105	1.2574	1.1431
5	1.3687	1.2932	1.2574	1.3694	1.2193	1.3336	1.2193
6	1.2193	1.4453	1.486	1.3336	1.4098	1.483	1.4098
7	1.9395	1.9392	1.9052	1.5623	1.8637	1.9395	1.9052
8	1.9433	2.3964	2.3624	2.5107	2.4348	2.3967	2.0576
9	2.3964	2.2821	2.2862	2.5865	2.4729	2.3964	2.2481
10	2.3586	2.1338	2.359	2.0576	2.4352	2.2862	2.1338
11	2.3209	2.21	2.2066		2.1308	2.1719	2.0165
12	1.9784	1.7909	1.826	.3395	2.0161	1.829	1.7502
13	1.826	1.7909	1.5596	2.4729	2.0542	1.8671	1.7121
14	1.826	1.4861	1.6358	2.2066	2.0165	1.829	1.826
15	1.7498		1.5218	2.0923	2.0546	1.7528	1.8641
16	1.7498		1.826	2.0165	1.9784	1.7528	1.9022
17	1.7498	1.5622	2.0546	2.1304	2.0923	1.7909	1.8641
18	1.9776	2.5148	1.9784	1.9052	2.0161	1.7909	1.826
19	2.5857	2.8578	2.5476	2.21	2.4718	2.3244	2.3575
20	3.1192	3.3913	3.1954	2.6673	3.2716	3.0103	3.0815
21	3.1196	3.277	3.2335	2.6292	3.2335	2.9721	3.0434
22	2.8151	2.9721	3.0438	2.4006	3.0819	2.8197	2.8151
23	2.3967	2.5529	2.5495	2.0576	2.4352	2.3243	2.4352
24	1.5984	1.6361	1.8671	1.7121	1.7128	1.7528	1.6385
Max	3.1196	3.3913	3.2335	2.6673	3.2716	3.0103	3.0815
Min	1.1793	1.1412	1.1812	.3395	1.105	1.1812	1.105
Avg	1.9561	2.0130	1.9888	1.8950	2.0453	1.9506	1.9065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254018 / 33/22 KV VELE S/STN

Feeder No / Name : 305 / OZARDE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.3048	.3018	.2667	.2667	.2667
2	.2641	.2641	.2667	.2641	.2667	.2667	.2667
3	.3395	.2641	.2667	.2641	.2667	.2667	.2667
4	.3018	.2641	.2667	.2641	.3048	.3048	.2667
5	.3395	.3395	.3429	.3395	.3429	.381	.3429
6	.4527	.4527	.4954	.415	.4527	.4904	.4954
7	.679	.6413	.6478	.679	.6413	.7167	.6478
8		.6413	.6478	.6413	.6413	.679	.6478
9	.4904	.4904	.5335	.5281	.5281	.6036	.4572
10	.415	.4191	.4527		.5281	.4954	.4572
11	.3772	.4191	.4527		.5281	.3048	.3772
12	.3772	.4572	.415		.3772	.3048	.3772
13	.3772	.3429	.4527		.3395	.4191	.3018
14	.3395	.3429	.4527		.3395	.3429	.3018
15	.3772	.3429	.4904		.3772	.381	.3018
16	.3772	.4191	.415		.3395	.381	.3395
17	.415	.4191	.3772		.4527	.381	.415
18	.4904	.4191	.4527		.5281	.381	.415
19	.6413	.724	.6036		.679	.6478	.6036
20	.679	.6859	.7167		.679	.6478	.6036
21	.0754	.6097	.6036		.6413	.5716	.5658
22	.4904	.4954	.5281		.5281	.4572	.5281
23	.3772	.381	.3772		.3772	.3429	.3772
24	.2641	.3018	.3048	.3018	.2641	.3048	.2667
Max	.679	.724	.7167	.679	.679	.7167	.6478
Min	.0754	.2641	.2667	.2641	.2641	.2667	.2667
Avg	.4002	.4334	.4528	.3999	.4454	.4308	.4121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 201 / 11 KV WAI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4082	3.126	3.4225	4.3537	3.2427	3.1223	3.4477
2	2.662	3.049	3.2076	3.8576	3.0354	2.998	3.2693
3	2.3975	2.9789	3.1245	3.6893	2.8776	2.9667	3.0727
4	2.3175	2.8289	2.9279	3.5025	2.745	2.5438	2.9271
5	2.3617	2.7374	2.9637	1.7299	2.5537	2.6894	2.8837
6	2.1758	2.8631	3.2015	3.0422	2.5122	2.9218	3.0567
7	2.2154	2.6208	3.1558	2.5187	2.5423	2.8647	2.8174
8	2.9401	3.1916	3.5711	3.0926	3.2069	3.4682	2.2939
9	3.363	3.8036	4.6487	3.927	3.6153	4.0146	2.4333
10	3.8546	4.2973	5.0321	4.6951	4.1419	4.164	2.4905
11	4.1762	4.5542	5.3186	4.9474	4.3255	4.4368	1.3681
12	3.9696	4.5458	2.8731	4.9169	4.4475	4.7767	.9886
13	3.8599	4.6288	5.1212	4.3812	4.388	4.5968	.849
14	2.0828	4.3287	4.9764	4.5153	4.2181	4.5023	.9899
15	4.1785	4.8255	5.0972	4.6761	4.3118	4.7287	.9915
16	3.9765	5.2027	4.6525	4.4269	4.2265	5.5129	1.8899
17	3.831	5.3567	4.6768	4.3332	4.0146	5.5784	2.1346
18	3.9582	4.6608	4.5572	4.2234	3.7655	4.9017	2.1476
19	3.975	5.1936	4.2501	3.9247	3.4659	4.9764	2.3845
20	3.818	2.1719	4.0939	3.786	3.6786	4.763	2.0309
21	3.2495	4.3149	4.1442	3.719	3.9925	3.6321	2.3982
22	3.1398	3.8797	3.9819	3.5429	3.5391	3.4439	2.3662
23	3.533	3.7586	4.3957	3.7212	3.4667	3.7586	2.6688
24	2.8357	3.6252	3.9232	4.0215	3.2876	3.4088	2.9927
Max	4.1785	5.3567	5.3186	4.9474	4.4475	5.5784	3.4477
Min	2.0828	2.1719	2.8731	1.7299	2.5122	2.5438	.849
Avg	3.2200	3.8560	4.0549	3.8977	3.5667	3.9488	2.2872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 202 / 11 KV MANDHARDEV AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0158	.0191	.4744	.3163	.381	.0381
2	.0191		.0191		.3163	.3429	.0191
3	.0191	.0158	.0191	.4428	.3163	.3429	.0191
4	.0191	.0158	.0191		.3795	.3429	.0191
5	.0191	.0158	.0381	.3953	.4111	.3429	.0191
6	.0191	.0158	.0381		.4428	.381	.0381
7	.0381	.0316	.0381	.8381	.7907	.4572	.0381
8	.0191	.0316	.0762	.7432	1.0669	.5716	.0381
9	.8539	.8764	.0191	.0158	.0381	.6478	.8865
10	.9172	1.0669	.0191	.0158	.0381	.724	1.0185
11	.8539	1.105	.0191	.0158	.0381	.7621	.6224
12	.7907	1.1431	.0191	.0158	.0381	1.105	.6036
13	.7907	1.1431	.0191	.0158	.0381	1.1431	.5658
14	.759	1.105	.0191	.0158	.0381	.8573	.5093
15	.7274	1.105	.0189	.0158	.0381	.9145	.5847
16	.7907	1.0669	.0189	.0158	.0381	.9526	.6979
17	.0158	.0191	.0191	.0158	.0381	.0381	.0377
18	.0158	.0381	.0191	.0158	.0381	.0381	.0377
19	.0316	.0381	.0381	.0158	.0381	.0762	.0377
20	.0316			.0158	.0381	.0762	.0381
21	.0316	.0381	.0381	.0158	.0762	.0381	.0381
22	.0158	.0381	.0377	.0158	.3048	.0381	.0381
23	.0158	.0381	.6602	.3795	.4191	.0381	.0191
24	.0191	.0158	.0191	.5847	.3479	.4572	.0381
Max	.9172	1.1431	.6602	.8381	1.0669	1.1431	1.0185
Min	.0158	.0158	.0189	.0158	.0381	.0381	.0191
Avg	.2847	.4081	.0544	.1942	.2352	.4612	.2501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 203 / 11 KV WAI NAGARPALIKA PWW NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0602	.0762	.0753	.0953	.0762	.0762
2	.061	.0753	.0762		.0602	.0762	.0762
3	.061	.0753	.0762	.0602	.0602	.0762	.0762
4	.0762	.0753	.0762	.0602	.0753	.0762	.0762
5	.0762	.0753	.0953	.0753	.0753	.0953	.0953
6	.0762	.0753	.0953	.0753	.0753	.0953	.0953
7	.0762	.0753	.0953	.0602	.0753	.0953	.0953
8	.0762	.0753	.0914	.0602	.0753	.0953	.0953
9	.0753	.0953	.0762	.0602	.0953	.0953	.0762
10	.0739	.0953	.0762	.0753	.0953	.0953	.0762
11	.0602	.0953	.061		.0953	.0953	.061
12	.0753	.0953	.061	.0753	.0953	.0953	.0762
13	.0753	.0953	.061	.0753	.0953	.0953	.0762
14	.0753	.0953	.061	.0753	.0762	.0953	.0762
15	.0753	.0953	.0762	.0753	.0762	.0953	.061
16	.0753	.0953	.0762	.0753	.0953	.0953	.0762
17	.0753	.0953	.0762	.0753	.0953	.0953	.061
18	.0753	.0953	.0762	.0753	.0953	.0953	.061
19	.0753	.0953	.0762	.0602	.0953	.0953	.061
20	.0753		.0762	.0753	.0953	.0953	.0762
21	.0602	.0953	.0762	.0753	.0953	.0953	.0762
22	.0953	.0953	.0762	.0753	.0953	.0953	.0762
23	.0753	.0953	.0762	.0602	.0953	.0953	.0762
24	.0762	.0753	.0762	.0762	.0753	.0762	.0953
Max	.0953	.0953	.0953	.0762	.0953	.0953	.0953
Min	.0602	.0602	.061	.0602	.0602	.0762	.061
Avg	.0739	.0868	.0767	.0705	.0858	.0913	.0770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 204 / 11 KV MAPRO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2667	.1905	.4954	.2858	.2667	.2286
2	.1715	.2286	.1905	.4001	.2667	.2477	.1905
3	.1715	.1905	.1905	.3429	.2858	.2477	.1905
4	.1715	.2286	.1905	.3048	.3048	.2286	.1905
5	.1715	.2286	.2286	.3048	.3048	.2667	.1905
6	.1905	.2858	.2477	.3239	.3239	.2667	.2477
7	.2286	.381	.2667	.3206	.3048	.3048	.2667
8	.362	.3239	.3429	.362	.381	.381	.2477
9	.362	.381	.4572	.381	.381	.381	.1905
10	.4382	.4191	.5525	.4382	.4191	.4382	.1143
11	.4191	.4763	.4572	.4191	.4001		.1143
12	.381	.381	.4382	.3429	.381	.4954	.1905
13	.4435	.3429	.3048	.3048	.4191	.4954	.1334
14	.4763	.3239	.362	.3429	.4572	.5335	.1143
15	.4954	.381	.4904	.4572	.4763	.5335	.0762
16	.5144	.4954	.5716	.4763	.4763	.5144	.1143
17	.4954	.5716	.4572	.4954	.4954	.5144	.1905
18	.4763	.5716	.4763	.5335	.4954	.4954	.1905
19	.4572	.4572	.4572	.4954	.4763	.4572	.2096
20	.381		.3048	.381	.4954	.4191	.1905
21	.2667	.3429	.3048	.2858	.3239	.3239	.1905
22	.2641	.3048	.3239	.3048	.3048	.3239	.1905
23	.2667	.3048	.3048	.3048	.2858	.3239	.1524
24	.1715	.2858	.2858	.5716	.3048	.2858	.3048
Max	.5144	.5716	.5716	.5716	.4954	.5335	.3048
Min	.1715	.1905	.1905	.2858	.2667	.2286	.0762
Avg	.3311	.3553	.3499	.3912	.3771	.3802	.1842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 205 / 11 KV MANDHARDEV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1478	.1905	.1478	.1478	.1524	.1905
2	.1478	.1478	.1905	.1478	.1478	.1524	.1715
3	.1478	.1478	.1905	.1478	.1663	.1524	.1715
4	.1663	.1663	.1905	.1663	.1848	.1905	
5	.1848	.2033	.2286	.1848	.2587	.2286	.2096
6	.3326	.3326	.2667	.3142	.3326	.2667	.2477
7	.4066	.4435	.3048	.4066	.4251	.2667	.3048
8	.3696	.4066	.4066	.4066	.3326	.3048	.4001
9	.3511	.381	.3326	.3326	.3429	.3048	.3142
10	.2957	.3048	.2957	.2772	.3048	.2667	.2667
11	.2587	.2667	.2587	.2218	.3048	.2667	.2402
12	.2218	.2667	.2033	.2218	.2858	.2667	.1848
13	.2096	.2286	.197	.2402	.2667	.2286	.2033
14	.1848	.2286	.2033	.2218	.2286	.2286	.2033
15	.1848	.2286	.2218	.2218	.2286	.2286	.2033
16	.2033	.2286	.1848	.2402	.2286	.2286	.2218
17	.3326	.2477	.2402	.2587	.2667	.2286	.2402
18	.4435	.3048	.2957	.2772	.3048	.3429	.2772
19	.4954	.4572	.499	.4251	.3429	.4572	.4066
20	.4435		.499	.4435	.3239	.5335	.4435
21	.3881	.381	.3881	.4251	.4191	.4763	.4066
22	.3326	.381	.3511	.3326	.3048	.381	.3326
23	.2033	.3048	.1848	.2218	.2286	.3239	.2033
24	.1663	.1663	.2286	.1663	.1663	.1905	.2286
Max	.4954	.4572	.499	.4435	.4251	.5335	.4435
Min	.1478	.1478	.1848	.1478	.1478	.1524	.1715
Avg	.2758	.2770	.2730	.2687	.2727	.2778	.2640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 301 / 22 KV DHAGE ALI (WAI CITY
ALT) Feeder KV- 22 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8715	.8535	.8992	.8763	.8535	.4191	.442
2	.804	.8687	.8687	.8154	.8001	.4115	.4191
3	.7964	.9298	.8535	.8078	.823	.4115	.4191
4	.7887	.4268	.9221	.4268	.8535	.4115	.4115
5	.8562	.9984	1.0289	.4649	.9755	.4267	.4115
6	1.1641	1.2194	1.2879	1.2194	1.1965	.4648	.5791
7	1.5912	1.7452	1.7452	1.8519	1.608	.6325	.7544
8	2.0801	2.1262	2.1399	2.1643	2.0576	.8001	.9145
9	2.111	2.1262	2.1704	2.1262	2.0881	.8992	.902
10	1.9052	1.9967	1.8431	1.9662	2.0043	.8382	.8497
11	1.6537	1.7757	1.5711	1.7528	1.0135	.8154	.6615
12	1.5242	1.6461	1.3066	1.6309	.7925	.7239	.4591
13	.7697	1.4937	1.4274	1.5699	.823	.6935	.631
14	1.3261	1.3946	1.262	1.5699	.8001	.7011	.6158
15	1.2422	1.387	1.3512	1.4861	.7163	.6858	.6158
16	1.2422	1.5623	1.3294	1.4861	.7392	.6096	.1829
17	1.4556	1.6995	1.4937	1.5851	.8001	.663	.5765
18	1.7376	1.8671	1.6895	1.7909	.8078	.7925	.841
19	1.9814	2.21	2.1693	1.9966	.884	.8459	.8486
20	2.0271	1.1584	2.0432	2.1414	.884	.503	.977
21	1.9357	2.1262	1.856	2.0348	.7925	.8459	.8726
22	1.7147	1.8061	1.6385	1.7757	.7239	.8001	.692
23	1.3718	1.4327	1.3012	1.3565	.6706	.6554	.5419
24	1.0151	1.0821	1.0135	1.0303	.6934	.5487	.541
Max	2.111	2.21	2.1704	2.1643	2.0881	.8992	.977
Min	.7697	.4268	.8535	.4268	.6706	.4115	.1829
Avg	1.4152	1.4972	1.4671	1.4969	1.0167	.6500	.6317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 302 / 22 KV MENAWALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4647	1.4571	1.5089	1.0517	1.4342	1.3641	1.3946
2	1.3885	1.344	1.3793	1.4864	1.2754	1.2955	1.2726
3	1.358	1.3059	1.2498	1.4407	1.283	1.2879	1.2726
4	1.358	1.3428	1.3565	1.4407	1.3493	1.2879	1.2879
5	1.4102	1.493	1.4785	1.0364	1.432	1.4861	1.4327
6	1.9608	1.9902	2.0195	2.0436	1.975	2.0119	1.9662
7	2.9771	3.1054	2.7435	3.1817	3.1778	2.6825	2.8197
8	3.5311	3.6747	3.1535	3.6595	3.6656	3.4675	3.818
9	3.5768	3.6046	3.0197	3.517	3.6518	3.4751	3.6226
10	3.5703	3.4141	3.0491	3.4331	3.3608	3.4598	3.2102
11	3.2602	3.2693	2.5896	3.2297	2.332	3.2083	2.0032
12	2.9881	2.9493	2.8487	3.1329	3.1779	2.8273	.037
13	2.7248	2.6597	2.9576	2.5595	2.6444	2.8045	1.5768
14	2.5583	2.3548	2.6433	2.3167	2.614	2.5835	1.5104
15	2.4211	2.1719	2.4516	2.2938	2.4615	2.4387	1.3199
16	2.4668	2.05	2.3179	2.3461	2.5377	2.3396	1.3504
17	2.9043	2.4463	2.4592	2.5811	3.0559	2.3015	1.456
18	3.2045	2.9797	3.1981	2.7911	3.5894	2.9187	1.728
19	4.4056	3.9323	4.1304	3.9247	4.1534	3.7875	3.8127
20	4.9905	3.3684	5.1002	4.9653	5.2203	4.8697	5.048
21	4.7284	4.4886	4.7565	4.7489	4.9231	4.5267	4.7782
22	3.8535	3.9095	4.0764	3.735	3.9095	3.6046	3.884
23	2.7088	2.8578	2.9481	2.6326	2.8807	2.7892	2.7599
24	1.7837	1.7684	1.9357	1.7966	1.7604	1.7223	1.8824
Max	4.9905	4.4886	5.1002	4.9653	5.2203	4.8697	5.048
Min	1.358	1.3059	1.2498	1.0364	1.2754	1.2879	.037
Avg	2.8164	2.6641	2.7238	2.7227	2.8277	2.6892	2.3018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 303 / 22 KV PASARNI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.8697	3.7708	.6097	.6196	.7613	.6097	4.3133
2	4.6868	3.3646	.6097	.5487	.7259	.6097	3.7951
3	4.4353	3.2579	.6097	.6196	.6904	.6097	3.7037
4	4.3858	3.3593	.6097	.5487	.6904	.6097	3.5818
5	4.3858	3.3288	.6097	.5487	.6904	.6859	3.536
6	4.6563	3.6385	.7011	.6702	.7765	.7011	3.9323
7	6.1843	4.8815	.7925	.5792	.8474	.7163	5.5327
8	7.0149	6.1809	.6874	.6702	.8273	.7163	7.2627
9	4.6174	7.697	6.3862	6.9102	7.2092	.6249	4.0505
10	.6649	8.5963	8.4781	9.7383	9.9223	.5944	.618
11	.6447	8.581	7.3617	10.3632	10.0365	.5487	.5529
12	.2538	8.5658	8.5467	10.0031	10.2348	.5639	.0343
13	.3148	8.0323	8.7906	9.7698	10.0289	.5639	.0347
14	.5788	8.0781	8.4248	9.089	9.1297	.5487	.0347
15	.6649	7.819	8.4324	9.0634	8.4286	.5487	.0347
16	.6649	7.7427	8.1581	9.0691	8.4362	.5487	.0347
17	.6497	4.7096	5.1185	5.8928	4.0543	.5487	.0693
18	.6649	.5944	.6074	.7308	.6401	.6249	.0693
19	.7003	.6859	.6375	.7816	.7468	.7163	.5155
20	.7156	.5639	.6821	.7918	.7773	.7773	.6527
21	.6954	.7011	.6832	.7765	.7925	.7773	.6375
22	.6954	.7163	.6832	.7765	.7011	.6859	.6375
23	3.943	.6249	.6691	.7613	.6859	4.2676	3.9552
24	4.0695	1.7738	.6401	.6516	.7461	3.2465	4.4963
Max	7.0149	8.5963	8.7906	10.3632	10.2348	4.2676	7.2627
Min	.2538	.5639	.6074	.5487	.6401	.5487	.0343
Avg	2.5482	4.4694	3.3137	3.7489	3.6908	.8935	2.1702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 402 / 33 KV GARWARE

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.1859	13.8146	9.7565	13.9803	13.1687	9.225	13.3688
2	13.3631	13.7974	13.3802	13.6774	12.8201	9.3964	13.1573
3	13.2202	13.4259	13.123	13.5117	12.923	8.9506	12.0256
4	12.9973	13.1287	12.8258	13.4145	13.0144	8.8992	12.4143
5	12.9344	12.8201	12.9687	13.786	13.0773	8.6591	12.5058
6	12.8144	13.4831	12.9401	13.3859	12.8944	8.9163	12.8658
7	12.1285	13.0488	10.2309	13.123	11.4655	12.3857	13.163
8	12.8944	12.4658	12.9458	13.5974	11.1054	12.8658	13.7231
9	13.1516	12.7515	13.163	13.5345	11.757	12.4771	13.1288
10	13.9289	13.1401	13.3173	13.1916	12.6086	12.4371	12.9287
11	13.4614	13.5632	13.8718	14.4547	12.8601	13.9975	14.3576
12	13.5631	13.3116	13.426	14.672	12.9058	13.8774	14.1061
13	13.0944	12.7858	13.4488	13.9061	11.6027	13.2888	13.5402
14	13.946	12.9001	13.2373	13.986	11.3169	13.746	13.7917
15	14.5062	12.9058	13.1916	13.2945	10.2824	14.1232	14.5233
16	14.1061	13.1058	13.4946	13.5745	9.968	10.6825	13.866
17	13.7231	14.3461	14.1175	13.7689	10.974	13.4602	13.9118
18	14.1061	14.0147	13.7861	13.9803	12.3228	13.3345	14.2147
19	13.9404	14.2718	14.2662	10.7682	12.6086	13.7288	13.9232
20	13.9803	10.6825	14.3005	14.1919	12.74	13.8431	13.7403
21	13.8774	13.7631	13.5803	13.1459	11.8142	13.4774	13.3231
22	14.2204	14.0832	13.9232	14.1918	12.0828	14.009	13.4831
23	13.7517	13.866	14.3633	14.329	12.4486	14.1461	13.4031
24	13.3745	13.2831	13.8774	13.9061	12.4371	10.0309	13.1116
Max	14.5062	14.3461	14.3633	14.672	13.1687	14.1461	14.5233
Min	12.1285	10.6825	9.7565	10.7682	9.968	8.6591	12.0256
Avg	13.5112	13.2816	13.2307	13.6405	12.1333	12.0816	13.4407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254019 / 33/22/11 KV WAI MIDC S/STN

Feeder No / Name : 404 / 33 KV ATHARVA

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1717	6.1557	6.6873	8.219	6.5215	6.5672	9.4193
2	1.246	6.9159	6.19	8.722	6.3557	7.9904	8.1676
3	1.1946	7.3331	6.2986	7.6818	6.7044	6.8416	8.2647
4	1.1202	5.5784	6.0814	8.9278	3.6694	6.5158	7.9446
5	1.2117	4.0752	5.9442	9.8136	4.5896	5.9499	6.9673
6	1.7318	5.8242	6.8473	9.2593	6.2357	5.3669	6.0585
7	6.3329	4.5496	6.8015	8.0361	5.8985	6.0871	7.9447
8	7.9732	4.1496	6.5787	6.1386	6.0013	7.1616	3.6865
9	4.0124	3.7037	7.3217	7.5732	6.6358	9.9052	1.7489
10	5.8414	4.8468	8.6306	9.6422	8.1504	9.6937	1.526
11	6.7673	6.3215	13.0373	9.0706	6.8016	10.9796	1.4917
12	6.2815	6.9044	9.7908	10.0252	5.9728	9.1335	1.5603
13	6.7102	7.7047	8.3162	8.9392	4.0352	6.773	1.6461
14	4.9954	6.8759	9.1564	6.7215	3.5608	8.299	1.5204
15	6.7444	6.4358	8.0967	7.9961	3.9152	8.8021	1.246
16	7.8646	5.9099	8.099	8.0018	4.4238	8.842	1.366
17	7.7218	5.9042	8.7277	7.7104	6.0357	9.6251	1.3318
18	5.9099	8.7506	9.3793	8.5448	8.0132	7.476	1.4003
19	5.5041	7.8304	6.2015	5.3155	7.9218	6.5387	1.7947
20	4.6411	2.8635	5.2126	8.8535	5.0526	4.3439	2.0176
21	6.8016	5.5842	7.0473	5.1898	8.5905	7.1731	5.2069
22	6.8644	7.0188	7.0816	4.6525	7.1388	7.6132	5.2641
23	5.9957	6.5787	7.9201	7.5332	8.0762	6.6301	3.7552
24	4.281	7.1559	8.179	8.3791	7.2874	7.013	5.847
Max	7.9732	8.7506	13.0373	10.0252	8.5905	10.9796	9.4193
Min	1.1202	2.8635	5.2126	4.6525	3.5608	4.3439	1.246
Avg	4.9550	6.0404	7.6511	7.9561	6.1495	7.5551	4.0490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 301 / BHUINJ AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	2.0195	1.829	1.5424	.0762	.1143	.1143
2	.0762	1.9814	1.7528	1.4083	.0762	.1143	.0762
3	.0762	1.9052	.1143	1.2071	.0762	.1143	.0762
4	.0762	1.8671	1.7147	1.2742	.0762	.1143	.0762
5	.1143	1.8671	1.7909	1.2742	.1143	.1524	.1143
6	.1143	1.8671	1.8671	1.5623	.1905	.1524	.1143
7	.1143	2.4768	2.1338	1.8671	.1905	.1524	.1143
8	.1143	2.6673	2.21	2.4006	.1905	.1524	.1143
9	.1143	.1524	.0762	2.934	2.4768	3.0483	2.4478
10	.1143	.1143	.1143	3.7342	3.658	3.0727	3.5056
11	.1143	.1143	.4024	3.5818	3.5818	3.3482	
12	.1524	.1143	.1143	3.658	3.6199	1.9669	
13	.1524	.1143	.1143	3.5056	3.4294	2.5149	
14	.1143	.1143	.1143	3.1626	3.315	2.5819	
15	.1143	.1143	.1143	3.2007	3.1626	2.3137	
16	.1143	.1143	.1143		3.0102	2.2466	
17	.1143	.1143	.1143	.1143	.1143	.1143	
18	.1524	.1143	.1143	.1143	.1143	.1143	
19	.1524	.1905	.1143	.1905	.1524	.1143	
20	.1524	.1905	.1143	.1905	.1524	.1143	2.6292
21	.1524	.1905	.1143	.1905	.1524	.1143	2.5149
22	.1524	.1905	.1143	.1905	.1524	.1143	2.3243
23	1.9052	2.0195	1.3748	.1143	.1143	.1143	.1143
24	.1143	2.0195	1.9433	1.6057	.1143	.1143	.1143
Max	1.9052	2.6673	2.21	3.7342	3.658	3.3482	3.5056
Min	.0762	.1143	.0762	.1143	.0762	.1143	.0762
Avg	.1953	.9431	.7742	1.6967	1.1796	.9614	.9634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 302 / JAMB AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	1.5242	1.2193	.9496	.0762	.0762	.0762
2	.0762	1.448	1.0669	.8139	.0762	.0762	.0762
3	.0762	1.3717	1.1431	.7164	.0762	.0762	.0762
4	.0762	1.3717	1.1431	.788	.0762	.0762	.0762
5	.0762	1.3717	1.1812	.788	.0762	.0762	.1143
6	.1143	1.3717	1.2574	.8764	.1905	.0762	.1143
7	.1143	1.7528	1.5242	1.2193	.1905	.0762	.1143
8	.1143	1.829	1.3336	1.4861	.1905	.0762	.1143
9	.1143	.1143	.0762	1.829	1.8671	2.21	1.56
10	.1143	.1143	.1143	1.9814	2.1719	2.0454	2.2481
11	.1143	.1143	.1143	2.0957	2.3243	2.2382	
12	.1143	.1143	.1143	2.1338	2.1338	1.8991	
13	.1143	.1143	.1143	1.8671	2.0576	1.8107	
14	.0762	.1143	.1143	1.9052	1.9814	1.6956	
15	.0762	.1143	.1143		1.829	1.56	
16	.0762	.1143	.1143	1.9052	1.7909	1.5261	
17	.0762	.1143	.1143	.1143	.0762	.1143	
18	.0762	.1143	.1143	.1143	.0762	.1143	
19	.0762	.1143	.1143	.1905	.1143	.1143	
20	.1143	.1905	.1143	.1905	.1143	.1143	1.6385
21	.1143	.1905	.1143	.1905	.1143	.1143	1.6766
22	.1143	.1905	.1143	.1905	.1143	.1143	1.5242
23	1.5242	1.3336	.9496	.1143	.1143	.1143	.0762
24	.1143	1.5242	1.1431	.9724	.1143	.0762	.1143
Max	1.5242	1.829	1.5242	2.1338	2.3243	2.2382	2.2481
Min	.0762	.1143	.0762	.1143	.0762	.0762	.0762
Avg	.1556	.6970	.5635	1.0188	.7478	.6863	.6400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 303 / BHUINJ GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.381	.4572	.3658	.3429	.3429	.3361
2	.3361	.381	.4572	.3361	.3429	.3429	.2987
3	.2987	.381	.381	.3361	.3429	.3429	.2987
4	.3361	.381	.381	.3361	.3429	.3429	.2987
5	.3734	.381	.4572	.4024	.381	.3429	.3361
6	.4755	.5335	.6097	.5335	.4572	.5335	.439
7	.695	.7621	.7621	.724	.6097	.6859	.6584
8	.695	.8002	.6478	.7621	.724	.7621	.7522
9	.5853	.6859	.5335	.6097	.6478	.6478	.6219
10	.4954	.6097	.4755	.4954	.5335	.5487	.4572
11	.5335	.5335	.439	.4572	.6097	.5121	
12	.5335	.4954	.4755	.4954	.5716	.5121	
13	.4572	.4954	.3361	.4572	.5335	.4755	
14	.4572	.4954	.4024	.4572	.4954	.4755	
15	.4954	.4572	.439		.4572	.4024	
16	.4954	.4572	.439	.4572	.4954	.2987	
17	.4572	.4191	.439	.5335	.5716	.4755	
18	.4954	.4572	.5121	.6478	.5335	.4755	
19	.724	.6859	.7522	.7621	.8002	.5853	
20	.8764	.724	.7522	.8383	.8383	.695	1.0288
21	.7621	.7621	.6805	.7621	.7621	.6584	.9145
22	.6859	.724	.6219	.6097	.6097	.5853	.7621
23	.4572	.6097	.5121	.4954	.381	.4755	.4954
24	.3658	.381	.5716	.3658	.381	.3429	.6219
Max	.8764	.8002	.7621	.8383	.8383	.7621	1.0288
Min	.2987	.381	.3361	.3361	.3429	.2987	.2987
Avg	.5176	.5414	.5223	.5322	.5319	.4943	.5546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 304 / JAMB GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3429	.3048	.3361	.3429	.3429	.3361
2	.3361	.3429	.3048	.2987	.3048	.3429	.2987
3	.2987	.3429	.3048	.3361	.3048	.3429	.2987
4	.3658	.3429	.381	.3658	.3429	.3429	.3361
5	.4024	.4191	.3429	.4024	.381	.381	.3658
6	.5487	.6097	.5335	.6097	.4572	.5716	.5487
7	.695	.7621	.7621	.8002	.6097	.8002	.7522
8	.6584	.724	.6478	.6859	.8002	.6478	.5853
9	.5121	.5716	.5335	.4954	.5716	.5716	.5487
10	.4954	.6097	.5121	.5335	.6859	.6584	.4572
11	.4572	.6478	.5373	.5716	.724	.6219	
12	.5716	.6097	.5487	.6097	.6478	.6584	
13	.5335	.6097	.3361	.5716	.5716	.5487	
14	.4954	.6097	.5853	.5716	.6097	.5121	
15	.381	.6478	.6219	.5335	.6859	.5487	
16	.4191	.6097	.6584	.5335	.6859	.4755	
17	.6097	.5716	.5121	.5716	.6097	.439	
18	.6478	.6097	.6584	.6859	.6478	.6584	
19	.724	.7621	.7164	.7621	.8764	.788	
20	.9907	.7621	.8596	.8764	.8383	.9313	.9907
21	.9145	.8002	.7522	.724	.7621	.788	.8764
22	.6478	.6859	.5487	.6097	.5716	.6219	.7621
23	.4954	.5335	.439	.4954	.381	.439	.4191
24	.3361	.3429	.381	.3361	.3429	.3429	.3658
Max	.9907	.8002	.8596	.8764	.8764	.9313	.9907
Min	.2987	.3429	.3048	.2987	.3048	.3429	.2987
Avg	.5364	.5779	.5326	.5549	.5732	.5573	.5294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 254020 / 33/22 KV JAMB S/STN

Feeder No / Name : 305 / 22 KV KHADAKI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.0762	.1143	1.9052	1.5242	.9835
2	.1143	.1143	.0762	.0762	1.829	1.5242	.8139
3	.0762	.1143	.0762	.0762	1.6766	1.3717	.7522
4	.0762	.1143	.0762	.0762	1.6766	1.3717	.7522
5	.0762	.1524	.1143	.1143	1.6004	1.3336	.7461
6	.1143	.1524	.1143	.1143	1.5242	1.1812	.7461
7	.1143	.1905	.1143	.1143	1.829	1.5623	1.0852
8	.1143	.1524	.0762	.1143	1.9052	1.9052	1.5424
9	.1143	2.3624	2.2862	.1143	.0762	.1143	1.9113
10	2.5911	2.4387	2.3137	.0762	.1143	.1143	2.3624
11	2.5911	2.5149	2.2466	.0762	.1143	.1143	
12	2.4768	2.3624	2.2131		.1143	.1143	
13	2.4768	2.4387	1.933		.1524	.1143	
14	2.2862	2.5149	1.7974		.1524	.1143	
15	2.0957	2.21	1.6956	.0762	.0762	.1143	
16	2.0957	2.2862	1.6617	.0762	.0762	.1143	
17	.1143	.0762	.1143	.0762	.1143	.1143	
18	.1143	.0762		.0762	.1524	.1143	
19	.1524	.0762	.1143	.0762	.1905	.1143	
20	.1905	.1143	.1143	.1143	.1905	.1143	1.448
21	.1905	.1143	.1143	.1143	.1524	.1143	1.3717
22	.1524	.1143	.1143	.1143	.1524	.1143	1.1431
23	.1143	.1143	.1143	2.0576	1.6766	1.1191	.0762
24	.1143	.1143	.1143	.1143	1.9814	1.5623	1.1065
Max	2.5911	2.5149	2.3137	2.0576	1.9814	1.9052	2.3624
Min	.0762	.0762	.0762	.0762	.0762	.1143	.0762
Avg	.7780	.8764	.7683	.1887	.8097	.6690	1.1227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 302 / 22 KV COLLEGE ROAD

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4725	.5182	.5335	.5487	.5335	.4877	.4572
2	.4268	.4572	.503	.503	.4877	.4572	.4572
3	.4115	.4877	.503	.503	.4877	.4572	.4572
4	.4115	.4725	.503	.5182	.4877	.4572	.4268
5	.4268	.4572	.503	.5335	.5182	.4725	.442
6	.5487	.5792	.6249	.6401	.6097	.5639	.6097
7	.9602	.9602	.9755	1.1279	.8688	.9145	1.0212
8	1.4175	1.3565	1.4175	1.2803	1.2651	1.3108	1.2803
9	1.2803	1.3413	1.3413	1.2346	1.326	1.387	1.326
10	1.2041	1.1736	1.2346	1.1279	1.3413	1.1279	1.2498
11	.9907	.9602	1.2041	1.0669	1.2346	1.0822	1.0822
12	1.0974	.884	.9907	.9755	1.1736	.9145	.8535
13	1.0059	.945	.9602	.8535	1.0669	.884	.8383
14	1.0059	.8078	.8688	.8078	.9297	.7926	.8535
15	.884	.7621	.8993	.7926	.945	.7621	.6859
16	.9145	.7773	.8535	.8078	.8688	.7773	.7316
17	1.0364	.9755	.884	1.0059	.8383	.8535	.8078
18	1.1584	1.0517	.9297	1.0212	.8993	.9297	.8383
19	1.1279	1.0669	.9602	.9755	1.0669	1.0822	.8535
20	1.1888	1.1126	1.1431	1.0822	1.1279	1.1888	.945
21	1.0669	1.0212	1.1126	1.0059	1.0212	.9755	.945
22	.9755	.9297	.9755	.9145	.8993	.8993	.945
23	.884	.8688	.8688	.8535	.8535	.8078	.823
24	7.5827	.6554	.6401	.6401	.6249	.5792	.5792
Max	7.5827	1.3565	1.4175	1.2803	1.3413	1.387	1.326
Min	.4115	.4572	.503	.503	.4877	.4572	.4268
Avg	1.1866	.8592	.8929	.8675	.8948	.8402	.8129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 304 / 22 KV WAI CITY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	2.1948	2.2558	2.2405	2.21	2.7282	2.6825
2	1.9509	1.9662	2.0729	2.0424	2.0119	2.4996	2.4539
3	1.8747	1.89	1.9966	1.9814	1.9509	2.4234	2.3929
4	1.8595	1.9052	1.9662	1.9509	1.9204	2.4234	2.3167
5	2.0729	2.0271	2.0576	2.0424	2.0271	2.5301	2.5453
6	2.4082	2.4234	2.5301	2.4844	2.3929	3.1703	3.1093
7	3.1093	3.094	3.2007	3.3074	2.8502	4.0085	4.1305
8	3.8561	3.8256	3.9323	3.8714	3.5818	4.984	5.1364
9	3.7494	3.6427	3.8866	3.7494	3.6275	5.0145	5.0602
10	3.5513	3.597	3.6732	3.3989	3.6123	4.7249	4.8621
11	3.3836	3.2312	3.4598	3.597	4.3591	4.3439	4.0847
12	3.2465	3.2007	3.3532	3.3379	4.1914	4.0085	3.7494
13	3.216	3.1703	3.4294	3.2617	4.1	3.9018	3.6275
14	3.0788	2.9874	3.2465	3.2617	3.9171	3.7952	3.5665
15	3.0331	2.9874	3.1398	3.094	3.658	3.6885	3.3532
16	2.8654	3.0483	2.9569	2.9721	3.5513	3.658	3.3379
17	3.1398	3.2007	3.1703	3.0788	3.7952	3.6885	3.5513
18	3.3532	3.3379	3.3227	3.1855	4.0847	4.0085	3.7342
19	4.2829	4.2067	4.2067	3.9018	5.1974	4.9992	4.7706
20	5.1517	4.8621	5.1669	4.6334	6.31	5.9899	5.9595
21	4.7401	4.6182	4.6792	4.4658	5.7766	5.7461	5.5632
22	4.0695	4.2524	4.0085	4.1762	5.1517	5.2126	5.0145
23	3.5665	3.7494	3.6123	3.6275	4.6182	4.5725	4.4658
24	9.5298	2.7587	2.7892	2.7282	3.3989	3.4141	3.2922
Max	9.5298	4.8621	5.1669	4.6334	6.31	5.9899	5.9595
Min	1.8595	1.89	1.9662	1.9509	1.9204	2.4234	2.3167
Avg	3.4676	3.1741	3.2547	3.1829	3.6789	3.9806	3.8650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 305 / 22 KV KENJAL AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17
HR	Load (MW)
24	6.893
Max	6.893
Min	6.893
Avg	6.893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 306 / 22 KV BAVDHAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	6.893
Max	6.893
Min	6.893
Avg	6.893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 307 / 22 KV SHAHABAUG GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	6.893
Max	6.893
Min	6.893
Avg	6.893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 402 / 33 KV MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17
HR	Load (MW)
24	5.715
Max	5.715
Min	5.715
Avg	5.715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

BARAMATI ZONE[052]

SATARA CIRCLE[575]

WAI DIVISION[700]

WAI[121]

BU 0957

Substation No/ Name :- 257014 / 132/33/22 KV WAI S/STN

Feeder No / Name : 404 / 33 KV WAI-VELE

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.0933	6.8587	3.2236	3.0864	3.0864	2.1948	6.3786
2	7.6132	6.1728	3.0864	2.9492	2.8121	2.0576	5.7613
3	7.1331	5.8299	2.8807	2.8807	2.8121	2.0576	5.6927
4	7.1331	5.8985	2.8807	2.8121	2.7435	2.0576	5.5556
5	7.1331	5.9671	3.0178	2.9492	2.9492	2.1948	5.4184
6	8.3676	7.2017	3.8409	3.8409	3.7037	2.8121	6.5158
7	11.1111	10.0823	5.4184	5.8299	5.4184	3.9781	9.6022
8	14.2661	13.0316	6.5844	6.9959	7.0645	5.144	12.4143
9	13.9918	15.0206	11.3169	12.0713	13.1687	5.0755	11.9342
10	6.9959	15.9808	14.8148	16.3238	16.8725	5.0069	5.0755
11	6.1728	15.1578	15.0892	16.941	16.118	4.4582	4.1838
12	5.5556	14.6091	13.4431	16.4609	14.8834	4.1152	
13	5.2812	12.7572	14.6777	15.8436	14.4719	4.0466	2.6063
14	4.8697	12.963	13.9918	14.3347	13.5803	3.7037	2.6749
15	4.5953	12.1399	13.5117	13.9918	11.9342	3.4979	2.4006
16	4.5268	12.5515	13.3745	14.4033	12.3457	3.4294	2.2634
17	5.2812	11.9342	12.4829	13.8546	11.4541	3.4979	1.9204
18	5.8985	5.9671	5.9671	5.6242	4.8011	3.9781	3.0864
19	7.0645	7.1331	7.2017	6.653	5.487	5.0069	4.9383
20	8.642	8.7106	8.7106	8.7106	6.9273	6.653	6.9959
21	8.4362	8.5048	8.3676	8.5048	6.7215	6.4472	6.7215
22	7.3388	7.4074	7.3388	7.4074	5.6927	5.487	5.7613
23	7.7504	6.0357	5.8985	5.7613	4.4582	6.9273	6.5158
24	18.0899	4.0466	4.0466	3.9095	2.8121	7.2017	7.0645
Max	18.0899	15.9808	15.0892	16.941	16.8725	7.2017	12.4143
Min	4.5268	4.0466	2.8807	2.8121	2.7435	2.0576	1.9204
Avg	7.9726	9.6651	8.3819	8.8392	8.0133	4.2095	5.7166