

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 201 / 11 KV LONKHEDI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147				1.7147	1.8861
2	1.7147				1.7147	2.0576
3					2.3148	2.2291
4					2.6578	2.4006
5					3.1722	2.7435
6						2.915
7	2.915	3.0864			3.4294	3.0864
8	2.3148	2.3148			2.2291	2.7435
11			3.4294			
12			3.4294			
13			3.4294			
14			3.3436			
15			3.3436			
17				2.915		
18				3.0007		
Max	2.915	3.0864	3.4294	3.0007	3.4294	3.0864
Min	1.7147	2.3148	3.3436	2.915	1.7147	1.8861
Avg	2.1648	2.7006	3.3951	2.9579	2.4618	2.5077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 202 / 11 KV SHIRDHANE AG 1  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	24-FEB-17
HR	Load (MW)
1	.6001
2	.6001
3	.6859
4	.8573
5	.8573
6	.9431
7	1.0288
8	.9431
Max	1.0288
Min	.6001
Avg	.8145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 203 / 11 KV DEUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	.1715	1.1145	1.2003
2			.1715	.1715	1.1145	1.2003
3			.1715	.1715	1.286	1.3717
4				.1715	1.4575	1.5432
5			.1715	.1715	1.6289	1.5432
6			.1715	.1715	1.7147	1.7147
7	1.7147	1.7147	.1715	.1715	1.8004	1.7147
8	1.0288	1.5432		.1715	1.286	1.5432
9	.1715	.1715			.1715	
10	.1715	.1715			.1715	
11	.1715	.1715				
12	.1715	.1715				
13		.1715				
14		.1715				
15		.1715				
16		.1715		1.5432		
17	.1715	.1715		1.5432		
18				1.1145		
19				.1715		
20				.1715		
21				.1715		
22				.1715		
23				.7716		
24				.9431		1.2003
Max	1.7147	1.7147	.1715	1.5432	1.8004	1.7147
Min	.1715	.1715	.1715	.1715	.1715	1.2003
Avg	.5144	.4365	.1715	.4690	1.1746	1.4480

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 204 / 11 KV NER AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	1.2003
2			.5144	1.2003
3			.5144	
4			.5144	
5			.6001	
6			.6859	
7			.7716	
8			.7716	
11	.8573	.9431		
12	.9431	.9431		
13	.9431	.9431		
14		.7716		
15	.8573	.7716		
16	.1905	.6859		
17	.8573	.6859		
Max	.9431	.9431	.7716	1.2003
Min	.1905	.6859	.5144	1.2003
Avg	.7748	.8206	.6109	1.2003

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 206 / 11 KV NANDRE SINGLE  
PHASING Feeder KV- 11 /  
OUTGOING

SINGLE PHASING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8657	.8596	1.4121	1.4121	1.3115	1.3725
2	.8634	.8535	1.4022	1.4076	1.3047	1.3664
3	.8474	.8375	1.3855	1.3916	1.2574	1.3596
4	.8642	.8634	1.3664	1.4091	1.243	1.374
5	.8863	.8848	1.4038	1.4198	1.3138	1.4228
6	.932	.9252	1.4571	1.4525	1.3626	1.4586
7	.9846	.9549	1.4838	1.5043	1.4159	1.4929
8	.9595	1.1264	1.4792	1.4807	1.4175	1.4929
9	.7918	1.3222	1.2818	1.3611	1.3359	1.3931
10	.8794	1.4358	1.3931	1.2102	1.3634	1.422
11	.9061	1.4335	1.4571	1.438	1.464	1.4312
12	.9015	1.4464	1.4403	1.4312	1.4685	1.4312
13	.8932	1.3817	1.4068	1.3199	1.8381	1.4175
14	.8505	1.3009	1.2917	1.3916	1.4121	1.403
15	.8604	1.39	1.3344	1.4129	1.4419	1.438
16	.8703	1.3877	1.3298	1.422	1.4053	1.454
17	.8581	1.3931	1.2612	1.3489	1.4015	1.435
18	.8238	1.3489	1.166	1.2597	1.3717	1.4007
19	.8299	1.4236	1.2856	1.1767	1.2651	1.4175
20	.7209	1.323	1.1363	1.512	1.6369	1.2468
21	.6889	1.1584		1.6027	1.6347	1.1248
22	.8169	1.3504	1.3908	1.6118	1.643	1.3763
23	.8733	1.4243	1.4327	1.323	1.4091	1.435
24	.8825	1.4274	1.4373	1.3123	1.3908	1.438
Max	.9846	1.4464	1.4838	1.6118	1.8381	1.4929
Min	.6889	.8375	1.1363	1.1767	1.243	1.1248
Avg	.8604	1.2189	1.3667	1.4005	1.4212	1.4002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 207 / 11 KV SHIRDHANE GAOTHAON

GAOTHAN FEEDER

FSS Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0762	.0572	.0762	.0572
2			.0762	.0572	.0762	.0572
3			.0762	.0572	.0762	.0762
4			.1143	.0762	.1143	.0762
5			.1334	.1143	.1715	.1143
6			.1524	.1334	.1715	.1715
7	.1715	.1905	.1905	.1905	.1905	.1524
8	.1524	.1524	.1524	.1143		
9	.0762	.0953	.0953		.0953	
10	.0572	.0762	.0762		.0953	
11	.0572	.0762				
12	.0762	.0762	.0762			
13	.0762	.0762	.0572			
14	.0762	.0762	.0572			
15	.0762	.0762	.0572			
16	.0762	.0762	.0572	.0762		
17	.0762	.0762	.0762	.0762		
18			.0953	.0953		
19			.1334	.1143		
20			.1143	.1143		
21			.0762	.1143		
22			.0572	.0953		
23				.0762		
24				.0762		
Max	.1715	.1905	.1905	.1905	.1905	.1715
Min	.0572	.0762	.0572	.0572	.0762	.0572
Avg	.0883	.0953	.0953	.0964	.1186	.1007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 208 / 11 KV DEUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0572	.0762	.0572
2			.0572	.0762	.0572
3			.0572	.0762	.0572
4			.0762	.0953	.0762
5			.0762	.0953	.1143
6			.1143	.1143	.1143
7	.1524	.1524	.1524	.1334	.1334
8	.1334	.1143	.1334	.1334	.1143
9	.0762	.0953		.0953	.0762
10	.0572	.0762		.0572	.0762
11	.0572	.0572			.0572
12	.0572	.0572			
13	.0572	.0572			
14	.0572	.0572			
15	.0572	.0572			
16	.0572	.0572			
17	.0762	.0572	.0572		
18			.0762		
19			.0953		
20			.0953		
Max	.1524	.1524	.1524	.1334	.1334
Min	.0572	.0572	.0572	.0572	.0572
Avg	.0762	.0762	.0873	.0953	.0849

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094003 / 33/11 KV NER

Feeder No / Name : 209 / 11 KV SHIRDHANE AG-2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2572	.0857	.0857
2			.2572	.0857	.0857
3			.2572	.0857	.0857
4			.2572	.0857	.0857
5			.3429	.0857	.0857
6			.3429	.0857	.0857
7	.0857	.0857	.5144		.0857
8	.0857	.0857	.4287		.0857
9	.0857	.0857			.0857
10	.0857	.0857			.0857
11	.3429	.3429			
12	.4287	.3429			
13	.4287	.2572			
14	.3429	.3429			
15	.3429	.3429			
16	.0762	.3429	.0857		
17	.3429	.3429	.0857		
18			.0857		
19			.0857		
20			.0857		
21			.0857		
22			.0857		
23			.0857		
Max	.4287	.3429	.5144	.0857	.0857
Min	.0762	.0857	.0857	.0857	.0857
Avg	.2407	.2416	.2090	.0857	.0857



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 201 / 11 KV BORKUND AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	1.0242				.6158	.0312
2	1.0402	1.0242				.6158	.0312
3	1.0883	1.0883				.6465	
4	1.1203	1.1012				.7389	
5	1.2146	1.1822				.7697	.0324
6	1.2631	1.2452				1.1084	.0324
7	1.668	1.8351				1.3547	.0486
8	1.4403	1.4089				1.2315	.0429
10				1.8473			
11			2.2291	1.8473	2.0012		
12			2.3148	1.9704	1.9704		
13			2.3663	1.9396	1.9089		
14			2.2291	1.9089	1.9089		
15			2.0576	1.8473	1.8473		
16			1.8519	1.7549	1.7549		
17			1.6804	1.7241	1.7549		
18			1.6118	.7697	.9236		
23	1.0402				.6773		1.0288
24	.9412	1.0242				.7081	.0312
Max	1.668	1.8351	2.3663	1.9704	2.0012	1.3547	1.0288
Min	.9412	1.0242	1.6118	.7697	.6773	.6158	.0312
Avg	1.1856	1.2148	2.0426	1.7344	1.6386	.8655	.1598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 202 / 11 KV SHIRUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377		.6859	.585	.0462	.0377
2	.0377	.0378		.7202	.585	.0616	.0377
3	.0373	.0377		.7202	.6158	.0616	.0377
4	.0373	.0377		.7888	.6465	.0616	
5	.0373	.0377		.9431	.6465	.0616	.0377
6	.0373	.0377		1.2003	.7081	.0616	
7				1.2346	.8313		
8				.9259	.9236		
11	.8223	.9259				1.0551	.9602
12	.9442	.9602				1.0997	1.0288
13	.828	.9602				.9712	.8916
14	.7181	.9259				.6944	.8573
15	.7432	.8573				.6923	.7202
16	.7116	.823				.7074	.6859
17	.6991	.7888				.7526	.6516
18	.6554	.6516				.5468	.5487
19	.0366	.0343	.0343	.0308		.0724	.0343
20	.0732	.0343	.0343	.0308		.0739	.0343
21	.0754	.0343		.0308		.0739	.0343
22	.0754	.0343	.0343	.0308		.0739	.0343
23	.0377		.6859	.1539		.0739	.0343
24	.0362	.0366		.6859	.1847	.0308	.0377
Max	.9442	.9602	.6859	1.2346	.9236	1.0997	1.0288
Min	.0362	.0343	.0343	.0308	.1847	.0308	.0343
Avg	.3341	.3838	.1972	.5844	.6363	.3636	.3725

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 203 / 11 KV I.O.C.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0377	.0377	.052	.0693	.0754
2	.0754	.0754	.0377	.0373	.052	.0693	.0754
3	.0754	.0754	.0373	.0566	.052	.0693	.0754
4	.0566	.0754	.0377	.0373	.052	.0866	.0754
5	.0566	.0754	.112	.0747	.052	.0866	.0754
6	.0566	.0754	.112	.0747	.052	.1039	.0754
7	.0566	.0566	.112	.0747	.052	.1039	.0566
8	.0566	.0566	.112	.056	.052	.0693	
9	.2263	.7282	.1509	.0693	.0693	.1509	.0566
10	.3395	.0754	.0934	.0693	.0693	.1886	.0747
11	.2829	.2263	.1509	.1039	.052	.1886	.1307
12	.132	.2263	.1698	.1039	.052	.132	.1494
13	.132	.2263	.1509	.1385	.052	.132	.1494
14	.0948	.2452	.1372	.1385	.052	.1509	.1494
15	.0943	.2263	.1132	.1039	.052	.1132	.1494
16	.0943	.2263	.1132	.1039	.052	.0754	.0747
17	.0754	.1886	.0754	.052	.052	.0566	.0747
18	.0754	.1509	.0754	.052	.052	.0568	.056
19	.132	.0754	.0754	.052	.1039	.0754	.056
20	.132		.0754	.052	.1039	.0754	.0747
21	.0566	.0754		.052	.0693	.0754	.0754
22	.1886	.0754	.0754	.052	.0693	.0754	.0754
23	.0566	.0686	.0377	.052	.0693	.0754	.0373
24	.0754	.0754	.0686	.0377	.052	.0693	
Max	.3395	.7282	.1698	.1385	.1039	.1886	.1494
Min	.0566	.0566	.0373	.0373	.052	.0566	.0373
Avg	.1124	.1502	.0940	.0701	.0599	.0979	.0860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 204 / 11 KV NIMGUL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0686	.0686	.0462		
2			.0686	.0686	.0462		
3			.0686	.0686	.0616		
4			.1029	.0686	.0616		
5			.1029	.1715	.0924		
6			.1715	.1715	.0924		
7			.1715	.1715	.1232		
8			.1372	.1372	.1847		
11	.1082	.1715				.1349	.2058
12	.1669	.1886				.1635	.2058
13	.1943	.2058				.1635	.1886
14	.1739	.1715				.1635	.1715
15	.1581	.1715				.1486	.1372
16	.1265	.1372				.1486	.1372
17	.1406	.1372				.104	.1029
18	.1158	.1372				.104	.1029
23		.0686	.0686	.0462			
24			.0686	.0686	.0462		
Max	.1943	.2058	.1715	.1715	.1847	.1635	.2058
Min	.1082	.0686	.0686	.0462	.0462	.104	.1029
Avg	.1480	.1543	.1029	.1041	.0838	.1413	.1565

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 205 / 11 KV BORKUND GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5281	.4108	.3734	.4503	.4849	.4904
2	.5228	.4338	.4668	.3734	.4503	.6581	.4904
3	.0566	.5281	.4108	.3772	.4849	.6927	.547
4	.5975	.5658	.449		.4849	.8313	.8676
5	1.1016	.9431	.8589	.4481	.5542	1.0737	1.094
6	1.2449	1.1506	.9335	1.0456	1.0391	1.1084	1.2071
7	1.1016	1.1694	1.0082	.9335	1.1084	1.0045	1.1506
8	1.0082	1.0374	.9335	.8402	1.0391	.8659	.9522
9	.8316	.7356	.5601	.6927	.6927	.7316	.5601
10	.4251	.4904	.4108	.5195	.4503	.4755	.4668
11	.3658	.4108	.3772	.4849	.4156	.4207	.4108
12			.2743	.3464	.3464	.3475	.3734
13		.2801	.2829	.3464	.3117	.3475	.3734
14		.2801	.2572	.3464	.3117	.3658	.4668
15	.4207	.2801	.3395	.3464	.3117	.3658	.4668
16	.4572	.2801	.3772	.4156	.3464	.4024	.4668
17	.3801	.3734	.415	.4849	.4156	.4163	.4668
18	.5249	.4854	.4715	.5542	.5195	.4755	.5601
19	.9979	.8676	.6602	.9352	.8313	.9979	.8589
20	.924	.8299	.7922	.7274	.6927	.8316	.9335
21	.7842	.6859	.7545	.6927	.6581	.6099	.7842
22	.6348	.4715	.5658	.5195	.6235	.5914	.5975
23	.5788		.3772	.4849	.5542	.499	.5228
24	.5281	.4668	.4715	.3772	.4156	.4156	.4904
Max	1.2449	1.1694	1.0082	1.0456	1.1084	1.1084	1.2071
Min	.0566	.2801	.2572	.3464	.3117	.3475	.3734
Avg	.6674	.6043	.5358	.5507	.5628	.6256	.6499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 208 / 11 KV VINCHUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1372	.1029	.0616		
2			.1372	.1029	.0616		
3			.1372	.1029	.0616		
4			.1715	.1029	.0924		
5			.2401	.2058	.0924		
6			.3429	.3086	.1232		
7			.3086	.3086	.1539		
8			.3086	.4115	.2771		
11	.301	.3429				.4214	.4115
12	.3612	.3772				.4515	.4115
13	.3612	.4115				.4214	.4801
14	.3612	.3772				.3763	.4458
15	.3612	.3429				.3913	.4115
16	.3462	.3086				.3913	.4115
17	.3311	.2743					.3429
18	.301	.2743				.3311	.2743
23		.1372		.0616			
24			.1372	.1029	.0616		
Max	.3612	.4115	.3429	.4115	.2771	.4515	.4801
Min	.301	.1372	.1372	.0616	.0616	.3311	.2743
Avg	.3405	.3162	.2134	.1811	.1095	.3978	.3986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094008 / 33/11 KV JUNWANE

Feeder No / Name : 209 / 11 KV RATANPURA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4489	.4793				.585	.4572
2	.4489	.4858				.585	.4572
3	.4778	.5357				.6158	.4923
4	.5796	.5716				.6465	.5796
5	.6923	.6226				.6465	.639
6	.8539	.7011				.6465	.6923
7	1.3603	1.2018				1.0468	1.1984
8	.9755					.8621	.9145
11			1.406	1.2315	1.3239		
12			1.4746	1.1853	1.2931		
13			1.406	1.2007	1.2315		
14			1.3717	1.0776	1.2007		
15			1.3717	1.0468	1.1084		
16			1.3032	1.016	1.0468		
17			1.2003	.9236	.9236		
18			1.0631	.7389	.8313		
23	.4512				.4618	.4633	.4801
24	.443	.4793				.4618	.4572
Max	1.3603	1.2018	1.4746	1.2315	1.3239	1.0468	1.1984
Min	.443	.4793	1.0631	.7389	.4618	.4618	.4572
Avg	.6731	.6347	1.3246	1.0526	1.0468	.6559	.6368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213] BU 0574

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 209 / 11 KV Kheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3498	.3547	.3574	.3761	.3437	.2103
2	.3437	.3547	.3589	.3669	.3384	.2054
3	.3372	.3513	.3578	.3685	.3353	.202
4	.3608	.378	.3628	.3879	.3506	.216
5	.4355	.4633	.4534	.4508	.4302	.2481
6	.62	.6367	.6207	.5944	.6135	.3738
7	.7141	.7209	.7305	.7152	.732	.5376
8	.6832	.6939	.7099	.4992	.7049	.5232
9	.5155	.5136	.5727	.5975	.5514	.5087
10	.3868	.173	.4439	.3909	.4184	.4009
11	.3509	.3768	.3677	.3673	.3666	.2911
12	.3437	.3849	.3586	.3464	.349	.2294
13	.2953	.2896	.2877	.3014	.2957	.2667
14	.2892	.2641	.2629	.2469	.2561	.2557
15	.2709	.2397	.253	.2568	.2534	.2641
16	.2774	.2442	.253	.2751	.2648	.274
17	.2843	.3083	.3003	.2995	.2961	.2881
18	.3304	.2991	.2736	.3048	.285	.3121
19	.4729	.4512	.4477	.2229	.4973	.4664
20	.5075	.5072	.4851	.5087	.5277	.3913
21	.4862	.4786	.4694	.4576	.474	.4866
22	.4622	.4424	.4481	.421	.4492	.4553
23	.3936	.3951	.4104	.3803	.3974	.2793
24	.3639	.3715	.3799	.3517	.365	.2618
Max	.7141	.7209	.7305	.7152	.732	.5376
Min	.2709	.173	.253	.2229	.2534	.202
Avg	.4115	.4039	.4152	.3953	.4123	.3312



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 201 / 11 KV AKALAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.9259	1.0059	1.0631	.7926	.2743	.2743
2	.2915	.9259	1.0059	1.1145	.8078	.2743	.2743
3	.2743	1.0288	1.0364	1.166	.823	.2743	.2743
4	.3258	1.1145	1.0517	1.1831	.8535	.2915	.2915
5	.3772	1.2346	1.0669	1.2003	.8993	.3258	.3429
6	.4287	1.3889	1.0822	1.2517	.9602	.3429	.3944
7	.0394	1.5775	1.5546	1.6975	1.2651	.3601	.4458
8	.3086	1.3375	1.3108	1.5432	1.1888	.2915	.3086
9	.1715	.1029	.2229	.0189	.12	.1886	.2229
10	.1715	.1029	.12	.1715	.1029	.1715	.1543
11	2.0405	.1372	.0857	.12	.12	1.8519	1.869
12	1.9204	.0514	.1715	.12	.12	2.0062	1.869
13	1.5775	.0514	.1886	.1372	.1372	1.9204	1.8004
14	1.4746	.2229	.1886	.1715	.1886	1.7661	1.5432
15	1.4232	.2229	.2058	.12	.2401	1.6804	1.4918
16	1.4403	.1886	.2058	.12	.2572	1.6289	1.5089
17	1.4403	.2229	.1886	.1715	.2058	1.5604	1.5947
18	1.2517	.2229	.2058	.1715	.2058	1.4575	.1337
19	.3601	.3944	.3601	.3086	.3772	.3429	.3601
20	.3772	.3772	.3429	.3086	.3772	.3772	.3772
21	.3601	.3429	.3258	.2915	.3429	.3601	.3601
22	.3258	.3086	1.0631	.3086	.3258	.3429	.3258
23	.9945	.884		.7468	.2915	.2915	.3086
24	.2743	.9602	1.0631		.8078	.2743	.2743
Max	2.0405	1.5775	1.5546	1.6975	1.2651	2.0062	1.869
Min	.0394	.0514	.0857	.0189	.1029	.1715	.1337
Avg	.7475	.5970	.6110	.5872	.4921	.7773	.7000

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 202 / 11 KV KUSUMBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.4801	.4973	.4973	.4801	.2743	.2572
2	.2572	.4973	.5144	.4973	.4973	.2743	.2572
3	.2743	.4973	.5316	.583	.5144	.2743	.2743
4	.3086	.5487	.5316	.5658	.5316	.3086	.3086
5	.0309	.6001	.5658	.6173	.6001	.3429	.3601
6	.3258	.6859	.6687	.703	.6687	.4115	.4115
7	.4115	.8402	.9259	.7888	.9088	.4458	.4458
8	.3772	.703	.703	.7373	.7545	.3772	.3601
9	.4458	.5316	.6516	.5487	.6001	.5316	.5316
10	.3772	.4801	.5658	.5144	.463	.4801	.4458
11	.5316	.1981	.0326	.2591	.3772	.4801	.4458
12	.4287	.3048	.3258	.2896	.3429	.463	.4458
13	.3944	.2896	.3429	.3048	.3429	.4287	.463
14	.4115	.3048	.0326	.3048	.3429	.4458	.4801
15	.463	.2896	.3086	.2896	.3258	.4973	.5144
16	.463	.2743	.2915	.3048	.3429	.5144	.4801
17	.4458	.2896	.3086	.3048	.3429	.4801	.4458
18	.463	.2896	.3772	.3048	.3601	.583	.6001
19	.7202	.6859	.823	.6516	.6687	.703	.6859
20	.7202	.6859	.6344	.6687	.6687	.6859	.6516
21	.6687	.6516	.6344	.6344	.6173	.6516	.6344
22	.6173	.6001	.6001	.6001	.5658	.6173	.6173
23	.5487	.583	.5316	.5316	.2743	.2572	.2572
24	.2058	.4973	.5144		.4801	.2743	.2572
Max	.7202	.8402	.9259	.7888	.9088	.703	.6859
Min	.0309	.1981	.0326	.2591	.2743	.2572	.2572
Avg	.4228	.4920	.4964	.5001	.5030	.4501	.4430

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 203 / 11 KV EXP WATER SUPPLY  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0865	.0862	.0691	.0883	.0861	.0695	.0514
2	.0867	.0691	.0863	.0884	.0861	.0697	.0514
3	.0866	.069	.0863	.0884	.086	.0868	.0686
4	.0866	.0862	.0862	.0885	.0688	.0867	.0514
5	.0866	.0862	.0863	.0886	.0689	.0867	.0686
6	.0893	.0904	.0896	.1236	.0719	.1066	.0686
7	.0902	.0911	.09	.1243	.0898	.107	.0686
8	.0891	.0862	.0897	.0898	.0892	.0893	.0686
9	.0906	.0871	.09	.0926	.0878	.1073	.0857
10	.1074	.0645	.0874	.0301	.0668	.0897	.0514
11	.0816	.0383	.0802	.0601	.0445	.0605	.0686
12	.0443	.0171	.0803	.059	.0616	.0256	.0686
13	.0428	.0171	.0796	.0421	.0444	.0426	.0686
14	.0431	.0173	.0798	.0415	.0443	***	.0686
15	.0435	.0389	.0798	.0386	.0443	.0428	.0686
16	.0507	.0511	.0842	.0535	.0729	.0522	.0686
17	.068	.0682	.0845	.0727	.1105	.0695	.0686
18	.0706	.072	.0837	.0707	.0892	.0659	.0686
19	.0881	.0719	.0868	.0703	.0878	.0834	.0686
20	.0888	.0711	.0917	.0716	.0716	.0693	.0686
21	.0891	.0715	.0918	.072	.0717	.0695	.0686
22	.0887	.071	.0909	.0711	.0714	.0693	.0686
23	.0862	.0862	.0885	.0689	.1038	.0851	.0514
24	.0862	.0862	.0885	.0174	.0695	.0851	.0686
Max	.1074	.0911	.0918	.1243	.1105	54.1065	.0857
Min	.0428	.0171	.0691	.0174	.0443	.0256	.0514
Avg	.0780	.0664	.0855	.0713	.0745	2.3261	.0657

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 204 / 11 KV SUNLINE EXPRESS 1

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.5658	.7049	.5906	.6478	.6344	.583
2	.743	.583	.7049	.5906	.6478	.6344	.6001
3	.7049	.583	.6859	.6097	.6287	.6516	.6001
4	.724	.5658	.6859	.6097	.6478	.6344	.6173
5	.6478	.583	.7049	.6287	.6478	.6344	.6173
6	.6097	.6001	.7049	.6478	.6478	.6516	.6344
7	.6668	.6001	.7621	.7049	.7049	.6344	.6344
8	.6478	.583	.6668	.6859	.6478	.6344	.6173
9	.6287	.5658	.6478		.6859	.583	.5658
10	.6687	.6516	.724		.6668	.6516	.583
11	.703	.8002			.7202	.7373	.7621
12	.6687	.8192	.8764		.7716	.7716	.703
13	.6687	.8192	.8002		.7373	.7373	.7049
14	.6687	.8383	.8002	.381	.7545	.7716	.724
15	.703	.8573	.8002	.6859	.7373	.7716	.7049
16	.6516	.8002	.8002	.6859	.7716	.703	.7049
17	.6687	.8383	.7621	.743	.7202	.7545	.6859
18	.6344	.724	.7049	.6478	.7373	.6859	.6287
19	.583	.7049	.6859	.6287	.6687	.6516	.6097
20	.5658	.7049	.6478	.6478	.6344	.5658	.6478
21	.5658	.6668	.6859	.6478	.6516	.583	.6478
22	.5487	.6668	.6859	.6478	.6516	.6344	.6859
23	.6001	.6859	.6859	.6478	.6687	.6516	.6478
24	.6478	.5658	.6478		.6478	.6516	.6001
Max	.743	.8573	.8764	.743	.7716	.7716	.7621
Min	.5487	.5658	.6478	.381	.6287	.5658	.5658
Avg	.6526	.6822	.7207	.6351	.6852	.6673	.6463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 205 / 11 KV Gotane

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.7716	.945	1.0631	.9602	.2743	.2743
2	.2743	.7888	.9755	1.0631	.945	.2743	.2743
3	.2915	.8573	.9755	1.0974	.9602	.2743	.2743
4	.3258	.9259	1.0212	1.1488	.945	.2915	.3086
5	.3772	1.046	1.0517	1.2003	.9602	.3258	.3258
6	.4115	1.2346	1.1431	1.2689	.9602	.3429	.3429
7	.3601	1.3717	1.5089	.823	1.3717	.3601	.3601
8	.3258	1.4232	1.387	1.4746		.2743	.2915
9	.1886	.2058	.2401	.2229	.2058	.1715	.2058
10	.1543	.1543	.1715	.1372	.1372	.1372	.1715
11	1.8861	.12	.12	.12	.1372	1.8347	1.869
12	1.8347	.1029	.12	.12	.12	1.6289	2.1091
13	1.9033	.12	.1029	.12	.12		2.0576
14	1.8861	.12	.12	.12	.12	2.0233	1.749
15	1.8176	.12	.1372	.12	.1029	1.9376	1.5775
16	1.5089	.1372	.1372	.12	.12	1.8861	1.7318
17	1.5947	.1543	.1372	.12	.12	1.8347	1.8176
18	.8573	.1886	.1715	.1543	.1372	1.869	1.5947
19	.3258	.3429	.3429	.3086	.3429	.3086	.3086
20	.3086	.3258	.2915	.2915	.3258	.3086	.0309
21	.2915	.3086	.2915	.2743	.3086	.3086	.3258
22	.2743	.2743	.2743	.2572	.2915	.2915	.3258
23	.7888	.8383	1.0288	.8383	.2743	.2915	.2915
24	.2915	.7716	1.0802		.9602	.2743	.2743
Max	1.9033	1.4232	1.5089	1.4746	1.3717	2.0233	2.1091
Min	.1543	.1029	.1029	.12	.1029	.1372	.0309
Avg	.7730	.5293	.5739	.5419	.4750	.7619	.7872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 206 / 11 KV Kawathi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8417	1.105	1.1065	1.0882	1.0551	.7079	.3258
2	.8425	1.1088	1.0887	.6306	1.0783	.7255	.3429
3	.9	1.137	1.1649	1.1534	1.1172	.7625	.3429
4	.9442	1.2277	1.3515	1.2765	1.2643	.8695	.3772
5	1.0578	1.4556	1.5432	1.5707	1.4525	1.054	.5144
6	1.3325	1.6484	1.7455	1.7463	1.656	1.3161	.703
7	1.8789	1.7692	1.7158	1.7113	1.6609	1.4815	.9088
8	1.5554	1.5565	1.4796	.7905	1.5943	1.3309	.7716
9	1.0178	1.0468	1.0357	1.0128	1.1073	.9427	.5316
10	.8585	1.1797	1.1496	.6358	1.0837	.8349	.4458
11	.7171	1.592	1.459	1.2178	1.3919	.6744	.3258
12	.6421	1.4754	1.3817	1.2498	1.4399	.5183	.3258
13	.7137	1.4144	.9111	1.2025	1.2456	.583	.3601
14	.7663	1.3626	1.2913	1.1256	1.0806	.7338	.3429
15	.8063	1.2887	1.209	.9091	1.1596	.7594	.3772
16	.7918	1.3511	1.1992	.9937	1.3416	.7731	.3772
17	.8036	1.3862	1.2163	1.0303	1.2452	.7552	.3772
18	1.1024	1.0738	1.0494	.9602	1.1027	1.0765	.4287
19	1.5969	1.544	.9181	1.6091	1.5615	1.526	.7202
20	1.5946	1.4884	1.5603	1.5326	1.5654	1.536	.0772
21	1.4625	1.4453	1.4803	1.3934	1.4236	1.4651	.7202
22	1.318	1.3264	1.2956	1.2239	1.0875	1.129	.6516
23	1.1721	1.211	1.1344	1.1253	.7201	.7808	.3353
24	.9724	1.1073	1.089	.5716	.8783	.7262	.3429
Max	1.8789	1.7692	1.7455	1.7463	1.6609	1.536	.9088
Min	.6421	1.0468	.9111	.5716	.7201	.5183	.0772
Avg	1.0704	1.3459	1.2740	1.1567	1.2630	.9609	.4594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094022 / 33/11 KV KUSUMBA

Feeder No / Name : 207 / 11 KV SUNLINE EXPRESS 2

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.046	1.1431	1.1431	1.086	1.0631	1.0974
2	1.2193	1.0631	1.1622	1.1622	1.105	1.0631	1.1145
3	1.2193	1.0631	1.2003	1.1431	1.1622	1.0802	1.1488
4	1.2384	1.0802	1.2003	1.1812	1.1812	1.0974	1.166
5	1.2574	1.0974	1.2384	1.1622	1.2193	1.1317	1.166
6	1.2574	1.0974	1.2574	1.1622	1.2574	1.1488	1.1831
7	1.3527	1.1145	1.1431	1.2003	1.3527	1.166	1.1831
8	1.2193	1.0974	1.0098	1.2384	1.2003	1.1145	1.1145
9	1.1431	1.0631	1.1431		1.1431	1.046	1.0288
10	1.0802	1.0631	1.086		1.1622	1.046	1.0288
11	1.2174	1.2384	1.3527		1.2174	1.1831	1.3908
12	1.2003	1.3717	1.3336		1.2346	1.286	1.3146
13	1.1145	1.3336	1.3146		1.2174	1.1831	1.2193
14	1.1831	1.3146	1.3146	.4191	1.2346	1.1831	1.2384
15	1.166	1.3336	1.2384	1.2003	1.2517	1.3203	1.3527
16	1.1317	1.3717	1.1812	1.2193	1.2689	1.166	1.1812
17	1.2174	1.2003	1.2384	1.2193	1.2517	1.1831	1.2003
18	1.1317	1.2003	1.0669	1.105	1.1831	1.0802	1.1622
19	1.046	1.1431	1.1622	1.0669	1.046	1.0802	.9526
20	1.0117	1.1622	1.1431	1.086	1.0631	.9945	1.0479
21	1.0288	1.2003	1.105	1.1241	1.0802	.9774	1.0098
22	1.0288	1.2003	1.1431	1.1241	1.0631	.9431	1.086
23	1.0631	1.1812	1.2384	1.105	1.0974	1.0974	1.1241
24	1.2003	1.046	1.1241		1.086	1.0631	1.0974
Max	1.3527	1.3717	1.3527	1.2384	1.3527	1.3203	1.3908
Min	1.0117	1.046	1.0098	.4191	1.046	.9431	.9526
Avg	1.1645	1.1701	1.1892	1.1145	1.1735	1.1124	1.1503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 201 / 11 KV ARVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	1.0631	.8916	.9259	.823	.8916	.9602
2	.9945	1.0631	.7926	.9259	.823	.8916	.9774
3	.9945	1.166	.823	.9259	.823	.9602	1.0288
4	1.0288	1.2003	.9945	.9431	.8573	.9945	1.166
5	1.2003	1.2003	.9145	1.0288	.945	1.0288	1.1831
6	1.4746	1.3032	1.0364	1.2193	1.1431	1.0974	1.4575
7	1.4746	1.2498	1.5242	1.6461	1.6766	1.2803	1.4575
8	1.2517	1.1584	1.3717	1.5242	1.3717	1.166	1.1831
9	.8745	.8573	.9088	.823	.8916	.8059	.7545
10	.6173	.6859	.8402	.7888	.823	.6859	.6344
11	1.1888	1.1584	.8745	.5792	.6516	1.4632	1.448
12	1.448	1.4022	.6344	.6516	.6859	1.6156	1.3717
13	1.326	1.448	.7202	.6516	.6859	1.6766	1.3717
14	1.2193	1.3717	.7202	.6859	.7545	1.5546	1.3717
15	1.3108	1.326	.703	.7545	.7545	1.448	1.3108
16	1.326	1.3108	.7888	.8916	.7888	1.4327	1.4022
17	1.3413	1.3413	.7373	.8573	.7202	1.4784	1.1888
18	1.1126	1.3717	.7373	.7202	.7545	1.326	1.0974
19	1.2689	1.4746	1.3717	1.406	1.3375	1.1831	1.3032
20	1.3717	1.406	1.286	1.3717	1.2689	1.3203	1.3375
21	1.3032	1.3375	1.286	1.286	1.2346	1.286	1.2689
22	1.2346	1.2003	1.2346	1.2003	1.166	1.2346	1.2003
23	1.0974	.7926	.9431	.8573	.9602	1.0974	1.166
24	.9945	1.0631	.9431	.9259	.823	.9602	.9774
Max	1.4746	1.4746	1.5242	1.6461	1.6766	1.6766	1.4575
Min	.6173	.6859	.6344	.5792	.6516	.6859	.6344
Avg	1.1854	1.2063	.9616	.9829	.9485	1.2033	1.1924



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 202 / 11 KV EKVIRA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1372	.1029	.1029	.0686	.0686
2	.1715	.1715	.1372	.1029	.1029	.0343	.0857
3	.1715	.1715	.1372	.1029	.1029	.0343	.1029
4	.1715	.1715	.1372	.0686	.0686	.0343	.0857
5	.1715	.1372	.0686	.1029	.0686	.0343	.0686
6	.1715	.1372	.0686	.1029	.1029	.0343	.0514
7	.1886	.1372	.0686	.1029	.1029	.0343	.0686
8	.0857	.061	.0686	.0343	.0514	.0343	.1029
9		.0857	.0686	.0514	.0686	.0686	.0857
10	.0857	.12	.1372	.0514	.0686	.1372	.0686
11	.0514	.0514	.0686	.1029	.0686	.1372	.12
12	.12	.0686	.0686	.0514	.0686	.0343	.12
13	.0514	.0514	.0514	.0686	.0686	.0514	.12
14	.0514	.1029	.0514	.0343	.0686	.0514	.0514
15	.0514	.0514	.1029	.1029	.0686	.0857	.0514
16	.12	.12	.0514	.0514	.0686	.0514	.12
17	.0514	.0686	.0343	.1029	.0686	.0514	.1372
18	.0343	.0686	.0857	.1029	.0686	.0857	.1029
19	.0857	.1029	.0686	.0686	.0343	.0514	.0686
20	.0343	.1029	.0857	.0686	.0343	.0514	.0686
21	.1715	.1715	.0514	.0514	.0343	.0514	.0686
22	.1715	.1715	.0343	.0514	.0686	.0514	.0686
23	.1715	.1715	.1029	.0514	.1029	.0514	.0686
24	.1715	.1372	.1715	.0514	.0514	.0686	.12
Max	.1886	.1715	.1715	.1029	.1029	.1372	.1372
Min	.0343	.0514	.0343	.0343	.0343	.0343	.0514
Avg	.1185	.1145	.0857	.0743	.0715	.0579	.0864

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 203 / 11 KV HENDRUN SINGLE  
PHASING Feeder KV- 11 /  
OUTGOING

SINGLE PHASING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1869	.9145	.5487	.5144	.5144	.9145	1.0364
2	1.2003	1.0974	.5487	.5144	.5144	.9145	1.0059
3	1.2003	1.2193	.6859	.5144	.5144	.945	.945
4	1.2517	1.3108	.7888	.6001	.5487	1.0059	1.2955
5	1.4575	1.3717	.9259	.9259	.8573	1.0059	1.448
6	1.6766	1.4022	1.0288	1.1488	1.166	2.1948	1.6309
7	2.2862	2.3472	1.166	1.166	1.1317	2.3167	2.21
8	1.9204	1.8595	.9145	.8573	.8916	2.1033	1.7223
9	.4801	.5144	.5639	.5144	.3963	.5316	.4973
10	.4115	.4458	.3944	.4458	.4801	.4973	.4115
11	.3601	.3429	1.6918	1.9204	1.5242	.3429	.3429
12	.3601	.3258	2.2558	2.1643	2.1643	.3429	.3429
13	.3086	.3429	2.1338	2.0119	2.1643	.2401	.3429
14	.2915	.3601	2.271	2.0119	1.9814	.3429	.3086
15	.3258	.3601	2.1948	1.3413	1.9204	.3601	.3772
16	.3429	.3772	2.1186	1.768	1.89	.4115	.3772
17	.3258	.3772	2.0729	1.6766	1.89	.3772	.3772
18	.4115	.3772	1.7833	1.5851	1.6461	.3772	.4115
19	.7888	.9259	.8573	.8916	.9945	.8059	.8916
20	.823	.823	.8573	.823	.8573	.823	.823
21	.7545	.8573	.7716	.7716	.7202	.7888	.7545
22	.6859	.7202	.6859	.6859	.6516	.6516	.6859
23	1.2193	.6859	.583	.5658	1.0974	1.406	1.0364
24	1.2003	.8916	.6859	.5487	.5487	1.0631	1.2041
Max	2.2862	2.3472	2.271	2.1643	2.1643	2.3167	2.21
Min	.2915	.3258	.3944	.4458	.3963	.2401	.3086
Avg	.8862	.8438	1.1887	1.0820	1.1277	.8651	.8533

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 204 / 11 KV SONEWADI SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.4877	.9259	.8916	.2743	.2915
2	.2401	.2401	.5182	.9431	.8916	.3086	.2743
3	.2401	.3086	.6097	.7545	.8916	.3086	.3429
4	.2572	.3429	.6706	.7545	.9259	.3429	.3086
5	.4115	.3772	.7621	.8573	1.0364	.3772	.4801
6	.583	.4458	.823	.9145	1.0364	.5144	.6516
7	.5487	.5487	1.0974	1.3717	1.6632	.6173	.6344
8	.4973	.4572	1.1888	1.2955	1.2955	.5144	.5144
9	.3772	.2743	.3944	.3429	.3086	.3601	.3429
10	.2572	.2401	.2572	.3086	.3086	.2401	.2058
11	1.1126	1.1888	.1715	.1829	.1715	.884	1.2498
12	1.4327	1.2193	.1543	.1715	.2058	1.387	1.3565
13	1.2955	1.2041	.1372	.1715	.1715	1.4632	1.2955
14	1.0517	.9145	.1543	.1715	.1715	1.3717	1.0974
15	1.0669	.8535	.1372	.1715	.1715	.9145	.884
16	1.0364	.8688	.1543	.1372	.1715	.9755	.884
17	1.1126	1.0364	.1886	.1715	.1715	1.1584	.823
18	.6097	.9602	.2401	.1715	.2058	.8535	.7926
19	.463	.5487	.4801	.3772	.4801	.463	.5144
20	.5487	.5144	.4287	.3429	.4115	.4801	.4115
21	.3772	.3772	.4115	.3772	.3772	.3944	.3772
22	.3086	.3429	.3086	.3258	.3429	.3429	.3429
23	.2401	.5487	.9259	.9259	.2743	.2915	.3086
24	.2572	.2401	.6859	.9602	.8916	.2743	.2743
Max	1.4327	1.2193	1.1888	1.3717	1.6632	1.4632	1.3565
Min	.2401	.2401	.1372	.1372	.1715	.2401	.2058
Avg	.6069	.5955	.4745	.5470	.5612	.6297	.6108

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 205 / 11 KV Kulthe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7926	.3429	.3429	.3429	.8535	1.2498
2	.6516	.9145	.3429	.3429	.3429	.8535	1.0517
3	.6516	.9755	.3429	.3429	.3429	.884	1.0364
4	.7716	1.0669	.3772	.3772	.1543	.884	1.0669
5	1.0288	1.1584	.3772	.4115	.5144	.9145	1.2955
6	1.153	1.2498	.4458	.5487	.5658	1.5242	1.387
7	1.7465	1.8595	.5487	.5316	.5487	1.6766	1.829
8	1.0174	1.5546	.4115	.3944	.4287	1.5242	1.7833
9	.2401	.2572	.2743	.2401	.2401	.2743	.2401
10	.1715	.1715	.1543	.1715	.1715	.1715	.1886
11	.0857	.1372	1.7528	1.6156	1.3108	.1543	.1715
12	.1372	.1372	2.1795	2.0424	1.89	.1372	.1715
13	.1372	.1543	2.0881	2.0729	1.9509	.0343	.1715
14	.1543	.1715	2.1643	1.829	1.9814	.0343	.1886
15	.1715	.1715	2.0576	1.829	1.6461	.1886	.1886
16	.12	.1715	2.1186	1.7985	1.7528	.1886	.1886
17	.1715	.1372	1.9662	1.6766	1.7375	.1886	.2058
18	.1886	.2058	1.6156	1.5546	1.5851	.1886	.1715
19	.3944	.4801	.4458	.5144	.4801	.4287	.4801
20	.463	.4115	.4801	.4458	.4115	.4458	.4458
21	.4458	.4801	.4801	.4458	.4115	.4458	.4458
22	.3772	.4115	.4458	.4287	.3772	.3601	.3772
23	.9602	.4115	.3772	.3429	.9259	1.1488	.9145
24	.8402	.7316	.3429	.3601	.3429	.9602	1.0669
Max	1.7465	1.8595	2.1795	2.0729	1.9814	1.6766	1.829
Min	.0857	.1372	.1543	.1715	.1543	.0343	.1715
Avg	.5304	.5922	.9222	.8608	.8523	.6027	.6798

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094025 / 33/11 KV ARVI

Feeder No / Name : 206 / 11 KV ERCON

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0309	.0343	.0343	.0343	.0343	.0291
2	.0343	.0309	.0343	.0343	.0343	.0343	.0291
3	.0343	.0309	.0343	.0343	.0343	.0343	.0309
4	.0343	.0309	.0343	.0343	.0343	.0343	.0326
5	.0343	.0309	.0309	.0343	.0343	.0309	.0326
6	.0291	.0274	.0309	.0309	.0309	.0309	.0274
7	.0257	.0274		.0274	.0274	.0309	
19	.0343	.0343	.0343	.0343		.0326	.0343
20	.0343	.0343	.0343	.0343	.0343	.0326	.0343
21	.0343	.0343	.0343	.0343	.0343	.0326	.0343
22	.0343	.0343	.0343	.0343	.0343	.0326	.0343
23	.0343	.0343	.0343	.0343	.0343	.0291	.0343
24	.0343	.0309	.0343	.0309	.0309	.0343	.0291
Max	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Min	.0257	.0274	.0309	.0274	.0274	.0291	.0274
Avg	.0332	.0317	.0337	.0332	.0332	.0326	.0319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 201 / 11 KV MUKTI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.2439	.3715	.3353	.3048	.1219	.0686
2	.08	.2439	.3715	.3353	.3048	.1219	.0686
3	.08	.2439	.3715	.381	.3239	.1219	.0686
4	.08	.3048	.3715	.4268	.3239	.1219	.0686
5	.08	.3048	.4374	.4572	.3239	.1219	.0838
6	.0743	.3658	.4687	.4572	.5182	.0762	.0838
7	.0743	.3658	.8124	.6097	.6478	.0762	.0838
8	.0762	.3658	.7499	.5716	.5792	.0762	.0819
9	.1189	.1219	.1143	.1417	.1296	.1219	.0476
10	.1158	.061	.1143	.1143	.1036	.0762	.6097
11	.4633	.061	.1143	.0762	.0762	.6097	.6097
12	.6097	.061	.0714	.0762	.0762	.6097	.4877
13	.6097	.061	.0714	.0667	.0762	.6097	.5335
14	.4877	.061	.0714	.0572	.0762	.5487	.4877
15	.4877	.061	.0667	.0667	.0762	.4877	.4877
16	.5487	.061	.0629	.0667	.0762	.4877	.4572
17	.4877	.061	.0629	.0572	.0762	.5487	.5135
18	.4268	.061	.1257	.0762	.0762	.4877	.3521
19	.1219	.1219	.1238	.1715	.1219	.1219	.1334
20	.1219	.1219	.2012	.1715	.1219	.1219	.1334
21	.1219	.1219	.1372	.2629	.1128	.1219	.1143
22	.1219	.1219	.1238	.1372	.1189	.1097	.1238
23	.1829	.381	.1238	.2286	.0762	.0705	.0991
24	.0781	.2439	.381	.1334	.2667	.1189	.0705
Max	.6097	.381	.8124	.6097	.6478	.6097	.6097
Min	.0743	.061	.0629	.0572	.0762	.0705	.0476
Avg	.2387	.1759	.2467	.2283	.2078	.2538	.2445

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 202 / 11 KV ANCHALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.125	.125	.1219	.1219	.1715	.1406	.125
2	.125	.125	.1219	.1219	.1715	.1406	.125
3	.1406	.1562	.1219	.1524	.2058	.1718	.125
4	.1562	.1875	.1219	.1829	.2572	.1718	.1406
5	.1718	.2343	.1829	.1829	.3086	.1875	.1875
6	.2134	.2812	.2743	.381	.3429	.2187	.2343
7	.2439	.3593		.3353	.3772	.2187	.2656
8	.2721	.2656	.2286	.2591	.2058	.1718	.125
9	.176	.1406	.1524	.1981	.12	.2031	.1094
10	.112	.1094	.1677	.1524	.096	.1067	.0781
11	.096	.2343	.1981	.1829	.16	.1094	.0781
12	.08	.2343	.1829	.1981	.16	.1094	.0781
13	.096	.2343	.1524	.2286	.192	.0781	.0781
14	.096	.1875	.1524	.1372	.192	.0781	.0781
15	.08	.1875	.1829	.1829	.176	.0937	.1094
16	.08	.1677	.1524	.1524	.176	.1094	.1094
17	.112	.2187	.1524	.1677	.176	.1094	.1094
18	.112	.1875	.1981	.1677	.176	.1094	.125
19	.2401	.2343	.2	.2286	.25	.2187	.2656
20	.2721	.2343	.2439	.2134	.2187	.2343	.2439
21	.2401	.1875	.1981	.1829	.2031	.25	.2286
22	.192	.1562	.1677	.1677	.1718	.2031	.1524
23	.16	.1562	.1524	.1524	.1406	.125	.1524
24	.1219	.16	.1562	.1524	.1524	.25	.1406
Max	.2721	.3593	.2743	.381	.3772	.25	.2656
Min	.08	.1094	.1219	.1219	.096	.0781	.0781
Avg	.1548	.1985	.1732	.1918	.2000	.1587	.1444

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 203 / 11 KV MUKTI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5228	.4668	.4668	.4854	.5601	.5975
2	.5601	.5975	.4668	.4668	.4854	.5601	.5975
3	.7842	.7095	.4668	.5601	.5601	.6722	.6722
4	.9709	.8215	.6535	.7842	.7468	.7468	.7468
5	1.2323	1.1203	.9335	1.1203	1.1203	1.0456	1.1949
6	1.4266	1.3817	1.4003	1.475	1.4003	1.3817	1.4563
7	1.6827	1.6804	1.4937	1.643	1.7364	1.643	1.6804
8	1.4937	1.4937	1.4003	1.4377	1.587	1.4937	1.4937
9	1.2071	1.1949	1.0456	.7716	1.0829	1.0829	1.0269
10	.8326	1.0269	.8589	.7095	1.0082	.8916	.8589
11	.7964	.7468	.8589	.5041	.9335	.9335	.8029
12	.7316	.7468	.4854	.5228	.8589	.6348	.5788
13	.5975	.6535	.4668	.4108	.7842	.5975	.6722
14	.7468	.6535	.6535	.4481	.7095	.7095	.6722
15		.5601	.7499	.5041	.7468	.7095	.6722
16		.6722	.695	.5601	.0934	.7095	.8029
17	.7316	.5601	.6219	.6722	.6348	.6722	.7282
18	.695	.6535	.6584	.6173	.7095	.7095	.6161
19	1.1949	1.1203	1.0903	.9694	1.2437	1.2323	1.1016
20	1.0829	1.0269	.8686	1.0242	1.1203	1.0829	.9896
21	.8215	.7468	.6838	.7095	.8215	.8589	.7468
22	.7468	.6535	.5914	.5788	.6722	.7095	.7282
23	.6722	.5601	.5544	.5228	.5975	.6348	.5415
24	.5601	.5601	.5601	.4805	.4854	.5487	.5975
Max	1.6827	1.6804	1.4937	1.643	1.7364	1.643	1.6804
Min	.5601	.5228	.4668	.4108	.0934	.5487	.5415
Avg	.9149	.8526	.7802	.7483	.8593	.8675	.8573



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094034 / 33/11 KV MUKTI

Feeder No / Name : 204 / 11 KV EXP.WATER SUPPLY  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0351	.1372	.1294	.1294	.032	.0351
2	.1097	.0351	.1372	.1294	.1294	.032	.0351
3	.1097	.0351	.1372	.1294	.1294	.032	.0351
4	.1463	.0351	.12	.1478	.1294	.032	.0351
5	.1463	.0351	.1372	.1478	.1294	.032	.0351
6	.1254	.0351		.1478	.1294	.032	.0351
7	.1254	.0351	.1372	.1494	.1478	.032	.0351
8	.0358	.0876	.0648	.0486	.1267	.064	.0351
9	.2149	.0876	.1134	.0972	.12	.0937	.0373
10	.2058	.0876	.1296	.0972	.12	.1029	.0373
11	.1715	.0876	.0324	.1296	.1029	.0937	.0373
12	.1772	.0876	.0305	.1134	.0343	.1029	.0373
13	.1949	.0876	.0305	.1067	.0343	.2058	.0324
14	.1772	.0876	.0305	.0914	.0343	.1886	.0324
15	.1772	.0876	.0248	.1677	.0343	.1029	.0324
16	.1772	.0876	.0366	.1829	.0343	.2058	.0324
17		.0876	.037	.2126	.0343	.2058	.0343
18	.1772	.0876	.0305	.1844	.0514	.1715	.0343
19	.124	.0876	.0457	.2103	.0514	.2058	.0566
20	.1063	.0876	.0457	.2103	.0457	.0514	.056
21	.1417	.0876	.0457	.1781	.1067	.1311	.1326
22	.1417	.0876	.0305	.1094	.1067	.12	.1341
23	.1029	.1402	.0305	.12	.0305	.0686	.1267
24	.112	.0876	.1402	.0305	.12	.0297	.0335
Max	.2149	.1402	.1402	.2126	.1478	.2058	.1341
Min	.0358	.0351	.0248	.0305	.0305	.0297	.0324
Avg	.1439	.0745	.0741	.1363	.088	.0987	.0487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094054 / 33/11 KV KUNDANE (WAR)

Feeder No / Name : 201 / 11 KV SANJORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3642	.4475	.5801	.9448
2		.4144	.4641	.5801	.9448
3		.4305	.4973	.663	.9779
4		.5298	.5304	.8288	.9945
5		.5629	.6299	1.0774	1.0277
6		.7293	.6962	1.2597	1.094
7		.6796	.6796	1.2266	1.6078
8		.6464	.6133	1.2431	1.3757
9		.431	.431	.4641	.3315
10		.3315	.3149	.3481	.2652
11		1.6409	1.326	.2321	.1989
12		1.6575	1.7238	.2155	.1823
13		1.7736	1.6575	.2155	.1823
14		1.5746	1.3757	.2321	.2155
15	1.1424	1.4238	1.3291	.2486	.2321
16	1.4735	1.4569	1.2929	.2486	.2321
17	1.4735	1.4735	1.1603	.2652	.2984
18	1.1589	1.1093	1.1271	.2652	.3978
19	.6126	.5795	.663	.5967	.6133
20	.5298	.5464	.5304	.5304	.5138
21	.5132	.4801	.4973	.4973	.4641
22	.4801	.4636	.431	.4144	.4144
23	.4636	.4475	.5801	1.1105	.9304
24		.447	.4475	.6299	.9945
Max	1.4735	1.7736	1.7238	1.2597	1.6078
Min	.4636	.3315	.3149	.2155	.1823
Avg	.8720	.8414	.8102	.5822	.6431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094054 / 33/11 KV KUNDANE (WAR)

Feeder No / Name : 203 / 11 KV KUNDANE (WAR)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5313	.3532	.6188	.6622	.486	.3776	.4158
2	.5313	.4908	.6535	.7393	.5066	.3791	.4158
3	.5687	.5287	.6873	.7087	.5258	.4154	.4536
4	.6066	.5639	.6996	.7754	.5281	.4914	.5103
5	.8901	.6068	.7578	.8322	.5897	.5693	.6602
6	1.0416	.787	.815	.8678	.7217	.6602	.9818
7	1.0405	.7422	1.1195	1.0541	.9383	.8685	
8	.7938	.7242	.7856	.7493	.7633	.9072	.8892
9	.606	.5847	.6922	.5475	.567	.473	.3965
10	.4154	.4527		.3765	.3371	.3584	.3402
11	.5035	.3953	.4859		.3584	.3529	.6585
12	.8011	.3949	.429		.3378	.506	.6655
13	.7433	.3937	.4653	.3738	.3385	.7378	.7262
14	.6562	.4108	.3757	.3344	.3761	.8492	.6234
15	.6139	.4112	.4467	.3562	.3761	.7467	.5999
16	.6584	.4299	.4845	.3746	.3555	.7513	.6539
17	.6125	.4504	.3749	.3555	.3978	.6841	.6147
18	.6132	.4889	.3925	.4499	.3812	.5992	.5014
19	.756	.9054	.7393	.816	.6602	.7954	.759
20	.756		.7393	.8349	.8539	.7764	.7772
21	.7938	.7393	.7211	.7204	.7182	.7204	.7189
22	.7182	.6824	.6256	.6072	.5698	.6642	.6072
23	.567	.5517	.5752	.4833	.5319	.5129	.4929
24		.3532	.569	.5251	.4296	.4749	.4373
Max	1.0416	.9054	1.1195	1.0541	.9383	.9072	.9818
Min	.4154	.3532	.3749	.3344	.3371	.3529	.3402
Avg	.6878	.5409	.6197	.6157	.5270	.6113	.6043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094055 / 33/11 KV VELHANE (NIMGUL)

Feeder No / Name : 201 / 11 KV DHAMANGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0606	.0191	.0191	.0191	.0693	.0514
2	.0732	.0606	.0191	.0191	.0191	.0793	.0533
3	.0754	.0663	.0191	.0191	.0191	.0914	
4	.0934	.0914	.0191	.0191	.0191	.0945	.3121
5	.096	.0914	.0191	.0191	.0191	.1296	.08
6	.1128	.2332	.0191	.0191	.0191	.217	.0975
7	.2641	.3121	.0191		.0191	.2418	.3121
8	.2641	.2103				.1858	.1709
11			.4001	.2498	.282		
12			.4344	.3144	.2606		
13			.4344	.3243	.282		
14			.4001	.2	.2782		
15			.3668	.2976	.2782		
16			.306	.2705	.2469		
17	.0191	.0191	.2705	.2195	.2364	.0191	.0381
18	.0191	.0191	.176	.1372	.1417	.0381	.0572
19	.0191	.0191	.0191	.0191	.0381	.0381	.0572
20	.0191	.0191	.0191	.0191	.0572	.0572	.0572
21	.0191	.0191	.0191	.0191	.0572	.0381	.0572
22	.0191	.0191	.0191	.0191	.0572	.0381	.0572
23	.0518	.0191	.0191	.0191	.068	.0572	.0814
24	.0707	.0191	.0191	.0191	.08	.0495	.0774
Max	.2641	.3121	.4344	.3243	.282	.2418	.3121
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0381
Avg	.0804	.0799	.1446	.1121	.1189	.0903	.1040

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094055 / 33/11 KV VELHANE (NIMGUL)

Feeder No / Name : 202 / 11 KV NIMGUL AG-2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1417	.1886	.18		
2			.1417	.1943	.204		
3			.1463	.2	.2229		
4			.1684	.2469	.2591		
5			.1684	.282	.2721		
6			.1867	.3185	.3067		
7			.4967	.6944	.6923		
8			.4923	.5647	.6287		
11	.6161	.5868				.7074	.6241
12	.7225	.7316				.9962	.6687
13	.8619	.6539				.8688	.7164
14	.7773	.5792				.6859	.5868
15	.7621	.5944				.6327	.443
16	.639	.5719				.5468	.4001
17	.5487	.5135				.6097	.3307
18	.4534	.4001				.4268	.1467
23		.1216	.1715	.1326			
24		.1372	.1772	.1686			
Max	.8619	.7316	.4967	.6944	.6923	.9962	.7164
Min	.4534	.1216	.1417	.1326	.18	.4268	.1467
Avg	.6726	.4890	.2291	.2991	.3457	.6843	.4896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094055 / 33/11 KV VELHANE (NIMGUL)

Feeder No / Name : 203 / 11 KV VELHANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1334				.1334	
2	.0953	.1334					
3	.0953	.1334				.1334	
4	.1143	.1715				.1524	
5	.1143	.1715				.1524	
6	.1334	.381				.2667	
7	.5335	.4763				.3048	
8	.4382	.4763				.2286	.2477
9							.381
10							.3048
11			.4763	.3429	.3048		.2286
12			.5716	.4191	.381		
13			.5716	.4382	.4954		
14			.5716	.3429	.362		
15			.4191	.3429	.381		
16			.4954	.381	.381		
17			.4763	.4001	.3429		
18			.3429	.2667	.1143		
23	.1334				.1334		.1334
24	.1334				.1334		.1334
Max	.5335	.4763	.5716	.4382	.4954	.3048	.381
Min	.0953	.1334	.3429	.2667	.1143	.1334	.1334
Avg	.1886	.2596	.4906	.3667	.3029	.1960	.2382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094059 / 33/11 KV VINCHUR

Feeder No / Name : 201 / 11 KV VINCHUR GAOTHAN

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7842		1.2696	.7468	.6859	.7842
2	.7545	.7842		1.307	.7468	.6859	.8402
3	.9431	.8215		1.6804	.7655	.703	.9335
4	1.3392	1.1203		2.0538	1.0269	.9602	1.0269
5	1.7918	1.643		2.4272	1.8858	1.6289	1.1949
6	2.6406	2.4459		2.6139	2.7073	2.332	1.2136
7	2.5086	2.2779		2.7633	2.5953	2.2291	1.2883
8	2.32	1.6991		2.2592	1.7364	2.1434	1.1203
9	1.7541	1.1576		1.7364	1.363	1.5432	1.5497
10	1.1694	1.0829	1.1488	1.307	1.3817	1.1317	1.1203
11	.9619	.9149	.9774	.7655	.7655	.823	.7655
12	.7356	.6348	.7716	.6161	.8215	.703	.7282
13		.6161	.5487	.6348	.8215	.6001	.5788
14		.5975	.6859	.6348	.8215	.583	.5601
15		.5975	.6687	.6722	.8589	.6173	.7282
16	.9242	.7282	.6173	.6908	.8589	.6859	.7655
17	.9997	.9335	.6859	.8402	.8402	.6859	.7655
18	1.1883	1.0269	1.1145	1.0269	1.0642	.5316	.8962
19	2.1879	1.9605	1.8519	2.1472	2.1658	.9088	1.0082
20	1.8296	1.9231	1.5432	1.7737	1.7924	1.6804	1.8484
21	1.4146	1.419	1.2003	1.3817	1.4003	1.2517	1.363
22	1.094	1.1949	1.0288	.9896	1.0269	.9774	1.0829
23	.8488	.8775		.8215	.8402	.7716	.8215
24	.7545	.7842		.9335	.7842	.703	.7373
Max	2.6406	2.4459	1.8519	2.7633	2.7073	2.332	1.8484
Min	.7356	.5975	.5487	.6161	.7468	.5316	.5601
Avg	1.3769	1.1677	.9879	1.3894	1.2424	1.0653	.9884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094059 / 33/11 KV VINCHUR

Feeder No / Name : 202 / 11 KV TARWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6481	.0594		
2			.6944	.0594		
3			.9259	.0743		
4			1.0185	.0892		
5			1.0802	.0892		
6			1.1111	.2526		
7			.8488	.3864		
8			.6173	.3269		
11	1.4198	1.2631			.9431	1.4563
12	1.4506	1.2483			1.0802	1.4563
13	1.4661	.4755			1.0802	1.4861
14	1.2809	1.174				1.2631
15	1.1728	1.1294			.8745	1.1443
16	1.142	1.0402			.823	1.1294
17	1.142	.9511			.7888	1.1294
18	.9259	.7579			.6859	.7727
23		.2824	.0617			
24			.463	.0594		
Max	1.4661	1.2631	1.1111	.3864	1.0802	1.4861
Min	.9259	.2824	.0617	.0594	.6859	.7727
Avg	1.2500	.9247	.7469	.1552	.8965	1.2297



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094059 / 33/11 KV VINCHUR

Feeder No / Name : 203 / 11 KV SITANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3756				.3086	.1692
2	.2934	.3384				.3086	.1833
3	.2934	.3384				.3086	.282
4	.3227	.3525				.3086	.3948
5	.3668	.3807				.3429	.4793
6	.5135	.4652				.3944	.4934
7	.7775	.4652				.6001	.7754
8	.6748	.6485				.6859	.5921
11			1.0288	.8619	.7895		
12			1.286	.8322	.7613		
13			1.2517	.8322	.7613		
14			1.0802	.6687	.5921		
15			.463	.6539	.5075		
16				.639			
17				.5944	.4512		
18				.535	.4512		
23	.4401				.2115	.6001	.282
24	.2641	.423				.3086	.2229
Max	.7775	.6485	1.286	.8619	.7895	.6859	.7754
Min	.2641	.3384	.463	.535	.2115	.3086	.1692
Avg	.4210	.4208	1.0219	.7022	.5657	.4166	.3874

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094060 / 33/11 KV CHOUGAON

Feeder No / Name : 201 / 11KV AJANALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.0171	.2743	.2591	.2743	.2229	.2743
2	.2058	.1715	.3048	.2743	.2743	.2229	.2896
3	.2058	.1715	.2439	.2896	.2743	.2229	.3201
4	.2401	.1886	.1981	.3201	.3086	.2229	.3353
5	.2743	.1886	.2896	.2286	.3429	.2572	.3506
6	.3429	.2743	.2134	.1981	.3944	.2915	.381
7	.3944	.3772	.3201	.2591	.3944	.3086	.2591
8	.2743	.0274	.3201	.2743	.3429	.2058	.1981
9	.2058	.1715	.3353	.1543		.1543	.1219
10	.1067	.1219	.1372	.1715	.12	.0914	.1067
11	.3429	.1219	.1067	.1372	.1029	.3506	.2743
12	.3601	.1219	.1219	.12	.12	.381	.3201
13	.3086	.0914	.1219	.1029	.12	.3506	.3353
14	.3086	.1372	.1372		.12	.3201	.2743
15	.3086	.1372	.1372	.1372	.12	.3048	
16	.3086	.1219	.1372	.8059	.1372	.3201	.2286
17	.2743	.1524	.1524	.1715	.1715	.3048	.2743
18	.2572	.1524	.1677	.1543	.1715	.2286	.2286
19	.3429	.2743	.2743	.3772	.3429	.3048	.3048
20	.2915	.2439	.2896	.3772	.3258	.2743	.2743
21	.2915	.2591	.2743	.3429	.2915	.2591	.2743
22	.2572	.2134	.2439	1.2003	.2572	.2439	.2439
23	.2572	.2743	.3353	.2743	.2401	.2591	.2439
24	.2058	.2591		.3506	.2743	.2229	.1981
Max	.3944	.3772	.3353	1.2003	.3944	.381	.381
Min	.1067	.0171	.1067	.1029	.1029	.0914	.1067
Avg	.2738	.1779	.2233	.3035	.2400	.2635	.2657

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

DHULE (R)[213]

BU 0574

Substation No/ Name :- 094060 / 33/11 KV CHOUGAON

Feeder No / Name : 202 / 11 KV CHOUGAON 1 PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	.2743	.3353	.3353	.2058	.2896	.7621
2	1.2003	.3048	.3658	.3658	.2058	.381	.823
3	1.0288	.3353	.2743	.3353	.2401	.4572	.9145
4	1.406	.3658	.2286	.4268	.3429	.7926	1.0364
5	1.6461	.381	.4572	.4572	.4115	.9907	1.0669
6	1.7833	.503	.5182	.5639	.5144	1.1736	1.2193
7	1.8861	.503	.5335	.4572	.5487	1.7985	1.829
8	1.7147	.4115	.3963	.3506	.4458	1.6461	1.9204
9	.1829	.024	.4268	.2401		.2439	.2286
10	.1219	.1524	.1219	.1543	.7926	.1524	.1524
11	.1372	2.21	2.0119	2.2291	1.3717	.1677	.1372
12	.1372	2.2405	2.1338	2.2977	2.1643	.1524	.1524
13	.1372	2.2253	2.2405	2.4006	2.1948	.1524	.1981
14	.1372	1.9052	1.9966		2.1948	.1524	.1524
15	.1372	1.8442	2.271	1.7147	1.9814	.1524	.2286
16	.1715	1.9357	2.1491	2.2291	1.9204	.1677	.1677
17	.1219	2.2253	1.9814	2.332	2.0424	.1524	.1524
18	.1829	.2896	1.8138	2.2291	1.8595	.1829	.1524
19	.3429	.2896	.3048	.3772	.2896	.3353	.3048
20	.3429	.2743	.3201	.5144	.3353	.3506	.3048
21	.3601	.3201	.3353	.4801	.3353	.3658	.3201
22	.3201		.3048	.4115	.3429	.3201	.3201
23	.0305	.3048	.3353	.3429	.2743	.4572	.2134
24	1.3717	.4572		.3048	.2401	.2134	.7621
Max	1.8861	2.2405	2.271	2.4006	2.1948	1.7985	1.9204
Min	.0305	.024	.1219	.1543	.2058	.1524	.1372
Avg	.6809	.8599	.9503	.9369	.9241	.4687	.5633

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 201 / DEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	1.7004	2.1052	2.0243	2.0243	2.2672	2.2672
2	.3239	1.7004	2.1052	2.0243	2.0243	2.1862	2.1052
3	.3239	1.7004	2.1052	2.0243	2.0243	2.1862	1.9433
4	.3239	1.7814	2.1052	2.1052	2.0243	2.2672	1.7814
5		1.7814	2.1052	2.1052	2.0243	2.2672	1.9433
6		1.9433	2.2672	2.2672	2.1052	2.2672	2.1052
7		2.3482	2.834	3.1579	2.915	3.2388	3.1579
8		2.3482	2.9959	2.672	.3239	2.5101	2.5911
9		.2429	.3239			.2429	.3239
10	.1619	.1619	.3239		.1619	.1619	.1619
11	3.3198	.1619	.1619		.1619	.081	.1619
12	3.0769	.1619	.1619		.1619	.081	.1619
13	3.2388	.1619	.1619		.1619	.081	.1619
14	3.1579	.1619	.1619		.1619	.1619	.1619
15	.1619	.1619	.1619		.1619	.1619	.1619
16	.1619	.1619	.1619		.1619	.1619	.1619
17	3.4008	.1619	.1619		.1619	.1619	.1619
18	3.5627	.2429	.1619		.2429	.2429	.2429
19	2.753	.4049	.4049	.4858	.4049	.4049	.4049
20	2.4291	.4049	.4049	.4858	.4049	.4049	.4049
21	.4049	.4049	.4049	.4049	.4049	.3239	.3239
22	.4049	.3239	.3239	.3239	.3239	.3239	.3239
23	1.7004	2.1052	2.0243	2.0243	2.2672	2.1862	2.2672
24	.3239	1.7814	2.1052	2.0243	2.0243	2.2672	2.2672
Max	3.5627	2.3482	2.9959	3.1579	2.915	3.2388	3.1579
Min	.1619	.1619	.1619	.3239	.1619	.081	.1619
Avg	1.5555	.9379	1.0931	1.7235	.9928	1.1100	1.0729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 202 / 11 KV BALHANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4334	1.9071	2.6006	2.4272	2.5139	2.6006	2.8607
2	.4334	1.8204	2.6006	2.4272	2.5139	2.6006	2.774
3	.4334	1.9071	2.6006	2.3405	2.5139	2.6006	2.6006
4	.4334	1.9938	2.6006	2.4272	2.5139	2.6873	2.5139
5	.5201	1.9938	2.7435	2.6006	2.5139	2.774	2.6873
6	.6935	2.2539	3.2074	2.8607	2.6873	2.9473	2.9473
7	.6068	3.034	3.8142	3.5542	3.8142	4.3343	4.0743
8	.5201	2.9473	3.4675	3.5542	.5201	4.161	4.161
9	3.5542	.4334	.4334			.4334	.4334
10	3.9009	.3467	.2601		.3467	.3467	.2601
11	4.0743	.2601	.1734		.2601	.1734	.1734
12	4.3343	.1734	.1734		.1734	.1734	.1734
13	.1734	.1734	.1734		.1734	.1734	.1734
14	.1734	.1734	.1734		.1734	.1734	.1734
15	3.9009	.1734	.1734		.1734	.1734	.1734
16	3.9009		.1734		.1734	.1734	.1734
17	4.0743	.2601	.1734		.1734	.1734	.1734
18	4.0743	.2601	.2601		.2601	.2601	.2601
19	.5201	.5201	.5201	.6935	.6068	.5201	.5201
20	.6068	.5201	.5201	.6068	.6068	.6068	.6068
21	.5201	.5201		.6068	.6068	.5201	.5201
22	.4334	.5201	.5201	.5201	.5201	.5201	.5201
23	1.9071	2.6873	2.6006	2.5139	2.6006	2.8607	2.6006
24	.3467	1.9071	2.6873	2.6006	2.6006	2.6006	2.9473
Max	4.3343	3.034	3.8142	3.5542	3.8142	4.3343	4.161
Min	.1734	.1734	.1734	.5201	.1734	.1734	.1734
Avg	1.6904	1.1646	1.4196	2.1238	1.2626	1.4412	1.4376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 203 / SAMODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7349	.4715	.5658	.4715	.5658	.5658	.5658
2	2.7349	.4715	.5658	.4715	.5658	.5658	.5658
3	2.7349	.4715	.5658	.4715	.5658	.5658	.5658
4	2.8292	.4715	.4858	.4715	.5658	.5658	.5658
5	2.9235	.6602	.7545	.6602	.7545	.6602	.7545
6	3.3951	.8488	.9431	.8488	.8488	.8488	.8488
7	4.5268	.9431	.9431	.7545	.9431	.8488	.9431
8	4.2438	.7545	.9431	.7545	4.8097	.8488	.8488
9	.6602	4.4324	4.904			4.5668	4.7154
10	.4715	4.904	4.7154		4.904	4.6211	4.5268
11	.3772	5.2812	4.8097		4.7154	4.7154	4.8097
12	.3772	5.1869	4.5077		5.1869	4.7154	4.8097
13	.3772	.3772	.3772		.3772	.3772	.3772
14	.3772	.3772	.3772		.3772	.3772	.3772
15	.3772	4.904	4.1495		4.8097	4.7154	4.4324
16		4.9983	4.3381		4.7154	4.8097	4.8097
17		5.3755	4.5268		4.7154	5.0926	4.4324
18		4.4324	4.2438		4.8097	4.8097	4.1495
19	.9431	.9431	.8488	3.0178	.8488	.8488	.8488
20	.8488	.9431	.8488	3.0178	.8488	.8488	.9431
21	.7545	.8488	.7545	.9431	.8488	.8488	.8488
22	.5658	.7545	.6602	.7545	.7545	.7545	.7545
23	.4715	.5658	.5658	.5658	.6602	.5658	.6602
24	2.7349	.4715	.5658	.4715	.5658	.5658	.5658
Max	4.5268	5.3755	4.904	3.0178	5.1869	5.0926	4.8097
Min	.3772	.3772	.3772	.4715	.3772	.3772	.3772
Avg	1.6885	2.0787	1.9567	.9768	2.1199	2.0293	1.9883

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 204 / SUKAPUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3472	.3772	.6602	.3772	.3772	.4715	.4715
2	2.2634	.3772	.6602	.3772	.3772	.4715	.3772
3	2.1795	.3772	.6602	.3772	.3772	.4715	.3772
4	2.2043	.3772	.6602	.3772	.3772	.4715	.3772
5	2.4587	.3772	.6602	.3658	.3772	.4715	.4715
6	2.5987	.4715	.6602	.4715	.3772	.4715	.5658
7	3.5208	.5658	.6602	.5658	.4715	.5658	.5658
8	3.1855	.5658	.6602	.5658	.6602	.5087	.5658
9	.4715	.4715	.1867			.4715	.5658
10	.3772	.3772	.0934		.5935	.3772	.6602
11		4.4086	4.1152		3.4294	4.2267	3.9876
12	.2829	4.2867	4.2867		4.2867	4.2267	4.201
13	.2829	4.2391	4.0295		4.4086	3.9781	4.0295
14	.2829	4.2867	3.6008		4.3239	3.437	3.4027
15	.2829	.6602	.6602		.6602	.2829	.6268
16	.2829	.6602	.6602		.6602	.3772	.6335
17	.2829	4.3239	4.161		4.0238	3.8123	3.858
18	.3772	4.0295	3.7275		3.8142	3.6885	3.3808
19	.5658		2.8921	1.0974	3.7275	3.7723	
20	.5658	.602	2.4272	.6602	2.9673	2.7349	2.5072
21	.5658	.5639	.5658	1.5384	.5658	.5658	.5658
22	.4715	.5792	.4715	1.8842	.5658	.5658	.5658
23	.4715	.6602	.4715	.3772	.4715	.4715	.5658
24	2.2377	.4715	.6602	.3772	.3772	.4715	.4715
Max	3.5208	4.4086	4.2867	1.8842	4.4086	4.2267	4.201
Min	.2829	.3772	.0934	.3658	.3772	.2829	.3772
Avg	1.2417	1.4830	1.5955	.6723	1.6639	1.5568	1.4693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 205 / PIMPALNER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6335	.6468	.6401	.7316	.6401	.6468
2	.6468	.6401	.6468	.6401	.7316	.6401	.6468
3	.6468	.6468	.6401	.6401	.7392	.6535	.6468
4	.6468	.6468	.7087	.6468	.7392	.7392	.8402
5	.8402	.924	.8573	.8402	.7468	.8402	.8402
6	1.2136	1.2136	1.1317	1.1203	1.1203	1.2136	1.2136
7	1.5089	1.5089	1.4146	1.4146	1.4146	1.6032	1.5089
8	1.4937	1.5708	1.587	1.4146	1.3575	1.587	1.4937
9	1.2936	1.1765	1.3575			1.267	1.2803
10	1.1393	1.1269	1.1393		1.3717	1.1145	1.1269
11	1.0059	1.0974	1.1088		1.2803	1.086	.985
12	1.0517	1.086	1.0974		1.2403	.9955	1.0974
13	.964	1.0059	1.0059		1.1765	1.0059	.9955
14	.8954	.9145	.924		.9955	.9145	.8859
15	.8954	.964	.8059		.9955	.905	.8954
16	.8954	.985	.8764		.9745	1.0745	1.2536
17	1.0059	1.086	.924		1.0059	.0572	1.1765
18	1.0164	1.0745	.905		1.0631	1.086	1.1641
19	1.1088	1.1765	1.1888	1.8604	1.2803	1.386	1.3717
20	1.1888	1.0974	1.1888	1.6118	1.0974	1.267	1.2012
21	1.0402	1.0631	1.1393	1.3432	1.086	1.086	1.1088
22	.9536	.9745	.9431	1.1641	.985	1.0174	.9955
23	.7316	.7392	.7316	.9145	.8145	.7392	.823
24	.6468	.724	.6468	.6401	.823	.7316	.6468
Max	1.5089	1.5708	1.587	1.8604	1.4146	1.6032	1.5089
Min	.6401	.6335	.6401	.6401	.7316	.0572	.6468
Avg	.9779	1.0032	.9840	1.0636	1.0335	.9854	1.0352



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094007 / 33/11 KV PIMPALNER

Feeder No / Name : 206 / SUKAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.3772	.3772	.3772	.3772
2	.3772	.3772	.3772	.3772	.3772	.3772	.3772
3	.3772	.3772	.3772	.3772	.3772	.3772	.3772
4	.3734	.4715	.3772	.4715	.3772	.3772	.3772
5	.5601	.5658	.4715	.5601	.3772	.5716	.4715
6	.7468	.7468	.6602	.6535	.6602	.7621	.6602
7	1.0374	1.0374	1.0374	1.0374	1.0374	1.1317	1.0374
8	.9431	1.1203	1.1317	1.0269	.7392		1.0374
9	.8402	.7545	.8488			.6535	.7545
10	.5487	.543	.5601		.6335	.543	.6468
11		.5544	.5601		.543	.462	.543
12	.5373	.462	.462		.5487	.4668	.462
13	.362	.3696	.4668		.4572	.5487	.4668
14	.3734	.3658	.3734		.3658	.3696	.462
15	.4525	.4572	.362		.3658	.4668	.3658
16	.4572	.4668	.362		.3658	.3658	.4525
17	.462	.4668	.4668		.5316	.5544	.5487
18	.6468	.5544	.5487		.5544	.6468	.6401
19		.8402	.8402	1.0974	.8488	.8402	.7468
20	.7468	.7468	.7468	1.0164	.8402	.7468	.7468
21	.5487	.5601	.6535	.7392	.6602	.5601	.5601
22	.4668	.4668	.462	.6401	.4715	.543	.5601
23	.3772	.3734	.3772	.4668	.4715	.3772	.4668
24	.3772	.3734	.3772	.3772	.3734	.3772	.3772
Max	1.0374	1.1203	1.1317	1.0974	1.0374	1.1317	1.0374
Min	.362	.3658	.362	.3772	.3658	.3658	.3658
Avg	.5450	.5595	.5532	.6584	.5371	.5433	.5631

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 201 / 11 KV KUDASHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2743		
2					.2778		
3	.3429						
5	.3086	.2896	.3429	.2229	.2343	.3052	.3258
6		.4374	.421	.3052	.583	.3429	.3561
7		1.085	.6874	.6859	.8453	.7802	.779
8		.9282	.8745	.9156	.9448	1.0227	1.0288
9		.9282	.9282		.9448	.9835	.9069
10		.8453	.6443		.7956	.7625	.7716
11			.6443		.7202	.5967	.6104
13	.8785						
14	.8356						
15	.8288						
16	.7537						
17	.8029						
18			.6783		.6783	.7373	.7969
19	.6154		.7045		.7122	.759	.7969
20	.4365		.5407	.6802	.6274	.4572	.6274
21			.5087	.578	.6104	.5247	.5765
22			.373	.4752	.39	.4451	.4748
23				.3437			
24				.779	.286		
Max	.8785	1.085	.9282	.9156	.9448	1.0227	1.0288
Min	.3086	.2896	.3429	.2229	.2343	.3052	.3258
Avg	.6448	.7523	.6123	.5540	.5950	.6431	.6709

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 202 / 11 KV VARSA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.0185		
2					1.0185		
3	.7888						
4	.7716						
5	.7455	.6984	.7011	.6836	.5243	.7042	.7975
6		.8962	.8402	.823	.8482	.823	.7975
7		1.0978	1.4232	1.3904	1.4752	1.6297	1.7511
8		1.7404	1.8519	1.9161	1.5581	1.6956	1.9547
9		1.6956	1.7635		1.576	1.7295	1.869
10		1.4083	1.5581		1.5415	1.2517	1.3927
11		1.1065	1.2517		1.2003	1.0576	1.0974
13	1.7204						
14	1.7072						
15	1.5565						
16	1.6617						
17	1.6278						
18		1.2136	1.5947		1.2209	1.3889	1.5604
19	1.2431	1.6289	1.2125	1.6385	1.7635	1.8031	1.8378
20	.8848	1.2574		.7074	1.2887	1.3565	1.3565
21		1.1105	1.0802	1.1012	1.0486	1.1336	1.1191
22		1.0322	.9088	.9667	.8383	1.0202	.9774
23				1.004			
24					.9511		
Max	1.7204	1.7404	1.8519	1.9161	1.7635	1.8031	1.9547
Min	.7455	.6984	.7011	.6836	.5243	.7042	.7975
Avg	1.2707	1.2405	1.2896	1.1368	1.1914	1.2995	1.3759

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 203 / 11 KV MALGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4784		
2					.463		
3		.3144	.4908	.407	.4687	.5365	.443
4		.3715	.5258	.4801	.5121	.5365	.5316
5	.5201	.4054	.5959	.4973	.4902	.5365	.5731
6	.5365						
7	1.0682						
8	1.406						
9	1.2308						
10	1.0688						
11	.8785						
13		1.3375	1.166		1.2209	1.1317	1.0974
14		1.1065	1.073		1.3916	1.1488	1.0343
15		1.0486	.9448		1.2548	1.0802	1.0562
16		.9503	1.0059		1.2039	1.17	1.1789
17		.9015	1.0749		1.286	1.3375	1.0749
18		.8063	.9835		1.0174	1.2309	.9088
19	1.065	.7362	.8322		.8817	.9816	.8238
20	.8124	.6935	.7042	1.2793	.7202	.7975	.7011
21	.7202			.8223			
22	.6401			.703			
23				.5864			
24	.8583				.4607		
Max	1.406	1.3375	1.166	1.2793	1.3916	1.3375	1.1789
Min	.5201	.3144	.4908	.407	.4607	.5365	.443
Avg	.9004	.7883	.8543	.6822	.8464	.9534	.8566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094027 / 33/11 KV KUDASHI

Feeder No / Name : 204 / 11 KV DANGSHIRWDE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7773		
2					.7811		
3		.5201	.502	.6935	.8097	.7865	.6344
4			.5761	.8139	.7682	.8139	.7202
5	.7716	.5268	.6554	.8551	.7373	.8987	.8048
6	.8718						
7	1.9669						
8	2.3807						
9	1.9662						
10	1.8138						
11	1.5249						
13		2.73	2.7435		2.4078	2.3739	2.364
14		2.5484	2.4478		2.6658	2.4078	2.1963
15			2.1136		2.73	2.2891	1.8233
16			1.9113		2.3807	2.0856	1.8652
17			1.6095		2.0062	2.2043	1.6787
18		1.6766	1.2452		1.5089	1.543	1.4083
19	1.9393	2.3908	1.2407		1.3904	1.4074	1.2209
20	1.4922	1.6194	1.0242	1.3441	1.2174	1.0562	.9762
21	1.3279	1.25		.5921			
22	1.1437	1.0551		1.5083			
23		.7964		1.3592			
24	1.5249				.9031		
Max	2.3807	2.73	2.7435	1.5083	2.73	2.4078	2.364
Min	.7716	.5201	.502	.5921	.7373	.7865	.6344
Avg	1.5603	1.5114	1.4608	1.0237	1.5060	1.6242	1.4266

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 201 / 11 KV DIGHAVE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0754
2					.0754
3					.0754
4					.0762
5					.0762
6				.1132	.1143
9				2.8509	
10				2.5606	
13				2.9843	
14				3.0167	
15				2.9835	
16				2.8166	
17				2.9504	
18				1.9757	
19				.1132	
20				.0754	
21				.0762	
22				.0762	
23	1.0105	1.2967	.0943	.0754	
24		.9242			.0754
Max	1.0105	1.2967	.0943	3.0167	.1143
Min	1.0105	.9242	.0943	.0754	.0754
Avg	1.0105	1.1105	.0943	1.6192	.0812

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 202 / 11 KV VITAI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.1385
2					1.1385
3					1.2163
4					1.2163
5					1.2955
6				.9945	1.4251
9				2.6216	
10				2.3205	
16	1.7404		2.2939		
19				.0777	
20				.1189	
21				.0549	
23	.0838	.1086	.8048	.1357	
24		.0838			1.2452
<b>Max</b>	<b>1.7404</b>	<b>.1086</b>	<b>2.2939</b>	<b>2.6216</b>	<b>1.4251</b>
<b>Min</b>	<b>.0838</b>	<b>.0838</b>	<b>.8048</b>	<b>.0549</b>	<b>1.1385</b>
<b>Avg</b>	<b>.9121</b>	<b>.0962</b>	<b>1.5494</b>	<b>.9034</b>	<b>1.2393</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 203 / 11 KV VITAI-DIGHAVE

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2481
2					.2835
3					.3224
4					.4572
5					.6283
6					1.0829
7					1.0829
8				.7392	.8589
9				.5544	
10				.3749	
11				.3155	
12				.2835	.3012
13				.2896	
16	.3113		.3721		
19				1.0136	
20				.7628	
21				.5087	
22				.2774	
23	.2896		.3258		
24		.2715			.2481
Max	.3113	.2715	.3721	1.0136	1.0829
Min	.2896	.2715	.3258	.2774	.2481
Avg	.3005	.2715	.3490	.5120	.5514



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 204 / 11 KV DEVKINANDAN  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0053	.0086	.0052	.0123	.0112	.0152	.0168
2	.0056	.0084	.0053	.0121	.0112	.0094	.0164
3	.0056	.0083	.0053	.0117	.0114	.0193	.0164
4	.0055	.0084	.0052	.0131	.0124	.0266	.0166
5	.0053	.0084	.0049	.0117	.0133	.039	.0168
6	.0072	.0106	.0054	.0113	.0131	.0422	.0168
7	.0055	.0085	.0057	.0061	.0074	.0442	.0168
8	.0106	.0064	.0048	.0205	.0394	.0899	.0503
9	.0083	.0108	.0078	.0081		.104	
10	.0098	.0138	.0133	.0192		.1052	
11	.0061	.0084	.0115	.014		.1107	
12	.0072	.0091	.009	.0106		.1096	
13	.0107	.0109	.009	.0112		.1039	
14	.0096	.0101	.008	.0112		.0971	
15	.0095	.0112	.0034	.0099		.0961	
16	.0091	.0106	.0004	.0094	.0497	.0964	
17	.0096	.0098	.0087	.0109		.0706	
18	.01	.0112	.0117	.0122		.0695	
19	.0149	.0122	.0137	.013	.0114	.0723	
20	.0145	.0116	.0082	.0166	.0119	.064	
21	.0128	.0107	.0096	.0123	.013	.0434	
22	.0134	.0105	.0098	.0102	.0121	.0358	
23	.0139	.0055	.0078	.011	.0362	.0224	
24	.0087	.0053	.0096	.0266	.0232	.0054	.0168
Max	.0149	.0138	.0137	.0266	.0497	.1107	.0503
Min	.0053	.0053	.0004	.0061	.0074	.0054	.0164
Avg	.0091	.0096	.0076	.0127	.0185	.0622	.0204

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094028 / 33/11 KV CHHAIL

Feeder No / Name : 205 / 11 KV KALGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5792
2					.5937
3					.7362
4					.8322
6				.7907	1.1469
7				1.186	2.0553
8				1.3443	1.8896
19				.3772	
20				.3582	
21				.2743	
22				.2427	
23	.2241	.2241	.3763	.6481	
24					.5792
Max	.2241	.2241	.3763	1.3443	2.0553
Min	.2241	.2241	.3763	.2427	.5792
Avg	.2241	.2241	.3763	.6527	1.0515

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 201 / 11 KV VASAMAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0876	.0701	.0526	.0701	.0701	
2		.0876	.0701	.0526	.0701	.0701	
3		.0876	.0876	.0526	.0701	.0701	
4		.0876	.0876	.0701	.0701	.0701	
5		.0701	.1052	.0876	.0876	.1052	
6		.0876	.1052	.1227	.0876	.1052	
7		.0876	.0876	.1052	.0876	.1052	
8		.0701	.1052	.1052	.0876		
9	.0876	.0701	.0701		.0701	.0701	
10	.0526	.0701	.0526		.0701	.0701	
11	.0526	1.6598	1.4255		1.4918	1.4083	1.5249
12	.0876	1.7939	1.6907		1.5581	1.7436	1.6078
13	.0526	1.7404	1.5581		1.6078	1.7101	1.4089
14	.0526	1.6078	1.5912		1.6409	1.643	1.4586
15	.0526	1.5746	1.5083		1.6244	1.5089	1.4752
16	.0526	1.5581	1.4586		1.5746	1.4754	1.2597
17	.0526	1.4255	1.3757			1.4083	1.4918
18	.0876	1.2431	1.326			1.3413	1.3592
19	.1052	.1052	.0876	.7625		.0701	.1052
20	.1052	.0876	.1052	.9116		.0876	.1227
21	.0701	.0876	.1052	.0876		.1052	.1052
22	.0876	.0876	.0876	.0876		.1052	.0876
23	.0701	.0701	.0876	.0701		.0876	.1052
24		.0876	.0701	.0724	.0701		
Max	.1052	1.7939	1.6907	.9116	1.6409	1.7436	1.6078
Min	.0526	.0701	.0526	.0526	.0701	.0701	.0876
Avg	.0713	.5806	.5549	.1886	.6082	.6105	.9317

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 202 / 11 KV MHASADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3149	.3647	.3315	.3481	.3391	
2		.3647	.3978	.3315	.3647	.3391	
3		.4144	.431	.3481	.3812	.3561	
4		.5138	.5801	.3812	.4807	.407	
5		.7293	.7293	.6464	.663	.5365	
6				.7293		.7712	
7				.8453		.8048	
8				.7956			
9	.5304	.7042	.663		.8453	.6874	
10	.4973	.5868	.6299		.5636	.5533	
11	.4144	.4409	.4641		.4807		.5967
12	.3149	.407	.4144		.4475	.4359	.3978
13	.3149	.3647	.3481		.3978		.3647
14	.3647	.3481	.3647		.3481	.3185	.3481
15	.3647	.3647	.3647		.3647	.3353	.3812
16	.3481	.3978	.3812		.4144	.3521	.431
17	.3812	.3812	.3978			.4024	.4475
18	.431	.431	.431			.4359	.4973
19	.6962	.7625	.5138	.7956		.4862	.7625
20	.5967	.5967	.5967	.7459		.5365	.6299
21	.4973	.4807	.4807	.6464		.5197	.4144
22	.4475	.4144	.3978	.4973		.4191	.4807
23	.3315	.3481	.3812	.3978		.3688	.3978
24		.3149	.3315	.3481	.3315		
Max	.6962	.7625	.7293	.8453	.8453	.8048	.7625
Min	.3149	.3149	.3315	.3315	.3315	.3185	.3481
Avg	.4354	.4610	.4602	.56	.4594	.4702	.4730

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 203 / 11 KV kakani

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0111	1.1934	1.1271	1.1934	1.073	
2		1.0111	1.1934	1.1768	1.1271	1.073	
3		1.0277	1.21	1.2266	1.094	1.1568	
4		1.0774	1.2431	1.3592	1.1437	1.2407	
5		1.1105	1.3592	1.6244	1.2266	1.3748	
6		1.3748	2.1714	1.7238	1.8564	1.8107	
7		1.643	2.3537	2.2708	2.0719	2.1795	
8		1.7604	2.3371	2.304	2.0056	2.0287	
9	.5258	.298	.4031		.3155	.4207	
10	.2629	.2103	.298		.1928	.3681	
11	2.0553	.1753	.2454		.1578	.1578	.1753
12	2.2045	.1402	.1928		.1402	.1402	.1402
13	2.0222	.1402	.1578		.1402	.1227	.1578
14	2.0056	.1578	.1578		.1402	.1227	.1578
15	1.757	.1402	.1578		.1753	.1402	.1402
16	1.7404	.1753	.1753		.2103	.1578	.1578
17	1.6244	.1753	.1753			.1928	.1928
18	1.6907	.2454	.1928			.2804	.2454
19	.6135	.5434	.3155	.5784		.3681	.5434
20	.5434	.5258	.5083	.5609		.5083	.5258
21	.4733	.4557	.5609	1.0608		.5434	.4908
22	.4733	.4382	.4557	1.2597		.4557	.4733
23	1.0111	1.1934	1.0608	1.21		1.1401	1.2266
24		1.0111	1.1934	1.0442	1.2266		
Max	2.2045	1.7604	2.3537	2.304	2.0719	2.1795	1.2266
Min	.2629	.1402	.1578	.5609	.1402	.1227	.1402
Avg	1.2669	.6684	.8047	1.3233	.8481	.7416	.3559

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 204 / 11 KV DHAMNAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4641	.7842	.8802	.7202	.7202	
2		.4641	.7362	.8962	.6241	.7202	
3		.4481	.6882	.9762	.5761	.7682	
4		.4961	.7362	1.0883	.5921	.8162	
5		.5601	.7682	1.2163	.7522	1.0883	
6		1.0883	1.6324	1.3283	1.7604	1.5684	
7		1.3443	1.7764	1.8404	1.6804	1.9364	
8		1.2323	1.5684	1.2483	1.4243	1.4243	
9	.032	.048	.048		.032	.032	
10	.032		.032		.032	.032	
11	1.8244		.032		.032	.032	.032
12	1.7764		.032		.032	.032	.032
13	1.5684	.032	.032		.032	.032	.032
14	1.4883	.032	.032		.032	.032	.032
15	1.2643	.032	.032		.032	.032	.032
16	1.2483	.032	.032		.032	.032	.032
17	1.3923	.032	.032			.032	.032
18	1.1683	.032	.032			.032	.032
19	.064	.048	.048	.032		.048	.048
20	.064	.048	.048	.064		.048	.064
21	.048	.048	.048	.048		.032	.048
22	.032	.032	.032	.032		.032	.032
23	.5441	.8962	.8162	.8322		.7042	.7042
24		.4641	.8162	.8642	.7202		
Max	1.8244	1.3443	1.7764	1.8404	1.7604	1.9364	.7042
Min	.032	.032	.032	.032	.032	.032	.032
Avg	.8365	.3749	.4514	.8105	.5356	.4446	.0886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094039 / 33/11 KV MHASADI

Feeder No / Name : 205 / 11 KV CHINCHKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3547	.3547	.3547	.2987	.2987	
2		.3547	.3547	.3547	.2987	.2987	
3		.3547	.3547	.3547	.2987	.2987	
4		.3921	.3734	.3734	.3174	.3547	
5		.4294	.4108	.4294	.3547	.3921	
6		.5194	.4108	.4668	.4668	.4481	
7		.5014	.4294	.3921	.5228		
8		.394	.3547	.3547	.4108	.4294	
9	.1494	.3734	.3921		.3174	.3361	
10	.1307	.2614	.3361		.4108	.2614	
11	.112	1.9418	1.9978		2.2032	2.2032	2.1472
12	.0934	2.2565	2.2592		2.2592	2.1472	2.1472
13	.112	2.2032	1.9605		1.9978	1.9978	1.8111
14	.0934	1.5123	1.8298		1.8484	1.7177	1.643
15	.1307	1.7364	1.7924		1.7177	1.587	1.5497
16	.112	1.8671	1.5684		1.643	1.531	1.7737
17	.1494	1.9231	1.4937			1.4937	1.8111
18	.168	1.587	1.4003			1.4563	1.4003
19	.4481	.4481	.4108	1.0456		.3921	.4294
20	.5415	.4668	.4854	1.587		.5415	.4668
21	.5415	.4854	.5788	.4668		.5601	.5228
22	.5228	.5228	.4854	.4854		.4668	.5041
23	.3734	.3361	.3547	.3547		.3921	.3361
24		.3547	.3361	.3547	.2987		
Max	.5415	2.2565	2.2592	1.587	2.2592	2.2032	2.1472
Min	.0934	.2614	.3361	.3547	.2987	.2614	.3361
Avg	.2452	.8990	.8635	.5268	.9215	.8911	1.2725

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 201 / 11 KV MALPUR GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3107	.3148	.3224	.3107			.275
2	.3437	.3134	.2968	.3093		.3639	.3093
3	.4488	.417	.3658	.3806		.3887	.4124
4	.5155	.6091	.5121	.5155		.6441	.519
5	.7612		.7316	.7218		.8596	.692
6	.8631	.857	.888	.8936		.9328	.9342
7	.9321		.8954	.928		.9593	.8631
8	.8631	.8968	.9372	.8592		.8238	.8592
9	.7595		.845		.8319	.7595	.7595
10	.66	.6211	.6228		.6626	.6221	.5556
11			.4488				
12			.4124				
13			.3806				
14			.3781				
15		.4326	.4143		.4568	.4147	.4524
16		.4364	.4468		.4726	.4833	.4191
17	.6096	.4825	.519		.5064	.5178	.4881
18	.5907	.578	.5536		.5525	.5869	.5545
19	.6321		.6559	.7905	.8368	.7905	
20	.6033	.6647	.749	.8735	.8037	.6904	
21	.4987	.5187	.6574	.6674		.5155	.572
22	.4768	.4508	.6214		.506	.4468	.5168
23	.4065		.5155	.3827		.4488	.386
24	.3789	.6154	.5178	.4143	.3448	.362	.4498
Max	.9321	.8968	.9372	.928	.8368	.9593	.9342
Min	.3107	.3134	.2968	.3093	.3448	.362	.275
Avg	.5919	.5472	.5703	.6190	.5974	.6111	.5566



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 202 / 11 KV NAWADNE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.588	1.7901	1.4986	1.7261			.0518
2	1.5863	1.571	1.7372	1.7529		.0549	.0518
3	1.6261	1.5656	1.7551	1.7529		.0732	.0516
4	1.6953	1.3959	1.7013	1.7872		.0758	.0516
5	1.8683		1.5638	1.7587			
6	2.0368	1.4934	1.5782	1.7185			
7	2.0622		1.749	2.0759			
8	2.0759		1.8031				
10		1.8827					
11						2.2489	2.4926
12						2.7587	2.417
13						2.7333	2.3179
14						2.4219	2.2299
15						2.4565	2.3005
16						.4844	2.3392
17							2.0767
18			.0346				1.9822
19	.0378	.0724	.0344	.0567	.0379	1.8642	
20	.0378	.0754	.0352	.0566	.0761	2.0622	
21	.0378	.0943	.0345	.0568		.0345	.0566
22	.0378	.0757	.0229		.0761	.0344	.0566
23	1.5985		1.588	1.6887		.0345	.0566
24	1.6571		1.4952	1.7261	1.7304	.0554	.0345
Max	2.0759	1.8827	1.8031	2.0759	1.7304	2.7587	2.4926
Min	.0378	.0724	.0229	.0566	.0379	.0344	.0345
Avg	1.2818	1.0017	1.1087	1.3464	.4801	1.1595	1.1604

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 203 / 11 KV GANESHPUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0518	.037	.0648	.069		.6958	1.4531
2	.0687	.0367	.0643	.0687		.7362	1.4877
3	.0692	.0336	.0655	.0692		.7682	1.5123
4	.0692	.0335	.0652	.0692		.7954	1.5466
5						.8133	1.6261
6						.8292	1.6841
7							2.0023
8							2.234
9						2.0368	
10						2.2785	
11	2.7037	2.3282	2.3475		2.5738		
12	2.5649	2.6673	2.382		2.7412		
13		2.2809	2.4219		2.5396		
14		2.259	2.2684		2.5252		
15		2.3457	2.2143		2.6642		
16		2.1939	1.7529		2.531		
17	2.0854		1.6916		2.3786		
18	1.8687		1.7299		2.1578	.0346	
19	.0707	1.3146	.0518	1.658	.0671	.0516	
20	.0611	1.3224	.069	1.6228	.0666	.069	
21	.0747	.0652	.069	1.5178		.069	.0758
22	.061	.0652	.069		.0607	.069	.0759
23	.0556		.0518	.0558		1.3839	1.3491
24	.0345		.0375	.0518	.0556	.6257	1.4499
Max	2.7037	2.6673	2.4219	1.658	2.7412	2.2785	2.234
Min	.0345	.0335	.0375	.0518	.0556	.0346	.0758
Avg	.7028	1.2131	.9676	.5758	1.6968	.7504	1.3747

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 204 / 11 KV KASARE GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.521	.5197	.5238	.4876	.3437	.52	.2406
2	.5611	.5281	.5602	.5157	.3338	.5232	.275
3	.6839	.6186	.6072	.6124	.3506	.5691	.346
4	.7788	.7956	.7653	.702	.3772	.6775	.4812
5	.9389	.4473	.9347	.9085	.4862	.9043	.519
6	1.2185	1.1945	1.1444	1.1428	.6257	1.193	.653
7	1.3578	.6943	1.4009	1.3503	.7788	1.3401	.6214
8	1.3696	1.4375	1.5157	1.5013	.8612	1.4258	.6559
9	1.277	.6836	1.4016		1.3172	1.3594	.5524
10	1.0758	1.1421	1.1869		1.2595	1.1163	
11		.0076	.7832				.3923
12			.6571				.2497
13			.6256				.2497
14		.0564	.6152		.093	.0511	.2675
15	.4626	.885	.6042		.8829	.8337	.3019
16	.4336	.8385	.6353		.8694	.8671	.3352
17	.9219	.9318	.6982		.8753	.8831	.3509
18	1.017	1.0338	.8168		.9906	.9543	.3852
19	1.2281	.5975	1.086	1.4596	1.1153	1.0672	
20	1.2282	1.1177	1.2303	1.5653	1.0936	1.1008	
21	1.0166	.934	1.027	1.2985	.5716	.9801	.5554
22	.8036	.7994	.9419	.5967	.8543	.8451	.5033
23	.6293	.3506	.6597	.7971	.3688	.638	.2951
24	.4929	.8376	.535	.5782	.6174	.5466	.2076
Max	1.3696	1.4375	1.5157	1.5653	1.3172	1.4258	.6559
Min	.4336	.0076	.5238	.4876	.093	.0511	.2076
Avg	.9008	.7478	.8732	.9654	.7174	.8760	.4018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 205 / 11 KV KOKALE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953			
2		.0762			
4		.0762			
10					2.2291
11	2.3624				
19	1.6194		1.8099		
20	1.5242		1.848		
21	.1334		.1334		.1524
22	.1143				.2096
23	.1143		.1143		1.467
24				.0762	
Max	2.3624	.0953	1.848	.0762	2.2291
Min	.1143	.0762	.1143	.0762	.1524
Avg	.978	.0826	.9764	.0762	1.0145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094048 / 33/11 KV KASARE

Feeder No / Name : 206 / 11 KV MALPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1834	1.8508	2.0049	2.1282	1.2003	.1572	.0692
2	2.2086	1.812	1.9801	2.1583	1.1416	.1557	.0692
3	2.2005	1.7119	1.9792	2.1232	1.0966	.1556	.0687
4	2.2722	1.6982	1.9809	2.1644	1.1065	.1541	.0687
5	2.3935	.9717	1.9843	2.1883	1.169	.0991	
6	2.4677	1.8817	1.9981	2.3085	1.1744	.08	
7		1.1378		2.8267	.2225		
8	.1113	2.4608	.0107	3.0919	.013		
9	3.0322		3.2015		3.3797		
10	3.0011		3.5394		3.3443	.0229	
11						3.3659	1.5382
12						3.6732	1.4741
13						3.7764	1.5079
14						3.6488	1.4919
15						3.7867	1.4741
16						3.417	1.41
17						3.3737	
18			.1385			3.1821	
19	.2298	.125	.2045	.1987	.174	.1907	
20	.2729	.2708	.2343	.2175	.2358	.2296	
21	.2305	.223	.2326	.2236	.1288	.24	.1259
22	.2151	.1771	.2919	.2256	.1965	.2243	.1416
23	1.7151	1.1264	2.1666	2.1606	.1021	.2006	.0788
24	1.9918	1.2184	2.1238	2.2159	1.0991	.1558	.1038
Max	3.0322	2.4608	3.5394	3.0919	3.3797	3.7867	1.5382
Min	.1113	.125	.0107	.1987	.013	.0229	.0687
Avg	1.6350	1.1904	1.5045	1.7308	.9865	1.4424	.6873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 201 / 11 KV SHEWAGE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.6874	1.2483	1.1012	1.1843	.9907	1.0911
2	.3921	.6874	1.2308	1.0526	1.1363	.945	1.0437
3	.4715	.6874	1.1843	1.0526	1.1203	.884	1.0364
4	.5975	.7655	1.1523	1.0526	1.1203	.9297	1.004
5		.8436	1.2323	1.1498	1.2323	1.0311	1.1984
6		.9061	1.2492	1.2955	1.3123	1.1092	1.3603
7			1.6762		1.7328		1.6356
8			1.8185	.7209	1.7976		1.5844
9		1.8461				1.9216	
10		1.8138				1.6975	
11	2.0645						
12	1.9826						
13	1.8842						
14	1.7532						
15	1.6221	.3018	.2801		.3547	.3018	.3174
16	1.6876	.3018	.3174		.3174	.3395	.2987
17	1.5893	.2652	.3206		.3395	.3018	.3018
18	1.3916	.3113	.3395			.3206	.6979
19	.7167	.639	.6979	.6979	.7545	.6413	.6979
20	.7167	.5761	.7167	.7922	.7167	.6413	.5658
21	.6224	.5658	.547	.6036	.5658	.5847	.5658
22	.547	.4715	1.1984	.4715	.4715	.4527	.4338
23	.703	1.3763	1.1984	1.4083	1.1279	1.2955	.9488
24	.3395	.6874	1.3123	1.1336	1.2643	1.0669	1.2176
Max	2.0645	1.8461	1.8185	1.4083	1.7976	1.9216	1.6356
Min	.3395	.2652	.2801	.4715	.3174	.3018	.2987
Avg	1.0810	.7630	.9845	.9640	.9734	.8586	.8889

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 202 / 11 KV PARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3768	.0819	.0983	.1147	.0983	.0983	.116
2	.3605	.0848	.0983	.1147	.0983	.1147	.1326
3	.3441	.0983	.1147	.1147	.1147	.1311	.1341
4	.3932	.1147	.1311	.1311	.1311	.1638	.1341
5	.426	.1475					
6	.5079	.213					
7		.2949					
8		.213					
9	1.1797	.1966					
10	.8619						
11		1.0526	.9878		1.085	.9231	.8583
12		1.0442	.9717		1.0202	.9393	.7125
13		.9831			.8259		.6154
14		1.0277			.7611		.5992
15	.0509	.5365	.8583		.6478	.4534	.5121
16	.1017	.7293	.8583		.6802	.4372	.5668
17	.0972	.7537	.8421		.8421	.759	.6554
18	.1296	.7537	.7935			.8855	.5735
19	.1943	.2458	.6299	.8097	.2155	.6802	.2294
20	.1619	.1989	.6554	.8097	.1989	.4858	.1475
21	.1296	.1311	.1341	.7045	.1658	.1475	.1475
22	.1147	.1147	.1147	.5735	.1311	.1326	.1341
23	.0819	.0983	.0983	.1147	.1147	.116	.1341
24	.3932	.0819	.0983	.1147	.0983	.0983	.1006
Max	1.1797	1.0526	.9878	.8097	1.085	.9393	.8583
Min	.0509	.0819	.0983	.1147	.0983	.0983	.1006
Avg	.3281	.3998	.4678	.3602	.4252	.4104	.3613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

PIMPALNER[211]

BU 0582

Substation No/ Name :- 094049 / 33/11 KV BALHANE

Feeder No / Name : 203 / 11 KV SHEWDIPADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	.1147	.3768	.2622	.2949	.213	.4111
2	.0492	.1147	.3277	.2458	.2622	.1966	.3953
3	.0492	.1147	.3441	.2294	.2622	.1802	.4161
4	.0492	.1147	.3605	.2622	.3113	.1638	.4534
5		.1311	.3768	.3277	.3113	.1638	.421
6		.1311	.4696	.3605	.3768	.1966	.4858
7		.2949		.6554		.4588	
8		.426					
9		.0492	.8192		.8684		.9555
10		.0503	.7209		.7537		.8322
11	.8684						
12	.8907						
15	.8848	.0503	.0492		.0492	.0486	.048
16	.8848	.0497	.0492		.0492	.0486	.048
17	.7045	.0497	.0503		.0503	.0492	.0492
18	.6226	.0492	.0503			.0655	.0492
19	.5407	.064	.0663	.0655	.0838	.0983	.0819
20	.3605	.064	.0829	.0983	.1006	.0983	.0983
21	.0655	.0655	.0829	.0655	.0838	.0983	.0983
22	.0655	.0655	.0655	.0655	.0819	.0838	.0671
23	.1311	.4096	.3277	.3605	.2458	.4372	.3239
24	.0492	.1311	.4096	.2949	.3441	.2294	.4534
Max	.8907	.426	.8192	.6554	.8684	.4588	.9555
Min	.0492	.0492	.0492	.0655	.0492	.0486	.048
Avg	.3916	.127	.2794	.2533	.2664	.1665	.3160



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 201 / 11 KV PINJARZADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0576	.897	1.0288	1.1774	1.2131	.9602	1.1323
2	.9774	.8126	1.0288	1.0167	1.1323	.9602	1.0512
8	1.1376	1.2681	1.5242	1.7449	1.7583	1.6804	1.5931
9	1.4643	1.6251	1.5924		1.7583	1.6804	1.7798
10		1.5242			1.7583	1.6605	1.3717
11		1.5242			1.6804	1.6537	1.448
12		1.3717			1.2803	1.6499	1.3717
13		1.2193	1.4916		1.4403	1.4402	1.2193
19		1.0669	.831	1.6175	1.5203	1.5402	1.5432
20		1.3717	1.3664	1.4558	1.6004	1.5766	1.6289
21		1.3717	1.3649	1.6175	1.5364	1.4043	1.5432
22		1.286	1.3425	1.5852	1.3443	1.37	1.3717
23		1.166	1.2986	1.4746	1.1203	1.2031	1.286
24	1.1416	.9785	1.1145	1.1645	1.278	.9602	1.1176
Max	1.4643	1.6251	1.5924	1.7449	1.7583	1.6804	1.7798
Min	.9774	.8126	.831	1.0167	1.1203	.9602	1.0512
Avg	1.1557	1.2488	1.2712	1.4282	1.4586	1.4100	1.3898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 202 / 11 KV MALANGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0488	1.2003	.9392	1.5242	.057	.1477
2	.0653	1.3717	1.2334	1.4449	.0761	.1474
3	.0677	1.3717	1.3775	1.5242	.0951	
4	.0674	1.3717	1.3907	1.5242	.0951	
5		1.4575	1.7049	1.6194		
6		1.4575	1.9589	1.7909		
7		1.5384	2.5339	2.3815		
8		1.9814	2.4148			
9				3.1028		
10				2.7378	.2858	
11					.2667	2.5911
12					3.1471	2.713
13	1.6766				2.7664	2.6673
14					2.6981	2.5149
15	1.829				2.6292	2.4387
16	1.9814				2.6673	2.5149
17	2.1338				3.1626	2.4387
18	1.829				2.8636	1.829
19	.0914		.0762	.0513	.1858	.1296
20	.0762		.0762	.057	.1858	.1543
21	.0857		.0722	.0951	.2225	.1372
22	.0857		.0761	.0761		.1372
23	.0686		.0761	.0761	.1844	.12
24	.0508	.0686		.0761		.1477
Max	2.1338	1.9814	2.5339	3.1028	3.1626	2.713
Min	.0488	.0686	.0722	.0513	.057	.12
Avg	.6772	1.3132	1.0715	1.2054	1.2699	1.3018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 203 / 11 KVDAHIWEL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8116	.8173	.0514		.0467	.7783	.9194
2	.8624	.9854	.0514		.0467	.8561	.9339
3	.8718	.9797	.0514		.0623	.8561	
4	.9545	1.0737	.0686		.0779	.9339	1.118
5	1.0989	1.1788				1.0896	1.2141
6	1.2788	1.3376				1.2452	1.3683
7	1.7541	1.9479				1.7122	2.3072
8	2.2005	2.4463				2.257	2.5223
9	2.0681	2.3863					2.5501
10	1.893	1.829				1.8558	1.829
11					2.672		
12					2.753		
13			2.7627		2.753		
14			2.8066		2.5101		
15			2.6758		2.2672		
16			2.4431		2.2672		
17			2.3032		2.2672		
18			1.9733		2.1052		
19	.0848	.0457	1.2342	.0467	.0648	.0941	.0514
20	.0683	.061		1.3231	.0648		.0686
21	.0677	.0686		.0623	.0648		.0514
22	.0506	.0686		.0623	.0648		.0514
23	.0506	.0514		.0623	.0762		.0514
24	.0652	.0512	.0514		.0467	.0648	
Max	2.2005	2.4463	2.8066	1.3231	2.753	2.257	2.5501
Min	.0506	.0457	.0514	.0467	.0467	.0648	.0514
Avg	.8863	.9580	1.3728	.3113	1.1228	1.0676	1.0740

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 204 / 11 KV DAHIWEL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8806	.8944	.9073	.952	.9814	.9136	.4696
2	.8834	.907	.9096	.9398	.9692	.9327	.4696
3	.9677	1.0058	.9301	.9756	.9822	.9441	.5057
4	1.1122	1.1445	1.073	1.059	1.1024	1.0818	.578
5	1.4259	1.4258	1.3904	1.6099	1.504	1.455	.6863
6	1.8898	2.0184	1.9307	2.2378	2.1624	2.2002	1.0114
7	2.6389	2.709	2.6707	2.7962	2.758	2.8338	1.3727
8	2.382	2.5793	2.2832	2.6804	2.6894	2.6167	1.2643
9	1.684	1.9316	2.0405		1.8126	1.8843	.7225
10							.381
11							.381
12	.6043	.7362	.6874		.743	.6645	.4268
13	1.0735	1.3199	1.477		1.3887	1.3414	.4268
14	1.038	1.3931	1.3228		1.3909	1.2969	.4572
15	.889	1.2254	1.214		1.2822	1.3376	.4877
16	1.1796	1.2186	1.3445		1.3833	1.3544	.4877
17	.7545	1.227	1.3795		1.4914	1.4686	.6097
18	.8794	1.3322	1.5071	1.0905	1.6808	1.5029	.6097
19	.9861	1.6346	1.802	2.4985	2.0028	1.9912	.823
20	.9328	1.5387	1.6068	2.2098	.9419	1.7621	.6859
21	.7567	1.3413	1.3114	1.7916	1.4453	1.443	.6173
22	.5655	1.2616	1.196	1.4476	1.3012	1.2212	.6001
23	.5289	1.0288	1.0483	1.2181	1.0714	1.0666	.5144
24	.9088	.9071	.9263	1.0556	1.0049	.9586	.5057
Max	2.6389	2.709	2.6707	2.7962	2.758	2.8338	1.3727
Min	.5289	.7362	.6874	.9398	.743	.6645	.381
Avg	1.1346	1.3991	1.4072	1.6375	1.4586	1.4669	.6289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 205 / 11 KV MALANGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1625	.1696	.1715	.2286	.2286	.2286	.2286
2	.1629	.1705	.1715	.1905	.1905	.1715	.1905
3	.1631	.1629	.1886	.1524	.1905	.1715	.1905
4	.1925	.1957	.1886	.1905	.1905	.1905	.1905
5	.219	.2438	.1715	.2286	.2286	.2286	.2286
6	.2386	.3266	.2915	.3048	.2286	.3048	.3048
10	.1154	.2134			.1905		.2134
11	.1642				.2667		.1981
12	.1623				.2667	.2667	.1981
13	.1625	.1829	.3048		.2667	.2667	.1981
14	.1591		.3048		.2667	.1905	.1829
15	.2115	.1677	.3048		.2667	.1905	.1829
16	.2113	.1981	.3048		.2667	.1905	.1829
17	.2125	.1981	.3048		.3048	.2286	.1829
18	.2438	.2286	.3429		.3429	.2667	.1981
19	.2118	.2439	.3048		.3429	.3429	.2915
20	.2275	.2439	.2858	.381	.7766	.3429	.2743
21	.2429	.2743	.3048	.3429	.3429	.3429	.2572
22	.2286	.2572	.3048	.3239	.3048	.3048	.2572
23	.1886	.2229	.2667	.2286	.2667	.2667	.2229
24	.1637	.1696	.2229	.2667	.1905	.2286	.2286
Max	.2438	.3266	.3429	.381	.7766	.3429	.3048
Min	.1154	.1629	.1715	.1524	.1905	.1715	.1829
Avg	.1926	.2150	.2633	.2580	.2819	.2487	.2192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 206 / 11 KV GHODADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.0512	.6859	.6497	.7202	.048	
2	.0815	.0682	.7716	.6533	.8002	.064	
3	.0814	.0649	.8573	.7549	.8002	.064	
4	.0814	.0652	.8573	.8013	.9602	.08	
5			.9431	.8836	1.1203		
6			1.0631	1.0602	1.2003		
7			1.1336	1.6914	1.9204		
8			2.21	2.5402	1.6804		
9			2.1948		2.2405		
10					1.7604		
11	2.516	2.2862				3.0674	2.5149
12	2.0111	2.2862				3.0075	2.4387
13	2.0334	2.1338				2.6852	2.2862
14	2.1152	1.829				2.3783	1.9814
15	2.0483	1.6766				2.2805	1.9052
16	1.8816	1.829				2.2742	2.0576
17		1.829					1.9814
18		1.6766					1.6766
19		.0762		.0645	.064		.0857
20		.0686		.0645	.064		.0857
21		.0686		.0645	.08		.0857
22		.0686		.0645	.064		.0686
23		.0514		.0647	.064		.0686
24	.0846	.0489	.0514		.064	.048	
Max	2.516	2.2862	2.21	2.5402	2.2405	3.0674	2.5149
Min	.0814	.0489	.0514	.0645	.064	.048	.0686
Avg	1.1836	.8988	1.0768	.7198	.8502	1.4543	1.3259

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094009 / 33/11 KV DAHIWEL

Feeder No / Name : 207 / 11 KV JAMBHORE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0551	.9785	.5144	1.105	1.2384	1.3336	1.5242
2	.9774	.9797	.5144	.8002	1.1431	.724	1.4098
3				.4572			
4				.4954			
5				.8002			
6				.9526			
7	1.7064	1.3641				1.9052	1.9814
8	1.8233	1.9502				2.4768	2.6673
9	2.1275	2.0433				2.3815	2.5911
10	1.8755	1.6766				2.191	1.6766
11					2.8578		
12					2.6673		
13			2.3243		2.6673		
14			2.3815		2.6673		
15			2.4196		2.2862		
16			2.2862		1.9052		
19	1.9662	1.448	2.2481	2.6673	2.2862	2.4387	2.0576
20	1.6232	1.3717	1.848	2.572	1.3336	2.0005	1.9719
21	1.5439	1.3717	1.5623	2.4768	1.7147	1.9052	1.7147
22	1.3878	1.2003	1.4861	2.191	1.5242	1.8099	1.5432
23	1.2189	1.1145	1.3717	1.9052	1.5242	1.7147	1.4575
24	1.1509	.9774	1.0288	1.2955	1.3336	1.3336	1.5623
Max	2.1275	2.0433	2.4196	2.6673	2.8578	2.4768	2.6673
Min	.9774	.9774	.5144	.4572	1.1431	.724	1.4098
Avg	1.5380	1.373	1.6655	1.4765	1.9392	1.8512	1.8465

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 201 / 11 KV ROSGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9323	2.4577				3.6866	2.6216
2	3.9323	2.4577				3.6866	2.6216
3	3.7685	2.6216				3.6046	2.7854
4	3.7685	2.9492				3.6046	3.0312
5	3.8504	3.2769				3.7685	3.195
6	3.8504	3.4408				3.7685	3.2769
7			4.7516	3.2769	4.5582		
8			5.1612	4.6696	5.8013		
9				4.5058	5.0554		
10				4.5058	4.8897		
11				4.0962	4.5582		
12			5.2431				
13	5.7347		5.0793				
14	4.26	5.9804				5.0793	5.2431
15	5.407	5.5708				5.325	5.5708
16	5.2431	5.325				5.0793	5.0793
17		4.9154				4.5877	4.9154
18	5.1612	4.342				4.4239	4.1781
19	5.0793		4.9154	4.0143	4.0609		
20			4.5877	3.7685	3.9781		
21			4.0143	3.8504	3.8952		
22			3.9323	3.6866	3.9781		.3277
23			3.8504	3.6046	3.7685		.3277
24	.3277			3.5227	3.3979	3.7685	.3277
Max	5.7347	5.9804	5.2431	4.6696	5.8013	5.325	5.5708
Min	.3277	2.4577	3.8504	3.2769	3.3979	3.6046	.3277
Avg	4.1781	3.9398	4.6150	3.9547	4.3583	4.1986	3.1073



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 202 / 11 KV NIJAMPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0974	1.0059	1.0974	1.0059	.9145	.9145
2	.9145	1.0974	1.1888	1.0974	1.0059	.9145	1.0974
3	1.0974	1.4632	1.4632	1.4632	1.0974	1.0974	1.3717
4	1.4632	1.4632	1.829	1.6461	1.4632	1.4632	1.6461
5	1.829	1.9204	2.1948	1.829	1.829	1.829	2.0119
6	2.1033	2.2862	2.3777	2.2862	2.1033	2.1948	2.1948
7	2.0119	2.1948	2.2862	2.2862	2.0119	2.1948	2.0119
8	1.829	2.0119	2.1948	2.0119	1.9204	1.829	1.9204
9	1.6461	1.6461		1.5546	1.829	1.7375	1.6461
10	1.5546	1.5546		1.5546	1.5546	1.5546	1.5546
11	1.4632	1.2803		1.4632	1.2803	1.4632	1.3717
12	1.5546	1.2803	1.5546	1.2803	1.2803	1.3717	1.3717
13	1.4632	1.0974	1.4632	1.3717	1.1888	1.2803	1.1888
14	1.2803	1.0974	1.2803	1.2803	1.1888	1.1888	1.1888
15	1.2803	1.2803	1.2803	1.2803	1.0974	1.2803	1.2803
16	1.2803	1.2803	1.3717	1.2803	1.2803	1.2803	1.2803
17		1.2803	1.3717	1.1888	1.3717	1.2803	1.1888
18		1.4632	1.6461	1.2803			
19	2.0119	1.829	1.9204	1.829	2.1948	2.1948	2.0119
20	2.1948	1.9204	1.829	1.9204	2.1033	2.1033	2.0119
21	1.7375	1.6461	1.6461	1.6461	1.7375	1.5546	1.6461
22		1.3717	1.3717	1.2803	1.0974	1.2803	1.4632
23		1.0974	1.0974	1.0974	1.0974	1.1888	1.0974
24	1.0059	1.0974	1.0059	1.0059	1.0059	.9145	.8954
Max	2.1948	2.2862	2.3777	2.2862	2.1948	2.1948	2.1948
Min	.9145	1.0974	1.0059	1.0059	1.0059	.9145	.8954
Avg	1.5318	1.4899	1.5895	1.5013	1.4672	1.4831	1.4942

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 203 / 11 KV VASKHEDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.4577	1.3108	1.6385		
2			2.4577	1.3108	1.6385		
3			2.4577	1.4746	1.6385		
4			2.4577	1.6385	1.6385		
5			2.6216	1.6385	1.9662		
6			2.4577	1.9662	2.0481		
7	3.2769	3.1493				3.0312	2.7854
8	3.6046	3.0664				3.3589	3.2769
9	3.6046	3.5637				3.4408	3.4408
10	3.6046	3.3979				3.3589	3.2769
11	3.3589	3.1493				3.1131	3.0312
12	3.2769						
14			3.5227	3.0312	3.7685		
15			3.2769	3.2769	3.7685		
16			3.4408	3.2769	3.5227		
17			3.4408	3.2769	3.6046		
18			2.8673	2.9492	3.195		
20	2.8673	2.9007				2.8673	2.8673
21	2.7035	2.9835				2.6216	2.7035
22	2.6216	2.9007				2.5396	2.5396
23	2.5396	2.652				2.4577	2.2939
24	2.2939		2.4577				2.3758
Max	3.6046	3.5637	3.5227	3.2769	3.7685	3.4408	3.4408
Min	2.2939	2.652	2.4577	1.3108	1.6385	2.4577	2.2939
Avg	3.0684	3.0848	2.8264	2.2864	2.5843	2.9766	2.8591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 204 / 11 KV DUSANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3758	1.4746				1.9662	1.7204
2	2.2939	1.4746				1.9662	1.8023
3	2.2939	1.4746				2.13	1.8842
4	1.9662	1.6385				2.2119	1.9662
5	2.13	1.9662				2.2119	1.9662
6	2.2939	2.2939				2.3758	2.2939
7	2.6216	2.6216				2.8673	2.5396
8	2.9492	2.9492				3.1131	2.7854
9	2.6216	2.7854				2.7035	2.6216
10	2.5396	2.4577				2.5396	2.2939
12			3.2769	3.195	3.3589		
13			3.3589	3.0312	3.195		
14			3.0312	3.0312	3.1131		
15			3.0312	2.9492	2.8673		
16			2.7854	2.6216	2.8673		
17			2.7854	2.6216	3.0312		
18			2.4577	2.5396	2.8673		
19			2.13	2.13	2.6216		
Max	2.9492	2.9492	3.3589	3.195	3.3589	3.1131	2.7854
Min	1.9662	1.4746	2.13	2.13	2.6216	1.9662	1.7204
Avg	2.4086	2.1136	2.8571	2.7649	2.9902	2.4086	2.1874

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 205 / 11 KV DUSANE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3658	.2743	.3658	.3658	.2743	.1829
2	.2743	.3658	.2743	.3658	.3658	.2743	.2743
3	.2743	.3658	.2743	.4572	.3658	.3658	.3658
4	.4572	.4572	.4572	.5487	.4572	.4572	.4572
5	.5487	.5487	.5487	.6401	.5487	.4572	.5487
6	.6401	.6401	.6401	.6401	.6401	.6401	.6401
7	.5487	.5487	.5487	.6401	.5487	.6401	.5487
8	.5487	.5487	.5487	.5487	.3658	.4572	.4572
9	.3658	.3658		.4572	.3658	.3658	.3658
10	.2743	.3658		.3658	.2743	.2743	.2743
11	.2743	.2743		.2743	.2743	.1829	.1829
12	.2743	.2743	.2743	.2743	.1829	.1829	.1829
13	.2743	.2743	.2743	.2743	.1829	.1829	.1829
14	.2743	.2743	.2743	.2743	.1829	.1829	.1829
15	.2743	.2743	.2743	.2743	.2743	.1829	.1829
16	.2743	.2743	.2743	.2743	.2743	.2743	.1829
17	.2743	.2743	.2743	.2743	.2743	.2743	.2743
18	.3658	.3658	.3658	.2743	.5487	.3658	
19	.5121	.4572	.3658	.4572	.5487	.5487	.4572
20	.5487	.5487	.4572	.5487		.4572	.4572
21	.5487	.4572	.4572	.4572	.4572	.3658	.3658
22	.3658	.3658	.3658	.3658	.3658	.3658	.3658
23	.3658	.2743	.3658	.3658	.3658	.2743	.2743
24	.3658	.3658	.2743	.3658	.3658	.3658	.2686
Max	.6401	.6401	.6401	.6401	.6401	.6401	.6401
Min	.2743	.2743	.2743	.2743	.1829	.1829	.1829
Avg	.3833	.3886	.3745	.4077	.3737	.3505	.3337

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 206 / 11 KV KHUDANE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	1.4746	1.9662	2.13	1.4746	1.3108	1.8842
2	.1638	1.4746	1.9662	2.13	1.4746	1.3108	1.8842
3	.1638	1.6385	2.4577	2.13	1.6385	1.4746	1.9662
4	.2458	2.4577	2.6216	2.6216	1.9662	1.7204	2.2119
5		2.7854	2.9492	2.7854	2.13	2.13	2.4577
6		2.9492	3.0312	2.9492	2.13	2.4577	2.6216
7		3.195	3.195	3.1131	2.8673	3.0312	2.7854
8		3.195	3.3589	3.0312	3.2769	3.3589	2.9492
9		2.4577		2.7854	3.0312	3.1131	2.7854
10		2.8673		2.7035	2.4577	2.7854	2.13
11	.9831						
17	.1638	.1638	.1638	.1638	.1638	.1638	.1638
18	.3277	.1638	.1638	.1638	.1638	.1638	.1638
19	.3277	.2458	.2458	.1638	.2458	.2458	.2458
20	.4096	.2458	.2458	.2458	.3277	.2458	.2458
21	.4096	.3277	.2458	.2458	.2458	.2458	.2458
22	.3277	.2458	.2458	.2458	.2458	.2458	.2458
23	.3277	.2458	.2458	.1638	.2458	.2458	.2458
24	.1638	.3277	.1638	1.8023	.1638	.2458	.1715
Max	.9831	3.195	3.3589	3.1131	3.2769	3.3589	2.9492
Min	.1638	.1638	.1638	.1638	.1638	.1638	.1638
Avg	.3214	1.4701	1.4542	1.6430	1.3472	1.3609	1.4113

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 207 / 11 KV WASDARA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.7404	1.3108	1.6385		
2			1.9062	1.4746	1.7204		
3			1.9062	1.4746	1.7204		
4			1.989	1.6385	1.7204		
5			1.989	1.9662	1.7204		
6			1.989	2.2939	1.7204		
7	2.7035	2.8673				2.8673	2.2939
8	.2458	2.6216				3.0312	2.6216
9	2.7854	3.0312				3.1131	2.9492
10	3.0312	3.1131				2.8673	2.8673
11	3.0312	2.7854				2.7035	2.7854
12	2.9492						
14			.4144	3.2769	3.195		
15			2.652	3.195	3.2769		
16			3.2322	2.7854	3.2769		
17			3.2322	2.7035	3.195		
18			2.4034	2.6216	2.7035		
19		2.5396				2.6216	2.3758
20	2.5396	2.6216				2.5396	2.2119
21	2.2939	2.2119				2.3758	2.13
22	2.2939	2.0481				2.13	1.9662
23	2.13	1.9662				2.2119	1.8023
24	1.7204	1.9662	1.9062				1.7204
Max	3.0312	3.1131	3.2322	3.2769	3.2769	3.1131	2.9492
Min	.2458	1.9662	.4144	1.3108	1.6385	2.13	1.7204
Avg	2.3386	2.5247	2.1134	2.2492	2.3534	2.6461	2.3385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094023 / 33/11 KV JAITANE

Feeder No / Name : 208 / 11 KV FOFADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.6385	1.3108	1.4746		
2			1.8842	1.3108	1.4746		
3			1.9662	1.4746	1.4746		
4				1.6385	1.6385		
5			2.0481	1.9662	1.9662		
6			2.13	2.13	2.0481		
7			2.4577	2.7854	2.7854		
8			2.7854	2.9492	.4915		
9				2.3758	1.1469		
10				2.0481	1.8842		
12	4.0962	3.195				3.2769	3.2769
13	3.2769	3.2769				3.3589	3.4408
14	3.2769	3.0312				3.3589	3.195
15	3.2769	2.8673				3.4408	2.7854
16	3.1131	2.8673				3.1131	2.8673
17	3.1131	2.8673				3.1131	2.8673
18	2.7854	2.6216				2.9492	2.5396
19	2.2119	2.0481				2.4577	1.9662
24				1.3108			
Max	4.0962	3.2769	2.7854	2.9492	2.7854	3.4408	3.4408
Min	2.2119	2.0481	1.6385	1.3108	.4915	2.4577	1.9662
Avg	3.1438	2.8468	2.1300	1.9364	1.6385	3.1336	2.8673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADEWEL

Feeder No / Name : 201 / 11 KV CHHADWEL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5623	1.9433	2.2939	1.8564	1.9433	2.2939	2.2939
2	1.5813	1.9433	2.2939	1.9204	1.9433	2.2939	2.2939
3	1.5813	1.9433	2.2939	1.9433	1.9433	2.2119	2.2939
4	1.6004	2.0243	2.2939	2.0081	2.1052	2.2119	2.2939
9	2.4615	2.7035	2.4577	2.5101	3.1855	2.13	1.9433
10	2.2771	2.2672	2.6216	2.4291	2.9007	1.9433	1.9204
11	2.2939	2.3482	2.332	2.0319	2.8178	1.8623	1.6194
12	1.9433	2.2634	2.2939	2.3482	2.8178	1.7004	1.406
13	2.7854	2.2672	2.4249	2.7206	2.652	2.7035	2.4034
14	2.7854	1.9433	2.6216	2.7206	2.8178	2.6216	2.4006
15	2.652	1.9433	2.4615	2.5301	2.8178	2.6216	2.4691
16	2.1862	1.9433	2.3685	2.4691	2.8178	2.6216	2.4034
19	2.7035	2.9007	2.6216	2.6825	2.7349	2.6216	2.5911
20	2.3205	2.6216	2.3967	2.4577	2.2939	2.4577	2.4905
21	2.0833	2.4577		2.3758	2.2939	2.2939	2.3205
22	2.1348	2.4577	2.3045	2.0243	2.2939	2.2939	2.0481
23	2.0005	2.4577	2.0241	1.9528	2.2939	2.2939	1.8623
24	1.5432	1.8976	2.4577	1.8785	1.9766	2.2939	2.2939
Max	2.7854	2.9007	2.6216	2.7206	3.1855	2.7035	2.5911
Min	1.5432	1.8976	2.0241	1.8564	1.9433	1.7004	1.406
Avg	2.1387	2.2404	2.3860	2.2700	2.4805	2.3039	2.1860



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADEWEL

Feeder No / Name : 202 / 11 KV BRAMANWEL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4232	1.5384	1.6194	1.7604	1.4403	1.6194	1.6194
2	1.4685	1.5384	1.6194	1.7924	1.4403	1.6194	1.5384
3	1.5181	1.5384	1.6194	1.8138	1.4403	1.6194	1.5384
4	1.5364	1.7004	1.6194	1.8351	1.6004	1.6194	1.5384
9			3.315	2.834	2.9835		
10			3.1493	3.1131	3.2322		
11			3.0803	2.8673	2.9007		
12			2.7206	2.4291	2.652		
13	3.2322	3.4808				3.0664	3.2322
14	2.9835	3.5637				2.9007	3.195
15	2.9492	3.315				2.8178	3.1131
16	2.7035	2.9835				2.652	2.9007
17	1.5623	2.7035				2.4577	2.6216
18	2.2138	2.4577				2.3758	2.2929
19			2.5934	2.8178	2.9835		
20			2.1765	2.4863	2.2939		
21	2.1548	2.1052	2.2024	2.0481	2.2939	2.2939	2.2377
22	2.1548	2.1862	1.9997	1.7604	2.2939	2.2939	2.0719
23	1.989	1.9433	1.9372	1.7604	1.9433	1.9433	1.989
24	1.5935	1.8023	1.7814	1.9006	1.6004	1.9433	1.7814
Max	3.2322	3.5637	3.315	3.1131	3.2322	3.0664	3.2322
Min	1.4232	1.5384	1.6194	1.7604	1.4403	1.6194	1.5384
Avg	2.1059	2.3469	2.2452	2.2299	2.2213	2.2302	2.2622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADEWEL

Feeder No / Name : 203 / 11 KV Titane

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0802	1.3279	1.6194	1.142	1.1145	1.4575	1.3717
2	1.1138	1.3279	1.6194	1.1728	1.1145	1.4575	1.3546
3	1.1728	1.3279	1.5384	1.1873	1.1145	1.3765	1.3717
4	1.2498	1.5203	1.5384	1.2163	1.2193	1.3765	1.3717
9	1.7814	1.7004	1.5384	1.3279	1.4403	1.7814	1.8404
10	1.8679	1.7814	1.4575	1.0279	1.2498	1.7814	1.6604
11	1.7204	1.7004	1.2967	.9116	1.1431	1.7004	1.8404
12	1.7204	1.7004	1.2018	.8697	1.1431	1.6194	1.6604
13	1.2651	1.2803	1.5203	1.4575	1.7004	1.6194	1.2651
14	1.4403	1.2803	1.5223	1.6194	1.6194	1.4575	1.2651
15	1.2651	1.2003	1.5384	1.4575	1.4575	1.2803	1.1069
16	1.1203	1.1203	1.4575	1.4575	1.4575	1.1203	1.0526
19	2.0309	2.1052	1.8747	1.7966	2.0481	2.0481	2.0309
20	1.6766	1.8623	1.5741	1.6004	1.7004	1.6194	1.8519
21	1.8747	1.9433	1.5546	1.4661	1.6194	1.6194	1.4661
22	1.6404	1.6194	1.4198	1.3117	1.5384	1.5384	1.3889
23	1.5813	1.6194	1.2498	1.3117	1.5384	1.4661	1.3117
24	1.0802	1.3889	1.6194	1.2498	1.2193	1.4661	1.3717
Max	2.0309	2.1052	1.8747	1.7966	2.0481	2.0481	2.0309
Min	1.0802	1.1203	1.2018	.8697	1.1145	1.1203	1.0526
Avg	1.4823	1.5448	1.5078	1.3102	1.4132	1.5436	1.4768

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094032 / 33/11 KV CHHADEWEL

Feeder No / Name : 204 / 11 KV BASAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.7621	.9145	.8322	.7811	.9374	.9755
2	.6706	.7621	.9145	.8223	.7811	.9374	.9145
3	.7407	.7621	.9145	.8223	.7811	.9374	.9145
4	.7407	.9374	.9145	.8322	.8592	.9061	.9145
5			.5944	.8745			
6			.5944	.9069			
9	1.6644	1.5384				1.6194	1.4899
10	1.6194	1.5546				1.5546	1.4232
11	1.4918	1.4251				1.4899	1.4746
12	1.1069	1.2955				1.3443	1.1717
13			1.4723	1.5746	1.6194		
14			1.2308	1.4746	1.5546		
15			1.3443	1.4403	1.4899		
16			1.2651	1.2498	1.4251		
17			1.2803	1.2346	1.3603		
18			1.2018	1.1288	1.2803		
19	1.4746	1.3443				1.2803	1.4089
20	1.2955	1.2163				1.1248	1.1797
21	1.0774	1.1248	.9602	.9945	.9998	1.1248	1.0059
22	2.1348	1.0623	.8962	.9012	.9998	1.0623	.9116
23	.9945	.9755	.8223	.9012	.9998	1.0623	.9116
24	.6958	.8097	.9145	.8322	.8192	.9998	.9755
Max	2.1348	1.5546	1.4723	1.5746	1.6194	1.6194	1.4899
Min	.6706	.7621	.5944	.8223	.7811	.9061	.9116
Avg	1.1698	1.1122	1.0147	1.0514	1.1251	1.1701	1.1194

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 201 / 11 KV CHAUPALE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1096	1.061	1.2253	1.1816	1.2689	1.0947	1.2803
2	1.0117	1.0646	1.1958	1.1789	1.2646	1.1478	1.2631
3	1.0288	1.0634	1.1958	1.1829	1.2517	1.2003	1.2003
4	1.1257	1.095	1.1998	1.2803	1.326	1.2163	1.2932
5	1.2203	1.1367	1.2801	1.2832	1.4404	1.3174	1.3074
6	1.4144	1.2684	1.3847	1.4866	1.5809	1.4205	1.4068
17	2.1269	2.1035	2.0713		1.905	1.7276	1.8861
18	2.1434	1.9478	2.2291		2.1767	2.3659	2.0576
19	2.0001	1.8189	2.0485	2.3765	1.9631	2.32	2.0576
20	1.6392	1.6861	1.6861	1.9176	1.6899	1.9071	1.8004
21	1.4147	1.4131	1.5141	1.9197	1.5158	1.905	1.5775
22	1.3458	1.4147	1.5158	1.8244	1.4397	1.6217	1.5432
23	1.2843	1.3458	1.3519	1.7299	1.2631	1.5192	
24	1.0622	1.28	1.2689	1.3717	1.1491	1.3519	
Max	2.1434	2.1035	2.2291	2.3765	2.1767	2.3659	2.0576
Min	1.0117	1.061	1.1958	1.1789	1.1491	1.0947	1.2003
Avg	1.4234	1.4071	1.5119	1.5611	1.5168	1.5797	1.5561

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 202 / 11 KV ROHOD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4716	.4716	.471	.4716	.5155	.4721	.5064
2	.4394	.4716	.4389	.4732	.4277	.4394	.5053
3	.4234	.4726	.4438	.5081	.4339	.423	.5408
4	.5133	.479	.4732	.5138	.4401	.5173	.6035
5	.6081	.4844	.5195	.6904	.5645	.6095	.6988
6	.7042	.5066	.6828	.7922	.7064	.7913	.7956
17	1.1816	1.1517	1.1145		1.3074	1.0105	1.1145
18	1.2346	1.1145	1.2442		1.5158	1.266	1.2346
19	1.0997	1.2154	1.0105	1.4435	1.2296	1.2126	1.1145
20	.8589	.979	.7622	.9661	.9577	.9389	.7716
21	.7242	.7444	.7596	.7426	.7819	.8688	.6859
22	.5901	.6591	.6729	.695	.676	.6965	.5144
23	.5396	.5389	.5915	.6595	.5908	.7026	
24	.4716	.4884	.5064	.6001	.5081	.5975	
Max	1.2346	1.2154	1.2442	1.4435	1.5158	1.266	1.2346
Min	.4234	.4716	.4389	.4716	.4277	.423	.5053
Avg	.7043	.6984	.6922	.7130	.7611	.7533	.7572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094042 / 33/11 KV JAMKHEL

Feeder No / Name : 203 / 11 KV SHIRSOLE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7052	1.6823	1.7704	1.6018	1.6899	1.5982	1.6054
2	1.6054	1.6337	1.7347	1.5477	1.5192	1.5512	1.6036
3	1.6217	1.6374	1.7386	1.5547	1.5449	1.5192	1.5495
7	2.4086	2.5084	2.3966	2.4112		2.5892	2.5949
8	3.0174	3.0933	3.1797	3.0274	.8211	3.2145	3.086
9	2.8355	2.8449	2.7404		.6778	2.7152	2.312
10	.9138	2.3148	2.0485		2.11	2.4863	1.7659
11					2.234		
18	2.954	2.7637	2.8183		2.9312	2.7374	2.4661
19	2.8277	2.8679	2.5377	3.1792	3.1581	2.9063	.3109
20	2.2307	2.3801	2.3579	2.3354	2.7039	2.3715	2.4863
21	2.0826	2.2257	2.2788	2.0462	1.939	2.1462	2.2291
22	1.9368	2.0042	2.1969	2.0279	1.9368	1.9727	1.8004
23	1.8884	1.882	2.11	1.8526	1.8505	1.9346	
24	1.8399	1.8399	1.8041	1.7704	1.6785	1.688	
Max	3.0174	3.0933	3.1797	3.1792	3.1581	3.2145	3.086
Min	.9138	1.6337	1.7347	1.5477	.6778	1.5192	.3109
Avg	2.1334	2.2627	2.2652	2.1231	1.9139	2.2450	1.9842

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094050 / 33/11 KV CHHAWADI

Feeder No / Name : 201 / 11 KV vehergaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8233	1.6766			1.2193	2.2862	1.9204
2	1.8233	.1677		.1219	1.2193	2.3472	1.9814
3	1.8896	1.768		.1219		2.3472	2.0119
4	1.9227			.1219		2.4387	1.9814
5	1.9227	1.7985		.1219		2.4387	1.9204
7			2.4813		2.4387		
8			3.1493		3.0483		
9			3.083		2.7435		
10			2.8349		2.7435		
11			2.8045		2.7435		
12			2.8654		2.8959		
13	3.0483	3.1493				2.9569	3.0483
14	1.7375	3.1824				3.0483	2.6825
15	2.8045	2.9835				3.0483	2.8959
16	2.774	2.7846				2.9569	2.8349
17	2.652	2.5526				2.9264	2.774
18	2.2862	2.3205				2.6825	2.652
19			1.9204	.6097	2.7435		2.652
20			2.1033	.6097	2.5911		
21				.4572	2.5911		.1829
22			2.0729	1.0669	2.4996		.1829
23	1.6461	1.5581	2.0119	1.0669	2.2862	1.9509	
24	1.8778			1.0669	1.0669	2.2862	1.9204
Max	3.0483	3.1824	3.1493	1.0669	3.0483	3.0483	3.0483
Min	1.6461	.1677	1.9204	.1219	1.0669	1.9509	.1829
Avg	2.1698	2.1765	2.5327	.5365	2.3450	2.5934	2.1094

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094050 / 33/11 KV CHHAWADI

Feeder No / Name : 202 / 11 KV Lonkhedi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1524	.1505	.1524	.1524		.1524
2	.1334	.1677	.1486	.1524	.1524	.1829	.1524
3	.1867	.1829	.2107	.1981	.1677	.2134	.1829
4	.2	.2134	.2408	.2439	.2134	.2439	.2134
5	.2	.2286	.2559	.2439	.2286	.2743	.2439
6					.2591		
9		.1505	.1158		.1219	.1524	.1524
10	.1524	.1505	.1524		.1981	.1829	.1829
11	.1524	.1158	.1677		.1829	.1219	.1829
15	.1372	.1158	.1219		.1524	.1219	.1219
16	.1677	.1158	.1524			.1524	.1677
17	.1524	.1158	.1524			.1715	.1829
18	.1677	.1448	.0152		.1677	.1524	.2134
19	.1981	.2027	.2134	.2896	.2591	.2134	.1981
20	.2286	.2317	.2439	.1677	.2286	.2134	.1981
21	.2134	.2172	.2134	.2134	.2134	.1829	.2134
22	.1981	.2258	.1981	.2134	.1677	.1524	.1829
23	.1524	.1806		.1829	.1524	.1524	
24	.1524	.1524	.1505	.1524	.1524	.1524	.1524
Max	.2286	.2317	.2559	.2896	.2591	.2743	.2439
Min	.1334	.1158	.0152	.1524	.1219	.1219	.1219
Avg	.1721	.1702	.1708	.2009	.1865	.1786	.182



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094050 / 33/11 KV CHHAWADI

Feeder No / Name : 203 / 11 KV Ghanegaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2452	.9145	.9755		
2			1.2452	.945	.9755		
3			1.2125	.945	.9755		
4			1.1797	.9755	1.0669		
5			1.1797	.9755	1.0669		
6					.9755		
7		1.3413				1.2003	1.3413
8	1.6766	1.6766				1.829	1.7375
9	1.768	1.9204				1.89	1.768
10	1.7375	1.7459				1.768	1.6766
11	1.6461	1.5653				1.4937	1.5851
12	1.5242	1.2944				1.2536	1.3413
13			1.89		1.829		
14			1.829		1.89		
15			1.6156		1.829		
16			1.6766		1.829		
17			1.5851		1.6766		
18			1.2803		1.448		
19	1.4632	1.5851				1.2003	1.3717
20	1.4022	1.5242		1.1888		1.4022	1.4327
21	1.3717	1.4327		1.2193		1.3717	1.2803
22	1.3413	1.5074		1.2193		1.2003	1.2498
23	1.0364	1.3108	.9145	1.2193	.7202	1.0136	
24		1.0364	1.2597	.9145			
Max	1.768	1.9204	1.89	1.2193	1.89	1.89	1.768
Min	1.0364	1.0364	.9145	.9145	.7202	1.0136	1.2498
Avg	1.4967	1.4950	1.3933	1.0517	1.3275	1.4202	1.4784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 201 / 11 KV DATARTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9762	.9175	.7537	.849	1.004	.9143	.9154
2	.9762	.9175	.7537	.849	1.0146	.8817	.9154
3	.9762	.9175	.7537	.849	1.0146	.8817	.9154
4	.9762	.9831	.7865	.849	1.0146	.8817	.9154
5			.9831	.8817	1.2321		
6			1.3108	.9143	1.3857		
7			1.3108	1.3062	1.5844		
8			1.9662	1.992	2.4019		
9			2.4806		2.6155		
10			2.027		2.9716		
11			1.8635		1.9593		
12	2.5072	.6211				1.9593	2.0805
13	2.0805	2.4291				2.3185	2.2405
14	2.0005	2.0243				2.2859	2.0805
15	1.9204	2.2348					2.1445
16	1.9204					1.992	2.2405
17	1.8023	2.2885				1.943	2.13
18	1.8023	1.9662				1.8613	1.9662
19	1.5074	1.4419	1.5693		1.796	1.5039	1.4746
20	1.3108	1.1142	1.3404	1.6654	1.3389	1.2423	1.1797
21	1.2125	.9831	1.177	1.4368	1.2082	1.0789	1.1469
22	1.0814	.9831	1.0462	1.1756	1.1103	1.0135	1.0486
23	.9831	.8848	.9481	.9797	.947	.9154	.9831
24	.9175	.8192	.8827	.947	.947	.8827	.9175
Max	2.5072	2.4291	2.4806	1.992	2.9716	2.3185	2.2405
Min	.9175	.6211	.7537	.849	.947	.8817	.9154
Avg	1.4677	1.3454	1.2914	1.1304	1.5027	1.4098	1.4879

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094058 / 33/11 KV SHEWALI

Feeder No / Name : 202 / 11 KV Tembhe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2512	.2515	.2201	.2343	.2656	.2346	.219
2	.2512	.2515	.2201	.2343	.2656	.2346	.2346
3	.2826	.2515	.2201	.2343	.2656		.2659
4	.2983	.2515	.2201	.2343	.2656	.2346	.2659
5			.2515	.2656	.3437		
6			.3144	.2968	.4218		
7			.3144	.3281	.5312		
8			.6287	.6562	.7968		
9			.6211		.9385		
10			.6249				
11			.5155				
12	.7143	.6211				.6726	.4658
13	.7764	.6211				.7802	.559
14	.9316	.5435				.7039	.5435
15	.9316	.4969				.5944	.4658
16	.4658					.5162	.4658
17	.4658	.4658				.5318	.4715
18	.4715	.4715				.5005	.3929
19	.4715	.3772	.4843		.6302	.4067	.3144
20	.4087	.3144	.3906	.4687	.5944	.3598	.2829
21	.3772	.2515	.3593	.4062	.438	.3598	.2515
22	.3144	.2515	.3125	.3281	.2972	.3285	.2201
23	.2515	.2515	.25	.2812	.2363	.2503	.1886
24	.2515	.1886	.2343	.2812	.2346	.219	.1886
Max	.9316	.6211	.6287	.6562	.9385	.7802	.559
Min	.2512	.1886	.2201	.2343	.2346	.219	.1886
Avg	.4656	.3663	.3636	.3269	.4350	.4330	.3409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094066 / 33/11 KV PINJARZADI

Feeder No / Name : 201 / 11 KV RAYKOT

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.779	.6859	.6859	.7621	.7011	1.0799	1.0526
2	.7318	.6859	.6859	.7316	.6706	1.0134	1.0037
3	.7651	.7316	.7621	.7011	.6706	1.0134	1.0037
4	.815	.9297	.8383	.7316	.7316	1.03	1.0371
5	.9647	.1067	.8383	.7926	.7621	1.0466	1.1141
6	1.2641	1.1888				1.3623	1.5389
7	1.6632	1.2651				1.6613	2.0575
8	1.5468	1.4327				1.5617	1.6337
9				1.5851	1.6766		
10			1.6156	1.4937	1.4784		
11			1.3108	1.3413	1.7278		
12			1.2193	1.1584	.9802		
13	.1402	1.5546				1.5284	1.3413
14	1.3413	1.448				1.5284	
15	1.2803	1.3108				1.5617	1.2193
16			1.0669	1.2193	1.4287		
17			1.4632	1.4937	1.545		
18			1.4022	1.4632	1.6447		
19	1.2193	1.1431	1.2193	.1097	1.2958	1.7776	1.2193
20	1.0364	1.1431	.1006	.945	1.2792	1.462	1.2193
21	1.0059	.9907	.9755	.9145	1.2792	1.2958	1.0669
22	1.0059	.9145	.945	.884	1.2626	1.2626	1.0669
23	.0914	.8383	.0914	.7926	1.1962	1.203	
24	.8815	.6859	.7621	.884		1.1131	1.1028
Max	1.6632	1.5546	1.6156	1.5851	1.7278	1.7776	2.0575
Min	.0914	.1067	.0914	.1097	.6706	1.0134	1.0037
Avg	.9725	1.0033	.9401	1.0002	1.1959	1.3236	1.2451

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094066 / 33/11 KV PINJARZADI

Feeder No / Name : 202 / 11 KV DEOJIPADA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8186	2.7221	2.5941	2.8029	2.7838	2.9901	1.3488
2	2.7111	2.668	2.5796	2.7153	2.7899	2.8911	1.3336
3	2.7223	2.6558	2.5675	2.7054	2.7762	2.9053	1.367
4	2.942	2.8364	2.9241	1.6026	1.6057	3.0005	1.467
5	3.3255	3.0262	3.2145	3.1054	2.7503	3.0109	1.5504
6	.1311	.7705	3.5284	3.4355	3.1932	.141	
7			3.9735	3.9324	2.3464		
8		.1974	4.1183	4.289	4.3134	.0427	
9	4.9896	5.1524	.1128			5.3747	2.5252
10	5.048	4.9908				5.0466	2.2253
11	4.4795	4.7713				4.5012	2.1491
12	4.0307	4.0886	.0351	.0282	.2317	4.0947	2.0576
13			5.1379	5.6668	5.0042	.0099	
14			5.1082	5.3285	4.9376		
15			4.875	5.0907	4.1916		
16	4.0832	3.7349	2.3952	2.5659	2.1704	3.8533	1.6766
17	4.651	4.4902				4.8879	1.9814
18	4.5809	4.2463	.0396	.0572		4.8989	1.6766
19	3.9537	3.6663	4.4986	3.9567	4.6948	4.1823	
20	3.6778	3.4042	4.0223	3.626	4.2477	3.8282	1.5242
21	3.5985	3.4286	3.661	3.2762	3.9097	3.6495	1.4022
22	3.5924	2.9485	3.5863	3.2846	3.6338	3.4569	1.4327
23	3.2914	2.8517	3.3447	3.0948	3.4205	3.3079	
24	3.0355	2.7694	3.0316	2.9378	2.9538	3.2334	1.4138
Max	5.048	5.1524	5.1379	5.6668	5.0042	5.3747	2.5252
Min	.1311	.1974	.0351	.0282	.2317	.0099	1.3336
Avg	3.5612	3.2710	3.1118	3.1751	3.2608	3.3003	1.6957

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 094066 / 33/11 KV PINJARZADI

Feeder No / Name : 203 / 11 KV PINJARZADI GAOTHAN

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.102	1.1469	1.1271	1.0783	.9267	1.1767
2	1.0822	1.1004	1.1325	1.009	.9092	1.1606
3	1.038	1.0844	1.1515	.9838	.9435	1.2186
4	1.0181	1.1896	1.1363	1.0029	.9755	1.2711
5	1.0197	1.2788	1.0837	1.0014	1.0014	1.2399
6	1.1706	1.4319	1.0562	.064	.3285	1.2308
7	1.6941	1.7444	.3841			1.6385
8	1.9799	1.8183		.0244	.0137	1.9532
9			1.8694	1.9227	1.9966	
10			2.0454	2.0675	2.1087	
11			2.0096	1.8115	1.9837	
12	.0472	.0251	1.7497	1.6834	1.5303	
13	1.6926	1.9906				1.7886
14	1.8648	1.9662				1.7193
15	1.736	1.7947				1.6895
16	1.4441	1.6979	1.0204	1.0661	1.0631	1.6811
17			1.7703	1.8656	1.8557	
18	.0366	.1448	1.7566	1.9029	1.9951	.0015
19	1.8785	1.9608	1.5333	1.4281	1.8999	1.9745
20	1.6354	1.8016	1.4708	1.4358	1.531	1.9197
21	1.3352	1.4685	1.2841	1.2346	1.4502	1.6027
22	1.307	1.3199	1.2468	1.1485	1.4502	1.4731
23	1.2704	1.2071	1.1858	1.0715	1.4586	1.4335
24	1.214	1.1934	1.1325	.9602	1.2399	1.3458
Max	1.9799	1.9906	2.0454	2.0675	2.1087	1.9745
Min	.0366	.0251	.3841	.0244	.0137	.0015
Avg	1.2783	1.3683	1.3573	1.2381	1.3331	1.4484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 097004 / 132 KV SAKRI

Feeder No / Name : 202 / 11 KV DATARTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048	.3048	.1524
3	.1524		.3048		.3048		.1524
4		.3048					
5	.3048		.3048		.3048		.3048
6				.3048			
7	.7621	.7621	.7621		1.0669	.9145	.7621
8				1.0669			
9	1.5242	1.5242	1.5242		1.6766	1.5242	1.5242
11	1.2193	1.0669	1.2193		1.5242	1.2193	.6097
13	.3048	.7621	.9145		1.0669	1.0669	1.0669
15	.7621		.9145				
16					1.0669		
17		1.2193					
19	.8078	.7621		.9145	.7621	.4572	.6097
20			.4572				
21						.4572	.6097
22		.3048	.3048		.3048		
24	.3048	.3048	.3048	.4572	.3048	.3048	.4572
Max	1.5242	1.5242	1.5242	1.0669	1.6766	1.5242	1.5242
Min	.1524	.3048	.3048	.3048	.3048	.3048	.1524
Avg	.6447	.7316	.6651	.6096	.7898	.7811	.6249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 097004 / 132 KV SAKRI

Feeder No / Name : 203 / 11 KV BHAMER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048	.3048	.3048
3	.3048		.3048		.3048		.3048
4		.3048					
5	.3048		.4572		.4572		.4572
6				.4572			
7	.7621	.7621	.7621		1.0669	.9145	.9145
8				1.0669			
9	1.2193	1.2193	1.0669		1.3717	1.2193	1.3717
11	1.0669	.9145	.9145		1.0669	.9145	.9145
13	.7621	.7621	.7621		.9145	.7621	.7621
14						.7621	
15	.7621		.7621				
16					.7621		
17		.9145					
19	.5335	.6097		.6097	.6097	.6097	
20			.4572				
21				.6097		.4572	
22		.3048	.3048		.3048		
24	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Max	1.2193	1.2193	1.0669	1.0669	1.3717	1.2193	1.3717
Min	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Avg	.6325	.6401	.5819	.5589	.6789	.6943	.6668



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 097004 / 132 KV SAKRI

Feeder No / Name : 204 / 11 KV CHHADWEL-P

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.6097	.6097	.7621	.7621	.7621
3	.6097		.6097		.7621		.7621
4		.8192					
5	.6097		.7621		.9145		.9145
6				.9145			
7	1.2193	1.0669	1.2193		1.3717	1.3717	1.3717
8				1.3717			
9	1.9814	2.1338	2.1338		2.2862	2.2862	2.1338
11	1.9814	1.9814	1.829		2.2862	2.1338	1.9814
13	.9145	1.5242	1.3717		1.829	1.829	1.6766
15	1.5242		1.3717			1.829	
16					1.829		1.9814
17		1.9814				2.1338	
19	1.2955	1.2193		1.3717	1.2193	1.3717	1.829
20			.9145				
21				.9145		.9145	.9145
22		.7621	.7621		.9145		
24	.7621	.6097	.6097	.7621	.7621	.7621	.7621
Max	1.9814	2.1338	2.1338	1.3717	2.2862	2.2862	2.1338
Min	.6097	.6097	.6097	.6097	.7621	.7621	.7621
Avg	1.1508	1.2708	1.1085	.9907	1.3579	1.5394	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE RURAL DIVISION[581]

SAKRI S/DN[212]

BU 0523

Substation No/ Name :- 097004 / 132 KV SAKRI

Feeder No / Name : 205 / 11 KV SAKRI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2003	1.0669	1.2003	1.3717	1.3717	1.3717
3	1.2003		1.2003		1.2003		1.2003
4		1.2003					
5	1.3717		1.3717		1.3717		1.3717
6				1.7147			
7	2.2291	2.2291	2.2291		2.0576	2.4006	2.4006
8				2.4006			
9	2.4006	2.4006	2.4006		2.572	2.4006	2.4006
11	2.0576	2.2291	2.2291		2.2291	2.2291	2.2291
13	1.8861	2.0576	2.0576		1.8861	1.8861	1.8861
15	1.8861		1.7147			1.8861	
16					1.8861		1.8861
17		2.0576				2.0576	
19	2.2805	2.0576		2.915	2.2291	2.0576	1.7147
20			2.0576				
21				2.4006		2.0576	2.0576
22		1.8861	1.7147		1.8861		
24	1.3717	1.3717	1.3717	1.8861	1.3717	1.3717	1.3717
Max	2.4006	2.4006	2.4006	2.915	2.572	2.4006	2.4006
Min	1.2003	1.2003	1.0669	1.2003	1.2003	1.3717	1.2003
Avg	1.8537	1.869	1.7649	2.0862	1.8238	1.9719	1.8082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 201 / LAMKANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8478	1.0288	1.0288	.8478		
8	1.0059	1.1336	1.0669	1.3413	1.2955		
11						1.1469	
12						1.1336	1.1869
15						1.1603	
16						1.0669	1.0174
24		.8573	1.0174	1.0288	.8573		
Max	1.0059	1.1336	1.0669	1.3413	1.2955	1.1603	1.1869
Min	.8573	.8478	1.0174	1.0288	.8478	1.0669	1.0174
Avg	.9316	.9462	1.0377	1.1330	1.0002	1.1269	1.1022

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 202 / BEHED AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.5144	.6783
8						.6478	.7545
12	.6783	.6478	.6097	.6783	.6478		
16	.6783	.4973	.6478	.6783	.663		
24						.6478	.6859
Max	.6783	.6478	.6478	.6783	.663	.6478	.7545
Min	.6783	.4973	.6097	.6783	.6478	.5144	.6783
Avg	.6783	.5726	.6288	.6783	.6554	.6033	.7062

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 203 / BURZAD Single phasing

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.5087	.3429	.3429	.5087	.8573	.8478
8	.8383	.6478	.9717	.5868	.8097	1.1336	1.1736
11						.3277	
12	1.0174	.9717	.9145	1.0174	.9717		.3391
15						.3315	
16	1.0174	.9945	.9717	1.0174	.9945	.3391	.3391
20	.5087	.6859	.6001	.5087	.6859	.7287	.5087
24	.3391	.3429	.3391	.4287	.3429	.8573	.8573
Max	1.0174	.9945	.9717	1.0174	.9945	1.1336	1.1736
Min	.3391	.3429	.3391	.3429	.3429	.3277	.3391
Avg	.6773	.6919	.69	.6503	.7189	.6536	.6776

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 204 / CHINCHWAR Single phasing SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6783	.6859	.6859	.6783	.3429	.4239
8	1.1736	1.1336	1.1336	1.3413	.9717	.4858	.503
11						1.3108	
12	.1696	.1619	.1524	.1696	.1619		1.0174
15						1.1603	
16	.1696	.1658	.1619	.1696	.1658	1.0174	1.0174
20	.3391	.5144	.5144	.3391	.5144	.4858	.5087
24	.6783	.6859	.6783	.6859	.6859	.5144	.4239
Max	1.1736	1.1336	1.1336	1.3413	.9717	1.3108	1.0174
Min	.1696	.1619	.1524	.1696	.1619	.3429	.4239
Avg	.5360	.5567	.5544	.5652	.5297	.7596	.6491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 205 / VADANA Single phasing

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6783	.6859	.6859	.6783	.1715	.1696
8	.8383	.9717	.9717	1.0898	1.0174	.1619	.1677
11						.9012	
12	.1696	.1619	.1619	.1696	.1619	1.0174	.8478
15						.8288	
16	.1696	.1658	.1715	.1696	.1658	.8097	.8478
20	.1696	.1715	.1715	.1696	.1715	.1619	.3391
24	.6783	.6859	.6783	.6859	.6859	.1715	.1715
Max	.8383	.9717	.9717	1.0898	1.0174	1.0174	.8478
Min	.1696	.1619	.1619	.1696	.1619	.1619	.1677
Avg	.4519	.4725	.4735	.4951	.4801	.5280	.4239

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 206 / LAMKANI BEHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1696	.1715	.1715	.1696	.1715	.1715
8	.3353	.3239	.3239	.2515	.3239	.3239	.3353
11						.1638	
12	.1696	.1619	.1524	.1696	.1619	.1619	.1696
15						.2486	
16	.1696	.1658	.1619	.1696	.1658	.2486	.1696
20	.3391	.1715	.3429	.3391	.1715	.3429	.3391
24	.1696	.1715	.1696	.1715	.1715	.1715	.1715
Max	.3391	.3239	.3429	.3391	.3239	.3429	.3391
Min	.1696	.1619	.1524	.1696	.1619	.1619	.1696
Avg	.2258	.1940	.2204	.2121	.1940	.2291	.2261



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094004 / 33/11 kv BORIS

Feeder No / Name : 207 / Nakumbhe ( Single Phasing) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.1696	.3429	.3429	.1696	.5144	.6859
8	.503	.3239	.6478	.503	.3239	.3239	.9221
11						.2458	
12	.8478	.8097	.7621	.8478	.6478	.2429	.1696
15						.2486	
16	.6783	.663	.6478	1.0174	.4973	.2286	.1696
20	.3391	.5144	.5144	.3391	.5144	.6478	.3391
24	.3391	.1715	.3391	.3429	.3429	.6478	.6859
Max	.8478	.8097	.7621	1.0174	.6478	.6478	.9221
Min	.3391	.1696	.3391	.3391	.1696	.2286	.1696
Avg	.5084	.4420	.5424	.5655	.4160	.3875	.4954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467] BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 201 / 11 KV Billadi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1738	.3357
2						.1738	.311
3						.1692	.3354
4						.1974	.3727
5						.2286	.3711
6						.4633	.5163
7						.5639	.8539
8						.5639	.6547
11	.8688	.6908	.7592	.719	.7964		
12	.8688	.7472	.6767	.6908	.8688		
13	.8398	.6344	.6438	.6344	.6661		
14	.5792	.4793	.819	.5075	.6371		
15	.5213	.4934	.5708	.4371	.5792		
16	.5792	.5216	.7461	.5216			
17	.5213	.578	.4554	.5498	.5792		
18	.5068	.4934	.5938	.4652	.4778		
23					.1738	.2854	.4054
24					.1738	.1692	.4054
Max	.8688	.7472	.819	.719	.8688	.5639	.8539
Min	.5068	.4793	.4554	.4371	.1738	.1692	.311
Avg	.6607	.5798	.6581	.5657	.5502	.2989	.4562

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 202 / NYHALOD Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3612	.3416
2						.3612	.3425
3						.3612	.3416
4						.3612	.5596
5						.3612	.427
6						.4666	.6974
7							.6074
8							.4566
11	.7225	.7225	.9326	.7074	.7676		
12	.7225	.6472	.8935	.6171	.6923		
13	.6321	.5418	.4829	.5268	.5213		
14	.5268	.5117	.6342	.4967	.5117		
15	.4816	.4816	.4839	.4967	.5117		
16	.5117	.4816	.5774	.4816	.4967		
17	.4816	.5117	.4554	.4816	.4816		
18	.4967	.5268	.4859	.5117	.4816		
22					.3311		
23					.3311	.4365	.4214
24					.3311		.4214
Max	.7225	.7225	.9326	.7074	.7676	.4666	.6974
Min	.4816	.4816	.4554	.4816	.3311	.3612	.3416
Avg	.5719	.5531	.6182	.5400	.4962	.3870	.4617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467] BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 203 / KAPADANE Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.271	.2115	.2347	.2569	.2054		
2	.3015	.2115	.2229	.2569	.2054		
3	.2737	.2115	.2229	.3254	.2054		
4	.2995	.2115	.2229	.3139	.2378		
5	.4198	.2256	.2347	.3139	.2494		
6	.4193	.3102	.2641	.373	.2787		
7	.5098	.4512	.4401	.3425	.4108		
8	.3898	.3525	.3814	.4476	.3668		
11						.5605	.3666
12						.5782	.423
13						.2846	.3384
14						.373	.3102
15						.0373	.2679
16						.3189	.282
17						.3341	.3102
18						.2588	.2115
22	.1692						
23	.1692	.2526	.1712	.2229			
24	.1692	.176	.2347	.1708			
Max	.5098	.4512	.4401	.4476	.4108	.5782	.423
Min	.1692	.176	.1712	.1708	.2054	.0373	.2115
Avg	.3084	.2614	.2630	.3024	.2700	.3432	.3137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 204 / Nyhalod Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3823	.3772	.4119	.3865	.394	.3772	.3823
2	.3865	.3772	.4119	.3865	.394	.3772	.3865
3	.3865	.3772	.4075	.3823	.3898	.4115	.3865
4	.4918	.3772	.4382	.527	.4382	.4458	.4216
5	.4929	.5144	.5258	.7124	.5609	.5144	.4918
6	.6337	.6859	.7186	.7026	.7362	.7373	.669
7	.6324	.6687	.7888	.7394	.7712	.6859	.6851
8	.7026	.4287	.5784	.5434	.6135	.5487	.4929
9	.4801	.3429	.4252	.5434	.4207	.3944	
10	.3944	.333	.3865	.3506	.3601	.3513	.3601
11		.3155	.3345	.2629	.3429	.2954	.2743
12		.2804	.3301	.2454	.3258	.2635	.2915
13		.298	.3265	.333	.2915	.2635	.2743
14	.3429	.298	.3162	.333	.2915	.2606	.2915
15	.3772	.3155	.3162	.3506	.2915	.2993	.3258
16	.3772	.3506	.3169	.3506	.3258	.2986	.3601
17	.4115	.3681	.3521	.3856	.3601	.3697	.3772
18	.4287	.4031	.3513	.3856	.3429	.3649	.3429
19	.5487	.5083	.4865	.5434	.4287	.3475	.583
20	.5144	.5083	.4918	.5316	.583	.3797	.5144
21	.3429	.4908	.4929	.5014	.5144	.3865	.4458
22	.4458	.4733	.4929	.4656	.4458	.4225	.4115
23	.3772	.4252	.4216	.4298	.3429	.417	.3772
24	.3772	.404	.4075	.394	.7369	.3823	.3429
Max	.7026	.6859	.7888	.7394	.7712	.7373	.6851
Min	.3429	.2804	.3162	.2454	.2915	.2606	.2743
Avg	.4537	.4134	.4387	.4494	.4459	.3998	.4125

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 205 / Kapadana Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0166	.0175	.0189	.0185	.0189	.0175	.0189
2	.0185	.0175	.0189	.0187	.0189	.0175	.0187
3	.0166	.0175	.0189	.0185	.0189	.0175	.0187
4	.0189	.0175	.0189	.0187	.0189	.0175	.0187
5	.0166	.0175	.0189	.0185	.0189	.0175	.0185
6	.0185	.0175	.0189	.0185	.0189	.0175	.0187
7	.0168	.0175	.0189	.0185	.0189	.0175	
8	.0187	.0175	.0189	.0187	.0189	.0175	.0189
9	.0175	.0175	.0189	.5445	.0189	.0175	
10	.0175	.0189	.0189	.0189	.0175	.0185	.0175
11	.0175	.0189	.0189	.0189	.0175	.0189	.0175
12	.0175	.0189	.0189	.0189	.0175	.0187	.0175
13		.0189	.0187	.0189	.0175	.0171	.0175
14		.0189	.0187	.0189	.0175	.0187	.0175
15		.0189	.0171	.0189	.0175	.0185	.0175
16	.0173	.0189	.0189	.0189	.0175	.0189	.0175
17	.0173	.0189	.0168	.0189	.0175	.0185	.0175
18	.0173	.0189	.0187	.0189	.0175	.0185	.0175
19	.0189	.0189	.0168	.0189	.0175	.0185	.0175
20	.0173	.0189	.0185	.0189	.0175	.0189	.0175
21	.0173	.0189	.0187	.0189	.0189	.0187	.0175
22	.0173	.0189	.0185	.0189	.0175	.0187	.0173
23	.0173	.0189	.0185		.0175	.0189	.0175
24	.0173	.0189	.0189	.0189	.0175	.0189	.0175
Max	.0189	.0189	.0189	.5445	.0189	.0189	.0189
Min	.0166	.0175	.0168	.0185	.0175	.0171	.0173
Avg	.0175	.0184	.0186	.0416	.0181	.0182	.0179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094006 / NYHALOD

Feeder No / Name : 206 / NAGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1214	.1494	.1494	.1867	.1214	.1494
2	.1509	.1214	.1494	.1509	.1867	.1214	.1494
3	.1494	.0693	.1494	.1494	.1867	.1214	.1478
4	.1848	.1214	.168	.1663	.1867	.1387	.1663
5	.1886	.1734	.1867	.1698	.2241	.1734	.168
6	.1867	.2427	.2801	.1867	.2829	.208	.2263
7	.2263	.2774	.3734	.1886	.3361	.2601	.2241
8	2.1125	.2601	.3174	.2263	.2241	.1734	.2263
9	.208	.208	.2241	.2263	.1867	.208	.208
10	.1753	.1867	1.6804	.1867	.1387	.1326	.1734
11	.1753	.1494	.1848	.0934	.1387	.1509	.1387
12	.1227	.1494	.1848	.1494	.1494	.1494	.104
13	.1227	.168	.1509	.1494	.112	.1478	.104
14	.1227	.1307	.1219	.1494	.1029	.1509	.1387
15	.1402	.1307	.1372	.1307	.1214	.1494	.104
16	.1753	.1307	.1494	.1307	.1387	.1307	.1387
17	.1753	.1494	.1509	.168	.1387	.132	.1387
18	.2103	.1494	.1478	.1867	.1387	.1698	.1734
19	.1753	.2241	.132	.2241	.1734	.1367	.208
20	.2454	.2241	.132	.2241	.208	.1698	.208
21	.1753	.1867	.1307	.1867	.1734	.1886	.1734
22	.1753	.1494	.132	.1867	.1387	.1886	.1402
23	.1402	.1494	.1307	.1494	.1214	.1494	.1387
24	.1402	.1494	.1494	.1341	.1494	.1307	.1214
Max	2.1125	.2774	1.6804	.2263	.3361	.2601	.2263
Min	.1227	.0693	.1219	.0934	.1029	.1214	.104
Avg	.2512	.1676	.2380	.1693	.1727	.1585	.1612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 201 / MOHADI PD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.4763	.6668		.4763	.381
2	.5716		.4763	.6668		.4763	.381
3	.5716		.4763	.7621		.4763	.381
4	.5487		.5144	.9127		.5704	.3944
5	.6173		.6001	1.0077		.6845	.4458
6	.7545		.7545	1.1385		.7606	.5144
7	1.046		1.0974	1.1385		.759	.8745
8	.9602		1.0974	1.1374		.7225	.7545
11	.7194	.6001	.7583	.7202	.6635	.9088	
12	.6921	.6097	.7583	.7194	.6635	.9774	
13	.6986	.4801	.8531	.695	.6635	.9602	
14	.7233	.4973	.7204	.6943	.6256	.823	
15	.6461	.5144	.5687	.6897	.6635	.823	
16	.6536	.5144	.6635	.6897	.7204	.7888	
17	.6361	.4801	.5687	.6897	.6642	.7545	
18	.5517	.4801	.5687	.7529	.4744	.6859	
23		.381	.6668		.4753	.3429	.4187
24		.4763		.6668		.4763	.381
Max	1.046	.6097	1.0974	1.1385	.7204	.9774	.8745
Min	.5487	.381	.4763	.6668	.4744	.3429	.381
Avg	.6852	.5034	.6835	.8087	.6238	.6926	.4926



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 202 / SANJAY AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	25-FEB-17	26-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145		.8565	
2		.9136		.8573	
3		.9136		.8755	
4		.9897		.8764	
5		1.142		.9526	
6		1.142		1.1431	
7		1.299		1.2411	
8		1.2942		1.142	1.0802
11					1.2371
12					1.0768
13					1.0928
14					.9107
15					.8688
16					.8624
17					.8343
18					.7255
23	.9526		.8573		
24				.5716	
Max	.9526	1.299	.8573	1.2411	1.2371
Min	.9526	.9136	.8573	.5716	.7255
Avg	.9526	1.0761	.8573	.9462	.9654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 203 / MOHADI PD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3388	.3429	.2641	.3276	.3018	.3048
2	.3429	.3388	.3429	.2641	.3807	.3018	.3048
3	.3086	.5647	.3429	.2815	.571	.3395	.3048
4	.3258	.5956	.3429	.3378	.5908	.4316	.2915
5	.3772	.6763	.4287	.4294	.6004	.4879	.4115
6	.5144	.6355	.5144	.5975	.5167	.5975	.4973
7	.4801	.618	.4801	.5788	.4844	.5601	.5144
8	.3429	.3823	.3429	.3511	.4152	.3734	.3601
9	.2572	.2847	.2743	.2658	.3445	.2926	.2401
10	.2368	.2477	.2378	.2411	.2835	.2229	.2241
11	.2257	.1715	.1829	.2411	.2149	.1886	.2241
12	.2154	.1715	.2378	.2603	.2149	.1886	.2249
13	.2241	.1715	.2378	.2575	.2353	.1715	.2241
14	.2417	.1715	.2561	.2759	.2328	.1886	.2067
15	.2586	.1715	.2743	.2756	.2303	.2058	.2239
16	.2756	.1715	.3292	.2595	.3224	.2743	.2595
17	.2586	.2058	.3292	.2756	.3258	.2829	.2768
18	.3276	.2572	.2926	.3276	.3439	.2743	.3174
19	.3979	.381	.4045	.4138	.4024	.4191	.3806
20	.3621	.4572	.3861	.3966	.3658	.4191	.3974
21	.3633	.4382	.3677	.3475	.3475	.3429	.397
22	.3612	.381	.3326	.3589	.3309	.3086	.3452
23	.3354	.362	.2772	.3093	.3142	.2915	.3388
24		.3429		.2815	.2542	.3018	.3048
Max	.5144	.6763	.5144	.5975	.6004	.5975	.5144
Min	.2154	.1715	.1829	.2411	.2149	.1715	.2067
Avg	.3207	.3557	.3286	.3288	.3604	.3236	.3156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 204 / Sanjay Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1523	.1334	.1463	.144	.1471	.1143
2	.1524	.1456	.1334	.1463	.1694	.1471	.1143
3	.1524	.2665	.1334	.1646	.2251	.1655	.1143
4	.1715	.2911	.1524	.1991	.3012	.1829	.12
5	.2058	.2954	.1715	.2172	.3236	.2195	.1715
6	.2572	.2899	.2572	.2865	.3033	.2896	.2572
7	.2401	.2911	.2058	.2743	.2417	.2715	.2743
8	.1543	.1934	.1543	.2353	.2174	.181	.1715
9	.1372	.139	.1417	.1578	.1882	.1595	.12
10	.1379	.12	.1417	.1378	.1214	.1372	.1211
11	.1557	.1029	.1595	.1207	.104	.1029	.1291
12	.1384	.0857	.1595	.1035	.104	.0857	.1211
13	.1384	.0857	.1595	.1211	.104	.0857	.1384
14	.1434	.0857	.1417	.1379	.1214	.12	.1384
15	.1436	.0857	.1772	.1381	.1387	.1029	.1384
16	.1451	.0857	.1595	.1373	.1387	.1029	.1384
17	.1557	.1372	.1791	.1379	.1417	.1029	.1384
18	.1207	.1543	.197	.2069	.1417	.1385	.1557
19	.1821	.1905	.1791	.2069	.1772	.1905	.1877
20	.1897	.1905	.1433	.2069	.1595	.1905	.2071
21	.1901	.1905	.144	.2001	.1612	.1543	.2076
22	.1713	.1524	.1629	.2094	.1433	.1029	.1901
23	.1456	.1334	.1448		.1629	.1029	.1728
24		.1334		.1463	.1089	.1463	.1143
Max	.2572	.2954	.2572	.2865	.3236	.2896	.2743
Min	.1207	.0857	.1334	.1035	.104	.0857	.1143
Avg	.1644	.1666	.1623	.1756	.1726	.1512	.1565

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094010 / NAVALNAGAR

Feeder No / Name : 205 / NAVRA-NAVRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0914	.1029	.1738	.0914		
2	.1143	.1029	.1029	.1738	.0914		
3	.1143	.1036	.12	.1882	.1029		
4	.1372	.1171	.1372	.2143	.1029		
5	.1715	.1691	.1524	.2589	.1372		
6	.1829	.2353	.2286	.2896	.2058		
7	.2286	.2515	.2439	.2751	.2172		
8	.2286	.2286	.2286	.2256	.1943		
11						.3258	.2172
12						.2896	.2172
13						.2286	.2058
14						.2439	.1943
15						.2743	.1943
16						.3048	.1829
17						.2896	.1943
18						.3201	.1829
23	.0914	.1143	.1738				
24		.1143	.1029	.1738	.0572		
Max	.2286	.2515	.2439	.2896	.2172	.3258	.2172
Min	.0914	.0914	.1029	.1738	.0572	.2286	.1829
Avg	.1537	.1528	.1593	.2192	.1334	.2846	.1986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 201 / FAGANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4115	.5487	.5144	.3772	.463	
2	.3772	.4115	.6001	.5144	.3772	.4801	
3	.3772	.4115	.6516	.5144	.4287	.5144	
4	.4801	.4801	.7202	.6516	.5487	.5658	
5	.6516	.583	.823	.823	.6859	.6516	
6	1.0288	.9602	.8916	1.2346	.823	.6859	
7	1.166	1.0974	.9602	.9088	.9602	.6859	
8	1.0631	1.1145	1.0288		.8916	.7716	
11							.7716
12						.9945	.9431
13							.6859
14							.6859
15						.8573	.6859
16							.6859
17							.8573
18						.583	.7716
23	.3772	.4287	.6859	.3772	.3429		
24	.3429	.3772	.5144	.6516	.3772	.4287	
Max	1.166	1.1145	1.0288	1.2346	.9602	.9945	.9431
Min	.3429	.3772	.5144	.3772	.3429	.4287	.6859
Avg	.6241	.6276	.7425	.6878	.5813	.6402	.7609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467] BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 202 / VARKHEDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.6859	.6859	.6001	.4287	.1029
2		.5144	.6859	.6859	.6001		.1029
3		.5144	.7888	.823	.6516		.12
4		.6173	.823	.8916	.6859		.1372
5		.823	1.0288	1.2003	.8916		.1372
6		1.0974	1.2346	1.406	1.2003		.1543
7		1.5089	1.3717	1.5432	1.286		.1543
8	1.2003	1.0802	1.2003	1.1145	1.0802		.1372
11		.2058	.12	.0343	.1372		1.2003
12	.1029	.1715	.1543	.0171	.1372		1.1145
13		.1715	.1372	.1715	.1372		.8573
14		.1372	.1372	.1715	.1372		.7716
15		.1372	.1029	.0686	.1372		.6859
16	.0857	.1372	.1029	.1372	.1372	.8916	.6859
17		.1029	.1029	.1372	.1372		.7716
18	.1029	.1029	.0686	.1029	.1372	.8573	.7716
23	.0069	.6173	.6859	.5658	.4287	.0686	.0686
24	.4801	.0686	.6173	.6516	.6001	.4287	.0686
Max	1.2003	1.5089	1.3717	1.5432	1.286	.8916	1.2003
Min	.0069	.0686	.0686	.0171	.1372	.0686	.0686
Avg	.3562	.4735	.5582	.5782	.5068	.5350	.4468

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467] BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 203 / ARNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0686
2							.0686
3							.0686
4							.0686
5							.1029
6							.1029
7							.12
8							.12
11	.0686	.1029	.0514	.0686	.0514		
12	.0686	.0857	.0514	.0514	.0857		
13		.0686	.0514	.0686	.0857		
14		.0514	.0514	.0686	.0686		
15		.0514	.0686	.0514	.0686		
16	.0514	.0686	.0686	.0686	.0686		
17		.0686	.0857	.0686	.0514		
18	.0514	.0514	.0686	.0514	.0514		
23						.0514	.0514
24	.0343	.0514					.0514
Max	.0686	.1029	.0857	.0686	.0857	.0514	.12
Min	.0343	.0514	.0514	.0514	.0514	.0514	.0514
Avg	.0549	.0667	.0621	.0622	.0664	.0514	.0823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 205 / 11 KV OM SHANTI EXP.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2954	.2646	.2591	.2965	.3329	.3209	.1372
2	.2882	.2636	.2591	.2945	.332	.3234	.1372
3	.293	.2611	.2964	.2971	.3318	.3389	.1372
4	.3277	.293	.2981	.2942	.329	.3203	.1372
5	.3296	.2959	.2622	.3123	.3265	.3188	.1372
6	.3845	.3137	.2963	.3343	.3097	.3719	.1372
7	.3894	.3333	.2932	.3329	.342	.1105	.1372
8	.304	.3685	.2457	.3129	.3428	.3173	.1029
9	.3138	.3638	.2504	.3171	.3363	.3776	.2744
10	.3625	.4378	.3253	.378	.3165	.2783	.2743
11	.3838	.5097	.3249	.3106	.424	.3151	.2058
12	.4014	.4439	.3208	.3303	.3941	.3535	.3429
13	.3945	.4372	.2239	.3115	.3934	.3843	.3086
14	.3963	.4357	.1996	.3081	.3913	.4231	.2743
15	.4065	.3968	.2206	.3234	.3581	.4281	.3086
16	.3657	.3955	.2579	.3262	.3627	.463	.3086
17	.3306	.2756	.3652	.3205	.3583	.4137	.3086
18	.262	.1954	.3271	.2761	.3231	.1083	.2743
19	.2242	.1995	.323	.2793	.3275	.083	.2401
20	.2054	.2611	.323	.2449	.3213	.0813	.2401
21	.1875	.2576	.3238	.2378	.3205	.0814	.2058
22	.1919	.2702	.2899	.2156	.3576	.3939	.1372
23	.1948	.25	.2926	.3291	.3251	.3628	.1029
24	.266	.2877	.2573	.278	.3392	.3439	.2058
Max	.4065	.5097	.3652	.378	.424	.463	.3429
Min	.1875	.1954	.1996	.2156	.3097	.0813	.1029
Avg	.3124	.3255	.2848	.3026	.3457	.3047	.2115



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 206 / FAGANA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3772	.3772	.3429	.3772	.3429	.3429
2	.4287	.3772	.3772	.3429	.3772	.3429	.3429
3	.4287	.3772	.4287	.3429	.3772	.3772	.3429
4	.4801	.4287	.4801	.4801	.4801	.463	.4458
5	.5487	.4801	.6001	.5487	.583	.5487	.5144
6	.6859	.6173	.6516	.5658	.7202	.6516	.6173
7	.7202	.7202	.6859	.5487	.6859	.6859	.6859
8	.5487	.5316	.5487	.5487	.5144	.5144	.4801
9	.3772	.3429	.4287	.4287	.4458	.3429	.3429
10	.3429	.3086	.0343	.3086	.3429	.3086	.2743
11	.3429	.2743	.3086	.3086	.3429	.2743	.2743
12	.3429	.2058	.2743	.2915	.2743	.2743	.2743
13	.3429	.2058	.2743	.3086	.2743	.2743	.2743
14	.3429	.2743	.0274	.2743	.2743	.2743	.2743
15	.3086	.2743	.3086	.3086	.2743	.3086	.2743
16	.3429	.2743	.3086	.3429	.2743	.3429	.2743
17	.3429	.2743	.2743	.2743	.3086	.3429	.2743
18	.4115	.2743		.3772	.3429	.3772	.3429
19	.4458	.5144	.3429	.4801	.4287	.4115	.5144
20	.4801	.5144	.3772	.5144	.5144	.4458	.5144
21	.4801	.5144	.4115	.4801	.4287	.4801	.5144
22	.4115	.4287	.4115	.4458	.4287		.4287
23	.3772	.4287	.3772	.3944	.3429	.3772	.4287
24	.3429	.3429	.4287	.3429	.3429	.0343	.3429
Max	.7202	.7202	.6859	.5658	.7202	.6859	.6859
Min	.3086	.2058	.0274	.2743	.2743	.0343	.2743
Avg	.4294	.3901	.3799	.4001	.4065	.3824	.3915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467] BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 207 / VADAJAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.3429	.3772	.3772	.3772
2		.3772	.4287	.3429	.3772		.3772
3		.4458	.4287	.3429	.3772		.3772
4		.5144	.463	.4801	.4287		.4801
5		.583	.5144	.5487	.5487		.583
6		.6516	.5658	.583	.6859		.6516
7		.703	.6001	.6173	.7202		.6859
8	.6859	.583	.6344	.6344	.6173	.6173	.6173
9		.4801	.6173	.5487	.4801		.5144
10		.3601	.5144	.3601	.4458		.3772
11		.3601	.4458	.3944	.4287		.4287
12	.0497	.3772	.3429	.3944	.3601	.3772	.4287
13		.3772	.3086	.3772	.3601		.4115
14		.3772	.2743	.3772	.3772		.3429
15		.3772	.3429	.3944	.3772		.3772
16	.5487	.4115	.3429	.3772	.3944	.4801	.4115
17		.463	.3772	.3772	.3772		.3772
18		.3772	.3086	.3944	.3944		.3601
19		.5144	.3772	.4801	.5144		.5144
20		.5144	.4115	.5144	.5487	.4801	.5316
21		.5144	.4801	.5144	.4458		.4801
22	.4458	.4287	.3944	.4115	.3944	.4458	.4115
23	.4115	.3772	.3772	.3772	.3772	.3772	.3772
24	.3429	.0377	.3772	.3429	.3772	.3772	.3429
Max	.6859	.703	.6344	.6344	.7202	.6173	.6859
Min	.0497	.0377	.2743	.3429	.3601	.3772	.3429
Avg	.4088	.4410	.4294	.4387	.4494	.4415	.4515

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094013 / FAGANE

Feeder No / Name : 208 / Varkheda Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.0514	.0514	.0343	.0343
2		.0514	.0514	.0514	.0514		.0343
3		.0514	.0514	.0514	.0343		.0343
4		.0514	.0514	.0514	.0514		.0343
5		.0686	.0686	.0686	.0686		.0514
6		.0686	.0686	.0686	.0857		.0514
7		.0857	.0686	.0857	.0857		.0514
8	.0857	.0686	.1029	.0686	.0857	.0686	.0343
9		.0514	.0686	.0514	.0686		.0857
10		.0686	.0686	.0857	.1029		.0514
11		.0857	.0514	.0857	.0686		.0686
12		.0686	.0514	.0686	.0686	.0686	.0514
13	.0051	.0686	.0514	.0686	.0514		.0514
14		.0514	.0514	.0686	.0514		.0343
15		.0514	.0051	.0857	.0343		.0514
16	.0686	.0686	.0514	.0686	.0343	.0686	.0857
17		.0686	.0514	.0686	.0514		.0686
18	.0514	.1029	.0686	.1029	.0514		.0857
19		.0686	.0686	.1029	.0686		.0857
20		.0686	.0686	.0686	.0686	.0686	.0857
21	.0514	.0686	.0514	.0686	.0686		.0686
22	.0514	.0514	.0514	.0686	.0514	.0514	.0514
23	.0514	.0514	.0514	.0514	.0514	.0514	.0514
24	.0514	.0514	.0514	.0514	.0514	.0514	.0514
Max	.0857	.1029	.1029	.1029	.1029	.0686	.0857
Min	.0051	.0514	.0051	.0514	.0343	.0343	.0343
Avg	.0520	.0643	.0574	.0693	.0607	.0579	.0564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 209 / 11 KV Kundane Gaothan  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1402	.136	.1391	.1341	.1402
2	.136	.1395	.1345	.1395	.1379	.1395
3	.1391	.1414	.1417	.1437	.1425	.1417
4	.152	.1578	.1612	.1616	.1524	.1547
5	.2195	.2149	.2241	.2282	.2027	.2111
6	.2984	.3003	.2774	.2968	.2747	.3018
7	.2976	.3003	.2812	.2732	.2892	.2843
8	.2191	.2378	.2176	.2362	.2301	.2309
9	.1509	.1475	.1764	.1456	.1578	.1444
10	.101	.1406	.1437	.1158	.12	.1052
11		.1025	.1677	.1223	.0975	.0854
12		.0899	.1452	.1101	.0793	.0838
13	.0034	.0774	.1337	.0907	.0827	.0827
14	.1135	.0926	.1116	.0941	.088	.0903
15	.1162	.1459	.1166	.1017	.093	.0964
16	.1044	.144	.1273	.128	.093	.1017
17	.1052	.128	.1345	.1326	.104	.109
18	.1238	.1147	.1147	.1105	.1189	.1155
19	.1909	.1791	.1753	.1787	.1856	.1943
20	.1829	.1745	.1661	.1692	.1753	.1776
21	.1665	.1665	.1574	.1566	.1593	.1593
22	.1593	.1604	.1509	.152	.1509	.1539
23	.1475	.1467	.1437	.1437	.1482	.1501
24	.1437	.1379	.1414	.1353	.1414	.1448
Max	.2984	.3003	.2812	.2968	.2892	.3018
Min	.0034	.0774	.1116	.0907	.0793	.0827
Avg	.1549	.1575	.1617	.1544	.1483	.1499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094031 / GONDUR

Feeder No / Name : 201 / 11 KV Nimdale Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1094	.1294	.0912	.1103	.0794	.1029	.1835
2	.1094	.1294	.0912	.1103	.0795	.1029	.1818
3	.1094	.1294	.0912	.1103	.0794	.1029	.1818
4	.1094	.1294	.0912	.1103	.1112	.12	.1823
5	.1094	.1294	.0919	.1102	.1112	.1715	.2181
6	.1276	.128	.0919	.1103	.1112	.2743	.2553
7	.1091	.1109	.0919	.1103	.0794	.3429	.547
8	.0727	.0924	.0919	.0735	.0794	.2743	.3647
9	.0729	.0477	.0368	.0729	.0857	.0343	.0729
10	.0543	.0318	.0368		.0857	.0365	.0477
11	.543	.1597	.4596	.2386	.1886	.0364	.0477
12	.543	.2398	.5148	.3182	.3658	.0364	.0477
13	.4525	.2398	.4045	.3182	.3201	.0365	.0318
14	.2715	.16	.2942	.2389	.2743	.0365	.0318
15	.2715	.1597	.2917	.2386	.2439	.0368	.0318
16	.2715	.1598	.2735	.2386	.2439	.0368	.0318
17	.2715	.3201	.2735	.2383	.2439	.0368	.0319
18	.2172	.2386	.2735	.1589	.2439	.0368	.0318
19	.1086	.0795	.1091	.0794	.1029	.0919	.0798
20	.1086	.0795	.1103	.1273	.1029	.1103	.0799
21	.1456	.0795	.1093	.1273	.1029	.1103	.0794
22	.1456	.0794	.1102	.0953	.1029	.1091	.0794
23	.1448		.1103	.0794	.1029	.1103	.1591
24	***		.1103	.0795		.1103	.1591
Max	13.498	.3201	.5148	.3182	.3658	.3429	.547
Min	.0543	.0318	.0368	.0729	.0794	.0343	.0318
Avg	.7490	.1388	.1771	.1520	.1540	.1041	.1316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094031 / GONDUR

Feeder No / Name : 202 / 11 kv INDIRA GARDEN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9299	.924	.9193	.9928	.9145	.8573	1.0274
2	.9481	.924	.9116	.9744	.9145	.8573	1.0091
3	.9663	.924	.9107	.9744	.823	.823	1.0274
4	1.0101	.924	1.0101	1.0112	.823	.823	1.0825
5	1.2087	1.2012	1.094	1.1387	1.0059	.9431	1.1926
6	1.4025	1.3703	1.2087	1.3421	1.0985	1.1145	1.3675
7	1.5863	1.4784	1.287	1.4509	1.2803	1.2193	1.5268
8	1.1851	1.4845	1.4708	1.3842	1.3717	1.286	1.4311
9	1.1293	1.1913	1.1975	1.2305	1.166	1.0288	1.1802
10	.905	1.0641	1.0112	1.1901	.9945	.9744	.9145
11	.905	.9164	1.0112	1.0059	.8573	.9193	.8248
12	.905	.823	.9009	.9145	.9088	.8816	.7339
13	.8145	.823	.956	.9154	.8573	.8387	.8248
14	.8145	.823	.9928	.823	.823	.8569	1.008
15	.905	.823	.9663	.823	.823	.8825	.9164
16	.905	.8248	.9481	.823	.823	.9193	.9174
17	.9955	.9145	.9116	.9145	.9602	.956	.9174
18	1.448	1.0974	.9918	1.0059	1.0288	1.0112	1.008
19	1.448	1.2803	1.2502	1.2803	1.286	1.3407	1.1926
20	1.448	1.2803	1.3237	1.3717	1.2003	1.4039	1.4311
21	1.3575	1.2803	1.2856	1.2816	1.1488	1.3817	1.2803
22	1.267	1.1888	1.2502	1.1901	1.1488	1.287	1.2803
23	1.086		1.1031	1.0974	1.0288	1.1215	1.0974
24	.9877		.9744	1.0059		1.0112	1.0059
Max	1.5863	1.4845	1.4708	1.4509	1.3717	1.4039	1.5268
Min	.8145	.823	.9009	.823	.823	.823	.7339
Avg	1.1066	1.0709	1.0786	1.0892	1.0124	1.0308	1.0916

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094031 / GONDUR

Feeder No / Name : 204 / GONDUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2772	.2786	.2231	.2783	.2572	.2417
2	.2229	.2772	.2786	.2231	.2783	.2572	.2417
3	.2188	.2772	.2786	.2417	.2783	.2572	.2603
4	.2786	.2772	.2735	.2603	.2783	.2572	.2553
5	.3347	.3696	.3677	.3715	.3711	.3429	.3719
6		.4572	.4649	.4463	.4644	.4287	.4649
7	.3905	.462	.5578	.4463	.4639	.5144	.3905
8	.4091	.4268	.4649	.4087	.3711	.5144	.4082
9	.3158	.2783	.3719	.3155	.3086	.2743	.2041
10	.2715	.2783	.2758	.2783	.2572	.2045	.1856
11	.181	.1856	.1859	.2783	.2058	.1859	.1299
12	.181	.1856	.1859	.1856	.2058	.1674	.1299
13	.181	.1856	.1655	.1856	.1715	.1488	.1485
14	.181	.1856	.1471	.1856	.1715	.1488	.167
15	.181	.1856	.1674	.1856	.1715	.1674	.167
16	.181	.1856	.1859	.1856	.1715	.1674	.1672
17	.181	.1856	.1859	.1856	.1886	.1859	.1856
18	.2715	.2783	.2231	.1856	.2572	.2045	.2783
19	.4525	.2783	.3347	.2783	.4115	.3905	.2783
20	.4525	.2783	3.5888	.3711	.3429	.3719	.3715
21	.3639	.3711	.2789	.3711	.2743	.2758	.2783
22	.2715		.2417	.2783	.2572	.2789	.2783
23	.2715		.2417	.2783	.2572	.2603	.2783
24	.2378		.2231	.2783		.2417	.2783
Max	.4525	.462	3.5888	.4463	.4644	.5144	.4649
Min	.181	.1856	.1471	.1856	.1715	.1488	.1299
Avg	.2719	.2803	.4153	.2770	.2798	.2710	.2567

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 201 / 11 KV Navlane AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1029	.0949
2						.1029	.0949
3						.1372	.096
4						.1372	.1147
5						.1715	.1341
6						.1715	.1372
7						.1886	.2058
8						.1886	.1715
11	.1265	.1372	.1638	.1457	.12		
12	.1581	.1543	.1638	.1638	.1372		
13	.1718	.1543	.1619	.1739	.1372		
14	.1562	.1543	.1581	.1562	.12		
15	.1423	.1715	.1423	.144	.12		
16	.1423	.1715	.16	.1423	.1372		
17	.1235	.1715	.16	.1265	.1543		
18	.1389	.1543	.125	.125	.1372		
23					.1372	.096	.081
24						.1029	.0949
Max	.1718	.1715	.1638	.1739	.1543	.1886	.2058
Min	.1235	.1372	.125	.125	.12	.096	.081
Avg	.1450	.1586	.1544	.1472	.1334	.1399	.1225



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 202 / MEHERGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1463	.1715	.1478	.1848	.1715	.1265
2	.1663	.1463	.1715	.1478	.2772	.2572	.1265
3	.1848	.1829	.2572	.1848	.3696	.3429	.16
4	.1867	.3292	.3429	.3361	.4668	.4287	.2949
5	.3206	.5041	.4287	.4854	.5281		.4359
6	.5093	.5847	.463	.5658	.6224	.6001	.4973
7	.6224	.6036	.5316	.5847	.6224	.5487	.4801
8	.4668	.3961	.4287	.415	.4527	.2572	.3601
9	.2957	.2801	.2743	.2957	.3018	.2572	.2801
10	.1848	.2058	.2195	.2172	.2058	.2126	.1663
11	.1107	.1715	.1802	.1134	.1715	.1267	.1075
12	.1107	.1372	.1311	.0983	.12	.1075	.1052
13	.1094	.1372	.1134	.0791	.12	.1063	.0876
14	.1094	.1372	.1265	.0937	.1029	.1063	.1052
15	.1094	.12	.1265	.096	.1029	.1063	.1052
16	.125	.12	.144	.1265	.12	.1227	.1448
17	.1389	.1372	.144	.1265	.12	.1402	.124
18	.1852	.1543	.1875	.1718	.1715	.1928	.1629
19	.3921	.1543	.4066	.3511	.2058	.3921	.2743
20	.2957	.1715	.2587	.2987	.2058	.2402	.2218
21	.2033	.1715	.2195	.2402	.1715	.1848	.1663
22	.1646	.1715	.1829	.2195	.1543	.1663	.1663
23	.1646	.1372	.1663	.1829	.1543	.144	.1457
24	.1494	.1463	.1372	.1478	.1478	.1372	.1265
Max	.6224	.6036	.5316	.5847	.6224	.6001	.4973
Min	.1094	.12	.1134	.0791	.1029	.1063	.0876
Avg	.2273	.2269	.2422	.2386	.2542	.2326	.2071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 203 / 11 KV Deshmukhwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1372	.1423
2						.1372	.1423
3						.0171	.16
4						.1715	.1966
5						.2058	.2347
6						.2572	.2743
7						.2915	.4287
8						.2058	.3429
11	.3005	.3086	.2622	.2429	.2572		
12	.3163	.2572	.2458	.2294	.2743		
13	.3281	.0206	.2267	.2214	.2401		
14	.2968	.2058	.2056	.1875	.1715		
15	.253	.2058	.2056	.192	.2058		
16	.2343	.2229	.192	.253	.2229		
17	.216	1.5432	.176	.2056	.2401		
18	.2623	.1886	.2343	.2031	.2401		
23					.1715	.128	.1134
24						.1543	.1581
Max	.3281	1.5432	.2622	.253	.2743	.2915	.4287
Min	.216	.0206	.176	.1875	.1715	.0171	.1134
Avg	.2759	.3691	.2185	.2169	.2248	.1706	.2193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094038 / MEHARGAON

Feeder No / Name : 204 / 11 Kv Tilenagar AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.5121	.6001	.5175	.2772	.6859	.759
2	.462	.5121	.6859	.5175	.3696	.7716	.759
3	.462	.5487	.6859	.5544	.3696	.8573	.8002
4	.5228	.6219	.6859	.6161	.5601	1.0288	.8848
5	.6602	.7095	.7716	.7095	.6535	1.2003	1.0395
6	.8488	.7922	.8573	.8865	.7545	1.3717	1.166
7	.9997	.9431	.9088	.9431	.9808	1.4918	1.5432
8	.8215	.7733	.6859	.7922	.8865	1.2517	1.2174
9	.4805	.4854	.5144	.5359	.7167	.4801	.4854
10	.3881	.3429	.4024	.3439	.6859	.3544	.4066
11	1.2492	1.1145	1.2125	1.166	1.3717	.2896	.3045
12	1.2651	1.286	1.2616	1.2125	1.5432	.3224	.2629
13	1.1717	1.3717	1.1174	1.0437	1.3717	.3012	.333
14	1.0936	1.4575	.9172	1.0311	1.2346	.3189	.333
15	1.0279	1.2003	.9488	1.0279	1.2003	.3189	.3681
16	.9962	1.1145	1.0242	1.0437	1.2003	.333	.362
17	.9414	1.0288	1.0722	1.0437	1.286	.3681	.3721
18	.787	.9945	.9061	.953	1.0802	.4031	.4344
19	.7282	.6001	.6838	.5914	.5144	.7095	.6401
20	.7207	.6001	.7207	.7655	.6859	.7207	.6838
21	.6838	.5144	.6584	.7392	.7716	.6283	.6468
22	.6219	.5658	.6036	.6584	.5144	.5729	.5729
23	.5487	.5144	.5544	.5487	.6859	.6401	.6154
24	.4668	.5121	.5144	.5175	.5175	.7716	.7907
Max	1.2651	1.4575	1.2616	1.2125	1.5432	1.4918	1.5432
Min	.3734	.3429	.4024	.3439	.2772	.2896	.2629
Avg	.7634	.7965	.7914	.7816	.8430	.6747	.6575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 201 / 11 KV Vadel AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4268	.8573
2						.4458	.8573
3						.4268	.8573
4						.4877	.823
5						.6401	.8402
6						.823	.8573
7						.7926	1.5775
8						.945	1.2346
11	1.5261	1.4937	1.2003	1.2346	1.406		
12		1.4632	1.2136	1.3717	1.2346		
13	1.5089	1.2803	1.1069	1.3375	1.1317		
14		1.0669	.9602	1.1831	1.0631		
15		1.0669	.8669	1.0631	.6516		
16	1.2346	1.0364	.8669	1.0288	1.0631		
17	1.2346	.9907	1.0974	.9945	1.0974		
18	.9602	.945	.7202	.9945	.8916		
23					.4458	.7621	.6859
24						.5144	.823
Max	1.5261	1.4937	1.2136	1.3717	1.406	.945	1.5775
Min	.9602	.945	.7202	.9945	.4458	.4268	.6859
Avg	1.2929	1.1679	1.0041	1.1510	.9983	.6264	.9413

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 202 / 11 KV Dhamane AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3048	.4801
2						.3048	.4458
3						.2743	.4287
4						.3353	.4458
5						.3353	.4458
6						.3963	.4287
7						.4268	.7202
8						.4877	.6516
11		.5792	.4934	.5487	.6235		
12		.6097	.5601	.6516	.6173		
13	.6173	.5792	.5335	.6516	.5487		
14		.5487	.5201	.5487	.5487		
15	.6173	.5792	.5068	.5144	.5487		
16	.6173	.5792	.5068	.5144	.583		
17		.5487	.5068	.4801	.6173		
18	.6173	.5335	.4401	.4801	.4801		
23					.3437	.4572	.3429
24						.4287	.4268
Max	.6173	.6097	.5601	.6516	.6235	.4877	.7202
Min	.6173	.5335	.4401	.4801	.3437	.2743	.3429
Avg	.6173	.5697	.5085	.5487	.5457	.3751	.4816

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 203 / Govinda Gas Ex. Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0171	.0171	.0173	.0171	.0171
2		.0171	.0171	.0171	.0171	.0171	.0171
3	.0171	.0171	.0171	.0171	.0171	.0171	.0171
4		.0171	.0171	.0171	.0171	.0171	.0171
5		.0171	.0171	.0171	.0173	.0171	.0171
6		.0171	.0171	.0171	.0173	.0171	.0171
7		.0171	.0171	.0171	.0171	.0171	.0171
8	.0171	.0171	.0171	.0171	.0171	.0171	.0171
9		.0171	.0171	.0171	.0171	.0171	.0171
10		.0171	.0171	.0171	.0171	.0171	.0171
11	.0171	.0171	.0171	.0171	.0171	.0171	.0171
12		.0171	.0171	.0171	.0171	.0171	.0171
13	.0171	.0171	.0171	.0171	.0171	.0171	.0171
14		.0171	.0171	.0171	.0171	.0171	.0171
15		.0171	.0171	.0171	.0171	.0171	.0171
16	.0173	.0171	.0171	.0171	.0346	.0171	.0171
17		.0171	.0171	.0171	.0343	.0171	.0171
18	.0171	.0171	.0171	.0171	.0171	.0171	.0171
19		.0171	.0343	.0171	.0171	.0171	.0171
20	.0171	.0171	.0343	.0171	.0171	.0171	.0171
21		.0171	.0343	.0171	.0171	.0171	.0171
22	.0171	.0171	.0171	.0171	.0173	.0171	.0171
23	.0171	.0171	.0171	.0171	.0171	.0171	.0171
24	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Max	.0173	.0171	.0343	.0171	.0346	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0193	.0171	.0186	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 204 / Ex. Jay Laxmi Fiber Ltd.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0171	.0171	.0171	.0171	.0171
2		.0171	.0171	.0171	.0171	.0171	.0171
3		.0171	.0171	.0171	.0171	.0171	.0171
4	.0171	.0171	.0171	.0171	.0171	.0171	.0171
5		.0171	.0171	.0171	.0171	.0171	.0171
6		.0171	.0171	.0171	.0171	.0171	.0171
7	.0171	.0171	.0171	.0171	.0171	.0152	.0171
8	.0171	.0171	.0171	.0171	.0171	.0171	.0171
9		.0171	.0171	.0171	.0171	.0171	.0171
10		.0171	.0171	.0171	.0171	.0171	.0171
11	.0171	.0171	.0171	.0171	.0171	.0171	.0171
12		.0171	.0171	.0171	.0171	.0171	.0171
13		.0171	.0171	.0171	.0171	.0171	.0171
14		.0171	.0171	.0171	.0171	.0171	.0171
15	.0171	.0171	.0171	.0171	.0171	.0171	.0171
16	.0171	.0171	.0171	.0171	.0171	.0171	.0171
17	.0171	.0171	.0171	.0171	.0173	.0171	.0171
18		.0171	.0171	.0171	.0171	.0171	.0171
19	.0171	.0171	.0171	.0171	.0171	.0171	.0171
20		.0171	.0171	.0171	.0173	.0171	.0171
21	.0171	.0171	.0171	.0171	.0171	.0171	.0171
22		.0171	.0171	.0171	.0171	.0171	.0171
23	.0171	.0171	.0171	.0171	.0171	.0171	.0171
24	.0171	.0171	.0171	.0171	.0171	.0173	.0171
Max	.0171	.0171	.0171	.0171	.0173	.0173	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0152	.0171
Avg	.0171	.0171	.0171	.0171	.0171	.0170	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 205 / 11 KV Dhamane Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0943	.1029	.1029	.1029	.0934	.1029
2		.0943	.1029	.1029	.1039	.0934	.1029
3	.0857	.1029	.1029	.1029	.1039	.0934	.1029
4	.1029	.1132	.12	.12	.1039	.112	.12
5		.132	.1372	.1543	.1372	.1307	.1372
6	.1543	.1494	.1715	.1715	.1559	.1494	.1886
7		.1867	.1715	.1886	.1886	.2054	.1715
8	.1372	.1663	.1372	.1543	.1559	.1478	.1543
9		.1478	.12	.1372	.1372	.1478	.1372
10	.12	.128	.12	.1029	.1029	.1097	.12
11		.1294	.1029	.1029	.1039	.0905	.1029
12	.1029	.1294	.0171	.0857	.1029	.0905	.0857
13		.1097	.0857	.0857	.1029	.0905	.0857
14		.1097	.0857	.0857	.1029	.0914	.0857
15		.0905	.0857	.1029	.1029	.0924	.0857
16	.1029	.1097	.0857	.1029	.1029	.0934	.0857
17	.1029	.1097	.1029	.1029	.1029	.112	.1029
18	.1029	.1294	.1029	.1029	.1029	.0934	.1029
19		.1494	.1372	.1372	.1543	.1307	.1029
20	.1372	.168	.1372	.1372	.1372	.1494	.12
21		.1494	.1372	.12	.1372	.1494	.1029
22	.1029	.132	.12	.12	.1212	.1307	.1029
23	.1029	.1132	.1029	.1029	.1029	.112	.1029
24	.0866	.0857	.112	.1029	.1029	.1029	.112
Max	.1543	.1867	.1715	.1886	.1886	.2054	.1886
Min	.0857	.0857	.0171	.0857	.1029	.0905	.0857
Avg	.1091	.1263	.1126	.1179	.1197	.1172	.1133



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094043 / DEOBHANE(DHODI)

Feeder No / Name : 206 / 11 Kv Gangamai Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3018	.2743	.2743	.2743	.3018	.3086
2	.2743	.2987	.2743	.2743	.2743	.3018	.2743
3		.2987	.2743	.2743	.2743	.3018	.2572
4	.3086	.4108	.3429	.3086	.3086	.2987	.2572
5		.6722	.5144	.3601	.3772	.4108	.4287
6		.7842	.6859	.6173	.583	.7468	.6859
7	.583	.6722	.7545	.7545	.7202	.7023	.7202
8	.5487	.6722	.5658	.5487	.4801	.5175	.4801
9		.5175	.3601	.4115	.4115	.3696	.4287
10		.3292	.3258	.3429	.3429	.3292	.2743
11		.2926	.2743	.3429	.2743	.2896	.2572
12		.2561	.2572	.3086	.2743	.2715	.2229
13		.2561	.2743	.3086	.2743	.2715	.2229
14		.2561	.2743	.2743	.2743	.2715	.2401
15		.2561	.2915	.2743	.2743	.2926	.2915
16	.2401	.2772	.2743	.3086	.2743	.3292	.2915
17		.2957	.2743	.3086	.2743	.3326	.2915
18		.3326	.2915	.3429	.3429	.3734	.2743
19	.6516	.499	.4458	.4115	.4801	.4668	.3429
20	.6173	.4668	.3772	.4458	.4458	.4854	.4115
21	.5487	.3734	.3601	.3429	.4115	.4481	.3429
22		.3734	.3429	.3429	.3772	.3734	.2743
23	.2743	.3361	.3086	.3086	.3429	.3174	.2743
24	.2743	.2743	.2987	.2915	.3086	.3429	.2987
Max	.6516	.7842	.7545	.7545	.7202	.7468	.7202
Min	.2401	.2561	.2572	.2743	.2743	.2715	.2229
Avg	.4177	.3960	.3632	.3658	.3615	.3811	.3397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 201 / 11 KV saitale Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	1.0974	1.1203	1.1088	1.086		
2	.9335	1.0974	1.1203	1.1088	1.0745		
3	.9335	1.086	1.1088	1.1088	1.0745		
4	1.0269	1.1393	1.2012	1.1888	1.1393		
5	1.086	1.1145	1.2536	1.2536	1.1145		
6	1.1765	1.286	1.3717	1.387	1.2003		
7	1.2012	1.6461	1.3717	1.5432	1.4899		
8	1.2803	1.4937	1.3717	1.286	1.3432		
11						1.5546	1.386
12						1.587	1.4937
13						1.4937	1.4937
14						1.4937	1.307
15						1.4003	1.307
16						1.4003	1.4003
17						1.4632	1.4003
18						1.3717	1.2803
23	1.0059	1.1088	1.1088	.9955			
24	.9335	1.1088	1.1088				
Max	1.2803	1.6461	1.3717	1.5432	1.4899	1.587	1.4937
Min	.9335	1.086	1.1088	.9955	1.0745	1.3717	1.2803
Avg	1.0511	1.2178	1.2137	1.2201	1.1903	1.4706	1.3835

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 202 / 11KV Rudane Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6401	.6401
2						.6401	.6401
3						.6401	.7316
4						.6468	.8145
5						.7316	.905
6						.9145	1.1088
7						.9955	1.1088
8						.7468	.8316
11	.964	.964	.964	.7888	1.1203		
12	.9745	.8764	.8764	.9431	1.0269		
13	.9431	.8573	.7802		1.0269		
14	.8573	.8573	.7716		.9145		
15	.8573	.8573	.7716		.823		
16	.8764	.8573	.6859	.8954	.9145		
17	.8859	.7973	.6859	.7973	1.0059		
18	.823	.7087	.7087		.7468		
19				.7316			
20				.6401			
21				.6535			
23					.6535	.7468	.7468
24					.6401	.6535	
Max	.9745	.964	.964	.9431	1.1203	.9955	1.1088
Min	.823	.7087	.6859	.6401	.6401	.6401	.6401
Avg	.8977	.8470	.7805	.7785	.8872	.7356	.8364

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094052 / 33/11 KV Lamkani S/S

Feeder No / Name : 203 / 11 kV Lamkani AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.9145	1.0974
2						.9145	1.0974
3						.9145	1.0059
4						1.267	1.1765
5							1.267
6						1.4632	1.4784
7						1.5384	1.6632
8						1.4003	1.386
11	1.4022	1.4022	1.4022	1.4022	1.587		
12	1.5061	1.4022	1.4022	1.3717	1.4937		
13	1.3717	1.3717	1.387		1.4937		
14	1.3717	1.3717	1.3717		1.3717		
15	1.3717	1.3717	1.3717		1.3717		
16	1.4899	1.3717	1.286	1.4327	1.4632		
17	1.5061	1.3289	.6859	1.3289	1.5546		
18	1.4632	1.2403	.7087		1.4003		
19				1.1888			
20				1.1888			
21				1.2136			
23					1.307	1.307	1.2136
24					1.1888	1.307	
Max	1.5061	1.4022	1.4022	1.4327	1.587	1.5384	1.6632
Min	1.3717	1.2403	.6859	1.1888	1.1888	.9145	1.0059
Avg	1.4353	1.3576	1.2019	1.3038	1.4232	1.2252	1.2650

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094063 / 33/11 KV KAPDANE

Feeder No / Name : 201 / 11KV NEW KAPDANE GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.3452	.3506	.3506	.3445	.3467	.3721
2	.3467	.4298	.3506	.3506	.3445	.3467	.3721
3	.3814	.4812	.3856	.3681	.4822	.3641	.3898
4	.4854	.653	.4382	.4207	.5499	.3988	.4075
5	.5201	.7553	.4733	.4557	.7545	.6935	.4908
6	.7282	.7202	.5609	.5609	.6773	.7628	.6661
7	.7108	.7046	.6836	.6485	.6465	.7282	.6836
8	.5375	.4995	.5959	.5083	.5327	.5721	.5493
9	.3658	.4557	.4207	.3856	.4161	.4207	.3988
10	.4134	.3856	.3681	.3445	.3641	.4031	.3814
11	.3789	.3856	.3856	.3224	.3641	.3856	.3988
12	.3582	.3681	.3681	.31	.3814	.3681	.3988
13	.3582	.3856	.3856	.3445	.3988	.4207	.4161
14	.3761	.4031	.3681	.3445	.3814	.4207	.4161
15	.394	.4207	.3506	.3789	.3988	.4382	.4161
16	.3856	.4031	.4031	.3789	.3988	.4207	.4207
17	.4031	.4207	.4382	.4124	.4334	.4031	.4527
18	.4031	.4557	.4908	.4812	.5258	.4733	.503
19	.5609	.5434	.4557	.5499	.5434	.5784	.5596
20	.5548	.5434	.4733	.5155	.5784	.5083	.5087
21	.5167	.5083	.4733	.4812	.5258	.4557	.4748
22	.4656	.4733	.4733	.4477	.4207	.4207	.4409
23	.439	.4382	.4252	.4024	.3856	.4031	.3561
24	.3467	.4024	.3681	.3721	.362	.3814	.3544
Max	.7282	.7553	.6836	.6485	.7545	.7628	.6836
Min	.3467	.3452	.3506	.31	.3445	.3467	.3544
Avg	.4490	.4826	.4369	.4223	.4671	.4631	.4512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094063 / 33/11 KV KAPDANE

Feeder No / Name : 202 / 11KV NEW KAPDANE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7926	.7014	.7676	.873	.6484		
2	.884	.8339	.9181	.873	.6994		
3	.9907	.9415	1.0536	.9031	.7801		
4	1.1431	1.0492	1.0837	1.1288	.9121		
5	1.2955	1.2742	1.1439	1.2041	1.0059		
6	1.3413	1.2572	1.4148	1.2793	1.1535		
7	1.326	1.284	1.5352	1.4299	1.1803		
8	1.3108	1.4399	1.3546	1.2643	1.1465		
11						1.2005	1.387
12						1.2679	1.3717
13						1.224	1.3413
14						1.1336	1.2498
15						1.0926	1.2193
16						1.0791	1.0492
17						1.2191	1.1465
18						1.1288	1.0131
23	.6417	.7526	.873	.5806			
24	.6142	.6205	.7526	.873	.5673		
Max	1.3413	1.4399	1.5352	1.4299	1.1803	1.2679	1.387
Min	.6142	.6205	.7526	.5806	.5673	1.0791	1.0131
Avg	1.0340	1.0154	1.0897	1.0409	.8993	1.1682	1.2222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

CC O&amp;M DHULE[467]

BU 0467

Substation No/ Name :- 094063 / 33/11 KV KAPDANE

Feeder No / Name : 203 / 11KV DHANUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6687	.7526
2						.6687	.7526
3						.743	.8278
4						.743	.873
5						.8916	.9031
6						.9659	.9482
7						.9659	.6773
8						.8916	1.174
11	1.2572	1.3847	1.4148	1.2375	1.3496		
12	1.3107	1.2191	1.2342	1.2572	1.379		
13	1.2973	1.1138	1.2041	1.284	1.1736		
14	1.2037	1.0536	1.2041	1.2037	1.2186		
15	1.1235	.9934	1.174	1.1568	1.1888		
16	1.0223	1.0536	1.189	1.0492	1.1591		
17	.8608	1.1138	1.0837	.9172	1.0402		
18	.7284	1.0385	1.0385	.8498	.8768		
23					.4607	.7225	.6112
24						.4572	.7526
Max	1.3107	1.3847	1.4148	1.284	1.379	.9659	1.174
Min	.7284	.9934	1.0385	.8498	.4607	.4572	.6112
Avg	1.1005	1.1213	1.1928	1.1194	1.0940	.7718	.8272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 201 / 11KV DEOPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9431	.8573	.9431	.8573	.8573	1.0288
2		.9431	.8573	.8573	.8573	.8573	.9431
3	.9431	.8573	.8573	.8573	.8573	.8573	.8573
4	.8573	1.0288	.8573	.8573	.8573	.8573	.9431
5	.9431	1.0288	.9431	.9431	1.0288	.8573	1.0288
6	1.2003	1.2003	1.1145	1.2003	.6859	1.2003	1.286
7	1.286	1.3717	1.286	1.286	1.2003	1.286	1.286
8	1.286	1.3717	1.4575	1.2003	1.2003	1.286	1.286
9	1.2003	1.286	1.286	1.1145	1.2003	1.2003	1.2517
10	1.0288	1.1145		1.1145	1.2003	1.0288	1.0631
11	1.0288	1.1145	1.2003	.9431	1.1145	1.0802	.9431
12	1.0288	.9431	1.2003	.9431	1.0288	1.1145	.9431
13	.9431	.9431	1.0288	.8573	.9431	1.0288	.9431
14	.9431	.9431		.8573	.8573	1.0288	.9431
15	.9431	.9431	.8573	.8573	.8573	.9431	.9602
16	.9431	.9431	.8573	.9431	.8573	.9431	1.0288
17	.9431	.9431	.8573	.9431	.9431	.8383	1.0288
18	1.0288	1.0288	.9431	1.0288	.9431	.9145	1.0288
19	1.3717	1.3717	1.286	1.3717	1.286	1.3717	1.3717
20	1.3717	1.3717	1.286	1.3717	1.286	1.286	1.2003
21	1.3717	1.286	1.2003	1.286	1.2003	1.286	1.286
22	1.2003	1.2003	1.2003	1.2003	1.2003	1.286	1.2003
23	1.1145	1.1145	1.0288	1.0288	1.0288	1.1145	1.1145
24		1.0288	.9431	.9431		.9431	1.0288
Max	1.3717	1.3717	1.4575	1.3717	1.286	1.3717	1.3717
Min	.8573	.8573	.8573	.8573	.6859	.8383	.8573
Avg	1.0873	1.0967	1.0639	1.0395	1.0213	1.0611	1.0831



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 204 / 11 KV VIDYANAGARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	.945	1.1145	1.1145	1.0288	1.1145	1.1145
2	1.1145	.945	1.0288	1.0288		1.0288	1.1145
3	1.0288	1.0802	1.0288	1.0288	.9431	1.0288	1.2003
4	1.1145	1.1145	1.0288	1.1145	1.0288	1.0288	1.2003
5	1.1145	1.1145	1.1145	1.2003	1.0288	1.0288	1.286
6	1.286	1.286	1.2003	1.4575	1.1145	1.286	1.5432
7	1.4575	1.3717	1.3717	1.5432	1.2003	1.3717	1.4575
8	1.286	1.286	1.3717	1.3717	1.5432	1.286	1.3717
9	1.2003	1.1145	1.286	1.3717	1.4575	1.1145	1.2003
10	1.1145	1.1145	1.0288	1.1145	1.3717	1.0288	1.1145
11	1.0288	1.1145	1.0288	1.0288	1.2003	1.0288	1.0288
12	.9431	1.0288	1.0288	1.0288	1.0288	1.0288	1.0288
13	.8383	1.0288	1.1145	1.0288	.9431	.9431	1.0288
14	1.0288	1.0288		.9431	.9431	.9431	.9431
15	1.0288	1.0288		.8573	1.0288	.9431	1.0288
16	1.0288	1.0288	1.0288	.8573	1.1145	1.0288	1.0288
17	1.0288	1.0288	1.0288	1.0288	1.2003	1.0364	1.1145
18	1.1145	1.2003	1.1145	1.1145	1.2003	1.2003	1.2003
19	1.6289	1.5432	1.5432	1.5432	1.5432	1.6289	1.6289
20	1.6289	1.5432	1.5432	1.5432	1.6289	1.6289	1.6289
21	1.5432	1.5432	1.5432	1.4575	1.5089	1.5432	1.5432
22	1.4575	1.4575	1.3717	1.3717	1.3717	1.4575	1.4575
23	1.286	1.286	1.286	1.2003	1.2003	1.286	1.286
24		1.2003	1.1145	1.1145		1.1145	1.2003
Max	1.6289	1.5432	1.5432	1.5432	1.6289	1.6289	1.6289
Min	.8383	.945	1.0288	.8573	.9431	.9431	.9431
Avg	1.1920	1.1847	1.1964	1.1860	1.2104	1.1720	1.2396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 206 / 11 KV EKVIRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6001	.6001	.6001	.6001	.6001	.6859
2	.5144	.5658	.6001	.5144	.5144	.5144	.6001
3	.5144	.5658	.6001	.5144	.6001	.5144	.6001
4	.6001	.5658	.6001	.5144	.6859	.6001	.6001
5	.6859	.6001	.6001	.5144	.6859	.6859	.6859
6	.823	.6859	.6859	.6859	.6859	.8573	.7716
7	.9431	.8573	.9431	.8573	.7716	.8573	.8573
8		.9431	1.2003	.9431	.9431	.9431	.9431
9	.9145	.8573	1.1145	.7716	.7716	.9431	.8745
10	.7621	.6859	.8573	.6859	.0171	.8573	.7888
11	.9145	.7716	1.1145	.6859	.8573	.9088	.8573
12	.9145	.7716	1.1145	.6859	.8573	1.0288	.8573
13	.7621	.6001		.6859	.7716	.8745	.7716
14	.5335	.6001		.6001	.6001	.6001	.6859
15	.6859	.6001		.6001	.6001	.6859	.6859
16	.6859	.6001	.6001	.6001	.6001	.6859	.6859
17	.7716	.6001	.5144	.6859	.6001	.703	.6859
18	.8573	.7716	.6859	.6859	.6001	.8916	.8573
19	1.0288	1.0288	.8573	.9431	.9431	1.0288	.9431
20	.8573	1.0288	.8573	.8573	.9431	1.1145	.8573
21	.8573	.8573	.7716	.8573	.7716	.9431	.8573
22	.8573	.7716	.7716	.7716	.6859	.7716	.7716
23	.6859	.6859	.6859	.6859	.6859	.6859	.6859
24		.6001	.6001	.6001		.6001	.8573
Max	1.0288	1.0288	1.2003	.9431	.9431	1.1145	.9431
Min	.5144	.5658	.5144	.5144	.0171	.5144	.6001
Avg	.7623	.7173	.7798	.6894	.6866	.7873	.7695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 207 / 11 KV ARTI

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.194	2.2344	2.2695			
2	2.2268	2.2344	2.3022			
3	2.258	2.2268	2.3015			
4	2.2405	2.2535	2.271			
5	2.2687	2.2725	2.2763			
6	2.3487	2.431	2.3777			
7	.1494	2.5522	2.5027			
8		2.4356	1.1759			
9		1.0936				
10				1.9189	3.3074	3.1672
11					3.6862	3.6466
12				3.2838	3.5536	3.6229
13				3.456	3.5871	3.4294
14				3.52	3.6191	3.4667
15				3.594	3.5833	3.6763
16				3.3996	3.4255	3.5239
17				3.4698	3.3638	3.4301
18				3.1664	2.1795	1.7878
19				1.7497		
22	.0015	2.2382				
23	2.2771	2.2512				
24	2.2687	2.2443				
Max	2.3487	2.5522	2.5027	3.594	3.6862	3.6763
Min	.0015	1.0936	1.1759	1.7497	2.1795	1.7878
Avg	1.8233	2.2056	2.1846	3.0620	3.3673	3.3057

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 210 / 11 KV JAIHIND COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6001	.6859	.6001	.6859	.8573
2	1.1145	.6859	.6001	.6001	.6001	.6001	.7716
3	.6001	.6001	.6001	.6001	.6001	.6001	.6859
4	.6001	.6001	.6001	.0686	.6001	.6859	.6859
5	.7716	.7716	.6859	.6859	.6859	.7716	.8573
6	.8573	.9431	.7716	.8573	.7716	.9431	.8573
7	.9431	1.0288	.8573	.9431	.7716	.9431	.9431
8	.9431	1.0288	.9431	.8573	.9431	.9431	1.0288
9	.9431	.8573	.9431	.8573	.9431	.8573	.8916
10	.7716	.8573	.8573	.7716	.8573	.7716	.8916
11	.7716	.8573	.7716	.7716	.8573	.7202	.8573
12	.7716	.6859	.8573	.6859	.6859	.6859	.7716
13	.6859	.6859	1.0288	.6859	.6859	.6859	.7716
14	.6859	.6859		.6859	.6859	.6859	.7716
15	.6859	.6859	.6859	.6859	.6001	.6859	.6859
16	.6859	.6859	.6859	.6859	.6001	.7716	.6859
17	.7716	.6859	.6859	.6859	.6859		.7716
18	.8573	.7716	.7716		.7716	.8573	.7716
19	1.1145	1.0288	1.0288	1.0288	1.1145	1.0288	1.1145
20	1.1145	1.0288	1.1145	1.1145	1.1145	1.0288	.9431
21	1.0288	.9431	.7716	.9431	.9431	1.0288	1.0288
22	.9431	.8573	.8573	.8573	.8573	.8573	.8573
23	.7716	.7716	.7716	.7716	.7716	.8573	.7716
24		.6859	.6859	.6859		.6859	.6859
Max	1.1145	1.0288	1.1145	1.1145	1.1145	1.0288	1.1145
Min	.6001	.6001	.6001	.0686	.6001	.6001	.6859
Avg	.8312	.7966	.7902	.7485	.7716	.7992	.8316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 211 / ITI EXPRESS

SHEDDABLE RURAL

Feeder KV- 11 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0305	.0343	.0343	.0343	.0171	.0343
2	.0343	.0305	.0343	.0343	.0343	.0343	.0343
3	.5144	.0305	.0343	.0343	.0343	.0343	.0343
4	.0343	.0305	.0343	.0343	.0343	.0343	.0343
5	.0343	.0305	.0343	.0343	.0343	.0343	.0343
6	.0343	.0305	.0343	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0343	.0343	.0343	.0305
8		.463	.0343	.0343	.0343	.0343	.0305
9	.0305	.0343	.0343	.0343	.0171	.0343	.0305
10	.0305	.0343	.0343	.0343	.0171	.0305	.0305
11	.0305	.0343	.0343	.0343	.0171	.0305	.0343
12	.0305	.0343	.0343	.0343	.0171	.0305	.0343
13	.0305	.0343	.0343	.0343	.0171	.0305	.0343
14	.0305	.0343		.0343	.0171	.0305	.0343
15		.0343		.0343	.0171	.0305	
16	.0305	.0343	.0343	.0343	.0171	.0305	.0343
17	.0343	.0343	.0343	.0343	.0171	.0305	.0343
18	.0305	.0343	.0343	.0343	.0171	.0305	.0343
19	.0305	.0343	.0343	.0343	.0171	.0305	.0343
20	.0343	.0343	.0343	.0343	.0171	.0305	.0343
21	.0343	.0343	.0343	.0343	.0171	.0305	.0343
22	.0343	.0343	.0343	.0343	.0171	.0305	.0343
23	.0343	.0343	.0343	.0343	.0171	.0305	.0343
24		.0305	.0343	.0343		.0171	.0343
Max	.5144	.463	.0343	.0343	.0343	.0343	.0343
Min	.0305	.0305	.0343	.0343	.0171	.0171	.0305
Avg	.0555	.0511	.0343	.0343	.0231	.0307	.0336

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 242 / 11KV INCOMER II

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.5165	9.5165	8.8992	9.465	9.0021	6.5329	7.2017
2	9.2593	9.2593	8.8477	9.5679	9.0021	6.4301	6.6873
3	9.1564	8.7449	8.7963	9.2593	9.0021	6.2243	6.6873
4	9.4136	8.7963	8.8992	9.1564	9.0021	6.5844	6.6873
5	***	***	9.7222	9.5165	***	7.1502	7.7161
6	***	***	***	***	8.642	9.2593	9.0021
7	***	***	***	***	***	9.6708	***
8	***	***	***	***	***	9.5165	***
9	9.9794	9.6194	***	7.9733	9.5165	8.7449	9.5679
10	8.2819	8.4362	***	8.179	9.5679	8.3333	8.642
11	8.642	8.5905	9.6194	7.6646	8.7963	***	***
12	8.642	7.5617	8.7963	7.2531	8.0247	***	
13	7.6132	6.9959	8.7963	7.1502	7.5103	***	***
14	7.0988	6.9959		6.5329	6.7387	***	***
15	7.6132	7.0473	7.4589	6.6873	6.4815	***	8.1276
16	7.5617	7.0988	6.9445	6.6873	6.4815	***	***
17	7.8189	7.1502	6.7387	7.2017	7.0473	***	***
18	8.642	8.1276	7.2017	7.7161	7.356	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	***	9.8251	9.5165	9.7222	9.5165	***	9.7737
22	9.5679	9.0535	***	9.0021	7.7161	9.5679	9.2593
23	8.4877	***	***		7.7161	8.4877	7.9218
24		9.9794	9.465	9.8251		6.7901	7.4589
Max	12.8601	14.1976	14.6091	13.3231	13.1173	12.6543	13.1173
Min	7.0988	6.9959	6.7387	6.5329	6.4815	6.2243	6.6873
Avg	9.4963	9.2957	9.6238	8.9976	8.8567	9.6065	9.4986

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 421 / 33 KV DEOPUR (I/C)

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.4527	5.4527	5.4012	5.5556		4.6296	4.8868
2	5.4012	5.4012	5.2469	5.3498	5.144	4.3724	4.6811
3	5.3498	5.1955	5.2469	5.3498	5.144	4.3724	4.6296
4	5.2469	5.1955	5.3498	5.1955	4.8868	4.4753	4.6296
5	5.5556	5.9156	5.4527	5.4527	5.4012	4.6811	4.8868
6	9.2593	6.6358	6.2243	6.6358		5.7099	6.0185
7	7.7161	7.7161	7.3045	7.6646	6.9445	6.2757	6.3786
8	6.2243	7.4074	7.7675	7.1502	7.4589	6.0185	6.2243
9	5.3041	5.8128	6.2757	5.5041	6.1214	5.144	5.7613
10	4.7097	5.1955	6.2757	5.2984	5.8128	5.0926	5.144
11	4.481	5.0412	5.607	4.5782	5.144	6.4301	6.6358
12	4.2981	4.7325	5.4527	4.4239	4.9897	6.4301	6.3786
13	4.161	4.4753	5.0926	4.6296	4.6296	6.1214	6.07
14	3.8866	4.5268	4.5782	4.4753	4.3724	5.8642	6.0185
15	4.1152	4.6296	4.4753	4.4239	4.3724	5.8128	4.8868
16	4.1152	4.6296	4.3724	4.3724	4.3724	6.0185	5.9156
17	4.784	4.6296	4.3724	4.4753	4.6296	6.1214	6.2757
18	5.3498	4.9897	4.8354	4.9897	4.9383	6.4301	6.6358
19	6.9959	6.7901	6.3272	6.6873	6.5329	6.9959	6.9959
20	6.9959	6.7901	6.5844	6.7901	7.0988	6.9445	7.0473
21	6.5844	6.4301	6.3786	6.2757	6.3272	6.6358	6.6358
22	6.2243	6.3272	6.0185	5.9156	5.8128	6.3272	
23	6.3786	6.1728	6.2757	6.07	5.2984	5.4527	5.6584
24		5.7613	5.607	5.5041		4.8354	5.144
Max	9.2593	7.7161	7.7675	7.6646	7.4589	6.9959	7.0473
Min	3.8866	4.4753	4.3724	4.3724	4.3724	4.3724	4.6296
Avg	5.5909	5.6606	5.6884	5.5320	5.4968	5.7163	5.8060

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094016 / 33/11 KV DEOPUR

Feeder No / Name : 424 / 33 KV UMRAONAGAR (O/G)

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.9897	5.3326	5.024	5.2983	5.247	5.2983	1.1831
2	4.8525	5.1612	4.8354	5.1612	4.8697	5.0755	1.1831
3	4.7839	5.0583	4.7668	4.9897	4.6639	4.9726	1.1317
4	4.5439	4.7668	4.6982	4.561	.9259	4.5439	1.0802
5	4.7496	4.904	4.6639	4.8697	5.0412	4.6982	1.1831
6	5.6585	5.7271	5.3326	5.9499	6.07	5.7271	1.3375
7	6.2586	6.2929	6.1729	6.4472	6.3615	6.1386	1.4403
8	6.1214	5.9842	6.3958	6.2758	6.4129	6.1386	1.3375
9	5.7785	5.6585	5.9499	5.8299	6.4644	5.5213	1.286
10	5.2469	5.4184	5.7442	5.7956	6.0871	5.2297	1.1317
11	4.5782	4.8354	5.0069	4.6811	5.024	4.6982	1.0802
12	1.6804	4.5439	4.681	3.2579	4.9554	1.7661	.9774
13	4.6639	3.2065	4.7496	3.7209	4.9211	3.0864	.9774
14	4.5782	4.6639	4.8182	4.4581	4.8011	4.5782	1.0802
15	4.2867	4.7496	4.7325	4.321	4.6296	3.4465	1.0288
16	4.6982	4.5953	4.6982	2.6406	4.6125	4.5782	1.0288
17	4.7325	4.6296	4.6639	4.5782	4.8011	3.0007	1.0288
18	5.2297	4.7325	5.264	4.9726	5.0583	5.0926	1.0802
19	6.8244	6.5844	6.7215	6.7558	7.0302	6.1899	1.5432
20	7.236	6.7044	7.0131	6.6701	7.1503	6.9273	1.6461
21	7.0645	6.7901	7.0817	6.2414	7.0474	7.0131	1.5947
22	7.0988	6.6872	6.9959	6.5329	6.653	7.0474	1.5947
23	6.2415	6.0528	6.2929	5.9842	6.1386	6.2415	1.3889
24	4.321	5.2983	5.5384	5.1783	4.2867	5.3498	1.2346
Max	7.236	6.7901	7.0817	6.7558	7.1503	7.0474	1.6461
Min	1.6804	3.2065	4.6639	2.6406	.9259	1.7661	.9774
Avg	5.2591	5.3491	5.4934	5.2155	5.3855	5.0983	1.2324



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 201 / 11 KV PAROLA ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9648	.9785	1.8312	.9861	.948	.977
2	.9435	.9694	1.746	.9663	.9358	1.957
3	.9297	.9633	1.64	.9526	.9282	.9404
4	.9663	2.0256	1.6797	.9907	1.9456	1.858
5	1.1157	1.2148	1.9516	1.1385	1.0471	1.1279
6	1.3611	2.6733	2.3807	1.3352	1.1873	2.4996
7	1.4022	1.5181	2.5225	1.3656	1.2574	1.4251
8	1.3245	2.7678	2.5781	1.3397	2.4234	2.5743
9	1.1904	1.2163	1.2955	1.3474	.4664	1.1782
10	1.1553	2.463	1.2711	1.3154	1.5424	1.1782
11	1.0943	1.166	1.1767	1.1416	1.3367	1.1462
12	.9998	2.146	2.0363	1.1126	2.0759	2.1521
13	.9404	.9983	1.0029	.9206	.9617	1.0547
14	1.0258	1.8945	.9922	.8429	.9861	1.9372
15	.9069	1.0517	1.044	.9877	.9953	1.0562
16	1.2254	1.9982	1.9631	1.012	1.8808	2.0911
17	1.1065	1.1248	1.0517	1.2209	1.0059	1.07
18	1.2544	1.2087	1.3062	1.2925	1.0974	2.4066
19	1.4632	1.419	1.5455	1.4601	1.358	1.4068
20	1.4312	2.367	2.8251	1.4114	2.5659	2.6962
21	1.3626	1.3763	1.3458	1.3504	1.3397	1.3214
22	1.3169	1.3032	1.3001	1.2925	1.2544	1.2955
23	1.1782	2.3289	1.198	1.1355	1.1325	2.3258
24	1.038	2.0728	1.9707	1.0044	2.0012	2.2694
Max	1.4632	2.7678	2.8251	1.4601	2.5659	2.6962
Min	.9069	.9633	.9922	.8429	.4664	.9404
Avg	1.1540	1.6352	1.6523	1.1634	1.3614	1.6644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 202 / 11 KV VADJAI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9204		
2	2.7054	1.8519		2.3624
3		1.6804		
4	2.8578	1.5432	2.0233	2.0195
5		1.5432		
6	3.0483	1.5775		2.21
7		1.7147		
8	3.3532	2.332	2.5034	2.7435
10	3.8485			
12	3.4294	2.0576	3.2236	3.8485
14	3.0483			3.315
16		.9602	2.7435	3.5056
20	3.6199	1.3375	3.2922	3.6199
23	2.6292			2.5911
24	2.8197	2.0233	1.989	2.6673
Max	3.8485	2.332	3.2922	3.8485
Min	2.6292	.9602	1.989	2.0195
Avg	3.1360	1.7118	2.6292	2.8883

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 204 / 11 KV WATER SUPPLY

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0762				
4		.0762	.0642		.0198	.1387
5			.1336		.0627	.0631
6	.0663	.1408	.136	.024	.0625	.0112
7	.0676	.0655	.1366	.0661	.0213	.0657
8	.0652	.1398	.1341	.0612	.0976	.1284
9	.0598	.0596	.0615	.0593	.0581	.0625
10	.0633	.1389	.0653	.0591	.0617	.0657
11	.0661	.0659	.0659	.0608	.0636	.0669
12	.0663	.1417	.0949	.0602	.133	.1436
13	.0617	.0625	.0604	.0598	.0625	.0673
14	.0642	.1368	.0596	.0608	.0623	.1427
15	.065	.0608	.06	.0621	.0634	.0676
16	.0623	.1351	.1282	.0623	.1322	.144
17	.0655	.0008	.0594	.0621	.0638	.0673
18	.0625	.0006	.0585	.061	.0617	.141
19	.0623		.0594	.0615	.0619	.0644
20	.0621	.0762	.1292	.061	.1305	.1393
21	.0613		.06	.0598	.0608	.0166
22	.0229		.0093	.0608	.0139	
23		.0762		.0448		.0762
24		.7621			.0343	.0762
Max	.0676	.7621	.1366	.0661	.133	.144
Min	.0229	.0006	.0093	.024	.0139	.0112
Avg	.0614	.1231	.0830	.0582	.0664	.0874

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 205 / Microtower

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	23-FEB-17	24-FEB-17
HR	Load (MW)	Load (MW)
1		.0343
2	.0762	.0343
3		.0343
4	.0762	.0343
5		.0343
6		.0343
7		.0343
8	.0762	.0343
10	.0762	
12	.0762	.0343
14	.0762	
16	.0762	.0343
18	.0762	
20	.0762	.0343
23	.0762	
24	.0762	.0343
Max	.0762	.0343
Min	.0762	.0343
Avg	.0762	.0343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 206 / ABHAY COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.765	1.9738	3.4042	.849	1.5745	1.8214	
2	1.7269	4.0161	3.1589	.8261	1.5684	3.4553	1.5775
3	1.6842	1.9433	2.7968	.8063	1.5592	1.6872	
4	1.6583	3.8089	2.8883	1.9959	2.9233	3.1901	
5	1.6004	1.7955	2.9965	.8124	1.3093	1.5196	
6	1.5653	1.7055	3.2328	.9511	1.2376	3.187	
7	1.7741	1.8778	3.4911	1.2193	1.5638	1.7147	
8	2.2558	4.5496	3.7609	2.6376	3.6435	4.2128	
9	2.5332	2.5636	1.9799	1.989	2.4066	2.4554	
10	2.6033	5.3163	1.8732	2.1064	2.4326	2.4737	
11	2.5499	2.6962	1.8549	2.05	2.556	2.4112	
12	2.8029	5.3696	3.4545	3.36	4.5908	5.1837	
13	2.684	2.5316	1.6217	1.9311	2.3152	2.4935	
14	1.8442	3.6184	1.0822	1.3245	1.5104	3.5802	
15	2.2375	2.1491	.9084	1.5577	1.8549	2.0439	
16	.7072	4.5206	1.7177	2.9196	3.8203	4.5587	
17	2.4082	2.2649	.9069	1.7177	2.0317	2.2573	
18	2.5956	2.3015	1.0197	1.9814	2.1933	5.1044	
19	2.7618	2.5514	1.2468	2.1689	2.4112	2.6581	
20	2.7923	2.7145	2.3457	3.3478	4.5321	5.173	
21	2.2237	2.0637	1.0867	1.7894	1.9494	1.9418	
22	1.9966	1.9875	1.0334	1.6217	1.832	1.8747	
23	2.0957	3.9857	.9633	2.918	1.8397	3.8897	
24	2.0927	4.0603	2.4783	2.8647	3.4042	3.9399	1.5775
Max	2.8029	5.3696	3.7609	3.36	4.5908	5.1837	1.5775
Min	.7072	1.7055	.9069	.8063	1.2376	1.5196	1.5775
Avg	2.1233	3.0152	2.1376	1.9061	2.3775	3.0345	1.5775

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 207 / KABIRGANJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4458		
2	.6097	.4458		.5716
3		.4115		
4	.6478	.4801	.5487	.4954
5		.4801		
6	.6859	.6173		.6859
7		.7202		
8	.8002	.7202	.7202	.8002
10	1.4861			
12	.8002	.7202	.6859	.7621
14	.5716			.6097
16	.724	.4458	.5487	.724
18				.7621
20	.8002	.583	.7545	.8383
23	.6097			.6859
24	.5335	.4458	.5144	.724
Max	1.4861	.7202	.7545	.8383
Min	.5335	.4115	.5144	.4954
Avg	.7517	.5430	.6287	.6963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 208 / 11KV OLD DHULE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7346	.7727	1.4053	.7667	.7514	.7651
2	.7225	1.4891	1.246	.7423	.7346	.759
3	.727	.7621	1.2521	.7392	.7407	.756
4	.8215	1.6903	1.467	.8032	1.6369	1.5242
5	1.1675	1.1919	1.9014	1.1065	1.0623	1.166
6	1.4525	2.5271	2.6543	1.4906	1.3778	1.5318
7	1.5546	1.6339	2.9508	1.5775	1.5638	1.6034
8	1.6369	2.8715	2.9432	1.4861	3.1123	2.9218
9	1.3656	1.2452	1.3672	1.198	1.422	1.2529
10	1.0776	1.8854	1.105	.9663	1.201	1.0151
11	.9663	.9114	.9404	.8993	.9938	.8871
12	.9267	1.48	1.5623	.8535	1.845	1.5699
13	.1966	.7712	.8398	.7819	.8657	.7499
14	.9587	1.4754	.7727	.7468	.8444	1.4266
15	.8794	.7697	.7667	.7179	.8093	.7346
16	.9145	1.4571	1.4183	.7179	1.5509	1.4663
17	.8764	.7682	.7667	.7484	.8368	.7484
18	1.0044	1.7193	.9709	.8825	.9556	1.6735
19	1.2422	1.1675	1.1431	1.1264	1.1645	1.1004
20	1.2269	2.146	2.0896	1.1675	2.2146	1.9799
21	1.1233	1.1446	1.0669	1.1385	1.0974	1.0669
22	1.1248	1.0761	1.0166	1.0532	1.0349	.9785
23	.9953	1.7117	.9191	.9114	.913	1.6735
24	.82	1.5638	1.4685	.7956	1.4907	1.7299
Max	1.6369	2.8715	2.9508	1.5775	3.1123	2.9218
Min	.1966	.7621	.7667	.7179	.7346	.7346
Avg	1.0215	1.4263	1.4181	.9757	1.2591	1.2950

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 209 / NATRAJ FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9404	.9335	1.5204	.5929	.8093	.9046
2	.932	.9694	1.4541	.5639	.7948	.881
3	.8711	.9374	1.3916	.5617	.7072	.82
4	.8848	1.9585	1.5417	.5548	1.4975	1.5897
5	.8589	.8764	1.6309	.5464	.5815	.7537
6	.8733	.8711	1.8595	.615	.583	.7796
7	.9709	.9991	1.9837	.7712	.711	.916
8	1.2422	2.62	2.3449	.9595	2.2459	2.3678
9	1.4487	1.5066	1.3024	1.0982	1.31	1.5264
10	1.4708	3.0026	1.1706	1.1606	1.4205	1.4975
11	1.4495	1.5181	1.3733	1.1164	1.3458	1.4342
12	1.5554	3.0392	2.2565		1.9266	2.8311
13	1.5493	1.4457	1.2872	.4016	1.3725	1.4205
14	1.262	2.271	.9503	.8627	1.1446	2.1155
15	1.0136	1.0395	.7606	1.028	.8703	1.0006
16	.9724	2.4767	1.3055	1.0509	1.9852	2.4219
17	1.3801	1.249	.6668	1.0059	1.0753	1.2788
18	1.3352	1.2201	.6493	1.0219	1.0799	2.5255
19	1.5455	1.3695	.8893	1.1949	1.1294	1.323
20	1.6278	2.617	1.6797	1.2498	2.4585	2.6231
21	1.3161	1.2353	.8261	.9968	1.1736	1.2582
22	1.0646	.9922	.8017	.8848	.9701	1.028
23	1.041	1.9342	.7202	.9236	.9602	1.8983
24	1.0395	1.8298	1.2681	.8764	1.605	1.9913
Max	1.6278	3.0392	2.3449	1.2498	2.4585	2.8311
Min	.8589	.8711	.6493	.4016	.5815	.7537
Avg	1.1935	1.6213	1.3181	.8712	1.2399	1.5494



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 210 / 11 kv Sultaniya

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288		
2		.9259		
3		.8916		
4	1.3336	.8573	1.2346	1.0669
5		1.166		
6		1.406		1.3717
7		1.6461		
8	1.6766	1.749	1.6804	1.6766
10	1.6766			
12	1.6766	1.8861	1.6804	1.6385
14	1.0669			1.2193
16	1.4861	.9259	1.2003	1.3336
18				1.4098
20	1.5623	1.3375	1.4746	1.4861
23	.1143			1.448
24	1.2193	1.0288	1.0288	1.4861
Max	1.6766	1.8861	1.6804	1.6766
Min	.1143	.8573	1.0288	1.0669
Avg	1.3125	1.2374	1.3832	1.4137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 241 / 11 KV INCOMER I

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5277	3.5117	***	3.3459	3.3219	3.4042
2	3.4431	3.4385	***	2.5674	3.235	3.3105
3	3.3905	3.4179	***	2.5354	3.219	3.2899
4	3.4614	***	***	7.7846	***	***
5	3.8386	4.0124	***	3.1207	3.6763	3.9095
6	4.4719	4.776	***	3.8912	4.2638	4.6022
7	4.84	5.1097	***	4.2524	4.7074	4.9977
8	5.0274	***	***	9.6753	***	***
9	4.7462	4.7097	4.7897	4.2204	3.9689	4.6525
10	4.4056	4.3484	4.401	4.0832	4.7074	4.776
11	4.3004	4.3759	4.2227	3.8432	4.4376	4.3964
12	4.3164	9.0238	***	8.978	***	***
13	3.5414	4.0969	3.9643	3.6283	4.0604	4.4673
14	3.7197	3.5848	3.4934	3.1687	3.5071	3.5391
15	3.786	3.7197	3.2419	3.3471	3.5391	3.9712
16	3.3448	8.3013	***	8.6191	***	***
17	4.0055	3.7814	3.187	3.6351	3.7129	4.2273
18	4.2455	3.93	3.2282	3.9095	3.9095	4.6799
19	4.984	4.7897	3.9232	4.6525	4.5999	5.3201
20	4.9314	***	***	9.7691	***	***
21	4.4445	4.3324	3.5963	4.2981	4.1838	4.4742
22	4.2295	4.1244	3.4019	4.0146	4.0169	4.1289
23	4.1152	***	3.1436	8.9757	3.8112	***
24	3.7471	***	***	***	***	***
Max	5.0274	20.2446	18.5208	11.7467	18.1985	19.5131
Min	3.3448	3.4179	3.1436	2.5354	3.219	3.2899
Avg	4.1193	7.3141	8.6745	5.3359	6.8529	7.9493

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 242 / 11KV INCOMER II

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		6.9959		
2		6.1728		
3		6.1728		
4	***	6.1728	7.6132	7.5446
5		6.3786		
6		6.9959		
7		8.3333		
8	***	9.5679	9.6708	***
12	4.9154	8.3333	***	***
16	4.3439	5.2469	9.6708	***
20	***	5.7613	***	***
23	9.7165			9.8308
24	9.6022	6.9959	7.4074	9.4879
Max	13.2602	9.5679	12.1399	13.8318
Min	4.3439	5.2469	7.4074	7.5446
Avg	9.1450	6.9273	9.7051	11.0393

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 424 / 33 KV INCOMER I

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	11.5912	11.1111	20.4733	15.6036	10.1852	10.5624	2.8807
2	10.8368	10.5967	18.69	15.1235	9.9451	10.2538	
3	10.8025	10.5281	18.2442	14.6091	9.8423	10.1509	2.9835
4	10.631	10.4938	18.6214	13.9575	20.3361	13.3973	3.3951
5	11.1111	11.0768	20.6105	15.535	10.3224	10.7682	
6	12.38	12.9973	24.4171	18.7929	11.5912	12.3457	4.0124
7	14.3004	15.0892	27.4005	22.3595	13.1344	14.369	3.4979
8	14.9177	20.6676	28.6352	24.4856	27.8121	19.9017	3.4979
9	15.3292	14.952	15.7408	13.7517	14.9177	14.369	3.9095
10	13.6831	13.4431	14.6091	12.4486	12.8944	15.0892	3.8066
11	12.9973	13.1344	13.546	12.0371	13.203	14.8491	3.7551
12	13.1002	13.203	22.8738	14.0604	25.6173	19.01	4.0124
13	13.1687	12.7572	12.4143	11.3855	13.0316	14.3347	3.7643
14	9.9451	11.7627	11.6598	10.0823	11.6598	12.9973	4.2181
15	11.214	10.5967	10.3224	9.465	10.2195	11.3169	4.321
16	11.8999	15.7065	17.3183	12.3457	21.2277	17.3754	4.4239
17	11.1454	11.3855	9.9451	10.0137	11.1797	13.2373	4.5268
18	12.4829	11.3512	9.808	10.8711	11.2483	13.0316	4.4239
19	13.8889	12.6886	10.4595	12.38	12.1399	14.6434	4.4753
20	15.1921	19.6159	19.1016	13.8889	27.5035	21.6392	
21	14.7462	13.7517	11.6941	13.203	13.5117	15.9122	
22	12.7572	12.62	11.3512	11.9685	12.1056	13.4088	
23	12.4486	16.3466	10.4595	14.0604	11.6941	17.1697	
24	12.1056	16.3123	18.9643	18.4499	18.8615	16.5867	3.3436
Max	15.3292	20.6676	28.6352	24.4856	27.8121	21.6392	4.5268
Min	9.9451	10.4938	9.808	9.465	9.8423	10.1509	2.8807
Avg	12.6115	13.4245	16.5567	14.2033	14.7577	14.4466	3.8471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094036 / 33/11 KV AGRI. COLLAGE

Feeder No / Name : 425 / 33 KV INCOMER II

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		6.9959	4.1152			2.1376
2		6.7901	3.7037			2.2611
3		6.1728	3.4979			2.3594
4	3.3722	6.1728	4.0124	7.6132	3.2007	2.8292
5		6.2757	4.7325			2.3148
6		6.9959	6.3786			2.8292
7		8.3333	6.3786			2.7778
8	4.1724	9.5679	7.2017	9.7737	3.5437	2.8292
9						2.9835
10						2.8807
11						2.9835
12	4.7439	8.3333	2.572	11.7284	4.7439	3.1893
13						2.9835
14						2.9504
15						3.1893
16	4.1724	5.2469	2.572	9.6708	4.6868	3.1893
17						3.3653
18						3.1459
20	4.401	5.7613	2.572	12.1399	4.5725	
23	3.4294		2.572		3.4294	
24	3.2007	7.2017	4.1152	7.4074	3.1436	2.6749
Max	4.7439	9.5679	7.2017	12.1399	4.7439	3.3653
Min	3.2007	5.2469	2.572	7.4074	3.1436	2.1376
Avg	3.9274	6.9873	4.1864	9.7222	3.9029	2.8355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094040 / 33/11 KV UMRAONAGAR

Feeder No / Name : 202 / 11 KV AKASHWANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3083	2.4074	2.3487	1.2932	2.2855	1.2872	1.0802
2	2.2984	2.3213	2.3224	2.4187	2.2001	1.2285	1.0974
3	2.2641	2.3011	2.3106	1.2224	2.1872	1.2003	1.1145
4	2.2565	2.2782	2.2489	2.3195	2.1315	1.0982	1.166
5	2.3373	2.4245	2.3422	1.2216	2.4341	1.169	1.2003
6	2.6856	2.7641	2.5617	1.515	2.742	1.4655	1.3889
7	2.835	2.9477	2.9355	3.1069	3.0399	1.5577	1.4575
8	2.7458	2.8022	2.9081	2.969	2.9584	1.4982	1.3889
9	2.5256	2.476	2.6437	1.4038	2.7222	2.4981	1.1317
10	2.2204	2.2474	2.4135	1.2993	2.5637	2.2573	1.0974
11	2.0058	2.1719	2.207	1.1256	1.201	2.053	1.0631
12	1.8846	2.0713	2.0027	2.0076	1.2048	1.8587	1.0288
13	2.0618	2.0176	2.0675	1.057	1.1744	1.9597	.9945
14	2.0271	2.0702	1.1385	2.0296	1.1629	2.0462	.9945
15	2.0401	2.1015	1.1256	1.0524	2.2055	1.949	.9945
16	2.1094	2.0149	2.15	1.9958	2.261	2.0873	.9945
17	2.1129	2.0241	2.1248	2.0996	2.233	1.9936	.9945
18	2.2054	2.1437	2.3227	2.2008	2.2802	2.2466	1.0974
19	3.1356	2.8937	3.0126	3.0605	3.2585	2.8799	1.4403
20	3.1656	3.0551	3.1488	2.9545	3.3216	3.0803	1.406
21	3.1352	3.0346	3.1877	2.9553	3.2478	3.1196	1.3717
22	3.1382	2.9896	3.123	2.8662	3.1442	3.11	1.4403
23	2.8978	3.1588	2.9296	2.6993	2.8717	2.7626	1.3032
24	2.4562	2.4753	2.4577	2.5472	2.444	1.2986	1.0974
Max	3.1656	3.1588	3.1877	3.1069	3.3216	3.1196	1.4575
Min	1.8846	2.0149	1.1256	1.0524	1.1629	1.0982	.9945
Avg	2.4522	2.4663	2.4181	2.0592	2.3865	1.9877	1.1810

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DEOPUR[215]

BU 5568

Substation No/ Name :- 094040 / 33/11 KV UMRAONAGAR

Feeder No / Name : 241 / 11KV INCOMER I

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8043	3.9872	3.8089	3.9278	3.7449	3.9689	
2	3.6397	3.8089	3.658	3.7814	3.562	3.7632	
3	3.5437	3.7037	3.6031	3.7083	3.4705	3.6534	
4	3.4431	3.5345	3.5437	3.5208	3.1504	3.3608	
5	3.3882	3.6031	3.3836	3.4934	3.4842	3.4065	
6	4.0284	4.1061	3.7814	4.2936	4.3942	4.1015	
7	4.6594	4.7965	4.5679	4.8834	4.8468	4.7142	
8	4.7737	4.7508	4.8468	4.8423	4.824	4.6411	
9	4.2936	4.225	4.4993	4.3393	4.6136	4.2936	
10	3.8317	3.7906	4.1792	3.9689	4.2524	3.8912	
11	3.4705	3.626	3.6991	3.5071	3.7677	3.4385	
12	3.0819	3.4339	3.4111	3.2465	3.6168	3.1413	
13	3.283	3.1916	3.3288	3.2099	3.6168	3.1733	
14	3.3516	3.3242	3.4339	3.2419	3.5254	3.315	
15	3.3288	3.3608	3.4385	3.2145	3.3745	3.2099	
16	3.4248	3.4659	3.3699	3.0956	3.2556	3.3745	
17	3.5162	3.3653	3.4065	3.3059	3.5574	3.3425	
18	3.5025	3.2739	3.4156	3.3516	3.562	3.4156	
19	4.7737	4.3804	4.0924	4.545	4.5953	4.3987	
20	5.1943	4.8651	4.9703	4.8377	5.2355	4.9429	
21	5.1075	4.8788	4.9566	4.7554	5.0755	4.9611	
22	5.0846	4.8926	4.9703	4.7462	5.0069	5.0252	
23	4.8331	4.6776	4.7554	4.5542	4.6731	4.8057	3.9609
24	4.2524	4.1198	4.257	3.9598	4.1975	4.1061	
Max	5.1943	4.8926	4.9703	4.8834	5.2355	5.0252	3.9609
Min	3.0819	3.1916	3.3288	3.0956	3.1504	3.1413	3.9609
Avg	3.9838	3.9651	3.9741	3.9304	4.0585	3.9352	3.9609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 202 / 11 KV CIRCUIT HOUSE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1425	.1768	.1753	.1372	.1431	.1615	.1486
2	.1425	.1598	.1753	.1526	.1433	.1612	.1486
3	.1425	.1605	.1753	.1734	.1433	.1436	.1655
4	.1425	.1614	.1753	.1753	.1433	.1433	.2206
5	.1781	.1812	.1753	.1781	.1789	.1457	.2229
6	.2138	.1846	.1791	.2206	.2147	.1646	.2229
7	.2138	.2035	.1791	.2763	.2147	.185	.2601
8	.2729	.1989	.2183	.3309	.322	.1812	.2328
9	.4003	.2686	.2701	.2865	.3176		.2149
10	.4597	.3582	.3601	.2686	.3176	.2715	.2149
11	.4225	.4477	.3241	.2507	.3697	.3639	.1791
12	.296	.4477	.2672	.2686	.3517	.332	
13	.296	.3582	.285	.2328	.3669	.2758	.2147
14	.4005	.3582	.3028	.216	.3669	.2574	.2675
15	.3839	.3582	.3206	.2341	.3657	.1839	.2862
16	.3923	.3582	.2686		.3134	.2206	.2701
17	.3753	.3582	.3086	.197	.2601	.2577	.2701
18	.3217	.3582	.3429	.1962	.1922	.2138	.2521
19	.3525	.3582	.3028	.1791	.2124	.285	.2328
20	.3429	.3544	.2643	.18	.32	.3125	.2147
21	.2229	.3544	.1762	.216	.3582	.2183	.2147
22	.2229	.2686	.2092	.1789	.3936	.18	.2142
23	.2058	.1791	.162	.1789	.323	.2574	.1791
24	.1425	.193	.1753	.1456	.1431	.18	.2218
Max	.4597	.4477	.3601	.3309	.3936	.3639	.2862
Min	.1425	.1598	.162	.1372	.1431	.1433	.1486
Avg	.2786	.2836	.2414	.2119	.2698	.2216	.2204



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 203 / 11 KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND

UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.1576	.2629	.2058		.2899	.2766
2	.2743	.2817	.2629	.2035	.2195	.3635	.3158
3	.2743	.3877	.2629	.2543	.2743	.3261	.3715
4	.3113	.3555	.2629	.2643	.3658	.3083	.3309
5	.3258	.3769	.3506	.2672	.3109	.3103	.3309
6	.3544	.3647	.3582	.3563	.3292	.2749	.3677
7	.3658	.4795	.3582	.3677	.2926	.2772	.3158
8	.2926	.2923	.2896	.3093	.2743	.2738	.3475
9	.3244	.3582	.3241		.2841	.3309	.3841
10	.3377	.4477		.3109	.2817	.2547	.4024
11	.3885	.4477	.2881	.4572	.3709	.4501	.3658
12	.4027	.4477	.2701	.3109	.3517	.4412	.3658
13	.4031	.4477	.3172	.3109	.3158	.2574	.4024
14	.4349	.4477	.3241	.2743	.2976	.2183	.4207
15	.4865	.4477	.3601	.2743	.2973	.2206	.439
16	.5316	.4477	.3028	.2561	.2957	.2743	.462
17	.3403	.4477	.3391	.2035	.2951	.2715	.4572
18	.4303	.2686	.2543	.1829	.052	.2206	.3841
19	.4294	.2686	.4097	.2378	.1939	.2475	.3658
20	.2915	.2658	.3206	.2743	.2847	.2743	.3292
21	.3258	.2658	.3206	.3292	.3057	.3241	.3292
22	.3601	.3582	.3741	.2926	.2881	.2183	.3721
23	.2743	.3582	.3241	.2743	.2914	.2574	.3475
24	.2926	.2798	.2629	.2798	.2743	.2542	.239
Max	.5316	.4795	.4097	.4572	.3709	.4501	.462
Min	.2743	.1576	.2543	.1829	.052	.2183	.239
Avg	.3553	.3625	.3130	.2825	.2846	.2891	.3635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 204 / AJINKYA TARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7194	.7434	.8764	.775	.5424	.8085	.8089
2	.7194	.745	.8764	.8139	.5424	.8076	.8359
3	.7194	.7506	.8764	.8573	.5786	.7171	.8102
4	.7913	.8076	.8764	.0876	.6104	.753	1.0143
5	.9532	1.0656	.8764	.9797	.8498	1.0028	1.0217
6	.9892	1.3108	1.1641	1.1031	.904	1.39	1.287
7	1.0252	1.5154	1.4327	1.195	.904	1.628	1.3932
8	1.0791	1.3756	1.2963	1.287	1.3741	1.448	1.3004
9	1.0917	1.0745	1.0802	1.0848	1.2702	1.287	1.2643
10	.8654	.8954	.985	1.0848	1.095	1.0007	1.2643
11		.8954	.8954	.452	1.0034	1.0371	1.2462
12	.9065	.8954	.8417	.5062	.8959	1.0112	1.174
13	.9065	.7164	.8551	.5424	.8395	.9193	.9402
14	.7314	.7164	.793	.8317	.7679	.9193	.8679
15	.695	.7164	.8016	.8136	.7338	.8825	.669
16	.6791	.7164	.8907	.8498	.781	.8273	.6328
17	.7498	.7164	.8573	.8462	.8166	.956	.7051
18	.7863	.7164	.8817	.8139	.9619	1.1703	.8136
19	1.0867	1.1641	1.1703	.9944	1.148	1.247	.904
20	1.1145	1.1517	1.247	1.1391	1.247	1.2502	1.1343
21	1.0802	1.0631	1.0574	1.0667	1.2165	1.1827	
22	1.0288	1.0745	.9588	.9934	1.1462	.9902	1.0994
23	.9431	.985	.8907	.904	1.0208	.9193	1.0487
24	.8633	.808	.8764	.8852	.904	.8573	.8273
Max	1.1145	1.5154	1.4327	1.287	1.3741	1.628	1.3932
Min	.6791	.7164	.793	.0876	.5424	.7171	.6328
Avg	.8924	.9425	.9732	.8711	.9231	1.0422	1.0027

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 205 / 11 KV MOGLAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.1568	1.2269	1.1145	1.0288	1.1584	1.1031
2	1.0288	1.1619	1.2269	1.1022	1.0288	1.0905	1.1031
3	1.0288	1.1644	1.2269	1.1869	1.0288	1.0883	1.2074
4	1.0974	1.3375	1.2269	1.2336	1.0631	1.0894	1.287
5	1.286	1.5647	1.2269	1.3403	1.3889	1.2607	1.287
6	1.5432	1.7887	1.5223	1.4654	1.6289	1.5762	1.5076
7	1.7147	1.9754	1.7013	1.7285	1.7147	1.7778	1.7833
8	1.8861	1.829	1.8904	1.8385	1.7147	1.7887	1.6289
9	1.6924	1.6118	1.6204	1.5432	1.7147	1.6461	1.6118
10	1.4738	1.4327		1.5261	1.5735	1.5465	1.6118
11	1.3731	1.2536	1.4327	1.3546	1.3716	1.3143	1.5432
12	1.2068	1.2536	1.3503	1.3375	1.2675	1.2986	1.5432
13	1.2068	1.1641	1.2336	1.2003	1.2283	1.2502	1.3032
14	1.1828	1.1641	1.0688	1.166	1.1919	1.1031	1.2346
15	1.1294	1.1641	.9797	1.2003	1.1181	1.0112	1.0974
16	1.0843	1.1641	1.1579	1.1736	1.112	1.0974	1.0631
17	1.0913	1.1641	1.166	1.0288	1.112	1.267	1.0288
18	1.2729	1.2536	1.286	1.0288	1.3074	1.5627	1.166
19	1.7711	1.7909	1.6389	1.406	1.6724	1.7814	1.3032
20	1.7318	1.7718	1.7635	1.6461	1.7376	1.7285	1.4918
21	1.6289	1.6832	1.6923	1.5432	1.7229	1.6547	1.6804
22	1.5432	1.6118	1.6032	1.4575	1.5091	1.3503	1.5775
23	1.4918	1.4327	1.4403	1.3375	1.4192	1.287	1.3032
24	1.2003	1.2431	1.2269	1.3375	1.1831	1.2372	1.195
Max	1.8861	1.9754	1.8904	1.8385	1.7376	1.7887	1.7833
Min	1.0288	1.1568	.9797	1.0288	1.0288	1.0112	1.0288
Avg	1.3623	1.4224	1.3873	1.3457	1.3683	1.3736	1.3609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094012 / NAKANE

Feeder No / Name : 206 / SRP Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1431	.1949	.1753	.1715	.1791	.1978	.1858
2	.1431	.1778	.1753	.1696	.1791	.1799	.1839
3	.1789	.1783	.1753	.1715	.1791	.1791	.2043
4	.2147	.197	.1753	.1743	.1791	.197	.2574
5	.2683	.2531	.1753	.3172	.197	.2911	.2972
6	.3399	.3688	.3582	.3677	.2149	.365	.3677
7	.3578	.4426	.3582	.4003	.2149	.4435	.3715
8	.3578	.3805	.3275	.3639	.4119	.3639	.3582
9	.2914	.2686	.3781	.3051	.3356	.3677	.3052
10	.2475	.2686		.2333	.2465	.3275	.2543
11	.2293	.1791	.2686	.2154	.2108	.2547	.2035
12	.1743	.1791		.1974	.1932	.2206	.1696
13	.1743	.1791	.2115	.1974	.193	.332	.1791
14	.1564	.1791	.1781	.1791	.1743	.2206	.1791
15	.1738	.1791	.1772	.1791	.1915	.2206	.1791
16	.1783	.1791	.1425	.1791	.1911	.2561	.1791
17	.1783	.1791	.1715	.197	.2085	.7202	.2149
18	.2323	.1791		.1865	.2269	.2701	.197
19	.2499	.2686	.2521	.2149	.2646	.2672	.2341
20	.2401	.1791	.1781	.2865	.2672	.2206	.2701
21	.2572	.1791	.2115		.2507	.1819	.2701
22	.2058	.1791	.2115	.2328	.2518	.162	.2686
23	.2058	.1791	.141	.216	.2333	.2206	.216
24	.1789	.2108	.1753	.1456	.1791	.2154	.2206
Max	.3578	.4426	.3781	.4003	.4119	.7202	.3715
Min	.1431	.1778	.141	.1456	.1743	.162	.1696
Avg	.2241	.2233	.2199	.2305	.2239	.2781	.2403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV SUNAVKAR-OM SHREE  
AGRO Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	1.0288	1.0642	.9149	1.0098	.9896	.9709
2		1.0669	1.0642	.9149	1.0098	.9896	1.0082
3	.9907	1.086	1.0456	.8962	1.0098	.9896	1.0456
4	1.0098	1.105	1.0456	.8962	1.0098	.9896	1.0829
5	1.0479	1.105	1.0456	.8962	1.0098	.9896	1.1203
6		1.1241	1.0269	.8775	1.0288	1.0082	1.1576
7	1.0669	1.105	1.0269	.8962	1.0479	1.0082	1.1576
8	1.086	1.1431	1.0269	.8775	1.0479	1.0269	1.3256
9	1.2193	1.2384	1.1576	.8962	1.1241	1.1576	1.475
10	1.4861	1.4098	1.2323	.9709	1.2765	1.419	1.531
11	1.5051	1.5813	1.3443	1.0456	1.3908	1.5123	1.4937
12	1.4098	1.531	1.3256	1.105	1.1622	1.475	1.4937
13	1.4098	1.475	1.307	1.086	1.0669	1.4003	1.475
14	1.4289	1.4563	1.2323	1.1812	.9335	1.419	1.4563
15	1.448	1.3817	1.2136	1.2955	.8002	1.3256	1.4377
16	1.4861	1.3443	1.2696	1.3336	.6859	1.307	1.4563
17	1.4289	1.2696	1.0082	1.1812	.724	1.307	1.4003
18	1.2574	1.2136	1.0829	1.1431	.7621	1.3256	1.363
19	1.2574	1.1949	.4108	1.1241	.7811	1.3443	1.307
20	1.0288	1.1203		.9907	.8002	1.1203	1.2883
21	1.0288	1.1389		.9526	.8002	.9709	1.1576
22	1.0098	1.1016	.5415	.7621	.9145	.9709	1.0642
23	1.0288	1.1016	.8775	.9526	.9907	.9896	1.0269
24	.8764	1.0098	1.0642	.9335	1.0098	.9896	.9522
Max	1.5051	1.5813	1.3443	1.3336	1.3908	1.5123	1.531
Min	.8764	1.0098	.4108	.7621	.6859	.9709	.9522
Avg	1.2003	1.2222	1.0642	1.0051	.9748	1.1677	1.2603

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV LAURAL-COLDSTORAGE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.2614	.2801	.2667	.4294	.3174
2	.381	.381	.2987	.2614	.2667	.4294	.3361
3	.4001	.362	.3174	.2614	.2667	.4294	.3734
4	.4001	.3429	.3361	.2427	.2667	.4294	.3921
5	.4001	.3429	.3547	.2427	.2667	.4108	.4108
6	.4191	.362	.3734	.2241	.2858	.4108	.3921
7	.4191	.3429	.3921	.2241	.3048	.4108	.4108
8	.3239	.3239	.4108	.2054	.3239	.4108	.5415
9	.4572	.4191	.4668	.2241	.5144	.5415	.5975
10	.743	.5716	.5975	.2241	.5906	.5975	.7095
11	.724	.7049	.7468	.2241	.6668	.6535	.6908
12	.7621	.6722	.7468	.2477	.6859	.7282	.7282
13	.7811	.6161	.7655	.2667	.7049	.7468	.7468
14	.7811	.6348	.7282	.2858	.724	.7842	.7468
15	.7621	.6348	.7095	.2858	.743	.7842	.7842
16	.8002	.6722	.7282	.3239	.743	.7655	.7842
17	.7621	.6348	.6535	.3048	.6668	.6722	.7095
18	.4572	.5788	.5228	.2858	.6097	.5601	.5975
19	.4572	.4668	.4108	.2477	.5144	.4854	.4854
20		.4294	.3921	.2667	.4763	.4294	.4481
21	.3429	.3734	.3547	.2858	.4763	.3921	.4481
22	.362	.3174	.3174	.2858	.4572	.3734	.4294
23	.362	.2801	.2801	.2667	.4382	.3174	.4294
24	.4191	.381	.2614	.2614	.2667	.4294	.2987
Max	.8002	.7049	.7655	.3239	.743	.7842	.7842
Min	.3239	.2801	.2614	.2054	.2667	.3174	.2987
Avg	.5260	.4678	.4761	.2595	.4803	.5259	.5337

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KVMADHUR -R M CHEMICAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0934	.0934	.112	.0762	.0747	.0934
2	.0953	.0934	.0934	.0934	.0762	.0747	.0934
3	.0953	.0934	.0934	.0934	.0762	.0747	.0934
4	.0953	.0934	.0934	.0934	.0762	.0747	.0934
5	.0953	.0934	.0934	.112	.0762	.0747	.112
6	.0953	.112	.112	.112	.0762	.0934	.112
7	.0953	.112	.112	.1132	.0762	.0934	.112
8	.0953	.112	.112	.112	.0762	.0934	.1307
9	.1143	.112	.112	.0934	.0762	.112	.1494
10	.1524	.1494	.112	.0747	.0572	.1307	.168
11	.1334	.168	.112	.0373	.0572	.0747	.1494
12	.1715	.168	.112	.0381	.0572	.0747	.1494
13	.2096	.2054	.112	.0381	.0572	.0747	.1307
14	.1905	.1867	.112	.0381	.0572	.0934	.1307
15	.1334	.1494	.112	.0572	.0572	.0934	.1307
16	.0953	.1307	.112	.0762	.0572	.112	.112
17	.0953	.112	.112	.0762	.0572	.112	.112
18	.1143	.0934	.0934	.0953	.0762	.0934	.112
19	.1143	.0747	.0934	.0953	.0953	.0934	.112
20	.1143	.0747	.0934	.0953		.0934	.112
21	.1143	.0747	.0934	.1143	.0953	.112	.112
22		.0934	.0934	.1143	.0953	.0934	.0934
23	.0953	.0934	.0934	.0953	.0762	.0934	.0934
24	.0953	.0747	.0934	.0934	.0953	.0747	.0934
Max	.2096	.2054	.112	.1143	.0953	.1307	.168
Min	.0953	.0747	.0934	.0373	.0572	.0747	.0934
Avg	.1176	.1152	.1027	.0864	.0729	.0910	.1167

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV NIRMAL-R K AGRO  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.2801	.3361	.3174	.1524	.2987	.3547
2	.381	.2987	.3547	.2987	.1524	.2987	.3734
3	.362	.2987	.3547	.2801	.1524	.2987	.4108
4	.362	.3174	.3361	.2614	.1524	.2987	.3921
5	.3429	.3174	.3361	.2427	.1524	.2987	.4108
6	.362	.3547	.1867	.1867	.1524	.3174	.4294
7	.381	.3361	.3361	.168	.1715	.3361	.4481
8	.3429	.3361	.3361	.1494	.1715	.3361	.7282
9	.4763	.4108	.4108	.1494	.1715	.4668	.8402
10	.5716	.6348	.5601	.1867	.1715	.5788	.9896
11	.5906	.8029	.7655	.2286	.1524	.6535	.9522
12		.7842	.7655	.2286	.3239	.7095	.9335
13		.8029	.7468	.2286	.5525	.7282	.9149
14		.7842	.7095	.2286	.6097	.8029	.9149
15		.7842	.7095	.1524	.6478	.8402	.9149
16		.7468	.7468	.1715	.6859	.9149	.9335
17		.7468	.5975	.1715	.6859	.7842	.7842
18		.7282	.5601	.1905	.6097	.7468	.6348
19		.4854	.3921	.1905	.4763	.6908	.4854
20		.4294	.3734	.2096	.3429	.5975	.3734
21		.3921	.3547	.2096	.3429	.4481	.3734
22		.3734	.3547	.2096	.3048	.3734	.3921
23		.3547	.3361	.1715	.2858	.3361	.4108
24	.381	.2801	.3361	.3174	.1524	.2801	.3361
Max	.5906	.8029	.7655	.3174	.6859	.9149	.9896
Min	.3429	.2801	.1867	.1494	.1524	.2801	.3361
Avg	.4096	.5033	.4707	.2145	.3239	.5181	.6138



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 208 / Dama water supply  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.4854	.4854	.0762	.2241	.1867
2	.5144	.4763	.4854	.4481	.0762	.2241	.1867
3	.5144	.4763	.4668	.3921	.0762	.2054	.2054
4	.4954	.4572	.4668	.3734	.0762	.2054	.2054
5	.4954	.4572	.4668	.3547	.0762	.2241	.1867
6	.5144	.4572	.4481	.3734	.0953	.2054	.1886
7	.5335	.4763	.4481	.3547	.1334	.2241	.1867
8	.5144	.4572	.4481	.3361	.1524	.2241	.2054
9	.5335	1.2955	.4854	.2241	.1905	.2241	.2427
10	.5525	.5906	.5228	.0747	.1905	.2614	.3361
11	.5525	.6668	.5788	.0747	.2096	.2801	.3547
12	.5716	.6348	.5975	.0762	.2286	.2987	.3174
13	.5906	.5788	.5601	.0762	.2667	.2987	.2801
14	.5906	.5601	.5788	.0762	.2858	.3174	.2987
15	.5716	.5788	.5788	.0762	.2858	.3174	.2614
16	.5906	.5601	.5788	.0762	.3048	.3361	.2241
17	.5716	.5228	.5228	.0572	.2858	.2801	.2241
18	.5335	.4854	.4854	.0762	.2858	.2427	.2241
19	.4954	.4481	.4668	.0572	.2477	.2241	.2241
20	.4763	.4668	.4854	.0572	.2286	.2241	.2241
21	.4572	.4668	.4854	.0572	.2286	.2054	.2241
22	.4763	.4668	.5041	.0572	.2286	.2054	.2241
23	.4763	.4668	.5228	.0762	.2286	.2054	.2241
24	.4572	.4763	.4854	.4904	.0762	.2241	.2054
Max	.5906	1.2955	.5975	.4904	.3048	.3361	.3547
Min	.4572	.4481	.4481	.0572	.0762	.2054	.1867
Avg	.5231	.5416	.5064	.2001	.1889	.2451	.2350

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 210 / New Madhur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8037	2.6953	2.3824	2.7802	2.6688	2.7839	1.226
2	2.7854	2.6581	2.4185	2.7517	2.6337	2.6993	1.2637
3	2.6627	2.6109	2.3889	2.6746	2.6962	2.7427	1.2826
4	2.6635	2.5753	2.0151	2.6404	2.6398	2.793	1.2637
5	2.5743	2.5335	2.3337	2.6291	2.6352	2.7553	1.3014
6	2.6223	2.5655	2.5202	2.557	2.6292	2.8266	1.3203
7	2.6657	1.5221	2.5461	2.6356	2.5499	2.8366	1.3203
8	2.6711	2.533	2.5269	2.5574	2.4005	2.7848	1.358
9	2.7633	2.5019	2.7203	2.7197	2.5621	2.9759	1.5844
10	2.9211	2.4779	2.9814	2.7092	2.7961	3.1927	1.6787
11	2.9568	2.0775	3.3042	2.7987	2.918	3.3814	1.6617
12	2.9965	2.0349	3.2937	2.8821	3.014	3.3849	1.6956
13	2.8845	2.2049	3.3886	2.7946	3.0011	3.416	1.6956
14	2.95	2.2447	3.1337	2.7572	2.9805	3.3087	1.6956
15	3.0347	2.4592	3.212	2.8669	3.1337	3.3326	1.6956
16	3.0384	2.4802	3.2521	2.9309	3.1878	3.3152	1.6575
17	3.0651	2.5322	3.2007	2.8273	3.1246	3.248	1.6194
18	3.0072	2.5907	3.1194	2.7267	2.9446	3.1758	1.5432
19	2.8608	2.6099	3.0496	2.6886	2.7587	3.096	1.448
20	2.7191	2.498	2.9656	2.6239	2.6498	2.9912	1.4289
21	2.6742	2.3114	2.806	2.5187	2.6056	3.0089	1.4289
22	2.6909	2.3641	2.7561	2.5248	2.6017	3.0199	1.4289
23	2.7245	2.3438	2.8103	2.6284	2.7641	3.0091	1.448
24	2.7199	2.4895	2.2332	2.7016	2.7221	2.9561	1.2826
Max	3.0651	2.6953	3.3886	2.9309	3.1878	3.416	1.6956
Min	2.5743	1.5221	2.0151	2.5187	2.4005	2.6993	1.226
Avg	2.8107	2.4131	2.8066	2.7052	2.7757	3.0431	1.4720

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 211 / New Deesan

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.2666	6.2007	5.6077	4.4677	4.286	2.7572	2.32
2	6.3763	6.0473	5.2597	4.5083	4.1069	2.8029	2.3388
3	6.2536	6.169	5.0189	4.4281	4.1419	2.7176	2.3577
4	6.2064	6.0315	4.7736	5.0299	3.956	2.7405	
5	6.0357	5.9884	4.5848	5.234	4.0276	2.7519	2.4143
6	5.6577	6.0216	4.4408	5.0507	3.9141	2.7206	2.4143
7	5.4046	5.9611	4.2907	4.9326	3.2609	2.8229	2.452
8	5.5731	5.7684	3.7922	4.7434	2.9302	2.9178	2.6217
9	5.8178	5.6504	3.7517	4.563	3.2845	3.7714	2.7349
10	6.7033	6.3417	4.199	5.2702	3.6511	4.8211	3.1121
11	6.8709	6.8461	4.751	5.4519	3.9171	5.8204	3.131
12	3.4797	6.9781	4.8164	5.5289	3.8935	5.8604	3.0864
13	3.514	6.9314	4.695	5.6805	3.8401	5.812	3.0483
14	3.3432	6.8099	4.5759	5.3749	3.6435	5.6354	2.9912
15	3.3676	7.0354	4.8219	5.442	3.0788	5.5676	2.9531
16	3.3768	7.0811	4.8009	5.3536	2.8745	5.7457	2.934
17	3.4682	7.0616	4.6719	5.5746	2.9233	6.0828	2.8578
18	3.0521	7.005	4.3456	5.4611	2.8471	6.059	2.8006
19	2.9043	6.3818	4.1934	5.5533	2.7419	6.173	2.7625
20	2.8045	6.127	3.875	5.5015	2.585	5.7236	2.7435
21	3.0034	5.9713	4.0903	5.3567	2.4767	5.1968	2.7435
22	3.2579	6.1934	4.4831	5.5662	2.6772	5.3791	2.7244
23	3.2708	6.1319	4.5089	5.16	2.7541	5.3689	2.6863
24	6.1386	6.2131	5.5289	4.8568	3.6557	4.2166	2.3577
Max	6.8709	7.0811	5.6077	5.6805	4.286	6.173	3.131
Min	2.8045	5.6504	3.7517	4.4281	2.4767	2.7176	2.32
Avg	4.6728	6.3728	4.5782	5.1704	3.3945	4.5611	2.7211

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094014 / 33/11 KV MIDC

Feeder No / Name : 212 / New RMC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6373	3.5776	4.957	4.1908	4.9147	3.677	2.1691
2	4.6555	3.5641	4.9461	4.1832	4.9124	3.6595	2.2068
3	4.5709	4.0511	4.8497	4.172	4.904	3.6664	2.1879
4	4.619	3.5764	4.7148	4.1455	4.888	3.9552	2.2257
5	4.5252	3.5208	4.7418	4.1187	4.9337	4.3395	2.2822
6	4.5992	3.5092	4.7765	4.2305	4.904	4.92	2.3011
7	4.42	3.4812	4.7091	4.2646	4.907	5.1109	2.32
8	4.5207	3.3739	4.5357	4.2151	4.8582	5.1322	2.4331
9	4.75	3.6024	4.7763	4.1259	5.1806	5.3208	2.6783
10	5.3589	3.9434	5.209	4.4401	5.3757	5.688	2.7915
11	5.6386	4.6017	5.8503	4.6515	5.0427	6.0033	2.8104
12	5.6783	4.6338	5.7638	4.9109	5.176	6.0103	2.8769
13	5.6333	4.2987	5.5731	4.8422	5.4649	5.9025	2.915
14	5.2043	4.0939	5.3285	4.7303	5.7964	5.7278	2.9531
15	5.2156	4.2493	5.2747	4.8324	6.3161	5.9372	2.9721
16	4.4292	4.3984	5.192	4.6502	6.4868	6.2226	2.9912
17	4.2143	4.9993	5.0248	4.5047	6.3923	6.0402	2.6863
18	4.7134	5.3247	4.9632	4.2654	6.3207	5.8897	2.6863
19	4.8834	5.1391	4.8697	4.0116	5.8124	5.6418	2.4768
20	4.7271	5.1501	4.6858	3.9933	5.2774	5.2629	2.3434
21	4.8681	4.9683	4.4667	4.0824	5.0595	4.8916	2.3434
22	4.7104	4.9286	4.3541	3.9796	4.8621	4.8545	2.3243
23	3.8889	4.9798	4.2119	4.638	4.7204	4.879	2.191
24	4.1236	4.2385	4.7485	4.4629	4.8384	4.4509	2.2068
Max	5.6783	5.3247	5.8503	4.9109	6.4868	6.2226	2.9912
Min	3.8889	3.3739	4.2119	3.9796	4.7204	3.6595	2.1691
Avg	4.7744	4.2585	4.9385	4.3601	5.3060	5.1327	2.5155

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 201 / 11 KV RAJWADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6562	2.6147	2.5614	2.4166	2.4943	2.5035	1.2003
2	2.5187	2.5553	2.5263	2.3678	2.4379	2.4852	1.2003
3	2.4943	2.5416	2.5035	2.3587	2.3323	2.2939	1.1145
4	2.4989	2.5248	2.5187	2.3617	2.3049	2.2954	1.1145
5	2.5888	2.7648	2.708	2.5004	2.378	2.5629	1.1145
6	2.9001	2.9812	3.1832	2.8727	2.564	3.0346	1.2003
7	3.3196	3.3478	3.6778	3.0528	2.95	3.4377	1.3717
8	3.8664	3.751	4.34	3.3383	3.813	3.9312	1.6289
9	4.2287	4.1297	4.766	3.5078	3.988	4.1758	1.8004
10	4.2612	4.1068	2.7587	3.9601	4.0733	3.8287	1.2574
11	4.2459	4.2505	4.9863	3.9937	4.2322	4.0223	2.0576
12		4.2231	5.0065	3.8226	4.2017	4.1754	2.1434
13	1.39	3.8424	4.0604	3.7083	3.9666	4.0226	2.0576
14	4.0824	3.3006	3.2274	2.1651	3.3989	3.2792	1.9719
15	4.026	3.5524	3.2274	2.9763	3.1691	3.4118	1.8861
16	4.0943	3.6976	3.0544	3.1794	2.8486	3.6332	1.9719
17	4.2063	3.9346	3.0772	3.2834	3.3326	3.754	1.9719
18	4.6384	4.3774	3.5749	3.844	3.7388	3.5109	2.2291
19	5.1075	4.6598	4.358	4.4197	4.281	4.699	2.4006
20	4.9409	4.4353	4.1914	4.3237	3.9876	4.6308	2.2291
21	4.225	3.9544	3.7029	3.8123	3.629	3.2251	2.1434
22	3.6458	3.5635	3.0589	3.3006	3.1371	3.3109	1.7147
23	3.2564	3.0315	2.8806	2.7717	2.9355	2.9766	1.3717
24	2.801	2.7522	3.5521	2.5736	2.5964	2.6041	
Max	5.1075	4.6598	5.0065	4.4197	4.281	4.699	2.4006
Min	1.39	2.5248	2.5035	2.1651	2.3049	2.2939	1.1145
Avg	3.5649	3.5372	3.4793	3.2046	3.2830	3.4085	1.7023

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 202 / 11 KV MOGLAI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.1027	1.0875	1.0905	1.0631	1.0722	.5144
2	1.0783	1.086	1.0783	1.0692	1.0479	1.0616	.5144
3	1.0753	1.0829	1.0753	1.0738	1.0402	1.0524	.5144
4	1.1088	1.1225	1.1103	1.1149	1.0875	1.089	.5144
5	1.4247	1.4861	1.3896	1.3957	1.2247	1.4541	.5144
6	1.8412	2.0263	1.8892	1.9364	1.6431	2.0557	.6859
7	2.4146	2.4009	2.3289	2.407	2.1213	2.4207	.9431
8	2.4131	2.4131	2.5477	2.3826	2.3978	2.41	.9431
9	2.0695	1.9151	2.1795	2.0207	2.1015	2.0192	.8573
10	1.8145	1.5181	2.0862	1.5013	1.8282	1.544	.4001
11	1.5135	1.3607	1.773	1.5394	1.6019	1.3256	.6859
12	1.48	1.3195	1.6324	1.4846	1.544	1.3134	.6859
13	1.483	1.2768	1.4811	1.3774	1.4968	1.3012	.6001
14	1.3317	1.1256	1.3226	1.2292	1.1774	1.225	.6001
15	1.257	1.0753	1.121	2.2584	1.1027	1.1027	.6001
16	.442	1.0814	1.118	1.2048	1.0186	1.1119	.6001
17	1.3134	1.2605	1.0814	1.2799	1.121	1.089	.6001
18	1.3607	1.4681	1.3363	1.3165	1.2109	1.1835	.7716
19	1.8815	1.7318	1.6461	1.819	1.7227	1.4941	.9431
20	1.8831	1.7836	1.8373	1.8495	1.8465	1.6709	.8573
21	1.7627	1.6617	1.6156	1.5516	1.6602	1.5364	.8573
22	1.5227	1.4922	1.5379	1.3683	1.4815	1.3622	.6859
23	1.3073	1.3088	1.2997	1.2692	1.2784	1.2265	.6001
24	1.1363	1.1256	1.121	1.1164	1.1027	1.0463	.5144
Max	2.4146	2.4131	2.5477	2.407	2.3978	2.4207	.9431
Min	.442	1.0753	1.0753	1.0692	1.0186	1.0463	.4001
Avg	1.5000	1.4677	1.5290	1.5273	1.4550	1.4237	.6668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 203 / 11 KV SHIVAJI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6806	2.5888	2.4051	2.4283	2.4135	2.476	1.2003
2	2.6547	2.5751	2.3624	2.3567	2.377	2.4501	1.2003
3	2.1787	2.364	2.3274	2.2497	2.2622	2.2436	1.1145
4	2.5202	2.3518	2.3228	2.2375	2.2409	2.2207	1.1145
5	2.5278	2.5599	2.4527	2.3948	2.2927	2.441	1.1145
6	2.8803	2.8635	2.6955	2.6635	2.4558	2.801	1.2003
7	2.9507	3.0731	2.8959	2.9081	2.6498	2.9766	1.3717
8	3.2118	3.1707	3.224	3.0518	3.0742	3.131	1.4575
9	3.467	3.3021	3.357	3.0838	3.1828	3.4076	1.5432
10	3.6717	3.1169	1.9875	3.2685	3.2289	3.6382	1.1431
11	4.1652	4.0504	4.0184	3.5813	3.3219	3.9434	2.0576
12	4.3758	4.3926	4.0367	3.7495	3.4853	4.1205	2.2291
13	4.385	4.5081	3.9712	3.722	3.2423	4.2719	2.1434
14	3.9159	4.1815	2.2542	3.6458	3.0483	4.0169	2.0576
15	4.0184	4.1286	3.4594	3.5097	2.9233	4.0093	2.0576
16	4.1667	4.1591	3.4853	3.6351	2.8776	4.1774	2.1434
17	4.3621	4.5058	3.6347	3.8687	3.171	4.3576	2.1434
18	4.8495	4.9307	4.2463	4.22	3.4228	4.6384	2.4006
19	5.7568	5.6406	5.1898	5.3228	4.1697	5.6772	2.6578
20	5.5655	5.4188	5.1487	5.2218	4.0702	5.4782	2.4006
21	4.8259	4.6624	4.3156	4.7059	3.5966	4.7409	2.1434
22	3.6896	3.6245	3.4423	3.4438	3.3249	3.4362	1.7147
23	3.128	3.0178	2.9309	2.8345	2.8224	2.9092	1.3717
24	2.7629	2.7705	3.0956	2.5341	2.6117	2.5995	1.286
Max	5.7568	5.6406	5.1898	5.3228	4.1697	5.6772	2.6578
Min	2.1787	2.3518	1.9875	2.2375	2.2409	2.2207	1.1145
Avg	3.6963	3.6649	3.3025	3.3599	3.0111	3.5901	1.7195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 204 / 11 KV Civil Hospital

SHEDDABLE RURAL

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.0857	.1715	.0857	.1715	.1715
2	.1715	.1715	.0857	.1715	.0857	.1715	.1715
3	.1715	.1715	.0857	.1715	.0857	.1715	.1715
4	.1715	.1715	.0857	.1715	.0857	.1715	.1715
5	.1715	.1715	.1715	.1715	.0857	.1715	.1715
6	.1715	.1715	.1715	.1715	.1715	.1715	.1715
7	.2572	.2572	.2572	.2572	.1715	.1715	.1715
8	.1715	.2572	.2572	.2572	.1715	.2572	.2572
9	.2572	.2572	.2572	.2572	.1715	.2572	.2572
10	.2572	.3429		.2572	.1715	.2572	.2286
11	.4287	.4287	.3429	.2572	.2572	.3429	.4287
12	.3429	.4287	.3429	.2572	.2572	.3429	.4287
13	.3429	.4287	.3429	.2572	.1715	.3429	.4287
14	.3429	.4287	.3429	.2572	.1715	.3429	.4287
15	.3429	.4287	.3429	.2572	.2572	.2286	.4287
16	.4287	.4287	.2572	.2572	.1715	.3429	.4287
17	.3429	.4287	.2572	.1715	.1715	.3429	.4287
18	.3429	.4287	.2572	.1715	.1715	.3429	.4287
19	.3429	.3429	.2572	.1715	.1715	.3429	.3429
20	.2572	.2572	.2572	.1715	.1715	.3429	.2572
21	.1715	.2572	.2572	.1715	.1715	.2572	.2572
22	.1715	.1715	.2572	.1715	.1715	.1715	.2572
23	.1715	.1715	.1715	.1715	.1715	.1715	.1715
24	.1715	.1715	.2572	.1715	.1715	.1715	.1715
Max	.4287	.4287	.3429	.2572	.2572	.3429	.4287
Min	.1715	.1715	.0857	.1715	.0857	.1715	.1715
Avg	.2572	.2894	.2348	.2072	.1643	.2524	.2846



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 094035 / 33/11 KV POWER HOUSE

Feeder No / Name : 205 / 11 KV Datta Mandir

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3681	.2808	.3651	.3529	.3605	.1715
2	.359	.362	.2732	.3605	.3483	.3559	.1715
3	.3544	.3574	.2716	.362	.3437	.3529	.1715
4	.3529	.3574	.2732	.3574	.3422	.3514	.1717
5	.3544	.3681	.359	.3651	.3483	.3498	.1715
6	.3696	.4584	.4492	.359	.3483	.3635	.1715
7	.3864	.4752	.5636	.4889	.3574	.3773	.2572
8	.4093	.5239	.5437	.5072	.3605	.4873	.2572
9	.3986	.527	.5163	.3971	.4828	.5376	.2572
10	.3864	.4245	.2134	.3849	.4138	.4093	.1143
11	.3757	.3727	.3757	.3437	.3605	.394	.1715
12	.359	.3864	.3529	.3224	.3574	.3925	.1715
13	.3544	.3651	.3483	.3072	.3529	.3559	.0857
14	.3437	.3651	.3468	.3346	.3376	.3544	.0857
15	.3529	.3635	.3392	.3361	.3422	.3651	.1715
16	.3574	.3529	.3376	.2843	.3117	.3498	.1715
17	.391	.3757	.3514	.3361	.3361	.3788	.1715
18	.4813	.498	.3605	.3864	.3605	.3818	.1715
19	.5483	.5559	.4474	.527	.5194	.5361	.2572
20	.559	.5468	.5437	.5255	.5255	.5483	.2572
21	.5346	.5133	.5102	.4245	.5102	.5255	.2572
22	.527	.4138	.5011	.4062	.4995	.498	.2572
23	.4858	.4032	.3956	.3788	.3849	.3986	.1715
24	.3788	.3788	.3788	.3605	.3712	.3788	.1715
Max	.559	.5559	.5636	.527	.5255	.5483	.2572
Min	.3437	.3529	.2134	.2843	.3117	.3498	.0857
Avg	.4079	.4214	.3889	.3842	.3862	.4085	.1870

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 207 / 11 KV Tikhi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	9.2402
2	***	***	***	***	***	8.1924
3	***	***	9.3545	***	***	8.7068
4	***	9.907	9.5641	***	***	8.6115
5	***	9.0497	9.2783	9.5069	***	8.0209
6	***	***	8.9163	9.145	***	8.9354
7	***	9.3545	8.3067	9.0688	8.5162	8.2495
8	***	8.3448	8.078	9.2021	7.6208	6.8968
9	9.3355	7.4493	7.4303	8.3448	9.4307	6.7635
10	6.4015	9.6213	7.8685	8.5162	9.7927	5.9633
11	7.2779	***	8.0399	7.6208	6.8778	6.7254
12	7.9637	6.4396	8.3257	8.4019	9.1259	8.7258
13	***	***	***	8.8211	***	***
14	***	***	***	8.5162	***	***
15	***	***	***	***	***	***
16	9.3164	***	7.4112	***	***	8.44
17	8.2305	8.2876	8.059	***	8.802	***
18	7.4112	8.078	9.164	***	8.44	***
19	9.1069	8.8592	8.8211	7.7351	8.6306	7.4112
20	***	***	***	***	***	***
21	***	***	***	***	***	***
22	***	***	***	***	***	***
23	***	***	***	***	***	***
24	***	***	***	***	***	***
Max	22.4433	19.2806	19.4711	20.6143	18.8043	21.8526
Min	6.4015	6.4396	7.4112	7.6208	6.8778	5.9633
Avg	13.2380	11.3439	10.6707	11.2335	11.9694	11.3479

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 406 / 33 KV SOOTGIRNI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	14.285	14.2233	14.3467	13.534	13.6266	13.7294
2	14.7737	14.7428	14.7274	13.6471	13.7963	14.4033
3	14.6451	14.7325	14.6039	13.6008	14.0998	14.5268
4	14.5422	14.3776	14.7634	13.7706	14.1564	14.5936
5	14.3724	14.3673	15.0617	13.6317	14.3159	14.2181
6	15.036	14.9897	14.5268	14.0072	14.0792	14.4187
7	15.2315	15.3755	14.7994	13.9249	14.5473	15.2572
8	15.8694	14.9794	15.2469	14.6965	14.8766	15.4887
9	13.9095	13.8169	13.8169	12.8035	13.7294	13.5906
10	14.3004	14.0329	14.3004	13.3796	14.1718	13.9712
11	14.9692	15.2727	14.4548	14.1513	14.7377	14.7891
12	16.07	15.7819	15.7768	14.0895	15.571	15.5813
13	14.6605	15.2264	14.9023	14.0021	15.5196	15.1904
14	15.7305	15.1904	14.8971	14.856	15.2984	15.2109
15	15.5144	15.1955	15.3241	14.7274	15.5813	15.6482
16	15.5659	15.4527	15.427	15.2984	15.7305	16.1831
17	14.7891	15.0206	13.0967	15.2778	15.0823	14.9949
18	15.2727	15.0052	13.6729	15.0412	15.1441	15.3498
19	14.2747	14.5988	14.0689	14.5113	14.465	14.3519
20	14.3724	13.9815	13.6934	14.5731	14.1924	13.7192
21	13.9969	13.8066	13.534	14.1976	14.141	13.5906
22	14.5782	14.0587	14.1924	14.5525	14.0895	14.1513
23	14.5782	14.2747	14.2233	14.5525	14.6091	14.2953
24	14.7737	14.6657	14.5576	14.964	14.8869	14.964
Max	16.07	15.7819	15.7768	15.2984	15.7305	16.1831
Min	13.9095	13.8066	13.0967	12.8035	13.6266	13.5906
Avg	14.8380	14.7154	14.5006	14.2413	14.6020	14.6757

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

DHULE (U-I)[214]

BU 0515

Substation No/ Name :- 097001 / 132 KV S/STN DHULE

Feeder No / Name : 421 / 33 KV AGRI.COLLEGE MAIN  
(I/C) Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	27.8464	26.6118	27.7092	20.8505	24.8286	25.1715
2	26.1317	25.1715	25.9945	19.6159	23.4568	24.3485
3	25.5144	24.76	25.5144	19.0672	22.6338	23.6626
4	25.0343	24.5542	24.8972	18.7929	22.428	23.4568
5	24.5542	24.4856	24.2113	19.273	19.8217	23.594
6	26.3375	27.2977	25.0343	21.4678	22.7024	25.7202
7	***	***	28.3951	26.2689	26.5432	***
8	***	***	***	28.4637	***	***
9	***	***	***	***	***	***
10	***	***	***	29.8354	***	***
11	***	***	***	29.7668	***	***
12	***	***	***	24.6228	***	***
13	***	***	***	19.6159	***	***
14	***	***	***	22.771	***	***
15	25.926	25.583	23.7998	22.771	24.0055	27.5721
16	27.915	28.3265	21.5364	25.7202	25.9945	***
17	21.262	28.9438	20.9191	26.6118	28.1893	***
18	***	29.1496	20.7819	27.2291	29.1496	***
19	***	***	22.8395	***	***	***
20	***	***	27.5721	***	***	***
21	***	***	27.2291	***	***	***
22	***	***	26.2689	***	***	***
23	***	29.4239	24.76	27.3663	28.2579	***
24	28.9438	28.738	23.1139	27.0919	27.0234	29.6297
Max	39.0947	36.8999	36.214	36.214	37.0371	40.3979
Min	21.262	24.4856	20.7819	18.7929	19.8217	23.4568
Avg	30.6728	30.3956	27.3663	25.8717	28.8152	31.9845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / NARDANA 33 KV

Feeder No / Name : 201 / 11 KV DONGARGAON GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4588	.4329	.4668	.4626	.4626	.4656	.2263
2	.4588	.4359	.4675	.4596	.4481	.4618	.2263
3	.4603	.4363	.4706	.4634	.4618	.4893	.2263
4	.5106	.519	.5227	.4763	.5007	.5388	.2829
5	.6623	.6562	.6773	.6241	.6197	.6185	.3395
6	.7689	.8406	.8291	.7666	.6946	.7373	.3772
7	.8124	.8155	.8555	.8048	.5617	.7144	.415
8	.5918	.5274	.6885	.4725	.4443	.4733	.2801
9	.4352	.3989	.5281	.3806	.3063	.3315	.1991
10	.3349	.346	.3909	.3521	.2636	.3542	.1886
11	.2652	.3345	.3566	.2885	.3025	.3338	.1867
12	.2758	.3695	.3524	.2984	.2888	.2879	.1867
13	.2751	.3664	.3513	.3149	.3027	.2938	.1867
14	.2953	.374	.3696	.3384	.285	.3441	.1646
15	.3163	.3916	.3361	.3157	.3052	.3644	.1829
16	.3247	.3969	.3006	.2591	.3096	.3506	.1867
17	.397	.4618	.3284	.3056	.3208	.4248	.2241
18	.4344	.5513	.4557	.3864	.381	.5167	.2801
19	.5571	.6546	.6402	.5975	.5891	.7095	.3395
20	.6013	.6893	.5748	.6096	.5822	.7019	.3018
21	.6386	.6348	.6234	.5979	.5915	.6493	.2801
22	.5765	.6173	.5509	.5476	.5659	.5938	.2801
23	.5274	.5445	.5179	.5175	.4785	.5567	.2641
24	.4786	.4908	.4845	.4702	.4497	.509	.2641
Max	.8124	.8406	.8555	.8048	.6946	.7373	.415
Min	.2652	.3345	.3006	.2591	.2636	.2879	.1646
Avg	.4774	.5119	.5058	.4629	.4382	.4925	.2537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / NARDANA 33 KV

Feeder No / Name : 202 / WARUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.8267	.7573
2						1.7345	.7573
3						1.7847	.7573
4						1.9105	.8362
5						1.9731	.945
6						2.2268	1.1279
7						2.8601	1.2955
8						2.4904	1.2651
10	1.6141	1.5988	1.5935	1.5821	1.6354		
11	3.011	2.9919	2.995	2.9325	3.1763		
12	3.0955	2.9927	2.7923	2.9634	3.0384		
13	3.0978	2.9744	2.8921	2.846	2.8442		
14	2.8372	3.0026	2.718	2.7191	2.5781		
15	2.9073	2.9515	2.8128	2.6673	2.6745		
16	2.9934	2.9628	3.0023	2.8117	2.848		
17	3.2274	3.0101	3.0907	2.8418	3.091		
18	2.6688	2.8365	2.7549	2.3488	2.1681		
22					1.0997	1.1797	
23					1.9898	2.0416	.8619
24					1.057	2.0187	.8688
Max	3.2274	3.0101	3.0907	2.9634	3.1763	2.8601	1.2955
Min	1.6141	1.5988	1.5935	1.5821	1.057	1.1797	.7573
Avg	2.8281	2.8135	2.7391	2.6347	2.3500	2.0043	.9472

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / NARDANA 33 KV

Feeder No / Name : 203 / 11 KV NARDANA TOWN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7141	.7232	.7289	.7522	.7213	.769	.3658
2	.6969	.7125	.7141	.7446	.7011	.7591	.3696
3	.6759	.7152	.711	.7149	.74	.7514	.3696
4	.7179	.7507	.7537	.7049	.7431	.801	.4108
5	.7377	.7689	.7935	.7278	.8216	.7983	.4251
6	.8802	.9609	.8636	.8878	.9286	.9183	.4805
7	1.0524	1.0135	.9637	1.028	.9953	1.0464	.5041
8	1.0234	.9533	.9925	1.0112	.9732	1.1081	.4755
9	.9442	.8734	.9518	.871	.8718	.9359	.3544
10	.8276	.8071	.833	.8463	4.1863	.8649	.362
11	.809	.7133	.8063	.7377	.7674	.7964	.3506
12	.7777	.7918	.7887	.7205	.711	.7057	.3155
13	.1776	.7415	.7773	.7106	.6931	.719	.3258
14		.7449	.708	.7438	.7057	.7053	.3258
15		.735	.7469	.7865	.7446	.7034	.3258
16	.9038	.7743	.7895	.7789	.7225	.708	.362
17	.91	.7713	.7553	.7918	.783	.7415	.3429
18	.929	.804	.82	.7476	.8893	.7712	.3856
19	.9793	.8886	.9244	.9069	.9411	.9157	.4908
20	1.0822	1.0356	1.0097	1.0471	1.0456	.9639	.4801
21	1.0227	.9907	1.0166	1.0699	1.0342	.9496	.4908
22	.9747	.9111	.9739	.9812	.9972	.8856	.4706
23	.913	.8459	.8756	.8231	.9267	.8147	.394
24	.8025	.7804	.7718	.788	.7987	.8089	.3696
Max	1.0822	1.0356	1.0166	1.0699	4.1863	1.1081	.5041
Min	.1776	.7125	.708	.7049	.6931	.7034	.3155
Avg	.8433	.8253	.8362	.8301	.9768	.8309	.3978

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / NARDANA 33 KV

Feeder No / Name : 204 / CHANDGAD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2643	1.2087	1.1928	1.3337	1.2231		
2	1.2361	1.2254	1.2205	1.3252	1.2101		
3	1.2155	1.2468	1.2468	1.3306	1.2216		
4	1.2109	1.342	1.3001	1.3101	1.2719		
5	1.2292	1.3748	1.3466	1.4236	1.3415		
6	1.3451	1.5417	1.422	1.5867	1.419		
7	1.9776	2.0035	2.1437	2.0752	2.1049		
8	2.0004	2.0615	2.3236	2.0965	2.0965		
10						.743	
11						1.9913	.6859
12						1.9075	.6584
13						1.8313	.5868
14						1.6393	.5335
15						1.5998	.7164
16						1.5772	.5868
17						1.7758	.5868
18						1.8085	.5784
22	.6074	.471	.6577	.602			
23	1.2376	1.2067	1.2966	1.2132			
24	1.2429	1.2563	1.2793	1.3078	.4572		
Max	2.0004	2.0615	2.3236	2.0965	2.1049	1.9913	.7164
Min	.6074	.471	.6577	.602	.4572	.743	.5335
Avg	1.3243	1.3580	1.4027	1.4186	1.3718	1.6526	.6166



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / NARDANA 33 KV

Feeder No / Name : 205 / Industrial Feeder, Nardana      SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING      STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.695	.7468	.695	.16	.381	.7468
2	.7316	.6878	.7545	.7468	.16	.6401	.7468
3	.7316	.7316	.7468	.7468	.2286	.6706	.7922
4	.7316	.7316	.7842	.7316	.1715	.6706	.7922
5	.7316	.6878	.8676	.7842	.2332	.7011	.7922
6	.7316	.695	.9431	.7468	.2332	.8916	.7392
7	.7316	.7316	.7922	.7468	.2591	.6401	.7392
8	.6089	.5975	.7023	.1372	.6706	.8048	.695
9	.6584	.7922	.7602	.1715	.6706	.7545	.6878
10	.7316	.8676	.7316	.2286	.852	.9808	.7602
11	.8775	.7922	.7316	.1905	1.0082	.9431	.9808
12	.8775	.7468	.7316	.1905	.9602	.8676	.8962
13	.9145	.8299	.8779	.1543	.9979	.8676	.8048
14	.5853	.9054	.8779	.1372	.9774	.9054	.7316
15	.7095	.8299	.695	.0914	.9511	.9431	.724
16	.7316	.8299	.695	.0914	.9511	.9808	.7392
17	.6584	.6516	.695	.0914	.5068	.8676	.7316
18	.6722	.5853	.6584	.1166	.5285	.7392	.695
19	.6584	.5316	.695	.1219	.6706	.8299	.7468
20	.6219	.5194	.695	.1486	.6401	.9054	.6878
21	.5959	.5731	.7316	.1486	.6173	.7023	.695
22	.6584	.7545	.724	.1585	.5357	.6516	.8299
23	.6447	.7468	.7468	.16	.7773	.6878	.7316
24	.7316	.7316	.7545	.7316	.1067	.3506	.7468
Max	.9145	.9054	.9431	.7842	1.0082	.9808	.9808
Min	.5853	.5194	.6584	.0914	.1067	.3506	.6878
Avg	.7092	.7186	.7558	.3445	.5778	.7657	.7597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / NARDANA 33 KV

Feeder No / Name : 206 / 11 KV WARUD GOATHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.12	.128	.12	.1067	.12	.128
2	.1029	.1227	.128	.12	.1067	.12	.128
3	.1029	.1227	.1294	.1227	.1094	.1219	.128
4	.1372	.1372	.1494	.1433	.1219	.125	.1267
5	.1402	.1402	.1478	.1791	.1311	.1629	.1463
6	.1402	.1402	.1478	.1463	.1067	.1629	.1433
7	.1402	.1433	.1478	.1433	.1067	.1448	.124
8	.1029	.1402	.1448	.0857	.1029	.112	.1086
9	.0857	.1029	.1402	.0876	.0914	.1029	.1029
10	.0857	.0857	.1052	.0886	.0819	.1029	.0701
11	.1029	.0857	.0857	.0857	.0857	.1029	.0857
12		.1029	.0876	.1029	.0857	.1006	.0857
13		.0857	.0857	.1029	.0857	.081	.0857
14	.12	.0857	.0857	.0857	.061	.0857	.0857
15	.12	.0857	.0857	.0857	.0648	.1029	.0905
16	.12	.1029	.0857	.12	.0857	.1029	.0876
17	.1227	.1029	.12	.1227	.1294	.1029	.1029
18	.1402	.1029	.1402	.1214	.128	.12	.1402
19	.1791	.1715	.1715	.1372	.1543	.1433	.2149
20	.2149	.1966	.1715	.1372	.1619	.1578	.1791
21	.1791	.181	.2058	.1543	.1619	.1448	.1715
22	.1715	.1646	.1734	.1402	.1543	.1448	.1791
23	.1372	.1646	.1372	.1372	.1433	.1478	.1372
24	.1402	.1402	.1463	.1372	.1372	.1448	.1433
Max	.2149	.1966	.2058	.1791	.1619	.1629	.2149
Min	.0857	.0857	.0857	.0857	.061	.081	.0701
Avg	.1314	.1262	.1313	.1211	.1127	.1232	.1248

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094001 / NARDANA 33 KV

Feeder No / Name : 207 / 11 Kv Chandgad Goathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3982	.415	.394	.3544	.362	.3734
2	.4024	.3658	.3734	.3658	.3429	.362	.3772
3	.3734	.439	.4108	.3658	.3856	.4024	.415
4	.439	.439	.4435	.3696	.4801	.4755	.4527
5	.6584	.6283	.6516	.5121	.5258	.5175	.5281
6	.8589	.8779	.8596	.8048	.7796	.8215	.7922
7	.8215	.8413	.8048	.8501	.8063	.8589	.8299
8	.6219	.6154	.5914	.5121	.5144	.6722	.5544
9	.6219	.4854	.3658	.5068	.4858	.439	.3582
10	.5853	.4435	.3658	.5373	.583	.4557	.4706
11	.5731	.4344	.4298	.4656	.5609	.543	.439
12		.4252	.4656	.4656	.5609	.6089	.5121
13		.3292	.439	.4344	.583	.5373	.4755
14	.7522	.2987	.5121	.4298	.6859	.5373	.4755
15	.7164	.2957	.4755	.3772	.6024	.5552	.5014
16	.7164	.2987	.4706	.3506	.5258	.5853	.5487
17	.6584	.4024	.4344	.4801	.6859	.6219	.543
18	.6722	.4607	.3856	.5959	.6859	.6653	.5487
19	.7316	.6335		.6859	.5731	.6878	.6722
20	.6584	.5914	.5853	.6173	.6154	.6653	.5853
21	.6722	.5544	.6584	.5959	.5609	.5487	.543
22	.6089	.5415	.5853	.5144	.543	.5175	.5487
23	.543	.4527	.5121	.4557	.5228	.4481	.4706
24	.439	.4557	.4338	.3982	.4344	.4854	.415
Max	.8589	.8779	.8596	.8501	.8063	.8589	.8299
Min	.3734	.2957	.3658	.3506	.3429	.362	.3582
Avg	.6149	.4878	.5074	.5035	.5583	.5572	.5179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 SUKWAD

Feeder No / Name : 201 / 11 KV Sawalde ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.1336	1.1174
2						1.1336	1.1174
3						1.1336	1.1012
4						1.2146	1.1012
5						1.2146	1.1012
6						1.2631	1.085
7						1.2631	1.085
8						1.2146	1.0526
11	1.5546	1.7004	1.4899	1.5546	1.5384		
12	1.6356	1.7004	1.5061	1.587	1.5384		
13	1.5546	1.6194	1.5384	1.4737	1.587		
14	1.6194	1.6194	1.4737	1.4899	1.587		
15	1.5223	1.6194	1.3441	1.4413	1.4575		
16	1.4737	1.5384	1.3441	1.4413	1.4575		
17	1.4575	1.4575	1.4089	1.4737	1.5384		
18	1.3117	1.3765	1.3279		1.5384		
19					1.2146		
23			1.4373		1.1336	1.085	.9393
24				1.4373	1.1336		1.1174
Max	1.6356	1.7004	1.5384	1.587	1.587	1.2631	1.1174
Min	1.3117	1.3765	1.3279	1.4373	1.1336	1.085	.9393
Avg	1.5162	1.5789	1.4300	1.4874	1.4295	1.1840	1.0818

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 SUKWAD

Feeder No / Name : 202 / 11 KV Tawkheda Ag

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	25-FEB-17
HR	Load (MW)
18	.0191
Max	.0191
Min	.0191
Avg	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 SUKWAD

Feeder No / Name : 203 / 11 KV Balde Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.2955	1.8785
2						1.2955	1.8947
3						1.4575	1.9109
4						1.6194	1.9271
5						1.7814	1.9433
6						2.0243	1.9595
7						2.0243	1.9757
8						1.7814	1.8138
11	1.9757	2.3482	2.4291	2.2834	2.4291		
12	1.9919	2.4291	2.2672	2.4291	2.4291		
13	2.1376	2.5101	2.251	2.4291	2.5101		
14	2.1862	2.5101	2.2348	2.4129	2.5911		
15	2.0243	2.5101		2.3644	2.5101		
16	1.9757	2.5101	2.0567	2.3805	2.4291		
17	2.1214	2.3482	2.17	2.2672	2.5911		
18	2.0405	2.1052	2.2348	2.1538	2.2672		
23					.9393	1.8785	1.6194
24					1.0526		1.8785
Max	2.1862	2.5101	2.4291	2.4291	2.5911	2.0243	1.9757
Min	1.9757	2.1052	2.0567	2.1538	.9393	1.2955	1.6194
Avg	2.0567	2.4089	2.2348	2.3401	2.1749	1.6842	1.8801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 SUKWAD

Feeder No / Name : 204 / 11 KV Dabhashi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	2.1238	2.4537	2.3438	2.1409	.3071	
2	.4916	2.0434	2.3501	2.2135	2.099	.3147	
3	.4923	2.0292	2.312	2.1616	2.0854	.3071	
4	.5296	2.057	2.2916	2.207	2.0984	.3178	
5	.6203	2.1778	2.3453	2.2392	2.1283	.3368	
6	.7354	2.3733	2.4748	2.4814	2.2266	.4009	
7	.8254	3.0256	3.0483	2.9611	2.6471	.4778	
8	.6821	3.2179	1.9951	3.2066	1.6354	.4123	
9	.5068	.9541	1.2315	1.3237	1.0562	.3201	
10	.3528	.1966	.2317	.2667	.1669	.2157	
11	1.7871	.1296	.1288	.2111	.1425	3.3337	1.7004
12	2.1864	.1341	.109	.1715	.1311	3.9457	1.6518
13	2.1437	.0259	.2233	.1745	.1349	3.8083	1.6032
14	1.7764	.1166	.2149	.1821	.2164	2.1498	1.6032
15	1.6369	.253	.2309	.1905	.2736	3.3932	1.6518
16	1.6148	.237	.2218	.1242	.2713	3.4505	
17	1.6789	.2149	.2058	.2065	.2743	3.566	
18	1.6461	.2378	.208	.1966	.2408	3.3582	1.4251
19	.881	.3292	.2782	.2225	.2721	.9945	
20	.4214	.4405	.4077	.4024	.4397	.4169	
21	.4085	.4199	.407	.4214	.4313	.4146	
22	.3788	.3887	.3673	.4024	.3841	.3765	
23	2.2474	2.3067	2.236	2.1635	.3605	.3833	
24	1.2757	2.4564	1.2132	2.1898	.3269	.3399	
Max	2.2474	3.2179	3.0483	3.2066	2.6471	3.9457	1.7004
Min	.3528	.0259	.109	.1242	.1311	.2157	1.4251
Avg	1.0754	1.1620	1.1328	1.1943	.9243	1.3892	1.6059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 SUKWAD

Feeder No / Name : 205 / EXPRESS SUKWAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0351	.0351	.0351	.0351	.0351	.0351
2	.0351	.0351	.0351	.0351	.0351	.0351	.0351
3	.0351	.0351	.0351	.0351	.0351	.0351	.0351
4	.0351	.0351	.0351	.0351	.0351	.0351	.0351
5	.0351	.0351	.0351	.0351	.0351	.0351	.0351
6	.0351	.0351	.0351	.0351	.0351	.0351	.0351
7	.0351	.0351	.0351	.0351	.0351	.0351	.0351
8	.0351	.0351	.0351	.0351		.0351	.0351
9	.0351	.0351	.0351	.0351	.0351	.0351	.0351
10	.0701	.0876	.0351	.0701	.0876	.0876	.0876
11	.0876	.1402	.0351	.0876	.0876	.0876	.0876
12	.0876	.0876	.0876	.0876	.0876	.0876	.0876
13	.0876	.0876	.0876	.0876	.0351	.929	.0876
14	.0876	.0876	.0876	.0876	.0351	.0876	.0351
15	.0351	.0351	.0876	.0351	.0351	.0876	.0351
16	.0351	.0351	.0351	.0351	.0351	.0351	.0351
17	.0351	.0351	.0351	.0343	.0351	.0351	.0351
18	.0351	.0351	.0351	.0351	.0351	.0351	.0351
19	.0351	.0351	.0351	.4908	.0351	.0351	.0351
20	.0351	.0351	.0351	.0351	.0351		.0351
21	.0351	.0351	.0351	.0351	.0351	.0351	.0351
22	.0351	.0351	.0351	.0351		.0351	.0351
23	.0351	.0351	.0351	.0351	.0351	.0351	.0351
24	.0351	.0351		.0351	.0351		.0351
Max	.0876	.1402	.0876	.4908	.0876	.929	.0876
Min	.0351	.0351	.0351	.0343	.0351	.0351	.0351
Avg	.0453	.0482	.0442	.0643	.0423	.0877	.0439



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 SUKWAD

Feeder No / Name : 206 / 11 KV Dabhshi Goathan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2454	.2454	.2454	.2454	.2629	.2629	.2629
2	.2454	.2804	.2804	.2454	.2804	.2804	.2804
3	.2454	.3155	.3155	.2454	.298	.2804	.3155
4	.2629	.3506	.3506	.2629	.333	.3155	.3506
5	.3155	.3856	.3856	.3155	.3681	.3506	.3856
6	.4031	.4207	.4207	.3506	.4031	.4207	.4207
7	.4557	.4557	.4557	.4382	.4557	.4557	.4557
8	.3856	.4031	.4031	.3506		.3856	.4031
9	.2454	.3506	.3155	.2629	.3506	.298	.3506
10	.1928	.298	.2804	.2279	.298	.2454	.298
11	.2103	.2103	.2454	.2103	.2454	.2172	.1578
12		.1928	.1928	.1928	.2454	.2103	.1578
13		.1753	.2279	.1928	.2279	.1928	.1928
14	.2804	.1753	.2103	.1928	.2279	.1928	.2103
15		.1928	.2103	.1928	.2103	.1928	.2103
16	.2103	.2103	.2103	.1928	.2279	.2103	.2103
17	.2629	.2103	.1928		.2454	.1928	
18	.298	.3155	.2279	.2454	.2804	.2804	
19	.3506	.3856	.298	.3506	.3856	.3681	.3506
20	.333	.3506		.3155	.4207	***	.3506
21	.298	.298	.3155	.3155	.3506	.3155	.3155
22	.2804	.2629	.3155	.298	.3155	.298	.3155
23	.2629	.2454	.2804	.2804	.298	.2804	.298
24	.2629	.2629		.1928	.2629		.2629
Max	.4557	.4557	.4557	.4382	.4557	33.0225	.4557
Min	.1928	.1753	.1928	.1928	.2103	.1928	.1578
Avg	.2879	.2914	.29	.2660	.3041	1.7074	.2980

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094019 / 33/11 SUKWAD

Feeder No / Name : 207 / 11 KV TAWKHEDA GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2103	.2103	.1753	.2103	.2103	.2454
2		.2454	.2279	.1753	.2454	.2103	.2629
3		.2804	.2629	.0351	.2804	.2454	.2804
4		.3155	.298	.2279	.3155	.2804	.298
5		.3506	.3506	.2629	.3506	.3506	.333
6		.3856	.3856	.4207	.3856	.3856	.3681
7		.3856	.4207	.4207	.4031	.4382	.4031
8		.333	.3506	.2804		.3155	.3506
9		.2804	.2103	.2103	.298	.1928	.298
10	1.56	.2279	.1928	.1753	.2454	.1928	.2454
11	.1578	.1928	.1928	.1928	.1928	.1753	.1578
12	.1402	.1578	.1753	.1753	.1928	.1753	.1753
13	.1402	.1578	.1928	.1928	.1928	.1753	.1753
14	.2103	.1402	.2103	.2103	.1928	.1928	.2103
15	.2103	.1753	.2103	.2103	.1753	.2103	.1928
16	.2103	.1928	.2103	.2103	.2103	.2103	.1928
17	.2454	.1928	.2103	.2454	.2103	.2279	.2279
18	.2454	.2454	.2103	.2279	.2629	.2279	.2629
19	.333	.3155	.2804	.298	.3155		.2804
20	.298	.2629	.2454	.2804	.3155	.0351	.2804
21	.2629	.2454	.2279	.2629	.2454	.2629	.2454
22	.2454	.2279	.2454	.2454	.2454	.2629	.2454
23	.2279	.2279	.2279	.2279	.2279	.2454	.2279
24		.2353		.2103	.2103		.2454
Max	1.56	.3856	.4207	.4207	.4031	.4382	.4031
Min	.1402	.1402	.1753	.0351	.1753	.0351	.1578
Avg	.3205	.2494	.2500	.2322	.2576	.2374	.2585

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / SONGIR 33 KV

Feeder No / Name : 201 / Industrial Feeder, Songir  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6085	.4972	.5441	.5601	.4816	.4954	.3772
2	.5304	.4896	.5531	.5556	.5182	.4877	.4207
3	.4919	.4915	.55	.543	.5171	.4854	.4338
4	.5202	.4877	.547	.5403	.5102	.4801	.4075
5	.5175	.4874	.5419	.5075	.4664	.4778	.4338
6	.482	.4835	.538	.5052	.4515	.4687	.3856
7	.4534	.4565	.4916	.4984	.447	.5331	.3772
8	.4206	.4961	.471	.4637	.4325	.4938	.3772
9	.4732	.4024	.4481	.4439	.4866	.4576	.3772
10	.4969	.5114	.4629	.4851	.5396	.5068	.3506
11	.4893	.5483	.5677	.4885	.5803	.501	.3467
12	.5373	.5521	.6383	.498	.5811	.5506	.3814
13	.5422	.5399	.6227	.4935	.6173	.5319	.3814
14	.5182	.5262	.5731	.4775	.5731	.5651	.3814
15	.607	.5354	.6135	.4233	.636	.5982	.3988
16	.6078	.5647	.5967	.3959	.6314	.594	.3641
17	.6618	.5415	.5788	.386	.6341	.5197	.3988
18	.6531	.5567	.6032	.4195	.6135	.5485	.3988
19	.5826	.5895	.5966	.4599	.6028	.5642	
20	.575	.5426	.5822	.4195	.6021	.5695	.3988
21	.5602	.5391	.5735	.4153	.5743	.576	.3988
22	.5548	.5609	.5396	.4126	.5503	.5207	.3988
23	.5822	.5334	.5639	.4447	.5007	.4694	.3988
24	.5407	.5868	.5601	.1135	.495	.4614	
Max	.6618	.5895	.6383	.5601	.636	.5982	.4338
Min	.4206	.4024	.4481	.1135	.4325	.4576	.3467
Avg	.5420	.5217	.5566	.4563	.5434	.5190	.3903

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / SONGIR 33 KV

Feeder No / Name : 202 / NANDANE 1 PHASING

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3658	.3814	.3814	.3641	1.6289	1.5947
2	.3772	.3658	.3814	.4161	.3467	1.7375	1.6289
3	.3944	.3658	.4854	.4681	.4334	1.829	1.7177
4	.6001	.4938	.6068	.5548	.6935	2.0119	1.9909
5	.6859	.7133	.8669	.7628	.8322	2.1582	1.9631
6	.823	.8962		.8322		2.1948	2.0858
7				.7802		2.268	2.1616
8		.7133		.6241			1.701
9	.5144	.4938	.4854	.4854	.5201	.5121	1.6301
10	.3439	.3294	.3467	.3121	.3814	.5068	.3506
11	2.0119	2.0458	1.5074	1.647	1.6461	.2774	.3294
12	2.0851		1.8427	1.8204	1.829	.208	.208
13	1.9004		1.7918	1.7337	1.9204	.208	.2254
14	1.9204	2.0805	1.7918	1.7511	1.9936	.1907	.208
15	2.0119	1.9938	1.5261	1.7337	1.9753	.1907	.2254
16	1.9909	2.0458	1.5604	1.7857	1.9753	.1907	.2774
17	2.0698	1.9071	1.6644	1.7337	1.8099	.208	.3121
18	1.829	1.8204	1.7164	1.6991	1.7558	.3641	.4854
19	.4938	1.647	.6068	.6001	.5487	.6588	
20	.567	.5487	.4854	.5487	.567	.5028	.5375
21	.4572	.4801	.4508	.4801	.4572	.4508	.4854
22	.4207	.4287	.3814	.4287	.4207	.3988	.4161
23	.3841	.4287	.3814	.3988	1.4632	1.1963	1.387
24	.3772	.3658	.3814		.3641	1.5083	
Max	2.0851	2.0805	1.8427	1.8204	1.9936	2.268	2.1616
Min	.3439	.3294	.3467	.3121	.3467	.1907	.208
Avg	1.0289	.9776	.9353	.9556	1.0618	.9305	.9964

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / SONGIR 33 KV

Feeder No / Name : 204 / WALKHEDA 1 PHASING

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6289	1.8099	1.647	1.7337	1.6118	1.829	1.7718
2	1.6461	2.1033	1.6991	1.9071	1.4737	1.9204	1.9004
3	1.6804	2.1948	1.7337	2.0111	1.387	2.0119	1.893
4	1.7147	2.2314	1.8204	2.1152	1.387	2.1033	2.0553
5	1.8861	2.3228	1.8724	2.0805	1.4217	2.2314	2.1971
6	1.9376	2.3777	1.9071	2.1845	1.4737	2.4326	2.2857
7	2.0062	2.4508	2.3405	2.2712	2.3405	2.5606	2.392
8	1.8176	2.0302	2.1672	1.9591	1.9938	2.2497	2.3388
9	.2572	.2561	.4334	.4161	.4334	.3292	2.3034
10	.2378	.1734	.2427	.208	.2601	2.1209	.2172
11	2.2862	1.7337	1.7337	1.7337	2.0119	2.0978	3.0514
12	2.3411	1.9071	2.0908	1.9938	2.2862	2.0285	2.1672
13	1.9909	1.9938	2.0995	1.8204	2.2314	2.0111	2.8607
14	2.0119	1.647	1.4883	1.6817	2.2497	2.0458	2.8433
15	2.1033	1.8204	1.4723	1.8204	2.2862	1.8031	2.7393
16	2.1033	1.9071	1.8204	2.0458	2.2862	1.8551	2.5312
17	2.1399	1.9938	1.7857	1.9938	2.1033	1.8204	2.1498
18	1.9022	2.0805	1.6817	1.9071	1.8839	1.7164	.4508
19	.5304	.4334	.4508	.4801	.4572	2.3405	
20	.4938	.4801	.4681	.5144	.5121	1.9418	.4854
21	.4572	.4458	.4681	.4287	.439	.5548	.4854
22	.4251	.4287	.4334	.3944	.4207	.4508	.4334
23	1.5546	1.4575	1.1789	1.647	1.6461	1.491	1.5604
24	1.6118	1.7558	1.647		1.7337	1.8031	
Max	2.3411	2.4508	2.3405	2.2712	2.3405	2.5606	3.0514
Min	.2378	.1734	.2427	.208	.2601	.3292	.2172
Avg	1.5318	1.5848	1.4451	1.5369	1.5138	1.8229	1.8688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / SONGIR 33 KV

Feeder No / Name : 205 / 11KV SONGIR GT

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5487	.4854	.5028	.5028	.5304	.5258
2	.4801	.5487	.4854	.5028	.4854	.5304	.5258
3	.4801	.5487	.5201	.5548	.4854	.5304	.5784
4	.5144	.5853	.5548	.6241	.5548	.5487	.631
5	.583	.6401	.6068	.6935	.6068	.6401	.7087
6	.7202	.7682	.6415	.7628	.6415	.7865	.7796
7	.7373	.8413	.7802	.7975	.7802	.9145	.8063
8	.6859	.8413	.7455	.6935	.7282	.7499	.6733
9	.6344	.6401	.6935	.7282	.6935	.7133	.6485
10	.6401	.6935	.5895	.5895	.6588	.6661	.6379
11		.6588	.6762	.5201	.6335	.6415	.6241
12		.6241	.6485		.6767	.5895	.6068
13		.6068	.5784	.5201	.6335	.5548	.5375
14	.6767	.5721	.583	.5548	.6335	.5548	.5028
15	.6584	.5548	.5847	.5201	.6401	.5895	.5375
16	.6584	.5895	.5548	.5548	.6036	.5895	.5375
17	.6584	.5895	.5895	.6068	.6401	.6241	.5895
18		.6068	.6588	.6588	.6401	.6588	.6935
19		.7282	.7108	.7202	.695	.7802	
20	.961	.7716	.7455	.7716	.8048	.8149	.7455
21	.7316	.7202	.6935	.6516	.7316	.7282	.7802
22	.6838	.6516	.6415	.6173	.6767	.6588	.7455
23	.6401	.6001	.5895	.5895	.5487	.6241	.5375
24	.4801	.5487	.5201		.5201	.5375	
Max	.961	.8413	.7802	.7975	.8048	.9145	.8063
Min	.4801	.5487	.4854	.5028	.4854	.5304	.5028
Avg	.6371	.6449	.6199	.6243	.6340	.6482	.6342

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / SONGIR 33 KV

Feeder No / Name : 206 / 11 KV BDTCL FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0549	.0543	.052	.0543	.0549	.0526
2	.0514	.0549	.0543	.052	.0543	.0549	.0549
3	.0514	.0549	.0543	.052	.0543	.0549	.0549
4	.0514	.0549	.0543	.0347	.0543	.0549	.0526
5	.0514	.0549	.0543	.0347	.0543	.0549	.0366
6	.0514	.0549	.0543	.0347	.0543	.0549	.0554
7	.0343	.0366	.0362	.0347	.0362	.0366	.0362
8	.0343	.037	.0362	.0347	.0362	.0366	.0366
9	.0343	.0366	.0362	.0362	.0362		.0362
10	.0366	.0362	.0347	.0362	.0362	.0362	.0354
11	.0366	.0362	.0347	.0362	.0366	.0347	.0347
12	.0366	.0362	.0362	.0362	.0366	.0347	.0347
13	.0366	.0362	.0362	.0362	.0366	.0347	.0347
14	.0366	.0362	.0366	.0362	.0366	.0347	.0347
15	.0366	.0362	.0362	.0362	.0366	.0347	.0347
16	.0366	.0362	.0347	.0362	.0366	.0347	.0347
17	.0366	.0362	.0347	.0362	.0366	.0347	.0347
18	.0366	.0362	.0347	.0362	.0366	.0347	.052
19	.0549	.0543	.052	.0514	.0549	.0347	
20	.0549	.0529	.052	.0514	.0549	.0347	.052
21	.0549	.0682	.052	.0537	.0557	.052	.052
22	.0554	.0544	.0528	.0583	.0557	.052	.052
23	.0549	.0514	.052	.0543	.0549	.052	.052
24	.0514	.0549	.052		.0543	.052	
Max	.0554	.0682	.0543	.0583	.0557	.0549	.0554
Min	.0343	.0362	.0347	.0347	.0362	.0347	.0347
Avg	.0445	.0459	.0444	.0418	.0456	.0432	.0434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / SONGIR 33 KV

Feeder No / Name : 207 / 11 KV Sayane 1 PHASING

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.7316	.6935	.7282	.6935	.1463	.1227
2	.6516	.823	.7282	.7628	.6588	.1463	.1578
3	.6516	.8779	.7282	.8669	.6588	.1463	.1595
4	.6859	.9145	.7802	1.0056	.7802	.0549	.2103
5	.823	1.0059	.9015	1.0749	.8669	.1829	.2126
6	1.1145	1.1706	1.0056	1.1963	.9536	.2743	.2629
7	1.286	1.3717	1.3146	1.283	1.3003	.3475	.2629
8	1.0802	1.1888	.9536	.9882	1.0402	.2195	.2303
9	.1715	.1829	.1734	.1387	.0867	.1448	.2303
10	.1829	.1214	.0693	.0867	.0867	.156	.1063
11	.1646	.0867	.0693	.0693	.0732	1.0229	.7282
12		.0867	.0543	.0693	.0732	1.0576	.9536
13		.0867	.0362	.052	.0732	1.0402	1.0056
14	.0914	.0867	.0532	.052	.0732	1.0056	.8669
15	.1829	.0693	.0526	.052	.0549		.8669
16	.2195	.0867	.0693	.0867	.0549	1.0402	.8669
17	.2195	.0867	.0693	.0867	.0549	1.0749	.8322
18	.2561	.104	.0867	.0867	.0914	.7975	.1734
19	.3292	.208	.1387	.1886	.1463	.1907	
20	.2926	.2401	.1907	.2572	.2378	.1734	.2254
21	.2561		.1907	.2229	.2743	.1734	.2254
22	.2195	.1029	.156	.2058	.1646	.156	.208
23	.6401	.6001	.5028	.6588	.1463	.156	.1907
24	.6173	.7316	.7628		.7282	.156	
Max	1.286	1.3717	1.3146	1.283	1.3003	1.0749	1.0056
Min	.0914	.0693	.0362	.052	.0549	.0549	.1063
Avg	.4888	.4767	.4075	.4443	.3905	.4288	.4136



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094020 / SONGIR 33 KV

Feeder No / Name : 208 / 11 KV Sondale 1 PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.7316	.6068	.6588	.5548	.0549	.0543
2	.6173	.823	.6068	.6588	.5201	.0549	.0351
3	.6516	.8779	.6588	.6935	.5201	.0549	.0354
4	.6859	.9145	.7282	.7975	.5895	.0549	.0351
5	.7716	1.0059	.7628	.8669	.6588	.0549	.0351
6	.9259	1.0974	.7975	.9189	.6935	.0732	.0362
7	.9945	1.1523	1.0056	.9536	.9015	.0914	.0354
8	.8573	.9328	.8669	.0347	.8669		.0351
9	.0343	.0366	.0347	.0347	.0347	.0366	.0354
10	.0366	.0347	.0347	.0347	.0347	.0347	.0354
11	.0366	.0347	.0347	.0347	.0366	.9536	.8322
12	.0366	.0347	.0351	.0347	.0366	1.0576	.9015
13	.0366	.0347	.0351	.052	.0366	1.0402	.9536
14	.0549	.0347	.0526	.052	.0366	.9362	.7975
15	.0549	.0347	.052	.0347	.0366	.7975	.8669
16	.0549	.0347	.052	.0347	.0366	.8322	.8322
17	.0549	.0347	.052	.0347	.0366	.9189	.8669
18	.0549	.0347	.052	.0347	.0366	.7628	.0347
19	.0732	.052	.052	.0514	.0549	.052	
20	.0732	.0686	.052	.0686	.0549	.052	.052
21	.0732	.0514	.052	.0514	.0549	.052	.052
22	.0732	.0514	.0347	.0514	.0549	.0347	.0347
23	.5487	.6001	.4161	.5548	.0549	.0347	.0347
24	.6001	.6584	.6935		.6068	.0347	
Max	.9945	1.1523	1.0056	.9536	.9015	1.0576	.9536
Min	.0343	.0347	.0347	.0347	.0347	.0347	.0347
Avg	.3334	.3903	.3237	.2931	.2729	.3508	.3014

From 22-FEB-17 and 28-FEB-17

**Feeder No / Name : 209 / 11 KV Songir Water Supply                NON SHEDDABLE WATER SUPPLY AND**  
**(Sep Feeder KV- 11 / OUTGOING    UTILITY)**

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.1029		.0122				
5	.1075	.0777	.1675	.08	.1084	.1912	
6	.2054	.2103	.1705	.2061	.1717	.1939	
7	.2454	.2591	.2126	.2297	.1983	.2183	.0886
8	.2454	.2572	.193	.2301	.2164	.2152	.0886
9	.2241	.224	.1539	.2117	.1865	.1666	.0905
10	.1643	.1781	.0842	.1412	.1694	.1379	.0709
11	.1357	.1282	.0732	.1417	.1604	.1213	.0693
12	.1425	.121	.1248	.1421	.1429	.1236	
13	.1418	.1206	.1244	.1052	.1437	.1229	
14	.0594	.1395	.124	.0492	.1345	.1233	
15	.1044	.1395	.0701	.1035	.1227	.1225	
16	.1044	.0671	.0701	.1233	.0594	.1425	
17	.1044	.0034	.1394	.1417	.1269	.1252	.0076
18	.053	.1417	.1328	.1631	.1486	.1278	.052
19	.1018	.0652	.0652	.1467		.0583	.052
20	.1018	.0476	.0518	.1315		.0514	.052
21			.0526			.0533	
22			.0526			.0533	
Max	.2454	.2591	.2126	.2301	.2164	.2183	.0905
Min	.053	.0034	.0122	.0492	.0594	.0514	.0076
Avg	.1379	.1363	.1092	.1467	.1493	.1305	.0635

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094045 / 33/11 kv Bhabhle MIDc

Feeder No / Name : 201 / New Walkheda 1 phasing

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9498	2.1714	2.2939	2.5606	2.1795	.6859	.4572
2	2.0553	2.1382	2.2939	2.5873	2.1963	.743	.4572
3	2.0885	2.2045	2.4453	2.726	2.1963	.8002	.4572
4	2.1548	2.3472	2.5101	2.3868	2.2131	1.0349	.5121
5	2.2801	2.4981	2.5301	2.4863	2.2211	1.1016	.6584
6	2.364	2.652	2.6246	2.7183	2.2969	1.134	.7602
7	2.7831	2.9172	2.7778	2.9338	2.7018	1.134	.8688
8	2.5316	2.6322	2.4034	2.4531	2.2874	.8326	.7049
9	.7049	.724	.2286		.6097	.6287	
10	.5525	.4954	.5906	.5716	.5144	.4191	
11	.5144	.4954	.4572	.4763	.4954		2.2177
12	.4001	.2286	.4572	.4572	.4763	2.8178	1.885
13	.4191	.4954	.4954		.5335		1.8861
14	.4382	.5144	.4954	.5525	.4954		1.7194
15	.5144	.5144	.4954	.5144	.4954		1.7556
16	.4954	.5144	.4572	.4954	.4954	1.9784	1.8111
17	.4572	.4954	.4191	.4572	.4954	2.1548	1.6575
18	.5144	.5335	.5335	.5335	.5144	1.668	1.4746
19	.9328	.8764	.743	.9145	.8869		.6859
20	.8507	.9145	.9145	.9526	.8688	1.1203	.724
21	.9145	.8688	.8764	.8573	.8507	1.1574	.724
22	.8192	.8383	.7811	.7811	.724	1.0753	.6478
23	2.3537	2.1548	2.2361	2.2377	.7049	.6287	.5716
24	2.1216	2.3205	.5906	2.4326	2.1714	.5906	.4572
Max	2.7831	2.9172	2.7778	2.9338	2.7018	2.8178	2.2177
Min	.4001	.2286	.2286	.4572	.4763	.4191	.4572
Avg	1.3004	1.3560	1.2771	1.5039	1.2344	1.1424	1.0497

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094045 / 33/11 kv Bhabhle MIDC

Feeder No / Name : 202 / 11 KV Abhay Cotex Exp.

SHEDDABLE FEEDER HAVING WEEKLY

Feeder Feeder KV- 11 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3053	.3542	.3792	.3425	.3185	.392	.4172
2	.3053	.2931	.3792	.3425	.3185	.3675	.4172
3	.3175	.2931	.3914	.3302	.3185	.3675	.4172
4	.3175	.2813	.3914	.318	.3308	.3553	.4049
5	.3297	.3058	.3669		.3185	.3798	.3926
6	.3419	.2936	.3302		.3185	.3675	.3558
7	.3175	.2691	.3425	.2691	.2818	.3553	.3558
8	.4396	.2813	.3669	.3302	.3185	.343	.3313
9	.4519	.3425	.3914	.3547	.3185	.3185	.5153
10	.3175	.3425	.3792	.3547	.3308	.343	
11	.2809	.318	.4281	.318	.294	.3675	.5153
12	.2931	.2813		.2936	.2695	.4043	.3558
13	.2931	.318	.3914	.3669	.294	.3553	.3435
14	.2931	.318	.3547	.3302	.343	.5023	.4049
15	.3297	.318	.3669	.2936	.3063	.454	
16	.2931	.318	.3669	.2936	.294	.4294	.3435
17	.2809	.318	.318	.318	.294	.3435	.4908
18	.3053	.3792	.318	.3302	.3308	.3558	.3926
19	.3542	.4036	.3302	.3675	.3553	.3804	.3926
20	.3542	.4648	.3302	.3798	.392	.4417	.3926
21	.3542	.477	.3669	.3798	.392	.4417	.6097
22	.3664	.4893		.343	.3798	.4172	.4172
23	.3175	.4281	.3792	.294	.3308	.4294	.4294
24	.3053	.3419	.3425	.3302	.343	.392	.4417
Max	.4519	.4893	.4281	.3798	.392	.5023	.6097
Min	.2809	.2691	.318	.2691	.2695	.3185	.3313
Avg	.3277	.3429	.3642	.3309	.3246	.3877	.4153

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094045 / 33/11 kv Bhabhle MIDC

Feeder No / Name : 203 / 11 KV MIDC FEEDER-3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.1048	.1257	.1928	.2031	.1147	.0667
2	.4954	.0701	.1048	.1488	.1463	.1115	.0667
3	.4763	.0566	.0953		.1372	.1147	.0572
4	.5144	.0629	.0857	.1446	.1467	.1014	.0572
5	.4954	.0524	.0762		.1189	.1029	.0514
6	.4572	.0419	.06	.2012	.1303	.0975	.0514
7	.4382	.0389	.0566	.2012	.1065	.0524	.0572
8	.4382	.724	.156	.2126	.4954	.7049	.0524
9	.8326	.6097	.2686	.4954	.499	.4334	.1715
10	1.0642	.7811		.2858	.5335	.4534	
11	1.0269	.7811	.5079	.2947	.5906	.7621	.9717
12	.9896	.743		.2029	.8002	.8954	.1905
13	.9907	.3294	.5335	.1623	.7811	.4435	.9145
14	.8954	.2515	.5716	.1052		.6668	.8002
15	.9896	.1692	.6478	.253	.1006	.6097	.7621
16	1.1241	.1097		.2408	.8002	.6668	.5716
17	1.0642	.1429	.8002	.0941	.8954	.7811	.8383
18	.5906	.1505	.6668	.1532	.4075	.7621	.743
19	.5525	.1894	.7049	.1372	.3841	.6478	.724
20	.5716	.1	.7023	.333	.4024	.6478	.7049
21	.2149	.1875	.6653	.1446	.3155	.6478	.6478
22	.2126	.1029	.5258	.1562	.1557	.5788	.4382
23	.1372	.1326	.1663	.0964	.1557	.1067	.0943
24	.4763	.1052	.1417	.1928	.1486	.1094	.0572
Max	1.1241	.7811	.8002	.4954	.8954	.8954	.9717
Min	.1372	.0389	.0566	.0941	.1006	.0524	.0514
Avg	.6476	.2516	.3649	.2022	.3676	.4422	.3952

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV Betawad

Feeder No / Name : 201 / 11 KV Betawad Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9998	.9755	1.0494	.9755	.933		
2	.9842	.9602	1.0494	.9755	.9488		
3	.9686	.945	1.0494	.9164	.9488		
4	.9962		1.0467	.7964	.9282		
5	.9962	.9633	1.0467	.8215	.9442		
6	1.0402	.8993	1.1069	.8383	.9922		
7	1.0722	1.1203	1.1843	1.0031	1.085		
8	1.2146	1.0669	1.07	.9242	.9374		
11						1.2803	1.2651
12						1.2963	1.2037
13						1.186	1.1279
14						1.0936	1.0822
15						1.0802	1.0623
16						1.0802	1.1092
17						1.1431	1.0822
18						1.0402	1.0669
22	.9783						
23	.9755	1.0802	.9145	.9962			
24	.9998	.9755	1.0802	.9145	.9646		
Max	1.2146	1.1203	1.1843	1.0031	1.085	1.2963	1.2651
Min	.9686	.8993	.9145	.7964	.9282	1.0402	1.0623
Avg	1.0205	.9985	1.0598	.9162	.9647	1.1500	1.1249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV Betawad

Feeder No / Name : 202 / 11 KV Betawad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7522	.7522	.7783	.7701	.8059	.8596	.8417
2	.7522	.6321	.7783	.7701	.8059	.823	.8417
3	.7522	.6001	.7783	.7964	.8059	.8316	.8596
4	.8507	.6626	.8413	.823	.8688	1.0534	.9412
5	1.0242	1.0719	1.0242	.8316	.9774	1.1949	1.0242
6	1.1273	1.1827	1.1273	1.1827	1.134	1.307	1.1273
7	1.3491	1.2752	1.2936	1.3443	1.3121	1.1643	1.2197
8	1.0534	.9774	1.086	1.0903	1.1157	.9877	.8417
9	.7628	.7716	.9015	.7973	.815	.8413	.788
10	.9282	.7712	.8478	.7716	.7291	.8478	.7127
11		.7888	.7011	.6733	.7796	.7628	.6935
12		.7802	.6935	.7186	.8316	.7537	.6588
13		.8063	.2686		.8048	.7712	.6687
14	.9362	.8063	.2686	.7282	.8145	.7975	.7628
15	.9015	.7712	.8764	.8322	.8682	.8413	.7628
16	.9114	.8063	.8764	.8149	.8413	.8859	.8322
17	.8238	.7888	.7628	.7975	.8589	.8573	.763
18	1.0341	.78	.7802	.8573	.8495	.8288	.7522
19	1.0166	1.0808	1.1269	.9816	1.0631	1.0208	1.0808
20	1.0166		1.0867	1.0631	.9745	1.0387	1.0631
21	.9114		1.0867	.9671	1.0099	.9492	.9671
22	.8936	.8954	.9114	.9134	.9568	.8859	.3045
23	.7701	.8326	.8238	.8688	.8505	.8596	.8059
24	.7522	.7522	.7783	.7701	.8059	.8417	.8417
Max	1.3491	1.2752	1.2936	1.3443	1.3121	1.307	1.2197
Min	.7522	.6001	.2686	.6733	.7291	.7537	.3045
Avg	.9200	.8448	.8541	.8767	.9033	.9169	.8398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DHULE URBAN DIVISION[582]

NARDANA[216]

BU 0566

Substation No/ Name :- 094057 / 33/11 KV Betawad

Feeder No / Name : 421 / 33 KV Incomer I

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0005	1.6004	2.1148	1.4186	2.0005	.9145	.9145
2	2.0005	1.5352	2.1148	1.6004	2.0005	.8573	.9145
3	2.0005	1.6461	2.1148	1.7078	2.0005	.8573	.9145
4	2.1148	1.829	2.1719	1.3014	2.0005	1.086	.9717
5	2.2862	1.8747	2.3434	1.6461	2.1719	1.2003	1.086
6	2.4006	1.6004	2.5149	1.8976	2.3434	1.3146	1.1431
7	2.6863	2.1559	2.7435	1.9662	2.6292	1.2003	1.2574
8	2.5149	1.945	2.5149		6.9159	1.0288	.9145
9	.8573	.8573	.9717		.8573	.9145	.8573
10	.8573	.0857	.9717	.8002	.8002	.9717	.8002
11		.8573	.743	.743	.7973	2.3434	2.1491
12		.8573	.743	.8002	.8573	2.3434	2.1176
13		.8573	.8002		.8573	2.2862	2.0416
14	.8939	.8573	.8573	.8002	.8573	2.2291	2.2262
15	.8745	.8573	.9717	.9145	.9145	2.2291	2.009
16	.9717	.8573		.9145	.9145	2.2862	2.2857
17	.8573	.8573	.8002	.8573	.9145	2.4006	2.1176
18	.9145	.8573	.8573	.9717	.9145	2.4006	2.0508
19	1.086	1.1431	.12	1.086	1.1431	1.086	1.1431
20	1.086		1.1431	1.1431	1.0288	1.086	1.1431
21	.9717		1.086	1.0288	1.086	1.0288	1.0288
22	.9717	.9717	.8573	.9717	1.0288	.9717	.9717
23	1.6004	2.2291	1.8804	2.1148	.9145	.0572	.8573
24	2.0005	1.6461	2.1719	1.5546	2.0005	.9145	.9145
Max	2.6863	2.2291	2.7435	2.1148	6.9159	2.4006	2.2857
Min	.8573	.0857	.12	.743	.7973	.0572	.8002
Avg	1.5213	1.2717	1.4612	1.2495	1.5812	1.4170	1.3679



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 201 / BALSANE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0631	1.3717	1.2003	1.406
2				1.1145	1.4232	1.3717	1.406
3				1.166	1.4575	1.3717	1.4575
4				1.2517	1.4918	1.5432	1.4918
5				1.3889	1.5775	1.8861	1.5947
6				1.749	1.9204	1.9033	1.8519
7				2.1776	2.9492	2.5892	2.4863
8				1.6632	2.1434	1.7661	2.0576
11	2.8292	3.0007	2.5377				
12	.4287	2.8807	1.8861				
13		2.7435	2.6749				
14	2.8292	2.572	2.3491				
15	2.9835	2.572	1.6118				
16	2.8464	2.6063	2.1434				
17	2.6578	2.1434	1.9719				
18	1.9547	1.8004	1.5947				
23			.9945	1.1488	1.7147	1.4403	
24				1.046	1.3203	1.7147	1.5775
Max	2.9835	3.0007	2.6749	2.1776	2.9492	2.5892	2.4863
Min	.4287	1.8004	.9945	1.046	1.3203	1.2003	1.406
Avg	2.3614	2.5399	1.9738	1.3769	1.7370	1.6787	1.7033

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 202 / HATI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.0288	1.0288				
2	1.1145	1.1145	1.0288				
3	1.166	1.2003	.9945				
4	1.2003	1.286	.9431				
5	1.286	1.5432	.8916				
6	1.3717	1.6289	1.2517				
7	1.6289	1.7833	1.6804				
8	1.5432	1.4575	1.2174				
11				1.8176	1.989	2.0405	2.0576
12				1.869	1.8861	1.6632	.1715
13				1.6804	1.406	1.5089	1.5432
14				1.3717	1.4575	1.166	1.2346
15				1.2517	1.286	1.0631	1.2346
16				1.1488	1.2346	1.0802	1.2003
17				1.2003	1.286	1.0974	1.2689
18				1.046	1.286	1.046	1.0288
19							1.0288
20							1.0288
23	.9945	1.1145					.6001
24	1.0288	.9431	1.0974				
Max	1.6289	1.7833	1.6804	1.869	1.989	2.0405	2.0576
Min	.9945	.9431	.8916	1.046	1.2346	1.046	.1715
Avg	1.2448	1.3100	1.1260	1.4232	1.4789	1.3332	1.1270

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 203 / HATTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.2058	.2401	.2572	.2401	.2401
2	.2572	.2401	.2058	.2743	.2572	.2401	.2572
3	.3429	.2572	.3429	.3258	.3086	.2572	.3086
4	.4458	.3429	.4801	.4115	.3772	.3429	.3601
5	.6001	.6001	.6516	.6859	.6687	.4287	.6687
6	.7716	.7202	.7888	.8402	.7716	.7373	.9431
7	.823	.8402	.823	.8059	.9431	.7545	.8573
8	.6173	.6344	.6859	.7202	.8059	.6173	.7202
9	.5144	.463	.4801	.6173	.4287	.4801	.4801
10	.3429	.2743	.3944	.4801	.2629	.3086	.3086
11	.2915	.1715	.3429	.2743	.2401	.2401	.2401
12	.2572	.1715	.2572	.2229	.2401	.2229	.2058
13	.2572	.1715	.2401	.2058	.2401	.2058	.2058
14	.2572	.1715	.2058	.2229	.2058	.1715	.1715
15	.2743	.2058	.2229	.2229		.1715	.2058
16	.2743	.2401	.2572	.2401	.2572	.2401	.2401
17	.2743	.3772	.2743	.2915	.2572	.2743	.2572
18	.6859	.4801	.4287	.463	.2572	.4973	.4268
19	.583	.7888	.7716	.7888	.2572	.7202	.7202
20	.4287	.5144	.5658	.6001	.4287	.6001	.5144
21	.3429	.4115	.4973	.4801	.5144	.4801	.4287
22	.3772	.3086	.3258	.3258	.4287	.3258	.3086
23	.2401	.2058	.2572	.2572	.3429	.2572	.2743
24	.1715	.2058	.2058	.2401	.2401	.2401	.2401
Max	.823	.8402	.823	.8402	.9431	.7545	.9431
Min	.1715	.1715	.2058	.2058	.2058	.1715	.1715
Avg	.4037	.3765	.4130	.4265	.3909	.3772	.3993

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 204 / malpur Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4287	.4115	.4115	.4115	.4287	.4287
2	.4287	.4801	.4115	.4458	.4115	.4287	.4287
3	.5144	.5144	.5144	.5144	.463	.5144	.4458
4	.6859	.6001	.6516	.5658	.4801	.6001	.4973
5	.8573	.7716	.7716	.8059	.6516	.6859	.6687
6	.9431	.8916	.9259	1.1145	.7545	.8059	1.166
7	.9774	.9088	1.1317	1.0288	.7888	1.0631	1.166
8	.8573	.7545	.9945	.8059	.8059	.9088	.9774
9	.5144		.6859	.6344	.5144	.703	.6859
10	.4287	.4801	.5658	.463	.463	.4801	.583
11	.3601	.4115	.4287	.3772	.4287	.4115	.4115
12	.3429	.3944	.3772	.3258	.3429	.3601	.3772
13	.2743	.3772	.3944	.3086	.3086	.3601	.3772
14	.0309	.3944	.3944	.3258	.3429	.3601	.3601
15	.2401	.3772	.4287	.3429	.3772	.3429	.3772
16	.2572	.3772	.3772	.3429	.4287	.3601	.3772
17	.3429	.4458	.4287	.3429	.4287	.3944	.4115
18	.4115	.4801	.5144	.4801	.3944	.5144	.583
19	.9431	.8916	.8402	.7888	.5658	.9774	.9602
20	.7373	.6859	.703	.6859	.8573	.7716	.703
21	.6859	.5487	.5316	.5316	.823	.6173	.6173
22	.5144	.4801	.5144	.4801	.6859	.5144	.5316
23	.463	.4115	.4287	.4115	.5144	.4458	.4458
24	.3429	.4115		.3944	.3944	.4287	.4115
Max	.9774	.9088	1.1317	1.1145	.8573	1.0631	1.166
Min	.0309	.3772	.3772	.3086	.3086	.3429	.3601
Avg	.5243	.5442	.5837	.5387	.5266	.5616	.5830

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 205 / AICHALE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3717	1.3717				
2	1.4575	1.4575	1.3717				
3	1.5432	1.5432	1.4575				
4	1.7147	1.6289	1.5089				
5	1.8861	1.8861	1.6289				
6	2.2291	2.0576	1.9204				
7	2.3663	2.2291	2.1776				
8	2.2291	1.8861	1.8176				
11				2.2805	2.0576	2.1605	1.9719
12				2.4691	2.2291	2.1605	2.1091
13				2.3663	2.1948	1.8176	1.749
14				2.1434	1.9719	1.6804	1.5261
15				1.8861	1.6804	1.4746	1.5432
16				1.869	1.5947	1.5261	1.5775
17				1.8176	1.6289	1.5604	1.6289
18				1.6804	1.5432	1.2517	1.4746
23	1.3717	1.3889					1.0288
24	1.3717	1.286	1.406				
Max	2.3663	2.2291	2.1776	2.4691	2.2291	2.1605	2.1091
Min	1.3717	1.286	1.3717	1.6804	1.5432	1.2517	1.0288
Avg	1.7541	1.6735	1.6289	2.0641	1.8626	1.7040	1.6232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094026 / 33/11KV INDAVE

Feeder No / Name : 206 / INDAVE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6859	.7373	.6859	.7716
2				.6859	.7716	.6859	.7716
3				.7202	.7716	.7716	.7888
4				.7202	.7888	.8573	.8573
5				.7888	.823	.8916	.8916
6				.9945	1.1145	.9088	1.2003
7				1.0974	1.7661	1.5432	1.6461
8				.9945	1.4403	1.5432	1.3032
11	1.3032	1.166	1.0802				
12	1.4403	1.3032	1.2517				
13	1.4575	1.2003	1.2346				
14	1.2003	1.0631	1.0631				
15	1.0631	1.0288	.8745				
16	1.0288	1.0288	1.0974				
17	1.0974	.9431	1.2003				
18	.9259	.7888	.9259				
20		.7888					
23			.6516	.7202	.8573	.8402	
24				.6687	.7545	.8573	.7888
Max	1.4575	1.3032	1.2517	1.0974	1.7661	1.5432	1.6461
Min	.9259	.7888	.6516	.6687	.7373	.6859	.7716
Avg	1.1896	1.0345	1.0421	.8076	.9825	.9585	1.0021

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094037 / 33/11 KV DEGAON

Feeder No / Name : 201 / DEVI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1334					
2		.1334					
3		.1334					
4		.1334					
5		.16					
6		.1829					
7		.1829					
8		.2286					
11				.1219	.2743	.2286	.1219
12				.2115	.2286	.2743	.0152
13	5.2949			.2029	.2743	.2743	.1524
14				.2058	.2743	.2743	.1829
15				.2115	.2743	.1829	.1829
16					.2439	.1219	.1829
17					.2439	.1219	.1524
18				.1972	.2286	.1219	.1524
19					.2		
20					.2		
23	.1067						.061
24	.1334	.1067	.1219				
Max	5.2949	.2286	.1219	.2115	.2743	.2743	.1829
Min	.1067	.1067	.1219	.1219	.2	.1219	.0152
Avg	1.845	.1550	.1219	.1918	.2442	.2000	.1338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094037 / 33/11 KV DEGAON

Feeder No / Name : 202 / Devi Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	28-FEB-17
HR	Load (MW)
24	.0762
Max	.0762
Min	.0762
Avg	.0762



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094037 / 33/11 KV DEGAON

Feeder No / Name : 203 / Varzadi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1334	.1219	.2286	.2
2				.1334	.1257	.2286	.2
3				.1315	.1238	.2286	.2
4				.1334	.1257	.2286	.2667
5				.1646	.1943	.2667	.2667
6				.2143		.2667	.4001
7				.2858	.2667	.4001	.4572
8				.2972	.2705	.4001	.4572
11	.4572	.3353	.301				
12	.4572	.4572	.4572				
13	.4572	.381	.381				
14	.3963	.381	.3763				
15	.381	.3048	.4572				
16	.381	.3048	.4572				
17	.381	.3048	.463				
18	.3048	.2743	.301				
22				.1238			
23			.1315	.1238	.2667	.2667	
24				.1315	.1334	.2667	.2667
Max	.4572	.4572	.463	.2972	.2705	.4001	.4572
Min	.3048	.2743	.1315	.1238	.1219	.2286	.2
Avg	.4020	.3429	.3695	.1702	.1810	.2781	.3016

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094037 / 33/11 KV DEGAON

Feeder No / Name : 204 / SHEWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	22-FEB-17	23-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6668				
2		.6668				
3		.7335				
4		.8002				
5		.8669				
6		1.0669				
7		1.2651				
8		1.1431				
11			1.3475	1.2955	1.2955	1.2193
12			1.0303	1.448	1.2955	1.2955
13			1.3555	1.326	1.2955	1.2193
14			1.3603	1.326	1.2193	1.2193
15			1.3796	1.2651	1.2193	1.1431
16			.7865	1.2346	1.2193	
17			1.2568	1.1431	1.0669	1.0669
18			1.0829	1.0669	.9145	.9907
23	.5335					.6001
24	.6668	.6668				
Max	.6668	1.2651	1.3796	1.448	1.2955	1.2955
Min	.5335	.6668	.7865	1.0669	.9145	.6001
Avg	.6002	.8751	1.1999	1.2632	1.1907	1.0943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 201 / NIMGUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2401	.2012	.2378	.2229	.2534	.2012
2	.2195	.2401	.2012	.2353	.2229	.2561	.2012
3	.2195	.2572	.2195	.2572	.2401	.2896	.2012
4	.2378	.2915	.2195	.3155	.2401	.3292	.2561
5	.2743	.3086	.2743	.3189	.2401	.3224	.3258
6	.394	.4287	.3582	.3658	.3429	.4024	.3801
7	.4119	.3944	.394	.3658	.3772	.4163	.3582
8	.3801	.3582		.3982	.3429	.3439	.3086
9	.2572	.2896	.3475	.2743	.2896	.2743	.2572
10	.2572	.2353	.2896	.2743	.2353	.2743	.1886
11	.3086	.3077	.3109	.2229	.2534	.2195	.3429
12	.2743	.1991	.2328	.2572	.2481	.2378	.2743
13	.2058	.2715	.3224	.2401	.2149	.2378	.2915
14	.2572	.2534	.2012	.2572	.2303	.2561	.2058
15	.2229	.2172		.2058	.2303	.2195	.2743
16	.2915	.2378		.2743	.2328	.2195	.2229
17	.3086	.2378		.2743	.2328	.2561	.2915
18	.3086	.3258		.3086	.2865	.2715	.3258
19	.3601	.362	.3982	.3601	.3898	.3982	.3601
20	.3429	.3439	.4119	.3601	.362	.362	.3429
21	.3086	.3077	.3012	.2915	.3258	.3077	.2915
22	.2915	.2715	.2804	.2743	.2896	.2926	.2915
23	.2572	.2378	.2534	.2401	.2507	.2561	.2572
24	.2378	.2401	.2195	.2328	.2229	.2561	.2378
Max	.4119	.4287	.4119	.3982	.3898	.4163	.3801
Min	.2058	.1991	.2012	.2058	.2149	.2195	.1886
Avg	.2853	.2857	.2862	.2851	.2718	.2897	.2787

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 202 / Takerkheda Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.7375	1.7147	1.4842	1.6118
2				1.7194	1.7318	1.4632	1.5089
3				1.8111	1.749	1.4327	1.4746
4				1.7737	1.749	1.3432	1.4746
5				1.8473	1.7661	1.3466	1.4746
6				1.8625	1.749	1.379	1.5089
7				1.9022	2.4691	1.5927	1.7147
8				2.0416	1.9719	1.5384	1.4746
11	2.0576	2.2462	2.4253				
12	2.2119	2.2634	2.6612		2.3461		
13	2.2805	2.2634	2.5789		2.0995		
14	2.3491	2.332	2.5606		2.1176		
15	2.2977	2.3834					
16	2.332	2.4177					
17	2.0576	2.4419					
18	2.0233	2.2977					
19			1.2567				
20			1.267				
21			1.448				
23			1.7741	1.749		1.6804	
24				1.7375	1.8004	1.5729	1.6804
Max	2.3491	2.4419	2.6612	2.0416	2.4691	1.6804	1.7147
Min	2.0233	2.2462	1.2567	1.7194	1.7147	1.3432	1.4746
Avg	2.2012	2.3307	1.9965	1.8182	1.9387	1.4833	1.5470

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 203 / Pathare Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.6001	.567			
2	.567	.6001	.567			
3	.5677	.6173	.567			
4	.6024	.6344	.5847			
5	.6201	.6687	.6024			
6	.6201	.703	.6661			
7	.6661	.7545	.7087			
8	.7186	.7796				
11				.7373	.7265	.7202
12				.7545	.7619	.6859
13				.703	.7442	.7373
14				.7545	.7442	.703
15				.8059	.7265	.7202
16				.7888	.7442	.7716
17				.7716	.7265	.703
18				.7545	.7265	.6859
23	.6173	.6024				.5658
24	.567	.6001	.6024			
Max	.7186	.7796	.7087	.8059	.7619	.7716
Min	.567	.6001	.567	.703	.7265	.5658
Avg	.6113	.6560	.6082	.7588	.7376	.6992

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 204 / PANI-PURWATHA TAVKHEDA NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.1543	.0914	.1991	.12	.1772	.1829
2	.0914	.1543	.0914	.2012	.12	.1772	.2012
3	.128	.1715	.128	.1991	.12	.1949	.2195
4	.1463	.1715	.1463	.2012	.12	.197	.2195
5	.1829	.1886	.1829	.1991	.12	.197	.2561
6	.1829	.1886	.1829	.197	.12	.197	.2743
7	.2012	.1886	.2012	.1991	.1372	.197	.2743
8	.1829	.2012		.1063	.0137	.1991	.2572
9	.1715	.1829	.2561	.12	.2534	.2561	.2572
10	.1715	.2743	.2534	.12	.2534	.2534	.2572
11	.2572	.2743	.2743	.12	.2658	.2743	.2743
12	.2572	.2743	.2715	.12	.2658	.2012	.2743
13	.2572	.2743	.2772	.12	.2658	.2012	.2572
14	.2572	.2743	.2743	.12	.2686	.2743	.2572
15	.2572	.2743		.0686	.2715	.2743	.2572
16	.2572	.2743		.1372	.2926	.2743	.2572
17	.2572	.2743		.1029	.2896	.2743	.2058
18	.1715	.1829		.12	.197	.2743	.2572
19	.1886	.1829	.1075	.12	.1433	.2012	.2401
20	.1715	.128	.1772	.12	.0526	.128	.2401
21	.1715	.1829	.1772	.12	.0526	.1097	.2572
22	.1715	.1829	.1949	.12	.0526	.1097	.2401
23	.1886	.1829	.197	.12	.1949	.1097	.2572
24	.0549	.1886	.128	.1991	.12	.1991	.1463
Max	.2572	.2743	.2772	.2012	.2926	.2743	.2743
Min	.0549	.128	.0914	.0686	.0137	.1097	.1463
Avg	.1847	.2095	.1901	.1437	.1713	.2063	.2425

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094047 / Nimgul 33/11 KV S/S

Feeder No / Name : 205 / Daul Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.4115	.3658	.4163	.3944	.4163	.4024
2	.4024	.4287	.3658	.4251	.4115	.4163	.4024
3	.439	.463	.4207	.462	.4458	.4119	.439
4	.5068	.5144	.4656	.5068	.4973	.4075	.4706
5	.591	.6173	.5373	.6154	.5316	.4207	.5611
6	.8682	.8573	.8505	.8686	.7545	.823	.8417
7	.9816	.9431	.9816	.9145	.9431	.9511	.9391
8	.8063	.8328		.7701	.823	.7865	.7716
9	.583	.5373	.6335	.5658	.6154	.591	.583
10	.583	.4887	.362	.4973	.5487	.4961	.463
11	.463	.4887	.4066	.3944		.4525	.3601
12	.3429	.4163	.394	.3601	.3982	.3801	.3772
13		.3292	.3506	.3601	.2686	.362	.3429
14		.2926	.3224	.3772	.3258	.3801	.3429
15		.3841		.3944	.4163	.3801	.3601
16	.3772	.362		.3772	.3761	.3982	.3601
17	.4287	.3801		.4115	.3841	.3982	.4115
18	.4801	.4163		.4115	.4477	.4887	.4458
19	.7716	.7619	.8507	.7373	.8238	.7964	.7202
20	.6001	.6733	.7164	.6859	.6767	.6089	.6687
21	.5316	.5731	.5493	.5658	.5304	.5792	.5487
22	.4973	.5249	.5068	.4801	.5175	.5249	.5487
23	.4458	.439	.4207	.4115	.4163	.4525	.4458
24	.4344	.4115	.4024	.4207	.3944	.4207	.4344
Max	.9816	.9431	.9816	.9145	.9431	.9511	.9391
Min	.3429	.2926	.3224	.3601	.2686	.362	.3429
Avg	.5492	.5228	.5212	.5179	.5192	.5143	.5100

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094062 / 33/11 KV Dondaicha (Tapi

Sagar

Feeder No / Name : 201 / 11Kv Dondaicha (Tapi

SHEDDABLE URBAN

Sagar) Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	1.9033	1.6289	1.6461	1.6118	1.6975	1.749
2	1.4918	1.9547	1.6118	1.3717	1.5775	1.6804	1.6461
3	1.5089	1.8176	1.5775	1.5089	1.6118	1.6632	1.6632
4	1.5089	1.8519	1.5947	1.4746	1.5432	1.6461	1.6461
5	1.8004	1.8004	1.6289	1.6804	1.8004	1.6975	1.6804
6	2.2462	2.2119	2.0233	2.1776	2.0919	2.1091	2.3834
7	2.5549	2.452	2.5549	2.5034	2.3148	2.4691	2.6063
8	2.332	2.5034	2.6749	2.3148	2.6235	2.2977	2.5892
9	2.1605	2.0748	2.4863	2.332	2.3148	2.1434	2.1262
10	2.2119	2.0405	2.1605	1.9547	2.2119	2.0919	2.1605
11	2.2805	1.9719	2.0233	1.9719	2.1776	2.0233	2.0576
12	2.2634	1.5604	2.1091	2.0233	1.989	2.1262	2.0062
13	2.0748	1.8176	1.9376	1.9547	1.8347	2.0062	2.0748
14	1.9033	1.8176	1.7147	1.8347	1.8347	2.0405	1.9547
15	1.9376	1.989	1.8004			2.0233	2.0919
16	2.0405	1.8519	1.8347	1.8861	1.869	2.0576	2.0576
17	2.0748	2.0405	1.8004	2.0919	1.8347	2.1776	2.1948
18		2.1091	2.0919	2.1948	2.0233	2.2462	2.2119
19	2.7263	2.692	2.6406	2.6063	2.5206	2.8635	2.5892
20	2.572	2.6063	2.4006	2.572	2.5206	2.6578	2.5377
21	2.2462	2.3663	2.2977	2.2634	2.2977	2.4348	2.5377
22	2.0919	2.2119	2.0405	.2006	2.0576	2.3148	2.332
23	2.0233	1.9376	1.8347	1.9204	1.8176	1.8519	2.0062
24	1.6118	.1783	1.6632	1.6289	1.6461	1.7318	.18
Max	2.7263	2.692	2.6749	2.6063	2.6235	2.8635	2.6063
Min	1.4403	.1783	1.5775	.2006	1.5432	1.6461	.18
Avg	2.0479	1.9900	2.0055	1.9180	2.0054	2.0855	2.0451



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094062 / 33/11 KV Dondaicha (Tapi

Sagar

Feeder No / Name : 202 / Universal Starch Allied NON SHEDDABLE EXPRESS HV FEEDERS  
 (USA) Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6344	.7888	.4973	.3086	.6859	.6516
2	.6516	.6344	.7888	.6516	.3258	.703	.6859
3	.6859	.6173	.7545	.6516	.3772	.7202	.6859
4	.7373	.5144	.7716	.6516	.4801	.7373	.6859
5	.7373	.7202	.8059	.6344	.5144	.7716	.6516
6	.7373	.7545	.823	.6516	.5487	.8402	.6516
7	.7545	.823	.9431	.2229	.5487	.7716	.6516
8	.583	.7716	.8059	.463	.1543	.6859	.6344
9	.2229	.7716	.9945	.3429	.3258	.6001	.6859
10	.2229	.8573	.7202	.1886	.7545	.4287	.6859
11	.2572	.8059	.823	.2058	.7202	.4801	.6687
12	.7373	.9088	.8573	.2572	.8573	.8059	.703
13	.6687	.2401	.8745	.2743	.8402	.7716	.7716
14	.7202	.2401	.8402	.4115	.7373	.8059	.703
15	.7202	.2401	.6859		.8573	.8059	.6859
16	.7202	.6344	.2229		.7545	.823	.7716
17	.703	.703	.2401		1.0288	.7373	.6001
18	.6859	.8573	.2058		.823	.9088	.6173
19	.6687	.8745	.2401		.7373	.7545	.703
20	.6344	.7716	.2401		.6859	.8402	.6687
21	.6859	.7716	.6344		.7888	.6516	.6173
22	.6516	.7888	.583		.7373	.6687	.6859
23	.6344	.823	.6687		.7545	.6344	.7202
24	.5487	.6344	.823	.4973	.3429	.7373	.583
Max	.7545	.9088	.9945	.6516	1.0288	.9088	.7716
Min	.2229	.2401	.2058	.1886	.1543	.4287	.583
Avg	.6259	.6830	.6723	.4401	.6251	.7237	.6737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094070 / 33/11KV VIKHARAN(DEVACHE)

SUBS

Feeder No / Name : 201 / VIKHARAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6283	.5729	.5729	.5359	.5544	.4805	.5228
2	.6099	.6838	.6468	.5544	.7023	.4435	.5228
3	.7577	.8501	.7392	.5544	.7762	.5175	.5415
4	.8131	.961	.924	.7947	.8871	.7392	.9335
5	1.1458	1.0719	1.0719	1.0349	.9795	.9979	1.0829
6	1.2382	1.1827	1.1643	1.1088	1.0903	1.2382	1.2883
7	1.1458	1.2382	1.2382	1.1458	1.1273	1.2752	1.2883
8	.924	1.1273	.9896	.9425	1.0719	.9896	1.1016
9	.8501	.7207	.9896	.8131	.7577	.7468	.6653
10	.6099	.5914	.6535	.6468	.6838	.5601	.5914
11	.5914	.5544	.6535	.5175		.5601	.5729
12	.5359	.5175	.5788	.5359		.5041	.499
13		.5175	.5415	.5359		.4854	.4805
14		.4805		.2587	.5729	.5041	.0499
15		.4435		.0536	.6653	.5041	.5544
16	.5544	.5359	.6722	.5914	.7023	.5788	.061
17	.6283	.5544	.6722	.6653	.7023	.7282	.0665
18	.8131	.7577	.8029	.7023	.7392	.8962	.7762
19	1.1827	1.0719	1.1763	1.0903	1.0349	1.1203	1.1458
20	.8686	.924	.8962	.961	.9425	1.0082	.961
21	.7762	.8131	.7282	.7762	.7392	.7655	.7207
22	.6653	.6468	.6535	.6283	.6283	.6348	.6653
23	.5729	.5914	.5359	.5415	.5544	.6161	.5544
24	.5359	.4294	.4435	.4481	.5041	.5415	.5729
Max	1.2382	1.2382	1.2382	1.1458	1.1273	1.2752	1.2883
Min	.5359	.4294	.4435	.0536	.5041	.4435	.0499
Avg	.7832	.7433	.7884	.6849	.7817	.7265	.6758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 094070 / 33/11KV VIKHARAN(DEVACHE)

SUBS

Feeder No / Name : 202 / METHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3067	.3666	.3807	.431
2				.3067	.4089	.4089	.3418
3				.3201	.4793	.4512	.3121
4				.3467	.5498	.5639	.3567
5				.3734	.5921	.7049	.431
6				.4001	.6485	.7613	.7282
7				.5868	.6908	.8318	.7727
8				.0547	.7472	.8025	.6836
11	.6535	.7472	.6836				
12	.5868	.7049	.6241				
13	.5201	.5498	.535				
14	.4801	.5216					
15	.4401	.5357					
16	.4801	.5639	.6093				
17	.5068	.578	.5944				
18	.048		.535				
23			.3269	.3269	.3525	.4458	
24			.3418	.3418	.3418	.4458	
Max	.6535	.7472	.6836	.5868	.7472	.8318	.7727
Min	.048	.5216	.3269	.0547	.3418	.3807	.3121
Avg	.4644	.6002	.5313	.3364	.5178	.5797	.5071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 201 / METHI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6859	.6859	.6859	.6859	.6859	.6859
2	.6097	.6859	.6859		.6859	.6859	.6859
3	.6097	.6859	.6859	.6859	.6859	.6859	.6859
4	.6097	.6859	.6859	.6859	.6859	.6859	.6859
5	.6097	.6859	.6859	.6859	.6859	.6859	.6859
6	.6097	.6859	.6859		.6859	.6859	.6859
7	.6097	.6859	.6859	.6859	.6859	.6859	.6859
8	.6097	.6859	.6859	.6859	.6859	.6859	.6859
9	.6097	.6859	.6859	.6859			.6859
10	.6097	.6859	.6859	.6859	.6859	.6859	
11	.6097	.6859	.6859	.6859	.6859	.6859	.6859
12	.6097	.6859	.6859	.6859	.6859	.6859	.6859
13	.6097	.6859		.6859	.6859	.6859	.6859
14	.6097	.6859	.6859	.6859	.6859	.6859	.6859
15	.6097	.6859	.6859	.6859	.6859	.6859	.6859
16	.6097	.6859	.6859	.6859	.6859	.6859	.6859
17	.6097	.6859	.6859	.6859	.6859	.6859	.6859
18	.6097	.6859		.6859	.6859	.6859	.6859
19	.6097	.6859		.6859	.6859	.6859	.6859
20	.6097	.6859		.6859	.6859	.6859	.6859
21	.6097	.6859		.6859	.6859	.6859	.6859
22	.6097	.6859		.6859	.6859	.6859	.6859
23	.6097			.6859	.6859	.6859	.6859
24	.6859	.6859	.6859	.6859	.6859	.6859	.6859
Max	.6859	.6859	.6859	.6859	.6859	.6859	.6859
Min	.6097	.6859	.6859	.6859	.6859	.6859	.6859
Avg	.6129	.6859	.6859	.6859	.6859	.6859	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 202 / S.MANDAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6859	.6859	.6097	.6859	.6859	.6859
2	.6097	.6859	.6859	.6859	.6859	.6859	.6859
3	.6097	.6859	.6859	.6859	.6859	.6859	.6859
4	.6097	.6859	.6859	.6859	.6859	.6859	.6859
5	.6097	.6859	.6859	.6859	.6859	.6859	.6859
6	.6097	.6859	.6859	.6859	.6859	.6859	.6859
7	.6097	.6859	.6859	.6859	.6859	.6859	.6859
8	.6097	.6859	.6859	.6859	.6859	.6859	.6859
9	.6097	.6859	.6859	.6859			.6859
10	.6097	.6859	.6859	.6859	.6859	.6859	.6859
11	.6097	.6859	.6859	.6859	.6859		.6859
12	.6097	.6859	.6859	.6859	.6859	.6859	.6859
13	.6097	.6859	.6859	.6859	.6859	.6859	.6859
14	.6097	.6859	.6859	.6859	.6859	.6859	.6859
15		.6859	.6859	.6859	.6859	.6859	.6859
16	.6097	.6859	.6859	.6859	.6859	.6859	.6859
17	.6097	.6859	.6859	.6859	.6859	.6859	.6859
18	.6097	.6859			.6859	.6859	.6859
19	.6097	.6859			.6859	.6859	.6859
20	.6097	.6859		.6859	.6859	.6859	.6859
21	.6097	.6859		.6859	.6859	.6859	.6859
22	.6097	.6859		.6859	.6859	.6859	.6859
23	.6097			.6859	.6859	.6859	.6859
24	.6859	.6859	.6859	.6859	.6859	.6859	.6859
Max	.6859	.6859	.6859	.6859	.6859	.6859	.6859
Min	.6097	.6859	.6859	.6097	.6859	.6859	.6859
Avg	.6130	.6859	.6859	.6824	.6859	.6859	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 203 / MALPUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6859	.6859	.6859	.6859	.6859	.6859
2	.6097	.6859	.6859	.823	.6859	.6859	.6859
3	.6097	.6859	.6859	.6859	.6859	.6859	.6859
4	.6097	.6859	.6859	.6859	.6859	.6859	.6859
5	.6097	.6859	.6859	.6859	.6859	.6859	.6859
6	.6097	.6859	.6859		.6859	.6859	.6859
7	.6097	.6859	.6859	.6859	.6859	.6859	.6859
8	.6097	.6859	.6859	.6859	.6859		.6859
9	.6097	.6859	.6859	.6859	.6859	.6859	.6859
10	.6097	.6859	.6859	.6859	.6859	.6859	.6859
11	.6097	.6859	.6859	.6859	.6859	.6859	.6859
12	.6859	.6859	.6859	.6859		.6859	.6859
13	.6859	.6859	.6859	.6859	.6859	.6859	.6859
14		.6859	.6859	.6859	.6859	.6859	.6859
15	.6097	.6859	.6859	.6859	.6859	.6859	.6859
16	.6097	.6859	.6859	.6859	.6859	.6859	.6859
17	.6097	.6859	.6859	.6859	.6859	.6859	.6859
18	.6097	.6859	.6859	.6859	.6859	.6859	.6859
19	.6097	.6859	.6859	.6859	.6859	.6859	.6859
20	.6859	.6859	.6859	.6859	.6859	.6859	.6859
21	.6859	.6859	.6859	.6859	.6859	.6859	.6859
22	.6859	.6859	.6859	.6859	.6859	.6859	.6859
23	.6859		.6859	.6859	.6859	.6859	.6859
24	.6859	.6859	.6859	.6859	.6859	.6859	.6859
Max	.6859	.6859	.6859	.823	.6859	.6859	.6859
Min	.6097	.6859	.6859	.6859	.6859	.6859	.6859
Avg	.6329	.6859	.6859	.6919	.6859	.6859	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 204 / S.S.K.FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6859	.6859	.6859	.6859	.6859	.6859
2	.6097	.6859	.6859	.6859	.6859	.6859	.6859
3	.6097	.6859	.6859		.6859	.6859	.6859
4	.6097	.6859	.6859	.6859	.6859	.6859	.6859
5	.6097	.6859	.6859	.6859	.6859	.6859	.6859
6	.6097	.6859	.6859	.6859	.6859	.6859	.6859
7	.6097	.6859	.6859	.6859	.6859	.6859	.6859
8	.6859	.6859		.6859	.6859	.6859	.6859
9	.6859	.6859	.6859	.6859	.6859	.6859	.6859
10	.6859	.6859	.6859	.6859	.6859	.6859	.6859
11	.6859	.6859	.6859	.6859	.6859	.6859	.6859
12	.6859	.6859	.6859	.6859	.6859	.6859	.6859
13	.6859	.6859	.6859	.6859	.6859	.6859	.6859
14	.6859	.6859	.6859	.6859	.6859	.6859	.6859
15	.6859	.6859	.6859	.6859	.6859	.6859	.6859
16	.6859	.6859	.6859	.6859	.6859	.6859	.6859
17	.6859	.6859	.6859	.6859	.6859	.6859	.6859
18	.6859	.6859	.6859	.6859	.6859	.6859	.6859
19	.6859	.6859	.6859	.6859	.6859	.6859	.6859
20	.6859	.6859	.6859		.6859	.6859	.6859
21	.6859	.6859	.6859	.6859	.6859	.6859	.6859
22	.6859		.6859	.6859	.6859	.6859	
23	.6859		.6859	.6859	.6859	.6859	.6859
24	.6859	.6859	.6097	.6859	.6859	.6859	.6859
Max	.6859	.6859	.6859	.6859	.6859	.6859	.6859
Min	.6097	.6859	.6097	.6859	.6859	.6859	.6859
Avg	.6637	.6859	.6826	.6859	.6859	.6859	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 205 / 11kv SINDHI COLONY,  
DONDAICHA Feeder KV- 11 /  
OUTGOING

SHEDDABLE URBAN

DATE	22-FEB-17	23-FEB-17	24-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6859
2	.6859	.6859	.6859
3	.6859	.6859	.6859
4	.6859	.6859	.6859
5	.6859	.6859	.6859
6	.6859	.6859	.6859
7	.6859	.6859	.6859
8	.6859	.6859	.6859
9	.6859	.6859	.6859
10	.6859	.6859	
11	.6859	.6859	.6859
12	.6859	.6859	.6859
13	.6859	.6859	.6859
14	.6097	.6859	.6859
15	.6859	.6859	.6859
16	.6859	.6859	.6859
17	.6859	.6859	.6859
18	.6859	.6859	.6859
19	.6859	.6859	
20	.6859	.6859	.6859
21	.6859	.6859	.6859
22	.6859	.6859	.6859
23	.6859	.6859	.6859
24	.6859	.6859	.6859
Max	.6859	.6859	.6859
Min	.6097	.6859	.6859
Avg	.6827	.6859	.6859



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 206 / NIMGUL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6859	.6859	.6859	.6859
2	.6859	.6859	.6859	.6859	.6859	.6859
3	.6859	.6859	.6859	.6859	.6859	.6859
4	.6859	.6859	.6859	.6859		.6859
5	.6859	.6859	.6859	.6859	.6859	.6859
6	.6859	.6859	.6859	.6859	.6859	.6859
7	.6859	.6859	.6859	.6859	.6859	.6859
8	.6859	.6859	.6859		.6859	.6859
9	.6859	.6859	.6859	.6859	.6859	.6859
10	.6859	.6859	.6859	.6859	.6859	.6859
11	.6859	.6859	.6859	.6859	.6859	.6859
12	.6859	.6859	.6859	.6859	.6859	.6859
13	.6859	.6859	.6859	.6859	.6859	.6859
14	.6859	.6859	.6859	.6859	.6859	.6859
15	.6859	.6859	.6859	.6859	.6859	.6859
16	.6859	.6859	.6859	.6859	.6859	.6859
17		.6859	.6859	.6859	.6859	.6859
18	.6859	.6859	.6859	.6859	.6859	.6859
19	.6859	.6859	.6859	.6859	.6859	.6859
20	.6859	.6859	.6859	.6859	.6859	.6859
21	.6859		.6859	.6859	.6859	.6859
22	.6859		.6859	.6859	.6859	.6859
23	.6859		.6859	.6859	.6859	.6859
24	.6859	.6859	.6859	.6859	.6859	.6859
Max	.6859	.6859	.6859	.6859	.6859	.6859
Min	.6859	.6859	.6859	.6859	.6859	.6859
Avg	.6859	.6859	.6859	.6859	.6859	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 207 / 11kV Starch Factory  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	24-FEB-17	25-FEB-17
HR	Load (MW)	Load (MW)
1	.6859	
2		.6859
23	.6097	
24	.6859	
Max	.6859	.6859
Min	.6097	.6859
Avg	.6605	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 208 / 11kV DONDAICHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17
HR	Load (MW)	Load (MW)
5		.6859
8		.6859
9		.6859
10		.6859
12		.6859
23		.6097
24	.6859	.6859
Max	.6859	.6859
Min	.6859	.6097
Avg	.6859	.6750

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

DONDAICHA[217]

BU 5525

Substation No/ Name :- 097002 / 132KV DONDAICHA

Feeder No / Name : 402 / Spare (Nimgul)

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3438	4.5782	2.4177	2.1091	1.9033	2.9379	2.3663
2	4.5097	4.7325	2.3663	2.0062	1.9033	2.9379	2.3148
3	4.5611	4.6296	2.3148	2.1605	1.9547	3.1665	2.3148
4	4.6696	4.6297	2.3663	3.0236	2.0062	3.2808	2.3148
5	5.0926	4.8354	3.3322	3.3436	2.3148	3.3836	2.3148
6	5.8413	5.607	4.0295	4.0295	3.7037	2.9321	4.2353
7	6.0357	6.1728	4.8696	4.098	4.0123	4.6124	4.5553
8	4.0238	6.3843	3.4465	3.9209	3.9095	4.1266	4.1667
9	3.2408	3.8009	4.2239	3.5494	3.538	3.6408	3.7037
10	2.4177	3.7952	5.91	4.6297	6.0757	5.607	5.2983
11	2.5206	2.7778	5.9728	4.9897	6.0243	5.6127	5.2983
12	2.9835	2.4691	6.19	5.0412	5.9156	5.9042	5.0412
13	2.7263	2.0576	5.407	4.8354	5.7042	5.6356	5.0411
14	2.6235	2.0576	5.1498	4.7839	5.4984	5.687	2.6235
15	2.6749	2.2119	2.4691	2.1091	5.647	5.5727	5.1955
16	2.7263	2.4691	2.0576	4.6811	5.6528	5.2813	5.2983
17	2.7778	2.7263	2.0062	5.0412	5.8585	5.3384	5.1955
18		2.9321	2.2634	2.4691	.2829	3.1379	4.8868
19	4.3725	4.6925	4.1381	3.9609	4.441	4.7439	4.3724
20	4.0638	4.3724	5.0697	3.9095	1.3477	4.5267	4.1667
21	2.9321	3.1379	5.3327	2.572	3.0864	3.0864	3.1379
22	2.7778	2.9835	2.6235	2.3663	2.7778	2.9835	
23	4.8354	2.7263		2.3148	2.572	2.4691	4.8868
24	4.4467	4.4753	2.4691	2.1091	.1852	1.0802	2.3663
Max	6.0357	6.3843	6.19	5.0412	6.0757	5.9042	5.2983
Min	2.4177	2.0576	2.0062	2.0062	.1852	1.0802	2.3148
Avg	3.7912	3.8023	3.7576	3.5022	3.5965	4.0702	3.9607

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 201 / AKKADASE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.5432	.1543	1.0288	1.2003	.1372	1.2003
2	1.5432	1.5432	.1543	1.0288	1.2003	.1372	1.2003
3	1.5432	1.5432	.1543	1.0288	1.2003	.1372	1.2003
4	1.5432	1.5432	.1543	1.0288	1.2003	.1372	1.2003
5	1.5432	1.5432	.1543	1.0288	1.3717	.1372	1.2003
6	1.5432	1.5432	.1543	1.0288	1.5432	.1372	1.2003
7	1.5432	1.7147	.1715	1.2003	1.5432	.1543	1.3717
8	1.5432	1.6289	.1629	1.2003	1.3717	.1372	1.2003
11	1.3717	.1372	1.7147	1.8861	.1524	2.0576	1.8861
12	1.5432	.1753	1.7147	1.8861	.1829	2.0576	1.8861
13	1.3717		1.7147	1.8861	.1829	2.0576	1.8861
14	1.3717		1.7147	1.8861	.1829	2.0576	1.8861
15	1.5432	.1143	1.7147	1.8861	.1829	2.0576	1.8861
16	1.3717	.1219	1.7147	1.8861	.1829	2.0576	2.0576
17	1.3717	.1372	1.5432	1.8861	.1829	2.0576	2.0576
18	1.3717	.1372	1.5432	1.8861	.1524	2.0576	2.0576
19		.1543					
23	1.5432	.1543	1.0288	1.3717	.1372	1.2003	1.5432
24	1.5432	1.5432	.1543	1.0288	1.3717	.1457	1.2003
Max	1.5432	1.7147	1.7147	1.8861	1.5432	2.0576	2.0576
Min	1.3717	.1143	.1543	1.0288	.1372	.1372	1.2003
Avg	1.4860	.8987	.8788	1.4479	.7523	1.0512	1.5623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 202 / VIRDEL

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.7716	.0686	1.2003	1.3717	.1372	1.286
2	.5144	.7716	.0686	1.2003	1.3717	.1372	1.286
3	.5144	.7716	.0686	1.2003	1.3717	.1372	1.286
4	.5144	.7716	.0686	1.2003	1.3717	.1372	1.286
5	.5144	.7716	.0686	1.2003	1.3717	.1372	1.286
6	.6859	.8573	.0686	1.2003	1.4575	.1372	1.286
7	.6859	.9431	.1029	1.3717	1.4575	.1543	1.286
8	.8573	.9431	.0857	1.3717		.1372	1.2003
11	1.5432	.16	1.5432	1.1145	.0991	1.0288	1.0288
12	1.7147	.1753	1.5432	1.0288	.0991	1.0288	.7716
13	1.6289		1.7147	1.0288	.0838	1.0288	.7716
14	1.6289		1.7147		.0838	.8573	.6001
15	1.7147	.0914	1.5432	1.0288	.0838	.8573	.8573
16	1.5432	.1524	1.5432	1.0288	.0838	.8573	.9431
17	1.5432	.1524	1.5432	1.1145	.0991	1.0288	.9431
18	1.4575	.1524	1.5432	1.0288	.0838	.8573	.7716
19		.1543					
23	.7716	.0686	1.2003	1.3717	.1457	1.286	.5144
24	.5144	.7716	.0686	1.2003	1.286	.1457	1.286
Max	1.7147	.9431	1.7147	1.3717	1.4575	1.286	1.286
Min	.5144	.0686	.0686	1.0288	.0838	.1372	.5144
Avg	1.0479	.4988	.8088	1.1700	.7013	.5606	1.0383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 203 / CHIMTHANE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6859	.8573	.0857	.8573
2				.6859	.8573	.0857	.8573
3				.6859	.8573	.0857	.8573
4				.8573	.8573	.0857	1.0288
5				.8573	1.2003	.0857	1.2003
6				1.2003	1.1431	.0857	1.3717
7				1.3717	1.2193	.1372	1.5432
8				1.2003	1.3717	.12	1.3717
11	1.3717	.1219	1.3717				
12	1.286	.1219	1.3717				
13	1.286		1.2003				
14	1.2003		1.2003				
15	1.2003	.0991	1.2003				
16	1.286	.1143	1.2003	.1219			
17	1.2003	.1143	1.2003				
18	1.1145	.1067	1.2003				
19		.0943					
23			.8573	.9431	.0943	.8573	
24				.8573	.8573	.0857	.8573
Max	1.3717	.1219	1.3717	1.3717	1.3717	.8573	1.5432
Min	1.1145	.0943	.8573	.1219	.0943	.0857	.8573
Avg	1.2431	.1104	1.2003	.8606	.9315	.1714	1.1050

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 204 / SHINDKHEDA URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0288	.1029	1.0288	1.0288	.0857	1.0288
2	1.0288	1.0288	.1029	1.0288	1.0288	.0857	1.0288
3	1.0288	1.0288	.1029	1.0288	1.0288	.0857	1.0288
4	1.2003	1.0288	.1029	1.0288	1.0288	.0857	1.0288
5	1.2003	1.2003	.12	1.0288	1.1145	.0943	1.2003
6	1.3717	1.3717	.1372	1.2003	1.2003	.12	1.3717
7	1.5432	1.3717	.1457	1.3717	1.2003	.1372	1.5432
8	1.3717	1.4575	.1457	1.3717	1.286	.1286	1.3717
9	1.2003	1.2003	.1286	1.2003	1.1145	.12	1.2003
10	1.0288	1.2003	.12	1.0288	1.0288	.1029	1.2003
11	1.0288	.0991	1.2003	1.0288	.0838	1.0288	1.2003
12	1.0288	.0991	1.2003	1.0288	.0914	1.0288	1.2003
13	1.2003		1.0288	1.0288	.0838	1.0288	1.1145
14	1.0288	.0991	1.0288		.0838	1.2003	1.1145
15	1.0288	.0914	1.2003	1.2003	.0838	1.2003	1.2003
16	1.1145	.0914	1.2003	1.2003	.0914	1.2003	1.286
17	1.2003	.0991	1.2003	1.2003	.0838	1.2003	1.2003
18	.6859	.1143	1.2003	1.2003	.0914	1.2003	1.286
19	1.5432	.1543	1.4575	1.4575	1.286	1.4575	1.4575
20	1.3717	.1457	1.3717	1.3717	.12	1.3717	1.5432
21	1.286	.1372	1.3717	1.286	.12	1.286	1.3717
22	1.2003	.1286	1.2003	1.2003	.1115	1.2003	1.3717
23	1.1145	.12	1.0288	1.1145	.1029	1.1145	1.2003
24	1.0288	1.0288	.12	1.0288	1.0288	.0857	1.0288
Max	1.5432	1.4575	1.4575	1.4575	1.286	1.4575	1.5432
Min	.6859	.0914	.1029	1.0288	.0838	.0857	1.0288
Avg	1.1610	.6228	.7091	1.1593	.6051	.6937	1.2324



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 205 / 11 kV SULWADE EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0017	.0171	.0034	.0017	.0171	.0034	.0017
2	.0017	.0171	.0034	.0017	.0171	.0034	.0017
3	.0017	.0171	.0034	.0017	.0171	.0034	.0017
4	.0017	.0171	.0034	.0017	.0171	.0034	.0017
5	.0017	.0171	.0034	.0017	.0171	.0034	.0017
6	.0017	.0171	.0034	.0017	.0171	.0034	.0017
7	.0017	.0171	.0017	.0017	.0171	.0034	.0017
8	.0017	.0171	.0017	.0017	.0171	.0017	.0017
9	.0017	.0171	.0034	.0017	.0171	.0017	.0017
10	.0171	.0171	.0017	.0171	.0171	.0017	.0171
11	.0171	.0015	.0171	.0171	.0015	.0017	.0171
12	.0171	.0015	.0171	.0171	.0015	.0017	.0171
13	.0171		.0017	.0171	.0015	.0017	.0171
14	.0171	.0015	.0017	.0171		.0017	.0171
15	.0171	.0015	.0017	.0171	.0015	.0017	.0171
16	.0171	.0015	.0017	.0171	.0015	.0017	.0171
17	.0171	.0015	.0017	.0171	.0015	.0017	.0171
18	.0171	.0015	.0017	.0171	.0015	.0017	.0171
19	.0171	.0017	.0017	.0171	.0171	.0017	.0171
20	.0171	.0034	.0017	.0171	.0034	.0017	.0171
21	.0171	.0034	.0017	.0171	.0034	.0017	.0171
22	.0171	.0034	.0017	.0171	.003	.0017	.0171
23	.0171	.0034	.0017	.0171	.0003	.0017	.0171
24	.0017	.0171	.0034	.0017	.0171	.0034	.0017
Max	.0171	.0171	.0171	.0171	.0171	.0034	.0171
Min	.0017	.0015	.0017	.0017	.0003	.0017	.0017
Avg	.0107	.0093	.0036	.0107	.0098	.0023	.0107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 206 / 11 kV TEMLAI + AKKADSE G/T

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.0343	.2572	.2572	.0429	.3429
2	.3429	.3429	.0343	.2572	.2572	.0429	.3429
3	.3429	.3429	.0343	.2572	.2572	.0429	.3429
4	.4287	.3429	.0343	.3429	.2572	.0429	.4287
5	.4287	.5144	.0429	.5144	.4287	.0514	.5144
6	.5144	.6001	.0514	.5144	.5144	.06	.6001
7	.6859	.6859	.06	.6001	.6001	.0686	.6001
8	.5144	.5144	.0514	.4287	.5144	.0429	.5144
9	.4287	.3429	.0429	.3429	.4287	.0429	.3429
10	.3429	.2572	.0343	.2572	.3429	.0343	.3429
11	.2572	.0229	.2572	.2572	.0305	.2572	.2572
12	.2572	.0229	.2572	.2572	.0152	.2572	.2572
13	.2572		.2572	.1715	.0229	.2572	.2572
14	.2572	.0305	.2572	.1715	.0229	.2572	.2572
15	.2572	.0229	.2572	.1715	.0229	.2572	.2572
16	.2572	.0229	.2572	.2572	.0305	.3429	.2572
17	.3429	.0229	.2572	.2572	.0305	.3429	.2572
18	.4287	.0381	.3429	.3429	.0381	.4287	.4287
19	.6001	.0514	.5144	.5144	.06	.5144	.5144
20	.5144	.0514	.4287	.5144	.0514	.5144	.5144
21	.4287	.0429	.4287	.4287	.0429	.4287	.4287
22	.4287	.0343	.3429	.3429	.0429	.4287	.4287
23	.4287	.0343	.3429	.3429	.0429	.3429	.3429
24	.3429	.3429	.0343	.3429	.3429	.0429	.3429
Max	.6859	.6859	.5144	.6001	.6001	.5144	.6001
Min	.2572	.0229	.0343	.1715	.0152	.0343	.2572
Avg	.3929	.2186	.1940	.3394	.1939	.2143	.3822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 207 / 11kV CMT + VIRDEL G/T

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6001	.06	.5144	.6001	.06	.6001
2	.6859	.6001	.06	.5144	.6001	.06	.6001
3	.6859	.6001	.06	.5144	.6001	.06	.6001
4	.6859	.6516	.06	.6859	1.0288	.06	.6859
5	.8573	1.2003	.0686	.8573	1.2003	.0772	.8573
6	1.0288	1.2003	.1286	1.0288	1.3717	.12	1.2003
7	1.0288	1.1145	.1286	1.0288	1.3717	.12	1.0288
8	.8573	.8573	.1029	.8573	.9431	.0857	1.0288
9	.8573	.6001	.0686	.6859	.6859	.06	1.0288
10	.5144	.5144	.0514	.6001	.5144	.0514	.5144
11	.4287	.0381	.5144	.4287	.0381	.5144	.5144
12	.4287	.0381	.5144	.5144	.0305	.5144	.5144
13	.4287		.5144	.4287	.0381	.5144	.4287
14	.4287	.0381	.5144	.4287	.0381	.5144	.5144
15	.4287	.0381	.5144	.5144	.0381	.5144	.5144
16	.4287	.0381	.5144	.5144	.0381	.5144	.4287
17	.4287	.0381	.6859	.5144	.0457	.6859	.5144
18	.6859	.0457	.6859	.6859	.0457	.6859	.6859
19	.9431	.0857	1.0288	.9431	.0762	1.0288	1.0288
20	.8573	.0857	1.0288	.8573	.0772	.8573	.9431
21	.7716	.0772	.8573	.7716	.0686	.8573	.6859
22	.6859	.0686	.6859	.6001	.0686	.8573	.7716
23	.6859	.06	.6859	.6001	.06	.6859	.6859
24	.6859	.6859	.06	.5144	.6001	.06	.6001
Max	1.0288	1.2003	1.0288	1.0288	1.3717	1.0288	1.2003
Min	.4287	.0381	.0514	.4287	.0305	.0514	.4287
Avg	.6752	.4033	.3997	.6501	.4241	.3983	.7073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094005 / 33/11 KV SHINDKHEDA

Feeder No / Name : 208 / 11 kV Temlai Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0288	.0943				
2	1.0288	1.0288	.0943				
3	1.0288	1.0288	.0943				
4	1.0288	1.0288	.0943				
5	1.2003	1.1145	.0943				
6	1.2003	1.2003	.1029				
7	1.3717	1.4575	.12				
8	1.2003	1.2003	.1115				
11				1.3717	.1219	1.3717	1.2003
12				1.3717	.1372	1.3717	1.286
13				1.2003	.1219	1.3717	1.2003
14					.1143	1.2003	1.2003
15				1.2003	.0991	1.2003	1.1145
16				1.286	.1067	1.2003	1.2003
17				1.286	.1143	1.2003	1.2003
18				1.286	.1143	1.0288	1.1145
23	1.0288	.1029					1.0288
24	1.0288	1.0288	.0943				
Max	1.3717	1.4575	.12	1.3717	.1372	1.3717	1.286
Min	1.0288	.1029	.0943	1.2003	.0991	1.0288	1.0288
Avg	1.1145	1.0220	.1000	1.286	.1162	1.2431	1.1717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 201 / AARAVE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2955	1.3717	1.2193	1.5242
2				1.2955	1.3717		1.5242
3				1.2955	1.2955	1.2193	1.5242
4				1.3717	1.2193	.1219	1.5242
5				1.3717	1.448	1.3717	1.5242
6				1.448	1.6766	1.5242	1.5242
7				1.448	1.7528	1.6004	1.6766
8				1.5242	1.3717	1.6766	1.7528
11	1.9814	1.829	2.0576				
12	1.6004	.1929	2.0576				
13	1.9814	1.9052	1.9814				
14	1.9814	1.9052	1.9814				
15	1.9814	1.9052	1.9052				
16	1.9052	1.9814	1.829				
17	1.829	1.9814	1.829				
18	1.6766	1.9814	1.7528				
23			1.1431	1.448	1.2193	1.3717	
24			1.2955		1.2193	1.5242	
Max	1.9814	1.9814	2.0576	1.5242	1.7528	1.6766	1.7528
Min	1.6004	.1929	1.1431	1.2955	1.2193	.1219	1.5242
Avg	1.8671	1.7102	1.7833	1.3887	1.3946	1.2921	1.5718

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 202 / CHIMTHANE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4572	.5335	.6097	.4572
2				.4572	.4572	.6097	.4572
3				.5335	.381	.6097	.4572
4				.5335	.381	.7621	.5335
5				.6097	.5335	.7621	.5335
6				.6859	.7621	.9145	.6097
7				.7621	.9145	.9145	.9145
8				.6859	.8383	.9145	.8383
11	.8383	.9145	.8383				
12	.9145	.9907	.9145				
13	.8383	.9145	.8383				
14	.9145	.9145	.8383				
15	.9145	.9145	.7621				
16	.8383	.9145	.7621				
17	.8383	.9145	.7621				
18	.6859	.9145	.6859				
23			.381	.4572	.061	.4572	
24			.4572		.6097	.4572	
Max	.9145	.9907	.9145	.7621	.9145	.9145	.9145
Min	.6859	.9145	.381	.4572	.061	.4572	.4572
Avg	.8478	.9240	.7240	.5758	.5472	.7011	.6001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 203 / KHALANE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4763	.0381				
2	.381	.381	.381				
3	.4268	.4572	.381				
4	.4572	.0457	.4572				
5	.4572		.4572				
6	.5335	.6097	.4572				
7	.5335	.6859	.6859				
8	.6097	.6859	.7621				
10							.5335
11				.6859	.4572	.5335	.4572
12				.6097	.5335	.5335	.4572
13				.5335	.0457	.4572	.4572
14				.5335	.4572	.381	.4572
15				.5335	.4572	.381	.4572
16				.5335	.4572	.4572	.381
17				.5335	.4572	.4572	.4572
18				.5335	.4572	.4572	.4572
23	.381	.4572					.381
24	.381	.0457					
Max	.6097	.6859	.7621	.6859	.5335	.5335	.5335
Min	.381	.0457	.0381	.5335	.0457	.381	.381
Avg	.4542	.4272	.4525	.5621	.4153	.4572	.4496

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 204 / 11 KV Shewale Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048	.3048	.3048
2	.3048	.3048	.3048	.3048	.3048	.3048	.3048
3	.3048	.3048	.3048	.3048	.3048	.3048	.3048
4	.381	.381	.381	.381	.381	.381	.4572
5	.5335	.0533	.5335	.5335	.4572	.4572	.6859
6	.6097	.6097	.7621	.6097	.6097	.5335	.7621
7	.7621		.6859	.6097	.6859	.6859	.6859
8	.5335	.5335	.5335	.5335	.5335	.3048	.5335
9	.381	.381	.4572	.3048	.381	.3048	.3048
10	.2286	.3048	.2286	.2286	.2286	.2286	.3048
11	.2286	.2286	.2286	.2286	.2286	.2286	.2286
12	.2286	.2286	.2286	.2286	.0229	.2286	.2286
13	.1524	.2286	.2286	.2286	.2286	.2286	.2286
14		.3048	.2286	.2286	.2286	.2286	.2286
15	.2286		.2286	.2286		.2286	.2286
16	.3048	.3048	.2286	.3048	.3048	.2286	.3048
17	.3048	.3048	.2286	.3048	.3048	.3048	.3048
18	.381	.381	.3048	.381	.381	.381	.381
19	.5335	.4572	.5335	.6097	.4572	.6097	.6097
20	.5335	.5335	.5335	.5335	***	.5335	.5335
21	.4572	.4572	.4572	.4572	.4572	.4572	.4572
22	.381	.381	.381	.381	.381	.381	.381
23	.3048	.381	.3048	.3048	.3048	.381	.381
24	.3048	.3048	.3048		.3048	.381	
Max	.7621	.6097	.7621	.6097	11.4312	.6859	.7621
Min	.1524	.0533	.2286	.2286	.0229	.2286	.2286
Avg	.3777	.3488	.3715	.3711	.8359	.3588	.3976



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094017 / 33/11 CHIMTHANE

Feeder No / Name : 205 / 11 KV Chimthana Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048	.3048	.3048
2	.3048	.3048	.3048	.3048	.3048	.3048	.3048
3	.3048	.3048	.3048	.3048	.3048	.3048	.3048
4	.381	.381	.4572	.381	.381	.0038	.4572
5	.5335	.5335	.6097	.5335	.5335	.5335	.6859
6	.6859	.6859	.7621	.6097	.6859	.6097	.7621
7	.8383	.7621	.8383	.7621	.7621	.7621	.7621
8	.5335	.6097	.6097	.5335	.6097	.6097	.5335
9	.381	.381	.4268	.381	.381	.3048	.3048
10	.2286	.3048	.3048	.3048	.381	.2286	.2286
11	.2286	.2286	.2286	.2286	.2286	.2286	.2286
12	.2286	.2286	.2286	.2286	.2286	.2286	.2286
13	.2286	.2286	.2286	.2286	.2286	.2286	.2286
14	.3048	.3048	.2286	.2286	.2286	.2286	.2286
15	.3048	.3048	.2286	.2286	.3048	.2286	.2286
16	.3048	.3048	.2286	.3048	.3048	.2286	.3048
17	.3048	.3048	.2286	.3048	.3048	.2286	.3048
18	.381	.381	.3048	.381	.381	.381	.381
19	.5335	.4572	.5335	.5335	.4572	.6097	.6097
20	.5335	.4572	.5335	.5335	.5335	.5335	.4572
21	.4572	.4572	.4572	.4572	.4572	.4572	.4572
22	.381	.4572	.381	.381	.381	.381	.381
23	.3048	.381	.3048	.3048	.3048	.381	.381
24	.3048	.3048	.3048		.3048	.381	
Max	.8383	.7621	.8383	.7621	.7621	.7621	.7621
Min	.2286	.2286	.2286	.2286	.2286	.0038	.2286
Avg	.3874	.3905	.3893	.3810	.3874	.3621	.3943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 201 / MAHATMA FULE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	.7316	.7926				
2	.961	.7468	.7926				
3	.961	.7926	.823				
4	.9795	.823	.823				
5	.961	.8383	.8535				
6	.9425	.8535	.8535				
7	.9795	.884	.8383				
8	.9425	.8078	.8383				
11				.9755	1.0212	1.0059	.823
12				.9602	1.0364	1.0364	.8535
13				.9602	1.0669	1.0059	.8688
14				.9755	1.0822	.9907	.8383
15				.9907	1.0669	.9602	.884
16				.9907	1.0364	.9602	.8688
17				.9907	1.0059	.9602	.8383
18				.9602	1.0212	.9145	.7926
23	.8078	.961					.7926
24	1.0349	.8383	.7926				
Max	1.0349	.961	.8535	.9907	1.0822	1.0364	.884
Min	.8078	.7316	.7926	.9602	1.0059	.9145	.7926
Avg	.9531	.8277	.8230	.9755	1.0421	.9793	.8400

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 202 / BAMHANE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2955		1.2193	1.1431
2				1.2955		1.2498	1.1431
3				1.2955		1.2498	1.1431
4				1.3717		1.2651	1.1584
5				1.3717		1.2955	1.1584
6				1.448		1.3413	1.1736
7				1.6448	1.6004	1.6156	1.5394
8				1.2498	1.5394	1.5546	1.448
11	1.6004	.16	1.9605				
12	1.6461	1.6004	1.9035				
13	1.6004		1.885				
14	1.6004		1.7741				
15	1.6004	1.4632	1.7372				
16	1.6156	1.6766	1.7002				
17	1.6461	1.6766	1.6804				
18	1.5699	1.6004	1.5339				
19		1.3872					
20		1.3717					
23			1.4784	1.1888	1.4175	1.1431	
24				1.4784	1.1888	1.3565	
Max	1.6461	1.6766	1.9605	1.6448	1.6004	1.6156	1.5394
Min	1.5699	.16	1.4784	1.1888	1.1888	1.1431	1.1431
Avg	1.6099	1.3670	1.7392	1.3640	1.4365	1.3291	1.2384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 204 / Bamhane Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.3048	.3201	.3201		.3048	.3201
2	.3881	.3048	.3201	.3201		.3048	.3201
3	.3881	.3353	.3201	.3201		.3353	.3048
4	.4435	.503	.4268	.4268		.4115	.4268
5	.6468	.5792	.5792	.5792		.5335	.5944
6	.7762	.6401	.6554	.6554		.6097	.6554
7	.8686	.6401	.7164	.8686	.7164	.6859	.7164
8	.6838	.5335	.6097	.5944	.6097	.4877	.5487
9	.3048	.462	.5175	.3963	.381	.3353	.3048
10	.3048	.3048	.4066	.3353	.3048	.2439	.2591
11	.2591	.2743	.3326	.2896	.2743	.2134	.2591
12	.2286	.3142	.3174	.1981	.2286	.2591	.2286
13			.2957	.1981	.2286	.2439	.1981
14			.2957	.1981	.2286	.2743	.2439
15		.3511	.3142	.2743	.2286	.2743	.2591
16	.2591	.2896	.3326	.3048	.2591	.0274	.2743
17	.2743	.3048	.3696	.2591	.2591	.2743	.3048
18	.3201	.3506	.3881	3.2465	.3353	.3353	.3353
19	.4268	.5792	.6283	.5335	.4115	.5182	.5639
20	.442	.5487	.5914	.5335	.4877	.5335	.5792
21	.381	.4572	.5175	.4572	.4572	.442	.4877
22	.3506	.4115	.499	.3963	.3506	.381	.0152
23	.3048	.4251	.3696	.3506	.3353	.3506	.3506
24	.3881	.381	.3506	.3734	.3201	.3048	.3201
Max	.8686	.6401	.7164	3.2465	.7164	.6859	.7164
Min	.2286	.2743	.2957	.1981	.2286	.0274	.0152
Avg	.4203	.4225	.4364	.5179	.3565	.3619	.3696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 205 / 11 kV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.381	.4268	.4268		.4115	.0442
2	.4435	.3963	.4268	.4268		.4572	.442
3	.4066	.3506	.4268	.4268		.4268	.442
4	.3881	.3658	.442	.4572		.4572	.4268
5	.4066	.3353	.4572	.4268		.4725	.4572
6	.4066	.3048	.4877	.4115		.4268	.5335
7	.1848	.3963	.3201	.4435	.4115	.4877	.3963
8	.3326	.0457	.3201	.2591	.1677	.1524	.2591
9	.2743	.061	.4066	.3506	.2286	.2286	.2743
10	.2743	.061	.3881	.3658	.2439	.381	.3048
11	.2286	.0457	.462	.4268	.3353	.4115	.3048
12	.1524	.0457	.6099	.4268	.2743	.4115	.2743
13	.1372		.5544	.4115	.2743	.2743	.3048
14	.1372		.5914	.4115	.3048	.2743	.2743
15	.1524		.5544	.4268	.3353	.4115	.2743
16	.1219	.061	.5175	.4115	.3658	.4115	.3201
17	.1219	.061	.5544	.4268	.3048	.3963	.3048
18	.2743	.061	.3696	.3658	.381	.3353	.2286
19	.2743	.061	.4435	.3048	.4572	.3658	.2743
20	.2591	.061	.4435	.1677	.503	.3658	.3048
21	.3048	.2286	.3326	.4725	.4572	.2591	.381
22	.3048	.3506	.3326	.4725	.4572	.3353	.4572
23	.3506	.462	.4066	.4572	.4572	.4268	.503
24	.2957	.381	.5175	.4435	.442	.4572	.4268
Max	.4435	.462	.6099	.4725	.503	.4877	.5335
Min	.1219	.0457	.3201	.1677	.1677	.1524	.0442
Avg	.2782	.2151	.4497	.4009	.3556	.3766	.3422

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094024 / 33/11 KV BAMHANE

Feeder No / Name : 206 / 11 kV TAPI Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.1372	.1829				
2	.2033	.1372	.1829				
3	.2033	.1372	.1829				
4	.2218	.1524	.1524				
5	.2218	.1677	.1677				
6	.2218	.1677	.1677				
7	.2402	.2134	.1829				
8	.2218	.2286	.1829				
11				.1981	.2134	.2134	.2439
12				.1981	.2134	.1981	.2286
13				.1829	.2134	.1677	.1372
14				.1524	.1981	.1981	.1829
15				.1524	.1981	.1981	.1829
16				.1677	.1981	.1829	.1829
17				.1829	.2134	.1829	.1981
18				.1829	.1981	.2134	.1829
23	.1372	.1848					.1219
24	.2033		.1829				
Max	.2402	.2286	.1829	.1981	.2134	.2134	.2439
Min	.1372	.1372	.1524	.1524	.1981	.1677	.1219
Avg	.2078	.1696	.1761	.1772	.2058	.1943	.1846

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 201 / 11 KV TAMTHARE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6859	.7621				
2	.7926	.6859	.7926				
3	.7621	.0762	.7621				
4	.7316	.7621	.7773				
5	.8078	.7621	.884				
6	.823	.9907	.9145				
7	1.0822	.1082	.9907				
8	.945	.9145	.8993				
11				.9907	.945	1.0059	1.0059
12				.9907	1.0212	1.0212	.945
13				.9907	1.0212	.9907	.945
14				.9907	1.0212	.9602	.0914
15				.9907	1.0669	.9145	.9145
16				.9907	1.0212	.9602	.9145
17				.9145	.9755	.9907	.9145
18				.9145	.9755	.8383	.8383
23	.7621	.7468					.6097
24	.7316	.6859	.7316				
Max	1.0822	.9907	.9907	.9907	1.0669	1.0212	1.0059
Min	.7316	.0762	.7316	.9145	.945	.8383	.0914
Avg	.8200	.6418	.8349	.9717	1.0060	.9602	.7976

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 202 / 11 KV SAWAI MUKTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1584	.9755	1.1888	1.0669
2				1.1888	.9755	.1189	1.0364
3				1.2193	.9755	1.2193	1.0669
4			.1524	1.2651	.9907	1.2193	1.1279
5				1.326	.9907	1.3717	1.1888
6				1.4022	1.2193	1.4632	1.2803
7				1.2193	1.4327	1.6156	1.4327
8				1.1888	1.387	1.3717	1.3413
11	1.5699	1.4632	1.4937				
12	1.4632	1.5546	1.448				
13	1.5242	1.6461	1.4022				
14	1.3717	1.5851	1.4175				
15	1.4632	1.5394	1.4327				
16	1.4632	1.4784	1.4175				
17	1.4632	1.4327	1.3108				
18	1.4632	1.3717	1.2651				
23			1.0974		1.1888	1.0974	
24				.9145	.9145	1.1888	1.0974
Max	1.5699	1.6461	1.4937	1.4022	1.4327	1.6156	1.4327
Min	1.3717	1.3717	.1524	.9145	.9145	.1189	1.0364
Avg	1.4727	1.5089	1.2437	1.2092	1.1050	1.1855	1.1821



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHINDKHEDA[221]

BU 0558

Substation No/ Name :- 094051 / 33/11 kV Sawai Mukti

Feeder No / Name : 203 / 11 kV SAWAI MUKTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.1067	.1067	.1067	.1067	.0914	.0914
2	.1067	.1067	.1067	.1067		.0914	.0914
3	.1067	.1067	.1067	.1067	.1067	.0914	.0914
4	.1219		.1372	.1372	.1219	.1524	.1219
5	.1524	.2134	.1829	.2286	.1677	.1829	.1372
6	.2134	.2439	.2134	.2591	.1677	.2134	.2591
7	.2439	.2439	.2591	.1829	.2439	.1677	.2439
8	.1677	.1829	.1219	.1829	.2134	.1524	.1677
9	.1067	.1372	.1219	.1067	.1829	.1372	.1219
10	.0762	.0762	.0914	.0914	.0914	.0914	.0762
11	.0762	.061	.0914	.061	.0914	.0762	.0762
12	.0457	.061	.0914	.061	.0914	.061	.0762
13		.061	.0762	.061	.0914	.0762	.0762
14		.061	.061	.061	.0762	.061	.0762
15		.0762	.0762	.061	.0762	.0762	.0762
16	.061	.0762	.0762	.0762	.0762	.0762	.061
17	.061	.0762	.0762	.0762	.0914	.0914	.0076
18	.061	.0914	.0762	.0762	.1067	.1067	.0762
19	.1829	.1372	.1219	.1677	.1524	.1524	.2286
20	.1829	.1677	.1524	.1829	.1219	.1524	.1677
21	.1524	.1524	.1677	.1219	.1067	.1372	.1524
22	.1067	.1219	.1067	.1067		.1372	.1219
23		.1067	.1067	.1067	.0914	.1067	.1219
24	.1067		.1067	.1067	.1067	.0914	.0914
Max	.2439	.2439	.2591	.2591	.2439	.2134	.2591
Min	.0457	.061	.061	.061	.0762	.061	.0076
Avg	.1219	.1213	.1181	.1181	.1219	.1156	.1172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 201 / THALNER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6216	2.652	2.7435				
2	2.6235	2.652	2.7435				
3	2.672	2.652	2.7435				
4	2.7206	2.7515	2.7778				
5	2.7526	2.7854	2.915				
6	2.7206	2.8178	2.9835				
7	3.0769	2.915	3.1893				
8	2.915	3.0864	3.0045				
11				3.6351	3.8866	3.6466	2.7572
12				3.7037	3.2769	3.8013	3.5208
13				3.8066	3.8866	3.8455	3.3998
14				3.8409	3.8866	3.8504	3.3208
15				3.8409	3.5627	3.9323	3.4789
16				3.2922	3.7685		3.4789
17				3.7037	3.5627		3.1245
18				3.738	3.315		2.9683
19						3.2217	
23	2.713	2.4006					
24	2.5396	2.5034					
Max	3.0769	3.0864	3.1893	3.8409	3.8866	3.9323	3.5208
Min	2.5396	2.4006	2.7435	3.2922	3.2769	3.2217	2.7572
Avg	2.7355	2.7216	2.8876	3.6951	3.6432	3.7163	3.2562

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 202 / HOLNANTHE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.5911	2.5377	2.4272	2.5911
2				2.5606	2.5377	2.4539	2.4966
3				2.451	2.5377	2.4272	2.4291
4				2.4806	2.5377	2.4691	2.2672
5				2.5606	2.572	2.4691	2.2672
6				2.5301		2.4691	2.2405
7				2.6092	2.7778	2.4756	2.372
8				2.8292	2.7183	2.4863	2.4996
11		3.0521	2.5911				
12		3.1207	2.7854				
13		3.1207	2.9492				
14	3.1131	3.0864	2.9492				
15	2.9835	3.155	2.8464				
16	2.9492	3.2236	2.8464				
17	2.7854	3.155	2.9254				
18	2.7854	3.0864	2.8807				
19	2.9473						
20	2.652						
23			2.5911	2.4006	2.4006	2.5987	
24				2.5911	2.5034	2.4272	2.5911
Max	3.1131	3.2236	2.9492	2.8292	2.7778	2.5987	2.5911
Min	2.652	3.0521	2.5911	2.4006	2.4006	2.4272	2.2405
Avg	2.8880	3.1250	2.8183	2.5604	2.5692	2.4703	2.4172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 203 / BHORKHEDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.2996	2.4348	2.4966	
2				2.3266	2.4348	2.5139	
3				2.2996	2.4348	2.4863	
4				2.2834	2.4691	2.4863	
5				2.3158	2.4863	2.5034	
6				2.2885	2.4863	2.5095	
7				2.3205	2.5549	2.5149	
8				2.4863	2.4366	2.5987	1.9766
9							2.2929
10							2.451
11		2.7092	2.6216				
12		2.7263	2.5425				
13		2.7092	2.5101				
14	2.7778	2.7092	2.5263				
15	2.7435	2.6749	2.5101				
16	2.8086	2.6235	2.4615				
17	2.7393	2.6749	2.451				
18	2.7393	2.7263	2.4669				
19	2.7168						
20	2.6818						
23			2.3758	2.4348	2.4966	2.1795	
24			2.5101	2.3266	2.4348	2.5139	2.1862
Max	2.8086	2.7263	2.6216	2.4863	2.5549	2.5987	2.451
Min	2.6818	2.6235	2.3758	2.2834	2.4348	2.1795	1.9766
Avg	2.7439	2.6942	2.4976	2.3382	2.4669	2.4803	2.2267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 204 / THALNER GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.462	.4287	.5853	.5487	.5914	.5853
2	.5373	.462	.4287	.5914	.5487	.5914	.5853
3	.6024	.4755	.463	.6283	.583	.6653	.5853
4	.7087	.6219	.583	.6838	.6516	.695	.7316
5	.9214	.9412	.9259	.823	.7545	.8688	.9412
6	1.0631	1.1584	1.1145	1.134	.9602	1.1462	1.086
7	1.1104	1.1041	1.1145	1.2254	1.046	1.0745	1.134
8	.8688	.8402	1.0608	.8573	.9511	.8682	.9145
9	.7316	.6516	.8131	.703	.7316	.6556	.7682
10	.5853	.5144	.6535	.5658	.6219	.5316	.6401
11		.463		.4973	.6036	.4252	.4572
12		.463	.543	.463	.5487	.5258	.4525
13		.4287	.567	.4801	.5175	.5316	.4887
14	.567	.4287	.567	.4801	.4938	.5316	.4656
15	.5487	.4458	.5611	.5144	.5304	.4961	.4835
16	.5544	.463	.543	.5487	.5304		.543
17	.5853	.5487	.6584	.6001	.6219		.6335
18	.695	.6344	.5487	.6173	.7602		.6584
19	.9328	.9259	.9511	.9088	.9955	.9816	.9896
20	.8869	.7888	.8589	.7888	.8779	.7888	.7842
21	.7499	.7202	.7468	.7202	.7964	.691	.8215
22	.7316	.6344	.6908	.6344	.6653	.6379	
23	.6653	.6516	.6219	.583	.499	.591	
24	.5731	.462	.463	.6036	.5487	.5729	.5487
Max	1.1104	1.1584	1.1145	1.2254	1.046	1.1462	1.134
Min	.5373	.4287	.4287	.463	.4938	.4252	.4525
Avg	.7217	.6371	.6916	.6765	.6828	.6886	.6954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 205 / 11KV ASALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1478	.12	.1478	.12	.1478	.1294
2	.1433	.1478	.12	.1463	.12	.1478	.1294
3	.1629	.1478	.1372	.1646	.1372	.1478	.1294
4	.2172	.1829	.1715	.1829	.1715	.1829	.1663
5	.2353	.2172	.2058	.2195	.2401	.2195	.2218
6	.2507	.3258	.2743	.2715	.3086	.2534	.2561
7	.2658	.2896	.3086	.2896	.2058	.2926	.1829
8	.2126	.2058	.3326	.2743	.2561	.2149	.1829
9	.1829	.1715	.2427	.2058	.181	.1772	.1646
10	.1848	.1543	.1463	.1715	.1829	.1595	.181
11		.1543	.128	.1715	.1478	.1433	.1463
12		.1372	.1086	.1715	.1478	.1595	.1829
13		.1372	.1086	.1543	.1109	.1433	.181
14	.1829	.12	.1086	.1372	.1109	.1433	.1448
15	.1478	.12	.1267	.1372	.1109	.1417	.1267
16	.1294	.1029	.1267	.12	.112		.1086
17	.1109	.1543	.1294	.1886	.1463		.1433
18	.1478	.1886	.1867	.1715	.1829		.181
19	.2561	.2058	.2241	.1886	.2195	.2303	.2241
20	.2195	.2058	.2241	.2058	.1829	.2149	.1867
21	.1848	.1886	.1494	.1886	.1478	.181	.1867
22	.1478	.1886	.1478	.1715	.1478	.1629	
23	.1478	.1543	.1494	.1715	.1478	.1448	
24	.1448	.1478	.1372	.1478	.1372	.1478	.1294
Max	.2658	.3258	.3326	.2896	.3086	.2926	.2561
Min	.1109	.1029	.1086	.12	.1109	.1417	.1086
Avg	.1819	.1748	.1714	.1833	.1657	.1789	.1675

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094011 / 33/11KV THALNER

Feeder No / Name : 206 / 11 Kv JAITPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.491	1.4403				
2	1.4918	1.5083	1.4403				
3	1.5249	1.5083	1.4403				
4	1.6057	1.5257	1.4746				
5	1.6385	1.5432	1.5432				
6	1.6385	1.6118	1.5775				
7	1.9062	1.6461	1.749				
8	1.8023	1.869					
11				2.1605	2.4981	2.3868	2.13
12				2.1776	2.5774	2.4577	2.4006
13				2.2291	2.2542	2.4577	2.3205
14				2.3148	2.3205	2.4577	2.2929
15				2.3148	2.4531	2.4577	2.372
16				2.1948	2.6113		2.2929
17				2.1605	2.4366		2.1348
18				2.2119	2.2552		2.2929
23	1.5238	1.3717					
24	1.4918	1.5249	1.3717				
Max	1.9062	1.869	1.749	2.3148	2.6113	2.4577	2.4006
Min	1.4918	1.3717	1.3717	2.1605	2.2542	2.3868	2.13
Avg	1.6132	1.56	1.5046	2.2205	2.4258	2.4435	2.2796

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 201 / SANGVI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.3148		1.9509	1.4022	1.6289	1.7985
2		2.1948		1.89	1.4632	.1698	1.829
3		2.0576		1.9052	1.6461	1.7833	1.89
4				1.9814	1.8595	1.8861	2.0119
5				2.0119	1.9509	2.3148	2.1491
6				2.21	2.0576	2.5892	2.6063
7				1.5394	2.9721	3.0007	3.1093
8				2.7282	3.2007	3.7723	3.3836
9				2.8654	3.1703		
10				2.4996	2.713		
11					2.4539		
12					2.2862		
13		3.2579	2.8197				
14		3.4637	3.0178				
15		3.3093	2.8654				
16	2.8045		2.9721				
17	3.0636	3.2236	2.8502				
18	3.094	3.0521	2.7892				
19	2.7587	2.8635	2.6825				
20	2.6063	2.6578	2.5758				
21	2.5453	2.452	2.4691				
22	2.4387	2.3148	2.3015				
23	2.3777		2.1795			2.0576	1.4327
24	1.8595	2.4006		2.0576		1.4918	2.0424
Max	3.094	3.4637	3.0178	2.8654	3.2007	3.7723	3.3836
Min	1.8595	2.0576	2.1795	1.5394	1.4022	.1698	1.4327
Avg	2.6165	2.7356	2.6839	2.1491	2.2646	2.0695	2.2253



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 202 / ROHINI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.8004	1.4327	1.326			
2	1.5089	1.8861	1.4632	1.3717			
3	1.5394	1.9547	1.4784	1.448			
4	1.9052	2.0919	1.6156	1.5242			
5	2.1491	2.3834	1.8138	1.7833			
6	2.3624	2.3834	2.0119	1.9966			
7	2.7435	3.155	2.4996	2.5149			
8		3.2922	2.7282				
9		3.0693	1.1584				
10	2.332		2.3167				
11	2.7435						
12	2.6216						
13				2.774	2.8045	3.2407	1.9814
14				2.713	2.8959	3.0864	2.5149
15				2.8502	2.8654	2.915	2.5149
16				2.8807	3.0026	2.9321	2.4691
17				2.8197	2.9111		2.6063
18				2.5301	2.774	3.1379	2.4996
19				2.4691	2.652	2.8464	2.1186
20				2.3777	2.4996	2.6063	1.9052
21				2.1795	2.332	2.2462	1.8442
22		1.3032		2.2405	1.9509	2.0919	1.7985
23	1.4632	1.5775	1.0974	2.0119	1.6766	2.0576	1.7528
24	1.4632	1.6975	1.4632	1.2651	1.9509	1.6632	1.768
Max	2.7435	3.2922	2.7282	2.8807	3.0026	3.2407	2.6063
Min	1.448	1.3032	1.0974	1.2651	1.6766	1.6632	1.7528
Avg	2.0233	2.2162	1.7566	2.1619	2.5263	2.6203	2.1478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 203 / 11KV SANGAVI EXPRESS

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7926	1.0288	.7926	.8993	.061	.0686	.061
2	.884	1.0631	.823	.8688	.061	.0686	.061
3	.9755	1.0974	.9145	.8383	.061	.0686	.061
4	1.0364	1.1145	.9602	.9145	.061	.0686	.061
5	1.0974	1.2346	.9907	.945	.0762	.0686	.061
6	1.2193	1.3203	1.0974	.9907	.0762	.0686	.0762
7	1.3565	1.7661	1.5699	1.0669	.061		.0914
8	1.5699	1.8176	1.7528				
9	1.5089	1.1888	1.4175				
10	1.3565	1.406	1.326				
11	.061	.0514	.0762		.0762	.0686	
12	.1067	.0686			.0914	.0686	.0762
13	.061	.0857	.061	1.4175	1.3413	1.5089	1.0974
14	.0457	.0686	.061	1.3413	1.3717	1.4918	1.2955
15	.0457	.0686	.061	1.2193	1.4327	1.5261	1.2955
16				1.326	1.326	1.5089	
17				1.2803	1.2955	1.5089	1.0822
18				1.2498	1.2498	1.4918	1.0974
19	.0914	.1029	.1219	1.2193	1.2498	1.4918	1.0669
20	.0914	.1029	.8383	1.1584	1.1431	1.406	1.2193
21	.0762	.0857	.945	1.0669	1.0974	1.2517	1.2041
22	.061	.0686	1.0212	1.0059	1.0669	1.2346	1.0974
23	.8383	.9431	.9907	.9602	1.0212	1.2003	1.0364
24	.823	.9945	.884	.9907	.9297	1.1145	
Max	1.5699	1.8176	1.7528	1.4175	1.4327	1.5261	1.2955
Min	.0457	.0514	.061	.8383	.061	.0686	.061
Avg	.6714	.7466	.8352	1.0926	.7214	.8642	.6689

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094018 / 33/11 KV SULE

Feeder No / Name : 204 / 11 Kv Hadakhed Checkpost      NON SHEDDABLE EXPRESS HV FEEDERS  
 Expre Feeder KV- 11 / OUTGOING      (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0686	.0857	.0857	.0857	.0857	.0857
2	.0857	.0686	.0857	.0857	.0857	.0857	.0857
3	.0686	.0686	.0686	.0857	.0857	.0857	.0857
4	.0686	.0686	.0686	.0686	.0857	.0857	.0857
5	.0686	.0686	.0686	.0686	.0857	.0686	.0857
6	.0686	.0686	.0686	.0686	.0857	.0686	.0686
7	.0514	.0686	.0514	.0514	.0686	.0686	.0686
8	.0514	.0514	.0514	.0514	.0514	.0686	.0686
9	.0686	.0686	.0514	.0514	.0514	.0686	.0686
10	.0686	.0514	.0686	.0514	.0686	.0686	.0514
11	.0686	.0514	.0686	.0514	.0857	.0686	.0686
12	.0514	.0514	.0686	.0686	.0857	.0686	.0686
13	.0686	.0514	.0686	.0686	.0686	.0514	.0514
14	.0686	.0686	.0686	.0686	.0686	.0514	.0686
15		.0686	.0686	.0686	.0857	.0514	.0686
16	.0514	.0686	.0686	.0686	.0857	.0686	.0857
17	.0514	.0686	.0686	.0686	.0857	.0686	.0857
18	.0514	.0686	.0686	.0686	.0686	.0514	.0686
19	.0857	.0686	.0857	.0857	.0857	.0514	.0857
20	.0686	.0686	.0857	.0857	.0857	.0686	.0857
21	.0857	.0857	.0857	.0857	.0857	.0686	.0857
22	.0857	.0857	.0857	.0857	.0857	.0686	.0857
23	.0857	.0857	.0857	.0857	.0857	.0857	.0857
24	.0857	.0686	.0857	.0857	.0857	.0857	.0857
Max	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Min	.0514	.0514	.0514	.0514	.0514	.0514	.0514
Avg	.0693	.0672	.0722	.0714	.0793	.0693	.0764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 201 / AJANDE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.7528	1.5337				
2	1.6766	1.7528	1.5337				
3	1.6766	1.7528	1.5337				
4	1.7528	1.7528	1.5337				
5	1.829	1.7528	1.6004				
6		1.7528	1.6004				
7		1.829	1.6004				
8		1.829	1.6004				
9		1.6004					
11					2.5339	2.4006	2.4387
12				2.4387	2.5339	2.6006	2.5911
13				2.6673	2.5339	2.4006	2.5911
14				2.6673	2.5339	2.2005	2.5911
15				2.8197	2.5339	2.4672	2.5911
16				2.8197	2.5339	2.4006	2.5911
17				2.6673	2.5339	2.4672	2.8292
18				2.3624	2.5339	2.1338	2.2862
19				2.3624			
23	1.6766	1.467					1.829
24	1.6766	1.7528	1.5337			2.4006	2.4387
Max	1.829	1.829	1.6004	2.8197	2.5339	2.6006	2.8292
Min	1.6766	1.467	1.5337	2.3624	2.5339	2.1338	1.829
Avg	1.7093	1.7268	1.5633	2.6006	2.5339	2.3857	2.4777

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 202 / 11 KV GHODASGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.8004	1.9814	2.1338	1.7337
2				1.8004	1.9814	2.2005	1.7337
3				1.8004	1.9814	2.2005	1.7337
4				1.8671	1.9814	2.2672	1.7337
5				1.8671	2.0576	2.2672	1.7337
6				2.0005	2.1338	2.2672	1.7337
7				2.0005	2.21	2.2672	1.8671
8				1.8671	1.9052	2.2672	1.9338
10		1.6004					
11	2.5911	1.6004	2.1338				
12	2.4387		2.1338				
13	2.3624		2.1338				
14	2.4387		2.1338				
15	2.4387	2.2005	2.0671				
16	2.4387	2.2005	2.2672				
17	2.4387	2.2005	2.2672				
18	2.2862	2.2672	2.2672				
23			1.7337	1.9052	1.8004	1.7337	
24				1.8004	1.9814	2.0005	1.7337
Max	2.5911	2.2672	2.2672	2.0005	2.21	2.2672	1.9338
Min	2.2862	1.6004	1.7337	1.8004	1.8004	1.7337	1.7337
Avg	2.4292	2.0116	2.1264	1.8709	2.0014	2.1605	1.7708

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 203 / JAPORA Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1524	.1524	.1715	.1715	.1524
2	.1715	.1715	.1524	.1524	.1715	.1715	.1524
3	.1715	.1715	.1524	.1524	.1715	.1715	.1524
4	.2572	.1715	.2286	.2286	.1715	.1334	.1524
5	.2572	.2572	.2286	.2286	.2572	.2	.1524
6	.3429	.2575	.3048	.3048	.3429	.3429	.3048
7	.3429	.3429	.3048	.3048	.3429	.3429	.3048
8	.3429	.3429	.3048	.3048	.3429	.2667	.3048
9	.3429	.3429	.3048	.2286	.3429	.3048	.2286
10	.2572	.1715	.2286	.2572	.2	.3048	.2572
11	.1715	.1715	.1524	.1715	.1334	.1524	.1715
12	.1715	.1715	.1524	.1715	.1334	.1524	.1715
13	.1715	.1715	.1524	.1715	.1334	.1524	.1715
14	.1715	.1715	.1524	.1715	.1334	.1524	.1715
15	.1715	.1715	.1524	.1715	.1334	.1524	.1715
16	.1715	.1715	.1524	.1715	.1715	.1524	.1715
17	.1715	.1715	.1524	.1715	.2572	.1524	.1715
18	.1715	.1715	.2286	.2572	.2572	.2286	.1715
19	.2572		.3048	.3429		.3048	.3429
20	.2572		.3048	.3429		.3048	.3429
21	.2572	.1524	.3048	.2572		.3048	.3429
22	.2572	.1524	.1524	.2572		.2286	.2572
23	.1715	.1524	.1524	.1715	.1334	.1524	.1715
24	.1715	.1715	.1524	.1524	.1715	.1715	.1524
Max	.3429	.3429	.3048	.3429	.3429	.3429	.3429
Min	.1715	.1524	.1524	.1524	.1334	.1334	.1524
Avg	.2251	.2001	.2096	.2207	.2086	.2155	.2143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 204 / GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2286	.2286	.1715	.2	.2286
2	.1715	.1715	.2286	.2286	.1715	.2	.2286
3	.1715	.1715	.2286	.2286	.1715	.2	.2286
4	.2286	.1715	.0305	.3048	.1715	.2667	.2
5	.2858	.2286	.381	.381	.2286	.3334	.3048
6	.4001	.2858	.381	.4572	.2858	.3334	.4572
7	.3429	.3429	.4572	.4572	.4001	.4668	.5335
8	.2858	.3429	.4572	.4572	.3429	.4668	.5335
9	.2286	.3334	.381	.381	.2858	.381	.381
10		.3334	.3048	.2286	.3334	.3048	.2286
11	.1715	.2667	.3048		.2667	.3048	
12		.2667	.3048	.1715	.2667	.2286	
13	.2286	.2	.3048	.1715	.2667	.2286	.2286
14	.1715	.2	.2286	.1715	.2667	.2286	.1715
15	.1715	.2	.2286	.1715	.1334	.2286	.1715
16	.1715	.2	.2286	.1715	.2667	.3048	.2286
17	.2286	.2	.3048	.1715	.2667	.3048	.2286
18	.2286	.2667	.3048	.2858	.3334	.381	.2286
19	.3429		.4572	.2858		.4572	.3429
20	.3429		.381	.2858		.4572	.2858
21	.2858	.2286	.381	.2286		.381	.2858
22	.2286	.2286	.3048	.1715		.3048	.2286
23	.1715	.2286	.2286	.1715	.2667	.2286	.1715
24	.1143	.1715	.2286	.2286	.1715	.2	.2286
Max	.4001	.3429	.4572	.4572	.4001	.4668	.5335
Min	.1143	.1715	.0305	.1715	.1334	.2	.1715
Avg	.2338	.2368	.3029	.2626	.2534	.3080	.2784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094029 / 33/11KV HOLNANTHE

Feeder No / Name : 205 / 11 KV JAPORA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.267	1.3717	1.0002	.9335
2				1.267	1.3717	1.0002	.9335
3				1.267	1.3717	1.0669	.9335
4				1.3336	1.3717	1.0669	.9335
5				1.3336	***	1.0669	.9335
6				1.3336	1.5242	1.1336	.9335
7				1.3336	1.5242	1.1336	1.0669
8				1.2003	1.2193	1.1336	1.2003
11	1.6766	1.467	1.3336				
12	1.6766		1.467				
13	1.6766		1.467				
14	1.6766		1.467				
15	1.6766	1.467	1.467				
16	1.6766	1.467	1.6004				
17	1.6766	1.467	1.6004				
18	1.5242	1.467	1.6004				
23			1.2003	1.3717	1.0669	.9335	
24				1.2003	1.3717	1.0669	.9335
Max	1.6766	1.467	1.6004	1.3717	13.7632	1.1336	1.2003
Min	1.5242	1.467	1.2003	1.2003	1.0669	.9335	.9335
Avg	1.6576	1.467	1.4670	1.2908	2.5956	1.0602	.9780



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 201 / BAHTPURA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7407	.8032	.7869				
2	.7415	.8169	.7869				
3	.7244	.8334	.8024				
4	.7407	.8326	.804				
5	.7747	.8489	.804				
6	.7541	.8318	.7411				
7	.8181	.7163	.6146				
8	.6973	.4938	.4477				
10				.4054	.4755	.4717	
11				.8486	.9279	.793	.3258
12				.8985	.9129	.8981	.3429
13				.8943	.9251	.9465	.3944
14				.9053	.9335	.9815	.3772
15				.9	.9591	.9683	.3772
16				.8786	.9591	.9442	.3944
17				.8615	.95	.8299	.3772
18				.6215	.7038	.5601	.2743
22	.4191	.4062					
23	.4184	.4092					.2915
24	.7659	.8219	.3601				
Max	.8181	.8489	.804	.9053	.9591	.9815	.3944
Min	.4184	.4062	.3601	.4054	.4755	.4717	.2743
Avg	.6904	.7104	.6831	.8015	.8608	.8215	.3505

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 202 / BABHALAJ

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.9547	2.0233	1.9547	1.8004
2				1.9547	2.0233	1.9547	1.8004
3				1.989	2.0748	2.0062	1.8861
4				2.0233	2.0748	2.0062	1.9204
5				2.0233	2.0919	2.0576	1.9547
6				2.0576	2.1262	2.0748	1.9547
7				2.0919	2.1262	2.1091	2.3148
8				2.0233	2.1605	2.0748	1.9376
11	2.6749	2.7606	2.4348				
12	2.6578		2.452				
13	2.6578	2.5206	2.4006				
14	2.6406	2.4863	2.3491				
15	2.6578	2.5206	2.4691				
16	2.6063	2.5377	2.5034				
17	2.5892		2.2977				
18	2.5206		2.1948				
23			1.7147	1.869	1.869	.1972	
24				2.0233	1.989	1.9204	1.5432
Max	2.6749	2.7606	2.5034	2.0919	2.1605	2.1091	2.3148
Min	2.5206	2.4863	1.7147	1.869	1.869	.1972	1.5432
Avg	2.6256	2.5652	2.3129	2.0010	2.0559	1.8356	1.9014

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 205 / 11 KV Ajnad Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3375	1.5775	1.6461	1.6118
2				1.3375	1.5775	1.6461	1.6118
3				1.3375	1.6461	1.6804	1.6804
4				1.3717	1.7147	1.7318	1.6804
5				1.406	1.7147	1.8004	1.7147
6				1.4403	1.7318	1.8176	1.8004
7				1.6289	1.749	1.8519	1.9547
8				1.5947	1.7833	1.8347	1.7833
11	1.9204	2.0919	1.8861				
12	1.9376	2.0062	1.9204				
13	1.9376	1.8861	2.0233				
14	1.9376	1.869	1.4918				
15	1.9376	1.8861	1.7147				
16	1.9033	1.9033	1.8004				
17	1.8519		1.8004				
18	1.7833		1.8519				
23			1.3375	1.4746	1.5775	1.5432	
24				1.3717	1.5261	1.6118	1.5432
Max	1.9376	2.0919	2.0233	1.6289	1.7833	1.8519	1.9547
Min	1.7833	1.869	1.3375	1.3375	1.5261	1.5432	1.5432
Avg	1.9012	1.9404	1.7585	1.4300	1.6598	1.7164	1.7090

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094033 / 33/11KV BABHALAJ

Feeder No / Name : 206 / 11KV NAGESHWAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	1.4232				
2	1.1317	1.166	1.4232				
3	1.1488	1.1831	1.4403				
4	1.1488	1.2346	1.4403				
5	1.166	1.3032	1.4575				
6	1.2003	1.3546	1.4746				
7	1.2003	1.4232	1.5775				
8	1.3717	1.4918	1.6461				
11				1.8347	1.869	1.7147	1.8176
12				1.8176	1.9376	1.8004	1.8519
13				2.0748	1.9719	1.7661	1.8347
14				2.0748	1.9719	1.8004	1.8347
15				2.0919	1.9376	1.8004	1.8861
16				1.8519	1.9204	1.8519	.1886
17				1.7833	1.8861	1.7833	1.9033
18				1.7661	1.869	1.7147	1.6461
23	1.166						1.2689
24	1.1488	1.1831	1.4403				
Max	1.3717	1.4918	1.6461	2.0919	1.9719	1.8519	1.9033
Min	1.1317	1.1317	1.4232	1.7661	1.869	1.7147	.1886
Avg	1.1814	1.2746	1.4803	1.9119	1.9204	1.7790	1.5813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 201 / UNTAWAD

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9615	3.0994	2.937				
2	2.9432	3.078	2.9446				
3	2.979	3.0826	2.9637				
4	2.9896	3.1375	2.9729				
5	3.0171	3.1786	2.9584				
6	3.3173	3.2739	3.0125				
7	3.7288	3.4995	3.4355				
8	3.7632	1.9616	3.4644				
10				.8977	.9617	1.4982	
11				4.1213	4.5709	4.7492	2.4006
12				4.385	4.5862	5.074	
13				4.4307	4.6212	4.9703	
14				4.4338	4.6212	5.0359	
15	1.829			4.494	4.8316	4.981	
16				4.462	4.9246	5.1227	2.2862
17				4.3645	4.8636	2.6398	
18				4.2752	4.8652	4.67	2.191
19							2.191
20							2.191
21							2.191
22	.9358	.8154					
23	2.9752	2.8509					1.7147
24	2.9462	3.1603	1.4098				
Max	3.7632	3.4995	3.4644	4.494	4.9246	5.1227	2.4006
Min	.9358	.8154	1.4098	.8977	.9617	1.4982	1.7147
Avg	2.8655	2.8307	2.8999	3.9849	4.3162	4.3046	2.1665

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 202 / EXP.KHARDE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5616	.4893	.82	.8292	.7971	.7567	
2	.5944	.4961	.8101	.833	.8017	.7712	.3429
3	.727	.6378	.9259	.9442	.9633	.9167	.362
4	.8536	.8086	1.1874	1.1714	1.1973	1.134	.5335
5	.8871	.8947	1.3832	1.3039	1.1439	1.1767	.6478
6			1.1561				
7			1.0707				
8			1.086				
9	.2896	.2728	.8245	.6089	.6127	.5929	
10	.7041	.746	.8383	1.0364	1.0509	1.1592	.4191
11	.6515	.6576	.7872	.935	.5342	.9023	.381
12	.5868	.4458	.7712	.8398	.4268		
13	.5296	.9328	.839	.8748	.9305		
14	.5098	.9007	.9	.8466	.9099	.4169	
15	.4907	.8802	.8657	.8078	.887	.8398	.5335
16	.5395	.8474	.8565	.839	.9068	.4199	.4572
17	.538	.8466	.3978	.8977	.8954	.4039	.5525
18	.679	.871	.8009	.9198	.8924	.8185	.4763
19	.7453	1.1142	.9876	1.0372	1.1157	1.0654	.4954
20	.8399	1.1813	1.0792	1.1828	1.1325	1.1721	.5335
21	.8079	1.2849	1.1241	1.105	1.1668	1.2574	.5335
22	.7681	.6287	1.0387	.6188	1.1439	1.2056	.5525
23	.634	1.0136	.8977	.503	.9625	1.0708	.4954
24	.599	.7956	.8672	.8261	.8108	.9358	.4763
Max	.8871	1.2849	1.3832	1.3039	1.1973	1.2574	.6478
Min	.2896	.2728	.3978	.503	.4268	.4039	.3429
Avg	.6446	.7974	.9298	.9029	.9182	.8956	.4870

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 203 / BALDE EXPRESS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7621	.6859	.6859	.8573	.8573	.8764
2	.6859	.7621	.6859	.6859	.8573	.8573	.8764
3	.724	.7621	.724	.7621	.8573	.8573	.9145
4	.9335	.9526	.9145	.9145	.9526	.9526	1.0669
5	1.0288	1.105	1.1241	1.0479	1.0479	1.2384	1.2765
6			.9907		1.1431	1.2384	1.2765
7			.9145		1.1431	1.1431	1.3336
8			.8954		1.0479	1.1431	1.086
9			.8192		.9526	1.1431	1.1812
10	.8383	1.0479	.6287	.8002	.9526	1.1431	1.1622
11	.8383	.8192	.6478	.7621	.9526	1.0288	1.0098
12	.8383		.6859	.8573	1.0479	1.0669	
13	.8383	.8383	.7621	1.0479	1.0479	.9907	1.0098
14	.8573	.8002	.8192	1.2384	1.0479		
15	.8383	.7621	.8383	1.0479	1.0479	1.0288	1.2574
16	.8383	.8383	.8383	1.0479	1.0479	1.1431	1.3336
17	.8573	.8192	.4191	.9526	1.0479	1.1431	1.3717
18	.9526	.8764	.4191	1.1431	1.1431	1.1812	1.3908
19	1.0479	1.105	1.105	1.1431	1.1431	1.3336	1.6766
20	1.0479	.9526	1.1431	1.1431	1.1431	1.2955	1.4861
21	1.0479	.9145	1.1431	1.0479	1.1431	1.2193	1.3717
22	1.0479		.8002		1.1431	1.1431	1.2574
23		.7049	.6097		1.0479	1.0288	1.1431
24	.6668	.8573	.6859	.5906	.8573	.9526	.9526
Max	1.0479	1.105	1.1431	1.2384	1.1431	1.3336	1.6766
Min	.6668	.7049	.4191	.5906	.8573	.8573	.8764
Avg	.8744	.8711	.8042	.9399	1.0280	1.0926	1.1959

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094041 / 33/11KV UNTAWAD

Feeder No / Name : 205 / Sakwad ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.6194					
2	1.448	1.7147					
3	1.467	1.7147					
4	1.4861	1.7147					
5	1.4861	1.8099					
6	1.5623	1.8099					
7	1.7528	1.8099					
8	1.7909	1.829					
9			1.0288				
11				1.9052	2.3624	2.553	2.7435
12				2.5149	2.4768	2.3434	
13				2.4768	2.4387	2.572	
14				2.6673	2.4387	2.6292	
15				2.8197	2.4768	2.6863	2.2862
16				2.8197	2.4768	2.8387	2.8006
17				2.8578	2.4768	.4191	.5716
18				2.191	2.4768	2.6673	2.0005
19							2.2291
23	1.5242	1.2384					2.3053
24	1.5051	1.6194	1.2384				
Max	1.7909	1.829	1.2384	2.8578	2.4768	2.8387	2.8006
Min	1.448	1.2384	1.0288	1.9052	2.3624	.4191	.5716
Avg	1.5471	1.688	1.1336	2.5316	2.4530	2.3386	2.1338



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094053 / 33/11 KV PANAKHED

Feeder No / Name : 201 / 11KV PALASNER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	1.0288	1.1145	.9259	.0926		
2	.823	1.046	1.0288				
3	.8916	1.0631	.9945				
4	.9602	.9774	.9431				
5	1.0288	1.0288	.8573				
6	1.0974	1.286	1.2003				
7	1.5432	1.5432	1.0974				
8	1.9719	1.8861	1.8176				
9	1.8004	1.8861	1.5775				
10	1.5432	1.1488	1.3717				
13				.1543	1.5432	1.6118	.1543
14					1.6118	1.4918	.1646
15				.1749	1.5089	1.5261	.144
16				.1698	1.4232	1.5432	.1337
17				.1646	1.4403	1.5432	.144
18				.1595	1.5261	1.406	.144
19				.144	1.4403	1.286	.1389
20				.1337	1.4403	1.2689	.1286
21				.1286	1.3717	1.2689	.1235
22		1.286	1.0974	.1235	1.3717	1.2003	.1183
23	.9945	1.286	.1063	.1063	1.286	1.2003	.1183
24	1.0288	1.2003	.9945		1.2003	1.166	.1166
Max	1.9719	1.8861	1.8176	.9259	1.6118	1.6118	.1646
Min	.823	.9774	.1063	.1063	.0926	1.166	.1166
Avg	1.2231	1.2820	1.0924	.2168	1.3274	1.3760	.1357

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094053 / 33/11 KV PANAKHED

Feeder No / Name : 202 / 11KV KHAIRKHUTI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7202	.6859	.583	.048	.5487	.6859
2		.6516	.6516	.6173	.0514	.5487	.6859
3		.6516	.6001		.0549	.6859	.7716
4			.6001	.6859	.0617	.6859	.7716
5				.7888	.0772	.9431	.8059
6				.9602	.1029	.9431	.8059
7				.9945	.1132	1.5432	1.5261
8				.1063	1.5432	1.6804	1.6461
9				.1132	1.4403	1.5432	.1543
10				.1029	1.3717	1.3032	.1286
13		1.3203	1.4746				
14		1.4575	1.5432				
15		1.3032	1.2346				
16	1.4403		1.4403				
17	1.5432	1.3032	1.3375				
18	1.5947	1.286	1.2689				
19	1.286	1.286	1.2003				
20	1.1831	1.0288	.7545				
21	.9774	.7716	.703				
22	.9774	.7545	.6859				
23	.7716	.7202	.6173	.0703	.6859	.6516	.0514
24	.7716	.7202	.583	.0772	.6516	.6859	.0583
Max	1.5947	1.4575	1.5432	.9945	1.5432	1.6804	1.6461
Min	.7716	.6516	.583	.0703	.048	.5487	.0514
Avg	1.1717	.9982	.9613	.4636	.5168	.9802	.6743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094061 / 33/11 KV Aade S/St

Feeder No / Name : 201 / 11 kv Aadhe Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2229	.2229	.2058	.2058	.2058	
2		.2058	.2229	.2058	.2058	.2058	
3		.1886	.2401	.2058	.2058	.2229	
4		.2058	.2572	.2229	.2058	.2401	
5		.2572	.2743	.2229	.2229	.2743	
6		.3429	.3086	.3086	.3086	.3086	
7		.3944	.0438	.3772	.3772	.3772	
8	.3258	.3258	.3601	.3429	.3429	.3258	
9	.3086	.3086	.3258	.3429	.3258	.3258	
10	.2743	.2572	.3258	.3258	.2743	.2915	
11		.2401	.2743	.2572	.2915		.2915
12		.2401		.2401	.2572	.0057	.2058
13	.2572	.2058	.2401	.1886	.2229		.2229
14	.2229	.1886	.2401	.1715	.2058		.1886
15	.2572	.2035	.2401	.2058	.1886		.2058
16	.2572	.1886	.2572	.2229	.2401		.2229
17	.2743	.2229		.2401	.2401		.2401
18	.3086	.2743	.3258	.2743	.2401	.0362	.3086
19	.3944	.4115	.0419	.3772	.3944		.3944
20	.3601	.3601		.3429	.3601		.3429
21	.3258	.3258		.3086	.3258		.2915
22	.2572	.3258		.2572	.3086		.2743
23	.2401	.2915		.2058	.2743		.2401
24		.2229	.0248	.2058	.2058	.2058	
Max	.3944	.4115	.3601	.3772	.3944	.3772	.3944
Min	.2229	.1886	.0248	.1715	.1886	.0057	.1886
Avg	.2903	.2671	.2348	.2608	.2679	.2327	.2638

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094061 / 33/11 KV Aade S/St

Feeder No / Name : 202 / 11 kv Tajpuri AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4232	1.2346				
2		1.4403	1.2803				
3		1.4575	1.3413				
4		1.4918	1.3717				
5		1.5261	1.4022				
6		1.5775	1.448				
7		1.7318	1.4784				
8	1.6975	1.6804	1.5242				
11				1.5242	1.9814	2.0271	1.9357
12				1.9509	2.1033	1.3717	2.0119
13				1.8747	2.0119	1.2003	2.0119
14				1.8747	1.9509		2.0119
15		.1219		1.9662	1.9204		2.0271
16				1.7071	2.0119		2.0271
17				1.9814	1.9357		1.9966
18				1.9204	1.9052	1.1812	2.0881
23	1.4746	1.1584					1.5394
24		1.4575	1.2041				
Max	1.6975	1.7318	1.5242	1.9814	2.1033	2.0271	2.0881
Min	1.4746	.1219	1.2041	1.5242	1.9052	1.1812	1.5394
Avg	1.5861	1.3697	1.3650	1.8500	1.9776	1.4451	1.9611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 094061 / 33/11 KV Aade S/St

Feeder No / Name : 203 / 11 kv Aadhe AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0669	1.1431	1.1431	
2				1.0669	1.1431	1.1888	
3				1.0974	1.1584	1.2193	
4				1.0974	1.1584	1.2498	
5				1.1126	1.1584	1.2651	
6				1.1126	1.1584	1.3108	.0686
7				1.2193	1.4022	1.3717	.6668
8				1.3413	1.326	1.326	
11		1.6613	1.8004				
12		1.5242	1.6309				
13	1.4575	1.7071	1.6004				
14	1.9033	1.6766	1.448				
15	1.9204	1.5699	1.6004				
16	1.9376	1.7528	1.5699				
17	1.8519	1.7223	1.5242				
18	1.8004	1.7071	1.5242				
23				1.0822	1.0822		
24			.6478	1.0364	1.0669	.6478	
Max	1.9376	1.7528	1.8004	1.3413	1.4022	1.3717	.6668
Min	1.4575	1.5242	.6478	1.0364	1.0669	.6478	.0686
Avg	1.8119	1.6652	1.4829	1.1233	1.1797	1.1914	.3677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 201 / WAGHADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.7263	2.7778
2				2.8464	2.8464
3				2.8292	2.6578
4				2.7949	2.8292
5				2.8292	2.915
6				2.8978	3.1207
7				3.3779	3.3436
8				3.275	2.1948
11	2.7435	2.6406	2.1091		
12	2.4006	2.6578	2.6063		
13	2.572	3.1722	2.6063		
14	2.6578	2.7092	3.1722		
15	2.7435	2.7092	3.1893		
16	2.6578	1.4746	2.6578		
17	2.4006	2.8464	2.7092		
18	2.6406	2.6578	2.6749		
19	2.6406	2.7092	2.6578		
20	2.6578	2.8807	2.7092		
21	2.6749	3.0864	3.2236		
22	2.692	3.1893	2.6749		
23	2.7092	2.6578	2.7092	2.6406	
24	2.2291	2.8292	2.8807	2.7263	2.8292
Max	2.7435	3.1893	3.2236	3.3779	3.3436
Min	2.2291	1.4746	2.1091	2.6406	2.1948
Avg	2.6014	2.7300	2.7558	2.8944	2.8349

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 202 / ASALI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6406	3.0007	3.2065			
2	2.915	2.915	3.4122			
3	2.915	2.915	3.2236			
4	.1715	2.915	.1715			
5	1.8519	3.0864	3.2407			
6	2.6406	2.915	3.0864			
7	3.1722	3.3436	3.2579			
8	2.6406	3.3436	3.5665			
9	1.869			1.7147		
10				1.869		
11				1.8519	3.6008	2.1434
12				2.0919	3.858	1.9547
13				2.1091	3.7723	2.6578
14				2.2805	3.7723	2.8121
15				1.8519	3.7723	3.1722
16				2.6578	3.7723	2.7092
17				2.3148	3.8237	2.5206
18				2.6406	3.858	2.1091
19				2.1434	3.858	
20				2.6578	3.6351	
21				2.8464	3.858	
22				2.6235	4.3381	
23	3.0864	2.915	2.1434	2.6063	4.321	
24	2.6749	3.0007	2.7092	3.0864	3.7894	
Max	3.1722	3.3436	3.5665	3.0864	4.3381	3.1722
Min	.1715	2.915	.1715	1.7147	3.6008	1.9547
Avg	2.4162	3.035	2.8018	2.3341	3.8592	2.5099

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 203 / DAHIWAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	24-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.5206
2				2.6063
3				2.6578
4				2.6063
5				2.6063
6				2.7092
7				2.6578
8				2.7949
9				3.1722
10				3.1722
11		3.0864		
12		1.7147		
13		3.3951		
14		3.2407		
15		3.0864		
16		1.5432		
17		3.2579		
18		3.2236		
19		3.0864		
20		3.2579		
21		1.8519		
22		3.3951		
23		3.3951		
24	1.5089	2.8807	.9431	
Max	1.5089	3.3951	.9431	3.1722
Min	1.5089	1.5432	.9431	2.5206
Avg	1.5089	2.8868	.9431	2.7504



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 204 / RHT

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1434	2.1434	2.8807			
2	2.0576	2.1434	2.8292			
3	2.0576	2.0576	2.8464			
4	2.0576	2.0576	3.0864			
5	2.0576	2.0576	2.7092			
6	2.1434	2.1434	2.8807			
7	2.4006	2.4006	3.3951			
8	2.4006	2.4006	3.2236			
9				2.915		
10				2.8807		
11				2.0748	3.0864	2.7435
12				2.7435	3.2579	2.7778
13				2.8464	3.2579	2.6578
14				3.0864	3.3951	2.6406
15				3.2236	3.0864	2.7092
16				2.8292	3.4122	2.7092
17				2.7435	3.2236	3.1893
18				2.3663	3.1722	1.7147
19				2.6578	3.0864	
20				3.2236	2.7263	
21				3.3608	3.5151	
22				3.1722	3.8237	
23	2.7435	1.5432	2.1091	2.1091	3.8066	
24	.2143	2.1434	2.8292	3.0864	2.4348	
Max	2.7435	2.4006	3.3951	3.3608	3.8237	3.1893
Min	.2143	1.5432	2.1091	2.0748	2.4348	1.7147
Avg	2.0276	2.1091	2.8790	2.8325	3.2346	2.6428

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 205 / PADMAVATI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	.1715
2	.1715	.1715	.1715	.1715	.1715	.1715
3	.1715	.1715	.1715	.1715	.1715	.1715
4	.1715	.1715	.1715	.1715	.1715	.1715
5	.1715	.1715	.1715	.1715	.1715	.1715
6	.1715	.1715	.1715	.1715	.1715	.1715
7	.1715	.1715	.1715	.1715	.1715	.1715
8	.1715	.1715	.1715	.1715	.1715	.1715
9	.1715	.1715	.1715	.1715	.1715	.1715
10	.1715	.1715	.1715	.1715	.1715	.1715
11	.1715	.1715	.1715	.1715	.1715	.1715
12	.1715	.1715	.1715	.1715	.1715	.1715
13	.1715	.1715	.1715	.1715	.1715	.1715
14	.1715	.1715	.1715	.1715	.1715	.1715
15	.1715	.1715	.1715	.1715	.1715	.1715
16	.1715	.1715	.1715	.1715	.1715	.1715
17	.1715	.1715	.1715	.1715	.1715	.1715
18	.1715	.1715	.1715	.1715	.1715	.1715
19	.1715	.1715	.1715	.1715	.1715	.1715
20	.1715	.1715	.1715	.1715	.1715	.1715
21	.1715	.1715	.1715	.1715	.1715	
22	.1715	.1715	.1715	.1715	.1715	.1715
23	.1715	.1715	.1715	.1715	.1715	.1715
24	.1715	.1715	.1715	.1715	.1715	.1715
Max	.1715	.1715	.1715	.1715	.1715	.1715
Min	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.1715	.1715	.1715	.1715	.1715	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 206 / 11 KV Shirpur Town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4287	.3944	.3086	.4287
2	.3429	.4287	.6001	.2915	.5144
3	.3429	.2572	.5487	.2915	.6001
4	.3086	.4287	.4287	.3086	.6859
5	.3258	.4287	.4287	.3429	.6001
6	.3429	.3258	.4458	.3429	.6516
7	.3086	.5658	.6173	.4973	.1715
8	.3429	.3772	.7716	.5658	.3086
9	.3601	.5658	.4287	.5658	.6516
10	.3772	.3772	.9431	.4458	.5658
11	.3944	.3944	.9431	.4287	.6344
12	.3086	.5144	.9431	.3086	.6859
13	.3086	.4287	1.1145	.2915	.8573
14	.3429	.4287	.9431	.2572	.2401
15	.3772	.5658	.4801	.2229	.2915
16	.5316	.4287	.6687	.2229	.3086
17	.3772	.7716	.4287	.2572	.4973
18	.3944	.3258	.4287	.2572	.5144
19	.4801	.9945	1.1317	.2915	.6687
20	.5658	.9602	.9431	.3086	.6859
21	.9431	.3944	.9431	.2401	.7716
22	.9431	1.1145	.5658	.3086	.3086
23	.5658	.3944	.3429	.4801	.1886
24	.4287	.3429	3.8237	.3086	.3429
Max	.9431	1.1145	3.8237	.5658	.8573
Min	.3086	.2572	.3429	.2229	.1715
Avg	.4387	.5101	.8045	.3394	.5073

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 207 / 11 KV Garg

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1715	.1715	.1715
2	.1715	.1715	.1715	.1715	.1715	.1715
3	.1715	.1715	.1715	.1715	.1715	.1715
4	.1715	.1715	.1715	.1715	.1715	
5	.1715	.1715	.1715	.1715	.1715	.1715
6	.1715	.1715	.1715	.1715	.1715	.1715
7	.1715	.1715	.1715	.1715	.1715	.1715
8	.1715	.1715	.1715	.1715	.1715	.1715
9	.1715	.1715	.1715	.1715	.1715	.1715
10	.1715	.1715	.1715	.1715	.1715	.1715
11	.1715	.1715	.1715	.1715	.1715	.1715
12	.1715	.1715	.1715	.1715	.1715	.1715
13	.1715	.1715	.1715	.1715	.1715	.1715
14	.1715	.1715	.1715	.1715	.1715	.1715
15	.1715	.1715	.1715	.1715	.1715	.1715
16	.1715	.1715	.1715	.1715	.1715	.1715
17	.1715	.1715	.1715	.1715	.1715	.1715
18	.6859	.1715	.1715	.1715	.1715	.1715
19	.1715	.1715	.1715	.1715	.1715	.1715
20	.1715	.1715	.1715	.1715	.1715	.1715
21	.1715	.1715	.1715	.1715	.1715	
22	.1715	.1715	.1715	.1715	.1715	
23	.1715	.1715	.1715	.1715	.1715	
24	.1715	.1715	.1715	.1715	.1715	.1715
Max	.6859	.1715	.1715	.1715	.1715	.1715
Min	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.1929	.1715	.1715	.1715	.1715	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 208 / 11KV KARWAND/DAHIWAD

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0516	1.0993	1.0536	.9869	.5868	.9145	.3944
2	1.0193	1.0688	.9278	.9278	.5716	.8916	.4287
3	.9774	1.0612	1.0307	.8707	.5639	.8916	.4287
4	.9754	1.0688	1.0021	.9126	.5944	1.0231	.4458
5	.9526	1.3698	1.3203	1.0783	.6935	1.185	.6173
6	1.2003	1.909	1.6385	1.4156	.9526	1.7394	.3772
7	1.5508	2.1243	1.6556	1.6156	1.1431	2.0176	.4801
8	1.4384	1.9928	1.5566	1.5699	1.1507	1.808	.9088
9	1.3832	1.6004	1.3527	1.8195	.8535	1.4079	.9431
10	1.6804	1.1374	1.6671	1.6976	.7697	1.1222	.8916
11	1.4327	.9983	1.5775	1.7185	.6478	1.0307	.4287
12	1.1145	.7907	1.5299	1.1831	.5944	.9526	.9431
13	1.1317	.7221	.8935	1.0212	.5944	.8916	.5658
14	1.4479	.9068	1.1336	.9107	.5792	.9145	.7202
15	1.629	.8916	1.5508	.9355	.5563	.9602	.3772
16	1.6061	.9297	1.3012	.9564	.6401	.9678	.5658
17	.9564	.9983	1.4422	1.0173	.6401	1.105	1.1145
18	1.6518	1.0669	1.3946	1.1164	.6401	1.105	.9431
19	1.328	1.4175	1.6042	1.328	.6173	1.2899	.9431
20	1.8976	1.2879	1.4708	1.3584	.8535	1.3432	.4287
21	1.7299	1.1736	1.187	1.7146	.8002	1.2517	
22	1.6613	1.1278	1.0783	.9374	.724	1.1317	
23	2.21	1.1374	1.6214	.9183	.6478	1.0574	
24	1.0917	1.0688	.9754	.8516	.5716	.9754	.2058
Max	2.21	2.1243	1.6671	1.8195	1.1507	2.0176	1.1145
Min	.9526	.7221	.8935	.8516	.5563	.8916	.2058
Avg	1.3799	1.2062	1.3319	1.2026	.7078	1.1657	.6263

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 401 / 33 KV SOOTGIRNI

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2181	6.4815	9.2593	4.6296	2.4691	2.4691
2	3.7037	6.4815	9.2593	4.1152	2.572	2.4691
3	3.858	5.8642	7.9733	5.6584	2.7263	2.572
4	4.4753	5.8642	9.6708	5.7613	2.7263	2.6749
5	4.4239	.4167	.9722	6.1728	2.8292	2.8807
6	7.5103	.4835	7.8189	7.8189	3.2922	2.9321
7	7.2017	6.2757	6.3272	6.1728	3.1893	2.6749
8	.3601	7.8189	7.9733	6.2757	5.4527	1.0802
9	.1029	.3755	10.0823	7.9733	1.749	3.1379
10	.0514	4.5782	9.6708	10.0823	1.4403	1.286
11	4.3724	.1029	9.5679	6.4301	.1029	1.5432
12	4.4239	.1029	9.6708	6.3272	.1029	3.1379
13	4.3724	4.8354	9.6708	8.1276	4.6296	1.286
14	3.9095	4.784	10.1852	8.5391	4.8354	1.5432
15	3.7551	3.858	10.2881	8.4877	4.8868	1.5432
16	4.0124	1.286	10.6996	8.1276	2.8292	5.144
17	4.0124	2.8807	10.6996	9.2593	3.3436	5.144
18	3.9095	2.8292	10.2366	9.5165	2.8292	5.5556
19	3.858	2.7778	10.2881	14.4033	2.9835	
20	.3858	2.9835	10.6996	10.8025	1.8004	
21	.4012	4.3724	10.1852	10.1852	2.9835	
22	4.0638	2.8292	10.751	10.9054	2.9835	
23	4.0638	4.5268	11.4198	10.2366	4.3724	
24	4.2181	6.4815	10.1852	5.144	2.4691	3.0864
Max	7.5103	7.8189	11.4198	14.4033	5.4527	5.5556
Min	.0514	.1029	.9722	4.1152	.1029	1.0802
Avg	3.5693	3.7204	9.3148	7.9647	2.8999	2.7453

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 402 / 33 KV SHIRPUR GOLD  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1831	.1286	1.1317	1.1831	1.1831	1.0288
2	1.2346	1.3375	1.2346	2.8292	1.1831	1.1317
3	1.2346	1.3375	1.0288	.9774	1.2346	1.286
4	1.286	1.2346	1.0802	1.6975	1.2346	1.1317
5	1.2346	1.3375	1.1317	2.8292	1.2346	1.1831
6	1.286	1.3375	1.0288	1.1317	1.286	1.2346
7	1.286	1.3375	1.0288	1.286	1.2346	1.0288
8	1.286	1.286	1.0288	2.8292	1.2346	1.286
9	1.3375	1.1831	1.1317	2.8807	1.2346	1.5432
10	1.2346	1.2346	1.1831	4.3724	1.1831	1.8004
11	1.3375	1.3375	1.5947	3.0864	1.2346	2.0576
12	1.3375	1.3375	1.6975	2.9835	1.286	2.3148
13	1.3889	1.3375	1.5432	2.8292	1.3375	1.1317
14	1.3889	1.2346	1.0288	4.1152	1.286	1.6461
15	1.3889	1.3375	.9259	5.0412	1.2346	2.2634
16	1.3889	1.3889	.7716	5.0412	1.286	1.8004
17	1.3889	1.3889	.9774	5.0926	1.2346	1.8004
18	1.3889	1.3889	1.0288	1.5432	1.2346	2.0576
19	1.3889	1.3375	1.2346	1.8004	1.4403	2.6749
20	1.3889	1.3889	1.1317	2.8292	1.6461	2.3148
21	1.3889	1.3889	1.8004	5.0926	1.2346	
22		1.3375	2.0576	4.1152	1.1317	
23	1.3889	1.3889	2.572	4.5268	1.286	
24	1.2346	1.286	1.0288	1.1317	1.1831	.9259
Max	1.3889	1.3889	2.572	5.0926	1.6461	2.6749
Min	1.1831	.1286	.7716	.9774	1.1317	.9259
Avg	1.3218	1.2764	1.2667	2.9685	1.2624	1.6020

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 405 / 33 KV Shirpur

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.7901	6.9959	4.1152	4.6296	11.8313	9.7737
2	7.0988	6.9959	4.6296	5.607	11.8313	9.8766
3	7.6646	7.0473	5.607	6.3272	11.7799	8.2305
4	7.5617	7.5617	5.607	7.8189	11.9856	10.391
5	.7613	8.5391	6.1728	6.3272	13.3745	
6	.7459	9.2078	5.7099	7.9733	14.7634	12.5515
7	.751	9.7737	6.3272	4.6296	13.8375	12.8601
8	.8076	7.7161	6.4301	6.3272	13.8889	13.3745
9	.7562	2.6235	7.9733	6.4301	2.8292	14.4033
10	.8488	2.2119	7.8189	7.9733	5.5556	14.9177
11	.7613	13.9918	8.1276	9.5165	9.1564	13.1173
12	8.0247	11.2654	5.5556	6.4301	9.7222	13.3745
13	.8848	12.9115	8.5391	6.3272	9.465	13.8889
14	.7562	11.5226	9.2593	7.9733	9.3622	14.4033
15	2.3457	12.9115	8.1276	7.8189	7.8189	8.2305
16	7.4589	13.4259	5.144	6.4301	9.5165	9.2593
17	9.0021	13.4259	8.1276	8.4877	9.5165	9.7737
18	.8025	13.4259	8.1276	.7819	8.1276	9.8766
19	.7665	13.6317	9.2593	6.3272		9.928
20	.9516	13.4774	7.9733	8.1276	10.0823	9.9794
21	.7613	13.4259	9.6708	7.8189	9.6708	10.0309
22	.751	13.5803	8.642	7.8189	9.6708	10.0823
23	2.464	13.4259	9.5165	7.9733	8.6934	10.1338
24	7.0988	6.9959	7.9733	4.1152	11.4712	9.2593
Max	9.0021	13.9918	9.6708	9.5165	14.7634	14.9177
Min	.7459	2.2119	4.1152	.7819	2.8292	8.2305
Avg	3.1923	10.2538	7.2681	6.6663	10.1718	11.2051



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-II[218]

BU 5576

Substation No/ Name :- 097006 / 132 KV DAHIWAD

Feeder No / Name : 407 / 33KV Boradi

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.6132	7.9733	7.7161	8.1276	7.5103	10.2881
2	7.356	7.8189	9.2593	9.5165	7.5617	10.4938
3	7.4589	7.8189	10.1852	8.1276	7.7161	10.6996
4	7.7161	8.0247	9.6708	9.6708	9.105	10.8025
5	.8745	8.0761	10.2366	9.5165	7.6646	8.2305
6	7.2017	8.0761	10.2881	9.5165	7.7161	8.7449
7		8.2819	10.2366	7.9733	7.7675	9.2593
8	7.2017	8.2819	10.6996	8.5391	7.6132	9.7737
9	7.4589	7.8704	10.751	9.5165	7.5103	9.8766
10	7.4589	7.4589	10.5453	4.6296	7.4074	10.3395
11	7.4589	8.3333	11.4198	9.6708	7.7675	10.391
12	7.4589	8.179	11.3169	8.0247	7.8704	12.5515
13	7.5103	7.9218	9.6194	10.2366	7.9218	7.356
14	7.8189	8.5905	10.6996	6.3272	7.9733	7.9733
15	7.5617	8.2305	11.3683	10.2881	8.1276	8.0247
16	7.5617	8.642	14.8148	11.4712	7.9218	8.1276
17	9.0535	8.2305	10.391	11.5741	7.8189	8.2305
18	7.5617	8.642	11.5741	10.1852	7.8704	9.7222
19	8.2305	7.7161	12.8601	11.4712	7.9733	
20	8.2305	8.3333	11.5741	12.8601	7.4589	
21	8.2305	8.7449	12.963	10.6996	8.1276	
22	8.2305	9.2593	13.1687	11.3683	8.0247	
23	8.2305	8.1276	13.1173	10.8025	7.9218	
24	5.0412	8.0247	8.4877	8.0247	7.4589	8.2305
Max	9.0535	9.2593	14.8148	12.8601	9.105	12.5515
Min	.8745	7.4589	7.7161	4.6296	7.4074	7.356
Avg	7.3269	8.1940	10.9568	9.5058	7.8254	9.4271

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 201 / 11 KV Main Road

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.961	.9922	.8916	1.2403	.964	.9259
2	.8916	.924	.9774	.8916	1.2489	.9391	.8916
3	.9088	.924	1.0425	.8916	1.2715	.929	.8916
4	.9945	.9709	1.1641	.9259	1.3032	1.1919	.9259
5	1.1145	1.0456	1.1744	.9945	1.3847	1.2715	.9602
6	1.2174	1.1458	1.2403	1.0631	1.4661	1.379	1.0631
7	1.2689	1.363	1.262	1.286	1.2536	1.3611	1.2689
8	1.2003	1.2197	1.3073	1.166	1.2489	1.134	1.166
9	1.2003	1.1763	1.2971	1.1643	1.134	1.2012	1.2382
10	1.1145	1.3121	1.3611	1.1458	1.2357	1.2752	1.251
11	1.0974	1.2752	1.3146	1.1458	1.2437	1.2752	1.2567
12	1.0631	1.2197	1.3032	1.1458		1.2012	1.2012
13	1.0631	1.2308	1.2048	1.0719	1.1584	1.2382	1.2012
14	1.0974	1.1458	1.1403	1.1273	1.1104	1.2012	1.1088
15	1.1145	1.2012	1.1222	1.0903	1.1163	1.2567	1.1949
16	1.0974	1.2567	1.2094	1.1458	1.0208	1.3306	1.2936
17	1.1317	1.1218	1.2003	1.0974	1.0631	1.2403	1.2757
18	1.2689	.6447	1.2689	1.2003	1.1145	1.2715	1.2851
19	1.419	1.2403	1.3032	1.3375		1.4723	1.4175
20	1.4784	1.2851	1.2689	1.3203		1.5565	1.5043
21	1.2936	1.3112	1.2346	1.2346		1.5061	1.4022
22	1.1203	1.0867	1.0631	1.0288		1.0631	
23	1.0349	1.0692	.9945	.9945		1.0277	
24	.8916	.961	1.0099	.8916	1.1043	.9568	.9602
Max	1.4784	1.363	1.3611	1.3375	1.4661	1.5565	1.5043
Min	.8916	.6447	.9774	.8916	1.0208	.929	.8916
Avg	1.1239	1.1288	1.1857	1.0938	1.2066	1.2185	1.1674

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 202 / 11 kV Karwand naka

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4784	1.448	1.3375	1.4661	1.448	1.406
2	1.3717	1.4784		1.3032	1.4148	1.4299	1.3717
3	1.406	1.4563	1.4299	1.3032	1.4632	1.2851	1.3717
4	1.5089	1.4415	1.4815	1.2689	1.5203	1.5746	1.2689
5	1.6804	1.4563	1.5203	1.406	1.6651	1.7375	1.5775
6	1.749	1.6263	1.6448	1.5775	1.7737	1.9366	1.5775
7	1.9719	2.0538	1.8107	1.749	1.8099	2.0633	1.8861
8	1.8347	1.9044	1.9387	1.6289	1.6827	1.8461	1.7147
9	1.5775	1.643	1.7187	1.4784	1.5746	1.6632	1.6263
10	1.4575	1.6057	1.6832	1.4969	1.6095	1.3676	1.4784
11	1.4403	1.6057	1.5775	1.4969	1.5912	1.5154	1.4969
12	1.4232	1.4563	1.5592	1.5708	1.5384	1.3676	1.5154
13	1.406	1.643	1.5364	1.4784	1.4299	1.5708	1.5708
14	1.4403	1.6057	1.4864	1.423	1.3611	1.5708	1.5893
15	1.5775	1.5708	1.6817	1.46	1.3575	1.6263	1.6263
16	1.4403	1.7372	1.5203	1.4969	1.3756	1.6817	1.8111
17	1.4746	1.6832	1.406	1.406	1.3717	1.6289	1.6651
18	1.5775	1.7013	1.4746	1.4918	1.5089	1.6095	1.6651
19	1.7372	1.8099	1.5775	1.9204		1.7194	1.829
20	1.922	1.8427	1.6804	1.7833		2.0995	2.0814
21	2.0538	1.8959	1.6461	1.749		2.0814	2.0271
22	1.749	1.8656	1.5775	1.6461		1.848	
23	1.643	1.6289	1.4403	1.4403		1.6289	
24	1.406	1.4998	1.4266	1.3375	1.5154	1.4842	1.4403
Max	2.0538	2.0538	1.9387	1.9204	1.8099	2.0995	2.0814
Min	1.3717	1.4415	1.406	1.2689	1.3575	1.2851	1.2689
Avg	1.5925	1.6538	1.5768	1.5104	1.5279	1.6577	1.6180

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 204 / CHANDPURI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4387	2.5911	2.6216				
2	2.4387	2.6216	2.6543				
3	2.4387	2.6543	2.7854				
4	2.4387	2.6871	2.8018				
5	2.4387	2.7199	2.6673				
6	2.4387	2.8182	2.967				
7	2.5911	2.8837	2.9312				
8	2.5911	2.8182	2.9492				
10	.1524						
11				3.2769	3.3198	3.2769	3.0769
12				3.4008		3.5627	3.4008
13				3.2769	1.3916	3.4008	3.2388
14				3.2769		3.4008	3.2769
15				3.4008	3.195	3.0769	3.2388
16				3.1626	3.4408	3.4008	3.2388
17				2.9264	3.0483	3.3979	3.3979
18				2.8654	2.8959	3.0483	3.315
23	2.4036	2.8012					
24	2.4387	2.6216	2.7854				
Max	2.5911	2.8837	2.967	3.4008	3.4408	3.5627	3.4008
Min	.1524	2.5911	2.6216	2.8654	1.3916	3.0483	3.0769
Avg	2.2554	2.7217	2.7959	3.1983	2.8819	3.3206	3.2730

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 205 / TOWN COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.3306	1.2489	1.2003	1.267	1.2536	1.2003
2	1.2003	1.3306	1.1765	1.166	1.262	1.2567	1.166
3	1.166	1.3306	1.2127	1.166	1.3121	1.1584	1.1317
4	1.2346	1.3817	1.2883	1.166	1.3491	1.2489	1.1317
5	1.6461	1.4784	1.4118	1.2689	1.4299	1.4118	1.1317
6	1.7661	1.7002	1.7556	1.5775	1.7556	1.9004	1.7147
7	1.869	1.9404	1.8099	1.7147	1.7013	1.9959	1.7661
8	1.8347	1.848	1.885	1.5775	1.6278	1.7194	1.8176
9	1.5089	1.6617	1.6651	1.4815	1.5203	1.4784	1.5261
10	1.3032	1.4937	1.4864	1.3717	1.4299	1.3491	1.423
11	.1029	1.4045	1.4661	1.3256	1.3717	1.4377	1.4784
12	.1029	1.4045	1.5154	1.3121	1.267	1.3491	1.4784
13	.1029	1.3443	1.4299	1.423	1.2489	1.3443	1.6804
14	1.6461	1.531	1.3169	1.386	1.2127	1.4415	1.4784
15	1.6289	1.4045	1.4299	1.2936	1.2489	1.5708	1.4969
16	1.4403	1.6244	1.2308	1.3306	1.1888	1.5123	1.5684
17	1.4784	1.46	1.1317	1.2003	1.2003	1.46	1.46
18	1.4045	1.3213	1.3032	1.2346	1.3032	1.3213	1.4045
19	1.5154	1.4118	1.5089	1.5432		1.4998	1.6448
20	1.5524	1.4661	1.5432	1.5089		1.6448	1.7193
21	1.885	1.5546	1.5432	1.4575		1.6804	1.701
22	2.0911	1.5565	1.406	1.4918		1.6263	
23	1.7002	1.4118	1.2689	1.286		1.39	
24	1.2003	1.386	1.2986	1.2936	1.3121	1.3213	1.2003
Max	2.0911	1.9404	1.885	1.7147	1.7556	1.9959	1.8176
Min	.1029	1.3213	1.1317	1.166	1.1888	1.1584	1.1317
Avg	1.3575	1.4907	1.4305	1.3657	1.3689	1.4738	1.4691

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 206 / 11 KV CHANDPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3326	.2534	.3086	.2926	.2957	.3086
2	.2915	.3326	.2378	.3086	.2715	.2587	.3086
3	.3086	.3326	.2715	.3086	.3142	.2353	.3086
4	.3772	.3326	.3109	.3429	.3224	.3077	.3429
5	.463	.3696	.3258	.3772	.362	.3077	.3772
6	.5144	.4805	.3658	.4801	.4706	.4805	.4801
7	.4458	.5914	.4755	.5487	.5487	.543	.5144
8	.4287	.5175	.5487	.4801	.439	.4805	.4801
9	.3772	.4108	.3439	.4435	.4024	.4066	.4115
10	.3429	.3734	.2743	.3696	.2926	.3696	.3734
11	.3086	.2957	.1267	.0566	.2561	.2772	.2614
12	.2743	.3142	.1086	.2801	.2353	.2218	.2772
13	.2743	.2957	.1646	.2587	.2172	.2587	.2957
14	.2401	.3142	.3982	.2614	.2353	.2772	.3142
15	.2401	.3326	.3258	.2772	.2534	.2587	.2772
16	.2743	.2957	.3658	.2772	.2715	.2772	.3174
17	.2957	.2715	.3429	.2743	.3086	.2896	.2926
18	.3696	.3292	.3772	.3086	.3429	.298	.3258
19	.4435	.362	.4115	.4458		.3439	.3881
20	.4805	.3475	.4458	.3772		.4024	.4755
21	.4435	.3982	.4115	.4115		.3801	.4024
22	.3734	.3544	.3772	.2743		.362	
23	.3734	.3189	.3429	.3086		.3696	
24	.2915	.3326	.3109	.3361	.3109	.3077	.3086
Max	.5144	.5914	.5487	.5487	.5487	.543	.5144
Min	.2401	.2715	.1086	.0566	.2172	.2218	.2614
Avg	.3552	.3598	.3299	.3381	.3235	.3337	.3564

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 207 / 11 KV Express Feeder PWW NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0934	.1629	.0857	.1646	.168	.0857
2	.12	.0934	.1478	.0857	.1867	.1478	.0857
3	.1715	.112	.1494	.1029	.1267	.1109	.1029
4	.2401	.1494	.1663	.1372	.1448	.181	.1372
5	.3086	.1494	.2218	.1715	.2075	.2402	.1715
6	.3772	.1867	.2075	.1715	.2218	.2957	.2058
7	.3772	.2033	.3174	.2572	.1867	.3206	.2401
8	.3772	.2801	.4108	.2743	.1991	.3142	.2401
9		.3174	.3734	.3361	.2241	.3547	.2801
10	.3429	.2054	.2957	.2241	.1267	.3174	.2801
11	.3086	.3174	.1991	.168	.1307	.3361	.2801
12	.3086	.4108	.1663	.1848	.1109	.3361	.2987
13	.3086	.3361	.1886	.1494	.1307	.2987	.2801
14	.2915	.3361	.1663	.1494	.1478	.2801	.2614
15	.3429	.3547	.1663	.168	.168	.4481	.2427
16	.3772	.3326	.2614	.1494	.1294	.4668	.1494
17	.2614	.3077	.2401	.2058	.1372	.3881	.2957
18	.2241	.2452	.2229	.2572	.2058	.3696	.2641
19	.2241	.3174	.2401	.2743		.3547	.2772
20	.1867	.3326	.2743	.2743		.2957	.2427
21	.1867	.2957	.2743	.2743		.2801	.2218
22	.112	.3174	.2915	.2743		.2896	
23	.112	.3395	.2401	.2915		.2218	
24	.0857	.0934	.1886	.0934	.2801	.3077	.1029
Max	.3772	.4108	.4108	.3361	.2801	.4668	.2987
Min	.0857	.0934	.1478	.0857	.1109	.1109	.0857
Avg	.2499	.2553	.2322	.1983	.1700	.2968	.2157

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094002 / 33/11 KV SHIRPUR

Feeder No / Name : 208 / 11 KV YOGESHWAR COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.112	.1086	.1029	.0732	.1267	.1372
2	.1029	.1109	.0905	.1029	.0905	.0924	.1029
3	.1029	.112	.1097	.1029	.1086	.0924	.1029
4	.12	.1494	.1267	.1029	.1109	.1478	.1372
5	.1372	.1867	.1629	.1372	.1829	.181	.1715
6	.1715	.2218	.1848	.1715	.197	.1991	.2058
7	.2401	.2614	.2033	.2058	.1991	.2218	.2401
8	.2401	.1867	.2195	.1715	.2012	.2279	.2401
9	.2058	.2054	.1848	.2033	.2195	.2587	.2401
10	.1715	.1848	.2012	.1478	.181	.2218	.2987
11	.1715	.1478	.1448	.1294	.1629	.1848	.2241
12	.1372	.1307	.128	.1294	.1463	.1478	.1867
13	.1372	.1109	.1448	.0924	.1629	.1478	.2054
14	.1372	.112	.0924	.0924	.1448	.1848	.2054
15	.1372	.112	.0924	.1109	.1267	.2241	.2218
16	.1372	.0934	.1086	.112	.1294	.2402	.2427
17	.1494	.0732	.0914	.1372	.1372	.2172	.2218
18	.1478	.1848	.1372	.2401	.1715	.2353	.1991
19	.2218	.1629	.2058	.2401		.2195	.2218
20	.2218	.1991	.1715	.2058		.1448	.1629
21	.1867	.1595	.1715	.1715		.1848	.1848
22	.1867	.1463	.1715	.12		.2172	
23	.1494	.1463	.1372	.12		.1848	
24	.1029	.1494	.128	.112	.1109	.128	.1372
Max	.2401	.2614	.2195	.2401	.2195	.2587	.2987
Min	.1029	.0732	.0905	.0924	.0732	.0924	.1029
Avg	.1591	.1525	.1465	.1442	.1503	.1846	.1950



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 201 / VARUL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5101	1.2955	2.296		1.6194	2.1262
2	2.4291	1.3765	2.296		1.7394	2.1262
3	2.3482	1.2955	2.296		1.7814	2.1262
4	2.4291	1.2146	2.4726		1.9204	2.3034
5	2.5101	1.1336	2.8578		2.1052	2.4752
6	2.4291	1.1336	2.8578		1.9433	2.4752
7	2.4291	1.0526	3.0483		1.9433	2.2984
8	2.2672	1.1336	2.6492		1.8976	2.1262
11				1.1069	1.2363	1.1069
12				1.2955	1.4129	1.2146
13				1.2955	1.4129	1.186
14				1.2146	1.2363	1.1336
15				1.2146	1.2363	1.186
16				1.186	1.2363	1.2003
17				1.2146	1.2363	1.1069
18				1.2146	1.2403	1.1069
23	1.1336	2.296			1.9448	2.372
24	2.4291	1.1336	2.296		1.4232	2.1445
Max	2.5101	2.296	3.0483	1.2955	2.1052	2.4752
Min	1.1336	1.0526	2.296	1.1069	1.2363	1.1069
Avg	2.2915	1.3065	2.5633	1.2178	1.5870	1.7675

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 202 / JALOD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.5911	2.2138	1.9433
2				2.5911	2.4291	2.1052
3				2.753	2.372	2.1052
4					2.4006	2.1052
5					2.5911	2.4291
6					2.5301	2.4291
7					2.5911	2.5911
8					2.5606	2.5911
11	2.5911	2.7368	2.5911			
12	2.753	2.891	2.753			
13	2.915	2.891	2.915			
14	2.915	3.0516	2.915			
15	3.0769	3.0588	3.0769			
16	2.915	3.0588	3.0769			
17	2.753	3.0588	2.915			
18	2.753	2.8978	2.915			
23			2.2672		1.9319	
24				2.4291	2.2138	1.9433
Max	3.0769	3.0588	3.0769	2.753	2.5911	2.5911
Min	2.5911	2.7368	2.2672	2.4291	1.9319	1.9433
Avg	2.834	2.9556	2.8250	2.5911	2.3834	2.2492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 203 / TEKWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7814	1.8623	1.9052			
2	1.8623	1.8623	1.9052			
3	1.8623	1.7814	2.0957			
4	1.7814	1.9433	2.0957			
5	1.7814	1.7814	2.0957			
6	1.9433	1.7814	2.2862			
7	1.9433	1.9433	2.2862			
8	1.9433	1.9433	2.0957			
11				2.1052	3.2388	2.1052
12				2.2138	3.4294	2.3482
13				2.2672	3.4294	2.372
14				2.0557	3.4294	2.3434
15				2.0557	3.2388	2.2653
16				2.0557	3.2388	2.372
17				2.1052	3.2388	2.1872
18				2.0309	3.0483	2.2138
23	1.6194	1.9052				1.7814
24	1.7814	1.7814	1.9052			
Max	1.9433	1.9433	2.2862	2.2672	3.4294	2.372
Min	1.6194	1.7814	1.9052	2.0309	3.0483	1.7814
Avg	1.8300	1.8585	2.0745	2.1112	3.2865	2.2209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 204 / BHAMPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.5813	1.7147
2				1.6194	1.7147
3				1.7394	1.7147
4				1.7604	1.9052
5				1.7394	2.0957
6				1.5813	2.2862
7				1.6194	2.2862
8				1.5813	2.0957
11	1.6194	2.0957	1.4575		
12	1.6194	2.2862	1.5384		
13	1.7814	2.2862	1.4575		
14	1.6194	2.2862	1.6194		
15	1.6194	2.0957	1.6194		
16	1.6194	2.0957	1.6194		
17	1.6194	2.0957	1.7004		
18	1.7004	1.9052	1.6194		
23			1.4575	1.7147	
24				1.4575	1.7147
Max	1.7814	2.2862	1.7004	1.7604	2.2862
Min	1.6194	1.9052	1.4575	1.4575	1.7147
Avg	1.6498	2.1433	1.5654	1.6394	1.9475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 205 / 11 KV VARUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.4858	.5335		.3125	.3125
2	.4858	.4858	.5335		.3125	.3125
3	.4858	.4858	.5716		.3125	.381
4	.4858	.4858	.5716		.3048	.381
5	.5668	.4858	.6668		.3906	.4572
6	.7287	.4858	.7621		.3906	.5468
7	.8907	.4858	.9526		.4744	.5468
8						.3048
9						.3125
10					.3125	.2812
11				.4572	.2812	.2743
12		.5716		.4534	.2743	.3125
13		.5716		.4428	.253	.3125
14		.381		.4744	.3048	.3163
15						.3125
17				.4687		
18				.4687	.3163	
19		.6668		.5335	.4687	.3125
20		.6668		.6249	.4687	.3953
21		.5716		.6249	.381	.4687
22		.5335		.5468	.3125	.3906
23		.5335			.3125	.3125
24	.4858	.4858	.5335		.1619	.3125
Max	.8907	.6668	.9526	.6249	.4744	.5468
Min	.4858	.381	.5335	.4428	.1619	.2743
Avg	.5769	.5239	.6407	.5095	.3340	.3598

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 206 / 11 KV BHAMPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3429		.3125	.3429
2	.3239	.3429		.3125	.3429
3	.3239	.3429		.3906	.381
4	.3239	.381		.3906	.4763
5	.3239	.381		.4858	.4763
6	.3239	.4763		.5535	.5716
7	.3239	.4763		.4687	.6668
8	.3239				.5716
9					.4763
10				.4763	.381
11			.3125	.381	.3048
12	.381		.3163	.381	.2846
13	.381		.2812	.381	.2915
14	.381		.2743	.3429	.2846
15	.381		.2812		.2846
16			.2812		
17			.2812		
18			.3163	.381	
19	.381		.3906	.4763	.3125
20	.4763		.4687	.4763	.3906
21	.381		.3953	.381	.3953
22	.381		.3906	.381	.3048
23	.381			.3429	.1562
24	.3239	.3429		.3163	.3429
Max	.4763	.4763	.4687	.5535	.6668
Min	.3239	.3429	.2743	.3125	.1562
Avg	.3577	.3858	.3325	.4016	.3828

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094015 / 33/11 KV VARUL S/STN

Feeder No / Name : 207 / 11 KV ABHANPURA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2672	2.1052	1.969			
2	2.2672	2.2672	1.969			
3	2.4291	2.2672	1.969			
4	2.4291	2.3482	1.969			
5	2.3482	2.4291	1.969			
6	2.2672	2.4291	2.1205			
7	2.2672	2.4291	2.1205			
8	2.1052	2.2672	2.1205			
11				2.2138	2.272	2.2672
12				2.372	2.4234	2.4006
13				2.5911	2.4234	2.372
14				2.5301	2.272	2.3482
15				2.5911	2.2805	2.2862
16				2.4291	2.2805	2.372
17				2.372	2.272	2.4006
18				2.4291	2.2805	2.372
23	1.9433	1.969				2.2405
24	2.1052	2.1052	1.969			
Max	2.4291	2.4291	2.1205	2.5911	2.4234	2.4006
Min	1.9433	1.969	1.969	2.2138	2.272	2.2405
Avg	2.2429	2.2617	2.0195	2.4410	2.3130	2.3399

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094021 / 33/11 KV BORADI

Feeder No / Name : 202 / MALKATAR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.7814	2.1338	1.8842	2.1338		
2	1.3717	1.9662	.2763	1.8515	2.1338		
3	1.6766	2.0645	2.21	1.8187	2.21		
4	2.6673	2.2119	2.2862	1.7814	2.2862		
5	2.9721	2.4531	2.4387	1.7814	2.2862		
6	3.0483	2.8178	2.7435	1.7004	2.2862		
7	3.1245	3.3532	2.8959				
8	3.2769	3.3867					
9	3.2769	3.5208					
10	2.9721	3.2007					
13					2.21	3.1131	2.8197
14					3.0483	3.4034	3.0483
15					3.0483	3.2693	2.8959
16					3.0483	3.2693	2.8197
17					3.0483	3.2693	2.8959
18					2.9721	3.4202	2.9721
19		2.9721	3.3867		3.1245	3.2693	2.8959
20		2.8959	3.1493	3.3532	2.9721	2.7681	2.6673
21		2.8197	2.8178	3.2007	2.6673	2.6543	2.4387
22		2.5149	2.2119	2.8197	2.4387	2.5888	2.2862
23		2.3624	2.1052	2.4387	2.1338	2.3758	2.21
24	1.0669	1.3763	2.0576	1.9662	2.3624		
Max	3.2769	3.5208	3.3867	3.3532	3.1245	3.4202	3.0483
Min	1.0669	1.3763	.2763	1.7004	2.1338	2.3758	2.21
Avg	2.4317	2.6061	2.3625	2.2360	2.5784	3.0364	2.7227



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094021 / 33/11 KV BORADI

Feeder No / Name : 205 / UMARDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.6385	1.1431		1.3927
2			1.5384	1.2193		1.4746
3			1.5384	1.2193		1.4746
4			1.5061	1.3717		1.5912
5			1.4737	1.5242		1.7604
6			1.4899	1.7528		1.9281
7			2.1051	2.0576	2.0576	2.4646
8			2.2801	2.4387	2.21	2.2862
9			2.3807	2.3624	2.3624	2.21
10			2.2634	2.21	2.2862	2.21
13	2.1628	1.9662				
14	2.4034	2.0957				
15	2.5149					
16	2.5987	2.5149				
17	2.5484	2.4646				
18	2.4863	2.1643				
19	2.3205	2.3205				
20	2.1879	2.0317				
21	1.9845	1.9662				
22	2.0153	1.9334				
23	1.9109	1.8623				
24			1.7166	.9907	.9145	1.1523
Max	2.5987	2.5149	2.3807	2.4387	2.3624	2.4646
Min	1.9109	1.8623	1.4737	.9907	.9145	1.1523
Avg	2.2849	2.1320	1.8119	1.6627	1.9661	1.8132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 201 / ARTHE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.271	2.3	2.332			
2	2.2634	2.2923	2.3198			
3	2.2542	2.2923	2.3152			
4	2.2512	2.2847	2.2939			
5	2.2451	2.2695	2.2893			
6	2.2801	2.2954	2.2969			
7	2.3503	2.3655	2.3609			
8	2.3624	2.4127	2.2497			
10				1.0684	1.3535	1.451
11				2.4295	2.5789	2.556
12				2.4448	2.5469	2.5789
13				2.4585	2.5941	2.585
14				2.4905	2.5972	2.5758
15				2.0043	2.5713	2.5758
16				2.4691	2.5819	2.5895
17				2.5271	2.6322	2.6185
18				2.5514	2.6475	2.5972
22	1.1264	1.2452				
23	2.2771	2.2984				
24	4.8606	2.3061				
Max	4.8606	2.4127	2.3609	2.5514	2.6475	2.6185
Min	1.1264	1.2452	2.2497	1.0684	1.3535	1.451
Avg	2.4129	2.2147	2.3072	2.2715	2.4559	2.4586

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 202 / BHARWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	2.3472	2.4863				
2	2.1338	2.3472	2.4863				
3	2.2862	2.3472	2.4863				
4	2.2862	2.5149	2.5377				
5		2.5149	2.572				
6	2.1338	2.3472	2.6406				
7	2.1338	2.3472	2.7092				
8		2.3472	2.572				
11				2.7435	2.5911	3.1017	2.6825
12				3.0483	2.7435	3.3532	2.934
13				2.8959	2.8959	3.1855	2.934
14				2.7435	2.8959	2.934	2.934
15				2.7435	2.7435	3.1855	2.934
16				2.7435	2.7435	3.1017	2.934
17				2.5911	2.7435	3.1017	2.8166
18				2.5911	2.7435	3.1017	2.8502
23	2.3472	2.4863					
24	2.1338	2.3472	2.4863				
Max	2.3472	2.5149	2.7092	3.0483	2.8959	3.3532	2.934
Min	2.1338	2.3472	2.4863	2.5911	2.5911	2.934	2.6825
Avg	2.1986	2.3947	2.5530	2.7626	2.7626	3.1331	2.8774

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 203 / VIKHRAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4668	.6097	.4572	.3829
2				.4668		.4572	.3829
3				.4668	.6097	.6097	.3829
4				.5335	.6097	.6097	.5106
5				.5792	.6859	.6097	.5106
6				.5792	.7621	.6097	.5106
7				.6097	.7621	.7621	.5744
8				.5335	.7621	.8383	.5744
11	.5999	.6001	.5735				
12	.5872	.6001	.6001				
13	.5744	.6001	.6001				
14	.5489	.6001	.6001				
15	.5361	.5735	.6001				
16	.5489	.5601	.6001				
17	.5361	.5601	.5868				
18	.5106	.5335	.5735				
23			.4668			.3829	
24				.4668	.5335	.4572	.3829
Max	.5999	.6001	.6001	.6097	.7621	.8383	.5744
Min	.5106	.5335	.4668	.4668	.5335	.3829	.3829
Avg	.5553	.5785	.5779	.5225	.6669	.5794	.4680

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 204 / ARTHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.5609	.6001			.5468
8			.6661				
12	.3906	.4382	.4382	.381	.381	.3593	.3953
16			.4207	.4572	.3048	.3281	.3749
20			.5959	.7621	.7621	.6562	.6874
24	.381	.3429	.4031	.4207	.1219	.3048	.3125
Max	.3906	.4382	.6661	.7621	.7621	.6562	.6874
Min	.381	.3429	.4031	.381	.1219	.3048	.3125
Avg	.3858	.3906	.5142	.5242	.3925	.4121	.4634

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 205 / BHARAWADE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.2279	.2229			.1581
8			.2103				
12	.1094	.1402	.1227	.1219	.1219	.1475	.1265
16			.1402		.1219	.125	.1265
20			.2279	.1524	.1524	.2401	.2372
24	.1219	.1402	.1753	.1543	.1219	.1219	.128
Max	.1219	.1402	.2279	.2229	.1524	.2401	.2372
Min	.1094	.1402	.1227	.1219	.1219	.1219	.1265
Avg	.1157	.1402	.1841	.1629	.1295	.1586	.1553

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 206 / 11 KV VIKHRAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***					
2	***						
3	***						
4	***		.2058	.2058			.1562
5	***						
6	***						
7	***						
8			.1715	.1715			
10	***						
11	***						
12	***	.1417	.1402	.1219	.1219	.1265	.125
13	***						
14	***						
15	***						
16	***		.1417	.1219	.1219	.1107	.1107
19	***						
20	***		.2103	.1524	.1524	.1739	.1898
24	.1219	.1402	.1753	.1543	.1219	.1219	.1265
Max	152.416	114.312	.2103	.2058	.1524	.1739	.1898
Min	.1219	.1402	.1402	.1219	.1219	.1107	.1107
Avg	107.6022	38.1980	.1741	.1546	.1295	.1333	.1416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 207 / 11 KV TEMBHE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.9814	1.829	1.829	1.9433
2				1.9814	1.829	1.829	1.9433
3				1.9814	.6097	1.829	1.9433
4				1.9814	1.829	1.9814	2.1052
5				2.0119	1.9814	1.9814	2.1052
6				2.0424	1.9814	1.9814	2.1052
7				2.1948	2.1338	2.1338	2.1862
8				2.21	2.2862	2.21	2.1862
11	2.7854	2.5911	2.5149				
12	2.8016	2.6216	2.6216				
13	2.753	2.6216	2.6673				
14	2.6882	2.6673	2.6673				
15	2.7206	2.5911	2.5911				
16	2.6882	2.5149	2.5149				
17	2.7206	2.4844	2.4387				
18	2.753	2.4387	2.3624				
23			1.9052			1.9433	
24				1.9052	1.829	1.829	1.9433
Max	2.8016	2.6673	2.6673	2.21	2.2862	2.21	2.1862
Min	2.6882	2.4387	1.9052	1.9052	.6097	1.829	1.9433
Avg	2.7388	2.5663	2.4759	2.0322	1.8121	1.9547	2.0512



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094030 / 33/11 KV ARTHE

Feeder No / Name : 208 / ARTHE-WAGHADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.2431	1.0669				
2	1.0669	1.1603	1.0669				
3	1.0669	1.1603	1.0669				
4	1.0669	1.1603	1.0669				
5	1.1431	1.2431	1.0974				
6	1.1431	1.2431	1.0974				
7	1.1431	1.2431	1.0974				
8	1.1431	1.2431	1.1431				
11				1.2193	1.2193	1.442	1.326
12				1.2955	1.3717	1.3757	1.3592
13				1.2193	1.2955	1.3592	1.326
14				1.1431	1.2193	1.326	2.1051
15				1.1431	1.2193	1.3757	1.2929
16				1.1431	1.2651	1.326	1.2929
17				1.2193	1.2193	1.326	1.326
18				1.2193	1.2193	1.326	1.2929
23	1.2431	1.0974					
24	1.1431	1.2431	1.0669				
Max	1.2431	1.2431	1.1431	1.2955	1.3717	1.442	2.1051
Min	1.0669	1.0974	1.0669	1.1431	1.2193	1.326	1.2929
Avg	1.1226	1.2037	1.0855	1.2003	1.2536	1.3571	1.4151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094046 / 33/11 KV WADI S/ST

Feeder No / Name : 201 / 11 KV Wadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2743	.3258	.216	.2743	.3429	.2263
2	.3258	.2915	.3258	.2332	.2915	.3429	.2332
3	.3258	.3086	.3772	.2667	.3086	.3772	.2705
4	.3772	.3772	.4115	.2401	.3429	.463	.3144
5	.4287	.4287	.4287	.3201	.4801	.4801	.3429
6	.4973	.5144	.4801	.5146	.5487	.4458	.3757
7	.583	.5487		.4075			
8	.4801	.4801		.2892			
9	.4287	.4458		.2585			
10	.3772	.3772	.463	.2801	.463	.4287	.463
11	.2572	.3429	.3048	.3429	.3429	.3429	.3429
12	.2572	.2743	.2	.3189	.3601	.2515	.3086
13	.2743	.2572	.176	.2915	.3086	.2401	.2915
14	.2572	.2401	.1943	.3012	.2915	.2462	.2743
15	.3086	.2743		.2915	.3429	.285	.2743
16	.3258	.3086	.3155	.3086	.3086	.2667	.2743
17							.2915
18							.3429
19			.3601				.4458
20	.463	5.4355	.3572	.4973	.5316	.3666	.4115
21	.3772	.463	.2892	.4458	.463	.3292	.3944
22	.3429	.3944	.2721	.3944	.4115	.2934	.3772
23	.3086	.3601	.2515	.3429	.3772	.2743	.3601
24	.3086	.2915	.3429	.2401	.3086	.3429	.2477
Max	.583	5.4355	.4801	.5146	.5487	.4801	.463
Min	.2572	.2401	.176	.216	.2743	.2401	.2263
Avg	.3625	.6042	.3264	.3239	.3753	.3400	.3268

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094046 / 33/11 KV WADI S/ST

Feeder No / Name : 202 / 11 KV Chandase Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.21	2.1338	2.271				
2	2.2253	2.1338	2.2862				
3	2.21	2.21	2.2862				
4	2.2558	2.2862	2.3167				
5	2.5549	2.3624	2.332				
6	2.3015	2.4387	2.3624				
7	2.5149	2.4844	2.3929				
8	2.4996	2.3624	2.4082				
11				2.6216	2.7282	2.8502	2.7046
12				2.6825	2.6978	2.5941	2.4672
13				2.6978	2.713	2.9767	2.4806
14				2.9165	2.6978	2.8433	2.4672
15				2.9001	2.6673	2.8464	2.4139
16				2.9165	2.8807	2.7195	2.4006
17				3.0521	2.774	2.6063	2.3739
18					2.774	2.6452	2.1338
23	2.0119	2.2405					1.9338
24	2.1948	2.1338					
Max	2.5549	2.4844	2.4082	3.0521	2.8807	2.9767	2.7046
Min	2.0119	2.1338	2.271	2.6216	2.6673	2.5941	1.9338
Avg	2.2979	2.2786	2.3320	2.8267	2.7416	2.7602	2.3751

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094046 / 33/11 KV WADI S/ST

Feeder No / Name : 203 / 11 KV Kuwe Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.626	.7621	.7621	.7514
2				.7059	.8383	.7621	.7545
3				.7545	.884	.8383	.8387
4				.8032	.9145	.884	.8413
5				.7926	.9297	.8993	.9054
6				.8939	.9602	.9602	.9335
7				.9069	.9907	1.0212	.8421
8				.6722	.9755	.9755	.8291
11	1.2498	1.1584	.8688				
12	1.2193	1.1888	.9808				
13	1.2651	1.2193	.9682				
14	1.1888	1.2041	.8291				
15	1.2498	1.2041					
16	1.2193	1.1736	.8669				
17	1.2193	1.0974	.9069				
18	1.1888	1.0669	1.0136				
23			.5304	.695	.7316	.5258	
24				.5716	.7621	.7468	.6192
Max	1.2651	1.2193	1.0136	.9069	.9907	1.0212	.9335
Min	1.1888	1.0669	.5304	.5716	.7316	.5258	.6192
Avg	1.2250	1.1641	.8706	.7422	.8749	.8375	.8128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094046 / 33/11 KV WADI S/ST

Feeder No / Name : 204 / NIMAZARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2826	1.3717	1.2955	1.2431
2				1.4403	1.387	1.3413	1.2071
3				1.5249	1.4022	1.3717	1.262
4				1.5287	1.448	1.448	1.3756
5				1.6968	1.5242	1.4937	1.2955
6				1.8968	1.5242	1.5242	1.5003
7				1.7871	1.6004	1.5851	1.3933
8				2.1136	1.9509	1.6309	1.3336
11	1.4632	1.6004	1.467				
12	1.5394	1.6766	1.5438				
13	1.6004	1.6461	1.5718				
14	1.6004	1.6918	1.3169				
15	1.6613	1.6461					
16	1.6004	1.6766					
17	1.6004	1.6766					
18	1.6004	1.6613	1.4662				
23			1.1393	1.3375	1.1431	.9202	
24				1.2269	1.4022	1.2193	1.0269
Max	1.6613	1.6918	1.5718	2.1136	1.9509	1.6309	1.5003
Min	1.4632	1.6004	1.1393	1.2269	1.1431	.9202	1.0269
Avg	1.5832	1.6594	1.4175	1.5835	1.4754	1.3830	1.2930

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094065 / 33/11 KV Vikharan Tq.Shirpur

Feeder No / Name : 201 / 11 KV Vikharan-Mukhed

GAOTHAN FEEDER

Gavthan Feeder KV- 11 /

OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4035	.4759	.4775	.2332	.4481	.4473	.2587
2	.4389	.5114	.5016	.2347	.4435	.4519	.2172
3	.4812	.5468	.5167	.2408	.5026	.5064	.2957
4	.5727	.5735	.5891	.2705	.5941	.5918	.3326
5	.7095	.6924	.6863	.3719	.3704	.7095	.3439
6	.7714	.7506	.7571	.423	.796	.7865	.3658
7	.1692	.298	.2378			.2698	
9				.077			
10	.4016	.3452	.1791	.2324	.3715	.4277	.2033
11	.3208	.3094	.4866	.3269	.3776	.3967	.1629
12	.2602	.2896	.4506	.3148	.1959	.3376	.1629
13	.2469	.27	.3868	.1768	.3466	.3269	.1629
14	.2419	.2669	.414	.3262	.3738	.3481	.181
15	.2677	.2873	.4073	.3479	.4073	.2343	.1629
16	.2639	.2911	.3549	.3399	.3639	.3793	.1629
17			.3443				
18	.0244	.0114	.3788	.0251	.0274	.0312	
19	.2218	.6194	.5201	.2964	.6035	.6102	.2715
20	.3445	.6335	.5476	.3467	.6325	.647	.2896
21	.3353	.6038	.5628	.6005	.5531	.6249	.2715
22	.6134	.5697	.5438	.5407	.527	.5792	.2534
23	.4862	.4771	.4824	.4778	.4911	.5468	
24	.4542	.5152	.4496	.4603	.4565	.4656	.2218
Max	.7714	.7506	.7571	.6005	.796	.7865	.3658
Min	.0244	.0114	.1791	.0251	.0274	.0312	.1629
Avg	.3823	.4447	.4670	.3173	.4441	.4628	.2400

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094065 / 33/11 KV Vikharan Tq.Shirpur

Feeder No / Name : 202 / 11 KV Ukhalwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.5565	1.4243	1.3763	1.4255
2				1.5565	1.4413	1.3763	1.3923
3				1.5729	1.4074	1.3763	1.442
4				1.6057	1.4251	1.3927	1.4586
5				1.4419	1.4251	1.3923	1.4089
6				1.4582	1.4083	1.4083	1.4255
7				1.5565	1.4575	1.4413	1.5746
8				1.5893	1.4706	1.4413	1.6078
11			1.3763				
12	1.7368	1.7368	1.6842				
13	1.7924	1.7695	1.7166				
14	1.7695	1.7814	1.7532				
15	1.668	1.757	1.7166				
16	1.7166	1.7204	1.7004				
17	1.7532	1.7368	1.7532				
18	1.4575	1.6194	1.7532				
19	1.3435	1.5565					
22				1.4582			
23			1.4419	1.4582	1.3603		
24			1.3927	1.4243	1.3763	1.4255	1.3765
Max	1.7924	1.7814	1.7532	1.6057	1.4706	1.4413	1.6078
Min	1.3435	1.5565	1.3763	1.4243	1.3603	1.3763	1.3765
Avg	1.6547	1.7097	1.6288	1.5162	1.4196	1.4034	1.4569

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

JALGAON ZONE[058]

DHULE CIRCLE[580]

DONDAICHA DIVISION[583]

SHIRPUR-I[222]

BU 5550

Substation No/ Name :- 094065 / 33/11 KV Vikharan Tq.Shirpur

Feeder No / Name : 203 / 11 KV Mukhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5338	3.0978	3.3585				
2	2.1605	3.0978	3.3488				
3	3.4713	3.136	3.4373				
4	3.4789	3.1382	3.4362				
5	2.0149	1.7574	3.3941				
6	1.9814	1.7756	3.3859				
7	3.6778	3.2914	3.6502				
8	3.7669	3.3577	3.6546				
10				.397	.269	.4184	
11				3.7822	3.6839	3.7132	1.7166
12				3.733	3.7875	3.6437	1.7004
13				3.8159	3.7898	3.7542	1.6842
14				3.8995	3.8714	3.7508	1.704
15				3.7395	3.7754	3.771	1.6712
16				3.693	3.7837	3.7744	1.6712
17				3.7152	3.8205	3.7464	1.7368
18				3.7022	2.0729	3.7666	1.7368
19					1.8461		
22	.282	.2233					
23	3.0193	3.2903					
24	3.3288	3.1184					
Max	3.7669	3.3577	3.6546	3.8995	3.8714	3.7744	1.7368
Min	.282	.2233	3.3488	.397	.269	.4184	1.6712
Avg	2.7923	2.6622	3.4582	3.3864	3.0700	3.3710	1.7027