

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184004 / DEOLA

Feeder No / Name : 201 / KHUNTEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17
HR	Load (MW)
9	1.9982
12	2.8395
15	2.3487
Max	2.8395
Min	1.9982
Avg	2.3955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184004 / DEOLA

Feeder No / Name : 202 / 11 KV MATANE FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17
HR	Load (MW)
9	1.7353
15	2.1209
Max	2.1209
Min	1.7353
Avg	1.9281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184004 / DEOLA

Feeder No / Name : 207 / LOHNER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17
HR	Load (MW)
9	1.8427
12	3.155
15	2.2436
Max	3.155
Min	1.8427
Avg	2.4138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184004 / DEOLA

Feeder No / Name : 209 / BHAVADE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.724	2.7664	2.8837	2.5835	2.4112	.7804
2	.7575	.727	2.8974	2.8685	2.7039	2.4387	.7987
3	.7971	.7423	2.9614	2.9584	2.8563	2.5652	.8505
4	.881	.7758	3.0346	3.219	2.995	2.7389	.8901
5	.9038	.7895	3.4522	3.4324	3.1443	3.1306	.8993
6	.4009	.5746	3.7083	3.7144	3.5604	3.4156	.6356
7			4.6944	4.8209	4.67	4.7798	
8			4.8285	5.141	4.5511	4.8118	
9	3.5437		3.754	5.0145	5.1334	4.51	
10	4.7249	4.76	1.7391	1.5333	1.9875	1.6842	4.635
11	4.923	5.0648					5.0069
12	8.6884	4.3911					4.3149
13	4.3164	3.911					3.8561
14	3.8668	3.5833					3.312
15	6.9426	3.3791					3.3013
16	3.9186	3.5071					3.4873
17	2.617	3.9842					4.0146
18	4.7813	1.576	.3048	.282	.2881	.3109	2.0485
19	2.2116	.3643	.3795	.413	.3475	.3887	.4115
20	.8048	.7453	.7529	.756	.7667	.8185	.7712
21	.8048	.7529	.7453	.8048	.82	.8429	.7956
22	.7941	.7316	.6767	.6859	.7026	.8017	.8474
23	.8261	.7072	.6523	.6645	.7225	.8581	.852
24	.7712	2.4158	2.4234	2.1917	2.2619	.8048	.7651
Max	8.6884	5.0648	4.8285	5.141	5.1334	4.8118	5.0069
Min	.4009	.3643	.3048	.282	.2881	.3109	.4115
Avg	2.6838	2.1051	2.3395	2.4344	2.3585	2.1948	2.0607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184004 / DEOLA

Feeder No / Name : 210 / KHUNTEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17
HR	Load (MW)
9	.1595
12	.0895
15	.0716
Max	.1595
Min	.0716
Avg	.1069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184004 / DEOLA

Feeder No / Name : 211 / DEOLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17
HR	Load (MW)
9	.567
12	.5552
15	.6447
Max	.6447
Min	.5552
Avg	.5890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184027 / THENGODA

Feeder No / Name : 201 / KHALAP G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3366			.3506			
2		.4108	.4458		.3734		
3	.3189			.4382			
4		.462	.5258		.3696		
5	.567			.5434			
6		.7392	.7186		.7577		
7	.5959		.6335	.4733			
8		.5121	.4525		.4805		.4733
9			.4344	.3772			
10		.4066		.3658			.4066
11		.3361	.362		.3547		
12		.3511	.3439	.3109	.3506		.3696
13	.3734	.333			.3921	.3155	
14		.3018	.333	.2957	.3547		
15					.3921	.298	
16		.4024	.298	.3547			.4668
17		.4694				.3506	
18		.4973	.4382				.5788
19	.5601	.5533				.5258	
20			.5194				
21		.463					.5041
22		.4115					
23			.3045			.3506	.4251
24					.3696		
Max	.5959	.7392	.7186	.5434	.7577	.5258	.5788
Min	.3189	.3018	.298	.2957	.3506	.298	.3696
Avg	.4587	.4433	.4469	.3900	.4195	.3681	.4606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184027 / THENGODA

Feeder No / Name : 202 / PILKOSH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4733			1.1869			
2		.5228	1.1142		1.182		
3	.5316			1.3565			
4		.5228	1.4083		1.1568		
5	.5316			1.5089			
6		.5975			1.9376		
7	.2915		2.7515	3.0178			
8		.3696			3.155		.2743
9				.0857			
10		.2033		.1109			.2054
11		1.1317			.0934		
12		2.4034	.1341	.112	.0934		3.3128
13	2.5941	2.3137			.1109	.1578	
14		1.7436	.0848	.1494	.0924		2.5766
15					.1478	.1578	
16		1.989	.0857	.1494			2.5941
17		2.0233				.1402	
18		.2058	.1543				1.9163
19	.2241	.2058				.298	
20		.4144	.4115				
21		.463					.4435
23		.4458	1.1145			.4382	.4668
24					1.182		
Max	2.5941	2.4034	2.7515	3.0178	3.155	.4382	3.3128
Min	.2241	.2033	.0848	.0857	.0924	.1402	.2054
Avg	.7744	.9722	.8065	.8531	.9151	.2384	1.4737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184027 / THENGODA

Feeder No / Name : 203 / 11KV LANDAGEBET FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804			.6859			.2743
2		.3361	.7537		.8059		
3	.3155			.7716			
4		.3326	.8916		.7888		
5	.3601			.8573	1.0631		
6		.462	.9724				
7	.3772		1.5604	1.6108			
8		.2772	1.7833		1.7833		.2401
9			.2058	.2058			
10		.1848		.1463			.2241
11		.4115	.1372		.12		
12		1.6078	.12	.1097	.1029		1.7703
13	1.8983	1.6817			.1029	.1029	
14		1.423	.1029	.0924	.1029		1.4899
15					.1029	.0857	
16		1.587	.12	.1109			1.4723
17		1.5524				.12	
18		1.5497	.1543				1.3321
19	.3206	.3658				.3429	
20		.3292	.3681				
21		.3109					.2987
22		.3292					
23		.7577	.3506			.2743	.3361
24					.8059		
Max	1.8983	1.6817	1.7833	1.6108	1.7833	.3429	1.7703
Min	.2804	.1848	.1029	.0924	.1029	.0857	.2241
Avg	.5920	.7940	.5785	.5101	.5779	.1852	.8264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184027 / THENGODA

Feeder No / Name : 204 / 11 KV SAWAKI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17
HR	Load (MW)
15	1.4091
Max	1.4091
Min	1.4091
Avg	1.4091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184027 / THENGODA

Feeder No / Name : 205 / OLD WATER SUPPLY

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413			.4207			
2		1.2178	.4207		.4481		
3	1.358			.4031			
4		1.2795	.4681		.4435		
5	1.5424			.4382			
6		1.7833			.5175		
7	2.0348		.4207	.4207			
8		2.2291	.3258		.3582		
9				.2103			1.8778
10		.2241		.2103			.2241
11		1.094	1.3717		1.6263		
12		.2058	2.332	2.2634	2.0698		.2241
13	.2241	.1886			2.2177	1.7833	
14		.2241	2.1948	1.9204	2.2177		.2241
15					1.8111	1.6289	
16		.2427	2.3148	2.1033			.2241
17		.2587				1.8004	
18		.2926	2.0576				.2614
19	.3734	.4527				.2743	
20		.4287	.4287				
21		.4481					.4668
22		.4668					
23		.4668	.4115			.9602	1.0608
24					.4435		
Max	2.0348	2.2291	2.332	2.2634	2.2177	1.8004	1.8778
Min	.2241	.1886	.3258	.2103	.3582	.2743	.2241
Avg	1.1457	.6767	1.1588	.9323	1.2153	1.2894	.5704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184027 / THENGODA

Feeder No / Name : 206 / NEW WATER SUPPLY EXPRES

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1288		.0762	.0351			
2	.0762	.1882	.0686	.0762	.1135		
3	.1463	.0762		.0526			
4	.0762	.1501	.052	.0762	.1871		
5	.0526		.0762	.1471			
6	.0762	.1501	.1463	.0762	.224	.0762	.0762
7	.1814	.0762	.112	.1294	.0762		.0762
8	.0762	.1132	.0358		.037		.0686
9	.0762		.0537	.0343	.0762	.0762	.0762
10	.1524	.2818	.0762	.1494	.0762	.0762	.2069
11	.1524	.1316	.1478	.0762	.2263	.0762	.0762
12		.1686	.2002	.2042	.1124	.0762	.1135
13	.1696	.037	.0762	.0762	.0351	.1113	
14		.0358	.0709	.037	.1135		.1135
15		.0762	.0762	.0762	.0373	.0351	
16	.0762	.0351	.1791	.037	.0762		.1494
17	.0762	.0351	.1524	.0762	.0762	.1463	.0762
18	.0762	.0526	.1471	.0762		.0762	.1135
19	.1135	.0895		.0762	.0762	.1288	
20		.0358	.1124				.0762
21		.0358					.0373
22		.1478					
23	.0762	.1478	.1667	.0762	.0762	.1113	.1322
24	.0762	.0762	.0762	.0762	.1132	.0762	.0762
Max	.1814	.2818	.2002	.2042	.2263	.1463	.2069
Min	.0526	.0351	.0358	.0343	.0351	.0351	.0373
Avg	.1033	.1019	.1051	.0832	.1019	.0889	.0979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184027 / THENGODA

Feeder No / Name : 207 / Dari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804			.8573			.2804
2		.3361	.6962		.788		
3	.298			.9259			
4		.3326	.823		.7712		
5	.3856			.9665			
6		.5175	1.0229		1.3203		
7	.4801		1.7878	1.95			
8		.4435			2.2462		.3155
9			.4294	.2629			
10		.2772		.2195			.2987
11			.1867		.1848		
12		1.4251	.1543	.1463	.1848		1.9105
13	1.6297	1.5154			.1294	.12	
14		1.448	.1595	.1294	.1478		1.595
15					.1478	.1372	
16		1.4661	.1433	.128			1.8404
17		1.4327				.1543	
18		1.4661	.197				1.7002
19	.3734	.3801				.3944	
20		.3982	.4961				
21		.3045					.3361
22		.298					
23		.6485	.6379			.3086	.3174
24					.788		
Max	1.6297	1.5154	1.7878	1.95	2.2462	.3944	1.9105
Min	.2804	.2772	.1433	.128	.1294	.12	.2804
Avg	.5745	.7931	.5612	.6206	.6708	.2229	.9549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184027 / THENGODA

Feeder No / Name : 208 / MALIWADA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8478			.1052			
2		.788	.1029		.112		
3	.8939			.0876			
4		.7712	.1174		.1109		
5	.9774			.1578			
6		.8059	.1372		.1663		
7	1.0631		.1372	.1402			
8		1.0562	.12		.1478		1.0117
9			.1372	.1227			
10		.1307		.0732			.1109
11		.0739	1.1145		1.0349		
12		.0514	1.286	1.3321	1.3306		.056
13	.0373	.0701			1.2012	1.1488	
14		.0857	1.2689	1.0974	1.2567		.056
15					1.2752	1.0802	
16		.1029	1.382	1.2696			.056
17		.12				1.0288	
18		.1372	1.2403				.0747
19	.1307	.1543				.2058	
20		.1372	.1595				
21		.1372					.1494
22		.1307					
23		.112	.1052			.583	.5487
24					.1075		
Max	1.0631	1.0562	1.382	1.3321	1.3306	1.1488	1.0117
Min	.0373	.0514	.1029	.0732	.1075	.2058	.056
Avg	.6584	.2862	.5622	.4873	.6743	.8093	.2579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184050 / BHAUR

Feeder No / Name : 201 / PALEKAR WASTI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	1.2487	.4252	.4626	.4405	.4504	.6203
2	.6615	1.4208	.4207	.781	.7031	.4496	.6295
3	.7613	1.5466	.4291	.5083	.4542	.4618	.6546
4	.8612	1.7149	.4915	.5426	.4733	.471	.7331
5	1.1043	1.9614	.5754	.6356	.5769	.5883	.9015
6	2.6948	2.4937	1.1446	1.1198	1.0451	.6744	1.2841
7	4.0391	4.0934	.6676	.6836	1.094	.6752	1.9738
8	4.509	4.6803	1.0754	1.0134	1.022	.5891	3.7679
9	2.6661	2.7126	.9692	.8249	.7987	.5098	2.3261
10	.6324	.4976	.5805	.6469	.3612	.6612	.7183
11	.4406	.495	1.5676	.9754	.2675	.314	.5384
12	.4122	.2492	1.5043	1.3451	1.3306	2.3421	.2705
13	.4168	.4145	2.9155	2.7842	2.5213	1.3161	.4659
14	.221	.2157	2.7227	1.4038	2.3873	2.2036	.2477
15	.4023	.2157	1.4556	2.5268	1.2056	1.1446	.4779
16	.437	.3952	1.5493	2.9082	2.4164	1.2818	.2728
17	.4659	.2347	1.4571	3.0903	2.9232	1.5356	.4993
18	.5231	.5019	1.7208	1.6347	1.6347	2.8768	.2896
19	.723	.6582	2.0252	1.6461	1.5127	1.5059	.3826
20	1.0809	.6219	.5906	1.0363	.6036	1.1079	.6165
21	.8751	.5388	1.0475	.5053	.5365	.5304	.5594
22	.7552	1.0032	.4771	.8208	.4588	.4542	.8072
23	.7981	.4534	.4778	.8506	.4649	.9577	.8919
24	.6432	1.0154	.9469	.8999	.8117	.6203	1.005
Max	4.509	4.6803	2.9155	3.0903	2.9232	2.8768	3.7679
Min	.221	.2157	.4207	.4626	.2675	.314	.2477
Avg	1.1157	1.2243	1.1349	1.2353	1.0852	.9884	.8722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184050 / BHAUR

Feeder No / Name : 202 / BHAUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1782	2.2575	.2942	.2972	.2804	.2759	1.1949
2	1.1629	2.3318	.2972	.6218	.5901	.2774	1.1721
3	1.1599	2.3604	.3018	.3033	.3018	.3033	1.1477
4	1.1843	2.3903	.314	.3262	.3323	.3231	1.1355
5	1.2132	2.4788	.4191	.3993	.3871	.3673	1.2742
6	2.7439	2.7978	.8199	.9037	.8259	.5045	1.5531
7	3.864	3.9264	.5274	.4969	.8983	.4984	1.925
8	4.4684	4.6862	.7671	.7802	1.8188	.4024	4.1789
9	2.4057	2.7245	.6205	.4926	.5115	.3429	2.2662
10	.4564	.2576	.3408	.3965	.1951	.3286	.3973
11	.3251	.3825	1.8732	2.0521	.4893	.378	.3858
12	.1471	.1829	2.0851	2.2481	2.2207	4.6207	.302
13	.1775	.266	2.4402	3.9859	3.6746	2.4905	.3076
14	.1478	.1753	2.4875	2.1826	4.0699	3.8583	.1692
15	.3542	.1844	2.3106	4.0778	2.1643	2.079	.2875
16	.3714	.3038	4.2821	4.0076	4.1165	2.178	.1844
17	.3882	.1707	2.4234	4.119	4.7067	2.3518	.3116
18	.2749	.4618	2.4874	2.1201	2.4021	2.3624	.192
19	.6183	.5011	2.6305	1.986	2.2695	2.0759	.285
20	.8111	.4054	.4176	.8265	.4161	.8195	.4191
21	.7721	.3673	.6285	.3795	.3597	.3902	.3597
22	.6783	.6075	.3323	.6539	.3216	.3445	.5654
23	1.2072	.3155	.317	.6696	.3003	1.4927	1.3918
24	1.2376	1.2493	.526	.6597	.5783	1.2224	2.3407
Max	4.4684	4.6862	4.2821	4.119	4.7067	4.6207	4.1789
Min	.1471	.1707	.2942	.2972	.1951	.2759	.1692
Avg	1.1395	1.3244	1.2476	1.4578	1.4263	1.2620	.9894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184050 / BHAUR

Feeder No / Name : 203 / VITHEWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.4502	.7285	.8749	.8612	.8703	.2378
2	.2698	.4615	.7301	1.3369	1.6709	.9099	.2439
3	.2728	.4956	.7057	.8246	.884	.9435	.2591
4	.2987	.5382	.7392	.852	.8779	.9953	.2728
5	.3125	.5936	.8413	.9587	.8993	1.0059	.2926
6	.5883	.6211	2.005	2.2933	2.0258	1.1431	.3094
7	.526	.5184	1.2605	1.4114	2.553	1.3352	.2987
8	.4122	.4295	2.6698	3.0407	1.777	1.5653	.3864
9	.3107	.3119	1.3437	1.7516	1.9119	1.4586	.2894
10	.1318	.1387	.1	.1261	.0655	.1263	.0826
11	.8967	.6747	.0979	.0824			.8466
12	2.9484	1.4891				.0814	2.7761
13	3.0647	2.8176		.0826	.092		2.7755
14	2.8413	1.4601			.0825	.0824	1.4982
15	2.7291	1.3413		.0826			2.6328
16	2.8246	2.353	.0824	.0824	.0824		1.4647
17	2.9647	1.3748		.0824	.0824		2.7717
18	2.9038	2.6489					1.515
19	1.6076	1.4169	.2641	.1219	.1189	.1753	1.5287
20	.4636	.2515	.2454	.4634	.2515	.4626	.2759
21	.4584	.2606	.4077	.2591	.2378	.2576	.2591
22	.491	.4747	.2439	.4694	.2469	.2652	.4941
23	.4929	.3643	.346	.8608	.3749	.4692	.4642
24	.253	.8654	1.547	1.5371	1.5623	.2408	.4672
Max	3.0647	2.8176	2.6698	3.0407	2.553	1.5653	2.7761
Min	.1318	.1387	.0824	.0824	.0655	.0814	.0826
Avg	1.1798	.9313	.7977	.8378	.8329	.6882	.9351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184050 / BHOUR

Feeder No / Name : 204 / VITHEWADI G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1153	.0625	.0114			
2	.0648	.0506		.0545	.0481		
3	.003	.0506					
4		.0488					
5	.0015	.065					
6	.1652	.0488	.0489	.0493	.0471		
7	.1477	.0611		.0053	.0307		.0651
8	.1374	.0757	.051	.032	.1826		.0488
9	.0783	.1363	.0682	.1513	.2104	.0579	.1965
10	.3056	.1174	.1497	.2134	.1303	.2709	.2269
11	.2657	.1754	.2195	.2142	.1456	.1189	.2208
12	.2699	.0716	.1029	.1158	.0701	.1929	.1664
13	.2112	.0687	.1736	.94	.2431	.0831	.0374
14	.1113	.0648	.2206	.0991	.2482	.2221	.0754
15	.1389	.0876	.096	.2114	.1143	.1151	.103
16	.1265	.1229	1.4907	.1982	.1886	.1067	.0183
17	.2002	.0518	.0998	.1873	.1155	.0655	.1805
18	.1941	.1334	.1052	.1113	.0617	.1174	.0876
19	.2518	.1799	.1927	.1021	.0351	.0221	.0343
20	.268	.1181	.1372	.2178	.0526	.1767	.1006
21	.2588	.1219	.2119	.1158	.0914	.1075	.0876
22	.2177	.1862	.109	.1438	.0922	.1067	.1521
23	.1802	.0991	.0876	.0833	.0282	.1296	.0889
24	.0594	.1704	.0905	.0802	.0658		.0488
Max	.3056	.1862	1.4907	.94	.2482	.2709	.2269
Min	.0015	.0488	.0489	.0053	.0282	.0221	.0183
Avg	.1623	.1009	.1957	.1589	.1101	.1262	.1077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184050 / BHAUR

Feeder No / Name : 205 / 11KV Express S&P

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4438					
2		.4742		.1646	.275		
3		.4065					
4		.3726					
5		.3222					
6	.3197	.1696	.0494	.4995	.3144		
7	.3197	.0848					.3573
8	.1821	.407	.1661	.2997	.2083		.0752
9	.1524	.3939	.4097	.0812	.3845		.0752
10	.0496		.3344	.4513		.2257	.1886
11	.0494	.4225	.3949	.3949			.3525
12	.0506				.4063	.2257	.4439
13	.0494	.422	.4889	.3761	.3124		.263
14			.5265		.3124	.3949	
15	.0493			.4701			.4171
16	.0478	.0494	.3009	.4137	.0659		
17	.0493			.4137	.066		.4115
18	.0661	.0488				.5829	
19	.1821	.0489	.4347				
20	.203			.3772			
21	.2815		.423				
22	.2792	.0487		.2634			.3457
23	.411			.2719		.4137	.3937
24		.3039	.0497	.2441	.3246		.3009
Max	.411	.4742	.5265	.4995	.4063	.5829	.4439
Min	.0478	.0487	.0494	.0812	.0659	.2257	.0752
Avg	.1613	.2762	.3253	.3372	.2670	.3686	.3021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184050 / BHAUR

Feeder No / Name : 206 / Khamkheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4295					
2		.4558		1.0762	1.1216		
3		.4573					
4		.5064					
5		.557					
6	.6001	.6246	1.6442	2.0247	1.9865		
7	.5508	.4901					.4955
8	.396	.4389	1.931	2.2779	2.2509		.379
9	.2802	.271	.267	.1794	.2884		.267
10	.1154		.1302	.1318		.1464	.1952
11	.7433	.1315		.1318			.5261
12	2.1754					.1318	2.3095
13	2.1374	1.9294	.1302	.1334	.13		1.9938
14			.1302		.1318	.1483	
15	1.9776			.1318			1.7828
16	2.027	1.8054	.1464	.1648	.1483		
17	2.1094			.1652	.1485		2.0247
18	2.2042	1.9895				.1648	
19	.3138	.2894	.2728				
20	.462			.4813		.4944	
21	.4625		.423				
22	.4768	.4785		.4558			.5103
23	.5148			.7849		.4625	.463
24		.4439	1.0174	.9054	.9614		.4625
Max	2.2042	1.9895	1.931	2.2779	2.2509	.4944	2.3095
Min	.1154	.1315	.1302	.1318	.13	.1318	.1952
Avg	1.0322	.7061	.6092	.6460	.7964	.2580	.9508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184050 / BHAUR

Feeder No / Name : 207 / NEW BAGADU

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4399					
2		.4404		.1927	.2278		
3		.4721					
4		.5075					
5		.5402					
6	.5174	.5219	.2318	.2115	.2166		
7	.8002	.8778			.2352		.7929
8	1.0064	.8609	.1877	.1773	.1911		.8512
9	.1324	.1694	.1705	.1442	.1282		.1652
10	.1159		.1154	.1154		.1142	.1283
11	.0825	.0988	.5109	.3304			.0796
12	.0989					.6262	.0822
13	.0985	.0953	.824	.6607	.6183		.0961
14			.7177			.6098	
15	.099			.6098			.1025
16	.0822	.0851	.7416	.6262			
17	.0989			.6277			.0988
18	.132	.0941				.6262	
19	.231	.1538	.1978				
20	.2483			.2406		.2142	
21	.2483		.3164				
22	.2278	.2382		.2085			.1886
23	.2766			.214		.2313	.2576
24		.4439	.2041	.1832	.2044		.2973
Max	1.0064	.8778	.824	.6607	.6183	.6262	.8512
Min	.0822	.0851	.1154	.1154	.1282	.1142	.0796
Avg	.2645	.3775	.3834	.3244	.2602	.4037	.2617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184078 / KHARDE

Feeder No / Name : 201 / KHARDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3458	1.4662	.3048	.2896	.3399	1.2056	1.2986
2	1.5653	1.5379	.3185	.3094	.3582	1.2269	1.3032
3	1.8046	1.733	.3353	.3353	.3734	1.3016	1.387
4	1.858	1.829	.3384	.3384	.3887	1.4129	1.5562
5	2.0729	1.9677	.3384	.3414	.3978	1.5531	1.8031
6	2.6459	2.2177	.282	.1692	.2088	2.1369	2.4326
7	2.7572	3.0422				2.5362	2.521
8	1.0867	2.7481				2.3746	2.4448
9	1.0242	1.6141	2.2436	2.2893	2.4082	.7438	.5274
10			2.1948	2.4676	2.6932		
11			2.1262	2.0698	2.492		
12			1.9646	1.9281	1.7756		
13			1.6034	1.4662	1.765		
14			1.9982	1.6994	1.8366		
15			2.079	1.8656	2.0104		
16			2.2939	2.0851	2.1933		
17			1.4495	1.0989	.916	.0015	
19	.189	.2058	.2591	.2698	.2027	.2347	.192
20	.2103	.2317	.282	.2911	.2469	.2393	.2271
21	.2256	.2561	.3003	.3018	.2317	.2454	.2271
22	.2393	.3109	.3048	.3338	.2301	.221	.2378
23	1.169	.2957	.2926	.3353	1.1126	1.2254	.9541
24	1.4419	.2835	.2804	.3246	1.2132	1.2925	1.1507
Max	2.7572	3.0422	2.2939	2.4676	2.6932	2.5362	2.521
Min	.189	.2058	.2591	.1692	.2027	.0015	.192
Avg	1.3090	1.3160	1.0281	.9814	1.1140	1.1220	1.2175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184078 / KHARDE

Feeder No / Name : 203 / VADALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3368	.3506	.6943	.7971	.7849	.3483	.3643
2	.3368	.3711	.7072	.7781	.7735	.3582	.3711
3	.362	.3841	.7164	.7857	.804	.3993	.4054
4	.394	.4077	.7948	.8764	.8436	.4306	.471
5	.4252	.4184	.9793	1.0646	.9419	.4679	.4809
6	.3033	.2164	1.0883	1.3893	1.3695	.4268	.442
7			1.5821	1.6034	1.5493		
8			1.8138	1.5264	1.5737		
9	1.3496	1.2719	1.0181	.9351	.8581	1.0684	1.1363
10	1.4822	1.4533				1.5013	1.3649
11	1.3115	1.2148				1.2833	1.3344
12	1.2605	1.1058				1.1035	1.0951
13	1.0463	.9732				.9976	.9686
14	.9221	.7987				.8749	.8566
15	.9793	1.0098				.9983	.9755
16	1.1827	1.1111				1.2407	1.1469
17	.996	.7019	.0053	.0053	.0404	1.1157	.8855
18	.1052	.1036	.0953	.125	.1235	.0975	.1311
19	.2904	.2736	.2637	.2637	.3064	.2904	.1433
20	.3414	.3208	.3216	.3254	.3765	.381	.3475
21	.3902	.3384	.3376	.3406	.3871	.3856	.3887
22	.4047	.3429	.3231	.3475	.3955	.407	.397
23	.3856	.57	.7362	.6013	.3749	.4009	.3772
24	.349	.6447	.775	.7644	.3498	.381	.3384
Max	1.4822	1.4533	1.8138	1.6034	1.5737	1.5013	1.3649
Min	.1052	.1036	.0053	.0053	.0404	.0975	.1311
Avg	.6798	.6538	.7207	.7370	.6972	.6799	.6555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184204 / Dahiwad

Feeder No / Name : 201 / dahiwad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
12	.8583	
17	1.2407	
24		.3018
Max	1.2407	.3018
Min	.8583	.3018
Avg	1.0495	.3018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184204 / Dahiwad

Feeder No / Name : 202 / ramnagar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
12	.547	
17	.6539	
23	.547	
24		.2515
Max	.6539	.2515
Min	.547	.2515
Avg	.5826	.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184204 / Dahiwad

Feeder No / Name : 203 / meshi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
12		.1844	
14	.9592		
17		.218	
24			.3185
Max	.9592	.218	.3185
Min	.9592	.1844	.3185
Avg	.9592	.2012	.3185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184204 / Dahiwad

Feeder No / Name : 204 / 11KV SONEWADI FEEDER
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
12	.1296	
17	.1341	
24		.3018
Max	.1341	.3018
Min	.1296	.3018
Avg	.1319	.3018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

DEOLA[530]

BU 6416

Substation No/ Name :- 184204 / Dahiwad

Feeder No / Name : 205 / 11 KV SINDOHAL FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
12	1.0442	
17	1.0562	
24		.4024
Max	1.0562	.4024
Min	1.0442	.4024
Avg	1.0502	.4024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184013 / ABHONA

Feeder No / Name : 201 / MANUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.2801	.2801	.2427	.5281	.6327	.7042
2	.6478	.2801	.2801	.2427	.5218	.6481	.6962
3	.6478	.2801	.2614	.2427	.5155	.6481	.7042
4	.6478	.2801	.2801	.2427	.5281	.6706	.7377
5	.7545	.2801	.2987	.2427	.6882	.6706	.8139
6	.8478	.2801	.2801	.2427	.7712		.9665
7	1.2498	.2241	.2054	.2241	1.0111	1.3272	1.3916
8	1.5203	.1448	.1494	.1463	1.358	1.4723	1.491
9	.0943	.132	.124	.1267	.0953	.132	.0943
10	.0754	.0924	.1052	.1075	.0953	.0762	.0943
11	.0754	.1448	.3479	.8916	.0754	.0754	.0943
12	.0754	1.6108	1.3599	1.3413	.0754	.0762	.0943
13	.0943	1.5089	1.2163	1.2071	.1132	.0943	.0943
14	.0754	1.4089	1.034	1.0486	.1132	.0953	.0943
15	.0943	1.085	.953	1.004	.1143	.0953	.0943
16	.1132	1.1603	1.1203	1.0883	.1143	.0953	.1132
17	.1132	1.2452	1.1822	1.1683	.132	.0953	.0943
18	.1132	1.2323	1.2003	1.1363	.1132	.1143	.0943
19	.1867	.1524	.1143	.1509	.1334	.1509	.1886
20	.2427	.2427	.2427	.2241	.2452	.2241	.2427
21	.2801	.2829	.2641	.2614	.2829	.2614	.2801
22	.3018	.3018	.2641	.3206	.3018	.3174	.3018
23	.5668	.2801	.2614	.2801	.2294	.5376	.4752
24	.663	1.1603	.2614	.2427	.4961	.6478	.6882
Max	1.5203	1.6108	1.3599	1.3413	1.358	1.4723	1.491
Min	.0754	.0924	.1052	.1075	.0754	.0754	.0943
Avg	.4220	.5871	.5036	.5178	.3605	.3982	.4435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184013 / ABHONA

Feeder No / Name : 202 / PALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.6554	.8436	.7865	.4572	.4572	.4572
2	.4191	.7773	.8642	.7865	.4572	.4572	.4572
3	.4191	1.0364	.8642	.7865	.4572	.4954	.4572
4	.4191	1.5729	.9061	.852	.4572	.5335	.4954
5	.4572	1.704	.9488	1.0852	.4572	.5906	.4954
6	.5335	1.7238	1.2929	1.3565	.4572	.5716	.5335
7	.4572	1.8778	1.8138	1.8778	.4572	.4382	.4572
8	.3048	1.7284	2.0481	1.9784	.3048	.3048	.3048
9	.1524		.1494	.1509	.1905	.1905	.2263
10	.1524		.1524	.1509	.1524	.1509	.1524
11	.9282		.0762	.1509	.3239	1.0486	1.073
12	1.5729		.0754	.1509	1.7004	1.8778	1.3748
13	1.6644		.0754	.1509	1.4842	1.5546	1.358
14	1.4083		.0754	.1509	1.2041	1.3123	1.2498
15	1.2193	.1524	.1524	.1509	1.2803	1.2651	1.2346
16	1.358	.1524	.1905	.1509	1.4413	1.2955	1.358
17	1.4815	.1524	.1905	.1509	1.6004	1.7436	1.4266
18	1.7238	.1715	.2286	.1509	1.4403	1.7238	1.2742
19	.3048	.381	.381	.3048	.2286	.3048	.3048
20	.5281	.4954	.5281	.5335	.4954	.4108	.5335
21	.5281	.4763	.4904	.4572	.4954	.5281	.5335
22	.5335	.4954	.4904	.5335	.4954	.5335	.5335
23	.4572	.4108	.6554	.5182	.4572	.4572	.4572
24	1.2193	.5243	.8322	.1509	1.4842	.4572	.4572
Max	1.7238	1.8778	2.0481	1.9784	1.7004	1.8778	1.4266
Min	.1524	.1524	.0754	.1509	.1524	.1509	.1524
Avg	.7776	.8049	.5969	.5632	.7491	.7793	.7169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184013 / ABHONA

Feeder No / Name : 203 / KANASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5256	1.9244	1.8233	1.8143	1.7126	.5144
2	.6097	.5256	1.9071	1.8233	1.7974	1.7804	.5144
3	.6097	.5256	1.8551	1.8442	1.7804	1.8143	.5144
4	.6287	.5256	1.9418	2.0957	1.8313	1.8442	.5335
5	.6478	.5256	1.9938	2.1795	2.2043	1.861	.5716
6	.6668	.5426	2.4863	2.431	2.3061		.6287
7	.5335	.5426	3.4421	3.2693	3.2217	3.3093	.4763
8	.4191	.3391	3.493	3.3913	3.3913	3.3093	.3048
9	2.4587	.5853	.2667	.2374	.1905	.1905	2.1704
10	3.5778	3.5305	.1905	.2035	.2096	.1524	3.3065
11	3.6286		.1524	.1187	.1905	.1715	3.6286
12	3.5269	3.6286	.1524	.1357	.1524	.1524	3.4082
13	3.3404	3.3065	.1524	.1357	.1524	.1715	3.2895
14	3.1539	3.1855	.1524	.1357	.1524	.1715	2.9504
15	3.12	2.8502	.1524	.1696	.1715	.1524	2.9843
16	3.2047	3.0182	.1905	.1696	.1715	.1715	3.0521
17	.1526	.1524	.1905	.1696	.1905	.1524	.1187
18	.1865	.2096	.2286	.2035	.1905	.2096	.2035
19	.5256	.4954	.4382	.4578	.381	.4001	.4578
20	.6274	.6668	.6287	.6274	.6668	.6287	.5935
21	.5935	.6859	.5906	.5596	.6859	.6287	.6104
22	.6104	.6859	.6668	.5596	.6478	.6668	.5765
23	.5765	.6478	.7545	.8309	.4458	1.3077	.5596
24	.6097	.5256	.5716	1.8233	1.7295	1.8347	.5093
Max	3.6286	3.6286	3.493	3.3913	3.3913	3.3093	3.6286
Min	.1526	.1524	.1524	.1187	.1524	.1524	.1187
Avg	1.4424	1.2272	1.0218	1.0581	1.0281	.9910	1.3532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184013 / ABHONA

Feeder No / Name : 204 / ABHONA GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.2743	.2629	.2804	.2987	.2896	.298
2	.2804	.2772	1.8551	.2804	.2987	.2896	.298
3	.2804	.2772	.2629	.2804	.2801	.2896	.298
4	.2804	.2743	.2629	.2804	.2801	.3109	.298
5	.2804	.2743	.2629	.3155	.3206	.3109	.3155
6	.298	.3475	.333	.333	.3395		.3155
7	.4382	.3841	.4031	.3681	.462	.3881	.4031
8	.4382	.431	.4207	.4557	.4066	.3681	.4382
9	.2713	.333	.298	.3353	.333	.3052	.3185
10	.3155	.3155	.1753	.2949	.333	.3155	.2947
11	.3292	.3155	.3155	.2984	.3856	.3506	.3294
12	.3467	.298	.3506	.3189	.3506	.4207	.3366
13	.3561	.2804	.3506	.3155	.3681	.4207	.3429
14	.3561	.2804	.3506	.333		.333	.3681
15	.3814	.333	.3155	.3506		.333	.3944
16	.3467	.3681	.2804	.3988	.3681	.3681	.4748
17	.3704	.2096	.3155	.4287	.4733	.4557	.4784
18	.3909	.4557	.3856	.3856	.4207	.4557	.3704
19	.3887	.3506	.5144	.426	.4031	.4207	.4641
20	.3944	.3856	.4031	.3988	.4031	.4031	.4334
21	.3772	.3681	.4031	.3601	.3856	.4031	.3944
22	.3601	.3681	.3681	.3681	.3681	.4031	.3898
23	.3077	.333	.3155	.3292	.333	.3506	.3658
24	.2804	.2743	.2804	.2804	.2957	.298	.3155
Max	.4382	.4557	1.8551	.4557	.4733	.4557	.4784
Min	.2713	.2096	.1753	.2804	.2801	.2896	.2947
Avg	.3396	.3254	.3952	.3423	.3594	.3602	.3640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184013 / ABHONA

Feeder No / Name : 205 / ABHONA 2

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.421		.1886	.1886	.2743	.3437	.3688
2	.426	.1494	.1886	.1886	.2683	.3437	.3688
3	.426	.1494	.1886	.1886	.2984	.3479	.3688
4	.4588	.1494	.2263	.1886	.3315	.176	.4359
5	.503	.1867	.2263	.2263	.4024	.3361	.4694
6	.5426	.2263	.2641	.2641	.4748	.4641	.5426
7	.7099	.2263	.2452	.2263	.663	.6718	.7377
8	.8223	.1524	.1698	.1494	.7956	.6554	.7773
9	.112	.0943	.0914	.1509	.1143	.1132	.0924
10	.0747		.0747	.0754	.0943	.0747	.0754
11	.0754	.1677	.4641	1.0242		.0754	.0762
12	.0754	.9614	.8962	.7956		.0747	.0754
13	.0754	.9175	.6401	.6478		.0754	.0747
14	.0754	.7682	.679	.5898		.0754	.0754
15	.0747	.8002	.6249	.5761		.0754	.0762
16	.0747	.8259	.7274	.583	.0754	.0754	.0762
17	.0739		.7682	.6554	.1132	.0754	.0762
18	.0747	.8333	.6874	.7377	.0943	.0943	.0762
19	.1509	.1143	.1509	.1905	.1132	.1509	.1509
20	.2263	.2096	.2263	.2263	.2286	.2263	.2667
21	.2263	.2286	.2263	.1886	.1886	.2263	.2286
22	.2263	.2096	.1886	.1886	.1886	.2075	.2286
23	.253	.2075	.1886	.1867	.1658	.2652	.2035
24	.4534	.1509	.2075	.1886	.1791	.3441	.3605
Max	.8223	.9614	.8962	1.0242	.7956	.6718	.7773
Min	.0739	.0943	.0747	.0754	.0754	.0747	.0747
Avg	.2763	.3680	.3558	.3594	.2665	.2320	.2618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184054 / DESRANE

Feeder No / Name : 201 / MOKHBHANGI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.852			.3326	
2			.852			.3326	
3		.823	.8951			.3326	1.0631
4			1.1043			.3696	
5			1.1843			.4251	
6	1.3923		1.4419			.462	1.4746
7	2.3472		2.4249		.3547	.3326	1.906
8	2.4813	2.7161	2.5888	.2926	.2614	.2957	1.9662
9	.2614	.3361	.2743	.2241	.1867	.2241	.2241
10	.1478	.0366		.168	1.9204		
11	.1307	.0366	.1372	1.1797	.7373	1.2452	.112
12	.1109	.0366		2.4531	1.9204		.1097
13	.1294	.0366		2.1879	1.9204	1.8564	.128
14	.1294	.0366	.1448	1.9559	1.7695	1.5912	.128
15	.1307	.0366		1.9559	1.6385	1.4586	.128
16	.1307	.0366	.1372	1.8564	1.6741	1.5912	.128
17		.0366		2.0553	1.8351	1.829	.1494
18		.168	.181	2.0553	1.8351	2.0919	.1848
19		.3326		.2987	.2957	.2481	.3547
20				.3772	.3326		.3772
21		.3361			.3361	.362	.3734
22		.3326		.3361	.3547	.3045	.3696
23		.6226		.3361	.3174	.4115	.8192
24	.7209	.8848	.8288	.3086	.3395	.3361	.9175
Max	2.4813	2.7161	2.5888	2.4531	1.9204	2.0919	1.9662
Min	.1109	.0366	.1372	.168	.1867	.2241	.1097
Avg	.6761	.4026	.9319	1.1276	1.0016	.7825	.5744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184054 / DESRANE

Feeder No / Name : 202 / DESRANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0831	.08	.1592	.5205	.5083	1.0216	.08
2	.0823	.0831	.1585	.4687	.4931	1.0193	.0831
3	.0869	.1623	.1608	.4603	.4748	1.1146	.1585
4	.0945	.0922	.1668	.4557	.4832	1.1763	.0884
5	.1067	.0991	.1979	.5022	.5213	1.1999	.0922
6	.2435	.1296	.2389	.6478	.6904	1.35	.2306
7	.2101	.1189	.1926	1.6682	1.7215	1.7688	.1554
8	.1116	.1501	.1051	1.669	1.7139	1.7696	.163
9	.0552	.0377	.0373	.8844	.9263	.9194	.0701
10	.0377	.04		.0377	.0377		
11	1.2597	1.3855	.8955	.0377	.0385	.0377	.9252
12	2.1986	1.992	1.0928	.0377	.0377		2.0042
13	2.1354	1.9296	1.0448	.0377	.0377	.037	1.9875
14	1.8938	1.7612	1.8	.0377	.0377	.037	1.89
15	1.762	1.7254	.9457	.0377	.0377	.037	1.8602
16	1.9052	1.7406	1.714	.0377	.0377	.037	1.8572
17	1.0997	1.8053	.9617	.0373	.0377	.0373	1.7649
18	1.0745	1.7764	1.6522	.0377	.0377	.0377	1.7307
19	.9747	1.0002	.8825	.2071	.1798	.1918	1.0263
20	.1158	.1699	.1158	.1867	.1874	.1128	.2208
21	.0922	.1957	.0823	.0861	.1347	.1562	.1699
22	.0914	.1623	.0747	.0907	.0484	.1585	.1699
23	.0838	.1608	.2667	.7911	.7811	.1555	.1653
24	.1196	.1196	.5845	1.0761	.9858	.5396	.1569
Max	2.1986	1.992	1.8	1.669	1.7215	1.7696	2.0042
Min	.0377	.0377	.0373	.0373	.0377	.037	.0701
Avg	.6633	.7049	.5883	.4189	.4246	.5870	.7413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184054 / DESRANE

Feeder No / Name : 203 / NALID

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1867			.3441	
2			.1867			.3605	
3		.1886	.1867			.426	.1886
4			.2054			.5571	
5			.2054			.6299	
6	.2452		.2241	.6401		.7042	.2075
7	.2075		.1509	.9717	1.1437	1.1363	.168
8	.1509	.1509	.1494	.9145	1.1271	1.0159	.1494
9	.1132	.0943	.0377	.0754	.0943	.0934	.1109
10	.0754	.0943		.0754	.0554		
11	.4161	.583	.2743	.0754	.0377	.0754	.3563
12	1.0159	1.0486		.0377	.0377		1.1469
13	.8642	.8356		.0943	.0377	.0377	.9831
14	.6722	.7209	.7888	.0943	.0377	.037	.5243
15	.6081	.6554		.0377	.0747	.0739	.639
16	.6722	.6226	.6706	.037	.0747	.0739	.7459
17		.7842		.0747	.0373	.0934	.8002
18		.6722	.7888	.0943	.0739	.0747	.8162
19		.1494		.1509	.1848	.1509	.1698
20		.1867		.2263	.1867		.1886
21		.1867			.2054	.2054	.2075
22		.2054			.1867	.1867	.1867
23		.1867		.3239	.3277	.1867	.1867
24	.1886	.1886	.1867	.6401	.3768	.3605	.1867
Max	1.0159	1.0486	.7888	.9717	1.1437	1.1363	1.1469
Min	.0754	.0943	.0377	.037	.0373	.037	.1109
Avg	.4358	.4197	.3030	.2685	.2389	.3249	.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184054 / DESRANE

Feeder No / Name : 204 / MOKHBHANGI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2073	.2103	.415	.2271	.2218	.4249	.2233
2	.2096	.218	.3993	.2286	.2279	.4489	.2271
3	.2309	.43	.4184	.2431	.2492	.4498	.4534
4	.2705	.2507	.4907	.2721	.2789	.5423	.2782
5	.3254	.3094	.5384	.346	.3163	.3285	.3528
6	.6969	.349	.6393	.771	.349	.7897	.8052
7	.6173	.3224	.6257	.6261	.6605	.6485	.6367
8	.5362	.4997	.4931	.4695	.543	.5091	.4778
9	.3974	.4081	.4131	.4201	.4088	.4194	.4125
10	.2511	.3224	.1699	.2821	.3132	.1654	.1562
11	.2583	.2795	.2812	.2405	.2839	.2519	.2941
12	.2176	.2374	.125	.2835	.2294	.128	.2704
13	.1784	.2321	.1242	.242	.2161	.242	.2681
14	.2004	.2336	.2275	.2283	.1987	.242	.2298
15	.2385	.2359	.1196	.2382	.212	.2466	.1532
16	.2542	.2557	.2663	.2466	.2633	.276	.3047
17	.1821	.3177	.1616	.358	.3239	.3429	.3384
18	.2248	.4016	.3986	.4043	.3468	.3345	.4363
19	.3246	.6226	.3567	.5979	.639	.6403	.6546
20	.3346	.3246	.3368	.6498	.6562	.3612	.6567
21	.2728	.5369	.285	.2743	.6097	.5669	.5694
22	.2469	.4988	.2515	.2477	.4801	.5289	.5209
23	.2172	.434	.2324	.4165	.4355	.4634	.4786
24	.4201	.4123	.4092	.2263	.4308	.4264	.4428
Max	.6969	.6226	.6393	.771	.6605	.7897	.8052
Min	.1784	.2103	.1196	.2263	.1987	.128	.1532
Avg	.3047	.3476	.3408	.3558	.3706	.4074	.4017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184054 / DESRANE

Feeder No / Name : 205 / NALID(G)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0754			.0754	
2			.0566			.0566	
3		.0549	.0566			.0566	.0724
4			.0754			.0747	
5			.0943			.0943	
6	.1132		.112	.128		.132	.124
7	.0943		.0754	.1086	.1132	.0754	.1086
8	.0566	.0377	.0566	.0543	.0754	.0566	.0724
9	.0377	.0377	.0354	.037	.0566	.0566	.0554
10	.037	.0377		.037	.0566		
11	.0377	.037	.0362	.037	.0377	.037	.037
12	.0378	.037		.037	.0377		.037
13	.0373	.037		.037	.0373	.037	.037
14	.0373	.037	.0354	.037	.0377	.037	.037
15	.0373	.037		.037	.0377	.037	.037
16	.056	.037	.0362	.037	.0377	.037	.037
17		.0554		.0747	.0377	.0362	.0377
18		.056	.0549	.0754	.0566	.0362	.0566
19		.0943		.0943	.0943	.0905	.0754
20				.0943	.1132		.1132
21		.0943			.0747	.0724	.0754
22		.0754		.0754	.0747	.0724	.0754
23		.0754		.0754	.0754	.0543	.0754
24	.0566	.0549	.0754		.0754	.0754	.0732
Max	.1132	.0943	.112	.128	.1132	.132	.124
Min	.037	.037	.0354	.037	.0373	.0362	.037
Avg	.0532	.0527	.0626	.0633	.0628	.0619	.0651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184054 / DESRANE

Feeder No / Name : 206 / Bhadane

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1698			.7373	
2			.1698			.7537	
3		.168	.1509			.9242	.1494
4			.1509			.852	
5			.1698			.8848	
6	.1698		.1509	.6706		.9175	.1886
7	.132		.1132	.7926	.0943	1.3108	.1307
8	.0943		.0566	.9602	.0754	.7362	.0543
9	.0566		.0373	.0754	.0566	.0377	.0373
10	.0377			.037	.0377		
11	.3277		.1524	.037	.0754	.037	.4049
12	1.2125			.037	.0566		1.1961
13	1.0814			.0554	.0566	.0554	1.1105
14	.9667		.9145	.037	.0566	.0554	1.0277
15	.8848			.037	.0566	.037	.9448
16	.8848	.9339	.7926	.037	.0566	.037	.9614
17		.9175		.037	.0566	.056	
18		.852	.9012	.0377	.0566	.0549	.852
19		.0943		.0377	.132	.112	.1132
20				.0754	.1509		.1509
21		.1698			.1698	.168	.1886
22		.1698			.1886	.1848	.1698
23		.1698		.0566	.4915	.1494	.1509
24	.1509	.1663	.1698		.0566	.7209	.8848
Max	1.2125	.9339	.9145	.9602	.4915	1.3108	1.1961
Min	.0377	.0943	.0373	.037	.0377	.037	.0373
Avg	.4999	.4046	.2928	.1888	.1069	.4201	.4842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184054 / DESRANE

Feeder No / Name : 207 / Ganore 1Ph Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5424			.7733	
2			1.5581			.7545	
3		1.6057	1.5249			.7356	1.2803
4			1.757			.7468	
5			1.8244			.7762	
6	2.1628		2.0165	.7842		.8299	2.2291
7	2.9007		3.1093	.5975	.5658	.5281	2.3624
8	2.7846	3.0476	2.9007	.3547	.3772	.2829	2.1948
9	.1886	.2263	.1829	.2241	.2427	.1698	.1867
10	.1509	.2054		.1494	.9892		
11	.0377	.0934	.0343	1.6194	.8029	1.9334	.1494
12	.0373	.0747		3.3589	2.7035		.0366
13	.0754	.0554		2.7515	2.4697	2.3371	.0924
14	.0943	.0924	.112	2.2377	1.8233	2.4034	.1478
15	.0754	.1478		2.1879	2.2801	2.1216	.1294
16	.1109	.1294	.0373	2.4863	2.2775	2.3537	.1294
17		.112		2.6355	2.4863	2.2253	.1509
18		.1886		2.4863	2.3922	2.3472	.1886
19		.5281		.5281	.3961	.3772	.5658
20		.6224		.7922	.7356		.7545
21		.7167			.7545	.7682	.7922
22		.7922			.8299	.7682	.7922
23				.7545	.7356	.4801	.9221
24	1.6057	1.6804	1.5249		.7545	.7545	1.5089
Max	2.9007	3.0476	3.1093	3.3589	2.7035	2.4034	2.3624
Min	.0373	.0554	.0343	.1494	.2427	.1698	.0366
Avg	.8520	.6070	1.3942	1.4968	1.3120	1.1651	.7691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184068 / DALWAT

Feeder No / Name : 201 / JIRWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7124	2.0033	3.6995	3.148	1.9829	2.0655	1.9741
2	1.9275	2.048	3.9148	2.2519	2.7534	2.185	1.9983
3	2.0361	2.0916	4.0193	2.1666	3.7742	2.3042	1.2612
4	1.352	1.0989	4.1656	2.2977	2.1453	2.4949	2.2772
5	2.5665	2.4135	4.3402	2.5827	4.5397	2.6616	2.5122
6	1.3656	2.6469	5.5651	2.742	5.8937	2.8036	2.6073
7	2.0423	2.2784	6.4039	3.8363	7.4335	2.3442	1.1721
8	1.3385	1.4096	5.8972	6.5856	7.0775	1.451	1.3488
9	.8767	.8036	2.3701	3.045	3.0012	.4809	.9557
10	.656	.7706	.7026	.8986	.7354	.5654	.3955
11	3.4298	2.5011	.5213	.713	.6453	3.9991	4.0737
12	6.9628	7.8345	.4217	.619	.5906	7.7002	3.5955
13	7.1975	7.0974	.4492		.5099	7.0268	7.2656
14	6.0707	5.4573	.3536	.6432	.2317	6.3634	3.283
15	3.0262	5.4925	.4962	.3315	.5815	5.6429	5.8063
16	6.4683	5.9984	.5124	.6937	.6567	6.222	6.2275
17	6.3383	6.035	.7286	.8351	.7024	7.5084	6.1674
18	5.6512	5.7875	.8805	1.0066	.8454	6.1957	5.483
19	3.3084	3.3287	1.6151	1.8555	1.4457	3.4381	3.2639
20	2.195	2.1791	1.962	2.1972	2.1941	2.0023	2.2809
21	2.1236	2.1182	1.984	2.1352	2.1734	2.1442	2.2397
22	1.0623	2.1283	1.9967	2.1834	2.191	2.0954	2.2726
23	1.9883	2.045	1.4975	2.6551	1.2224	1.7235	2.2306
24	2.0111	2.2276	2.1536	3.6435	3.0821	1.0639	2.0889
Max	7.1975	7.8345	6.4039	6.5856	7.4335	7.7002	7.2656
Min	.656	.7706	.3536	.3315	.2317	.4809	.3955
Avg	3.0711	3.2415	2.3604	2.1333	2.3504	3.4368	3.0325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184068 / DALWAT

Feeder No / Name : 202 / DALWAT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2258	2.5834	1.3833	1.2822	1.2734	1.5913	1.9503
2	2.175	2.6231	1.4427	.6958	1.2917	1.6525	2.147
3	2.0576	2.6581	1.4891	.7468	1.3443	1.624	2.343
4	1.9622	1.2582	1.5492	.7849	.7369	1.7916	1.3085
5	2.2477	2.9768	1.6421	.8269	1.5677	2.0024	1.5206
6	3.112	3.99	1.6595	.8482	1.7031	3.19	2.922
7	4.4087	5.2318	1.3486	.7308	1.3334	4.8658	3.3186
8	4.131	4.9406	.8895	.9705	.9812	4.0544	4.308
9	1.7059	2.1201	.0107	.6799	.505	1.3222	1.6602
10	.3898	.4843	.4496	.5108	.5208	.3897	.2393
11	.3135	.4492	2.1842	2.2432	2.3383	.3243	.3821
12	.2828	.3738	4.6931	3.964	4.8831	.3079	.1753
13	.3169	.3717	4.8267		4.2722	.3007	.3213
14	.3421	.318	3.9588	2.7702	1.0181	.3401	.1722
15	.0754	.4335	3.2908	1.7741	3.9173	.3475	.3232
16	.3809	.4546	2.9444	3.4735	4.115	.349	.3618
17	.4193	.4586	3.3812	4.0788	3.9944	.4085	.4401
18	.6648	.4807	3.3536	4.016	3.6962	.6022	.6807
19	1.2622	1.0234	1.5284	1.9254	1.7687	1.1449	1.2447
20	1.4967	1.3697	1.2219	1.4139	1.412	1.3325	1.2585
21	1.4072	1.2987	1.2258	1.3573	1.3779	1.3465	1.3981
22	.6927	1.3881	1.243	1.3791	1.4268	.7756	1.387
23	1.1938	1.4636	.711	1.3036	.6996	1.5446	1.3822
24	2.5721	1.4096	.6783	1.252	.692	1.3923	2.1598
Max	4.4087	5.2318	4.8267	4.0788	4.8831	4.8658	4.308
Min	.0754	.318	.0107	.5108	.505	.3007	.1722
Avg	1.4932	1.6733	1.9627	1.6969	1.9529	1.3750	1.3919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184076 / NANDURI

Feeder No / Name : 201 / NANDURI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658		.3944			
2			.3506			
3	.3292		.4115			
4	.4024		.4458			.2572
5	.439		.4801			
6	.439	.4458				.3258
7	.4024	.463	.4115	.3086		
8	.3658	.4287	.3944	.2572		.3772
11	.0343	.3772		.2401		
12	.3429	.3429		.2058	.2134	
13	.3086	.3429		.2058		
14		.3258		.2058		
15	.3086	.3429				
16	.3086	.3258		.2058	.2229	
17	.3429	.2743		.2229		
18	.3429	.3258				
19		.463		.3086		
20	.463	.4801		.3429	.3258	
21	.4801					
22	.463	.4801			.2915	
23		.463		.2743		
24	.3429	.3429	.4287	.2572		.2401
Max	.4801	.4801	.4801	.3429	.3258	.3772
Min	.0343	.2743	.3506	.2058	.2134	.2401
Avg	.3601	.3890	.4146	.2529	.2634	.3001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184076 / NANDURI

Feeder No / Name : 202 / MOHANDORI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2146		.2591			
2	1.2146		.2743			
3	1.2146		.2743			
4	1.2955		.3048			1.0669
5	1.4575		.4877			
6	1.587	.4725				1.2955
7	1.8785	.3963	.381	1.5699		
8	1.8461	.2286	.2591	1.4327		1.4175
11	.0762	.7316		.0914		
12	.0762	1.2498		.1067	.1067	
13	.0762	1.1279		.0762		
14		1.1736		.0076		
15	.0762	1.2498				
16	.0762	1.2193		.0762	.1067	
17	.0914	1.3413		.1219		
18	.1981	1.3717				
19	.2743	.3353		.3048		
20	.4115	.381		.4115	.3963	
21	.3658					
22	.3201	.3353			.3201	
23		.2743		.4572		
24	.3048	.2439	.2743	.8535		.884
Max	1.8785	1.3717	.4877	1.5699	.3963	1.4175
Min	.0762	.2286	.2591	.0076	.1067	.884
Avg	.7028	.7583	.3143	.4591	.2325	1.1660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184076 / NANDURI

Feeder No / Name : 203 / Sakora

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926		1.0669			
2	.2926		1.0669			
3	.2926		1.0669			
4	.3658		1.1431			.2743
5	.439		1.7071			
6	.439	1.829				.3658
7	.4024	1.4327	2.0881	.3658		
8	.1463	1.9357	2.2405	.1829		.2286
11	1.3413	.0914		.7468		
12	2.4539	.0914		1.9662	1.7833	
13	2.1795	.0762		1.8138		
14		.0762		1.7528		
15	1.6918	.0914				
16	1.7528	.1067		1.4022	1.2193	
17	1.7375	.1067		1.5394		
18	1.7223	.1067				
19	.3772	.3048		.3048		
20	.3658	.3353		.3658	.3353	
21	.3048					
22	.3048	.3048			.2591	
23		.8383		.2439		
24	.9145	.9145	1.0669	.2439		.2591
Max	2.4539	1.9357	2.2405	1.9662	1.7833	.3658
Min	.1463	.0762	1.0669	.1829	.2591	.2286
Avg	.8908	.5401	1.4308	.9107	.8993	.2820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184082 / OTUR

Feeder No / Name : 201 / SHIRASMANI Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.6722	.6481	.6562	.6173	.2286
2	.1905	.2096	.6722	.7407	.6802	.6562	.2286
3	.2286	.2286	.6722	.7811	.7287	.7682	.2477
4	.2286	.2667	.6964	.8855	.8192	.8002	.2667
5	.2667	.2858	.7611	1.0753	.8848	1.0364	.3048
6	.3048	.3429	1.0978	1.2803	1.1822	1.2146	.3429
7	.2858	.2667	1.6356	1.8138		1.7869	.2667
8	.2096	.2096	1.7124	1.8947	2.1548	2.0165	.2286
9	.1143	.1715	.1715	.1334	.1334	.1334	.1334
10	.0953	.1334	.0953	.1143	.0953	.0953	.1143
11	.8482	.828	.0762	.0762	.0572	.0762	1.2163
12	1.6518	1.5844	.0953	.0953	.0762	.0572	1.9433
13	1.5364	1.5203	.0953	.0953	.0953	.0762	1.668
14	1.3763	1.3117	.0953	.0953	.0953	.0762	1.4575
15	1.3603	1.1405	.0953	.0953	.0953	.0762	1.4255
16	1.3923	1.2323	.0953	.0953	.0762	.0953	1.3435
17	1.5524	1.3279	.0953	.1143	.0762	.0762	1.4899
18	1.5364	1.3592	.1524	.1143	.1143	.0953	1.4746
19	.1715	.1715	.2096	.2096	.1905	.2286	.1905
20	.2858	.2858	.2096	.2858	.2286	.2667	.2858
21	.2667	.2858	.2477	.2286	.2477	.2667	.3048
22	.2477	.2096	.2286	.1905	.2286	.2477	.2286
23	.2286	.5335	.5556		.5624	.2286	.2096
24	.1905	.2096	.6405	.6173	.664	.6173	.2286
Max	1.6518	1.5844	1.7124	1.8947	2.1548	2.0165	1.9433
Min	.0953	.1334	.0762	.0762	.0572	.0572	.1143
Avg	.6150	.5969	.4616	.5078	.4410	.4837	.6595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184082 / OTUR

Feeder No / Name : 202 / MULANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.4917	.724	.6859	.743	.724	.5144
2	.5765	.4917	.724	.6859	.743	.724	.5144
3	.57	.5087	.743	.724	.7621	.7621	.5316
4	.5801	.5197	.8192	.7621	.8002	.7621	.5426
5	.5898	.547	.8764	.8002	.8573	.8002	.5596
6	.6062	.6133	.8573	.8954	.8192	.8573	.6783
7	.8951	.9175	.5906	.6668	.5906	.7049	.8259
8	1.1279	.9922	.4191	.4572	.4382	.4954	.8583
9	.2858	.3048	.3239	.3239	.3048	.3048	.4001
10	.2667	.3048	.2858	.2477	.2096	.2286	.2667
11	.2477	.2477	.4801	.4801	.5407	.2401	.2096
12	.2286	.2477	.6687	.6882	.6097	.6009	.2477
13	.2286	.2477	.6097	.6226	.5498		.1143
14	.2286	.2477	.5792	.4961	.5335	.4572	.2477
15	.2286	.2477	.5556	.4961	.4877	.4268	.2667
16	.2667	.2667	.5937	.6722	.6173	.503	.2286
17	.2667	.3048	.8333	.7701	.7407	.8192	.2858
18	.3429	.362	.7316	.8322	.4572	.8356	.3239
19	.5906	.7049	.4382	.5525	.6668	.6097	.6478
20	.8764	.8954	.5335	.8192	.724	.8764	.7621
21	.8002	.7621	.743	.743	.7621	.6287	.724
22	.8002	.7811	.7621	.7621	.8002	.7811	.743
23	.3978	.7621	.7621		.7621	.4024	.4801
24	.5487	.4862	.743	.724	.724	.724	.5087
Max	1.1279	.9922	.8764	.8954	.8573	.8764	.8583
Min	.2286	.2477	.2858	.2477	.2096	.2286	.1143
Avg	.5056	.5106	.6415	.6482	.6352	.6204	.4784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184082 / OTUR

Feeder No / Name : 203 / KUNDANE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2477	.2096	.1905	.1905	.1905	.2286
2	.1905	.2477	.2096	.1905	.1905	.1905	.2286
3	.2286	.2477	.2286	.2286	.2096	.2286	.2477
4	.2286	.2667	.2667	.2667	.2096	.2286	.2667
5	.2667	.2667	.2858	.3048	.2286	.2667	.2858
6	.3239	.3048	.3429	.2858	.2858	.3239	.2858
7	.3048	.2667	.3048	.2477	.2477	.2858	.2286
8	.2096	.1905	.2286	.2096	.1905	.2096	.2286
9	.2286	.2096	.2667	.2096	.2096	.2667	.2286
10	.2096	.2286	.2667	.1715	.2096	.2286	.2286
11	.2286	.2126	.2286	.1905	.2286	.2477	.2286
12	.1715	.2126	.3048	.1524	.2286	.2096	.1905
13	.1524	.1433	.3239	.1715	.2286		.1715
14	.1715	.1791	.2858	.1715	.2286	.1524	.1715
15	.1715	.1772	.2858	.1715	.2477	.1524	.1905
16	.1524	.1928	.2858	.1905	.2477	.1524	.2286
17	.1715	.1966	.3239	.2667	.2477	.2286	.1715
18	.2286	.1966	.3429	.2667	.2858	.2286	.2286
19	.2477	.2515	.362	.2667	.3048	.3429	.2667
20	.2858	.2572	.3429	.3048	.2858	.3429	.3239
21	.2477	.2427	.3239	.2858	.2858	.2858	.2667
22	.2667	.2454	.2667	.2667	.2667	.2858	.2477
23	.2667	.2477	.2096		.2477	.2286	.2286
24	.2286	.2477	.2286	.1905	.1905	.2286	.2286
Max	.3239	.3048	.362	.3048	.3048	.3429	.3239
Min	.1524	.1433	.2096	.1524	.1905	.1524	.1715
Avg	.2239	.2283	.2802	.2261	.2374	.2394	.2334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184082 / OTUR

Feeder No / Name : 204 / KUNDANE Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.6964	.6173	.6802	.6173	.1905
2	.1905	.2286	.7125	.6481	.7125	.6249	.1905
3	.1905	.2286	.7287	.6874	.7373	.6722	.2096
4	.2096	.2477	.7701	.7499	.7701	.7362	.2286
5	.2286	.2477	.7701	.8223	.9339	.8097	.2286
6	.2477	.2477	.8907	1.0562	.9339	.9393	.2286
7	.2858	.2477	1.1683	1.2146	1.2289	1.186	.1715
8	.2096	.1905	1.2651	1.3927	1.2763	1.1683	.1524
9	.1334	.1334	.0953	.0762	.0762	.0572	.9907
10	.0953	.0762	.0572	.0762	.0572	.0572	.0762
11	.7202	.6964	.0572	.0572	.0572	.0572	.6642
12	1.004	1.065	.0953	.0762	.0572	.0762	1.0242
13	.9282	.9831	.0572	.0762	.0572	.0762	.9393
14	.8482	.8619	.0572	.0762	.0572	.0572	.8745
15	.8322	.7676	.0572	.0762	.0762	.0572	.8356
16	.8962	.8749	.0572	.0953	.0762	.0572	.9175
17	1.0082	.8592	.0572	.0953	.0762	.0572	1.0082
18	1.0402	.9031	.1905	.0953	.1143	.0572	1.0159
19	.1715	.1524	.1905	.1524	.1905	.1715	.1334
20	.2096	.2096	.2096	.2286	.1905	.2096	.2286
21	.2286	.1905	.2096	.1905	.1905	.2096	.2096
22	.2477	.1905	.1905	.1905	.1524	.2286	.1905
23	.2477	.6081	.6173		.5937	.2096	.2096
24	.1905	.2286	.6802	.6173	.6802	.6173	.1905
Max	1.0402	1.065	1.2651	1.3927	1.2763	1.186	1.0242
Min	.0953	.0762	.0572	.0572	.0572	.0572	.0762
Avg	.4398	.4445	.4117	.4073	.4157	.3754	.4629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184082 / OTUR

Feeder No / Name : 205 / Mehadar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8085	.7327	.6005	.5411	.6249	.5395	.6371
2	.8501	.7335	.6036	.5456	.6455	.5494	.6402
3	.8779	.7632	.6218	.5868	.6554	.5929	.6596
4	.8794	.7785	.647	.6203	.6851	.6836	.6935
5	.9198	.8168	.6585	.682	.6919	.73	.7227
6	.9534	.9793	.6905	.6287	.6908	.7484	.8839
7	1.3815	1.4964	.6478	.5327	2.202	.5975	1.3923
8	1.5196	1.4906	.4969	.4969	.4552	.5365	1.4161
9	.8612	.9321	.301	.3795	.4291	.4199	.8329
10	.3582	.3514	.2614	.3231	.3231	.3475	.2721
11	.2378	.2691	.8795	.9496	.7773	.7758	.2423
12	.1669	.2553	1.0935	1.0658	1.0745	1.03	.1982
13	.2066	.2096	1.0592	1.006	1.0212	1.0079	.2005
14	.1959	.2523	1.031	.8905	.9336	.8908	.2081
15	.2028	.2553	1.1012	.8406	.9129	.8231	.2454
16	.2347	.2127	1.2936	1.0307	1.0475	1.0136	.2378
17	.25	.2698	1.4076	1.0877	1.1936	1.1843	.3147
18	.3765	.3672	1.2048	1.0983	1.1325	1.2879	.3902
19	.5929	.5365	.961	.8292	.8764	.9587	.586
20	.6188	.6455	.586	.6942	.6736	.6927	.6577
21	.6226	.6409	.6104	.6355	.6585	.5929	.6226
22	.6645	.6386	.6622	.6219	.6759	.66	.6211
23	.6943	.647	.6348	.3437	.6638	.5609	.6928
24	.8444	.6068	.6409	.5784	.6195	.6424	.655
Max	1.5196	1.4964	1.4076	1.0983	2.202	1.2879	1.4161
Min	.1669	.2096	.2614	.3231	.3231	.3475	.1982
Avg	.6383	.6200	.7789	.7087	.8193	.7444	.5843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184095 / CHANKAPUR

Feeder No / Name : 201 / JAMSHET

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3959	.1261	.1318	.1219	.1353	.2915	.3852
2	.378	.1307	.1303	.1292	.1345	.3197	.3761
3	.3547	.1398	.1299	.1318	.1383	.3151	.3509
4	.325	.1429	.1395	.144	.1395	.3117	.3395
5	.3121	.1623	.157	.1631	.1646	.3285	.3422
6	.3528	.1886	.181	.1779	.1928	.3612	.4115
7	.5674	.1273	.1696	.1692	.1806	.4874	.5708
8	1.7105	.1814	.2572	.2271	.2298	1.5368	1.5554
9	.612	.0537	.0834	.0895	.0846	.5037	.5818
10	.0648	.0412	.0556	.064	.0564	.0636	.0682
11	.0118		.0179	.0469	.0427	.0499	.0453
12	.1029	2.0333	.6489	.6348	.6554	.0507	.0469
13	.04	.6843	.6786	.6241	.538	.0419	.0511
14	.0427	.6104	.5937	.3079	.5342	.045	.0492
15	.0457	.5011	.5049	.5049	.4462	.0564	.0514
16	.1071	1.3633	.471	1.2765	1.4411	.1166	.1368
17	.0457	.5064	.4927	.5068	.5373	.0461	.0495
18	.0568	.5525	.4824	.4645	.5323	.0591	.069
19	.0793	.5647	.5034	.487	.5022	.0937	.1059
20	.1585	.1879	.1425	.1612	.1684	.1642	.1555
21	.1482	.1524	.1345	.1494	.1612	.1631	.1703
22	.1463	.152	.1467	.1494	.1558	.1772	.1642
23	.1437	.1456	.1437	.1536	.1471	.1696	.157
24	.8726	.3582	.3655	.1372	.3631	.6626	.8943
Max	1.7105	2.0333	.6786	1.2765	1.4411	1.5368	1.5554
Min	.0118	.0412	.0179	.0469	.0427	.0419	.0453
Avg	.2948	.3959	.2817	.2926	.3201	.2673	.297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184095 / CHANKAPUR

Feeder No / Name : 202 / DESGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4207	2.3137	2.4006	2.1033	2.8045	.3681	.4207
12	2.5065	.0876					
16	2.0919	.1402		.0876	.1578	2.6642	2.1033
24	.5144	.4733	1.5424		1.4723	.5959	.4908
Max	2.5065	2.3137	2.4006	2.1033	2.8045	2.6642	2.1033
Min	.4207	.0876	1.5424	.0876	.1578	.3681	.4207
Avg	1.3834	.7537	1.9715	1.0955	1.4782	1.2094	1.0049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184095 / CHANKAPUR

Feeder No / Name : 203 / BORDAIVAT SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.4294	.3086	.1372	.1402	.1928	2.6467	3.0849
12	.1372	3.0178					
16	.1543	2.8807		2.5591	2.7519	.1402	.1578
24		.4115	.4458		.3856	.9114	1.6476
Max	3.4294	3.0178	.4458	2.5591	2.7519	2.6467	3.0849
Min	.1372	.3086	.1372	.1402	.1928	.1402	.1578
Avg	1.2403	1.6547	.2915	1.3497	1.1101	1.2328	1.6301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184095 / CHANKAPUR

Feeder No / Name : 204 / MOHPADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3429	1.4575	1.6289	1.406	1.4373	.2743	.3086
12	1.7661	.0857					
16	1.3203	.1372		.1372	.12	1.5261	1.2689
24	.2401	.3258			.6859	.2572	.2401
Max	1.7661	1.4575	1.6289	1.406	1.4373	1.5261	1.2689
Min	.2401	.0857	1.6289	.1372	.12	.2572	.2401
Avg	.9174	.5016	1.6289	.7716	.7477	.6859	.6059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184097 / JAIDAR

Feeder No / Name : 201 / JAIDAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4287		.2286	.1715
2			.4287		.2286	.1715
3			.5144		.2286	
4			.6859		.2286	.1715
5			.7716		.2743	
6			.8402		.2439	.1715
7		1.0288	1.166			.1715
8		.8573	1.0288	.1715	.1372	.1715
9		.0857	.0857	.5144	.3048	.5144
10		.061	.0857		1.1145	1.0288
11		.0457	.0857	2.4006	1.2003	.9431
12		.061	.0857	2.1605		.7716
13		.061	.0857	1.6461	.8573	.7716
14		.061	.0857	1.6461		.0772
15		.0457	.0857	1.5947	.6859	.7716
16	2.0576	.0457	.0857	1.749		.8573
17	.0857	.0762	.0857	.0762	.0857	.0857
18		.5639	.0857	.0762		.2572
19	.2572	.1524	.2058	.1829	.2572	.3429
20		.2134		.2134		.2572
21	.2572	.2134	.2572	.2439	.2572	.2572
22	.2572	.2134	.1715	.2439		.1715
23	.2572	.0394		.2439		
24		.1715	.4287		.2572	.1715
Max	2.0576	1.0288	1.166	2.4006	1.2003	1.0288
Min	.0857	.0394	.0857	.0762	.0857	.0772
Avg	.5287	.2220	.3538	.8776	.4119	.3956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184097 / JAIDAR

Feeder No / Name : 202 / VARKHEDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8383		1.5947	1.4575
2			.9431		1.5947	1.5432
3			.8383		1.7147	1.8004
4			.7773		1.7147	1.9719
5			.7926		1.7528	
6			.8078		2.8292	2.0576
7		.6859	.5639			3.0864
8		.6859	.5639	1.8861	2.572	2.7435
9		.6859	.5144			.4287
10		.442	.5144			.4287
11		1.1831	.8573	.442	.4287	.4287
12		3.155	3.0007	.442		.4287
13		1.869	2.7435	.442	.5144	.4287
14		2.1491	2.7435	.4973		.4287
15		2.21	2.6578	.442	.5144	.4287
16	.6001	2.5549	2.572	.442		.4287
17	.6001	2.692	2.4863	.442	.6001	.5144
18		2.7435	2.572	.442		.7716
19	.8573	.6859	.6859	.6097	1.0288	.9431
20		.6859		.6401		.9431
21	1.0288	.6859	1.0288	.6859	1.0288	.9431
22	1.0288	.6859	.9431	.8078		.6859
23	1.3717	.6097	.8573	.6344		
24		.8573			1.0288	1.4575
Max	1.3717	3.155	3.0007	1.8861	2.8292	3.0864
Min	.6001	.442	.5144	.442	.4287	.4287
Avg	.9145	1.4037	1.3774	.6325	1.3512	1.1068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184097 / JAIDAR

Feeder No / Name : 203 / PUNAD NAGAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0288		.0884	.8573
2			1.0288		.884	.8573
3			1.2003		.9145	.8573
4			1.3717		.9145	.9431
5			1.7147		.9907	
6			1.9204		.9145	.6001
7		2.4006	2.7263			.5144
8		2.2291	2.2805	.5144	.5944	.5144
9		.5144	.583	.6859	.5487	.8573
10		.4268	.5487	1.7833	2.915	2.6578
11		.3658	.5144	1.7147	2.7435	2.4006
12		.381	.5144	1.4403		2.0576
13		.4115	.5144	1.0288	2.0576	2.1434
14		.4115	.5144	1.0288		2.6578
15				1.1317	1.5432	2.572
16	1.5432	.442	.5144	1.286		2.7435
17	.5144	.503	.5144	.4572	.6859	.5144
18			.6001	.5487		.7716
19	.8573	.8383	.9431	.8535	1.0288	.9431
20		.9297		.9907		1.0288
21	1.0288		1.0288	1.0059	1.0288	1.0288
22	1.0288	.9755	.9431	1.0212		.9431
23	.8573	.9088	.6001	.9755		
24		.6859			.8573	.8573
Max	1.5432	2.4006	2.7263	1.7833	2.915	2.7435
Min	.5144	.3658	.5144	.4572	.0884	.5144
Avg	.9716	.8283	1.0288	1.0292	1.1694	1.3328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261] BU 0418

Substation No/ Name :- 184097 / JAIDAR

Feeder No / Name : 204 / EXP.PUNADNAGAR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	10-APR-17
HR	Load (MW)
15	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184241 / 33/11 KV Pale

Feeder No / Name : 201 / PALE 1 PH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.2286	.3048	.3048	.4572	.4572
2	.4572	.4572	.2286	.3048	.3048	.4572	.4572
3	.4572	.4572	.3048	.3048	.3048	.4572	.4572
4	.5335	.5335	.3048	.3048	.3048	.5335	.5335
5	.6097	.5335	.3048	.3048	.381	.6097	.6097
6	.6097	.6097	.381	.381	.381	.6097	.6097
7	.6097	.6097	.381	.381	.381	.6097	.6097
8	.4572	.5335	.3048	.381	.3048	.5335	.5335
9	.381	.4572	.3048	.3048	.3048	.381	.381
10	.3048	.3048	.2286	.3048	.2286	.2286	.2286
11	.2286	.2286	.2286	.1524	.1524	.1524	.2286
12	.2286	.2286	.1524	.1524	.1524	.3048	.2286
13	.2286	.2286	.1524	.1524	.1524	.3048	.3048
14	.2286	.3048	.1524	.1524	.1524	.3048	.2286
15	.2286	.2286	.1524	.1524	.1524	.3048	.3048
16	.2286	.2286	.1524	.1524	.1524	.3048	.3048
17	.3048	.3048	.1524	.1524	.1524	.2286	.2286
18	.3048	.3048	.2286	.1524	.2286	.3048	.2286
19	.3048	.3048	.381	.381	.381	.3048	.3048
20	.5335	.5335	.5335	.5335	.6097	.5335	.5335
21	.4572	.5335	.4572	.4572	.5335	.4572	.4572
22	.4572	.4572	.4572	.4572	.4572	.4572	.4572
23	.4572	.4572	.4572	.4572	.4572	.4572	.4572
24	.4572	.4572	.3048	.3048	.3048	.4572	.4572
Max	.6097	.6097	.5335	.5335	.6097	.6097	.6097
Min	.2286	.2286	.1524	.1524	.1524	.1524	.2286
Avg	.3969	.4064	.2889	.2953	.3016	.4064	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184241 / 33/11 KV Pale

Feeder No / Name : 202 / PALE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2286	.9907	1.0669	1.0669	.2286	.2286
2	.1524	.2286	.9907	1.0669	1.0669	.2286	.2286
3	.1524	.2286	.9907	1.0669	1.0669	.2286	.2286
4	.2286	.2286	1.0669	1.0669	1.1431	.2286	.2286
5	.2286	.3048	1.0669	1.0669	1.1431	.2286	.2286
6	.3048	.3048	1.1431	1.1431	1.1431	.3048	.3048
7	.3048	.3048	1.3717	1.448	1.448	.3048	.3048
8	.2286	.3048	1.829	1.7528	1.6766	.2286	.2286
9	.1524	.2286	1.6766	1.6766	1.6766	.2286	.2286
10	.1524	.1524	.2286	.1524	.1524	.1524	.1524
11		.0762	.0762	.0762	.1524	.1524	.0762
12	1.1431	1.6766	.0762	.0762	.0762	1.829	1.6766
13	1.829	1.6766		.0762	.0762	1.829	1.6766
14	1.829	1.6004		.0762	.0762	1.6766	1.6004
15	1.6766	1.5242	.0762	.0762	.0762	1.5242	1.5242
16	1.6766	1.448	.0762	.0762	.0762	1.5242	1.5242
17	1.6766	1.6004	.0762	.0762	.0762	1.5242	1.5242
18	1.6766	1.5242	.0762	.0762	.0762	1.5242	1.5242
19	1.6004	1.5242	.1524	.1524	.1524	1.5242	1.5242
20	.2286	.3048	.2286	.2286	.3048	.2286	.2286
21	.2286	.3048	.2286	.2286	.2286	.2286	.2286
22	.2286	.2286	.2286	.2286	.2286	.2286	.2286
23	.2286	.2286	.2286	.2286	.2286	.2286	.2286
24	.2286	.2286	.9907	1.0669	.9907	.2286	.2286
Max	1.829	1.6766	1.829	1.7528	1.6766	1.829	1.6766
Min	.1524	.0762	.0762	.0762	.0762	.1524	.0762
Avg	.7091	.6859	.6304	.5938	.6001	.6922	.6732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184241 / 33/11 KV Pale

Feeder No / Name : 203 / Wadi 1 Ph

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5335	.1524	.0762	.1524	.4572	.6097
2	.5335	.5335	.1524	.1524	.1524	.4572	.6097
3	.6097	.6097	.1524	.1524	.1524	.5335	.6097
4	.6097	.6097	.1524	.1524	.1524	.5335	.6097
5	.6859	.6097	.1524	.1524	.2286	.5335	.6097
6	.6859	.6859	.1524	.1524	.2286	.6097	.6859
7	.9907	1.0669	.1524	.1524	.2286	.9145	.9907
8	1.2193	1.1431	.0762	.0762	.1524	1.1431	1.2193
9	1.2193	1.1431	.0762	.0762	.0762	1.1431	1.2193
10	.2286	.1524		.0762		.2286	.1524
12			1.2193	1.2193	1.1431		
13			1.1431	1.2193	1.2193		
14			1.2193	1.1431	1.1431		
15			1.2955	1.1431	1.0669		
16			1.2193	1.1431	1.0669		
17			1.2955	1.1431	1.0669		
18			1.2955	1.1431	1.0669		
19	.0762	.0762	1.2193	1.1431	1.0669	.0762	.0762
20	.1524	.1524	.2286	.2286	.2286	.1524	.1524
21	.0762	.1524	.1524	.1524	.1524	.1524	.1524
22	.1524	.1524	.1524	.1524	.1524	.1524	.1524
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.5335	.381	.1524	.1524	.1524	.6097	.5335
Max	1.2193	1.1431	1.2955	1.2193	1.2193	1.1431	1.2193
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.5287	.5096	.5438	.4937	.5092	.4906	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

KALWAN DIVISION[606]

KALWAN S/DIV[261]

BU 0418

Substation No/ Name :- 184242 / 33/11 kv Bej

Feeder No / Name : 203 / VISAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7232	.7232	.5693	.5617	.5327	.7362	.8566
2	.7453	.7461	.5533	.5601	.5487	.7346	.8993
3	.7697	.7438	.5784	.5609	.5571	.7522	.9366
4	.8619	.8147	.6333	.6081	.6249	.8124	.9777
5	1.012	.9686	.7461	.6935	.7026	.9496	1.0997
6	1.4426	1.403	.8627	.8855	.868	1.3176	1.5036
7	2.2451	2.0858	.9054	.8947	.9099	2.037	2.38
8	2.4737	2.4501	.7697	.7263	.7834	2.3213	2.6444
9	2.3434	2.3785	.5487	.5517	.5601	2.2291	2.4158
10	.4481	.4108	.4169	.4009	.4412	.3849	.3772
11	.269	.2835	.2782	.4999	.3612	.266	.3102
12	.1959	.1768	2.1948	2.1216	1.9334	.1974	.2393
13	.2058	.1806	2.1453	2.1308	1.9776	.1837	.2187
14	.2195	.202	2.0401	1.9982	1.8077	.205	.2248
15	.237	.2202	1.6392	1.7513	1.5958	.2271	.2134
16	.2187	.2271	1.7276	1.7787	1.6027	.2218	.2241
17	.2561	.2484	1.9441	2.0104	1.8061	.2446	.2462
18	.2896	.2972	1.9517	2.0767	1.845	.3147	.3285
19	.3688	.5335	1.7635	1.9578	1.7734	.567	.5495
20	.833	.7217	.7522	.743	.823	.7758	.7232
21	.6661	.6706	.6577	.6539	.7407	.6828	.6348
22	.6203	.6562	.6455	.6478	.6645	.6501	.6333
23	.618	.6325	.6295	.6257	.618	.6196	.6036
24	.6737	.5799	.5609	.5479	.6409	.8162	.8162
Max	2.4737	2.4501	2.1948	2.1308	1.9776	2.3213	2.6444
Min	.1959	.1768	.2782	.4009	.3612	.1837	.2134
Avg	.7807	.7648	1.0631	1.0828	1.0299	.7603	.8357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184023 / GOLDENNAGAR

Feeder No / Name : 201 / AGRA ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	4.6776	4.6197	4.9303	4.7843	2.5453	4.7035
2	.8573	4.7066	4.5161	4.901	4.5557	2.4249	4.481
3	.8573	4.4902	4.385	6.8786	4.449	2.4554	4.4658
4	.8573	4.4246	4.3682	4.5379	4.3164	2.3624	4.449
5	.9431	4.3118	4.196	4.388	4.1793	2.303	4.1366
6	.9431	4.1183	4.1625	4.449	4.2235	2.3061	4.1518
7	1.0288	4.164	4.2981	4.2844	4.353	2.3807	3.9552
8	1.6289	4.545	4.6913	4.4521	4.6944	2.4661	4.3454
9	2.3148	5.2111	5.2598	5.1196	2.6658	2.7892	4.5435
10		3.0041	2.966	3.0072	2.239	2.998	2.5895
11	2.21	5.4733	2.931	5.3818	2.9858	2.9584	3.6519
12		3.152	5.5373	3.1474	3.1946	3.0468	1.7071
13		3.2266	3.1581	5.7857	3.1901	5.0861	1.2163
14	1.9814	2.8136	2.8868	2.899	2.8258	2.6749	.9724
15	1.9814	2.4646	4.0405	4.4719	2.399	4.2707	.7072
16	2.21	4.8514	4.6532	4.9367	4.7051	4.6852	1.4465
17	2.21	5.144	4.8438	5.1775	2.7907	4.9352	1.515
18	2.2862	5.3239	5.0358	5.4184	2.7221	5.1089	1.6114
19	2.4387	5.5114	5.3482	5.5785	2.9401	5.4245	1.8827
20	2.3624	5.487	5.3772	5.6227	2.9447	5.3834	1.9559
21	2.3624	5.3162	5.5194	5.4153	2.9553	5.1775	1.845
22	2.21	5.0571	5.2264	5.0785	2.8639	4.9154	2.0584
23	2.21	4.8925	5.1898	4.8346	2.7785	4.7447	2.074
24	.8573	4.6593	4.6746	5.1928	4.8316	2.6917	3.0605
Max	2.4387	5.5114	5.5373	6.8786	4.8316	5.4245	4.7035
Min	.8573	2.4646	2.8868	2.899	2.239	2.303	.7072
Avg	1.6956	4.4594	4.4952	4.8287	3.5245	3.5889	2.8136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184023 / GOLDENNAGAR

Feeder No / Name : 202 / OWADI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	4.1152	4.1152	4.7154	4.2676		4.1152
2	.8573	4.1152	4.039	4.4582			4.1152
3	.8573	4.1152	3.8866	4.4582	3.8104		4.1152
4	.8573	3.8104	3.8104	4.2867	3.658		4.1152
5	1.0288	3.8104	3.8104	4.1152	3.5056		3.8104
6	1.2003	4.0295	3.7342	4.1152	3.5818		3.5056
7	2.8292	3.658	3.8104	3.7342	3.8104		3.3532
8	2.8292	4.1152	4.2676	4.2676	4.1914		3.0483
9	4.6296	4.5725	4.542	4.4963	4.5725		3.2007
11	4.5725	4.5725		4.6487			1.829
12			4.8011				
13				4.8011		4.7249	
14	3.7342						
15	4.039		3.8104	3.9628		3.8866	
16	4.4963	4.4963	4.1914	4.4963	4.4201	4.4963	1.1145
17	4.4201	4.6487	4.3439	4.6487		4.8011	1.2003
18	4.4963	4.8011	4.5725	4.7706		4.4963	1.2003
19	4.5725	4.6944	4.4201	4.8011		4.4201	1.3717
20	4.5725	4.7249	4.9726	4.8011		4.4963	1.3375
21	4.5725	4.5725	5.0583	4.4963		4.542	1.286
22	4.2676	4.2676	4.6296	4.2676		4.3439	1.2517
23	4.1152	4.1914	4.6296	4.2676		4.0847	1.1317
24	4.5725	4.1152	4.2676	4.7154	4.2676		4.1152
Max	4.6296	4.8011	5.0583	4.8011	4.5725	4.8011	4.1152
Min	.8573	3.658	3.7342	3.7342	3.5056	3.8866	1.1145
Avg	3.2561	4.2856	4.2856	4.4440	4.0085	4.4292	2.5904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184023 / GOLDENNAGAR

Feeder No / Name : 203 / SARDAR NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6589	6.9559	6.7173	7.2531	6.7928	3.6088	7.2805
2	2.7298	6.853	6.5325	6.9468	6.6297	3.4831	6.9948
3	2.7355	6.8302	6.3573	6.7661	6.3961	3.4682	6.9502
4	2.8281	6.4117	6.323	6.5386	6.3211	3.4339	6.9285
5	2.8326	6.0517	6.1557	6.3066	6.2186	3.3916	6.5146
6	3.0259	6.214	6.1466	6.3524	6.19	3.3836	6.2151
7	3.1413	6.6106	6.6404	6.685	6.701	3.602	6.2837
8	4.3382	7.3525	7.0233	6.9277	6.8823	3.7391	6.4404
9	7.0622	7.6307	7.5557	7.5808	3.9689	4.0158	5.9004
10	3.7597	4.0924	4.0329	4.1427	4.0318	4.0398	3.3848
11	3.2769	8.0392	4.225	7.9969	4.1998	4.2055	4.7748
12		4.3839	8.208	4.4376	4.329	4.4627	2.4657
13		4.4422	4.473	7.9405	4.385	8.0914	2.0919
14	2.5911	3.9963	4.0215	4.0592	3.9518	4.0764	1.6758
15	2.6673	3.4785	6.3264	6.3199	3.3779	6.2685	1.5581
16	3.0483	6.973	7.0949	7.0458	6.8644	7.0618	2.6418
17	3.1245	7.1269	7.3777	7.4909	3.9335	7.3835	2.6543
18	3.858	7.5926	8.1093	7.7264	3.9963	7.7062	2.6326
19	3.9438	7.8944	7.9165	7.8967	4.2661	7.7885	2.8476
20	4.0295	7.9264	7.8045	7.8921	4.2135	7.8407	2.8075
21	4.0295	7.5103	8.1379	7.5972	4.1747	7.713	2.7195
22	3.2007	7.1486	7.8384	7.2664	3.9941	7.3179	2.7207
23	3.4294	6.8831	7.6726	7.0256	3.8489	7.0892	2.6943
24	1.2003	7.1343	6.9094	7.38	6.8636	3.7689	5.0388
Max	7.0622	8.0392	8.208	7.9969	6.8823	8.0914	7.2805
Min	1.2003	3.4785	4.0215	4.0592	3.3779	3.3836	1.5581
Avg	3.3414	6.4805	6.6500	6.8156	5.1055	5.2892	4.2590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184023 / GOLDENNAGAR

Feeder No / Name : 204 / AZAD NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4381	5.1456	4.0314	4.3641	3.9506	1.3199	5.4062
2	3.6179	5.2706	4.0344	4.2845	3.8774	1.3352	5.2073
3	3.8069	5.4062	3.879	4.3027	3.7296	1.4784	5.2164
4	3.8081	5.1928	3.9262	4.209	3.7692	1.5577	5.3063
5	3.9148	5.4001	3.8165	4.1487	3.6626	1.6644	4.9047
6	4.1769	5.8345	3.9293	4.2478	3.7906	2.1201	4.7394
7	5.7114	7.1529	3.9842	4.0832	4.0405	3.3806	6.3626
8	7.0847	8.7128	4.0801	3.9597	4.0299	4.2128	7.1765
9	8.565	8.6298	4.5801	4.571	.6798	4.2494	6.7612
10	1.7467	.5609	.9343	.7499	.4313	.7667	1.1218
11	4.2326	4.4079	.4664	4.3835	.317	.096	2.4478
12	.5502	.5929	7.7564	1.6613	2.8883	.3399	.3536
13	.5167	.6356	4.2753	7.2855	3.3501	4.2722	.4405
14	3.4537	.6554	4.2234	3.2968	3.2526	.3826	.506
15	3.4598	.695	6.9761	6.1332	2.6993	3.1504	.5411
16	3.9171	4.1915	7.3755	6.8709	6.592	3.716	1.9097
17	4.2219	4.2387	7.3114	6.9731	3.7601	4.1473	2.1986
18	4.6148	4.5268	7.569	6.8892	3.7967	4.2341	2.391
19	4.7371	4.5039	6.7825	7.0035	3.5239	4.3561	2.5576
20	5.1349	4.8575	4.3637	4.5999	.8703	4.6457	2.7065
21	5.0526	4.4506	4.6456	4.3165	.8764	4.5557	2.6394
22	4.5557	4.2996	4.4574	4.1106	.7956	4.3226	2.4382
23	4.1793	4.0405	4.5077	4.0512	.7346	3.9872	2.3879
24	3.1302	4.3972	3.9201	4.7173	4.3484	1.5516	5.0366
Max	8.565	8.7128	7.7564	7.2855	6.592	4.6457	7.1765
Min	.5167	.5609	.4664	.7499	.317	.096	.3536
Avg	4.0678	4.3250	4.6594	4.6339	2.9070	2.7434	3.3649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184023 / GOLDENNAGAR

Feeder No / Name : 205 / MILLAT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8433	4.7874	4.4795	4.9257	4.5588	2.6216	4.6456
2	.7549	4.7203	4.3439	4.7501	4.513	2.588	4.5222
3	.7351	4.7508	4.3591	4.7028	4.3713	2.5347	4.4383
4	.7351	4.5557	4.225	4.5008	4.4018	2.5164	4.4277
5	.8208	4.4566	4.0954	4.417	4.2326	2.5149	4.1914
6	.9938	4.3728	4.0543	4.4124	4.3286	2.4478	4.2052
7	.4603	4.4307	4.1686	4.3256	4.4459	2.5149	3.9705
8	3.0723	4.5389	4.1945	4.4795	4.4917	2.5118	3.8821
9	4.7257	4.9657	4.4338	4.3621	4.6624	2.6581	3.9781
10	2.6063	2.7572	2.4813	2.4448	2.6246	2.6155	2.2207
11	4.8346	5.0373	2.5835	4.4917		2.7755	2.082
12	2.8106	2.8487	4.7127	2.6078		2.809	1.5089
13	2.6719	2.8608	2.5027	4.6395		4.9322	.6523
14	4.0878	2.6124	2.399	2.5042		2.5072	.4283
15	3.7723	2.3167	3.7738	3.9461		4.1747	.3262
16	4.1518	4.4002	4.2661	4.4566		4.5862	1.2479
17	4.795	4.6258	3.7265	4.6166		4.798	1.3637
18	4.9443	4.9078	4.9291	4.6532		4.6974	1.5204
19	5.1272	4.9489	4.7599	4.6898		4.8529	1.6175
20	5.1166	4.9992	4.8316	5.0251		4.984	1.5829
21	5.0769	4.2738	4.9943	4.8925		4.9382	1.5661
22	4.9535	4.6883	4.8781	4.8072		4.8194	1.5265
23	4.7737	4.5069	4.8019	4.6989		4.6395	1.5082
24	4.8422	4.6212	4.577	4.9196		2.652	2.7419
Max	5.1272	5.0373	4.9943	5.0251	4.6624	4.984	4.6456
Min	.4603	2.3167	2.399	2.4448	2.6246	2.4478	.3262
Avg	3.2378	4.2493	4.1072	4.3446	4.2631	3.4871	2.5064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184047 / AZADNAGAR

Feeder No / Name : 201 / RAUNAKABAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.546		4.6677	
16		3.5117		2.2497
17				2.4421
18				2.7073
19				3.0178
20				2.7721
21				2.4691
22				2.2862
23				2.1948
24	1.9589			
Max	3.546	3.5117	4.6677	3.0178
Min	1.9589	3.5117	4.6677	2.1948
Avg	2.7525	3.5117	4.6677	2.5174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184047 / AZADNAGAR

Feeder No / Name : 204 / CHANDANPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.963		3.6408	
16		3.1121		1.8042
17				1.7928
18				1.9204
19				2.3529
20				2.3777
21				1.9204
22				1.9004
23				1.7194
Max	2.963	3.1121	3.6408	2.3777
Min	2.963	3.1121	3.6408	1.7194
Avg	2.963	3.1121	3.6408	1.9735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184047 / AZADNAGAR

Feeder No / Name : 205 / DATAR NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.9973		4.1495	
16		3.7912		1.4695
17				1.6385
18				1.989
19				2.1434
20				2.2043
21				1.7147
22				1.7804
23				1.7604
Max	2.9973	3.7912	4.1495	2.2043
Min	2.9973	3.7912	4.1495	1.4695
Avg	2.9973	3.7912	4.1495	1.8375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184092 / KILLA

Feeder No / Name : 201 / HAKIM NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4232	3.275	2.9874	2.9874	3.275		3.3128
2	1.406	3.2407	2.9111	2.9416	3.0864		3.155
3	1.3889	3.0864	2.8959	2.8959	2.9165		3.0178
4	1.3717	2.915	2.8349	2.774	2.8334		2.6406
5	1.0631	2.7778	2.713	2.5911	2.652		2.5377
6	1.1317	2.6235	2.7435	2.6216	2.7161		2.7263
7	1.2003	2.6406	2.774	2.652	2.7978		2.822
8	2.4691	3.8237	3.3227	3.216	3.4979		3.3385
9	3.8409	4.1076	3.8256	3.8256			3.3265
10	3.6923	3.8704	4.0306	4.0278			3.1131
11	3.6374	3.7129	3.8996	4.1107			
12	4.0143		4.2105	4.5085	4.4075		1.9342
13	3.834	4.4597	4.2273	4.177	4.1289	4.1747	1.3756
14	2.4352	2.9172	2.7639	2.7846		2.7496	
15	3.0203	3.103	2.8182	3.0333	2.9172	2.8841	
16	3.3366	3.7813	3.621	3.5951	3.5543	3.5391	1.3032
17	3.4572	3.6866	3.7849	3.858		3.7849	
18	3.6866	3.5208	3.597	3.8923		3.866	1.6118
19	3.9095	3.6123	3.6732	3.9438		4.1495	1.6975
20	3.8321	3.658	3.5665	4.0124			1.5604
21	3.4082	3.8237	3.4751	3.5837			1.3889
22	3.2579	3.1398	3.2007	3.219			1.4403
23	3.2922	2.9416	3.0026	3.2526		2.2462	1.5261
24	1.4575	3.3265	3.0483	3.0636	3.3234		3.0361
Max	4.0143	4.4597	4.2273	4.5085	4.4075	4.1747	3.3385
Min	1.0631	2.6235	2.713	2.5911	2.652	2.2462	1.3032
Avg	2.7319	3.3932	3.3303	3.3987	3.2390	3.4243	2.3432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184092 / KILLA

Feeder No / Name : 202 / RASALPURA-I OLD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1931	4.8438	5.0331	4.6533	5.0161	2.7313	4.8853
2	3.0079	4.7196	4.8662	4.4993	4.9391	2.6185	4.7249
3	2.9024	4.5999	4.7618	4.4185	4.7721	2.5469	4.614
4	2.7828	4.4635	4.6937	4.3012	4.7575	2.4585	4.5004
5	2.7103	4.2867	4.5987	4.2189	4.7226	2.4341	4.5176
6	3.1131	4.2897	4.8552	4.6609	4.7527	2.4021	4.5968
7	3.9917	4.419	5.5514	5.484	5.2555	2.6566	5.0115
8	2.2462	5.6142	6.1725	5.6394	6.0772	2.934	5.8516
9	2.5549	6.3897	6.5577	6.0753	3.408	3.3486	6.1919
10	2.8807	6.549	6.4468	6.6835	3.4995	3.4004	6.2357
11	2.934	6.592	6.6583	7.0887	3.472	3.4659	2.3899
12	3.0178	7.0889	7.2543	7.3434	6.7646	3.7967	5.6676
13	3.0333	6.9575	7.0149	7.1296	6.9326	7.1826	4.3065
14	2.3537	5.7949	5.7278	5.8084	3.2754	5.8501	2.2451
15	2.1879	4.9063	4.8537	4.6538	5.0708	4.8103	1.797
16	2.6235	5.6669	5.7093	5.5649	5.7857	5.5983	3.3284
17	2.8147	6.0012	6.02	5.8696	3.1596	5.9251	3.5452
18	2.6621	5.8588	6.2685	5.8943	3.312	6.0555	3.8515
19	3.0521	6.3161	6.6122	6.6491	3.6214	6.5508	4.2963
20	3.155	6.4213	6.4997	6.973	3.7052	3.4888	4.2851
21	2.7469	6.55	6.2631	6.5063	3.6397	2.3533	4.0375
22	2.572	6.001	5.7564	5.8147	3.2419		3.8363
23	2.4177	5.5026	5.3338	5.4816	2.9995	4.0996	3.7441
24	1.5261	5.1665	5.1746	5.1604	5.3078	2.7191	4.1354
Max	3.9917	7.0889	7.2543	7.3434	6.9326	7.1826	6.2357
Min	1.5261	4.2867	4.5987	4.2189	2.9995	2.3533	1.797
Avg	2.7700	5.6250	5.7785	5.6905	4.4787	3.8881	4.2748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184092 / KILLA

Feeder No / Name : 205 / SANAULLA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	1.6741	1.5851	1.6004	1.7072		1.6741
2	.8059	1.6409	1.5546	1.5546	1.6244		1.6575
3	.7888	1.4918	1.5394	1.5242	1.5249		1.6409
4	.7716	1.4586	1.4937	1.4632	1.4752		1.6244
5	.7202	1.3757	1.4632	1.4022	1.4089		1.5912
6	.7545	1.3923	1.5546	1.4327	1.4255		1.5339
7	.823	1.3923	1.6004	1.4784	1.442		1.6244
8	1.5604	2.1714	1.9509	1.9814	1.989		1.8564
9	2.4177	2.2939	2.1948	2.2405			1.989
10	2.0891	2.1605	2.13	2.3868			2.0058
11	2.0645	2.2119	2.2119	2.2874			
12	2.3758	2.2283		.7459			1.0208
13	2.2447		2.5069	2.4646	2.4646	2.4478	.905
14		1.7436	1.8143	1.9281		1.8778	
15	1.6762	1.8482	1.6385	1.7736	1.6766	1.6409	
16	2.0222	1.9784	1.9334		1.9951	1.8515	.8589
17	1.9826	2.0178	1.9662	2.1714		2.0481	.8326
18	2.1136	1.9204	1.9509	2.2542		2.1382	.9088
19	2.0719	2.0729	2.0576	2.1879		2.1216	.9945
20	2.1548	2.0881	1.9509	2.1714			.9259
21	1.9559	1.829	1.8442	1.8067			.8745
22	1.6741	1.989	1.768	1.5912			.8745
23	1.7238	1.7223	1.6613	1.6741		1.6078	.8573
24	.8573	1.757	1.5699	1.6309	1.757		1.6575
Max	2.4177	2.2939	2.5069	2.4646	2.4646	2.4478	2.0058
Min	.7202	1.3757	1.4632	.7459	1.4089	1.6078	.8326
Avg	1.5865	1.8460	1.8235	1.8153	1.7075	1.9667	1.3289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184239 / JAFARNAGAR

Feeder No / Name : 201 / BISMILLAH BAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	3.8866		3.8104	3.658		3.7342
2	.7621	3.8104		3.8104	3.658		
3	.5335	3.7342		3.8104	3.658		
4	.4572	3.658		3.8104	3.658		
5	.4572	3.6123		3.7342	3.5818		
6	.7621	3.6111		.381	3.658		
7	1.2193	.3963		3.8866	4.1152		
8	2.4006	4.1114		3.4675	4.1914		3.4294
9	4.1049	4.1914	3.6675	4.1914	4.2676		3.6923
10		3.8676	3.8676	4.3439			3.4526
11	4.4056	3.9342	3.9342	4.4201			
12		3.9342	4.0009	4.4963	4.5931		1.3957
13		3.6008	3.7342	4.2676			
14		3.3341	3.4008				.4239
15		3.0674	3.0007				
16			3.7342		3.7746	4.2962	1.3491
17	4.2676	4.213	4.1914	4.1152			1.1279
18	4.2676		.4191	4.1152		4.3134	
19	4.4201		3.7342	4.1457		4.3439	
20				3.8104		4.2676	
21				4.1914		4.1152	
22	4.1152	3.9434		3.9628		4.039	
23	4.039	3.8832		3.7342		3.7342	
24	.9907	3.8866		3.3341	3.8104		3.8866
Max	4.4201	4.213	4.1914	4.4963	4.5931	4.3439	3.8866
Min	.4572	.3963	.4191	.381	3.5818	3.7342	.4239
Avg	2.3823	3.6145	3.4259	3.8019	3.8853	4.1585	2.4991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184239 / JAFARNAGAR

Feeder No / Name : 202 / GULAB PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	2.672		2.5149	2.5149		2.7435
2	.7716	2.753		2.5149	2.4387		
3		2.3624		2.4387	2.3624		
4	.6859	2.21		***	2.2862		
5	.6859	2.1052		2.3624	2.21		
6	.8573	2.2809		2.3624	2.3624		
7	1.0288	2.4387		2.5149	2.6673		
8	2.1338	2.8837		2.5911	2.8959		2.5911
9	3.1047	3.0178	2.8197	2.7435	3.0483		2.8675
10		2.8197	2.8197	2.8197			2.672
11	3.3261	2.8959	2.8959	2.8959			
12		2.9721	3.0483			3.1903	1.3908
13		2.7435	2.8959			3.1741	
14		2.4387	2.5911				.5716
15		2.2862	2.2862				
16					2.6558	2.9797	.8764
17	2.9721			2.8959			.7011
18	3.0483			2.9721		3.0788	1.1279
19	2.9721	2.9721		3.0178		3.2769	1.1431
20	3.0483			3.0178		3.2769	1.1431
21	2.7435			2.8959		3.0483	1.1431
22	2.5911	2.7854		2.8197		2.9721	1.0669
23	2.5911	2.7206		2.6673		2.8197	1.0669
24	.8383	2.5911		2.5911	2.5911		2.7435
Max	3.3261	3.0178	3.0483	24.417	3.0483	3.2769	2.8675
Min	.6859	2.1052	2.2862	2.3624	2.21	2.8197	.5716
Avg	2.0151	2.6289	2.7653	3.8449	2.5485	3.0908	1.5899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

(U)S/DN.III MALEGAON[748] BU 4748

Substation No/ Name :- 184240 / PAWARWADI

Feeder No / Name : 201 / ABDULLA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	3.9815	3.7494	3.5361	3.5105	2.21	5.2292
2	1.5604	4.0356	3.597	3.4751	3.2575	2.0911	5.0097
3	1.4918	3.883	3.5056	3.4294	3.1784	2.0683	4.9348
4	1.3717	3.722	3.3684	3.3684	3.0045	2.0637	4.8392
5	1.3032	3.3532	3.2769	3.7209	2.9729	1.9966	4.4683
6	1.3717	3.3097	3.3074	3.3532	2.9096	2.0652	4.2758
7	1.4232	3.3261	3.3532	3.3989	2.9412	1.9509	4.1666
8	2.2977	4.0007	3.4903	3.6427	3.4789	1.6202	1.3931
9	4.3896	4.6533	4.3286	4.2981		2.0195	4.4813
10	4.5068	4.5344	4.3328	4.4593		2.1597	4.3225
11	4.5068	4.7851	4.9154	4.6965		2.2619	4.0933
12	4.8705	5.2103	4.9653	5.0444	4.8826	2.3807	3.2556
13	4.6491	5.0301	4.9021	5.2974	4.5877	2.5804	3.1104
14	3.1468	3.0045	3.2114	3.0519		1.5546	1.3504
15	3.9059	3.1017	3.8996	3.6212	3.6885	5.4887	1.3489
16	4.3961	3.8832	4.3747	3.8584	3.9323	6.0035	3.1222
17	1.5181	4.1453	4.5344	4.2537		6.4533	1.5023
18	4.6016	4.039	4.3286	4.4435		5.4304	1.8861
19	4.2696	4.2219	4.481			6.0039	2.0233
20	4.4277	4.2524	4.2676	3.9691		2.1658	1.8347
21	4.2537	4.3896	4.0543	3.9217		1.5394	1.7147
22	4.0165	3.9781	3.8561	3.558			1.7661
23	3.9533	3.7037	3.5361	3.5421		4.6089	1.8347
24	1.6288	3.8584	3.8714	3.6123	3.5263	6.1715	3.0045
Max	4.8705	5.2103	4.9653	5.2974	4.8826	6.4533	5.2292
Min	1.3032	3.0045	3.2114	3.0519	2.9096	1.5394	1.3489
Avg	3.1461	4.0168	3.9795	3.8936	3.5285	3.1691	3.1237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184014 / LAKHMAPUR

Feeder No / Name : 207 / TALWADE GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1151	.1082	.1135	.2141
2		.1143	.109	.112	.2385
3		.1227	.1105	.1158	.2477
4		.1273	.1113	.1158	.2576
5		.125	.1151	.1212	.2789
6		.1265	.1379	.1463	.2728
7		.1113	.1296	.1372	.4893
8		.093	.0899	.0953	.66
9		.016	.0549	.08	.6341
10		.0251	.0511	.0427	.1593
11	.0099	.0114	.0099	.0251	.0472
12	.4618	.4138	.4077	.349	.0008
13	.423	.3536	.4512	.3445	
14	.455	.3673	.455	.3841	
15	.5045	.413	.4374	.3932	
16	.4031	.4001	.4374	.3788	
17	.4976	.4595	.4748	.4161	
18	.5175	.4725	.4717	.045	
19	.5022	.4847	.4672	.4542	.0465
20	.1189	.1707	.157	.1524	.1257
21	.1364	.128	.1265	.128	.1235
22	.1387	.1364	.1296	.1364	.128
23	.1379	.1341	.1364	.1273	.125
24	.1135	.1128	.125	.1113	.2614
Max	.5175	.4847	.4748	.4542	.66
Min	.0099	.0114	.0099	.0251	.0008
Avg	.3157	.2098	.2210	.1886	.2395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184033 / VADNER

Feeder No / Name : 202 / VADNER GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4017	.394	.4382	.4073	.4127	.234	.4299
2	.2469	.4127	.455	.418	.4207	.2366	.444
3	.4935	.5285	.4817	.5365	.4611	.2572	.5167
4	.6439	.6798	.639	.671	.5838	.3208	.6466
5	.8082	.7834	.7529	.7575	.8055	.4138	.7948
6	.0362	.0263	.1372	.3608	.0229		.3132
9	.7107	.6557	.6745	.6626	.7004	.671	.6527
10	.5914	.5582	.5479	.6131	.5525	.5438	.5746
11	.4485	.429	.4321	.4321	.4085	.3799	.4431
12	.3018	.3464	.3765	.423	.3582	.3837	.3868
13	.2758	.2976	.2819	.3372	.3205	.3837	.3402
14	.2804	.301	.2633	.3582	.3121	.3605	.362
15	.2766	.295	.3083	.3944	.1738	.359	.3441
16	.2991	.3296	.423	.439	.3627	.386	.3471
17	.375	.3971	.4177	.45	.4066	.4379	.3764
18	.522	.5799	.49	.5201	.5049	.4912	.5902
19	.6614	.8013	.708	.6957	.8188	.7156	.8063
20	.6584	.6694	.6542	.7075	.7388	.7335	.7731
21	.5613	.5385	.5407	.548	.5556	.5875	.626
22	.4821	.4794	.4821	.5026	.5064	.5095	.5152
23	.4492	.4367	.4302	.4523	.4386	.4439	.468
24	.4172	.4116	.4035	.4268	.4134	.4233	.4207
Max	.8082	.8013	.7529	.7575	.8188	.7335	.8063
Min	.0362	.0263	.1372	.3372	.0229	.234	.3132
Avg	.4519	.4705	.4699	.5052	.4672	.4415	.5078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184033 / VADNER

Feeder No / Name : 203 / KHAKURDI AG SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.6859	.1781	.1677	.1372		.4534
2	.4877	.6859	.1943	.1844	.1524		.4534
3	.5335	.7042	.1943	.1844	.1524		.4858
4	.5335	.7377	.1943	.1844	.1829		.5668
5	.5792	.7773			.1829		.583
6	.6401	.8097					.6154
7	1.5851	1.4575					1.247
8	1.5089	1.5384					1.3117
11			1.1336	.6249	.7125	.8097	
12			1.3603	1.1888	1.247	1.1336	
13			1.1336	1.0364	.8421	.9555	
14			.9878	.7773	.7773	.8097	
15	.081	.081	.8583	.6859	.6802	.6964	.081
16	.081	.081	.9717	.7316	.7449	.8097	.081
17	.081	.081	.9393	.823	.8097	.9231	.0972
18	.1174	.1296	.9393	.7011	.9069	.9069	.1174
19	.1543	.1619	.1372	.1067	.1296	.1296	.1341
20	.1715	.1781	.1886	.1524	.1715	.1619	.1715
21	.1886	.1781	.2058	.1677	.2012	.1619	.1886
22	.1886	.1781	.1886	.1677	.2012	.1781	.1886
23	.5658	.5344	.1677	.1677	.2012	.1781	.4115
24	.5182	.6516	.1619	.1844	.1524	.1781	.3887
Max	1.5851	1.5384	1.3603	1.1888	1.247	1.1336	1.3117
Min	.081	.081	.1372	.1067	.1296	.1296	.081
Avg	.4724	.5362	.5630	.4576	.4519	.5737	.4209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184033 / VADNER

Feeder No / Name : 207 / VADNER AG SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2572	.6478	.6371	.4725		.2429
2	.2286	.2572	.6478	.6874	.4725		.2429
3	.2743	.285	.664	.7377	.5335		.2591
4	.3048	.3077	.664	.788	.5639		.2591
5			.664	.8383	.5944		
6			.7287	.8718	.7773		
7			1.4575	1.5708	1.4632		
8			1.6194	1.7814	1.6309	1.749	
11	.7773	.7287					.8097
12	1.1174	1.1174					1.2955
13	1.0526	1.0364					1.2146
14	.9555	.9717					.9717
15	1.1012	.8259	.081	.0914	.081		.8745
16	1.1336	.9717	.1296	.1067	.1296	.0972	.9717
17	1.2146	1.2146	.1619	.1219	.1457	.1296	1.2631
18	1.2742	1.1336	.1715	.2439	.1619	.1296	1.2574
19	.3086	.2429	.2572	.2439	.2429	.2591	.2515
20	.2915	.2591	.2743	.2439	.2743	.2591	.2743
21	.2743	.2591	.2743	.2572	.2515	.2915	.2743
22	.2572	.2429	.2543	.2286	.2515	.2429	.2572
23	.2572	.2429	.4862	.4725	.4862	.5344	.2572
24	.2286	.2572	.5182	.5365	.4725	.4858	.2267
Max	1.2742	1.2146	1.6194	1.7814	1.6309	1.749	1.2955
Min	.2286	.2429	.081	.0914	.081	.0972	.2267
Avg	.6267	.5895	.5390	.5811	.5003	.4178	.6224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184033 / VADNER

Feeder No / Name : 208 / CHINCHAVE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.1317	.6478	.5868	.5335		.9717
2	.9145	1.1568	.6478	.5868	.4572		1.0526
3	.945	1.2239	.6802	.6706	.3963		1.1012
4	1.0822	1.3077	.6802	.6706	.3201		1.2146
5	1.1431	1.3916					1.2955
6	1.2955	1.643					1.3279
7	1.9052	2.1963					1.8623
8	1.8595	1.8785					1.8623
11			.8907	1.0517	.8583	.9393	
12			1.3279	1.0974	1.2146	1.2146	
13			1.1498	1.0364	1.1336	1.1336	
14			1.085	.9755	1.1174	1.0526	
15	.4287	.2915	1.0526	.8535	1.0202	.9717	.2915
16	.4191	.4049	1.3279	.9907	1.1012	1.1336	.3239
17	.4359	.4534	1.3441	1.1888	1.247		.3239
18	.9724	.4858	1.3603	1.0974	1.3927	1.2146	.8383
19	1.0288	.9069	.9259	.7926	.8421	.8259	.9724
20	.9431	.8907	.9259	.7773	.8573	.8097	.9259
21	.8573	.7449	.8916	.6401	.823	.6802	.9259
22	.823	.6802	.8916	.6097	.823	.6478	.8916
23	.9088	.7773	.6687	.5639	.6371	.5668	.8573
24	.9145	1.0288	.6802	.6478	.5792	.6478	.5506
Max	1.9052	2.1963	1.3603	1.1888	1.3927	1.2146	1.8623
Min	.4191	.2915	.6478	.5639	.3201	.5668	.2915
Avg	.9884	1.0330	.9543	.8243	.8530	.9106	.9772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184033 / VADNER

Feeder No / Name : 209 / KHAKURDI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.1715	.1715	.1715	.1372		.1715
2	.1067	.1715	.2058	.1715	.1372		.1715
3	.1372	.2229	.2058	.2915	.1543		.2572
4	.2286	.3086	.2572	.3258	.2743		.2572
5	.3048	.3601	.3601		.3601		.3429
9	.3086	.2743	.3086	.2743	.2229		.2743
10	.2743	.2058	.1886	.2134	.12	.1715	.2401
11	.1715	.1715	.1543	.1715	.12	.1372	.1543
12	.1372	.1372	.1029	.1372	.0857	.12	.1029
13	.12	.1029	.1029	.1219	.1029	.1372	.1029
14	.1029	.1029	.1029	.12	.12	.1029	.12
15	.1029	.1029	.1029	.1372	.1372	.12	.12
16	.12	.12	.12	.1372	.1543	.1543	.1372
17	.1372	.1372	.1715	.12	.1715	.1543	.1372
18	.2572	.2572	.1715	.1372	.2058	.2058	.2572
19	.3258	.3086	.2572	.2743	.3086	.2915	.3429
20	.2915	.3258	.2572	.2401	.2743	.3258	.3258
21	.2229	.2743	.2229	.2401	.2058	.2058	.3086
22	.1886	.2058	.1886	.1715	.1715	.1715	.2401
23	.1715	.1715	.1715	.1219	.1543	.1372	.1543
24	.1372	.1715	.1715	.1715	.1372	.1372	.1372
Max	.3258	.3601	.3601	.3258	.3601	.3258	.3429
Min	.1029	.1029	.1029	.12	.0857	.1029	.1029
Avg	.1883	.2050	.1903	.1875	.1788	.1715	.2074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184033 / VADNER

Feeder No / Name : 211 / WALWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1446	.7826	1.0787	1.5257	1.1264	.663	.591
2	1.1751	.7225	1.0901	1.5974	1.1591	.6523	.5773
3	1.1865	.801	1.149	1.6689	1.1606	.6409	.6104
4	1.1606	.5864	1.1536	1.7444	1.1896	.6333	.6158
5	.8566	.2705	1.3108	1.7467	1.214	.6683	.2843
6	.8002	.2431	1.3346	1.557	1.4495	.6478	.3757
7	.7514	.1837	2.1725	2.4325	2.4966	.3597	.3246
8	.7796	.1913	2.4459	2.4583	2.7153	2.4603	.3307
9	.7461	.2248	.3711	.3079	.5075	.3612	.3147
10	.5449	.2241	.4557	.3719	.6219	.5175	.5251
11	1.7366	.2157	.5083	.3239	.6348	.4489	1.7272
12	2.5204	2.1513	.5708	.2835	.6409	.3605	2.5715
13	2.1658	1.7632	.663	.3201	.6981	.4397	2.3536
14	1.8103	1.5058	.647	.301	.7575	.3681	1.9096
15	1.8097	1.4696	.785	.4001	1.1378	.3216	1.6452
16	1.7671	1.4875	.7639	.3734	1.1579	.4367	1.1028
17	1.8391	1.6351	.8596	.3513	1.3405	.7469	1.2667
18	1.829	1.4616	.868	.3833	1.4186	.7192	1.5326
19	.8268	.5805	.9891	.5792	1.3996	.8856	.9899
20	.8352	.5659	1.0341	.5929	1.1073	.8307	1.0848
21	.8367	.6047	1.0681	.4039	1.0417	.5958	1.1195
22	.7925	.6021	1.012	.4404	1.0425	.5971	1.1339
23	.7742	.546	1.3862	1.0433	1.7018	.9572	1.0867
24	.794	.5372	1.3341	1.0631	1.6103	1.1262	1.0503
Max	2.5204	2.1513	2.4459	2.4583	2.7153	2.4603	2.5715
Min	.5449	.1837	.3711	.2835	.5075	.3216	.2843
Avg	1.2285	.8065	1.0438	.9279	1.2221	.6849	1.0468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184036 / DABHADI

Feeder No / Name : 201 / PIMPALGAON AG SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7865	1.6766	2.3396	2.1048	1.4529	.7613
2		.7834	1.7085	2.3579	1.4834	1.5561	.7719
3		.849	1.8138	2.4295	1.6628	1.6575	.8215
4		.8825	1.9677	2.646	1.9608	2.8784	.852
5		.9557	2.2924	2.9965	2.2927	2.3396	.977
6		.5746	3.0285	3.7967	2.931	4.199	.961
7			4.2989	5.2492	4.3031	4.4086	.9126
8			4.3712	5.3421	4.6121	5.5144	
9			2.521	2.6414	2.5438	2.5393	
11		1.3854					1.7056
12		3.9933					4.3103
13		3.6549					4.0158
14		3.4019					3.4248
15		2.8746	.2927	.3399	.2774	.2942	3.4091
16		3.0193	.3857	.407	.3383	.4054	3.7681
17		1.9948	.4085	.1859	.3155	.4127	4.1595
18	2.4158	3.3897	.5091	.5167	.3688	.5288	4.6842
19	2.5743	2.4859	.7133	.7225	.6835	.7739	2.6817
20	.8672	.8036	.7987	.8299	.7758	.916	.8882
21	.8002	.6866	.7194	.6355	.6249	.9667	.8162
22	.7911	.6642	.6325	.602	.5864	.887	.8395
23	.7987	1.2944	1.8976	1.6754	1.8777	.8169	.7945
24	.442	1.6031	2.2508	2.3914	1.9539	.7925	.413
Max	2.5743	3.9933	4.3712	5.3421	4.6121	5.5144	4.6842
Min	.442	.5746	.2927	.1859	.2774	.2942	.413
Avg	1.2413	1.8042	1.6993	2.0055	1.6682	1.7547	1.9985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184036 / DABHADI

Feeder No / Name : 203 / DABHADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0593	1.2563	1.1996	1.2852	1.243	1.2174	1.0882
2	1.1336	1.2997	1.2312	1.2616	1.2715	1.238	1.0775
3	1.494	1.5097	1.3245	1.4758	1.3599	1.3679	1.3561
4	1.7498	1.7341	1.5806	1.7006	1.5642	1.5955	1.6887
5	1.9799	1.9769	1.8835	1.9601	1.9071	1.9277	2.0065
6	2.2828	2.2889	2.1556	2.3758	2.2184	2.2223	2.2123
7	2.0759	2.1811	1.9441	2.2036	1.9528	2.0469	2.2287
8	1.7311	1.8194	1.539	1.7795	1.6449	1.661	1.7513
9	1.5855	1.592	1.4209	1.5691	.583	1.5703	1.5855
10	1.43	1.4289	1.3972	1.4327	1.3619	1.5428	1.4818
11	1.3363	1.2833	1.3107	1.2434	1.3261	1.5067	1.4148
12	1.2045	1.2407	1.1275	1.0921	1.1542	1.3241	1.2952
13	1.1009	1.0852	1.0056	1.004	1.0981	.418	1.174
14	1.041	1.0776	1.0208	.9255	1.0536	1.0178	1.0105
15	.9914	1.0418	1.0593	.9853	1.0753	1.0643	.8771
16	1.0635	1.1252	1.1161	1.0719	1.0955	1.291	1.1973
17	.4382	1.182	1.246	1.139	1.1405	1.2955	1.2697
18	.4778	1.2613	1.5661	1.5051	1.254	1.5912	1.6232
19	1.9426	1.8827	2.0222	1.8732	1.7326	1.9338	2.0931
20	2.1022	1.9418	2.0549	1.9814	2.0732	1.8473	1.9681
21	1.7749	1.7044	1.8511	1.7372	1.7977	1.8255	1.7688
22	1.6038	1.5512	1.6468	1.5905	1.5775	1.7242	1.6213
23	1.4156	1.4152	1.4784	1.4121	1.4353	1.5184	1.4544
24	1.3279	1.2993	1.2411	1.3169	1.3332	1.2049	.4961
Max	2.2828	2.2889	2.1556	2.3758	2.2184	2.2223	2.2287
Min	.4382	1.0418	1.0056	.9255	.583	.418	.4961
Avg	1.4309	1.5074	1.4760	1.4967	1.4272	1.4980	1.4892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184036 / DABHADI

Feeder No / Name : 204 / JIJAMATA INDUSRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7114	.6489	.6725	.7422			.4992
2	.6531	.6451	.7411	.7789			.7019
3	.7598	.6832	.7201	.777			.7796
4	.8005	.7243	.708	.6893			.7662
5	.711	.7682	.719	.6844			.6984
6	.7156	.836	.6462	.7484			.735
7	.5731	.6999	.5041	.6283	.2572		.711
8	.5571	.6382	.4843	.5563		.2286	.6546
9	.5404	.7034	.5876	.7145		.7133	.6077
10	.586	.724	.5391	.6764		.8208	.5727
11	.7156	.6835	.6581	.3086		.9164	.594
12	.6851	.7476	.7674			.7883	.7217
13	.6866	.7639	.8733			.8478	.7281
14	.6519	.7259	.7967			.7335	.7533
15	.5857	.6973	.7663			.7041	.7404
16	.6428	.6737	.711			.8257	.8703
17	.4028	.7907	.7583			.6908	.7586
18	.7274	.6687	.7461			.578	.7914
19	.6782	.6394	.61			.5487	.631
20	.6802	.6977	.6882			.5586	.7034
21	.7087	.6935	.8482			.4591	.7145
22	.6718	.7037	.7331			.4119	.6923
23	.6539	.6439	.6912			.3769	.7171
24	.6889	.647	.6939	.3601		.4264	.3822
Max	.8005	.836	.8733	.7789	.2572	.9164	.8703
Min	.4028	.6382	.4843	.3086	.2572	.2286	.3822
Avg	.6578	.7020	.6943	.6387	.2572	.6252	.6885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184036 / DABHADI

Feeder No / Name : 205 / DABHADI AG SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7602	.2591	.2743	.2915	.2591	.6097
2	.6097	.7468	.2743	.2743	.2743	.2743	.6097
3	.9145	.8269	.2896	.2896	.2743	.2743	.9145
4	1.1431	1.0212	.3048	.2534	.2896	.2896	1.1431
5	1.1431	1.0212	.3048	.2667	.2896	.2896	1.2193
6	1.1431	1.1736				.3048	1.3717
7	1.3717	1.7071					1.4784
8	1.6461	1.768					1.448
11			.5335	.7621	.3429	.442	
12			1.5242	1.1431	1.2041	1.1431	
13			1.2651	1.0669	1.0974	.9755	
14			1.1431	.9602	1.0364	.9297	
15	.1372	.1524	1.0059	1.0669	1.046	.9602	.1372
16	.1524	.1677	1.0669	1.0974	1.0364	1.0059	.1677
17		.1981	1.3413	1.1888	1.2193	1.2803	.1715
18		.1829	1.2193	1.2193	1.2498	1.0669	.2229
19	.2439	.2591	.2896	.2896	.3429	.3429	.2915
20	.2591	.2743	.3201	.3258	.3429	.3086	.2743
21	.2439	.2439	.2591	.3086	.2896	.2743	.2743
22	.2286	.2915	.2743	.3258	.2896	.2572	.2401
23	.7773	.3086	.2743	.3258	.3258	.1829	.4973
24	.823	.9602	.3086	.3086	.3258	.5335	
Max	1.6461	1.768	1.5242	1.2193	1.2498	1.2803	1.4784
Min	.1372	.1524	.2591	.2534	.2743	.1829	.1372
Avg	.7154	.6702	.6452	.6183	.6089	.5697	.6512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184036 / DABHADI

Feeder No / Name : 207 / PIMPALGAON GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4073	.3711	.3891	.3692	.3544	.3852
2	.3437	.4111	.3734	.3936	.3646	.378	.3944
3	.4142	.4386	.4203	.4256	.3944	.3898	.4531
4	.5132	.4717	.458	.4657	.4348	.4337	.5605
5	.5434	.5251	.506	.5514	.4893	.5103	.6325
6	.5754	.5772	.5514	.5921	.5399	.5777	.5617
7	.5465	.5932	.4797	.5541	.5083	.5388	.4828
8	.4024	.4957	.407	.4992	.4092	.4374	.4774
9	.3696	.4389	.4222	.4702	.3761	.4775	.4645
10	.3844	.4809	.466	.4455	.4267	.4691	.4874
11	.359	.4149	.4051	.3345	.3639	.3769	.4027
12	.2904	.2621	.3098	.2675	.3163	.2534	.3124
13	.298	.2648	.2663	.2652	.3399	.2614	.3513
14	.3414	.3139	.2671	.2987	.3578	.2949	.3025
15	.3033	.3231	.2884	.3087	.3006	.2812	.3349
16	.3079	.2941	.2831	.3204	.3418	.3117	.3326
17	.3083	.3162	.3273	.077	.3662	.2907	.3372
18	.3864		.3993	.4229	.3952	.3372	.4039
19	.2683	.5803	.5091	.4577	.5688	.4614	.6024
20	.6066	.6622	.5362	.4946	.5933	.6016	.5007
21	.5784	.5792	.5403	.5014	.5022	.5613	.5137
22	.5822	.5019	.4901	.5083	.4721	.5875	.4702
23	.503	.4283	.4287	.4306	.4027	.4995	.3928
24	.3616	.423	.3723	.3895	.5354	.4013	.1901
Max	.6066	.6622	.5514	.5921	.5933	.6016	.6325
Min	.2683	.2621	.2663	.077	.3006	.2534	.1901
Avg	.4138	.4436	.4116	.4110	.4237	.4203	.4311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184203 / AJANG

Feeder No / Name : 201 / AJANG 1-PHASE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
7			1.6476
9			.9231
10			.7796
11			.7682
12	.7545		.6836
13			.7122
14			.6935
15			.7442
16			.7802
17			.7712
18		.9465	.4024
19			1.3169
20			1.2308
21			1.1523
22			1.1706
23			.6001
Max	.7545	.9465	1.6476
Min	.7545	.9465	.4024
Avg	.7545	.9465	.8985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184203 / AJANG

Feeder No / Name : 203 / DABALI 1-PHASE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
11			.5506
12	1.4413		1.5402
13			1.4255
14			1.0814
15			.9503
16			1.0364
17			1.2146
18		1.1174	1.2631
Max	1.4413	1.1174	1.5402
Min	1.4413	1.1174	.5506
Avg	1.4413	1.1174	1.1328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184230 / SATMANE

Feeder No / Name : 201 / ONKAR NAGAR AG SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.1029	.12	.1886	.1886	.0171	.7316
2	.7202	.1029	.1372	.1543	.1715	.0171	.6859
3	.6859	.1115	.1715	.1715	.1543	.0171	.6859
4	.7716	.1115	.2058	.1886	.1715	.0152	.8745
5	1.2517	.1082					.9602
6	1.3717	.1457					.125
7		.1972					.1663
8	2.0576	.1903					.1677
9	2.2291						
11			.1715	.1715	.1524	.0152	
12			1.8861	1.6632	1.3717	.1372	
13			1.8519	1.6461	1.3717	.1492	
14			1.6975	1.6118	1.2193	.1372	
15	.0857	.0103	1.5851	1.5604	1.0669	.1067	.0051
16	.1029	.0086	1.6156	1.5775	1.2193	.1448	.0086
17	.1029	.0103	1.6918	1.6289		.1494	.0103
18	.12	.0137	1.5699	1.4575		.1494	.012
19	.1372	.0171					.0154
20	.1715	.0206	.1829	.2401		.0137	.0171
21	.2058	.0171	.1677	.2401		.0183	.0189
22	.1715	.0171	.1981	.2229			.0206
23	.1715	.0171	.1981	.2058		.0152	.0257
24	.6859	1.1488		.2058	.0189	.0171	.0171
Max	2.2291	1.1488	1.8861	1.6632	1.3717	.1494	.9602
Min	.0857	.0086	.12	.1543	.0189	.0137	.0051
Avg	.6516	.1306	.8407	.7726	.6460	.0700	.2527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184230 / SATMANE

Feeder No / Name : 202 / DHUNDE AG SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.0257	.6516	.6401	.7011	.0762	.0309
2	.2229	.0257	.6859	.6706	.6859	.0762	.0171
3	.2401	.0274	.7202	.6706	.7164	.0762	.0171
4	.2572	.0274	.7716	.7621	.7621	.0762	.0223
5			.9431	.9145	.7926	.0914	
6			1.0974	1.7071	.9755	.1372	
7			1.869	1.7071	1.4937	.2058	
8				1.89	1.6461	.2143	
11	.1715	.0206					.0257
12	1.326	.1509					.1494
13	1.1888	.1128					.1143
14	1.0974	.12					.1097
15	1.1431	.1097	.1067	.0762	.1067	.0069	.1128
16	1.2498	.12	.1219	.0762	.1219	.0103	.1174
17	1.3413	.156	.1219	.0914	.1219	.0103	.1372
18	1.5089	.1402	.1372	.0914	.1524	.0171	.168
19			.2572	.1981	.2439	.024	
20	.2915	.0309	.2591	.2572	.2743	.0309	.0343
21	.3429	.0274	.2439	.2134	.3353	.0343	.0343
22	.3429	.024	.2134	.1829	.2896	.0291	.0326
23	.3086	.024	.1524	.1524	.1524	.0171	.0274
24	.2401	.2915		.6401	.7316		
Max	1.5089	.2915	1.869	1.89	1.6461	.2143	.168
Min	.1715	.0206	.1067	.0762	.1067	.0069	.0171
Avg	.6772	.0844	.5220	.6079	.5724	.0667	.0719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

DABHADI (R) SUBDN[267] BU 0434

Substation No/ Name :- 184230 / SATMANE

Feeder No / Name : 203 / TALWADE AG SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.0394	.1715	.1715	.2058	.0206	.0412
2	.4458	.0335	.1543	.1543	.1715	.0206	.0396
3	.4115	.0335	.1886	.1715	.1715	.0206	.0381
4	.4287	.0396	.2401	.1886	.2058	.0206	.0427
5	.4572	.0457					.0457
6	.6097	.061					.0457
7	1.0288	.0892					.0762
8	.9145	.0975					.0793
10			.1715				
11				.1524		.0206	
12			.7202	.5658	.0457	.0457	
13			.6859	.5658	.5335	.0457	
14			.6001	.5487	.4572	.0412	
15	.0857		.5487	.5144	.3048	.0366	.0069
16	.0686	.0103	.6516	.6001	.4572	.0457	.0086
17	.0857	.0154	.6859	.7202	.6097	.061	
18	.0857	.0154	.8573	.7716	.7621	.061	.0103
19	.1543	.0206					.0206
20	.2058	.024	.2229	.2401	.1981	.0223	.0223
21	.1715	.024	.2058	.2229	.1981	.0029	.0171
22	.1715	.0223	.2058	.2229	.2134	.0206	.0137
23	.1677	.0171	.2058	.2058	.1981	.0137	.0171
24	1.6632	.4287	.0171	.2058	.2058		.0171
Max	1.6632	.4287	.8573	.7716	.7621	.061	.0793
Min	.0686	.0103	.0171	.1524	.0457	.0029	.0069
Avg	.4214	.0598	.3843	.3660	.3086	.0312	.0319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184062 / DAHIWAL

Feeder No / Name : 201 / AJANDEPADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3146	1.2346	.7202	.6859	.7011		1.2003
2	1.3146	1.2346	.7545	.7202	.7011		1.2003
3	1.3146	1.2689	.7545	.7545	.7011		1.2003
4	1.4022	1.3032	.8573	.8573	.8764		1.2346
5	1.5074	1.406	1.1317	1.166	1.1393		1.3032
6	1.7147	1.8861					1.7833
7	2.4177	2.4006					2.2291
8	2.3491	2.4006					2.0576
9	1.8861						1.4746
12			1.9204	1.8004			
13				1.6804		1.6461	
14			1.8519	1.6118		1.6289	
15			1.8176	1.5432		1.5432	
16	.4458	.5487	1.7833	1.7147		1.3717	.7202
17	.5487	.6001	1.8861	1.8347		1.7833	.8573
18	.6859	.7545	1.9547	1.9719		1.9719	1.166
19		1.0288	1.7833	1.8176		1.8861	1.3032
20	1.3375	1.2346	1.2346	1.3717		1.2346	1.0288
21	.8916	.8573	.9602	1.2003		.9259	.9945
22	.7545	.8573	.8916	.8916		.7716	.8573
23	.6516	.823	.7545	.7545		.6859	.6859
24	1.3889	1.166		.6859	.7545		1.2003
Max	2.4177	2.4006	1.9547	1.9719	1.1393	1.9719	2.2291
Min	.4458	.5487	.7202	.6859	.7011	.6859	.6859
Avg	1.2897	1.2356	1.3160	1.2813	.8123	1.4045	1.2498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184062 / DAHIWAL

Feeder No / Name : 202 / HISWAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.9259	.9602	.7888	.7888		.8916
2	.8764	.8916	1.0288	.823	.7888		.8573
3	.964	.9259	.9945	.8573	.7888		.8916
4	1.0517	1.1317	1.1145	1.0631	.8764		1.0974
5	1.4373	1.406	1.2346	1.2689	1.1568		1.406
6			1.5089	1.5775	1.406		
7			1.8004	1.6804	1.7147		
8			1.6804	1.4232	1.749		
9			1.166	1.3203			
12	1.4575	1.286					1.3717
13	1.406	1.1317					1.2346
14	1.3717	1.1317					1.166
15	1.2003	1.1831					1.0288
16	1.2003	1.2003	.9259	.9259		.9431	.9945
17	1.286	1.286	1.0631			1.0288	1.0288
18	1.3717	1.4575	1.2003	1.3375		1.1145	1.3546
19	1.5775	1.3375		1.6632		1.4746	1.4918
20	1.6804	1.6289	1.7318	1.5432		1.6461	1.7147
21	1.2003		1.406	1.3717		1.4575	1.5775
22		1.1317	.9602	1.1831		1.166	1.1488
23	1.0288	.8916	.9431	.9945		1.0288	.9774
24	.8916	.9259	.9259	.7716	.9088		.9259
Max	1.6804	1.6289	1.8004	1.6804	1.749	1.6461	1.7147
Min	.8764	.8916	.9259	.7716	.7888	.9431	.8573
Avg	1.2281	1.169	1.2144	1.2114	1.1309	1.2324	1.1755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184062 / DAHIWAL

Feeder No / Name : 205 / 11kv Girana Dam

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5974	1.0806	.9904	.8093	1.0112	.6371	.4977
2	.5974	.9709	1.0006	.8001	.9092	.5883	.4908
3	.5967	.9953	.9465	.82	.9137	.5609	.4809
4	.5967	1.0075	.9274	.8238	.9259	.5693	.5038
5	.5974	.964	.8928	.8162	.9443	.5449	.4858
6	.6055	.9739	.8413	.8771	.985	.5578	.4641
7	.6009	1.0529	.788	.6203	1.0186	.5472	.484
8	.5913	1.1302	.7346	.5967	.7323	.5335	.5262
9	.4847	.1547	.6332	.7986	.4915	.5266	.4165
10	.3757	.4222	.6683	.8863	.3437	.4176	.4347
11	.3674	.6645	.855	.9168	.3742	.4138	.4526
12	.3003	.6797	.9678	.9355	.5388	.5235	.2427
13	.3319	.7361	.9823	.9164	.5373	1.0143	.5486
14	.4992	.3506	.8573	.9119	.4664	.9571	.5006
15	.6142	.9096	.6332	.9805	.4801	.7324	.6142
16	.589	.9831	.8969	.8814	.535	.4908	.6851
17	.6081	1.041	.8771	.9015	.5647	.5274	.6774
18	.5875	.8771	.5426	.8024	.5243	.5061	.7392
19	.3281	.762	.4245	.4657	.298	.5662	.7552
20	.759	.772	.3407	.5349	.2896	.5829	.6203
21	.6203	.6995	.3483	.7041	.3117	.5244	.7315
22	.6607	.759	.823	.9263	.5601	.471	.8959
23	1.0661	.9625	.8809	.9301	.5815	.4253	.9084
24	.8486	.9854	.9541	.8558	1.0982	.2469	.5907
Max	1.0661	1.1302	1.0006	.9805	1.0982	1.0143	.9084
Min	.3003	.1547	.3407	.4657	.2896	.2469	.2427
Avg	.5760	.8306	.7836	.8130	.6431	.5611	.5728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184087 / ZODGE

Feeder No / Name : 201 / Devarpade SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2938	2.2186	2.1681	2.3091	2.7825	2.3205	2.5186
2	2.3301	2.1701	2.4958	2.2558	2.6711	2.3282	2.2364
3	2.3129	2.2302	2.5682	2.2177	2.6359	2.4044	2.2634
4	2.3853	2.2798	2.8045	2.3282	2.7101	2.4539	2.4318
5	2.4729	2.4996	3.1322	2.6368	3.1583	2.7511	2.6939
6	3.2502	3.1261	3.6733	3.2084	4.1915	3.578	3.0216
7	4.1724	4.1547	5.4679	4.6677	4.1293	4.0238	4.1
8	4.8316	5.1802	5.3841	5.6867	4.2075	4.4163	5.4755
9	5.304	5.4908	4.5648	4.8019	3.9171	3.7913	5.5807
10	4.3124	4.3591	3.1512	3.4932	2.8883	3.3513	4.8164
11	2.4318	2.875	2.8921	2.5687	2.7397	2.894	3.261
12	2.223	2.5567	3.075	2.7606	2.2291	3.0217	2.7456
13	1.6937	2.0824	4.1191	3.1693	2.9073	3.1893	2.1415
14	1.6522	2.1033	4.0219	2.9127	2.873	2.8083	1.9862
15	1.7132	2.1338	3.3074	2.5491	2.4272	2.8349	1.7917
16	1.9105	2.0195	3.3226	2.2672	2.3967	2.633	1.8336
17	2.0315	2.1758	3.6618	1.3622	3.0026	2.9721	2.0728
18	2.1224	2.3358	3.94	3.6294	3.7151	3.2198	2.4234
19	2.9623	3.0902	4.1228	3.277	3.8256	3.9628	2.9577
20	5.2705	5.0678	4.7972	2.9864	3.8409	4.382	4.0124
21	5.3864	5.2393	5.1326	3.6363	3.4141	4.843	4.16
22	4.2075	3.94	3.7875	3.7495	3.6046	3.9209	3.8912
23	3.2979	3.3607	3.5284	3.4094	3.1893	3.3475	3.0131
24	2.6444	2.6259	2.8578	3.0606	3.0628	2.3929	2.6406
Max	5.3864	5.4908	5.4679	5.6867	4.2075	4.843	5.5807
Min	1.6522	2.0195	2.1681	1.3622	2.2291	2.3205	1.7917
Avg	3.0505	3.1381	3.6657	3.1227	3.1883	3.2434	3.0862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184087 / ZODGE

Feeder No / Name : 202 / Zodge Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.415	.3429	.4294	.2987		.3395
2	.3772	.415	.3772	.3898	.2622		.3206
3	.3944	.3801	.3944		.3109		.2743
4	.3944	.3961	.4287		.2774		.3429
5	.3944	.4527	.463		.2713		
6	.4973	.5304	.048		.3734		.381
7	.4268	.547	.463		.3982		.381
8	.12	.4527	.3944		.3077		.3258
9	.4298	.4108	.3601	.3734	.2883	.3429	.2622
10	.3734	.3772		.362		.3086	.2949
11	.3361	.3772	.3601	.3121	.2572	.2743	.3086
12	.3734	.2915		.2294		.2572	.2785
13	.3734	.2743	.3772	.2713		.2572	.2743
14	.3734		.3601	.2614		.2743	.2743
15	.3506	.3258	.3429	.2774		.2915	.2294
16	.3772	.3429	.3429	.2713			.2374
17	.3077	.3086	.3429	.2622		.2915	.3681
18	.2241	.3258	.3772	.3052			.3391
19	.6036	.4458	.4572	.3921		.381	.4748
20	.6602	.4877	.503	.4527		.3963	.543
21	.5281	.4801	.4725	.3982		.4287	.5068
22	.4715	.4287	.4458	.3561		.3772	.4525
23	.4108	.4115	.4287	.3292		.3429	.3898
24	.3944	.4108	.3772	.4338	.3206		.3086
Max	.6602	.547	.503	.4527	.3982	.4287	.543
Min	.12	.2743	.048	.2294	.2572	.2572	.2294
Avg	.3987	.4038	.3845	.3393	.3060	.3249	.3438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184087 / ZODGE

Feeder No / Name : 203 / HARITWAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191		.0191		.0191
2	.0191	.0191	.0191		.0189		.0191
3	.0191	.0191	.0191		.0191		.0191
4	.0191	.0191	.0191		.0191		.4287
5	.0191	.0191	.0191		.0191		.0191
6	.0191	.0191	.0191		.0191		.0191
7	.0191	.0191	.0191		.0191		.0191
8	.0191	.0191	.0191	.0191	.0191		.0191
9	.0191	.0191	.0191		.0181	.0191	
10	.0191	.0191				.0191	.0191
11	.0191	.0191	.0191	.0191	.0191	.0191	.0191
12	.0191	.0191	.0191	.0191		.0191	.0191
13	.0191	.0191	.0191	.0191		.0191	.0191
14	.0191	.0191	.0191	.0191		.0191	.0191
15	.0191	.0191	.0191	.0191		.0191	.0191
16	.0191	.0191	.0191	.0191		.0191	.0191
17	.0191	.0191	.0191	.0191		.6097	.0191
18	.0191	.0191	.0191	.0191			.0191
19	.0191	.0191	.0191	.0191		.0191	.0191
20	.0191	.0191	.0191	.0191		.0191	.0191
21	.0191	.0191	.0191	.0191		.0191	.0191
22	.0191	.0191	.0191	.0191		.0191	.0191
23	.0191	.0191	.0191	.0191		.0191	.0191
24	.0191	.0191	.0191	.0191	.0191		.0191
Max	.0191	.0191	.0191	.0191	.0191	.6097	.4287
Min	.0191	.0191	.0191	.0191	.0181	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0190	.0613	.0369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184087 / ZODGE

Feeder No / Name : 204 / Zodge Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1141	1.1428			.0181		.905
2	1.1527	1.1713			.0181		.8901
3	1.1805	1.1668			.0187		.8916
4	1.1991	1.1965			.017		.9065
5	1.1827	1.257			.0181		.8878
6	1.3641	1.4585					1.0776
7	1.8039	1.8812					1.4807
8	1.7185	1.8511					1.5623
9	1.5002	1.4058					.7026
11			.8688	.74	.7583	.7118	
12			1.7505	1.6278	.8147	1.4304	
13			1.6255	1.5947	.7804	1.3253	
14			1.3863	1.4442	.7026	1.3322	
15	.0008		1.3047	1.302	.6828	1.1561	
16			1.3641	1.4152	.7735	1.2361	.0183
17			1.6294	1.6059	.8505	.7918	.017
18			1.5242	1.5689	.8718	.7842	.0183
19	.0377		1.2834	.98	.6783	1.2338	.0171
20	.0758	.1067		.0377			.0181
21	.0644	.109		.0377			.0193
22		.0038		.0181			.0228
23	.5639	.5037		.0181			.5294
24	1.1271	1.0378	.3506		.017	.3727	.5235
Max	1.8039	1.8812	1.7505	1.6278	.8718	1.4304	1.5623
Min	.0008	.0038	.3506	.0181	.017	.3727	.017
Avg	.9390	1.0209	1.3088	.9531	.4680	1.0374	.5827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184087 / ZODGE

Feeder No / Name : 205 / RAJMANE NEW

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.5658	.3048		.3506		.4725
2	.5144	.543	.381		.3439		
3	.5487	.567	.3963		.362		.5316
4	.5335	.5792	.4268		.3734		.5658
5	.6859	.6535	.0457		.4344		.6401
6		1.0136	.0518		.6584		.884
7	.6706		.6859		.8326		.7926
8	.6554		.6097	.9694	.7969		.6097
9	.8402	.8589	.5335	.6154	.5784	.4877	.543
10	.6584	.5335		.567		.5487	.3113
11	.4481	.381	.3506	.415	.4115	.3963	.2561
12	.6161	.4268	.3048	.3467	.3772	.4115	.5068
13	.4854	.4268	.2915	.3155		.3429	.5087
14	.4481	.3353	.3258	.2949		.3772	.3856
15	.3982	.3506	.3086	.2774		.3048	.4458
16	.4715	.4572	.3772	.3856		.3429	.5548
17	.547	.4725	.3772	.4344		.4115	.6733
18	.547	.3963	.4458	.5083			.7087
19	.6036	.4877	.8383	.9955		.8535	.6767
20		.9259		.9593		.7011	.8669
21	.8596	.6249	.7011	.8326		.8383	.763
22	.7468	.5182	.6097	.7059		.6706	.6613
23	.6036	.4572	.5144	.543		.5182	.5426
24	.463	.9694	.3963	.3584	.6413		.3086
Max	.8596	1.0136	.8383	.9955	.8326	.8535	.884
Min	.3982	.3353	.0457	.2774	.3439	.3048	.2561
Avg	.5814	.5702	.4217	.5603	.5134	.5147	.5743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184087 / ZODGE

Feeder No / Name : 206 / Bhilkot Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2054	.1886		.1696		
2	.1715	.2054	.1524		.181		.1886
3	.1886	.1991	.1829		.181		
4	.1886	.2012	.2591		.2715		.2058
5	.2229	.2353	.3201		.2743		.2743
6	.3601	.3561	.4115		.4887		.4268
7	.3353	.5068	.3353		.5068		.381
8	.3086	.2829	.3048	.3658	.373		.3086
9	.2801	.1629	.1981	.2378	.2353	.2229	.2126
10	.1307	.1543		.1307		.0686	.1802
11	.1097	.0857	.0857	.132	.12	.0686	.1254
12	.1086	.0857	.1029	.0648		.0857	.1086
13	.1267	.0857	.0686	.08		.0857	.1086
14	.1307	.1029	.0857	.0972		.0857	.104
15	.1307	.0762	.0857	.0983		.1029	.1097
16	.132	.1067	.12	.1086		.12	.1526
17	.1509	.1219	.1372	.0983		1.5432	.1629
18	.2075	.1524	.2058	.1734			.2353
19	.3772	.3353	.3353	.362		.3963	.4031
20	.4527	.3772	.3506	.3734		.3258	.407
21	.2715	.2134	.2134	.2743		.2915	.2896
22	.2241	.1677	.1886	.2353		.2229	.2172
23	.1867	.1677	.1715	.1638			.1802
24	.1715	.1886	.1715	.181	.1509		.1715
Max	.4527	.5068	.4115	.3734	.5068	1.5432	.4268
Min	.1086	.0762	.0686	.0648	.12	.0686	.104
Avg	.2141	.1990	.2033	.1869	.2684	.2784	.2252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184094 / VADGAON DYANE

Feeder No / Name : 201 / DYANE IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1807		2.2291	2.452	2.4905		2.4508
2	2.2361	.9375	2.2885	2.3712	2.5377		2.3411
3	2.2177		2.1672	2.3899	2.6063		2.4326
4	2.1807	1.1061	1.9839	2.3765	2.3403		2.3777
5	2.2177		2.1152	2.4331	2.4863		2.3411
6	2.2361	1.0447	2.0233	2.3899	2.4177		2.347
7	2.1948		1.9006	2.4832	2.3148		2.2916
8	1.9774	1.331	2.0111	2.4459	2.3834		2.524
9	1.8296	1.4465	2.6513	2.4926	3.0807		2.2891
10	1.7741	2.2462	2.8292	2.2969	3.0994		2.4109
11	1.5775	2.4981	2.8669	2.2939	3.3608		2.7238
12	1.5091	2.2977	2.9047	2.3061			
13	1.4746	2.1325	2.3525	2.1365	2.9687		1.897
14	1.3735	1.8818	2.2779	1.8821	2.5579	2.4143	
15	1.406	2.0622	2.5766	2.1628	3.0994	2.7801	1.6986
16	1.0791	2.3137	2.838	2.3569	3.2674	3.091	2.1891
17	1.1014	2.2611	2.8753	2.6282		3.219	2.4172
18		2.1628	2.7633	2.556			1.9766
19	1.0983	2.2291	2.6326	2.4691		2.8715	
20		1.95	2.4086	2.5034		2.652	2.1191
21		1.9547	2.4086	2.5206		2.4508	
22		1.95	2.1098	2.3405		2.5972	1.8696
23			2.2779	2.4417			
24	2.2177		2.1776	2.3899	2.572		2.3411
Max	2.2361	2.4981	2.9047	2.6282	3.3608	3.219	2.7238
Min	1.0791	.9375	1.9006	1.8821	2.3148	2.4143	1.6986
Avg	1.7833	1.8781	2.4029	2.3800	2.7240	2.7595	2.2652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184094 / VADGAON DYANE

Feeder No / Name : 202 / 11 kv Ramjanpura

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.873		3.3916	3.2808	3.4252		2.9321
2	.7926	2.5789	3.0312	3.2442	3.3608		2.9254
3	.8139		2.878	2.8807	3.2236		2.8464
4	.6773	2.684	3.0687	2.7854	2.6353		2.734
5	.7432		2.4905	2.6406	3.0007		2.5606
6	.7907	2.4784	2.7664	2.4966	2.5587		2.4905
7	.8278		2.4985	2.9447	3.0864		2.451
8	1.2811	2.9068	3.1207	3.0152	3.0403		2.037
9	2.934	3.9323	3.8432	3.5665	3.9057		2.3562
10	3.4903	3.6702	3.658	4.0143	3.9369		2.3785
11	3.4316	4.3239	3.8409	4.1781	4.0931		1.717
12	4.1667	4.6609	4.1762	4.7154			
13	4.0962	4.3408	3.658	4.6984	4.2219		.9157
14	2.2939	2.3663	2.0881	2.572	2.4082	2.4777	
15	2.9683	2.8464	3.0026	2.7121	3.0026	2.9995	.5266
16	3.7575	3.7477	3.658	4.0809	3.658	3.6245	.8585
17	3.8035	4.1945	3.9171	4.273		3.7191	.8279
18		4.0962	4.0085	4.1617			.9883
19	3.8035	4.2436	4.1152	4.2379		3.9506	
20			4.2221	4.3724		3.6819	.8279
21		3.9323	3.6528	4.0049		3.4919	
22		3.7209	3.558	3.9952		3.558	.9065
23			3.3448	3.6523			
24	.9602	4.2391	3.3916	3.155	3.5151		3.1152
Max	4.1667	4.6609	4.2221	4.7154	4.2219	3.9506	3.1152
Min	.6773	2.3663	2.0881	2.4966	2.4082	2.4777	.5266
Avg	2.2371	3.6091	3.3909	3.5699	3.3170	3.4379	1.9155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184094 / VADGAON DYANE

Feeder No / Name : 203 / VADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0932	.6935	.4698	.5474	.5506	.2393	.9372
2	1.1176	1.2538	.4924	.5228	.5323	.2393	.9528
3	1.1199	.6874	.4725	.5015	.5514	.2416	1.0214
4	1.1995	1.3655	.5121	.5662	.5624	.2469	1.0189
5	1.3612	.7156	.5525	.65	.5798	.285	1.0615
6	1.6278	1.5443	.5639	.708	.6459	.3323	1.235
7	2.0142	1.038	.6657	.6966	.5921	.3635	1.9623
8	2.5185	2.4687	.5977	.615	.5856	.2995	2.1979
9	2.4516	2.2489	.5666	.4885	.548	.2355	1.8293
10	.9206	.8139	.5536	.482	.5376	.2378	.7147
11	.3665	.4474	.4862	.4691	.4741	.2187	.4238
12	.3566	.4896	2.0987	1.025	.9412	.7933	.2172
13	.4032	.5367	2.0912	2.0393	1.7741	1.0037	.3932
14	.4309	.4971	2.0629	1.9718	1.5547	1.7055	.1997
15	.3844	.4073	1.7551	1.9242	1.3431	1.5135	.3483
16	.4843	.3953	1.5021	1.7448	1.3177	1.3732	.2858
17	.5209	.4556	1.7246	1.7802	.8124	1.4699	.3738
18	.3033	.5502	1.8709	1.752	.8756	.9069	.4435
19	.6188	.5929	1.893	1.8183	.9214	1.7292	.2469
20	.4138	.4214	.9496	.9617	.5525	.784	.6478
21	.3925	.7697	.6051	.6066	.2721	.5033	.3323
22	.3856	.7385	.6051	.65	.2812	.534	.658
23	.3483	.3765	.5807	.6226	.2759	.2698	.3269
24	1.117	.6752	.4658	1.1378	.4973	.5106	1.0159
Max	2.5185	2.4687	2.0987	2.0393	1.7741	1.7292	2.1979
Min	.3033	.3765	.4658	.4691	.2721	.2187	.1997
Avg	.9146	.8410	1.0057	1.0117	.7325	.6682	.7852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184094 / VADGAON DYANE

Feeder No / Name : 204 / VAJIRKHEDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0624	.5312	1.387	1.3054	1.3363	.6897	.9602
2	1.0715	1.0183	1.3584	1.3851	1.3576	.7164	.985
3	1.1347	.538	1.3367	1.3702	1.3618	.7278	1.077
4	1.1873	1.2748	1.4979	1.4405	1.4724	.7331	1.1355
5	1.3929	.6683	1.6201	1.5021	1.5314	.7476	1.2735
6	1.6249	1.5557	1.8721	1.6545	1.9223	.8642	1.6605
7	1.8579	1.0555	2.3068	2.5004	2.3192	1.3237	1.8763
8	1.7208	1.5377	2.8236	2.9427	3.2068	1.5882	1.633
9	1.3426	1.5006	2.4646	2.5907	2.7717	1.5379	1.2151
10	.9924	.9449	.5003	1.0082	.9328	.4786	.9817
11	.6081	.7312	.2469	.7464	.6119	.4153	.7221
12	1.986	2.1856	.5921	.5952	.3132	.3536	1.3024
13	1.334	2.1102	.5746	.5575	.602	.5632	2.1235
14	2.0779	1.9012	.5898	.5693	.5997	.5723	1.2231
15	1.7897	1.6006	.5853	.5822	.615	.6076	1.6953
16	1.7771	1.5814	.5997	.6074	.6249	.6184	1.8736
17	1.9257	2.0839	.611	.5537	.3384	.6539	1.9162
18	1.1919	2.2275	.7392	.6737	.3262	.3666	2.2068
19	2.0069	2.1944	1.1721	1.2681	.5708	1.0825	1.3085
20	.8772	1.7009	1.6727	1.7756	.8878	1.5455	1.4664
21	.82	1.4777	1.4991	1.515	.8215	1.419	.8345
22	.6798	1.2432	1.2905	1.2296	.6729	1.2544	1.1274
23	.6059	.6005	1.1041	1.1093	.6158	.6158	.6135
24	.5898	1.2016	1.278	1.2696	1.2832	.57	1.0082
Max	2.0779	2.2275	2.8236	2.9427	3.2068	1.5882	2.2068
Min	.5898	.5312	.2469	.5537	.3132	.3536	.6135
Avg	1.3191	1.3944	1.2384	1.2814	1.1290	.8352	1.3425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184094 / VADGAON DYANE

Feeder No / Name : 205 / 11 KV VADGAON GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294		.104	.1214	.104		.1294
2	.1109	.132		.1294	.1214		.1294
3	.1294		.1387	.156	.1478		.1478
4	.1663	.1886	.1734	.208	.208		.2033
5	.2402		.2254	.2926	.2772		.2402
6	.2957	.3018	.2774	.2947	.2774		.2772
7	.2587		.1907	.2378	.2587		.2587
8	.1663	.1698	.1663	.2033	.156		.1663
9	.1294	.1214	.0848	.104	.1663		.1698
10	.0914	.1109	.12	.104	.1294		.1509
11	.0867	.0867	.0857	.1294	.0867		.112
12	.0867	.0924	.0867	.1109			
13	.104	.0867		.0867	.0867		.0924
14	.104	.104	.1187		.0867	.1109	
15	.0867	.0924	.0857	.104	.0867	.0924	.0943
16	.0924	.104	.1017		.1214	.0924	.1109
17	.1109	.0924	.1214	.104		.1109	.0924
18		.0867	.1214	.0924			.1109
19	.1698	.1663	.2254	.1214		.1663	
20		.2033	.2012	.156		.2402	.2614
21		.156	.156	.1663		.1848	
22		.1214	.156	.1387		.1663	.1698
23			.1294	.1214			
24	.104	.132	.12	.1294	.1294		.1294
Max	.2957	.3018	.2774	.2947	.2774	.2402	.2772
Min	.0867	.0867	.0848	.0867	.0867	.0924	.0924
Avg	.1402	.1341	.145	.1505	.1527	.1455	.1603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184094 / VADGAON DYANE

Feeder No / Name : 207 / Dyane Ind 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3121		2.3739	3.0727	2.8292		2.5972
2	1.2752	1.5512	2.198	2.9995	2.7435		2.3777
3	1.1088		2.4097	2.8898	2.4249		2.2862
4	1.1827	1.3759	2.2805	2.6337	2.2455		2.2314
5	1.2012		2.2462	2.561	2.3472		2.1948
6	1.2197	1.3795	2.1365	2.5701	2.3834		2.0668
7	1.2437		1.9989	2.5072	2.4177		2.0698
8	1.4266	1.7546	2.3102	2.955	2.6578		1.9589
9	2.268	2.5702	3.1161	3.3093	3.53		1.4594
10	2.4326	2.8509	3.0982	3.155	3.53		1.3394
11	2.3975	3.0691	3.4027	3.195	3.6534		1.2706
12	2.5095	3.086	3.5482	3.3524			
13	1.95	1.906	2.5789	2.9165	2.8833		.9035
14	1.2944	1.4746	2.0452	1.7147	1.9521	1.7741	
15	1.933	2.343	2.9264	2.625	2.9012	2.7435	.6945
16	1.9019	2.8673	3.4202	3.2726	3.4206	3.2556	.9212
17	2.1575	3.0521	3.2922	3.3779		3.4202	1.0179
18		2.9656	3.5482	3.2922			.9482
19	1.8302	2.6543	3.1642	2.7526		3.0361	
20		2.7435	3.2007	2.8509		3.1093	.9349
21		2.6791	3.091	2.769		2.9447	
22		2.4413	2.7618	2.774		2.8898	.9442
23			2.7801	2.4863			
24	1.2936	1.5581	2.3739	3.0178	2.6216		2.7618
Max	2.5095	3.086	3.5482	3.3779	3.6534	3.4202	2.7618
Min	1.1088	1.3759	1.9989	1.7147	1.9521	1.7741	.6945
Avg	1.6810	2.3328	2.7626	2.8771	2.7838	2.8967	1.6304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184218 / 33/11 KV KALWADI

Feeder No / Name : 201 / 11 kv NARDANE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.12				1.5432
2		.1372				1.4575
3		.12				1.3717
4		.2058				1.4232
5		.2229				1.4746
6		.2915				1.5947
7		.3601				1.6804
8		.2743				1.6118
12	.1372					
13					1.7318	
14		.2229			1.5947	
15					.1543	
16	.12				.1372	
17	.1372				.1372	.1029
18	.1886				.2058	.2058
19	.2229				.2401	.2401
20	.2743				.3772	
21	.2229		.1715		.2743	
22	.1715				.1886	
23	.1372				.1372	
24		.1372		.12		1.6289
Max	.2743	.3601	.1715	.12	1.7318	1.6804
Min	.12	.12	.1715	.12	.1372	.1029
Avg	.1791	.2092	.1715	.12	.4708	1.1946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184218 / 33/11 KV KALWADI

Feeder No / Name : 202 / 11 KV KALWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8004				.072
2		1.7318				.6516
3		.168				.6001
4		1.8861				.7716
5		2.0748				1.166
6		2.5206				
7		3.0007				
8		3.0178	3.035			
9		2.6578				
10		.7545				
11		.072				
12	3.3779	.6516				
13		.6687			.6687	
14		.6516			.6859	
15					.703	
16	3.2065				.703	
17	3.2236				.6859	3.3093
18	3.0007				.9945	3.1722
19	2.8121				1.3203	2.3148
20	1.5089				1.5604	
21	1.2174		1.0802		1.406	
22	1.0631				.108	
23	.7716				.8916	
24		1.9376		2.1091		.0754
Max	3.3779	3.0178	3.035	2.1091	1.5604	3.3093
Min	.7716	.072	1.0802	2.1091	.108	.072
Avg	2.2424	1.5729	2.0576	2.1091	.8843	1.3481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184218 / 33/11 KV KALWADI

Feeder No / Name : 203 / 11 KV CHINCHGAVAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3258				1.2346
2		.3429				1.166
3		.3944				1.2689
4		.4973				1.4575
5		.6001				1.6118
6		.7888				1.9719
7		.8916				1.3717
8		.7202	.583			1.9204
9		.5658				
10		.3944				
12	.3944					
13		.2401			.2229	
14		.1886			.2058	
15					2.2634	
16	.3772				2.3834	
17	.0412				2.4691	.4115
18	.5487				2.1262	.4115
19	.7202				1.9204	.6173
20	.8916				.823	
21	.6687		.5144		.6173	
22	.5144				.463	
23	.4115				.3772	
24		.3429		.3429		1.286
Max	.8916	.8916	.583	.3429	2.4691	1.9719
Min	.0412	.1886	.5144	.3429	.2058	.4115
Avg	.5075	.4841	.5487	.3429	1.2611	1.2274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184218 / 33/11 KV KALWADI

Feeder No / Name : 204 / 11 KV GIRNA DAM CHALISGAON NON SHEDDABLE EXPRESS HV FEEDERS
WAT Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343				.0343
2		.0343				.0034
3		.0343				.0343
4		.1886				.0343
5		.1886				.1886
6		.1886				.1886
7		.1886				.1886
8		.1886	.0857			.1886
12	.1886	.1886				
13					.1886	
14					.0686	
15					.1886	
16	.1886				.1886	
17	.0343				.1886	.1715
18	.0343				.3772	.1715
19	.1886				.1715	.1715
20	.1886				.3601	
21	.0343		.1715		.0343	
22	.0343				.0189	
23	.0343				.0343	
24		.0514		.1715		.0343
Max	.1886	.1886	.1715	.1715	.3772	.1886
Min	.0343	.0343	.0857	.1715	.0189	.0034
Avg	.1029	.1286	.1286	.1715	.1654	.1175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184243 / Aayeshanagar

Feeder No / Name : 201 / Aayeshanagar 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4161	1.6461	1.595	1.6118	1.6118		1.4413
2	.2572	1.6118	1.4899	1.5432	1.56		1.3904
3	.2254	1.6118	1.5775	1.3717	1.4737		1.3735
4	.2103	1.5257	1.4217	1.3375	1.3546		1.3226
5	.2481	1.4198	1.3496	1.283	1.283		1.1869
6	.2601	1.2269	1.2094	1.2309	1.2445		1.0974
7	.2835	1.1043	1.1919	1.2269	1.3696		.9774
8		1.2269	1.2094	1.3176	1.2971		.7712
9	1.1961	1.4022		1.5089			.7537
10	1.3927	1.5604		1.5257			.6556
11	1.2289	1.6461	1.5083	1.6126	1.4918		.4835
12	1.0608	1.6632	1.6804	1.6991	1.6221		
13	1.3426		1.5947	1.4918	1.5089	1.3763	
14	1.0343	1.0566	1.134	1.1269	.9259	.9259	.2012
15	1.21	1.262	1.3375	1.4575	1.3565	1.3375	.2033
16	1.4089	1.6461	1.5432	1.5777	1.4586		.4477
17	1.5261	1.647	1.7147	1.6124	1.5432	1.4586	.5731
18	1.6118	1.7164	1.749	1.6817		1.5083	.591
19	1.5432	1.749	1.9204	1.9105		1.6078	.6268
20	1.5777	1.8031	1.9033	1.8378		1.6741	.7265
21	1.6124	1.7511	1.6804	1.7661		1.5912	.5493
22	1.6817	1.7857	1.6461	1.7528		1.5415	.567
23	1.5261	2.5434	1.6118	1.6991		1.4918	.4961
24	.4973	1.6632	1.6461	1.5604	1.6991		1.442
Max	1.6817	2.5434	1.9204	1.9105	1.6991	1.6741	1.442
Min	.2103	1.0566	1.134	1.1269	.9259	.9259	.2012
Avg	1.0153	1.5769	1.5325	1.5310	1.4250	1.4513	.8126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184243 / Aayeshanagar

Feeder No / Name : 202 / Aksa Colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6836	2.4348	2.34	2.3908	2.4646		2.3148
2	.4854	2.4006	2.2043	2.1776	2.4078		2.332
3	.4334	2.3663	2.3148	2.3148	2.3148		2.4348
4	.4031	2.3491	2.2805	2.2291	2.2961		2.2634
5	.4252	2.2805	2.1325	2.2634	2.2018		2.2365
6	.4557	2.0978	2.2885	2.1948	2.1262		2.0683
7	.4733	1.8755	2.0858	2.2365	2.0978		1.7878
8		2.0978	2.2119	2.191	2.3059		1.6289
9	2.2542	2.5774	2.7978	2.5819			1.7375
10	2.4366	2.8166	2.7183	2.713			1.647
11	2.6189	2.8509	2.8509	2.982	2.8487		1.2489
12	2.7469	3.0013		3.1375	2.8656		
13	2.6063		2.2805	2.6452	2.572	2.5774	
14	2.0631	1.5238	2.2119	1.8004	2.0022	1.858	.4805
15	2.3061	1.9418	2.5943	2.3739	2.3752	2.2611	.4294
16	2.6155	2.6825	2.5819	2.6155	2.5377	2.5206	.8507
17	2.6658	2.7831	2.6993	2.7808		2.6406	.9511
18	2.7328	2.6791	2.7978	2.7496		2.692	.8669
19	2.6452	2.6452	2.6621	2.73		2.7435	1.0056
20	2.6113	2.6993	2.6825	2.5987		2.6235	1.0229
21	2.5943	2.536	2.5943	2.6113		2.6406	1.0056
22	2.5377	2.5774	2.5604	2.6699		2.5549	.9709
23	2.4417		2.5265	2.6235		2.6749	1.0056
24	.8962	2.4756	2.5434	2.5774	2.5095		2.5206
Max	2.7469	3.0013	2.8509	3.1375	2.8656	2.7435	2.5206
Min	.4031	1.5238	2.0858	1.8004	2.0022	1.858	.4294
Avg	1.8318	2.4406	2.4765	2.5079	2.3951	2.5261	1.4914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184243 / Aayeshanagar

Feeder No / Name : 203 / Ayesha Nagar 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	2.8045	2.572	2.6578	2.8959		2.5072
2	.724	2.6292	2.572	2.6578	2.8349		2.5072
3	.5373	2.2786	2.6578	2.6578	2.6863		2.5072
4	.543	2.2786	2.5072	2.4806	2.5339		2.5873
5	.5487	2.4806	2.5072	2.4806	2.4539		2.4025
6	.905	2.6578	2.5339	2.3034	2.3282		2.2177
7	1.2803	2.6578	2.8959	2.6578	2.7149		2.4025
8		3.155	3.155	3.2236	3.2922		2.6406
9	3.0864	3.5056	3.5056	3.7209			2.9569
10	3.2579	3.6408	3.4675	3.5818			2.8292
11	3.4294	3.6408	3.6408	3.9819	3.8142		2.452
12	3.8142	3.9438	3.9438	4.2981	3.9438		
13	3.6808			3.5437	3.5056	3.4675	
14	2.3529	2.2634	2.3282	2.1719	2.2177	2.1948	1.1317
15	2.6292	3.155	3.155	2.8045	2.8654	2.6863	.9431
16	2.774	3.155	3.2579	3.1207	3.155		.9335
17	3.5056	3.2941	3.4294	3.5437		3.155	.9145
18	3.6408	3.6408	3.6408	3.8009		3.6808	1.086
19	3.6008	3.6408	3.6408	3.7209		3.6808	1.307
20	3.4294	3.6008	3.4675	3.5818		3.6808	1.2536
21	3.2941	3.3303	3.2941	3.2579		3.3303	1.0745
22	2.9797	2.9797	3.155	3.0445		3.0121	.8954
23	2.8045	2.9797	2.8045	2.9797		2.8349	.8859
24	.905	2.8045	2.6292	2.8045	2.8045		2.8045
Max	3.8142	3.9438	3.9438	4.2981	3.9438	3.6808	2.9569
Min	.5373	2.2634	2.3282	2.1719	2.2177	2.1948	.8859
Avg	2.3673	3.0660	3.0766	3.1282	2.9364	3.1723	1.8745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184244 / Malgaon

Feeder No / Name : 201 / 11 KV MALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9955	4.2482	1.2742	1.2387	.6676	.663	3.7365
2	4.0766	4.2774	1.2681	1.2238	.6661	.6737	3.8222
3	4.0502	4.3311	1.3434	1.275	.7042	.695	3.9155
4	4.0442	4.4313	1.4769	1.561	.791	.8063	3.9897
5	4.2412	4.6152	1.768	1.8297	.9313	.9252	4.2082
6	4.7968	5.0263	.5319	1.041	1.0014		4.5801
7	5.7685	5.7588					5.1452
8	6.0104	5.9954					5.5344
9	5.4279	5.4209					5.1329
10	.0945	.0671					.2012
12			5.3536	4.6255	2.364	4.9497	
13			5.3435	4.7549	4.8821	5.0368	
14			5.0683	4.8182	2.5149	4.9993	
15			4.9667	4.7059	2.4798	4.8587	
16	.9076	.9221	5.0089	4.9555	4.6791	5.0063	.9935
17	.9567	.9034	5.2123	5.089	5.0937	4.9367	1.0448
18	1.0785	1.0229	5.1247	4.9442	2.649	4.7931	1.3296
19	1.6331	1.6827	5.2033	4.6511	2.6901	4.6464	1.8263
20	1.9748	2.0789	2.1247	2.1897	1.2483	2.3061	2.3737
21	1.6272	1.7834	1.9674	1.868	1.1706	1.9877	1.9953
22	1.4645	1.6065	1.6931	1.6185	.9419	1.5989	1.5699
23	1.2094	1.3938	1.4889	1.4891	.791	1.315	1.2531
24	4.0208	2.6519	1.2895	1.301	1.2645	1.8762	3.5905
Max	6.0104	5.9954	5.3536	5.089	5.0937	5.0368	5.5344
Min	.0945	.0671	.5319	1.041	.6661	.663	.2012
Avg	3.0199	3.0641	3.0267	2.9042	1.9753	2.8930	2.9601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184244 / Malgaon

Feeder No / Name : 202 / 11 KV KHYADE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5937	.5382	1.6934	1.4556	.8977	.7583	.5438
2	.574	.5469	1.6629	1.501	.8977	.7644	.5603
3	.5644	.5272	1.664	1.5328	.8924	.7606	.5571
4	.586	.5557	1.6835	1.5141	.9046	.7674	.5769
5	.6049	.5565	1.7352	1.6018	.9214	.8116	.5807
6			1.8965	1.7297	.945	.9297	
7			2.0377	2.0306	2.2015	1.1408	
8			2.0435	2.2999	2.2501	1.1728	
9			1.1469	2.1212	2.1378	1.1751	
10				.0373		.0236	
11	.0053						.0236
12	2.6086	2.2855					2.3341
13	3.0724	2.4962					2.4085
14	3.084	2.5221					2.11
15	3.0699	2.5122	.0053	.003	.0061		1.9899
16	3.027	2.3678	.2456	.2588	.2695	.285	1.9673
17	2.5416	2.2191	.2496	.265	.2415	.2694	2.2085
18	2.3258	2.2192	.2471	.2573	.1357	.2532	1.3913
19	2.2198	2.0382	.3745	.3277	.1844	.3971	.3579
20	.5364	.5091	.5415	.5548	.2911	.6203	.5443
21	.5522	.5579	.5504	.5297	.3155	.6413	.545
22	.5962	.5586	.5453	.5896	.3109	.5899	.6133
23	.5871	.4672	.527	.5577	.2957	.5968	.5959
24	.5571	1.1261	1.5211	1.5114	1.4764	.3041	.5297
Max	3.084	2.5221	2.0435	2.2999	2.2501	1.1751	2.4085
Min	.0053	.4672	.0053	.003	.0061	.0236	.0236
Avg	1.4582	1.3669	1.0722	1.0340	.8197	.6453	1.0757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184263 / 33/11 KV SAYANE

Feeder No / Name : 201 / 11 KV SPINNING MILL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.2267	.1898	.08	.1581
9	.2743				.1715
10	.407				
11	.7011				
12	.7316				
13	.7316				
14	.6516				
15	.6516				
16	.6516	.5175			.1219
24			.1829		
Max	.7316	.5175	.1898	.08	.1715
Min	.2743	.2267	.1829	.08	.1219
Avg	.6001	.3721	.1864	.08	.1505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184263 / 33/11 KV SAYANE

Feeder No / Name : 202 / 11 kv Sayne Industrial SHEDDABLE FEEDER HAVING WEEKLY
 Feeder Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.2347	.4717	.5213	.5746	.5952	.676
2	.5335	.2324	.4618	.4938	.5312	.5746	.6508
3	.5525	.2286	.4618	.5182	.5487	.5891	.6333
4	.5533	.25	.4649	.49	.474	.5906	.6272
5	.5213	.2545	.4618	.4976	.4268	.5571	.6066
6	.5281	.2484	.4755	.519	.4618	.5685	.6142
7	.5022	.3048	.4931	.5418	.5205	.6318	.6219
8	.4679	.3117	.5243	1.0966	.57	.5761	1.1767
9	.7663	.4954	.6874	.7179	.8017	.7941	1.5166
10	.7331	.5883	.8368	.9549	.8863	.9221	.7895
11	.6646	.6843	.8703	.929	.9153	.8672	.8284
12	.5705	.6943	.8505	.9099	.8802	.9412	.8352
13	.4946	.6485	.7392	.8657	.7567	.8497	.7293
14	.603	.647	.6737	.7621	.7613	.833	.6927
15	.6744	.6676	.9328	.9023	.8505	.9267	.7773
16	.5403	1.3382	.9099	.8307	.9023	.9198	1.5474
17	.3582	.6569	.9503	.8833	.8871	.9541	.7796
18	.3445	.6805	.8711	.8733	.8886	.9991	.7857
19	.3429	.5731	.7964	.7004	.8109	.7895	.708
20	.3125	.5053	.6302	.6447	.7316	.7247	.6295
21	.2599	.4847	.5639	.599	.6683	.6752	.5556
22	.2843	.4733	.5578	.5396	.6234	.6805	.5045
23	.2888	.4557	.5426	.554	.6569	.679	.4809
24	.2759	.471	.5777	1.0257	.5914	.6828	.4938
Max	.7663	1.3382	.9503	1.0966	.9153	.9991	1.5474
Min	.2599	.2286	.4618	.49	.4268	.5571	.4809
Avg	.4873	.5054	.6586	.7238	.6967	.7467	.7609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184263 / 33/11 KV SAYANE

Feeder No / Name : 203 / 11kv Daregaon1 (Old)
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-17	09-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			3.5665	2.7357
9	3.0864			2.8995
10	3.2606			
11	3.5555			
12	3.5439			
13	3.3913			
15	3.0521			
16	3.2693	3.9487		1.1128
24			3.4408	
Max	3.5555	3.9487	3.5665	2.8995
Min	3.0521	3.9487	3.4408	1.1128
Avg	3.3084	3.9487	3.5037	2.2493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184263 / 33/11 KV SAYANE

Feeder No / Name : 204 / 11kv Dasane feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.8962	1.0974	
12	.759				
13	.823				
14	.7316				
15	.6706				
16	.6706	.6554			.6097
24			.5243		
Max	.823	.6554	.8962	1.0974	.6097
Min	.6706	.6554	.5243	1.0974	.6097
Avg	.7310	.6554	.7103	1.0974	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184263 / 33/11 KV SAYANE

Feeder No / Name : 206 / 11kv Daregaon2 (New)
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-17	09-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			2.5057	.852
9	2.3243			.9465
10	2.0972			
11	2.3834			
12	2.4013			
13	2.3491			
14	2.1033			
15	1.8755			
16	2.0809	2.0233		1.4449
24			2.0805	
Max	2.4013	2.0233	2.5057	1.4449
Min	1.8755	2.0233	2.0805	.852
Avg	2.2019	2.0233	2.2931	1.0811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184263 / 33/11 KV SAYANE

Feeder No / Name : 207 / 11kv Chalisgaon Phata
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-17	09-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.3067	.4031	.3441
9	.381			.3012
10	.3113			
11	.2454			
12	.2229			
13	.2204			
14	.2303			
15	.2126			
16	.3012	.2507		.2743
24			.2401	
Max	.381	.3067	.4031	.3441
Min	.2126	.2507	.2401	.2743
Avg	.2656	.2787	.3216	.3065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184263 / 33/11 KV SAYANE

Feeder No / Name : 209 / 11kv Chikalohol feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0883	.9572	1.0029	1.1599	1.1767	1.1446	1.0943
2	1.1004	.9511	1.0044	1.1538	1.1721	1.1614	1.0943
3	1.102	.9541	.9435	1.1965	1.2178	1.2132	1.0928
4	1.1264	.9968	.9572	1.3214	1.3001	1.2894	1.1126
5	1.1767	1.0517	.9694	1.387	1.4266	1.3184	1.0654
6	1.262	1.134		1.419	1.4693		1.1416
7	1.7436	1.5973		.1677			1.608
8	1.829	3.3699					2.9923
9	2.6383	1.6491					2.7814
10							.5594
11			.1113	.2058	.1463	.1661	.6859
12			1.326	1.2757	1.3535	1.3184	
13			1.6004	1.2605	1.3794	1.1218	
14			1.4297	1.1782	1.2209	1.1751	
15			1.137	1.1203	1.1355	1.0761	.2743
16	1.7494	1.1671	1.1538	1.1523	1.1507	.8886	1.8061
17	.9191	.6173	1.4083	1.291	1.2224	1.3778	.913
18	.9069	.8825	1.4312	1.3138	1.3123	1.3535	.9541
19	1.3306	1.2986	1.5135	1.4068	1.3611	1.4495	1.3199
20	1.5531	1.4845	1.6324	1.5364	1.4739	1.5821	1.608
21	1.4891	1.4373	1.5912	1.483	1.483	1.4632	1.5089
22	1.3504	1.3809	1.4601	1.4388	1.3748	1.3824	1.3169
23	1.1584	1.2925	1.3428	1.3641	1.2955	1.2361	1.2087
24	1.0501	1.0867	1.2163	2.3445	1.1995	1.1355	1.0852
Max	2.6383	3.3699	1.6324	2.3445	1.483	1.5821	2.9923
Min	.9069	.6173	.1113	.1677	.1463	.1661	.2743
Avg	1.3652	1.2949	1.2227	1.2465	1.2436	1.2028	1.2963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184263 / 33/11 KV SAYANE

Feeder No / Name : 210 / 11kv Pawar Wadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			1.9814	1.387
9	2.2862			1.4175
10	2.2539			
11	2.572			
12	2.3739			
13	2.4539			
14	2.2939			
15	2.2291			
16	2.1338	1.829		.8859
24			2.2939	
Max	2.572	1.829	2.2939	1.4175
Min	2.1338	1.829	1.9814	.8859
Avg	2.3246	1.829	2.1377	1.2301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184263 / 33/11 KV SAYANE

Feeder No / Name : 211 / 11 KV WATER SUPPLY 2 (New) NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-APR-17	09-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.0025	.0025
9	.0686			.0019
10	.0025			
11	.0025			
12	.0019			
13	.0025			
14	.0025			
15	.0025			
16	.0025	.0025		.0025
24			.0025	
Max	.0686	.0025	.0025	.0025
Min	.0019	.0025	.0025	.0019
Avg	.0107	.0025	.0025	.0023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184263 / 33/11 KV SAYANE

Feeder No / Name : 212 / dr.hire cluster

Feeder KV- 11 / INCOMING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1875	.2273	.1212	.1818	.132	.128	.1701
2	.1456	.2155	.1155	.164	.1303	.1158	.1459
3	.14	.1945	.1259	.1484	.1254	.0775	.1332
4	.144	.1747	.1156	.1671	.1223	.0734	.1457
5	.1438	.1871	.1198	.1336	.14	.0676	.1484
6	.1454	.2027	.1337	.1364	.1383	.0707	.1357
7	.1372	.2115	.1419	.1416	.1307	.0714	.1187
8	.1168	.1711	.128	.2367	.1282	.0648	.1724
9	.2726	.2199	.2271	.2404	.2389	.2084	.1898
10	.446	.218	.2484	.2389	.2366	.237	.093
11	.5085	.2528	.2709	.277	.2932	.2401	.0831
12	.506	.2905	.3149	.2862	.293	.2759	.1019
13	.5184	.285	.3029	.301	.29	.2757	.065
14	.5034	.2894	.2761	.2987	.2844	.2349	.0772
15	.5163	.2631	.3016	.2959	.293	.2566	.0772
16	.5957	.4586	.2814	.3115	.3111	.2997	.1587
17	.3393	.2378	.2736	.3128	.3147	.294	.076
18	.33	.2608	.3184	.3302	.318	.3035	.0735
19	.3151	.2698	.3248	.3022	.3224	.2833	.0732
20	.289	.1898	.2818	.2869	.3079	.2732	.033
21	.2728	.1336	.2526	.1945	.2324	.2732	.0326
22	.2671	.1263	.2585	.2075	.2176	.2721	.0312
23	.2589	.1076	.2561	.2014	.1861	.2296	.032
24	.2298	.1195	.189	.3142	.1393	.1924	.0332
Max	.5957	.4586	.3248	.3302	.3224	.3035	.1898
Min	.1168	.1076	.1155	.1336	.1223	.0648	.0312
Avg	.3054	.2211	.2242	.2379	.2219	.2008	.1000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184264 / 33/11 KV TINGRI

Feeder No / Name : 201 / 11 KV DAHIDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.5415	.8192	.8002			.6136
2	.5975	.5521	.8573	.8215			.6495
3	.6722	.6355	.8954	.8686			.6887
4	.7468	.7138	.9526	.9709			.6965
5	.8029	.8257	1.0269	1.0642			.7446
6	.961	.8632	1.061	1.1389			.8078
7	.8779	1.5576	1.1203	1.2003			1.4277
8	1.9204	1.7668	.9335	.9526			1.621
9	.9526	.8937	.8215	.8573			1.0164
10	.6668	.7319	.6535	.7811	1.0456		.8192
11	.5975	.6478	.7842	.6535	.6455		.7621
12	.5601	.5335	1.307	1.0903	1.1016	1.0926	.6979
13	.5601	.5335	1.0829	.8871	.9522	.9335	.6413
14	.5041	.5228	.9145	.8131		.8215	.6224
15	.6275	.5335	.8589	.7577		.7484	.6036
16	.5641	.5335	.9896	.961		1.0144	.6224
17	.5636	.5525	1.2382	1.1273		1.2398	.6478
18	.6348	.6668	1.2323	1.1458		1.0729	.8383
19	1.0895	1.0669		1.105			1.1622
20	.9896	1.0669	1.1622	1.0288		1.1271	.9526
21	.8962	.9717	1.2193	.9717		1.167	1.0288
22	.9149	.8573	1.0479	.9145		.9768	.9907
23	.5788	.5239	.8764	.8383		.8069	.6036
24	.5975	.5636	.7811		.8192		.5944
Max	1.9204	1.7668	1.307	1.2003	1.1016	1.2398	1.621
Min	.5041	.5228	.6535	.6535	.6455	.7484	.5944
Avg	.7713	.7773	.9842	.9456	.9128	1.0001	.8272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184264 / 33/11 KV TINGRI

Feeder No / Name : 202 / 11 KV TINGARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2454	.2801	.4066	.4854	.4133		.3388
2	.2268	.3174	.4854	.5228	.4504		.3757
3	.2457	.3388	.5228	.5788	.4869		.4137
4	.2646	.3765	.6099	.6212	.5987		.4668
5	.3021	.4133	.6722	.6535	.6701		.5963
6	.3584	.5072	.679	.6535	.7453		
7	.3961	.4508	.9795	.8589	1.0269		
8	.4141	.3569	.9055	1.0829	.8333		.4467
9	.3027	.4251	.6287	.3921			.6535
10	.4919	.4091	.5144	.4668	.3361		.5823
11	.5453	.5975	.2241	.2445	.2635		.4508
12	.7073	.8029	.2427	.1879	.2772	.2066	.8385
13	.6535	.6958	.362	.1692	.2846	.2818	.8704
14	.7124	.6224	.3429	.2071		.2467	.8342
15	.6468	.6161	.362	.2071		.2818	.7585
16	.7207	.5975	.3429	.2263		.3006	
17	.6515	.6908	.3429	.2832		.3742	.963
18	.7468	.7095	.381	.2457		.3949	.9297
19	.7468	.6859	.8589	.8324		.8274	.7356
20	.8829	.7762	.9149	.9081		.8266	.8127
21	.5975	.6287	.6859	.6066		.6212	.6054
22	.5041	.4382	.5525	.5113		.4889	.5108
23	.3193	.4294	.2957	.5281		.2402	.3591
24	.2643	.32	.3734		.3555		.2981
Max	.8829	.8029	.9795	1.0829	1.0269	.8274	.963
Min	.2268	.2801	.2241	.1692	.2635	.2066	.2981
Avg	.4978	.5203	.5286	.4988	.5186	.4242	.6115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184264 / 33/11 KV TINGRI

Feeder No / Name : 203 / 11 KV HATANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.5641	.4481	.3361			.6387
2	.6097	.6017	.4481	.3921			.6387
3	.6287	.7522	.5228	.4294			.6577
4	.6859	.8257	.5415	.4668			.7334
5	.8192	.9383	.5601	.5041			.789
6	.9145	1.0353	.5601	.5415			.711
7	.9054	1.0154	.8215	.9335			.9402
8		.8194	.9709	1.1088	1.0059		.871
9	.8764	.7655	.7522	.7842			.7655
10	.7621	.5359	.5788	.6036	.5601		.6568
11	.4632	.2801	.5041	.4894	.4701		.4294
12	.7655	.5975	.394	.4133	.4481	.4435	.8316
13	.5865	.4904	.3761	.3385	.3921	.4481	.7762
14	.58	.4854	.3696	.3395		.4108	.5544
15	.5902	.5601	.3326	.3584		.4141	.6283
16	.6086	.5415	.3734	.4158		.4183	.6653
17	.6951	.5914	.4108	.473		.3945	.4066
18	.7882	.6348	.4527	.4914		.5426	.8131
19	.9026	.8029	.8501	.9145		.8606	.9335
20	.9976	.9202	.9896	1.0669		.964	.9335
21	.8962	.8402	.8215	.8764		.8829	.8764
22	.7193	.6461	.6979	.724		.7282	.7049
23	.6161	.6023	.3881	.3921		.4294	.6097
24	.6097	.5823	.3361		.4668		.6212
Max	.9976	1.0353	.9896	1.1088	1.0059	.964	.9402
Min	.4632	.2801	.3326	.3361	.3921	.3945	.4066
Avg	.7239	.6845	.5625	.5823	.5572	.5781	.7161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184264 / 33/11 KV TINGRI

Feeder No / Name : 204 / 11 KV GALANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3945	.7095	1.0164			.2635
2	.3048	.3378	.7529	1.0829			.2818
3	.3048	.3378	.8757	1.1763			.3009
4	.3429	.3765	.9335	1.2071			.32
5	.362	.4133	.9307	1.2975			.3193
6	.381	.4229	.9431	1.307			.3392
7	.4001	.4133	1.6827	1.7683			.3547
8	.3395	.3174	1.6804	2.0911	1.6461		.2987
9	.3429	.2254	.1143	.1334			.2852
10	.2096	.3006	.1715	.1715	.1898		.2277
11	.9522	.823	.1905	.1905	.1691		.5228
12	1.8222	1.5364	.1524	.2075	.1691	.2054	1.7372
13	1.9044	1.643	.1715	.1886	.2241	.2252	1.7558
14	1.5623	1.5364	.2477	.1886		.244	.8779
15	1.4723	1.5729	.1905	.2075		.2252	1.4266
16	1.5013	1.4784	.1905	.2075		.2252	1.3717
17	1.5644	1.6817	.2096	.2263		.2252	1.3169
18	1.6012	1.587	.2096	.2263		.2442	1.2071
19	.2241	.2096	.3048	.381		.4321	.2286
20	.4108	.4191	.381	.4382		.4879	.3429
21	.4294	.4191	.3772	.381		.4481	.381
22	.4321	.3547	.3239	.3239		.3757	.362
23	.4133	.3429	.7468			.5729	.362
24	.3429		1.0164		.9522		.2818
Max	1.9044	1.6817	1.6827	2.0911	1.6461	.5729	1.7558
Min	.2096	.2096	.1143	.1334	.1691	.2054	.2277
Avg	.7477	.7454	.5628	.6554	.5584	.3259	.6319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (RSD)[266] BU 6424

Substation No/ Name :- 184264 / 33/11 KV TINGRI

Feeder No / Name : 205 / 11 KV VANAPAT KAULANE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0466	.5987	.3012	.3734	.3213		.7153
2	1.0103	.6387	.32	.3734	.3027		.7282
3	1.0051	.6763	.3511	.4066	.3216		.8376
4	1.1552	.7842	.3921	.4286	.3595		.964
5	1.4474	.9149	.4481	.4668	.3969		1.315
6	1.7778	1.1271	.5082	.5041	.4536		1.4465
7	2.4427	2.0732	.5788	.5041	.3776		2.1603
8	2.5869	2.1576	.3921	.3953	.2826		1.6389
9	.2273	.2241	.4294	.2829			.1475
10	.2083	.2442	.2824	.2427	.263		.2772
11	.1655	.112	.1867	1.2087	.9946		.2636
12	.1475	.0934	2.0485	1.8347	1.6745	1.6397	.1503
13	.1103	.168		1.8492	1.4277	1.3817	.1316
14	.112	.1867	1.419	1.7741		1.1529	.1128
15	.1521	.1867	1.2986	1.5945		1.0031	.1506
16	.2054	.1867	1.5684	1.776		1.0774	.2254
17	.2241	.2054	1.7551	1.8839		1.3512	.2257
18	.1844	.1694	1.848	1.8309		1.419	.3193
19	.4481	.3921	.3475	.2835		.1692	.4725
20	.6161	.5175	.5788	.4356		.2993	.5492
21	.4108	.4329	.4294	.4545		.3323	.5113
22	.2818	.3881	.4066	.473		.2954	.3788
23	.4668	.4706	.4294	.3402		.2241	.6749
24	.9875	.5902	.4481		.3598		.3905
Max	2.5869	2.1576	2.0485	1.8839	1.6745	1.6397	2.1603
Min	.1103	.0934	.1867	.2427	.263	.1692	.1128
Avg	.7258	.5641	.7290	.8572	.5796	.8621	.6161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) DIV.[264] BU 0426

Substation No/ Name :- 184044 / OLD POWER HOUSE

Feeder No / Name : 201 / Express water supply (PWW) NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2829	.2054		.1829	.2641	
2	.2254		.1867		.1829	.2641	
3	.2801				.2743	.2829	
4	.2829				.2772	.2829	
5					.2743		
6	.3547		.2801		.3696		
7	.3734	.3395	.3734		.4108	.3547	
8	.3584	.3395	.3734		.3734	.3658	.2829
9	.3734		.3921	.3001	.2641	.3696	.3018
10				.3734	.3696	.3174	.3801
11			.3734	.4024	.3734	.3881	.3174
12		.3768	.3206	.439	.2452	.4435	.3142
13			.3584	.439	.2263	.4207	.2987
14			.2263	.4066	.2987	.4163	.2263
15					.3696		.3292
16		.3856		.3982	.462	.4435	.3696
17		.4251		.4024	.4435	.439	.4119
18	.4251	.4251		.4251	.4435	.4435	.4075
19	.4066	.4481		.4207	.4344	.439	.4031
20	.3506	.439		.4163	.4207	.439	.3988
21	.3506	.3395		.4207	.4207	.3921	
22	.4207	.3292		.4163	.3658	.3547	.3403
23		.3734			.3841	.2801	.3189
24	.1829	.2829	.2054		.2641	.2263	.2075
Max	.4251	.4481	.3921	.439	.462	.4435	.4119
Min	.1829	.2829	.1867	.3001	.1829	.2263	.2075
Avg	.3267	.3682	.2996	.4046	.3388	.3632	.3318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) DIV.[264] BU 0426

Substation No/ Name :- 184044 / OLD POWER HOUSE

Feeder No / Name : 202 / KIDWAI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7455	.8669	.8764		.9492	.7802	
2	.6935		.9335		.9145	.7712	
3	.8145				.924	.7682	
4	.8316				.924	.7362	
5					.924		
6	.7865		.8764		.9145		
7	.7499	.8507	.8596		.924	.7316	
8	.788	.9511	.8238		.9795	.8413	1.1523
9	.929		1.0056	.9774	1.0745	.8413	1.1643
10			1.0387	1.086	1.0029	.9955	1.0277
11			1.1584	1.2567	1.1765	1.2136	1.1203
12		1.2631	1.2197	1.4815	1.2851	1.3443	1.1827
13			1.2254	1.39	1.2803	1.1403	1.2357
14			1.0208	1.2178	1.1222	1.1041	1.0099
15					1.086		1.086
16		1.153		1.2308	1.1222	1.1088	.9492
17		1.2536		1.2567	1.1523	1.1765	.9955
18	1.3432	1.1641		1.2803	1.1888	1.2308	1.0387
19	1.5384	1.386		1.5746	1.3756	1.3352	1.2357
20	1.4175	1.3213		1.5746	1.4118	1.4266	1.2894
21	1.4327	1.2934		1.5746	1.3421	1.386	1.2269
22	1.379	1.166		1.3575	1.2071	1.267	1.1043
23		.985			.9955	1.182	1.0029
24	.8328	1.0631	.9036		1.0208	.8775	.9568
Max	1.5384	1.386	1.2254	1.5746	1.4118	1.4266	1.2894
Min	.6935	.8507	.8238	.9774	.9145	.7316	.9492
Avg	1.0202	1.1321	.9952	1.3276	1.0957	1.0599	1.1046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) DIV.[264] BU 0426

Substation No/ Name :- 184044 / OLD POWER HOUSE

Feeder No / Name : 203 / POWER HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4718	2.8292	2.8006		3.0178	2.999	
2	.828		2.8006		2.9874	2.9613	
3	.9002				2.9874	2.9235	
4	.9492				2.894	2.9235	
5					2.8006		
6	.8722		2.2862		2.8006		
7	.8905	2.3339	2.5423		2.452	2.4646	
8	1.4952	2.5463	2.5953		2.5206	2.584	1.9919
9	2.9047		3.0123	2.4177	3.0178	3.1367	2.0567
10			3.3234	3.2674	3.3234	3.263	1.8861
11			3.4168	3.3836	3.4189	3.4189	2.2365
12		3.6923	3.6397	3.5113	3.77	3.7494	1.5356
13			3.4355	3.5113	3.5475	3.5288	1.383
14			2.584	2.6406	2.6783	2.5766	.9816
15					2.9424		1.4137
16		3.4385		3.4541	3.3794	3.4355	1.3336
17		3.5848		3.4189	3.6035	3.3471	1.5813
18	3.5113	3.4928		3.3265	3.5662	3.4004	1.3717
19	3.5113	3.4189		3.5113	3.4743	3.3981	1.5158
20	3.5113	3.5852		3.5113	3.4915	3.4004	1.5352
21	3.4541	3.2487		3.4541	3.4743	3.1276	1.3603
22	3.2674	3.0678		3.2674	3.3008	2.999	1.3908
23		2.999			3.3385	2.9754	1.7896
24	1.4098	3.0178	3.0933		3.1121	3.0178	3.0367
Max	3.5113	3.6923	3.6397	3.5113	3.77	3.7494	3.0367
Min	.828	2.3339	2.2862	2.4177	2.452	2.4646	.9816
Avg	2.0698	3.1735	2.9608	3.2827	3.1625	3.1253	1.6706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) DIV.[264] BU 0426

Substation No/ Name :- 184044 / OLD POWER HOUSE

Feeder No / Name : 204 / MOMIN PURA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3073	2.5206	2.5766		2.6139	2.5953	
2	1.0623		2.5503		2.6139	2.4086	
3	1.0467				2.6406	2.3899	
4	1.0212				2.5206	2.4143	
5					2.452		
6	.9063		2.1948		2.4272		
7	1.1294	1.9805	2.2546		2.1691	2.1691	
8	1.439	2.3577	2.3388		2.452	2.4897	2.4253
9	2.5463		3.0678	2.2382	3.0178	3.0862	2.5423
10			3.2341	3.2674	3.3794	3.1971	2.3891
11			3.271	3.4751	3.3819	3.4751	2.2207
12		3.5848	3.6408	3.6961	3.6591	3.6397	2.1498
13			3.4019	3.658	3.4374	3.308	1.8404
14			2.3388	2.5463	2.5652	2.5652	1.2803
15					2.6699		1.2489
16		2.9199		2.9569	2.9199	2.9081	1.3253
17		2.955		3.2007	3.0493	3.095	1.3889
18	3.1674	3.1161		3.2007	3.2373	3.276	1.6409
19	3.3265	3.2398		3.4751	3.3819	3.2526	1.7737
20	3.0493	3.4208		3.4751	3.4202	3.2556	1.6804
21	2.9569	3.0045		3.3836	3.1232	3.1367	1.531
22	2.8645	2.846		3.0178	3.006	3.0367	1.6032
23		2.6326			2.95	2.652	1.6787
24	1.5154	2.6139	2.5766		2.7073	2.7446	2.6612
Max	3.3265	3.5848	3.6408	3.6961	3.6591	3.6397	2.6612
Min	.9063	1.9805	2.1948	2.2382	2.1691	2.1691	1.2489
Avg	1.9528	2.8609	2.7872	3.1993	2.9081	2.9093	1.8459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) DIV.[264] BU 0426

Substation No/ Name :- 184044 / OLD POWER HOUSE

Feeder No / Name : 205 / MACCHI BAJAR FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7522	.9431	.9156		.9536	.9259	
2	.6984		.9259		.9536	.8951	
3	.7316				.964	.9362	
4	.7095				1.0164	.8718	
5					.964		
6	.6767		.8842		.8764		
7	.8029	.8688	1.0402		.905	1.0808	
8	.8775	.924	1.1706		1.1643	1.1403	
9	1.2689		1.358	1.1222	1.2715	1.2934	
10			1.4148	1.2934	1.2752	1.3253	
11			1.448	1.3003	1.4685	1.3937	
12		1.4373	1.4148	1.4118	1.4373	1.3643	
13			1.3998	1.3969	1.379	1.1043	1.4632
14			1.1163	1.1999	1.0242	1.0808	1.0498
15					.9717		.9231
16		1.1043		1.1869	1.0631	1.1831	.905
17		1.0802		1.2403	1.1517	1.1694	.9991
18	1.1616	1.2071		1.2403	1.1744	1.262	1.0208
19	1.2269	.8962		1.286	1.3496	1.5091	1.2826
20	1.2136	1.4198		1.5432	1.3998	1.4198	1.0808
21	1.2136	1.2346		1.286	1.2689	1.406	
22	1.2003	1.166		1.2346	1.2094	1.2795	.9362
23		1.0852			1.1145	1.1919	.9492
24	.8962	1.0402	1.0004		1.0402	1.0288	1.1616
Max	1.2689	1.4373	1.448	1.5432	1.4685	1.5091	1.4632
Min	.6767	.8688	.8842	1.1222	.8764	.8718	.905
Avg	.9593	1.1082	1.1741	1.2878	1.1415	1.1839	1.0701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) DIV.[264] BU 0426

Substation No/ Name :- 184268 / 33/11KV KALLI-KUTTI S/S

Feeder No / Name : 207 / 11KV KUSAMBA ROAD SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.9689			3.9689		
2		3.9323			3.8958		
3		3.914					
4		3.8775					
5		3.8409		3.4208			
6		3.658		3.8009		3.6199	
7	2.5057	3.5475		3.9323			
8		4.1518		4.1884	4.2616	4.0905	
9		5.3224			5.1583		4.233
10					5.2488	5.1945	
11		5.5397		5.3188	5.5053	5.3589	4.225
12					5.6699	5.8528	3.8009
13					5.6344	4.6334	3.3484
14					3.8371	3.7647	
15					4.2172		2.2081
16	4.5637	4.3713		4.5525	4.7963		2.1719
17	5.2126		5.3772	5.1943	5.285		2.4326
18	5.3955			5.3955	5.5927		
19	5.6333		5.5384	5.5384	5.5565		
20	5.6333			5.7918			2.7435
21	4.9749		5.1029	4.9931	5.0135		
22	4.5725			4.6639			
23	4.2981		4.3982	4.2172	4.3077		
24		4.1518			4.2067		
Max	5.6333	5.5397	5.5384	5.7918	5.6699	5.8528	4.233
Min	2.5057	3.5475	4.3982	3.4208	3.8371	3.6199	2.1719
Avg	4.7544	4.1897	5.1042	4.6929	4.8327	4.6450	3.1454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) DIV.[264] BU 0426

Substation No/ Name :- 184268 / 33/11KV KALLI-KUTTI S/S

Feeder No / Name : 208 / 11KV SHIVAJI PUTALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4252	.9172	.5007	.5037	.415		
2	.3932	.9081	.4687	.4611	.3772		
3	.3605	.8405	.439	.4367			
4	.3567	.8253	.442	.4344			
5	.3551	.82	.4306	.7823			
6	.3605	.8497	.4222	.8006		.3584	
7	.6788	.8172	.4184	.3584			
8	.3879	.7933	.4854	.3584	.4527	.3772	
9	.423	.8585	.5441		.4527		.3985
10	.4786	.4824	.5167		.4715	.4338	
11	.5411	.9374	.5617	.5123	.5093	.5281	.4527
12	.5807	.5456	.6043		.6413	.6224	.4715
13	.5853	.5449	.6249		.6224	.5658	.4527
14	.5121	.4801	.5235		.4904	.5093	
15	.5037	.4816	.5396		.5281		.415
16	.9599	.9561	.5769	.5503	.5847		.4715
17	1.1473	.5281	1.2313	.5658	.6036		.4527
18	1.073	.522	.6059	.5658	.547		
19	1.2374	.5891	1.2308	.6036	.6036		
20	1.1739	.5883	.6478	.5658			.547
21	1.0892	.5365	1.1376	.5281	.547		
22	1.0791	.5312	.5335	.5093			
23	1.0292	.5228	1.0475	.5093	.5281		
24	.5342	.9907	.5327		.4527		
Max	1.2374	.9907	1.2313	.8006	.6413	.6224	.547
Min	.3551	.4801	.4184	.3584	.3772	.3584	.3985
Avg	.6777	.7028	.6277	.5321	.5193	.485	.4577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) DIV.[264] BU 0426

Substation No/ Name :- 184268 / 33/11KV KALLI-KUTTI S/S

Feeder No / Name : 209 / Express Feeder civil NON SHEDDABLE WATER SUPPLY AND
 hospital Feeder KV- 11 / UTILITY
 OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0324			.0324		
2		.0324			.0343		
3		.0324					
4		.0324					
5		.0305		.0305			
6		.0305		.0305		.0324	
7	.0324	.0305		.0305			
8		.0381		.0362	.0343	.0362	
9		.0324			.0362		.0343
10					.04	.0637	
11		.0419		.0495	.0419	.0553	.0419
12					.04	.0457	.04
13					.04	.0419	.0362
14					.0381	.0457	
15					.0362		.0381
16	.0362	.0362		.04	.0362		.0305
17	.0324		.061	.0457	.0495		.0305
18	.0419			.0381	.0381		
19	.0457		.04	.0419	.0324		
20	.0343			.0343			.0343
21	.0343		.0362	.0362	.0381		
22	.0324			.0362			
23	.0324		.0343	.0476			
24		.0343			.0362		
Max	.0457	.0419	.061	.0495	.0495	.0637	.0419
Min	.0324	.0305	.0343	.0305	.0324	.0324	.0305
Avg	.0358	.0337	.0429	.0382	.0377	.0458	.0357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) S/DN II[265] BU 4265

Substation No/ Name :- 184088 / 33/11 KV MALEGAON CAMP

Feeder No / Name : 201 / CAMP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2744		2.3282	2.3529	2.4177	2.5252
2	2.1849	2.2624		2.2386	2.2862	2.3461	2.5652
3				2.2502	2.268	2.3819	2.4177
4	2.1491	2.167	2.2028	2.371	2.2624	2.4615	2.4177
5		2.4072		2.5158	2.4143	2.552	2.5431
6		2.6578	2.8715	3.0361	2.9938		3.0087
7	2.7166	2.7351	2.7721	2.9199	2.846		3.2036
8	2.5701	2.6427		2.4579	2.8715		2.7252
9	2.0953	2.19	2.2028	2.0995			2.561
10	1.9806	2.0058	2.0508	1.8088			2.2857
11	1.8073	1.9136	1.8404	1.8625	2.1845		2.1971
12	1.9105	1.97	1.9105	1.8625	2.0199	2.0553	2.2786
13	2.0285	1.9313	1.9281	1.8229		1.9879	2.226
14	1.9105	1.9281	1.858	1.9667		2.0199	2.2207
15	2.0022	1.9163	1.9163	2.0237		2.0416	2.4792
16	2.0199	1.9521	2.0022	1.9909			2.4451
17	2.0022			1.9879	2.4097	2.19	2.3565
18	2.0111		1.9105	2.0858	2.1384	2.191	2.4006
19	2.7519		2.7869	2.7168	3.0653	2.7995	3.083
20	3.0445		3.2217	3.1602	3.2415	3.3131	3.3133
21	2.955		3.1493	2.9864		3.152	3.1878
22	2.9191		2.9502	2.914		3.1131	3.0445
23	2.6787	2.6968	2.7511	2.733		2.8416	2.9321
24	2.4177	2.4177	2.4434	2.4714	2.4796		2.733
Max	3.0445	2.7351	3.2217	3.1602	3.2415	3.3131	3.3133
Min	1.8073	1.9136	1.8404	1.8088	2.0199	1.9879	2.1971
Avg	2.3078	2.2393	2.3760	2.3588	2.5223	2.4915	2.6313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) S/DN II[265] BU 4265

Substation No/ Name :- 184088 / 33/11 KV MALEGAON CAMP

Feeder No / Name : 202 / Ravalgaon Industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1307		.112	.1698	.112	.112
2	.1132	.1307		.112	.1698	.112	.168
3				.1307	.1698	.1307	1.8298
4	.1132	.112	.1132	.168	.1698	.168	.0934
5		.112		.2054	.1698	.2054	.168
6		.0934	.2054	.2241	.2075		.1867
7	.2829	.112	.2427	.2614	.2829		.2241
8	.2427	.1307	.2427	.2614	.2641		.1867
9	.2987	.1494	.2427	.2641			.2801
10	.3361	.112	.2427	.2829			.2614
11	.3174	.1867	.2801	.3018	.3206		.2801
12	.2801	.1307	.2801	.2829	.3206	.2987	.2614
13	.2427	.1494	.2054	.2075			.2054
14	.168	.112	.2054	.1886		.2801	.168
15	.2054	.1494	.3174	.2263		.2801	.168
16	.2241	.1867	.2614	.2263	.2075		.2054
17	.2241		.2427	.1886	.2241	.2241	.2241
18	.2054		.2427	.1886	.2054	.2241	.1867
19	.1867		.2801	.2075	.1494	.2241	.2054
20	.1494		.1307	.2075	.1307	.112	.1307
21	.1307		.112	.1698		.1494	.1307
22	.1307		.112	.1509		.1494	.1307
23	.112	.1132	.112	.1698		.112	.112
24	.1509	.112	.1132	.112	.1698		.0934
Max	.3361	.1867	.3174	.3018	.3206	.2987	1.8298
Min	.112	.0934	.112	.112	.1307	.112	.0934
Avg	.2057	.1308	.2092	.2021	.2082	.1855	.2505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) S/DN II[265] BU 4265

Substation No/ Name :- 184088 / 33/11 KV MALEGAON CAMP

Feeder No / Name : 203 / 11 KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.7846		2.8344	2.8675	2.967	3.0011
2	1.6461	2.7846		2.6686	2.6686	2.6852	2.7328
3				2.5526	2.652	2.5526	2.7328
4	1.4969	2.6023	2.6543	2.5987	2.6023	2.5987	2.6686
5		2.5652		2.6322	2.3758	2.6322	2.6063
6		2.5766	2.7519	2.7566	2.4905	2.878	2.9127
7	2.0328	2.733	3.0121	2.8654	3.0087		2.6981
8	2.2779	3.0687		3.1341	3.0803		2.8006
9	3.1184	3.4873	3.476	3.504			2.9569
10	3.3916	3.3979	3.6702	3.4034			3.0407
11	3.3196	3.3979	3.5376	3.5543	3.5711		2.6699
12	3.5803	3.6117	3.7388	3.866	3.8999	3.6866	2.5652
13	3.315	3.5608	3.2386			3.6286	2.3712
14	2.6749	2.5692	2.4792	2.7221		2.7393	1.9404
15	2.8334	2.8669	2.713	3.2442		3.0011	1.8111
16	3.1786	3.1295	3.0996	3.3316			1.9936
17	3.5656		3.3813	3.3979	3.774	3.4591	1.9366
18	3.4008		3.3589	3.4311	3.5803		2.0633
19	3.6717		3.7304	3.7643	3.8152	3.8237	2.5423
20	3.476		3.8491	3.9847	3.9339	3.9952	2.4874
21	3.476		3.5439	3.5947		3.5778	2.2497
22	3.2386		3.3065	3.3573		3.275	2.2805
23	3.155	3.1722	3.1036	3.155		3.1379	2.268
24	1.9204	2.9675	2.9675	3.0011	2.8988		2.0668
Max	3.6717	3.6117	3.8491	3.9847	3.9339	3.9952	3.0407
Min	1.4969	2.5652	2.4792	2.5526	2.3758	2.5526	1.8111
Avg	2.9385	3.0162	3.2428	3.1893	3.1479	3.1649	2.4749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) S/DN II[265] BU 4265

Substation No/ Name :- 184088 / 33/11 KV MALEGAON CAMP

Feeder No / Name : 204 / RAWALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8029		.2753	.2785	.2785	.8192
2	.8097	.8192		.2591	.2785	.2785	.852
3				.2267	.2785	.2785	.852
4	.9069	.8684	.2429	.2294	.2785	.2785	.8848
5		.9175		.2294	.2785	.2949	.9339
6		1.0486	.2915	.2622	.3113		1.0978
7	1.873	1.704	.2753	.2622	.2622		1.6057
8	2.0056	1.8023	.2753	.2785	.2785		1.7695
9	1.4089	1.4089	.2458	.2785			1.3599
10	.2429	.2267	.2458	.213			.2294
11	.2267	.2591	.213	.1966	.213		.2458
12	.2267	.2429	1.5238	1.3108	1.3108	1.3435	.2458
13	.2458	.2429	1.3927	1.1797		1.1633	.2294
14	.2458	.2429	1.2452	1.1305		1.0486	.2622
15	.2294	.2429	1.2452	1.1469		1.0322	.2458
16	.2622	.2267	1.2944	1.3272	1.2616		.2294
17	.213		1.5708	1.4746	1.4582	1.4419	.2622
18	.2785		1.4575	1.491	1.4091	1.3599	.2785
19	.2949		1.2793	1.278	1.1305	1.2289	.2785
20	.213		.2753	.2785	.2785	.2949	.2949
21	.2294		.3077	.2785		.2622	.2785
22	.2294		.2915	.2949		.2622	.2294
23	.213	.2753	.2915	.2915		.2294	.2294
24	.8097	.8192	.7625	.2915	.2949		.8029
Max	2.0056	1.8023	1.5708	1.491	1.4582	1.4419	1.7695
Min	.213	.2267	.213	.1966	.213	.2294	.2294
Avg	.5582	.7147	.7364	.6035	.6001	.6922	.6049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) S/DN II[265] BU 4265

Substation No/ Name :- 184088 / 33/11 KV MALEGAON CAMP

Feeder No / Name : 205 / 11 KV Amit Filament

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.132		.0754	.1132	.1132	.1509
2	.1132	.132		.0754	.1132	.0943	.1132
3				.0754	.0943	.0943	.1509
4	.1132	.132	.0754	.0754	.0943	.1132	.1509
5		.0943		.0943	.0943	.132	.1698
6		.1132	.0754	.0754	.0943		.1698
7	.1886	.1698	.1132	.0754	.1509		.2641
8	.1494	.132		.1886	.1509		.1886
9	.2452	.1509	.2829				.3018
10	.2829	.0943	.3018	.3018			.4527
11	.2829	.1509	.3206	.3018	.3206		.3584
12	.2829	.1132	.2829	.2452	.2829	.3584	.3395
13	.2641	.1509	.2641	.2641		.3206	.3018
14	.3018	.1509	.2829	.2829		.3772	.4338
15	.3206	.1509	.3206	.3018		.4338	.3584
16	.2829	.1509	.3206	.2829	.3018		.415
17	.3018		.3395	.3018	.3018	.4338	.3961
18	.2452		.2829	.2829	.2829	.3772	.3584
19	.2263		.2641	.2263	.2452	.3206	.3206
20	.1509		.0943	.1132	.132	.2075	.1698
21	.112		.0943	.1132		.2263	.2075
22	.112		.1132	.1132		.1698	.1509
23	.112	.0754	.0754	.1132		.1698	.1509
24	.1132	.1132	.0754	.0754	.0943		.1698
Max	.3206	.1698	.3395	.3018	.3206	.4338	.4527
Min	.112	.0754	.0754	.0754	.0943	.0943	.1132
Avg	.2101	.1298	.2094	.1763	.1792	.2464	.2602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) S/DN II[265] BU 4265

Substation No/ Name :- 184267 / 33/11 KV MALEGAON CAMP-

2(SOYEG

Feeder No / Name : 201 / 11 KV SATANA NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1831	1.1145	1.0974			1.2003
2	1.1145	1.166	1.046	1.046			1.166
3	1.1145	1.166	1.0288	1.0631			1.1317
4	1.1488	1.1831	1.0974	1.0974			1.1145
5	1.2174	1.2003	1.2003	1.1317			1.1488
6	1.286	1.2174	1.3375	1.3889	1.2041		1.3375
7	1.3889	1.3032	1.3546	1.3375	1.3032		1.4232
8	1.1831	1.2346		1.2003	1.166		1.2346
9	.9774	1.0631		1.0117	1.0117	1.046	1.046
10	.8916	.8745		.8573	.9431	.9431	.9602
11	.8916	.9431		.9259	.9945	.9602	1.0288
12	.8573	1.0117		1.0288	.9088	1.046	1.046
13		.9774		.9945	.9602	1.046	1.0288
14	.6468	1.0631		1.0288	.9431	1.1145	1.0802
15	1.0974	.9945		1.0288	1.0117	1.0974	1.1317
16	1.0802	.9774		1.0288	1.0802	1.1317	1.1317
17	1.0117	.9431	.8535	.9774	.9774	1.0288	1.1145
18	1.0802	.9774	.9755	.9602	1.0802	1.0631	1.1145
19	1.4746	1.286	1.3108	1.2689	1.4575	1.406	1.4403
20	1.5432	1.3375	1.5089	1.406	1.5604	1.4575	1.5775
21	1.3889	1.3889	1.3717	1.3717		1.406	1.5432
22	1.286	1.3203	1.3203	1.3717		1.3889	1.4575
23	1.2346	1.286	1.2517	1.2689		1.3546	1.4575
24	1.2346	1.2003	1.2003	1.1488	1.1831		1.286
Max	1.5432	1.3889	1.5089	1.406	1.5604	1.4575	1.5775
Min	.6468	.8745	.8535	.8573	.9088	.9431	.9602
Avg	1.1427	1.1374	1.1981	1.1267	1.1116	1.1660	1.2167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON (U) S/DN II[265] BU 4265

Substation No/ Name :- 184267 / 33/11 KV MALEGAON CAMP-

2(SOYEG

Feeder No / Name : 202 / MUNGSE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1584			***	***	1.2803
2	1.1431	1.1431				***	1.2955
3	1.1584	1.1431				***	1.3108
4	1.2803	1.2955				***	1.3717
5	1.0822	1.4784				***	1.5851
6			1.8595	1.7071	1.7985	***	
7			2.1491	1.7071	2.2405		
8				2.4234	2.3929		
9				2.3015	2.2862		
10				1.8138	1.8442		
11					***		
14	1.4937	1.3717				***	1.6461
15	1.6156	1.4937				***	1.6766
16	1.7833	1.5851				***	1.8138
17	1.8747	2.0576				***	2.2558
18	2.2862	2.332				2.1033	2.5758
19			2.2558	1.9052	2.3167	***	
20			1.89	1.89	1.9509		
21			1.4784	1.5394			
22			1.2803	1.2651	***		
23			1.2346	1.2193	***		
24	1.1736	1.1888	1.2346	1.1736	***		1.326
Max	2.2862	2.332	2.2558	2.4234	185.6427	189.3007	2.5758
Min	1.0822	1.1431	1.2346	1.1736	1.7985	2.1033	1.2803
Avg	1.4577	1.4770	1.6728	1.7223	65.2086	130.3220	1.6489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184009 / SAUNDANE

Feeder No / Name : 201 / NANDGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5068	.3086	.2743	.2987	.3086	.4115
2	.5487	.5014		.3429	.3292	.3258	.4458
3	.583	.4733		.3772	.3292	.3429	.4801
4	.6173	.5258		.463	.3077	.4115	.5144
5	.9088	.823	.583	.5316	.7059	.5144	.5487
6	1.0974	.9602	.5487	.6001	.7842	.6001	.8916
7	1.5089	1.3717		.4115	.4252	.4115	1.3032
8	1.5432	1.5257		.3086	.2926	.2743	1.5947
9	.1494	.1372	.1886	.2987	.2401	.2229	.2987
10	.1494	.1372	.1715	.1829	.1715	.1543	.2614
11	.3361	.12	.1543	.3506	1.2193	.5144	.1867
12	.1494	.12	1.1831	.823	.8535	1.1145	.1867
13	.1494	.1543	1.166	.9602	.8535	1.2003	.1867
14	.1494	.1543	1.1488	.7316	.6706	1.3375	.2241
15	.1494	.1543	1.1145	.7621	.6097	1.4232	.2241
16	.168	.1715	1.0974	.9602	.8535	1.4575	.2241
17	.1494	.1543	1.5089	1.0974	.9755	1.5089	.1867
18	.2241	.1372	1.5432	1.1584	1.0974	1.5432	.2054
19	.3658	.3429	.2743	.2587	.2401	.2743	.3734
20	.439	.4115	.2915	.4481	.4115	.5144	.439
21	.4024	.3429	.3258	.3734	.3601	.4458	.2926
22	.2987	.3429	.3429	.3734	.3429	.3944	.3734
23	.1867	.3086	.3258	.3361	.3429	.3429	.362
24	.4801	.5975		.3944	.8535	.3429	.3429
Max	1.5432	1.5257	1.5432	1.1584	1.2193	1.5432	1.5947
Min	.1494	.12	.1543	.1829	.1715	.1543	.1867
Avg	.4695	.4364	.6821	.5341	.5653	.6659	.4399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184009 / SAUNDANE

Feeder No / Name : 202 / UMRANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	.4481	.5182	.6859	.631	.6097	.3772
2	.7545	.4668	.5487	.7202	.6173	.6401	.3772
3	.5487	.4481	.5487	.7716	.6516	.6401	.3944
4	.4458	.4854	.5792	.8916	.6859	.6401	.463
5	.6859	.5914		1.0288	.8573	.7316	.5144
6	.9145	.7602		1.0974	1.073	.9755	.7716
7	.6516	.7316		1.4403	1.6289	1.3108	.6344
8	.5144	.5228		1.5432	1.5775	1.3413	.4801
9	.2987	.2743	.3086	.2987	.2743	.2058	
10	.2241	.2743	.2401	.2241	.1715	.2058	.2172
11	.631	.2439	.1886	.1494	.1543	.1372	.2126
12	1.262	1.0059	.1715	.1509	.1372	.1886	1.134
13	1.1919	.945	.1715	.1867	.1372	.1715	.9568
14	1.0974	.8383	.1715	.1848	.1543	.1886	.8413
15	.9602	.8535	.1886	.2012	.1715	.1886	.8916
16	1.0974		.1886	.2241	.1524	.2058	.9602
17	1.0974	1.2003	.2058	.2241	.1715	.2058	1.2071
18	1.166	1.0974	.2401	.3658	.2058	.2058	1.2346
19	.5228	.4973	.5144	.4481	.4458	.2058	.5068
20	.5975	.583	.463	.5304	.6173	.5487	.439
21	.4481	.4287	.4287	.5228	.4801	.5144	.4481
22	.4481	.4115	.4115	.4668	.3601	.5144	.439
23	.4481	.2439	.5144	.2987	.4268	.3601	.3734
24	.3944	.3734		.7202	.5609	.5792	.3944
Max	1.262	1.2003	.5792	1.5432	1.6289	1.3413	1.2346
Min	.2241	.2439	.1715	.1494	.1372	.1372	.2126
Avg	.7241	.5967	.3475	.5573	.5143	.4798	.6204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184009 / SAUNDANE

Feeder No / Name : 203 / MUNGASE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.443	.4458	.4801	.4887	.4801	.4115
2	.4287	.4908		.5144	.4938	.4801	.4115
3	.4458	.5258		.5658	.4755	.5144	.3944
4	.463	.5258		.6516	.4706	5.487	.4458
5	.823	.6516		.7202	.567	.6344	.4801
6	.9945	.9945		.7888	.8328	.7716	.8916
7	1.6118	1.4918		.7716	.8596	.703	1.4232
8	1.8519	1.7833		.5658	.6219	.5487	1.4575
9	.3077	.2915	.4115	.3772	.4287	.4287	.3258
10	.2427	.2229	.4115	.2801	.3086	.3086	.2926
11	.2241	.2401	.4287	.2353	.1524	.3429	.2987
12	.2801	.2401	.9602	.631	.5944	.7545	.3077
13	.2926	.2401	.9088	.6173	.503	.6173	.2896
14	.2241	.2401	.8573	.5639	.503	.823	.2926
15	.2241	.2572	.823	.5792	.4572	.8573	.2743
16	.2801	.2572	.7716	.6859	.7011	.9259	.3109
17	.2801	.2743	1.4232	.9602	.8688	1.0974	.3109
18	.4854	.3086	1.5775	1.0364	1.0669	1.3375	.3439
19	.6767	.6516	.6173	.443	.5144	.5144	.724
20	.7499	.703	.583	.7265	.7202	.3429	.724
21	.5914	.5658	.5658	.6036	.6001	.3429	.5853
22	.5601	.5144	.5316	.5788	.5487	.3258	.4887
23	.3658	.4458	.4801	.5415	.4973	.3086	.2896
24	.3944	.4163		.4801	.5068	.4801	.3772
Max	1.8519	1.7833	1.5775	1.0364	1.0669	5.487	1.4575
Min	.2241	.2229	.4115	.2353	.1524	.3086	.2743
Avg	.5497	.5323	.7373	.5999	.5742	.8095	.5063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184009 / SAUNDANE

Feeder No / Name : 204 / SAUNDANE - AG -
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1463	.3048	.4115	.4115	.4268	.1372
2	.1372	.1448		.4287	.4557	.4877	.1372
3	.1372	.1448		.5144	.4458	.4572	.1372
4	.1543	.1463		.5658	.4801	.4572	.1372
5	.1372	.1448		.6687	1.5424	.4877	.1372
6	.1372	.1646	.6401	.7888	2.0576	.7316	.1372
7	.1029	.1417		1.3717	1.3717	1.2193	.1029
8	.0857	.0905		1.5089	.1543	1.2803	.0857
9	.056	.0686	.0514	.0549	.0762	.0514	.1629
10	.0543	.0514	.0343	.0549	.0572	.0343	.0549
11	.631	.3048	.0343	.0549	.0572	.0343	.5121
12	.9945	.7621	.0343	.0549	.0572	.0343	.8916
13	.8573	.6706	.0343	.0549	.0572	.0343	.8383
14	.6859	.5792	.0343	.0532	.6706	.0343	.823
15	.7545	.5792	.0343	.0532	.0572	.0343	.6859
16	.823	.6097	.0343	.0532	.0572	.0343	.823
17	.9602	.7316	.0343	.0549	.0572	.027	.9602
18	.9945	.7926	.0343	.1097	.0572	.0343	.9945
19	.1063	.0953	.0686	.1463	.0686	.0686	.0857
20	.1417	.0953	.0857	.1448	.1334	.1029	.12
21	.1417	.1143	.0857	.124	.1143	.1029	.1448
22	.1463	.1143	.1029	.0905	.1143	.1029	.1448
23	.1463	.2743	.2743	.3658	.1829	.1372	.1448
24	.1372	.1448		.4115	.0572	.4268	.1372
Max	.9945	.7926	.6401	1.5089	2.0576	1.2803	.9945
Min	.0543	.0514	.0343	.0532	.0572	.027	.0549
Avg	.3608	.2963	.1131	.3392	.3664	.2851	.3556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184009 / SAUNDANE

Feeder No / Name : 205 / SONAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.8682	.7316	.8573	.8745	.8535	.7716
2	.4458	.8764		.8916	.8859	.7926	.7545
3	.5144	.8573		.9431	.9511	.8535	.7716
4	.5487	1.046		1.0974	.8688	.884	.8573
5	.823	1.2346		1.5089	1.4632	1.0974	.9602
6	.9259	1.7661	1.4632	1.7147	1.7147	1.5851	1.5089
7	.7545	2.1052	1.5851	1.8519	1.7604	1.6766	1.6461
8		1.9204	1.5242	1.5604	1.8861	1.6461	1.6461
9		.4801	.583	.4108	.3772	.583	.3189
10	.4344	.2743	.5144	.1829	.3772	.3086	.3258
11	.3544	.6097	.5487	.5609	.3048	.3086	.4908
12	1.0288	.7621	.8916	.7888	.5487	.6001	1.0631
13	.8573	.7011	.8573	.7202	.4877	.583	.9602
14	.8573	.6706	.8059	.7202	.4572	.6516	.7888
15	.823	.7011	.7716	.6859	.3963	.7202	.8059
16	.9556	.823	.7545	.6036	.6097	.9602	.8916
17	1.0802	.9145	1.0288	1.0288	.4877	1.0631	1.1488
18	1.166	.9755	1.0802	.9755	.8535	1.2003	1.2689
19	.6733	.4115	.5487	.3898	.583	.583	.6878
20		.7888	.583	.7442	.7202	.6859	.8048
21	.695	.6859	.6173	.7442	.6173	.6859	.6722
22	.7095	.6173	.6516	.6733	.6516	.6516	.6348
23	.7712	.7316	.9088	.8916	.8535	.8916	.631
24	.4801	.8589		.823	.8745	.7316	.7202
Max	1.166	2.1052	1.5851	1.8519	1.8861	1.6766	1.6461
Min	.3544	.2743	.5144	.1829	.3048	.3086	.3189
Avg	.7307	.9033	.8658	.8904	.8169	.8582	.8804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184009 / SAUNDANE

Feeder No / Name : 206 / GUNJALWADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1919	.4458	.463	.2772	.4458	.7202
2	1.166	1.1568		.4801	.2743	.463	.7373
3	1.1831	1.0974		.5144	.2926	.5144	.7716
4	1.2346	1.166		.5487	.4024	.5658	.823
5	1.286	1.5089		.5658	.7682	.7545	.8573
6	1.9033	1.9204	.5487	.6173	.7316	.8402	1.3717
7	2.6235	2.146	.5487	.6173	.6401	.6516	1.9719
8	2.4691	2.2291		.463	.4607	.463	1.8176
9	.3801	.3772	.4115	.2801	.2572	.4115	.5228
10	.2801	.3086	.3944	.3361	.3086	.3601	.3361
11	.2172	.2229	1.0288	.7362	1.1584	.6173	.2987
12	.1867	.1829	1.5947	1.4575	1.3717	1.286	.2126
13	.1494	.2058	1.5432	1.4575	1.4784	1.2689	.2012
14	.1867	.2058	1.4403	1.1431	1.4632	1.3717	.2054
15	.168	.2058	1.3889	1.3717	1.4632	1.4232	.168
16	.168	.2058	1.3375	1.4575	1.4632	1.4746	.168
17	.168	.1543	1.7833	1.448	1.5546	1.5432	.168
18	.2926	.2572	1.8519	1.9052	1.5089	1.6461	.2743
19	.4668	.6173	.5658	.443	.1829	.2058	.4525
20	.5121	.5316	.5487	.4572	.463	.2058	.4572
21	.3361	.4973	.5144	.2743	.4287	.1715	.2801
22	.2987	.5144	.4801	.2801	.4801	.1715	.2241
23	.4108	.4458	.4287	.2772	.4115	.4801	.8145
24	1.0631	.9745		.3944	.2772	.3429	.8916
Max	2.6235	2.2291	1.8519	1.9052	1.5546	1.6461	1.9719
Min	.1494	.1543	.3944	.2743	.1829	.1715	.168
Avg	.7617	.7635	.9364	.7495	.7549	.7366	.6144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184009 / SAUNDANE

Feeder No / Name : 207 / SHIRSONDI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.6001	.5639	.3429
2		.4801	.6135	.5639	.4115
3		.6001	.567	.5792	.4801
4		.583	.6173	.7011	.4801
5		.703	.8718	.8078	.5144
6		.8573	1.3717	1.1584	.6859
7		.9774	1.9204	1.4327	.5487
8		1.0288	1.8004	1.4022	.3429
9		.1867	.1143	.2572	.2012
10		.0747	.2058	.1886	.2743
11		.0747	.0572	.0857	.2715
12		.0373	.0572	.0857	1.1145
13		.0373	.0572	.0857	.4801
14		.112	.0381	.1029	.4382
15		.0732	.0381	.1372	.9431
16		.0373	.0381	.1543	1.1145
17		.0373	.1143	.1543	1.1317
18		.1509	.0381	.1715	1.286
19		.3696	.3944	.3429	.2572
20		.5487	.5658	.5144	.6201
21		.3511	.4287	.4801	.4668
22		.5041	.3258	.4458	.4066
23	.5144	.5487	.3201	.4287	.4572
24		.2572	.6001	.3353	.4115
Max	.5144	1.0288	1.9204	1.4327	1.286
Min	.5144	.0373	.0381	.0857	.2012
Avg	.5144	.3810	.4898	.4658	.5700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184009 / SAUNDANE

Feeder No / Name : 208 / SAUNDANE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1417	.1715	.1715	.1417	.1715	.1905
2	.1715	.1417		.1524	.1402	.1715	.1905
3	.1715	.1417		.1524	.1402	.1715	.2096
4	.1715	.1417		.1715	.1715	.1715	.2096
5	.2096	.2126		.2096	.1715	.1905	.2096
6	.2477	.2279		.2286	.2058	.2286	.2096
7	.1543	.2804		.1886	.2058	.2477	.1886
8	.1543	.1829	.1334	.1905	.1772	.1715	.1715
9	.1267	.1905	.1524	.1086	.1524	.1715	.1595
10	.1086	.1905	.1524	.1463	.1524	.1524	.1417
11	.1448	.1905	.1715	.1372	.1334	.1905	.1417
12	.1417	.1524	.1543	.124	.1143	.1715	.1417
13	.1448	.1524	.1715	.124	.1715	.1905	.1578
14	.1417	.1715	.1715	.1402	.1905	.1715	.1772
15	.1417	.1524	.1715	.1417	.1715	.1715	.1772
16	.1417	.1905	.1905	.1417	.1905	.1715	.2126
17	.1417	.1905	.1543	.1417	.1905	.1905	.1753
18	.1417	.1905	.1715	.1753	.1905	.1905	.1753
19	.1417	.2286	.2286	.2103	.2286	.2286	.2195
20	.2126		.2286	.2279	.2667	.2477	.2126
21	.1949	.2286	.2286	.2103	.2286	.2058	.2126
22	.1772	.1905	.2286	.1753	.2096	.1886	.1772
23	.181	.1715	.1886	.1715	.1905	.1715	.1753
24	.1715	.2477		.1905	.1543	.1715	.1905
Max	.2477	.2804	.2286	.2286	.2667	.2477	.2195
Min	.1086	.1417	.1334	.1086	.1143	.1524	.1417
Avg	.1620	.1874	.1805	.1680	.1787	.1879	.1845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184030 / NIMGAON

Feeder No / Name : 202 / PATHARDHE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1326	.2515	.2401	.2439		
2	.1524	.1492	.2347	.2401	.2315		.1677
3	.1829	.1638	.2515	.16	.2315		.1677
4	.2267	.1802	.2683	.2401	.2469		.2012
5	.2056	.1966	.2683	.2572	.2315		.1677
6	.4784	.3113					.3018
7	.703						1.5089
8	.8097	.7459					.6706
9	.4687	.5243					.4801
12				.2372	.3277		
13			.2572	.2561	.3113	.3353	
14			.2058	.2401	.2458	.2515	
15			.2058	.2561	.1989	.2515	
16	.0663	.0457	.3772	.3549	.2458	.3018	
17	.0655	.0838	.4973	.463	.3768	.3688	.0686
18	.0829		.5316	.4012	.4424	.3506	.1029
19	.1989	.1844	.3658	.2743	.3932	.3201	.1886
20	.2652	.2591	.2743	.2286	.2652	.1829	.2743
21	.2486	.285	.2915	.2315	2.5857	.1829	.2229
22	.2155	.3018	.2591	.2439	.2652	.218	.2229
23	.2486	.2515	.2572	.2315	.2652	.1844	.1715
24	.1326		.2515	.2229	.2315	.3521	.1372
Max	.8097	.7459	.5316	.463	2.5857	.3688	1.5089
Min	.0655	.0457	.2058	.16	.1989	.1829	.0686
Avg	.2733	.2543	.2970	.2655	.4078	.2750	.3159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184030 / NIMGAON

Feeder No / Name : 204 / MEHUNE-SP SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.364	1.4327	1.2468	1.227	1.219	.6097	1.4937
2	1.3948	1.4417	1.2636	1.2441	1.2578	.7621	1.5836
3	1.4183	1.4994	1.2803	.6611	1.2971	.7621	1.6004
4	1.4807	1.507	1.2971	1.448	1.4339	.7621	1.7863
5	1.7526	1.7566	1.4663	1.5166	1.4104	.7621	1.8534
6	.1524		2.1552	2.01	2.0862	1.0669	
7			2.6646	2.8292	2.8677	1.5242	
8			2.9661	2.9474	3.184	3.1827	
9			2.7245	2.9626	2.9397	2.9883	
10			.3048				
12	1.8376	2.2755					2.4691
13	1.837	1.0669					2.2481
14	1.6918	1.7193					1.8899
15	1.483	1.669					1.7547
16	1.5394	1.7528	.5963	.5548	.5801	.5334	1.9509
17	1.7404	2.1064	.6306	.6211	.5963	.823	2.0957
18	2.1519	2.3426	.5791	.7159	.7582	.9937	2.3624
19	2.3335	2.3258	1.4499	1.5053	1.1765	1.6675	2.4843
20	2.0117	1.7528	1.7375	1.9151	1.832	1.5028	1.8233
21	1.406	1.4632	1.4308	1.5707	1.6518	1.8884	1.7718
22	1.6846	1.223	.6097	1.3542	1.4011	1.736	1.7718
23	1.4503	1.1127	1.0727	1.1117	1.1176	1.6004	1.5337
24	1.4423	1.4175	1.23	1.227	1.1565	.7621	1.4785
Max	2.3335	2.3426	2.9661	2.9626	3.184	3.1827	2.4843
Min	.1524	1.0669	.3048	.5548	.5801	.5334	1.4785
Avg	1.5880	1.6592	1.4056	1.5234	1.5537	1.3293	1.8862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184030 / NIMGAON

Feeder No / Name : 205 / NIMGAON GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1802	.1311	.1509	.1715	.1677		.1524
2	.1943	.1475	.1677	.1715	.1718		.1372
3	.2294	.1802	.1844	.1715	.2031		.2012
4	.2591	.2105	.2347	.2058	.2343		.2134
5	.2949	.2429		.2743	.253		.285
9	.3239	.2915	.3429	.3086	.3932	.2949	.3086
10	.3113	.3048	.3258	.1875	.2915	.3185	.3429
11	.2458	.3018	.2058	.2031	.2105	.2286	.2743
12		.1677	.2058	.1677	.1457	.1372	.1715
13			.2058	.1372	.1781	.1677	.2058
14	.213	.1677	.2058	.1562	.1966	.2012	
15	.1966	.1524	.1886	.1543	.1638	.1677	.2058
16	.1638	.1677	.1715	.1852	.1619	.1677	
17	.1802	.1677	.1715	.1898	.1781	.1844	.2401
18	.2267	.2347	.2572	.1875	.2267	.2347	.2572
19	.213	.2347	.2229	.2056	.1943	.2012	.2229
20							.2229
21							.2915
22	.2785	.2286		.2214	.2622	.2286	.2743
23	.1638	.1524	.1886	.208	.2294	.2012	.1715
24	.1638	.1509	.2515	.1886	.1898	.1966	.1844
Max	.3239	.3048	.3429	.3086	.3932	.3185	.3429
Min	.1638	.1311	.1509	.1372	.1457	.1372	.1372
Avg	.2258	.2019	.2166	.1945	.2132	.2093	.2296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184030 / NIMGAON

Feeder No / Name : 206 / NIMBAYATI-SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6483	.639	.6097	.6859	.6405		.6706
2	.7042	.639	.6539	.703	.6562		.5944
3	.7253	.6718	.6371	.703	.6249		.6706
4	.8322	.7125	.6706	.7202	.6944		.7042
5	.7907	.7611	.7209	.7545	.6874		.7545
6	1.1683	.9231					1.073
7	1.4737	1.4737					1.2955
8	1.6194	1.6842					1.5592
9	1.2125	1.3279					.9602
10		1.3413					
12			1.1317	.8697	1.166		
13			1.0288	.8905	1.0202	.9724	
14			1.0117	.8179	.9555	.6036	
15			.8745	.7811	.8745	.788	
16	.1966	.2012	.9088	.8381	.9069	.9221	.2058
17	.213	.2347	1.166	.9122	.9878	1.0898	.2572
18	.4588	.3521	1.3032	1.0402	1.1822	1.1271	.3429
19	.7045	.663	1.0059	1.0883	1.1174	1.0562	.5658
20	.5898	.8383	.7373	.7116	.6882	.6249	.6173
21	.5243	.8122	.8059	.7042	.7373	.6539	.6001
22	.502	.8383	.7716	.7449	.7373	.5533	.5144
23	.4915	.6097	.6859	.6882	.6882	.3963	.4458
24	.6882		.5944	.6859	.6327	1.0059	.7042
Max	1.6194	1.6842	1.3032	1.0883	1.1822	1.1271	1.5592
Min	.1966	.2012	.5944	.6859	.6249	.3963	.2058
Avg	.7524	.8180	.8510	.7966	.8332	.8161	.6964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184030 / NIMGAON

Feeder No / Name : 207 / GILANE-SP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.6316	.6036	.7926	.7362		.7011
2	.7125	.6478	.4973	.9431	.6874		.6554
3	.7449	.7125	.5365	.9259	.6009		.6859
4	.8162	.7449	.5533	1.0288	.5218		.7712
5	.8097	.8097	.5365	1.2003	.4744		.8383
6	1.0526	.7125	.9221	.6859	1.0402		.9221
7	1.1843	1.1984	1.0059	1.0288	1.0883		1.1603
8	1.4419	.9717	1.0898	1.2346	1.2323	1.2308	1.1437
9	.8802	.8259	.8573	.8688	.9488	.9231	.7888
12	.8097	.8078	1.3375	.7042	.8259		1.0288
13	.7373		.8573	.7116	.7287	.852	1.0288
14	.7125	.8122	.8059	.6173	.6478	.5868	.7716
15	.664	.8048	.7545	.6722	.5992	.5197	.823
16	.664	.9282	1.0974	.7362	.7773	.8048	.9259
17	.5992	.9282	.5658	.7811	.9069	.9448	.9297
18	.9555	1.0277		.8592	.9555	1.1105	1.0669
19	.8097	.8288	1.1126	.9442	.8745	1.0486	1.0669
20	.5243	.3048	.6001	.4687	.5243	.431	.6516
21	.4424	.3481	.5658	.4374	.4915	.431	.5487
22	.3768	.285	.5316	.3658	.426	.4191	.4801
23	.3932	.2347	.463	.3479	.3932	.4024	.4287
24	.5992	.8785	.57	.9088	.6483	.779	.7956
Max	1.4419	1.1984	1.3375	1.2346	1.2323	1.2308	1.1603
Min	.3768	.2347	.463	.3479	.3932	.4024	.4287
Avg	.7568	.7354	.7554	.7847	.7332	.7488	.8279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184064 / UMARANE

Feeder No / Name : 201 / UMARANE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
1	.2804	.2486
2	.2658	.2486
3	.2629	.2486
4	.2774	.2818
5	.3506	.3315
6	.4382	.3978
7	.3944	.3647
8	.3467	.3481
9	.3294	.2984
10	.3012	.2652
11	.2658	.2321
12	.2481	.1658
13	.2629	.1989
14	.2601	.2486
15	.2303	.2818
16	.2427	.2984
17	.2658	.2984
18	.3189	.2984
19	.3429	.3978
20	.3856	.3647
21	.3856	.3315
22	.3506	.3149
23	.298	.2984
24		.2454
Max	.4382	.3978
Min	.2303	.1658
Avg	.3089	.2920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184064 / UMARANE

Feeder No / Name : 202 / GORNARE-AG SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
1		.4973
2		.4973
3	1.1869	.4973
4	1.4232	.5801
5	1.5912	
6	1.8461	
7	2.1605	
8	1.9113	
11		.3315
12		1.6575
13		1.5912
14		1.4089
15		1.3592
16	.2543	1.5912
17	.2012	1.757
18	.2543	1.8564
19	.5087	.5304
20	.5316	.5967
21	.5935	.5801
22	.503	.4144
23	.8478	.4144
24		.4382
Max	2.1605	1.8564
Min	.2012	.3315
Avg	.9867	.9222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184064 / UMARANE

Feeder No / Name : 203 / SANGAVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6629	1.5775	.6706	.6706	.6691	1.3058	2.3634
2	1.6522	1.5485	.631	.6737	.6813	1.3117	2.4258
3	1.6324	1.5196	.6584	.7026	.7148	1.3657	2.4228
4	1.7071	1.5104	.7164	.7453	.7438	1.4632	2.496
5	1.768	1.6278	.7865	.7941	.7804	.7788	2.709
6	1.8808	1.7635	.2561	.5883	.1661	.7834	3.2838
7	2.6581	2.6368				.0076	4.228
8	2.8487	2.8929					4.4551
9	2.6703	2.681					2.2481
10	.6386						.2942
11						.4525	
12			2.489	2.2725	2.2542	4.2448	
13			2.4402	2.3731	2.2283	3.834	
14			2.2024	2.0668	1.9311	3.1474	
15			2.053	1.7345	1.6964	2.8465	.1326
16		.2408	1.9509	1.6004	1.8427	2.8562	.4462
17		.2987	2.1399	2.0729	2.1552	3.19	.5019
18		.3033	2.2466	2.1094	2.178	3.5467	.5184
19		.3338	1.9814	2.0119	2.0485	2.2991	.8947
20	.8124	.7788	.7529	.7743	.8307	1.5657	1.3874
21	.8246	.7743	.7987	.695	.8368	1.5135	1.4327
22	.7103	.7606	.7194	.7301	.7346	1.2681	1.2422
23	.6173	.7042	.7087	.7148	.7225	1.1363	1.1024
24	1.4373	1.4495	.6783	.6722	.6737	.5853	1.6707
Max	2.8487	2.8929	2.489	2.3731	2.2542	4.2448	4.4551
Min	.6173	.2408	.2561	.5883	.1661	.0076	.1326
Avg	1.5681	1.3001	1.3095	1.2633	1.2573	1.8811	1.8128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184064 / UMARANE

Feeder No / Name : 204 / UMARANE AG SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
1	.3856	.8288
2	.3561	.8288
3	.4024	.8288
4	.4641	.9116
5		.9945
6		1.0774
7		1.442
8		1.6575
11	.4382	
12	1.1869	
13	1.0288	
14	.9431	
15	.8573	.0497
16	.7716	.0663
17	.8478	.0663
18	.8478	.0663
19	.3506	.3315
20	.4031	.3647
21	.3506	.3315
22	.3506	.2984
23	.3052	.2652
24		.3391
Max	1.1869	1.6575
Min	.3052	.0497
Avg	.6053	.5971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184064 / UMARANE

Feeder No / Name : 205 / ZADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
1	.4031	
2	.4382	
3	.4508	
4	.5548	
5	.6173	
6	.6613	
7	1.0227	
8	.9717	
11		.1989
12		.9282
13		.8288
14		.7459
15		.6299
16		.7459
17		.9116
18		.9945
20		.1989
21		.1989
22		.2321
23	.3506	.2155
Max	1.0227	.9945
Min	.3506	.1989
Avg	.6078	.5691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184064 / UMARANE

Feeder No / Name : 206 / GIRNARE-G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
1	.0693	.0497
2	.0701	.0663
3	.052	.0829
4	.0701	.0829
5	.1227	.0995
6	.1578	.116
7	.104	.0995
8	.0693	.0663
9	.0701	.0497
10	.052	.0497
11	.0339	.0332
12	.0339	.0332
13	.0514	.0332
14	.0347	.0497
15	.0339	.0497
16	.0351	.0497
17	.0701	.0497
18	.0509	.0497
19	.0867	.0829
20	.1387	.0995
21	.1017	.0829
22	.0686	.0497
23	.0532	.0332
24		.0514
Max	.1578	.116
Min	.0339	.0332
Avg	.0709	.0629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184064 / UMARANE

Feeder No / Name : 207 / TISGAON-VARHALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
1	.7291	.1989
2	.7059	.2321
3	.6299	.2321
4	.6874	.2818
5	.9835	
6	1.0576	
7	1.491	
8	1.6448	
11		.2321
12		1.326
13		1.1603
14		1.1271
15		1.0608
16	.0701	1.2266
17	.104	1.3592
18	.1402	1.4089
19	.1739	.1326
20	.3429	.1989
21	.3391	.2652
22	.2883	.2486
23	.4239	.2321
24		.2601
Max	1.6448	1.4089
Min	.0701	.1326
Avg	.6132	.6213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184064 / UMARANE

Feeder No / Name : 208 / PADGHAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
1	.333	.7459
2	.3052	.7459
3	.3052	.7459
4	.4458	.8288
5		.8288
6		1.0774
7		1.326
8		1.5249
11	.3391	
12	.9326	
13	.9326	
14	.7545	
15	.7287	.0995
16	.8478	.0995
17	.9326	.116
18	1.0288	.1492
19	.2103	.1989
20	.2254	.2652
21	.2401	.2818
22	.2204	.2321
23	.2103	.2652
24		.3052
Max	1.0288	1.5249
Min	.2103	.0995
Avg	.5290	.5465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184064 / UMARANE

Feeder No / Name : 209 / PARSUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
1	.8478	.8288
2	.763	.8288
3	.763	.9116
4	.8309	1.0774
5	.9724	1.0774
6	1.2378	1.2431
7	1.7465	1.4586
8	1.8442	1.8233
12	.3506	
13	.8573	
14	.763	
15	.7888	
16	.8573	.0829
17	.9536	.1326
18	.964	
19	.298	
20	.3856	
21	.373	
22	.3506	
23	.3155	.2984
24		.3506
Max	1.8442	1.8233
Min	.298	.0829
Avg	.8131	.8428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184085 / JALGAON NIMBAYAT

Feeder No / Name : 202 / Chondi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17
HR	Load (MW)	Load (MW)
1		.5144
2		.5144
3		.5487
4		.0566
5		.583
6		.8916
7		1.2003
8		1.3375
18	.2743	
19	.7545	
20	.6859	
21	.6173	
22	.6516	
23	.6173	
24		.4801
Max	.7545	1.3375
Min	.2743	.0566
Avg	.6002	.6807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184085 / JALGAON NIMBAYAT

Feeder No / Name : 203 / Varhane

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3803	.3772	.3582	.4161		.4115	.415
2	.4347	.5487	.3906	.4409		.4287	.4536
3	.4347	.4115	.423	.5144	.4409	.4287	.4734
4	.4527	.4458	.4557	.5487	.4428	.4458	.4934
5	.4904	.4801	.4838	.583	.4726	.4973	.5324
6	.6268	.5487	.5959	.6173	.6173	.5144	.6084
7	.5693	.4801	.7647	.7545	.7826	.7545	.5687
8	.4115	.3429	.9602	.8916	.9602	.8916	.4115
9				.6859	.1715	.7545	.2743
10	.2058			.1372	.7202	.1372	.2058
11	.1372			.1715	.2058	.1372	.3086
12	.583	.6859		.1372	.1715	.208	.7186
13	.4973	.5487		.1715	.1372	.1715	.5658
14	.5487	.4973		.1886	.2058		.3429
15		.5144	.1829	.2058	.1886		.2743
16		.4801	.1372	.2229	.2282		.3429
17			.2058	.1901	.1901	.1715	.4801
18	.7202		.2743	.2282	.2277	.2852	.6173
19	.7545	.5693	.4115	.4364	.3993	.4175	.6173
20	.4115	.3795	.4801		.4944	.4661	.407
21	.4458	.4183		.4563	.3887	.4554	.3772
22	.4287	.4175		.4183	.3605	.4563	.3429
23	.4115	.3803		.3795	.3239	.4563	.3391
24	.4175	.4115	.3402	.4527		.4115	.4183
Max	.7545	.6859	.9602	.8916	.9602	.8916	.7186
Min	.1372	.3429	.1372	.1372	.1372	.1372	.2058
Avg	.4681	.4704	.4309	.4021	.3871	.4238	.4412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184085 / JALGAON NIMBAYAT

Feeder No / Name : 204 / Erandgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5249		.4554	.4934		.4715	.4934
2	.5098		.4934	.4914		.4715	.5292
3	.5304		.5303	.6001	.5281	.5281	.5601
4	.5506		.5658	.7545	.5647	.5658	.5731
5	.6443		.6054	.8916	.6066	.6413	.6214
6	.8249		.7552	.9602	.7034	.7733	.814
7	.9437		.677	.823	.679	.7842	1.0123
8	1.2346		.6859	.6859	.5487	.7545	1.153
9				.4115	.3429	.5658	.8063
10	.2058	.2743		.2058	.3429	.1886	.2427
11	.2058	.1715		.2058	.1372	.1494	.2075
12	.2401	.3429		.6173	.6859	.7545	.2263
13	.2743	.2743		.6516	.6859	.6535	.1886
14	.3086	.3086	1.0288	.5144	.5144		.1867
15		.3429	.9431	.583	.583	.6535	.2263
16		.2743	.9602	.6173			.2241
17			.9945	.5929	1.0077	.7733	.2241
18	.1029	.4175	.9088	.7668	.8156	.8065	.2427
19	.061		.7545	.6473	.6341	.679	.4108
20		.4944	.7202		.4527	.5704	.4108
21		.4347		.4563	.415	.4563	.6602
22		.4563		.4158	.4904	.4158	.7095
23		.4563		.3795	.4706	.4527	.6908
24			.4183	.4527		.4706	.4554
Max	1.2346	.4944	1.0288	.9602	1.0077	.8065	1.153
Min	.061	.1715	.4183	.2058	.1372	.1494	.1867
Avg	.4774	.354	.7186	.5747	.5604	.5718	.4946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184085 / JALGAON NIMBAYAT

Feeder No / Name : 205 / JALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.6935	.4481	.51	.2423	.5037	.74
2	.7572	.6653	.4925	.5231	.2423	.5083	.7484
3	.7709	.7572	.5274	.4744	.5085	.5194	.8233
4	.8042	.8189	.5639	.5224	.5127	.524	.8288
5	.9084	1.0311	.6504	.6089	.5819	.6082	.976
6	1.2083	1.1774	.7882	.7346	.7652	.857	1.2996
7	1.1683	1.1812	.9133	.8367	.9685	1.0105	1.2498
8	.8306	.98	.9472	.8535	.9518	.9084	.9228
9	.6729	.439	.407	.6843	.6691	.7514	.7
10	.5868			.5198	.6081	.606	.5586
11	.4702			.4527	.4801	.4854	.4793
12	.5128	.4695		.3605	.4207	.2347	.4991
13	.3788	.4111		.3544	.1844	.3909	.4453
14	.4177	.3971	.1036	.4116	.3742	.2073	.3852
15	.1524	.3834	.4492	.4005	.3742	.2012	.3292
16		.4005	.4161	.3773	.2027	.189	.3536
17		.2271	.45	.3943	.3943	.3913	.4649
18	.5273	.3803	.4779	.4583	.4175	.4507	.6588
19	.7941	.631	.791	.7719	.7051	.7118	.6346
20	.9168	1.0023	.9827	.5365	.9135	1.0223	1.0097
21	.823	.9623	.4725	.9203	.8738	.9279	.8772
22	.7823	.829	.4313	.8237	.7945	.8291	.8901
23	.7514	.7827	.3932	.7727	.7476	.769	.7826
24	.7499	.7491	.5886	.5019	.2683	.8592	.711
Max	1.2083	1.1812	.9827	.9203	.9685	1.0223	1.2996
Min	.1524	.2271	.1036	.3544	.1844	.189	.3292
Avg	.7147	.6986	.5647	.5752	.5501	.6028	.7237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184212 / NAGAON

Feeder No / Name : 201 / KAULANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4508	.3506	.3601	.4191	.381	.4656
2	.4954	.4382	.3544	.3429	.381	.381	.4607
3	.5335	.4908	.394	.3429	.4191	.381	.4557
4	.6097	.5434	.4607	.4115	.4572	.4001	.5138
5	.7621	.5847	.4908	.5487	.4954	.4954	.5609
6	.8383	.8238	.5258	.6173	.5335	.6859	.7712
7	.8002	.9816	.5609	.5487	.5525	.6478	.8764
8	.8383	1.0166	.4908	.4801	.5716	.5335	.964
9	.7621	.5784	.3944	.3944	.4382	.4031	.4784
10	.3239	.2629	.2401		.3239	.298	.3086
11	.2667	.2103	.3086		.381	.3544	.2401
12	.2286	.208	.583		.6097	.5083	.2229
13	.2286	.2103	.5487		.5906	.4961	.2229
14	.2286	.1928	.5144		.5525	.3856	.2058
15	.2286	.1928	.4458		.5335	.4031	.2058
16	.2477	.2103	.5144		.5716	.4382	.2401
17	.2667	.2103	.583		.5716	.4908	.2572
18	.2667	.2481	.6173		.6097	.6201	.2572
19	.4954	.4557	.4458		.4763	.5552	.463
20	.5335	.5083	.5487		.5906	.5316	.5487
21	.4572	.4382	.4115		.5144	.4557	.4287
22	.4191	.3856	.3944		.4954	.4031	.4115
23	.4031	.3681	.3772		.4191	.4075	.4287
24		.4854	.3506	.3772		.381	.4557
Max	.8383	1.0166	.6173	.6173	.6097	.6859	.964
Min	.2286	.1928	.2401	.3429	.3239	.298	.2058
Avg	.4665	.4373	.4544	.4424	.5003	.4599	.4352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184212 / NAGAON

Feeder No / Name : 202 / NAGAON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.5788	.6722	.7356	.724	.724	.6348
2	.7621	.5601	.6413	.7356	.724	.743	.6161
3	.7621	.547	.6161	.7545	.724	.6859	.5601
4	.7811	.5658	.6348	.7922	.743	.6668	.6161
5	.7811	.5601	.6722	.7922	.743	.7049	.5847
6	.6859	.5601	.6908	.8299	.7621	.7049	.6036
7	.6478	.5975	.7282	.7922	.7621	.724	.5975
8	.6478	.6348	.6722	.7545	.7811	.7049	.5788
9	.6097	.5415	.6979	.811		.7842	.5601
10	.6478	.7282	.7865		.9145	1.0642	.7922
11	.7811	.8402	.9328		.9717	1.1203	.9619
12	.8002	.9619	1.0059		1.1622	1.2323	.9431
13	.7621	.7842	.9511		1.105	1.1949	.8676
14	.743	.6908	.9145		.8573		.7922
15	.724	.7842	.8779		.9526	1.0642	.7167
16	.7621	.8402	.9511		1.0288	1.2449	.7922
17	.8383	.8589	1.0242		1.2574	1.4146	.8488
18	.8002	.8962	1.0608		1.1241	1.2883	.8676
19	.7621	.8962	.9808		1.1431	.7468	.8299
20	.6668	.8029	.811		.8764	.7468	.6602
21	.6668	.7842	.8488		.8954	.679	.6036
22	.5716	.7282	.7922		.8573	.679	.6036
23	.6161	.6722	.7922		.8002	.7356	.6036
24		.5784	.6908	.7545		.724	.679
Max	.8383	.9619	1.0608	.8299	1.2574	1.4146	.9619
Min	.5716	.5415	.6161	.7356	.724	.6668	.5601
Avg	.7201	.7080	.8103	.7752	.9050	.8860	.7048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184212 / NAGAON

Feeder No / Name : 203 / NAGAON-AG -SDT

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2454	.2835	.2743	.3048	.3048	.2454
2	.3048	.2629	.2804	.3086	.3048	.3048	.2481
3	.3048	.2804	.333	.3772	.3429	.3239	.2454
4	.3429	.3155	.3814	.4458	.381	.381	.2804
5	.4572	.3506	.4607	.583	.4572	.4382	.3189
6	.6097	.5548	.4908	.6173	.5716	.5716	.4252
7	.5716	.5784	.631	.6859	.6859	.6097	.4557
8	.4572	.5548	.631	.7202	.8383	.8002	.3856
9	.3239	.4334	.4207	.4115	.6097	.3189	.2103
10		.2629	.2058		.3048	.2454	.1715
11	.381	.2686	.1715		.2286	.1753	.1715
12	.4191	.3506	.1372		.1905	.1753	.4458
13	.381	.3155	.1372		.1715	.1402	.4115
14	.3429	.2804	.1372		.1715	.1402	.3772
15	.3429	.2804	.1372		.1715	.1402	.3429
16	.362	.3155	.1715		.1715	.1417	.4115
17	.4191	.3814	.2058		.1715	.1402	.4458
18	.4954	.4557	.2401		.2477	.2481	.5144
19	.5716	.4557	.4287		.4954	.4252	.4115
20	.4572	.4557	.4287		.4191	.4207	.4287
21	.3048	.2835	.2401		.3429	.2835	.3429
22	.3048	.2507	.2058		.3048	.2804	.2915
23	.2454	.2835	.2743		.2667	.2507	.2743
24		.2454	.2835	.2743		.3048	.2481
Max	.6097	.5784	.631	.7202	.8383	.8002	.5144
Min	.2454	.2454	.1372	.2743	.1715	.1402	.1715
Avg	.3939	.3526	.3049	.4698	.3545	.3152	.3377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184260 / PATANE

Feeder No / Name : 201 / Aghar(Kh)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2667	.5135	.4816	.5216		.2667
2	.8002	.2667	.4988	.4816	.5001		.2667
3	.2477	.2858	.5213	.5335	.5001		.2858
4	.2858	.3048	.6081	.5639			.3429
5	.3429	.381	.7819	.5944	.602		.4382
6	.4763	.6097	.9762	.8592	.7773	.9172	.5716
7	.5716	.6097	1.2809	1.3283	1.3443	1.1683	.5335
8	.4572	.4572	1.2944	1.5023	1.3889	1.3123	.362
9	.3048	.3239	.2858	.2286	.3239	.3239	.3048
10	.2667	.2667	.1905	.2477	.2667	.2667	.1524
11	.6687	.5944		.1143	.1334		.6241
12	1.1574	1.0974		.1334	.1524		1.2654
13	1.1145	1.2037		.1334	.1715		1.1888
14	1.086	.9095		.1334	.1715		.9783
15	.9907	.9633		.1334	.1905	.2096	.8322
16	1.0536	.9907		.1334	.1715	.2096	.8173
17	1.1279	.945	.1524	.1905	.2286	.2477	.8322
18	1.1149	1.1288	.2667	.1905	.1715	.2667	1.1138
19	.3429	.4001	.381	.4191	.4001	.4001	.3429
20	.4001	.4572	.381	.4382	.4954	.5716	.4572
21	.362	.381	.3429	.3239	.3239	.4572	.362
22	.3239	.3048	.362	.3239	.3239	.362	.3239
23	.2858	.4755	.4161	.3418	.5418	.3239	.3239
24	.2667	.2515	.4923	.4458	.5216		.3048
Max	1.1574	1.2037	1.2944	1.5023	1.3889	1.3123	1.2654
Min	.2286	.2515	.1524	.1143	.1334	.2096	.1524
Avg	.5949	.5781	.5414	.4282	.4445	.5026	.5538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184260 / PATANE

Feeder No / Name : 202 / Patane

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0098	.9526	2.5339	2.553	2.5529	2.0957	1.0098
2	1.0098	.9145	2.4577	2.4958	2.5148	2.0957	1.0098
3	1.0098	.9717	2.5339	2.6101	2.5529	2.0957	1.0098
4	1.0288	.9526	2.7244	2.9722	2.5148	2.1719	1.0669
5	1.1812	1.0288	3.0865	3.2389	2.7435	2.3624	1.1431
6	1.5241	1.5622	3.8866	4.5153	4.0962	4.2296	1.5622
7	1.4289	1.6003	3.7723	4.0772	4.3439	3.8104	1.7337
8	1.1241	1.2003	2.3434	2.5529	2.7434	2.8959	1.2216
9	.9145	1.105	1.81	2.1148	2.0195	2.2291	1.105
10	2.7244	1.8481	1.7146	1.7338	1.7338	1.8481	1.9243
11	1.6575	1.8481	1.5241	1.5074	1.2003	.2667	1.9814
12	1.829	2.0195	.9526	.974	.8978	1.0479	2.1719
13	1.7909	2.0576	1.0288	.9526	.8764	1.0117	2.2291
14	1.9052	2.1681	.9526	1.0098	.9907	1.0324	2.2291
15	2.0957	2.0961	.9907	.9907	1.0669	1.0288	2.2481
16	2.0767	2.0957	.9526	1.0479	1.086	1.0479	2.2291
17	1.9433	2.0195	1.0669	.9907	.9717	1.0517	2.0767
18	1.9624	2.2862	1.2955	.9336	.9717	1.0517	2.3624
19	2.7435	2.6482	1.9052	1.8289	1.9815	2.0576	2.9341
20	3.3913	3.4294	3.5818	3.2198	3.4675	3.4675	3.6008
21	3.296	3.3532	3.3341	3.6961	3.3151	3.4294	3.5056
22	3.0674	3.1436	3.1436	3.1436	3.1817	3.2389	3.277
23	2.4767	2.7815	2.7434	2.8006	2.8387	2.5721	2.7054
24	1.0288	2.5339	2.5339	2.6101	2.6101	1.0498	1.086
Max	3.3913	3.4294	3.8866	4.5153	4.3439	4.2296	3.6008
Min	.9145	.9145	.9526	.9336	.8764	.2667	1.0098
Avg	1.8425	1.9424	2.2029	2.2737	2.2197	2.0495	1.9760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MALEGAON URBAN DIVISION[603]

MALEGAON CC(O&M)[545] BU 0485

Substation No/ Name :- 184260 / PATANE

Feeder No / Name : 203 / Chinchawad SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.1736	.5197	.503	.503		1.0059
2	1.2574	1.1736	.5533	.5197	.5197		1.0395
3	1.3077	1.2071	.6036	.5533	.5365		1.1065
4	1.3748	1.1736	.6539	.6371	.7209		1.1736
5	1.5089	1.2742	.7209	.7209	.7209		1.2742
6	1.861	1.6598	.6706	.6706	.7545	.7545	1.6598
7	2.4478	2.2801	.4862	.6036	.6036	.5533	2.2131
8	2.431	2.3137	.4024	.4191	.4191	.3688	2.2634
9	.3353	.3353	.2683	.3185	.3521	.3018	.3353
10	.218	.2683	.2012	.218	.2683	.2347	.285
11	.1677	.1844	1.1065	.7545	.3353		.2515
12	.1509	.2012	2.0119	1.861	1.7101	1.8945	.2012
13	.1677	.1677	2.0957	1.7101	1.6766	1.7436	.1844
14	.2012	.1844	1.5592	1.6598	1.6263	1.6933	.218
15	.1844	.1844	1.6095	1.643	1.6095	1.6766	.2347
16	.218	.2347	1.5927	1.8107	1.7772	1.7939	.2347
17	.1844	.1677	1.861	1.8442	1.9281	1.861	.2347
18	.1509	.2347	1.9281	1.9113	1.8778		.2515
19	.4527	.4694	.4191	.3856	.4024		.4862
20	.5365	.5868	.5197	.5197	.5533	.5365	.5533
21	.4862	.4694	.503	.4527	.4862	.4862	.4527
22	.503	.5365	.4725	.503	.5533	.503	.4527
23	.9556	.4862	.4862	.4527	.503	.8886	.8718
24	1.2239	1.0898	.5197	.503	.4694		.9892
Max	2.4478	2.3137	2.0957	1.9113	1.9281	1.8945	2.2634
Min	.1509	.1677	.2012	.218	.2683	.2347	.1844
Avg	.8159	.7524	.9069	.8823	.8711	1.0194	.7489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263] BU 5444

Substation No/ Name :- 184063 / 33/11 KV KUNDALGAON

Feeder No / Name : 201 / Kanadgaon ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5487			.2229
2		.583			.2229
3		.583			.2401
4		.6173			.2229
5		.6516			.3086
6		.8573			.2743
7		1.0631			.2743
8		1.1145			.1886
9	.0686				
10	.1029				
11	.0857				
12	.0857				
13	.0686		.1029		
14	.0857		.1029	.0857	
15	.0857			.0857	
16	.0857		.0686	.0686	
17	.0686		.1029	.0686	
18	.0857			.1715	
19	.1715			.1715	
20	.2401			.2229	
21	.2401			.2743	
22	.1543			.2572	
23	.3772			.2229	
24		.5487			.2401
Max	.3772	1.1145	.1029	.2743	.3086
Min	.0686	.5487	.0686	.0686	.1886
Avg	.1337	.7297	.0943	.1629	.2439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263] BU 5444

Substation No/ Name :- 184063 / 33/11 KV KUNDALGAON

Feeder No / Name : 202 / Khadgaon ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.583	.1715	.1715	.1029		.5144
2	.4801	.6859	.1715	.1372	.1372		.5487
3	.4801	.7716	.1715	.1715	.1372		.5144
4	.5144	.8573	.1715	.2058	.1715		.5144
5	.5144	1.1145	.2401	.2058	.1715		.5487
6	.8573	1.2003	.2743	.2401	.2058		.7888
7	1.3717	1.2689	.2058	.2401	.2058		1.2003
8	1.3375	1.3717	.1372	.1715	.1372		1.2689
9	.1029	.1029	.1029	.1372			.1029
10	.0686	.1029	.0686				.0686
11	.0686	.0686	.2401				.0686
12	.0686	.0686	.9602	.7202			
13	.0686	.1029	.8916		.8573		
14	.0686	.0857	.823		.7202	.6516	.0686
15	.0686	.0857	.7202	.5144		.6516	.0686
16		.0857	.7888	.6859	.6516	.7202	.0686
17		.0857	1.1317	.823	.7545	.9259	
18		.0857	1.1317	.8916		.9259	
19		.1543	.1372	.16		.1715	
20		.2401	.2401	.2058		.2058	
21		.2058	.2058			.2401	
22		.1715	.2058			.1715	
23		.1715	.1715			.5144	
24	.6173	.5487	.1715	.1715	.1029		.4458
Max	1.3717	1.3717	1.1317	.8916	.8573	.9259	1.2689
Min	.0686	.0686	.0686	.1372	.1029	.1715	.0686
Avg	.4501	.4258	.3973	.3443	.3350	.5179	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263]

BU 5444

Substation No/ Name :- 184063 / 33/11 KV KUNDALGAON

Feeder No / Name : 203 / Khadgaon gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	.1543	.1372	.1372		.2229
2	.1543	.1715	.1715	.1543	.1543		.1715
3	.1715	.2058	.1715	.1543	.1715		.1886
4	.2229	.2401	.2229	.1715	.2401		.2058
9	.1715	.1886	.1543	.1372			.2401
10	.1543	.1886	.1543	.1715			.2058
11	.12	.12	.1029	.12			.12
14				.1029			.1029
15	.0514	.0514	.0514	.0514		.0514	.1029
16		.1029	.1029		.1029	.12	.12
17		.1715	.12	.12	.1029	.12	
18		.1886	.1372	.1372		.1715	
19		.2572	.2401	.1715		.2743	
20		.2401	.2401	.2058		.2058	
21		.1543	.2058			.1886	
22		.2058	.1543			.1715	
23		.1543	.1543			.1543	
24	.1543	.1543	.1543	.1029	.1372		.1715
Max	.2229	.2572	.2401	.2058	.2401	.2743	.2401
Min	.0514	.0514	.0514	.0514	.1029	.0514	.1029
Avg	.1505	.1735	.1584	.1384	.1494	.1619	.1684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263]

BU 5444

Substation No/ Name :- 184063 / 33/11 KV KUNDALGAON

Feeder No / Name : 205 / kundalgaon industrial
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0514	.0343	.0343		.0343
2	.0343	.0343	.0343	.0343	.0343		.0343
3	.0343	.0343	.0343	.0343	.0343		.0343
4	.0343	.0343	.0343	.0343	.0343		.0343
5	.0343	.0343	.0343	.0343	.0229		.0343
6	.0343	.0343	.0343	.0343	.0343		.0343
7	.0343	.0343	.0343	.0343	.0343		.0343
8	.0343	.0343	.0343	.0343			.0343
9	.0686	.0686	.0514				.0686
10	.0857	.12	.1029				.1029
11	.1029	.1372	.1372				.1029
12	.1029	.0857	.1715	.1029			
13	.1029	.0343	.0514		.0686		
14	.1029	.0857	.12		.1543	.1886	.1029
15	.1029	.1029	.0857	.1029		.1029	.1029
16		.0686	.1029	.12	.1372	.12	.1029
17		.0514	.0686		.12	.1372	
18		.0857	.12	.1029		.1029	
19		.1029	.1029	.0343		.12	
20		.0343	.0686	.0343		.0857	
21		.0514	.0343			.0857	
22		.0514	.0686			.0857	
23		.0343	.0686			.0686	
24	.0514	.0343	.0857	.0686	.0343		.0857
Max	.1029	.1372	.1715	.12	.1543	.1886	.1029
Min	.0343	.0343	.0343	.0343	.0229	.0686	.0343
Avg	.0622	.0593	.0722	.0560	.0619	.1097	.0629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263] BU 5444

Substation No/ Name :- 184063 / 33/11 KV KUNDALGAON

Feeder No / Name : 206 / kundalgaon ag SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.583	.4458	.3944	.5144		.583
2	.583	.6173	.4801	.4115	.6516		.583
3	.583	.6859	.4801	.4115	.6859		.6173
4	.6859	.7545	.5144	.4458	.7716		.6516
5	.823	.823	.5487	.5144	.8573		.823
6	.9945	.8573	.7888	.8916	1.0802		.9259
7	.823	.6516	1.2003	1.2003	1.3032		.7202
8	.7888	.8916	1.3717	1.4403			.8916
9	.5144	.6859	.3429	.5144			
10	.4115	.4458	.2743	.3772			.3772
11	.3429	.4801	.2401				.4115
12	1.0288	.9259	.2058	.2401			
13	.9259	.7545	.2401		.2401		
14	.823	.7202	.2058		.2401	.2401	
15	.6859	.583	.2058	.2743		.2401	
16		.6516	.2058	.2743	.2743	.3086	.8573
17		.8916	.2058		.3086	.2743	
18		1.0288	.2743	.3429		.4458	
19		.6516	.6173	.6516		.7545	
20		.823	.6859	.823		.8916	
21		.6859	.6859			.7888	
22		.583	.583			.6859	
23		.3772	.2743			.6173	
24	.583	.6859	.4458	.3772	.4458		.5144
Max	1.0288	1.0288	1.3717	1.4403	1.3032	.8916	.9259
Min	.3429	.3772	.2058	.2401	.2401	.2401	.3772
Avg	.6966	.7016	.4801	.5638	.6144	.5247	.663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263] BU 5444

Substation No/ Name :- 184063 / 33/11 KV KUNDALGAON

Feeder No / Name : 207 / navsari ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.7373	.2743	.4458	.1715		.6859
2	.6859	.7716	.2743	.4801	.2058		.703
3	.6859	.8573	.2743	.4801	.2058		.6859
4	.7545	.9431	.2743	.2401	.2401		.6859
5	.7545	.9945	.2743	.2401	.2401		.7545
6	.9259	1.0802	.2743	.2058	.2743		.7888
7	1.1317	1.1317	.2743		.2743		1.0288
8	1.2003	1.1317	.2743		.2401		1.0631
9	.2058	.2401	.5144				.2401
10	.1029	.2401	.4801				.2058
11	.0686	.2401	.7202				.2058
12	.1029	.2401		.7202			
13	.1029	.2401	.8916		.7202		
14	.1029	.2401	.7202		.6859	.6859	.2058
15	.1029	.2401	.7202	.6173		.6859	.2401
16		.2401	.6859	.6859	.6516	.7202	.2401
17		.2401	.7888	.9259	.823	.9259	
18		.2401	.7202	1.0288		.9602	
19		.2743	.4801	.3086		.4801	
20		.2743	.2743	.2401		.2401	
21		.2743	.2743			.2743	
22		.2743	.2743			.2743	
23		.2743	.2401			.8573	
24	.7888	.6859	.2743	.4458	.1715		.7545
Max	1.2003	1.1317	.8916	1.0288	.823	.9602	1.0631
Min	.0686	.2401	.2401	.2058	.1715	.2401	.2058
Avg	.5273	.5044	.4458	.5046	.3772	.6104	.5659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263] BU 5444

Substation No/ Name :- 184237 / 33/11 KV MOHEGAON

Feeder No / Name : 201 / 11 KV MOHEGOAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.2614	.2667	.2667	
2	.5182	.2477	.2667	.2286	
3	.5335	.2286	.2477	.2286	
4	.5792	.2096	.2858	.2667	
5	.6401	.2667	.3048	.3429	
6	.6859	.2858	.362	.4763	
7	1.1279	.362	.381		
8	1.1203	.2667	.362		.9145
9	.8749	.2096	.2667		.8535
10	.1867	.1905	.2286		.1905
11	.112	.1143	.0953		.1334
12	.1494	.9892	.6036		
13	.168	.9995	.663		
14	.168	.9724	.788		
15	.1494	.9556	.7545		
16	.1867	.9556	.7293		
17	.1867	.9054	.78		
18	.2241	.9326	.7293		
19	.2801	.8383	.6952		
20	.3734	.4763	.4954		
21	.4668	.4954	.4191		
22	.3734	.3239	.3429		
23	.2987	.2667	.2667		
24	.4572	.2801	.2667	.2477	
Max	1.1279	.9995	.788	.4763	.9145
Min	.112	.1143	.0953	.2286	.1334
Avg	.4312	.5014	.4417	.2939	.5230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263] BU 5444

Substation No/ Name :- 184237 / 33/11 KV MOHEGAON

Feeder No / Name : 202 / 11 KV EKWAI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3201	.285	.3185
2	.3239	.3353	.3149	.3688
3	.4001	.3605	.3688	.3856
4	.4191	.4239	.4527	.4475
5	.5144	.4694	.5365	.5304
6	.5525	.6036	.639	.5935
7	.5525	.7209	.6952	
8	.4668	.6539	.6706	
9	.3734	.5868	.57	
10	.2427	.2858	.2667	
11	.168	.1905	.1334	
12	.4801	.1715	.1715	
13	.4111	.1524	.1524	
14	.4218	.1905	.1905	
15	.4321	.2286	.2286	
16	.4858	.2667	.2667	
17	.5312	.2858	.2858	
18	.578	.2477	.3429	
19	.5218	.4572	.4191	
20	.4668	.5144	.4954	
21	.4668	.4763	.4572	
22	.4108	.4191	.381	
23	.2614	.2286	.2667	
24	.3429	.3239	.2683	.3018
Max	.578	.7209	.6952	.5935
Min	.168	.1524	.1334	.3018
Avg	.4228	.3714	.3691	.4209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263]

BU 5444

Substation No/ Name :- 184269 / 33/11 kV WAGDARDI

Feeder No / Name : 201 / Hanuman Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.724	.0734	.6516	.7343		.724
2	.7164	.7087	.0716	.6516	.7164		
3	.7164	.724	.0716	.6878	.7164		
4	.8596	.7164	.0752	.724	.7522		
5	.8954	.7602	.0842	.8145	.788		.724
6	.9313	.8688	.0895	.9593	.9492		.905
7	.9671	.9412	.0842	.9955	1.0387		.9412
8	.8417	.9134	.0788	.9492	.8775		.9231
9	.7701	.8238	.0716	.9412	.8775		.8688
10	.7602	.788	.6373	.7964			.8869
11	.7164	.7701	.6447	.7522			.8326
12	.724	.7164			.0734		
13	.6878	.6984	.6516	.6984	.0716	.7421	.7522
14	.6878	.6805	.7164	.6089	.0681	.7602	.7522
15	.7164	.6984	.7602	.5552		.7421	.7522
16	.724	.7343	.7421	.6984		.7783	.8059
17	.7701	.077	.7602	.7701	.0726	.8688	.8059
18	.7783	.0806	.7602	.8417		.8145	.8238
19	.7783	.086	.9412			.8688	.8954
20	.9671	.1021	.9412	.985		1.0317	1.0566
21	.9593	.0931	.8688	.9671		.9593	.985
22	.905	.0895	.905	.9313		.9593	.9134
23	.7602	.086	.724	.8954		.8869	.8596
24	.7522	.724		.6878	.788		.7602
Max	.9671	.9412	.9412	.9955	1.0387	1.0317	1.0566
Min	.6878	.077	.0716	.5552	.0681	.7421	.724
Avg	.7959	.5669	.4888	.7983	.6089	.8556	.8484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263]

BU 5444

Substation No/ Name :- 184269 / 33/11 kV WAGDARDI

Feeder No / Name : 202 / Hudco Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9214	.7973	.086	.8505	.9568		.8954
2	.9313	.8059	.0806	.7973	.9214		.8596
3	.9568	.8059	.0824	.8059	.8859		.8596
4	.9671	.8505	.0913	.8859	.9568		.8688
5	1.0387	.9568	.1021	.9671	1.0631		.7973
6	1.182	1.0808	.1254	1.2757	1.258		1.2536
7		1.3643	.1397	1.258	1.4175		1.2934
8	1.2178	1.3112	.1182	1.2757	1.2934		1.382
9	1.1283	1.2048	.1182	1.1694	1.2048		1.2934
10	.9745	1.1163	.0967	1.0631			1.0631
11	.8859	.9922	.9568	.9745			1.0631
12	.9214	.9745	.8859	.9214			
13	.8859	.9214	.7973	.8505			1.0277
14	.8596	.8596	.815	.8505		.8869	.9922
15	.8505	.8954	.815	.8859		.8869	.9568
16	.9214	.9214	.8505	.9568		.9412	.9745
17	.8859	.0985	1.0277	.9568		1.0317	1.0099
18	.9313	.1075	1.0631	1.0631		1.086	1.1163
19	1.0745	.1128	1.1694	1.134		1.1104	1.2226
20	1.2894	.1289	1.2757	1.3466		1.3253	1.3466
21	1.2536	.1254	1.2757	1.2403		1.182	1.3289
22	1.2048	.1164	1.2403	1.1871		1.1283	1.258
23	1.0277	.1075	1.0745	1.0631		1.1283	1.1517
24	.9214	.9745	.8859	.9568	.9568		1.0208
Max	1.2894	1.3643	1.2757	1.3466	1.4175	1.3253	1.382
Min	.8505	.0985	.0806	.7973	.8859	.8869	.7973
Avg	1.0101	.7346	.6322	1.0307	1.0915	1.0707	1.0885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263]

BU 5444

Substation No/ Name :- 184270 / 33/11kV BURKULWADI

Feeder No / Name : 201 / 11kV Pakija

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2576	.2766	.2705	.2728	.2934	.2888
2	.2462	.237	.2561	.2469	.2507	.282	.2804
3	.2332	.2241	.2416	.2385	.2454	.2774	.2797
4	.2286	.221	.2362	.2378	.2385	.2728	.2637
5	.2378	.2202	.2454	.2462	.2583	.2873	.2705
6	.2599	.2423	.2774	.285	.2789	.3064	.3033
7	.3086	.2904	.3155	.3277	.2995	.3445	.3231
8	.33		.2812	.3277	.077	.3414	.3315
9	.2926		.2827	.5552	.2591	.3231	.3178
10	.301	.0015	.301	.5401	.2332	.3414	.3163
11	.2873		.2515	.5538	.237	.3338	.317
12	.298	.3406	.2919	.5613	.2408	.3734	.3102
13	.301	.3856	.2919	.5251	.2439	.3826	.3125
14	.2987	.3193	.2896	.4163	.2393	.3384	.2782
15	.2644	.2957	.2995	.4239	.2233	.3361	.2637
16	.2698	.2766	.3109	.4634	.2256	.3094	.2843
17	.2705	.285	.298	.5131	.1623	.3079	.2827
18	.2812	.2751	.2995	.5746	.3414	.3147	.2904
19	.3307	.3262	.3445	.7013	.3635	.333	.3292
20	.3772	.3635	.407	.7651	.471	.4054	.3696
21	.3765	.3079	.3978	.3871	.4557	.3833	.3521
22	.3292	.3528	.362	.3589	.4595	.3597	.3414
23	.2972	.3323	.3178	.3315	.378	.3391	.3102
24	.2964	.3109	.583	.5592	.5872	.3361	.2926
Max	.3772	.3856	.583	.7651	.5872	.4054	.3696
Min	.2286	.0015	.2362	.2378	.077	.2728	.2637
Avg	.2909	.2793	.3108	.4338	.2934	.3301	.3046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

MANMAD[263] BU 5444

Substation No/ Name :- 184270 / 33/11kV BURKULWADI

Feeder No / Name : 203 / 11 KV NEW FCI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	11-APR-17	12-APR-17
HR	Load (MW)	Load (MW)
9	2.6787	
10	2.2443	
11	1.9728	
12	1.7375	
13	1.6289	
14	1.5384	
15	1.7556	
16	1.9728	
17	2.1538	
18	2.5158	
19	2.6968	
20	2.7692	
24	2.782	1.7013
Max	2.782	1.7013
Min	1.5384	1.7013
Avg	2.1882	1.7013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184006 / NANDGAON

Feeder No / Name : 201 / NANDGAON U1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5427	1.2772	1.2209	2.3487	1.2155	2.4642	2.5411
2	1.2445	1.1325	1.1706	1.15	1.1667	1.2445	2.4562
3	2.4699	1.1126	1.153	2.3003	1.1401	1.2048	1.2978
4	1.1713	1.0913	1.1393	1.1454	1.1355	1.1805	1.2651
5	1.2193	1.1667	1.2132	1.2445	1.1927	1.2811	2.4577
6	2.6364	1.3024	2.5114	2.7035	1.3169	1.406	2.6368
7	2.589	2.7191	2.6307	1.3938	2.5187	1.4106	2.6513
8	2.5675	2.6707	2.5526	2.4028	2.5194	1.3077	2.3594
9	1.2551	1.3611	1.3695	1.2391	1.2605	1.3352	1.2117
10	1.2955	1.3596	1.3016	2.4207	1.3527	1.3268	1.2125
11	1.1927	1.2437	1.371	2.5042	1.3512	1.3382	1.4617
12	1.2414	2.3106	1.2841	1.3062	1.3778	1.3832	2.7865
13	1.23	1.2071	1.3695	1.2605	2.6734	2.5461	2.7423
14	1.1896	1.1622	1.3504	1.2666	1.464	1.3885	1.4243
15	1.1812	1.198	1.3161	1.2795	2.585	2.5919	1.3877
16	2.2508	2.2413	2.524	2.4531	2.612	2.6105	2.6498
17	2.1772	1.2513	2.6475	2.4581	1.4159	2.5533	2.601
18	1.2788	2.2862	2.7023	1.3435	1.3222	1.4045	1.3344
19	2.75	1.4929	3.099	2.7733	1.5127	1.6057	3.1756
20	1.5386	1.5821	1.608	1.5615	1.6514	1.6865	3.2369
21	2.7286	1.5211	3.0811	2.7542	1.5455	3.0666	1.5806
22	1.4563	1.496	1.5775	1.4525	1.4998	2.9176	1.5295
23	2.8487	1.4624	2.7816	2.556	1.4723	2.8197	2.9229
24	1.4845	2.4989	1.3451	2.5034	2.4756	1.467	2.5815
Max	2.8487	2.7191	3.099	2.7733	2.6734	3.0666	3.2369
Min	1.1713	1.0913	1.1393	1.1454	1.1355	1.1805	1.2117
Avg	1.8142	1.5895	1.8467	1.9092	1.6574	1.8142	2.1460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184006 / NANDGAON

Feeder No / Name : 202 / NANDGAON U 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545			.7167		.679	.6173
2							.583
3	.5658			1.1694			
5							.6516
6	.8299		.7202	.7545			.6859
7	.7545	.6516	.6859		.6859		.6516
8	.679	.583	.6173	.6859	.5487		.583
9				.583			
10				.583			
11				.6173			
12		.6859					.6516
13					.7545	.6173	.6516
15					.6173	.6516	
16	.6173	.5487	.6859	.6516		.6516	.6516
17	.6516		.679	.6516	.6516	.6516	
18		.5487	.679				.6173
19	.7888		.7922	.7545			.8676
20							.7922
21	.7888		.8676	.7545			
22						.6859	
23	.6859		.7167	.6859		.6859	.8299
24		.6859		.7316	.6516		.6516
Max	.8299	.6859	.8676	1.1694	.7545	.6859	.8676
Min	.5658	.5487	.6173	.583	.5487	.6173	.583
Avg	.7116	.6173	.7160	.7184	.6516	.6604	.6776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184006 / NANDGAON

Feeder No / Name : 203 / JALGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018			.5281		.3772	.1829
2							.1829
3	.2263			.4904			
5							.2439
6	.2641		.6706	.7545			.3048
7	.2263	.2134	.9145		.9145		
8	.1509	.1829	.9145	.9145	1.0669		.1219
9				.061			
10				.061			
11				.061			
12		.6097					.7926
13					.061	.061	.6706
15					.061	.061	
16	.6097	.5487	.061	.061	.061	.061	.5487
17	.7316		.0754	.061		.061	.7316
18		.6706	.0754				
19	.1829		.1509	.1829			.2263
20							.2829
21	.2439		.2263	.1829			
22						.1829	
23	.1829		.3772	.2134		.1829	.2263
24		.1829		.3772	.4572		.1829
Max	.7316	.6706	.9145	.9145	1.0669	.3772	.7926
Min	.1509	.1829	.061	.061	.061	.061	.1219
Avg	.3120	.4014	.3851	.3038	.4369	.141	.3614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184006 / NANDGAON

Feeder No / Name : 204 / SAKORA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573			.1715		.2263	.4877
2							.4877
3	.823			.1886			
5				.1715			.6097
6	1.0288		.1829	.1886			.8383
7	1.5089	1.5242	.1829		.1524		1.448
8	2.0576	1.6766	.1372	.1219	.1219		1.5242
9				.1219			
11				.3658	.3048		
12		.1524					.1524
13					1.9814	1.5242	.1524
15				1.5242	1.6766	1.0669	
16	.1524	.1524		1.5242	1.5242	.9145	.1886
17	.1524		1.6766	1.5242			.1524
18		.1524	.4338				.1886
19	.1829		1.6766	1.2193			.6859
20							1.3717
21	1.6766		1.5242	1.0669			
22						.7316	
23	.7621		.1715	.1524		.7621	.6859
24		.5335	1.5242	.1715	1.6766		.5335
Max	2.0576	1.6766	1.6766	1.5242	1.9814	1.5242	1.5242
Min	.1524	.1524	.1372	.1219	.1219	.2263	.1524
Avg	.9202	.6986	.8344	.6080	1.0626	.8709	.6338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184006 / NANDGAON

Feeder No / Name : 205 / HISWAL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458			.1467		.1143	.381
2							.381
3	.4161			.1189			
5							.381
6	.5944		.1677	.1886			.4572
7	.8688	.7926	.1219		.1524		.7621
8	.8688	.8002	.1067	.1067	.1067		.7621
9				.1219			
10				.1219			
11				.3048	.2439		
12		.1219					.1067
13					.6097		
14						.4572	
15					.4572	.4572	
16	.1067	.1067	.6097	.6097	.4572	.5335	.1067
17	.1067		.743	.6097		.6401	.1219
18		.1219					
19	.1829		.0892	.1219			.1486
20							.1806
21	.2134		.1204	.1829			
22						.1219	
23	.2134		.1143	.1524		.2134	.2858
24		.381	.6097	.1486	.1524		.381
Max	.8688	.8002	.743	.6097	.6097	.6401	.7621
Min	.1067	.1067	.0892	.1067	.1067	.1143	.1067
Avg	.4017	.3874	.2981	.2257	.3114	.3625	.3427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184006 / NANDGAON

Feeder No / Name : 206 / WAKHARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743			1.8861		1.6766	.1829
2							.1829
3	.2641			1.7147			
4			1.0974				
5			1.2803				.1829
6	.2743		1.5242	2.8292			.2439
7	.2058	.2439	1.7071		3.0483		.1829
8	.2572	.1829	1.7375	3.0178	2.7435		.1829
9				.2134			
10				.1219			
11				.2134	.2134		
12		2.4996					2.7435
13					.2439	.1372	
15					.1524	.1524	
16	2.1338	1.9204	.2401	.1219	.1524	.1219	1.6766
17	2.1338		.2263	.1219		.1219	1.829
18			.1886				
19	.2134		.2263	.1829			.1886
20							.2641
21	.2134		.2641	.2134			
22						.2439	
23	.1829		1.0288	.381		.1829	.1886
24		1.829	.1829	1.8004	1.6004		.1829
Max	2.1338	2.4996	1.7375	3.0178	3.0483	1.6766	2.7435
Min	.1829	.1829	.1829	.1219	.1524	.1219	.1829
Avg	.6153	1.3352	.8086	.986	1.1649	.3767	.6332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184006 / NANDGAON

Feeder No / Name : 207 / SAKORA WAKHARI G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829			.2641		.2829	.2572
2							.2572
3	.2641		.2058	.3018			
4			.2572				
5			.3601				.3258
6	.5658		.4115	.5281			.463
7	.3961	.3601	.4115		.4287		.4115
8	.2641	.2915	.2401		.2058		.3601
9				.2572			
10				.1372			
11				.2401	.3429		
12		.3258					.3772
13					.2743	.2743	.3086
15					.2743	.1715	
16	.1886	.2896		.3086	.2401	.1886	
17	.3601		.3206	.4115			.2743
18		.2743	.1886				.3395
19	.3772		.3961	.3258			.415
20							.4338
21	.2915		.3584	.3086			
22						.2915	
23	.2572		.3018	.2401		.2572	.2641
24		.2401		.2572	.2743		.2572
Max	.5658	.3601	.4115	.5281	.4287	.2915	.463
Min	.1886	.2401	.1886	.1372	.2058	.1715	.2572
Avg	.3248	.2969	.3138	.2984	.2915	.2443	.3389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184006 / NANDGAON

Feeder No / Name : 208 / 11kv Patkhana

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377			.1509		.0754	.0305
2							.0305
3	.0377			.1886			
5							.0457
6	.0377		.2134	.2641			.061
7	.0377	.061	.2743		.3048		.061
8	.0377	.0305		.3353	.3658		.0305
9				.0305			
10				.0305			
11				.0152			
12		.2439					.3048
13					.0305	.1219	.3048
15					.0305	.0305	
16	.1829	.2134	.0305	.0152	.0305	.0305	.1524
17	.2134		.0377	.0152		.0305	.1524
18		.2439	.0377				
19	.061		.0377	.061			.0377
20							.0377
21	.061		.0377	.061			
22						.0305	
23	.0457		.1132	.0457		.0305	.0189
24		.0457	.3353	.1509	.1219		.0457
Max	.2134	.2439	.3353	.3353	.3658	.1219	.3048
Min	.0377	.0305	.0305	.0152	.0305	.0305	.0189
Avg	.0753	.1397	.1242	.1049	.1473	.0500	.0938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184006 / NANDGAON

Feeder No / Name : 209 / 11KV HISWAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075			.2075			.2058
2							.2058
3	.2195			.2641			
5							.3086
6	.4904		.3944	.3018			.3772
7	.4338	.3944	.2058		.3429		.2229
8	.3206	.3086	.2743	.2572	.2572		.3258
9				.2401			
10				.1715			
11				.2058			
12		.2229					.3086
13					.1715	.1372	.2572
15					.2915	.12	
16	.2743	.2401	.2572	.2572	.3086	.1372	.3086
17	.1886		.1698	.1543		.1715	.2058
18		.2572	.2263				
19	.4458		.3395	.3601			.4338
20							.415
21	.2743		.2829	.3258			
22						.2401	
23	.3258		.2075	.2915		.2058	.2641
24		.2915		.2075	.2572		.2058
Max	.4904	.3944	.3944	.3601	.3429	.2401	.4338
Min	.1886	.2229	.1698	.1543	.1715	.12	.2058
Avg	.3181	.2858	.2620	.2496	.2715	.1686	.2889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184006 / NANDGAON

Feeder No / Name : 210 / water works Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415			.1509		.1132	.442
2							.442
3	.3772			.1509			
5							.3048
6	.3395		.2286	.2641			
7	.415	.3258	.2286		.2915		.2286
8	.415	.3086	.2286	.2591	.2743		.2134
9				.2286			
10				.1372			
11				.3658			
12		.3353					.2439
13					.3353	.2439	.2743
15					.2591	.2439	
16	.3353	.3353	.3658	.1067	.3506	.2591	.1829
17	.2743		.4527	.4458			.3048
18		.3353					
19	.2401		.4527	.3772			
20							.1509
21	.2915		.2829	.3944			.2263
22						.3353	
23	.583		.1509	.1543		.442	.6036
24		.583		.1509	.1372		.442
Max	.583	.583	.4527	.4458	.3506	.442	.6036
Min	.2401	.3086	.1509	.1067	.1372	.1132	.1509
Avg	.3686	.3706	.2989	.2451	.2747	.2729	.3123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184040 / VEHEL GAON

Feeder No / Name : 201 / AMODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9075	3.8579	.6768	.6303	.6917	1.531	1.765
2	1.8877	3.7929	.7373	.6409	.7153	1.4922	1.7071
3	1.8549	3.8162	.8563	.894	.8086	1.4853	1.6514
4	1.7802	3.8555	1.008	1.0736	1.051	1.5059	1.6659
5	1.7772	4.0046	.9405	1.1171	1.0753	1.6072	1.733
6	2.1315	4.4873	.5768	.314	.0069	2.0713	2.191
7	2.4562	4.8811				2.5133	2.5774
8	4.5458	4.5166	.6498	.3475	.483	2.5164	4.7775
9	2.6573	3.8718	.8461	.8381	.4024	2.2527	1.6857
10	.6058	.5871	.6206	.6078	.3445	.3368	.3292
11	.4977	.495	2.1463	1.8995	1.1843	.5186	.6024
12	.5163	.4836	5.2666	5.1972	.3772	.2683	.2949
13	.5521	.462	5.1115	5.1017	.1158	.4835	.2919
14	.5343	.4897	5.0544	4.6563	2.6642	.2728	
15	.5183	.4889	4.9514	4.5269	2.7618	.5122	
16	.4691	.4897	4.5755	2.3297	2.6284	.2759	
17	.5608	.4726	4.5339	2.3129	2.5644	.5003	
18	.5936	.6061	4.462	2.1041	2.3564	.3445	
19	.8532	.8188	4.072	3.599	2.1872	.9274	
20	1.0635	1.0155	1.013	.6074	.5998	.5914	
21	.9233	.9475	.9679	.5464	.5022	.5243	
22	.8131	.8066	.8742	.4832	.4489	.4504	
23	1.6876	.6415	.6342	.3902	1.3862	2.862	
24	3.3078	2.2885	.6284	.6966	1.8447	1.7657	1.5432
Max	4.5458	4.8811	5.2666	5.1972	2.7618	2.862	4.7775
Min	.4691	.462	.5768	.314	.0069	.2683	.2919
Avg	1.4373	2.0074	2.2262	1.7789	1.1826	1.1504	1.6297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184040 / VEHEL GAON

Feeder No / Name : 202 / MANGALANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1527	.3262	.2936			
2		2.1201	.3425	.2936			
3		2.2832	.3914	.3262			
4		2.3158	.4077	.3262			
5		2.3484	.4944	.4893			
6		2.5767	.3262	.4893			
7		2.6094	.3262	.4893			
8	2.7435	2.6094	.2446	.424	.424		2.5377
9	.2743	2.5767	.2772	.2936			.3429
10	.2743	.2283	.2283	.2609			
11	.2743	.2446	.212	.2609		.2401	.2743
12	.2572	.2446	2.5767	2.7398			
13	.2401	.2283	2.5931	2.7724		.2743	.2572
14	.2401	.2446	2.6094	2.7398			
15	.2572	.2772	2.7072	2.6583		.2743	.2743
16	.2743	.2609	2.7398				
17	.3086	.2609	2.7398			.2915	.2915
18	.3429	.3262	2.7398				
19	.3772	.3751	2.7235	2.5604		.3772	.4115
20	.4458	.3425	.3914				.4801
21	.4287	.3914	.4566				
22	.3772	.3262	.4893				
23	.2915	.3099	.2936			2.3148	1.7318
24	2.2291	2.1201	.3099	.2936			2.3148
Max	2.7435	2.6094	2.7398	2.7724	.424	2.3148	2.5377
Min	.2401	.2283	.212	.2609	.424	.2401	.2572
Avg	.5668	1.1572	1.1228	1.0418	.424	.6287	.8916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184040 / VEHEL GAON

Feeder No / Name : 203 / TALWADE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4893	.5708	.6523	.6523		
2		.5219	.6523	.6523	.6523		
3		.5545	.6686	.7828	.7828		
4		.6197	.7828	.8154	1.109		
5		.6523	.848	1.109	1.1742		
6		.6197	1.0274	1.3047	1.2721		
7		.5708	1.2231	1.5004	1.4351		
8	.4115	.4077	1.1742	1.0764	1.2231		.3944
9	.3772	.3425	.9785	1.0764			.3772
10	.3429	.2936	.3099	.2772			
11		.1957	.3099	.2772		.9431	1.0288
12	1.4746	1.4025	.3099	.3588			
13	1.4918	1.5004	.3099	.3588		1.166	1.2003
14	1.3717	1.4678	.3262	.3588			
15	1.2003	1.5982	.3588	.3425		1.0802	1.2003
16	1.406	1.2394	.3588				
17	1.3717	1.2068	.3588			1.3717	1.2003
18	1.286	1.109	.3588				
19	1.166	.9785	.5545	.5382		.5487	.4115
20	.703	.4893	.5545				.6859
21	.6687	.6197	.5871				
22	.583	.5545	.5545				
23	.5487	.4729	.5056			.4801	.5316
24	.5144	.5219	.5708	.6523	.6523		.4458
Max	1.4918	1.5982	1.2231	1.5004	1.4351	1.3717	1.2003
Min	.3429	.1957	.3099	.2772	.6523	.4801	.3772
Avg	.9323	.7679	.5939	.7137	.9948	.9316	.7476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184040 / VEHEL GAON

Feeder No / Name : 204 / SAWARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2936	1.0601	1.1416			
2		.3262	1.0927	1.1416			
3		.3425	1.1416	1.2068			
4		.3914	1.533	1.3047			
5		.4566	1.6635	1.4678			
6		.4893	1.8102	1.7939	1.8918		
7		.4077	2.1364	2.0875	1.9733		
8	.2915	.2936	2.1038	2.1201	1.9407		.2572
9	.2058	.2446	1.745	1.8592			.1886
10	.2229	.1631	.1631	.1794			
11		.1142	.1631	.1794		1.0288	1.3717
12	2.3148	2.1201	.1468	.1794			
13	2.4006	2.2016	.1468	.1794		2.4348	2.1434
14	2.2977	2.1527	.1468	.1957			
15	2.1605	2.1201	.1631	.212		2.2634	2.0576
16	2.1948	2.1038	.1468				
17	2.1605	2.0875	.1957			1.9376	2.1091
18	2.1262	1.9896	.2446				
19	2.0576	1.9244	.3751	.3751		.2572	.3429
20	.4973	.4729	.4566				.2743
21	.4287	.3914	.4566				
22	.3601	.3262	.424				
23	.3086	.2772	.2772			.2743	.2915
24	.3086	.3099	1.0601	1.1416			.2572
Max	2.4006	2.2016	2.1364	2.1201	1.9733	2.4348	2.1434
Min	.2058	.1142	.1468	.1794	1.8918	.2572	.1886
Avg	1.2710	.9167	.7855	.9862	1.9353	1.3660	.9294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184040 / VEHEL GAON

Feeder No / Name : 205 / GIRANADAM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1468	.1468	.1631	.1468		
2		.1468	.1468	.1631	.1468		
3		.1468	.1468	.1468	.1468		
4		.1468	.1468	.1468	.1638		
5		.1468	.1468	.1631	.1468		
6		.1468	.1305	.1468	.1468		
7		.1468	.1468	.1468	.1468		
8	.1715	.2283	.1468	.1468	.1468		.3086
9	.1543	.2283	.1142	.2283			.3086
10	.2058	.2283	.1142	.2772			
11	.2401	.2283	.2446	.2772		.2572	.2915
12	.2401	.2283	.2446	.2446			
13	.2572	.212	.2446	.2446		.2572	.2572
14	.2572	.212	.2609	.2283			
15	.2572	.2283	.2609	.2283		.2743	.2572
16	.2401	.2283	.2609				
17	.2401	.2772	.2609			.2401	.2572
18	.1543	.1468	.2609				
19	.1543	.1468	.2936	.1794		.1543	.1543
20	.1543	.1468	.2936				.1543
21	.1543	.1631	.1631				
22	.1372	.1468	.1631				
23	.1372	.1305	.1631			.1543	.12
24	.1543	.1468	.1468	.1631	.1631		.1543
Max	.2572	.2772	.2936	.2772	.1638	.2743	.3086
Min	.1372	.1305	.1142	.1468	.1468	.1543	.12
Avg	.1947	.1814	.1937	.1938	.1505	.2229	.2263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184040 / VEHEL GAON

Feeder No / Name : 206 / KALAMDHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.212	1.745	1.7939		
2		.1957	1.7939	1.7939		
3		.212	1.8266	1.8592		
4		.2772	2.0549	1.957		
5		.3262	2.1527	2.0875		
6		.4403	2.1853	2.218		
7		.4077	2.4463	2.2832		
8	.2572	.2772	2.4137	2.2343	2.4463	
9	.1715	.2283	2.1853	2.0712		
10	.1886	.1957	.1468	.1631		
11		.1794	.1468	.1631		2.4006
12	2.7435	2.642	.0979	.1305		
13	2.915	2.7398	.0979	.1305		2.7263
14	2.9492	2.6094	.0979	.0979		
15	2.6578	2.3647	.0815	.0979		2.4177
16	2.7092	2.2016	.1142			2.4006
17	2.7435	2.0712	.1142			2.6063
18	2.6406	2.0549	.1142			
19	2.572	2.0712	.2283	.2609		
20	.4115	.3588	.3262			
21	.3429	.2446	.3914			
22	.2915	.212	.3262			
23	.2401	.1631	.212			
24	.2401	.2283	1.7287	1.7939		
Max	2.9492	2.7398	2.4463	2.2832	2.4463	2.7263
Min	.1715	.1631	.0815	.0979	2.4463	2.4006
Avg	1.5046	.9547	.9595	1.2433	2.4463	2.5103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184084 / JATEGAON

Feeder No / Name : 201 / BOLTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7582	.7411	.903	.9202	.9202	.7582	.6725
2	.7582	.7582	.7925	.9202	.9373	.7239	.7068
3	.7925	.7754	.8859	1.2288	.9716	.7925	.7582
4	.8097	.8097	.9202	1.0822	.9545	.7754	.7925
5	.9202	.9716	1.1336	1.1679	1.0479	.903	.8516
6	1.0822	1.1165	1.2956	1.5089	1.1584	1.1927	.4287
7	1.1584	1.1755	1.8233	1.909	1.6956	1.1927	
8	.9279	.9965	2.0957	2.2748	2.1814	1.107	.2743
9	.7582	.8173	.9907	1.5279	.9907	.8344	.945
10	.6896	.6553		.7144	.381	.6382	.783
11	.4858	.5029		.4687	.2286	.5201	.682
12	1.3032	1.3718		.4858	.1524	1.4575	1.3889
13	1.0154	1.4308		.4687	.1524	1.5585	1.5337
14	1.3718	1.3546	1.0022	.4344	.1524	1.5166	1.4308
15	1.3889	1.3203	.4344	.3239	.1524	1.4137	1.3889
16	1.3718	1.3375	.4172	.341	.1524	1.2613	1.4061
17	1.6785	1.4308	.4515	.341	.1524	1.4994	1.4994
18	1.9166	1.6613	.5029	.4344	.2286	1.6442	1.7128
19	1.4098	1.2155	.8783	.7506	.381	1.2574	1.2231
20	1.0479	1.0822	1.0479	1.0479	.6097	1.1165	1.0479
21	.8344	.9107	.9279	.8173	.5335	.9793	.9793
22	.7411	.7239	.7411	.7411	.381	.8687	.8687
23	.7411	.6306	.8097	.6553	.381	.7582	.8516
24	.381	.7582	.9373	.9202	.8611	.381	.6725
Max	1.9166	1.6613	2.0957	2.2748	2.1814	1.6442	1.7128
Min	.381	.5029	.4172	.3239	.1524	.381	.2743
Avg	1.0143	1.0228	.9495	.8952	.6566	1.0479	.9956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184084 / JATEGAON

Feeder No / Name : 202 / JATEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6222	2.3563	1.0612	1.1309	1.0643	1.6587	1.6594
2	.7178	2.4417	1.0882	1.1446	1.1004	1.6846	1.7315
3	.743	2.383	1.1245	1.0608	1.1599	1.8335	1.8134
4	.8059	2.4375	1.1744	1.1149	1.2079	1.9753	2.0606
5	.9187	2.6018	1.2727	1.1492	1.2768	2.3468	2.5118
6	1.0704	3.3364		.8383		3.134	3.525
7	1.2978	4.3222		.6698		3.9594	3.8931
8	1.3836	4.0493	.934	.684	.9046	3.6492	3.8249
9	.6569	1.3519	.4268	.4404	.49	1.2609	1.2947
10	1.5112	.7003		.0472	.3841	.5822	.6622
11	1.0231	.6073		1.7192	1.3093	.4512	.5773
12	.4724	.5015		3.1992	2.0858	.4573	.6322
13	.4233	.554	1.0738	3.0132	2.0058	.4462	.5552
14	.4641	.5685	3.5734	2.8806	1.7353	.4687	.5186
15	.5045	.4687	3.6847	2.7024	1.419	.519	.5529
16	.6017	.5651	3.9365	2.9977	1.467	.5689	.5845
17	.594	.6256	3.8656	2.9463	1.4594	.6428	.6238
18	.7388	.7811	3.4637	2.7725	1.419	.7582	.719
19	1.0044	1.1713	2.7382	1.3816	.9153	1.1329	1.2033
20	1.1728	1.2677	2.2276	1.0711	.6394	1.2669	1.1991
21	1.0943	1.1375	1.1477	1.0494	.5312	1.1085	1.0128
22	1.0006	1.1721	.6302	1.1154	.4992	.9401	.948
23	1.3413	1.0498	1.1713	1.086	.6539	1.1385	1.2925
24	1.1896	1.518	1.198	1.1126	1.3394	.9755	1.4921
Max	1.5112	4.3222	3.9365	3.1992	2.0858	3.9594	3.8931
Min	.4233	.4687	.4268	.0472	.3841	.4462	.5186
Avg	.8897	1.5820	1.8838	1.5553	1.1394	1.3733	1.4537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184084 / JATEGAON

Feeder No / Name : 203 / DHEKU

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1886	.2915	.2915	.3086	.2401	.3086
2	.2229	.1715	.2915	.2743	.3086	.2401	.3429
3	.2915	.1886	.3086	.3086	.3258	.2572	.3429
4	.3429	.2058	.3258	.3601	.3258	.2743	.3601
5	.3772	.2401	.2743	.4287	.3944	.3429	.4287
6	.4287	.2915	.2572	.5487	.5487	.3772	.5487
7	.8059	.6859	.3086	.5144	.4458	.7202	.8402
8	.8573	.8402	.1886	.4115	.3601	.6516	.9602
9	.2572	.2229		.3258		.2058	.2572
10	.1715	.1372		.2058		.1372	.1715
11	.1029	.1715		.1715		.0857	.1543
12	.1372	.1543		.3772		.0857	.1543
13	.12	.1543		.4287		.1029	.1543
14	.1372	.1543	.5658	.3944		.1029	.1543
15	.1543	.1543	.5316	.4115		.0857	.1886
16	.2058	.1715	.5487	.4287		.1372	.1715
17	.2401	.2058	.6173	.463		.12	.1715
18	.2401	.2401	.583	.5487		.12	.2401
19	.4287	.3772	.3944	.3429		.3772	.4115
20	.4458	.4115	.4801	.4801		.4801	.4801
21	.3944	.4115	.4287	.4115		.4115	.3772
22	.3772	.3601	.3429	.3429		.3601	.3429
23	.1372	.2915	.3086	.2915		.2401	.2915
24	.2229	.1886	.2915	.2915	.3258		.2743
Max	.8573	.8402	.6173	.5487	.5487	.7202	.9602
Min	.1029	.1372	.1886	.1715	.3086	.0857	.1543
Avg	.3058	.2758	.3862	.3772	.3715	.2676	.3386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184084 / JATEGAON

Feeder No / Name : 204 / BOLTHAN JATEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2915	.3086	.2743	.2915	.2915	.3086
2	.3429	.2915	.2915	.2743	.2915	.2915	.3258
3	.2743	.3086	.2915	.2915	.3086	.3086	.3429
4	.3086	.3086	.3086	.3258	.3086	.3258	.3429
5	.3429	.3258	.3086	.4458	.3429	.3429	.4287
6	.4458	.4115	.4973	.4801	.3944	.3944	.463
7	.4801	.4801	.5144	.3944	.4458	.463	.4801
8	.3258	.5144	.4287	.4115	.463	.3772	.5144
9	.3944	.3944		.3429		.3944	.4287
10	.3429	.3429		.3258		.3086	.3772
11	.3086	.3086		.3086		.2915	.3429
12	.2743	.3086		.2915		.2915	
13	.2915	.2743		.2915		.2915	
14	.2915	.3258	.2058	.3086		.3086	.4801
15	.2915	.3086	.2572	.2915		.3086	.4287
16	.3086	.2915		.3086		.3772	.3772
17	.3086	.2743	.3429	.2915		.3772	.4115
18	.3601	.3429	.3601	.3086		.4287	.4115
19	.4287	.463	.4458	.3772			.4287
20	.4973	.4458		.4973			.4115
21	.4115	.3944	.3944	.3944		.4973	.3601
22	.3429	.3429	.3429	.3429		.4458	.3429
23	.3258	.3258	.3086	.3086		.3601	.4458
24		.3086	.3258	.2743	.3086		.2743
Max	.4973	.5144	.5144	.4973	.463	.4973	.5144
Min	.2743	.2743	.2058	.2743	.2915	.2915	.2743
Avg	.3511	.3494	.3490	.3401	.3505	.3560	.3967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184091 / BANGAON

Feeder No / Name : 201 / KASARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	10-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
14	1.2193		
20		.0829	
23			.1562
Max	1.2193	.0829	.1562
Min	1.2193	.0829	.1562
Avg	1.2193	.0829	.1562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184091 / BANGAON

Feeder No / Name : 202 / BANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	10-APR-17	13-APR-17
HR	Load (MW)	Load (MW)
13	.2286	
20		.3277
Max	.2286	.3277
Min	.2286	.3277
Avg	.2286	.3277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184091 / BANGAON

Feeder No / Name : 203 / BHALUR

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	10-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
13	2.3624		
20		.4049	
23			.2187
Max	2.3624	.4049	.2187
Min	2.3624	.4049	.2187
Avg	2.3624	.4049	.2187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184091 / BANGAON

Feeder No / Name : 204 / 11KV TAKALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	10-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
14	.1242		
20		.2486	
23			.25
Max	.1242	.2486	.25
Min	.1242	.2486	.25
Avg	.1242	.2486	.25

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184091 / BANGAON

Feeder No / Name : 205 / WADALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-APR-17
HR	Load (MW)
20	.1783
Max	.1783
Min	.1783
Avg	.1783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184091 / BANGAON

Feeder No / Name : 206 / BHAURI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	10-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
14	.1067		
20		.1677	
23			.2187
Max	.1067	.1677	.2187
Min	.1067	.1677	.2187
Avg	.1067	.1677	.2187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184257 / 33/11 KV NAIDONGARI

Feeder No / Name : 201 / PARDHADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3978	.4572		.3963	.4908	.5258
2		.4115	.4908		.4458		.5609
3		.4641	.5215		.4661		.6135
4		.4938	.5487		.4607		.631
5		.5992			.5689	.6661	.6516
6		.6613	.7064		.7945		.7291
7		.5898	1.0822		1.1963		.6167
8		.431	1.166		1.0889		.4586
9	.2622			.381			.3067
10		.2301		.3048			.3067
11		.3083		.1981	.2454		.3527
12	.6859	1.0736		.2147	.2804		1.121
13	1.1831	.9816			.2804	1.0202	.9686
14	.9431	.9145			.298	.9945	.8599
15	.9724					.8939	.7707
16	.9995	.7515		.2764		.929	.7697
17	.9835	.9049				.9568	.9148
18	1.1831	.8589				1.0802	.9666
19	.5243	.4754				.5256	.4908
20	.5935	.6165				.6836	.5981
21	.5992	.4778				.7011	.6097
22	.5155	.4316				.6173	.5375
23	.4801	.3083				.5426	.4754
24		.3018	.3681		.3681		.5258
Max	1.1831	1.0736	1.166	.381	1.1963	1.0802	1.121
Min	.2622	.2301	.3681	.1981	.2454	.4908	.3067
Avg	.7635	.5765	.6676	.275	.5300	.7771	.6401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184257 / 33/11 KV NAIDONGARI

Feeder No / Name : 202 / CHANDORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5601	.2762		.2934		.3479
2		.6226	.2934				.4031
3		.6562	.2915				.3944
4		.8139	.3086		.328		.4382
5		.8383	.3625		.3621		.4458
6		.9602	.4498		.4458		.5083
7		1.3717	.4115		.4325		.9602
8		1.2967	.2968		.3429		.9816
9	.2561	.2229					
10	.25	.2058					
11	.2515	.1899			.5426		
12	.1829	.1886			.8817		
13	.2006	.1899			.8413	.2058	
14	.1739	.1899			.7522	.1739	
15	.1943	.2071					
16	.216	.2058		.9546			.2071
17	.1829	.2229					.2071
18	.2294	.2589				.1492	.2589
19	.3185	.3601				.3155	.328
20	.3437	.5316			.4207		.4661
21	.4115	.4315				.3772	.3107
22	.3113	.3633				.3506	.2572
23	.4409	.3107				.3681	.3441
24		.5487	.2743		.2925		.4031
Max	.4409	1.3717	.4498	.9546	.8817	.3772	.9816
Min	.1739	.1886	.2743	.9546	.2925	.1492	.2071
Avg	.2642	.4895	.3294	.9546	.4946	.2772	.4272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184257 / 33/11 KV NAIDONGARI

Feeder No / Name : 203 / NAIDONGARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.253	.2762		.3452		.3086
2		.2652	.2607		.3452		.3391
3		.3086	.3107		.3452		.3506
4		.2968	.3114		.3625		.373
5		.3561	.3797		.3834		.4557
6		.3688	.4115		.4833		.5258
7		.3321	.3948		.5178		.3772
8		.3086	.2915		.397		.3321
9	.2818	.2759					
10	.3052	.274					.328
11	.3005	.2934			.3258		.3258
12	.2688	.2915			.298		.3258
13	.3185	.2743			.2688	.2204	.3258
14	.2622	.2762			.298	.2401	.3258
15	.2883	.0171				.3077	.3429
16	.2743	.2902		.3452		.3163	.3601
17	.2881	.3107				.3801	.3625
18	.3353	.328				.3772	.3772
19	.3239	.3625				.4586	.4143
20	.3048	.3797				.4744	.5006
21	.2846	.3797				.4409	.4458
22	.2915	.328				.373	.397
23	.2743	.2762				.3429	.3681
24		.2515	.2572		.3107		.3189
Max	.3353	.3797	.4115	.3452	.5178	.4744	.5258
Min	.2622	.0171	.2572	.3452	.2688	.2204	.3086
Avg	.2935	.2958	.3215	.3452	.3601	.3574	.3731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184257 / 33/11 KV NAIDONGARI

Feeder No / Name : 204 / NASTANPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3521	.5675		.5215		.4961
2		.3704	.5828		.6214		.5144
3		.4801	.6288		.6732		.5487
4		.4902	.6748		.6441		.583
5		.5571	.8383		.7208		.6135
6		.6036	.8785		.9202		.6516
7		.4961	1.3636		1.4263		.583
8		.4424	1.3565		1.3837		.5258
9	.3953	.2914					.3658
10	.3812	.2591					.3201
11	.5668	.3506			.3856		.3988
12	1.6289	1.3036			.3681		1.2346
13	1.543	1.1948			.3155	1.3757	
14	1.1191	1.1224			.2915	1.2445	1.0212
15	1.166	1.0429				1.046	.8535
16	1.286	.9521		.2914		1.0974	.9049
17	1.3717	.9662				1.3496	
18	1.6461					1.2445	.9864
19	.4917	.4115				.5434	.5144
20	.5316	.5368				.6344	.6135
21	.4725	.5061				.6001	.5368
22	.4481					.5316	.4908
23	.3932	.3237				.4908	.5351
24		.3605	.5215		.5368		.4557
Max	1.6461	1.3036	1.3636	.2914	1.4263	1.3757	1.2346
Min	.3812	.2591	.5215	.2914	.2915	.4908	.3201
Avg	.8961	.6097	.8236	.2914	.6776	.9235	.6249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184258 / JALGAON (BK)

Feeder No / Name : 201 / JALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1372	.6858	1.2822	.6097	1.448	.0823
2	.0762	.1372	.9298	1.4384	.6859	1.7071	.0853
3	.0762	.1162	.6097	1.5242	.8383	1.6309	.1524
4	.0762	.1295	.6097	1.4251	.8383	1.6461	.0762
5	.0762	.1448	.6097	1.5851	.8383	.9907	.1524
6	.1372	.1524	.6859	1.5089	1.4632	1.0669	.1631
7	.1372	.0823	1.4632	1.7909	1.7833	1.1431	.1524
8	.1372	.0823	1.4784	1.7737	1.7833	1.0669	.1631
9	.0762	.0823	.8288	1.0517	.9907	.6859	.0808
10	.0762	.0762	.2038	.2896	.2286	.0762	.1524
11	.0762	.1677	.1448	.061	.0762	.0762	.2591
12	.5335	.9603	.1524	.1372	.0762	.0762	1.0212
13	.6097	.9907	.1372	.061	.0762	.0762	1.1584
14	.5335	.7774	.1619	.0762	.0762	.0853	1.0974
15	.4572	.5334	.1429	.1219	.1372	.0853	.9603
16	.3048	.6553	.1524	.1372	.0762	.0869	.9449
17	.4572	.762	.1676	.1372	.1372	.0838	.9603
18	.4572	.7925	.1429	.1372	.0762	.0853	.9603
19	.5334	.4618	.0762	.0762	.0762	.0838	.5945
20	.1524	.0853	.2191	.1524	.0762	.0869	.2286
21	.1524	.0823	.2191	.1524	.1524	.1585	.2286
22	.1619	.0762	.1524	.1524	.1524	.0762	.2286
23	.1619	.0884	.3048	.1524	.1524	.0808	.1524
24	.1372	.1524	.5335	.9773	.5335	.7773	.1631
Max	.6097	.9907	1.4784	1.7909	1.7833	1.7071	1.1584
Min	.0762	.0762	.0762	.061	.0762	.0762	.0762
Avg	.2364	.3219	.4505	.6751	.4973	.5575	.4258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184258 / JALGAON (BK)

Feeder No / Name : 202 / JALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.04	.0813	.1219		.1276	.0051
2	.0762	.0305	.0813	.1029		.1448	.0813
3	.0762	.0267	.0762	.0267		.0686	.0813
4	.0762	.0514	.0762	.0457		.0686	.0762
5	.0762	.1276	.0762	.1219	.0762	.0762	.0762
6	.1524	.1295	.0762	.1448	.1372	.0762	.0831
7	.1372	.0848	.0831	.1276	.1524	.0762	.0762
8	.1372	.0831	.0813	.1448	.1372	.0762	.0831
9	.0762	.0831	.1067	.1372	.0762	.0762	.0813
10		.0762	.0343	.1372	.0762	.0762	.0762
11	.0762	.0069	.0343	.061			.0457
12	.0762	.0069	.0305	.061			.061
13		.0051	.0343	.061			.0457
14	.0762	.0069	.0457			.0051	.1219
15		.0069	.0267	.061	.0686	.0051	.061
16		.0069	.0514	.0457		.0051	.0457
17		.0051	.0514	.061	.0857	.0069	.1219
18	.0762	.0813	.1448			.0813	.1372
19	.1219	.0813	.1524	.0762	.0762	.0813	.1372
20	.1372	.0831	.1105	.0762	.1524	.1575	.0762
21	.1448	.0831	.1029	.0762	.0762	.0796	.0762
22	.1276	.0762	.1219	.0762	.0762	.0762	.0762
23	.1105	.0796	.1276	.0762	.0762	.0796	.0762
24	.061	.1276	.0762	.1105	.0762	.0514	.0813
Max	.1524	.1295	.1524	.1448	.1524	.1575	.1372
Min	.061	.0051	.0267	.0267	.0686	.0051	.0051
Avg	.0996	.0579	.0785	.0888	.0959	.0712	.0785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259] BU 6459

Substation No/ Name :- 184258 / JALGAON (BK)

Feeder No / Name : 203 / 11KV POKHARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4877	.0107	.0914		.08	.3963
2		.6687	.0107	.0914		.08	.4115
3		.5735		.08		.08	.4268
4		.5068		.0914		.0667	
5		.6668		.12			
6	.9145	.6802		.12			.7468
7	1.1584	1.3108	.0122	.08	.1829		
8	1.4022	1.387		.0914	.2134		1.3413
9		.0107	.0686	.0914			.0091
10		.0091	.0686	.1219			
11		.0091	.5487	.6097			.1219
12		.0107	1.0269	.9145			.1829
13		.0122	1.1888	1.0364			.1219
14		.0107	1.1126			.6859	.1219
15		.0107	.9069	1.0212	.6935	.6859	.1219
16		.0122	.8935	1.0364		.6706	.1219
17		.0107	1.0402	1.0822	.8402	.9145	.1219
18		.0122	1.0402			1.0974	.1829
19	.08	.0091				.0107	.2439
20	.1029	.0122	.0914			.0122	
21	.0914	.0107	.08			.0091	
22	.1029		.1029				
23	.3048	.0076	.08			.0061	
24	.5487	.4134		.08		.0667	.4877
Max	1.4022	1.387	1.1888	1.0822	.8402	1.0974	1.3413
Min	.08	.0076	.0107	.08	.1829	.0061	.0091
Avg	.5229	.2975	.4872	.3976	.4825	.3190	.3225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

NANDGAON[259]

BU 6459

Substation No/ Name :- 184258 / JALGAON (BK)

Feeder No / Name : 204 / WATER SUPPLY EXPRESS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187		.0541	
2	.0196		.0528	
3	.0196		.0528	
4	.0196		.053	
5	.0196		.0532	
6	.0217		.0549	
7	.0107		.0802	
8	.0122		.047	
9	.009		.0267	
11				.089
12				.097
13				.094
14		.0137		.094
15				.0942
16				.0565
17				.0543
18				.0467
19				.0461
20			.0002	.0335
21	.0082			.0349
22				.0349
23				.0332
24	.0137	.0053		.0345
Max	.0217	.0137	.0802	.097
Min	.0082	.0053	.0002	.0332
Avg	.0157	.0095	.0475	.0602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184001 / YEOLA (U) SUB STATION

Feeder No / Name : 201 / 11 kV YEOLA 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6937	.8947	1.8896	.9389	.9739	.98	1.012
2	1.6602	.8733	1.8683	.9084	.9374	.9496	.9785
3	1.6373	1.7108	1.7642	.8901	.9084	.9236	.948
4	1.8195	.8657	1.7809	.9191	.913	.9389	.9496
5	1.9247	1.8069	1.9719	1.0578	.9892	1.0166	1.0974
6	2.1357	1.0608	2.2466	1.1599	1.0959	1.1416	1.1584
7	1.9753	1.8016	2.3186	1.0898	1.0364	1.1416	1.134
8	1.957	1.8884	1.8541	.9892	.9968	1.1294	1.0578
9	.9404	1.0501	1.8541	1.6964	.9983	1.0395	2.0131
10	.9709	.9953	2.0652	1.0029	1.0136	1.0486	1.9471
11	.9907	1.0517	2.1506	1.7574	1.0197	1.1614	2.1655
12	.9694	1.0181	1.9734	1.7848	1.0456	1.169	2.101
13	.9892	.8962	1.848	1.8305	1.0745	1.1065	2.1841
14	1.0425	.9755	1.9704	1.041	1.0943	1.0913	1.9867
15	1.0501	1.0151	1.8709	1.9067	1.1218	1.1081	2.1582
16	1.0227	.9785	1.9369	1.922	1.0822	1.1203	1.1126
17	1.0014	1.9658	1.0532	1.0532	1.137	1.1187	1.1477
18	1.0197	1.941	1.1538	1.105	1.1462	1.1416	1.1538
19	2.1777	2.3121	1.2894	1.2605	1.3565	1.3824	1.3443
20	1.2026	2.3872	1.2651	1.2544	1.3824	1.3413	1.3016
21	2.0938	2.3155	1.1873	1.1949	1.2422	1.262	1.2071
22	1.1081	2.178	1.1751	1.1965	1.2178	1.23	1.2376
23	1.0562	2.0146	1.0959	1.1446	1.1568	1.166	1.1888
24	1.8129	1.7669	1.8419	1.0517	1.038	1.0623	1.0943
Max	2.1777	2.3872	2.3186	1.922	1.3824	1.3824	2.1841
Min	.9404	.8657	1.0532	.8901	.9084	.9236	.948
Avg	1.4272	1.4902	1.7261	1.2565	1.0824	1.1154	1.4033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184001 / YEOLA (U) SUB STATION

Feeder No / Name : 202 / 11 kV YEOLA 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.787	.8962	1.8225	.9343	.8993	.9564	1.0044
2	1.7482	.8566	1.8846	.9	.8558	.9229	.9435
3	1.7024	1.7146	1.8648	.8733	.8482	.9092	.9275
4	1.7276	.8718	1.7783	.8954	.8391	.9343	.9297
5	1.9292	1.816	1.8839	.9145	.913	1.0037	.9503
6	2.0347	.9854	2.0145	.9412	1.0059	1.0471	.9579
7	2.1159	1.7901	2.2482	.9922	1.0059	1.0501	1.1111
8	2.2565	1.9319	2.1616	1.0761	1.0875	1.0913	1.2224
9	1.073	1.182	2.1041	1.8427	1.0524	1.1789	2.0942
10	1.15	1.1728	1.9997	1.137	1.1248	1.2765	2.348
11	1.1957	1.2231	2.2672	2.1049	1.0639	1.23	2.194
12	1.2003	1.2391	2.3182	2.1849	1.2353	1.3237	2.3141
13	1.1408	1.2003	2.0903	2.1765	1.2094	1.2856	2.3434
14	1.1401	1.1629	2.0515	1.2094	1.2452	1.2003	2.0545
15	1.1591	1.1431	2.0698	2.2085	1.2574	1.2231	2.2908
16	1.1591	1.1485	2.2215	2.1285	1.2635	1.2353	1.259
17	1.201	2.1704	1.2094	1.1408	1.2323	1.2346	1.1492
18	1.1972	2.226	1.2833	1.1927	1.2209	1.3138	1.2574
19	2.5431	2.4337	1.3535	1.3877	1.3717	1.3946	1.419
20	1.2689	2.5004	1.3352	1.3275	1.3222	1.3557	1.3573
21	2.1841	2.3419	1.2125	1.2269	1.2277	1.2483	1.2681
22	1.086	2.205	1.1462	1.15	1.1058	1.1225	1.1896
23	1.038	1.0715	1.0692	1.0044	1.0814	1.1027	1.1599
24	1.9117	1.7726	1.8526	.9556	1.0059	1.0646	1.0692
Max	2.5431	2.5004	2.3182	2.2085	1.3717	1.3946	2.348
Min	1.038	.8566	1.0692	.8733	.8391	.9092	.9275
Avg	1.5396	1.5440	1.8018	1.3294	1.1031	1.1544	1.4506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184001 / YEOLA (U) SUB STATION

Feeder No / Name : 203 / 11 kV ANDERSUL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5362	1.1797	1.3984	.9419	.8185	1.0829	1.0738
2	2.492	1.1515	1.4342	.9511	.833	1.0669	1.0684
3	2.5732	2.5354	1.3973	.9846	.9137	1.0532	1.0753
4	2.7031	1.2247	1.5455	1.0601	1.0029	1.1279	1.0532
5	2.5282	2.8776	1.0425	.8893	1.0555	1.1927	1.1584
6	3.8096	1.7459		.9084	.8246	1.5005	1.6072
7	4.4955	3.9484		.8581		1.9395	2.1353
8	4.7867	4.3423		.8825		2.2123	2.3442
9	2.1902	2.0729	1.0859	1.1835	.6501	1.7238	2.4851
10		.6478	1.4304	.5479	.865	.5426	1.118
11	.5159	.4954	1.9178	1.9456	1.2262	.5609	1.0338
12	.6882	.5799	3.4408	3.4835	1.6438	.5952	.9137
13	.6318	.6036	3.5292	3.328	1.701	.6531	1.0589
14	.3597	.6196	3.3966	1.5859	1.6255	.6188	1.0951
15	.5258	.6264	3.2064	2.6703	1.422	.5959	1.0246
16	.7461	.631	3.0635	2.6131	1.531	.6089	.6059
17	.772	.9118	1.7924	1.6834	1.7299	.6485	.5754
18	.7766	1.1683	1.9243	1.7604	1.7246	.7034	.6081
19	1.7124	1.4445	1.1606	1.6011	1.6278	.8154	.8642
20	1.0517	1.5729	1.0654	1.0311	1.0661	1.0715	1.0722
21	1.8732	1.6624	1.0456	1.0265	1.0677	1.0341	1.0806
22	.9709	1.6784	1.0326	1.0052	1.0159	.9663	1.0608
23	1.0776	1.4563	1.0105	.8642	.961	.9922	.9739
24	2.3991	1.8164	1.2734	.8124	1.0806	1.0486	1.1172
Max	4.7867	4.3423	3.5292	3.4835	1.7299	2.2123	2.4851
Min	.3597	.4954	1.0105	.5479	.6501	.5426	.5754
Avg	1.8355	1.5414	1.8187	1.4424	1.1994	1.0148	1.1751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184001 / YEOLA (U) SUB STATION

Feeder No / Name : 204 / 11 KV BADAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.6001		
2	.1715		.6001		
3	.1715	.1715	.5144		
4	.1715		.6859		
5	.1715	.1715	.7716		
6	.2572		1.0288		
7	.3429	.1524	1.2003		
8	.3429	.1524	.1029		
9			.2286	.1524	.1715
10			.2572		.1715
11			.2572	.1524	.1715
12			.2572	.1524	1.2003
13			.0171	.1524	1.0288
14			.2572		.9431
15			.2572	.1524	.8573
16			.2286	.1524	
17		.8573			
18		1.0288			
19	.1715	.3429			
20		.4801			
21	.1715	.4287			
22		.3429			
23		.3429			
24	.2572	.1715	.5144		
Max	.3429	1.0288	1.2003	.1524	1.2003
Min	.1715	.1524	.0171	.1524	.1715
Avg	.2182	.3869	.4576	.1524	.6491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184001 / YEOLA (U) SUB STATION

Feeder No / Name : 205 / 11 kV NAGARSUL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5035	1.4175	1.1659	.756	.7438	1.0974	1.2971
2	2.6764	1.3931	1.1705	.756	.7514	1.1218	1.2651
3	2.1803	2.7526	1.1888	.7636	.7667	1.1309	1.2681
4	2.4356	1.4114	1.2726	.8398	.8276	.8916	1.2544
5	2.556	3.0232	1.3996	.9831	.9556	.9922	1.3108
6	3.0304	1.7726	1.5688	1.0654	1.0837	1.5135	1.7177
7	4.2455	3.94	1.5981	1.0608	1.0273	2.1155	2.2573
8	4.6243	4.2158	1.47	.881	.8688	2.2268	2.3564
9	2.1232	2.2146	1.0989	1.1736	.5609	2.082	2.0911
10	.5274	.5655	.9678	.5197	.189	.4451	
11	.5335	.599	1.6613	1.8899	.6417	.4466	1.0128
12	.5502	.6127	3.536	3.6854	1.8305	.538	.8901
13	.6036	.6051	3.5932	3.3593	1.9052	.6005	.8794
14	.5746	.602	3.3825	1.6126	1.7193	.5563	.9282
15	.66	.6889	3.1638	2.7678	1.6217	.5396	.9876
16	.6493	.6843	3.4484	2.6307	1.64	.5853	.602
17	.7194	.9172	2.0469	1.7055	1.8884	.6173	.6325
18	.7484	1.0349	2.0088	1.8046	1.9448	.6478	.6173
19	1.576	1.3691	1.7436	1.736	1.8305	.8672	.8688
20	1.0212	1.4362	.823	.8779	.8718	.9145	.9678
21	1.8927	1.3889	.82	.8688	.8291	.8505	.9206
22	.8993	1.3969	.7834	.823	.7834	.8185	.8459
23	1.0319	1.1842	.7819	.7621	.8261	1.0364	.8032
24	2.2717	1.6007	1.0269	.759	1.0608	1.2818	1.1142
Max	4.6243	4.2158	3.5932	3.6854	1.9448	2.2268	2.3564
Min	.5274	.5655	.7819	.5197	.189	.4451	.602
Avg	1.6931	1.5344	1.7384	1.4201	1.1320	.9965	1.1691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184001 / YEOLA (U) SUB STATION

Feeder No / Name : 206 / 11 KV ERANDGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4114	.9175	1.7703	.9275	.9496	.916	.8391
2	1.4213	.9061	1.579	.8429	.9374	.9061	.8497
3	1.5161	1.7497	1.5531	.8185	.8596	.9069	.8528
4	1.0429	.9069	1.7075	.8482	.8619	.9153	.8665
5	1.6106	1.9628	2.2191	.9015	.8535	.9648	.9412
6	1.8168	1.1523	2.556	1.0197	.9953	1.0357	1.0418
7	1.9262	1.9776	3.3082	1.669	1.6057	1.0113	1.0951
8	1.8366	1.7338	3.8096	1.9944	1.9029	.9732	.9816
9	.7903	.8604	1.8381	2.4287	1.9418	.8223	1.2997
10	.7796	.807	1.2193	.8055	.6539	.7804	1.3393
11	.6927	.6897	1.1759	1.227	.5396	.7964	1.1637
12	1.765	1.6042	1.2292	1.2308	.6943	1.7017	3.4293
13	1.6758	1.6309	1.0788	1.2895	.7674	1.6766	3.6313
14	1.4906	1.4091	.8985	.775	.7263	1.5417	3.1146
15	1.3154	1.3474	1.0117	1.179	.7796	1.3687	1.1881
16	1.3535	1.3565	1.1324	1.352	.775	1.3519	
17	1.5973	2.9916	.6501	.663	.7606	1.5501	.7842
18	1.6956	1.8339	.6203	.7667	.7263	1.5257	1.7894
19	2.2119	2.037	.7781	.8406	.7552	1.5379	1.6049
20	1.0547	1.733	.9823	1.0669	1.0433	.9229	.9701
21	2.021	1.8088	.9808	1.0631	1.0273	.9968	.9831
22	1.0204	1.76	.9511	.98	1.0189	.961	.9785
23	1.0349	1.0124	.9328	.9678	.9976	.9503	.9549
24	1.5443	1.4552	1.7611	.9884	.9358	.8627	.8665
Max	2.2119	2.9916	3.8096	2.4287	1.9418	1.7017	3.6313
Min	.6927	.6897	.6203	.663	.5396	.7804	.7842
Avg	1.4427	1.4852	1.4893	1.1102	.9629	1.1240	1.3724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184001 / YEOLA (U) SUB STATION

Feeder No / Name : 207 / 11 KV GANGASAGAR EXPRESS NON SHEDDABLE WATER SUPPLY AND
FEEDER Feeder KV- 11 / OUTGOING UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2244	.1574	.1981	.1067	.1029	.1764	.1741
2	.2217	.1528	.1947	.1078	.104	.1856	.1894
3	.2206	.2339	.1977	.1082	.1135	.1848	.1936
4	.2366	.1665	.2034	.112	.1143	.1898	.1913
5	.2644	.2667	.2053	.1223	.1212	.2069	.2039
6	.3101	.2115	.2095	.1337	.1292	.2157	.2229
7	.3654	.4092	.2008	.1353	.133	.2801	.2919
8	.4492	.4812	.1821	.0975	.1075	.3521	.3326
9	.3254	.3547	.1653	.1593	.0838	.2953	.3928
10	.0446	.0492	.1436	.0598	.0686	.0598	.1131
11	.0377	.0488	.1482	.1208	.0564	.0579	.1368
12	.0111	.0267	.2831	.2972	.2073	.0549	.1451
13	.0019	.0088	.2972	.2934	.2111	.0457	.1455
14	.0202	.0114	.2835	.216	.2084	.0412	.1379
15	.0453	.0488	.2701	.2949	.2119	.0461	.1413
16	.0488	.0461	.2819	.2888	.2233	.0499	.0533
17	.0476	.131	.2256	.2336	.2237	.0446	.0461
18	.0758	.1352	.2873	.2644	.2389	.0507	.0472
19	.181	.1638	.2724	.2648	.2233	.0713	.0781
20	.1174	.2168	.1033	.0911	.1078	.1082	.1204
21	.1802	.2015	.1044	.0937	.1033	.0945	.1101
22	.0983	.2221	.1181	.1052	.1048	.0945	.0972
23	.0781	.2008	.1105	.1101	.0979	.0911	.0949
24	.2305	.1989	.1916	.1059	.1619	.1772	.1654
Max	.4492	.4812	.2972	.2972	.2389	.3521	.3928
Min	.0019	.0088	.1033	.0598	.0564	.0412	.0461
Avg	.1598	.1727	.2032	.1634	.1441	.1323	.1594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184001 / YEOLA (U) SUB STATION

Feeder No / Name : 208 / 11 KV YEOLA - 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432		1.7147		
2	1.5432		1.6289		
3	1.4575	1.6289	1.6289		
4	1.4575		1.5432		
5	1.4575	1.7147	1.5432		
6	1.6289		.0857		
7	1.8861	1.6004	2.0576		
8	1.9719	1.6766	1.8861		
9			1.9719		1.7147
10			2.0576		1.7147
11			2.0576	1.9814	1.8861
12			2.1434	1.829	1.7147
13			1.8861	1.7528	1.8861
14			1.7147		1.8004
15			1.7147	1.448	1.8861
16			1.8004	1.448	
17		2.4006			
18		2.2291			
19	1.9719	2.3148			
20		2.4006			
21	1.8861	2.2291			
22		2.0576			
23		1.7147			
24	1.7147	1.6289	1.7147		
Max	1.9719	2.4006	2.1434	1.9814	1.8861
Min	1.4575	1.6004	.0857	1.448	1.7147
Avg	1.6835	1.9663	1.7147	1.6918	1.8004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184001 / YEOLA (U) SUB STATION

Feeder No / Name : 209 / 11 KV EXPRESS (PWW) NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857		.0857		
2	.0857		.0857		
3	.0857	.0857	.0857		
4	.0857		.0857		
5	.0857	.0857	.0857		
6	.0857		.0857		
7	.0857	.0762	.0857		
8	.0857	.0762	.0857		
9			.0857	.0762	.0857
10			.0857		.0857
11			.0857	.0762	.0857
12			.0857	.0762	.0857
13			.0857	.0762	.0857
14			.0857		.0857
15			.0857	.0762	.0857
16			.0857	.0762	
17		.0857			
18		.0857			
19	.1715	.0857			
20		.0857			
21	.0857	.0857			
22		.0857			
23		.0857			
24	.0857	.0857	.0857		
Max	.1715	.0857	.0857	.0762	.0857
Min	.0857	.0762	.0857	.0762	.0857
Avg	.0935	.0841	.0857	.0762	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184024 / ANDERSUL SUB STATION

Feeder No / Name : 201 / 11 KV BHULEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5689	.6134	.1524	.3239	.3222	.3048	.5963
2	.6254	.6134	.1524	.3239	.3204	.3048	.5639
3	.6409	.6134	.1524	.3239	.3204	.3048	.5639
4	.6595	.6306	.1524	.3067	.3204	.3048	.6553
5	.7691	.6134	.1524	.3239	.3204	.381	.6858
6	.843	.6477	.3368	.3239	.3204	.381	.7163
7	1.4066	1.227	.3222	.2896	.3018	.5335	1.1432
8	1.6796	1.6442	.3033	.2724	.3018	.7621	1.5242
9	.8962	1.0265	.1848	.0762	.0762	.8383	1.0059
10	.1509	.1705	.1667	.0762	.0762	.0762	.1619
11	.1696	.1705	.4191	.0762	.0762	.0762	.1619
12	.1516	.1705	1.1241	.5335	.9622	.0762	.1619
13	.1448	.1705	.9622	.4572	.6477	.0762	.1448
14	.1448	.1705	.8516	.4572	.8344	.1667	.1448
15	.0762	.1705	.6896	.381	.7754	.1667	.0762
16	.1619	.1705	.7068	.6782	.7754	.1667	.0762
17	.1619	.0762	.9907	.9228	.5335	.1448	.0762
18	.1619	.0762	1.0669	.9679	.6097	.1705	.0762
19	.221	.0762	.7244	.6066	.6097	.2408	.0762
20	.3334	.1524	.2286	.3599	.1524	.3353	.1524
21	.3334	.1524	.341	.341	.1524	.341	.1524
22	.2984	.2286	.1524	.3391	.1524	.3239	.1524
23	.4096	.4298	.4096	.341	.1524	.3067	.1524
24	.6222	.4601	.3162	.1524	.4172	.562	.3048
Max	1.6796	1.6442	1.1241	.9679	.9622	.8383	1.5242
Min	.0762	.0762	.1524	.0762	.0762	.0762	.0762
Avg	.4846	.4365	.4608	.3856	.3971	.3060	.3969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184024 / ANDERSUL SUB STATION

Feeder No / Name : 202 / 11 KV DUGALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3429		.3086	.3174		.3429
2	.3696	.3429		.3086	.3174		.3048
3	.3881	.3429		.3258	.3361		.3353
4	.4066	.3429		.3601	.3361		.3772
5	.4435	.3772		.3601	.3696		.3506
6	.4938	.4115	.4668	.4115	.4066		.381
7	1.0059	.9431	.3856	.4115	.4024		.7621
8	1.1041	1.258	.285	.2743	.3174		.9145
9	.0469	.1307	.2353				.0762
10	.112	.0943	.181				.1029
11	.0943	.1132	.4287				.1372
12	.1715	.1494	.8573		.6516		.1543
13	.1715	.168	.7202		.6001		.1372
14	.1543	.1867	.6001		.4973	.1448	.1715
15		.168	.463		.4801	.1267	
16	.2058	.1867	.5161	.4755	.4801	.1448	
17	.1715		.6859	.6805		.1715	
18	.2058		.7621	.7442		.1698	
19	.2715		.1311	.1494		.3292	
20	.362			.3361		.3292	
21	.362		.3429	.3547		.2743	
22	.3258			.3361		.2401	
23	.2572	.2675	.3086	.3174		.1715	
24	.3547	.3258	.3086	.2743	.3174	.2743	
Max	1.1041	1.258	.8573	.7442	.6516	.3292	.9145
Min	.0469	.0943	.1311	.1494	.3174	.1267	.0762
Avg	.3414	.3418	.4517	.3782	.4164	.2160	.3248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184024 / ANDERSUL SUB STATION

Feeder No / Name : 203 / 11 KV RAHADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4706		.6097	.6878		.4458
2	.4805	.4706		.6097	.7059		
3	.499	.4706		.7373	.724		.4287
4	.5121	.4887		.6859	.7343		.4458
5	.5487	.5068		.7621	.7619		.4801
6	.6154	.5611	.639	.7621	.7973		.4877
7	.4805	.4706	.9457	1.0669	1.2039		.463
8	.4066	.3801	1.1443	1.3717	1.4255		.3086
9	.2263	.3326	.1086				.2915
10	.2614	.2614	.1086				.2401
11	.2427	.7796	.181				
12	.9907	1.0277	.1991		.181		.9755
13	.9145	.9036	.1991		.181		.8269
14	.9145	.8764	.2715		.181	1.0288	.8535
15		.8238	.2715		.1991	.8916	
16	.9012	.8149	.2715	.1844	.1991	.9431	
17	.9145		.2572	.2218		1.0669	
18	1.1279		.2915	.2402		1.2289	
19	.2715		.3601	.3361		.2058	
20	.4887			.4805		.463	
21	.4887		.3944	.2614		.5144	
22	.4887			.4481		.4801	
23	.4706	.3567	.2286	.5068		.3963	
24	.4805	.4706	.5335		.6201	.4115	
Max	1.1279	1.0277	1.1443	1.3717	1.4255	1.2289	.9755
Min	.2263	.2614	.1086	.1844	.181	.2058	.2401
Avg	.5744	.5815	.3768	.5803	.6144	.6937	.5206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184024 / ANDERSUL SUB STATION

Feeder No / Name : 204 / 11 KV NAGADE SDT SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6222	.6306	.4572	.9907	.9876	.3048	.5963
2	.6222	.6306	.4572	.9907	.9821	.3048	.5791
3	.619	.6306	.4572	1.107	1.0946	.3048	.562
4	.619	.6306	.5335	1.1832	1.1245	.3048	.5487
5	.619	.6306	.6097	1.2194	1.1536	.3048	.5963
6	.619	.6306	1.2506	1.2956	1.283	.3048	.5963
7	.5635	.5401	1.5813	1.7528	1.8092	.3048	.5791
8	.434	.4277	2.2298	2.5453	2.5129	.2286	.4001
9	.3048	.3002	1.4584	1.3717	1.3717	.1524	.2896
10	.3239	.2831	.3372	.1524	.2286	.1524	.2724
11	.2305	.5776	.1848	.0762	.1524	.0762	.461
12	1.6956	1.1873	.1848	.0762	.221	.9907	1.6309
13	1.6004	1.2769	.1848	.0762	.2972	.9145	1.4022
14	1.3718	.6097	.221	.1524	.2972	1.4137	.9144
15	.6859	1.0119	.2972	.1524	.2972	1.286	.5335
16	1.5242	1.0828	.2987	.2865	.2972	1.1927	.6097
17	1.4784	.7621	.1962	.1871	.0762	1.5242	.8383
18	1.829	.9907	.2134	.1696		2.0081	.9907
19	1.2441	.9907	.3582	.2442	.1524	1.3584	1.0669
20	.4858	.2286	.2286	.49	.2286	.6553	.3048
21	.5944	.2286	.4687	.49	.3048	.5029	.2286
22	.6306	.2286	.2286	.4713	.3048	.5963	.3048
23	.6306	.5258	.4858	.6992	.3048	.5963	.3048
24	.6222	.783	.945	.4572	.8116	.5963	.3048
Max	1.829	1.2769	2.2298	2.5453	2.5129	2.0081	1.6309
Min	.2305	.2286	.1848	.0762	.0762	.0762	.2286
Avg	.8321	.6591	.5778	.6932	.7084	.6824	.6215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184024 / ANDERSUL SUB STATION

Feeder No / Name : 206 / 11 KV HT EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1006	.1963	.0275	.077	.0381	.012	.0884
2	.0869	.1958	.0274	.0922	.0381	.0119	.0884
3	.0864	.1956	.0272	.0826	.0381	.0119	.0979
4	.0862	.1958	.0275	.0691	.0381	.0119	.0979
5	.0853	.2307	.0282	.0618	.0381	.0121	.0886
6	.0851	.2302	.1701	.0696	.0381	.0122	.0982
7	.0483	.2246	.1525	.0686	.0387	.0122	.0883
8	.0504	.0755	.1451	.0352	.0632	.0122	.0883
9	.1064	.0943	.0903	.001	.0278	.0119	.0879
10	.0873	.0754	.1106	.0004	.0268	.0117	.0978
11	.1063	.0754	.1133	.0007	.0255	.0122	.0977
12	.1144	.0754	.0944	.0003	.2487	.0121	.0881
13	.1129	.0754	.0949	.0001	.231	.0119	.0729
14	.0961	.0943	.0765		.2296	.0843	.0805
15	.0114	.0943	.0807		.2258	.0844	.0121
16	.0972	.0747	.0769	.0594	.2178	.0843	.0125
17	.0969		.0959	.0381	.0186	.0978	.0129
18	.0715		.0706	.0381	.016	.098	.0122
19	.0863		.0343	.0572	.0155	.0968	.0111
20	.0905	.0238		.0381	.0111	.0973	.0113
21	.0919	.0237	.0343	.0381	.0116	.0974	.0115
22	.1242	.0292	.0014	.0381	.0114	.0976	.0117
23	.1278	.1182	.0619	.0381	.0111	.0979	.0122
24	.1743	.1132	.0694		.0502	.0979	.0122
Max	.1743	.2307	.1701	.0922	.2487	.098	.0982
Min	.0114	.0237	.0014	.0001	.0111	.0117	.0111
Avg	.0927	.1196	.0744	.0430	.0712	.0496	.0575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184024 / ANDERSUL SUB STATION

Feeder No / Name : 207 / 11 KV SAIGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3429		.3601	.3921		.3353
2	.4294	.362		.3429	.3921		.3048
3	.4435	.3982		.3429	.4294		.3353
4	.4805	.3772		.4287	.462		.3658
5	.5175	.4115		.4287	.499		.381
6	.6219	.463	.5847	.5144	.5914		.4268
7	.9328	.7716	.4904	.463	.462		.6859
8	1.0425	1.0985	.4338	.2591	.4024		.8383
9	.2401	.2218	.2172				.2572
10	.1715	.168	.2172				.1715
11	.1715	.2427	.3429				.1715
12	.1372	.2427	.6859		.5144		.1886
13	.1543	.2241	.6001		.463		.1886
14	.1715	.2402	.5658		.4801	.2355	.2058
15		.2427	.5611		.4801	.2353	
16	.2572	.2054	.5487	.4607	.5144	.2534	
17	.2572		.6097	.5014		.2229	
18	.2572		.6859	.691		.2401	
19	.3601		.3353	.2427		.3772	
20	.4887			.439		.4287	
21	.4887		.3601	.4066		.3944	
22	.362			.4108		.3353	
23	.2572	.3961	.3429	.3921		.1886	
24	.3881	.3429	.3353		.3921	.3429	
Max	1.0425	1.0985	.6859	.691	.5914	.4287	.8383
Min	.1372	.168	.2172	.2427	.3921	.1886	.1715
Avg	.3931	.3751	.4657	.4178	.4625	.2958	.3469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184024 / ANDERSUL SUB STATION

Feeder No / Name : 209 / 11 KV ANDERSUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2058		.2058	.2427		.2058
2	.2263	.2058		.1886	.2427		.1886
3	.2241	.2058		.1886	.2427		.1886
4	.2263	.2058		.2058	.2427		.2058
5	.2241	.2058		.1981	.2427		.2058
6	.2402	.2229	.2229	.2286	.2427		.1981
7	.2772	.2401	.208	.2743	.2427		.1981
8	.2614	.2561	.2056	.2915	.2614		.2401
9	.2204	.2587	.2401				.2591
10	.2294	.2801	.2572				.3258
11	.2401	.2614	.2401				.2439
12	.2058	.2241	.2401		.2572		
13	.1981	.2427	.2401		.2572		.2439
14	.2401	.2241	.2572		.2572	.2572	.2743
15		.2772	.2743		.2572	.2743	
16	.2294	.2427	.2572	.2688	.2572	.2743	
17	.2572		.2572	.2054		.2591	
18	.2572		.2286	.2801		.2915	
19	.2915		.2743	.3174		.3475	
20	.3086			.3361		.3772	
21	.2743		.2622	.2987		.3086	
22	.2534			.2987		.2915	
23	.2229	.2086	.2134	.2987		.2572	.3086
24	.2263	.2058	.2229		.2614	.2229	
Max	.3086	.2801	.2743	.3361	.2614	.3772	.3258
Min	.1981	.2058	.2056	.1886	.2427	.2229	.1886
Avg	.2418	.2319	.2413	.2553	.2506	.2874	.2348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184025 / RAJAPUR SUB STATION

Feeder No / Name : 201 / 11 KV LAHIT FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.3391
8	.463	.4458		.3429
9				.4115
12	.9145		.7811	.7287
13				.5967
14			.643	
16	.4725			.5487
18				.5935
21	.463		.5658	.5765
23				.4374
24	.4801	.4458		.463
Max	.9145	.4458	.7811	.7287
Min	.463	.4458	.5658	.3391
Avg	.5586	.4458	.6633	.5038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184025 / RAJAPUR SUB STATION

Feeder No / Name : 202 / 11 KV MAMADAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				1.1279
8	1.1279	1.1888		
12	.2058		.1715	.1619
13				.1852
16	.1543			.1486
18				.4096
21	.6001		.5316	.4428
24	.4801			.4287
Max	1.1279	1.1888	.5316	1.1279
Min	.1543	1.1888	.1715	.1486
Avg	.5136	1.1888	.3516	.4150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184025 / RAJAPUR SUB STATION

Feeder No / Name : 204 / 11 KV KHIRDISATHE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6859	.2286	.2286	.2286	.5335	.6097
2	.6097	.6097	.2286	.2286	.2286	.5335	.6097
3	.6859	.5335	.2286	.2286	.2286	.5335	.6097
4	.6097	.5335	.3048	.3048	.3048	.5335	.6097
5	.6859	.6097	.3048	.3048	.3048	.6097	1.0955
6	.7621	.6859	.381	.381	.381	.7621	.7621
7	1.1431	.8383	.0762	.381	.381	1.0669	1.0669
8	2.0728	1.9814	.2286	.3048	.3048	1.1431	1.2193
9	1.0669	1.0669	.1524	.2286	.2286	.9907	.9907
10	.0762	.1524	.2286	.2286	.1524	.1524	.0762
11	.1524	.1524	.1524	.1524	.0762	.1524	.1524
12	.2305	.0762	.8383	.8383	.7621	.2896	.2861
13	.1524	.0762	.8383	.8383	.8383	.1524	.2981
14	.1524	.1524	.8383	.7621	.7621	.3067	.1524
15	.1524	.0762	.7621	.6859	.7621	.1524	.1524
16	.2896	.1524	.6859	.6859	.6859	.1524	.2461
17	.1524	.1524	.6859	.7621	.8383	.1524	.1524
18	.1524	.1524	.7621	.7621	.9145	.1524	.318
19	.2286	.2286	.7621	.1524	.8383	.2286	.2286
20	.381	.381	.3048	.3048	.3048	.381	.381
21	.6125	.381	.381	.3048	.3048	.7068	.6125
22	.3048	.3048	.3048	.3048	.3048	.3048	.3048
23	.2286	.3048	.3048	.3048	.2286	.3048	.3048
24	.9965	.743	.2286	.2286	.4572	.5335	1.0479
Max	2.0728	1.9814	.8383	.8383	.9145	1.1431	1.2193
Min	.0762	.0762	.0762	.1524	.0762	.1524	.0762
Avg	.5212	.4596	.4255	.4128	.4509	.4512	.5120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184207 / GAVANDGAON SUB STATION

Feeder No / Name : 201 / 11 KV KHAMGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227		.3155	.3772			
2	.1387		.3121				
3	.1387		.3506	.3801			.2229
4	.1734		.3721				
5	.1715		.4207	.4904			
6	.2035		.4854	.5658			
7	.3988		.4458	.5359	.4748		
8	.5765	.6001	.4287	.4527	.3772		.5658
9	.3944	.4287	.3361	.2915	.2947		.3353
10	.1417	.1886	.2452	.2058		.1227	.2279
11	.1543	.1372	.1698	.1886		.156	
12	.1357	.1526	.3163	.2683	.1989	.1372	
13	.1886	.1543	.2561	.2347	.1677		.208
14		.1715	.2439	.218	.1526		.1715
15	.1543	.1543	.192	.1543	.1526	.1734	.156
16	.1543	.1543	.208	.2374	.2012	.1753	.1715
17	.1543	.1715	.3041	.2058	.2572	.1715	.2058
18		.2629	.3401	.2572		.1886	.1886
19		.3294	.2652	.2915		.3641	.3429
20		.4607	.5975	.4115		.4681	.4733
21	.3772	.3856	.4904	.3856		.4207	.3988
22		.3898	.4481	.3856			.3721
23		.3544	.3961	.3544		.2804	.2947
24	.12	.1029	.3506	.3772	.333		.12
Max	.5765	.6001	.5975	.5658	.4748	.4681	.5658
Min	.12	.1029	.1698	.1543	.1526	.1227	.12
Avg	.2166	.2705	.3454	.3304	.2610	.2416	.2784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184207 / GAVANDGAON SUB STATION

Feeder No / Name : 203 / 11 KV KAUTKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4784		.3467	.3841			
2	.4961		.3391				
3	.4908		.3601	.499			.4973
4	.5493		.3988				
5	.5959		.4681	.5853			
6	.6588		.5426	.5895			
7	.5959		.7122	.7968	.78		
8	.4458	.4287	.8383	.9922	.9665		.3944
9	.3429	.3601	.5624	.6173			.3294
10	.1928	.2058	.2427	.156		.0351	.208
11	.1543	.1715	.1698	.1387		.0343	.12
12	.4191	.5365	.1698	.1187	.1341	.5868	.4641
13	.3561	.4801	.1698	.1187	.1357		.3688
14		.373	.1698	.1526	.1526		.3688
15	.3222	.2883	.1886	.1715	.156	.4973	.3391
16	.3561	.4239		.1715	.1886	.4973	.4191
17	.4973	.4973		.1372	.1715	.5426	.4748
18		.5426	.2263	.1886		.5765	.4973
19		.6036	.4668	.3944		.583	.5487
20		.4908	.6224	.5548		.5434	.5548
21	.5144	.4382	.5228	.4607		.5258	.4961
22		.4119	.5093	.443			.4908
23		.3856	.4527	.3856		.5138	.4733
24	.4733	.463	.3429	.3881	.333		.5144
Max	.6588	.6036	.8383	.9922	.9665	.5868	.5548
Min	.1543	.1715	.1698	.1187	.1341	.0343	.12
Avg	.4411	.4177	.401	.3838	.3353	.4487	.4200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184207 / GAVANDGAON SUB STATION

Feeder No / Name : 204 / 11 KV EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905		.1772	.181			
2	.0895		.1612				
3	.1267		.1629	.1433			.2229
4	.1417		.1433				
5	.1254		.124	.1417			
6			.0358	.0354			
7	.1254		.0886	.0549	.12		
8	.1772	.1543	.1791	.1341	.1886		
9	.12	.1372		.0514	.1595		.0354
10	.2401	.1886	.1638	.1715		.1254	.197
11	.2401	.1886	.1739	.0857		.1949	.1448
12	.12	.1372	.1966		.1387	.2303	.1417
13	.0343	.2743	.1341	.1372	.1417		.1254
14		.1372	.1581	.12	.0351		.1595
15	.1372	.1543	.1619	.0514	.124	.0716	.2126
16	.0514	.12	.1581	.1372	.1417	.1063	.2103
17	.1715	.2279	.1296	.1543	.12	.12	.2204
18		.197	.0335	.0343		.0343	.1372
19		.0351		.1578		.0343	.2058
20		.0895		.1543		.0343	.1886
21	.1372	.124		.1543		.0177	.12
22		.1629	.056	.0343			.0347
23		.2507		.1387		.0351	.2254
24	.0537	.2229	.2686	.1696	.1715		.0343
Max	.2401	.2743	.2686	.181	.1886	.2303	.2254
Min	.0343	.0351	.0335	.0343	.0351	.0177	.0343
Avg	.1283	.1648	.1424	.1163	.1341	.0913	.1539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184207 / GAVANDGAON SUB STATION

Feeder No / Name : 205 / 11 KV SINGLE PHASE BOKTE SINGLE PHASING
FEEDER Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104		.208	.2263			
2	.1372		.2229				
3	.1357		.2254	.2772			.2572
4	.1372		.2804				
5	.1696		.3294	.3292			
6	.2515		.4115	.3801			
7	.5144		.3391	.3734	.3086		
8	.7545	.823	.3018	.3206	.2572		.7373
9	.5316	.5316	.2218	.1886	.1886		.3812
10	.104	.1029	.1294	.1214		.0867	.1372
11	.12	.12	.0572	.0857		.0857	.1214
12	.12	.1372	.4531	.2515	.3315	.0848	.1187
13	.12	.12	.3605	.285	.2818		.0857
14		.1372	.3239	.2713	.2515		.1017
15	.1543	.12	.2787	.2058	.2543	.12	.1372
16	.1543	.1715	.3321	.2374	.3353	.12	.1357
17	.2058	.1509	.4334	.3258	.3772	.1715	.1715
18		.2229	.39	.3601		.1715	.2058
19		.2915	.2713	.298		.208	.2401
20		.3467	.3881	.2601		.3086	.3121
21	.2915	.3294	.2772	.2947		.298	.2947
22		.2835	.2587	.2804			.2629
23		.2629	.2218	.2279		.2103	.2103
24	.1017	.1029	.2254	.2263	.2103		.1029
Max	.7545	.823	.4531	.3801	.3772	.3086	.7373
Min	.1017	.1029	.0572	.0857	.1886	.0848	.0857
Avg	.2282	.2502	.2892	.2649	.2796	.1696	.2230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184207 / GAVANDGAON SUB STATION

Feeder No / Name : 206 / 11 KV SINGLE PHASE SINGLE PHASING
 GARKHEDA Feeder KV- 11 /
 OUTGOING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
1		.0762
2		.0762
3		.1962
4		.0762
5		.0762
6		.1524
7		.2286
8		.6477
9		.5037
10		.1791
11		.1629
12		.1791
13		.1448
14		.1448
15	.161	.161
16	.1619	.161
17	.1802	.1455
18	.1619	.1455
19	.2134	.2149
20	.4389	.4412
21	.4412	.4435
22	.2286	.4589
23	.4039	.4058
24	.0762	.1791
Max	.4412	.6477
Min	.0762	.0762
Avg	.2467	.2334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184207 / GAVANDGAON SUB STATION

Feeder No / Name : 207 / 11 KV PIMPALKHUTE RLY GATE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.0339	.0549			
2	.0347		.0335				
3	.0343		.0335	.0377			.0343
4	.0343		.0343				
5	.052		.0514	.0554			
6	.0509		.0503	.0509			
7	.0514		.0663	.1768	.1029		
8	.0339	.0343	.1745	.2999	.1962		.0171
9	.0171	.0175	.1282	.2553	.1757		.017
10	.0179	.0175	.0191	.0175			.017
11	.0171	.0177		.0175			.0171
12	.0686	.0857		.0171	.0164	.0995	.1745
13	.1105	.1276		.0171	.0168		.1572
14		.0514	.0187	.0173	.0335		.1591
15	.0514	.0514	.0191	.0171	.0343	.0492	.1265
16	.0514	.0514		.0171	.0339	.1591	.1259
17	.0514	.0819		.0171	.0343	.1288	.052
18	.0762	.16		.0171		.1791	.0514
19	.0762	.1425	.0189	.0171		.1619	.0526
20		.0343	.0381	.0179		.0171	.0175
21	.0343	.0339	.0381	.0179		.0179	.0179
22		.0351	.0373	.0179			.0179
23		.0347	.0187	.0179		.0177	.0179
24	.0343	.0343	.0339	.0509	.0532		.0343
Max	.1105	.16	.1745	.2999	.1962	.1791	.1745
Min	.0171	.0175	.0187	.0171	.0164	.0171	.017
Avg	.0466	.0595	.0471	.0557	.0697	.0923	.0615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184253 / NAGARSUL SUB STATION

Feeder No / Name : 201 / 11 KV RENDALE FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4725	.5535				.4744
2		.4877	.5693	.5144			.506
3		.5335	.5792		.5182		.5376
4	.5144	.6097	.6325				.6325
5		.6859	.7621		.6325		.7373
6		.7164			.6859		.7907
7		.7621	.5182	.6001	.759		
8	1.286	1.0517	.4877				
9	.381	.4268	.381	.6516			
10	.3163		.442				.2743
11	.2286		.3048	.4572			
12	.2286	.3086	.2591	.442	.4268		
13	.2439		.5639	.5182	.4268		.2286
14	.2591		.503		.381	.3601	
15	.2896		.442	.5487	.4115		.2591
16	.3163	.3429	.5182	.4572	.4572	.3944	
17		.4744		.5335			
18		.5535		.5487		.4744	
19	.4725	.7164	.6001			.6642	.583
20	.6097	.7621				.7907	
21	.7011	.7926	.7716	.7621		.7116	.7373
22	.6859	.7907				.6554	
23		.7116		.6706		.4915	.5144
24	.4287	.6325	.7545	.6401		.5535	
Max	1.286	1.0517	.7716	.7621	.759	.7907	.7907
Min	.2286	.3086	.2591	.442	.381	.3601	.2286
Avg	.4641	.6227	.5357	.5650	.5221	.5662	.5229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184253 / NAGARSUL SUB STATION

Feeder No / Name : 202 / 11 KV ANKAI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1219	.1581				.2372
2			.1829				.2372
3					.1829		.2372
4	.3429		.253				.2688
5			.3048		.2743		.2846
6			.381		.3048		.3163
7		.1524	.4268	.7202	.4572		
8	.3429	.1372	.4572				
9	.3048	.1219	.1715	.1715			
10	.1581		.1524				.1524
11			.1524				
12	.6097	.6859	.1524	.1219	.1524		.5335
13	.5335		.1219	.1067	.1524		
14	.4572		.5792		.1219		
15	.4915		.1524		.1219		.442
16	.381	.5487	.1829	.1067	.1524	.6001	
17		.3953		.1219		.4744	
18		.3353		.2286		.3953	
19	.3048	.2743	.3429			.3795	.4801
20		.381				.4744	
21	.2439	.381	.4801	.3048		.4744	.5144
22	.2286	.3479				.3932	
23		.0949	.1715	.1524		.3479	.3429
24	.1524	.1067		.1524		.3277	
Max	.6097	.6859	.5792	.7202	.4572	.6001	.5335
Min	.1524	.0949	.1219	.1067	.1219	.3277	.1524
Avg	.3501	.2917	.2680	.2187	.2134	.4297	.3372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184253 / NAGARSUL SUB STATION

Feeder No / Name : 203 / 11 KV MATULTHAN FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3353	.6325				.2372
2		.4572	.6325	.5144			.2372
3		.5335	.6401		.6706		.253
4	.3429	.5944	.7907	.8573			.2846
5		.6097	.8383		.7621		.3005
6		.7621	.9145		.9488		.3163
7		.3506	1.1279	1.3375	1.1797		
8	.5144	.2286	1.1431				
9	.3048	.1524	.1524	.2572			
10	.3163		.1829				.2134
11	.2439		.1524	.2134			
12	1.0669	1.1831	.2591	.1981	.1677		1.0517
13	1.0974		.1524	.1829	.1677		
14	1.0212		.1524		.1829	1.2003	
15	.9755		.1677	.1372	.1829		.8993
16	.9145	1.1145	.1829	.2134	.1981	1.0631	
17		1.1069		.2439		1.1385	
18		.9907		.2846		1.1797	
19	.9602	.381	.5658			.3795	.5144
20	.3048	.4572				.4915	
21	.5182	.4572	.5658	.4572		.4915	.5144
22	.4877	.3953				.4424	
23		.6958	.3429	.7164		.3163	.3944
24	.3429	.6642	.1829	.6401		.3163	
Max	1.0974	1.1831	1.1431	1.3375	1.1797	1.2003	1.0517
Min	.2439	.1524	.1524	.1372	.1677	.3163	.2134
Avg	.6274	.6037	.4890	.4467	.4956	.7019	.4347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184253 / NAGARSUL SUB STATION

Feeder No / Name : 204 / 11 KV DHAMODA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0593	1.6811	1.4622	1.259	1.0334	.8657	1.6495
2	1.1309	1.8184	1.5043	1.6968	1.0303	.8993	1.6922
3	1.105	1.2651	1.6224	1.2559	1.5241	.9663	1.7573
4	1.198	1.9296	1.7223	1.7471	1.1385	1.0425	1.8911
5	1.2559	2.0576	1.7939	1.4769	1.8091	1.2361	2.0911
6	1.483	2.239	1.9631	1.6293	2.0439	1.4723	2.4307
7	2.3152	2.9051	2.021	2.2009	2.0115	2.0332	2.1064
8	2.9546	4.1335	1.7299	1.2087	1.2026	2.4463	2.6216
9	3.2495	2.7953	1.2578	1.2498	.7971	2.3716	2.7023
10	.7219	.4923	.9358	.6462	.631	.4435	.692
11	.7172	.5091	1.0547	.8398	.5319	.506	.5868
12	.6981	.7198	2.5377	2.175	2.1993	.4512	.6813
13	.7148	.5838	2.2954	2.2207	2.1292	.5426	.5792
14	.698	.5578	2.082	1.512	1.7376	.6542	.5898
15	.7621	.5716	1.9372	2.0591	1.6309	.567	.8139
16	.8526	.7888	2.4082	2.3274	1.8945	.8733	.6462
17	.5533	.8985	1.8625	2.7923	1.7802	.8302	.6828
18	.5533	1.009	2.2344	3.0391	2.1445	.9946	.7712
19	1.3046	1.5104	2.21	2.1643	2.1948	1.2451	1.47
20	1.6323	1.8854	1.1873	1.0791	1.1477	1.8176	1.1248
21	1.7345	1.8682	1.8606	1.6156	1.1096	1.7806	1.1446
22	1.6903	1.8061	1.3138	1.1614	1.1065	1.7859	1.6834
23	1.1203	1.6713	1.9205	1.4983	1.0303	1.6434	1.4662
24	1.4342	1.4899	1.2361	1.4434	.8474	1.1309	.9953
Max	3.2495	4.1335	2.5377	3.0391	2.1993	2.4463	2.7023
Min	.5533	.4923	.9358	.6462	.5319	.4435	.5792
Avg	1.2891	1.5494	1.7564	1.6791	1.4461	1.1916	1.3696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184253 / NAGARSUL SUB STATION

Feeder No / Name : 205 / 11 KV NAGARSUL GAOTHAN & SINGLE PHASING
SHIW Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097	.506				.3953
2		.6097	.5182	.5144			.3953
3		.6249	.2214		.5182		.427
4	.4287	.6249	.5792	.5144			.4744
5		.6401	.6097		.6401		.6325
6		.6554	.6401		.6706		.8097
7		.6706	.6554	.703	.6554		
8	.6859	.8078	.5335				
9	.6097	.5487	.3048	.5316			
10	.4744		.442				.4725
11	.3658		.3048	.5335			
12	.381	.4801	.6859	.5792	.6097		.4877
13	.4115		.5792	.6097	.5182		
14	.4572		.5792		.4725		
15	.4572		.4725	.1067	.4725		.4725
16	.4877	.5144	.503	.5182	.4572	.6001	
17		.506		.5335		.5535	
18		.5693		.5182		.6325	
19	.5639	.6249	.823			.6642	.6859
20	.6249	.6859				.7432	
21	.7011	.6859	.7888	.6097		.7274	.7888
22	.6859	.6325				.7373	
23		.5693	.6859	.5487		.6642	.3429
24	.4287	.506		.4877		.4915	
Max	.7011	.8078	.823	.703	.6706	.7432	.8097
Min	.3658	.4801	.2214	.1067	.4572	.4915	.3429
Avg	.5176	.6087	.5491	.5220	.5572	.6460	.5320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184253 / NAGARSUL SUB STATION

Feeder No / Name : 206 / 11 KV KUSUR (New Ankai) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4268	.3953				.3953
2		.4572	.3963	.3429			.4744
3		.4725	.427		.4877		.4744
4	.5144	.5335	.5335	.6859			.4744
5		.5944	.5335		.6325		.506
6		.6097	.6097		.7907		.5376
7		.6249	.823	.9259	.9804		
8	.4115	.5182	.9831				
9	.3658	.3658	.2058	.3429			
10	.427		.2286				.2591
11	.4902		.2439				
12	.7621	.8573	.2439	.2286	.2591		.7468
13	.9145		.2743	.2134	.2591		
14	.8383		.2439		.2591	.6859	
15	.6706		.2591	.1829	.2591		.6249
16	.6401	.7888	.2439	.2591	.2743	.7545	
17		1.0279		.3048		.9488	
18		.9145		.381		.8697	
19	.7011	.3658	.5144			.3163	.4287
20	.3658	.4572				.5693	
21	.503	.4877	.6344	.5182		.5735	
22	.4725	.4744				.5376	.583
23		.2846	.3429	.381		.506	.5316
24	.5144	.3953		.381		.506	
Max	.9145	1.0279	.9831	.9259	.9804	.9488	.7468
Min	.3658	.2846	.2058	.1829	.2591	.3163	.2591
Avg	.5728	.5609	.4282	.3960	.4669	.6268	.5030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184253 / NAGARSUL SUB STATION

Feeder No / Name : 208 / SPARE BAY SINGLE PHASING

Feeder KV- 11 / INCOMING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.061	.1524				.1265
2		.0914	.1829	.1715			.1265
3		.1219	.2056		.2134		.1265
4	.1372	.1372	.2134	.1715			.1423
5		.1524	.2286		.3201		.1581
6		.1524	.2439		.3479		.1898
7		.1677	.2591	.3429	.3795		
8	.12	.1372	.2743				
9	.1067	.1219	.0686	.0857			
10	.0819		.061				.061
11	.0762		.0457	.061			
12	.2134	.3086	.0457	.0457	.0457		.2439
13	.2439		.0305	.0457	.0457		
14	.2134		.0305		.0305	.1886	
15	.1829		.0305	.0305	.1219		.1829
16	.1829	.2058	.0305	.0305	.0457	.1886	
17		.1898		.0316		.1898	
18		.1829		.0457		.1898	
19	.1829	.0762	.12			.0791	.12
20	.1372	.1524				.1898	
21	.1219	.1524	.1543	.1524		.1581	.1543
22	.1067	.1265				.1107	
23		.1107	.1715	.1067		.1107	.1543
24	.1372	.1265		.1219		.1107	
Max	.2439	.3086	.2743	.3429	.3795	.1898	.2439
Min	.0762	.061	.0305	.0305	.0305	.0791	.061
Avg	.1496	.1460	.1342	.1031	.1723	.1516	.1488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184254 / BHARAM SUB STATION

Feeder No / Name : 201 / 11 KV BHARAM FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3605	.7224	.1898	.4649	.208	.3734	.3772
2	.349	.7293	.1829	.4641	.208	.3772	.3704
3	.3856	.7323	.1875	.511	.1997	.3795	.3826
4	.4321	.788	.2042	.5499	.2126	.4169	.3818
5	.5091	.8776	.2629	.6097	.2522	.5022	.4679
6	.5243	.9843	.333	.665	.3338	.5548	.5037
7	.4626	.8916	.4824	.9424	.4725	.5053	.4512
8	.4222	.743	.487	1.0197	.5556	.3948	.314
9	.6035	.605	.6112	.4862	.6356	.2919	.59
10	.4451	.4245	.3574	.2157	.3834		.5104
11	.3674	.1859	.2905	.3971	.3559	.1966	.386
12	.6119	.3003		.205	.3521	.3788	.5784
13	.5403	.2393	.4481	.1867	.1859	.3185	.5868
14	.4717	.1722	.4127	.2286	.1776	.189	.5346
15	.4968	.2004	.4027	.2187	.1722	.2088	.4556
16	.4991	.2385	.4279	.1981	.1974	.3064	.5397
17	.5807	.2759	.4384	.2157	.1943	.3574	.7148
18	.6535	.2995	.5461	.2454	.2378	.4237	.7482
19	.3163	.3406	.8524	.4481	.4336	.3978	.6684
20	.7594	.4702	.9071	.4908	.5175	.5213	.9623
21	.8817	.4481	.8471	.4176	.49	.4923	.8766
22	.8489	.4115	.8306	.4359	.4489	.471	.8578
23	.7552	.3704	.54	.3635	.746	.4313	.7872
24	.3871	.5349	.2583	.4069	.3818	.394	.3582
Max	.8817	.9843	.9071	1.0197	.746	.5548	.9623
Min	.3163	.1722	.1829	.1867	.1722	.189	.314
Avg	.5277	.4994	.4565	.4328	.3480	.3862	.5585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184254 / BHARAM SUB STATION

Feeder No / Name : 202 / 11 KV DONGARGAON FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5335		.2452		
2		.5335		.2452		
3		.5335		.2452		
4		.5639		.2641		
5		.6097		.2641		
6		.6401		.2641		
7		.7773		.2263		
8		.7011		.1509		
9	.0686	.0686	.132		.1029	.0754
10	.12	.0857	.1132		.0857	.0943
11	.0514		.1696		.0857	.0566
12	.0514		.5967		.503	.0566
13	.0514		.4641			.0754
14	.0686		.4641			.0754
15	.0857		.4641			.0754
16	.1029		.4475			.0943
17	.1029		.5801			.0943
18	.1372		.5967			.1132
19	.1715		.1132			.132
20	.2572		.2263			.2263
21	.2572		.2452			.2263
22	.2229		.2452			.1886
23	.1715		.2452			.2035
24		.583		.2452		
Max	.2572	.7773	.5967	.2641	.503	.2263
Min	.0514	.0686	.1132	.1509	.0857	.0566
Avg	.1280	.5118	.3402	.2389	.1943	.1192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184254 / BHARAM SUB STATION

Feeder No / Name : 203 / 11 KV BILONI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886		.3315		
2		.1886		.3315		
3		.2058		.3315		
4		.2058		.3315		
5		.2401		.3647		
6		.2572		.4973		
7		.2401		.663		
8		.1886		.663		
9	.1372	.1886	.0566		.0686	.1132
10	.1029	.1029	.0754		.0857	.1698
11	.2572		.0754		.0857	.3315
12	.4572		.0943		.0857	.4641
13	.381		.0943			.431
14	.381		.1132			.4144
15	.3353		.132			.4144
16	.3506		.132			.4641
17	.4268		.1509			.3315
18	.4572		.1509			.5801
19	.1715		.2263			.0566
20	.2572		.2263			.2075
21	.2572		.2263			.2263
22	.2401		.2263			.2263
23	.2401		.1696			.1886
24		.1886		.2818		
Max	.4572	.2572	.2263	.663	.0857	.5801
Min	.1029	.1029	.0566	.2818	.0686	.0566
Avg	.2968	.1995	.1433	.4218	.0814	.3080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA (U) S/DN[258] BU 6441

Substation No/ Name :- 184254 / BHARAM SUB STATION

Feeder No / Name : 204 / 11 KV SHIVAJI NAGAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572		.415		
2		.4572		.415		
3		.4572		.415		
4		.4877		.4715		
5		.5335		.6602		
6		.6097		.7167		
7		.9145		.6413		
8		.9145		.5658		
9	.2743	.2743	.3772		.3429	.3395
10	.2572	.2229	.2263		.2572	.2263
11	.2572		.3391		.1715	.2263
12	.2572		.7459		.6859	.2263
13	.1715		.7459			.1509
14	.2572		.663			.2263
15	.1715		.5967			.2641
16	.1886		.6133			.2641
17	.2058		.7459			.3018
18	.3429		.7621			.3395
19	.5144		.3395			.4904
20	.5144		.6036			.6036
21	.5144		.5281			.5281
22	.3772		.4904			.4904
23	.1715		.4715			.2035
24		.4268		.415		
Max	.5144	.9145	.7621	.7167	.6859	.6036
Min	.1715	.2229	.2263	.415	.1715	.1509
Avg	.2984	.5232	.5499	.5239	.3644	.3254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184032 / PATODA

Feeder No / Name : 201 / PATODA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.5487			.5087		.4572
6			.5801			
8			.9012	.9945		
12	.8192	.6249				.9326
14		.4172				
15						.5087
16		.4515				
17	.7545					
18		.6859		.1638		.8478
20	.4477	.3734	.3582		.362	
21				.3277		.4239
23		.5487				
24	.4477		.5144	.4973		.462
Max	.8192	.6859	.9012	.9945	.362	.9326
Min	.4477	.3734	.3582	.1638	.362	.4239
Avg	.6036	.5169	.5885	.4984	.362	.6054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184032 / PATODA

Feeder No / Name : 203 / EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.0857			
4	.0753			.0791		.0781
6			.1619			
8	.0724		.0762	.0791		.0753
12		.1524	.2086	.0562		.0724
13	.08					
14		.0667				
15				.0448		.0553
16		.1429	.0743		.0791	
17	.0686					
18		.0762		.0753		.1124
20	.0724	.0857	.0762		.08	
21				.0657		.0533
23		.0857				
24	.0781		.0857	.0753		.0781
Max	.08	.1524	.2086	.0791	.08	.1124
Min	.0686	.0667	.0743	.0448	.0791	.0533
Avg	.0745	.1016	.1098	.0679	.0796	.0750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184032 / PATODA

Feeder No / Name : 205 / SHIRASGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.5601			
4	.4915			.4572		.4744
8	1.4251					1.1603
12			.8192	.763		
15				.763		
16			.9116		.6401	
17	.181					
18		.2801		.9326		.2515
20	.3658	.5601	.4525		.4668	
21				.3353		.3353
23		.4715				
24	.503		.4668	.4572		.4144
Max	1.4251	.5601	.9116	.9326	.6401	1.1603
Min	.181	.2801	.4525	.3353	.4668	.2515
Avg	.5933	.4372	.6420	.6181	.5535	.5272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184032 / PATODA

Feeder No / Name : 208 / PATODA GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.3772			
4	.4715			.462		.462
6			.6602			
8	.5658		.5658	.5544		.462
12		.1886	.2772	.2772		.3696
14	.2829	.1886				
15				.2772		.2772
16		.1886	.2772		.2772	
17	.3772					
18		.4715		.462		.4572
20	.6535	.7545	.6468		.6468	
21				.462		.462
23		.3772				
24	.3734		.3772	.3696		.3696
Max	.6535	.7545	.6602	.5544	.6468	.462
Min	.2829	.1886	.2772	.2772	.2772	.2772
Avg	.4541	.3615	.4545	.4092	.462	.4085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184032 / PATODA

Feeder No / Name : 209 / SOMTHANDESH

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			1.2574				
4	1.3413			1.2003			1.2717
6			.8192				
8	1.2717		1.186	1.2146			1.1336
12		.9488	.9221	.9012	.8288		.9831
13	.9012						
14		.6859					
15				.8478			.763
16		.6773	.9945			.6859	
17	.4239						
18		1.2651		1.2431			1.065
20	1.0164	1.1145	1.2012			1.1088	
21				.8478			.8192
23		1.0288					
24	1.1869		1.1869	1.1736			1.1469
Max	1.3413	1.2651	1.2574	1.2431	.8288	1.1088	1.2717
Min	.4239	.6773	.8192	.8478	.8288	.6859	.763
Avg	1.0236	.9534	1.0810	1.0612	.8288	.8974	1.0261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184060 / JALGAON NEUR

Feeder No / Name : 202 / JALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8886	.9198	.9023	.9564	.9907	.9175	.9351
2	.9046	.9229	.9099	.9488	.9816	.9335	.9153
3	.9343	.9435	.9297	.9656	.9656	.9069	.9259
4	1.0059	.9831	.9656	.9777	1.012	.961	.9694
5	1.0913	1.1218	.9938	1.0898	1.0943	1.0677	1.0844
6	1.1637	1.2727	1.1195	1.307	1.3382	1.2323	1.2292
7		1.2803	1.8762	1.9601	2.0309	1.2308	1.2993
8	.7827	.9884	2.3365	2.585	2.2398	.9343	.9877
9	.7682	.8063	2.2542	2.4714	2.2908	.7834	.6927
10	.5868	.6714	.6706	.6752	.455	.6257	.6272
11	.4321	.5037	.4047	.3734	.3856	.5037	.4877
12	1.733	1.4655	.378	.3841	.3887	1.797	1.64
13	1.8473	1.6956	.3963	.3864	.4001	1.9403	1.8206
14	1.7825	1.643	.4146	.4199	.4062	1.717	1.5737
15	1.5981	1.4175	.4184	.4237	.4321	1.5379	1.3771
16	1.6164	1.4525	.4252	.4611	.4611		1.5165
17	1.9547	2.0287	.4268	.4519	.4519		1.9189
18	2.1445	2.2588	.439	.4801	.4915	2.3746	2.0576
19	2.1087	2.2215	.612	.6135	.6302	2.4493	2.066
20	1.0684	.9892	1.0677	1.0166	1.0471	1.0646	1.0151
21	1.07	.9922	1.0288	.9694	1.0639	1.0296	1.054
22	1.0166	.9709	.945	.9175	.9595	1.0159	.9496
23	.9884	.8901	.852	.8939	.9717	1.0105	.9473
24	.9259	.8276	.8901	.9244	.945	.9473	.9107
Max	2.1445	2.2588	2.3365	2.585	2.2908	2.4493	2.066
Min	.4321	.5037	.378	.3734	.3856	.5037	.4877
Avg	1.2353	1.2195	.9024	.9439	.9347	1.2264	1.2084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184060 / JALGAON NEUR

Feeder No / Name : 203 / NEURGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6043	.6363	.413	.49	.4832	.5937	.5921
2	.5838	.615	.3909	.4862	.4885	.5906	.583
3	.5998	.6508	.423	.4862	.4946	.583	.5853
4	.6272	.6805	.4839	.5083	.5205	.5952	.6287
5	.7598	.7773	.5335	.5998	.5586	.6508	.7324
6	.8291	.8535	.6478	.7461	.6241	.7026	.8246
7	.7255	.7926	1.1004	1.1706	1.2132	.6661	.7842
8	.6142	.5388	1.2894	1.4274	1.3977	.5418	.5891
9	.4351	.4336	.7019	1.262	1.464	.3894	.4603
10	.3117	.3117	.1997	.1951	.253	.2858	.2873
11	.2759	.2629	.0709	.1585	.1989	.2522	.2218
12	.711	.9938	.1776	.1753	.2233	.9953	.9381
13	.8825	1.0303	.1981	.2134	.2599	1.0639	1.0654
14	1.0852	.9617	.2705	.2164	.2614	.9686	.9877
15	1.0159	.8086	.2926	.2507	.2538	.865	.82
16	1.0059	.8246	.2599	.2317	.2111	.9183	.8025
17	1.2353	1.0875	.1326	.2507	.218	1.2094	1.0791
18	1.3504	1.1759	.2987	.3216	.2355	1.2978	1.1325
19	1.1782	1.0707	.4092	.4306	.3437	1.278	1.0486
20	.5632	.5822	.5601	.5959	.5891	.6104	.5373
21	.6135	.599	.5731	.5693	.5822	.6158	.5761
22	.6775	.6013	.6577	.6257	.6706	.6645	.6158
23	.7217	.6165	.6211	.599	.6927	.6379	.6462
24	.6394	.3909	.4717	.4748	.5792	.5967	.5639
Max	1.3504	1.1759	1.2894	1.4274	1.464	1.2978	1.1325
Min	.2759	.2629	.0709	.1585	.1989	.2522	.2218
Avg	.7519	.7207	.4657	.5202	.5340	.7322	.7126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184060 / JALGAON NEUR

Feeder No / Name : 205 / DHULGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4816	.3155	.3064	.3414	.349	.4755
2	.5441	.5533	.3125	.3125	.3414	.4374	.535
3	.5639	.5777	.314	.314	.3475	.4908	.5441
4	.5685	.5883	.3064	.3185	.3521	.4877	.6097
5	.6081	.6234	.3246	.3445	.3475	.538	.6341
6	.7423	.7377	.3612	.3445	.3414	.6554	.7133
7	1.041	1.0806	.4054	.3567	.3597	.9694	.9922
8	1.1355	1.0791	.3749	.3749	.3262	1.0319	1.0303
9	.9587	.9739	.2652	.3109	.3125	.8261	.9267
10	.0503	.0838	.2347	.2027	.2058		.125
11	.1417	.1692	.032	.2286	.4252		.1417
12		.1768	.5304	.7484	.7026	.0808	.1372
13	.1113	.0549	.7773	.7026	.6752	.1814	.1905
14	.2164	.1768	.7499	.6081	.6249	.0168	.2042
15	.2042	.1814	.7148	.5517	.5883	.1677	.2378
16	.2408	.0777	.7727	.7133	.5685	.2241	.2469
17	.3612	.2195	.2896	.849	.6981	.2469	.2942
18	.4054	.346	.8886	.8794	.8413	.3094	.3658
19	.3887	.3734	.8657	.8535	.8429	.3003	.378
20	.3612	.4024	.3445	.3826	.2926	.3125	.3841
21	.349	.3963	.3323	.3551	.3277	.2789	.3246
22	.3201	.3734	.3643	.378	.3826	.2881	.3262
23	.3094	.3612	.3475	.3506	.3643	.2835	.3185
24	.4237	.3125	.3125	.3384	.346	.3932	.4512
Max	1.1355	1.0806	.8886	.8794	.8429	1.0319	1.0303
Min	.0503	.0549	.032	.2027	.2058	.0168	.125
Avg	.4583	.4334	.4390	.4635	.4565	.4032	.4411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184060 / JALGAON NEUR

Feeder No / Name : 206 / SATARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17
HR	Load (MW)
24	.1372
Max	.1372
Min	.1372
Avg	.1372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582]

BU 5291

Substation No/ Name :- 184090 / TANDULWADI

Feeder No / Name : 201 / 11 KV ANKUTE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1886	.1886		
3	.1928			.1886	.1886		
5				.2058	.2229		
6							.3048
7	.4733		.1578	.2058	.2058		.4115
9	.0686						
10		.0857				.0686	.0686
11	.0514						
12			.2896			.0686	.1029
13	.0514	.0526					
14						.0886	.0857
15	.0857						
16					.3601		.0857
18	.1307	.1578	.0343	.3772			
19		.1578				.168	
20			.2401	.2401			.1629
22			.2058	.1886		.168	
23		.1928					.2172
24	.2103	.0526	.1928	.1886	.1886		.2439
Max	.4733	.1928	.2896	.3772	.3601	.168	.4115
Min	.0514	.0526	.0343	.1886	.1886	.0686	.0686
Avg	.1580	.1166	.1867	.2229	.2258	.1124	.1870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582]

BU 5291

Substation No/ Name :- 184090 / TANDULWADI

Feeder No / Name : 202 / TANDULWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2309	.2606	.2942	.559	.5274	.2629	.2439
2	.2408	.2439	.3155	.3277	.2964	.253	.2332
3	.5685	.2774	.3323	.6085	.6089	.2675	.2431
4	.2827	.3041	.3262	.3559	.3216	.2873	.2614
5	.3643	.3544	.3185	.6729	.634	.3307	.3262
6	.458	.455	.3414	.4016	.3521	.4473	.9694
7	.8916	.49	.9366	.8078	.5151	.5022	1.0006
8	.4641	.4512	.5738	.5243	.5327	.4451	.5014
9	.5693	.4054	.6554	.5761	.5777	.3658	.3902
10	.2393	.4321	.3765	.3612	.2881	.407	.4756
11	.5128	.5471	.1913	.1509	.2126	.1959	.2172
12	.4108	.6775	.223	.157	.1463	.7194	.6942
13	.7079	.6828	.1341	.1288	.1097	.3765	.3597
14	.365	.3102	.1235	.1242	.1097	.6523	.6355
15	.6664	.3208	.1196	.1364	.1059	.317	.3003
16	.3635	.3437	.1196	.1478	.2881	.285	.6009
17	.3841	.426	.1471	.1677	.1059	.3849	.3475
18	.743	.8695	.2244	.3384	.1158	.455	.4755
19	.4557	.8444	.234	.2545	.2141	.8196	.5136
20	.4169	.3864	.7567	.7285	.426	.4443	.7493
21	.4047	.3841	.4397	.4062	.4306	.4001	.4024
22	.2865	.2599	.5212	.5404	.2827	.5106	.2591
23	.2774	.5997	.2324	.253	.269	.2263	.4741
24	.5144	.6066	.6432	.5155	.5205	.2484	.5022
Max	.8916	.8695	.9366	.8078	.634	.8196	1.0006
Min	.2309	.2439	.1196	.1242	.1059	.1959	.2172
Avg	.4508	.4555	.3575	.3852	.3330	.4002	.4657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582]

BU 5291

Substation No/ Name :- 184090 / TANDULWADI

Feeder No / Name : 203 / KASARKHEDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2774	.2957	.3292	.6424	.5692	.3033	.2827
2	.3064	.3018	.3323	.3528	.2919	.3086	.2766
3	.8512	.3163	.3292	.7125	.5951	.3178	.2911
4	.3567	.3711	.3429	.4001	.3292	.3467	.3307
5	.4329	.4748	.3856	.8665	.727	.423	.4161
6	.5716	.6607	.4146	.4984	.4504	.6379	1.2948
7	1.4373	.7369	1.2902	1.1088	1.0704	.7552	1.4624
8	.7171	.7125	.7103	.6935	.7278	.7057	.7095
9	1.0407	.6196	.7926	.7476	.7857	.6211	.6051
10	.4847	.8246	.5136	.519	.4496	.7819	.8177
11	.7095	.6622	.3285	.3185	.2987	.3666	.394
12	.5296	.692	.3129	.2553	.1898	.9678	.9777
13	.9202	.7724	.1555	.1821	.1753	.522	.522
14	.5434	.4161	.144	.1814	.1395	.9442	.9815
15	.855	.3803	.1486	.1623	.1456	.4062	.442
16	.4481	.3673	.1722	.1745	.2683	.3734	.8848
17	.5121	.4565	.173	.1242	.1638	.4633	.4908
18	1.0417	1.0614	.3864	.3704	.173	.5426	.6211
19	.5807	1.185	.3681	.2926	.3025	1.139	.6798
20	.6851	.6622	1.0905	1.0826	.6424	.6356	1.2382
21	.6783	.6638	.5921	.6706	.6912	.6386	.6173
22	.4481	.397	.7236	.6771	.4641	.764	.423
23	.3734	.6884	.3406	.2881	.3445	.3353	.7507
24	.6531	.6295	.7034	.5997	.605	.2934	.5883
Max	1.4373	1.185	1.2902	1.1088	1.0704	1.139	1.4624
Min	.2774	.2957	.144	.1242	.1395	.2934	.2766
Avg	.6439	.5978	.4617	.4967	.4417	.5664	.6707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582]

BU 5291

Substation No/ Name :- 184090 / TANDULWADI

Feeder No / Name : 204 / Antarvelli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4287	.5144		
3	.4733			.4287	.6516		
5				.4801	.5487		
6							.6097
7	1.1568		.631	.6173	.6344		.945
9	.2572						
10		.2058				.2454	.2572
11	.2572						
12						.2658	.1886
13	.2572	.2058					
14						.3189	.2058
15	.2229						
16					.6516		.2229
18	.2614	.3982	.8573	.7373			
19		.4733				.4668	
20			.6001	.5487			.5792
22			.463	.4115		.4854	
23		.4908					.3772
24	.3681	.4801	.4908	.3772	.4458		.4725
Max	1.1568	.4908	.8573	.7373	.6516	.4854	.945
Min	.2229	.2058	.463	.3772	.4458	.2454	.1886
Avg	.4068	.3757	.6084	.5037	.5744	.3565	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582]

BU 5291

Substation No/ Name :- 184090 / TANDULWADI

Feeder No / Name : 205 / SAWARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1886	.4801		
3	.583			.5487	.6001		
5				.6173	.6173		
6							1.1576
7	.7545		.964	.9602	1.0288		.8215
9	.3772						
10		.5144					.3772
11	.4115					.6201	
12			.3734				.8573
13	.6859	.6173					
14							.7716
15	.7545					.8328	
16					.4287		.8573
18	.8383	.8764	.3772	.3429			
19		.724				.4854	
20			.8916	.8573			.6001
22			.823	.8573		1.0082	
23		.5258					.9774
24	.7011	.6173	.5258	.4115	.4287		1.0082
Max	.8383	.8764	.964	.9602	1.0288	1.0082	1.1576
Min	.3772	.5144	.3734	.1886	.4287	.4854	.3772
Avg	.6383	.6459	.6592	.5980	.5973	.7366	.8254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582]

BU 5291

Substation No/ Name :- 184090 / TANDULWADI

Feeder No / Name : 206 / GORAKHNAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4458	.4115		
3	.4557			.4458	.4115		
5				.4801	.4115		
6							.5335
7	.6687		.463	.5487	.5487		.6097
9	.2572						
10		.2401				.2058	.2058
11	.0857	.2804					
12		.2915	.6097			.0857	.0857
13	.0857	.2743					
14						.0686	.0686
15	.0686						
16					.6001		.0857
18	.1494		.8059	.6001			
19		.6154				.5601	
20			.5144	.5144			.1629
22			.463	.4287		.4854	
23		.3982					.4557
24	.362	.2743	.3506	.463	.4287		.3963
Max	.6687	.6154	.8059	.6001	.6001	.5601	.6097
Min	.0686	.2401	.3506	.4287	.4115	.0686	.0686
Avg	.2666	.3392	.5344	.4908	.4687	.2811	.2893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582]

BU 5291

Substation No/ Name :- 184224 / 33 / 11 KV MUKHED

Feeder No / Name : 201 / 11KV MUKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.6859			.4287
2	.3772		.7202			.5144
3	.4115		.7716			.5487
4	.463		.9431			.583
5	.5144		1.0288			.6173
6	.6173		1.1145			.6516
7	.6173		1.1831			.5144
8	.583		1.0802			.4801
9		.5144	.3772		.4296	.8573
10		.4287	.1886		.3429	.6173
11		.6001	.2058		.2229	.5487
12		.8916		.2058	1.0288	.8573
13		.8916			.9431	.7202
14		.9431		.2743	.6859	.7373
15		.8573		.2401	.7716	.7888
16		.7716		.2572	.8916	.8573
17		.8916			.9259	.8573
18	.823	.9945			1.0117	.6859
19		.5144			.8573	.7888
20		.6516			.6001	1.0631
21		.6001			.4287	.823
22		.4801			.463	.8059
23		.6001			.4458	.7888
24		.703			.3429	
Max	.823	.9945	1.1831	.2743	1.0288	1.0631
Min	.3429	.4287	.1886	.2058	.2229	.4287
Avg	.5277	.7084	.7545	.2444	.6495	.7015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184224 / 33 / 11 KV MUKHED

Feeder No / Name : 202 / 11KV DESHMANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
1	.2743	.2401
2		.2743
3		.3086
4		.3601
5		.3944
6		.4287
7		.463
8		.2915
9		.4115
10		.3429
11		.3086
12		.6859
13		.6516
14		.6344
15		.6173
16		.7202
17		.823
18		.8916
19		.3772
20		.7545
21		.6516
22		.6001
23		.5487
24		.2572
Max	.2743	.8916
Min	.2743	.2401
Avg	.2743	.5015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582]

BU 5291

Substation No/ Name :- 184224 / 33 / 11 KV MUKHED

Feeder No / Name : 203 / 11KV SATYEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716		.1715	.0686			.7716
2	.8059		.1715	.0514			.8573
3	.8573		.1886	.0686			.9431
4	.9431		.1715	.0857			1.0288
5	1.1145		.1886	.0686			1.0631
6	1.2003		.2058	.0514			1.1145
7	1.5775		.1715	.0514	.1372		1.4575
8			.1886				1.6804
9		.12	.1372			1.286	
10		.0857	.0686			.0514	
11		.0514				.0343	
12		.0686	1.5089		1.3889	.0171	.1029
13		.0686	1.4575			.0343	.1715
14		.0514	1.4232		1.6461	.0514	.1715
15		.0514	1.4403		1.4575	.0514	.2058
16		.0514	1.3717		1.3375	.0514	.2058
17		.1029	1.2689				.2743
18	.1029	.12	1.3546				.2743
19		.1372	1.1488				.4115
20		.2058	.1886			.2229	.5487
21		.1886	.1372			.2572	.5487
22		.1715	.1029			.2229	.4801
23		.1543	.0514			.1886	.7888
24		.1715	.0514			.6859	
Max	1.5775	.2058	1.5089	.0857	1.6461	1.286	1.6804
Min	.1029	.0514	.0514	.0514	.1372	.0171	.1029
Avg	.9216	.1125	.5726	.0637	1.1934	.2427	.6550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184225 / 33 / 11 KV CHICHONDI

Feeder No / Name : 201 / 11 KV SATALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6882	.6859	.4115	.3688	.3429		.5304
2	.6882	.7202	.4115	.3647	.3429		.5304
3	.6882	.7888	.4115	.3647	.3429		.547
4	.7287	.8916	.4458	.3978	.3772		.6299
5	.9231	1.1145	.4801	.4588	.4115		.7449
6	1.2631	1.3717	.5487	.5243	.4458		1.1012
7	1.8884	2.0576	.4458	.3605	.4115		1.8138
8	2.1052	2.2977	.3605	.3563	.3086		1.9204
9	.2058	.1029	.426	.3429			.1715
10	.1886	.2058	.1943	.1715			.1372
11	.2058	.2058	.1943	.2058			.1543
12	.2058	.2401	1.7004	1.7147			.2058
13	.2401	.2743	1.7604	1.5775			.2058
14	.2401	.2915	1.7736	1.4403		.116	.2401
15	.2058	.3086	1.7204	1.4403		.1326	.2229
16	.2058	.2743	1.6385	1.4746		.1638	.2401
17	.2401	.3086	1.5546	1.406		.2267	.3429
18	.3086	.3772	1.4899	1.3375		.3277	.3429
19	.3429	.4801	1.1736	.1715		.426	.4115
20	.4801	.4801	.3688	.3944		.431	.4458
21	.5144	.4115	.3353	.3772		.3978	.4801
22	.4801	.4115	.373	.3601		.3353	.0343
23	.3429	.4115	.373	.3429		.2683	.4801
24	.6516		.4115	.3429			.0514
Max	2.1052	2.2977	1.7736	1.7147	.4458	.431	1.9204
Min	.1886	.1029	.1943	.1715	.3086	.116	.0343
Avg	.5847	.6396	.7918	.679	.3729	.2825	.4994

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582]

BU 5291

Substation No/ Name :- 184225 / 33 / 11 KV CHICHONDI

Feeder No / Name : 202 / 11KV NIMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6133	.0549	.3772	.407	.3772		.663
2	.6133	.5487	.3944	.407	.4115		.663
3	.6133	.6001	.3944	.4024	.4458		.663
4	.6133	.6001	.4801	.4359	.5144		.048
5	.5967	.6173	.5487	.4973	.5487		.7865
6	.5571	.6516	.6516	.5898	.6516		.3768
7	.4588	.6001	1.0288	.9339	1.0288		.3277
8	.3077	.4115	1.2793	1.3927	1.3546		.2743
9	.2572	.3258	1.004	.2058			.1543
10	.2058	.2915	.2105	.2229			.1715
11	.3086	.4115	.2267	.0257			.4287
12	.9602	.7888	.2561	.2401			.7888
13	1.0631	.7888	.3077	.2572			.8402
14	.8573	.7545	.3077	.2572		.7125	.823
15	.7888	.703	.3077	.2743		.6882	.7716
16	.8916	.8573	.2949	.3429		.6882	.7716
17	1.0288	1.1145	.2591	.3772		.8097	.8573
18	.9602	1.1488	.2785	.5487		1.004	1.046
19	.3086	.3429	.4917	.6173		.8684	.4801
20	.703	.6344		.6859		.6554	.5144
21	.6687	.6344	.6371	.7202		.6371	.6001
22	.6516	.6173	.6104	.6173		.6613	.6516
23	.6859	.3086	.5935	.3086		.6613	.6516
24	.6001		.3772	.3772			.6173
Max	1.0631	1.1488	1.2793	1.3927	1.3546	1.004	1.046
Min	.2058	.0549	.2105	.0257	.3772	.6371	.048
Avg	.6380	.6003	.4921	.4644	.6666	.7386	.5821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582]

BU 5291

Substation No/ Name :- 184225 / 33 / 11 KV CHICHONDI

Feeder No / Name : 203 / 11kv M.I.D.C. (Angangaon)

SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 11 / OUTGOING

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0343	.0343	.0377	.0343		.0566
2	.0189	.0343	.0343	.0377	.0343		.0566
3	.0189	.0343	.0343	.0377	.0343		.0566
4	.0189	.0343	.0343	.0377	.0343		.0566
5	.0377	.0343	.0343	.0566	.0343		.0566
6	.0566	.0343	.0343	.0747	.0686		.0566
7	.0566	.0514	.0514	.056	.0514		.0566
8	.056	.0514	.0566	.056	.0514		.0514
9	.0857	.0686	.0566	.0686			.0514
10	.0686	.0514	.0566	.0343			.0514
11	.0857	.0686	.0566	.0343			.0686
12	.0686	.0514	.0377	.0343			.0686
13	.0069	.0343	.0377	.0343			.0686
14	.0686	.0514	.0373	.0343		.0747	.0686
15	.0514	.0514	.0373	.0171		.0747	.0686
16	.0686	.0514	.056	.0343		.056	.0686
17	.0514	.0686	.0566	.0343		.0566	.0514
18	.0514	.0686	.0754	.0343		.0377	.0686
19	.0514	.0686	.0566	.0514		.0754	.0686
20	.0686	.0686	.0686	.0343		.0943	.0686
21	.0514	.0686	.0377	.0343		.0943	.0686
22	.0343	.0514	.0377	.0343		.0566	.0686
23	.0343	.0343	.0377	.0343		.0377	.0514
24	.0343		.0343	.0343			.0514
Max	.0857	.0686	.0754	.0747	.0686	.0943	.0686
Min	.0069	.0343	.0343	.0171	.0343	.0377	.0514
Avg	.0485	.0507	.0456	.0407	.0429	.0658	.0608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184225 / 33 / 11 KV CHICHONDI

Feeder No / Name : 204 / 11 Kv ANGANGAON-AG-SDT SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.2401	.3772	.3521	.3086		.2683
2	.2515	.2401	.3772	.3521	.3086		.2683
3	.2486	.2572	.3772	.3561	.3429		.2713
4	.2486	.2572	.4458	.373	.4458		.2683
5	.2652	.2915	.4801	.4191	.4801		.2883
6	.2458	.2743	.5487	.4862	.5316		.2883
7	.1966	.2229	.7716	.6962	.7888		.213
8	.1311	.1715	.8684	.8907	.8745		.0154
9	.12	.12	.6718	.12			.1543
10	.1715	.1029	.0663	.0857			.1029
11	.2058	.3258	.0663	.0857			.1372
12	.4801	.6687	.0819	.0686			.3429
13	.6001	.6516	.081	.0857			.703
14	.5144	.6001	.0819	.0857		.4694	.6687
15	.4287	.5144	.0819	.0857		.4973	.6001
16	.3429	.6173	.0819	.1029		.4915	.6173
17	.2743	.8402	.081	.0857		.5801	.6859
18	.3601	.7888	.0983	.12		.6796	.7373
19	.1543	.12	.1492	.1543		.5735	.1372
20	.2401	.2058	.2035	.1715		.2155	.1715
21	.2915	.1886	.1865	.2058		.2486	.2401
22	.2743	.1715	.1844	.2401		.2713	.2743
23	.2915	.3258	.1865	.2572		.2713	.2572
24	.2572		.3772	.3086			.2572
Max	.6001	.8402	.8684	.8907	.8745	.6796	.7373
Min	.12	.1029	.0663	.0686	.3086	.2155	.0154
Avg	.2852	.3564	.2886	.2579	.5101	.4298	.3320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

MANMAD RURAL DIVISION[602]

YEOLA-R[582] BU 5291

Substation No/ Name :- 184225 / 33 / 11 KV CHICHONDI

Feeder No / Name : 205 / 11Kv ERANDGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.373	.3429	.3944	.373	.3429		.3391
2	.373	.3772	.3944	.373	.3429		.3391
3	.3688	.4287	.3944	.373	.3772		.3391
4	.4024	.4801	.4287	.4024	.048		.3688
5	.4475	.5144	.4801	.4359	.5144		.4359
6	.5182	.6001	.5487	.4862	.5144		.4973
7	.7449	.823	.4973	.4694	.463		.7701
8	.9069	.9602	.3605	.3605	.3601		.9602
9	.1715	.1372	.3113	.3086			.2058
10	.1715	.1886	.1966	.2743			.1886
11	.1886	.2401	.1134	.1715			.1715
12	.2401	.2229	.5079	.3429			.1886
13	.2401	.2229	.4858	.4801		.1658	.1715
14	.2058	.2229		.4115		.1989	.2058
15	.2229	.2229	.4858	.3772		.1989	.2401
16	.2229	.2229	.583	.5144		.1966	.2572
17	.2401	.2401	.7045	.7202		.2347	.2401
18	.3086	.2743	.7701	.6173		.2652	.2572
19	.3772	.3601	.547	.2058		.3401	.4115
20	.463	.4115	.4287	.3429		.4096	.4115
21	.4115	.4458	.4024	.3944		.4144	.4115
22	.3429	.4287	.3688	.3772		.3688	.4287
23	.2572	.4115	.373	.3772		.3185	.2058
24	.3429		.3944	.3429			.3086
Max	.9069	.9602	.7701	.7202	.5144	.4144	.9602
Min	.1715	.1372	.1134	.1715	.048	.1658	.1715
Avg	.3559	.3817	.4422	.3972	.3704	.2829	.3481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184007 / 33/11 KV TAHARABAD

Feeder No / Name : 201 / MANGITUNGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.7108	.5716	.5716	.5335		.3563
2	.6554		.5601	.5716	.5335		.3725
3	.7287	.6762	.5906	.5716	.5335		.4049
4	.964	.7282	.5716	.5906	.5716		.4858
5	1.1765	.8149	.5906	.5906	.5906		.7287
6	1.2071	1.0576	.6287	.6097	.6478		.9717
7	1.8519	1.9244	.463	.4572	.5093		1.4575
8	2.1719	2.2365	.3429	.3239	.3961		.7287
9	1.7164	1.3765	.3174	.3048			1.283
10	.1907	.2477	.2286	.2452	.2858		.2286
11	.2096	.2477	.1905	.1905	.2096		
12	.1907	.2096	1.6956	1.6278	1.4083		
13	.2096	.1907	1.7101	1.4413	1.2631	1.2955	
14		.2286	1.2955	1.094	1.1736	.9717	
15	.2254	.2286	1.166	1.0111	.7287	.8259	.2667
16	.2427	.2667	1.2955	1.0898		.9393	.2858
17	.2858	.2667	1.576	1.3735	1.5257	1.1498	.2401
18	.2427	.2858	1.4754	1.2717		1.5546	.2667
19	.4001	.4572	1.0688	.9156		1.085	.4382
20	.5375	.5906	.5335	.6413		.5716	.6287
21	.5548	.5906	.5335	.5716		.6668	.6097
22	.5375	.6287	.5335	.5847		.5906	.6097
23	.5375	.6287	.5335	.5525		.5525	.5906
24	.583	.6762	.5668	.5335	1.0526		.4763
Max	2.1719	2.2365	1.7101	1.6278	1.5257	1.5546	1.4575
Min	.1907	.1907	.1905	.1905	.2096	.5525	.2286
Avg	.6972	.6639	.7933	.7390	.7477	.9276	.5715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184007 / 33/11 KV TAHARABAD

Feeder No / Name : 202 / MUNGASE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.2429	.2753	.3077	.0572	.0572
2		.2591	.2753	.3077	.0572	.0572
3	.0572	.2753	.2915	.2915	.0572	.0572
4		.2591	.3077	.2753	.0572	.0572
5		.2753	.3239	.3077	.0762	.0572
6		.3077	.3887	.3563	.0762	.0572
7	.0762	.6478	.6478	.7125	.0762	.0953
8	.0572	.7125	.7449	.583	.0572	.0572
9	.0572	.583	.664	.583	.0572	.0572
10	.0572	.0381	.0381	.0381	.0381	.0572
11	.0381	.0381	.0381	.0381	.0572	.0572
12	.5668	.0381	.0381	.0381	.7611	.7449
13	.5668	.0381	.0381	.0381	.6964	.7125
14	.4858	.0572	.0381	.0381	.6802	
15	.4858	.0572	.0381	.0381	.6478	.5506
16	.4372	.0572	.0572	.0381	.6802	.664
17	.4696	.0572	.0381	.0381	.7611	.6316
18	.4696	.0572	.0381	.0572	.6964	.5668
19	.3563	.0572	.0762	.0762	1.1012	.4858
20	.0762	.0762	.0572	.0762	.0953	.0762
21	.0762	.0762	.0572	.0762	.0762	.0762
22	.0762	.0762	.0762	.0762	.0762	.0762
23	.0572	.0762	.0572	.0762	.0762	.0572
24		.0381	.2374	.3547	.0572	.0572
Max	.5668	.7125	.7449	.7125	1.1012	.7449
Min	.0381	.0381	.0381	.0381	.0381	.0572
Avg	.2381	.1834	.2018	.2009	.2947	.2333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184007 / 33/11 KV TAHARABAD

Feeder No / Name : 203 / PIMPALKOTHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3239	.3563	.502	.5365		
2	.3048		.3563	.5182	.5365		.3048
3	.3429	.3429	.3353	.5506	.57		.3239
4	.381	.3429	.4115	.6371	.57		.3429
5	.4001	.381	.5182	.6478	.6068		.381
6	.4382	.4191	.6401	.8048	.8669		.4001
7	.362	.3048	.9145	1.4083	1.3565		.3048
8	.1905	.3239	1.2346	1.3765	1.6448		.2096
9	.1715	.2477	1.1401	1.1934			.1905
10	.1524	.1524	.0762	.0762	.0953		.1524
11	.0953	.0953	.0762	.0762	.0953		.0953
12	1.3565	1.2308	.0953	.0953	.0953	1.2631	1.2742
13	1.4083	1.1336	.0953	.0953	.1143	1.3908	1.1065
14		.9231	.0953	.1143	.1143	.9878	
15	1.1233	.8745	.0953	.1143	.1143	.9878	1.1736
16	1.2742	.9069	.1143	.1524	.1143	1.0526	1.2574
17	1.291	.9717	.1143	.1143	.1524	1.2955	1.291
18	1.2742	1.0526	.2858	.1334		1.2955	1.1904
19	1.1065	.9393	.2858	.2096		1.004	.9556
20	.2858	.3048	.362	.3239		.3048	.3239
21	.2858	.2858	.2858	.3048		.3048	.3048
22	.3429	.3048	.3429	.3048		.3429	.3048
23	.3239	.3048	.3048	.2477		.3239	.3239
24	.3048	.3048	.2667	.5256	.5533		.3239
Max	1.4083	1.2308	1.2346	1.4083	1.6448	1.3908	1.291
Min	.0953	.0953	.0762	.0762	.0953	.3048	.0953
Avg	.5879	.5422	.3668	.4386	.4786	.8795	.5698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184007 / 33/11 KV TAHARABAD

Feeder No / Name : 204 / HARANBARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.442	.1307	.1524	.1294		1.4089
2	1.3435		.1524	.1524	.1294		1.4251
3	1.3927	1.3923	.1524	.1524	.1478		1.4251
4	1.4754	1.3592	.1524	.1524	.1494		1.5384
5	1.4918	1.4089	.1524	.1524	.1494		1.587
6	1.6194	1.5746	.1715	.1715	.1698		1.668
7	1.8947	2.1382	.1372	.1524	.1509		2.0891
8	2.1879	2.3205	.12	.1524	.132		2.2348
9	2.1136	2.0243	.1334	.1267			2.0645
10	.1715	.1905	.1715	.1326	.1715		.1715
11	.1334	.1334	.1334	.1107	.1143		.1334
12	.0819	.0953	2.34	2.1026	2.2211		.0829
13	.0819	.0762	2.2969	2.0388	2.0567	.1143	.0829
14		.0953	2.3137	1.917	2.0243	.1143	
15	.0655	.0953	2.2186	2.0222	1.9271	.0953	.0663
16	.0663	.1143	2.17	2.0957	1.9109	.0953	.0829
17	.0663	.0953	2.0729	2.0622	2.0405	.0953	.0829
18	.0829	.0762	2.0729	1.8842		.1143	.1334
19	.1326	.1715	1.7976	1.8138		.1334	.1326
20	.1989	.2477	.2286	.2012		.2477	.2477
21	.1989	.2286	.2286	.2241		.2096	.2477
22	.1823	.2096	.2096	.2012		.2096	.2286
23	.1492	.1905	.1905	.1734		.1905	.1905
24	1.2955	1.4255	1.3441	.1524	.1478		1.3927
Max	2.1879	2.3205	2.34	2.1026	2.2211	.2477	2.2348
Min	.0655	.0762	.12	.1107	.1143	.0953	.0663
Avg	.7705	.7437	.8788	.7707	.8101	.1472	.8138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184007 / 33/11 KV TAHARABAD

Feeder No / Name : 205 / DAREGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.373	.4696	.5365	.4527		.3801
2	.3658		.4887	.5506	.4527		.4163
3	.4108	.4409	.442	.5898	.4694		.4163
4	.4908	.373	.442	.6371	.4694		.5068
5	.4908	.407	.4877	.6882	.583		.5792
6	.543	.5426	.5487	.7459	.7802		.6154
7	.4908	.4748	.6097	1.4575	1.4413		.5087
8	.3856	.39	1.3717	1.6518	1.8143		.3561
9	.3239	.3258	1.0526	1.2239			.3222
10	.2286	.2534	.2172	.1629	.2378		.1905
11	.1715	.1629	.1524	.128	.1905		.1715
12	1.2887	.5668	.0953	.128	.1524		1.1869
13	1.153	.9717	.0934	.0914	.128	1.1336	1.0174
14		.8097	.0905	.1097	.1267	.8097	
15	.9156	.7287	.0914	.1097	.1524	.8907	.78
16	.9496	.8907	.1524	.1478		.9393	.9156
17	1.1361	.9878	.1524	.128		1.3279	1.0004
18	1.2209	.9878	.2286	.2012		1.2955	1.2039
19	1.1191	.9393	.439	.3841		1.1012	1.0004
20	.5335	.4938	.5121	.5121		.5525	.4954
21	.407	.4572	.4572	.4207		.4572	.4763
22	.407	.4163	.4191	.439		.4572	.5144
23	.407	.4207	.381	.4024		.4382	.4572
24	.3658	.4191	.3801	.5365	.1524		.3801
Max	1.2887	.9878	1.3717	1.6518	1.8143	1.3279	1.2039
Min	.1715	.1629	.0905	.0914	.1267	.4382	.1715
Avg	.6164	.5580	.4073	.4993	.5069	.8548	.6040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184007 / 33/11 KV TAHARABAD

Feeder No / Name : 206 / TAHARABAD G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3366	.3045	.2743	.3292	.2987		.3439
2	.3439		.2926	.3258	.2987		.362
3	.3658	.3045	.3077	.3658	.3174		.362
4	.4066	.3224	.3439	.4207	.3174		.4525
5	.4572	.3582	.3801	.4207	.3734		.5068
6	.5487	.4835	.4344	.4755	.5093		.543
7	.5304	.5552	.463	.5304	.5601		.5792
8	.4938	.4656	.4344	.4572	.4805		.4887
9	.394	.4887	.3982	.362			.4119
10	.3761	.3921	.4344	.3521	.4207		.4298
11	.3582	.4108	.3658	.3149	.4163		.3761
12	.3403	.3258	.3841	.3898	.4024		.3582
13	.3403	.4163	.3475	.3898	.3982	.4525	.394
14		.3982	.3982	.3544	.3961	.3982	
15	.3403	.3801	.4163	.3721	.3841	.3801	.3403
16	.3582	.3982	.4024	.4075	.3841	.4163	.394
17	.3582	.3801	.3801	.3898	.3658	.3801	.3582
18	.3224	.3801	.3841	.3012		.3439	.3582
19	.3582	.4163	.4163	.4075		.4344	.394
20	.4119	.4108	.4344	.4706		.4572	.4119
21	.3582	.3921	.3658	.394		.4108	.394
22	.3761	.3734	.3841	.362		.4108	.3761
23	.3403	.3361	.3658	.3292		.3801	.3403
24	.362	.3045	.3174	.3258	.2987		.3439
Max	.5487	.5552	.463	.5304	.5601	.4572	.5792
Min	.3224	.3045	.2743	.3012	.2987	.3439	.3403
Avg	.3860	.3912	.3802	.3853	.3895	.4059	.4052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184007 / 33/11 KV TAHARABAD

Feeder No / Name : 207 / KATARWEL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694		.4382	.4572	.4572		.3077
2	.4915		.4382	.4572	.4572		
3	.5365	.4696	.4572	.4763	.4572		.3563
4	.5868	.4858		.5144	.4954		.4049
5	.6226	.5668	.5144	.5716	.5525		.5182
6	.663	.6964	.5525	.6287	.6097		.5521
7	1.2407	1.3117	.4801	.5144	.5335		1.1498
8	1.5089	1.7166	.3601	.4001	.4382		1.3603
9	1.0364	1.0526	.3239	.3048			1.0343
10	.1334	.1715	.1715	.2096	.2477		.1905
11	.1905	.1715	.0953	.1334	.1524		
12		.1334	1.1105	.8817	.8718		
13	.1524	.1387	.9945	.8478	.7956	.7287	
14		.1715	.8383	.7127	.6371	.6154	
15	.1715	.1715	.7449		.583	.6154	.1905
16	.1905		.8583	.7712	.7935	.7773	.2286
17	.1905	.1715	1.1233	.8309	.9556	.8745	.1905
18	.1905	.1867	1.0526	.8817		.9393	.2286
19		.4001	.081	.7461		.7449	.4001
20	.5144	.5144	.5144	.5906			.5525
21	.4382	.4954	.4763	.4572			.4382
22		.4954	.4954	.5144		.4572	.4763
23	.362		.4763	.4763		.4191	.4001
24	.4527	.4372	.2753	.4572	.4572		.3429
Max	1.5089	1.7166	1.1233	.8817	.9556	.9393	1.3603
Min	.1334	.1334	.081	.1334	.1524	.4191	.1905
Avg	.5071	.4979	.5597	.5581	.5585	.6858	.4907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184008 / 33/11 KV NAMPUR

Feeder No / Name : 201 / DYANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201	.5144	.6783	.6859	.724		.543
2	.5201	.5144	.6554	.6859	.724		.543
3	.5201	.5144	.663	.7716	.724		.543
4		.543	.7459	.8573	.8145		.543
5	.6001	.6001	.8097	1.3717	1.086		.6335
6	.6859	.7716	.9831	1.6956	1.267		.8145
7	.6859	.6859	1.8623	2.2043	2.1719		.6335
8		.4287	1.8023	1.7804	2.3529		.543
9			1.3717	1.1869			.4525
10	.3429	.3353	.1753	.2572			.2572
11	.2572	.2486	.1753	.1715			.1715
12	1.286	1.1603	.1734	.1715	.1715	.1715	1.8004
13	1.1145	.9831	.1734	.1715	.1715	.1715	1.6289
14	1.0288	.9012	.1753	.1715	.1715	.1715	1.1145
15	.9431	.8192	.1734	.1715	.1715	.2572	1.1145
16	1.448	1.065	.1734	.1715	.1715	.1715	1.4575
17	1.8099	1.4575	.2601	.1715	.1715	.1829	1.6289
18	1.6289	1.4746	.3467	.1715		.3734	1.5384
19	1.3717	1.0526	.5201	.5144		.4525	1.3575
20	.6335	.5087	.5201	.4525		.5087	.5144
21	.5144	.4239	.5201	.4525		.543	.5487
22	.543	.503	.5201	.4287		.543	.543
23	.5144	.503	.5258	.4287		.5373	.543
24	.4382	.2572	.663	.6859	.6859		.543
Max	1.8099	1.4746	1.8623	2.2043	2.3529	.543	1.8004
Min	.2572	.2486	.1734	.1715	.1715	.1715	.1715
Avg	.8289	.7072	.6111	.6596	.7719	.3403	.8338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184008 / 33/11 KV NAMPUR

Feeder No / Name : 202 / AMBASAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.2572	.503	.6859	.8145		.2715
2	.5144	.2572	.6706	.8573	.905		.2715
3	.5144	.2715	.663	1.0288	.905		.2715
4	.5144		.8192	1.2003	1.086		
5	.6001		.9116	1.3565	1.3575		
6	.7716		.9945	1.6956	1.7194		
7	1.0174		1.7004	1.8442	2.0814		
8	1.2717		1.6575	1.7604	1.9909		
9	.8573		1.2003	1.5089			
10		.1658	.0876	.0857			
11		.1638	.0876	.0857			
12	1.3717	1.1469	.6859	.5144	.5144		1.5432
13	1.286	1.0774	.6859	.4287	.4287	.3429	1.3717
14	1.2003	1.065	.6001	.4287	.4287	.3429	1.2003
15	1.1145	.8907	.6001	.3429	.3429	.3429	1.1145
16	1.5384	.9831	.6859	.4287	.5144	.3429	1.3717
17		1.3108	.6859	.6001	.6001	.0905	1.5432
18	1.6289	1.3765	.6001	.0857		.1829	1.8099
19	1.286	.8907	.6001	.181		.2743	1.6289
20	.2715	.2486	.2601	.2715		.2715	.2715
21	.2572	.1658	.2601	.2715		.2743	.2715
22	.2715	.1638	.2601	.2715		.2743	.2715
23	.2572	.1696	.2572	.2715		.2715	.2715
24	.5201	.2715	.5801	.6001	.7716		.2715
Max	1.6289	1.3765	1.7004	1.8442	2.0814	.3429	1.8099
Min	.2572	.1638	.0876	.0857	.3429	.0905	.2715
Avg	.8371	.6042	.6690	.7002	.9640	.2737	.8597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184008 / 33/11 KV NAMPUR

Feeder No / Name : 203 / KHIRMANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.362	.3277	.5144	.362		.362
2	.2629	.362	.3277	.6001	.362		.3734
3	.2629	.3429	.3315	.6001	.3429		.362
4	.2629	.3429	.4096	.6859	.4525		.362
5	.2629	.362	.4973	.7716	.6335		.3239
6	.3506	.4287		.8573	.8145		.4525
7	.4334	.3429	.9012	1.0288	1.1765		.362
8	.2601	.2572	.8192	1.0059	1.267		.2715
9	.1734	.1715	.6859	.8573			.181
10	.1715	.1638	.1753	.1715			.1715
11	.1715	.0819	.0876	.1715			.1715
12	.6859	.6554	.1734	.1715	.0857	.1715	.7716
13	.5144	.5801	.1753	.1715	.0857	.1715	.6859
14	.5144	.4858	.1753	.1715	.0857	.1715	.6001
15	.4287	.4858	.1753	.343	.1715	.1715	.6001
16	.724	.6478	.1734	.1715	.1715	.1715	.7716
17	.905	.8192	.1753	.1715	.0857	.181	.8573
18	.8145	.8192	.1734	.1715		.181	.905
19	.8145	.7287	.3506	.2572		.3658	.8145
20	.362	.3353	.3506	.362		.3582	.362
21	.362	.3391	.3506	.3429		.362	.3658
22	.3429	.2515	.3506	.2715		.3734	.362
23	.3429	.2515	.2629				.362
24	.6859	.3429	.3315	.5144	.362		.362
Max	.905	.8192	.9012	1.0288	1.267	.3734	.905
Min	.1715	.0819	.0876	.1715	.0857	.1715	.1715
Avg	.4322	.4150	.3383	.4515	.4306	.2435	.4672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184008 / 33/11 KV NAMPUR

Feeder No / Name : 205 / NAMPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.7011	.6859	.724		.724
2	.6859	.724	.7011	.6859	.724		.724
3	.6859	.724	.7011	.6859	.724		.724
4	.6859	.724	.7087	.6859	.724		.7316
5	.8573	.7716	.7802	.7716	.724		.8145
6	.9431	1.0288	1.0517	.8573	1.086		1.0174
7	1.0288	1.0288	1.0517	.9431	1.086		.9955
8	.8573	.8573	.8669	.8573	.8573		.9955
9	.8573	.7716	.8573	.7716			.905
10	.7716	.8764	.8573	.8573			.8573
11	.7716	.8573	.7716	.7716			1.0288
12	.7716	.7802	.7716	.6859	.7716	.8573	.9431
13	.7716	.7888	.7716	.7716	.7716	.8573	.8573
14	.6859	.763	.7716	.7716	.7716	.8573	.7716
15	.6859	.7716	.8573	.7716	.7716	.8573	.8573
16	.8145	.763	.8573	.7716	.7716	.8573	.0857
17	.8145	.7716	.8573	.8573	.8573		.0857
18		.8478	.9431			.9955	.9955
19	1.086	.9536	1.0288	1.086		1.1088	1.086
20	1.0288	1.0517	1.1145	1.086		1.0974	.9955
21	.9431	.9745	.9431	.9955		1.0269	1.0269
22	.8573	.964	.8573	.905		.924	1.0059
23		.7973	.7716	.7716		.9335	.9335
24	.8573	.6859	.7087	.6859	.724		.724
Max	1.086	1.0517	1.1145	1.086	1.086	1.1088	1.086
Min	.6859	.6859	.7011	.6859	.724	.8573	.0857
Avg	.8249	.8318	.8459	.8145	.8059	.9430	.8286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184008 / 33/11 KV NAMPUR

Feeder No / Name : 206 / OLD TEMBHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.8573	.1638	.2629	.181		.8145
2	1.0288	.9431	.1638	.2629	.181		.8145
3	1.0288	1.0288	.1658	.2629	.181		.905
4	1.2003	1.1145	.1658	.2629	.2715		1.086
5	1.3717	1.1765	.2515	.2629	.2715		1.267
6	1.5261	1.448	.2515	.2601	.362		1.448
7	1.6766	1.8861	.2458	.2629	.2715		2.3529
8	2.0348	1.9004	.1619	.2601	.181		1.9004
9	1.3717	1.4089	.1753	.1753			1.3717
10	.1715	.0848	.1753	.0857			.1715
11	.1715		.0876	.0857			.1715
12	.1715	.0819	1.1145	1.7147	1.8861	1.7147	.1715
13	.1715	.0819	1.2003	1.4575	1.7147	1.5432	.1715
14	.1715	.081	1.0288	1.286	1.3717	1.3717	.1715
15	.1715	.081	.8573	1.3717	1.2003	1.2003	.1715
16	.2715	.081	1.2003	1.3717	1.3717	1.2003	.1715
17	.0905	.0819	1.3413	1.5432	1.4575	1.267	.1715
18	.181	.0819	1.3413	1.7194		1.267	.2715
19	.362	.2429	1.3565	1.448		1.3575	.2715
20	.3429	.2515	.3467	.2715		.362	.2715
21	.4287	.2515	.3467	.2715		.362	.2715
22	.2572	.2458	.2629	.2715		.2743	.1867
23	.1715	.2486	.2629	.181		.1848	.181
24	1.0288	.8573	.1524	.2629	.181		.8145
Max	2.0348	1.9004	1.3565	1.7194	1.8861	1.7147	2.3529
Min	.0905	.081	.0876	.0857	.181	.1848	.1715
Avg	.6846	.6312	.5342	.6506	.7389	1.0087	.6500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184008 / 33/11 KV NAMPUR

Feeder No / Name : 208 / RATIR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.4287	.4973	.2629	.181		.4525
2	.6001	.5144	.503	.2629	.181		.4668
3	.6001	.5144	.4973	.2629	.181		.543
4	.6859	.6335	.4915	.2601	.181		.5487
5	1.0288	.724	.5868	.2601	.2715		.6335
6	1.3565	.9431		.3467	.3429		.905
7	1.6766	1.6289	.4973	.3506	.362		1.8099
8	1.8861		.4973	.2629	.2715		1.7194
9	1.4575	1.4575	.1753	.1753			1.448
10	.1715	.1658	.0876	.1715			.1715
11	.1715	.2486	.0876	.0857			.1715
12	.1715	.1638	.9431	.8573	1.0288	.8573	.2572
13	.1715	.1677	1.0288	.8573	.8573	.6859	.1715
14	.1715	.1658	.9431	.8573	.6859	.6859	.1715
15	.2572	.1619	.8573	.8573	.6859	.6859	.2572
16	.2715	.2458	1.1869	1.0288	1.0288	.7716	.2572
17	.2715	.2429	1.3413	1.2003	1.1145	1.267	.2572
18		.3239	1.2717	1.5432		1.3575	.2715
19		.4915	1.2003	1.267		1.267	.2715
20	.2572	.6706	.3506	.3429		.3429	.2715
21	.2572	.5868	.3506	.2572		.362	.2743
22		.5801	.2629	.2715		.2715	.2743
23	.1715	.4973	.2629	.2715		.2715	.181
24	.6859	.4525	.4915	.2629	.2715		.4525
Max	1.8861	1.6289	1.3413	1.5432	1.1145	1.3575	1.8099
Min	.1715	.1619	.0876	.0857	.181	.2715	.1715
Avg	.6153	.5222	.6266	.5240	.5096	.7355	.5099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184008 / 33/11 KV NAMPUR

Feeder No / Name : 209 / Ambasan G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0838	.0867			.0905
2	.0857	.0905	.081	.0867	.0905		.0905
3	.0857	.0905	.0829	.0867	.0905		.0905
4	.0857	.0857	.0838	.0867	.0905		.0905
5	.0857	.0857	.0829	.0857	.0905		.0905
6	.0857	.0857	.1677	.0857	.0905		.0905
7	.1715	.0857	.1619	.1715	.0905		.0905
8	.0857	.0857	.081	.0857	.0905		.0905
9	.0867	.0857	.0867	.0876			.0905
10	.0857	.0848	.0867	.0857			
11	.0857	.0819	.0867	.0857			.1715
12	.0857	.0829	.0867	.0857	.0857	.0857	.0857
13	.0857	.0819	.0867	.0857	.0857	.0857	.0857
14	.0857	.081	.0867	.0857	.0857	.0857	.0857
15		.0819	.0867	.0857	.0857	.0857	.0857
16	.0905	.0819	.0867	.0857	.0857	.0857	
17	.0905	.0819	.0857	.0857	.0857	.0905	
18		.0838	.0857	.0905		.0934	.0914
19	.0905	.0819	.0867	.0905		.0934	.0905
20		.0857	.1734	.0857		.0934	.0905
21	.0857	.0848	.0857	.0905		.0905	.0934
22	.0857	.0848	.0867			.0924	.0934
23	.0857	.0838	.0876	.0905		.0905	.0905
24	.0867	.0857	.1734	.0857	.0905		.0905
Max	.1715	.0905	.1734	.1715	.0905	.0934	.1715
Min	.0857	.081	.081	.0857	.0857	.0857	.0857
Avg	.0906	.0846	.0993	.0905	.0884	.0894	.0938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184008 / 33/11 KV NAMPUR

Feeder No / Name : 210 / MORANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.4525	.0829	.0876	.0905		.2715
2	.6001	.4525	.0819	.0876	.0905		.2715
3	.6001	.4287	.0829	.0876	.0905		.2715
4	.6001	.5144	.0829	.0876	.0905		.362
5	.6859	.543	.0819	.0876	.0905		.4525
6	.763	.5144		.0876	.0905		.5601
7	.8478	.905	.0829	.0867	.0857		.724
8	1.0174	.9431	.081	.0876	.0905		.6859
9	.7716	.7716	.0857	.0876			.6335
10	.0857	.0829	.0876	.0857			.0857
11	.0857		.0876	.0857			.0857
12	.0857	.081	.7716	.7716	.8573	.8573	.0857
13	.0857	.0838	.8573	.7716	.7716	.9431	.0857
14	.0857	.081	.7716	.7716	.6859	.7716	.0857
15	.0857	.0819	.6859	.6001	.6001	.5144	.0857
16	.0905	.0829	.6859	.6001	.5144	.5144	.0857
17	.0905	.081	.6859	.6859	.6001	.543	.0857
18	.0905	.0819	.6859	.6859		.543	.0905
19	.0905	.081	.6859	.6001		.543	.0905
20	.0905	.0848	.0876	.0857		.0914	.0905
21	.0857	.0848	.0876	.0905		.0924	.0905
22	.0857	.0848	.0867	.0905		.0905	.0914
23	.0905	.0838	.0876	.0857		.0905	.0905
24	.6859	.5144	.0829	.0876	.0905		.2715
Max	1.0174	.9431	.8573	.7716	.8573	.9431	.724
Min	.0857	.081	.081	.0857	.0857	.0905	.0857
Avg	.3500	.3094	.3087	.2869	.3226	.4662	.2389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184046 / 33/11 KV JAIKHEDA

Feeder No / Name : 201 / NITANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6722	.7773	.8951	1.0166		.415
2	.679	.5487	.8383	.9503	1.0517		.3772
3	.7167	.5544	1.1401	.9614	1.0802		.3772
4	.7842	.6468	1.1934	1.065	1.3672		.3772
5	.8589	.8573	1.247	1.3765	1.5432		.4854
6	1.0642	.9945	1.6617	1.8351	2.4478		.7095
7	1.0269	.7392	2.5095	2.9767			.8962
8	.7922	.5935	2.4291	2.9959			.7167
9	.439	.6036	.3395	.3395			.4904
10		.3772	.2241	.2218			.3772
11	.8288	.9962	.2075	.1867		1.448	.7712
12	2.13	2.0388	.2263	.1867	.2829	1.9814	1.3283
13		1.8138	.2452	.2241	.2641	2.1529	1.6004
14	1.7368	1.5935	.2641	.2614		1.8595	1.4706
15	1.8564	1.6194	.2427	.2801	.2641	1.8976	1.5123
16	2.2291	1.8947	.2427	.2987	.3018	1.9608	1.8122
17	2.4249	2.2672	.2829	.2801		2.5617	2.2497
18	2.5149	2.4486	.415	.3326		2.6246	2.3845
19	.5853	.7922	.8962	.7316		1.8976	.5144
20	.7023	.8676	.8962	.9145		.6722	1.0185
21	.7087	.7167	.7468	.8501		.7095	.8589
22	.7023	.6224	.6602	.6099		.6722	.7922
23	.6468	.5761	.7042	.6201		.6979	.7167
24	.6602	.6653	.7287	.8718	.9431		.5281
Max	2.5149	2.4486	2.5095	2.9959	2.4478	2.6246	2.3845
Min	.439	.3772	.2075	.1867	.2641	.6722	.3772
Avg	1.1249	1.0625	.7966	.8444	.9602	1.6258	.9492

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184046 / 33/11 KV JAIKHEDA

Feeder No / Name : 202 / BRAMHANPADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7459	.763	.3961	.4527	.4066		.6554
2	.6962	.7122	.3961	.4527	.3734		.6226
3	.7042	.7888	.4338	.4527	.3734		.6299
4	.7625		.4715	.5281	.3361		.7537
5	.852	1.0288	.547	.5975	.4294		.8421
6	1.1336	1.2209	.7167	.7282	.4435		.8962
7	1.6762	1.9204	.6602	.6413			1.6129
8	1.7604	1.989	.4338	.4904			1.8501
9	.2241	.2641	.3206	.3206			1.4251
10	.168	.1509	.2054				.1509
11	.1494	.132	.7537	.6859		.124	.132
12	.1478	.1132	1.3441	1.0288	1.2483	.1227	.132
13	.1494	.132	1.1683	1.286	1.0526		.1509
14	.1294	.1698	1.1305	1.262		.1147	.1886
15	.1867	.1698	1.0814	1.166	.9259	.1417	.1886
16	.1848	.1698	1.1843	1.1603	1.0774	.2058	.1886
17	.2218	.1698	1.2963	1.2346		.2058	.2075
18	.2772	.1698	1.4251	1.1406		.2103	.2829
19	.5228	.6224	.4854	.4481		.3506	.5975
20	.4805	.6036	.5228	.4435		.4481	.5658
21	.4435	.4715	.4854	.4251		.4108	.4481
22	.4066	.4338	.4854	.3658		.3395	.3584
23	.6401	.3961	.415	.4024		.3018	.5636
24	.7045	.7202	.3961	.4294	.4251		.5304
Max	1.7604	1.989	1.4251	1.286	1.2483	.4481	1.8501
Min	.1294	.1132	.2054	.3206	.3361	.1147	.132
Avg	.5570	.5788	.6981	.7019	.6447	.2480	.5822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184046 / 33/11 KV JAIKHEDA

Feeder No / Name : 203 / JAIKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5449	.5487	.6973		
2			.4972	.5194	.6631		
3			.4801	.4954	.5525		
4			.4268	.4566	.5586		
5			.4268	.4414	.6317		
6		.7023	.4889	.4877	.6066		
7			.4591	.6325	.4268		
8			.5533	.3734	.4268		
9			.3201	.3658	.4191		
11	.4115	.3772				.5144	.3481
12	1.0219	.9107				1.0517	.9087
13	1.0219	.7895		.3155		1.0402	.8135
14	.9587	.7621				.9526	.7064
15	.8344	.815				.8154	.5497
16	.7869	.7109				.7507	.567
17	.8033	.743				.6858	.5086
18	.7983	.7869				.7468	.6082
19	.4268	.4039				.663	.3353
23		.2713	.2515	.3368			
24		.3125	.5591	.3429	.4024		
Max	1.0219	.9107	.5591	.6325	.6973	1.0517	.9087
Min	.4115	.2713	.2515	.3155	.4024	.5144	.3353
Avg	.7849	.6321	.4553	.4430	.5385	.8023	.5939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184046 / 33/11 KV JAIKHEDA

Feeder No / Name : 204 / PADGHAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4748	.5487	.3018	.3584	.3361		.4973
2	.503	.4908	.3206	.3584			.4694
3	.503	.5144	.3584	.3961	.2987		.4641
4	.5365		.3584	.415	.3326		.5898
5	.5407	.7202	.3961	.4527	.3361		.7537
6	.6226	.823	.415	.4108	.3696		.8097
7	1.1523	1.4575	.4715	.4668			1.439
8	1.2483	1.4575	.3584	.3961			1.2803
9	.2054	.1698	.2829	.2829			.9503
10		.1698	.2075	.168			.1698
11		.1509	.5636	.4748		.12	.132
12		.1132	1.0814	.9945	.9503	.12	.1698
13		.1132	.8848	.964	.8907	.12	.132
14	.112	.0943	.8192	.8573		.12	.132
15	.1294	.132	.8684	.8817	.7865	.12	.1509
16	.112	.1698	.9393	.9816	.9339	.1372	.1509
17	.1307	.1509	1.0562	1.1022		.1402	.1509
18	.1867	.2075	.9762	1.0517		.1372	.2263
19	.3921	.415	.415	.4108		.2743	.4338
20	.3326	.3584	.3584	.3326		.3361	.415
21	.2957	.3395	.3206	.3734		.3361	.3395
22	.2772	.3206	.3772	.3658		.3018	.3584
23	.5373	.3206	.3584	.3326		.3018	.431
24	.4915	.6135	.3206	.3584	.3361		.4359
Max	1.2483	1.4575	1.0814	1.1022	.9503	.3361	1.439
Min	.112	.0943	.2075	.168	.2987	.12	.132
Avg	.4392	.4283	.5337	.5494	.5571	.1973	.4617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184046 / 33/11 KV JAIKHEDA

Feeder No / Name : 205 / EKALAHARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4862	.4908	.3206	.3206	.2801		.4359
2	.4694	.4748	.3018	.3018	.2801		.3978
3	.5243	.5144	.3395	.3018	.2957		.4024
4	.5735		.3961	.3395	.3361		.5243
5	.5898	.7011	.4527	.4527	.4251		.6882
6	.6964	.7362	.5281	.5601	.4435		.7045
7	1.2483	1.406	.547	.5281			1.2803
8	1.4083	1.4918	.3584	.4338			1.4706
9	.1867	.132	.2452	.2452			1.1843
10	.1307	.1509	.1698	.168			.1886
11	.112	.0943	.7459	.5144			.1698
12	.0934	.0943	1.1336	1.1919	.7926		.1509
13	.0934	.0943	1.0486	1.1145	.8482		.1509
14	.112	.0943	.9503	1.0174		.0953	.132
15	.112	.0943	.9995	.9774	.7122	.0953	.1132
16	.0934	.0943	.9878	.9602	.6706	.0953	.132
17	.1307	.0943	1.0322	.9991		.1063	.1698
18	.168	.1886	1.1203	.9945		.1334	.2452
19	.3696	.4527	.3584	.2987		.4001	.4527
20	.3326	.4715	.4854	.4668		.3772	.4527
21	.3142	.3772	.3772	.4024		.3395	.3395
22	.2957	.3772	.3961	.3475		.2641	.3206
23	.4119	.3206	.3395	.3142		.2641	.3185
24	.4534	.3856	.3206	.3206	.2801		.4024
Max	1.4083	1.4918	1.1336	1.1919	.8482	.4001	1.4706
Min	.0934	.0943	.1698	.168	.2801	.0953	.1132
Avg	.3919	.4057	.5814	.5655	.4877	.2171	.4511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184046 / 33/11 KV JAIKHEDA

Feeder No / Name : 206 / SOMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3763	1.278	.2263	.2452	.2427		1.0159
2	1.3435	1.0288	.2263	.2452	.2427		.9831
3	1.3765	1.286	.2452	.2829	.2614		1.1012
4	1.3763	1.3375	.2829	.3018	.2614		1.2125
5	1.4723	1.5432	.3206	.3395	.2743		1.4899
6	1.5844	1.7147	.3206	.3772	.3142		1.5684
7	2.1822	2.3758	.3395	.3772			2.1822
8	2.3205	2.2874	.2641	.3018			2.3045
9	.2614	.2263	.3395	.2641			2.0405
10	.2054	.1886	.1886	.1698			.2452
11	.1478	.1509	1.6385	.929		.1524	.1698
12	.0924	.132	2.2725	1.6244	1.8461	.1143	.1698
13	.1509	.1509	2.2348	1.989	1.9006	.0953	.1509
14	.1307	.132	1.9595	1.8351		.0953	.1509
15	.112	.1509	1.9524	1.9559	1.7204	.0953	.132
16	.112	.132	1.9989	1.8023	1.7695	.0953	.132
17	.1307	.132	2.1445	2.0576		.1063	.1509
18	.168	.1698	2.1235	1.8351		.1524	.1698
19	.3734	.4338	.3921	.3326		.4001	.3772
20	.3142	.3584	.3584	.3921		.3772	.415
21	.2614	.2641	.2641	.3109		.3395	.2829
22	.2614	.2641	.2452	.2743		.2641	.2452
23	.8954	.2263	.2263	.2195		.2263	1.1633
24	1.2803	1.286	.2263	.2263	.2218		1.0159
Max	2.3205	2.3758	2.2725	2.0576	1.9006	.4001	2.3045
Min	.0924	.132	.1886	.1698	.2218	.0953	.132
Avg	.7471	.7187	.8663	.7787	.8232	.1934	.7862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184046 / 33/11 KV JAIKHEDA

Feeder No / Name : 207 / TANDULWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4481	.6443	.9831	1.0288		.415
2	.4715	.4024	.6613	1.0277	1.0631		.3772
3	.5281	.4066	.6962	1.065	1.1233		.3772
4	.5847	.4854	.7545	1.1469	1.166		.4527
5	.6722	.6468	.8215	1.278	1.4575		.5658
6			1.0562	1.3603	1.8233		.6348
7		.7762	1.873	2.0005			.6348
8	.5093	.5228	1.9757	2.1052			
9	.462	.4527	.2263	.2641			.4904
10	.3326	.2829	.2427	.2033			.3395
11	.6226	.8421	.1886	.2241		1.5242	1.1469
12	1.8004	1.4899	.1698	.1494	.1698	1.6827	1.7124
13	1.7204	1.4723	.1698	.1494	.1698	1.9433	1.4737
14	1.6575	1.2498	.1886	.1867		1.949	1.3283
15	1.5729	1.21	.1509	.1867	.1886	1.8671	1.1111
16	1.4575	1.3279	.2075	.2241	.2263	1.7528	1.3757
17	1.5432	1.4255	.1886	.1848		1.5935	1.4706
18	1.6461	1.5203	.415	.1867		1.6461	1.5844
19	.4805	.4527	.6413	.462		1.4998	.4715
20	.6584	.5847	.5601	.6468		.5281	.6602
21	.5914	.5093	.5228	.6838		.5601	.5975
22	.5175	.4527	.4904	.5975		.4904	.5281
23	.4435	.6154	.8288	.6935		.4527	.4904
24	.4527	.4481	.6401	.2241	1.0166		.4527
Max	1.8004	1.5203	1.9757	2.1052	1.8233	1.949	1.7124
Min	.3326	.2829	.1509	.1494	.1698	.4527	.3395
Avg	.8726	.7837	.5964	.6764	.8576	1.3454	.8126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184046 / 33/11 KV JAIKHEDA

Feeder No / Name : 208 / JAIKHEDA G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.298	.3155	.333	.333	.3155		.3506
2	.298	.3155	.3155	.3012	.3155		.3544
3	.3366	.3506	.3681	.3189	.3506		.3506
4	.4031	.4207	.4733	.3681	.4075		.4557
5	.4908	.6135	.5784	.5258	.6068		.6661
6	.6935	.823	.7888	.8149	.6882		.7455
7	.6661	.7545	.7628	.7975			.7282
8	.5258	.6516	.6135	.631			.5609
9	.4031	.5552	.7011	.5434			.5258
10	.3544	.5258	.4382	.4801			.5609
11	.3772	.4031	.3641	.3772		.362	.4382
12	.3506	.3856	.3294	.3155	.4031	.381	.4557
13	.3601	.333	.3681		.3856	.381	.3856
14	.3429	.3856	.3121	.3506		.4191	.3856
15	.3544	.4031	.333	.3772	.3681	.4572	.5258
16	.4239	.3856	.3641	.3681	.3681	.5144	.4733
17	.4409	.4207	.4382	.3506		.3963	.4207
18	.5426	.4908	.4207	.3856		.381	.5784
19	.6859	.8413	.6935	.6173		.6642	.7362
20	.6001	.631	.6935	.7011		.7362	.7186
21	.5083	.5258	.5258	.6024		.5548	.5609
22	.4344	.5083	.4382	.5068		.4908	.5083
23	.362	.4031	.3641	.4119		.3856	.4031
24	.3155	.3155	.3506	.333	.3292		.3506
Max	.6935	.8413	.7888	.8149	.6882	.7362	.7455
Min	.298	.3155	.3121	.3012	.3155	.362	.3506
Avg	.4403	.4899	.4737	.4701	.4126	.4710	.5100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184046 / 33/11 KV JAIKHEDA

Feeder No / Name : 209 / JAIPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.3361	.373	.4694	.5258		.3018
2	.415	.3361	.373	.5304	.5144		.3018
3	.415	.3734	.4239	.547	.6661		.3018
4	.4527		.4748	.5735	.7956		.3018
5	.4854	.4458	.5596	.6882	.9945		.3395
6			.779	.8907	1.2929		.3772
7		.3142	1.5769	1.7924			
8		.3142	1.5402	1.8027			
9	.3142	.3395		.3018			.3961
10	.2801	.2829	.2452	.2241			.3395
11	.503	.4858	.1698	.2241		.8573	.4024
12	1.1317	1.065	.1132	.1307	.132	1.0631	1.085
13	1.1603	.9614	.132	.112	.132	1.0867	1.0242
14	1.1142	.8139	.132	.1307		1.2193	.7274
15	.852	.8215	.1698	.1494	.132	1.2193	.7116
16	1.0682	.8718	.1698	.1494	.1698	1.1568	8.2579
17	1.3108	1.2574	.2263	.168		1.3032	1.012
18	1.2289	1.1736		.2218		1.3889	1.0437
19	.499					1.1317	
20	.4805	.4527	.3921	.4755		.4527	.415
21	.3734	.3395	.3944	.5041		.415	.3772
22	.3511	.3395	.3395	.462		.3772	.3772
23	.3734	.3521	.3688	.4031		.3961	.3772
24	.3584	.3921	.4287	.4359	.4458		.3395
Max	1.3108	1.2574	1.5769	1.8027	1.2929	1.3889	8.2579
Min	.2801	.2829	.1132	.112	.132	.3772	.3018
Avg	.6459	.5747	.4468	.4951	.5274	.9283	.8957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184093 / 33/11 KV TEMBHE

Feeder No / Name : 205 / TALWADE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8154	.8154	.3582	.3582	.3353	.3125	.7621
2	.8307	.823	.3734	.3658	.3582	.3353	.7697
3	.8459	.8459	.4191	.3963	.3734	.3582	.7926
4	.8459	.8993	.4344	.4191	.4039	.3887	.8307
5	.9145	.9526	.442	.4725	.4496	.4344	.8612
6	1.0517	1.105	.4572	.4877	.4801	.4496	1.0212
7	1.7452	1.7147					1.5699
8	2.1186	2.0119					1.547
9	1.8976	1.8671		.0152	.0152	.0076	1.5775
10	.1753	.1981	.2667	.2667	.282	.221	.1372
11	.16	.1981	.221	.221	.221	.2743	.1372
12	.1219	.16	1.5394	1.387	1.4708	1.4251	.1372
13	.1372	.1372	1.6232	1.5165	1.3336	1.3489	.1372
14	.1372	.1296	1.4251	1.2803	1.4327	1.2117	.1372
15	.1372	.1296	1.3565	1.2193	1.2955	1.0898	.1448
16	.1296	.1448	1.326	1.2651	1.326	1.2651	.1753
17	.1524	.16	1.4784	1.6156	1.5318	1.5318	.1981
18	.1829	.1829	1.4937	1.7985	1.5851	1.4327	.2134
19	.3125	.2972	1.6309	1.7833	1.5165	1.3108	.282
20	.3963	.4268	.381	.3582	.4039	.3734	.4039
21	.3277	.3734	.381	.3887	.381	.3353	.3353
22	.3277	.3506	.3658	.3582	.3734	.3353	.3125
23	.2743	.3353	.3506	.3353	.3429	.3125	.2743
24	.7926	.3429	.3353	.3277	.3125	.7392	.9374
Max	2.1186	2.0119	1.6309	1.7985	1.5851	1.5318	1.5775
Min	.1219	.1296	.221	.0152	.0152	.0076	.1372
Avg	.6179	.6084	.7933	.7562	.7375	.7042	.5706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184099 / 33/11 KV ASKHEDA

Feeder No / Name : 201 / ASKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1305	1.0552			.6218		
2	1.1305	1.0552		.603	.6218		1.2436
3	1.1682	1.0552	.8102	.603	.6406		1.3943
4	1.3001	1.1682		.6783	.6972		1.5451
5	1.4132	1.319		.7514	.7914		1.6958
6	1.8277	1.6581	.9986	.9044	.9233		1.8654
7	2.0538	2.1857	1.0175	1.0175	1.0552		2.2422
8	2.2422		.8668	.8668	.8102		2.5626
9	.6972		.6406	.6406			.603
10	.4334	.5653		.4899			
11	.3015		1.1305	1.3755		.3391	.4145
12	.2638	.3957	2.2234	1.9596		.3203	.3392
13	.2826		2.1857	1.9785		.2638	.3392
14	.3015		1.8466	2.035		.3015	.3392
15	.3015	.3203	1.6204	2.0538		.3203	.3392
16	.3015		1.7335	2.0727		.0188	.3392
17	.3015	.3203	1.9596	2.0161		.3392	.3768
18	.5276		1.8034	1.9219		.5087	.4899
19	.8668			.8102		.9421	.8668
20	.9044		.9421	.9986		.7725	.958
21	.7537		.6783	.8291		.716	.7537
22	.603		.6406	.7537		.6406	
23	.9044		.5653	.6406			.9421
24		1.0175	.6406	.6218		.9421	1.0929
Max	2.2422	2.1857	2.2234	2.0727	1.0552	.9421	2.5626
Min	.2638	.3203	.5653	.4899	.6218	.0188	.3392
Avg	.8700	1.0096	1.2391	1.1575	.7702	.4942	.9877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184099 / 33/11 KV ASKHEDA

Feeder No / Name : 202 / GORANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0332	.9768		.8291	.526		1.0929
2	1.0332	.9768		.8291	.526		1.3001
3	1.0708	.9768	.9768	.8291	.5448		1.5216
4	1.2398	1.1305		.9017	.6575		1.7282
5	1.484	1.2813		.9768	.8453		1.9537
6	2.104	1.677	1.1271	1.2398	1.0144		2.1791
7	2.8366	2.6863	1.0332	1.0332	1.0708		2.5548
8	3.0432		.7702	.8078	.8266		2.9869
9	.1315		.5448	.6387			.1691
10	.2254	.2066		.3945			
11	.1691		.8266	.8453		.263	
12	.2254	.2818	1.747	1.5951			
13	.263		1.6343	1.5216		.2818	
14	.3006		1.5404	1.7282		.2818	.3006
15	.2789	.3381	1.4277	1.841		.3006	.3193
16	.3569		1.7846	1.9349		.3381	.3381
17	.3203	.3569	2.1791	1.9725		.3569	.3569
18	.4508		2.3482	2.2167		.4696	.6011
19	.789			.3945		.6575	.8266
20	.8829		1.0144	.9205		.6951	.9017
21	.7514		.8266	.8078		.7326	.7326
22	.6199		.8641	.6763		.6011	
23	.6387		.8266	.5448			.789
24		.9017	.8641	.526		.7514	
Max	3.0432	2.6863	2.3482	2.2167	1.0708	.7514	2.9869
Min	.1315	.2066	.5448	.3945	.526	.263	.1691
Avg	.8804	.9826	1.2409	1.0835	.7514	.4775	1.1474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184099 / 33/11 KV ASKHEDA

Feeder No / Name : 203 / SHRIPURWADE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0896	1.069	.8192	1.7255	1.5925	.4976	1.0618
2	1.1056	1.0858	.7499	1.7118	1.6748	.5152	1.177
3	1.1784	1.1033	1.5491	1.7796	1.799	.551	1.2968
4	1.2752	1.2611	.8893	2.1768	2.1398	.5998	1.4096
5	1.5123	1.4297	1.0966	2.8822	2.6923	.7583	1.604
6	1.7266	1.7057	3.0118	3.73	4.1817	.9313	1.7832
7	1.5662	1.7065	4.9333	5.5102	5.7495	.7987	1.4579
8	1.1227	.6607	4.6005	5.3618	5.5665	.5914	1.133
9	.8767	.4649	.9569	1.2995	.5746	.3719	.8231
10	.3281	.6054	.4209	.4308	.2195	.2096	.3315
11	2.4487	1.4335	.176	.4433	.1844	2.1566	1.968
12	3.7041	3.8296	.321	.4079	.1936	4.5105	3.9092
13	3.7254	1.9654	.324	.3938	.1631	3.132	3.5722
14	3.2489	1.6164	.3499	.4227	.2401	3.0055	2.857
15	3.6212	2.9462	.3614	.4445	.2294	3.2663	2.7587
16	4.1945	1.8701	.3728	.4338	.2332	3.841	3.4348
17	4.112	4.0167	.4155	.4548	.2233	4.1974	3.8166
18	4.2165	2.066	.6046	.5383	.3414	4.0617	3.6157
19	1.4636	.8886	.6607	1.1677	.7171	1.3224	1.1532
20	1.3023	.6821	1.2527	1.3027	.7141	1.1185	1.3069
21	1.0286	.5388	.9943	1.0114	.5655	1.0224	1.0919
22	1.0156	.4572	.9226	.9291	.5243	1.0057	1.0141
23	.995	.4611	1.2763	1.1558	.506	.5228	.9905
24	.5373	1.1909	1.293	1.385	.4923	1.0168	.5053
Max	4.2165	4.0167	4.9333	5.5102	5.7495	4.5105	3.9092
Min	.3281	.4572	.176	.3938	.1631	.2096	.3315
Avg	1.9748	1.4606	1.1813	1.5458	1.3133	1.6669	1.8363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184099 / 33/11 KV ASKHEDA

Feeder No / Name : 204 / 11 KV RAJPURPANDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3091	1.4014	.9069	2.1003	2.1188	.6158	1.4892
2	.6699	1.4258	.9137	2.0347	2.0403	.6546	1.6074
3	1.3927	1.4692	2.0014	2.0218	2.0241	.6767	1.7122
4	1.4932	1.6522	.9633	2.1908	2.1464	.7103	1.8472
5	1.7077	1.8629	1.1606	2.5745	2.6854	.9	2.0328
6	2.2293	2.4362	2.7219	3.045	3.2317	1.2422	2.468
7	2.5212	2.5621	4.9745	5.24	5.598	1.323	2.4307
8	2.2314	1.1073	5.0335	5.5382	5.6908	1.1302	2.1497
9	1.7309	.9343	2.8287	3.1839	2.4577	.6927	1.6342
10	1.1441	1.2771	.8433	1.1794	.4969	.4633	.6935
11	1.5603	.695	.6676	.8902	.4412	1.2231	1.7324
12	4.9306	4.6994	.5773	.6772	.3033	4.9174	4.4618
13	4.7254	2.2565	.6018	.6341	.2721	4.1459	3.8554
14	4.0505	1.9349	.5914	.5914	.2904	3.4506	2.7779
15	3.7931	3.3217	.5983	.6071	.3018	3.3359	2.573
16	3.6978	1.6994	.7117	.6563	.3155	3.5523	3.1543
17	4.1354	3.7742	.8077	.788	.3521	3.9599	3.2422
18	4.0596	1.9784	1.1944	1.053	.5037	4.2318	3.543
19	3.0784	1.9037	.9816	1.8497	.9587	2.9936	2.6897
20	2.2114	1.134	2.1075	2.2483	1.1667	2.2605	2.1425
21	1.7126	.8833	1.6725	1.7565	.9838	1.7237	1.7206
22	1.5382	.7255	1.4656	1.3574	.8467	1.5858	.7948
23	1.4229	.6622	1.4809	1.5304	.7407	.7575	1.4813
24	.6775	1.693	1.6905	2.1264	.6638	1.4202	.663
Max	4.9306	4.6994	5.0335	5.5382	5.6908	4.9174	4.4618
Min	.6699	.6622	.5773	.5914	.2721	.4633	.663
Avg	2.4176	1.8121	1.5624	1.9114	1.5263	1.9986	2.2040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184216 / 33/11 KV KARANJAD

Feeder No / Name : 201 / 11 KV JAKHOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7545			
2				.7716			
3				.7716			
4		.3086		.7888			
5			.823	.823			
6				1.0174			
7	.3429	.4115		1.7635			
8	.3391	.3391		1.8519			
9	.2058	.2743		1.2346			
10	.1753	.1753		.2058			.2804
11	.1372						.2126
12	1.7204					1.4746	1.3413
13					.0701	1.4746	1.3413
14						1.1469	1.1869
15							1.2574
16			.0686			1.3108	
17	1.4746					1.4899	1.2717
18	1.4746		.2058	.1417			1.2717
19	1.2289						1.1869
20	.3506		.3429				.4298
21	.3506		.2743				.4298
22			.2743				
23			.2743				
24					.7716		
Max	1.7204	.4115	.823	1.8519	.7716	1.4899	1.3413
Min	.1372	.1753	.0686	.1417	.0701	1.1469	.2126
Avg	.7091	.3018	.3233	.9204	.4209	1.3794	.9282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184216 / 33/11 KV KARANJAD

Feeder No / Name : 202 / 11 KV BHUYANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1886	.1772		
2				.2058	.1772		
3				.2058	.1772		
4		.6554		.2229	.2303		
5				.2572	.2629		
6				.2915	.3155		
7	1.4746	1.3765	.2915	.2743	.2774		
8	1.4575	1.4575		.2401	.208		
9	1.1797	1.1469		.1715			
10	.1772	.2103		.1886			1.1603
11	.1715						.1772
12			1.166			.1372	.1063
13	.12		1.1361		.9556	.1372	.1063
14						.1029	.0886
15							.124
16			.9835			.1029	
17	.12					.1029	.1595
18	.1372						.1595
19	.2572		.8987				.2658
20	.3506		.3052				.3582
21	.3506	.2572	.2401				.3224
22		.2401	.2401				
23			.2401				
24					.1772		
Max	1.4746	1.4575	1.166	.2915	.9556	.1372	1.1603
Min	.12	.2103	.2401	.1715	.1772	.1029	.0886
Avg	.5269	.7634	.6113	.2246	.2959	.1166	.2753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184216 / 33/11 KV KARANJAD

Feeder No / Name : 203 / 11 KV PARNER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3772	.3898		
2				.3772	.3898		
3				.4287	.3898		
4		1.4746		.4801	.4252		
5				.6173	.4908		
6				.6516	.5609		
7	3.1131	2.915		.5487	.6068		
8	3.0769	2.9959		.2229	.4854		
9	2.2939	2.3758		.2572			
10	.3506	.3506		.2401			2.2377
11	.2058	.2401					
12	.1372	.2058				.1715	.1417
13	.12					.1715	.1417
14						.1372	.1063
15							.2126
16						.1372	.2481
17	.1715		2.4417			.1715	.2481
18	.2058		2.4756				.2481
19	.3772	.4115	2.1704				.443
20	.5201	.5487					.6268
21	.5201		.4458				.6089
22		.4801	.4287				
23		.4458	.4115				
24			.3772		.4075		
Max	3.1131	2.9959	2.4756	.6516	.6068	.1715	2.2377
Min	.12	.2058	.3772	.2229	.3898	.1372	.1063
Avg	.9244	1.1313	1.2501	.4201	.4607	.1578	.4785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184216 / 33/11 KV KARANJAD

Feeder No / Name : 204 / 11 KV PINGALWADE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.823	.7716		
2				.8573	.823		
3				.8817	.9431		
4		.5144	.7202	.8987	1.1022		
5			.7716	.9835	1.3226		
6				1.3226	1.6766		
7	.6001	.5935		2.0348	2.2634		
8	.5087	.5087		2.2462	2.3205		
9	.3772	.4287		1.7318			
10	.1715	.3506		.3772			.5258
11	.1715						.3544
12	1.5565					1.5565	1.5581
13	1.4746				.1753	1.4746	1.3748
14						1.2289	1.2717
15			.2058				1.2574
16			.2058			1.3765	
17	1.8842					1.8623	1.8442
18	1.8842		.3086				1.8442
19	1.5565		.5144				1.5261
20	.5201		.583				.6268
21	.5201		.4458				.5731
23			.4287				
24			.823		.8573		
Max	1.8842	.5935	.823	2.2462	2.3205	1.8623	1.8442
Min	.1715	.3506	.2058	.3772	.1753	1.2289	.3544
Avg	.9354	.4792	.5007	1.2157	1.2256	1.4998	1.1597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184261 / 33 /11 KV MULHER

Feeder No / Name : 201 / ANTAPUR G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241		.2315	.2054	.208	.2107	
2	.2241		.2286	.2054	.208	.2107	
3	.2187		.2439	.2054	.2027	.2229	
4	.2606		.2526	.2347	.2027		
5	.2606		.2643	.2401	.2534		
6	.3368		.3109	.3239	.3144		
7	.3829		.3481	.3467	.3414		
8	.3227		.3144	.2858	.2934		
9	.3125	.3551	.3521	.2812			.2942
10		.3898	.3189	.394			.394
11		.3258	.3224	.3582	.3898		.3258
12		.2785	.2294	.2469	.2753		.2743
13		.2458	.218	.2458			.2743
14		.2204	.2374	.2321			.2187
15		.2374	.2294	.2321			.2187
16		.2347	.2347	.2294	.2458		.2214
17		.2743	.2804	.2743			.2785
18		.3121	.2713	.298			.2572
19		.2984	.3018	.3222			.2812
20		.4075	.3772	.3856			.4207
21		.3982	.3772	.3429			.4298
22		.4119	.3521	.3185			.4298
23		.3467	.3018	.285			.3601
24	.25	.3293	.2343	.2134	.2378		
Max	.3829	.4119	.3772	.394	.3898	.2229	.4298
Min	.2187	.2204	.218	.2054	.2027	.2107	.2187
Avg	.2793	.3166	.2847	.2795	.2644	.2148	.3119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184261 / 33 /11 KV MULHER

Feeder No / Name : 202 / ALIYABAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886		1.3279	1.6712	1.6712	1.6057	
2	.1886		1.3279	1.6712	1.6712	1.6057	
3	.1886	.1381	1.3279	1.6712	1.6712	1.6385	.2039
4			1.3927	1.6712	1.6712		
5			1.3927	1.8023	1.8233		
6			2.3594	2.2542	2.0119		
7			2.7846	2.7515	2.9843		
8			2.3594	2.7183	2.8837		
9			1.9109	2.0729			
12		2.9843					3.5269
13		2.7831					3.0849
14		2.2119					2.7831
15		2.1548					2.5819
16		2.4366					2.5194
17		2.2874					2.7496
18		2.1216					2.649
19		1.8399	.181	.1867			1.722
20		.197	.1991	.2241			.2149
21		.197	.1991	.197			.2126
22		.2172	.181	.1848			.2126
23		.2218	.181	.1867			.1991
24	.1886		1.4089	1.6907	1.6712		
Max	.1886	2.9843	2.7846	2.7515	2.9843	1.6385	3.5269
Min	.1886	.1381	.181	.1848	1.6712	1.6057	.1991
Avg	.1886	1.5224	1.2356	1.3969	2.0066	1.6166	1.7431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184261 / 33 /11 KV MULHER

Feeder No / Name : 203 / MOHLANGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.854	.4397	2.7374	3.3722	3.3562	3.3971	.4214
2	.8524	.4359	2.7306	3.4537	3.3798	3.3377	.4184
3	.8479	.8443	2.7207	3.4385	3.3562	3.2552	.7698
4	.3018	.4428	2.7827	3.504	3.421	1.8084	.3986
5		.4359	3.0245	3.6294	3.6268	1.8442	.3978
6		.4252	3.9472	3.9788	4.1906	1.9852	.4062
7		.3559	5.2246	6.0479	6.1225	2.6231	.3528
8			5.627	6.3877	6.1317		
9			4.8379	5.5114	3.2236		
10			1.4678	1.653	1.6674		
12	2.7854	5.8966					6.8382
13	3.6923	6.0886					7.3153
14	3.421	5.2934					6.5825
15	2.9599	4.682					5.6729
16	2.8387	5.1973					5.3208
17	2.79	5.5304					5.4839
18	2.9866	5.4492					5.2237
19	2.982	4.6138	.3186	.317	.0655	.2599	4.8948
20	1.8823	2.2992	.8432	.8322	.3955	.4321	2.0431
21	.4633	.8433	.9107	.8676	.4306	.455	.9385
22	.4793	.868	.913	.8559	.4435	.4664	.9381
23	.4771	.8711	.9069	.849	.4451	.4618	.932
24	.8806	3.8637	2.9039	2.9944	3.2601	.4443	.4565
Max	3.6923	6.0886	5.627	6.3877	6.1317	3.3971	7.3153
Min	.3018	.3559	.3186	.317	.0655	.2599	.3528
Avg	1.8526	2.7438	2.6185	2.9808	2.7198	1.5977	2.7903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184261 / 33 /11 KV MULHER

Feeder No / Name : 205 / ALIYABAD GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829		.1829	.181	.1791	.2054	
2	.1829		.1791	.181	.1791	.2054	
3	.1829		.1791	.1867	.181	.2033	
4	.1829		.2218	.181	.181		
5	.2241		.2218	.2172	.2195		
6	.2801		.2987	.2414	.2743		
7	.2801		.3395	.3174	.2641		
8	.2263	.211	.2427	.2614	.2241		
9	.1848	.1886	.1663	.3361			.1701
10		.1227	.1372	.1214			.1063
11		.1267	.112	.1052	.1086		.104
12		.0886	.0876	.1086	.0934		.0905
13		.0829	.081	.1052			.0876
14		.0914	.3401	.1086			.0895
15		.0943	.0934	.1086			.0895
16		.1075	.0724	.1097	.0848		
17		.1715	.1294	.1052			.1357
18		.1753	.156	.1341			.1715
19		.3012	.2149	.2303			.2172
20		.2507	.2328	.2328			.2534
21		.2353	.2303	.2328			.2172
22		.2149	.2126	.1949			.2172
23		.1174	.1928	.1753			.2033
24	.1791		.1829	.181	.1791		
Max	.2801	.3012	.3401	.3361	.2743	.2054	.2534
Min	.1791	.0829	.0724	.1052	.0848	.2033	.0876
Avg	.2106	.1613	.1878	.1815	.1807	.2047	.1538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184261 / 33 /11 KV MULHER

Feeder No / Name : 206 / MOHLANGI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132		.1132	.112	.1132	.112	
2	.1132		.1132	.112	.1132	.1132	
3	.1132		.1698	.112	.1132	.0943	
4	.1132		.1132	.112	.1132		
5	.1509		.1698	.1494	.1509		
6	.2075		.2075	.2241	.2263		
7	.2452		.2641	.2427	.2263		
8	.1867	.1699	.132	.1307	.1494		
9	.0924	.1318	.0943	.1097			.085
10		.0914	.0709	.0709			.0709
11		.1267	.0633	.0532	.0747		.0724
12		.0716	.0747	.056	.0747		.0747
13		.0701	.0747	.056			.0747
14		.0701	.0709	.056			.0747
15		.0739	.0747	.056			.0747
16		.0716	.0686	.0549	.0732		.0724
17		.0857	.0671	.0671			.0724
18		.0895	.0983	.0937			.0686
19		.1928	.1543	.1595			.124
20		.197	.181	.1991			.2172
21		.1848	.1463	.181			.1463
22		.1494	.1294	.1494			.1478
23		.1307	.1294	.1307			.1307
24	.1132		.1132	.112	.1132		
Max	.2452	.197	.2641	.2427	.2263	.1132	.2172
Min	.0924	.0701	.0633	.0532	.0732	.0943	.0686
Avg	.1449	.1192	.1206	.1167	.1285	.1065	.1004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184261 / 33 /11 KV MULHER

Feeder No / Name : 207 / WAGHAMBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694		.3048	.381	.4191	.3429	
2	.4694		.3048	.0381	.4191	.3429	
3	.4694		.3048	.381	.4191	.3429	
4	.4694						
5	.4694						
6	.9175						
8	.7373	.6401					
9	.4915	.4268					.5335
12				.663	.6962		
13			.663	.5571			
14			.5535	.5121			
15			.4843	.4687			
16			.502	.4843	.506		
17			.6062	.5571			
18			.6316	.6062			
19		.3429	.5761	.4801			.2667
20		.3429	.381	.381			.3429
21		.3429	.4001	.381			.381
22		.362	.4001	.4191			.4001
23		.3429	.4001	.4191			.3429
24	.4359		.3239	.362	.4191		
Max	.9175	.6401	.663	.663	.6962	.3429	.5335
Min	.4359	.3429	.3048	.0381	.4191	.3429	.2667
Avg	.5477	.4001	.4558	.4432	.4798	.3429	.3779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

NAMPUR[260]

BU 5436

Substation No/ Name :- 184261 / 33 /11 KV MULHER

Feeder No / Name : 208 / MORANE DIGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9568		.1334	.0857	.0894	.1334	
2	.9568		.1334	.0857	.0766	.1334	
3	.9568		.1334	.0857	.0894	.1334	
4	.9568						
5	1.0185						
6	1.2176						
7	1.7976				.0894		
8	1.749	1.3717					
9	1.6194	1.2929					1.326
12			1.9271	1.9109	1.6484		
13			1.917	1.8785			
14			1.6288	1.6964			
15			1.6356	1.5813			
16			1.5813	1.5813	1.4723		
17			1.6164	1.5497			
18			1.6324	1.5181			
19		.1334	1.3748	1.0974			.0857
20		.096	.076	.1021			.096
21		.0869	.0774	.1021			.0838
22		.0854	.0774	.1021			.0869
23		.076	.0774	.0894			.08
24	.9259		.0774	.0057	.0894		
Max	1.7976	1.3717	1.9271	1.9109	1.6484	.1334	1.326
Min	.9259	.076	.076	.0057	.0766	.1334	.08
Avg	1.2155	.4489	.8812	.8420	.5078	.1334	.2931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184014 / LAKHMAPUR

Feeder No / Name : 201 / BRAMHANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7716			
2		.5335			
5		.8669		.4115	
6		.9536		.4334	
7		1.7337		.3641	
8	1.7269	1.647	.3086	.3294	
9				.2401	
11				.8573	.2058
13				1.2346	
14			1.2483		
15			1.2483	1.3032	.1715
16			1.283		
17			1.3523	1.3203	.2058
18	.1214		1.1616		
19	.2774		.2947		.2915
20			.3641		
22					.3772
23			.3121		
24		.2743		.2947	
Max	1.7269	1.7337	1.3523	1.3203	.3772
Min	.1214	.2743	.2947	.2401	.1715
Avg	.7086	.9687	.8414	.6789	.2504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184014 / LAKHMAPUR

Feeder No / Name : 202 / RAMWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3294			
5		.4334		.2947	
6		.6068		.3294	
7		1.2483			
8	1.1736	1.2136	.2743	.2401	
9		.0206		.1886	
11				.4287	.1029
12		.0514			
13				.7716	
14			.7802		
15			.7282	.7545	
16			.8669		
17			.9362	.7545	.12
18	.1387		.7628		
19	.2572		.2427		.2743
20			.2947		
22					.2743
23			.2774		
24		.3258		.2601	
Max	1.1736	1.2483	.9362	.7716	.2743
Min	.1387	.0206	.2427	.1886	.1029
Avg	.5232	.5287	.5737	.4469	.1929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184014 / LAKHMAPUR

Feeder No / Name : 203 / DHANDARI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743				
3					1.3032	
5		.3467		1.0402		
6		.3467	1.6975	1.286	1.6289	
7		.3467	2.1262	1.387	1.9033	
8	.2035	.3467	2.2119	2.3405	2.0576	
9		.0857		.2058		
11				.1372		
12	1.6991	1.9719				
13	1.647			.1029		
14			.0693			
15			.0693	.0686		
16			.0867			
17	1.4737			.0686		
18	1.4737					
19	.208		.0867	.2058		.2572
20			.2947			
23			1.0402			
24		.2774		1.0402	1.1145	
Max	1.6991	1.9719	2.2119	2.3405	2.0576	.2572
Min	.2035	.0857	.0693	.0686	1.1145	.2572
Avg	1.1175	.4995	.8536	.7166	1.6015	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184014 / LAKHMAPUR

Feeder No / Name : 204 / LAKHAMAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6644	1.7337			
2	1.6817				
3	1.7164				
4	1.9071				
5	2.2885	1.8204			
6	2.4272	1.9719			
7	2.6353	2.6006			
8		2.6006			
9				.1886	
11				1.5432	
13				2.0576	
14			2.1325		
15			1.9938	1.8519	
16			1.9765		
17	.3467		1.9591	1.6461	.1543
18	.3467		1.8378		
19			.2601		.3429
20			.3467		
22					.3429
23			.2774		
24	1.6644	1.7337		.2601	
Max	2.6353	2.6006	2.1325	2.0576	.3429
Min	.3467	1.7337	.2601	.1886	.1543
Avg	1.6678	2.0768	1.3480	1.2579	.2800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184014 / LAKHMAPUR

Feeder No / Name : 206 / LAKHMAPUR G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2202	.4087	.2263	.2294	.2423	.237	.2462
2	.2157	.2126	.2225	.2256	.2431	.2393	.2462
3	.2164	.2103	.2279	.2195	.2393	.237	.2385
4	.2164	.2134	.2279	.2172	.2401	.2431	.2385
5	.234	.4404	.2324	.4338	.2553	.2606	.253
6	.2843	.5632	.2926	.5596	.2949	.3117	.3071
7	.2987	.2904	.3033	.3086	.3025	.3208	.3246
8	.455	.5163	.5205	.5007	.2835	.253	.2873
9	.2629	.3841	.2561	.4337	.2446	.2606	.2515
10	.2583	.2652	.2263	.2568	.2568	.2568	.2942
11	.2423	.2644	.3254	.3818	.2477	.2553	.4161
12	.234	.2241	.2454	.2347	.2454	.2423	.2637
13	.358	.1928	.2187	.3673	.2446	.2309	.2454
14	.2195	.2134	.4157	.2378	.2324	.2515	.2591
15	.2347	.2294	.4488	.3681	.234	.2545	.4039
16	.2309	.2286	.4519	.2431	.2401	.2751	.2804
17	.4822	.237	.4769	.394	.2591	.282	.407
18	.4889	.253	.2545	.2492	.2408	.2759	.2759
19	.4325	.285	.5556	.1265	.2431	.3147	.4965
20	.3429	.2942	.6056	.3658	.333	.3574	.3521
21	.3071	.3003	.3064	.314	.3163	.3384	.3353
22	.2942	.2949	.3071	.3041	.2964	.3147	.4492
23	.2622	.2827	.4953	.2911	.2873	.2911	.2789
24	.2332	.4096	.2477	.4483	.2462	.2545	.253
Max	.4889	.5632	.6056	.5596	.333	.3574	.4965
Min	.2157	.1928	.2187	.1265	.2324	.2309	.2385
Avg	.2927	.3006	.3371	.3213	.2612	.2733	.3085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184014 / LAKHMAPUR

Feeder No / Name : 208 / DHANDRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.052			
5		.0693		.0693	
6		.0693		.0693	
7		.0693		.0693	
8	.0678	.0693	.0514	.0693	
9				.0343	
11				.0343	.0343
12	.052				
13	.052			.0343	
14			.052		
15			.0347	.0343	.0343
16			.0347		
17	.052		.0347	.0343	.0343
18	.052		.0693		
19	.052		.0693		.0686
20			.0693		
22					.2743
23			.052		
24		.0514		.052	
Max	.0678	.0693	.0693	.0693	.2743
Min	.052	.0514	.0347	.0343	.0343
Avg	.0546	.0634	.0519	.0501	.0892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184014 / LAKHMAPUR

Feeder No / Name : 209 / YASHVANT NAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1734			
5		.1734		.3294	
6		.208		.6241	
7		.1907		1.0402	
8	.0838	.1387	1.0288	1.1789	
9				.0857	
11				.0686	.3429
12	.8669	.7888			
13	.6935			.0514	
14			.0693		
15			.052	.0514	.7202
16			.052		
17	1.387			.0343	.703
18	.7802		.0693		
19	.104		.0693		.1372
20			.156		
22					.1372
23			.1734		
24		.0686		.2254	
Max	1.387	.7888	1.0288	1.1789	.7202
Min	.0838	.0686	.052	.0343	.1372
Avg	.6526	.2488	.2088	.3689	.4081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184019 / DANGSOUNDANE

Feeder No / Name : 201 / DANG SAUNDANE AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	10-APR-17	11-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1848		.7888
2	.1867		.8322
3	.2241		.8478
4	.2241		.8916
5	.2427		.9362
6	.2641		1.1963
7	.2263		1.5947
8	.1905		1.7375
9	.1848		.1463
10		.1463	
11		.1075	
12		.1143	
13		.0686	
14		.0686	
15		.0663	
16		.0686	
17		.0953	
18		.0895	
19		.2033	
20		.2241	
21		.2241	
22		.2054	
23		.7545	
24	.1867		.7628
Max	.2641	.7545	1.7375
Min	.1848	.0663	.1463
Avg	.2115	.1740	.9734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184019 / DANGSOUNDANE

Feeder No / Name : 202 / NIKWEL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4191		.8322
2	.4572		.8402
3	.4763		.8573
4			.8817
5			.8962
6	.5525		1.0517
7	.4954		1.6842
8	.4572		.1524
9	.362		
10		.1524	
11		.1143	
12		.1524	
13		.1524	
14		.1524	
15		.1524	
16		.1524	
17		.1524	
18		.1143	
19		.4954	
20		.4954	
21		.4572	
22		.4572	
23		.5898	
24	.4572		.8322
Max	.5525	.5898	1.6842
Min	.362	.1143	.1524
Avg	.4596	.2707	.8920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184019 / DANGSOUNDANE

Feeder No / Name : 203 / SAKODE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.9709		.2096
2	.6283		.2096
3	.9431		.2096
4	.9835		.2477
5	1.1271		.2477
6	1.2548		.3018
7	1.595		.2452
8			.2286
9	.0762		.1886
10		.1143	
11		1.2346	
12		1.8378	
13		1.5912	
14		1.5432	
15		1.5089	
16		1.8107	
17		1.8861	
18		1.6118	
19		.1509	
20		.208	
21		.2286	
22		.2263	
23		.2286	
24	.9431		.2096
Max	1.595	1.8861	.3018
Min	.0762	.1143	.1886
Avg	.9469	1.0129	.2298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184019 / DANGSOUNDANE

Feeder No / Name : 204 / BUNDHATE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.4572
2			.4572
3			.4954
4			.0381
5			.5906
6	1.3203		.6859
7	1.7661		.6097
8	1.6804		.4191
9	.2641		.3048
10		.2263	
11		.8482	
12		1.647	
13		1.7804	
14		1.5261	
15		1.6004	
16		1.4575	
17		1.491	
18		1.4752	
19		.4191	
20		.6097	
21		.4954	
22		.5144	
23		.4572	
24			.4572
Max	1.7661	1.7804	.6859
Min	.2641	.2263	.0381
Avg	1.2577	1.0391	.4515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184019 / DANGSOUNDANE

Feeder No / Name : 205 / DANG SAUNDANE GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.1307		.1075
2	.1307		.124
3	.1307		.1214
4	.1494		.1214
5	.1372		.156
6	.1698		.1718
7	.1543		.208
8	.1107		.1734
9	.1334		.1509
10		.1063	
11		.1132	
12		.0943	
13		.1132	
14		.0754	
15		.0754	
16		.1132	
17		.1886	
18		.1886	
19		.1698	
20		.2075	
21		.1698	
22		.132	
23		.1132	
24	.1132		.1097
Max	.1698	.2075	.208
Min	.1107	.0754	.1075
Avg	.1360	.1329	.1444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184019 / DANGSOUNDANE

Feeder No / Name : 206 / KANHDANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.78
2			.8478
3			.8718
4			.9496
5			.7362
6	.5716		.9816
7	.5281		1.4529
8	.4527		1.5074
9	.3048		.2286
10		.1524	
11		.1143	
12		.0762	
13		.0762	
14		.0762	
15		.1143	
16		.1143	
17		.0754	
18		.2286	
19		.381	
20		.1905	
21		.2263	
22		.1509	
23		.4359	
24			.6706
Max	.5716	.4359	1.5074
Min	.3048	.0754	.2286
Avg	.4643	.1723	.9027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184037 / VIRGAON

Feeder No / Name : 201 / DASANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3048	.2759	.2256		
2			.3125	.2766	.2263		
3			.3147	.2606	.221		
4			.3132	.2637	.2241		
5			.3269	.2644	.2568		
6			.3429	.2942	.2964		
7			.4938	.4466	1.43		
8			.644	.6348	1.7992		
9			.6737	.6531	.6325		
10			.3384	.3178	.3231		
11							.7545
12	.6897	2.0261				.5906	1.5844
13	.775	.6897				.6767	1.5825
14	.7362	.6813				.6584	1.5704
15	.6813	.6158				.5495	1.6358
16	.6752	.5998				.5617	1.8145
17	.7621	1.6705				.5876	1.7699
18	.8215	.6104				.6485	1.7852
19	.6683	.6249				.6081	.631
20	.3086	.3048				.2728	.346
24		.2713	.7843	.2088	.5087		
Max	.8215	2.0261	.7843	.6531	1.7992	.6767	1.8145
Min	.3086	.2713	.3048	.2088	.221	.2728	.346
Avg	.6798	.8095	.4408	.3542	.5585	.5727	1.3474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184037 / VIRGAON

Feeder No / Name : 202 / KERSANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2202	.2286	.397	.3536	.4176	.2164	.2088
2	.2256	.2248	.3826	.4512	.4778	.2157	.2073
3	.2218	.2225	.3986	.5053	.4832	.2187	.2241
4	.2774	.2553	.4085	.5228	.4748	.2553	.2462
5	.3269	.2888	.4633	.5647	.6005	.2957	.2919
6	.3536	.3536	.6607	.7583	.7263	.3361	.346
7	.3551	.3429	1.1919	1.2612	2.7282		.3597
8	1.794	.282	1.7482	1.7985	3.3547	.2972	.2126
9	.2583	.2134	1.7101	1.6994	1.9121	.2683	.2522
10	.1875	.1951	.7979	.9589	.8764	.2027	.4237
11	.1357	.1349	.0419	.5115	.0511	.0633	.7773
12	1.3893	2.4673	.0427	.9299	.0495	1.3435	2.4009
13	1.5943	1.5386	.0213	.9077	.0663	1.672	2.7646
14	1.6911	1.4716	.0099	1.0261	.0823	1.595	2.6437
15	1.4159	1.1873		1.0738	.0724	1.4502	2.3398
16	1.422	1.1439		1.1683	.0854	1.342	2.3098
17	1.544	2.369	.0358	.0861	.0884	1.4068	2.469
18	1.5447	1.2872	.1052	.0968	.1036	1.3618	2.463
19	1.4609	1.5338	.1859	.1501	.1402	1.2818	1.6107
20	.6386	.5594	.3307	.317	.3048	.6661	.6401
21	.2964	.3048	.2995	.2934	.2904	.3201	.3094
22	.2484	.2241	.2126	.2271	.2492	.2454	.2362
23	.2408	.2073	.1966	.2126	.2477	.2439	.2271
24	.9885	.362	.8493	.3963	1.579	.2256	.2294
Max	1.794	2.4673	1.7482	1.7985	3.3547	1.672	2.7646
Min	.1357	.1349	.0099	.0861	.0495	.0633	.2073
Avg	.7846	.7249	.4768	.6779	.6442	.6749	1.0081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184037 / VIRGAON

Feeder No / Name : 203 / VATAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2385	.2401	.7712	.8375	.8589	.2393	.2515
2	.2439	.2446	.7682	.8368	.8733	.2462	.2561
3	.2507	.2462	.8093	.8993	.9175	.25	.2637
4	.2614	.25	.8238	1.0227	.9762	.2423	.2637
5	.2667	.2538	.9762	1.1812	1.1736	.2469	.2614
6	.2446	.2591	1.5714	1.6964	1.7383	.2355	.2561
7	.176	.1768	1.9265	2.3373	4.1752	.1936	.205
8	.3041	.1539	2.0538	2.4066	4.1278	.1821	.1638
9	.1288	.1311	1.2254	1.2551	1.2041	.1242	.1196
10	.0991	.0998	.0991	.1944	.0945	.0884	.1623
11	1.5303	1.6987	.0907	.1026	.0815	1.6057	.6783
12	1.9357	3.7199	.0648	.0822	.0297	2.0157	3.1298
13	1.9212	1.7993		.1005	.0579	1.9105	3.4857
14	1.6773	1.5722	.0015	.0861	.0389	1.4716	2.9622
15	1.6408	1.4861	.0053	.0914	.013	1.7284	3.2705
16	1.7955	1.7193	.0091	.0945	.0206	1.7596	3.5468
17	1.9151	3.3499	.0053	.0099	.0488	1.9898	3.5238
18	1.8861	1.7299	.0968	.0899	.1166	1.9143	3.2469
19	1.0524	1.1512	.1959	.1852	.2073	1.1035	1.2536
20	.2324	.1722	.1974	.1928	.2134	.2492	.2324
21	.2423	.1814	.1722	.1677	.2423	.2622	.2507
22	.2614	.1776	.1745	.1738	.25	.2751	.2599
23	.2545	.7087	.7575	.7895	.2454	.2561	.2568
24	.4709	.7606	1.371	.8711	.9084	.2492	.2484
Max	1.9357	3.7199	2.0538	2.4066	4.1752	2.0157	3.5468
Min	.0991	.0998	.0015	.0099	.013	.0884	.1196
Avg	.7929	.9284	.6160	.6544	.7756	.7850	1.1895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184037 / VIRGAON

Feeder No / Name : 204 / AWATHI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6455	.2888	.2812	.2637	.6386	.6836
2	.6866	.6478	.2911	.285	.2713	.6592	.6927
3	.7301	.6638	.2926	.2911	.2782	.6699	.7034
4	.775	.7415	.2934	.301	.2865	.727	.7354
5	.8505	.8291	.2949	.3132	.3025	.8009	.7987
6	.9534	.964	.2972	.3262	.3056	.9297	.9983
7	1.6118	1.5737	.2835	.2942	.2797	1.3923	1.3344
8	1.8496	1.8595	.2294	.2195	.2241	1.6118	1.8275
9	1.6644	1.6766	.1821	.1882	.1745	1.4563	2.0607
10	.1456	.1555	.16	.1029	.1532	.128	.1593
11	.1318	.1341	.1974	.1707	.2256	.1135	.1296
12	.1082	.1235	1.3801	1.2102	1.323	.1143	.1196
13	.1075	.1181	1.3512	1.1469	1.2536	.0914	.0823
14	.109	.1219	1.2643	1.0052	1.028		.1075
15	.0998	.125	.9777	.916	.8589		.0975
16	.1082	.1105	1.0997	1.0197	.9892		.0983
17	.1105	.1082	.9755	1.1446	1.0479	.0831	.0991
18	.1082	.1158	1.3352	1.1462	1.2087	.1135	.1143
19	.1631	.1799	1.3032	1.3283	1.2986	.1799	.1776
20	.2728	.2774	.2812	.2774	.2675	.2583	.2698
21	.2469	.2774	.2698	.2637	.2583	.2515	.2484
22	.2149	.2843	.2964	.285	.2408	.2225	.2241
23	.2088	.2919	.3018	.2896	.2698	.2462	.2362
24	.644	.2919	.2843	.266	.631	.6805	.6882
Max	1.8496	1.8595	1.3801	1.3283	1.323	1.6118	2.0607
Min	.0998	.1082	.16	.1029	.1532	.0831	.0823
Avg	.5244	.5132	.5805	.5447	.5600	.5414	.5286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184037 / VIRGAON

Feeder No / Name : 205 / VIRGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.1886	
8	.2075				.1879	
10				.1518		.1517
11				.132		.1327
12		.1088		.1328		.1132
13				.1132		.1132
14				.1126		.132
15				.1262		.1327
16				.1509		.1509
17		.1267				.1517
18						.1698
19		.2358				.2467
24	.1708		.1512		.1691	
Max	.2075	.2358	.1512	.1518	.1886	.2467
Min	.1708	.1088	.1512	.1126	.1691	.1132
Avg	.1892	.1571	.1512	.1314	.1819	.1495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184037 / VIRGAON

Feeder No / Name : 206 / Dongreg Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.2801	
8	1.0343				.2263	
10				.2282		.0953
11				.4904		.0762
12		.0951		.8139		.0762
13				.7969		.0762
14				.6952		.0759
15				.6828		.0762
16				.78		.0953
17		.0951				.0953
18						.13
19		.2277				.2641
24	.4715		.2277		.2641	.0953
Max	1.0343	.2277	.2277	.8139	.2801	.2641
Min	.4715	.0951	.2277	.2282	.2263	.0759
Avg	.7529	.1393	.2277	.6411	.2568	.1051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184037 / VIRGAON

Feeder No / Name : 207 / Virgaon Pade

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					1.6575	
8	.2477				1.7804	
10				.0762		.1515
11				.0762		.415
12		1.3375		.0762	.057	1.3489
13				.0762		1.2887
14				.0762		1.0517
15				.0693		.8768
16				.0762		1.2123
17		1.2012				1.1843
18						1.1789
19		.1898				.2286
24	.2286		.3591		.3726	
Max	.2477	1.3375	.3591	.0762	1.7804	1.3489
Min	.2286	.1898	.3591	.0693	.057	.1515
Avg	.2382	.9095	.3591	.0752	.9669	.8937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184071 / JORAN

Feeder No / Name : 201 / JORAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.33	.3315	.8101	.7865	.775	.7948	.5952
2	.3315	.3346	.8772	.8375	.7613	.8177	.6132
3	.3391	.3361	.8947	.8688	.759	.8421	.6337
4	.3406	.3368	.9351	.868	.7926	.8672	.6413
5	.3368	.3391	.9739	.9671	.8612	.964	.3323
6	.077	.061	1.1035	1.1302	1.0684	1.041	.1882
7			1.643	1.8267	1.6156	1.56	
8			2.0439	2.2253	2.1735	2.1353	
9			3.465	2.1315	2.1689	1.8999	
10			.4969	.3864	.3833	.2904	
11							.6935
12	1.8328	1.7101					3.5521
13	1.8313	1.813					3.4955
14	1.9006	1.6507					3.1161
15	1.7848	1.6659					2.8167
16	1.8054	1.7154					3.1724
17	1.8991	1.8168					3.2455
18	1.9616	1.832					1.7878
19	1.9342	1.7863	.1417	.1006		.2854	1.9037
20	.4938	.4649	.2271	.2416	.2309	.551	.6047
21	.3041	.2347	.2241	.2362	.2385	.5693	.5451
22	.3422	.2157	.2073	.2119	.2149	.636	.603
23	.3498	.2058	.1913	.192	.1997	.6459	.6114
24	.6467	.5433	1.4487	1.419	1.4098	.3254	.615
Max	1.9616	1.832	3.465	2.2253	2.1735	2.1353	3.5521
Min	.077	.061	.1417	.1006	.1997	.2854	.1882
Avg	.9917	.9155	.9802	.9018	.9102	.8891	1.4883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184071 / JORAN

Feeder No / Name : 202 / MORKURE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8657	.9358	.7967	.7857	.6848	.3925	.7583
2	.8977	1.0022	.8437	.7872	.6947	.4169	.7811
3	.9183	1.0875	.9183	.8246	.8116	.4603	.8495
4	1.038	1.2544	1.0051	.9561	.8642	.5228	.9732
5	1.1826	1.3396	1.073	1.0745	.9813	.5738	1.1145
6	1.4373	1.6686	1.1759	1.1389	1.0263	.6219	1.5333
7	2.5075	2.3003	.9435	.8535	.8467	.474	2.0851
8	2.8951	2.6351	.6287	.6637	.6276	.3681	2.4211
9	1.4137	1.1679	.586	.5282	.2789	.5175	1.0677
10	.3315	.3506	.3072	.2004	.1928	.3437	.3376
11	.2161	.2503	1.0266	1.0006	.7293	1.0151	.253
12	.1772	.2396	1.1119	1.7814	.9595	1.6377	.2217
13	.2034	.2236	1.0433	1.7753	.9656	1.5592	.1753
14	.2736		1.8884	1.6434	.8566	1.2201	.2576
15	.295	.2136	1.8625	1.3786	1.4846	1.11	.2263
16	.2679	.2752	1.9974	.8474	.9595	1.4663	.2207
17	.2911	.3228	1.9082	.9747	.9724	1.5585	.2537
18	.314	.3815	1.9294	1.8915	.9602	1.6129	.2103
19	.74	.7335	1.8101	.9145	.6546	.849	.3757
20	.9183	.8158	.8741	.6958	.4161	.8269	.7918
21	.793	.841	.836	.7712	.3864	.7426	.7682
22	.7796	.7807	.8387	.8062	.3894	.7324	.7712
23	.5876	.7392	.8131	.794	.3864	.711	.8494
24	.8932	.8524	.7853	.7964	.7727	.346	.6924
Max	2.8951	2.6351	1.9974	1.8915	1.4846	1.6377	2.4211
Min	.1772	.2136	.3072	.2004	.1928	.3437	.1753
Avg	.8432	.8874	1.1251	.9952	.7459	.8366	.7495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184071 / JORAN

Feeder No / Name : 203 / KIKWARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5617	.5799	.4877	.487	.5014	.5182	.9076
2	.6013	.5998	.5213	.4999	.5228	.5533	1.0318
3	.6767	.6379	.5495	.535	.551	.5822	1.1172
4	.756	.6447	.5937	.5677	.5571	.6341	1.2544
5	.8756	.7933	.6805	.6104	.5952	.6996	1.5546
6	1.4053	1.3131	.6821	.5197	.6295	.6927	2.3098
7	2.002	1.6644	.6478	.5136	.5243	.6325	3.2674
8	2.111	1.8808	.5045	.397	.3864	.5045	3.5699
9	1.2818	1.214	.4214	.314	.317	.7575	1.3687
10	.2362	.2698		.2111	.2225	.4954	.3155
11	.1692	.1882	1.2993	1.2628	.9587	1.6217	.2713
12	.1349	.1425	1.6789	1.5104	1.4007	2.4687	.3003
13	.1311	.1379	1.5988	1.5112	1.3824	2.2352	.2499
14	.1257	.144	1.4312	1.2879	1.2856	2.0154	.2484
15	.1425	.1738	1.4632	1.4175	1.2955	2.1506	.3041
16	.1768	.173	1.6103	1.5661	1.4556	2.4677	.3445
17	.2134	.1806	1.5181	1.6232	1.5021	2.8868	.3848
18	.3185	.3041	1.5135	1.4777	1.4594	2.7957	.3094
19	.5914	.6622	1.134	.9061	.9015	1.1614	.6592
20	.6493	.6211	.6401	.6737	.6592	1.2631	1.1138
21	.4946	.519	.5243	.5182	.538	1.0322	1.089
22	.4877	.5258	.5296	.5517	.5464	.9873	1.0913
23	.4908	.5182	.506	.5235	.5426	.9606	1.0852
24	1.0471	.95	.95	.966	1.0089	.4512	.9152
Max	2.111	1.8808	1.6789	1.6232	1.5021	2.8868	3.5699
Min	.1257	.1379	.4214	.2111	.2225	.4512	.2484
Avg	.6534	.6183	.9342	.8521	.8227	1.2737	1.0443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184071 / JORAN

Feeder No / Name : 204 / JORAN GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.052	.0358	.0373	.0526	.0351		.0358
2	.052	.0358	.056	.0343	.0514		.0358
3	.052	.0526	.056	.0526	.0526		.0537
4	.0724	.0732	.056	.0905	.0724		.0709
5	.0905	.0914	.112	.1109	.1109		.0895
6	.1086	.1075	.112	.1063	.1109		.1063
7	.0924						
8		.0724	.056	.0526	.056		.0701
9	.0972		.1063	.1029		.1006	.0914
10	.0995		.0867			.0497	.0446
11	.0526	.0509	.0526	.0503		.0492	.0305
12	.0526	.0509		.0347		.0351	.0354
13	.0492	.0532		.0339		.017	.0175
14	.0328	.0177	.0166	.0373		.017	.0171
15	.0324	.0179	.0171	.017	.0362	.0166	.0173
16	.0324	.0179	.0175	.0168		.0175	.0173
17	.0543	.0537	.0332			.0347	.0532
18	.0724	.0537	.052	.0514		.0526	.0543
19	.1052	.0838	.0905	.0663		.0857	
20	.1052	.0838	.0876	.1052		.104	.1254
21	.0876	.0848	.1052	.1052		.1052	.128
22	.0716	.0503	.1017	.0848		.0914	.1097
23	.0537	.0168	.052	.052		.0543	.0732
24	.056		.0373	.052	.0347		.0373
Max	.1086	.1075	.112	.1109	.1109	.1052	.128
Min	.0324	.0168	.0166	.0168	.0347	.0166	.0171
Avg	.0685	.0552	.0639	.0624	.0622	.0554	.0597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184071 / JORAN

Feeder No / Name : 205 / PATHAVA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.5335	.2949	.3768	.4096		.381
2	.4763	.4954	.3353	.4359	.5087		.3429
3	.4763	.5335	.3315	.4915	.6783		.381
4	.5716	.5716	.3277	.5304	.8478		.4572
5	.6097	.5716	.3315	.6001	1.0174		.4572
6		.5335	.5868	.7449	1.2003		.4191
7		.4191	1.1336	1.5249	1.1603		
8	.3048	.3429	1.7404	1.3413	1.3413		.2286
9	.3048	.3048	1.0395	.2286		.1905	.1905
10	.1905	.1905	.0762			.0762	.0953
11	.1715	.3391	.0762	.1143		.1524	.3239
12	.8817	1.1022		.0953		.1143	1.4419
13	1.3413	1.0774				.1143	1.4582
14	1.1065	.9116	.0762	.0953		.1143	.9945
15	1.0059	.5868	.0762		.1143	.1524	.8192
16	.9221	.7459	.1143			.1524	.9448
17	.9831	1.073	.1143			.1524	.9945
18	1.0311	.9945	.1715	.2286		.2286	
19	.1524	.3429	.2858	.381		.4191	.3734
20	.3429	.5335	.381	.381		.4954	.4763
21	.4382	.5335	.4572	.4763		.4954	.4763
22	.4763	.5335	.4191	.4763		.5335	.4763
23	.4572	.5335	.5335			.5335	.3429
24	.4954	.4954	.2035	.4031	.4915		.381
Max	1.3413	1.1022	1.7404	1.5249	1.3413	.5335	1.4582
Min	.1524	.1905	.0762	.0953	.1143	.0762	.0953
Avg	.6007	.5958	.4139	.4959	.7770	.2616	.5662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184071 / JORAN

Feeder No / Name : 206 / TALWADE DIGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5801	.7042	.6478		.5716		.5658
2	.663	.8048	.6478		.6668		.5144
3	.7459	.9339	.6478		.6668		.6706
4	.8383	1.0814	.6478		.6668		.7865
5	1.0059	1.4413	.6859		.5716		.8848
6	1.1736	1.7604	.5716				1.0623
7	2.0348	2.1247	.6097				1.5242
8	2.4587	2.2405	.4954	.6097	.1905		1.8595
9	.1905	.1562	.4572	.4954		.4572	.3048
10		.1524	.2667			.3048	.1905
11		.1524	.1524	.6882		.503	.1905
12	.1524	.1524		1.9062		1.5939	.1905
13	.1905	.1524		1.8842		1.6575	.1905
14	.1524	.1905	1.7772	1.6766		1.4419	.2286
15	.1905	.1905	1.7368	1.7295	1.56	1.4918	.1905
16	.1905	.2286	1.8442	1.9281		1.6766	.2286
17	.2286	.2667	1.989			1.7974	.2667
18	.2667	.3429	2.0481			1.5074	.3429
19	.6478	.6097	1.8652	.4954		.1905	
20	.5716	.6478	.6097	.5716		.6097	.6668
21	.5716	.6859	.6668	.6668		.5716	.6668
22	.5335	.6859		.6668		.5716	.6668
23	.3429	.5716		.6668		.5716	.5716
24	.6036	.6859	.6478		.5716	.6097	.381
Max	2.4587	2.2405	2.0481	1.9281	1.56	1.7974	1.8595
Min	.1524	.1524	.1524	.4954	.1905	.1905	.1905
Avg	.6515	.7068	.9507	1.0758	.6832	.9723	.5715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184071 / JORAN

Feeder No / Name : 207 / VINCHURE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4748	.1905	.1715	.1524		.3749
2	.4191	.5087	.1905	.1524	.1715		.4359
3	.503	.5533	.1905	.1524	.1905		.4807
4	.5868	.5735	.1905	.1715	.1905		
5	.6783	.6316					.583
6	.7291	.7682					.6325
7	1.1361	1.1683					.9217
8	1.153	1.2186					1.0669
11				.4748		.3749	
12				1.0059		.8642	
13				.9116		.8002	
14			.8642	.8192	.8002	.7499	
15			.9156	.8097	.7865	.7362	
16			1.0159			.8002	
17			1.1191	1.0288		.8886	
18			1.3203	.8288		.8684	
19	.1334	.0953	.8907	.1143		.0762	
20	.1524	.1905	.2096	.1524		.1524	.1334
21	.1524	.1905	.1905	.1905		.1334	.1715
22	.1524	.1905	.1905	.1905		.1334	.1715
23	.2572	.1696	.1905	.1905		.1143	.381
24	.462	.4694	.1905	.1715	.1715	.1905	.1143
Max	1.153	1.2186	1.3203	1.0288	.8002	.8886	1.0669
Min	.1334	.0953	.1905	.1143	.1524	.0762	.1143
Avg	.4953	.5145	.5240	.4433	.3519	.4916	.4556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184098 / AJMERSAUNDANE

Feeder No / Name : 201 / KIRTWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
12	.9088	.7811	.3048
15		.703	
16		.8535	.362
24	.6653		.5792
Max	.9088	.8535	.5792
Min	.6653	.703	.3048
Avg	.7871	.7792	.4153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184098 / AJMERSAUNDANE

Feeder No / Name : 202 / DEVLANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
12	.1334	.132	.8573
15		.132	
16		.132	.6478
24	.5068		.2667
Max	.5068	.132	.8573
Min	.1334	.132	.2667
Avg	.3201	.132	.5906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184098 / AJMERSAUNDANE

Feeder No / Name : 203 / KARHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
12	.9835	.9175	
15		.7362	
16		.8421	.1905
24	.415		.5068
Max	.9835	.9175	.5068
Min	.415	.7362	.1905
Avg	.6993	.8319	.3487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184098 / AJMERSAUNDANE

Feeder No / Name : 204 / Waygaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
12	.0362	.0358	.0377
15		.0351	
16		.0358	.0543
24	.0543		.0377
Max	.0543	.0358	.0543
Min	.0362	.0351	.0377
Avg	.0453	.0356	.0432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184098 / AJMERSAUNDANE

Feeder No / Name : 205 / SURANE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
12	.2286	.1524	.3982
15		.1715	
16		.1715	.3429
24	.2477		.3258
Max	.2477	.1715	.3982
Min	.2286	.1524	.3258
Avg	.2382	.1651	.3556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184098 / AJMERSAUNDANE

Feeder No / Name : 206 / Arai Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
12	1.1012	1.0288	.3048
15		.7194	
16		.8554	.381
24	.5359		.4527
Max	1.1012	1.0288	.4527
Min	.5359	.7194	.3048
Avg	.8186	.8679	.3795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184098 / AJMERSAUNDANE

Feeder No / Name : 207 / Pahadeshwar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
12	.2096	.1475	1.3279
15		.1802	
16		.164	.9686
24	.6733		.5175
Max	.6733	.1802	1.3279
Min	.2096	.1475	.5175
Avg	.4415	.1639	.938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184100 / TATANI

Feeder No / Name : 201 / TATANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3584	
2					.3881	
3					.5068	
4					.5373	
5		.1524			.567	
6					.5552	
7					.5373	
8					.5068	
9					.4435	
11	.3475					
12		.5548				
15				.0762	.0762	
16	.5847					
17				.0953		
18	.5487			.1143		
19	.5228			.1886		
20				.2054		
21				.1698		
22				.1524		
23	.1715			.3584		
24		.1524	.2715		.3734	.1524
Max	.5847	.5548	.2715	.3584	.567	.1524
Min	.1715	.1524	.2715	.0762	.0762	.1524
Avg	.4350	.2865	.2715	.1701	.4409	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184100 / TATANI

Feeder No / Name : 202 / VATHODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4108			.543	
2		.3429			.6379	
3		.381			.6935	
4		.3961			.7888	
5		.4108			.8916	
6					.9259	
7					.9431	
8					.8916	
9					.7783	
11	.4298					
12		.6859				
15				.2286	.2477	
16	.8059					
17	.9156			.2477		
18	.9088			.3239		
19	.9015			.415		
20				.5068		
21	.5121			.4755		
22	.4938			.4435		
23	.462			.4904		
24		.4251	.5373		.5175	.4763
Max	.9156	.6859	.5373	.5068	.9431	.4763
Min	.4298	.3429	.5373	.2286	.2477	.4763
Avg	.6787	.4361	.5373	.3914	.7144	.4763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184100 / TATANI

Feeder No / Name : 203 / MANUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9149		.7621	.724	
2		1.0425			.7392	
3		1.086			.7842	
4		1.1104			.8131	
5		1.1283			.8316	
6		1.134				
7		1.1283				
8		1.086				
9		.8686				
12					.7522	
15	.5716	.5716		.6878		
16	.6668					
17	.724			.7442		
18	.9054			.9088		
19	.9149			.9015		
20				.8962		
21	.743			.924		
22	.7621			.9149		
23	.8002			.7922		
24		.8299	.8573		.7392	.7602
Max	.9149	1.134	.8573	.924	.8316	.7602
Min	.5716	.5716	.8573	.6878	.724	.7602
Avg	.761	.9910	.8573	.8369	.7691	.7602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184234 / NIRPUR

Feeder No / Name : 201 / NIRPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.3239
2							.3563
3							.4096
4							.4588
5							.4858
6							.502
7							.4534
8							.4372
12							1.9376
15							.0754
18							2.2462
22							.3921
24	.3401	.2347	.4049	.6443	.7537	.4858	.3239
Max	.3401	.2347	.4049	.6443	.7537	.4858	2.2462
Min	.3401	.2347	.4049	.6443	.7537	.4858	.0754
Avg	.3401	.2347	.4049	.6443	.7537	.4858	.6463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184234 / NIRPUR

Feeder No / Name : 202 / CHAUNDHANA- II

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.5182
2							.6154
3							.6802
4							.7287
5							.7935
6							.8848
7							1.3923
8							1.3748
12							.0943
15							.0754
18							.132
22							.2263
24	.5243	.2347	.1677	.1696	.1311	.1457	.5182
Max	.5243	.2347	.1677	.1696	.1311	.1457	1.3923
Min	.5243	.2347	.1677	.1696	.1311	.1457	.0754
Avg	.5243	.2347	.1677	.1696	.1311	.1457	.6180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184234 / NIRPUR

Feeder No / Name : 203 / TARSALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.1943
2							.2429
3							.2721
4							.3521
5							.4001
6							.5601
7							1.1717
8							1.1405
12							.0943
15							.1132
18							.132
22							.3206
24	.2622	.2012	.3239	.3052	.2915	.2915	.1619
Max	.2622	.2012	.3239	.3052	.2915	.2915	1.1717
Min	.2622	.2012	.3239	.3052	.2915	.2915	.0943
Avg	.2622	.2012	.3239	.3052	.2915	.2915	.3966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184236 / WASUL

Feeder No / Name : 201 / NATHBABA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6562	.8962	.2829	.3206	.2829		.5281
2	.6562	.8962	.2829	.3206	.3018		.5281
3	.6554	.9061	.2829	.3206	.3395		.5281
4	.7202	.953	.3395	.3395	.3772		.6401
5	.8356	1.1227	.3772	.3961	.415		.7522
6	1.0608	1.2334	.3961	.4382	.4338		1.2003
7	1.2498	1.6164	.3584	.3772	.3961		1.3283
8	1.7185	1.7869	.2641	.2829	.2829		1.4563
9	.1886	.2641		.2075	.1509		.2829
10	.1132	.1698	.2075	.1698			.2743
11	.0754	.1132	.1989	.463			.132
12	.1509	.132	1.3125	1.2803		1.278	.1509
13	.1509	.132	1.4419	1.0848		1.1469	.132
14	.1509	.132	1.3272	1.0105		1.1142	.112
15	.1509	.1132	1.1843	.9267		1.0082	.132
16	.1509	.1509	1.3435	.9783		1.0277	.1494
17	.1698	.132	1.2289			1.2003	.1494
18	.1698	.132	1.2125	1.2037		1.1012	.112
19	.2829	.2641	.2829	.2452		.3961	.2801
20	.415	.3772	.3395	.3395		.3772	.3547
21	.3206	.3395	.2641	.3018		.2641	.3395
22	.3206	.3395	.3206	.3018		.2641	.2614
23	.3206	.6097	.2829	.3018		.2452	.2458
24	.2294	.8642	.2829	.2452	.2829		.1989
Max	1.7185	1.7869	1.4419	1.2803	.4338	1.278	1.4563
Min	.0754	.1132	.1989	.1698	.1509	.2452	.112
Avg	.4547	.5698	.6006	.5155	.3263	.7853	.4279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184236 / WASUL

Feeder No / Name : 202 / VASUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5624	.2667	.3239	.3048		.4588
2	.5601	.5624	.2858	.3239	.3048		.4641
3	.5735	.6405	.2858	.3239	.3429		.4641
4	.5571	.8436	.3429	.3429	.381		.4915
5	.7373	.8749	.381	.4001	.381		.6554
6	.8097	.9374	.362	.362	.4001		.7045
7	1.0802	1.2498	.2477	.2667	.2667		1.0082
8		1.2342	.1524	.1905	.1905		1.0402
9	.0953	.1334	.1524	.1524	.1524		.1143
10	.0953	.1334	.1524	.1143			.1143
11	.0953	.0953	.1638	.3201			.1524
12	.0953	.0953	1.0402	.8802		.852	.1524
13	.0953	.0953	.9602	.8642		.8684	.1143
14	.0762	.0953	.9175	.787		.8192	.1334
15	.0762	.1143	.8356	.7225		.8002	.1334
16	.0953	.1143	.8642	.8179		.9231	.1143
17	.0953	.0953	.9762	.9259		.9831	.0953
18	.1143	.1143	.9831	.8642		.8962	.1143
19	.2096	.1905	.2096	.1905		.2096	.2667
20	.2096	.2858	.2477	.2858		.2286	.3048
21	.2477	.2477	.2477	.2286		.2667	.3048
22	.3048	.3395	.3048	.2858		.2858	.3239
23	.2858		.3239	.3048		.3048	.2401
24	.2241	.5761	.2477	.3048	.3048		.2155
Max	1.0802	1.2498	1.0402	.9259	.4001	.9831	1.0402
Min	.0762	.0953	.1524	.1143	.1524	.2096	.0953
Avg	.3171	.4187	.4563	.4410	.3029	.6198	.3409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184236 / WASUL

Feeder No / Name : 203 / BRAHMANGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3018	.3521	.3647	.3315		.2452
2	.3206	.3018	.3521	.3647	.3647		.2452
3	.3174	.3395	.3795	.3647	.4641		.2452
4	.3395	.5093	.4428	.4096	.4915		.2641
5	.3584	.5093	.4744	.4801	.7373		.3395
6	.3961	.5281	.5121	.7042	.8192		.3584
7	.4527	.5093	.9602	1.1363	1.2597		.415
8	.3772	.3206	1.0279	1.247	1.278		.3018
9	.3018	.2641	.2075	.2829	.2452		.2452
10	.2641	.2263	.2075	.1886			.2263
11	.2829	.2709	.1886	.132			.2229
12	1.1012	1.0669	.1132	.1509		.1509	1.0814
13	1.0279	.9962	.132	.1132		.1698	1.0279
14	.9217	.8179	.1132	.0934		.1698	.9602
15	.9374	.7907	.132	.1307		.1698	.9831
16	.8065	.7522	.1509	.132		.1509	.9602
17	.7343	.7407	.1509	.132		.1698	.9831
18	.7343	.6859	.1509	.132		.1509	.8802
19	.3772	.2829	.3018	.3395		.3018	.3018
20	.415	.3772	.3772			.3206	.3547
21	.3395	.3206	.3018			.3018	.3772
22	.3395	.3206	.2829	.2829		.2829	.3361
23	.3206	.3206	.2058	.2829		.1802	.3018
24	.3584	.3018	.2829	.2818	.3315		.2641
Max	1.1012	1.0669	1.0279	1.247	1.278	.3206	1.0814
Min	.2641	.2263	.1132	.0934	.2452	.1509	.2229
Avg	.5060	.4940	.3250	.3521	.6323	.2099	.4967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184259 / Mahal Patne

Feeder No / Name : 201 / MAHAL PATNE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3387	2.2251	.3109	.33	.3376	.3307	.8749
2	2.2303	2.1558	.3254	.3399	.333	.3452	.8558
3	2.2367	2.1146	.349	.362	.3406	.3765	.8451
4	2.223	2.1426	.3795	.4092	.3818	.4039	.8497
5	2.2455	2.1597	.4275	.4763	.4603	.4816	.9412
6	2.2747	2.3095	.4489	.4862	.5114	.5228	1.1439
7	3.2429	3.2502	.4428	.7887	.4641	.4565	3.1147
8	3.6728	3.503	.3414	.3384	.3391	.3117	1.6552
9	2.0024	1.8118	.2423	.2599	.2553	.2538	1.5493
10	.2785	.1997	.1936	.2103	.269	.2004	.304
11	.2146	.1463	.157	.4542	.6737	.8612	.2425
12	.2105	.1311	1.8023	2.6851	3.0161	1.5607	.1993
13	.2109	.1303	1.8999	1.48	2.7969	1.5745	.1996
14	.2219	.128	1.8336	1.5341	1.4411	1.4548	.1189
15	.2285	.1387	1.6408	1.3847	1.4167	1.3176	.2009
16	.2337	.1402	1.5394	1.3428	1.3778	1.2864	.2163
17	.2048	.1288	1.6575	2.8494	1.4068	1.3481	.2166
18	.2375	.1425	1.701	1.4944	1.4259	1.3588	.2669
19	.4835	.2858	1.6842	1.3649	1.1789	1.3756	.5182
20	.6324	.3711	.3887	.4123	.394	.6988	.6429
21	.5809	.3109	.3231	.3635	.3696	.3536	.5684
22	.5089	.3315	.3285	.3307	.3582	.3262	.5596
23	.8414	.33	.3292	.3582	.3414	.4504	.7788
24	2.2468	1.3325	.3208	.6416	.6019	.8505	.9445
Max	3.6728	3.503	1.8999	2.8494	3.0161	1.5745	3.1147
Min	.2048	.128	.157	.2103	.2553	.2004	.1189
Avg	1.2417	1.0800	.7945	.8624	.8538	.7708	.7420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184259 / Mahal Patne

Feeder No / Name : 202 / VASUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1406				
2	.1677	.144				
3	.1677	.1696				
4	.2035	.1696				
5	.2035	.2035				
6	.2347	.2035				
7	.2374	.2204	.0198			.2667
8	.2204	.2204				
9	.0381	.0381				.0381
10	.0381			.0373		.0191
11	.0381			.0671	.0762	.0191
12	.0381		.1829	.1619		.0191
13	.0191			.16		.0191
14	.0191					
15	.0381		.1417			.0191
16	.0381					.0191
17	.0191		.144			.0191
18	.0191					.0191
19	.0381				.0381	.0381
20	.0381					.0381
21	.0381					.0381
22	.0381					.0381
23						.0678
24	.1696	.1526	.016	.016		.0191
Max	.2374	.2204	.1829	.1619	.0762	.2667
Min	.0191	.0381	.016	.016	.0381	.0191
Avg	.0970	.1662	.1009	.0885	.0572	.0436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184259 / Mahal Patne

Feeder No / Name : 203 / FULENAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143				
2	.1143	.1143				
3	.1143	.1143				
4	.1334	.1334				
5	.1521	.1524				
6	.1524	.1524				
7	.1143	.1143	.8535			.0762
8	.0953	.0953				
9		.0572				.0762
10	.0572			.0566		.0572
11	.1696			.0566	.0762	.1669
12	.96		.0658	.0381		.8093
13	.8173			.0377		.7219
14	.7178					.0381
15	.8011		.0494			.6842
16	.857					.7423
17	.9296		.0377			.9371
18	.7581					.8472
19	.1143				.1143	.0953
20	.1524					.1524
21	.1524					.1524
22	.1524					.1524
23	.1334					.1524
24	.0572	.1334	.305	.4051		.6371
Max	.96	.1524	.8535	.4051	.1143	.9371
Min	.0572	.0572	.0377	.0377	.0762	.0381
Avg	.3400	.1181	.2623	.1188	.0953	.3823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184259 / Mahal Patne

Feeder No / Name : 204 / DEOPURPADE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667				
2	.2667	.2667				
3	.2667	.2667				
4	.3048	.3048				
5	.3429	.362				
6	.381	.4563				
7	.3033	.3429	1.7528			.3048
8	.2092	.3048				
9	.1715	.1905				.2286
10	.1524			.1132		.1524
11	.2529			.0943		.1686
12	1.3875		.0658	.0754		1.2612
13	1.204			.0754		1.1742
14	1.1716					1.1025
15	1.2655		.0656			1.0489
16	1.3607					1.0877
17	1.4806		.082			1.1258
18	1.5185					1.3225
19	.1905				.3429	.2286
20	.3429					.362
21	.3036					.3429
22	.3048					.3239
23	.2667					.3048
24	.2667	.2667	.5047	.6569		
Max	1.5185	.4563	1.7528	.6569	.3429	1.3225
Min	.1524	.1905	.0656	.0754	.3429	.1524
Avg	.5826	.3028	.4942	.2030	.3429	.6587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184259 / Mahal Patne

Feeder No / Name : 206 / DONGARGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8368	.7883				
2	.8669	.853				
3	.9357	.9271				
4	.9569	.9968				
5	1.0159	1.0099				
6	1.0814	1.0402				
7	1.4849	1.4866	.2628			1.5242
8	1.5153	1.4678				
9	.1524	.1512				.0762
10	.1143			.1132		.0762
11	.0953			.2543	.2858	.0953
12	.0953		1.3267	.9717		.0953
13	.0953			.8749		.0762
14	.0953					.0762
15	.0953		1.1056			.0762
16	.0953					.0953
17	.0953		.9476			.0953
18	.0953					.1143
19	.2477				.2667	.2667
20	.3048					.2667
21	.3036					.2477
22	.2662					.2096
23	.2501					.1654
24	.7397	.7169	.2701	.25		
Max	1.5153	1.4866	1.3267	.9717	.2858	1.5242
Min	.0953	.1512	.2628	.1132	.2667	.0762
Avg	.4931	.9438	.7826	.4928	.2763	.2223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184259 / Mahal Patne

Feeder No / Name : 207 / MAHAL PATNE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.0702	.0545	.0152			.0004
2	.1107	.0397	.0541	.0015	.0019	.0324	
3	.0908	.0374	.0556	.0351	.0221	.0255	.0004
4	.1082	.058	.0469	.0431	.0564	.0427	.0564
5	.1103	.0979	.0507	.0434	.0568	.0415	.0633
6	.1417	.125	.0682	.0671	.0728	.0705	.0678
7	.1224	.1421	.0834	.1536	.0636	.0697	.1425
8	.1272	.1233	.0686	.0705	.0545	.0648	.0655
9	.0137	.0732	.0156	.0343	.0282	.0457	.1174
10	.1072	.0568	.0484	.045	.1078	.0415	.1067
11	.0928	.0495	.0511	.0453	.0892	.0968	.0963
12	.0801	.0145	.0244	.0686	.0807	.0335	.0951
13	.0761	.0004	.0438		.0594	.0027	.074
14	.0825	.0046	.0156	.0251	.0008	.0046	.0476
15	.0794		.0004	.0858		.0046	.0802
16	.057	.0293	.0568	.0069	.0309	.0579	.0991
17	.0908	.0533	.0575	.0923	.0518	.064	.1211
18	.1228	.0625	.0693	.0248	.0545	.0678	.1244
19	.1479	.0629	.0655		.0587	.1497	.1516
20	.1631	.0937	.093	.0259	.1109	.0854	.1631
21	.1588	.0751	.0812	.1246	.1101	.0846	.149
22	.0987	.0633	.0568	.0995	.0686	.0793	.1153
23	.0878	.0518	.0453	.0857	.0514	.0556	.0973
24	.0952	.0931	.0324	.1074	.0745	.0343	.0794
Max	.1631	.1421	.093	.1536	.1109	.1497	.1631
Min	.0137	.0004	.0004	.0015	.0008	.0027	.0004
Avg	.1032	.0642	.0516	.0591	.0593	.0546	.0919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184259 / Mahal Patne

Feeder No / Name : 208 / VASUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0563	.0564				
2	.0566	.0563				
3	.0559	.0565				
4	.0562	.0561				
5	.0751	.0755				
6	.0756	.0758				
7	.0948	.0939	.0762			.0953
8	.0748	.0751				
9	.0562	.075				.0572
10	.0569			.0526		.0542
11	.0562			.0543	.0572	.054
12	.0373		.0572	.0351		.0538
13	.0562			.0351		.0537
14	.0557					
15	.0564		.0572			.0534
16	.0559					.0716
17	.0553		.0572			.0709
18	.0738					.0524
19	.0876				.0953	.0722
20	.09					.0912
21	.0742					.0726
22	.0748					.0541
23	.0561					.0554
24	.0559	.056	.0572	.0572		.0534
Max	.0948	.0939	.0762	.0572	.0953	.0953
Min	.0373	.056	.0572	.0351	.0572	.0524
Avg	.0643	.0677	.061	.0469	.0763	.0635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184259 / Mahal Patne

Feeder No / Name : 209 / PADGHAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0367	.0516				
2	.0372	.0514				
3	.0436	.0514				
4	.0433	.0608				
5	.0489	.0687				
6	.0523	.0785				
7	.0403	.0603	.9017			.1143
8	.0306	.043				
9	.0271	.0349				.0953
10	.0209			.0114		.0344
11	.1686			.008	.0762	.1861
12	.8797		.038	.0114		.837
13	.8029			.0103		.8089
14	.7103					.7225
15	.7335		.0506			.7049
16	.7896					.6897
17	.8413		.0506			.708
18	.7845					.7282
19	.0524				.1334	.0386
20	.0687					.0693
21	.0686					.0687
22	.0683					.0689
23	.0608					.0693
24	.0601	.0521	.4024	.3789		
Max	.8797	.0785	.9017	.3789	.1334	.837
Min	.0209	.0349	.038	.008	.0762	.0344
Avg	.2696	.0553	.2887	.084	.1048	.3715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184259 / Mahal Patne

Feeder No / Name : 210 / DEOPURPADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6635	.6445				
2	.7095	.6749				
3	.7499	.7049				
4	.8056	.8115				
5	.8642	.8697				
6	.9164	1.008				
7	1.4232	1.4818	.3429			1.4861
8	1.4083	1.4818				
9	.1137	.1141				.0762
10	.0948			.112		.0762
11	.0943			.2486	.2858	.0761
12	.0949		1.2193	.7202		.0762
13	.0951			.6249		.0762
14	.0953					
15	.0948		1.105			.0762
16	.0951					.0762
17	.0937		1.0669			.0762
18	.0953					.0953
19	.2282				.1524	.2477
20	.2852					.3048
21	.2667					.2477
22	.2277					.1905
23	.1875					.1842
24	.6205	.5877	.2858	.2858		.0762
Max	1.4232	1.4818	1.2193	.7202	.2858	1.4861
Min	.0937	.1141	.2858	.112	.1524	.0761
Avg	.4301	.8379	.8040	.3983	.2191	.2151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184262 / Satana S/S

Feeder No / Name : 201 / 11 KV Satana (U) Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8763	2.9622	3.2857	2.9668	2.9617	1.6491	3.2251
2	2.7612	2.8464	3.0948	2.867	2.8432	1.5234	3.0376
3	2.6391	2.7706	3.0224	2.803	2.7891	1.4906	2.9561
4	2.6079	2.8486	2.958	2.7809	2.7742	1.4784	2.9599
5	2.8586	3.0057	3.1623	2.9325	2.875	1.5546	3.0933
6	3.2731	3.2007	3.6043	3.4313	3.4247	1.6979	3.4152
7	3.9879	3.5376	4.1781	3.9666	3.7362	2.0027	3.6252
8	3.7084	3.6706	3.9549	2.069	3.77	2.0683	3.6557
9	3.1924	3.5779	3.6679	3.5707	3.5739	3.4492	3.4529
10	3.0701	3.3951	3.4114	3.4085	1.7703	3.357	3.4377
11	2.9763	1.7535	3.2385	3.3672	1.7071	3.3471	3.6961
12	1.4937		3.1608	3.2399	1.6773	3.2137	3.7174
13	2.8989		3.0262	3.1809	1.6133	3.166	3.552
14	2.966		2.3815	3.0158	1.6377	3.0765	3.3612
15	2.9782		2.5305	3.0653	1.5867	3.1802	3.4038
16	2.9938		3.2789	3.1654	1.6583	3.285	3.3783
17	2.9477		3.3013	3.3106	1.6598	3.4529	3.3928
18	3.0869		3.3996	3.3722	1.736	3.5635	3.477
19	3.5097	3.9141	3.9342	3.5955	1.864	4.0505	3.9544
20	3.9415	5.7758	4.3286	4.2634	2.3114	4.4101	4.2909
21	2.159	5.3514	4.1397	4.1693	2.364	4.2547	4.1999
22	2.0736	4.6598	3.866	3.9698	2.1887	4.0367	3.9156
23	1.9791	4.3302	3.5616	3.6166	2.0782	3.7726	3.7269
24	3.2528	4.0208	1.7901	3.597	3.3507	1.9022	3.44
Max	3.9879	5.7758	4.3286	4.2634	3.77	4.4101	4.2909
Min	1.4937	1.7535	1.7901	2.069	1.5867	1.4784	2.9561
Avg	2.9263	3.6248	3.3449	3.3219	2.4146	2.8743	3.5152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184262 / Satana S/S

Feeder No / Name : 202 / 11 KV Mahalaxmi Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9191	.8825	.9122	.9313	.9518	.9145	.9526
2	.8512	.7811	.8619	.7888	.8253	.8284	.8619
3	.8078	.7659	.807	.7598	.759	.7575	.8398
4	.7781	.7948	.7918	.7506	.7438	.7552	.788
5	.8238	.8101	.7987	.7697	.8208	.8276	.8551
6	.9846	.9374	.9709	.9511	.9861	.9366	.932
7	1.1111	1.262	1.1538	1.1584	1.1279	1.0806	1.1485
8	1.0631	1.4007	1.1728	1.1721	1.1934	1.1355	1.1988
9	1.0509	1.0738	1.0806	1.1416	1.0669	1.121	1.1797
10	1.1004	1.1286	1.121	1.118	1.1363	1.1606	1.2407
11	1.0905	1.1134	1.1645	1.1454	1.2369	1.2437	1.2239
12	1.0951	1.1065	1.201	1.1789	1.2529	1.2231	1.2795
13	1.0898	1.0684	1.2216	1.182	1.23	1.1904	1.2856
14	1.0532	1.0319	1.2209	1.1241	1.2231	1.1164	1.2292
15	1.0319	.9663	1.1363	.9656	1.15	1.1416	1.0646
16	1.0555	.9564	1.1637	.9617	1.1805	1.1271	1.121
17	1.1073	.9838	1.1599	.9747	1.1858	1.1104	1.1286
18	1.0547	1.0608	1.2033	1.2407	1.1606	1.1462	1.1652
19	1.1264	1.1385	1.2849	1.2879	1.2041	1.2727	1.3275
20	1.374	1.4319	1.5432	1.5272	1.5135	1.528	1.5333
21	1.3359	1.454	1.5127	1.5203	1.4792	1.5143	1.5371
22	1.1736	1.2765	1.2864	1.326	1.262	1.358	1.3199
23	1.1256	1.1706	1.1446	1.2071	1.1378	1.2216	1.2079
24	1.0585	1.089	1.044	1.1081	1.0319	1.0943	1.054
Max	1.374	1.454	1.5432	1.5272	1.5135	1.528	1.5371
Min	.7781	.7659	.7918	.7506	.7438	.7552	.788
Avg	1.0526	1.0702	1.1232	1.0955	1.1192	1.1169	1.1448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184271 / NIMBOLA

Feeder No / Name : 201 / NIMBOLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0362			.0537	
4					.0358	
5		.0543				
6		.0358				
7					.0549	
8					.0549	
9		.0358		.0543		
10			.037			
12	.0362		.037	.0362		.037
13				.0181		.037
14			.0179	.0362		.0181
15	.0183			.0181		
16	.0362					.0181
17	.0362			.0366		
18	.0181					.0181
19	.0543			.0549		.0358
20						.0537
22						.0543
23				.0543		
24					.0362	
Max	.0543	.0543	.037	.0549	.0549	.0543
Min	.0181	.0358	.0179	.0181	.0358	.0181
Avg	.0332	.0405	.0306	.0386	.0471	.0340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

MALEGAON CIRCLE[600]

SATANA DIVISION[605]

SATANA[262]

BU 5479

Substation No/ Name :- 184272 / 33/11 KV KHAMTANE

Feeder No / Name : 201 / 11 kV KHAMTANE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.301	.157	.3079	.3101	.3079	.1669	.3124
2	.298	.1562	.3063	.3101	.3094	.1768	.3079
3	.3132	.1661	.3559	.3628	.333	.1867	.3437
4	.3727	.1936	.4062	.4359	.3681	.1997	.4268
5	.5152	.2858	.5326	.5509	.5198	.2797	.5311
6	.7461	.394	.7628	.4242	.7331	.3963	.7735
7	.7804	.4313	.8063	.8215	.4214	.4329	.8017
8	.5518	.2942	.5457	.554	.5777	.269	.6058
9	.3879	.4321	.413	.426	.2545	.2309	.4489
10	.2995	.3711	.2652	.3223	.1806	.1745	.362
11	.2514	.2667	.1989	.2522	.1494	.1341	.285
12	.2278	.2149	.1981	.1974	.1014	.1867	.2522
13	.1897	.1973	.2133	.1906	.2095	.1845	.1982
14	.1935	.1958	.2339	.1951	.1966	.1959	.1982
15	.2042	.1928	.1723	.1928	.2278	.1989	.2042
16	.2385	.2232	.1662	.2492	.2377	.2232	.237
17	.2987	.285	.1471	.362	.1631	.3056	.3094
18	.439	.423	.093	.3757	.1699	.4542	.3978
19	.5814	.5586	.2354	.4817	.2728	.5525	.5776
20	.631	.5464	.74	.5899	.3391	.5502	.6752
21	.5121	.49	.5213	.4687	.2614	.4656	.548
22	.4413	.3909	.2271	.3986	.2271	.4077	.426
23	.3788	.365	.3612	.3635	.1943	.4001	.3681
24	.33	.3201	.314	.3124	.317	.1821	.3452
Max	.7804	.5586	.8063	.8215	.7331	.5525	.8017
Min	.1897	.1562	.093	.1906	.1014	.1341	.1982
Avg	.3951	.3146	.3552	.3812	.2947	.2898	.4140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184002 / CHANDWAD

Feeder No / Name : 201 / CHANDWAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3249	3.3623	3.3078	1.9037	1.8861	1.9753	1.9631
2	3.248	1.7337	3.2156	1.8	1.7962	1.8999	1.816
3	3.1946	1.6827	3.2746	1.7513	1.7193	1.8412	1.6872
4	3.1824	3.4434	3.2487	1.717	1.6895	1.8069	1.6537
5	3.232	1.6682	3.4423	1.7459	1.7162	1.7993	1.6613
6	3.4571	1.7604	3.6294	1.8511	1.8282	1.9479	1.7452
7	3.9887	2.098	3.9437	2.1178	2.0911	2.1643	2.0233
8	3.9734	2.127	3.8984	2.1445	2.2108	2.2062	2.1209
9	3.9849	3.9136	3.6664	2.1597	2.143	2.1384	2.0675
10	3.8626	2.1293	3.6732	2.1567	2.0797	2.2253	2.1285
11	3.7452	2.0889	3.8047	2.0546	2.0782	2.2763	2.1773
12	3.7113	3.592	3.7312	1.986	2.1514	2.2237	2.0386
13	3.557	1.8801	3.7681	1.9479	2.1552	2.0553	2.021
14	3.48	1.8701	3.6519	1.8983	2.0203	2.0668	2.0035
15	3.4381	3.4693	3.6728	1.8793	1.9479	2.0401	1.9029
16	3.5704	1.8816	3.8024	1.9014	1.9936	2.0462	1.7932
17	3.6214	1.829	3.6233	2.0599	2.1567	2.1956	1.9273
18	3.7304	2.0317	3.6995	2.0812	2.0858	2.2306	2.1262
19	3.9498	3.9925	4.0409	2.0683	2.194	2.3114	2.1963
20	4.5782	2.3624	4.5607	2.5354	2.4425	2.5987	2.524
21	4.3755	2.3388	2.4318	2.4592	2.4425	2.5453	2.479
22	4.1629	2.207	2.2047	2.0622	2.2085	2.3259	2.3251
23	3.9723	3.8714	2.1506	2.1011	2.2001	2.2291	2.2855
24	3.5841	3.6431	3.7117	2.0546	2.1239	2.1742	2.1407
Max	4.5782	3.9925	4.5607	2.5354	2.4425	2.5987	2.524
Min	3.1824	1.6682	2.1506	1.717	1.6895	1.7993	1.6537
Avg	3.7052	2.5407	3.5064	2.0182	2.0567	2.1385	2.0336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184002 / CHANDWAD

Feeder No / Name : 203 / DUGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6843	.7423	1.1763	.4923	.4969	.482	.3376
2	.6896	.3216	1.1813	.466	.5064	.5045	.3326
3	.6885	.3353	1.2338	.4793	.5239	.5213	.3391
4	.714	.7987	1.3073	.5121	.575	.5316	.3738
5	.7308	.4058	1.3949	.5628	.5796	.5815	.3951
6	.7624	.8547	1.5208	.6184	.6337	.6424	.4576
7	.5491	.4028	1.643	.7129	.6874	.6935	.463
8	.7099	.4431	1.7166	.836	.8688	.833	.3681
9	.5967	.6839	1.7219	.9713	.9983	.9343	.3349
10	.4725	.2713	1.03	.8029	.7461	.7526	.2759
11	.3197	.2496	.2575	.1802	.1699	.1417	.2336
12	1.0593	1.1931	.2267	.1379	.1566	.1235	.6447
13	1.1481	.6394	.2004	.136	.1551	.1395	.6447
14	1.1035	.5761	.2183	.141	.149	.1398	.5643
15	1.1016	1.2163	.2168	.1265	.1395	.1391	.5083
16	1.1092	.5182	.2164	.1288	.1456	.1505	.4824
17	1.2395	.5632	.1284	.1257	.1353	.1791	.5784
18	1.3321	.6855	.1345	.144	.1578	.2103	.7762
19	1.257	1.7105	.1844	.1699	.1802	.2355	.831
20	1.078	.6581	.3445	.2652	.2892	.3277	.7091
21	.7613	.3037	.3582	.2964	.3132	.3528	.3018
22	.7701	.2804	.3243	.2968	.3258	.3692	.3304
23	.7785	.559	.3273	.2816	.3254	.3669	.3513
24	.6763	.8981	1.041	.4561	.4108	.3723	.2248
Max	1.3321	1.7105	1.7219	.9713	.9983	.9343	.831
Min	.3197	.2496	.1284	.1257	.1353	.1235	.2248
Avg	.8472	.6379	.7544	.3892	.4029	.4052	.4524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184002 / CHANDWAD

Feeder No / Name : 204 / PATHERSHEMBE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5186	.5605	1.0098	.5982	.586	.5464	.3003
2	.5224	.3056	1.054	.615	.5784	.5441	.3079
3	.5216	.3056	1.1343	.6188	.5906	.5357	.3041
4	.5277	.5681	1.1473	.631	.6234	.5487	.3254
5	.5491	.3269	1.2704	.6341	.6706	.5807	.3361
6	.7011	.6896	1.5234	.5761	.6958	.6775	.3795
7	.7399	.4001	1.9029	.9381	.8307	.8825	.4275
8	.6032	.3589	.9625	1.2048	1.1347	1.0585	.3384
9	.4649	.4428	.0015	1.2856	1.1378	1.1035	.2591
10	.3887	.2111		.6821	.6234	.5639	.1943
11	.2122	.202		.1364	.1539	.0122	.1547
12	1.4518	1.3748		.1227	.1128	.0975	.932
13	1.5044	.7369		.1097	.1021	.1082	.8436
14	1.4617	.6935	.1204	.1044	.0998	.1227	.7171
15	1.4426	1.2555	.1341	.1036	.093	.0998	.6828
16	1.4274	.6333	.0983	.0998	.0846	.1113	.6798
17	1.603	.8009	.1189	.1318	.0922	.1334	.849
18	1.7459	.9457	.1539	.1456	.1486	.1707	.9503
19	1.8236	1.7288	.2134	.1547	.1692	.2241	1.0395
20	.9998	.6592	.3307	.2583	.3323	.349	.5784
21	.6912	.317	.3445	.2873	.3521	.3368	.3246
22	.5658	.2713	.2949	.2759	.2728	.346	.3056
23	.562	.4085	.2568	.2385	.2149	.3368	.3086
24	.5575	.6394	1.0684	.5594	.5068	.3132	.3056
Max	1.8236	1.7288	1.9029	1.2856	1.1378	1.1035	1.0395
Min	.2122	.202	.0015	.0998	.0846	.0122	.1547
Avg	.8994	.6182	.6570	.4380	.4253	.4085	.4935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184002 / CHANDWAD

Feeder No / Name : 205 / RAJEDERWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6073	.7887	.2149	.1905	.173	.1783	.2157
2	.6142	.285	.221	.189	.1791	.1821	.2241
3	.6104	.2797	.221	.1837	.1806	.1898	.2385
4	.6119	.7887	.2218	.1829	.1852	.1814	.2484
5	.7046	.2858	.2294	.1928	.2065	.1951	.2538
6	.7918	.9019	.2385	.2065	.221	.2157	.266
7	1.038	.3696	.2248	.2279	.2279	.2401	.3086
8	1.2342	.471	.1966	.189	.1882	.1829	.4115
9	1.1869	1.313	.1395	.1433	.1341	.1242	.4176
10	.3471	.285	.112	.1113	.1067	.0884	.2164
11	.0872	.0084	.0594	.048	.0693	.0046	.0008
12	.0857	.0926	.3323	.1204	.2713	.2964	
13	.0857	.0693	.3567	.3201	.2934	.2728	
14	.0857	.0899	.3361	.3163	.2881	.2667	
15	.091	.1802	.266	.2873	.2576	.2507	
16	.088	.0945	.2637	.2881	.2317	.2446	
17	.0857	.0914	.314	.3064	.2583	.2995	
18	.0857	.0983	.3506	.3277	.3277	.33	
19	.3509	.3814	.3727	.3155	.3048	.3506	.093
20	.5212	.2195	.2964	.2263	.2431	.2705	.1715
21	.5167	.2233	.1913	.1806	.1852	.1806	.1776
22	.5197	.2088	.1859	.1707	.1715	.1692	.1692
23	.5319	.5685	.1989	.1882	.1821	.1768	.1715
24	.6588	.7392	.4569	.1844	.1783	.1913	.2058
Max	1.2342	1.313	.4569	.3277	.3277	.3506	.4176
Min	.0857	.0084	.0594	.048	.0693	.0046	.0008
Avg	.4808	.3681	.2500	.2124	.2110	.2118	.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184002 / CHANDWAD

Feeder No / Name : 206 / GANUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0856	1.3027	.5849	.3429	.2987	.3094	.6051
2	1.113	.6828	.5864	.3384	.2804	.3064	.602
3	1.1649	.6767	.6813	.3521	.2835	.314	.6523
4	1.1877	1.2966	.6858	.3551	.2987	.3216	.6783
5	1.3222	.756	.8052	.3978	.3414	.3536	.7194
6	1.3893	1.723	.8417	.4786	.4405	.4344	.7758
7	1.8343	1.1309	.7727	.4512	.4313	.4176	1.0791
8	2.3414	1.233	.2911	.3231	.3003	.3216	1.2209
9	2.2329	2.2371	.2058	.2469	.2225	.2378	1.2117
10	.0857		.1692	.1844	.1433	.2149	
11	.0857			.0213	.0716	.0503	
12	.0857	.0857	1.0547	.913	.8916	.8048	
13	.0857		.9191	.8657	.8566	.7423	
14	.0857	.0015	.8429	.7636	.7545	.7301	
15	.0857	.0857	.7788	.6722	.692	.6401	
16	.0857		.8627	.7255	.5609	.6935	.0015
17	.0857		.9907	.8657	.7788	.8596	.0122
18	.0994	.2572	1.1416	.9816	1.0242	.5944	.0046
19	.3635	.2347	1.1126	.9678	.9861	.9419	.2439
20	.559	.3871	.2088	.2759	.3292	.3094	.3384
21	.5483	.381	.3963	.3155	.317	.3048	.282
22	.5559	.3506	.4054	.2972	.3323	.2804	.2774
23	.423	.695	.3658	.2911	.3201	.2241	.2362
24	1.044	1.0243	.6843	.2942	.3064	.5563	.6295
Max	2.3414	2.2371	1.1416	.9816	1.0242	.9419	1.2209
Min	.0857	.0015	.1692	.0213	.0716	.0503	.0015
Avg	.7479	.7653	.6690	.4884	.4692	.4568	.5317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184002 / CHANDWAD

Feeder No / Name : 208 / CHINCHOLE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6996	.8383	.5304	.5014	.5274	.535	.6493
2	.7209	.7773	.538	.503	.5258	.535	.6478
3	.7118	.7377	.5411	.5014	.5396	.5396	.66
4	.7788	.756	.5411	.538	.5533	.5807	.6889
5	.8612	.8444	.602	.6005	.5761	.6112	.7667
6	.9191	.9313	.6173	.631	.6188	.6341	.8901
7	1.2254	1.2803	.349	.5716	.5761	.5944	1.0623
8	1.829	1.6918	.3612	.381	.3765	.41	1.576
9	1.7162	1.704	.3932	.2804	.0945	.2423	1.5927
10	.2042	.1021	.3795	.2103		.192	.032
11			.3018	.0823	.0015	.0808	.0076
12			1.4967	1.2087	1.3474	1.2422	.0046
13			1.3748	1.0852	1.1949	1.1721	.0061
14			1.1294	.9831	.9709	.9953	.0701
15		.1219	.9541	.881	.8825	.7225	.0991
16		.0747	1.0197	1.0562	.8855	.8383	.2103
17			1.2529	1.2087	1.3306	1.1218	.2149
18			1.4647	1.3839	1.5226	1.4327	.2058
19	.2164	.2225	1.5013	1.3931	1.5867	1.4754	.2926
20	.41	.4496	.3826	.3277	.442	.3765	.4085
21	.4359	.4618	.4207	.3871	.4252	.3841	.3826
22	.3917	.5319	.4938	.4862	.4801	.4054	.407
23	.3948	.5563	.5136	.5197	.506	.3643	.3551
24	.8261	.5319	.5106	.5182	.5106	.6523	.791
Max	1.829	1.704	1.5013	1.3931	1.5867	1.4754	1.5927
Min	.2042	.0747	.3018	.0823	.0015	.0808	.0046
Avg	.7713	.7008	.7362	.6767	.7163	.6724	.5009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184026 / VADALI BHOI

Feeder No / Name : 201 / PURI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.4572	.6097	.6097	.6097	.6097	.6097
2	.6097	.4572	.6097	.6097	.6097	.6097	.6097
3	.6097	.4572	.6097	.7621	.7621	.7621	.6097
4	.6097	.4572	.6097	.7621	.7621	.7621	.6097
5	.6097	.4572	.7621	.7621	.7621	.7621	.6097
6	.6097	.6097	.7621	.9145	.9145	.9145	.7621
7	1.1927	1.107	2.0576	2.4196	2.4196	1.3717	1.0384
8	.6097	.4572	1.5242	1.5242	1.5242	1.5242	.3048
9	.3048	.3048	1.3717	1.5242	1.5242	1.3717	.3048
10	.3048	.1524	.3048	.3048	.1524	.1524	.1524
11	.2381	.2553		.1524	.1524	.2896	.2381
12	2.1033	2.2481		.3048	.1524	.0343	1.0669
13	1.0669	1.0669	.1524	.1524			.9145
14	.7621	.6097	.1524	.1524		.1524	.6097
15		.6097	.1524	.1524	.1524	.1524	.7621
16		.7621	.1524	.1524	.1524	.1524	.7621
17	1.0669	.9145	.1524	.1524	.1524	.1524	.9145
18	1.2193	1.2193	.1524	.1524	.1524	.1524	1.0669
19	2.149	1.7985	.1524	.8383	.3048	.7335	
20	1.1927	.903	.4572	1.1432	.6097	1.2613	.6097
21	.4572	.4572	.6097	.6097	.6097	.6097	.6097
22	.6097	.4572	.6097	.6097	.6097	.6097	.6097
23	1.1413	.8344	.4572	.6858	.6097	1.227	.6097
24	1.0059	1.0898	1.0898	.6097	.4572	.6097	1.227
Max	2.149	2.2481	2.0576	2.4196	2.4196	1.5242	1.227
Min	.2381	.1524	.1524	.1524	.1524	.0343	.1524
Avg	.8674	.7560	.6142	.6692	.6434	.6512	.6788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184026 / VADALI BHOI

Feeder No / Name : 202 / SOGRASS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6097	.6097	.6097	.5335	.4572
2			.6097	.6097	.6097	.5335	.4572
3			.6097	.6097	.6097	.6097	.381
4			.6859	.6859	.6097	.6097	.4572
5			.6859	.6859	.6097	.6859	.4572
6			.7621	.7621	.7621	.7621	.4572
7	.3772	.3944	1.829	1.789	1.0669	.9907	.8173
8			1.2193	1.2193	1.2955	1.2193	.381
9			1.1431	1.1431	1.1431	1.2193	.2286
10			.1524	.3048	.2286	.1524	.2286
11	.1372	.1715	.1524	.1524	.3048	.461	.4001
12	.7716	.7621	.1524	.3239	.3048	.3582	.9907
13			.1524	.1524	.1524	.2286	.9145
14			.1524	.1524	.1524	.2286	.8383
15			.1524	.1524	.1524	.2286	.7621
16			.1524	.1524	.1524	.2286	.7621
17			.1524	.2286	.1524	.2286	.9145
18			.1524	.2286	.1524	.2286	1.0669
19	.9297	.8688	.2286	.6096	.2286	.5201	1.0669
20	.4115	.3601	.381	.762	.3048	.8859	.381
21			.381	.381	.3048	.4572	.381
22			.381	.381	.3048	.4572	.381
23	.4115	.2915	.4572	.5334	.3048	.903	.381
24	.3772	.3601	1.1927	.6097	1.7242	.4572	.7925
Max	.9297	.8688	1.829	1.789	1.7242	1.2193	1.0669
Min	.1372	.1715	.1524	.1524	.1524	.1524	.2286
Avg	.4880	.4584	.5228	.5516	.5100	.5495	.5981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184026 / VADALI BHOI

Feeder No / Name : 203 / DHODAMBE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	1.0669	.4572	.4572	.4572	.4572	.9907
2	.9907	1.0669	.4572	.4572	.4572	.4572	.9907
3	.9907	1.0669	.4572	.4572	.4572	.4572	1.0669
4	.9907	1.0669	.4572	.4572	.5335	.4572	.9907
5	1.0669	1.1431	.4572	.5335	.5335	.5335	1.0669
6	1.1431	1.1431	.5335	.4572	.5335	.5335	1.2193
7	2.6063	2.6826	.7658	.6401	.6858	.4572	2.6978
8	1.448	1.7528	.3048	.3048	.3048	.3048	1.6766
9	1.6004	1.829	.2286	.2286	.2286	.2286	1.6004
10	.4572	.3048	.1524	.1524	.1524	.1524	.1524
11	.1791	.2724	.1524	.1524	.0838	.1962	.2896
12	.1791	.1962	1.5242	1.3717	2.2481	2.3624	.0762
13	.0762	.0762	1.5242	1.448	1.1431	1.2955	.0762
14		.1524	1.448	1.2955	.9907	1.2193	.0762
15		.0762	1.2193	1.2193	.9145	1.1431	.0762
16		.0762	1.2955	1.3717	.9907	1.1431	.1524
17	.0762	.0762	1.6004	1.448	1.2955	1.3717	.0762
18	.1524	.1524	1.7528	1.448	1.6004	1.3717	.0762
19	.4096	.4858	1.6766	2.5815	1.6766	2.4386	.2286
20	.7411	.7582	.6097	.6858	.381	.7582	.3048
21	.381	.381	.381	.381	.381	.381	.3048
22	.381	.4572	.4572	.4572	.4572	.381	.3048
23	.7239	.9202	.5335	.8382	.5335	.6896	.381
24	1.9052	1.3107	.9202	.4572	.4572	.8383	1.829
Max	2.6063	2.6826	1.7528	2.5815	2.2481	2.4386	2.6978
Min	.0762	.0762	.1524	.1524	.0838	.1524	.0762
Avg	.8328	.7714	.8069	.8042	.7290	.8179	.6960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184026 / VADALI BHOI

Feeder No / Name : 204 / BHATGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.6344	.6173	1.7223	2.2119	2.0576		.5144
11	.1029	.3086			.1524	.1372	.2915
12	1.4937	1.5242		.1524	.1524	.1543	
19	1.6613	1.4175		.381		.4801	
20	.6687	.5316		.5335		.7202	
23	.6516	.3944		.381		.6001	
24	.6001	.6344	.9602				.6001
Max	1.6613	1.5242	1.7223	2.2119	2.0576	.7202	.6001
Min	.1029	.3086	.9602	.1524	.1524	.1372	.2915
Avg	.8304	.7754	1.3413	.7320	.7875	.4184	.4687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184026 / VADALI BHOI

Feeder No / Name : 206 / KEDRAI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	1.829	.4572	.3048	.4572	.3048	2.1338
2	2.1338	2.2862	.4572	.4572	.4572	.3048	2.2862
3	2.1338	2.2862	.4572	.4572	.4572	.4572	2.4387
4	2.1338	2.4387	.4572	.4572	.4572	.4572	2.5911
5	2.1338	2.4387	.4572	.4572	.4572	.4572	2.5911
6	2.1338	2.4387	.4572	.4572	.4572	.4572	2.5911
7	4.7554	1.0669	.562	.6096	.8382	.3048	5.2583
8	2.7435		.1524	.3048	.3048	.3048	3.0483
9	2.7435		.1524	.1524	.3048	.1524	2.8959
10	.7621		.1524	.1524	.1524	.1524	.1524
11	.2381	.7812	.1524		.1524	.2381	.341
12	.1543	.2896	1.9814	3.2103	2.2862	4.1457	.1524
13	.1524	.1524	2.2862	2.2862	2.1338	2.1338	.1524
14	.1524	.1524	2.2862	1.9814	2.1338	2.1338	.1524
15	.1524	.1524	2.2862	2.1338	2.1338	1.9814	.1524
16	.1524	.1524	2.4387	2.1338	.1524	2.1338	.1524
17	.1524	.1524	2.4387	2.2862	2.2862	2.2862	.1524
18	.1524		2.5911	2.4387	2.2862	2.2862	.1524
19	.4096	.341	2.4387	4.5821	2.2862	3.6123	.1524
20	.6306	.6477	.7621	.8859	.3048	.6477	.3048
21	.3048	.3048	.3048	.4572	.3048	.3048	.3048
22	.3048	.4572	.3048	.4572	.4572	.3048	.3048
23	.5791	.9373	.4572	.9144	.4572	.4934	.3048
24	4.2981	1.4936	.7678	.762	.3048	1.829	3.8866
Max	4.7554	2.4387	2.5911	4.5821	2.2862	4.1457	5.2583
Min	.1524	.1524	.1524	.1524	.1524	.1524	.1524
Avg	1.3184	1.0399	1.0524	1.2321	.9176	1.1618	1.3605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184026 / VADALI BHOI

Feeder No / Name : 207 / GOPAL POLE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.724	.381	.6668	.4001	.5716		.381
11	.8002	.6668				.4572	.6478
12	.7545	.6668		.5335		.3239	
19	.5906	.7202		.6668		.4001	
20	.5335	.5716		.6668		.724	
23	.6668	.6859		.6668		.3048	
24	.743	.5335	.5144				.724
Max	.8002	.7202	.6668	.6668	.5716	.724	.724
Min	.5335	.381	.5144	.4001	.5716	.3048	.381
Avg	.6875	.6037	.5906	.5868	.5716	.442	.5843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184026 / VADALI BHOI

Feeder No / Name : 208 / 11 KV SHELU FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.5658	.5487	.3601	.3201	.3048		.4877
10						.0857	
11	.0857	.0857					.12
12	.1029	.0686		.5144	.4287	.381	
19	.3086	.2915		.6001		.4572	
20	.3601	.3601		.3048		.3429	
23	.1715	.2743				.1886	
24	.3258	.2915	.2572	.2286	.0762		.2572
Max	.5658	.5487	.3601	.6001	.4287	.4572	.4877
Min	.0857	.0686	.2572	.2286	.0762	.0857	.12
Avg	.2743	.2743	.3087	.3936	.2699	.2911	.2883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184051 / VADNER BH

Feeder No / Name : 201 / BAHADURI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					2.2466		.3361
2				1.6766	2.2298		.3361
3	.2401		2.0576		2.2874		.3361
4				1.8004	2.3137		.3361
5					2.364		.3361
6	.2058		.3772	2.6578	2.3807		.3361
7		.181			2.7526		.2987
8		.181	2.6578	2.5149	2.7526		.1867
9		.181	2.4006	2.6825			.1494
10	.181			.112			.181
11	.181			.112			
12	2.834	2.6578		.1494			.1619
13	2.753		.181	.168		.1494	3.0769
14	2.834			.1307		.2241	3.1579
15		2.7435		.112		.2241	3.4818
16	2.753			.1494		.2241	3.1579
17				.2241		.2241	
18				.2241		.2614	3.2388
19	3.0769	2.6578		.2987		.2987	.1619
20	.2715			.3361		.3361	.181
21				.2614		.3361	.181
22				.2614		.3361	.181
23				.2614		.3361	
24	.2572	.181	1.8861		2.2213		.3361
Max	3.0769	2.7435	2.6578	2.6825	2.7526	.3361	3.4818
Min	.181	.181	.181	.112	2.2213	.1494	.1494
Avg	1.4170	1.2547	1.5934	.7438	2.3943	.2682	.9595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184051 / VADNER BH

Feeder No / Name : 202 / DHONDGAVAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.724			1.1736		.7095
2				1.4251	1.3748		.7095
3	.6859		1.9033		1.576		.6722
4				1.5432	1.6385		.7095
5					1.7238		2.0538
6	.6173		1.9204	2.2939	2.0119		.7842
7		.724			2.4813		.7095
8		.6135	2.9664	3.0312	3.0148		.5601
9		.543	2.8635	3.1131			.5601
10	.181		.2715	.2241			.362
11	.181		.2715	.1867			
12		3.2579	.2715	.2987		.2987	3.0769
13	3.0769		.2715	.2987		.3361	3.0769
14	3.2388			.3734		.3361	.8907
15	2.9959	2.9492		.3361		.3361	3.2388
16	2.9959			.4108		.3361	3.2388
17				.3734		.3547	
18				.3734		.4108	3.0769
19	3.2579	2.452		.4854		.6722	2.9959
20				.6722		.8962	
21				.7468		.8589	.8145
22				.7095		.7842	.8145
23				.6722		.8402	
24	.6859	.724	1.5775	1.1736	1.0974		.362
Max	3.2579	3.2579	2.9664	3.1131	3.0148	.8962	3.2388
Min	.181	.543	.2715	.1867	1.0974	.2987	.362
Avg	1.7917	1.4985	1.3686	.9371	1.7880	.5384	1.4708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184051 / VADNER BH

Feeder No / Name : 203 / VADNER -R2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8861			.4108		1.643
2				.3734	.3734		1.6766
3	1.9719		.3429		.3734		1.7101
4				.3734	.3734		1.7772
5					.3734		1.8442
6	2.4006		.2743	.3734	.3361		2.146
7		2.915			.2641		2.8509
8		3.2388	.2572	.2801	.1867		3.0803
9		2.753	.1543	.1867			2.7854
10	.181		.181	.1509			.181
11	.181		.181	.112			
12	.181	.1372	3.6199	2.5888			.181
13	.181		3.6199	2.5888		2.7526	.181
14	.181			2.5232		2.556	.181
15	.181	.1715		2.4577		2.42	3.2388
16	.181			2.1956		2.5888	.181
17				2.6216		2.6852	
18				2.5888		2.4577	.181
19	.2715	.2572		2.2131		2.1956	.181
20	.362			.3361		.3361	.362
21				.3772		.3361	.362
22				.4108		.3361	
23				.4108		.3361	
24	2.0233	1.8623	.3429	.3734	.3734		1.6095
Max	2.4006	3.2388	3.6199	2.6216	.4108	2.7526	3.2388
Min	.181	.1372	.1543	.112	.1867	.3361	.181
Avg	.6914	1.6526	.9970	1.1768	.3405	1.7273	1.3177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184051 / VADNER BH

Feeder No / Name : 204 / PIMPALNARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0526			.2987		.9724
2				.2801	.2987		1.0059
3	1.1145		.2572		.2987		1.0395
4				.2801	.3361		1.1065
5					.3361		1.1736
6	1.4403		.2572	.2801	.3361		1.2742
7		1.7814			.2614		1.8515
8		2.1052	.1715	.1867	.1886		1.8778
9		2.2672	.1372	.1867			2.079
10	.0905			.112			.0905
11	.0905						
12	.0905	.0857	.0905	2.1628		2.3266	.0905
13	.0905		2.4434	2.1628		2.3758	.0905
14	.0905			2.0153		2.2611	.0905
15	.081	.12		1.8351			
16	.0905			1.8679		2.1879	.0905
17				1.8679		2.0972	
18				2.0119		1.9662	.181
19		.1715		1.7238		1.5565	.181
20				.2987		.2987	.2715
21				.3361		.3361	.2715
22				.3361		.3361	.181
23				.3361		.2987	
24	1.1145	1.1145	.2743	.2829	.2987		.8817
Max	1.4403	2.2672	2.4434	2.1628	.3361	2.3758	2.079
Min	.081	.0857	.0905	.112	.1886	.2987	.0905
Avg	.4293	1.0873	.5188	.9770	.2948	1.4583	.7400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184051 / VADNER BH

Feeder No / Name : 206 / VADNER GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2614		.2987
2				.2858	.2614		.2614
3	.2572		.3086		.2987		.2614
4				.3734	.3018		.2614
5					.2987		.2987
6	.2743		.3429	.3734	.3395		.2987
7		.3239			.3361		.3361
8			.3429	.3734	.2987		.3734
9		.4287	.3429	.3772	.3361		.4481
10	.4858		.4525	.3361			.362
11	.543		.4525	.2987			
12	.4858	.3429	.362	.3361			.3239
13	.4049		.2715	.3361		.2987	.362
14	.3239			.3734		.2987	.3239
15	.4525	.4458		.3361		.2614	.3239
16	.4049			.4108		.2987	.3239
17				.3734		.3734	
18				.4108		.4481	.3239
19	.4525			.4854		.4108	.4049
20	.543			.5658		.4481	.4525
21				.4481		.3734	.4049
22				.415		.3361	.4049
23				.3772		.3018	
24	.2743	.3429	.3429	.3734	.3361		.2614
Max	.543	.4458	.4525	.5658	.3395	.4481	.4525
Min	.2572	.3239	.2715	.2858	.2614	.2614	.2614
Avg	.4085	.3768	.3576	.3830	.3069	.3499	.3386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184051 / VADNER BH

Feeder No / Name : 207 / Dhotarkheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4049			.1867		.8383
2				.2801	.1867		.8573
3	.8573		.1715		.1867		.8718
4				.2829	.1867		.9054
5					.1867		.9054
6	.9259		.1715	.2801	.1867		.9724
7		.9717			.1867		1.2929
8		.9717	.1372	.1867	.1494		1.073
9		.9717	.1029	.1867			1.1736
10	.0905		.0905	.0747			.0905
11	.0905		.0905	.0747			
12	.0905	.0514	1.086	1.0814		1.2452	.0905
13	.0905		1.1765	1.1736		1.073	.0905
14	.0905			1.073		1.2929	.0905
15	.0905	.0857		1.073		1.0486	.0905
16				.9724		1.1271	.0905
17				1.1401		1.2071	
18				1.1401		1.2125	.181
19	.2715	.1372		1.1065		1.2742	.181
20	.2715			.1886		.1867	.181
21				.2263		.1867	.181
22				.2241		.1867	.181
23				.2241		.1867	
24	.7888	.2572	.2058	.2801	.1867		.8573
Max	.9259	.9717	1.1765	1.1736	.1867	1.2929	1.2929
Min	.0905	.0514	.0905	.0747	.1494	.1867	.0905
Avg	.3325	.4814	.3592	.5635	.1826	.8523	.5331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254] BU 5461

Substation No/ Name :- 184052 / KAZI-SANGVI

Feeder No / Name : 202 / DEORGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431		.9945
2		.9602		1.0288
3		.9945		1.0802
4		1.0288		1.166
5		1.0974		1.2517
6		1.2003		1.5947
7		1.3717		1.8004
8		1.5432		1.8347
9	1.4746			
13			1.0117	
14			.9774	
15			.9945	
16			1.0288	
17	1.3546		1.0288	
18	1.3889		1.0802	
19			1.4403	
20	.5487		.4973	
21	.583		.463	
22	.5316		.4458	
23	.4801		.4115	
24		.9431		.9088
Max	1.4746	1.5432	1.4403	1.8347
Min	.4801	.9431	.4115	.9088
Avg	.9088	1.1203	.8527	1.2955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184052 / KAZI-SANGVI

Feeder No / Name : 203 / WAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.583		.6516
2		.583		.6516
3		.583		.6687
4		.6173		.7202
5		.7373		.823
6		.823		.9431
7		.8402		.823
8		1.2003		.5144
13			.2229	
14			.2229	
15			.2229	
16			.2401	
17	.2915		.2401	
18	.3086		.2743	
19	.4973		.4458	
20	.6859		.6859	
21	.6001		.6687	
22	.6859		.7202	
23	.6001		.7373	
24		.4801		.6516
Max	.6859	1.2003	.7373	.9431
Min	.2915	.4801	.2229	.5144
Avg	.5242	.7164	.4256	.7164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254] BU 5461

Substation No/ Name :- 184052 / KAZI-SANGVI

Feeder No / Name : 204 / KAZISANGVI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859		.4115
2		.6859		.4115
3		.6859		.4458
4		.7202		.4801
5		.7888		.5487
6		.823		.6516
7		.7716		.823
8		.6001		1.0631
13			.5144	
14			.463	
15			.4458	
16			.5144	
17	.7716		.6859	
18	.7888		.8916	
19	.8059		.7888	
20	.8059		.7202	
21	.823		.6859	
22	.7545		.6859	
23	.7202		.6687	
24		.6859		.3429
Max	.823	.823	.8916	1.0631
Min	.7202	.6001	.4458	.3429
Avg	.7814	.7164	.6422	.5754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184052 / KAZI-SANGVI

Feeder No / Name : 205 / ANAND PIPE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514		.0857
2		.0514		.0857
3		.0514		.0857
4		.0514		.0857
5		.0514		.0857
6		.0514		.0857
7		.0514		.0857
8		.0514		.0857
9		.0514		
16			.0857	
17	.0514		.0857	
18	.0514		.0857	
19	.0514		.0857	
20	.0514		.0857	
21	.0514		.0857	
22	.0514		.0857	
23	.0514		.0857	
24		.0514		.0857
Max	.0514	.0514	.0857	.0857
Min	.0514	.0514	.0857	.0857
Avg	.0514	.0514	.0857	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184052 / KAZI-SANGVI

Feeder No / Name : 206 / 11 KV VITAVE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8733	.8993	.5822	1.0928	.4877	.5152	1.7124
2	.8794	.9114	.599	1.1004	.5014	.5213	1.7231
3	.9191	.945	.5807	1.1149	.5426	.5319	1.7676
4	1.0044	.9694	.5914	.5624	.5685	.5685	1.8583
5	1.1096	1.1416	.6341	1.3001	.6371	.6569	2.0301
6	1.2849	1.2864	.7042	1.4267	.6737	.7026	2.3556
7	1.3032	1.3184	.9206	1.6583	.9374	.9496	1.853
8	.9755	1.0547	1.2422	2.2504	1.2635	1.0334	1.858
9	.7697	.7392	1.2285	1.2056	1.2102	1.0578	.823
10	.5136	.5441	.3993	.3521	.3826	.3216	.5807
11	.2911	.3307	.2622	.2774	.282	.2728	.4024
12	.663	.6295	.2012	.1997	.2378	.2683	.7118
13	.5807	.538	.1981	.2164	.2347	.439	.6234
14	.4786	.5213	.2027	.2088	.2347	.4314	.5578
15	.5014	.4725	.2332	.2378	.2347	.4851	.4572
16	.5472	.5258	.2469	.2469	.2332	.5084	.5335
17	.7514	.7209	.945	.2576	.2454	.5624	.6539
18	.9313	.8886	.6703	.2789	.2683	.7129	.9389
19	.9648	.9556	2.1498	.5319	.5731	1.2875	.9267
20	.9648	.9069	1.8701	.9648	1.0029	1.8686	.916
21	.9282	.8429	1.7444	.9191	.8916	1.8362	.8932
22	.9389	.8612	1.6328	.8657	.8307	1.8823	.9206
23	.9846	.8733	1.5135	.8276	.8261	1.7954	.9404
24	.9175	.5136	1.1904	.9606	.4893	.9145	1.6808
Max	1.3032	1.3184	2.1498	2.2504	1.2635	1.8823	2.3556
Min	.2911	.3307	.1981	.1997	.2332	.2683	.4024
Avg	.8365	.8079	.8560	.7940	.5746	.8385	1.1549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184077 / DUGAON

Feeder No / Name : 201 / HARSUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4801			.7373
2			.4801			.7373
3			.4801			.7373
4			.5144			.7716
5			.583			.8745
6			.7545			
7			1.0288		1.0117	
8			1.3032			
9	.3258					
10	.2572					
11	.2572					
12	.823					
13	.7716			.1715		
14	.7202			.1715		
15	.6516					
16	.703	.1715			.2058	
17		.2058			.2229	.6859
18		.2401			.2915	.6001
19		.5144			.6173	.2058
20		.6001			.3944	.4287
21		.4287			.7716	.6344
22		.6173			.7888	.6859
23		.3429			.7373	.6859
24			.4458	.3086	.6344	.7716
Max	.823	.6173	1.3032	.3086	1.0117	.8745
Min	.2572	.1715	.4458	.1715	.2058	.2058
Avg	.5637	.3901	.6744	.2172	.5676	.6582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184077 / DUGAON

Feeder No / Name : 202 / BHADANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4458			.3429
2			.4973			.3429
3			.4458			.3429
4			.4973			.3429
5			.5487			.4287
6			.4973			
7			1.0631		.4115	
8			.2743			
9	.0857					
10	.0857					
11	.0857					
12	.1029			.6344		
13	.12			.5658		
14	.12			.5144		
15	.1372			.463		
16	.1372	.9431		.703		
17		1.046			1.0974	.1715
18		1.0117			.9945	.1715
19		.1886			.2229	.2572
20		.4458			.3944	.3429
21		.4458			.3944	.3772
22		.4458			.3772	.3429
23		.4287			.3772	.2401
24		.4458	.4458	.3429	.4287	.6173
Max	.1372	1.046	1.0631	.703	1.0974	.6173
Min	.0857	.1886	.2743	.3429	.2229	.1715
Avg	.1093	.6001	.5239	.5373	.5220	.3324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184077 / DUGAON

Feeder No / Name : 203 / KOKANKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9602			.5658
2			.9602			.5658
3			1.0288			.6001
4			1.1831			.6859
5			1.286			.7888
6			1.4575			
7			1.0631		.9259	
8			.9602			
9	.583					
10	.5144					
11	.4458					
12	.3944			.9259		
13	.4458			.8573		
14				.7716		
15				.463		
16		1.0802		.9431	.823	
17		1.2689			1.2003	.5144
18		1.3546			1.1488	.6001
19		.8402			.8745	.6859
20		1.1488			1.2174	.9945
21		1.166			1.0288	1.0288
22		1.0631			.9774	.9431
23		.9602			.583	.5144
24		1.1488	.9602	.8573	.9259	1.0631
Max	.583	1.3546	1.4575	.9431	1.2174	1.0631
Min	.3944	.8402	.9602	.463	.583	.5144
Avg	.4767	1.1145	1.0955	.8030	.9705	.7347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184077 / DUGAON

Feeder No / Name : 204 / DAREGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9259			.9602
2			.9259			.9602
3			1.0802			1.0288
4			1.0802			1.0631
5			1.1145			1.2346
6			1.3032			
7			1.5604		1.6804	
8			1.7147			
9	.8573					
10	.5658					
11	.7716					
12	1.1145					
13	.9945			.4287		
14	.8573			.4287		
15	.8916			.4287		
16	1.0117	.463		.463	.463	
17		.4458			.5144	.9431
18		.463			.6859	.8573
19		1.1831			1.3203	.5144
20		1.166			1.2517	.5487
21		1.0288			1.2003	.6344
22		.8745			1.0802	.7716
23		.7716			.9088	.8573
24			.9259	.5144	.8745	1.5261
Max	1.1145	1.1831	1.7147	.5144	1.6804	1.5261
Min	.5658	.4458	.9259	.4287	.463	.5144
Avg	.8830	.7995	1.1812	.4527	.9980	.9154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184077 / DUGAON

Feeder No / Name : 205 / RAIPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2972		.4801			.604
2	.3048	.2743		.4973			.5963
3	.3048	.2667		.4973			.5963
4	.3125	.2667		.5144			.6134
5	.3048	.2896		.4973			.6287
6	.3277	.2972		.4801			.3506
7	.503	.5792		.4115		.3258	.5716
8	.8993	1.0212		.2743			.9297
9	1.4708	1.0288					.9069
10	.0933						
11	.0857						
12	.0857		.5487	.503	1.0651	.5639	
13	.1543		.503	.4801	.964	.5487	
14	.1715		.4268	.4039	.8097	.4191	
15	.1543		.3582	.381	.7564	.381	
16	.1372		.3887	.4877	.8649	.3658	
17			1.4061	.6249	.5106		.1886
18			1.5413	.7316	.7164	1.6118	.2058
19			.9869	.7316	.602	1.105	.2572
20			.3944			.4458	.3429
21			.4287			.3944	.4115
22			.4801			.3944	.3772
23			.4458			.2572	.3258
24	.2972			.463	.3429	.7811	.7544
Max	1.4708	1.0288	1.5413	.7316	1.0651	1.6118	.9297
Min	.0857	.2667	.3582	.2743	.3429	.2572	.1886
Avg	.3477	.4801	.6591	.4976	.7369	.5842	.5095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184081 / DHODAMBA

Feeder No / Name : 201 / DHODAMBA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.4656	.5335	.5788	.5144		.3681
2	.4435	.4656	.5335	.5788	.5144		.3544
3	.462	.4656	.5335	.5975			.3681
4	.462	.4835	.5335	.6535			.3641
5	.4755	.5138	.6287	.6908			.3772
6	.4887	.5138	.7167	.7095	.6668		.4694
7	.6097	.6859	.6097	.6348	.6097		.6478
8	.6882	.8059	.4954	.4668	.4763		.6316
9	.6299	.6516	.3429	.3429			.5668
10	.2667	.3239	.381	.2858			.2667
11	.2096	.2477	.2667	.2286			.2667
12	.2286	.2096	.631	.5182	.5784		.1905
13		.1905	.5258	.502		.4481	.2096
14		.1905	.5014	.3932		.3887	.1905
15		.2096	.5258	.426		.3605	.1905
16		.2286	.5258	.4534	.4607	.4049	.2286
17	.2858	.1905	.6415	.5868		.4858	.2477
18	.3206	.3048	.6687	.5506		.5761	.362
19	.5281	.4572	.6068	.5182		.5344	.5525
20	.6535	.6287	.6348	.6668		.6668	.6287
21	.5975	.6287	.5601	.5906		.5716	.6097
22	.5601	.6097	.5788	.5716		.5716	.5906
23	.5415	.5906	.5788	.5525		.5525	.4572
24	.4382	.4656	.5335	.5788	.5144		.3467
Max	.6882	.8059	.7167	.7095	.6668	.6668	.6478
Min	.2096	.1905	.2667	.2286	.4607	.3605	.1905
Avg	.4667	.4386	.5453	.5282	.5419	.5055	.3952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184081 / DHODAMBA

Feeder No / Name : 202 / VIJAYNAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5571	.5922	.8581	.9153	.8825	.4512	.5058
2	.5616	.5891	.8238	.8977	.8894	.4313	.5317
3	.5647	.6163	.833	.9046	.4793	.4161	.5567
4	.5868	.6573	.8337	.941	.4923	.4458	.6104
5	.6698	.7316	.8885	1.0265	.5456	.4992	.6992
6	.7697	.8009	.9366	1.2315	1.2536	.7034	.7613
7	.5875	.7171	1.2193	1.5623	1.5242	.7522	.5074
8	.4679	.4906	1.2924	1.3565	1.4188	.6965	.2961
9	.3521	.3224	.9065	.8859	.3292	.2332	.0069
10	.1799	.1852	.0572	.0734	.0389	.0701	.1638
11	.6996	.6928	.0572	.0619	.0168	.0914	.7362
12	1.1919	1.0151	.0572	.0833	.0572	.0488	1.0448
13	1.0867	.8665	.0572	.0726	.045	.0732	.976
14	.9853	.95	.1418	.1691	.032	.1562	.8804
15	.9739	1.0144	.138	.1653	.0884	.1722	.8244
16	1.0829	1.028	.096	.1432	.1852	.1364	.9012
17	1.3466	1.3693	.0861	.1503	.0663	.1783	1.3306
18	1.5531	1.5485	.2081	.2353	.1349	.2543	1.3702
19	1.1469	1.0433	.4641	.4458	.2751	.5409	1.0212
20	.7038	.6074	.6437	.6195	.3307	.6864	.6638
21	.7122	.6409	.6885	.6173	.3567	.7499	.6714
22	.6901	.615	.5961	.5651	.3208	.6824	.6569
23	.6657	.6806	.6416	.7384	.4649	.5316	.615
24	.5937	.7613	.8696	.9237	.8954	.2614	.5356
Max	1.5531	1.5485	1.2924	1.5623	1.5242	.7522	1.3702
Min	.1799	.1852	.0572	.0619	.0168	.0488	.0069
Avg	.7804	.7723	.5581	.6161	.4635	.3859	.7028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184081 / DHODAMBA

Feeder No / Name : 203 / PAREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.98	1.0718	.7084	.4519	.4268	.2347	.7327
2	.9937	1.0749	.7335	.4519	.4352	.2324	.7571
3	.996	1.0642	.8004	.4427	.2309	.2431	.7763
4	.996	1.0718	.8034	.4601	.2538	.2568	.8002
5	1.0157	1.1179	.8358	.5194	.282	.2736	.8623
6	1.0615	1.1271	.9031	.5491	.5824	.2926	.8886
7	1.2548	1.2681	.9119	.4389	.4818	.2553	1.1778
8	1.4022	1.4876	.2454	.3552	.3466	.1898	1.3942
9	1.3923	1.3972	.1958	.2912	.1425	.1478	1.3598
10	.2073	.2104	.1745	.1995	.0937	.1059	.1669
11	.1951	.186	.1265	.1534	.0625	.0937	.1098
12	.1357	.1029	1.2125	1.2628	1.2552	.5792	.0838
13	.0572	.1052	1.1598	1.2016	.6683	1.0648	.1212
14	.0572	.1273	.9012	1.1751	.6401	.9917	.0572
15	.0572	.0595	.9053	1.1155	.6043	.9373	.0572
16	.0755	.08	1.1546	1.1759	1.0417	.9934	.0572
17	.0991	.0587	1.3001	1.162	.6272	1.1679	.0572
18	.1905	.1448	1.3553	1.3354	.7186	1.3119	.1044
19	.3856	.3262	1.3283	1.3028	.7202	1.3389	.3444
20	.5572	.4443	.3231	.4293	.2401	.4224	.4565
21	.5489	.4359	.3544	.4298	.2309	.4155	.4618
22	.5346	.439	.4215	.4506	.2469	.4321	.4664
23	.54	.4298	.4702	.4709	.25	.4058	.4367
24	1.0229	.6885	.4046	.4504	.4405	.4024	.7788
Max	1.4022	1.4876	1.3553	1.3354	1.2552	1.3389	1.3942
Min	.0572	.0587	.1265	.1534	.0625	.0937	.0572
Avg	.6148	.6050	.7387	.6781	.4593	.5329	.5212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184081 / DHODAMBA

Feeder No / Name : 204 / DAHYANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905		.5194	.5144		.2286
2	.1905	.1905		.5194	.5144		.2096
3	.1905	.2096		.5258			.2096
4	.1905	.2096		.5721			.2096
5	.2096	.2263		.6001			.2096
6	.2477	.2263		.6173	.6962		.2096
7	.2286	.2263		.6952	.7287		.1715
8	.1905	.132	.8583	.8215	1.0364		.1524
9	.1143	.1334	.7682	.6516			.1334
10	.1143	.1143	.0572	.0762			.1334
11	.0762	.0762	.0953	.0953			.0572
12	.6687	.7127	.1334	.1143	.0953		.6299
13	.7202	.7537	.1143	.0953		.1143	.6443
14	.7377	.7459	.0953	.0953		.1143	.6464
15	.7545	.7127	.0953	.0953		.1143	.6203
16	.788	.7127	.1143	.0953	.1334	.1334	.5868
17	.8356	.7045	.1334	.1143		.1143	.8192
18	.8886	.8259	.1334	.1143		.1334	.7773
19	.6874	.7373	.1905	.1905		.0953	.6464
20	.2096	.2096	.1715	.2477		.2477	.1715
21	.2096	.1905	.1715	.2286		.2286	.1905
22	.2452	.1715	.1715	.2096		.2477	.1905
23	.2452	.1334	.1524	.1524		.3048	.1905
24	.1905	.1905	.5138	.5194	.5144		.2858
Max	.8886	.8259	.8583	.8215	1.0364	.3048	.8192
Min	.0762	.0762	.0572	.0762	.0953	.0953	.0572
Avg	.3802	.3640	.2335	.3319	.5292	.1680	.3468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184081 / DHODAMBA

Feeder No / Name : 205 / SHINDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3077	.381	.4108	.4001		.2835
2	.3395	.3077	.381	.4108	.4001		.298
3	.3395	.3258	.381	.4108			.298
4	.3395	.3258	.381	.4108			.3294
5	.3696	.362	.4191	.4294			.3601
6	.4163	.4119	.362	.4294	.4001		.373
7	.6097	.631	.2286	.2641	.2667		.6478
8	.8097	.9054	.1524	.1905	.1524		.7522
9	.6554	.7545	.0953	.1524			.6316
10	.0572	.1143	.0572	.0572			.0381
11	.0762	.0572	.0572	.0381			.0572
12	.0762	.0762	.631	.4858	.5959		.0572
13	.0762	.0762	.4908	.4049		.3841	.0572
14	.0762	.0762	.394	.3277		.3401	.0572
15	.0762	.0762	.4557	.3768		.3277	.0572
16	.0762	.0762	.5144	.421	.5194	.426	.0572
17	.0953	.0762	.6859	.6722		.5344	.0953
18	.1143	.0953	.8048	.6722		.6401	.0953
19	.2263	.2286	.703	.6478		.6154	.1905
20	.2829	.2858	.2829	.2858		.3048	.3239
21	.3018	.3239	.3206	.362		.3239	.3429
22	.3395	.4001	.3734	.381		.362	.362
23	.3395	.4191	.4108	.4001		.381	.3429
24	.3239	.3077	.381	.4108	.4001		.2629
Max	.8097	.9054	.8048	.6722	.5959	.6401	.7522
Min	.0572	.0572	.0572	.0381	.1524	.3048	.0381
Avg	.2815	.2925	.3893	.3772	.3919	.4218	.2654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184081 / DHODAMBA

Feeder No / Name : 206 / BHAYALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6201	.631	.3048	.3395	.3048		.5721
2	.6485	.631	.3048	.3395	.3429		.5895
3	.6687	.6588	.3048	.3772	.381		.6001
4	.6874	.7202	.3048	.4481	.4001		.6344
5	.7373	.8048	.4572	.5228			.6613
6	.8322	.9012	.5906	.5601	.6287		.9282
7	1.0753	1.247	.4382	.4668	.4954		1.085
8	1.1702	1.4083	.3048	.3018	.2667		1.1843
9	1.1363	1.2146	.2286	.2096			.9922
10	.1905	.1905	.1905	.1905			.2096
11	.1715	.2096	.1334	.1715			.1524
12	.1334	.1334	.9221	.8322	.8886		.1524
13	.1334	.1334	.8048	.7522		.7907	.1334
14	.1524	.1334	.7209	.7125		.6882	.1334
15	.1334	.1524	.8048	.7125		.664	.1143
16	.1334	.1334	.9503	.7935	.852	.7449	.1143
17	.1334	.1524	1.065	.9762		.8962	.1334
18	.1334	.1715	1.0814	.9602		1.0402	.1905
19	.3018	.362	1.1469	.9602		1.0526	.4001
20	.4668	.4191	.4481	.4382		.4382	.4191
21	.4108	.4001	.3772	.381		.381	.381
22	.3734	.381	.3772	.362		.362	.362
23	.3206	.3239	.3395	.3239		.3429	.3239
24	.6219	.6135	.3048	.3395	.2858		.5487
Max	1.1702	1.4083	1.1469	.9762	.8886	1.0526	1.1843
Min	.1334	.1334	.1334	.1715	.2667	.3429	.1143
Avg	.4744	.5053	.5377	.5196	.4846	.6728	.4590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184081 / DHODAMBA

Feeder No / Name : 207 / 11 KV KANMANDALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4481	.3841	.4344	.463		.4715
2	.4572	.4481	.3841	.4344	.4973		.4715
3	.4572	.4481	.3841	.4706			.4904
4	.4572	.4668	.4024	.5249			.5281
5	.4763	.4854	.4163	.5847			.5847
6	.5144	.5228	.4525	.6859	.6962		.5093
7	.3048	.4481	.7865	1.0978	.9231		.3772
8	.2477	.3395	.9282	1.247	1.085		.2987
9	.1715	.2641	.933	.4344			.2075
10	.1143	.1524	.0762	.0754			.1143
11	.0762	.0762	.0762	.0754			.0572
12	.8745	.8356	.0762	.1132	.1143		.663
13	.7202	.6882	.0953	.1132		.0943	.7459
14	.6588	.6539	.0953	.0943		.1132	.7127
15	.6859	.5868	.0953	.0943		.1132	.7459
16	.7545	.7209	.0953	.0754	.1143	.1132	.7625
17	.9012	.8802	.1334	.0943		.1307	.8848
18	.9717	.8583	.1334	.0943		.1698	1.0242
19	.8684	.9555	.3018	.1698		.3018	1.0082
20	.4294	.381	.3584	.4001		.4191	.362
21	.4668	.381	.4108	.415		.415	.4763
22	.4854	.381	.3772	.3961		.4763	.5335
23	.5041	.3429	.3018	.3772		.5144	.4763
24	.4763	.4481	.3881	.4344	.4334		.4715
Max	.9717	.9555	.933	1.247	1.085	.5144	1.0242
Min	.0762	.0762	.0762	.0754	.1143	.0943	.0572
Avg	.5221	.5089	.3369	.3724	.5408	.2601	.5407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184089 / JOPUL

Feeder No / Name : 202 / JOPUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9873	1.0463	1.672	1.9708	1.925	1.6659	1.0318
2	.5319	.5319	1.0761	1.2178	1.1477	1.073	.5624
3	.5335	.5365	1.134	1.259	1.166	1.0822	.5655
4	.5502	.5289	1.1675	1.2864	1.1827	1.1111	.5639
5	.5594	.5487	1.2224	1.2772	1.2102	1.1888	.5517
6	.5624	.5609	1.2239	1.3352	1.2544	1.2727	.5456
7	.4481	.503	1.6217	1.5927	1.5272	1.6766	.4466
8	.2058	.3201	1.7878	1.9067	1.7817	1.9372	.2683
9			3.2709	3.3074	3.0209	3.2586	
10			.852	.8718	.9983	.7651	
12	2.745	2.5423					2.8045
13	1.5973	1.4236					1.5059
14	1.5287	1.3443					1.451
15	1.4312	1.2361					1.3717
16	1.4586	1.3138					1.3931
17	1.6507	1.6461					.8413
18	1.8458	1.7574			.0015	.0625	1.7665
19	1.7924	1.7101	.1738	.1768	.189	.25	1.8381
20	1.4007	.9861	.3155	.3048	.346	.4268	1.0684
21	.4786	.3429	.349	.3185	.3612	.4405	.4481
22	.5014	.3704	.3414	.8062	.3704	.4908	.4847
23	1.0646	.3506	.5727	.3551	.3612	.9679	1.001
24	.5456	1.0562	1.1904	1.1142	.8535	.5365	.5274
Max	2.745	2.5423	3.2709	3.3074	3.0209	3.2586	2.8045
Min	.2058	.3201	.1738	.1768	.0015	.0625	.2683
Avg	1.0676	.9836	1.1232	1.1938	1.0410	1.0710	1.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254] BU 5461

Substation No/ Name :- 184089 / JOPUL

Feeder No / Name : 203 / BHOYEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5335	.3429	.4268	.2743	.3258	.4572
9	.7164	.6859					.6401
12			.6249	.6097	.5487	.5487	
22		.3601		.3086		.2058	
23	.2058		.4115		.3201		.2401
Max	.7164	.6859	.6249	.6097	.5487	.5487	.6401
Min	.2058	.3601	.3429	.3086	.2743	.2058	.2401
Avg	.4598	.5265	.4598	.4484	.3810	.3601	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184089 / JOPUL

Feeder No / Name : 206 / Khadakozar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.0364	.2743	.5487	.4287	.4458	1.3717
9	1.829	1.5242					1.5851
12			.9526	1.6766	1.2193	1.4632	
22		.2572		.5144		.4287	
23	.3429		.4572		.4801		.2572
Max	1.829	1.5242	.9526	1.6766	1.2193	1.4632	1.5851
Min	.3429	.2572	.2743	.5144	.4287	.4287	.2572
Avg	1.1304	.9393	.5614	.9132	.7094	.7792	1.0713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184210 / 33kV Rahud

Feeder No / Name : 201 / 11kV Rahud

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0883	1.2003	.4481	.4321	.4161		.9282
2	1.0883	1.2163	.4481	.4321	.4161		.9602
3	1.1523	1.2323	.4641		.4161		.9602
4	1.2483	1.2803	.4641	.4641	.4481		.9922
5	1.3443	1.3603	.5121	.4961	.4801		1.0562
6	1.3763	1.5203	.5761	.5441	.4481		1.2643
7	1.8404	1.9204	.4801		.4161		1.7284
8	1.9044	2.1765	.3041	.2561	.3041		1.7444
9	1.4083	1.5844	.2401	.2881			1.4403
10		.3201					.112
11	.064	.112	.112	.176			.128
12		.112	1.7604				.112
13	.064	.112	1.6004	1.4403		1.2323	
14		.112	1.4243	1.3443		1.0722	.128
15	.128	.112	1.3763	1.2323		1.0883	
16	.144	.112	1.4403	1.3763		1.3123	.144
17	.144	.144	1.6804	1.8084		1.3443	.16
18		.16	1.6804	1.6484		1.4563	.208
19	.3361	.4161	1.4883	1.4883		1.2163	.3841
20	.4801	.5121	.4641	.4481		.3201	
21	.3521	.4801	.4161	.4801		.3201	.3361
22	.3041	.4641	.4161	.4481		.2881	.3041
23	.2561	.4481	.4161	.4481		.2401	.2561
24	.192	1.1363	.4481	.4161	.4161		.9282
Max	1.9044	2.1765	1.7604	1.8084	.4801	1.4563	1.7444
Min	.064	.112	.112	.176	.3041	.2401	.112
Avg	.7458	.7602	.8113	.7834	.4179	.8991	.6798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184210 / 33kV Rahud

Feeder No / Name : 203 / 11kV Dongargaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3704	.3858		.4784	.4784		.3549
2	.3704	.4012		.5093	.4938		.3549
3	.3704	.4167		.5401	.5247		.3549
4				.5864	.6019		
5				.6636	.6944		
6				.7253	.8796		
7				1.0494	1.0648		
8				1.142	1.1265		
9			.3704	.8488			
12	.8488	.6173					.8179
13	.6944	.6327					.6944
14	.6944	.6173					.6944
15	.7099	.5864					.6481
16	.7716	.6636	.1235	.1235		.0926	.6944
17	.9259	.7562	.1389	.0926		.1235	.9722
18	.9877	.8179	.1852	.108		.2315	1.0802
19	.8951	.787	.2932	.216			.8642
20	.4012	.3704	2.5154	.3086		.3704	.3549
21	.3549	.2778	.2315	.2623		.3858	.3704
22	.3704	.216	.2006	.216		.3858	.3858
23	.3858	.1698	.1698	.1543		.3506	.3395
24	.3704	.3704		.463	.4784		.3549
Max	.9877	.8179	2.5154	1.142	1.1265	.3858	1.0802
Min	.3549	.1698	.1235	.0926	.4784	.0926	.3395
Avg	.5951	.5054	.4698	.4715	.7047	.2772	.5835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184210 / 33kV Rahud

Feeder No / Name : 204 / 11 KV SUJAL PLAST EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.0164	.0166	.0164	.0164		
2	.0164		.0166	.0164	.0164		
3	.0164		.0166	.0164	.0164		
4	.0164		.0166				
5			.0166	.0164	.0164		
6	.0164		.0166		.0164		
7	.0164	.0164	.0166	.0328	.0164		.0164
8	.0164	.0164	.0166	.0164	.0164		.0164
9	.0164	.0166	.0164	.0164			.0164
10	.0492	.0663		.0492			.0164
11	.0492	.0497	.0164	.0655			.0328
12	.0655	.0663		.0492			.0655
13	.0492	.0829		.0492		.0492	.0492
14	.0328	.0663		.0492		.0492	.0328
15	.0492	.0663		.0492		.0492	.0655
16	.0655	.0829		.0819		.0492	.0655
17	.0492	.0663		.0492		.0328	.0655
18	.0492	.0663		.0655		.0328	.0328
19	.0328	.0663	.0164	.0328		.0328	.0492
20	.0492	.0663	.0164	.0655		.0328	.0492
21	.0492	.0663	.0164	.0492		.0328	.0492
22	.0492	.0663	.0164	.0328		.0492	.0655
23	.0492	.0497	.0164	.0492		.0164	.0328
24		.0164	.0166	.0164	.0328		
Max	.0655	.0829	.0166	.0819	.0328	.0492	.0655
Min	.0164	.0164	.0164	.0164	.0164	.0164	.0164
Avg	.0373	.0532	.0165	.0402	.0185	.0388	.0424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184220 / 33kV Wadgaon Pangu

Feeder No / Name : 201 / 11kV Katerwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3721		.3292
2	.3927		.3738
3	.4081		.3772
4	.4235		.3995
5	.451		.4544
6	.5538		.5281
7	.703		.6036
8	.7167		.6824
9			.4801
10			.0549
11		.0772	.0823
12		.499	.0772
13		.4715	.0806
14		.415	.0823
15		.3807	.0806
16		.4201	.084
17			.0995
18			.1012
19			.1595
20			.2075
21			.168
22			.1766
23			.1406
24			.3412
Max	.7167	.499	.6824
Min	.3721	.0772	.0549
Avg	.5026	.3773	.2568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184220 / 33kV Wadgaon Pangu

Feeder No / Name : 202 / 11 KV TALEGAON(R)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7064		.7047
2	.7167		.6893
3	.7305		.7167
4	.7493		.751
5	.7682		.7253
6	.6464		.5521
7	.511		.4853
8	.3875		.3824
9			.2829
10			.1852
11		.144	.1406
12		.1612	.5195
13		.1646	.4835
14		.1749	.4887
15		.1732	.4818
16		.1989	.4904
17			.643
18			.5624
19			.5624
20			.5144
21			.6036
22			.7064
23			.7013
24			.6722
Max	.7682	.1989	.751
Min	.3875	.144	.1406
Avg	.652	.1695	.5435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184220 / 33kV Wadgaon Pangu

Feeder No / Name : 203 / 11kV Wadgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5796		.5161
2	.5916		.5778
3	.6053		.5916
4	.6276		.6001
5	.6584		.6516
6	.8162		.7064
7	1.0151		.8865
8	1.0511		1.0254
9			.7236
10			.1406
11		.1578	.1783
12		.619	.1578
13		.5418	.1783
14		.5161	.1852
15		.5213	.1783
16		.5761	.1835
17			.192
18			.2126
19			.2949
20			.3721
21			.3206
22			.3464
23			.2521
24			.5041
Max	1.0511	.619	1.0254
Min	.5796	.1578	.1406
Avg	.7431	.4887	.4157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184221 / chikhalambe

Feeder No / Name : 201 / EKRUKHE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0978	1.0883	.2721	.2401	.2591		.7287
2	1.065	1.1012	.2721	.2401	.2591		.7287
3	1.0159	1.1142	.2721	.2401	.2591		.7287
4	1.0159	1.2146	.2591	.2881	.2881		.8097
5	1.0202	.8745	.2429	.2881	.3361		.8907
6	1.0526	1.166	.2458	.3563	.3239		.9231
7	1.3117	1.2955	.2105	.2881	.3041		1.166
8	1.5043	1.5203	.192	.1943	.2056		1.2146
9	1.1934	1.2631	.16	.1802	.1619		.9878
10	.1134	.192	.0486	.1147	.1147	.1296	.0829
11	.0972	.1781	.048	.0497	.0328	.0324	.0995
12	.1296	.0972	1.3272	1.2018	1.2793	1.3279	.0995
13	.1296	.0972	1.3923	1.2651		1.6194	.1311
14	.0655	.1134	1.2631	1.2334		1.587	.1147
15	.128	.1296	1.0722	1.1069		.9069	.1296
16	.1475	.1457	1.1683	1.0242		.9231	.1311
17	.1457	.1457	1.2323	1.1683		1.1012	.1296
18	.1802		1.1683	1.2793		1.166	.1802
19	.1943	.2105	1.1012	.9831		.9878	.2155
20	.2753	.2429	.2721	.2652		.1781	.285
21	.1943	.2753	.2401	.2984		.1781	.2347
22	.2105	.2753	.2721	.3149		.1781	.2012
23	.1781	.2753	.2401	.2818		.1296	.1509
24	1.0978	1.1012	.2753	.2401	.2591		.7125
Max	1.5043	1.5203	1.3923	1.2793	1.2793	1.6194	1.2146
Min	.0655	.0972	.048	.0497	.0328	.0324	.0829
Avg	.5652	.6138	.5520	.5476	.3141	.7461	.4615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184221 / chikhalambe

Feeder No / Name : 202 / PAREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3239	.8002	.9012			.3563
2	.3277	.3277	.8097	.8907			.3563
3	.3605	.3239	.8097	.8802			.3563
4	.3605	.3401	.8962	.9602			.3563
5	.3932	.3361	.9717	1.0688			.3563
6	.421	.3887	1.0159	1.2963			.3563
7	.3239	.2753	1.3603	1.6804			.2591
8	.2241	.2241	1.5684	1.8842			.1943
9	.1658	.208	1.4413	1.5339	1.4899		.1619
10	.1147	.1296	.112	.0983	.0983	.1296	.1326
11	.1147	.0648	.1147	.1326	.1311	.1943	.0663
12	1.5546	1.4251	.112	.1265	.1619	.1943	1.7072
13	1.3123	1.4575		.1265		.1296	1.2125
14	1.0202	1.587		.1265		.1296	1.1469
15	1.1336	1.6194		.1265		.1296	1.278
16	1.4899	1.6194	.16	.096		.1296	1.2616
17	1.5546	1.5223	.1943	.128		.1296	1.3765
18	1.5402	1.3443	.208	.1619		.1296	1.5074
19	1.4899	1.3765	.3077	.2949		.2915	1.3592
20	.3725	.3239	.3521	.663		.2915	.3018
21	.4858	.3887	.426	.3481		.3239	.4024
22	.4696	.3887	.4481	.3315		.4858	.4024
23	.421	.3887	.2949	.2652		.3887	.3688
24	.3277	.3841	.6478	.7621			.3563
Max	1.5546	1.6194	1.5684	1.8842	1.4899	.4858	1.7072
Min	.1147	.0648	.112	.096	.0983	.1296	.0663
Avg	.6794	.6987	.6215	.6201	.4703	.2198	.6514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184221 / chikhalambe

Feeder No / Name : 203 / 11 KV DHAYNE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6062	.4534	1.1336	1.1203	1.166		.4696
2	.4752	.4534	1.1203	1.1069	1.166		.4696
3	.4915	.4481	1.1336	1.1469	1.2793		.4696
4	.5407	.4858	1.4575	1.1544	1.4243		.4858
5	.5898	.502	1.6518	1.2308	1.6324		.4049
6	.6802	.4858	1.7078	1.6324	1.9595		.421
7	.6154	.3563	1.7924	1.3004	2.1125		.3725
8	.5121	.2753	1.9109		1.9925		.2591
9	.5967	.3041	1.7814	1.4403	1.668		.2105
10	.6062	.3887	.3841	.3277	.2622	.3239	.1989
11	.5281	.3887	.3841	.431	.4588		.1326
12	1.9757	1.587	.3681	.3953	.4696		1.2929
13	2.0325	1.7004	.2721	.3953			1.491
14	1.6194	2.0243	.3361	.3953			1.4746
15	2.0081	2.0243	.3201	.427		.4858	1.4413
16	2.0567	2.0243	.2881	.4641		.4858	1.4255
17	1.587	2.0243	.3521	.4801		.4858	1.2146
18	1.8299	1.668	.4372	.4696		.4696	1.4419
19	1.5546	1.6194	.4961	.6554		.6316	1.3923
20	.5668	.6478	.5601	.5967		.6154	.3018
21	.6802	.6316	.5921	.5801		.5992	.3353
22	.4372	.6316	.5992	.5636		.5992	.3688
23	.6478	.4858	.4001	.2486		.5668	.3856
24	.5898	.5668	1.0526	1.1203	1.1012		.5668
Max	2.0567	2.0243	1.9109	1.6324	2.1125	.6316	1.491
Min	.4372	.2753	.2721	.2486	.2622	.3239	.1326
Avg	.9928	.9241	.8555	.7688	1.2840	.5263	.7094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184222 / HIRAPUR

Feeder No / Name : 201 / 11 KV PIMPALAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6001	.6859	.7716	.6516	.4458
2		.6859	.703	.7716	.6516	.4458
3		.7716	.7373	.7716		.3772
4		.9259	.7716	.7716		.3601
5		1.0802	.8402	.823		.3429
6		1.2174	.9259	.8573		.4115
7		1.3032	1.3032	.9431		.4287
8		1.3203	1.4232			.3429
9	.2743		1.1145		1.0974	.2915
10	.1543		.2058		.1886	.2058
11	.1372		.1715		.1543	.1715
12	.9774		.1715		.1543	1.1145
13	.8916		.1715		.0686	1.0288
14	.7545		.1543		.1543	1.0288
15	.7373		.1372	.1372	.1543	.9431
16	.8402		.1715		.1543	1.1145
17	1.1317				.1715	1.3717
18	1.1831				.1886	1.3717
19	1.1488		.3429		.2915	1.286
20	.3429		.3429		.4458	.4287
21	.3772		.3429		.463	.3944
22	.3944		.3429		.4801	.4801
23	.3772		.3429		.4458	.4801
24		.583	.6516	.6859	.6687	.4458
Max	1.1831	1.3203	1.4232	.9431	1.0974	1.3717
Min	.1372	.583	.1372	.1372	.0686	.1715
Avg	.6481	.9431	.5479	.7259	.3658	.6380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184222 / HIRAPUR

Feeder No / Name : 202 / 11 KV URDUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3601	.4115	.4458	.3944	.6859
2		.3772	.4287	.4458	.3944	.6859
3		.3772	.4458	.4458		.7716
4		.3601	.463	.4458		.8573
5		.3429	.4287	.4115		.9259
6		.2572	.3258	.3772		1.0288
7		.2058	.2058	.1715		1.0631
8		.1372	.1543	.1715		1.2003
9	1.2003		.1029		.1029	1.1317
10	.0857		.0857		.1029	.0857
11	.0686		.0857		.0686	.0857
12	.0343		1.0288		.9259	.0857
13	.0686		.8573		.8573	.0857
14	.0857		.7716		.6516	.0857
15	.0857		.6859	.4801	.6173	.0857
16	.0686		.7716		.6859	.0857
17	.12		1.1145		.9945	.0857
18	.12		1.1145		1.0117	.12
19	.2058		1.2003		1.046	.1715
20	.2229		.2743		.2401	.2229
21	.3086		.2915		.2572	.2058
22	.3429		.3429		.3429	.2058
23	.3772		.3601		.3429	.1715
24		.3601	.3944	.3944	.3772	.6687
Max	1.2003	.3772	1.2003	.4801	1.046	1.2003
Min	.0343	.1372	.0857	.1715	.0686	.0857
Avg	.2263	.3086	.5144	.3789	.5230	.4501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

CHANDWAD[254]

BU 5461

Substation No/ Name :- 184222 / HIRAPUR

Feeder No / Name : 203 / 11 KV HIRAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7202	.823	.8573	.8745	.5144
2		.7545	.8402	.8573	.8573	.5144
3		.8573	.8745	.8573		.5144
4		.8916	.9088	.9431		.4801
5		.6001	1.0802	1.0288		.4973
6		.583	1.3032	1.1145		.5144
7		.583	1.6118	1.1145		.5316
8		.7202	1.6118	1.5432		.463
9	.3429		1.3375		1.3375	.3429
10	.1372		.1372		.2229	.2058
11	.0857		.1029		.2229	.1715
12	1.166		.1029		.1543	1.1145
13	.8916		.1715		.0857	1.0288
14	.8059		.1543		.2058	.9431
15	.823		.1715	.0857	.2229	.8573
16	.9602		.1715		.2229	1.0288
17	1.0974				.2229	1.286
18	1.0974				.1886	1.286
19	1.166		.3429		.3258	1.1145
20	.2572		.3772		.5144	.3944
21	.2915		.4287		.5144	.3429
22	.3429		.3772		.5144	.4287
23	.4115		.3429		.4801	.4801
24		.703	.823	.8573	.8573	.5144
Max	1.166	.8916	1.6118	1.5432	1.3375	1.286
Min	.0857	.583	.1029	.0857	.0857	.1715
Avg	.6584	.7125	.6407	.9259	.4458	.6487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 201 / MARALGOI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2743	.5658	.7373	.6344	.6001	.2229
2	.2401	.2915		.7716	.6859	.6687	
3	.2572	.3086		.8402	.7373	.823	
4	.2915	.3258		.9602	.8059	.9945	
5	.3258	.3258		1.0288	.9774	1.0974	
6	.2915	.3429		1.2346	1.2174	1.1831	
7	.2572	.2743	1.6632	1.7833	1.5947	1.8347	.2743
8	.1886	.2229	1.6289	1.8861	1.869	1.7833	.1886
9	.1029	.1886	1.406	1.4918	1.4746	1.3889	.1715
10		.1886		.1886	.1715	.1543	
11		.1715		.1372	.12	.1372	
12		1.7661		.0857	.0857	.1029	
13		1.5432		.0686	.1029	.1029	
14		1.5261			.1029	.0857	
15		1.5432	.1029	.0686	.12	.12	1.5432
16		1.5261	.1029	.0857	.12	.12	1.4232
17		1.5604	.12	.1029	.12	.12	
18	1.4403	1.6118		.12	.12	.1029	
19	1.5261	1.4403		.1372	.1543	.1543	
20	.2915	.2572		.1886	.1715	.2858	
21	.2743	.2572		.2401	.2572	.2743	
22	.2572	.2401		.2572	.2915	.2572	
23	.2572	.2229		.2572	.2743	.2401	
24	.2572	.2572	.4973	.703	.6687	.5144	.2229
Max	1.5261	1.7661	1.6632	1.8861	1.869	1.8347	1.5432
Min	.1029	.1715	.1029	.0686	.0857	.0857	.1715
Avg	.4062	.6944	.7609	.5815	.5365	.5477	.5781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 202 / WAKAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	1.166	1.166	1.1317	1.1145	1.286	.9774
2	.9259	1.2003		1.1488	1.1317	1.3375	
3	1.0288	1.3375		1.2003	1.2003	1.406	
4	1.2174	1.406		1.4575	1.2689	1.4232	
5	1.3032	1.5089		1.5089	1.406	1.4403	
6	1.6289	1.6289		1.4403	1.3032	1.4575	
7	2.0576	2.2805	.9602	1.1831	.8402	1.3546	1.7147
8	2.3148	2.332	.9945	.8745	.823	1.0631	1.9547
9	1.8861	2.0405	.703	.7545	.7545	.8573	1.6289
10		.583		.6001	.6001	.583	
11		.5144		.5487	.5487	.5658	
12		.3772		2.0748	2.0748	1.6632	
13				1.9547	2.0576	1.5947	
14				1.869	1.8861	1.5432	
15		.2401	2.2291	1.7833	1.8004	1.5432	.583
16		.2743	2.1091	1.8347	1.8176	1.5261	.5487
17		.6173	2.0062	1.8861	1.9547	1.5432	
18	.7373	.6687		1.7147	1.9204	1.6289	
19	1.0288	1.046		1.4575	1.6289	1.3032	
20	1.5089	1.4403		1.3375	1.3717	1.3717	
21	1.3375	1.3032		1.2174	1.3375	1.2517	
22	1.2689	1.2346		1.2003	1.3203	1.2174	
23	1.1317	1.1831		1.1831	1.2174	1.1831	
24	.8059	1.1145	1.166	1.1488	1.1488	1.2003	.9602
Max	2.3148	2.332	2.2291	2.0748	2.0748	1.6632	1.9547
Min	.7373	.2401	.703	.5487	.5487	.5658	.5487
Avg	1.3171	1.1590	1.4168	1.3546	1.3553	1.3060	1.1954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 203 / MANORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.5144	.703	.8573	.823	.8745	.4458
2	.5144	.6173		.8402	.8402	.8916	
3	.5487	.6516		.8745	.8916	.9088	
4	.5658	.6859		.8916	.9259	.9259	
5	.6173	.9145		.9259	.9945	.9602	
6	1.1488	.8745		.9431	.8573	.9945	
7	1.5947	1.5947	.0789	.7373	.7716	.8573	1.2003
8	1.8861	1.9204	.703	.5658	.583	.6859	1.5432
9	1.4575	1.3717	.5658	.4458	.4801	.5144	1.046
10		.3429		.3258	.3429	.4115	
11		.3601		.1886	.2743	.2743	
12		.3429		1.046	.823	.6687	
13		.3258		.8745	.7888		
14		.3258		.823	.7202	.6001	
15		.2915	1.2174	.9259	.6001	.6687	.0429
16		.3258	1.1317	1.0631	.7888	.6859	.4115
17		.4115	1.2003	1.1317	1.1831	.9088	
18	.3772	.4458		1.1145	1.3203	.9259	
19	.7716	.7373		1.0974	1.1145	.7373	
20	.9259	.8916		.5316	.7888	.8402	
21	.8059	.8402		.823	.7545	.7545	
22	.7716	.8059		.8573	.8916	.7373	
23	.7373	.7716		.8402	.8573	.703	
24	.5144	.4973	.703	.8402	.8059	.8573	.4115
Max	1.8861	1.9204	1.2174	1.1317	1.3203	.9945	1.5432
Min	.3772	.2915	.0789	.1886	.2743	.2743	.0429
Avg	.8584	.7025	.7879	.8152	.8009	.7559	.7287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 204 / KH ZUNGE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0822	1.0136	2.3072	2.4786	2.2824	2.0157	1.0384
2	1.0822	1.0479	1.2955	2.572	2.2405	2.1185	.6097
3	1.0993	1.0651	1.2955	2.6234	2.2576	2.1871	.6097
4	1.1679	1.0822	1.3717	2.7683	2.2576	2.4005	.6859
5	1.1927	1.1755	1.3717	2.9131	2.6234	2.6063	.6859
6	1.1413	1.1927	1.5242	3.3055	3.0598	2.9131	.6859
7	1.0555	1.0727	4.0123	3.978	3.3932	3.6294	1.107
8	.7658	.9793	4.2162	4.3438	4.0885	3.9171	.783
9	.562	.5791	4.2066	4.0009	3.6961	3.6694	.5963
10		.4687	.2286	.3925	.4344	.3067	.3048
11		.4001	.1524	.3067	.4172	.2724	.2286
12		4.0295	.1524	.341	.3067	.3239	1.7528
13		4.4372	.1524	.3239	.3067	.1886	2.1338
14		4.5992	.0762	.3239	.3067	.3239	2.21
15		4.3	.2305	.3239	.3067	.3067	3.9247
16		4.079	.2305	.341	.2896	.3239	3.6446
17		4.1476	.3067	.341	.3067	.341	1.9814
18	3.4675	4.5478	.1524	.3925	.3239	.341	2.1338
19	4.2581	4.2485	.2286	.5201	.5201	.5715	2.1338
20	1.0822	.8687	.6097	.8687	.9716	1.0136	.4572
21	1.0136	.9202	.6097	.9202	1.0136	1.0136	.5335
22	1.1241	.9793	.6097	.9793	1.0136	1.0136	.5335
23	1.1413	1.0136	.6097	.9965	1.0136	1.0555	.6097
24	1.1584	1.6994	2.2214	2.2919	2.2405	1.2098	1.0212
Max	4.2581	4.5992	4.2162	4.3438	4.0885	3.9171	3.9247
Min	.562	.4001	.0762	.3067	.2896	.1886	.2286
Avg	1.3996	2.0811	1.1738	1.6103	1.4863	1.4193	1.2669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 205 / VINCHUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.6173	.583	.5144	.6001	.2229
2	.2229	.2401		.6001	.5487	.6516	
3	.2401	.2743		.6344	.6687	.823	
4	.2915	.3429		.6859	.7545	.9259	
5	.3429	.3772		.7888	.8916	.9945	
6	.2743	.3944		.9259	1.1831	1.0288	
7	.1715	.2572	1.5604	1.5775	1.6118	1.6461	.2915
8	.12	.1715	1.7661	1.6118	1.749	1.6975	.1543
9	.0857	.12	1.2689	1.3889	1.3375	1.3717	.12
10		.12		.12	.1715	.12	
11		.1029		.0686	.0857	.0857	
12		1.4918		.0686	.0514	.0686	
13		1.1831		.0686	.0514		
14		1.0802			.0514	.0686	
15		1.2174	.0686	.0686	.0514	.1029	1.3203
16		1.3032	.0686	.0514	.0514	.0857	1.3032
17		1.5947	.0514	.0514	.0514	.1029	
18	1.3546	1.6461		.1029	.0686	.0686	
19	1.6461	1.3032		.1372	.1543	.2229	
20	.2915	.2572		.1886	.3086	.2743	
21	.2401	.2572		.2229	.2572	.2401	
22	.2058	.2743		.2229	.2572	.2401	
23	.1886	.2572		.2058	.2229	.2229	
24	.2058	.1886	.5316	.5658	.5316	.4973	.2058
Max	1.6461	1.6461	1.7661	1.6118	1.749	1.6975	1.3203
Min	.0857	.1029	.0514	.0514	.0514	.0686	.12
Avg	.3805	.6109	.7416	.4756	.4844	.5278	.5169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 206 / RUI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.6859	.3258	.3086	.2915	.2915	.4458
2	.6344	.7202		.3258	.2915	.2915	
3	.6687	.7545		.3086	.2915	.2915	
4	.6859	.823		.3086	.3086	.2915	
5	.6859	.8573		.3258	.3258	.2915	
6	.9088	.8745		.2915	.2572	.2915	
7	1.166	1.3546	.2229	.2401	.2229	.2572	1.0288
8	1.406	1.4232	.1886	.1715	.1543	.1886	1.1488
9	1.2174	1.2003	.1886	.1715	.1543	.1715	.0995
10		.0686		.0686	.1029	.1715	
11		.0686		.0171	.0686	.0686	
12		.1029		1.3546	1.1317	.8745	
13		.0857		1.2003	1.1488	1.0288	
14		.1543		1.0802	1.0631	1.0117	
15		.1029	1.3032	1.0288	.9945	.8402	.1029
16		.1029	1.1831	.9259	1.0117	.8402	.12
17		.1372	1.1488	.9431	1.0117	.8745	
18	.0857	.1543		.9431	.9774	.9088	
19	.1543	.2401		.9259	.9431	.8059	
20	.2401	.2915		.1543	.3086	.2401	
21	.2572	.8402		.2743	.2915	.2229	
22	.2058	.7888		.2915	.3258	.2058	
23	.1543	.2401		.3086	.3258	.1886	
24	.6344	.6344	.3258	.3258	.2915	.3086	.4458
Max	1.406	1.4232	1.3032	1.3546	1.1488	1.0288	1.1488
Min	.0857	.0686	.1886	.0171	.0686	.0686	.0995
Avg	.6087	.5294	.6109	.5123	.5123	.4565	.4845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 207 / Kolgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4287	.6687	.9431	.8916	.7888	.4973
2	.3944	.4801		.9602	.9259	.823	
3	.3944	.5144		.9431	.9431	.8573	
4	.463	.5144		.9774	.9774	.9259	
5	.5316	.6001		.9602	1.0288	.9259	
6	.5658	.583		.9774	1.0974	.9431	
7	.6344	.5316	1.046	1.0802	1.1488	1.1145	.5144
8	.4287	.0412	1.1831	1.1488	1.166	1.1488	.4115
9	.3258	.3429	1.1831	1.0802	1.0974	1.0288	.2743
10		.2572		.2058	.1715	.2058	
11		.1886		.1886	.12	.1372	
12		.2572		.1543	.1543	.1543	
13		1.2517		.12	.1543	.1715	
14		1.2346			.1543	.1886	
15		1.2003	.12	.1372	.1543	.2229	1.2517
16		1.166	.12	.1543	.1543	.2915	1.2517
17		1.1831	.1372	.1543	.1372	.1715	
18	1.1488	1.2003		.2915	.2401	.1543	
19	1.286	1.2174		.4115	.3258	.3944	
20	.5658	.4801		.4287	.6001	.5144	
21	.4115	.5144		.3601	.4287	.5144	
22	.4115	.4973		.4115	.3601	.5316	
23	.4115	.4458		.4287	.3944	.5144	
24	.3772	.4115	.6516	.9774	.8916	.7716	.4801
Max	1.286	1.2517	1.1831	1.1488	1.166	1.1488	1.2517
Min	.3258	.0412	.12	.12	.12	.1372	.2743
Avg	.5455	.6476	.6387	.5867	.5716	.5623	.6687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 208 / Dhanora

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.3375	.4515	.4687	.4687	.4687	1.0212
2	1.3546	1.3718	.2286	.4858	.4687	.4858	.6097
3	1.3889	1.4747	.2286	.4687	.4858	.4858	.6097
4	1.4823	1.5851	.2286	.4687	.4858	.5029	.6097
5	1.5166	1.7299	.3048	.4858	.5963	.5791	.6097
6	1.9605	1.9509	.3048	.562	.5449	.5791	.6859
7	2.7777	2.1719	.4344	.4172	.4344	.4172	2.4367
8	3.0922	3.0579	.2896	.2724	.3486	.2896	2.6063
9	2.6311	2.553	.3582	.2134	.1962	.2896	2.3243
10		.3315	.1524	.1962	.1791	.1791	.1524
11		.1791	.0762	.1619	.1619	.1619	.0762
12		.1791	1.1431	1.789	2.0443	1.6442	.0762
13		.1791	1.2955	1.8137	2.1033	.9145	.0762
14		.1619	1.2955	.9145	1.9242	1.7375	.0762
15		.1791	2.2405	1.6956	1.6613	1.6271	.1619
16		.1791	2.1471	1.8919	1.6099	1.5166	.1619
17		.1962	2.2481	2.2062	2.0957	1.7718	.0762
18	.1791	.1791	1.1431	2.0004	1.9928	1.848	.0762
19	.341	.3239	.9907	1.8899	1.8309	2.0633	.1524
20	.4687	.4687	.2286	.4001	.4858	.4344	.2286
21	.4515	.4515	.2286	.4344	.4344	.4344	.2286
22	.4687	.4515	.2286	.4515	.4687	.4344	.2286
23	.4687	.4515	.2286	.4687	.4687	.4344	.2286
24	1.2441	.8459	.4515	.4687	.4687	.8498	1.0041
Max	3.0922	3.0579	2.2481	2.2062	2.1033	2.0633	2.6063
Min	.1791	.1619	.0762	.1619	.1619	.1619	.0762
Avg	1.3216	.9162	.7053	.8594	.9150	.8396	.6049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 209 / 11 kV New Rui

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.5144	.5144	.5144	.5144	.6001	.463
2	.4973	.5658		.5316	.5316	.6173	
3	.583	.6344		.5487	.5487	.0634	
4	.703	.6859		.5316	.5658	.6516	
5	.7888	.8059		.6001	.6001	.6687	
6	1.0631	.8402		.6344	.5658	.6859	
7	1.3375	1.3375	.5658	.5316	.5487	.5316	1.0974
8	1.3717	1.4232	.4458	.4115	.4115	.4115	1.166
9	1.166	1.166	.3772	.3601	.3429	.3429	.9945
10		.2229		.2915	.2401	.2401	
11		.1886		.1372	.1715	.2229	
12		.2058		.9602	1.046	.8573	
13		.2229		.8745	.9945		
14		.2401		.8059	.9259	.8059	
15		.2229	.9774	.8573	.823	.7888	.2401
16		.2401	.9431	.9431	.8573	.7545	.2572
17		.2743	.9774	1.0117	.9259	.9088	
18	.2572	.2915		.9431	.9259	.8916	
19	.4458	.4458		.9088	.9259	.8059	
20	.6173	.5487		.4115	.5144	.4973	
21	.4458	.6001		.6001	.583	.5658	
22	.4458	.5658		.583	.6001	.5316	
23	.4458	.5316		.5658	.583	.5144	
24	.4973	.4801	.5144	.5316	.5316	.583	.4458
Max	1.3717	1.4232	.9774	1.0117	1.046	.9088	1.166
Min	.2572	.1886	.3772	.1372	.1715	.0634	.2401
Avg	.6945	.5523	.6644	.6287	.6366	.5887	.6663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 211 / 11 kV Canol feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.6344	.3772	.3944	.3772	.4287	.3944
2	.4801	.6516		.4115	.3772	.4458	
3	.5144	.6859		.4115	.3944	.463	
4	.5144	.7202		.4287	.4115	.4801	
5	.5487	.7373		.463	.4287	.4973	
6	.8573	.7545		.4973	.4458	.5144	
7	1.2003	1.2174	.463	.4115	.4801	.4801	.9088
8	1.5089	1.406	.3944	.4115	.3601	.4287	1.166
9	1.4232	1.4403	.3601	.2915	.2915	.3601	.9259
10		.1886		.2058	.2058	.2572	
11		.1715		.1543	.1715	.1886	
12		.1543		1.0288	1.0802	.8916	
13		.1543		.9431	1.2003	.7545	
14		.1715			1.3717		
15		.1886	1.1488	.9431	1.6461	.7545	.2401
16		.2058	1.046	.9774	.8573	.7373	.2572
17		.2058	1.046	.9259	.8916	.8402	
18	.1886	.2058		.8573	.9088	.9259	
19	.3258	.3601		.7716	.9088	.823	
20	.5144	.4954		.4287	.3429	.4287	
21	.4458	.4458		.3944	.3601	.3429	
22	.3772	.4287		.3944	.4115	.3258	
23	.3258	.4115		.3944	.4115	.3429	
24	.463	.6344	.3772	.4115	.0377	.4115	.3944
Max	1.5089	1.4403	1.1488	1.0288	1.6461	.9259	1.166
Min	.1886	.1543	.3601	.1543	.0377	.1886	.2401
Avg	.6344	.5279	.6516	.5457	.5988	.5271	.6124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184005 / 33/11 kV DEOGAON

Feeder No / Name : 212 / 11 kV Tukaram Baba

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4287	.8402	1.0117	.7373	.6859	.3601
2	.3944	.4801		1.046	.7716	.823	
3	.4115	.5144		1.0802	.8745	.8916	
4	.4287	.5316		1.0631	.9259	.9945	
5	.4801	.5487		1.0802	1.0288	1.0974	
6	.4973	.5658		1.1145	1.2003	1.1317	
7	.463	.463	1.2689	1.3375	1.3203	1.2346	.4115
8	.3429	.3429	1.406	1.406	1.4575	1.3889	.2915
9	.2572	.2572	1.3203	1.286	1.286	1.2003	.2401
10		.2401		.2915	.2572	.3258	
11		.2229		.1886	.1886	.1886	
12		1.0402		.1715		.1886	
13		1.5604		.1886	.1886		
14		1.5261			.1886	.2058	
15		1.5432	.2058	.1886	.1886	.1715	1.4575
16		1.5261	.2058	.1715	.2058	.1886	.1389
17		1.4918	.2058	.1886	.1886	.1886	
18	1.3203	1.3717		.2229	.2058	.2058	
19	1.4918	1.2689		.2572	.2915	.3086	
20	.4115	.3601		.3601	.4458	.4115	
21	.4287	.3429		.3944	.4115	.3944	
22	.4115	.3429		.3944	.4115	.3772	
23	.3944	.3258		.3601	.3601	.3601	
24	.3772	.3772	.7373	.9945	.7373	.6173	.3429
Max	1.4918	1.5604	1.406	1.406	1.4575	1.3889	1.4575
Min	.2572	.2229	.2058	.1715	.1886	.1715	.1389
Avg	.5305	.7364	.7738	.6434	.6031	.5904	.4632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184031 / 33/11 kV LASALGAON

Feeder No / Name : 201 / TAKALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6001	.5365		
2				.6154	.5365		
3				.724	.6036		
4				.7602	.6859		
5		.6613		.6706	.7042	.6371	
6		.6706		.7621	1.0059		
7				1.0722	1.4083		
8				1.3108	1.643	.9221	.6516
9	.427	.5376		.2721	1.2803	1.0059	.4801
10	.3321					.3429	.3658
11		.3005	.2846	.2721	.2881	.181	.3292
12	.8065	.8223	.2688	.3201	.3201	.3086	1.2489
13	.7907		.2721			.2743	1.1336
14		.7682		.3041	.2846	.2286	1.0498
15		.8002		.3201	.2688	.2915	.8886
16	.8288	.7522	.253	.3321		.2572	1.0212
17	.4915	.9945	.3048	.3812	.3391		1.2407
18	1.0395	1.2174	.3658	.431	.4578	.5765	1.4419
19	1.0395	.9602		.503	.5668		1.3245
20	.6539	.5944	.5792	.6539	.6613	.6613	.6539
21	.6706	.6687	.5944	.6539	.6464		.6539
22	.6783	.5944	.6516	.6371			.6539
23	.6859	.6371	.5335	.6036			.6539
24	.6539		.503	.5335	.3041	.5596	
Max	1.0395	1.2174	.6516	1.3108	1.643	1.0059	1.4419
Min	.3321	.3005	.253	.2721	.2688	.181	.3292
Avg	.6999	.7320	.4192	.5788	.6601	.4805	.8620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184031 / 33/11 kV LASALGAON

Feeder No / Name : 202 / KH MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3201	.3688		
2				.3201	.3688		
3				.3353	.3688		
4				.3353	.4024		
5		.2515		.3658	.4024	.4359	
6		.3018		.4458	.4024		
7				.3048	.3353		
8				.2429	.2515	.2374	.6687
9	.4744	.5441		.2372	.1581	.218	.4268
10	.0633					.2229	.0857
11		.112	.1107	.1107	.112	.12	.12
12	.1265	.096	.4428	.2688	.2846	.3201	.1629
13	.1107		.427			.2058	.1341
14		.0791		.253	.3041	.1981	.1296
15		.0949		.3163	.2561	.2896	.1341
16	.1844	.1581	.3321	.3041		.3429	.1543
17	.1844	.1715	.3658	.4096	.4694		.1677
18	.1658	.1524	.4572	.3978	.5935	.5935	.1677
19	.2515	.3086		.3812	.4191	.4409	.285
20	.3018	.3658	.2896	.2818	.3353	.3222	.3353
21	.3353	.3506	.3201	.3149	.3978		.3688
22	.3353	.381	.3201	.3353			.3688
23	.3149	.3772	.3353	.3688			.3647
24	.2347		.373	.3201	.2846	.3688	
Max	.4744	.5441	.4572	.4458	.5935	.5935	.6687
Min	.0633	.0791	.1107	.1107	.112	.12	.0857
Avg	.2372	.2496	.3431	.3168	.3429	.3083	.2546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184031 / 33/11 kV LASALGAON

Feeder No / Name : 204 / MARALGOI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.463	.4694		
2				.4887	.4641		
3				.4534	.4694		
4				.4268	.4973		
5		.5868		.442	.5304	.5935	
6		.7209		.4725	.4641		
7				.4525	.4024		
8				.3258	.3018	.373	1.1126
9	1.0437	1.1203		.2294	.2241	.2429	.9259
10	.1581					.2401	.0686
11		.1898	.112	.1265	.1265	.0686	.1372
12	.1898	.1265	1.1043	1.0595	.933	1.2003	.1844
13	.1739		1.0753			1.0212	.1844
14		.1581		1.0562	.8642	1.0117	.1886
15		.1898		.8482	.8962	.9774	.1943
16	.1966	.1581	.9172	1.0082		.9259	.2286
17	.1638	.2401	1.1488	1.1065	1.1145		.2458
18	.2321	.2591	1.1145	1.0059	1.0852	1.153	.2683
19	.3185	.3353		.9221		.8478	.3688
20	.4641	.3963	.381	.3932	.4578	.39	.3688
21	.4694	.3963	.4287	.4024	.431		.4024
22	.4694	.4801	.381	.4359			.3978
23	.4527	.4801	.4115				.4024
24	.5365		.4748	.4268	.9122	.4748	
Max	1.0437	1.1203	1.1488	1.1065	1.1145	1.2003	1.1126
Min	.1581	.1265	.112	.1265	.1265	.0686	.0686
Avg	.3745	.3892	.6863	.5974	.5913	.6800	.3549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184031 / 33/11 kV LASALGAON

Feeder No / Name : 205 / LASALGAON U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3717	1.5089		
2				1.3413	1.5089		
3				1.4575	1.5775		
4				1.4175	1.5775		
5		1.5261		1.448	1.595	1.869	
6		1.7661		1.9033	1.6804		
7				1.8176	1.7147		
8				1.4937	1.6118	1.7511	1.7833
9	.9014	1.4864		1.5203	1.5181	1.8642	1.448
10	1.0437					1.6004	1.4937
11		1.5181	1.5971	1.5684	1.4403	1.7661	1.6461
12	1.4232	1.5181	1.5971	1.5684	1.6484	1.5851	1.7353
13	1.4232		1.5971			1.8004	1.7194
14		1.4243		1.5339	1.5813	1.5242	1.4022
15		1.4403		1.5023	1.5023	1.5394	1.6632
16	1.5432	1.4864	1.5684	1.4706	1.5546	1.5851	1.6975
17	1.5089	1.6118	1.5699	1.6975	1.749		1.8004
18	1.5432	1.4632	1.5699	1.749	1.56		1.9631
19	1.7353	1.989		1.893	2.1091	2.1033	2.2085
20	2.0633	1.9662	2.0119	2.1735	1.7974	2.2977	2.4253
21	1.9806	2.1605	2.0919	2.2624	2.1262		2.2085
22	1.9547	2.0233	1.7528	1.8861			2.1033
23	1.8461	1.6004	1.6004	1.8347			2.0683
24	1.5261			1.4175	1.6804	1.7002	
Max	2.0633	2.1605	2.0919	2.2624	2.1262	2.2977	2.4253
Min	.9014	1.4243	1.5684	1.3413	1.4403	1.5242	1.4022
Avg	1.5764	1.6653	1.6957	1.6513	1.6521	1.7682	1.8354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184031 / 33/11 kV LASALGAON

Feeder No / Name : 206 / BARC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0305	.0191	.0171	.0152
9		.0316	.0191	.0305	.0305
10		.0316		.0343	.0305
11	.0191	.0316	.0312	.0171	.0324
12	.0191	.0474	.0381	.0305	.0457
13	.016			.0343	.0362
14		.0324	.0377	.0171	.0316
15		.0486	.0377		.0305
16	.0316	.032	.0377		.0343
17	.0343	.0191	.0335		.0191
18	.0171	.0191	.017		.0191
Max	.0343	.0486	.0381	.0343	.0457
Min	.016	.0191	.017	.0171	.0152
Avg	.0229	.0324	.0301	.0258	.0296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184031 / 33/11 kV LASALGAON

Feeder No / Name : 209 / Lasalgaon(AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3772	.3353		
2				.4115	.3277		
3				.4115	.3688		
4				.4458	.4024		
5		.1509		.4115	.463	.5765	
6		.1658		.5344	.503		
7				.8048	.7377		
8				.823	1.0059	1.0227	.1543
9	.0876	.1524		.7888	.7186	.6249	.0762
10	.0701					.061	.0514
11		.0762	.0566	.0526	.0701	.061	.0648
12	1.0341	.6097	.0754	.0876		.0724	.8309
13	.9816		.0754			.0838	.8328
14		.9335		.0791	.0943	.0762	.6859
15		.9526		.0791	.1132	.0914	.6167
16	.8718	.5609	.0943	.0876		.1029	.6249
17	.8551	.6859	.1029	.0972	.0663		.7625
18	.8383	.7316	.0686	.0819	.0648	.0848	.8551
19	.7377	.5792		.0819	.1187	.0339	.6539
20	.1638	.1372	.1219	.1509	.1677	.1526	.0819
21	.1658	.12	.1219	.1341	.1492		.1492
22	.1677	.1067	.0914	.0983			.1492
23	.1492	.081	.0762	.0819			.1509
24	.1326		.3391	.3353	.1132	.39	
Max	1.0341	.9526	.3391	.823	1.0059	1.0227	.8551
Min	.0701	.0762	.0566	.0526	.0648	.0339	.0514
Avg	.4812	.4029	.1112	.2935	.3233	.2453	.4213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184031 / 33/11 kV LASALGAON

Feeder No / Name : 210 / 11 kv aishwarya express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0457	.0572		
2				.0457	.0572		
3				.0486	.0572		
4				.0457	.0572		
5		.0572		.0457	.0572	.0509	
6		.0572		.0543	.0572		
7				.0503	.0572		
8				.0457	.0572	.0514	.0457
9	.048			.056	.0562	.0514	.0457
10	.0474			.056		.0486	.0514
11			.048	.0562	.0561	.0543	.0446
12	.0474		.048	.0561	.0935	.0486	.0633
13	.0469		.048			.0486	.0543
14				.056	.1038	.0514	.0457
15				.056	.0865	.0457	.0457
16	.0572	.0474	.048	.112	.064	.0457	.0457
17	.1905	.0514	.0514		.1187		.0572
18	.0953	.0457	.0514	.0953	.0343	.0509	.0572
19	.0572	.0514		.0572	.0509	.0509	.0572
20	.0572	.0486	.0457	.0572	.0503	.0514	.0572
21	.0572	.0514	.0457	.0572	.0497		.0572
22	.0572	.0457	.0457	.0572			.0572
23	.0572	.0503	.0514	.0572			.0572
24	.0572		1.6289	.0457	.0572	.0509	
Max	.1905	.0572	1.6289	.112	.1187	.0543	.0633
Min	.0469	.0457	.0457	.0457	.0343	.0457	.0446
Avg	.0674	.0506	.1920	.0571	.0639	.0501	.0527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184073 / 33/11 kV VINCHUR

Feeder No / Name : 204 / MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1608	.2462	.1981	.2065	.2195	.1997	.2103
2	.1631	.2202	.1997	.1936	.2042	.189	.2035
3	.202	.1959	.2004	.1943	.1486	.1943	.2157
4	.2301	.1943	.1989	.1936	.2202	.1905	.2324
5	.1821	.1905	.1989	.1913	.2119	.1867	.202
6	.1532	.2263	.189	.1859	.173	.1867	.1707
7	.1692	.2286	.192	.1799	.1669	.2195	.1494
8	.096	.2065	.1928	.2004	.1722	.205	.1478
9	.1257	.1753	.1799	.1936	.173	.1837	.1631
10	.2096	.2439	.253	.2401	.1959	.1882	.1578
11	.1989	.2149	.2538	.1943	.1669	.189	.1997
12	.1303	.1471	.1875	.1486	.1776	.125	.1867
13	.1433	.096	.1547	.1486	.1859	.1128	.1791
14	.2774	.1288	.1654	.1456	.1364	.0922	.1318
15	.2583	.1387	.1669	.1288	.1471	.1646	.1471
16	.2622	.16	.1844	.0983	.1677	.1539	.1265
17	.1135	.1235	.1814	.0838	.1311	.1135	.1463
18	.1677	.1235	.173	.096	.0069	.1014	.157
19	.2065	.1151	.1654	.1318	.1387	.1052	.1296
20	.2035	.1753	.3391	.2279	.1372	.1539	.1547
21	.176	.1943	.2827	.2218	.1738	.1913	.1913
22	.1959	.2804	.2507	.2522	.2263	.2164	.2027
23	.2347	.2637	.2096	.208	.2187	.2225	.1867
24	.2462	.2004	.2103	.192	.2012	.2309	.1623
Max	.2774	.2804	.3391	.2522	.2263	.2309	.2324
Min	.096	.096	.1547	.0838	.0069	.0922	.1265
Avg	.1878	.1871	.2053	.1774	.1709	.1715	.1731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184073 / 33/11 kV VINCHUR

Feeder No / Name : 206 / PPF

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2317	.16	.285	.2942	.2484	.2271	.2119
2	.2256	.1844	.2713	.2644	.2439	.2256	.1936
3	.2317	.173	.2721	.2583	.2454	.2218	.1974
4	.2446	.1837	.2591	.2614	.2378	.2195	.1745
5	.2294	.1859	.2599	.2454	.2401	.2286	.1974
6	.2256	.2058	.2484	.2599	.234	.2423	.2012
7	.2065	.1684	.2393	.2629	.2241	.2294	.1882
8	.2119	.1745	.2088	.2789	.2355	.2477	.2126
9	.2301	.1722	.1981	.2492	.2233	.2362	.1791
10	.2507	.173	.2103	.2583	.2301	.2583	.1806
11	.2294	.2164	.2385	.2568	.2408	.2583	.2073
12	.2241	.2149	.2439	.2614	.2568	.2774	.2484
13	.2241	.1799	.2202	.2492	.2545	.2553	.2492
14	.2134	.1494	.237	.2347	.2477	.2301	.2591
15	.2126	.1661	.2362	.2012	.2637	.1974	.2378
16	.2058	.192	.2263	.1928	.2431	.2149	.2279
17	.1974	.1745	.2583	.1882	.2553	.2126	.2347
18	.1852	.1684	.2446	.2111	.3018	.2119	.2073
19	.2073	.1783	.2378	.2271	.2606	.2393	.2271
20	.1821	.202	.2027	.2347	.1859	.218	.2035
21	.1661	.1837	.1852	.2233	.1501	.176	.1783
22	.1837	.2919	.2157	.2279	.1532	.1684	.1959
23	.176	.2934	.253	.2484	.1837	.1669	.2774
24	.1623	.2774	.2858	.266	.2027	.2256	.2736
Max	.2507	.2934	.2858	.2942	.3018	.2774	.2774
Min	.1623	.1494	.1852	.1882	.1501	.1669	.1745
Avg	.2107	.1946	.2391	.2440	.2318	.2245	.2152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184227 / 33/11 kV Maralgoi

Feeder No / Name : 201 / 11KV Gondegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7087	.7011	.6588	.7545	.8063		.7545
2	.7362	.7108	.6859	.7888	.8328		.7975
3	.7712		.6859	.8149	.8505		.7975
4	.7888	.7545	.7716	.8495	.8764		.8139
5	.823	.8048	.8669	.929	.9568		.8322
6			1.0802	1.1096	1.1744		.5895
7	.7865		1.5893	1.7736	1.6409	1.6057	.502
8	.6154	.4902	1.9498	2.0481	1.1203	1.8461	.4801
9	.4111	.4012	1.4373		1.2963	1.5604	.3953
10	.3258	.2481	.2658	.3189	.2303	.2254	.3258
11	.2254	.2149	.2629	.2753	.2058	.2058	.2658
12	1.4548	1.2163	.2372	.253	.1829	.1981	1.3123
13	1.3108	1.0536	.216	.1907	.1783	.1981	1.2193
14	1.174	.9808	.2286	.1957	.2559	.2134	1.0669
15	1.0212	.9808	.216	.208	.2561	.2134	
16	1.2041	1.0802	.2343	.2315	.1829	.2439	.2743
17	1.4937	1.078	.2343	.2656	.2214	.2286	.3048
18	1.3279	1.25	.2743	.2107	.2743	.2469	.3506
19	1.1544	1.2492	.4218	.3963	.4999	.4744	1.1069
20	.8299	.7655	.7545	.7356	.7468	.7922	.8299
21	.7655	.7095	.7167	.679	.6348	.7282	.7922
22	.7655	.6722	.679	.6413		.811	.7545
23	.7468	.6413	.6979	.6036			.7545
24	.7087	.7011	.6584	.7373	.815		.8048
Max	1.4937	1.25	1.9498	2.0481	1.6409	1.8461	1.3123
Min	.2254	.2149	.216	.1907	.1783	.1981	.2658
Avg	.8761	.7954	.6593	.6526	.6472	.6120	.7011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184227 / 33/11 kV Maralgoi

Feeder No / Name : 202 / 11KV Shivapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.3506	.5028	.5144	.4908		.3601
2	.3506	.3467	.4973	.5144	.4961		.3467
3	.3856	.3467	.4973	.5375	.5316		.3467
4	.4115	.3772	.5548	.5548	.5316		.373
5	.4801	.4359	.5895	.6135	.567		.3814
6	.5735	.4915	.6001	.5548	.5609		.4334
7	1.0814	.9374	.4588	.4973	.4641	.426	.8097
8	1.2955	1.2018	.3563	.4096		.3239	1.0562
9	1.1385	.9877	.3437	.2343	.216	.3005	.8697
10	.2534	.1772	.2835	.2126	.2126	.2427	.2715
11	.1734	.1791	.2629	.1619	.1715	.1715	.2658
12	.1898	.16	.8855	.6642	.6401	.3963	.1875
13		.2107	.8025	.5575	.5944	.5487	.1981
14	.1219		.6554	.602	.5117	.5792	.1677
15	.1524	.1189	.6944	.5944	.3201	.5182	.1524
16	.1829	.1543	.7811	.7562	.6706	.6097	.1981
17	.2134	.1562	.9374	.7811	.7274	.6706	.1829
18	.25	.2469	.7316	.7074	.7316	.7716	.1677
19	.3479	.3795	.6249	.6097	.6874	.6325	.3163
20	.6036	.5281	.4715	.5093	.4854	.4904	.5847
21	.5601	.4854	.5093	.4338	.4108	.3921	.5658
22	.5601	.5093	.5658	.4904		.4904	.5658
23	.5228	.5281	.5658	.5281			.5658
24	.3544	.3506	.5121	.5144	.4961		.3841
Max	1.2955	1.2018	.9374	.7811	.7316	.7716	1.0562
Min	.1219	.1189	.2629	.1619	.1715	.1715	.1524
Avg	.4590	.4200	.5702	.5231	.5008	.4728	.4063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184227 / 33/11 kV Maralgoi

Feeder No / Name : 203 / 11KV Velapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7087	.7011	.6935	.6859	.6485		.6516
2	.7011	.6935	.6859	.6859	.6733		.6935
3	.7011	.7282	.6859	.7282	.7087		.6935
4	.7888	.7545	.7455	.7628	.7362		.7122
5	.8916	.8048	.7975	.8413	.7796		.7802
6	.9831	.9831	.6859	.5895	.7712		.8669
7	1.5729	1.4373	.5898	.4973	.7293	.7537	1.3927
8	1.749	1.5813	.5571	.5735	.5761	.5182	1.6964
9	1.5023	1.4198	.3906	.3906	.3704	.3479	1.4232
10	.3258	.2835	.3544	.3544	.3544	.3294	.3258
11	.3121	.2507	.2804	.2591	.2401	.2915	.3189
12	.2846	.2241	1.3757	1.2651	1.2193	.945	.25
13	.2591	.2107	1.3889	1.0416	1.1294	1.1279	.2286
14	.2378	.2378	1.2955	1.0536	1.0536	1.0059	.2286
15	.2134	.2378	1.2037	.9808		.945	.2439
16	.2439	.2469	1.2029	1.1728	.6401	1.0212	.2591
17	.2743	.2656	1.3435	1.2186	1.012	1.1736	.2591
18	.3437	.3241	1.1431	1.2342	1.3413	1.2193	.3048
19	.5218	.4744	1.0936	1.0517	1.1561	1.1069	.4428
20	.7733	.811	.7545	.811	.7468	.7922	.7922
21	.6722	.7095	.7922	.679	.6908	.7095	.7545
22	.6535	.7468	.7922	.7167		.6979	.7545
23	.6348	.7356	.7545	.6979			.7167
24	.7087	.631	.7133	.6516	.6556		.695
Max	1.749	1.5813	1.3889	1.2651	1.3413	1.2193	1.6964
Min	.2134	.2107	.2804	.2591	.2401	.2915	.2286
Avg	.6691	.6455	.8467	.7893	.7730	.8116	.6452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184229 / 33/11 kV kh.malegaon

Feeder No / Name : 201 / 11 KV MALRAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.0974		
3		1.0974		
5		1.2826		
6		1.4335		
7		1.6975		
9		.0185		
10		.037		.0754
12			.0924	1.3763
14	.0857			
15	.0857			
16	.0838			1.9404
17			.0754	
18	.1029			1.848
19	.128		.132	.0572
21	.1494			
22	.1867			
23	.4075			
24	.0857	1.0288		
Max	.4075	1.6975	.132	1.9404
Min	.0838	.0185	.0754	.0572
Avg	.1462	.9616	.0999	1.0595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184229 / 33/11 kV kh.malegaon

Feeder No / Name : 202 / 11 KV KHADAK MALEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7716		
2		.7716		
3		.7716		
4		.7716		
6		.9808		
7		.811		
8		.6722		
9		.462		
10				.3772
12			2.6797	
14	2.5206			.4805
15	2.452			
16				.4854
17			3.2442	
18				.5359
19	.4024		.3772	.8002
20	.8402			
21	.8402			
22	.9709			
23	.815			
24	.2572	.7888		
Max	2.5206	.9808	3.2442	.8002
Min	.2572	.462	.3772	.3772
Avg	1.1373	.7557	2.1004	.5358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184229 / 33/11 kV kh.malegaon

Feeder No / Name : 203 / 11 KV SAROLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7373		
3		.7545		
4		.7716		
6		1.094		
7		1.5655		
9		.0924		
10				.0566
12			.1109	1.3927
13				1.6409
14	.1372			1.7187
15	.1372			
16				1.7372
17			.1509	
18	.1543			1.7741
19	.2378		.2641	.1334
20	.3174			
21	.3361			
22	.3086			
23	.3544			
24	.6516	.6859		
Max	.6516	1.5655	.2641	1.7741
Min	.1372	.0924	.1109	.0566
Avg	.2927	.8145	.1753	1.2077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

LASALGAON (R) S/DIV.[257] BU 0442

Substation No/ Name :- 184229 / 33/11 kV kh.malegaon

Feeder No / Name : 204 / 11 KV VANASGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431		
2		.8916		
3		.8916		
4		.8573		
6		1.2071		
7		2.0748		
8		2.4646		
9		.2218		
10		.2033		
12				2.1956
14	.3086			2.384
15	.3258			
16				2.2361
17			.4715	
18	.3086			2.0883
19	.4755		.6413	
20	.6722			
21	.6722			
22	.6908			
23	.6201			
24	.8059	.9259		
Max	.8059	2.4646	.6413	2.384
Min	.3086	.2033	.4715	2.0883
Avg	.5422	1.0681	.5564	2.226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184028 / PIMPALAS

Feeder No / Name : 201 / SUKENE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	3.6904	1.4575	2.4768	1.5851	.7621	3.7723
2	1.7528	3.6904	1.4575	2.4768	1.6537	.7621	3.7723
3	1.7528	3.7247	1.4575	2.4768	1.7566	.7621	3.7723
4	1.829	3.8009	1.6194	2.553		.7621	3.9247
5	3.8695	3.8352	1.9433	2.7816	2.1834	.8383	4.039
6	1.9814	3.9628	2.3015	3.1626	2.7015	.9907	4.1914
7	4.1419	4.0905	3.3151	3.6009	3.3322	1.5242	4.2867
8	1.9814	3.9971	3.477	3.4675	3.6389	1.7528	3.9819
9	3.7666	3.7837	3.1779	3.3055	1.6766	3.6199	3.7533
10	.9373	1.0993	.8001	1.0059	.4572	1.105	1.0136
11		.6859	.8573	1.2594	.6097	1.0859	1.0479
12		3.3494	3.7723	3.7837	3.7837	2.1338	3.6389
13		3.2636	4.039	3.8695	1.829	2.1719	3.7075
14	3.3913	3.0941	4.1915	3.98	1.829	2.0957	3.6732
15	3.477	2.8387	4.3439	3.98	1.9052	2.1338	3.4865
16	3.3494	2.5739	4.2296	3.9628	1.829	2.0576	1.448
17	3.3151	2.753	4.039	3.9628	1.829	2.1719	3.0084
18	3.0331	3.0084	4.0581	3.9628	1.7528	3.9247	3.2046
19	2.6577	2.692	4.0009	4.0828	1.7528	3.9819	2.8026
20	1.6023	1.6194	1.3337	1.5851	.6859	1.3337	1.7814
21	1.5851	1.568	1.4099	1.5509	.7621	1.6004	1.7642
22	1.4747	1.4575	1.3718	1.4747	.7621	1.7909	1.3794
23	1.4575	1.3718	1.2194	1.1927	.6097	1.7528	1.8137
24	3.6732	2.6235	1.4823	2.4768	1.5851	1.7528	3.9247
Max	4.1419	4.0905	4.3439	4.0828	3.7837	3.9819	4.2867
Min	.9373	.6859	.8001	1.0059	.4572	.7621	1.0136
Avg	2.5134	2.8573	2.5565	2.8513	1.7613	1.7861	3.0495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184028 / PIMPALAS

Feeder No / Name : 202 / MAMLESHWER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	1.2098	3.2617	3.5056	3.0141	1.6004	1.448
2	.6097	1.2098	3.2617	3.5818	3.1245	1.6004	1.448
3	.6097	1.2098	3.2617	3.5818	3.2103	1.6766	1.448
4	.6097	1.227	3.296	3.658		1.6766	1.5242
5	1.286	1.3032	3.3646	3.7342	3.4084	1.6004	1.448
6	.7621	1.4137	3.4332	3.8104	3.5285	1.7528	1.4861
7	1.3108	1.4137	4.0123	4.039	4.039	2.0576	1.3908
8	.6097	1.1927	4.5229	4.1723	4.54	2.3624	1.1241
9	.8001	.9202	4.4715	4.1209	2.4387	4.4581	.8763
10	.6134	.7239	1.1431	1.4098	.7621	1.2574	.7582
11		.381	.6668	.6134	.3048	.6858	.7582
12		4.9326	.6477	.6477	.6306	.762	4.5915
13		4.9993	.6096	.6649	.3048	.7239	4.7021
14	4.6258	4.8297	.6096	.7754	.3048	.7239	4.5915
15	5.0336	4.7021	.5715	.7754	.381	.762	4.6335
16	5.0679	4.6678	.6096	.7582	.381	.6858	2.4387
17	4.9231	4.7097	.7239	.7411	.3048	.8001	4.5478
18	4.9402	4.5649	.762	.7411	.381	.8764	4.4715
19	4.5725	4.42	1.0669	.9716	.4572	1.0288	4.3343
20	1.7966	1.6347	1.4861	1.4404	.7621	1.448	1.6518
21	1.5928	1.4823	1.6004	1.5166	.7621	1.6385	1.5166
22	1.5756	1.448	1.5051	1.5928	.7621	1.6766	1.6099
23	1.448	1.448	1.467	1.4137	.7621	1.6194	1.5585
24	1.3032	2.2005	3.0922	3.3532	2.9379	.7621	1.5242
Max	5.0679	4.9993	4.5229	4.1723	4.54	4.4581	4.7021
Min	.6097	.381	.5715	.6134	.3048	.6858	.7582
Avg	2.1286	2.4269	2.0603	2.1508	1.6305	1.4265	2.3284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184028 / PIMPALAS

Feeder No / Name : 203 / KURADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5487	
2	.5144	.5487	
3	.5144	.5487	
4	.5487		
5	.6001	.6344	
6	.6344	.6516	
7	.6001	.6001	
8	.5144	.4287	
9	.3258		
10	.2572		.2572
11	.2058		.2915
12	1.9547	1.7833	.3086
13	1.9376		.3258
14	1.9719		.3086
15	1.9547		
16	1.9547		
17	1.989		.3086
18	1.9376		.3429
19	1.9204		.4287
20	.6001		.6001
21	.6173		.6173
22	.6516		.6173
23	.6001		.6173
24	.5144	.5487	
Max	1.989	1.7833	.6173
Min	.2058	.4287	.2572
Avg	.9931	.6992	.4187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184028 / PIMPALAS

Feeder No / Name : 206 / KOTHURE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			3.1855	3.5056	3.0579	1.829	
2			3.1855	3.5056	3.0579	1.829	
3			3.1855	3.5056	3.1436	1.829	
4			3.2198	3.5818		1.829	
5			3.3646	3.6961	3.2541	1.9052	
6			3.4922	3.7342	3.5018	1.9052	
7			3.978	3.9247	4.1571	2.21	
8			4.3438	4.1647	4.6258	2.3624	
9			4.4715	4.3857	2.4387	2.2862	
10	.4687	.4858	.9526	1.4765	.9145	.9145	.5106
11		.3048	.5144	.4687	.2286	.2286	.5449
12		5.0259	.1524		.0762	.1524	4.4391
13		5.1193					4.8126
14	4.7783	5.1783					4.8545
15	5.1783	5.0336					4.7021
16	5.1536	4.8888					4.8545
17	5.1955	4.8545					4.8545
18	4.8107	4.563					4.5821
19	4.462	4.1476					4.5649
20	1.3432	1.2422	.8763	.9965	.4572	.5335	1.2079
21	.8859	.903	.9144	.9202	.4572	.5335	.9202
22	.8687	.8687	.8763	.8859	.4572	.5335	.9202
23	.8516	.8344	.8192	.8173	.4572	.5335	.8687
24	.0762	1.6766	3.1093	3.5056	3.2865	.1524	.0762
Max	5.1955	5.1783	4.4715	4.3857	4.6258	2.3624	4.8545
Min	.0762	.3048	.1524	.4687	.0762	.1524	.0762
Avg	2.8394	3.0084	2.3907	2.6922	2.0982	1.2686	2.8475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184028 / PIMPALAS

Feeder No / Name : 207 / B. S. Patil

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0062	.4801	.4954	.4287		2.4768
2		.6001	.4801	.4954	.4287		2.4768
3		2.0576	.4801	.4954	.4287		2.4768
4		2.1262	.5144	.5525			2.5911
5		2.3148	.6001	.6097	.4801		2.7054
6		2.4348	.5658	.5335	.4801		2.934
7		2.6749	.4287	.4763	.4458		
8		2.8292	.3429	.3772	.3601		3.3913
9	2.6578	2.7778	.3086	.3258		.381	2.8959
10	.3429	.3258	.3429			.3429	.3258
11			.3429	.2743		.2858	.3258
12		.2743	3.2388	3.1379	3.2065	3.2388	.3086
13		.3258	3.4294	3.1893		3.3913	.3086
14		.3086	3.5437	3.0007		3.4675	.2743
15		.2572	3.5818	3.035		3.5056	.2915
16		.2401	3.4294	3.035		3.4294	.3086
17	.4115	.3258	3.3532	3.0007		3.2388	.3258
18	.4115	.3086	3.2388	2.915		3.0483	.3429
19	.4287	.3601	2.915	2.6235		2.8387	.4115
20	.5144	.463	.5716	.463		.381	.4801
21	.5144	.4973	.6478	.4458		.4954	.5144
22	.5316	.4801	.6478	.4801		.5716	.5144
23	.5316	.5144	.5716	.463		.5144	.5144
24		2.0062	.4801	.4954	.4287		2.4768
Max	2.6578	2.8292	3.5818	3.1893	3.2065	3.5056	3.3913
Min	.3429	.2401	.3086	.2743	.3601	.2858	.2743
Avg	.7049	1.1526	1.4390	1.3443	.7430	1.9420	1.2901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184028 / PIMPALAS

Feeder No / Name : 208 / Mercury

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1543	.0762	.1372		.0762
2		.1715	.1372	.0762	.1715		.0762
3		.1715	.1372	.0762	.1715		.0762
4		.1715	.1543	.0762			.0762
5		.1372	.1715	.0762	.0857		.0762
6		.1372	.2058	.0762	.0686		.0762
7		.1715	.1372	.0762	.0069		.0762
8		.1715	.12	.0762	.2058		.0762
9	.1715	.2058	.2058	.0762		.1524	.0762
10	.1715	.2401	.1143			.1905	.1715
11			.1143	.2915		.1905	.2572
12		.2915	.1143	.1715	.2229	.1524	.2743
13		.2572	.1143	.1372		.1524	.2915
14		.2401	.1143	.2915		.1143	.2572
15		.2058	.1143	.3086		.1143	.3086
16		.1715	.1143	.3429		.1143	.3429
17	.2058	.2229	.1143	.2743		.0762	.3601
18	.2058	.2915	.1143	.1543		.0762	.2058
19	.1029	.2915	.1143	.3086		.0762	.1543
20	.2229	.1543	.5716	.2743		.0762	.2401
21	.1372	.1543	.6478	.0686		.0762	.1715
22	.1372	.1372	.6478	.2058		.0762	.12
23	.2229	.2229	.5716	.1715		.0762	.2229
24		.1715	.1543	.0762	.1029		.0762
Max	.2229	.2915	.6478	.3429	.2229	.1905	.3601
Min	.1029	.1372	.1143	.0686	.0069	.0762	.0762
Avg	.1753	.1983	.2150	.1636	.1303	.1143	.1725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256] BU 5428

Substation No/ Name :- 184038 / NAITALE

Feeder No / Name : 201 / NANDUR EXPRESS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)
7		.1219
14	.0191	
Max	.0191	.1219
Min	.0191	.1219
Avg	.0191	.1219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184038 / NAITALE

Feeder No / Name : 203 / SONEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.9526
2					.9907
3					.9907
4					1.0669
5					1.2193
6					1.4289
7					2.1338
8	2.4196				2.5149
9	2.191			.381	1.2003
10	.1677			.3239	.1829
11	.1524		.1905	.2286	.1981
12	.1829			.2591	.1981
13	.2286			1.3565	.2134
14	.2286			1.4175	.2286
15	.2439			1.5089	.2286
16	.2439			1.5242	.2286
17				1.7528	.2286
18				1.7528	.9526
19			1.9052	1.4175	
23				1.5242	
24	.8954	.6706			
Max	2.4196	.6706	1.9052	1.7528	2.5149
Min	.1524	.6706	.1905	.2286	.1829
Avg	.6954	.6706	1.0479	1.1206	.8421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184038 / NAITALE

Feeder No / Name : 205 / DHARANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.0212
2					1.0212
3					1.0212
4					1.0364
5					1.0517
6					1.0517
7					.8383
8					.6249
9				3.1436	.4268
10				.2743	.3048
11			.3429	.1905	.2286
12				.3048	3.658
13				.4191	3.5246
14				.381	3.0674
15				.4001	3.1626
16				.4001	3.2769
17					3.4294
18					3.2198
19			.8192		2.8578
20					.6859
21					.884
22					.9907
23					.9602
24	1.1241	1.6194			1.0212
Max	1.1241	1.6194	.8192	3.1436	3.658
Min	1.1241	1.6194	.3429	.1905	.2286
Avg	1.1241	1.6194	.5811	.6892	1.6402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184038 / NAITALE

Feeder No / Name : 206 / BOKADDARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2743
2						.2743
3				.4191		.2743
4						.2743
5						.2743
6						.2743
7						.2134
8	.1524					.1524
9	.1067				.5487	.0914
10	.0914				.1143	.1067
11	.0762		.0953		.0953	.0762
12	.8002				.0762	.7811
13	.8002				.0953	.743
14	.743				.0953	.7049
15	.6668				.0953	.7049
16	.5716				.0953	.7049
17						.6859
19			.2286			
24	.3048	.4001		.381		.2743
Max	.8002	.4001	.2286	.4191	.5487	.7811
Min	.0762	.4001	.0953	.381	.0762	.0762
Avg	.4313	.4001	.1620	.4001	.1520	.3825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184038 / NAITALE

Feeder No / Name : 207 / Dudh dairy

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	09-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0191
2			.0191
3			.0191
4			.0191
5			.0191
6			.0191
7			.0191
8	.0191		.0191
9	.0191		.0191
10	.0191		.0191
11	.0191		.0191
12	.0191		.0191
13	.0191		.0191
14			.0191
15	.0191		.0191
16	.0191		.0191
17	.0191	.0191	.0191
18	.0191	.0191	.0191
19		.0191	
20		.0191	
21		.0191	
22		.0191	
23		.0191	
24			.0191
Max	.0191	.0191	.0191
Min	.0191	.0191	.0191
Avg	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184038 / NAITALE

Feeder No / Name : 208 / SHIVRE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					3.2388
2					3.2769
3					3.2388
4					3.2769
5					3.2769
6					3.315
7					3.6961
8					3.1245
9				.2096	3.0864
10				.2286	.1524
11			.1905	.1905	.1372
12				3.6885	
13				3.2007	.1829
14				3.1093	.1981
15				3.0483	.1981
16				2.9569	.2134
17					.2134
18					.2591
19					.3048
20					.3506
21					.381
22					.3963
23					.3963
24	2.8197	.503			3.2388
Max	2.8197	.503	.1905	3.6885	3.6961
Min	2.8197	.503	.1905	.1905	.1372
Avg	2.8197	.503	.1905	2.0791	1.5719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184061 / KUNDEWADI

Feeder No / Name : 201 / LASALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	1.0288	1.4232	1.406	1.046		1.0288
2	.7888	1.0288	1.4232	1.406	1.046		.9945
3	.7888	1.0802	1.4232	1.406	1.046		.9945
4	.8573	1.1145	1.4575	1.4575	1.1145		1.0631
5	.9259	1.1488	1.5432	1.8861	1.2003		1.166
6	1.046	1.2689	1.8004	2.2291	1.8861		1.166
7	.8745	1.0288	2.6063	3.1722	2.7778		1.1145
8	.6173	.9431		2.915	3.0864		.9431
9	.5316	.7545		2.6406			
10	.5316	.703		.583			
11		.583	.0857	.5658			.7545
12		2.8464	.8573	.6516	.6344		3.1722
13		2.8807	.7888	.6859		.7373	3.0864
14	3.1379	2.8121	.7888	.6859		.5144	3.0864
15	3.2065	2.7778	.823	.7202	.7202	.7373	2.7435
16	3.0864	3.0521	.7545	.703		.8059	2.7778
17	3.4294	3.0178	.8059	.703		.823	2.915
18	2.9492	2.6749	.7716	.6516		.823	2.7435
19	2.8121	2.6063	1.0288	.9602		1.0974	2.7435
20		1.0974	1.2003	1.2003		1.2003	1.0288
21	1.046	1.1317	1.166	.6001		1.2003	1.1145
22	1.0631	1.166	1.1317	1.1145		1.1831	1.1317
23	1.0288	.9945	1.0288	.9431		1.166	1.0631
24	.7716	1.0288	1.4232	.6173	1.046		1.0631
Max	3.4294	3.0521	2.6063	3.1722	3.0864	1.2003	3.1722
Min	.5316	.583	.0857	.5658	.6344	.5144	.7545
Avg	1.5141	1.6154	1.1586	1.246	1.4185	.9353	1.7225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184061 / KUNDEWADI

Feeder No / Name : 202 / NIPHAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.749	1.8861	1.8519	1.7177	1.9719		2.0576
2	2.1262	1.8861	1.8519	1.7177	1.9719		1.9547
3	1.7833	1.9204	1.8176	1.7177	1.9719		1.9547
4	1.8176	1.9547	1.8861	1.7878	1.9719		2.0576
5	1.8861	1.9547	1.9719	1.9281			2.1948
6	2.1091	2.1948	2.2291	2.0332	1.989		2.332
7	2.1948	2.0748	2.1262	2.1033	2.1262		2.2634
8	1.8861	2.1262	2.0233	2.1384	2.0233		2.3148
9	2.3491	2.0233	1.989	2.3491			2.0576
10	2.452	1.1145	2.1262	2.1091			2.2291
11		2.1948	2.3838	2.0919			2.2462
12		2.0233	2.2436	1.6804	2.1776		1.989
13		2.0233	2.1384	1.7147		2.2634	2.0233
14	2.3663	1.9547	2.1384	2.0062		2.2634	2.0233
15	2.2634	1.8861	2.1033	2.0748		2.0576	2.0576
16	2.1948	1.9376	2.1384	2.0405		2.1091	2.0919
17	2.2634	2.0405	2.2786	1.8861		2.0919	2.2291
18	2.2634	2.1434	2.3137	1.6461		2.1262	2.2291
19	2.3834	2.4006	2.3838	1.7318		2.4348	
20	2.332	2.4348	2.3838	2.4006		2.5377	
21	2.0233	2.2634	2.2611	2.2291		2.4006	
22	2.0576	2.1262	2.1033	2.1605		2.332	2.2119
23	2.0576	2.0576	1.8755	2.4863		2.2462	
24	1.9719		1.8861	2.0405	1.989		2.1434
Max	2.452	2.4348	2.3838	2.4863	2.1776	2.5377	2.332
Min	1.749	1.1145	1.8176	1.6461	1.9719	2.0576	1.9547
Avg	2.1205	2.0270	2.1044	1.9913	2.0214	2.2603	2.1331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184061 / KUNDEWADI

Feeder No / Name : 203 / RANWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.583	.9945	.8916	.9602		.5487
2	.5487	.583	.9945	.8916	.9602		.5487
3	.5487	.583	.9945	.9259	.9602		.5487
4	.6173	.6001	1.0288	.9431	1.0288		.6001
5	.703	.6344	1.1145	1.166	1.6289		.6859
6	.703	.5144	1.4232	1.3717	2.2805		.6516
7	.5144	.4458	2.0576	2.0576	2.2805		.5658
8	.3772	.3772	2.2634	2.4348	2.3663		.3944
9	.2572	.2743	1.8861	1.6975			.3601
10	.2743	.2401	.2401	.1715			.2743
11		.2058	.2401	.1715			.2058
12		2.2291		.1715	.2401		2.572
13		2.0576	.12	.1715		.2572	2.6406
14	2.4006	1.989	.1372	.2058		.2743	2.8121
15	2.3148	1.9204	.1372	.2743	.2572	.2743	2.2805
16	2.4691	2.1091	.1372	.2572		.2743	2.2805
17	2.572	2.0919	.1715	.2572		.3086	2.2977
18	2.8121	1.989	.1715	.7545		.3086	2.2291
19	1.8861	1.7147	.2743	.3772		.4458	1.9719
20	.5144	.463	.0857	.5144		.583	.5144
21	.6001	.5144	.4458	.5144		.583	.5487
22	.6001	.583	.463	.5487		.6001	.5658
23	.6173	.6001	.463	.4801		.583	.583
24	.5487	.583	.9945	.8916	.9602		.5487
Max	2.8121	2.2291	2.2634	2.4348	2.3663	.6001	2.8121
Min	.2572	.2058	.0857	.1715	.2401	.2572	.2058
Avg	1.0680	.9952	.7321	.7559	1.2657	.4084	1.1345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184061 / KUNDEWADI

Feeder No / Name : 205 / CHANDORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5944	.7678	.9648	.905	.9549	.5007	.5
2	.5921	.7693	.9633	.9141	.9488	.5037	.4916
3	.5707	.7975	.977	.9119	.964	.5053	.4863
4	.602	.8067	1.0067	.9412	.9709	.5045	.5285
5	.6492	.9252	1.1054	1.0044	1.0379	.5342	.5875
6	.9175	.9739	1.1698	1.0379	1.1363	.57	.7529
7	1.2689	1.2319	1.0643	1.0334	1.0246	.5556	.9907
8	1.3614	1.3321	.8703	.9	.8555	.4572	1.2323
9	1.2605	1.3001	.7026	.6611	.3993	.4374	1.19
10	.6238	.5746	.6104	.503	.365	.3788	.5837
11	.3277	.5529	.5602	.4733	.3391	.33	.5768
12		.6348	1.2163	.8753	1.1157	.5365	.6592
13		.6687	1.3309	1.0318	.5838	1.0151	.6508
14	.8558	.7194	1.2155	1.0341	.5136	1.0064	.6599
15	.8253	.7148	1.0928	.9911	.5487	.9888	.6569
16	.772	.6916	1.166	1.0189	.5426	1.0357	.6599
17	.7107	.6977	1.1919	1.0654	.5761	1.1157	.6813
18	.6954	.7773	1.227	1.1058	.6028	1.1115	.6736
19	.8067	.855	1.0376	1.0486	.6302	1.0783	.8444
20	1.0913	1.0875	1.0433	1.0018	.4854	1.0997	.9648
21	1.1027	1.0997	1.0898	1.0974	.5365	1.1199	1.0387
22	1.0562	1.0966	1.0658	1.1088	.5487	1.118	1.0699
23	1.0059	1.0597	1.0235	1.044	.5426	1.0158	1.0417
24	.6035	.9431	.9472	.9724	.9739	.2568	.6135
Max	1.3614	1.3321	1.3309	1.1088	1.1363	1.1199	1.2323
Min	.3277	.5529	.5602	.4733	.3391	.2568	.4863
Avg	.8315	.8782	1.0268	.9450	.7165	.7407	.7556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184061 / KUNDEWADI

Feeder No / Name : 206 / OZHAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.6859	.4287	.4458	.4287		.6859
2	.823	.7202	.4287	.4287	.4287		.6859
3	.823	.823	.4287	.4287	.4287		.6859
4	.8916	.823	.4973	.463	.463		.7202
5	.9602	.583	.5487	.4973	.4801		.7888
6	1.0288	.9431	.5487	.4973	.5316		.8916
7	1.3032	1.0974	.4973	.463	.4801		1.166
8	1.3032	1.3032	.3944	.4115	.3772		1.2517
9	1.2003	1.2689	.3429	.7373			1.0802
10	.2058	.2572	.2743				.2058
11		.2229	.1029				.2915
12		.3429	1.2003	1.1831	1.166		.2743
13		.3429	1.2003	1.2003		1.2346	.2401
14	.2572	.3429	1.2346	1.2517		1.166	.2743
15	.3429	.3601	1.2689	.9774		1.0974	.2572
16	.3601	.3086	1.2346	1.2003		1.166	.2572
17	.3429	.2743	1.2517	1.2003		1.2346	.2743
18	.3429	.3429	1.3375	1.1488		1.3546	.3086
19	.4458	.3772	1.1317	.8573		.9431	.3772
20	.4801	.4801	.4458	.4287		.3429	.4287
21	.4973	.4973	.4458	.4801		.3429	.5144
22	.4115	.4973	.4458	.4801		.3258	.4115
23	.2743	.4801	.4458	.4287		.2743	.4115
24	.7888	.6859	.4287	.4458	.4287		.6859
Max	1.3032	1.3032	1.3375	1.2517	1.166	1.3546	1.2517
Min	.2058	.2229	.1029	.4115	.3772	.2743	.2058
Avg	.6622	.5858	.6902	.7116	.5213	.8620	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184061 / KUNDEWADI

Feeder No / Name : 207 / NIPHAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1262	1.6289	.8745	.8745	.8573		1.9204
2	2.1262	1.6289	.8745	.8745	.8573		1.9204
3	2.1262	1.6632	.8745	.8745	.8573		1.9204
4	2.1605	1.6804	.9259	.8916	.8916		1.9547
5	2.1948	1.7318	.9602	.9259	.9259		2.0576
6	2.2977	1.8347	.9259	.9431	1.989		2.2119
7	2.915	2.572	.8573	.9088	.8402		2.7949
8	2.915	2.9492	.7888	.8059	.823		3.2236
9	2.8121	3.0521	.7545	.7373			3.2236
10	.7202	.7545	.7545	.7545			.7545
11		.7545	.7373	.7202			.7545
12		.7202	2.915	3.3608	3.2579		.6859
13		.7545	3.1722	3.3951		2.8121	.2572
14	.7202	.7545	3.2922	3.1036		2.8292	.1715
15	.7202	.7373	3.3436			2.7435	.1715
16	.7373	.7545	3.0864	2.915		2.7092	.1715
17		.7716	3.1722	2.915		2.7778	.1372
18	.7545	.7716	2.915	2.2291		2.7778	.703
19	.7545	.7716	2.572	2.7435		2.8807	.8573
20	.8059	.8573	.8573	.8573		.8916	.8573
21		.8573	.8573	.8573		.8745	.8573
22	.8745	.8745	.8745	.8573		.8745	.8916
23	.8916	.8745	.8745	.8916		.8745	.8916
24	2.1948	1.6289	.8573	.8745	.8573		1.8861
Max	2.915	3.0521	3.3436	3.3951	3.2579	2.8807	3.2236
Min	.7202	.7202	.7373	.7202	.823	.8745	.1372
Avg	1.6235	1.3074	1.5882	1.4918	1.2157	2.0950	1.3031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184223 / Nandur Madyameshwar

Feeder No / Name : 201 / Dindori

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						2.146
2						2.1293
3						2.1125
4	1.9113	1.9448		.4578		2.1125
5						2.146
6						2.1628
7						2.2634
8	2.2466			.2543		2.2801
9						2.2801
10						.1357
11					.1187	.1543
12	.1187				2.4813	.12
13					2.4813	.1696
14					2.5149	.1696
15					2.5484	.1357
16	.1357		2.5316		2.5484	.2035
17					2.7161	.2204
18					2.5987	.1865
19					2.5987	.2883
20	.3391		.3222		.3561	.3561
21					.373	.373
22					.373	.39
23					.3772	.39
24	1.6095	2.3472		.4239		2.1963
Max	2.2466	2.3472	2.5316	.4578	2.7161	2.2801
Min	.1187	1.9448	.3222	.2543	.1187	.12
Avg	1.0602	2.146	1.4269	.3787	1.6989	1.0467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184223 / Nandur Madyameshwar

Feeder No / Name : 202 / Thadi-Sarole

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1907
2						.1907
3						.1907
4	.1734	.1907		.1734		.1907
5						.1907
6						.1907
7						.1907
8		.1907		.1734		.1907
9						.0693
11					.1907	.208
12	.0173				.104	.0175
13					.1907	.0347
14					.1907	.1734
15					.1907	.0173
16	.0867		.0867		.1907	.0173
17					.1907	.0867
18					.1907	.1734
19					.1907	.1734
20	.1734		.1734		.1907	.3121
21					.1907	.0173
22					.1907	.0173
23					.1907	.0173
24	.104	.1734		.1734		.1907
Max	.1734	.1907	.1734	.1734	.1907	.3121
Min	.0173	.1734	.0867	.1734	.104	.0173
Avg	.1110	.1849	.1301	.1734	.1840	.1327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184223 / Nandur Madyameshwar

Feeder No / Name : 203 / Nandur(M)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-APR-17
HR	Load (MW)
1	.6173
2	.6173
3	.6173
4	.6516
5	.6687
6	.703
7	.5487
8	.4287
9	.2915
10	.2401
11	.2058
13	2.572
14	2.5377
17	2.4177
18	2.7435
19	2.6063
20	.5658
21	.6173
22	.6516
23	.6687
Max	2.7435
Min	.2058
Avg	1.0485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184223 / Nandur Madyameshwar

Feeder No / Name : 204 / GajarWadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.9842
2						1.0467
3						1.078
4		1.2498		.3321		1.1717
5						1.2186
6						1.3123
7						1.5623
8				.1423		1.6872
9						1.0311
10					.0791	.048
11					.0633	.048
12	.1581					.064
13						.08
14					.4218	.096
15					.4687	.096
16	.1898		1.6091		.4374	.096
17					1.781	.0949
18					1.8747	.128
19					1.6872	.16
20	.2846		.2372		.2056	.1898
21					.2372	.2056
22					.2372	.2056
23					.2056	.1898
24		1.906		.3321		.8436
Max	.2846	1.906	1.6091	.3321	1.8747	1.6872
Min	.1581	1.2498	.2372	.1423	.0633	.048
Avg	.2108	1.5779	.9232	.2688	.6416	.5682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184238 / Kasbe-Sukene

Feeder No / Name : 201 / Kasbe-Sukene

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7922		
8			.8383
11		.6668	
12		.6478	
14		.6859	
15		.6859	
16		.6668	1.531
17		.6859	
18		.7621	
19		.9526	
20		1.1431	
21		1.105	
22		1.0669	
23			.9808
24			.9526
Max	.7922	1.1431	1.531
Min	.7922	.6478	.8383
Avg	.7922	.8244	1.0757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184238 / Kasbe-Sukene

Feeder No / Name : 202 / Vijay Agro

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0762	.0762	.0762	.0762
2	.0762	.0762	.0762	.0762	.0762	.0762	.0762
3	.0762	.0762	.0762	.0762	.0762	.0762	.0762
4	.0762	.0762	.0762	.0762	.0762	.0762	.0762
5	.0762	.0762	.0762	.0762	.0762	.0762	
6	.0762	.0762	.0762	.0762	.0762	.0762	.0762
7	.0762	.0762	.0762				.0762
8	.0762	.0762	.0762			.0762	.0762
9	.0762	.0762	.0762	.0762	.0762	.0762	.0762
10	.0762	.0762	.0762	.0762	.0762	.0762	.0762
11		.0762	.0762	.0762	.0762	.0762	.0762
12		.0762	.0762	.0762	.0762	.0762	.0762
13		.0762	.0762	.0762	.0762	.0762	.0762
14	.0762		.0762		.0762		
15	.0762	.0762	.0762	.0762	.0762	.0762	
16	.0762	.0762		.0762	.0762	.0762	
17	.0762	.0762	.0762	.0762	.0762	.0762	.0762
18	.0762	.0762	.0762	.0762	.0762	.0762	.0762
19	.0762	.0762	.0762	.0762	.0762	.0762	.0762
20	.0762	.0762	.0762	.0762	.0762	.0762	.0762
21		.0762	.0762	.0762			
22			.0762	.0762			
23	.0762	.0762	.0762	.0762	.0762	.0762	.0762
24	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Max	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.0762	.0762	.0762	.0762	.0762	.0762	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

NIPHAD[256]

BU 5428

Substation No/ Name :- 184238 / Kasbe-Sukene

Feeder No / Name : 203 / MANDAKINI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.7811
2	.4338		.7811
3	.4527		.7202
4	.4904		.6706
5	.5093		.7468
6	.5093		.823
7			1.5242
8	.3206		1.9662
9	.1886		1.7071
10	.1698		.1991
11	.1698		.1663
12	1.5242	1.6309	.1848
13		1.8515	.1867
14		1.5935	.1448
15		1.6356	
16		1.4575	
18		1.7223	.2641
19		1.5203	.3772
20		.4572	.4527
21		.4763	.4527
22		.4001	.4527
23			.3734
24			.703
Max	1.5242	1.8515	1.9662
Min	.1698	.4001	.1448
Avg	.4769	1.2745	.6513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184003 / 33/11 KV PIMPALGAON

Feeder No / Name : 204 / 11 KV CIVIL COURT

SHEDDABLE URBAN

PIMPALGAON Feeder KV- 11 /
OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7665	1.8031	1.9738	1.8747	1.8823	1.9921	2.2207
2	1.7071	1.7299	1.89	1.8336	1.8244	1.9326	2.1171
3	1.669	1.704	1.8519	1.7833	1.7741	1.8823	2.0393
4	1.6552	1.6796	1.8366	1.7726	1.7924	1.8412	2.0058
5	1.7528	1.7375	1.8854	1.8198	1.8381	1.8991	2.0317
6	1.8778	1.8884	2.0317	1.9692	1.9235	1.9784	2.1232
7	2.082	2.0485	2.1917	2.1445	2.0683	2.1262	2.2268
8	2.1414	2.1171	2.2161	2.1552	2.1201	2.1399	2.2055
9	1.954	2.0195	2.0226	2.0119	1.9921	2.0302	2.1323
10	2.0073	2.0241	2.1643	2.1963	2.0119	2.2207	2.1933
11	2.018	2.1155	2.1933	2.3198	2.2253	2.3182	2.2619
12	1.8701	2.0683	2.2542	2.2268	2.3137	2.3564	2.2862
13	1.7741	1.9982	2.2237	2.1872	2.3442	2.335	2.3061
14	1.8214	1.9921	2.1887	2.1125	2.2954	2.207	2.2298
15	1.7589	2.0409	2.1552	2.2237	2.3137	2.2893	2.2253
16	1.7894	2.0957	2.2237	2.3411	2.6642	2.4036	2.3
17	1.8229	2.1475	2.364	2.3442	2.5652	2.4996	2.3198
18	1.8092	2.2359	2.431	2.367	2.4829	2.5103	2.4219
19	1.8762	2.3762	2.4829	2.4691	2.5225	2.5956	2.5545
20	2.3061	2.7298	2.7374	2.6749	2.9706	2.9813	2.7008
21	2.2954	2.7145	2.6932	2.524	2.7846	2.8334	2.5987
22	2.2527	2.4371	2.4143	2.2984	2.463	2.5682	2.4112
23	2.1917	2.3061	2.2664	2.2344	2.364	2.4966	2.271
24	2.0027	2.1277	2.1049	2.0576	2.1948	2.364	2.2192
Max	2.3061	2.7298	2.7374	2.6749	2.9706	2.9813	2.7008
Min	1.6552	1.6796	1.8366	1.7726	1.7741	1.8412	2.0058
Avg	1.9251	2.0891	2.1999	2.1642	2.2388	2.2834	2.2668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184003 / 33/11 KV PIMPALGAON

Feeder No / Name : 207 / 11 KV WANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7215	1.7337	.4938	.4954	.5053	.455	1.7612
2	1.6857	1.7345	.5175	.4915	.5075	.4512	1.7406
3	1.6766	1.7299	.5121	.5098	.5266	.4641	1.7368
4	1.7093	1.8023	.5472	.5289		.4915	1.7703
5	1.7901	1.8069	.583	.5495		.5144	1.8077
6	1.9997	2.0279	.5898	.567		.5213	2.0302
7	2.7625	2.6703	.4862	.4214		.4405	2.7534
8	3.3493	3.1984	.3955	.3612		.3467	3.0407
9	3.2922	3.0056	.2926	.2843	.3185	.2888	2.9325
10	.2568	.2477	.218	.2827	.317	.2515	.2606
11	.2378	.2522	.8779	.7468	.7682	.82	.2492
12	.2065	.2309	2.8868	3.075	3.1283	3.4377	.2301
13	.2324	.2309	3.3082	3.1946	3.2686	3.3493	.2202
14	.269	.2431	3.2472	3.2427	3.2327	3.3775	.2309
15	.2454	.25	3.1809	3.1344	3.139	3.2853	.2408
16	.2286	.2561	3.0712	2.9378	3.0537	3.1299	.2271
17	.2492	.2522	2.5232	3.0704	2.8677	3.421	.2271
18	.2797	.2637	2.7443	3.0803	2.7138	3.2587	.301
19	.3673	.3818	2.7702	2.7122	3.0453	3.2427	.3909
20	.4656	.4588	.4435	.407	.4191	.4862	.4588
21	.4847	.49	.4793	.4321	.4557	.4877	.487
22	.5258	.5098	.5235	.4893	.5152	.5235	.5091
23	.6424	.5167	.5342	.519	.5213	.7659	.5296
24	1.6773	.4915	.4839	.5014	.487	1.7208	2.0988
Max	3.3493	3.1984	3.3082	3.2427	3.2686	3.4377	3.0407
Min	.2065	.2309	.218	.2827	.317	.2515	.2202
Avg	1.0981	1.0327	1.3213	1.3348	1.5679	1.4805	1.0931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184003 / 33/11 KV PIMPALGAON

Feeder No / Name : 209 / 11 KV SHAMPEN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.178	1.5562	1.7086	2.0027	1.7695	1.9814	1.8762
2	1.9692	1.4129	1.5455	1.8839	1.5912	1.7558	1.1782
3	1.7695	1.2209	1.5074	1.7711	1.5043	1.7208	1.102
4	1.7299	1.0578	1.4525	1.6034		1.6354	.9922
5	1.7253	.9236	1.4571	1.6141		1.6369	1.5775
6	1.6248	.913	1.4845	1.6126	.4664	1.4922	1.6415
7	1.5699	1.0258	1.5882	1.6888	1.2894	1.5577	1.643
8	1.608	1.2056	1.6629	1.7238	1.4952	1.6293	1.7101
9	1.451	1.5562	1.6156	1.9403	1.7741	1.9296	1.7878
10	1.358	1.9235	2.1277	2.1536	2.1948	2.2893	2.2161
11	1.326	1.9143	2.3503	2.2512	2.3106	2.3655	2.2664
12	1.4159	2.0332	2.4356	2.0927	2.3685	1.5958	2.2634
13	1.4388	2.0287	2.1399	1.9174	2.2969	1.6263	1.7787
14	1.3885	1.9585	2.1795	2.0591	2.1582	1.9707	2.1094
15	1.3687	2.0713	2.4173	2.242	1.7787	2.1933	2.2878
16	1.6278	2.0287	2.4234	1.6065	1.6385	1.8549	2.0988
17	1.7208	2.0668	2.3746	1.8884	2.2893	1.8976	2.4661
18	1.765	2.0744	2.5911	2.2817	2.4676	2.0195	2.6459
19	1.7421	2.0835	2.6856	2.4371	2.4615	2.3411	2.5347
20	1.6263	2.0851	2.4508	2.3365	2.4432	2.3655	2.5393
21	1.64	1.8915	2.3335	2.2344	2.4691	2.4554	2.489
22	1.5684	1.7833	2.0195	2.0043	2.2344	2.0256	2.3289
23	1.6232	1.9067	2.0622	2.0622	2.1597	2.079	2.303
24	1.5546	1.9159	1.9692	1.9342	1.9509	2.0729	2.143
Max	2.178	2.0851	2.6856	2.4371	2.4691	2.4554	2.6459
Min	1.326	.913	1.4525	1.6034	.4664	1.4922	.9922
Avg	1.6162	1.6932	2.0243	1.9726	1.9596	1.9371	1.9991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184034 / 33/11 KV BOPEGAON

Feeder No / Name : 201 / 11 KV KHEDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.5432		.3239		
2	1.1431	1.5432		.3239		
3	1.1431	1.5813		.3429		1.3717
4	1.3336	1.6575				
5	1.4289	1.7718				
6	1.6004	2.0576				1.7909
7	2.0957	2.4577				
8	2.572	2.572				2.6101
9	2.3434	2.5339				2.3243
12			2.5339	2.2291	2.3624	
13			2.4006	2.3815		
14			2.3624	2.2862		
15			2.4768	2.2862	2.3815	
16			2.4768			
17			2.5339	2.4006		
18	.1715	.2667	2.4768			.2096
19	.2477	.3048	2.2862	2.3053	2.3053	.2286
20	.3429		.4572	.3429		.3429
21	.362		.4572	.362		.4001
22	.362		.4382	.362		.381
23	.362			.362	.381	.3429
24	1.1431	1.5242		.3429		1.3717
Max	2.572	2.572	2.5339	2.4006	2.3815	2.6101
Min	.1715	.2667	.4382	.3239	.381	.2096
Avg	1.1122	1.6512	1.9	1.1894	1.8576	1.0340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184034 / 33/11 KV BOPEGAON

Feeder No / Name : 202 / 11 KV JOPUL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.1919	6.1728	.4572	.9716	.4572	.4572	2.5911
2	3.0483	6.1728	.4572	.9526	.4572	.4572	2.5911
3	3.0483	6.1728	.4572	.9716	.4572	.4572	5.2584
4	3.0483	6.2109	.1524	.4572	.1524	.4572	2.5911
5	3.0483	6.23				.3048	2.7435
6	3.0483	6.3252					6.3253
7	7.8494	7.5827					3.5056
8	8.078	7.1826					7.9256
9	7.5827	7.7541					7.2969
10	1.2193	.4572					1.0669
12			7.3541	7.697	3.8104	8.6115	
13			7.8114	7.678	3.9628	3.9628	
14			8.6305	7.2779	3.9628	3.8104	
15			8.1161	3.5056	3.658	7.8685	
16			7.7351	7.6018	3.5056	3.5056	
17			7.4493	7.5065	4.1152	7.678	
18	.4382	.6096	7.2017	6.9731	3.658	3.5056	.381
19	.1524	.7239	6.7444	6.5539	3.658	6.5539	.4763
20	.4572	.4572	1.1812	1.1812	1.0669	1.5623	.743
21	.743	.4572	.9526	.743	.4572	.4572	.9526
22	.9526	.4572	.9907	.9526	.4572	.4572	.9526
23	.4572	.4572	.4572	.9907	.4572	.9526	.9335
24	6.0395	3.5627	.4572	.9907	.4572	2.5911	5.7156
Max	8.078	7.7541	8.6305	7.697	4.1152	8.6115	7.9256
Min	.1524	.4572	.1524	.4572	.1524	.3048	.381
Avg	3.2590	3.9404	3.9180	3.7062	2.0441	2.9806	3.0618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184034 / 33/11 KV BOPEGAON

Feeder No / Name : 203 / 11 KV RAJAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429		2.2862		
2	.3429	.3429		2.2862		
3	.3429	.362		2.3624		3.5246
4				2.4768		
5				2.6292		
6				2.9531		
7				3.2388		
8		.1524		3.3913		
9				3.2007		
12	3.6961					
13	3.658					4.2486
14	3.315					3.6199
15	3.1055	2.8578				3.7913
16	3.0293	3.4294				3.9057
17	3.0864	3.1626				3.8866
18	3.0102	2.8578	.1334	.2096		3.4675
19	2.6863	2.6863	.3048	.2286	.4001	3.2388
20	.3048		.362	.3048		.381
21	.362		.3429	.3429		.4001
22	.3429		.3429			.4001
23	.3239			.2858	.381	.4001
24	.3429	.3429		2.2291		.381
Max	3.6961	3.4294	.362	3.3913	.4001	4.2486
Min	.3048	.1524	.1334	.2096	.381	.381
Avg	1.7683	1.6537	.2972	1.8950	.3906	2.4343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184034 / 33/11 KV BOPEGAON

Feeder No / Name : 204 / 11 KV JAULKE WANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2858		.9907		
2	.3048	.2858		.9907		
3	.3048	.3048		1.0479		.3429
4				1.105		
5				1.1431		
6				1.2384		
7				1.5432		
12	1.6956					1.829
13	1.6575					1.6575
14	1.7147					1.5813
15	1.6956	1.6004				1.5813
16	1.467	1.6575				1.5623
17	1.3717	1.7147				1.5623
18	1.5813	1.6385	.1524	.1524		1.3146
19	1.4289	1.5242	.1905	.1715	.3048	1.4098
20	.2477		.2667	.2286		.2667
21	.2667		.3048	.2667		.2858
22	.2667		.3048	.2667		.2858
23	.2477			.2858	.3429	.3048
24	.3048	.2667		.9526		.3429
Max	1.7147	1.7147	.3048	1.5432	.3429	1.829
Min	.2477	.2667	.1524	.1524	.3048	.2667
Avg	.9288	1.0309	.2438	.7417	.3239	1.0234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184034 / 33/11 KV BOPEGAON

Feeder No / Name : 205 / 11 KV VARKHEDA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.3429		.3048		
2	.2667	.3239		.3048		
3	.2667	.3048		.3048		.3048
12	2.2862		2.7435	2.3624	2.3815	2.3243
13	2.2672		2.7816	2.6101		2.1719
14	2.4196		2.8197	2.4196		
15	2.2672	2.6673	2.6673	2.3815	2.3815	2.3434
16	2.3624	2.8578	2.572			2.0767
17	2.6292	2.6673	2.6101			2.2862
18	2.6292	2.3815	2.553		2.21	2.1148
19	2.4196	1.9052	2.4768	2.4387		1.9433
20	.2858		.2477	.2286	.3048	.2286
21	.2858		.3239	.2667		.2286
22	.2858		.3429	.2858		.2286
23	.2858			.2858	.3048	.2858
24	.2667	.3429		.3048		.3048
Max	2.6292	2.8578	2.8197	2.6101	2.3815	2.3434
Min	.2667	.3048	.2477	.2286	.3048	.2286
Avg	1.3432	1.5326	2.0126	1.1153	1.5165	1.2955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184034 / 33/11 KV BOPEGAON

Feeder No / Name : 206 / 11 KV SONJAMB

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.653	3.8744	3.7334	7.8083	3.674	3.8218	3.6435
2	3.5475	7.6033	3.7449	7.8105	3.6976	3.8386	3.4042
3	6.6819	7.4851	3.533	7.7801	3.6626	3.7913	7.0027
4	6.7383	7.4005	3.5185	6.5943	3.594	3.8386	3.4621
5	6.9738	7.3754		7.3426	3.5467	3.5856	3.5642
6	7.3846	7.5179		3.6062	3.7525	3.7974	7.5415
7	5.5677	2.271		1.8099	1.8503	1.4861	3.8119
8	.4359	1.608				3.3897	
9	3.5208	7.2893			3.5208	3.4888	6.6324
10	.1882	.5891				.3285	.2195
18	.3125		.5304	.4915	.2667		.4839
19	.3711	.5419	.314	.8451	.2942	.5776	.5777
20	.81	.3765	.8078	.7559	.3925	.5418	.7568
21	.8581	.41	.8817	.7598	.4108	.5891	.8962
22	.9038	.4664	.916	.8894	.4786	.4481	1.0007
23	.932	.487	.503	.9008	.5045	.9465	1.0197
24	7.0058	7.4943	3.03	3.5574	3.7022	3.5391	7.0789
Max	7.3846	7.6033	3.7449	7.8105	3.7525	3.8386	7.5415
Min	.1882	.3765	.314	.4915	.2667	.3285	.2195
Avg	3.4638	3.9244	1.9557	3.6394	2.2232	2.3755	3.1935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184034 / 33/11 KV BOPEGAON

Feeder No / Name : 207 / 11 KV NAVODAY G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6942	.6866	.3353	.6877	.3723	.3483	.3445
2	.69	.6805	.3292	.6809	.3616	.341	.3418
3	.6896	.6824	.3349	.7266	.3669	.3502	.6847
4	.7491	.7117	.3635	.7918	.3997	.3612	.3639
5	.7982	.3989	.4237	.8718	.442	.4374	.415
6	1.0407	.9522	.4477	1.0506	.5205	.5129	1.0692
7	1.025	.9762	.6036	1.0197	.5403	.5388	.5415
8	.9228	.8615	.5472	.8779	.447	.5007	.9892
9	.7282	.7426	.4039	.7819	.3688	.4005	.8177
10	.6199	.3822	.6847	.3887	.3711	.3506	.3963
11	.6298	.3399	.6992	.7407	.3494	.3875	.4146
12	.5696		.6885	.8021	.3864	.5494	.7944
13	.6089		.7342	.7571	.3917	.402	.7483
14	.6322		.759	.6942	.3681	.3955	.6957
15	.6371	.7727	.7841	.7403	.3685	.7685	.6462
16	.5772	.7888	.8131	.349	.4043	.3757	.7709
17	.6882	.8718	.9061	.8874	.4111	.4009	.788
18	.6794	.8921	.9542	.892	.4382	.9038	.8523
19	.8326	.7712	1.0856	.9843	.535	.4504	1.0285
20	1.0289	.6142	1.2297	1.1214	.652	1.1359	1.163
21	1.0014	.5998	1.0887	1.0745	.5548	.5681	1.1214
22	.8607	.4995	.9209	.9689	.4763	.4412	.9792
23	.77	.4595	.431	.8513	.4424	.7971	.8074
24	.7083	.7068	.3818	.7384	.3723	.3742	.7266
Max	1.0407	.9762	1.2297	1.1214	.652	1.1359	1.163
Min	.5696	.3399	.3292	.349	.3494	.341	.3418
Avg	.7576	.6853	.6646	.8116	.4309	.5038	.7292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184034 / 33/11 KV BOPEGAON

Feeder No / Name : 208 / 11 KV KADWA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4431	.4637	.2301	.4637	.2458	.2503	.2462
2	.4439	.4587	.2343	.4648	.2404	.2481	.2458
3	.4466	.4744	.2469	.4755	.2473	.2591	.4889
4	.4999	.4965	.2641	.5106	.2644	.2793	.2728
5	.6298	.5514	.3033	.6035	.3102	.309	.3079
6	.722	.6634	.3624	.7079	.354	.3437	.7197
7	.7037	.6573	.3014	.6253	.2923	.2987	.3426
8	.5666	.6687	.3075	.6142	.3197	.3475	.6207
9	.4999	.6218	.3185	.541	.3254	.3315	.6112
10	.5578	.274	.5974	.4279	.309	.3086	.5799
11	.5441		.6054	.3608	.3353	.2972	.2671
12	.4317		.5445	.4717	.2511	.5075	.5037
13	.4725		.4946	.157	.2629	.2888	.2747
14	.458	.1955	.4332	.3216	.2843	.2652	.5015
15	.4969	.6081	.4488	.4698	.2961	.5742	.5685
16	.58	.6394	.5292	.5662	.3391	.3311	.5738
17	.6623	.6874	.6576	.6394	.3045	.3246	.6535
18	.7651	.6664	.7144	.6836	.3894	.3563	.831
19	.8474	.8855	.9816	.8348	.4721	.4736	.8116
20	.9068	.4687	.9305	.9134	.4828	1.0007	.8871
21	.6767	.4553	.823	.7076	.3887	.4161	.7095
22	.5879	.3391	.6992	.6016	.346	.3159	.6584
23	.498	.2755	.2999	.4405	.2942	.5551	.6272
24	.4736	.4527	.2305	.4839	.2622	.2561	.4965
Max	.9068	.8855	.9816	.9134	.4828	1.0007	.8871
Min	.4317	.1955	.2301	.157	.2404	.2481	.2458
Avg	.5798	.5240	.4816	.5453	.3174	.3724	.5333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184034 / 33/11 KV BOPEGAON

Feeder No / Name : 209 / 11 KV MATEREWADI WATER NON SHEDDABLE WATER SUPPLY AND
SUPPLY Feeder KV- 11 / OUTGOING UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1905	.0762	.1715	.0762	.0762	.0762
2	.1334	.1905	.0762	.1715	.0762	.0762	.0762
3	.0572	.1905	.0762	.0953		.0762	.1524
4	.1334	.1905	.0762	.1905	.0762	.0762	.0762
5	.1524	.2096	.0762	.2286	.0762	.0762	.0762
6	.2667	.3429	.1524	.3429	.1524	.1524	.3048
7	.3429	.362	.1524	.3048	.1524	.1524	.1524
8	.3239	.3429	.0762	.2096	.1524	.1524	.2858
9	.2858	.2667	.0762	.3048	.1524	.0762	.3048
10	.3429	.1524	.3239	.3048	.1524	.1524	.3048
11	.381		.3239	.3048	.1524	.1524	.3239
12	.362		.2096	.3048	.1524	.1524	.1524
13	.3429		.3048	.3239	.1524	.3048	.3048
14	.381	.0762	.3048	.3429	.1524	.1524	.3239
15	.362	.1905	.362	.1524	.1524	.3048	.3048
16	.362	.0762	.4191	.3239	.1524	.1524	.2858
17	.3429	.3429	.3048	.2667	.1524		.3048
18	.2858	.3429	.2286	.3048	.1524	.3429	.2667
19	.2858	.3048	.3048	.1905	.1524	.1524	.2096
20	.2858	.1524	.2286	.2096	.1524	.1524	.1905
21	.2858	.1524	.1905	.3048	.1524	.0762	.1905
22	.2096	.0762	.1905	.2096	.0762	.0762	.2286
23	.1905	.0762	.0762	.1905	.0762	.1905	.2286
24	.1334	.1905	.0762	.1715	.0762	.0762	.1524
Max	.381	.362	.4191	.3429	.1524	.3429	.3239
Min	.0572	.0762	.0762	.0953	.0762	.0762	.0762
Avg	.2659	.2105	.1953	.2469	.1292	.1458	.2199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184034 / 33/11 KV BOPEGAON

Feeder No / Name : 210 / 11 KV AMBEWANI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572		2.0957		
2	.4572	.4572		2.0576		
3	.4572	.4572		2.1338		.4572
4				2.2481		
5				2.3624		
6				2.4768		
7				3.1245		
8				3.5437		
9				2.8006		
12						3.7151
13	3.1245					2.7054
14	3.4865					3.4865
15	3.4675	3.6199				3.3722
16	3.3722	3.6199				3.5437
17	3.3532	3.4294				3.4865
18	3.0293	3.2007	.2096	.1905		3.2198
19	2.7816	2.4768	.2286	.2477	.2667	3.3341
20	.4191		.381	.381		.4382
21	.4572		.4954	.4191		.4763
22	.4572		.4954	.4572		.4763
23	.4763			.4763	.4954	.4954
24	.4572	.4572		1.9814		.4572
Max	3.4865	3.6199	.4954	3.5437	.4954	3.7151
Min	.4191	.4572	.2096	.1905	.2667	.4382
Avg	1.7502	2.0195	.362	1.6873	.3811	2.1189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184202 / 33/11 KV KHEDGAON

Feeder No / Name : 201 / 11 KV SHINDWAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.753	2.7854	3.1255	3.1093	2.4905		3.1741
2	2.753	2.8673	3.1255	3.1417	2.5232		
3	2.753	2.8182	3.1255	2.9995			3.1579
4	2.834	2.9329	3.1093	3.1417	2.8346		3.2065
5	2.8826	2.9984	3.1579	3.1741	2.7854		
6	2.915	3.0803	3.1741		2.6216		
7	2.9959	2.9492	3.1093	2.753	2.7035		
8	3.1741	2.7526	3.1255	2.8826	2.769		
9		.1311	2.915	2.7206			
10	.1638	.1543	.1134	.1311			
11	.1311	.1029	.1134	.1638			.1311
12							.0983
13							.0983
14							.0972
15							.0972
16							.0972
17							.1296
18							.1134
19	.1638	.1524	.1296	.1638		.1619	.2286
20	.2294	.2058	.1943	.1966		.2105	.2286
21	.2294	.2058	.2429	.213		.2267	.2134
22	.2294	.2058	.2429	.2294		.2429	.2267
23	.2294	.2058	.2429	.213		.2267	.2267
24	2.672	2.9165	3.0769	3.0769	2.3594		
Max	3.1741	3.0803	3.1741	3.1741	2.8346	.2429	3.2065
Min	.1311	.1029	.1134	.1311	2.3594	.1619	.0972
Avg	1.6943	1.6156	1.9014	1.7694	2.6359	.2137	.7203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184202 / 33/11 KV KHEDGAON

Feeder No / Name : 202 / 11 KV NEW KHEDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5026	.5091	.5121	.527	.4995	.3033	.5216
2	.5018	.5114	.519	.5315	.498	.2843	.5178
3	.5033	.5129	.5274	.5376	.5026	.2881	.5254
4	.5071	.5152	.5319	.5506	.4963	.2926	.5216
5	.5163	.5461	.5205	.5376	.5062	.3003	.5285
6	.5132	.5224		.5369	.4869	.3018	.6527
7	.0739	.1181		.1029	.1174	.1006	.5127
8							.3331
9							.2651
10	.3734	.3182	.3341	.3757	.1608	.1943	.2759
11	.325	.298	.2988	.3541	.1562	.176	.2526
12	5.9372	5.8272	5.7255	5.9457	3.3562	3.296	6.4577
13	6.7082	6.3283	5.8735	5.9773	3.5338	6.1256	6.4007
14	6.2854	6.1075	6.2135	5.8789	3.2518	6.1027	6.7231
15	6.2308	6.2323	6.0272	6.1323	3.4797	6.1728	6.7433
16	6.4338	6.2643	5.8855	6.2549	3.6237	6.2902	6.2822
17	6.5546	6.7269	6.0486	6.4209	3.6862	6.1058	6.0886
18	6.354	6.0599	6.1439	6.2592	3.4903	6.2153	6.1233
19	6.378	5.0651	5.8467	5.9259	3.3897	6.1523	5.9302
20	1.0155	1.2509	1.2427	1.6449	1.0418	1.5341	1.1187
21	.5317	.5609	.5738	.5264	.3269	.5761	.5571
22	.5346	.5792	.5807	.5308	.3384	.5746	.567
23	.5502	.5762	.5776	.5292	.3353	.5716	.57
24	.5247	.5167	.5348	.5226	.5399	.2873	.5224
Max	6.7082	6.7269	6.2135	6.4209	3.6862	6.2902	6.7433
Min	.0739	.1181	.2988	.1029	.1174	.1006	.2526
Avg	2.6298	2.5430	2.7259	2.5729	1.5372	2.3748	2.4580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184202 / 33/11 KV KHEDGAON

Feeder No / Name : 203 / 11 KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9412	1.1765	.9877	1.1222	.9877		1.0317
2	.9412	1.2127	1.0059	1.1222	.9694		1.0317
3	.9114	1.2308	1.0059	1.1222	.9511		1.0317
4	1.0136	1.3213	1.0059	1.1222	1.0608		1.0317
5	1.0498	1.3756	1.0059	1.0498			1.0136
6	1.1222	.3982	1.0059	1.0498	.9694		.9955
7	1.1765	.5973	1.0059	1.1584	.9328		1.1403
8	1.1041	.8145	1.0608	1.1946	.8596		1.1403
9	1.1584	1.2489	1.086	1.2127			1.1765
10	1.1222		.6335	1.267			.9412
11	1.1584	.9593	.6878	1.2308			.6516
12	1.4118	1.1012	.724	1.3213			.4887
13	1.3394	1.2146	1.267	.5611		1.086	.4887
14	1.2851	1.1822	1.1584	1.1946		1.2308	.4887
15	1.3213	1.2146		1.2489		1.2308	.4706
16	1.267	1.2146	.3258	1.2489		1.1222	1.0974
17	1.0498	1.1336	1.1765	1.1946		1.1584	1.2437
18	1.1041	1.1498	1.1765	1.1946		1.1222	1.1458
19	1.0498	.2591	1.1222	1.1222		1.0498	1.1273
20	1.0498	1.1946	1.004	.9774		.9774	1.0719
21	1.0679	1.1222	1.0498	.9231		1.0136	.9425
22	1.0317	1.2803	1.0136	.9593		.9955	.8907
23	1.1403	1.3352	1.1222	.9231		1.1222	.9717
24	.8688	1.1584	1.1765	1.2489	.9877		1.0498
Max	1.4118	1.3756	1.267	1.3213	1.0608	1.2308	1.2437
Min	.8688	.2591	.3258	.5611	.8596	.9774	.4706
Avg	1.1119	1.0824	.9916	1.1154	.9648	1.1008	.9443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184208 / 33/11 KV PALKHED

Feeder No / Name : 201 / 11 KV NEW PALKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.695	.8322	1.085			.7682
2	.6401	.6767		1.085			.7682
3	.6401	.6767		1.1174			.7682
4	.6401	.6584		1.1336			.7865
5	.6584	.6767		1.2146			.7865
6	.6401	.7316		1.4737			.8048
7	.567	.695		2.0081			.7682
8	.4755	.695		2.4453			.8779
9	.4572	.6767		2.0405			.823
10	.4024	.0343		.3292			.695
11	.3077	.3768	.4527	.4755			1.2378
12	1.917	2.0645	.5121	.5487			2.4939
13	1.9989	2.1376	.5304	.567	.6154	2.2131	
14	2.1464	1.9595	.4755	.5853			
15	1.9334	2.0325	.6219	.5853			2.4777
16	2.13		.5487	.6219	.7133		
17	2.0645		.5853	.6401	.724		2.672
18	2.0153		.6401	.6219			
19	.4024		.7316	.7499		2.649	1.9757
20	.6882		.7133	.7865		.9145	.9145
21	.7682		.7682	.7316		.9877	.9328
22	.823		.7682	.6584		.9877	.9328
23	.7682	.5735	.6584	.5197		.9145	.8413
24	.6401	.6401	.7865	1.085	1.2239		.7682
Max	2.1464	2.1376	.8322	2.4453	1.2239	2.649	2.672
Min	.3077	.0343	.4527	.3292	.6154	.9145	.695
Avg	1.0152	.9412	.6417	.9629	.8192	1.4444	1.1547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184208 / 33/11 KV PALKHED

Feeder No / Name : 202 / 11 KV REDGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036		1.4548	1.6356			.695
2	.6036	.5611		1.6356			.6767
3	.5853	.5611		1.668			.6767
4	.5853	.5792		1.6842			.6584
5	.567	.5973		1.749			.6584
6	.567	.6697		1.9433			.6401
7	.5121	.4887		2.5587			.5304
8	.4572	.5068		2.915			.5304
9	.4024	.4344		2.4453			.5304
10	.3109	.3982		.2378			.4572
11	.081	.2591	.3206	.3292			1.4083
12	2.4777	2.2885	.2743	.3292			2.7044
13	2.6073	2.4006	.2926	.3658	.3258	2.4981	
14	1.9757	2.4194	.2926	.3658	.439		
15	2.3805	2.4985	.3658	.4024			2.5911
16	2.4777		.4755	.439	.3841		
17	2.5911		.4938	.4755	.4706		2.6073
18	2.6882		.4858	.5121			
19	.181		.5487	.567		2.6852	2.2348
20	.5344		.6401	.6219		.7316	.6219
21	.5792		.695	.5487		.7682	.6767
22	.5792		.6401	.5121		.7499	.6767
23	.5792	.7373	.3292	.9116		.7316	.6767
24	.6283	.5611	.9717	1.5384	1.5927		.6767
Max	2.6882	2.4985	1.4548	2.915	1.5927	2.6852	2.7044
Min	.081	.2591	.2743	.2378	.3258	.7316	.4572
Avg	1.0648	.9976	.5520	1.0996	.6424	1.3608	1.0464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184208 / 33/11 KV PALKHED

Feeder No / Name : 203 / 11 KV SHIWADEWANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4083	1.7004	.4715	.6584			1.4918
2	1.4586	1.668		.6584			1.5415
3	1.5424	1.668		.6401			1.5581
4	1.5592	1.7004		.6401			1.6575
5	1.6263	1.7976		.6584			1.757
6	1.861	2.0567		.6401			2.2211
7	2.6322	2.6558		.6401			2.5857
8	3.2023	2.0081		.4755			2.7183
9	.1646	.181		.439			.2012
10	.2743	.3439		.3841			.2926
11	.3801	.362	1.3927	.3658			.2561
12	.3439	.3772	2.5749	2.5194			.4207
13	.362	.4715	2.8826	2.6189	2.834	.3696	
14	.3801	.547	2.5263	2.7349			
15	.362	.547	2.753	2.6686			.4572
16	.4344		2.6235	2.7681	2.672		
17	.4887		3.0283	2.9338	2.8826		
18	.4525		2.8016	2.8178			.4207
19	.583		2.3482	.3326		.7577	.6584
20	.6878		.695	.499		.7865	.6584
21	.724		.7682	.7207		.8048	.6401
22	.724		.7682	.7207		.695	.695
23	.2915	.4715	.7499	.7023		.7209	
24	1.3413	1.5546	.4338	.6584	.7023		1.3094
Max	3.2023	2.6558	3.0283	2.9338	2.8826	.8048	2.7183
Min	.1646	.181	.4338	.3326	.7023	.3696	.2012
Avg	.9702	1.1830	1.7878	1.2040	2.2727	.6891	1.1337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184208 / 33/11 KV PALKHED

Feeder No / Name : 204 / 11 KV LONWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8192	.4715	.4938			.9892
2	.8718	.8029		.4938			1.0227
3	.9221	.8029		.4755			1.0395
4	.9556	.8192		.4755			1.1065
5	1.0059	.8356		.4938			1.1736
6	1.1401	1.1142		.4572			1.3916
7	2.1125	2.0481		.4207			2.4981
8	2.5987	2.5724		.3475			2.6658
9	.0732	.0914		.3109			.128
10	.1463	.1829		.2926			.2012
11	.1829	.2195	1.0978	.1463			.2743
12	.2012	.2641	2.3805	2.1293			.3109
13	.2378	.2641	2.5425	2.2131	2.0972	.2743	
14	.2743	.2641	2.3805	2.2298			
15	.2926	.2829	2.2186	2.0454			.3475
16	.2561		2.3482	2.1293	2.1136		
17	.3109		2.17	2.2634			.4024
18	.4024		2.0729	2.146			
19	.439		1.7652	.2033		.5544	.4938
20	.5121		.5121	.462		.5853	.567
21	.5121		.5487	.6099		.6219	.567
22	.5121		.567	.5544		.6036	.5853
23	.2294	.5093	.5487	.5175		.6203	.4572
24	.788	.8029	.4715	.4938	.5175		.9221
Max	2.5987	2.5724	2.5425	2.2634	2.1136	.6219	2.6658
Min	.0732	.0914	.4715	.1463	.5175	.2743	.128
Avg	.6590	.7468	1.4730	.9335	1.5761	.5433	.8572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184208 / 33/11 KV PALKHED

Feeder No / Name : 205 / 11 KV NEW DAWACHWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3185	.3647	.2263	.2743			.3561
2	.3353	.3481		.2743			.3561
3	.3688	.3481		.2561			.373
4	.3856	.3647		.2561			.407
5	.4024	.3812		.2561			.4917
6	.4527	.4475		.2561			.5256
7	.8215	.7293		.2378			.9156
8	.9389	.8785		.2195			.9665
9	.0732	.0739		.2012			.1097
10	.1463	.116		.1829			.1646
11	.1663	.1848	.4588	.1463			.1646
12	.1848	.2075	.7287	.6274			.2012
13	.2033	.2075	.8097	.6613	.5967	.1663	
14	.2402	.2452	.7449	.6274			
15	.2402	.2452	.7449	.5765			.2012
16	.2218		.7125	.6104	.6133		
17	.2402		.8097	.6443			.2195
18	.2402		.7935	.7291			
19	.2772		.6478	.1294		.3326	.2926
20	.2957		.2743	.1848		.3292	.3292
21	.2772		.3109	.2587		.3109	.3109
22	.2772		.2743	.2957		.3292	.3292
23	.0829	.2829	.2743	.2402		.1341	.2378
24	.285	.3647	.2452	.2743	.2402		.3561
Max	.9389	.8785	.8097	.7291	.6133	.3326	.9665
Min	.0732	.0739	.2263	.1294	.2402	.1341	.1097
Avg	.3115	.3406	.5371	.3508	.4834	.2671	.3654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184208 / 33/11 KV PALKHED

Feeder No / Name : 206 / 11 KV RAIEN INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1307	.1307	.1867			.112
2	.1307	.112		.1867			.112
3	.1307	.112		.1867			.112
4	.112	.1494		.168			.112
5	.112	.168		.168			.112
6	.0934	.0934		.1494			.112
7	.0934	.1307		.1494			.168
8	.0934	.1494		.0934			.112
9	.1867	.168		.2054			.0934
10	.0934	.0934		.1494			.1867
11	.1307	.0747	.1663	.1494			
12	.2054	.1663	.1867	.1494			.112
13	.1494	.1829	.1494	.1478		.112	
14	.2427	.1494	.168	.1294			
15	.2241	.1629	.1307	.1294			.112
16	.1307		.112	.1478	.112		
17	.1867		.168	.1478			.0934
18	.2427		.0934	.1663			
19	.2614		.1307	.1663		.1494	.168
20	.168		.1867	.1478		.1478	.1494
21	.112		.2054	.1478		.1663	.1494
22	.2054		.168	.1478		.2402	.2054
23	.2427		.1867	.1294		.2218	.2054
24	.1867	.1867	.1478	.2054	.168		.2033
Max	.2614	.1867	.2054	.2054	.168	.2402	.2054
Min	.0934	.0747	.0934	.0934	.112	.112	.0934
Avg	.1618	.1394	.1554	.1565	.14	.1729	.1384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184209 / 33/11 KV KOKANGAON

Feeder No / Name : 201 / 11 KV KOKANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3565	1.3441	.5335	.6001			1.4632
2	1.4022	1.3765	.5182	.5487			1.6032
3	1.4632	1.3765	.503	.5639			1.5546
4	1.7147	1.4089	.5487	.5944			1.7166
5	1.6004	1.4413	.5639	.6249			1.749
6	1.6766	1.6842	.6097	.6401			1.8623
7	2.1338	2.5425	.6097	.5182			2.6558
8	2.652	2.915	.4572	.4268			3.0445
9	2.6368	2.5453	.3963	.3963		.3658	2.7435
10	.2591	.2439	.3048	.2915		.3048	.3401
11	.2915	.2743	.1886	.2429		.1829	.2915
12	.3239	.2591	2.8197	2.4291	2.6673	2.5301	.3725
13	.3239	.2743	2.8349		2.4691	2.5911	.3725
14		.3048	2.652	2.4777	2.5587	2.3167	.3887
15		.2439	2.5301	2.3805	2.4129	1.89	.3963
16	.3725	.3506	2.5911	2.5749	2.4939	2.3167	.3658
17	.3563	.3963	2.8807	2.6397	2.6882	2.4996	.4049
18	.4049	.4115	2.4387				.3963
19	.4858	.5182	2.1186				.4572
20	.664	.6706	.6097				.6249
21	.664	.7202	.6401			.6706	.6401
22	.6154	.6706	.6097			.6401	.5182
23	.4858	.6097	.5639			.5487	.5182
24	1.326	1.2793	.5792	.5487			1.3717
Max	2.652	2.915	2.8807	2.6397	2.6882	2.5911	3.0445
Min	.2591	.2439	.1886	.2429	2.4129	.1829	.2915
Avg	1.0550	.9942	1.2126	1.0881	2.5484	1.4048	1.0772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 184209 / 33/11 KV KOKANGAON

Feeder No / Name : 202 / 11 KV SHIRASGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.583	1.2498	1.6004			.5639
2	.5487	.6154	1.3565	1.6766			.5792
3	.5639	.6154	1.4632	1.7071			.5944
4	.5792	.6478	1.5089	1.7985			.664
5	.6249	.6802	1.5851	1.9052			.6802
6	.6401	.6802	1.8138	1.9814			.6802
7	.5144	.4858	2.4996	2.5911			.5668
8	.3048	.3563	2.7892	2.9264			.421
9	.3086	.2439	2.5301	2.4691		2.7892	.2743
10	.1943	.2134	.1219	.1296		.1524	.2267
11	.1619	.1829	.1524	.1619		.1829	.1619
12	2.672	2.4844	.1981	.1943	.2134	.2134	3.0769
13	2.7692	2.7892	.2286	.1943	.1829	.2439	3.1741
14		2.6216	.2134	.2591	.2591	.2439	2.9797
15		2.5453	.2439	.2591	.2439	.2401	2.5911
16	2.7206	2.5758	.2743	.2591	.2591	.2439	1.9433
17	2.7854	2.6216	.2591	.2591	.2439	.2439	2.7854
18	2.8826	2.3777	.2439				2.6673
19	2.5425	1.9052	.381				2.4691
20	.5668	.5182	.4572				.5182
21	.583	.5944	.5182			.5639	.5944
22	.6478	.5639	.5487			.6249	.6097
23	.6316	.4877	.503			.6249	.6249
24	.5639	.583	1.1584	1.4937			.5944
Max	2.8826	2.7892	2.7892	2.9264	.2591	2.7892	3.1741
Min	.1619	.1829	.1219	.1296	.1829	.1524	.1619
Avg	1.1064	1.1655	.9291	1.2148	.2337	.5306	1.2517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 187006 / 132 KV RANWAD

Feeder No / Name : 201 / 11 KV SAWARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8212	2.0216		.8865	.7545	.7167	1.6872
2	1.8427			.8962	.7922	.6979	1.7223
3	1.8427	2.0833	.9335	.9242	.7733	.7545	1.761
4	1.9265			.9431	.7733	.7922	1.776
5	2.0168	2.234		.9431	.8299	.811	1.8212
6	2.2994		1.0642	.9522	.8865	.8299	2.1403
7	2.8395	2.8433		.8775	.6348	.6036	2.7778
8	3.187				.5601	.5601	3.2183
9	2.7892	2.8433	.7392	.5914	.5914	.4294	3.0933
10	.2957			.3921	.4066	.3696	.2241
11	.3841	.567		.2772	.2402	.2614	.2957
12	.4755		2.8464	2.9412	2.8622	2.4827	.3174
13	.5304	.6401		3.1089	3.131	2.9887	.3921
14	.5487			2.9527	3.2101	3.0994	.3734
15	.5304	.6036	3.1626	3.0994		3.0045	.3921
16	.567			2.9412	3.0519	3.1784	.4294
17	.5792			3.312	3.384	3.0836	.2402
18	.5853		3.2651	3.312		3.062	.4481
19	.7499	.7316			3.0093	2.9371	.6348
20	.961			.7167		.5281	.703
21	.9054	1.0719	.8775	.7922		.5847	.7655
22	.7762			.8488	.7922	.6224	.6908
23	.6535	1.0269	.9522	.811	.7167	.5093	.4607
24	1.7901	1.829	.9055	.8962	.7545	.7167	1.6204
Max	3.187	2.8433	3.2651	3.312	3.384	3.1784	3.2183
Min	.2957	.567	.7392	.2772	.2402	.2614	.2241
Avg	1.2874	1.5413	1.6385	1.5189	1.4077	1.4010	1.1660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 187006 / 132 KV RANWAD

Feeder No / Name : 202 / 11 KV RANWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.828	.5335	.4763		.4954	.7611
2	.8179			.4954	.4954	.4954	.7748
3	.8179	.8223	.5525	.5144	.5144	.4954	.8179
4	.823			.5525	.4954	.5335	.8749
5	.9105	.9488		.5906	.5525	.5525	.8905
6	1.1248		.5906	.5658	.5335	.5525	1.1469
7	1.4784	1.7185		.4715	.547	.4527	1.4784
8	1.713			.4108	.3395	.3734	1.7438
9	1.6105	1.4817	.3361	.2801	.2987	.2801	1.5565
10	.1478			.2427	.2614	.2241	1.7372
11				.1867	.1663	.1478	.2402
12	.2402	.2427	1.5123	1.4842	1.358	1.406	.2614
13	.2957			1.5123	1.5278	1.4352	.2427
14	.3142			1.448	.7095	1.6804	.2587
15	.3142	.2957	1.4815	1.4043		1.3592	.2427
16	.3326			1.4506	1.5154	1.4043	.2801
17	.3174			1.6512	1.6091	1.5779	.2614
18	.3734	.3326	1.6156	1.3094	1.5699	1.6512	.2957
19	.3921			1.6194	1.4148	1.4632	.3395
20	.4715			.415	.4715	.415	.415
21	.4949	.5093	.4338	.4715	.5093	.4338	.4338
22	.499			.5093	.547	.4338	.4435
23	.6224	.547	.5093	.4715	.5281	.4338	.4338
24	.7362	.7655	.5525	.4904	.4715	.3913	.7202
Max	1.713	1.7185	1.6156	1.6512	1.6091	1.6804	1.7438
Min	.1478	.2427	.3361	.1867	.1663	.1478	.2402
Avg	.6795	.7720	.8118	.7927	.7471	.7787	.6938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 187006 / 132 KV RANWAD

Feeder No / Name : 203 / 11 KV OLD DAWACHWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4382	.7727	.7375	.6984	.7526	.5093
2	.4338			.7579	.6836	.7827	.4904
3	.4527			.7676	.7042	.7727	.4904
4	.4904	.4763		.8579	.743	.8128	.5093
5	.4904			.9722	.7922	.9145	.5281
6	.5093		.9907	1.2346	1.0517	1.0936	.4904
7	.5658	.5144		1.6362	1.6284	1.6049	.4527
8	.3772			2.0319	2.0881	2.0469	.3961
9	.3881			1.6941	1.7535	1.7311	.044
10	.3361	.2926		.1848	.2507	.2012	.2818
11	.168			.2241	.2772	.2218	.2012
12	1.555	1.5257		.2614	.2587	.2427	1.3413
13	2.0767			.2452	.2427	.2427	1.3094
14	1.438			.2427	.2241	.2427	1.3847
15	1.3676	1.2163	.2402	.0934		.2427	1.3847
16	1.4098			.2054	.2587	.2402	1.46
17	1.6651			.3361	.3326	.2957	1.7387
18	1.5577	1.6495		.4251	.3155	.3511	1.7311
19	1.3352			.4294	.4108	.462	1.5257
20	.3227		.4338	.4527	.4904	.5093	
21	.462	.3961		.4527	.4527	.5281	.4481
22				.4715		.5281	.4854
23	.4715	.3772	.3961	.362		.5281	.4854
24	.4382	.4435	.7763	.7011	.6622	.7316	.4904
Max	2.0767	1.6495	.9907	2.0319	2.0881	2.0469	1.7387
Min	.168	.2926	.2402	.0934	.2241	.2012	.044
Avg	.8160	.7330	.6016	.6574	.6819	.6700	.7904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

CHANDWAD DIVISION[601]

PIMPALGAON[255]

BU 5487

Substation No/ Name :- 187006 / 132 KV RANWAD

Feeder No / Name : 208 / 11 KV KKW

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.1524	.1524	.1905	.132	.1886	.2075
2	.2096	.1334		.1698	.1509	.1886	.2263
3	.1715	.1886	.1905	.1509	.132	.1886	.2452
4	.1524	.0381		.1698	.1132	.1886	.2452
5	.1334	.1905		.1886	.1509	.1886	.2452
6	.1715		.1905	.1698	.132	.1886	.2641
7	.1715	.1524		.0754	.1698	.1886	.2263
8	.1143			.1698	.2075	.2075	.132
9	.2286	.0953	.1715	.0754	.2075	.1886	.2452
10	.1334			.132	.1886	.2075	.2641
11	.1715	.1715		.1132	.1698	.1886	.1698
12	.1905		.1334	.132	.132	.2075	.1698
13	.1524	.1143		.0943	.132	.2641	.2263
14	.2096			.1509	.132	.1509	.1886
15	.1905	.1524	.1334	.132	.132	.1886	.1509
16	.1715			.1698	.132	.1698	.1698
17	.1509	.2096		.132	.1509	.1886	.1698
18	.1524			.132	.1509	.1698	.1698
19	.1524	.1905		.1132	.1509	.1509	.1886
20	.1715		.1905	.1132	.1886	.1698	.2075
21	.1715			.1886	.1886	.1698	.2263
22	.1905			.132	.1886	.1886	.1698
23	.1905	.1905		.1509	.1886	.2452	.1509
24	.2286	.3429	.1715	.2096	.1509	.1886	.2452
Max	.3429	.3429	.1905	.2096	.2075	.2641	.2641
Min	.1143	.0381	.1334	.0754	.1132	.1509	.132
Avg	.1801	.1659	.1667	.1440	.1572	.1902	.2043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184020 / DINDORI

Feeder No / Name : 201 / NILWANDI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2058	.1715	.2229		.2229	.1715
2	.2229	.2058	.1715	.2401			.1715
3	.2401	.2229	.1715	.2401			.1715
4	.2572	.2229	.2058	.2572			.2058
5	.2229	.2401	.2058	.2743			.2058
6	.2229	.2572	.2401	.3429			.2743
7	.2229	.2572	.2058	.2572	.2572		.2401
8	.1886	.2229	.1715		.2229		.2401
9	.2058	.1715	.2401	.0857			.1715
10		.1372	.2229	.1029			.2058
11	.1715	.1372	.1543	.1029		.1372	.12
12	.1886	.1372	.1715	.1715	.1886	.1029	.1372
13	.1886	.1372	.1372	.1886	.1715	.1029	.1886
14	.1715	.1029	.1715	.1886		.1029	.1543
15	.1886	.1029	.1886	.1677		.1372	.12
16	.1886	.1029	.1886	.1715	.1715	.1372	.1543
17	.1886	.1372	.2229	.1715		.1372	.1372
18	.2058	.1715	.2743	.1886		.2058	.1372
19	.2401	.2743	.3601	.2058		.3086	.2915
20	.2572	.3086	.3429	.2401		.3429	.2401
21	.2572	.2743	.3086	.2572		.3258	.2572
22	.2572	.2401	.2743	.2572		.2743	.2058
23	.2401	.1715	.2401	.2401		.2058	.1715
24	.2229	.2229	.1715	.2058	.2058		.1715
Max	.2572	.3086	.3601	.3429	.2572	.3429	.2915
Min	.1715	.1029	.1372	.0857	.1715	.1029	.12
Avg	.2170	.1943	.2172	.2078	.2029	.1960	.1893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184020 / DINDORI

Feeder No / Name : 203 / PALKHED MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.4973	.5487	.6173			.583
2	.703	.0497	.5144	.6001			.5487
3	.6859	.0463	.5144	.6001			.5487
4	.6687	.4801	.5316	.583			.5658
5	.6516	.4801	.5316	.5658			.583
6	.7202	.5144	.583	.5658			.583
7	.7202	.5487	.5144	.5487	.583		.5487
8	.3772	.6859	1.0288	.6001	.6344		.6344
9	.3429	.6859	1.1145	1.2174			1.4918
10	.4458	.8916	1.1145	1.7661			1.5775
11		.9088	1.5089	1.6461		1.4403	1.5089
12	.6859	1.166	1.4403	1.5775		1.6804	1.5261
13	.7202	1.1317	1.4746	1.8347	1.6975	1.4746	1.9033
14	.7888	1.0974	1.4403	1.0631	1.2689	1.2689	1.8861
15	.8059	1.0117	1.6118	1.6632		1.1145	1.8347
16	.7888	1.4403	1.7833	1.4918	1.3717	.9602	1.3546
17	.823	1.3375	1.8176	1.3032		1.1317	1.3717
18	.4458	1.166	1.2174	.8402		1.3203	1.3546
19	.463	.9945	.9088	.7888		1.166	.9088
20	.4973	.8059	.9602	1.0974		1.1317	.9259
21	.5487	.7716	1.1317	.7202		.8916	.8402
22	.5316	.6859	.9088	.0789		.7716	.9259
23	.583	.6001	.6344	.6173		.6344	.823
24	.9431	.4801	.5487	.6516	.583		.6001
Max	.9431	1.4403	1.8176	1.8347	1.6975	1.6804	1.9033
Min	.3429	.0463	.5144	.0789	.583	.6344	.5487
Avg	.6359	.7699	1.0159	.9599	1.0231	1.1528	1.0595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184020 / DINDORI

Feeder No / Name : 204 / NILWANDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6344	1.6289	1.166			.6173
2	.6859	.6344	1.7147	1.3375			.6516
3	.7202	.6516	1.8004	1.4575			.6516
4	.703	.6687	1.9204	1.8176			.7202
5	.7373	.6859	2.0233	1.9376			.7545
6	.6859	.6859	2.1262	2.1091			.6516
7	.5316	.5487	2.7092	2.7435	2.8292		.4973
8		.3429	3.1036	3.1379	3.0864		
9		.2401	2.7949	2.6578			
10		.2401	.2058				
11	.2915	.2401					
12	2.4006	2.7606				1.6289	
13	3.1722	2.8121				2.7435	2.9492
14	3.1379	2.8464				2.6578	2.9492
15	3.1207	2.8807				2.8635	2.4177
16	3.0007	2.8978				3.0864	3.035
17	2.9492	2.7778				3.0521	2.915
18	2.915	2.7263	.2743	.2401		2.9664	2.7435
19	2.572	2.692	.3086	.3429		2.6578	2.5377
20	.5316	.4801	1.2003			.463	.6173
21	.4973	.5144	.5144	.4458		.5144	.463
22	.6173	.5658	.583	.5487		.583	.5658
23	.6859	.6344	.5658	.5487		.6516	.5658
24	.6173	.6001	.583	1.0974	1.8004		.6173
Max	3.1722	2.8978	3.1036	3.1379	3.0864	3.0864	3.035
Min	.2915	.2401	.2058	.2401	1.8004	.463	.463
Avg	1.4869	1.2817	1.4151	1.4392	2.572	1.9890	1.4169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184020 / DINDORI

Feeder No / Name : 205 / AWANKHED

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3148	3.0864	.7202	.6859		2.6749	2.4863
2	2.4006	3.1893	.7202	.703			2.4863
3	2.4006	3.2922	.7373	.6859			2.5034
4	2.4348	3.4465	.7373	.7202			2.5034
5	2.4863	3.6008	.7716	.7202			2.5034
6	2.7435	3.6866	.7888	.6859			2.7092
7	3.7723	4.2867	.7545				3.7723
8	3.4294	4.4582	.4801				3.738
9	3.0864	3.6694	.3601				3.0864
10	.3086		.3429				
11	.3258		.3086				
12	.3429		2.9492	3.3436			
13	.3258		4.0466	3.7723	3.1207		
14	.3429		3.9438	3.6866	3.1379		
15	.3601		3.9609	3.6694			.2401
16	.3258		3.9781	3.5151	3.3951		.3429
17	.3429	.3086	3.6351	3.7894		.4458	.3772
18	.3944	.4287	3.9438	3.6351		.4115	.4115
19	.5144	.5487	1.1831	3.3951		.4973	.5658
20	.6344	.6859	.6516	.6001		.6173	.583
21	.6859	.7202	.6687	.6859		.6516	.6859
22	.6687	.7716	.7716	.6687		.6859	.7716
23	.8059	.823	.7716	.8059		.7373	.7716
24	2.2291	2.915	2.572	.7202	.7545		2.4863
Max	3.7723	4.4582	4.0466	3.7894	3.3951	2.6749	3.7723
Min	.3086	.3086	.3086	.6001	.7545	.4115	.2401
Avg	1.4032	2.3481	1.6582	1.9204	2.6021	.8402	1.7381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184020 / DINDORI

Feeder No / Name : 206 / INDUST. FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	.9945	1.6118	.9945			1.5432
2	1.6461	1.0117	1.5775	1.0288			1.5432
3	1.6804	1.0288	1.5432	1.1145			1.5775
4	1.6632	1.0288	1.5432	1.166			1.5775
5	1.6804	1.0631	1.5089	1.2003			1.5775
6	1.6461	.1183	1.4746	1.2003			1.7147
7	1.2346	1.0631	1.4746	1.406	1.6461		1.6461
8	1.0288	1.0288	1.5432	1.406	1.7318		1.749
9	.9945	1.0288	1.8176	2.0576			1.7147
10	1.0631	1.1317	1.9204	2.1434			1.989
11	1.0288	1.166	2.1605	2.0919		1.5261	1.2003
12	1.1145	1.4403	2.0576	1.6804		1.5432	1.2346
13	1.0117	1.406	1.749	1.749	1.9204	1.406	1.2689
14	1.0631	1.3375	1.7147	1.9719	2.0576	1.2689	1.869
15	1.046	1.0974	1.6118	1.8004		1.406	1.8861
16	1.0117	1.3032	1.3717	1.6804	1.3717	1.5432	1.8519
17	1.0631	1.2689	1.4403	1.6461		1.5432	1.8861
18	1.0288	1.2689	1.2003	1.5432		1.5432	1.3717
19	1.0631	1.3032	1.2003	1.286		1.3032	1.2346
20	1.166	1.0974	1.2003	1.3032		1.2003	1.3717
21	1.0631	1.0974	1.0631	1.3375		1.2346	1.2346
22	1.1317	1.1317	1.166	1.2689		1.3203	1.2346
23	1.0631	1.166	.9259	1.286		1.406	1.2003
24	1.749	.9945	1.6118	.8916	1.3717		1.5432
Max	1.749	1.4403	2.1605	2.1434	2.0576	1.5432	1.989
Min	.9945	.1183	.9259	.8916	1.3717	1.2003	1.2003
Avg	1.2482	1.1073	1.5203	1.4689	1.6832	1.4034	1.5425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184020 / DINDORI

Feeder No / Name : 207 / DINDORI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.286	1.1317	1.2346	1.3375			1.3717
2	1.3032	1.1488	1.2689	1.3546			1.3375
3	1.2517	1.166	1.2689	1.3375			1.3375
4	1.2346	1.1488	1.286	1.3032			1.3203
5	1.2689	1.2003	1.3203	1.2517			1.3203
6	1.4403	1.3717	1.3717	1.4232			1.4403
7	1.4746	1.4403	1.5604	1.5261	1.4575		1.5432
8	1.2689	1.3203	1.4232	1.4918	1.4403		1.3032
9	1.1145	1.2689	1.2346	1.2346			1.2517
10	.8573	1.2346	1.2689	1.2689			1.2689
11	1.2003	1.1488	1.2689	1.3032		1.3546	1.2517
12	1.0974	1.1488	1.3032	1.3375		1.406	1.2346
13	1.1488	1.166	1.1831	1.286	1.2346	1.3546	1.2689
14	1.1831	1.2003	1.2003	1.2346	1.2174	1.286	1.286
15	1.166	1.2174	1.2517	1.406		1.3717	1.3717
16	1.2346	1.3889	1.3032	1.4918	1.2689	1.4403	1.406
17	1.2174	1.3203	1.3375	1.4575		1.4746	1.3889
18	1.2003	1.406	1.3717	1.4746		1.5261	1.3889
19	1.5432	1.5089	1.6289	1.6118		1.7318	1.5775
20	1.6461	1.8347	1.6632	1.8004		1.749	1.5432
21	1.406	1.6289	1.5775	1.6804		1.7147	1.5089
22	1.4403	1.4746	1.4746	1.5261		1.5775	1.4575
23	1.2517	1.3717	1.406	1.3889		1.4575	1.3546
24	1.2689	1.1317	1.2346	1.3717	1.3375		1.3717
Max	1.6461	1.8347	1.6632	1.8004	1.4575	1.749	1.5775
Min	.8573	1.1317	1.1831	1.2346	1.2174	1.286	1.2346
Avg	1.2710	1.3074	1.3517	1.4125	1.3260	1.4957	1.3710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184020 / DINDORI

Feeder No / Name : 208 / AWANKHED GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1029	.0857	.1372			.1372
2	.1543	.1029	.0857	.1029			.1372
3	.1372	.12	.0857	.12			.1372
4	.12	.12	.1029	.1372			.1543
5	.1372	.1372	.1029	.1372			.1543
6	.1372	.1543	.1372	.1543			.1543
7	.1372	.1543	.1372	.12	.1372		.1715
8	.12	.1372	.1029	.12	.12		.1372
9	.1029	.1029	.1029	.1029			.1372
10	.0857	.12	.12	.1029			.1372
11	.0857	.0857	.0686	.0857		.0857	.1372
12	.0686		.0857	.0686		.0686	.1372
13	.0857	.1029	.0686	.0686	.1029	.0857	.1029
14	.0857	.0857	.0857	.0686	.1029	.0857	.1029
15	.0857	.0857	.0857	.0857		.0857	.1029
16	.0857	.0857		.0857	.1029	.0857	.1029
17	.0857	.0857	.0857	.1029		.0857	.1029
18	.1029	.1372	.1372	.0103		.1372	.1372
19	.12	.1372	.1372	.1372		.1715	.1372
20	.1543	.1715	.1372	.1715		.1886	.1372
21	.1543	.1715	.1543	.1543		.1715	.12
22	.1372	.1543	.1372	.1543		.1715	.1543
23	.12	.1372	.1372	.1372		.1543	.1543
24	.12	.1029	.1029	.1372	.12		.1372
Max	.1543	.1715	.1543	.1715	.1372	.1886	.1715
Min	.0686	.0857	.0686	.0103	.1029	.0686	.1029
Avg	.1150	.1215	.1081	.1126	.1143	.1213	.1343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184020 / DINDORI

Feeder No / Name : 209 / Hatnore

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.332	2.1434	.6516	.7545		2.2291	2.4006
2	2.3663	2.1776	.6516	.7373			2.4348
3	2.3834	2.2291	.6859	.7202			2.4691
4	2.4006	2.2634	.7202	.6859			2.5034
5	2.4006	2.3148	.7545	.823			2.5377
6	2.4863	2.572	.7545	.6173			2.6749
7	3.4294	2.915	.4115	.6173	.5144		3.155
8		3.0007	.3429	.3429	.4287		3.4294
9		2.8292	.3258	.4115			3.2922
10		.2058	.2572	.3429			.3429
11	.2743	.2743	.2743	.2058		.2058	.2743
12	.3429	.2058	2.1262	3.7723		.2058	.2743
13	.3429	.2058	3.5665	3.2579	3.2922	.2401	.2743
14	.3601	.2058	3.4637	3.0864	3.0864	.2743	.2743
15	.3429	.2058	3.4294	3.0007		.2743	.2743
16	.3429	.2058	3.3265	3.0178	2.915	.2743	.2058
17	.3601	.2743	3.3265	3.0864		.2743	.1886
18	.3772	.3772	2.8807	3.0007		.2743	.2058
19	.4801	.4801	2.7435	2.572		.4801	.5658
20	.5316	.4801	.5144	.5144		.4801	.5144
21	.6173	.5487	.5487	.5487		.5487	.6859
22	.6859	.6859	.6859	.6173		.6173	.7545
23	.7202	.823	.7545	.7202		.6859	.7202
24	2.3148	2.0576	2.0576	.7202	.7545		2.4006
Max	3.4294	3.0007	3.5665	3.7723	3.2922	2.2291	3.4294
Min	.2743	.2058	.2572	.2058	.4287	.2058	.1886
Avg	1.2329	1.2367	1.4689	1.4239	1.8319	.5046	1.3689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184020 / DINDORI

Feeder No / Name : 210 / DINDORI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.046	3.0864	3.155		.8573	1.0288
2	1.046	1.0288	3.1722	3.3951			1.0288
3	1.0631	1.0117	3.3436	3.4637			1.0631
4	.9602	1.046	3.6008	3.6351			1.1145
5	1.0288	1.0288	3.8409	3.7723			1.166
6	1.0631	1.0974	4.0124	4.1838			1.0288
7	.9602	.9602	5.0755	4.561	4.5439		.8916
8	.7545	.8916	4.8697	4.8011	4.6296		.9602
9	.6859	.8573	4.1838	4.2867			.8573
10	4.1152	4.1152	.5144	.0617			2.7778
11		3.9781	.6173	.6344		3.8066	4.3896
12	4.2867	4.1152	.6516	.6516	.6173	3.8409	4.4239
13	4.4582	3.9438	.6859	.5144	.6516	3.8409	4.1838
14	4.6296	3.7894	.7202	.6173	.6516	3.7723	4.1495
15	4.4582	3.6351	.7202	.6859		3.7037	3.4294
16	2.572	1.9204	.6859	.6516	.6173	1.7833	1.7147
17	2.4006	1.9547	.6859	.7545		1.8176	1.9204
18	2.2291	1.989	.7545	.7716		1.8519	1.9547
19	2.0576	2.0233	.823	.0789		1.9204	1.9204
20	.1852	1.7833	.8916	.9602		1.7833	1.8861
21	1.6804	1.7147	.9602	.9945		1.6461	.6173
22	1.0288	.9945	1.0288	1.0288		1.0631	1.0974
23	1.0631	1.0288	1.0288	1.0117		1.166	1.166
24	1.0288	1.0288	.9602	2.7778	.3292		1.0974
Max	4.6296	4.1152	5.0755	4.8011	4.6296	3.8409	4.4239
Min	.1852	.8573	.5144	.0617	.3292	.8573	.6173
Avg	1.9486	1.9576	1.9547	1.9770	1.7201	2.3467	1.9111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184020 / DINDORI

Feeder No / Name : 211 / INDORE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.6344	.3086	.3772		.5144	.6859
2	.7545	.6687	.3086	.4115			.7202
3	.7716	.6859	.2058	.3772			.7888
4	.7373	.7202	.2058	.3429			.8573
5	.7545	.7716	.1715	.3772			.9088
6	.9431	.9602	.1715	.4115			1.0974
7	1.3203	1.3375	.2058	.3772	.2229		1.3889
8	1.4918	1.4575	.1372	.4115	.1715		1.5261
9	1.3717	1.3032	.1372	.3429			1.2517
10	.1715	.2058	.1372	.2572			.1372
11	.1715	.1715	.1372	.1715		.1715	.1372
12	.1886	.1372	1.0631	1.2003		.1715	.1372
13	.1886	.1372	1.3203	1.2003	1.2003	.2058	.1372
14	.1715	.1372	1.2689	1.1831	1.1317	.2058	.1372
15	.1886	.1372	1.3375	1.166		.1715	.1372
16	.1715	.1372	1.3546	1.0974	1.2003	.1715	.1372
17	.1715	.1372	1.3717	1.2174		.2058	.1372
18	.1886	.1715	1.406	1.2346		.2401	.1543
19	.2058	.2401	1.1831	1.1145		.2401	.1715
20	.2229	.2743	.2058	.2058		.2743	.1543
21	.2058	.2743	.2401	.2229		.2743	.2743
22	.1886	.3086	.2743	.2401		.3086	.3086
23	.1715	.3086	.3429	.2229		.3086	.2743
24	.7202	.6173	.4115	.4115	.2058		1.3889
Max	1.4918	1.4575	1.406	1.2346	1.2003	.5144	1.5261
Min	.1715	.1372	.1372	.1715	.1715	.1715	.1372
Avg	.5087	.4973	.5794	.6073	.6888	.2474	.5437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184067 / LAKHAMAPUR

Feeder No / Name : 201 / LAKHAMAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0117	.9088	.9945	.2058	.2401		.7373
2	1.0117	.9259	.9945	.2058	.2229		.9602
3	1.0288	.9602	.9774	.2058	.2058		1.166
4	1.0288	1.0117	.9774	.2572	.2743		1.1317
5	1.0974	1.0631	1.0117	.2743	.2572		1.2689
6	1.166	1.1317	1.166	.2401	.2572		1.3375
7	1.4746	1.5775	1.5089	.2229	.2401		1.406
8	1.6461	1.6461	1.4918	.1886	.1886		1.4232
9	.1029	.1372	.12	.2058			.1372
10	.1372	.1715	.1543	.1543			.1372
11	.1029	.1543	.12	1.1831			.1372
12	.12	.1543	.1372	1.4918	1.4575	1.5604	.1372
13	.12	.1886	.1543	1.6118	1.3717	1.4232	.1543
14	.12	.1886	.1543	1.4746	1.3032	1.3032	.12
15	.1372	.1372	.1543	1.406		1.3203	.1372
16	.1543	.1372	.1543	1.4403	1.3203	1.3203	.1372
17	.12	.1372	.1543	1.4918	1.3889	1.2517	.1715
18	.1715	.1543	.2058	1.4403		1.3032	.2058
19	.2058	.2572	.2743	.2058		.1372	.2572
20	.2229	.2915	.2229	.2401		.2401	.2743
21	.2572	.2743	.2401	.2572		.2401	.2572
22	.2401	.2572	.2401	.2743		.2401	.2743
23	.823	.823	.8573	.2572		.2401	.7545
24	.9945	.8916	.9774	.2229	.2401		.703
Max	1.6461	1.6461	1.5089	1.6118	1.4575	1.5604	1.4232
Min	.1029	.1372	.12	.1543	.1886	.1372	.12
Avg	.5623	.5658	.5601	.6316	.6406	.8817	.5594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184067 / LAKHAMAPUR

Feeder No / Name : 202 / INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0171		.0171
2	.0171	.0171	.0171	.0171	.0171		.0171
3	.0343	.0171	.0343	.0171	.0171		.0171
4	.0343	.0171	.0343	.0343	.0171		.0171
5	.0343	.0343	.0343	.0343	.0343		.0343
6	.0514	.0343	.0514	.0514	.0343		.0686
7	.0343	.0171	.0343	.0171	.0343		.0857
8	.0343	.0171	.0343	.0514	.0686		.0686
9	.0686	.0171	.0686	.0686			.0514
10	.0514	.12	.0686	.0514			.1029
11	.0857	.0857	.0686	.0857			.0686
12	.0857	.0857	.0686	.0514	.0857	.0857	.0686
13	.0857	.1029	.1029	.0343	.0857	.0686	.0686
14	.0686	.0857	.0857	.0343		.0343	.0686
15	.0686	.1029	.0686	.0343		.0686	.0857
16	.0686	.0857	.0686	.0686	.0686	.0857	.1029
17	.0686	.0857	.0686	.0686	.0686	.0686	.0343
18	.0686	.0686	.0686	.0686		.0857	.0343
19	.0686	.0857	.0857	.0857		.12	.0343
20	.0514	.0686	.0514	.0514		.1029	.0514
21	.0171	.0343	.0171	.0171		.0171	.0171
22	.0171	.0171	.0171	.0171		.0171	.0171
23	.0171	.0171	.0171	.0171		.0171	.0343
24	.0171	.0171	.0171	.0343	.0171		.0343
Max	.0857	.12	.1029	.0857	.0857	.12	.1029
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0486	.0521	.05	.0428	.0435	.0643	.05

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184067 / LAKHAMAPUR

Feeder No / Name : 203 / DAHEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.4287	.3944	2.1091	2.0233		.3429
2	.3944	.4287	.3944	2.1434	2.0919		.3258
3	.3944	.4287	.4115	2.1776	2.1605		.3944
4	.4115	.3944	.4287	2.2805	2.2634		.3772
5	.4115	.4458	.4458	2.4348	2.3663		.4115
6	.4115	.463	.4115	2.5377	2.5549		.4287
7	.3086	.3944	.3086	2.7435	2.7435		.3258
8	.3258	.2743	.2743	2.915	2.9321		.2401
9	.2915	.2229	.2743	.1029			.2229
10	.2743	.2058	.2572	.12			.2058
11	1.9719	2.0405	1.4575	.1543			1.8861
12	2.6406	2.4863	2.7778	.1715	.2229	.2229	2.0062
13	2.8635		2.8292	.1715	.2229	.1715	2.5377
14	2.8121	2.5549	2.8292	.1715	.2229	.2058	
15	2.7606	2.7263	2.915	.1715		.2229	
16	2.692	3.0864	2.9664	.1715	.2229	.2401	2.2977
17	2.8978	2.9835	2.915	.1543	.1372	.2229	2.4348
18	2.8292	2.8807	2.5377	.1543		.2229	2.0576
19	.2229	.2229	.2915	.2572		.2915	
20	.3086	.3601	.3429	.3258		.3429	
21	.3601	.3429	.3772	.3429		.3772	.3429
22	.3944	.3772	.3944	.3601		.4115	.4458
23	.4287	.4115	.3772	1.9204		1.7833	.4115
24	.4115	.4287	.4115	1.9719	1.9719		.3601
Max	2.8978	3.0864	2.9664	2.915	2.9321	1.7833	2.5377
Min	.2229	.2058	.2572	.1029	.1372	.1715	.2058
Avg	1.1338	1.0691	1.1260	1.0860	1.5812	.3930	.9028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184067 / LAKHAMAPUR

Feeder No / Name : 204 / LAAKHAMAPUR GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.12	.1372	.12	.1372		.1372
2	.12	.12	.1372	.12	.1372		.1372
3	.12	.1372	.1372	.12	.1372		.1372
4	.1372	.1372	.1372	.1372	.1372		.1543
5	.1715	.1543	.1715	.1372	.2058		.1886
6	.2058	.1886	.2058	.2058	.1886		.2058
7	.1715	.1715	.1543	.1543	.1715		.1715
8	.1372	.12	.1543	.1543	.1372		.12
9	.12	.1029	.12	.1029			.1372
10	.12	.1372	.12	.1029			.1372
11	.0857	.1029	.0857	.1029			.1372
12	.1029	.0857	.0857	.1029	.0686	.0857	.1029
13	.0857	.0857	.0857	.1029	.0686	.1029	.1029
14	.0857	.0857	.0857	.1029	.0857	.1029	.1029
15	.0857	.0857	.0857	.1029		.1029	.1029
16	.1029	.1029	.1029	.1029	.1543	.1029	.1029
17	.1029	.1029	.0857	.1372	.12	.1029	.1372
18	.1372	.12	.1715	.1372			.1543
19	.1543	.1886	.2058	.1715		.2229	.1715
20	.2229	.2058	.2058	.2229		.2058	.2401
21	.1886	.1886	.1715	.1886		.1886	.1886
22	.1543	.1715	.1715	.1715		.1715	.1715
23	.1372	.1543	.1372	.1543		.1715	.1715
24	.1372	.1372	.1372	.1372	.12		.1543
Max	.2229	.2058	.2058	.2229	.2058	.2229	.2401
Min	.0857	.0857	.0857	.1029	.0686	.0857	.1029
Avg	.1336	.1336	.1372	.1372	.1335	.1419	.1486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184067 / LAKHAMAPUR

Feeder No / Name : 205 / NEW INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.0857	.2058	.2058	.2572		.2743
2	.3772	.0686	.2058	.2058	.2401		.2401
3	.3429	.0686	.1886	.1886	.2058		.2401
4	.3086	.0686	.1886	.2058	.2058		.2058
5	.2743	.0686	.2058	.2058	.2058		.2058
6	.2572	.0857	.2058	.2229	.2229		.2058
7	.3086	.2058	.2058	.2229	.2229		.2229
8	.4287	.1715	.2229	.2058	.3086		.2401
9	.2229	.2743	.3601	.4287			.4287
10	.2572	.3772	.4115	.463			.5144
11	.2401	.5487	.2572	.3429			.3086
12	.2229	.4115	.3772	.2743	.3772	.5487	.3429
13	.2058	.3772	.2229	.2058	.2229	.5144	.2743
14	.2058	.2401	.2743	.1886		.2915	.2743
15	.2058	.4458	.2743	.1715		.3772	.463
16	.2229	.4458	.2572	.4287	.3258	.4458	.4115
17	.2229	.3601	.3086	.2743	.3086	.4115	.2401
18	.2058	.3429	.2743	.2229		.5487	.3429
19	.2229	.2401	.4115	.2401		.463	.2572
20	.2229	.2401	.3429	.2572		.3086	.1886
21	.2229	.3944	.4801	.2743		.2572	.2229
22	.1029	.3772	.5144	.2915		.3429	.2915
23	.1029	.3086	.463	.2743		.5487	.3772
24	.463	.1029	.3944	.2572	.2401		.2743
Max	.463	.5487	.5144	.463	.3772	.5487	.5144
Min	.1029	.0686	.1886	.1715	.2058	.2572	.1886
Avg	.2579	.2629	.3022	.2608	.2572	.4215	.2936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184067 / LAKHAMAPUR

Feeder No / Name : 206 / permori

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.5658	.583	2.4691	2.332		.583
2	.583	.5658	.583	2.4691	2.2977		.583
3	.583	.583	.583	2.4863	2.2634		.5658
4	.583	.583	.583	2.5034	2.4006		.5658
5	.583	.583	.583	2.4006	2.4863		.583
6	.583	.583	.5658	2.5034	2.4348		.583
7	.5144	.5658	.5316	2.9321	2.8635		.583
8	.3772	.4115	.4287	2.915	3.1893		.4973
9	.3429	.3772	.3772	.2572			.4287
10	.3086	.3258	.3258	.2743			.3429
11	2.692	2.6406	2.6578	.2401			2.572
12	3.2579	3.1207	3.2236	.2401	.2915	.2572	2.9492
13	3.275	3.2065	3.2579	.2401	.2743	.2401	3.0864
14	3.2922	3.1036	3.1893	.2401	.2915	.2915	3.2922
15	3.1893	3.0693	3.155	.2572		.2915	2.7092
16	3.1207	3.2065	3.1207	.3086	.2229	.2743	3.2065
17	2.9492	3.2065	3.0864	.3601	.3601	.3258	3.0864
18	3.035	3.1036	2.9492	.3429		.3772	2.8807
19	.2572	.3086	.3772	.4115		.463	.3429
20	.4801	.4287	.4801	.5144		.4973	.4458
21	.5144	.4801	.5316	.583		.5316	.4801
22	.6173	.583	.5658	.583		.5658	.5487
23	.583	.583	.583	2.2119		1.6461	.583
24	.583	.5658	.583	2.3663	2.2977		.583
Max	3.2922	3.2065	3.2579	2.9321	3.1893	1.6461	3.2922
Min	.2572	.3086	.3258	.2401	.2229	.2401	.3429
Avg	1.3703	1.3646	1.3710	1.2546	1.7147	.4801	1.3367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184067 / LAKHAMAPUR

Feeder No / Name : 207 / OZE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.7092	2.9492	.3429	.3429		2.4177
2	2.7435	2.8464	2.9492	.3429	.3429		2.9835
3	2.7606	2.9492	2.9664	.3429	.3772		2.7778
4	2.7778	2.9835	2.9835	.3601	.3944		3.1893
5	2.8464	3.1893	3.0178	.3944	.4115		3.4637
6	2.9664	3.3093	3.1036	.3429	.3601		3.5837
7	3.7037	4.0295	3.5151	.3429	.2915		3.6694
8	3.7209	3.858	3.4294	.3429	.2058		3.5494
9	.2401	.2401	.2572	.2401			.1543
10	.2743	.2743	.1715	.2058			.2572
11	.1543	.2058	.1372	2.5377			.0857
12	.1886	.1886	.1715	3.3608	3.6008	3.7551	.12
13	.1886	.3086	.2058	3.6694	3.4637	3.6523	.1372
14	.2058	.2572	.1715	3.6008	3.6351	3.6866	
15	.2058	.2401	.1886	3.4979		3.4637	
16	.1886	.2058	.2058	3.8237	3.5494	3.3608	.12
17	.2058	.2058	.2572	3.7037	3.4979	3.6351	.2058
18	.1543	.2401	.2743	3.5665		3.5151	.1372
19	.2743	.2915	.3772	.2572		.2401	.1372
20	.3258	.3601	.3944	.2915		.2915	
21	.3944	.3601	.4115	.3429		.3601	.3086
22	.4287	.4115	.4458	.3944		.3944	.3772
23	2.0576	2.0748	1.8861	.3944		.4115	.0099
24	2.7435	2.5034	2.6578	.3429	.3944		2.1091
Max	3.7209	4.0295	3.5151	3.8237	3.6351	3.7551	3.6694
Min	.1543	.1886	.1372	.2058	.2058	.2401	.0099
Avg	1.3539	1.4268	1.3803	1.3767	1.4905	2.2305	1.4188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184248 / 33/ 11 KV Ware (Dindori)

Feeder No / Name : 201 / KARANJALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3601	.3258	.6173			.3601
2	.3429	.3601	.3258	.6687			.3086
3	.3429	.3601	.3258	.7202			.3429
4	.3772	.3944	.3429	.7545			.3772
5	.4115	.4287	.3772	.7888			.3772
6	.4458	.463	.4287	1.0974			.4115
7	.3772	.3772	.3258	1.286			.3772
8	.2401	.2743	.2229	1.2517			.2229
9	.1886	.2058	.1715	.1372			.1715
10	.12	.1543	.1372	.12			
11		.8059	.8745	.1029			
12		2.0405	1.5089	.1029	.1029		
13		2.0748	1.749		.1029	.1372	1.7833
14	2.0748	2.0062	1.7318	.12	.1029	.1372	1.869
15	1.9376	1.9376	1.8861	.1029		.12	1.749
16	2.0405	2.0576	1.749	.12	.12		1.9033
17	2.0748	2.1605	1.8519	.1372		.1543	1.9376
18	2.1262	.216	1.8004	.1543		.2058	1.2689
19	.2058	.2401	.2058	1.1317		.3086	1.5947
20	.4115	.3944	.3772	.4115		.3772	.3944
21	.4287	.3772	.3944	.4458			.4115
22	.4115	.3944	.3772	.3772		.3086	.4115
23	.3944	.3429	.3601	.3944		.3429	.3944
24	.3772	.3601	.3772	.5316		.3258	.3258
Max	2.1262	2.1605	1.8861	1.286	.12	.3772	1.9376
Min	.12	.1543	.1372	.1029	.1029	.12	.1715
Avg	.7479	.7828	.7595	.5032	.1072	.2418	.8092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184248 / 33/ 11 KV Ware (Dindori)

Feeder No / Name : 202 / WANARE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7545	.6859	.2229			.7545
2	.7373	.7545	.6859	.2229			.5144
3	.7716	.7716	.6859	.2401			.6859
4	.823	.8059	.7202	.2743			.7545
5	.8916	.7716	.7716	.3086			.823
6	1.0288	.7716	.8402	.3086			.8916
7	1.2517	1.286	1.2174	.3258			1.0974
8	1.3203	1.3203	1.2689	.2058			1.2689
9	.1886	.1715	.1372	.1543			.12
10	.1372	.12	.12	.1372			.12
11		.0857	.0857	.7888			.0686
12		.0857	.0857	1.3203	1.3203		.12
13		.0857	.0857	1.3375	1.406	1.2689	.0857
14	.12	.1029	.0686	1.286	1.2003	1.2689	.0857
15	.1029	.1029	.0857	1.3889		1.286	.1029
16	.1029	.12	.1029	1.2003	1.406		.1029
17	.12	.1372	.1029	1.3546		1.3032	.1372
18	.1372	.0171	.1715	1.2174		1.3032	.1886
19	.2743	.2915	.3086	1.1317		.2401	.2915
20	.3258	.3258	.3429	.3772		.3258	.3429
21	.2915	.2572	.3429	.3086			.2915
22	.2401	.2572	.2743	.2572		.2743	.2572
23	.4801	.5144	.2058	.2572		.2229	.5144
24	.6516	.7202	.2229	.2401		.1715	
Max	1.3203	1.3203	1.2689	1.3889	1.406	1.3032	1.2689
Min	.1029	.0171	.0686	.1372	1.2003	.1715	.0686
Avg	.5087	.4430	.4008	.6194	1.3332	.7665	.4182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184248 / 33/ 11 KV Ware (Dindori)

Feeder No / Name : 203 / BARAPADE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6516	.583	.2229			.4801
2	.5487	.6516	.583	.0223			.5144
3	.5487	.6687	.583	.2229			.6173
4	.6001	.7202	.6344	.2572			.6859
5	.7202	.7716	.6859	.2915			.6859
6	.8573	.8059	.7373	.3086			.7545
7	1.0288	1.046	.9259	.3258			.7545
8	.9259	1.0631	.9259	.2229			.8916
9	.1372	.1372	.12	.1029			.1543
10	.0686	.1029	.1029	.0514			.1029
11		.0857	.0686	.3772			.0686
12		.0686	.0514	.823			.0686
13		.0686	.0686	.7716	.6859	.9088	.0686
14	.0857	.0686	.0686	.7202	.7888	.823	.0514
15	.1029	.0686	.0686	.7202		.6173	.0857
16	.12	.1029	.0686	.7373	.6859		.0686
17	.1372	.1372	.0686	.8745		.8059	.1372
18	.1715	.1886	.1715	.6687		.8573	.1886
19	.3086	.3258	.2915	.7373		.2915	.3429
20	.3258	.3086	.3772	.3944		.3601	.3601
21	.2915	.3086	.3772	.3258			.3086
22	.2743	.2743	.2743	.2572		.3086	.2915
23	.3258	.3086	.1715	.2572		.2401	.2572
24	.4458	.2743	.2058	.2229		.2572	.2572
Max	1.0288	1.0631	.9259	.8745	.7888	.9088	.8916
Min	.0686	.0686	.0514	.0223	.6859	.2401	.0514
Avg	.4066	.3837	.3422	.4132	.7202	.5470	.3415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184249 / 33/ 11 KV Talegaon (Dindori)

Feeder No / Name : 201 / Express

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	.823	1.1317	.823	1.0288	.9259	.8573
2	.8745	.7202	.7716	.7716	1.0288		.823
3	.9259	.9259	.7716	.8745	1.0802		.8745
4	.823	.823	.823	.823	.9259		.9259
5	.7716	.823	.7716	.8573	.9774		.9774
6	.7202	.7888	.823	.9259	1.0288		.823
7	.7373	.7202	.8745	.9774	1.0802		.8573
8	.7716	.7202	.9259	.9259	.8745		.9259
9	.7202	1.0288	1.0288	1.1317	1.1317		1.1488
10	.6687	1.2346	1.2003	1.3889		1.4403	1.3717
11	.7202	1.5432	1.2346	1.6461		1.4918	1.4861
12	.7202	1.5432	1.4918	1.6461		1.2346	1.2574
13	.6859	1.286	1.5432	1.4918	1.3889	1.4403	1.1431
14	.7202	1.3889	1.6461	1.3889	1.5432	1.4918	1.3717
15	.7202	1.4403	1.5432	1.4403		1.5432	1.4861
16	.7888	1.4403	1.2346	1.4403	1.3375	1.4403	1.6004
17	.7888		1.5775	1.5947	1.5432	1.5432	1.7147
18	.7202	1.2346	1.4403	1.5432		1.4918	1.4861
19	.823	1.1317	1.3717	1.2346		1.2346	1.3717
20	.7888	1.1317	1.2003	1.0288		1.0802	1.2574
21	.7888	.9259	.9259	1.0802		1.0288	1.1431
22	.823	.9259	.823	1.0288		.9259	1.1431
23	.6173	.9774	.8573	1.0288		.8745	1.0288
24	.823	1.3889	.9259	.823	1.0802		.823
Max	.9774	1.5432	1.6461	1.6461	1.5432	1.5432	1.7147
Min	.6173	.7202	.7716	.7716	.8745	.8745	.823
Avg	.7716	1.0855	1.1224	1.1631	1.1464	1.2791	1.1624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184249 / 33/ 11 KV Talegaon (Dindori)

Feeder No / Name : 202 / Dhakambe 1 SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.406	.583	.583	.5144	.5144	.5144
2	1.3717	1.4746	.583	.583	.5144		.5144
3	1.5432	1.5089	.6173	.583	.4801		.5487
4	1.6118	1.5432	.6859	.583	.5144		.583
5	1.6461	1.5775	.6859	.583	.5487		.583
6	.1749	1.6461	.7202	.583	.6173		.6173
7	1.8347	1.749	.6516	.5487	.6173		.7202
8	1.989	2.0576	.6859	.5487	.5144		.9945
9	.3429	.2743	.6173	.5144	.4801		.2401
10	.3429	.2743	.583	.4115		.2058	.3048
11	.2743	.2401	.7202	.8573		.2058	.3048
12	.3429	.1372	1.9204	1.3889		.3086	.3429
13	.3772	.3772	1.8519	1.3717	1.1317	.3086	.3048
14	.3772	.4287	1.8519	1.3375	1.0974	.3086	.2667
15	.3429	.4115	1.6804	1.286		.3086	.2667
16	.3772	.4458	1.749	1.3375	.9088	.3429	.3048
17	.3772		1.8861	1.3889	1.2689	.3429	.3048
18	.4458	.583	1.9204	1.3203		.4115	.381
19	.5144	.6859	.4115	.3258		.4801	.4191
20	.6173	.6859	.5487	.583		.5144	.6097
21	.6173	.6859	.583	.6001		.5144	.6097
22	.583	.6859	.583	.583		.4115	.5716
23	.6859	.8573	.583	.583			.5335
24	1.3717	.5144	.3944	.583	.5487		.4458
Max	1.989	2.0576	1.9204	1.3889	1.2689	.5144	.9945
Min	.1749	.1372	.3944	.3258	.4801	.2058	.2401
Avg	.8175	.8804	.9624	.7945	.6969	.3699	.4703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184249 / 33/ 11 KV Talegaon (Dindori)

Feeder No / Name : 203 / Akrale SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.749	.4801	.5144	.4801	1.3717	1.2689
2	1.6118	1.7833	.4801	.5144	.4801		1.2689
3	1.8861	1.8176	.4801	.5144	.463		1.3375
4	1.9719	1.8861	.5144	.5144	.463		1.3717
5	2.0576	1.9204	.5487	.5144	.5144		1.4746
6	2.2634	1.9547	.5144	.4801	.5487		1.6461
7	2.452	2.2291	.4115	.4801	.4115		2.0576
8	2.6578	2.4691	.3429	.4801	.3429		2.3663
9	.4287	.3429	.3429	.4458	.3086		.2058
10	.3772	.3772	.2743	.3429		.2058	.3429
11	.3429	.4115	.7545	1.2689		.2401	.4191
12	.3086	.2743		2.1091		.1372	.4572
13	.3772	.2058		2.2634	1.9204	.1372	.4572
14	.4115	.2572	2.2634	2.3148	2.0576	.1372	.4191
15	.4115	.2572	2.2291	2.4006		.1372	.4572
16	.4115	.3086	2.1262	2.452	2.1091	.1372	.4191
17	.3772	.3429	2.1605	2.4177	2.3663	.2058	.4572
18	.4458	.4115	2.2291	2.3663		.2401	.4954
19	.4801	.5144	.3772	.4115		.4115	.5335
20	.5487	.5487	.5144	.5144		.4801	.6478
21	.583	.583	.5487	.5487		.4801	.6097
22	.5487	.583	.5487	.5487		.4801	.5716
23	.6859	1.0288	.5487	.5144		1.0631	.7621
24	1.7147	.3429	.5144	.5487	.5144		1.2003
Max	2.6578	2.4691	2.2634	2.452	2.3663	1.3717	2.3663
Min	.3086	.2058	.2743	.3429	.3086	.1372	.2058
Avg	1.0417	.9416	.8729	1.0617	.9272	.3910	.8853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184249 / 33/ 11 KV Talegaon (Dindori)

Feeder No / Name : 204 / Dhakambe 2 SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6516	.8916	.8916	1.0288	.6859	.5487
2	.6859	.6516		.9602	1.0288		.5487
3	.7202	.6859		.9602	1.0631		.5487
4	.7373	.7202		1.0288	1.0974		.5487
5	.7716	.6859	.9088	1.166	1.0974		.5144
6	.823	.6516	1.0288	1.3375	1.2003		.5144
7	.6859	.583	1.5089	1.5432	1.6804		.5144
8	.4801	.4458	1.7147	1.8519	1.6975		.4801
9	.4287	.3429	.3772	.4115	.3429		.3772
10	.3429	.2743	.3429	.3429		.2743	.3429
11	.5144	.4458	.3429	.3086		1.5775	.5335
12	1.2346	1.166	.3429	.2743			1.2574
13	1.1317	1.3032	.3429	.2572	.3086	1.5432	1.3336
14	1.0974	1.2517	.3429	.2572	.2915	1.4746	.5716
15	1.1317	1.2346	.3429	.2743		1.3717	1.1431
16	1.3375	1.2346	.4115	.2743	.2743	1.406	1.2955
17	1.3717	1.6289	.4115	.3429	.3086	1.4746	1.448
18	1.3717	1.6975	.5144	.3429		1.5775	1.5242
19	.3772	.4801	.5487	.5144		.4115	.4191
20	.7202	.6516	.583	.6516		.5487	.724
21	.6859	.6516	.583	.6516		.5487	.8002
22	.6173	.6687	.583	.6173		.5487	.7621
23	.6516	.6344	.6859	.7545		.5487	.724
24	.6859		.8916	.7202	.9945		.5487
Max	1.3717	1.6975	1.7147	1.8519	1.6975	1.5775	1.5242
Min	.3429	.2743	.3429	.2572	.2743	.2743	.3429
Avg	.8038	.8148	.6524	.6973	.8867	.9994	.7510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184249 / 33/ 11 KV Talegaon (Dindori)

Feeder No / Name : 205 / BORGAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.3086	.6859	.5487	1.0974	.8573	.8573
2	.6001	.2743	.4115	.5487	1.0288		.8916
3	.5144	.2743	.3772	.5144	1.2003		.9602
4	.4458	.2401	.4458	.583	1.2346		.9259
5	.4801	.2743	.4115	.6173	1.166		.9259
6	.5144	.2743	.4115	.6516	1.2689		.8916
7	.4801	.2401	.4458	.6859	1.7833		1.0631
8	.4287	.583	1.0974	.823	1.0974		1.2346
9	.9088	.7545	1.4746	.8916	2.0233		1.5432
10	.4115	1.1317	1.3717	1.0631		2.0576	1.7909
11	.2743	.9259	1.2346	1.406		2.2462	1.9052
12	.2401	.7888	1.3717	1.6461		1.749	1.7528
13	.2743	.9259	1.406	1.749	1.5432	1.6118	1.6385
14	.3086	1.2346	1.3717	1.749	1.6461	1.7147	1.5623
15	.2401	1.2003	1.4746	1.3717		1.4403	1.5242
16	.3086	1.0631	1.3717	1.5775	1.7147	1.5432	1.7528
17	.2401	1.166	1.5432	2.1948	1.7661	1.5775	1.7147
18	.2401	1.1317	1.3717	2.1262		1.6118	1.9052
19	.2743	1.0288	1.1317	1.3032		1.2346	2.0957
20	.2401	.583	.8916	1.2003		1.2003	1.7147
21	.2058	.4458	.6859	1.2689		.9602	1.5242
22	.2058	.4801	.7202	1.166		.8916	1.6004
23	.2401	.5144	.5144	1.2346		.8573	1.5623
24	.3086		.7545	.6516	1.2003		.823
Max	.9088	1.2346	1.5432	2.1948	2.0233	2.2462	2.0957
Min	.2058	.2401	.3772	.5144	1.0288	.8573	.823
Avg	.3765	.6889	.9574	1.1488	1.4122	1.4369	1.4233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184250 / 33/ 11 KV Koshimbe

Feeder No / Name : 202 / DEOSANE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7202	.7716	1.5432	1.5432	1.5775	.583
2	.6859	.7545	.7888	1.5775	1.6461	1.749	.6001
3	.7373	.823		1.6118	1.6632	1.8176	.6344
4	.7888	.8573	.823	1.6289	1.6804	1.9204	.6859
5	.823	.8916	.8402	1.6632	1.7147	1.989	.7888
6	.9431	.9431	1.0631	1.7661	2.0576	2.1605	.9431
7	1.406	1.3717	1.4232	2.1605	2.3491	2.1948	1.2689
8	1.4575	1.4918	1.4403	2.452	2.5377	2.2462	1.3546
9	.2743	.3258	.2743	.2401	.2401	.2401	.2915
10	.2401	.2229	.2401		.2229	.2058	.2743
11	1.406	1.4918	1.2003	.6173	.5658	.3944	1.4918
12	2.4177	2.1605	2.0919	1.1488	1.0802	1.1488	2.5206
13	2.2977	2.2634	2.1605	1.1145	1.2003	1.0974	2.1605
14	2.2805	2.4348	2.2462	1.2517	1.2517	1.0288	2.692
15	2.1948	2.4691	2.1605	1.1488		.9431	2.6749
16	2.452	2.572	2.3148	1.2003	1.5604		2.7435
17	2.5034	2.4863	2.4691	1.2517	1.3375	1.046	2.6063
18	2.5377	2.3148	2.4006	1.2346	1.3375	1.0631	2.572
19	.463	.4287	.3772	.3944	.4115	.3429	.4801
20	.6001	.6001		.5316	.6516	.5658	.6173
21	.583	.6173	.6344	.583	.583		.5658
22	.5658	.6001		.4973	.5658	.6001	.5144
23	.6859	.3772		1.1488	1.1488	.9431	.4458
24	.2743	.6859	.7716		1.6289	.1578	1.0288
Max	2.5377	2.572	2.4691	2.452	2.5377	2.2462	2.7435
Min	.2401	.2229	.2401	.2401	.2229	.1578	.2743
Avg	1.2196	1.2460	1.3246	1.2166	1.2599	1.1560	1.2724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184250 / 33/ 11 KV Koshimbe

Feeder No / Name : 204 / KOKANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-APR-17
HR	Load (MW)
20	.0686
Max	.0686
Min	.0686
Avg	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184250 / 33/ 11 KV Koshimbe

Feeder No / Name : 205 / PURKAR AGRO

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5						.0343	.0514
6		.0343	.0514	.0343			.0514
7			.0686				.0514
8	.0686	.0343	.0686	.0343	.0686		.0514
9	.0686	.0857	.0686	.0514	.0857		.0857
10	.0686	.0686	.0686			.0686	.1029
11	.0343	.0857	.0857	.0857		.0686	.12
12		.0514	.0343	.0514		.0686	.0514
13		.0514	.0857	.0686	.0686	.0857	.0686
14	.0686	.0514	.0686	.0514	.0686	.0686	
15	.0343	.0686	.1029	.0857		.0514	.0857
16	.0514	.0686	.0857	.0686	.0686	.0514	.1029
17	.0343	.0343	.0686	.0514		.0514	.0857
18						.0686	.0514
19	.0343	.0343	.0514			.0514	
20	.0343		.0514	.0686		.0514	.0686
21	.0343	.0514	.0343	.0514			.0686
22						.0514	.0686
23			.0343			.0514	.0686
24							.0514
Max	.0686	.0857	.1029	.0857	.0857	.0857	.12
Min	.0343	.0343	.0343	.0343	.0686	.0343	.0514
Avg	.0483	.0554	.0643	.0586	.0720	.0588	.0714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184250 / 33/ 11 KV Koshimbe

Feeder No / Name : 206 / KARANJWAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.406	1.5775	2.0919	2.0576	1.8861	1.2517
2	1.7147	1.4403	1.5432	2.1434	2.1605	1.9547	1.286
3	1.7147	1.4403	1.5432	2.1605	2.2291	2.0233	1.3203
4	1.749	1.4746	.156	2.1948	2.332	2.1091	1.3375
5	1.7661	1.5432	1.5947	2.3148	2.3834	2.1776	1.406
6	1.8176	1.8004	1.8861	2.5549	2.572	2.1948	1.5261
7	2.0576	1.8861	2.0576	3.0693	2.7949	2.5377	1.8004
8	2.2291	1.8861	1.989	3.1722	3.155	2.5206	1.8347
9	.1543	.12	.1543	.2058	.1372	.1715	.1372
10	.1372	.1543	.12		.1886	.1372	.1886
11	1.8004	1.9376	1.4403	1.3717	1.3375	1.286	2.1262
12	2.5377	2.6749	3.2922	2.0919	1.9033	2.3834	2.7092
13	2.1948	2.7435	3.0007	1.8861	1.869	2.1434	2.6578
14	2.1948	2.7263	2.9492	1.8861	1.8861	2.0576	2.692
15	2.2805	2.692	.3241	1.7661			2.5206
16	2.4006	2.6063	3.1722	1.7147	1.8176		2.6578
17	2.332	2.7435	2.8807	1.6289	1.6975	2.1434	2.4006
18	2.332	2.6235	2.7778	1.4918	1.7147	1.9719	2.572
19	.2401	.2572	.3086	.2401	.2058	.2572	.2572
20	.3772	.4115	.4801	.4287	.0394	.4287	.3772
21	.4115	.4287	.4801	.4287	.4287		.3601
22	.3601	.4115	.4458	.3086	.4115	.4973	.3601
23	1.286	1.3032	.6859	1.8519	1.4746	1.3717	.8573
24	1.6289	2.7435	1.6461	.072	1.9547	1.8519	1.6289
Max	2.5377	2.7435	3.2922	3.1722	3.155	2.5377	2.7092
Min	.1372	.12	.12	.072	.0394	.1372	.1372
Avg	1.5582	1.6439	1.5211	1.6120	1.5979	1.6241	1.5111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184251 / 33/ 11 KV Pimpri anchala

Feeder No / Name : 201 / 11 KV MALE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4908	3.0864	3.6008			.4458
2	.4287	.4801	3.0864	3.6351			.4458
3	.4287	.4115	3.0864	3.6694			.463
4	.4287	.4191	3.0864	3.6626			.4694
5	.4858	.426	2.8292	3.6965			.4862
6		.4588	2.834	3.6286			.4915
7		.2915	3.6008	3.1786	3.5879		.3353
8		.208	3.6008	3.5376			.2401
9	.1646	.1886	.1509	.1867			.1886
10	.1448	.168	.1509	.1509		.1509	.1509
11	2.1948	1.3756	.1132	.1463		.1372	3.1121
12	3.858	3.4294	.1372	.1341	.1463	.1677	3.6866
13	3.3065	3.858	.1372	.1341		.1677	2.8509
14	3.4294	3.6866	.1475	.1326		.1638	3.3979
15	3.4465	3.6008	.1475	.1311		.1638	3.4873
16	3.6008	3.1579	.1311	.1296			3.5376
17	3.7304	3.0864	.1372	.1457		.1943	3.504
18	3.6008	3.2388	.1698	.1677		.1943	3.2861
19	.2926	.2801	.3206	.3772		.3772	.3018
20	.5853	.5041	.4904	.5093		.5415	.5093
21	.567	.5601	.5281	.5281			.5658
22	.5121	.5601	.5093	.5121		.5415	.547
23	.5068	1.086	2.8858	2.7149		.4801	.5281
24	.4287	.4344	3.0864	3.6008	3.0864		.4359
Max	3.858	3.858	3.6008	3.6965	3.5879	.5415	3.6866
Min	.1448	.168	.1132	.1296	.1463	.1372	.1509
Avg	1.5509	1.3500	1.4356	1.5963	2.2735	.2733	1.3945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 201 / nanduri ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.5335	1.56	2.0195	1.7194		.4572
2	.724	.5335	1.56	2.0957	1.8099		.4572
3	.743	.5335	1.543	2.2481	1.9909		.4382
4	.724	.5144	1.5261	2.3815	2.1719		.4382
5	.7049	.5144	1.5261	2.4768	2.3529		.4382
6	.7811	.5144	1.7604	2.5149	2.4615		.4382
7			1.9498	2.5339	2.8416		
8			2.2996	2.9531	2.7511		.4954
9	.5144		2.0222	1.8138			.5525
10	.5716	.6478		.362			.4954
11	.5144	.4954	.381				.5144
12	2.8387	2.3805		.5144	.4954		2.4129
13	2.6673	2.3805		.4382		2.7149	2.251
14	2.5339	2.1862		.4382		2.6787	2.2834
15	2.191	2.1862		.4382		2.6968	2.1214
16	2.553	2.2186		.4191			2.4777
17	2.251	1.917		.4001			2.0243
18		2.1862		.5525			2.2834
19	2.371	1.8351		.7621		2.5339	1.7404
20	.4954	.7621	.5906	.6668		.4382	.4572
21	.4763	.6859	.5716	.6668			.5335
22	.5335	.724		.5716		.4572	.5716
23	.5906	.7049		.5335		.4763	.5906
24	.7621	.5716	1.6244	1.9814	1.6289		.4763
Max	2.8387	2.3805	2.2996	2.9531	2.8416	2.7149	2.4777
Min	.4763	.4954	.381	.362	.4954	.4382	.4382
Avg	1.2507	1.1917	1.4550	1.2949	2.0224	1.7137	1.0847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 202 / MAUDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8347	1.5384	.5906	.7811	.8764		.5716
2	1.8652	1.6289	.6097	.7811	.8764		.5716
3	1.8991	1.7194	.6287	.8002	.8764		.5716
4	2.6282	1.8099	.6287	.8192	.8764		.5906
5	1.9669	1.9004	.6668	.8573	.8764		.6097
6	2.1534	2.0271	.5906	.8764	.8764		.5716
7	2.5263	2.1176	.4572	.6668			.6287
8	2.4129	2.4434	.3429	.5525			.7621
9	2.7054	1.8947	.362	.381			1.6956
10	.362	.3239	.3429	.2858			1.4413
11		.3239	.2667	.2477			1.4582
12		.3239	1.7804	1.7004	2.2986		
13		.4572	1.7238	1.7004	2.0243		
14		.4572	1.8652	1.9595			
15		.4191	1.8896	1.7976			.1905
16		.4191	2.0081	2.0243			.3429
17		.4763	2.4387	2.4434			
18	.1524	.5525	2.572	2.3529			.381
19	.3429	.724	2.1529	2.1357		.381	.5906
20	.8145	.6478	.743	.6668		.6668	.6668
21	.8573	.6859	.8192	.724			.6478
22	.7621	.7811		.8002		.5716	.6478
23	.724	.7049		.9145		.5525	.6287
24	1.8519	1.448	.724	.7811	.8954		.5716
Max	2.7054	2.4434	2.572	2.4434	2.2986	.6668	1.6956
Min	.1524	.3239	.2667	.2477	.8764	.381	.1905
Avg	1.5211	1.0760	1.1002	1.1271	1.1641	.5430	.7070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 203 / TISGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4763	1.0343	1.5242	.9955		.4382
2	.5335	.4763	1.0343	1.4289	1.105		.4382
3	.5335	.4954	1.0513	1.3908	1.086		.4191
4	.5144	.4954	1.0513	1.3908	1.1622		.4191
5	.5144	.5144	1.0562	1.4289	1.1403		.4001
6	.4191	.5144	1.0059	1.3908	1.2384		.381
7			1.1437	1.467	1.5242		
8			1.2631	1.6575	1.6289		.1905
9	.1715		1.2717	1.3603			.1524
10	.1715	.1905	.1334	.1715			.1334
11	.1334	.1334	.1143	.1715			.1334
12	1.6575	1.5043		.1524	.1143		1.56
13	1.5242	1.4899		.1524		1.8461	1.5581
14	1.4289	1.4737		.1334		1.8099	1.3757
15	1.4289	1.3279		.1334		1.8099	1.3599
16	1.5623	1.4089		.1334			1.7126
17		1.4575		.1334		.6478	1.5083
18	1.3757	1.3117		.1334		1.4118	
19	1.5565	1.0814	.1905	.1334		1.267	1.3056
20	.362	.381	.4001	.2858		.4001	.381
21	.381	.4001	.4382	.381			.4191
22	.4191	.4382		.4191		.4382	.4763
23	.4954	.4382		.4572		.4572	.5144
24	.4572	.4763	.9556	1.6004	.905		.4572
Max	1.6575	1.5043	1.2717	1.6575	1.6289	1.8461	1.7126
Min	.1334	.1334	.1143	.1334	.1143	.4001	.1334
Avg	.7702	.7850	.8096	.7346	1.0900	1.1209	.7152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 204 / PANDANE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1195	1.9909	.6287	.381	.5716		1.949
2	2.1534	2.1719	.6478	.4763	.5716		2.1262
3	2.1534	2.3529	.6668	.5716	.5716		2.3034
4	2.1382	2.5339	.7049	.6287	.5716		2.6673
5	2.1548	2.7149	.743	.6287	.5906		2.6578
6	2.5069	2.8959	.6097	.6287	.5906		2.8959
7	2.8664	3.0769	.4954	.6287			3.1131
8	2.7692	3.2941	.4001	.2286			2.914
9	3.1055	2.8578		.2858			2.1538
10	.2096	.2858		.2096			.2667
11	.1905	.2667	.1524				.2477
12		.2667	2.5911		2.7206		
13		.2667	2.9635	3.2198	2.7854		
14		.2858	2.9959	2.9912			
15		.2858	2.8178	3.2388			.2286
16		.2667	2.915	3.2769			.2858
17		.2667	3.4675	2.6606			
18		.3429	3.4103	2.5339			.381
19	.4191	.5144	1.7718	2.5158		.4763	.4763
20	.7049	.6287	.4382	.5716		.6478	.6287
21	.7049	.6668	.4572	.6097			.6478
22	.6668	.7049		.5716		.6097	.5335
23	.4954	.6668		.5525		.5906	.5335
24	2.1091	1.8099	.6287	.362	.5716		1.7718
Max	3.1055	3.2941	3.4675	3.2769	2.7854	.6478	3.1131
Min	.1905	.2667	.1524	.2096	.5716	.4763	.2286
Avg	1.6157	1.3089	1.4753	1.2624	1.0606	.5811	1.4391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 205 / 11 KV CHANDIKAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.6668	1.6617	1.8671	1.9909		.6668
2	.6668	.6478	1.6617	1.8861	2.1719		.6668
3	.6668	.6478	1.6787	2.0195	2.3529		.6478
4	.6668	.5716	1.7295	2.191	2.5339		.6287
5	.6668	.5716	.4763	2.4768	2.6244		.6287
6	.6287	.5335	.6287	2.7244	2.6787		.6097
7		.5335		3.7151	3.3122		.4191
8		.4191		3.1626	3.4027		.4001
9	.3048	.2477		2.6397			.3429
10	.1905	.2286		.1905			.2667
11	.1905	.1905	1.7295				.1905
12	3.0102	2.5911		.2096	.1905		2.5587
13	2.8578	2.3805		.2096		2.9864	1.9919
14	2.6673	2.4129	.0191	.2096		2.9683	2.0405
15	2.5911	2.2672		.2096		2.9683	2.2186
16	2.915	2.3482		.2096			2.5425
17	2.5263	2.7044				2.9321	2.672
18	2.6235	2.5425		.381		3.0226	2.3644
19	1.9547	1.917	.2858	.4382		2.3529	2.1538
20	.7049	.6287	.7049	.5716		.6668	.6859
21	.7049	.6478	.743	.7049			.6668
22	.7049	.6478		.6668		.6859	.6859
23	.7049	.6287		.6478		.724	.6859
24	.6097	.6668	1.5927	1.829	1.8099		.6668
Max	3.0102	2.7044	1.7295	3.7151	3.4027	3.0226	2.672
Min	.1905	.1905	.0191	.1905	.1905	.6668	.1905
Avg	1.3284	1.1518	1.0760	1.3255	2.3068	2.1453	1.1417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 206 / Vani U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	1.0479	.9877	1.105	1.0498		1.0631
2	.9877	1.0479	.9877	1.0669	1.105		1.1431
3	.9955	1.1431	1.0242	1.105	1.1431		1.2384
4	1.0242	1.2384	1.0608	1.1431	1.1622		1.3466
5	1.0317	1.2955	1.0974	1.2384	1.2003		1.258
6	1.1765	1.3717	1.2489	1.2955	1.2384		1.3756
7	1.2851	1.4098	1.3032	1.2193	1.2489		1.3756
8	1.1584	1.4861	1.262	1.3336	1.1041		1.3032
9	1.1431	1.2071	1.1403	.823			1.2803
10	1.1431	1.1888	1.1403	1.0974			1.1888
11	1.086	1.134	1.0608	1.0608			1.2127
12	1.0288	.9877	1.0498	1.1888	1.1765		1.1041
13	.9907	1.0791	1.0136	1.1706	1.1403	1.0631	1.1523
14	.9526	1.0059	1.0679	1.134		1.0808	1.1041
15	.9907	1.0425	1.1403	1.1523		1.0808	1.1403
16	1.0288	1.1523	1.1403	1.1706			1.1041
17	1.0498	1.1706	1.2384	1.2127		1.1517	1.1041
18	1.1041	1.2071	1.2574	1.3336		1.2403	1.2071
19	1.3146	1.3535	1.3527	1.3908		1.4175	1.2437
20	1.448	1.3756	1.4861	1.4098		1.3289	1.3575
21	1.0669	1.262	1.3336				1.2851
22	1.3336	1.2986		1.3146		1.267	1.267
23	1.2765	1.2071		1.3146		1.2851	1.262
24	1.0242	1.1431	1.0791	1.105	1.1431		1.1517
Max	1.448	1.4861	1.4861	1.4098	1.2489	1.4175	1.3756
Min	.9526	.9877	.9877	.823	1.0498	1.0631	1.0631
Avg	1.1095	1.2023	1.1578	1.1907	1.1556	1.2128	1.2195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 207 / Ozarkhed

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2477	.961	1.1431	.8688		.2477
2	.2667	.2477	.961	1.1431	.9526		.2477
3	.2667	.2477	.9795	1.1431	1.0479		.2477
4	.2667	.2477	.9795	1.1812	1.105		.2286
5	.2667	.2477	.9979	1.1812	1.1812		.2477
6	.2477	.2477	1.0425	1.1812	1.1765		.2286
7	.2477	.2286	1.1523		1.448		.2286
8	.2477	.2286	1.2803	.381	1.4289		.2286
9	.4763	.2477	1.0974	1.2437			.2477
10	.4191	.2667	.2477	.2667			.2477
11	.381	.2477	.2477	.2477			.2286
12	1.3527	1.1946	.2286	.2477	.0381		.5144
13	1.3336	1.3032	.2286	.2477	.0381	1.448	
14	1.2384	1.3937	.2286	.2477		1.3575	.2801
15	1.3717	1.3756	.2286	.2477		1.3394	.4024
16	1.467	1.448	.2286	.2477			.543
17	1.0974	1.3394	.2286	.2477			
18	1.1488	1.1523	.2286	.2477			.9774
19	.9526	.9511	.2286	.2477		.4763	.7716
20	.2667	.2667	.2858	.2477		.2667	.6859
21	.2667	.2858	.2858	.2667			.6516
22	.2858	.2858		.2667		.2667	.2667
23	.2667	.2667		.2667		.2667	.2667
24	.2286	.2667	.9335	1.1622	.8573		.2667
Max	1.467	1.448	1.2803	1.2437	1.448	1.448	.9774
Min	.2286	.2286	.2286	.2477	.0381	.2667	.2286
Avg	.6096	.5931	.6037	.5784	.9220	.7745	.3753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 208 / MJP Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.8208	.828	.8489	.7941	.4374	.8261
2	.7788	.8215	.8415	.8504	.8139	.4359	.8421
3	.817	.8413	.8369	.8833	.81	.4351	.8429
4	.8909	.852	.8962	.9457	.8634	.4862	.932
5	.9039	.9153	.9356	.9533	.8718	.4915	.9069
6	.9533	.9267	.9697	.9404	.8847	.503	.9564
7	.9244	.9145	.9394	.5411	.9107	.471	.9556
8	.9396	.9115	.9191	.9587	.551	.285	.9091
9	.4748	.8918	.8734	.9359	.3544	.455	.7171
10	.4321	.8667	.8299	.6169	.4351	.4382	.8642
11	.4298	.9023	.8703	.9234	.4565	.4534	.8688
12	.6844	.7522	.9251	.9328	.9833	.4801	.5465
13	.7895	.515	.9062	.9071	.9808	.9556	.6409
14	.8253	.4914	.9373	.8242	.4374	.9031	.8452
15	.7758	.8629	.9046	.8491	.4466	.887	.7804
16	.7521	.9577	.7788	.8758	.3803	.4412	.8398
17	.7064	.841	.6332	.9526	.4557	.5228	.8086
18	.4748	.8296	.8009	.916	.4481	.5594	.7865
19	.4725	.7826	.8391	.5213	.4374	.778	.7651
20	.4542	.7802	.4908	.4778	.3856	.7209	.7337
21	.6957	.6211	.3879	.5114	.3826	.3757	.458
22	.7438	.7613	.4009	.6226	.3826	.743	.4424
23	.4039	.8017	.4031	.7537	.4153	.7788	.5776
24	.8177	.7537	.8364	.7933	.8169	.4085	.8603
Max	.9533	.9577	.9697	.9587	.9833	.9556	.9564
Min	.4039	.4914	.3879	.4778	.3544	.285	.4424
Avg	.7051	.8090	.7910	.8057	.6124	.5602	.7794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 209 / Saguna

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.381	.4191	.4191	.3429		.381
2	.3292	.381	.4191	.4191	.3429		.381
3	.3292	.381	.4001	.4191	.3429		.4001
4	.3292	.381	.4001	.4001	.362		.4001
5	.3258	.4001	.4001	.4191	.362		.4191
6	.3841	.4191	.381	.4191	.3239		.4001
7	.3475	.4191	.4338	.381	.381		.4001
8	.3658	.381	.415	.3239	.4001		.4001
9	.381	.4904	.4207	.4715			.5304
10	.4191	.4715	.4024	.362			.4572
11	.4763	.4715	.439	.4382			.4572
12	.4382	.3961	.5121	.3239	.4706		.5121
13		.4904	.4572	.4715	.4887	.4954	.4755
14	.4763	.5281	.4572	.4715			.4755
15	.4572	.4715	.4572	.4715		.4763	.4755
16	.4191	.4904	.4024	.4527			.4755
17	.4024	.4338	.4191	.4763		.4763	.4572
18	.3841	.4715	.4191	.4572		.4191	.4572
19	.4763	.415	.4382	.4191		.381	.3658
20	.4001	.415	.381	.381		.381	.3475
21	.381	.4001	.3429	.3429			.3475
22	.381	.381		.362		.381	.3475
23	.362	.4001		.362		.362	.3292
24	.3439	.381	.4191	.4191	.362		.362
Max	.4763	.5281	.5121	.4763	.4887	.4954	.5304
Min	.3258	.381	.3429	.3239	.3239	.362	.3292
Avg	.3886	.4271	.4198	.4118	.3799	.4215	.4189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 210 / Sangamner

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0479	.6287	.5716	.6859		1.0479
2	1.0631	1.1431	.6287	.5716	.7049		1.1431
3	1.0631	1.2384	.6478	.6097	.724		1.2384
4	1.1145	1.3336	.6478	.6097	.743		1.6832
5	1.1145	1.3717	.6668	.6478	.7621		1.3289
6	1.0974	1.4098	.6287	.6859	.7621		1.7194
7	1.3904	1.4289	.4572	.4572			1.7194
8	1.3226	1.6766	.381	.4001			1.5927
9	1.3717	1.3717	.3239	.381			1.286
10	.3048	.2667	.2667	.1905			.2667
11	.3239	.3048	.2477	.2477			.3239
12		.2858	1.2003	1.3203	1.3923		
13		.3429	1.2174	1.2656	1.3032		
14		.3239	1.2209	1.2136			
15		.362	1.2346	1.2136			.1715
16		.4001	1.3226	1.2689			.3429
17		.4191	1.5242	1.2127			
18	.2286	.4572	1.5813	1.3575			.2667
19	.6478	.5716	1.5242	1.5242		.381	.4191
20	.6668	.5716	.4763	.5716		.3239	.5335
21	.6478	.6097	.6097	.6097			.5716
22	.6097	.5716		.6287		.3239	.5716
23	.5716	.6287		.6668		.3239	.5525
24	.9774	.9526	.6097	.5335	.6668		.9526
Max	1.3904	1.6766	1.5813	1.5242	1.3923	.381	1.7194
Min	.2286	.2667	.2477	.1905	.6668	.3239	.1715
Avg	.8636	.7954	.8203	.7816	.8605	.3382	.8866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

DINDORI (R) SUBDN[270] BU 5410

Substation No/ Name :- 184252 / 33/11 KV Vani

Feeder No / Name : 211 / TALEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.787	2.0119	1.0365	.823	.823	.8459	1.7909
2	1.787	2.0691	1.1203	.823	.8269	.8612	1.7699
3	1.8366	2.2215	1.1813	.9107	.8382	.884	1.8509
4	1.949	2.2653	1.2155	.9831	.8535	.9145	.884
5	2.0862	2.3863	1.2765	1.0289	.8802	1.044	2.0359
6	2.3033	2.6006	1.1926	1.0289	.9107	1.0974	2.2587
7	2.9747	2.9798	.8687	.8954	.0457	1.3565	2.7492
8	3.1043	3.0749	.7354	.7468		1.3946	2.936
9	2.6711	2.5987	.7392	.6516	.0381	1.2117	2.572
10	.362	.6059	.5944	.602	.221	.1981	.3963
11	.3963	.5106	.884	.5334	.6478	.2591	.5868
12	.2286	.4763	2.8978	2.411	2.8972	.2286	.0686
13		.5373	2.8408	2.5721	2.8552		
14		.5106	2.821	2.4806	1.4022		
15		.5373	2.6095	2.4149	1.3946		.3353
16		.5982	2.7726	2.2233	1.3489		.5639
17		.6554	3.0179	2.5092	1.3413		.2667
18	.2401	.5678	2.8426	2.4416	1.3032		.5525
19	.9945	.7202	2.5035	2.2444	1.1584	.762	.7087
20	1.0746	.8154	.7888	.522	.3887	1.0783	.762
21	.9488	.8459	.823	.6364	.3887	.4954	.7735
22	.9488	.9526	.442	.7316	.4115	1.0212	.8269
23	.9564	.9335	.4572	.7888	.4039	.9336	.9336
24	1.7052	1.3318	.8993	.8001	1.2117	.8764	1.7718
Max	3.1043	3.0749	3.0179	2.5721	2.8972	1.3946	2.936
Min	.2286	.4763	.442	.522	.0381	.1981	.0686
Avg	1.4923	1.3670	1.5234	1.3251	.9822	.8590	1.2452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184017 / WADIVARE

Feeder No / Name : 201 / SHALIMAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2637	.7762		1.358	1.3847	1.2346
2	1.3014	.7842		1.2637	1.3672	1.2003
3	1.2826	.7577		1.2071	1.3146	1.1317
4	1.1883	.7577		1.1128	1.2795	1.0631
5	1.094	.7392		1.1506	1.2269	1.0288
6	.8299	.7392		1.094	1.1393	.9431
7	.8299	.7392		.9808	1.0341	.8402
8	.7922	.9492		1.4712	1.2309	1.0631
9	.724		1.3203	1.3889		1.1517
10	.9145		2.0182	1.7147		1.286
11	.9991		2.1691	1.7147		1.56
12	.8682		1.6787	1.6289		1.5089
13	.815		1.5466	1.8004		1.3146
14	.7973		1.9427	1.8861		1.5432
15	.9511		2.1125	1.8861		1.8519
16	.985		2.2257	1.869		1.5775
17	.9745		1.9805	1.6461		1.2445
18	.4108		1.5089	1.4575		1.1517
19	.4294		1.3014	1.286		1.0631
20	.7602		1.3203	1.3496		1.0277
21	.8048		1.3769	1.3496		1.1218
22	.7865		1.094	1.382		1.1043
23	.7964		1.3392	1.3672		1.0808
24	1.3203	.8029		1.4335	1.4022	1.286
Max	1.3203	.9492	2.2257	1.8861	1.4022	1.8519
Min	.4108	.7392	1.094	.9808	1.0341	.8402
Avg	.9133	.7828	1.6623	1.4499	1.2644	1.2241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184017 / WADIVARE

Feeder No / Name : 202 / ASVALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2772		.3395	.2957		.1372
2	.2263	.2957		.2829	.3142		.1372
3	.1886	.3142		.2641	.3326		.1543
4	.2263	.3326		.2829	.3696		.1715
5	.2641	.3696		.3584	.4207		.2572
6	.3395	.3881		.547	.4525		.3258
7	.3772	.4066		.6413	.5068		.3944
8	.4527	.4344		.415	.3801		.5144
9	.2614		.3018	.3326			.5959
10	.2427		.2263	.2772			.4435
11	.2054		.2075	.2218			.2614
12	.2054		.2263	.197			.2614
13	.1867		.1886	.2427			.2614
14	.1867		.2075	.1991		.2058	.1478
15	.2054		.1509	.2033		.2229	.1494
16	.2054		.2075	.1848			.2427
17	.2054		.1698	.2772			.3174
18	.2987		.2263	.2572			.3734
19	.3696		.1886	.2561			.4435
20	.5249		.5281	.4024			.5304
21	.4706			.4066			.4938
22	.4207		.4338	.3475			.4755
23	.4066		.3772	.2926			.4572
24	.1886	.2587		.3206	.2957		.1372
Max	.5249	.4344	.5281	.6413	.5068	.2229	.5959
Min	.1867	.2587	.1509	.1848	.2957	.2058	.1372
Avg	.2861	.3419	.2600	.3146	.3742	.2144	.3202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184017 / WADIVARE

Feeder No / Name : 203 / MUKANE IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2637	.8413		1.4523	1.5432		1.2346
2	1.2449	.8688		1.4712	1.5261		1.2346
3	1.2637	.905		1.4335	1.5089		1.2003
4	1.1883	1.0498		1.358	1.4918		1.1488
5	1.2637	1.0745		1.4901	1.4582		1.1317
6	1.2071	1.1222		1.5844	1.4083		1.1488
7	.9997	1.1462		1.4901	1.4529		1.166
8	.9619	1.3466		1.9239	1.5604		1.3375
9	.8859		1.7918	1.6804			1.2048
10	.8145		1.905	1.7147			1.3847
11	.7865		2.037	1.8176			1.5432
12	.8326		1.773	1.6461			1.5947
13	.823		1.8861	1.6461			1.5432
14	.823		1.9616	1.6289			1.5432
15	.7701		1.9239	1.6804		1.6804	1.5432
16	.7265		1.9427	1.7147			1.5432
17	.7133		1.905	1.5947			1.5432
18	.724		1.7918	1.5424			1.4373
19	.7602		1.8107	1.4548			
20	.8869		1.6409	1.6804			1.2757
21	.8145		1.4901	1.6804			1.1694
22	.7947		1.5844	1.6118			1.1871
23	.823		1.6598	1.5432			1.2254
24	1.3014	.823		1.3957	1.5432		1.2517
Max	1.3014	1.3466	2.037	1.9239	1.5604	1.6804	1.5947
Min	.7133	.823	1.4901	1.358	1.4083	1.6804	1.1317
Avg	.9447	1.0197	1.8069	1.5932	1.4992	1.6804	1.3301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184017 / WADIVARE

Feeder No / Name : 204 / MURAMBI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.7207		1.2637	.7059		.5658
2	.6036	.7392		1.1506	.724		.5658
3	.5847	.7762		1.094	.7421		.5487
4	.5847	.8131		1.1883	.7602		.6001
5	.6224	.8501		1.4901	.7783		.0514
6	.7356	.8688		1.6409	.7796		.7202
7	.8865	.8869		1.8673	1.1517		.7888
8	.7167	.7316		1.9616	1.7528		.6516
9	.7316		1.7353	1.5604			.5601
10	.4294		.4904	.462			.5601
11			.415	.4251			.5601
12	1.3032		.3772	.3881			1.4403
13	1.2094		.3206	.3921			1.4575
14	1.2269		.4527	.4066			1.5432
15	1.2517		.4904	.4294		1.6289	1.6118
16	1.3546		.4527	.4481			1.6289
17	.9431		.4904	.4572			1.5432
18	1.5432		.5281	.567			1.6118
19	1.6461		.7545	.6767			1.3112
20	.815		.9054	.7783			.8048
21	.8328		.8488	.7783			.8328
22	.7442		.8488	.7133			.7762
23	.6733		.6979	.6401			.6838
24	.5847	.7023		1.2071	.6733		.5487
Max	1.6461	.8869	1.7353	1.9616	1.7528	1.6289	1.6289
Min	.4294	.7023	.3206	.3881	.6733	1.6289	.0514
Avg	.8952	.7877	.6539	.9161	.8964	1.6289	.9153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184017 / WADIVARE

Feeder No / Name : 205 / SANJEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2826	1.0498		.6413	.7316		1.286
2	1.3392	1.086		.6224	.7682		1.2689
3	1.2637	1.1641		.5658	.7602		1.3032
4	1.358	1.2536		.5847	.8688		1.3546
5	1.4523	1.3289		.7733	.905		1.406
6	1.5844	1.4175		.9808	.985		1.4746
7	1.6409	1.4723		1.2071	1.0341		1.5775
8	1.6598	1.3643		.9431	.815		1.5604
9	1.3717		.6979	.695			1.4746
10	.5228		.4527	.5544			.5601
11	.4854		.415	.4435			.5228
12	.4668		1.4523	1.5604			.4481
13	.4481		1.5089	1.5432			.4854
14	.4668		1.6975	1.4918			.4668
15	.462		1.8107	1.4918		.3601	.3658
16			1.6787	1.4918			.4854
17			1.6032	1.5432			.5415
18	.6335		1.5089	1.5089			.5729
19	.7343		1.4335	1.4746			.7783
20	.9745		1.094	.9955			.8859
21	.8573		.9242	.9955			
22	.7682		.8865	.8869			.823
23	.6335		.7545	.7421			.7577
24	1.2637	.9955		1.5432	.7316		1.3032
Max	1.6598	1.4723	1.8107	1.5604	1.0341	.3601	1.5775
Min	.4481	.9955	.415	.4435	.7316	.3601	.3658
Avg	.9850	1.2369	1.1946	1.0533	.8444	.3601	.9436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184017 / WADIVARE

Feeder No / Name : 206 / 11 KV Parle

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.4108		.6979	.8413	1.0288
2	.5847	.3921		.6413	.8238	.9602
3	.5658	.3921		.6224	.815	.9259
4	.6224	.3547		.7356	.7973	.8916
5	.5281	.3734		.7733	.7973	.8573
6	.4904	.3921		.7167	.788	.7716
7	.3772	.4108		.5847	.788	.7888
8	.3206	.5973		.6224	.6626	.5487
9	.2801		.8573	.5304		.6201
10	.2801		1.0751	.6201		.6379
11	.2987		1.0374	.7087		.6344
12	.3142		.9431	.8316		.691
13	.2987		.8676	.6335		.6556
14	.2801		1.1694	.7087		.7011
15	.2987		1.3957	.7783		.7537
16	.3258		1.226	.8059		.7973
17	.3921		1.226	.8505		.8505
18	.4066		1.0751	.7619		.7343
19	.4251		.811			.6984
20	.4066		.7545	.9114		1.0288
21	.4435		.6979	.9412		
22	.4251		.6602	.9231		.9036
23	.4066		.6602	.8954		1.0745
24	.6036	.4108		.6602	.8764	1.0631
Max	.6224	.5973	1.3957	.9412	.8764	1.0745
Min	.2801	.3547	.6602	.5304	.6626	.5487
Avg	.4134	.4149	.9638	.7372	.7989	.8094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184017 / WADIVARE

Feeder No / Name : 208 / Nandgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.5975		1.1506	1.0277		.6001
2	.6224	.6535		1.0185	1.0517		.5487
3	.6036	.6722		1.1506	1.1393		.5658
4	.5658	.7023		1.094	1.2136		.6001
5	.6979	.7316		1.2071	1.2136		.6344
6	.7356	.7602		1.358	1.387		.6859
7	.7922	.7783		1.4523	1.4918		.703
8	.5658	.5853		1.6221	1.6461		.5487
9	.4481		1.2826	1.1919			.4481
10	.4294		.5093	.4572			.3921
11	.4108		.3961	.4755			.3361
12	1.406		.3584	.5175			2.3491
13	1.3375		.3772	.5175			2.452
14	1.3717		.3961	.5175			2.431
15	1.2003		.3772	.462		1.3203	2.4478
16	1.2517		.3961	.4251			2.5149
17	1.3032		.4338	.4805			2.5819
18	1.3546		.4715	.5304			2.5316
19	1.406		.7545	.5973			2.3491
20	.7087		.9808	.7602			.7602
21	.7421		1.1883	.7602			.7023
22	.6335		1.0751	.724			.6767
23	.6468		.9619	.6878			.6584
24	.6036	.6535		1.094	.985		.583
Max	1.406	.7783	1.2826	1.6221	1.6461	1.3203	2.5819
Min	.4108	.5853	.3584	.4251	.985	1.3203	.3361
Avg	.8509	.6816	.6639	.8438	1.2395	1.3203	1.2125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184049 / GHOTI

Feeder No / Name : 201 / GHOTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.5089	1.4575	1.5432	1.6118		1.3717
2	1.5261	1.4575	1.4403	1.4403			1.3032
3	1.6289	1.4918	1.5432	1.3717			1.3717
4	1.4403	1.5432	1.6804	1.4403			1.4403
5	1.6118	1.6118	1.7147	1.5089			1.5089
6	1.8004	1.7147	1.7833	1.5775			1.6118
7	1.7661	1.7833	1.8519	1.6461			1.7147
8	1.7147	1.8519	1.7147	1.7147			1.6461
9	1.749	1.7833	1.8519	1.7147			1.7147
10	2.1262	2.1948	2.2634	2.7263	2.0233		1.7147
11	2.2634	2.4691	2.5377	2.8121	2.6749		3.0864
12	2.4006	2.2634	2.5377	2.7606	2.7435	3.2236	3.2236
13	2.2977	2.3148	2.1262	2.8121	2.1434	2.4691	2.6749
14	2.1948	2.2634	2.2634	2.7778	3.2236	2.4691	2.4691
15	2.4006	2.6063	1.8519	2.7435		2.7435	1.2346
16	2.332	2.6578	2.2634	2.7263	3.2236	2.7435	1.5089
17	2.4691	2.6749	2.0748	2.6063		2.6749	3.0178
18	1.7147	2.1948	1.9204	2.5034		2.1948	2.332
19	2.0576	2.1262	1.7833	2.3834			2.5377
20	1.3717	2.2634	1.8176	2.332		2.1262	2.4006
21	1.989	2.2291	1.8519	2.1262		2.0576	2.332
22	1.9204	2.1262	1.7147	1.989		1.989	2.2634
23	1.7147	1.8519		1.8519		1.7147	2.1262
24		1.5775	1.7147	1.6461	1.7833		1.5089
Max	2.4691	2.6749	2.5377	2.8121	3.2236	3.2236	3.2236
Min	1.3717	1.4575	1.4403	1.3717	1.6118	1.7147	1.2346
Avg	1.9108	2.0233	1.9026	2.1148	2.4284	2.4005	2.0047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184049 / GHOTI

Feeder No / Name : 202 / DEVALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8004	2.0576	2.0919	1.9547	1.9204		.3086
2	1.8519	1.989	2.0576	2.0233			.3429
3	1.9204	2.0233	2.2291	2.1262			.3772
4	2.0576	2.1262	2.4006	2.2291			.4115
5	2.1262	2.2291	2.572	2.3663			.4801
6	2.3148	2.4006	2.7435	2.5034			.5487
7	2.4348		2.915	2.7092			.6173
8	2.7435	2.915	2.6578	2.3663			.4115
9	.4115	2.7092	.3086	.3772			.2743
10	.2743		.2058	.2401	.3258		.2058
11	.1715		.1372	.1372	.2401		.2058
12	.2058	.1715	.1715	.12	.2058	2.7435	2.2291
13	.2229	.2058	.1715	.1372	.1715	2.5377	2.7435
14	.2058	.1715	.1372	.1372	.2058	2.7778	2.9492
15	.1715	.1715	.1715	.1372		2.5034	2.8807
16		.2058	.2058	.1372	.2058	2.6749	
17	.1372	.2058	.2058	.1715		2.572	3.1893
18	.2058	.2058	.2058	.2058		.4458	2.915
19	.4115	.4115	.3772	.1886			2.6749
20	.583	.5487	.4801	.2058		.5144	.5144
21	.5144	.583	.5144	.2401		.5487	.5487
22	.4801	.5487	.4458	.3258		.4801	.4801
23	.3772	.4801		.4115		.3772	.3772
24		2.0919	2.0576	1.8861	.9259		.3086
Max	2.7435	2.915	2.915	2.7092	1.9204	2.7778	3.1893
Min	.1372	.1715	.1372	.12	.1715	.3772	.2058
Avg	.9828	1.1644	1.1071	.9724	.5251	1.6523	1.1302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184049 / GHOTI

Feeder No / Name : 203 / KAWANAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.1372	.1372		.2915
2	.12	.12	.1543	.1372			.3086
3	.1543	.1029	.1715	.1543			.3086
4	.1715	.1543	.2058	.1715			.3429
5	.1886	.2058	.2229	.1715			.3429
6	.2058	.2915	.2572	.2058			.3601
7	.2572	.2915	.2401	.2229			.3772
8	.1886	.1886	.1029	.1543			.3772
9	.1372	.1543	.1029	.1372	.1372		.1029
10	.1029	.1029	.1029	.1029	.1029		.1029
11	.0686	.0514	.0686	.1029	.0857		.12
12	.3086	.0857	.3086	.1886	.3429	.1029	.1029
13		.2743	.3429	.3601	.3772	.0857	.0686
14		.3258	.3429	.4115	.3944	.0857	.1029
15		.3772	.3944	.4287		.0857	.0857
16		.3258	.3944	.4115	.3772	.1029	.0857
17	.0171	.2915	.4115	.4287		.12	.1029
18		.0514	.4115	.3944		.2058	.1029
19	.3429	.2058	.1372	.4115			.2058
20	.2572	.2572	.1715	.2401		.2229	.2743
21	.2401	.1486	.1886	.2229		.2572	.2572
22	.2058	.2229	.1715	.1886		.2229	.2229
23	.1715	.1715		.1715		.1372	.1886
24		.1543	.1372	.1372	.1543		.2915
Max	.3429	.3772	.4115	.4287	.3944	.2572	.3772
Min	.0171	.0514	.0686	.1029	.0857	.0857	.0686
Avg	.1820	.1955	.2252	.2372	.2343	.1481	.2136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184049 / GHOTI

Feeder No / Name : 204 / 11 KV Kaluste

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7716	.4287	.3086	.3944		.823
2	.6687	.7202	.4115	.2743			.8573
3	.6859	.7545	.4801	.3086			.8916
4	.6859	.7888	.5144	.3429			.9259
5	.8573	.8573	.6344	.3772			.9602
6	.9431	.9259	.6859	.4115			1.0288
7	.4801	.9602	.583	.4801			.5487
8	.4458	.4458	.4801	.3429			.5144
9	.3429	.3772	.3429	.2743			.4458
10	.3086	.3086	.2401	.2915			.3772
11	.2743	.2401	.2401				.3601
12	.2401	.2401		.6344	.6859	.3086	.3258
13	.2572	.2058	.3772	.7545	.7716	.3086	.3429
14	.2572	.2743	.4801	.823	.8059	.3086	.3601
15	.2915	.3086	.3086	.8402		.2743	.3429
16	.3086	.2743	.5487	.8573	.8745	.2743	.3772
17	.3601	.2401	.6173	.8745		.3086	.3772
18	.4287	.3772	.6859	.8573		.2743	.4458
19	.6173	.5487	.2229	.8402		.4458	.6173
20	.7373	.7373	.3429	.4458		.5487	.7545
21	.6859	.7716	.4115	.463		.7202	.7545
22	.6344	.6001	.3772	.463		.6859	.7202
23	.5487	.4287		.4801		.5144	.6344
24	.6516	.8402	.4115	.3429	.4458	.2743	.7888
Max	.9431	.9602	.6859	.8745	.8745	.7202	1.0288
Min	.2401	.2058	.2229	.2743	.3944	.2743	.3258
Avg	.5151	.5416	.4466	.5256	.6630	.4036	.6073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184058 / PARDESWADI

Feeder No / Name : 201 / PARDESWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.6104	.6458	.5935	.5935	1.0774	1.2452
2	.5935	.5935	.6274		.6104		1.2887
3	.6104	.5935	.5935		.6443		1.3395
4	.6104	.6443	.6274	.6104	.6783	1.4074	1.3108
5	.6443	.6783	.6613	.6783	.6783		1.5261
6	.6952	.7122	.7291	.6952	.78		1.5261
7	.6952	.6104	.8139	.7291	.7122		1.5939
8	.6443	.5087	.5596	.5935	.6443	1.3435	1.3927
9	.4578	.4748	.5426	.3391	.4748		.3222
10	.373		.3391	.3561	.4748		
11			.3391	1.0852	.2035		
12	1.6108	1.543	1.543	1.4922		.3222	.373
13		1.6278	1.6278		1.5261		
14	1.6956	1.5939			1.5769		
15	1.5939	1.5261					
16	1.543	1.4413	1.5261	1.56	.2035	.3052	.407
17	1.448	1.3735					
20	.78	.9156	.78	.763	.8817	.6783	.9448
21		.8817	.8139				
22	.7461	.8309	.6952				
23	.6859	.763	.6952	.6783	.7291	.3391	.8192
24	.6443	.6952	.6443	.6443	.6952	1.2209	1.0486
Max	1.6956	1.6278	1.6278	1.56	1.5769	1.4074	1.5939
Min	.373	.4748	.3391	.3391	.2035	.3052	.3222
Avg	.8780	.9309	.7792	.7727	.7122	.8368	1.0813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184058 / PARDESWADI

Feeder No / Name : 203 / BELAGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4239	.3052	.3601	.407	.3391	1.5261	1.6975
2	.4409	.3052	.3944	.4287	.373	1.6108	
3	.4409	.3429	.4287	.4239	.373		
4	.5087	.4115	.4801	.4115	.407	1.749	1.7147
5		.4458	.4973	.4801	.4409	1.8519	
6	.5256		.5487	.5316	.5426	2.0576	
7	.5596		.5658	.6001		2.3148	
8	.4409	.4801	.4287	.5087	.407	2.4006	2.1262
9	.373	.5487	.3429	.3601	.373	2.1434	
10	.2374	.2743	.2915	.3429	.2713	.2572	
11	1.5939	1.5775	.2915		1.56	.2229	
12	2.3739	2.0576	2.2634	2.4006		.2058	.2401
13		2.2291	2.3663	2.3148		.2058	
14		2.2291	2.332	2.2291			
15	2.3061	2.2291	2.2552	2.1605			
16	2.3739	2.3148	2.2805	2.2977	2.3148	.1715	.2743
17	2.3908	2.3663	2.332	2.2634			
18	2.0348	2.3663	2.2462	.3429	2.2382		
19	.407	.3429	.3429	.6173	.3391		
20	.5426	.583	.4115	.5144	.4917	.4287	.5144
21	.4409	.5658	.463		.5256		
22	.407	.5144	.4458		.5144	.4287	
23	.3391	.4458	.4115	.3772	.3391	.3429	1.406
24	.3391	.3772	.4287	.3772	.2883	1.7661	1.7833
Max	2.3908	2.3663	2.3663	2.4006	2.3148	2.4006	2.1262
Min	.2374	.2743	.2915	.3429	.2713	.1715	.2401
Avg	.9286	1.0597	.9670	.9709	.6743	1.1579	1.2196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184058 / PARDESWADI

Feeder No / Name : 204 / 11 kv JYOTI EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0002	.0002	.0002	.0004	.0002	.0002
2	.0002	.0002	.0002	.0002		.0019
3	.0002	.0004	.0002	.0004	.0002	.0019
4	.0002	.0002	.0002	.0002	.0002	.0229
5			.0002	.0002	.0002	.0002
6	.0002		.0002		.0002	.0019
7	.0002					.0019
8	.0002	.0002	.0002	.0002	.0002	.0019
9	.0002					.0019
10	.0002	.0004	.0002			
11	.0002			.0002		
12	.0002	.0002	.0002	.0004	.0002	.0002
13		.0002		.0004		
14	.0002	.0002		.0004		
15	.0002	.0002				
16		.0002	.0002	.0004	.0002	.0002
17	.0002					
18	.0002			.0002		
19	.0002			.0002		
20	.0002	.0002	.0002	.0002	.0002	.0002
21	.0002	.0002		.0002		
22		.0004	.0004	.0002		
23		.0002	.0004	.0002	.0002	.0002
24		.0002	.0002	.0002	.0002	.0002
Max	.0002	.0004	.0004	.0004	.0002	.0229
Min	.0002	.0002	.0002	.0002	.0002	.0002
Avg	.0002	.0002	.0002	.0003	.0002	.0026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184058 / PARDESWADI

Feeder No / Name : 205 / 11 KV Barshingave

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.3052	.4239	.2713	.4239	.1696	.2543
2	.6443	.3052	.4409	.2543		.1357	
3	.6613	.3391					
4	.6952	.373	.4578	.3222	.4239	.1696	.2713
5	.7461	.407	.5256	.4748		.2035	
6	.78	.4578	.6104	.5087		.2543	
7	.7969	.8478	.763	.5426			
8	.6613	.7461	.6783	.4917	.7461	.1886	.2374
9		.1187	.0678	.1017			
11	.1017	.0848			.0509		
12	.1017	.0848	.0848	.1017		.2035	.3561
13			.0848		.0848		
14		.0678					
15		.0509					
16	.1357	.0678	.0678	.1357	.1017	.5935	.5087
19	.2713	.2883	.2713				
20	.3561	.3561	.3391	.373	.373	.2713	.39
21		.3391	.3561		.39		
22	.2883	.2883	.2713		.3391		
23	.3222	.3222	.2713	.3391	.3561	.3222	.3052
24	.3222	.407	.2883	.4409	.39	.2713	.2543
Max	.7969	.8478	.763	.5426	.7461	.5935	.5087
Min	.1017	.0509	.0678	.1017	.0509	.1357	.2374
Avg	.4684	.3129	.3531	.3352	.3345	.2530	.3222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184083 / SAKUR

Feeder No / Name : 201 / BHARVEER-II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.7718	6.6957	6.4891	6.2681	.9145	1.5318
2	1.7033	1.6861	6.5783	6.592	6.2128	.9145	1.6004
3	1.8404	1.669	6.5257	6.6949	6.1804	.9145	1.6861
4	1.9433	1.6004	6.7132	6.592	6.2505	.9145	1.7718
5	2.0462	2.0443	6.7997	6.7463	6.3557	1.0669	1.789
6	2.2329	2.231	7.5484	7.4112	6.714	1.0669	2.0271
7	1.0669	2.01	6.0051	7.4093	5.3879	1.0669	1.6194
8	1.5146	1.568	8.3265	8.0227	4.6439	.9145	1.6004
9	1.107	1.1241	4.6963	4.7957	3.9628	1.1413	1.1944
10	.3048	.9202	1.326	1.0058	.9145	.9545	.8344
11	.6858	3.2883	.6649	.6443	.3048	3.4941	2.2052
12	7.5903	7.5655	.1524	.6254	.6649	7.1559	7.4989
13	7.6208	7.1598	.3048	.5877	.6306	4.46	8.2781
14	7.4074	7.6151	.3048	1.9166	.6134	7.8703	8.1924
15	7.6817	7.3598	.3048	2.1496	.6134	7.8723	8.32
16	7.2855	4.0727	.3048	.6066	.5963	7.9218	8.1505
17	8.2953	6.7111	.6649	.7009	.1524	8.0227	7.998
18	7.8189	8.0149	.7163	.7575	.3048	8.179	8.4439
19	4.4105	4.681	1.2288	1.0593	.4572	4.9535	4.7754
20	2.1967	2.3133	2.0271	2.142	1.0669	1.8747	2.2944
21	2.0786	2.142	2.0957	2.142	1.0669	1.9433	2.1043
22	2.0786	2.1043	2.0957	2.1609	1.0669	2.0957	1.933
23	2.0271	2.5434	3.3817	2.8044	1.0669	1.7033	1.801
24	4.0848	3.9723	6.5783	5.9804	3.8767	.9145	1.6004
Max	8.2953	8.0149	8.3265	8.0227	6.714	8.179	8.4439
Min	.3048	.9202	.1524	.5877	.1524	.9145	.8344
Avg	3.6029	3.5904	3.4183	3.5849	2.7239	3.2638	3.7188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184083 / SAKUR

Feeder No / Name : 202 / DHAMANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	4.201	1.0185	.9259	1.0185		3.7723
2	3.0521	4.2353	.9997	.9088	1.0185		3.738
3	3.2579	4.2696	1.0374	.823	1.0562		3.858
4	3.3951	4.3381	1.1317	.8745	1.1317		3.9438
5	3.4979	4.3038	1.1694	.9602	1.226		3.9095
6	3.7723	4.3553	1.3392	1.2174	1.358		3.7723
7	4.0295	1.0974	1.2071	1.2689	1.2071		4.2867
8	4.2181	.9088	.9431	.8916	.9431		3.9438
9	.5316	.5658	.583	.7167		.6859	.5847
10	.4973	.4458	.5144	.5658		.5658	.7545
11	.381	.4801		1.1888		.5487	.6224
12	.4973	.463		2.8746	2.5377	.4973	.5281
13	.4973	.4458		2.8607	2.6235	.5144	.547
14	.4287	.463		2.5139	2.7263	.5316	.547
15	.5144	.463		2.5415	2.6063	.4973	.5281
16	.5658	.4115		2.6406	2.5034	.5316	.5658
17	.6001	.4904	3.738	2.692		.5144	.5847
18		.5847	3.9095	4.1076		.5316	.6602
19	.9088	.9997	.7545	.6036		.7888	.9431
20	1.1145	1.1883	.9945	1.2449		.9945	1.2826
21	1.1831	1.3203	1.1317	1.2826		1.1317	1.2826
22	1.1488	1.2449	1.2003	1.2637		1.0631	1.2637
23	2.7092	1.1317	1.0974	1.1694		2.3663	2.0119
24	2.5377	4.1838	1.094	.9774	1.0751		3.3951
Max	4.2181	4.3553	3.9095	4.1076	2.7263	2.3663	4.2867
Min	.381	.4115	.5144	.5658	.9431	.4973	.5281
Avg	1.8297	1.7746	1.3257	1.5464	1.6451	.7842	1.9719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184083 / SAKUR

Feeder No / Name : 203 / SMBT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4446	.3921	.4031	.4812	.4241	.1802	.4401
2	.413	.3826	.3719	.4423	.4092	.1638	.3937
3	.413	.3608	.3696	.3841	.3879	.1467	.3449
4	.4111	.3506	.3955	.3502	.4001	.1459	.3121
5	.4119	.3566	.3974	.3857	.4047	.149	.2748
6	.41	.3532	.4211	.4641	.4318	.1638	.354
7	.4092	.3494	.4645	.5391	.4427	.1547	.399
8	.5106	.402	.5708	.5266	.6034	.1673	.5125
9	.7156	.4728	.7388	.8597	.2618	.8086	.612
10	.6306	.4843	.772	.8705	.2785	.698	.6066
11	.6093	.485	.285	.8044	.3205	.7225	.6454
12	.6093	.4108	.2389	.8923	.7476	.8322	.6786
13	.6237	.3689	.208	.7943	.7305	.7765	.5571
14	.5522	.3829	.216	.7619	.7377	.7956	.5719
15	.5982	.37	.2572	.7207	.7533	.8303	.655
16	.5373	.4199	.2416	.6693	.7868	.7937	.6554
17	.4865	.442	.5433	.6469	.3003	.772	.5925
18	.1654	.4165	.618	.6979	.2355	.5517	.5719
19	.3341	.4359	.6363	.5514	.2088	.5254	.6032
20	.4298	.4927	.6504	.5114	.21	.5933	.5952
21	.4366	.4931	.6054	.5861	.2012	.6302	.5197
22	.434	.5007	.6756	.5175	.1871	.5239	.5208
23	.3975	.4459	.7167	.4957	.184	.4759	.4854
24	.386	.4032	.4481	.5022	.4873	.1692	.4496
Max	.7156	.5007	.772	.8923	.7868	.8322	.6786
Min	.1654	.3494	.208	.3502	.184	.1459	.2748
Avg	.4737	.4155	.4686	.6023	.4223	.4904	.5146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184083 / SAKUR

Feeder No / Name : 204 / Sakur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	2.2977	.6036	.5144	.6036		2.0576
2	1.7833	2.4006	.5658	.4801	.5658		2.1262
3	1.7833	2.4348	.6036	.4115	.6036		2.0576
4	1.989	2.5206	.6602	.4801	.679		1.989
5	2.2634	2.6063	.7545	.5487	.7922		2.1948
6	2.7435	2.692	.9054	.823	.9054		2.332
7	3.155	2.7435	.7922	.6859	.8488		2.6063
8	2.7435	2.7949	.5847	.4801	.6036		2.7435
9	.4801	.3429	.1372	.3772		.3429	.3772
10		.3429	.1372	.3584		.2915	.3772
11	.2286	.3601		1.0974		.3086	.3395
12	.1829	.3086		3.2065	3.0693	.3086	.3206
13	.2572	.3086		3.2922	3.1207	.2743	.3395
14	.2743	.2743		3.3951	3.2407	.3429	.3206
15	.2743	.2915		3.3093	3.1207	.3772	.3395
16	.2401	.3086		3.2952	3.0693	.3429	.3206
17	.3772	.3584	3.155	3.0148		.3429	.2829
18	.3429	.415		3.2922		.2743	
19	.4287	.6036	.4801	.4527		.5487	.6036
20	.6516	.7922	.5487	.8299		.6859	.8299
21	.7373	.7545	.6516	.7922		.7545	.8865
22	.703	.7356	.7545	.7922		.5487	.7733
23	1.6461	.6602	.6173	.6413		1.6804	1.3717
24	1.5775	2.2805	.6224	.5487	.6224		1.8519
Max	3.155	2.7949	3.155	3.3951	3.2407	1.6804	2.7435
Min	.1829	.2743	.1372	.3584	.5658	.2743	.2829
Avg	1.1526	1.2345	.7396	1.3800	1.5604	.4950	1.1931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184083 / SAKUR

Feeder No / Name : 205 / 11 KV Shenit

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	1.0802	.2641	.2401	.3395		.6859
2	.823	1.1488	.2641	.2058	.3206		.7545
3	.8573	1.1831	.2829	.2058	.3395		.823
4	.8916	1.286	.3018	.2743	.3395		.8573
5	1.0288	1.3203	.3772	.4115	.3772		.8916
6	1.166	1.3717	.415	.4801	.415		.9602
7	1.2346	1.406	.3961	.4115	.4527		.9602
8	1.2346	1.5089	.3395	.3429	.3772		.823
9	.2058	.2229	.2743	.1886		.1715	.2263
10		.2058	.2743	.2829		.1372	.2263
11	.1524	.2058		.5487		.2058	.1886
12	.1524	.1886		1.6834	1.5432	.1886	.2452
13	.1372	.2058		1.7002	1.5775	.2743	
14	.1372	.1886		1.6651	1.6118	.2743	.1698
15	.2401	.1886		1.6126	1.5089	.2743	.1886
16	.2401	.2058		1.5424	1.4746	.1372	.2641
17	.2401	.2075	1.5089	1.4883		.2743	.2075
18	.1715	.2641	1.3717	1.5424		.2743	.2641
19	.3258	.3584	.2743	.2829		.2743	.2641
20	.3429	.3584	.3429	.3772		.3429	.3395
21	.3429	.3772	.4115	.3584		.4115	.3206
22	.3086	.3206	.4801	.3206		.3429	.3018
23	.823	.2829	.3429	.3395		.823	.6468
24	.9602	1.0631	.2641	.2743	.3772		.7545
Max	1.2346	1.5089	1.5089	1.7002	1.6118	.823	.9602
Min	.1372	.1886	.2641	.1886	.3206	.1372	.1698
Avg	.5612	.6312	.4548	.6991	.7896	.2938	.4941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184265 / Shenwad

Feeder No / Name : 201 / Shenwad

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6173	.181				.6516
2		.6173	.181				.6516
3		.6001	.181				.6516
4		.6344	.181		.2401		.6859
5		.6859	.2172	.3506			.7545
6		.0772	.3258	.4075			.8573
7		.9431	.362	.3721			.9088
8		.8059	.2534	.1772			.9431
9	.7888	.9955	.2254		.2058		.7716
10	.1543	.2172	.1227				.1372
11	.12	.1448	.124				.1372
12	.12	.1448	.8322				.1134
13	.12	.1448	.8764		.8916	.12	.1134
14	.1372	.1267	.8238		.8573	.12	.0972
15	.1372	.1267	.9036			.12	.1372
16	.1372	.1267	.8859		.8573	.1372	.1543
17	.1372	.1267	.9189			.1715	.1715
18	.1715	.2172	.9015			.1715	.1886
19	.2743	.2715	.8842			.2401	.2915
20	.3601	.2715	.3681			.3086	.3258
21	.3429	.2896	.333			.3429	.3258
22	.3086	.2715	.3155			.3086	.3258
23	.2572	.2353				.2572	.2401
24		.6173	.181	.2481	.2915		.6516
Max	.7888	.9955	.9189	.4075	.8916	.3429	.9431
Min	.12	.0772	.1227	.1772	.2058	.12	.0972
Avg	.2378	.3879	.4599	.3111	.5573	.2089	.4286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184265 / Shenwad

Feeder No / Name : 202 / Samnera

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801	2.0328	1.8378			.4458
2		.4458	2.0328				.4458
3		.4458	2.0328				.4458
4		.4801	2.0328		2.1262		.5144
5		.583	2.0328				.6516
6		.8573	2.2177	2.4272			.7545
7		.8573	2.2177	2.7778			.7888
8		.4458	2.5873	2.8746			.5487
9		.4344	2.2539		2.7435		.4115
10	.2743	.362	.3189				.2401
11	.2401	.2896	.1772				.2743
12	2.3663	2.7721	.1063			2.7435	2.4939
13	.2641	2.7721	.1772		.1029	2.7435	2.4939
14	2.7122	2.9569	.0709		.1029	2.915	2.8826
15	2.6749	2.9569	.0701			2.915	3.0521
16	2.6406	2.7721	.1063		.2058	2.915	2.8807
17	2.7435	2.5873	.1063			2.915	3.0521
18	2.7092	2.5873	.1063			2.572	2.8292
19	2.7435	2.5873	.3189			2.4006	2.8121
20	.7545	.6878	.7796			.8573	.823
21	.7545	.8326	.7442			.7545	.7888
22	.6516	.724	.7087			.6859	.6859
23	.5487	.6154				.583	.583
24		.5144	2.2177	1.7878	2.0919		.4801
Max	2.7435	2.9569	2.5873	2.8746	2.7435	2.915	3.0521
Min	.2401	.2896	.0701	1.7878	.1029	.583	.2401
Avg	1.577	1.2936	1.1065	2.3410	1.2289	2.0834	1.3074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184265 / Shenwad

Feeder No / Name : 203 / Mundhegaon

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.12	.1307	.1417			.1029
2		.12	.112	.1227			.1029
3		.1372	.0934	.1063			.0857
4		.1372	.1494	.1063	.0857		.0857
5		.1372	.1494	.0886			.1372
6		.12	.168	.0886			.1543
7		.12	.168	.0709			.12
8		.1029	.1307	.0532			.1029
9		.1494	.1402		.0857		.12
10	.0514	.1494	.1753				.12
11	.1029	.1307	.1402				.1372
12	.0686	.112	.1063			.2058	.1457
13	.0305	.112	.1402		.1543	.2058	.1457
14	.0343	.1307	.1227		.1715	.2572	.1296
15	.0051	.1307	.2103			.2572	.12
16	.0514	.1307	.1052		.1372	.2058	.2401
17	.0686	.1867	.1417			.2058	.2743
18	.0514	.2241	.1417			.2058	.2229
19	.0514	.2427	.1052			.2058	.2915
20		.2427	.2126			.2058	.12
21	.1372	.2427	.2126			.1029	.12
22	.1372	.2427	.1949			.1372	.12
23	.1543	.168				.1543	.1372
24		.1543	.1867	.1417	.12		.4801
Max	.1543	.2427	.2126	.1417	.1715	.2572	.4801
Min	.0051	.1029	.0934	.0532	.0857	.1029	.0857
Avg	.0726	.156	.1495	.1022	.1257	.1958	.1590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184266 / Padali

Feeder No / Name : 201 / Mukane Rural

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.8097	.2543	.1949	.2103		.7625
2	.8785	.8322	.2652	.2126	.2279		.5992
3	.8619	.9012	.2949	.2303	.2601		.4858
4	.8951	.9614	.3239	.2629	.2774		.6316
5	.9116	1.0059	.3481	.333	.2947		.639
6	.9556	1.0513	.3605	.4908	.298		.7545
7	.9945	1.0608	.3856	.4382	.4557		1.0277
8	1.0608	1.1065	.3052	.298	.3467		.9448
9	.9614	1.0898	.2713	.2279		.9568	.7377
10	.2012	.2347	.1174	.1907		.1753	.1696
11	.1526	.1677	.1187	.1734		.1578	.1844
12	.1509	.1677	1.0227	1.0166		.156	.1865
13	.1677	.1509	.8048	1.0631		.1696	.1677
14	.1696	.1341	.9054	1.0852		.1509	.1526
15	.1509	.1341	.9156	1.073		.1341	.1509
16	.1677	.1475	.9448			.1357	.2012
17	.1658	.1823	1.094	1.085		.1772	.2103
18	.2204		1.0774	1.166		.2279	.2507
19	.3185	.2949	1.0442	1.1305		.3155	.3155
20	.4144	.3647	.4207	.3988		.4161	.3681
21	.3077	.3353	.3681	.333		.333	.3012
22	.3277	.3113	.3544	.2947		.298	.3189
23	.2652	.2883	.2658	.2454		.2804	.2686
24	.7865	.7373	.2683	.2126	.2279		.7625
Max	1.0608	1.1065	1.094	1.166	.4557	.9568	1.0277
Min	.1509	.1341	.1174	.1734	.2103	.1341	.1509
Avg	.5127	.5422	.5221	.5285	.2887	.2723	.4413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

IGATPURI (R) SUBDN[271] BU 5401

Substation No/ Name :- 184266 / Padali

Feeder No / Name : 202 / 11 KV Industrial-I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.4706	.3582	.3696	.4024		.3982
2	.4163	.4477	.3721	.4066	.4207		.3801
3	.4163	.4938	.3982	.4066	.439		.3982
4	.4163	.5175	.4572	.4024	.4572		.4207
5	.4755	.543	.5175	.439	.4755		.4525
6	.5359	.6089	.5552	.5359	.5914		.5544
7	.6219	.6584	.6154	.5175	.5729		.6335
8	.591	.5973	.5487	.4066	.5249		.6556
9	.5373	.6447	.567	.5487		.5304	.3856
10	.5194	.5973	.2715	.4572		.4163	.4656
11	.181	.443	.3439	.3982		.4024	.6733
12	.3224	.4252	.394	.3475		.3982	.6984
13	.3544	.4119		.3224		.3761	.6733
14	.3544	.3982		.3898		.3898	.6733
15	.3721	.3801	.2629	.4298		.3721	.6984
16	.3721	.394	.3696			.4207	.7087
17	.4344	.439	.4066	.4119		.4477	.6661
18	.4755		.499	.4656		.4835	.7545
19	.5249	.5792	.5792			.5249	.823
20	.5014	.5014	.4572	.4835		.543	.823
21	.5487	.4525	.5121			.4938	.8059
22	.4706	.4075	.4572	.4344		.4207	.78
23	.4298	.4024	.4207	.4024		.4163	.6874
24	.4163	.4572	.3801	.3881	.4207		.3801
Max	.6219	.6584	.6154	.5487	.5914	.543	.823
Min	.181	.3801	.2629	.3224	.4024	.3721	.3801
Avg	.4453	.4900	.4429	.4268	.4783	.4424	.6079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184015 / CHANDORI

Feeder No / Name : 201 / BERWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1		2.0919	2.1091
2		2.1605	2.1434
3		2.2291	2.2291
4		2.4006	2.4006
5		2.572	2.6063
6		3.1207	2.8978
7		3.5837	3.5665
8		3.5322	3.7037
9		.3944	.4973
10		.3772	.4458
11		.3772	.4115
12		.4115	
16		.3772	
17		.4115	.4973
18	.6173	.4115	.5487
19	.6173	.5144	
20	.7716	.6173	
21	.823	.7716	
22	.8402	.7888	
23	.8573	1.8861	
24		2.0919	2.0576
Max	.8573	3.5837	3.7037
Min	.6173	.3772	.4115
Avg	.7545	1.4820	1.8653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184015 / CHANDORI

Feeder No / Name : 202 / KARANJGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.9376	1.9376
2		1.9547	1.9376
3		1.9719	.0171
4		1.989	1.989
5		2.0576	2.0233
6		3.2922	2.1091
7		2.6406	2.5034
8		2.8807	2.8978
9		3.0178	3.0521
10		2.915	2.9492
11		2.7606	2.8635
14		2.5149	
15		2.5774	
18	2.6749		
19	2.6406		
20	2.572		
21	2.3148		
24		1.9376	1.9376
Max	2.6749	3.2922	3.0521
Min	2.3148	1.9376	.0171
Avg	2.5506	2.4605	2.1848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184015 / CHANDORI

Feeder No / Name : 203 / SAIKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6813	.6615	.6569	.5959	.6386	5.849	5.6802
2	.7133	.6874	.6889	.6188	.6615	5.4671	5.6051
3	.727	.7225	.7118	.6584	.6904	5.8932	5.636
4	.7834	.7712	.756	.7453	.7255	5.8859	5.8284
5	.8596	.8764	.884	.8474	.8124	6.0616	6.07
6	.9236	.9465	.9404	.948	.9206	6.6606	6.5287
7	.8581	.9252	.9343	.8444		7.8559	7.7531
8	.317	.2393	.2789	.3795		5.4138	4.2097
9					.1402	4.5351	4.281
10	.346	.3643	.3307	.4237	.3871	1.6506	1.7875
11	.2774	.3262	.2835	.378	.2835	.5746	.5852
12	3.3821	3.6565	3.7494	3.6946	3.8714	.6073	.6668
13	4.225	4.0497	3.7814	4.0116	4.0177	.2683	.7682
14	4.2905	3.8089	3.9369	3.9811	4.0543	.2915	.666
15	4.1518	3.9643	3.9537	3.7022	3.8333	.6409	.6332
16	4.007	3.8485	3.7632	3.5757	3.8104	.6515	.6767
17	4.0969	3.9963	3.6168	3.7403	3.6214	.6409	.7076
18	3.9262	3.9354	3.914	3.7235	6.9026	.6698	.7229
19	3.751	3.7769	3.8134	3.565	3.7479	.3887	.4512
20	1.1004	.8322	1.4038	1.0852	1.4731	.9701	.5365
21	.6523	.6645	.6249	.6523	1.1363	1.1027	.5959
22	.7484	.7453	.6722	.7103	1.3462	1.0303	.6676
23	.791	.7621	.6752	.7575	1.4266	3.1973	.6981
24	.6904	.6798	.6188	.6645	3.0468	5.8947	5.6421
Max	4.2905	4.0497	3.9537	4.0116	6.9026	7.8559	7.7531
Min	.2774	.2393	.2789	.378	.1402	.2683	.4512
Avg	1.8391	1.7931	1.7821	1.7523	2.1613	3.0084	2.8082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184015 / CHANDORI

Feeder No / Name : 204 / CHANDORIGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.5316	.5487
2		.5316	.5316
3		.5316	.5487
4		.5658	.583
5		.6001	.6173
6		.6859	.6687
7		.823	.7888
8		.7888	.7888
9		.8402	.8402
10		.8573	.823
11		.8916	.7888
12		.8573	.8745
13		.8573	.8916
14		.823	.8745
15		.8916	.8916
16		.8916	.9259
17		.9088	.9431
18	.8573	.9602	1.0117
19	.8745	1.0288	
20	.8916	.9431	
21	.823	.823	
22	.7888	.6859	
23	.7888	.6173	
24		.5316	.5144
Max	.8916	1.0288	1.0117
Min	.7888	.5316	.5144
Avg	.8373	.7695	.7608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184015 / CHANDORI

Feeder No / Name : 205 / CHEHADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2739	3.5101	3.9567	3.9491	3.6808	2.5911	2.7088
2	3.1779	3.5132	3.9643	3.972	3.7068	2.5895	2.7042
3	3.1139	3.4568	3.8805	3.8759	3.6854	2.5972	2.7027
4	3.155	3.4995	3.7769	3.8348	3.6671	2.6574	2.8037
5	3.0849	3.5421	3.8226	4.007	3.6976	2.7343	2.9184
6	3.312	3.7083	3.9506	4.3149	4.0268	2.8452	2.9153
7	4.225	4.2783	4.4262	4.5191	4.3637	2.9302	2.8139
8	3.504	4.8697	4.5329	.7225	4.8102	2.7008	2.2714
9	4.6136	5.1928	5.1943	5.6226	5.0252	1.4937	4.4436
10	4.7782	4.8621	5.0373	5.4504	4.6121	2.5377	7.4261
11	.602	.6158	.5563	.5578	.5959	5.1806	***
12	.6036	.6401	.5792	.6142	.2652	8.8363	9.7741
13	.7194	.3384		.6341	.6691	5.2736	5.0709
14	.6676		.6234	.6965	.7103	6.3585	6.9623
15	.6904	.6874	.6981	.6676	.7118	***	8.7933
16	.727	.7621	.7514	.7468	.6981	5.7476	8.6584
17	.7834	.788	.7697	.8048	.7209	5.8246	4.9642
18	.8124	.8352	.9694	.7331	1.3017	5.7682	5.0747
19	.8246	.8855	.977	.6737	1.7367	1.153	.756
20	1.1325	1.5607	.791	.4816	1.9399	2.1971	1.2788
21	1.6476	1.5821	.82	.8932	2.7145	2.8411	1.5973
22	1.6537	1.6461	.8109	.8855	2.7282	2.8365	1.6476
23	1.6476	1.6476	.8093	.9221	4.217	2.8936	1.6583
24	3.0514	3.5787	3.4797	3.0605	1.6903	2.6886	2.7382
Max	4.7782	5.1928	5.1943	5.6226	5.0252	10.4592	10.3232
Min	.602	.3384	.5563	.4816	.2652	1.153	.756
Avg	2.1584	2.4348	2.3990	2.1933	2.5823	3.9057	4.2919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184015 / CHANDORI

Feeder No / Name : 206 / CHANDORISHIVAR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.4403	1.5604
2		1.5432	1.5604
3		1.5432	1.6289
4		1.6289	1.7147
5		2.1434	1.8519
6		2.1434	2.1948
7		2.4006	2.8121
8		.3429	2.8978
9			.5144
10		.5144	.5316
11		.6001	.6859
12		.6001	.583
13		.5487	.5316
14		.5316	.5316
15		.6516	.5658
16		.6516	.5658
17		.6173	.6687
18	2.2291	.6859	.7202
19	.6173	.8745	
20	.7545	.8573	
21	.7545	.823	
22	.7888	.823	
23	.7888	.8916	
24		1.4403	1.5432
Max	2.2291	2.4006	2.8978
Min	.6173	.3429	.5144
Avg	.9888	1.0564	1.2454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184015 / CHANDORI

Feeder No / Name : 207 / CHITEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.0974	1.0288
2		.1097	1.0288
3		1.0974	.1063
4		1.1145	1.0974
5		1.1317	1.1317
6		1.1317	1.2003
7		1.0802	1.0802
8		.9602	.9088
9		.8573	.8059
10		.823	.7716
11		1.166	1.6118
12			2.5549
13			2.5377
14			3.1722
15			3.1036
16		2.4006	3.0521
17		2.2977	3.155
18	.9088	2.2291	3.2065
19	.9602	.9774	
20	.9088	.9431	
21	.9602	.9259	
22	1.166	1.0288	
23	1.8861	1.8861	
24		1.0974	1.0288
Max	1.8861	2.4006	3.2065
Min	.9088	.1097	.1063
Avg	1.1317	1.2178	1.7149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184015 / CHANDORI

Feeder No / Name : 208 / 11KV BERWADI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
11		.463	.6001
12		.463	.6516
13		.463	.4801
14		.463	.4458
15		.6516	.4287
16		.6173	.4287
17		.6173	.3772
18		.5487	.3772
23	.4458		
Max	.4458	.6516	.6516
Min	.4458	.463	.3772
Avg	.4458	.5359	.4737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184015 / CHANDORI

Feeder No / Name : 209 / NHRDF

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0103	.0086
2		.0103	.0086
3		.0103	.0086
4		.0103	.0103
5		.0086	.0086
6		.0086	.0086
7			.0103
8		.0086	.0103
9		.0086	.012
10		.0137	.012
11		.0137	.012
12		.0137	.0103
13		.0137	.012
14		.012	.0103
15		.012	.012
16		.012	.012
17		.0086	.012
18	.0137	.0103	.0086
19	.012	.0103	
20	.012	.0103	
21	.0103	.0103	
22	.0103	.0103	
23	.0103	.0086	
24		.012	.0086
Max	.0137	.0137	.012
Min	.0103	.0086	.0086
Avg	.0114	.0107	.0103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184015 / CHANDORI

Feeder No / Name : 210 / 11 KV CHITALESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0017
2			.0171
3		.0171	.0171
4		.0343	.0034
5		.0343	.0343
6		.0343	.0343
7		.0343	.0343
8		.0171	
9		.0171	.0171
10		.0171	.0171
11		.463	.4287
12		.4115	.463
13		.463	.4801
14		.5316	.463
15		.5316	.4801
16		.5316	.4973
17		.5316	.5144
18	.0171	.5144	.5144
19	.0171	.0171	
20	.0171	.0343	
21	.0171	.0343	
22	.0171		
23	.3601	.0343	
24	.3601	.0171	.0343
Max	.3601	.5316	.5144
Min	.0171	.0171	.0017
Avg	.1151	.1972	.2251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184039 / M. SAKORE

Feeder No / Name : 201 / KHANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.4098	.8002	.6859	.8002	.141	1.3146
2	1.2574	1.448	.8002	.6516	.7811	.1448	1.3717
3	1.2193	1.4861	.7621	.6859	.8192	.1486	1.4098
4	1.2384	1.6385	.7621	.7202	.7621	.1562	1.4861
5	1.2955	1.7909	.7811	.6859	.8573	.1791	1.6575
6	2.4196	1.9052	.7811	.6516	.8764	.1981	2.0957
7	2.4768	2.2862	.6478	.6173	.6859	.2286	2.4006
8	2.4768	2.3434	.4572	.4801	.4572	.2439	2.5911
9	.2286	2.1338	.3429	.3429	.0305	2.21	2.4387
10	.0229	.2286	.2743		.0286	.2858	.3048
11		.1905			.0229	.3048	.2858
12		.2096	1.9204	2.7625	.2724		.2858
13		.1905	2.1262		.2743		
14	.04	.1905	2.332		.2629		.362
15	.0419	.1905	2.4348	2.6673	.2191	.362	.3239
16	.0419	.2286	2.4691	2.6863	.2305	.362	.3429
17	.0419	.3429	2.4006	2.6863	.242	.362	.3048
18	.0457	.381	2.2977	2.6673	.2362	.381	.4572
19	.0629	.5335	2.1948	2.3815	.2039	.724	.5716
20	.0686	.7621	.583	.6859	.0648	.724	.7621
21	.0724	.7811	.6173	.6859	.0686	.8002	.8573
22	.0762	.8002	.6516	.8764	.0686	.8192	.8192
23	.08	.8002	.6859	.8573	.08	.8573	.7811
24	1.086	1.3717	.8192	.6859	.8573	.1372	1.2384
Max	2.4768	2.3434	2.4691	2.7625	.8764	2.21	2.5911
Min	.0229	.1905	.2743	.3429	.0229	.1372	.2858
Avg	.7423	.9851	1.2149	1.2582	.3834	.4652	1.0636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184039 / M. SAKORE

Feeder No / Name : 202 / TARUKHEDELE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2667	.0419	.4382
2		.2858	.0381	.4191
3		.3048	.0381	.4191
4		.3048	.0419	.4382
5		.2858	.0457	.4572
6		.3048	.0419	.4382
7		.1715	.0362	.4001
8		2.553	.0248	.2401
9		.2915	.2477	.1715
10		.0095	.3239	.1524
11		.0095	.0953	.0953
12		.0114	3.1817	3.2388
13		.0152	3.5818	
14		.0171	3.6199	3.0674
15	.1905	.021	3.6389	3.4865
16	.2096	.0229	3.5818	3.3532
17	.2286	.0229	3.5437	3.315
18	.2667	.021	3.4294	3.1245
19	.3048	.0324	.4382	2.8769
20	.362	.0419	.4763	.4191
21	.381	.0438	.4572	.4572
22	.381	.0419	.4572	.4763
23	.362	.0457	.4572	.4763
24		.3429	.0419	.4382
Max	.381	2.553	3.6389	3.4865
Min	.1905	.0095	.0248	.0953
Avg	.2985	.2278	1.1617	1.2347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184039 / M. SAKORE

Feeder No / Name : 203 / TALWADE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.7621	.4191	.4115	.4001	.0667	.6859
2	.7621	.8002	.4001	.6516	.381	.0762	.724
3	.8192	.8383	.4001	.4115	.4191	.08	.7621
4	.8002	.9526	.4001	.4115	.4001	.0876	.8002
5	.8383	1.0669	.5144	.4458	.5335	.0953	.8764
6	1.6194	1.105	.5525	.4801	.6287	.1067	.9717
7	1.6575	1.7147	.5144	.4973	.6097	.1334	1.5242
8	1.8861	1.8099	.362	.4115	.5144	.16	1.7528
9	.1524	1.467	.3086	.4001	.0476		1.5051
10	.0248				.0343	.2286	.2286
11					.0229	.2286	.2858
12		.1905	1.2346	1.1812	.1315	.2286	.2667
13		.2096	1.3032		.1276	.2477	
14	.0267	.2096	1.2689		.1219	.2477	.2477
15	.0324	.2096	1.2689	1.1812	.1124	.2667	.2477
16	.0362	.2286	1.2689	1.3336	.1181	.3048	.2667
17	.0457	.2667	1.2003	1.3527	.1219	.3429	.3239
18	.04	.3048	1.1317	1.2765	.1143	.381	.4001
19	.0457	.4191	1.0288	.8573	.0914	.4572	.4382
20	.0419	.4572	.3601	.3429	.0381	.4572	.4382
21	.0381	.4382	.3944	.4191	.0419	.4382	.4954
22	.0381	.4382	.4115	.4191	.0381	.4382	.4763
23	.04	.4191	.4287	.4572	.0362	.4191	.362
24	.5906	.724	.4191	.4115	.4191	.6478	.6478
Max	1.8861	1.8099	1.3032	1.3527	.6287	.6478	1.7528
Min	.0248	.1905	.3086	.3429	.0229	.0667	.2286
Avg	.4913	.6833	.7087	.6677	.2293	.2670	.6403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184039 / M. SAKORE

Feeder No / Name : 204 / BHUSE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.0914	.9335
2		.4954	.0953	.9717
3		.4572	.1029	1.0098
4		.4954	.1105	1.0669
5		.743	.1219	1.2574
6			1.3813	1.3527
7		.8002	.1791	2.0005
8		.6859	.2039	1.8671
9		.0553	1.4861	1.6194
10		.0343	.2858	.3429
11		.0305	.3429	.3429
12		.1391	.3239	.3239
13		.1543	.362	
14		.1543	.3048	.3239
15	1.5432	.1448	.3239	.362
16	1.5813	.1372	.3429	.381
17	1.6956	.1448	.362	.381
18	1.6385	.1372	.4763	.5335
19	1.3336	.1048	.5906	.724
20	.6859	.0648	.6097	.724
21	.743	.0686	.6287	.7811
22	.743	.0648	.6287	.724
23	.724	.0648	.6097	.5906
24		.6097	.0876	.8764
Max	1.6956	.8002	1.4861	2.0005
Min	.6859	.0305	.0876	.3239
Avg	1.1876	.2764	.4188	.8474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184039 / M. SAKORE

Feeder No / Name : 205 / KARANJI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.381	1.4098	1.1317	1.3336	.0381	.4191
2	.3048	.3429	1.448	1.2346	1.3717	.0343	.4001
3	.3048	.3429	1.4861	1.3032	1.3527	.0343	.4001
4	.3239	.381	1.5623	1.406	1.3336	.0381	.4191
5	.3048	.4191	1.6956	1.5089	1.4861	.0419	.4382
6	.3429	.4382	2.191	1.6804	1.9433	.0438	.4382
7	.3239	.3429	2.6292	2.0748	2.4768	.0305	.3239
8	.2286	.2477	2.934	2.6578	2.8578	.0229	.2286
9	.0191	.2096	2.5377	2.8959	.2553	.1905	.1905
10	.0133	.1715	.1029		.0095	.0953	.1524
11		.1143	.12		.0114	.0953	.0762
12		3.1626	.1029	.1524	.0114	3.0674	3.296
13		2.9531	.1029		.0152	2.8769	
14	.2858	2.8959	.12		.0152	2.8959	3.2007
15	.2953	2.8197	.12	.1524	.0133	2.8959	3.315
16	.3086	2.6482	.1372	.1524	.0152	2.8769	3.2198
17	.3105	2.7244	.1543	.1524	.0152	2.8959	3.315
18	.2896		.1886	.2096	.0191	2.6673	2.8769
19	.2743		.2058	.2286	.0305	2.9531	2.5911
20	.0419	.362	.3086	.362	.0381	.362	.4001
21	.04	.362	.3258	.362	.0419	.381	.4191
22	.04	.362	.2743	.3048	.0419	.4001	.4572
23	.04	.3048	.2401	.2477	.0381	.4001	.4191
24	.3429	.381	1.1317	1.0802	1.4289	.0381	.4191
Max	.3429	3.1626	2.934	2.8959	2.8578	3.0674	3.315
Min	.0133	.1143	.1029	.1524	.0095	.0229	.0762
Avg	.2275	1.0167	.8970	.9649	.6732	1.0573	1.1920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184086 / MOHADI

Feeder No / Name : 201 / 11 KV MOHADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5685	.5853	2.2573	2.5309	2.4081	.5982	1.7406
2	.5708	.5838	2.3671	2.5149	2.5362	.5944	1.7352
3	1.7703	1.7223	2.4318	2.556	2.6673	.599	1.736
4	1.8001	.5952	2.5797	2.6521	2.9767	.6097	1.7871
5	1.8717	.6211	2.7641	2.7618	3.1291	.6203	1.8542
6	1.9365	.6501	2.9722	3.5376	3.4819	.6371	1.8831
7	1.7642	.6142	4.1968	4.382	4.8689	.5845	1.6949
8	1.3847	1.4426	5.4207	5.1037	5.8223	1.2696	1.3801
9	.4085	1.2003	2.1551	2.0714	2.4928	1.1805	1.2148
10	.4359	.397	.8444	.8612	.9252	1.0212	1.0487
11	.413	.9488	.9618	.9183	.333	1.4876	2.0104
12	5.0709	4.7569	.9655	.9404	.977	5.029	5.0686
13	1.7886	4.8361	.9785	.8406	.4367	5.8177	4.9687
14	1.659	4.5016	1.0326	.9001	.9885	5.5457	4.8704
15	1.4716	4.414	1.0357	.9077	.9831	5.4276	4.6974
16	1.4083	4.4384	1.0426	.9785	1.0029	5.5395	4.7302
17	1.5364	4.8285	1.0257	.9862	.4001	5.3148	4.7294
18	1.5623	4.9192	1.0807	1.0067	.3871	5.2827	4.7242
19	1.4594	2.3007	1.3191	1.3771	.4717	2.178	2.2504
20	.6081	1.7771	1.7505	1.7261	.6417	1.8343	1.7124
21	.6257	1.8549	1.8046	1.8732	.6897	1.8801	1.816
22	.66	1.8702	1.6956	1.5615	.6927	1.9372	1.9113
23	.6569	1.5577	1.2506	1.6849	.6706	1.906	1.8793
24	1.7505	1.8838	2.2641	2.5652	1.9158	.6127	1.7916
Max	5.0709	4.9192	5.4207	5.1037	5.8223	5.8177	5.0686
Min	.4085	.397	.8444	.8406	.333	.5845	1.0487
Avg	1.3826	2.2208	1.9249	1.9683	1.7458	2.3961	2.6348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184086 / MOHADI

Feeder No / Name : 202 / 11 KV WARVANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.137	1.1203	.9175	.9984	.8589	1.121	2.4059
2	1.1866	1.1667	.9175	.9922	.8703	1.1721	2.4158
3	2.367	2.3396	.9214	1.0342	.8946	1.1431	2.3822
4	2.4783	1.23	.9305	1.0982	.9404	1.1782	2.4166
5	2.713	1.3131	1.0021	1.1606	1.0136	1.2506	2.614
6	2.9058	1.4335	1.0349	1.1386	1.0098	1.3596	3.0407
7	3.7913	1.7817	.8863	1.0234	.8604	1.7353	4.0954
8	4.76	4.6342	.7583	.7674	.7628	4.6517	4.7653
9	2.412	2.5781	.6333	.6173	.647	2.5644	2.5362
10	1.4335	1.3847	.4489	.2888	.4359	1.6263	1.8076
11	.1905	.4138	.6721	.698	.2111	.3643	.4847
12	.3825	.4687	3.7822	3.706	4.0908	.3788	.5113
13	.2065	.4466	4.4459	3.9689	4.4818	.4603	.5601
14	.2172	.413	4.4239	3.9163	4.3111	.5038	.6058
15	.2401	.4123	2.2588	3.719	4.023	.548	.5914
16	.2507	.4755	4.2463	3.8279	3.9834	.5518	.5876
17	.2576	.5015	4.1785	3.9887	2.2923	.6181	.4976
18	.285	.5631	4.2928	3.9293	2.4348	.6447	.5441
19	.3231	.6561	2.3259	2.2565	2.2718	.7567	.6477
20	.4153	.8855	1.6766	1.156	1.0753	.9374	.903
21	.458	.9922	1.0502	.945	.4877	1.1051	.9625
22	.4626	1.0235	1.0647	.964	.5075	.8969	.9808
23	.4512	.9846	1.0837	.9678	.4984	.7476	1.102
24	2.0454	1.4319	1.012	.9839	1.3001	1.1843	2.3106
Max	4.76	4.6342	4.4459	3.9887	4.4818	4.6517	4.7653
Min	.1905	.4123	.4489	.2888	.2111	.3643	.4847
Avg	1.3071	1.1938	1.8735	1.8394	1.6776	1.1458	1.6570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184086 / MOHADI

Feeder No / Name : 203 / 11 KV MJP

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3414	.325	.6657	.6767	.6733	.3201	.5788
2	.3163	.3307	.6657	.6714	.6733	.3353	.599
3	.5883	.6367	.7011	.6855	.6527	.3346	.6581
4	.5696	.3372	.6786	.6912	.6649	.3262	.6124
5	.5635	.3372	.6569	.6843	.679	.341	.6223
6	.5933	.3342	.6623	.6767	.6577	.3376	.6394
7	.5956	.3285	.7011	.6508	.6604	.3399	.6162
8	.5903	.6062	.7057	.6436	.6585	.6314	.5914
9	.293	.6515	.6386	.6618	.6383	.5132	.4798
10	.2846	.3075	.5974	.6443	.5742	.6276	.5384
11	.2721	.5612	.5914	.6466	.3014	.6314	.58
12	.1189	.5948	.5971	.62	.6374	.6432	.5582
13	.0728	.5933	.6314	.65	.6329	.4493	.5975
14	.1101	.5849	.6695	.671	.6279	.3658	.6188
15	.1395	.5651	.6767	.6992	.6283	.4427	.674
16	.128	.5876	.6359	.7248	.6508	.2839	.6489
17	.1623	.6585	.7297	.7183	.3387	.2717	.6234
18	.317	.6241	.6996	.7198	.3098	.5266	.4275
19	.3403	.6275	.7106	.7167	.325	.5906	.7922
20	.3281	.6272	.7388	.6272	.3224	.5914	.6855
21	.3582	.6112	.7579	.5941	.3147	.5792	.6672
22	.3551	.6672	.3589	.6451	.3159	.6131	.551
23	.3361	.7145	.3528	.6634	.3315	.6245	.783
24	.6581	.6527	.7145	.6562	.6714	.3205	.5468
Max	.6581	.7145	.7579	.7248	.679	.6432	.7922
Min	.0728	.3075	.3528	.5941	.3014	.2717	.4275
Avg	.3514	.5360	.6474	.6683	.5392	.4600	.6121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184086 / MOHADI

Feeder No / Name : 204 / 11 KV KURNOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4191	.6859	.6097		.1143
2			.4191	.6859	.6097		.1143
3	.1524	.1524	.4763	.6668	.6478		.1143
4	.1524		.5144	.6668	.724		.1143
5	.1524		.6097	.6478	.8002		.1143
6	.1524		.6668	.7621	.9145		.1143
7	.1143		1.2765	1.1812	1.4861		.0762
8	.0381	.1143	1.5623	1.5242	1.7147	.1143	.0762
9		.1143	.0381	.0381	.0381	.0762	.0762
10			.0572	.0762	.0572	.0381	.0381
11		.3429	.0762	.0762		.0381	.5335
12	1.6766	1.4861	.0953	.0762	.0572	1.8671	1.7147
13		1.467	.0953	.0762	.0572	1.6194	1.6766
14		1.3336	.1143	.0762	.0572	1.3908	1.6194
15		1.3336	.1143	.0381	.0572	1.4861	1.5623
16		1.3717	.1143	.0381	.0762	1.6766	1.5242
17		1.4289	.1143	.0381		1.5623	1.5242
18		1.467	.1334	.0762		1.5242	1.448
19		.0381		.1143		.0572	.0953
20		.1524	.2096	.1715		.1143	.1715
21		.1524	.2096	.1905		.1524	.1905
22		.1524	.1715	.1524		.1524	.1524
23		.4001	.4191	.5144		.1524	.1524
24	.1905	.1524	.4191	.6859	.5716		.1524
Max	1.6766	1.4861	1.5623	1.5242	1.7147	1.8671	1.7147
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.3286	.6859	.3620	.3858	.5299	.7514	.5612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184086 / MOHADI

Feeder No / Name : 205 / 11 KV SHAVANAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4763	.362	.3429		.6668
2			.4763	.362	.3429		.7049
3	.9526	.9526	.4763	.4001	.362		.7621
4	1.0479		.4763	.4191	.4572		.8192
5	1.1431		.4763	.4572			.8954
6	1.2574		.5144	.4382	.4572		1.0479
7	1.4861		.4191	.381	.3429		1.5242
8	1.5813	1.6956	.381	.2477	.2286	1.5242	1.7147
9		.0953	.2477	.2096	.2096	.0762	.1143
10			.1905	.1524	.1715	.1334	.1334
11		.1715	.1524	.4191		.1524	.1334
12	.2096	.1905	1.6385	1.2955	1.3527	.1715	.1524
13		.2096	1.5813	1.2193	1.3527	.1715	.1524
14		.2286	1.5242	1.1431	1.4289	.1905	.1715
15		.2286	1.4289	1.2193	1.2384	.1905	.1715
16		.2477	1.5623	1.2955	1.2384	.1905	.1905
17		.2477	1.6385	1.3717		.2096	.2286
18		.3048	1.2955	1.4289		.2096	.2096
19		.381		.1715		.2858	.3048
20		.5144	.4191	.362		.4191	.4191
21		.5525	.4572	.4572		.4763	.4572
22		.5144	.4191	.4191		.4191	.4572
23		.4763	.381	.4001		.381	.4191
24	.9907	.8573	.4763	.362	.381		.7049
Max	1.5813	1.6956	1.6385	1.4289	1.4289	1.5242	1.7147
Min	.2096	.0953	.1524	.1524	.1715	.0762	.1143
Avg	1.0836	.4628	.7438	.6247	.6605	.3251	.5231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184086 / MOHADI

Feeder No / Name : 206 / PALKHED INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9145	.9907	.8383		1.0288
2			.9526	1.0288	.8383		1.0669
3	.7621	1.3336	.9907	1.0288	.8002		1.1431
4	.8002		.9145	.9907	.7621		1.1812
5	.8002		.9526	1.0288	.7621		1.2193
6	.7621		.8764	.9526	.8002		.9526
7	.7621		.9526	.9145	.9907		.9907
8	.6859	.9907	1.0669	.9907	1.2574	1.105	1.0669
9		1.1812		1.0669	1.3717	1.5242	1.1431
10			1.0288	1.1431	.9907	1.1812	1.1812
11		.9907	1.0288	1.1431		1.0669	1.2193
12	1.1812	1.2955	1.1812	1.0669	1.1812	1.2193	1.3717
13		1.2574	1.3336	1.0669	1.1812	1.4098	1.3336
14		1.3336	1.4861	1.1812	1.1812	1.6385	1.3717
15		1.3336	1.6004	1.448	1.1812	1.4861	1.4861
16		1.3717	1.5623	1.6385	1.1812	1.6385	1.4098
17		1.6385	1.5242	1.6766		1.5813	
18		1.3717	1.4289	1.5623		1.6194	1.5242
19		1.3717	1.2955	1.5623		1.5623	1.4861
20		1.3336	1.2384	1.3336		1.1812	1.3336
21		1.2384	1.1812	1.0669		1.3336	1.2955
22		1.1812	.362	.9907		1.2574	
23		1.1812	.3429	.9145		1.3336	1.1431
24	.8383	1.1431	.8383	.9907	.8764		1.1431
Max	1.1812	1.6385	1.6004	1.6766	1.3717	1.6385	1.5242
Min	.6859	.9907	.3429	.9145	.7621	1.0669	.9526
Avg	.8240	1.2675	1.0893	1.1574	1.0121	1.3836	1.2314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184214 / Aurangpur sub stn

Feeder No / Name : 201 / Mahajanpur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.6859	.4877	.6878	.6687	.5906	.724
2	.6478	.6859	.663	.6878	.6687	.6097	.724
3	.6859	.6859	.7522	.6697	.7545	.6859	.724
4	.6859	.724	.7655	.6878	.9259	.7049	.7621
5	.724	.8002	.8002	.7602	1.1145	.743	.8002
6	.8002	.8383	1.0682	.8954	1.3375	.5716	.8383
7	.6859	.6478	1.1092	1.4575	1.4403	.5335	.6097
8	.4001	.4954	1.2492	1.5604	1.5604	.4572	.4572
9	.3239	.381	.5716	.2096	.2286	.362	.3239
10	.2286	.3048	.1905	.2286	.1715	.3048	.2667
11	.3605	.442	.1524	.1715	.2096	.4915	.6516
12	.852	1.0277	.1715	.2096	.2096	1.0814	1.182
13	.852	.9259	.1715	.2096	.2096	1.0486	.9412
14	.852	.9231	.3048	.2096	.2858	1.0159	.9955
15	.8192	.9555	.381	.2096	.2858	1.0814	1.0498
16	.9831	.9835	.2096	.2286	.3239	1.1469	1.1222
17	1.0486	.9374	.2096	.2286	.3239	1.1797	1.3032
18	1.065	.9922	.2096	.2477	.3429	1.1469	1.2851
19	.3429	.2858	.4191	.4191	.4954	.3239	.2858
20	.6859	.4001	.6287	.4572	.6859	.6478	.6478
21	.6859	.5525	.5716	.5335	.7621	.724	.7049
22	.6859	.5716	.5335	.5716	.743	.6859	.6097
23	.6859	.4144	.5611	.2572	.7049	.6859	.6668
24	.6287	.6859	.4973	.5487		.6859	.6478
Max	1.065	1.0277	1.2492	1.5604	1.5604	1.1797	1.3032
Min	.2286	.2858	.1524	.1715	.1715	.3048	.2667
Avg	.6816	.6811	.5283	.5145	.6284	.7295	.7635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184214 / Aurangpur sub stn

Feeder No / Name : 202 / 11kv Bhendali SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8688	.7209	.7621	.743	.724	.6316	.7209
2	.9955	.7209	.7621	.743	.724	.779	.7209
3	1.0317	.9389	.7811	.7621	.724	.8642	.9503
4	1.1222	1.073	.8192	.8002	.8002	1.1069	1.1797
5	1.267	1.4419	.8383	.8192	.7621	1.5912	1.3435
6	1.5043	1.643	.7811		.8002	2.0309	1.4419
7	2.4188	2.5149	.7621	.6859	1.0479	2.1643	2.4249
8	2.8807	2.6155	.6097	.5906	.5906	2.1464	2.6543
9	.1334	.2286	.5716	.4763	.5335	.1094	.2096
10	.1143	.3239	.381	.4191	.4954	.1524	.2096
11	.2286	.362	.5792	.1715	.7449	.2286	.3239
12	.2286	.381	2.5701	1.8347	1.2266	.3048	.4382
13	.3429	.4001	2.6244	1.9204	1.6404	.3048	.4572
14	.381	.4191	2.4615	1.989	1.7695	.3239	.4763
15	.4191	.5716	2.19	2.1605	1.6975	.4191	.4763
16	.4382	.5716	2.2262	2.1948	1.8564	.4191	.4954
17	.4763	.6097	2.4615	2.2291	1.933	.4572	.5335
18	.5716	.6668	2.3348	2.1434	1.8185	.6097	.5716
19	.724	.8764	.1905	.2858	.2477	.6478	.6478
20	.7621	.8383	.5906	.724	.6478	.6478	.7049
21	.7621	.7811	.6287	.743	.6478	.6859	.743
22	.6478	.8192	.6668	.8002	.6859	.6668	.724
23	.4588	.8002	.743	.7811	.3041	.3605	.6516
24	.6697	.6554	.8192	1.448		.4877	.6226
Max	2.8807	2.6155	2.6244	2.2291	1.933	2.1643	2.6543
Min	.1143	.2286	.1905	.1715	.2477	.1094	.2096
Avg	.8103	.8739	1.1731	1.1072	.9749	.7558	.8217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184214 / Aurangpur sub stn

Feeder No / Name : 203 / 11kv bagalwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.3563	.2534	.3772	.2286	.2667
2	.2286	.2286	.373	.2353	.3772	.2286	.2667
3	.2667	.2286	.4049	.2534	.4115	.1905	.3048
4	.3239	.2667	.4321	.2715	.4115	.2096	.4191
5	.362	.3429	.4687	.3077	.583	.2286	.4191
6	.4001	.4191	.5304	.3582	.583	.2667	.4572
7	.3429	.3429	.5668	.703	.6859	.2667	.3048
8	.2096	.2096	.6562	.9259	.7373	.1905	.1905
9	.1143	.1524	.0762	.0762	.0762	.1524	.1334
10	.0762	.1334	.0762	.0381	.0762	.1143	.1143
11	.1638	.0762	.0572	.0762	.1143	.1638	.2172
12	.4915	.4641	.0953	.0762	.1334	.6554	.6447
13	.5898	.4801	.1143	.1143	.1143	.6882	.543
14	.5898	.5138	.0953	.1334	.1143	.6226	.5068
15	.5407	.5182	.0953	.1143	.1334	.6882	.5068
16	.6882	.5506	.0953	.1143	.1334	.7537	.543
17	.7537	.5935	.1524	.1143	.1524	.8192	.7964
18	.7209	.5792	.1524	.1143	.1905	.8192	.7602
19	.1524	.1143	.2286	.0953	.2096	.1524	.1334
20	.1905	.1905	.3048	.2286	.3239	.1905	.3239
21	.2286	.3239	.2286	.2286	.3048	.2286	.2858
22	.2286	.2858	.1905	.1905	.2477	.2667	.2858
23	.2286	.0762	.1086	.0686	.2286	.2477	.2477
24	.2286	.2286	.1524	.3772		.2286	.2477
Max	.7537	.5935	.6562	.9259	.7373	.8192	.7964
Min	.0762	.0762	.0572	.0381	.0762	.1143	.1143
Avg	.3471	.3145	.2505	.2279	.2922	.3584	.3716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184214 / Aurangpur sub stn

Feeder No / Name : 204 / Kadwagoda NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0328	.0305	.0362	.0343	.0324	.0328
2	.0362	.0328	.0332	.0362	.0343	.0829	.0328
3	.0362	.0328	.0312	.0362	.0343	.0324	.0328
4	.0362	.0328	.0324	.0362	.0171	.0312	.0328
5	.0543	.0328	.0339	.0362	.0171	.0328	.0328
6	.0358	.0328	.0301	.0179	.0171	.0166	.0164
7	.0175	.0164	.016	.0171	.0171	.0158	.0164
8	.0171	.0164	.017	.0171	.0171	.0168	.0164
9	.0164	.0164	.017	.0171	.016	.016	.0181
10	.0164	.0152	.0181	.0171	.017	.0328	.0905
11	.0164	.017	.0724	.0514	.0469	.0492	.0543
12	.0328	.0166	.0543	.0514	.0166	.0328	.0537
13	.0328	.016	.0543	.0343	.016	.0328	.0181
14	.0328	.0164	.0543	.0171	.0156	.0328	.0181
15	.0492	.0171	.0543	.0171	.0328	.0492	.0362
16	.0492	.017	.0572	.0171	.0309	.0492	.0362
17	.0492	.0166	.0543	.0171	.0158	.0492	.0543
18	.0328	.0166	.0543	.0171	.0162	.0492	.0181
19	.0328	.0339	.0543	.0171	.032	.0328	.0362
20	.0328	.032	.0362	.0171	.0332	.0492	.0362
21	.0328	.0339	.0381	.0171	.0324	.0492	.0362
22	.0328	.0332	.0543	.0343	.0309	.0328	.0362
23	.0164	.0343	.0362	.0343	.0332	.0328	.0362
24	.0362	.0164	.0301	.0343		.032	.0328
Max	.0543	.0343	.0724	.0514	.0469	.0829	.0905
Min	.0164	.0152	.016	.0171	.0156	.0158	.0164
Avg	.0326	.0241	.0402	.0268	.0250	.0368	.0344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184245 / KARANJGAON

Feeder No / Name : 201 / 11 KV KARANJGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5592	1.5074	1.4723	1.6461	1.6461		.6415
2	1.5592	1.4746	1.4563	1.6461	1.6461	.6344	.6415
3	1.5592	1.4746	1.4723	1.6461	1.6632		.6588
4	1.8427	1.4746	1.5775	1.6461	1.6975	.7202	.6935
5	2.1262	1.6804	1.749	1.749	2.0062	.7888	.7108
6	2.7286	2.0233	1.9547	2.0919	2.2119		.7628
7	2.826	2.332	2.5034	2.4006	2.5377	.6516	.6762
8	2.6063	2.4143	2.5377	2.6749	2.4006	.4115	.4161
9	2.0405	2.2382	2.2291	2.3663	2.3834	.3429	.2427
10	.3429	.3086	.2743	.2743	.3258	.3086	.2601
11		.2915	.2743	.2915	.3086	.2743	.2774
12		.3353	.2683	.2401	.2915	2.7435	2.6006
13		.3429	.3086	.2743	.2915	2.6578	2.8086
14	.3391	.3429	.3086	.3429	.2572	2.572	2.8086
15	.3391	.3429		.3258	.2401	2.6063	2.8086
16	.3772	.3429	.3086	.3467	.2743	2.6235	2.8086
17	.3086	.3601		.3258	.3086	2.6406	2.8086
18	.3429	.3772		.3601	.2915	2.5377	2.6006
19	.4458	.3944	.4115	.4458	.3944	2.4863	2.4099
20	.6001	.5144	.6001	.6001	.583	.5316	.5721
21	.6001	.5658	.6001	.6001	.583	.6001	.6588
22	.583	.5959	.6173	.583	.6173	.6001	.6762
23	.583	.6135	.5959	.583	.6344	.6344	.6588
24	1.5089	1.3717	1.4723	1.6461	1.6461	.6344	.6415
Max	2.826	2.4143	2.5377	2.6749	2.5377	2.7435	2.8086
Min	.3086	.2915	.2683	.2401	.2401	.2743	.2427
Avg	1.2009	.9883	1.0949	1.0461	1.0517	1.3334	1.2851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184245 / KARANJGAON

Feeder No / Name : 202 / Shingave

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2103	.1949	.2058	.2058		.3294
2	.1886	.2058	.1886	.2058	.2058		.3294
3	.1928	.2058	.1886	.2058	.2058		.3467
4	.208	.2058	.2058	.2058	.2058		.3988
5	.2229	.2058	.2229	.2058	.2572		.5201
6	.2058	.2058	.2401	.2743	.2401		.7282
7	.1715	.2401	.1715	.2058	.2058	.7545	.8495
8	.1372	.1715	.1543	.1372	.1543	.8059	.9882
9	.0678	.12	.1029	.1029	.0514	.6859	.8322
10	.0678	.1029	.1029		.0514	.12	.104
11	.0686	.0857	.1029		.0514	.12	.0867
12	.6859	.8059	.7202	.6687	.7716	.0857	.0867
13	.7122	.823	.7362	.6859	.7545	.0686	.0867
14	.6783	.7716	.7011	.6859	.7716	.0857	.0867
15	.6859	.7202	.6859	.703	.7888	.0857	.104
16	.7202	.6516	.6859	.7202	.7888	.0857	.104
17	.7545	.7011	.6001	.7716	.8573	.0857	.104
18	.7202	.7186	.6516	.8059	.8059	.12	.1214
19	.6859	.6516	.5144	.5658	.6687	.1543	.1214
20	.2401	.6516	.2103	.1886	.1886	.1886	.208
21	.2229	.2058	.2103	.2058	.1886	.2058	.2254
22	.2229	.2058	.2454	.2058	.2058	.2058	.2254
23	.2229	.208	.2279	.2058	.2058	.1886	.208
24	.1949	.2126	.1928	.2058	.2058		.3294
Max	.7545	.823	.7362	.8059	.8573	.8059	.9882
Min	.0678	.0857	.1029	.1029	.0514	.0686	.0867
Avg	.3599	.3870	.3441	.3804	.3765	.2380	.3135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184245 / KARANJGAON

Feeder No / Name : 203 / Chapadgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0343	.0343	.0343	.0343		1.6644
2	.0351	.0343		.0343	.0343		1.6644
3	.0351	.0343	.0343	.0343	.0343		1.6817
4	.0351	.0343	.0343	.0343	.0343		1.6991
5	.0347	.0343	.0347	.0343	.0343		1.7164
6	.0343	.0343	.0343	.0343	.0343		1.7164
7	.0343	.0343	.0343	.0343	.0343	1.8519	1.7164
8	.0171	.0343	.0343	.0343	.0171	1.9376	1.8378
9	.0171	.0343	.0343	.0343	.0171	1.9204	1.6817
10	.017	.0343	.0343	.0343	.0171	.0343	
11	.017		.0343		.0171	.0343	
12	2.1262	.0343	2.0576	2.0748	2.1091	.0343	
13	2.0919	1.8861	2.0919	2.0062	2.1262	.0171	
14	2.0348	1.9281	2.0919	2.0748	2.0919	.0343	
15	2.0119	1.949	2.0576	2.0919	2.1091	.0017	
16	1.989	1.8861	2.0576	2.1262	2.1262	.0171	
17	1.9547	1.9033	1.989	2.1091	2.0748	.0343	
18	1.9204	1.9204	1.9204	2.0576	2.0062	.0034	
19		1.9033	1.9719	1.9376	1.9547	.0347	
20	1.8861	.0343	.0343	.0343	.0343	.0347	
21	.0343	.0343	.0343	.0343	.0343	.0347	
22	.0351	.0343	.0343	.0343	.0171		
23	.0351	.0343	.0343	.0343	.0171	.0347	
24	.0343	.0351	.0347	.0343	.0343		1.6817
Max	2.1262	1.949	2.0919	2.1262	2.1262	1.9376	1.8378
Min	.017	.0343	.0343	.0343	.0171	.0017	1.6644
Avg	.7159	.6055	.7284	.7388	.7102	.3787	1.706

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 184246 / DIXI

Feeder No / Name : 201 / 11 KV DIXI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.6401	.9755	.9414	1.0669	.6706	.6859
2	.5792	.6401	.9907	1.0031	1.0822	.6706	.6706
3	.5792	.6554	.945	1.0185	1.1126	.6859	.7011
4	.5639	.6706		1.0648	1.1126	.6859	.6706
5	.5792	.9907	1.0517	1.2191	1.4784	.6859	.6859
6	.6401	.6706	1.448	1.4661	1.9052	.6706	.6706
7	.6249	.5639		2.4537	2.5301	.5944	.6097
8	.5144	.4572	2.6063	2.7932	2.8045	.4572	.503
9	.4287	.3963	2.2405	2.4691	2.6216	.381	.4572
10	.381	.381	.2932	.2896	.3048	.2896	.4268
11	.2896	.3048	.3395	.3048	.3658	.3048	.3353
12	2.6978	2.0424	.3549	.3048	.381	2.774	2.8349
13	2.6825	2.4234	.3704	.381		2.8502	2.8197
14		2.2558	.4167	.3963	.442	2.6063	2.6825
15	2.5149	2.1643	.463	.381	.4268	2.4691	2.5453
16	2.2558	2.1338	.4167	.4268	.3963	2.5453	2.5911
17	2.5453	2.1948	.4475	.442	.442	2.4844	2.6673
18	2.652	2.0881	.4321	.4268	.4268	2.5606	2.5149
19	2.2253	1.9052	.5864	.5944	.5944	2.271	2.2405
20	.7011	.7621	.7407	.7164	.7773	.823	.7621
21	.7468	.7621		.7011	.7926	.823	.7773
22	.7316	.7468	.7253	.6859	.7164	.7926	.7621
23	.6706	.5944	.5864	.5944	.7011	.7621	.7468
24	.6516	.6401	.9297	.8951	1.0364	.6859	.7011
Max	2.6978	2.4234	2.6063	2.7932	2.8045	2.8502	2.8349
Min	.2896	.3048	.2932	.2896	.3048	.2896	.3353
Avg	1.1691	1.1285	.8267	.9154	1.0225	1.2727	1.2943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 187003 / OZAR

Feeder No / Name : 202 / MES 1

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1753	.1753	.1867	.1715	.141	.1753
2	.1753	.1524	.16	.1829	.1638	.1372	.1677
3	.141	.1372	.141	.1524	.1372	.1372	.141
4	.141	.1372	.1372	.1486	.1372	.1372	.141
5	.141	.1372	.1372	.1486	.1372	.1715	.141
6	.141	.1372	.1372	.1448	.1372	.1753	.141
7	.1296	.1296	.1296	.1372	.1372	.1715	.1296
8	.1029	.0991	.4763	.6897	.4001	.5639	.1067
9	.2058	.0991	1.2422	1.3603	1.025	1.0898	.1296
10	1.044	.1448	1.2993	1.2955	1.2727	1.2269	.301
11	1.086	.1638	1.0059	1.0936	1.1393	1.0174	.282
12	.9907	.1677	1.3108	1.2422	1.2727	1.1927	.3315
13	1.1355	.1715	1.2536	1.1507	1.166	1.307	.3391
14	.9183	.1562	1.2689	1.1622	1.307	1.1927	.2934
15	.2858	.1219	1.1279	.9755	1.0593	1.0326	.1638
16	.1867	.1257	.4992	.522	.2782	.5449	.1296
17	.1981	.1257	.4877	.9107	.4763	.5754	.1257
18	.1791	.1296	.5182	.884	.5449	.602	.1219
19	.1181	.1296	.4687	.6592	.442	.442	.1219
20	.141	.141	.4077	.3696	.2934	.2782	.1448
21	.1448	.1448	.2248	.1981	.2362	.2096	.141
22	.1715	.1677	.2172	.1791	.1715	.2248	.1753
23	.1791	.1791	.202	.1829	.1562	.2286	.1753
24	.1753	.1753	.1867	.1753	.141	.1981	.1753
Max	1.1355	.1791	1.3108	1.3603	1.307	1.307	.3391
Min	.1029	.0991	.1296	.1372	.1372	.1372	.1067
Avg	.3461	.1437	.5506	.5897	.5168	.5416	.1789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 187003 / OZAR

Feeder No / Name : 203 / HAL TOWN SHIP

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8459	.884	.9145	.9145	.9069	1.0288	.9831
2	.7773	.8459	.8307	.8383	.8535	.9221	.8916
3	.7468	.7926	.7926	.7926	.8154	.8612	.8459
4	.7164	.7621	.7621	.7773	.7849	.823	.823
5	.724	.7468	.7697	.7697	.7773	.8078	.8078
6	.8154	.7697	.8688	.8383	.8459	.884	.8078
7	1.0059	.8002	1.0822	1.105	1.1203	1.0517	.8764
8	.945	.823	1.0136	.9983	1.0212	.9069	.8459
9	.8154	.7926	.8688	.8459	.9069	.8078	.8688
10	.7621	.7621	.8002	.823	.8383	.7773	.8383
11	.7773	.724	.7697	.7697	.7926	.7926	.8307
12	.7468	.7087	.8383	.7392	.8383	.7545	.8078
13	.7316	.7087	.8002	.7697	.823	.8002	.8078
14	.6783	.6935	.7468	.7392	.724	.7621	.7621
15	.6554	.7164	.7545	.7164	.6859	.7849	.7926
16	.7011	.7011	.724	.7697		.7926	.8002
17	.7392	.7087	.4344	.8383		.8535	.7926
18	.7087	.7468	.442	.8459		.8383	.8154
19	.7545	.7545	.8612	.8535		.9069	.8078
20	1.1507	1.1203	1.2041	1.2041		1.2269	1.1279
21	1.166	1.1355	1.2498	1.2651		1.2651	1.1279
22	1.0822	1.1355	1.2498	1.1888		1.2727	1.1507
23	1.044	1.1279	1.1736	1.1507	.221	1.1584	1.1126
24	.9983	1.0288	1.0898	1.0364	1.1888	1.1126	1.0745
Max	1.166	1.1355	1.2498	1.2651	1.1888	1.2727	1.1507
Min	.6554	.6935	.4344	.7164	.221	.7545	.7621
Avg	.8370	.8329	.8767	.8996	.8320	.9247	.8916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 187003 / OZAR

Feeder No / Name : 204 / JAULKE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.9433	1.7833	1.5318	1.9052
2	1.8061	1.7909	1.6842	1.5699	1.9204
3	1.6918	1.7375	1.6385	1.5546	1.8747
4	1.6994	1.7223	1.6156	1.5089	1.768
5	1.608	1.6918	1.6004	1.4632	1.7528
6	1.5318	1.6613	1.5699	1.4403	1.7528
7	1.5089	1.6156	1.5013	1.4632	1.669
8	1.4708	1.4556	1.4098	1.448	1.4708
9	1.5013	1.5775	1.5927	1.5927	1.5927
10	1.7299	1.7452	1.6918	1.9814	1.9052
11	1.9814	1.89	2.0729	2.4463	2.1795
12	2.1414	2.0881	2.2481	2.4768	2.3167
13	2.4691	2.0957	2.2329	2.3929	2.2862
14	2.4082	1.9814	2.1186	2.1795	2.0957
15	2.1491	1.9662	1.9814	2.271	1.7833
16	2.1262	2.0043		2.431	.3887
17	1.9814	2.0576		2.5606	1.9966
18	2.1567	2.2024		2.5758	2.1262
19	2.0957	2.0729		2.2253	1.9509
20	1.8671	1.8519		2.0119	1.7452
21	1.7375	1.6994		1.8519	1.6537
22	1.7147	1.7147		1.7833	1.608
23	1.8671	1.8442	.1372	1.9357	1.6994
24	1.89	1.8823	1.4556	1.9357	1.7756
Max	2.4691	2.2024	2.2481	2.5758	2.3167
Min	1.4708	1.4556	.1372	1.4403	.3887
Avg	1.8750	1.8455	1.6667	1.9430	1.8007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 187003 / OZAR

Feeder No / Name : 205 / DIXI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	1.6156	1.8214	1.9814	.8993	.8764
2	.8688	1.6766	1.8519	2.0195	.8993	.8764
3	.884	1.6766	1.8366	2.05	.9145	.8993
4	.9145	1.5394	1.8366	2.0881	.9297	.9297
5	.9678	1.6918	1.9433	2.1719	1.0212	.9678
6	1.0364	1.9433	2.1948	2.2177	1.0974	1.0745
7	1.0745	2.271	2.5606	2.6139	1.1355	1.1355
8	.9983	3.1398	3.5208	3.6504	.8764	.9374
9	.7392	3.5589	3.9933	3.818	.6097	.6706
10	.5106	3.2617	3.6656	3.7266	.4801	.5106
11	.442	.3658	.381	.3582	.4191	.4572
12	1.8138	.3125	.3277	.3353	.3734	.2134
13	3.216	.2591	.3277	.3277	3.8104	2.9874
14	3.3074	.3048	.3277	.3277	3.7647	3.5894
15	3.1093	.2972	.3353	.2972	3.6732	3.4979
16	2.8121	.3125	.3429	.2743	3.4827	3.5818
17	3.0026	.282	.3658		3.437	3.5208
18	3.2998	.3658	.3582	.3658	3.7799	3.597
19	3.2846	.3887	.3887	.4496	3.6961	3.5132
20	2.8197	.7164	.663	.7392	3.2693	2.5682
21	.7621	.8383	.8154	.884	.7849	.7621
22	.8002	.8383	.8307	.9069	.8078	.7849
23	.823	.8688	.8459	.9526	.8916	.8764
24	1.5242	.8535	1.768	.9526	.8916	.8612
Max	3.3074	3.5589	3.9933	3.818	3.8104	3.597
Min	.442	.2591	.3277	.2743	.3734	.2134
Avg	1.6620	1.2241	1.3876	1.4569	1.7477	1.6537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 187003 / OZAR

Feeder No / Name : 206 / AMBHEHILL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	1.1317	1.1888	1.3527	1.2384
2	.9335	1.1469	1.2574	1.2384	1.1965
3	1.0593	1.0517	1.1203	1.2384	1.1317
4	.9335	.9717	1.086	1.2117	1.0136
5	.8535	1.0174	1.105	1.1431	1.0974
6	.8878	.9945	1.0174	1.0326	1.0974
7	.8612	1.0136	1.1393	1.1012	.9793
8	.9069	1.0783	1.0555	.9869	.8383
9	1.0707	1.0936	.8993	.9526	.7659
10	1.2193	1.2574	1.1012	1.0021	.9602
11	1.3032	1.1736	1.2765	1.1927	1.1965
12	1.3375	1.2041	1.2308	1.1736	1.2346
13	1.2231	1.0593	1.2689	1.1241	1.3756
14	1.1622	1.1393	1.3222	1.0936	1.3908
15	1.2231	1.2917	1.1774	1.0174	1.2803
16	1.2041	1.2841		1.0631	1.3756
17	.9983	1.2384		1.0364	1.2003
18	1.1698	1.2041		1.2308	1.0631
19	1.1126	1.3679		1.1622	.9793
20	1.3108	1.3184		1.0555	1.0288
21	1.3565	1.2498		1.0555	1.0174
22	1.3489	1.1546		1.0136	.8154
23	1.2384	1.0479	.0953	.8764	.7697
24	1.2003	1.2422	1.406	1.1088	.8993
Max	1.3565	1.3679	1.406	1.3527	1.3908
Min	.8535	.9717	.0953	.8764	.7659
Avg	1.1171	1.1555	1.1028	1.1026	1.0811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 187003 / OZAR

Feeder No / Name : 207 / Ozar

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6978	2.9721	3.0788	2.9416	3.1474	3.0407	3.2312
2	2.5377	2.7282	2.8959	2.7816	2.9721	2.8807	2.9569
3	2.4844	2.652	2.8045	2.6978	2.8807	2.7892	2.9874
4	2.4463	2.5835	2.7816	2.6749	2.8578	2.7511	2.9721
5	2.4996	2.5987	2.8121	2.713	2.8578	2.5606	2.9569
6	2.6825	2.7435	3.0255	2.9645	3.0864	2.8426	3.0864
7	3.0483	3.2998	3.4827	3.5589	3.4675	3.2998	3.5818
8	3.0102	3.7494	3.4827	3.7494	3.4446	3.3455	3.9171
9	3.1703	3.5208	3.4522	3.4217	3.3532	3.4141	3.7875
10	3.2007	3.5513	3.4598	3.2007	3.5132	3.5284	3.6961
11	3.1169	3.5665	3.6351	3.2388	3.5284	3.6961	3.8485
12	2.4615	3.4598	3.5132	3.2007	3.4217	3.5437	3.6351
13	1.4403	3.3532	3.3074	3.1321	3.1779	3.437	3.6275
14	1.3946	3.0559	3.0864	2.9264	3.0559	3.2769	3.3532
15	1.9509	2.9645	2.9188	2.934	2.9492	3.1017	2.9874
16	2.5987	3.0178	2.7511	2.9416	2.9492	3.2236	3.2465
17	2.652	3.1779	2.7892	3.1474	3.1779	3.3989	3.4522
18	2.9416	3.597	3.3608	3.3989	3.4217	3.6961	3.8637
19	3.5208	3.8028	3.6504	3.4675	3.719	3.6961	3.9552
20	3.9095	4.1	4.0314	3.8637	4.2372	4.1838	4.3667
21	3.879	3.9247	3.9704	3.94	4.1457	4.1305	4.1686
22	3.6046	3.6885	3.719	3.6808	3.7647	3.8714	3.8637
23	3.3684	3.4751	3.5056	3.5208	3.4522	3.6656	3.6199
24	3.2769	3.3074	3.2922	3.3608	3.2693	3.5056	3.5589
Max	3.9095	4.1	4.0314	3.94	4.2372	4.1838	4.3667
Min	1.3946	2.5835	2.7511	2.6749	2.8578	2.5606	2.9569
Avg	2.8289	3.2871	3.2836	3.2274	3.3271	3.3700	3.5300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

OZAR (R) SUBDN[274] BU 0469

Substation No/ Name :- 187003 / OZAR

Feeder No / Name : 209 / MES 2

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3868	.4125	.421	.2782	.4201	.4449	.4439
2	.3515	.3887	.3734	.2534	.4001	.4058	.402
3	.3286	.3744	.362	.3591	.3829	.3877	.3829
4	.322	.3591	.3525	.3344	.3696	.3744	.3591
5	.3115	.3487	.3372	.3163	.362	.3639	.3534
6	.3172	.3401	.3429	.3439	.3868	.3953	.3582
7	.3353	.341	.4792	.4687	.5011	.4801	.362
8	.3553	.3477	.4201	.423	.4525	.4363	.3496
9	.3696	.3506	.3296	.3372	.3487	.341	.3534
10	.3629	.3696	.3677	.3429	.381	.3429	.3915
11	.3696	.3858	.3763	.3515	.421	.3753	.3934
12	.3668	.2134	.3763	.3629	.4106	.3877	.3744
13	.3668	.0981	.3763	.3467	.4296	.3887	.3467
14	.3496	.2477	.3963	.3544	.422	.3858	.3696
15	.3334	.3753	.3668	.3648	.4468	.3944	.3553
16	.3363	.3668	.3515	.3829		.4296	.3515
17	.3391	.3429	.14	.3563	.4592	.3972	.3525
18	.3363	.3448	.2677	.3601	.462	.3915	.3572
19	.3582	.3572	.2629	.3953	.4096	.3849	.3706
20	.4677	.4315	.3496	.4849	.4963	.4801	.463
21	.5192	.5011	.3744	.5306	.5211	.5144	.4954
22	.4963	.5316	.382	.5306	.5344	.5049	.5106
23	.4963	.5239	.3648	.522	.5335	.5087	.5106
24	.4601	.462	.3353	.4887	.5011	.4887	.4792
Max	.5192	.5316	.4792	.5306	.5344	.5144	.5106
Min	.3115	.0981	.14	.2534	.3487	.341	.3467
Avg	.3765	.3673	.3544	.3870	.4370	.4168	.3953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184010 / NANASHI

Feeder No / Name : 201 / PIMPALGAON DHOOM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	1.5432	1.7147	1.4746		.3086
2	.3429	.3086	1.4575	2.2291	1.5089		.2915
3	.3429	.2915	1.3717		1.5432		.2915
4		.3086					.2743
5	.3429	.3258	1.3717	2.2291	1.6118		.3086
6	.3429	.3601	1.4918	2.2291	1.6289		.3258
7	.2058		1.7147	2.4006	1.8861		.2229
8	.1715	.1715	1.9719	2.4006			.1715
9	.1372	.1715	.2401	2.0576			.1715
10	.1715	.1372	.1715	.1372			
11	1.6804	.2572	.1715	.1372			.1715
12	1.8176	1.4918	.1372	1.6975	.1372		1.406
13	1.9719	1.6289	.1372	.1372		1.8004	1.4575
14	2.0576	1.8861	.1715	.1886		1.8347	1.5432
15	1.8004	1.869		.1543			1.6975
16	1.7318	1.9719	.1715	.1543		1.8004	1.6289
17	1.9204	1.8861	.1372	.1372		1.749	1.6632
18	1.8519	1.8347	.1372	.1715		1.6289	1.3889
19	.1715	.1715	.2058	.2401		.1715	.8916
20	.2229	.2058		.3258		.2058	.3086
21	.2572	.2058	.2401	.2743		.2572	.2058
22	.3086	.2572		.3086			.2572
23	.3429	.2401	.2743	.4287		.3086	.3086
24		.3086	1.3375				.3086
Max	2.0576	1.9719	1.9719	2.4006	1.8861	1.8347	1.6975
Min	.1372	.1372	.1372	.1372	.1372	.1715	.1715
Avg	.8425	.7217	.7228	.9406	1.3987	1.0841	.6784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269] BU 5495

Substation No/ Name :- 184010 / NANASHI

Feeder No / Name : 202 / BHANDWAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	11-APR-17	12-APR-17
HR	Load (MW)	Load (MW)
4		1.5775
24	1.4403	
Max	1.4403	1.5775
Min	1.4403	1.5775
Avg	1.4403	1.5775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184010 / NANASHI

Feeder No / Name : 203 / PAIETH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.7202	1.5432	1.5432	1.4403		.7202
2	.823	.7716		1.7147	1.4746		.6859
3	.823	.7202	1.5089		1.5089		.6859
4		.6859	1.4575		1.6118		.6516
5	.823	.7716	1.5261	2.0576	1.6632		.6859
6	.823	.9088	2.0405	2.0576	1.9376		.8573
7	.6859	.6859	2.0576	2.0576	2.1605		.6859
8	.4115	.6001	2.1605	2.0576			.4801
9	.4115	.5487	.3258	1.8861			.463
10	.4115	.4458	.3429	.4115			
11	.3429	.4287	.2743	.3601			1.0631
12	1.7661	1.9719	.2743	.3772			1.7318
13	1.7318	1.9204	.3772	.3601		1.8861	1.8519
14	1.5775	1.8176	.3772	.3601		1.7833	1.8861
15	1.6461	1.8004		.3772		1.7318	1.9033
16	1.8347	2.0062	.3772	.3772		1.9719	1.9719
17	2.0919	2.1434	.3772	.4287		2.0576	2.0576
18	2.1091	2.1091	.5316	.5144		1.8519	1.9204
19	.4801	.4973	.703	.7202		.5316	.5487
20	.7373	.5487		.7888		.7202	.6859
21	.7716	.6516	.7545	.7373		.7545	.7373
22	.8059	.6859		.7373			.7202
23	.7716	.703	.7202	.9431		.7716	.7545
24		.7202	1.6804	1.406			.7202
Max	2.1091	2.1434	2.1605	2.0576	2.1605	2.0576	2.0576
Min	.3429	.4287	.2743	.3601	1.4403	.5316	.463
Avg	1.0319	1.0360	.9705	1.0124	1.6853	1.4061	1.0639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184010 / NANASHI

Feeder No / Name : 204 / C&M EXP

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0171	.0343	.0362		.0343
2	.0343	.0343		.0343	.0362		.0343
3	.0343	.0343	.0171		.0362		.0343
4		.0343	.0171		.0343		.0343
5	.0343	.0343	.0171	.0343	.0362		.0343
6		.0343	.0343	.0343	.0362		.0343
7		.0343	.0343		.0362		.0343
8		.0343	.0343	.0343			.0343
9		.0514	.0343	.0514			.0343
10		.0343	.0343	.0724			
11		.0857	.0343	.1086	.0543		.0857
12		.1029	.0343	.1029			.0686
13		.0857	.3772	.0724	.0181	.0343	.0857
14		.0686	.0514	.0724		.0343	.0857
15		.1029		.0724		.0343	.1029
16		.0857	.0857	.0724		.0343	.0857
17		.0343	.0857	.0514		.0343	.0857
18		.0857	.0857	.0543		.0343	.0686
19		.0343	.0514	.0362		.0343	.0171
20		.0343		.0362		.0343	.0343
21		.0343	.0514	.0362		.0343	.0343
22	.0514	.0343		.0343			.0343
23	.0514	.0343	.0343	.0362		.0343	.0343
24		.0343	.0171	.0362			.0343
Max	.0514	.1029	.3772	.1086	.0543	.0343	.1029
Min	.0343	.0343	.0171	.0343	.0181	.0343	.0171
Avg	.04	.0507	.0574	.0532	.0360	.0343	.0507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184010 / NANASHI

Feeder No / Name : 205 / VANI KHURD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.5775	.4801	.823	.6173		1.286
2	1.3717	1.5432		.823	.6687		1.2003
3	1.5432	1.5089	.4458		.6859		1.2346
4		1.4575	.3772		.6516		1.286
5	1.5432	1.5089	.4458	.823	.6859		1.5432
6		1.5432	.7545	.823	.6516		1.7147
7	1.7147		.6859	.6859	.7202		1.8861
8	1.7147	2.0576	.6001	.583			1.9719
9	1.2003	.3429	.5144	.5144			.2572
10	.2401	.3086	.4287				
11	.2401	.3429	.3086	.6859	.8573		.2743
12	.3086	.2401	1.7147	1.5775	1.5089		.2572
13	.3086	.2572	1.8861	1.5432		.3086	.2401
14	.2743	.2743	1.8861			.2743	.2915
15		.2915		1.4403		.3429	.3086
16		.3086	1.7147	1.6118		.4287	.3772
17	.2743	.2743	1.7147	1.5775		.4458	.4115
18	.4801	.2743	1.7147	.823		.4458	.5144
19	.4458	.6516	1.5432	.5144		.4287	.6516
20	.823	.6001		.7545		.5487	.6001
21	.7202	.6859	.6859	.072		.5144	.6173
22	.6859	.5487		.7545			.6001
23	.6516	.4458	.6859	.7202		.4801	.6859
24		1.6289	.4287	.583			1.4918
Max	1.7147	2.0576	1.8861	1.6118	1.5089	.5487	1.9719
Min	.2401	.2401	.3086	.072	.6173	.2743	.2401
Avg	.8375	.8118	.9508	.8867	.7830	.4218	.8566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184010 / NANASHI

Feeder No / Name : 206 / 11 KV SADRALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.583	.5144	.3944		.3086
2	.3429	.3086		.5144	.4287		.3086
3		.2915	.4801		.4458		.2915
4		.3086			.4801		.2915
5	.3429	.3258	.5144	.5144	.5144		.3086
6	.3086	.3601	.6001	.6859	.7202		.3772
7	.3086		.6859	.823	.823		.2915
8	.3086	.1886	.823	.8573			.2229
9	.2058	.1715	.2058	.6859			.2058
10	.1715	.1543	.1715	.1029			
11	.3772	.1543		.1029	.12		.1715
12	.7716	.6344	.1372	.12	.1029		.8059
13	.7202	.6001	.1372	.12		.8573	.6516
14	.6859	.6001	.1372	.12		.6859	.6859
15	.6859	.6173		.1029		.6859	.6859
16	.7373	.7202	.1715	.12		.7545	.7716
17	.7888	.7888	.1715	.1372		.7716	.7202
18	.7373	.6516	.1715	.1886		.6516	.6001
19	.2401	.2915	.1715	.3258		.2572	.3601
20	.3258	.2743		.3258		.2915	.3429
21	.3429	.3086	.3086	.2915		.3086	.3258
22	.3601	.2743		.3086			.3429
23	.3601	.2572	.3086	.3429		.3258	.3258
24		.3429	.5144	.3944			.3086
Max	.7888	.7888	.823	.8573	.823	.8573	.8059
Min	.1715	.1543	.1372	.1029	.1029	.2572	.1715
Avg	.4507	.3884	.3496	.3499	.4477	.5590	.4220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184010 / NANASHI

Feeder No / Name : 207 / BARHE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.9719	1.7147	1.3717		
2				1.8861	1.4575		
3			1.8004		1.5432		
4			1.8347		1.5775		
5			1.7318	1.8861	1.6461		
6			1.9204	1.8861	1.8519		
7	2.4006	2.332					2.452
8	2.4006	2.4863					2.2977
9	2.0576	2.3491					2.1605
10	2.0576	2.2119					
11	2.0062	1.9204					2.1262
12				1.0288	1.0288		2.0233
13			2.332				
14			2.4006				
15				2.2291			
16			2.2977	2.3148			
17			2.2977	2.4348			
18	1.5432	1.5432	2.0919			1.3717	1.5432
19	2.3663	2.4863				2.332	2.3663
20	2.4863	2.4006				2.5034	2.1434
21	2.1434	2.2805				2.4863	2.0919
22	2.1776	2.2634					2.1091
23	2.0576	1.9547				2.1262	2.0576
24		1.9719	1.8861	1.4232			2.0576
Max	2.4863	2.4863	2.4006	2.4348	1.8519	2.5034	2.452
Min	1.5432	1.5432	1.7318	1.0288	1.0288	1.3717	1.5432
Avg	2.1543	2.1834	2.0514	1.8671	1.4967	2.1639	2.1191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184056 / UMARALE

Feeder No / Name : 201 / RASEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.4148	.5548	.5274			1.105
2		1.4632	.5609	.5127			1.1431
3	1.3336	1.448	.5959	.5011			1.105
4	1.7147	1.4998	.6173	.5174			1.1431
5	1.9052	1.5565					1.2384
6	2.2481	1.6827					1.448
7	2.2862	2.1582					1.5242
8	2.3624	2.2131					1.829
11				1.5623		1.9433	
12				2.3624	1.5813	1.829	
13			1.9868	2.4006		2.2481	
14			2.115	2.2862		2.1338	
15			2.083	2.3815	1.9334	1.829	
16			2.4406	2.4768		2.3243	
17	.1772	.1052		2.6292		2.4006	.2334
18	.2774	.2774	2.3293	2.6292		2.3624	.2515
19	.3403	.4961	.5194	.4191		.4954	.3905
20	.3366	.4557	.424	.4954		.4954	.3818
21	.3681	.4908	.4215	.4954		.4954	.4136
22	.394	.567	.4721	.5335		.5335	.4726
23	1.2308	.567	.487	.5716		.5716	.8786
24	1.2574		.3144	.5188	.6097		1.105
Max	2.3624	2.2131	2.4406	2.6292	1.9334	2.4006	1.829
Min	.1772	.1052	.3144	.4191	.6097	.4954	.2334
Avg	1.1660	1.0930	1.0615	1.3234	1.3748	1.5124	.9164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184056 / UMARALE

Feeder No / Name : 202 / NALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6154	1.8976	2.06	2.0957		.6478
2		.591	1.8747	2.06	2.191		.6478
3		.6154	1.8976	2.1386	2.2862		.6478
4		.6219	1.9292	2.1175	2.572		.6478
5			1.9216	2.3035	2.6673		
6			2.2497	2.5214	2.7435		
7			2.5772	2.9176	3.5056		
8			2.753		3.5437		
11	1.5384	1.6461					1.0242
12	2.8881	2.4352					1.0242
13	2.6684	2.4059					3.0323
14	2.8235	2.2929					3.003
15	2.9191	1.9208					2.7757
16	3.0727	2.0719	.4572				2.886
17	3.1493	2.4669		.4001		.2858	2.3619
18	2.8395	2.4577	.423	.4572		.4191	2.9994
19	.4607	.4557	.5687	.5906		.5716	1.7583
20	.5552	.5493	.6842	.6097		.6287	.6316
21	.567	.5847	.682	.6097		.6287	.5274
22	.5973	.5721	.569	.6478		.5906	.7034
23	.6154	1.7901	2.0559	2.0576		.6859	.7285
24	.6478	2.2298	1.8501	2.0256	2.0005		.6668
Max	3.1493	2.4669	2.753	2.9176	3.5437	.6859	3.0323
Min	.4607	.4557	.423	.4001	2.0005	.2858	.5274
Avg	1.7327	1.4624	1.5244	1.5678	2.6228	.5443	1.4841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184056 / UMARALE

Feeder No / Name : 203 / CHACHADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	2.5606	1.1056	1.138			2.3243
2		2.5789	1.1174	1.1292			2.3243
3	2.6673	2.6057	1.2021	1.0764			2.3815
4	3.0483	2.5882	1.3096	1.1893			2.6292
5	3.2388	2.6886					2.8578
6	3.4294	2.8166					3.0102
7	3.5818						3.0864
8	3.5818						3.3913
9							.523
10							.4785
11			.6523	2.0576		2.4387	.4138
12			3.0488	3.1626	.1502	1.4098	
13			2.9361	3.0483		2.21	
14			2.6289	2.7816		2.2862	
15			2.6289	2.8578	2.2776	2.21	
16			2.5606	2.934		2.8197	
17	.5014	.4641		2.8578		2.7435	.797
18	.5847	.7138	2.663	2.8959		2.6673	.7049
19	.8326	1.0144	.6834	.8383		.7621	.9558
20	.9412	1.1271	1.0277	1.0288		1.0669	1.1233
21	.985	1.1092	1.0277	1.0669		1.105	1.0584
22	1.0317	1.1883	1.1883	1.105		1.105	1.0808
23	1.9936	1.1547	1.138	1.2574		1.9433	2.0462
24	2.4387		1.1186	1.177	1.2955		2.3243
Max	3.5818	2.8166	3.0488	3.1626	2.2776	2.8197	3.3913
Min	.5014	.4641	.6523	.8383	.1502	.7621	.4138
Avg	2.0889	1.7392	1.6492	1.8668	1.2411	1.9052	1.7637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184056 / UMARALE

Feeder No / Name : 204 / UMARALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.7499	2.1247	2.2779			.9145
2		.724	2.2283	2.3979			.9145
3		.7499	2.2775	2.3899			.9145
4		.7499	2.2939	2.4321			.9145
5			2.3537	2.4582			.9145
6			2.284	2.6134			.7621
7			2.5587	2.9784			.6478
8			2.5617	2.5056			.6097
9							.4978
10				.5335			
11	2.2207	2.4446		.5525			2.2516
12	3.0445	2.4829		.5335			2.439
13	3.1674	2.4619					2.5545
14	2.3743	2.7778					2.6683
15	2.5072	2.8509					
16	3.0445	2.5263					2.8927
17	3.2952	2.6698				.381	2.7654
18	3.1184	2.5339		.5144		.5144	2.8337
19	.5973	.5609	.5804	.6097		.6859	.5768
20	.6201	.6241	.6487	.6859		.743	.6126
21	.6485	.6805	.7365	.743		.743	.6724
22	.7421	.7087	.7496	.743		.724	.7587
23	.7602	2.3266	2.1924	2.2862		.8764	.7879
24	.8002	2.4619	2.2283	2.2374	2.5149		.8764
Max	3.2952	2.8509	2.5617	2.9784	2.5149	.8764	2.8927
Min	.5973	.5609	.5804	.5144	2.5149	.381	.4978
Avg	1.8481	1.7269	1.8442	1.6385	2.5149	.6668	1.3536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184056 / UMARALE

Feeder No / Name : 205 / SPECTRUM

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3812	1.3546	1.5196	1.5476	1.2701	.74	1.3151
2	.7103	1.3283	1.4764	1.5369	1.3014	.6668	1.3189
3	1.3067	.7194	1.4741	1.5634	1.3623	.6424	1.3044
4	1.1863	1.3331	1.3889	1.5825	1.3836	.6447	1.2717
5	1.2244	1.3595	1.3555	1.7051	1.3844	.6424	1.2877
6	1.2109	1.2506	1.5095	1.648	1.4344	.6264	1.2832
7	1.2702	1.155	1.4877	1.5866	1.4648	.6333	1.2542
8	1.2999	1.3264	1.7029	1.7459	1.4718	.6401	1.2907
9	1.3507	1.6198	1.6482	1.6163	.6584	1.2938	1.3037
10	1.2846	1.6373	1.5995	1.5675	.6127	1.2503	1.2938
11	1.1476	1.6419	1.6063	1.1763	.6081	1.3516	1.3266
12	1.4792	1.7109	1.6482	1.4665	1.1669	.7557	1.341
13	1.4568	1.6367	1.5371	1.3668	.5708	1.3446	1.4467
14	1.3546	1.6442	1.5066	1.3432	1.0305	1.2671	1.4376
15	1.2651	1.6305	1.5204	1.3857	1.1332	1.2671	1.3433
16	1.166	1.4322	1.6129	1.4245	.5578	1.3925	1.3623
17	1.0978	1.4094	.836	1.3827	.6447	1.4275	.8158
18	1.0976	1.253	1.6429	1.3167	.4374	1.3607	1.4215
19	1.1134	1.1001	1.529	1.2003	.6257	1.2519	1.2866
20	1.1336	1.2877	1.4238	1.0602	.5914	1.2054	1.1768
21	1.1984	1.2734	1.3501	1.0237	.6241	1.2016	1.2064
22	1.275	1.3096	1.3918	1.0996	.631	1.1706	1.093
23	1.3149	1.4655	1.3037	1.2153	.7148	1.1635	1.109
24	1.3822	1.5597	1.5454	1.4022	1.3982	.6661	1.3043
Max	1.4792	1.7109	1.7029	1.7459	1.4718	1.4275	1.4467
Min	.7103	.7194	.836	1.0237	.4374	.6264	.8158
Avg	1.2378	1.3933	1.4840	1.4151	.9616	1.0253	1.2748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184056 / UMARALE

Feeder No / Name : 206 / WAGHAD L.I.S.

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.0366	.0379	.038			.0339
6	.0373	.0379	.0377			.0339
7	.1867	.0379	.0379			.0509
8	.2427	.038	.2657			.2374
9	.2459	.038	.2204		.1526	.2657
10	.2462	.0379	.0339		.1696	.2467
11	.2273		.2374		.1526	.2469
12	.2462		.2374	.1706	.2035	.0379
13	.2462	.2464	.2204		.1526	.2464
14	.2462	.2654	.2204		.1526	.2469
15	.2464		.2204	.1706	.1526	.2464
16	.2464	.1137	.2204		.1526	.2464
17	.2464		.2374		.1526	3.071
18	.2464	.2462	.1865		.1526	.2657
19	.2654	.2657	.2374		.1526	.2657
20	.2464	.2654	.2543		.2543	.2844
24		.2654				
Max	.2654	.2657	.2657	.1706	.2543	3.071
Min	.0366	.0379	.0339	.1706	.1526	.0339
Avg	.2162	.1458	.1816	.1706	.1667	.3766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184056 / UMARALE

Feeder No / Name : 207 / KOCHARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2012	.38	.3877			.2477
2		.197	.3955	.3835			.2477
3		.1991	.422	.3919			.2477
4		.2172	.4315	.418			.2667
5			.445	.423			
6			.4893	.5111			
7			.5715	.6121			
8			.5219	.5985			
11	.1829	.1888					.1764
12	.5731	.5085					.4291
13	.543	.5056					.5862
14	.5731	.5292					.6155
15	.543	.5262					.544
16	.567	.542	.1139				.5463
17	.5973			.1524		.1334	.423
18	.567	.0959	.1453	.1905		.1334	.1451
19	.1791	.3707	.2241	.2667		.2477	.3104
20	.1991	.1821	.2586	.2858		.2858	.2718
21	.2126	.2022	.2715	.2858		.2858	.2721
22	.2149	.1902	.2701	.2667		.2667	.2672
23	.1991	.321	.2022	.1715		.2667	.2569
24	.2477	.5402	.408	.3643	.4001		.2477
Max	.5973	.542	.5715	.6121	.4001	.2858	.6155
Min	.1791	.0959	.1139	.1524	.4001	.1334	.1451
Avg	.3764	.3245	.3469	.3568	.4001	.2314	.3390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184056 / UMARALE

Feeder No / Name : 208 / SUNRISE

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.3921	.3602	.3791			.4191
2		.3734	.3602				.4191
3	.0554	.3921	.3602	.3989			.381
4	.0739	.3547	.3791	.3799			.381
5	.0739	.3921	.3791	.3795			.4191
6	.0739	.3734	.3602	.3985			.381
7	.0924	.2054	.2654	.3033			.381
8	.0924	.1494	.3981	.1517			.2286
9	.1109	.303	.2279	.2286		.2096	.2849
10	.1848	***	.436	.2667		.2096	.4939
11	.4066	.4166	.4929	.4191		.381	.4939
12	.4294	.3973		.3048	.2464	.4382	
13	.5041	.3788		.362		.4382	.4739
14	.4251	.3219	.5313	.4763		.4763	.4744
15	.4294	.3791		.4572	.1896	.362	.4554
16	.5041	.3981	.2846	.4001		.4191	.4744
17	.4294			.4191		.3429	.4739
18	.4481	.3791	.3799	.4763		.4572	.3791
19	.3547	.3412	.2462	.362		.2286	.2085
20	.2241	.3412	.3039	.2858		.3239	.3605
21		.3791	.4179	.2096		.2096	.1898
22	.3174	.3223	.3602	.1715		.2096	.3605
23	.3361	.3981	.3419	.1715		.2096	.3981
24	.0554	.3602	.3602	.3799	.1905		.381
Max	.5041	13.6541	.5313	.4763	.2464	.4763	.4939
Min	.0554	.1494	.2279	.1517	.1896	.2096	.1898
Avg	.2580	.9306	.3623	.3383	.2088	.3277	.3875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269] BU 5495

Substation No/ Name :- 184255 / PEINTH

Feeder No / Name : 201 / KARANJALI SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.1715				
2	.1311	.1677				
3	.1475	.1696				
4	.1658	.2804				
5	.1677					
6	.1844					
7					.2543	
8					.3429	
11				.2623		
12				.2315	.2214	
13	.3185					
14	.4096					
15	.5182					
16	.4973					
17	.5087					
18				.1966		
21				.3315		
22				.2785		
23				.2572		
24	.1753	.0229	.0286	.2126		.1254
Max	.5182	.2804	.0286	.3315	.3429	.1254
Min	.128	.0229	.0286	.1966	.2214	.1254
Avg	.2793	.1624	.0286	.2529	.2729	.1254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184255 / PEINTH

Feeder No / Name : 202 / KUMBHALE

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2195		
3					.2286		
4					.2096		
5					.2054		
6					.2772		
7	.2858	.3429					
8	.3696	.3239					.3224
9	.2667	.2772					
10	.2957	.2715					.2279
11	.2561						
12	.2353						
13				.311	.2926		
14				.2743			
15				.3292			
16				.362			
17				.3326			
18	.2858						
19	.4024						
20	.4066						
21						.3012	
22	.3801						
23	.3326					.2601	
24	.3048	.0286	.021	.2286			.2454
Max	.4066	.3429	.021	.362	.2926	.3012	.3224
Min	.2353	.0286	.021	.2286	.2054	.2601	.2279
Avg	.3185	.2488	.021	.3063	.2388	.2807	.2652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269] BU 5495

Substation No/ Name :- 184255 / PEINTH

Feeder No / Name : 203 / PEINTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858			.3439		
2	.2667	.2614			.3258		
3	.2587	.2667			.3109		
4	.2957	.2858			.3109		
5	.3292	.3142			.3696		
6	.3841	.3475			.4066		
7	.3881	.3841			.3801		
8	.4294	.4066			.3658		.4119
9	.3511	.3801					
10	.3841	.3467					.394
11	.3696			.4239			
12	.4001			.4115	.4525		
13	.3881			.4706	.4344		
14	.3658			.439	.4572		
15	.4251			.4572			
16	.4024			.4344			
17	.4207			.4344			
18	.3511			.439			
19	.4075			.543			
20	.4706						
21				.5249		.4656	
22	.3658			.4938			
23	.3292			.3841		.4119	
24	.3239	.0324	.0343	.3439			
Max	.4706	.4066	.0343	.543	.4572	.4656	.4119
Min	.2587	.0324	.0343	.3439	.3109	.4119	.394
Avg	.3649	.3010	.0343	.4461	.3780	.4388	.4030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

PEINTH[269]

BU 5495

Substation No/ Name :- 184255 / PEINTH

Feeder No / Name : 204 / JOGMODI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.905		
2					.924		
3					.8145		
4					.823		
5					1.0059		
6					1.1888		
7	1.5708	1.419					
8	1.8839	1.7002					1.6832
9	1.9387	1.5546					
10	1.7741	1.3575					1.4022
11	1.6651						
12	1.4632						
13				1.4784	1.4784		
14				1.386	1.4003		
15				1.6078			
16				1.5708			
17				1.5546			
18	1.5729						
19	2.0668						
20	1.9035						
21						1.5061	
22	1.4784						
23	1.307					1.2269	
24	1.1317	1.1145	.0857	.8573			1.1517
Max	2.0668	1.7002	.0857	1.6078	1.4784	1.5061	1.6832
Min	1.1317	1.1145	.0857	.8573	.8145	1.2269	1.1517
Avg	1.6463	1.4292	.0857	1.4092	1.0675	1.3665	1.4124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184012 / WAVI

Feeder No / Name : 201 / WAVI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029		.1029	.1029	
2	.1029	.1029		.1029		
3	.1029	.1029		.1029		
4	.1029	.12		.12		
5	.1029	.1372		.12		
6	.1029	.1372		.1372		
7	.1372	.1372		.1372	.1372	
8	.1372	.1029		.1029	.1715	
9	.1372		.1372	.1715		.1372
10	.12		.1029	.1715		.1543
11	.1029		.1029	.1372		.1715
12	.1029		.1029	.1372	.1372	.1372
13	.1029		.1029	.1372		.1372
14	.1029		.1029	.1372		.1372
15	.1029		.1029			.1372
16	.1029		.1372	.1715		.1372
17	.1029		.1372	.1715		.1372
18	.1372		.1372	.1715		.1715
19	.2058		.2058	.2401		.1715
20	.1886		.1715	.2401		.2058
21	.1715		.1543	.2058		.1715
22	.1372		.1372	.1715		.1715
23	.1029		.1029	.1372		.1372
24	.1029	.1029		.1029	.1029	
Max	.2058	.1372	.2058	.2401	.1715	.2058
Min	.1029	.1029	.1029	.1029	.1029	.1372
Avg	.1215	.1162	.1292	.1491	.1303	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184012 / WAVI

Feeder No / Name : 202 / PANGARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859		.6173	.7545	
2	.6859	.7202		.6516		
3	.703	.7202		.7716		
4	.703	.7202		.7716		
5	.7373	.7202		.823		
6	.8059	.823		.9431		
7	.7373	.7545		1.3889	.8059	
8	.583	.6001		1.5604	.583	
9	.4801		1.2003	1.166		.463
10	.3429		.3601	.3601		.3429
11	.3258		.3601	.3601		.3086
12	.8573		.3944	.3258	1.0974	.823
13	.8916		.3944	.3258		.7716
14	.9259		.3944	.3772		.7888
15	.9259		.4458			.7373
16	.9602		.3944	.4287		.7545
17	1.0288		.3944	.463		.7716
18	1.286		.4458	.4458		1.3032
19	1.1488		.703	.7202		1.046
20	.823		.823	.823		.823
21			.8059	.823		.8059
22	.8059		.7888	.8059		.7888
23	.8059		.6344	.8059		.7716
24	.703	.6859		.5144	.7716	
Max	1.286	.823	1.2003	1.5604	1.0974	1.3032
Min	.3258	.6001	.3601	.3258	.583	.3086
Avg	.7805	.7145	.5693	.7075	.8025	.7533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184012 / WAVI

Feeder No / Name : 203 / TALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.6173		.6859	.6173	
2	.6173	.6173		.6859		
3	.6173	.6516		.7202		
4	.6516	.6516		.7202		
5	.7888	.6859		.8573		
6	.7545	.823		.9602		
7	.6173	.6173		1.3717	.6173	
8	.4801	.4801		1.7147	.2743	
9	.4115		1.2346	1.5432		.4115
10	.3429		.2743	.3429		.2401
11	.3086		.2401	.2743		.2058
12	.9259		.2743	.2743	1.2346	1.0974
13	.9602		.2743	.2743		1.0288
14	1.0631		.2743	.2743		.9259
15	1.0802		.2743			.8916
16	1.0974		.2743	.3429		.9945
17	1.3717		.2743	.3429		1.0631
18	1.4403		.3429	.2743		1.3717
19	1.1488		.5487	.6173		1.0974
20	.8402		.7545	.823		.7545
21	.7545		.6859	.7545		.6859
22	.6859		.6173	.6859		.6859
23	.6173		.5487	.6173		.6173
24	.6173	.6173		.6516	.6173	
Max	1.4403	.823	1.2346	1.7147	1.2346	1.3717
Min	.3086	.4801	.2401	.2743	.2743	.2058
Avg	.7838	.6402	.4595	.6874	.6722	.8048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184012 / WAVI

Feeder No / Name : 204 / PANCHALE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.7202		.5144	.7202	
2	.6516	.7545		.5144		
3	.6516	.823		.5316		
4	.703	.823		.5316		
5	.7716	.823		.5316		
6	1.0631	1.1317		.6001		
7	1.3717	1.4746		.4458	1.2517	
8	1.6632	1.4575		.3429	1.3546	
9	1.0974		.3086	.2743		1.166
10	.2743		.2401	.2229		.2401
11	.1886		.1372	.1372		.2229
12	.2058		.9945	.9945	.2401	.2401
13	.2229		.9259	.9431		.2229
14	.2401		.9259	.8573		.2229
15	.2401		.9602			.2058
16	.2572		.9945	.8916		.2229
17	.2743		1.166	1.166		.2229
18	.2743		1.1831	1.3375		.2401
19	.4287		1.166	1.0631		.3772
20	.6173		.583	.583		.5487
21	.5658		.5487	.5316		.4801
22	.463		.5144	.4973		.463
23	.463		.5316	.3086		.3772
24	.5487	.6173		.5144	.6859	
Max	1.6632	1.4746	1.1831	1.3375	1.3546	1.166
Min	.1886	.6173	.1372	.1372	.2401	.2058
Avg	.5773	.9583	.7453	.6233	.8505	.3635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184012 / WAVI

Feeder No / Name : 205 / RAMPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3429			.4287	
2	.4287	.3429				
3	.4287	.3429				
4	.4458	.3429				
5	.4458	.3429				
6	.4115	.3944				
7	.3772	.3601			.3772	
8	.3429	.3601			.3772	
9	.0429					.3601
11			.3944			
12			.3944	.4287		
13			.3944	.4115		
14			.3944	.4115		
15			.3772			
16			.3944	.4115		
17			.3601	.3772		
18			.3772	.3944		
19				.4115		
24	.4287	.3429			.4287	
Max	.4458	.3944	.3944	.4287	.4287	.3601
Min	.0429	.3429	.3601	.3772	.3772	.3601
Avg	.3781	.3524	.3858	.4066	.4030	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184012 / WAVI

Feeder No / Name : 206 / SHAHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1372		.1372	.12	
2	.1543	.1715		.1372		
3	.1715	.2058		.1372		
4	.1886	.2058		.1372		
5	.2058	.2058		.1372		
6	.2743	.3086		.1715		
7	.3601	.4115		.1715	.3429	
8	.4287	.463		.1029	.3772	
9	.3086		.0686	.12		.3429
10	.0686		.0686	.0857		.0514
11	.0686		.0514	.0514		.0343
12	.0686		.2401	.2401	.0686	.0514
13	.0686		.2229	.2058		.0514
14	.0686		.2058	.1886		.0514
15	.0514		.2229			.0514
16	.0514		.2572	.2572		.0514
17	.0514		.3258	.3086		.0686
18	.0686		.2915	.3258		.1029
19	.1029		.2743	.2401		.1029
20	.1715		.1543	.1372		.1715
21	.1543		.1543	.1372		.1715
22	.1543		.1543	.1372		.1372
23	.12		.1543	.0857		.12
24	.1372	.12		.1372	.12	
Max	.4287	.463	.3258	.3258	.3772	.3429
Min	.0514	.12	.0514	.0514	.0686	.0343
Avg	.1522	.2477	.1898	.1648	.2057	.1040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184012 / WAVI

Feeder No / Name : 207 / 11kv Dusingwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.3772		.4801	.4801	
2	.5144	.3429		.4801		
3	.5144	.3086		.4801		
4	.5144	.2743		.5144		
5	.5316	.2743		.5144		
6	.4801	.2229		.5316		
7	.4115	.2058		.7716	.463	
8	.3258	.1715		.8573	.3601	
9	.2401		.6516	.703		.2743
10	.2572		.1715	.2572		.3086
11	.2572		.1715	.2401		.2915
12	.5144		.2058	.2743	.6173	.6173
13	.5316		.2058	.2229		.5144
14	.5487		.2058	.2572		.5144
15	.5487		.2229			.4801
16	.583		.2229	.2401		.5487
17	.6859		.2058	.2743		.583
18	.7545		.2058	.2915		.703
19	.7373		.3429	.4973		.6516
20	.5144		.5316	.5487		.4801
21	.463		.5316	.5144		.4973
22	.5144		.5316	.4973		.5144
23	.4287		.4458	.4801		.4801
24	.4973	.4458		.4801	.463	
Max	.7545	.4458	.6516	.8573	.6173	.703
Min	.2401	.1715	.1715	.2229	.3601	.2743
Avg	.4944	.2915	.3235	.4525	.4767	.4973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184012 / WAVI

Feeder No / Name : 208 / 11kv Ghotewadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.5487		.4115	.4115	
2	.4458	.583		.4115		
3	.4458	.583		.4458		
4	.463	.583		.4801		
5	.4801	.6516		.5144		
6	.6173	.6859		.5487		
7	.823	.8916		.4801	.7545	
8	1.0288	.9259		.3601	.823	
9	.8916		.3429	.3258		.7202
10	.1543		.2401	.2401		.2058
11	.1372		.1886	.1886		.2058
12	.1029		.7202	.583	.1715	.2058
13	.1029		.6859	.5316		.1715
14			.6516	.5144		.1715
15			.6173			.1715
16	.1715		.583	.6173		.1715
17	.1715		.6173	.6173		.1715
18	.1886		.583	.7202		.2058
19	.3429		.6173	.6859		.3429
20	.583		.4801	.583		.5658
21	.5316		.4801	.5144		.5658
22	.4801		.4801	.4458		.4801
23	.4115		.4458	.3944		.3772
24	.4287	.4801		.4115	.3772	
Max	1.0288	.9259	.7202	.7202	.823	.7202
Min	.1029	.4801	.1886	.1886	.1715	.1715
Avg	.4528	.6592	.5156	.4794	.5075	.3155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184012 / WAVI

Feeder No / Name : 209 / SAISH AGRO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1185	.1021	.0713	.0711	.1021	.1217	.0697
2	.1187	.1025	.0714	.0713	.1021	.0705	.0699
3	.1187	.1025	.0714	.0713	.1025	.0707	.0703
4	.1187	.1021	.0714	.0714	.1023	.0707	.0701
5	.1187	.1017	.0714	.0713	.1016	.0703	.0699
6	.1181	.1008	.0711	.0705	.1175	.0695	.0684
7	.1141	.0936	.0688	.0673	.0958	.1185	.0642
8	.1091	.1087	.0572	.0623	.1072	.116	.0613
9	.1	.0583	.0602	.1087	.1084	.0638	.116
10	.1049	.0564	.0638	.1219	.115	.0713	.1209
11	.0596	.0413	.0623	.1217	.1219	.0705	.1221
12	.0857	.0484	.0585	.0993	.1194	.1235	.1183
13	.0867	.049	.0568	.0976	.1202	.0678	.1169
14	.0838	.049	.0564	.0989	.1207	.0621	.1185
15	.0791	.0613	.0562	.0981	.069	.0623	.1097
16	.08	.0629	.0572	.0977	.1194	.0608	.1171
17	.0852	.0566	.0627	.0958	.1183	.0589	.1145
18	.1091	.0627	.0671	.1118	.1166	.0593	.1107
19	.1177	.0653	.0667	.1131	.1179	.0671	.112
20	.1219	.0663	.0697	.1188	.1213	.0699	.1147
21	.1219	.0663	.0701	.1213	.1215	.0703	.1213
22	.1219	.0701	.0703	.1211	.1219	.0701	.1215
23	.105	.0705	.0707	.1213	.1217	.0701	.1215
24	.1194	.1056	.0711	.0673	.1215	.1207	.0655
Max	.1219	.1087	.0714	.1219	.1219	.1235	.1221
Min	.0596	.0413	.0562	.0623	.069	.0589	.0613
Avg	.1049	.0752	.0656	.0946	.1119	.0782	.0985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184016 / NANDUR SHINGOTI

Feeder No / Name : 201 / NANDUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3772	.1543	.1715	.1715	.3944	.4287
2	.3429	.3944	.1886	.1715	.1715	.3944	.4115
3	.3429	.3772	.1886	.1543	.1886	.4287	.3772
4	.3601	.4287	.1543	.1715	.1886	.4287	.3772
5	.4115	.4801	.1886	.1886	.2058	.463	.4287
6	.4458	.463	.2058	.2229	.2058	.463	.4801
7	.463	.463	.2058	.2572	.2229	.463	.463
8	.3772	.4973	.2401	.2401	.2058	.4287	.4458
9	.3429	.5144	.3601	.3601		.4287	.463
10	.4287	.463	.3944	.3944	.4287	.4458	.5144
11	.1715	.2058	.3429	.4801	.463	.1886	.1715
12	.2058	.2401			.463	.2572	.2229
13	.2058	.2058	.4115	.3429	.463	.2401	.2572
14	.2229	.2058	.4458	.4287	.463	.2572	.2572
15	.2058		.463	.4801		.2572	.2401
16	.2229	.2401	.4458	.4458	.4973	.2401	.2572
17	.2401	.2229	.463	.4458	.463	.2229	.2572
18	.2229	.2058	.4458	.4458	.5658	.2058	.2401
19	.3429	.463	.5487	.6001		.5487	.3429
20	.6173	.6001	.6344	.6516	.583	.6687	.6687
21	.6001	.583	.583	.6516	.6001	.6173	.6344
22	.5658	.5487	.5316	.5658	.5658	.583	.6173
23	.463	.1886	.2058	.1715	.5144	.5144	.5487
24	.4287	.4287	.1886	.1886	.1886	.463	.4458
Max	.6173	.6001	.6344	.6516	.6001	.6687	.6687
Min	.1715	.1886	.1543	.1543	.1715	.1886	.1715
Avg	.3594	.3825	.3474	.3578	.3723	.4001	.3980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184016 / NANDUR SHINGOTI

Feeder No / Name : 202 / CHASS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.4006	.3944	.4115	.1372	2.7949	2.8121
2	2.8121	2.2291	.3944	.4115	.1372	2.8292	2.8807
3	2.915	2.572	.4287	.3944	.1715	2.8635	2.915
4	3.3608	2.7435	.4287	.4115	.1715	2.9664	3.0521
5	3.4979	3.4294	.4287	.4115	.1715	3.1722	3.1893
6	3.5322	3.7723	.4287	.4458	.1715	3.6351	3.3779
7	3.8752	1.2003	.4287	.4801	.1715	4.1667	3.5665
8	4.1667		.3086	.4115	.1372	4.1324	4.0124
9	.3429	.12		.2743		.2743	.3429
10	.2743	.2743		.1029	.2743	.2915	.2743
11	.1029	.2743	1.4746	.5144	1.5775	.2743	.1715
12	.1029	.2058	3.5665	3.2579	3.5494	.2915	.1372
13	.1029	.2058	3.5322	3.4294	3.3779	.2743	
14	.1029	.2058	3.4465	3.2579	3.1722	.2572	
15	.1029		3.275	3.2579		.2743	
16	.1029	.2058	3.2922	3.3436	3.4465		
17	.1029	.2058	3.3265	3.6008	3.6351		
18	.1029	.2058	3.858	3.6008		.2229	
19	.1715	.3601	.3429	.1372	.3601	.3429	.2743
20	.1715	.3944	.5144	.1715	.5144	.4801	.3086
21	.1715	.4287	.4801	.1715	.4973	.4973	.1715
22	.1715	.4287	.463	.1715	.4287	.4801	.1715
23	.3429	.4287	.823	.1715	1.8519	.9945	.5144
24	2.4348	1.7147	.3944	.4287	.1715	2.7606	2.7606
Max	4.1667	3.7723	3.858	3.6008	3.6351	4.1667	4.0124
Min	.1029	.12	.3086	.1029	.1372	.2229	.1372
Avg	1.3253	1.0912	1.4559	1.2196	1.1489	1.5580	1.7185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184016 / NANDUR SHINGOTI

Feeder No / Name : 203 / PALASKHEDE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.2401	.2229	.2058	.3086	.2915
2	.3429	.3086	.2401	.2401	.2058	.3086	.3086
3	.3429	.3601	.2401	.2401	.2058	.3086	.2915
4	.3258	.3772	.2743	.2743	.2572	.3601	.2743
5	.3429	.4287	.3086	.3429	.2572	.463	.2572
6	.3772	.3429	.3944	.4801	.3086	.4973	.2915
7	.3601		.4973	.5487	.3944		.3086
8		.2743	.463	.4973	.4287		
9	.2229	.1715	.2058	.1886		.2401	.1886
10	.2915	.2401	.1886	.12	.2058	.1886	.2743
11	.2058	.1886	.1543	.2058	.2058	.2572	.1715
12	.3601	.3086	.1372	.1543	.1886	.3258	.3086
13	.3086	.3086	.1543	.1715	.1886	.3086	.2743
14	.2915	.2743	.1715	.1543	.1886	.3086	.2743
15	.2743		.1543	.1715		.2743	.2401
16	.3772	.2743	.1715	.1886	.1886	.2572	
17	.3772	.3086	.1543	.1886	.1886	.4287	
18	.4458	.4287	.1886	.1715	.2058	.4115	
19	.2572	.2743	.3429	.4115	.3944	.3258	.2572
20	.4458	.463	.4115	.4458	.4287	.4801	.4801
21	.4458	.463	.3772	.4287	.4287	.4458	.4287
22	.4115	.4287	.3429	.4115	.3944	.3944	.4115
23	.3429	.2401	.2401	.1715	.3601	.3429	.3601
24	.3601	.3429	.2401	.2229	.2572	.3601	.2915
Max	.4458	.463	.4973	.5487	.4287	.4973	.4801
Min	.2058	.1715	.1372	.12	.1886	.1886	.1715
Avg	.3414	.3234	.2622	.2772	.2767	.3453	.2992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184016 / NANDUR SHINGOTI

Feeder No / Name : 204 / DODI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.2058	.2401	.2743	.3601	.3601
2	.3086	.3429	.2229	.2401	.2743	.3086	.3429
3	.2915	.3429	.2401	.2229	.3086	.3086	.3258
4	.2743	.3772	.2743	.2401	.3772	.3601	.3086
5	.2915	.3944	.3086	.3086	.5144	.4287	.2915
6	.3258	.4287	.3601	.4458	.6001	.463	.3429
7	.2915	.3772	.6344	.583	.6859	.3086	.3086
8	.2743	.3086	.6687	.8059	.7373	.2743	.2743
9	.2058	.2572	.1886	.2058		.2401	.2229
10	.2229	.2058	.1886	.2058	.1886	.2572	.2058
11	.3086	.2743	.1543	.2058	.1886	.3944	
12	.583	.5658	.2229	.2058	.2401	.6859	
13	.583	.5487	.3086	.2401	.2058	.6001	
14	.6001	.5144	.2915	.2401	.2058	.5316	
15	.5487		.2743	.2401		.5487	.6173
16	.6173	.5487	.2743	.2572	.2401	.5658	.6344
17	.6859	.583	.2572	.2229	.1715	.7202	.6687
18	.7545	.6344	.2401	.2401	.2058	.7545	.7545
19	.3429	.2743	.3601	.3772		.3429	.2572
20	.4287	.3944	.463	.4458	.4973	.4458	.5144
21	.4287	.4287	.4115	.4287	.463	.4801	.4801
22	.3944	.3086	.3429	.4115	.4287	.463	.463
23	.3772	.1886	.1886	.2572	.3944	.4115	.4115
24	.3601	.3429	.2058	.2572	.2572	.3601	.3772
Max	.7545	.6344	.6687	.8059	.7373	.7545	.7545
Min	.2058	.1886	.1543	.2058	.1715	.2401	.2058
Avg	.4101	.3891	.3036	.3137	.3552	.4422	.4081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184016 / NANDUR SHINGOTI

Feeder No / Name : 205 / NALWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2566	2.3667	.6177	.6676	.6764	1.8537	2.3099
2	2.3457	2.2839	.6489	.6474	.6576	1.9631	2.3648
3	2.3601	1.7745	.6817	.6451	.6599	2.0211	2.2238
4	2.5598	2.1902	.7274	.6729	.6878	2.0759	2.4143
5	2.9462	2.6079	.8501	.7705	.7335	2.6803	2.8219
6	3.6793	3.5521	.9099	.9011	.852	3.4503	3.6843
7	4.5511	4.6011	.8833	.8916	.7648	4.4265	4.5191
8	4.4761	4.8803	.7076	.724	.8444	4.6201	5.0435
9	1.7379	1.9063	.5651	.5609	.5373	1.8389	2.0332
10	.4625	.4343	.4542	.375	1.377	.4698	.4835
11	.327	.391	1.2296	.7621	1.6038	.4877	.3982
12		.3765	5.9046	5.8093	5.4797	.4515	.3132
13		.391	5.825	5.3178	5.5841	.4679	.4119
14		.3841	5.7156	5.5495	5.4371	.4515	.4122
15	.4249	.1456	5.5632	5.4581	1.8496	.4625	
16	.4271	.3841	5.5708	5.5122	4.9878	.0892	
17	.4397	.3643	5.423	5.516	5.5956		.3936
18	.4641	.378	4.0428	5.4192	2.0081	.4447	.4648
19	.6505	.5666	1.7524	1.1389	1.2803	.6668	.6573
20	.9369	.9221	.9781	.8619	.9613	.9872	.9529
21	.8741	.9049	.9369	.9468	.988	.9778	.8695
22	.8208	.8314	.8665	.8573	.94	.9072	.7648
23	.804	.7648	.8063	.7495	.8291	.9397	.82
24	1.9807	1.1248	.6931	.7362	1.0429	2.0077	2.2798
Max	4.5511	4.8803	5.9046	5.8093	5.5956	4.6201	5.0435
Min	.327	.1456	.4542	.375	.5373	.0892	.3132
Avg	1.6917	1.4386	2.1814	2.1455	1.9324	1.5105	1.6653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184016 / NANDUR SHINGOTI

Feeder No / Name : 206 / MANORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.4458	.3944	.4115	.5144	.463	.4115
2	.3772	.4801	.4287	.4287	.4801	.4973	.4115
3	.3772	.5316	.4287	.4458	.4801	.5144	.3944
4	.4458	.6001	.4973	.4801	.6859	.583	.4115
5	.5144	.6687	.583	.6173	.8573	.6687	.4973
6	.5658	.6687	.7373	.9259	1.0288	.6687	.5658
7	.583	.5316	1.046	1.1488	1.1145	.583	.583
8	.4458	.463	1.1145	1.2517	1.2346	.4973	.4287
9	.3429	.3429	.3086	.2915		.3601	.3601
10	.2401	.2743	.3086	.2058	.2401	.2572	
11	.3429	.5487		.2229	.2058	.4115	.3429
12	1.166	.6687		.2058	.2058	.6687	.6859
13	.6859	.6687	.2229	.2058	.1886	.6344	.7373
14	1.0117	.6344	.2401	.1886	.1886	.6001	.2743
15	.583		.2229	.2058		.6344	.7202
16	1.166	.6687	.2401	.2229	.2401	.6859	.6001
17	.9259	.7716	.2229	.2572	.1715	.8059	.8402
18	.9774	.9259	.2915	.2572	.2058	.9945	.8745
19	.3429	.3944	.5487	.5658		.3429	.3429
20	.6859	.6344	.6859	.6173	.6687	.5658	.6687
21	.6859	.6001	.6344	.6001	.6344	.5316	.6173
22	.6173	.5144	.583	.5487	.6001	.4973	.6173
23	.5487	.3944	.3772	.3429	.5487	.4801	.5487
24	.4115	.5144	.3086	.4458	.6001	.5144	.4458
Max	1.166	.9259	1.1145	1.2517	1.2346	.9945	.8745
Min	.2401	.2743	.2229	.1886	.1715	.2572	.2743
Avg	.6016	.5629	.4739	.4622	.5283	.5608	.5383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184016 / NANDUR SHINGOTI

Feeder No / Name : 207 / SHELKE WASTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.6687	.7888	.6859	.2401	.2572
2	.2743	.2572	.6859	.7202	.6001	.2401	.2401
3	.2572	.2572	.703	.7373	.703	.2401	.2401
4	.2572	.2743	.7373	.823	.8573	.2743	.2572
5	.2743	.2743	.7716	1.0631	1.0288	.3086	.2743
6	.2572	.2572	.8402	1.2003	1.2003	.1715	.3086
7	.2401		1.2689	1.3203	1.286		.2058
8			1.3203	1.3546	1.2517		
9	.1886	.1372	.12	.1372		.1886	.1543
10	.1715	.1543	.12	.12	.12	.1886	.1886
11		.7716	.1372	.12	.1543	.7202	.3429
12		1.0117	.12	.1372	.1543	1.166	1.0117
13	1.166	.9774	.1372	.1372	.1543	1.0802	.9602
14		.9259	.1543	.1372	.1543	.9431	.9259
15	1.046		.1372	.1372		1.0117	.9088
16	1.166	1.0117	.1372	.12	.1543	1.0631	1.046
17	1.3546	1.0802	.12	.1543	.1543	1.2174	
18	1.4403	1.2689	.1372	.1372	.1886	1.2689	1.2689
19	.1715	.2058	.2229	.2058	.2058	.2401	.1715
20	.3086	.2743	.3086	.3086	.3086	.2915	.3429
21	.3086	.3086	.3258	.3086	.3086	.3258	.3086
22	.3086	.2743	.2915	.2743	.3086	.3086	.3258
23	.2743	.6344	.823	.3429	.2915	.2743	.2915
24	.2743	.2572	.6687	.8059	.8573	.2743	.2572
Max	1.4403	1.2689	1.3203	1.3546	1.286	1.2689	1.2689
Min	.1715	.1372	.12	.12	.12	.1715	.1543
Avg	.5007	.5185	.4565	.4830	.5058	.5471	.4676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184042 / MUSALGAON

Feeder No / Name : 205 / Datali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6714	.6752	.4969	.5266	.4679	.5396	.6661
2	.708	.7034	.5007	.5205	.474	.5563	.6722
3	.7293	.7522	.5243	.5319	.4877	.5868	.7042
4	.8002	.8551	.5502	.5868	.5281	.6943	.8002
5	.9023	.8863	.6783	.6843	.6257	.7926	.8619
6	.1875	.1006	.8962	.9381	.9983	.7987	.8817
7	.7636	.8383	1.2376	1.249	1.2239	.6325	.6851
8	.6142	.6569	1.2414	1.249	1.2704	.4458	.5525
9	.4047	.4374	.6485	.57	.5449	.0648	.1021
10	.2553	.3399	.3224	.2751	.1189		.0678
11	.506	.7461	.3231	.2522	.2705		.2149
12	.8253	.7735	.2873	.2538	.2804	.8947	.9084
13	.9008	.7423	.2225	.253	.2713	.9617	.8429
14	.8345	.7064	.2545	.2439	.2728	.7354	.7842
15	.7888	.6783	.3201	.0617	.2446	.8429	.7209
16	.7682	.7994	.3262	.0328	.2484	1.0448	.929
17	.9046	.948	.314	.0617	.2538	1.0707	1.0364
18	.9107	.9404	.3368	.0701	.2515	1.2361	1.0189
19	.7125	.6295	.647	.5456	.5578	.7087	.711
20	.7888	.6699	.6523	.7049	.6592	.772	.7415
21	.7255	.6683	.6302	.7064	.6241	.7415	.631
22	.7057	.6249	.6767	.5373	.612	.7095	.6577
23	.6874	.4085	.4816	.4824	.5586	.6821	.6516
24	.6607	.5075	.5106	.4588	.522	.644	.6188
Max	.9107	.948	1.2414	1.249	1.2704	1.2361	1.0364
Min	.1875	.1006	.2225	.0328	.1189	.0648	.0678
Avg	.6982	.6703	.5450	.4915	.5153	.7343	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184057 / WADANGALI

Feeder No / Name : 201 / WADANGALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-APR-17
HR	Load (MW)
1	.9412
2	.9412
3	.9877
4	.9774
5	.9774
6	.9955
8	2.6063
9	1.7528
10	.2195
11	.2743
12	.2686
13	.2149
14	.2149
15	.2149
16	.2507
17	.2686
18	.3258
19	.5068
20	.543
21	.543
22	.5068
23	.4755
24	.9145
Max	2.6063
Min	.2149
Avg	.6922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184057 / WADANGALI

Feeder No / Name : 202 / MENDHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-APR-17
HR	Load (MW)
1	.2926
2	.2561
3	.2561
4	.2561
5	.2561
6	.2896
7	.2926
8	.2172
9	.181
10	.1463
11	.1448
12	2.5072
13	2.3529
15	2.2386
16	2.2786
17	2.4539
19	2.1491
20	.3658
21	.4024
22	.362
23	.3258
24	.2926
Max	2.5072
Min	.1448
Avg	.8326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184057 / WADANGALI

Feeder No / Name : 203 / KOMAL WADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-APR-17
HR	Load (MW)
1	.7602
2	.7602
3	.7964
4	.7964
5	.8413
7	1.8099
8	2.4714
9	1.9185
10	.1463
11	.1463
12	.1463
13	.1448
14	.1448
15	.1448
16	.1448
17	.181
18	.2172
19	.2686
20	.3258
21	.3292
22	.3258
23	.2926
24	.7316
Max	2.4714
Min	.1448
Avg	.6019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184057 / WADANGALI

Feeder No / Name : 204 / KHADANGALI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	14-APR-17
HR	Load (MW)
1	.724
2	.724
3	.724
4	.724
5	.724
6	.7164
7	.6878
8	.6447
9	.4024
10	.3982
11	.362
12	.3582
13	2.8654
14	2.9235
15	2.8349
17	3.1341
18	3.1674
19	2.6863
20	.6219
21	.7316
22	.7964
23	.7682
24	.7316
Max	3.1674
Min	.3582
Avg	1.237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184066 / PATHARE

Feeder No / Name : 201 / KOLGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2284	2.5149	1.0303	.9907	.9602	1.7656	2.0988
2	2.2165	2.4653	1.0166	1.0259	.9572	1.8076	2.2665
3	2.2298	2.4358	1.0166	1.0427	.9998	1.9784	2.3289
4	2.2352	2.6429	1.0227	1.0014	.9983	2.0528	2.4227
5	2.8868	2.8547	1.0671	1.0734	1.0136	2.4085	2.8399
6	3.4145	3.5277	1.0836	1.0762	1.0566	2.9554	3.6187
7	5.2372	5.7644	.8492	1.0288	1.012	4.3244	6.1096
8	6.1439	5.9389	.7956	.8581	.8017	5.5814	6.4617
9	2.7275	3.2329	.6383	.6416	.6142	3.0375	3.4499
10	.1807	.5137	.4643	.5015	.4825	.421	.4558
11	.2469	.5152	1.302	1.1469	1.2559	.4878	.3201
12	.3742	.547	5.6958	4.4285	4.0116	.3856	.6005
13	.4238	.5716	6.1	4.5351	4.1176	.3627	.61
14	.4839	.5883	5.5533	4.3781	3.9453	.3868	.6081
15	.5407	.6158	5.326	4.3271	2.0043	.5099	.6051
16	.5484	.6295	5.4656	4.6007	3.2914	.5662	.6989
17	.599	.6373	5.6345	4.8568	4.2738	.6249	.672
18	.7339	.7032	5.3544	4.9909	5.208	.6668	.691
19	.7638	.8848	2.9717	2.5655	2.9111	.8434	.9248
20	1.1008	1.2562	1.0295	1.0962	1.0234	1.1264	1.0656
21	1.1103	1.2316	.5533	1.0848	1.0448	.9995	1.0528
22	1.0365	1.2471	1.089	1.1062	1.0185	1.0051	1.0635
23	1.2083	1.1485	1.0749	.9576	1.265	1.3412	1.2784
24	2.364	1.8377	1.0305	1.0257	2.5887	2.0728	2.3792
Max	6.1439	5.9389	6.1	4.9909	5.208	5.5814	6.4617
Min	.1807	.5137	.4643	.5015	.4825	.3627	.3201
Avg	1.7098	1.8460	2.3819	2.0975	1.9523	1.5713	1.8593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184066 / PATHARE

Feeder No / Name : 202 / PATHARE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5014	.6283	.724	.7362	.543	.5853
2	.5493	.5316	.6283	.7023	.7011	.5487	.5487
3	.5731	.5316	.7023	.7392	.7087	.5788	.5487
4	.5609	.5373	.7392	.7602	.7796	.6283	.5792
5	.6447	.591	.8131	.8501	.8779	.6722	.6335
6	.6733	.6626	.8779	.924	1.307	.7095	.6878
7	.4854	.5609	1.3032	1.7558	1.885	.5249	.6335
8	.4161	.3772	1.4784	1.9204	1.8839	.4207	.4458
9	.3403	.4251	.2987	.3174	.2987	.3696	.3734
10	.2686	.2957	.2957	.2801	.2772	.3045	.2801
11	.8048	.5853	.2587	.2058	.2743	.7316	
12	1.4083	1.3676	.2401	.2572	.2629	1.6817	1.419
13	1.419	1.2936	.2401	.2572	.2629	1.6632	1.3443
14	1.307	1.3169	.2427	.2572	.2804	1.4563	1.307
15	1.2323	1.2567	.2601	.2572		1.46	1.3443
16	1.2323	1.2936	.2401	.2743	.3155	1.4937	1.3443
17	1.4937	1.4415	.2401	.2743	.3155	1.6448	1.5154
18		1.2382	.2401	.2743	.3045	1.531	1.5154
19	.4527	.4854	.5975	.463	.6722	.5658	.4527
20	.7167	.6908	.7095	.7167	.7468	.7095	.7733
21	.679	.6722		.679	.7282	.7282	.7167
22	.6413	.6161	.5601	.6036	.7095	.7095	.679
23	.567	.5544	.815	.6859	.6161	.6401	.591
24	.5258	.5194	.5914	.7682	.3155	.5487	.5853
Max	1.4937	1.4415	1.4784	1.9204	1.885	1.6817	1.5154
Min	.2686	.2957	.2401	.2058	.2629	.3045	.2801
Avg	.7616	.7644	.5652	.6228	.6635	.8693	.8219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184066 / PATHARE

Feeder No / Name : 203 / MIRGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.7522	.6838	.5792	.5609		.8048
2	.7265	.7442	.6653	.6099	.5959		.8413
3	.7522	.7796	.6653	.6653	.6024		.8596
4	.7712	.8596	.7023	.6516	.6379		.9412
5	.9313	.8954	.8131	.7023	.695		1.0498
6	1.134	1.2178	.7316	.7392	.7468		1.267
7	1.5257	1.6126	.5792	.6584	.6653		1.9547
8	1.8724	1.7147	.5175	.439	.439	.2926	1.7318
9	.2865	.2957	.3734	.5228	.2987	.1478	.3361
10	.2686	.3326	.2957	.2801	.2772	.5014	.2801
11	.2926	.2926	.5144	.6173	.5487	.1463	
12	.2195	.2957	1.0974	1.0974	.9114	.1478	.2241
13	.2241	.2772	1.0288	1.0288	.8764	.2218	.2241
14	.2241	.2926	1.0056	.9602	.8413	.2241	.2241
15	.2987	.2957	.9709	1.1145		.2218	.2241
16	.2987	.3326	1.166	1.166	1.0517	.2241	.2241
17	.2987	.3696	1.2346	1.2689	1.262	.2957	.2218
18	.3018	.4435	1.3032	1.3717	1.576	.2241	.2957
19	.6224	.5975	.5601	.4481	.5975	.6036	.5658
20	.7922	.7842	.7468	.8488	.7842	.7842	.8488
21	.7922	.7655		.7922	.7842	.7655	.7922
22	.7356	.7468	.6722	.7356	.7095	.7468	.7545
23	.6379	.7392	.6379	.6173	.5601	.695	.6447
24	.7011	.7164	.7023	.6584	1.0517		.7682
Max	1.8724	1.7147	1.3032	1.3717	1.576	.7842	1.9547
Min	.2195	.2772	.2957	.2801	.2772	.1463	.2218
Avg	.6420	.6731	.7681	.7739	.7423	.3902	.6991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184066 / PATHARE

Feeder No / Name : 204 / 11kv Bharatpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6629	1.7158	2.0775	2.2764	2.367	1.5442	1.8656
2	1.6871	1.6966	2.1205	2.2851	2.3335	1.6294	1.8732
3	1.7402	1.7234	2.1529	2.3697	2.3792	1.6686	1.8656
4	1.7993	1.829	2.2623	2.4416	2.4744	1.6293	1.8808
5	1.8442	1.8503	2.3743	2.5187	2.7542	1.7139	1.8944
6	1.68	1.7646	2.9188	2.9031	3.94	1.6854	1.8563
7	1.2391	1.3123	3.6206	4.9383	5.4039	1.2529	1.2592
8	.9557	1.012	4.6422	5.6424	5.7476	1.1096	1.0379
9	1.0017	1.1586	1.7932	2.3286	2.3541	1.0757	1.0497
10	.9069	.9434	.5083	.772	.74	.756	.9831
11	2.8319	2.6215	.3948	.5968	.6401	2.1338	1.8595
12	4.8636	4.3629	.4512	.5343	.5875	1.8702	5.2496
13	4.6955	4.2023	.4634	.5822	.6584	4.9844	5.1151
14	4.0878	3.7799	.515	.6028	.6889	5.1212	4.7295
15	3.8215	3.5079	.5414	.5791	.3262	5.2424	4.1427
16	4.0212	3.6471	.5712	.6321	.628	5.6383	4.4383
17	4.4749	3.9441	.6253	.759	.7415	5.6783	5.0357
18	3.982	3.5333	.735	.7636	.8353	5.5792	4.5786
19	1.8551	1.5264	1.4632	1.4693	1.712	2.2878	1.8351
20	1.7833	1.7284	1.632	1.7376	1.7303	1.957	1.7221
21	1.8489	1.7345	.788	1.6581	1.7383	1.981	1.8047
22	1.9052	1.7334	1.547	1.6091	1.7627	2.0644	1.8839
23	1.8316	2.0435	2.335	2.239	1.6713	2.0119	1.7875
24	1.6659	1.9528	2.0805	2.367	1.1248	1.6491	1.7726
Max	4.8636	4.3629	4.6422	5.6424	5.7476	5.6783	5.2496
Min	.9069	.9434	.3948	.5343	.3262	.756	.9831
Avg	2.4244	2.3052	1.6089	1.8586	1.8891	2.5943	2.5634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184066 / PATHARE

Feeder No / Name : 205 / 11kv canol feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0554	.0362	.0526	.0543	.0549
2	.0709	.0554	.037	.0701	.0549	.0549
3	.0709	.0554	.037	.0709	.056	.0549
4	.0716	.0554	.0724	.0709	.0554	.0543
5	.0716	.0554	.0739	.0549	.0747	.0543
6	.0716	.0549	.0739	.0747	.0747	.0724
7	.0701	.0724	.0732	.0185	.0543	.0724
8	.0857	.0739	.0366	.0183	.0366	.0686
9	.0739	.037	.056	.0187	.037	.0187
10	.0554	.037	.0373	.0185	.0358	.056
11	.0183	.0343	.0171	.0549	.0732	
12	.037	.0343	.0171	.0701	.0739	.0747
13	.0554	.0686	.0171	.0526	.0739	.056
14	.0549	.0693	.0171	.0526	.0747	.056
15	.0554	.0693	.0171		.0554	.056
20						.8488
22	.0187	.0373	.0189	.0373	.0373	.0189
23	.0185	.0532	.0171	.056	.0366	.0179
24	.0358	.0554	.0366		.0549	.0549
Max	.0857	.0739	.0739	.0747	.0747	.8488
Min	.0183	.0343	.0171	.0183	.0358	.0179
Avg	.0560	.0541	.0384	.0495	.0563	.0969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184201 / SOMATHANE

Feeder No / Name : 201 / 11kv Somthane

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5359	.5083	.9656	1.5364	1.226	.4954	
2	.5359	.5083		1.5364	1.226		.4607
3	.5601	.5258	.1014	1.4299	1.2936	.4311	.4607
4	.5729	.5258	1	.3734	1.2936	.4311	.5373
5	.5601	.5434		1.848	1.4784	.4483	.5194
6	.5415	.5609	1.7414	1.9936	1.6804	.4483	.4961
7	.543	.4908			1.8671		.394
8	.4525	.0456	1.1035	.8402			.362
9	.381	.1928	.2069	.1663	.1524	.3104	.3189
10	.3506	.1753	.2012	.2858		.2759	.362
11	1.0341	.4557	.1658	.2477	.2096	1.1035	1.0566
12			.2058	.2353	.2477		
13	1.4198	.8063	.2427	.2218	.2667	.6379	.8596
14	1.7177	1.5775	.2303	.2241	.2858	1.9547	1.7541
15	1.7528	1.56	.1991	.2075		1.856	1.6118
16			.2263	.2427	.2667		
17	1.7878	1.1218	.2614	.2896	.2858	.6687	.8842
18	1.6476	1.7703	.2957	.2614	.3239	1.8446	1.7718
19	.5083	.2411	.3696	.4572	.4001	.1612	.1886
20	.5083	.5167	.4108	.6478	.5144	.5014	.3734
21	.5434	.5345	.4527	.6097	.5525	.5014	.4191
22	.5258	.5155	.4382	.5716	.5525	.5194	.4527
23	.5083	.5345	.7621	.5716	.5144	.5014	.5068
24	.5525	.5083	.9602	1.7013	1.1812	.4954	.5194
Max	1.7878	1.7703	1.7414	1.9936	1.8671	1.9547	1.7718
Min	.3506	.0456	.1014	.1663	.1524	.1612	.1886
Avg	.7973	.6463	.5019	.7174	.7533	.7151	.6814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184201 / SOMATHANE

Feeder No / Name : 202 / 11kv Sangavi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.5373		.1791	1.3203	.5716	
2	.5544	.5373	.9311	1.5546	1.4146	.5144	.5792
3	.5788	.4961	.9342	1.3394	1.386	.5144	.5731
4	.5544	.5138	.9128	1.4937	1.4784	.4801	.5511
5	.5788	.4961	.9645	1.5524	1.5708	.4801	.543
6	.5228	.4961	1.7395	1.7353	1.4937	.4458	.5068
7	.362	.3721	1.7759	1.7353	2.0538	.3772	.3801
8	.2896	.298			2.0538	.3086	.3045
9	.2858	.2481	.155	.1848	.1524	.2572	.2481
10	.2835	.9922	.1463	.1905		.9311	.3439
11		.9816	.1492	.1905	.1905		
12	2.0553	1.9136	.1372	.1629	.2096	2.2032	.7316
13	2.0553	1.97	.3294	.1663	.1905	2.1971	1.7551
14			.1772	.1494	.2096		
15	1.893	1.3969	.1267	.1886		1.286	.8596
16	1.7177	1.9879	.1509	.2241	.1905	2.0058	1.7703
17	1.8229	2.0022	.1494	.1991	.2667	2.0452	1.647
18		.1595	.1663		.2286	.1612	
19	.4382	.3445	.3142	.381	.4001	.4119	
20	.4961	.4134	.4668	.5716	.5335	.5552	.4108
21	.5258	.5173	.5093	.6097	.6287	.5611	.5144
22	.5609	.5167	.5335	.5716	.6478	.5731	.5658
23	.5609	.6552	.7811	.9526	.6287	.6154	.5973
24	.6097	.5609	.7266	1.6804	.1905	.5716	.5373
Max	2.0553	2.0022	1.7759	1.7353	2.0538	2.2032	1.7703
Min	.2835	.1595	.1267	.1494	.1524	.1612	.2481
Avg	.8227	.8003	.5581	.7279	.7927	.8212	.7063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184201 / SOMATHANE

Feeder No / Name : 204 / 11kv Dahiwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.7541		.3582	.3772	1.4861	.8596
2	1.2012	1.5939	.3265	.3475	.3961	1.5242	.8417
3	1.307	1.5769	.3265	.3077	.3696	1.3809	.8596
4	1.4784	1.7364		.3734	.4066	1.5413	.8449
5	1.8671	1.8604	.3086	.4066	.3881	.1774	.8793
6	2.0538	1.97	.3093	.439	.3734	1.9226	1.7013
7	2.2624		.2915	.415	.3361		
8		1.8959	.0271	.3734	.2427	1.7703	1.5043
9	.1524	.0886	.2481	.3511	.2286	.1718	.0716
10		.2149	.2195	.1905		.2756	.1086
11	.2835		.5801	1.1431	2.2862	.1372	.1254
12	.2481	.2303	2.0405	1.9004	2.2862		.1463
13	.2658			1.8111			.1254
14		.2481	.815		1.6004	.1372	.1417
15	.2481	.2835	2.2624	2.0748		.1886	.1791
16	.3189	.2835	2.4897	2.0538	1.9433	.2303	.1753
17	.2865			1.8099		.2229	.156
18	.2865	.3224	.8871		1.3146		.1949
19	.4119		.1848	.1524	.0381		
20	.4075	.0461	.3361	.4572	.3048	.3224	.4854
21	.4252	.4458	.3961	.4763	.362	.3258	.5144
22	.4119	.4473	.4572	.4763	.3429		.547
23	1.7353	.464	.381	.4763	.6859		.724
24	1.1431	1.7718	.2411	.3547	1.6194	1.6194	.1433
Max	2.2624	1.97	2.4897	2.0748	2.2862	1.9226	1.7013
Min	.1524	.0461	.0271	.1524	.0381	.1372	.0716
Avg	.8525	.9070	.6564	.7613	.7951	.7902	.5150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184206 / DEOPUR

Feeder No / Name : 201 / Deopur A

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3978	.3978	.3429	.2984	.2818	.3647	.4475
2	.3944	.431	.3429	.2818	.2984	.3812	.4475
3	.4973	.4475	.3601	.2984	.2818	.3812	.4475
4	.6104	.4973	.3601	.3149	.2818	.4144	.6299
5	.5967	.7459	.3772	.3429	.3481	.4475	.779
6			.5658	.3647	.3315		
7	.8619	1.1603	.3429	.2984	.2984	.779	.8288
8	.9779	1.1869	.2915	.2486	.2652	.9945	1.1603
9	.1326	.1492	.2229	.1989	.1823	.1658	.1658
10	.1658	.1823	.1658	.1492	.1658	.1492	.1658
11	.1492	.1823	.6299	.5304	.4641	.1658	.1823
12	.1326	.1989				.2486	.1492
13	.1492	.1823	.6299	.5138	.4973	.1658	.1492
14	.1658	.1658	.6464	.3315	.5801	.1658	.1326
15	.1658	.1658	.7293	.7293		.1658	.1658
16	.1492	.1886				.1658	.1823
17	.1658	.1823	.7293	.4641	.5967	.1823	.2155
18	.1823	.1989	1.1271	.9282	.9282	.1989	.2321
19	.2652	.2984	.1989	.2321	.2321	.2321	.3149
20	.3149	.3647	.3647	.3481	.4475	.3647	.3647
21	.3481	.3647	.3149	.3647	.3481	.3315	.3647
22	.3812	.3647	.3315	.3481	.3315	.3315	.3481
23	.3647	.3149	.3258	.2984	.2984	.3315	.3149
24	.407	.3812	.3258	.2818	.2818	.3647	.4748
Max	.9779	1.1869	1.1271	.9282	.9282	.9945	1.1603
Min	.1326	.1492	.1658	.1492	.1658	.1492	.1326
Avg	.3468	.3805	.4421	.3712	.3686	.3258	.3767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184206 / DEOPUR

Feeder No / Name : 202 / 11kv Bhokani

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.6371	.2915	.3222	.3222	.7122	.5426
2	.6104	.6783	.2743	.3052	.3391	.7291	.5596
3	.6274	.6783	.2743	.3052	.3391	.7461	.5596
4	.6952	.7122	.3258	.3391	.373	.8309	.5935
5	.6783	.7291				.8309	.6783
6	.5935	.7461	.3772	.407	.407	.8478	.763
7	.5087	.6104	.5658	.6783	.6783	.6274	.4748
8	.373	.2374	.6173	.78	.763	.4239	.2713
9	.2883	.2374	.12	.0995	.1017	.1865	.1989
10	.2543	.1187	.1187	.1526	.1187		.1357
11		.1017	.116	.1357	.1187		
12	.1526	.1017	.1526	.1526	.1187	.1989	.1696
13	.4748	.3391	.2035	.1696	.1357	.4807	.407
14	.407	.3561	.3052	.1357	.1357	.4748	.3391
15			.1526	.1526			
16	.2713	.1696	.1865	.1526	.1357	.5426	.2058
17	.3561	.5935	.2204	.1696	.1357	.5596	.6104
18	.5426	.6613	.2374	.1526	.1372	.6687	.5935
19	.1865	.2204	.4807	.5256	.5765	.6687	.2374
20	.7122	.7122	.7291	.6783	.8139	.5935	.763
21	.763	.7122	.7461	.763	.7969	.6104	.78
22	.8139	.6104	.6952	.7122	.8139	.6173	.7122
23	.7545	.1865	.2035	.2035	.7122	.5426	.6796
24	.6173	.6783	.2915	.2713	.2713	.5658	.5256
Max	.8139	.7461	.7461	.78	.8139	.8478	.78
Min	.1526	.1017	.116	.0995	.1017	.1865	.1357
Avg	.5132	.4708	.3341	.3376	.3793	.5933	.4909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184206 / DEOPUR

Feeder No / Name : 203 / 11kv khopadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.823	.8573	.7888	.7888	.7716	.823
2	.8573	.8402	.823	.7545	.823	.7888	.7716
3	.8573	.823	.8059	.8916	.9431	.7888	.7716
4	.8745	.8573	.8573	.9431	1.0631	.8402	.7716
5	.8573	.8745	.9431	.9774	1.2346	.8402	.8059
6	.6859	.8573	1.0288	1.2517	1.2517	.8402	.8573
7	.5658	.6687				.6173	.6173
8	.5316	.5316	1.6118	1.0288	1.4232	.463	.463
9	.3772	.4287	.2743	.2058	.3944	.3429	.4287
10	.3429	.3601	.2743	.3086	.3086	1.1488	.3429
11	.6001	.7545	.2572	.3258	.3086	1.1488	1.0631
12	1.0288	1.0974	.2572	.3258	.3429	1.4575	1.1831
13			.2572	.3086	.3944		
14	.6516	.6859	.2572	.3258	.3944	.8573	.6344
15	.9945	.823	.3086	.3086		1.0288	.9088
16	1.1488	1.046	.3086	.3258	.3944	1.2346	1.1317
17			.2743		.3772		
18	.6859	1.2003	.2915	.3944	.4458	1.4746	1.046
19	.4973	.4801	.5487	.5316	.7373	.5487	.5144
20	.8573	.823	.7545	.8573	.8573	.8916	.823
21	.8745	.823	.7373	.823	.8573	.8745	.8916
22	.823	.8402	.7202	.823	.8573	.8573	.8745
23	.8402	.6173	.6344	.7716	.7888	.8402	.8402
24	.8573	.823	.8573	.7888	.7888	.8573	.8402
Max	1.1488	1.2003	1.6118	1.2517	1.4232	1.4746	1.1831
Min	.3429	.3601	.2572	.2058	.3086	.3429	.3429
Avg	.7576	.7763	.6061	.6391	.7170	.8870	.7911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184206 / DEOPUR

Feeder No / Name : 204 / Panchale

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.823	.5144	.4115	.5487	.8573	.9431
2	.8745	.8573	.5144	.4115	.5658	.8916	.9431
3	.9602	.8916	.4801	.463	.5487	.8916	.9431
4	.9945	1.0631	.4801	.5144	.583	.9945	1.0288
5	1.0288	1.3375	.5144	.5658	.6173	1.2003	1.2346
6	2.0919	1.6804	.583	.583	.6859	1.5432	1.5947
7	2.1434	2.7092	.5144	.6173	.5487	2.0576	2.2291
8			.4801	.7888	.5487		
9	.1715	.2401	.3429	.3086	.3086	.2401	.2263
10	.2058	.3086	.2401	.3086	.2401	.2572	.2058
11	.2401	.3944	1.0288	1.153	.8059	.2572	.2401
12	.2743	.3944	1.8347	1.6804	1.7147	.2572	.2743
13	.2401	.2743	1.869	1.5947	1.3203	.2572	.2401
14	.2743	.3086				.2572	.2743
15	.2543	.2743	.6516	1.1831		.2572	.3086
16	.2401	.3086	2.1091	1.5775	1.5947	.2743	.3429
17	.3086	.2915	1.9376	2.0233	1.8519	.2743	.3258
18	.3258	.4115			.1543	.2743	.5487
19	.6516	.5487	.5658	.4115	.4973	.6344	.5487
20	.6859	.6001	.6516	.6443	.5487	.6516	.6516
21	.7202	.6173	.6516	.7202	.5487	.583	.6173
22	.6516	.583	.5658	.6516	.5487	.8573	.583
23	.7167	.4458	.5144	.6173	.583	.6516	.5487
24	.7888	.7373	.4801	.5487	.5487	.823	.8916
Max	2.1434	2.7092	2.1091	2.0233	1.8519	2.0576	2.2291
Min	.1715	.2401	.2401	.3086	.1543	.2401	.2058
Avg	.6796	.7000	.7965	.8081	.7233	.6627	.6845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184256 / DAPUR

Feeder No / Name : 201 / GONDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.7506	1.0818	1.1096	1.1073	.7026	.6828
2	.6462	.7407	1.0879	1.0951	1.0989	.6988	.6386
3	.7053	.7499	1.0955	1.1473	1.1119	.6896	.6805
4	.8467	.8444	1.1397	1.2075	1.169	.7651	.7831
5	1.0314	.916	1.2494	1.3161	1.259	.8768	1.0486
6	1.2872	1.2483	1.4132	1.4727	1.4922	1.1839	1.7242
7	2.585	2.4821	1.4719	1.3977	1.3843	2.1986	2.7881
8	3.4164	2.9965	1.0902	1.1435	1.0971	2.7393	3.3379
9	1.8278	1.7021	.892	.9107	.852	1.5493	2.0461
10	.65	.5674	.7468	.7419	.7369	.623	.6146
11	.5331	.5575	.884	.7633	.6497	.6962	.5533
12	.5259	.5041	2.0241	1.2277	1.4686	.652	.5921
13	.5651	.5735	1.9776	1.4902	1.4381	.6489	.6344
14	.6283	.5719	1.6301	1.398	1.3299	.6668	.6553
15	.6276	.6108	1.4647	1.3652	1.377	.6553	.6843
16	.6249	.6081	1.9735	1.6567	.8017	.6843	.7046
17	.679	.6576	2.5076	2.2847	1.9018	.6752	.6759
18	.6908	.7087	2.5937	2.5553	2.4478	.7239	.7194
19	.9088	1.0506	1.7154	1.6099	1.5119	1.017	1.0277
20	1.4198	1.3485	1.353	1.3393	.7209	1.3588	1.273
21	1.3398	1.3713	1.3123	1.3154	1.3149	1.3497	1.3062
22	1.2562	1.2966	1.2418	1.2273	1.2498	1.2951	1.2639
23	.873	1.1839	1.2094	1.1866	.9034	.9808	.9282
24	.7277	.9606	1.139	1.1157	.9385	.6706	.6584
Max	3.4164	2.9965	2.5937	2.5553	2.4478	2.7393	3.3379
Min	.5259	.5041	.7468	.7419	.6497	.623	.5533
Avg	1.0442	1.0417	1.4289	1.3366	1.2234	1.0042	1.0842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184256 / DAPUR

Feeder No / Name : 202 / SONEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2229	2.2977	2.332	2.6063	.1886	.2229
2	.2401	.2058	2.332	2.4006	2.572	.1886	.2401
3	.2572	.2229	2.3834	2.572	2.4177	.1886	.2401
4	.2743	.2401	2.4691	2.5377	2.4691	.2058	.2401
5	.3086	.2743	2.5377	2.4863	2.5034	.2401	.2401
6	.3258	.3086	2.9492	2.4691	2.5377	.2915	.3086
7	.2743	.3086	3.2407	3.0007	3.0521		.2915
8	.2229	.2401	3.5151	3.2579	2.7435	.2229	.2058
9	.2058	.2058	.1543	.1372	.1372	.1886	.1715
10	.1715	.1715	.12	.1372	.12	.1543	.1372
11	1.5432	2.3663	.1372	.12	.0857	2.7606	2.0576
12	2.8464	3.4637	.12	.12	.12	4.0466	3.618
13	2.915	3.6694	.12	.1372	.1029	3.8409	3.618
14	2.8464	3.4979	.1372	.1372	.1029	3.618	3.5837
15	2.8464	3.2065	.1372	.1372	.12	3.2922	3.4465
16	2.9492	3.0864	.1372	.12		3.2922	3.2579
17	3.0864	3.3951	.12	.1029	.1372	3.618	3.2579
18	2.9664	2.9492	.1372	.12	.1886	3.2407	2.8121
19	.2058	.2058	.2743	.2572	.2058	.2058	.3258
20	.3086	.3086	.3258	.2915		.3086	.2915
21	.2915	.2915	.3086	.2743	.2915	.2915	.2915
22	.2743	.2572	.2572	.2743	.2572	.2743	.2915
23	.2401	1.9376	2.2634	1.7147	.2401	.2401	.2401
24	.2401	.2229	2.2291	2.332	.2915	.1715	.2229
Max	3.0864	3.6694	3.5151	3.2579	3.0521	4.0466	3.618
Min	.1715	.1715	.12	.1029	.0857	.1543	.1372
Avg	1.0867	1.3024	1.1960	1.1446	1.0592	1.3509	1.2339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184256 / DAPUR

Feeder No / Name : 203 / EXPRESS PWW

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1372	.0857	.0857	.1029	.0686	.1029
2	.0857	.1372	.0857	.0857	.1029	.0686	.1029
3	.0857	.1372	.0857	.0857	.1029	.0686	.1029
4	.0857	.1372	.0857	.0857	.0857	.0686	.1029
5	.1029	.1372	.0857	.0857	.0857	.0686	.12
6	.1029	.12	.0857	.0857	.0857	.0686	.12
7	.1372	.12	.0857	.12	.0857	.0686	.1372
8	.1372	.12	.0857	.12	.0857	.0514	.1372
9	.1372	.12	.0857	.12	.0857	.0686	.1372
10	.1372	.1372	.1029	.1029	.1029	.0857	.1029
11	.1372	.1372	.12	.1029	.0857	.0857	.1029
12	.12	.0514	.12	.1029	.0857	.0686	.1029
13	.1029	.0514	.12	.1029	.0686	.1372	.1029
14	.1029	.0343	.12	.1029	.0686	.0857	.1029
15	.1372	.1029	.12	.1029	.0686	.0857	.1029
16	.12	.1029	.12	.1029		.0686	.1029
17	.12	.12	.0857	.1029	.0857	.0686	.1029
18	.12	.12	.0857	.1029	.0857	.0686	.0857
19	.12	.12	.0857	.1029	.0857	.0686	.12
20	.12	.1029	.0857	.1029		.0686	.1029
21	.12	.12	.0857	.1543	.0514		.1029
22	.1372	.12	.0857	.1029	.0514	.1029	.1029
23	.1372		.0857	.1029	.0686	.1029	.1029
24	.0857	.1372	.0857	.0857	.0686	.0686	.1029
Max	.1372	.1372	.12	.1543	.1029	.1372	.1372
Min	.0857	.0343	.0857	.0857	.0514	.0514	.0857
Avg	.1157	.1141	.0950	.1022	.0818	.0768	.1086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184256 / DAPUR

Feeder No / Name : 204 / DATTANAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2743	.2915	.2743	.1543	.1372
2	.1715	.1886	.2743	.2915	.2915	.1543	.1372
3	.2401	.1886	.2743	.3086	.2915	.1715	.1372
4	.3258	.2058	.2915	.3258	.3429	.2058	.1715
5	.4115	.2915	.3086	.4115	.3772	.2572	.2743
6	.4801	.463	.3258	.463	.4801	.4458	.6516
7	.823	.9602	.3258	.3429	.3258	.8573	.8573
8	1.1831	1.1317		.2572	.2572	.9602	1.046
9	.1715	.1543	.1886	.1886	.2229	.3086	.1715
10	.1372	.1372	.1372	.1715	.12	.1715	.1715
11	.12	.1715	.3258	.2058	.2229	.1886	.1372
12	.12	.1715	.703	.4287	.5487	.1715	.1543
13	.1543	.1715	.5658	.4287	.4801	.2229	.1715
14	.1715	.1715	.4458	.3944	.4801	.1886	.1715
15	.1543	.1543	.4458	.4115	.5144	.1886	.1715
16	.1715	.1543	.7202	.6173		.1886	.1543
17	.1543	.1715	.9774	.7545	.6859	.1886	.1543
18	.1372	.1715	.9088	.8916	.823	.1715	.1372
19	.2401	.3258	.2743	.2058	.2743	.3086	.2743
20	.3601	.3772	.3601	.3772		.3772	.3772
21	.3429	.3429	.3429	.3601	.3429	.3772	.3429
22	.3086	.3258	.3086	.3429	.3086	.3258	.3429
23	.1372		.3086	.3258	.12	.1372	.1543
24	.1715	.1715	.2743	.2915	.3772	.1543	.1372
Max	1.1831	1.1317	.9774	.8916	.823	.9602	1.046
Min	.12	.1372	.1372	.1715	.12	.1372	.1372
Avg	.2858	.2945	.4070	.3787	.3710	.2865	.2765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184256 / DAPUR

Feeder No / Name : 205 / DAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.4801	.3944	.4115	.4115	.4115	.463
2	.583	.4458	.3944	.4115	.3944	.4287	.4458
3		.4458	.4115	.4115	.3944	.463	.4458
4	.7202	.463	.4458	.4801	.4115	.463	.4973
5	.8573	.6001	.4801	.5316	.4458	.5658	.6001
6	.9088	.7888	.5144	.6173	.5658	.9431	1.3375
7	1.6632	1.5947	.4973	.5144	.5658	1.406	1.8004
8	1.989	1.5775	.4287	.3772	.3944	1.5261	1.7661
9	.2572	.2058	.3429	.3772	.3772	.3086	.2743
10	.2401	.2572	.3086	.3258	.2915	.2915	.2743
11	.2401	.2572	.6859	.6344	.3772	.3086	.2572
12	.2572	.2572	1.3032	1.0802		.3258	.3086
13	.3086	.2743	1.3889	1.0288	1.1145	.2915	
14	.2743	.2572	1.3375	1.0802	1.2003	.3086	.3258
15	.3086	.2915	1.2689	1.0631	1.3375	.2915	.3258
16	.2915	.2915	1.4575	1.166		.3258	.3086
17	.2743	.2915	1.6289	1.4575	1.5432	.3258	
18	.2743	.2743	1.5604	1.5604	1.6804	.3429	.3086
19	.3944	.4801	.3944	.3429	.4287	.463	.463
20	.5316	.5316	.5144	.5316		.5487	.5144
21	.4801	.4973	.5144	.4973	.4801	.4801	.4973
22	.4287	.463	.463	.463	.4287	.463	.4801
23	.3258	.4287	.4287	.4115	.2058	.4115	.4458
24	.5144	.5316	.3944	.4115	.4458	.3772	.463
Max	1.989	1.5947	1.6289	1.5604	1.6804	1.5261	1.8004
Min	.2401	.2058	.3086	.3258	.2058	.2915	.2572
Avg	.5517	.4994	.7316	.6744	.6426	.5030	.5729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-II (R) SUBDN[273] BU 0477

Substation No/ Name :- 184256 / DAPUR

Feeder No / Name : 206 / SHREE GANESHA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8272	.2854	.4858	.7064	.6969	.5251	.7003
2	.6143	.2988	.5334	.7152	.6843	.535	.6561
3	.849	.3163	.5236	.7328	.5556	.3185	.6637
4	.8165	.2942	.5373	.6744	.5757	.3201	.626
5	.6927	.3033	.5068	.3658	.5753	.3109	.591
6	.652	.3829	.4957	.626	.5643	.3258	.5361
7	.6066	.5598	.5403	.6633	.6298	.3536	.6059
8	.426	.4847	.5677	.6725	.5895	.6828	.6398
9	.2739	.4561	.6112	.6706	.6367	.7186	.5838
10	.3125	.5883	.7201	.7049	.7674	.6775	.5769
11	.295	.61	.7102	.7091	.7106	.6866	.6081
12	.3216	.7251	.7335	.7255	.4279	.8062	.639
13	.3003	.6775	.7152	.6108	.7213	.6143	.612
14	.2523	.7803	.7377	.6089	.7293	.567	.7316
15	.2537	.6668	.809	.7	.7883	.6794	.7392
16	.272	.6607	.7796	.8344	.4058	.631	.7613
17	.2557	.8181	.7651	.7639	.8344	.6035	.4405
18	.2702	.8489	.8188	.7457	.7834	.6531	.6672
19	.3071	.7956	.7426	.6943	.7335	.6935	.6173
20	.2976	.7004	.6565	.639	.4146	.7632	.5304
21	.2729	.5461	.5517	.7087	.6382	.6927	.6146
22	.3098	.5879	.6718	.7674	.5689	.6329	.5293
23	.2828	.3441	.6119	.708	.5244	.6519	.5875
24	.5372	.4054	.6866	.6687	.6325	.6204	.6127
Max	.849	.8489	.8188	.8344	.8344	.8062	.7613
Min	.2523	.2854	.4858	.3658	.4058	.3109	.4405
Avg	.4291	.5474	.6463	.6840	.6329	.5860	.6196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184042 / MUSALGAON

Feeder No / Name : 201 / IND 1

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166		1.2193	1.166		1.2384	
2	1.1145		1.2384	1.1317			
3	1.046		1.2003	1.046			.9907
4	.9774		1.1431	1.0117			
5	.8916		1.1431	.9088			.9717
6	.8573		.9145	.8745			
7	.6687		.8573	.9088			.9526
8	.4287		1.6004	1.3717			1.2003
9	.4973		1.6194	1.4232		2.191	1.6575
10		2.1338	2.3243	2.0005		2.4196	
11		2.0957	2.1529	2.1719		2.4196	2.0005
12		1.2003	1.9624	1.8099	1.7147	1.8671	1.6575
13		1.5051	2.0386	1.7909	1.9052	1.9433	1.848
14		1.9624	2.0767		1.9433	2.2291	2.0195
15		2.0957	1.9624		2.0195	2.3243	1.8671
16		2.1529	2.2481	2.2672	1.9433		1.9624
17		1.8861	1.9719	1.9624	1.9052	2.0386	1.5947
18		1.7528	1.8347			1.9814	1.5604
19		1.5242	1.406			1.7147	1.406
20		1.4098	1.4575			1.6004	1.0802
21		1.2193	1.3717			1.3717	1.3546
22		1.2384	1.1831			1.3336	1.1145
23		1.3336	1.2517			***	1.1488
24	1.2003		1.1622	1.2174		1.2384	
Max	1.2003	2.1529	2.3243	2.2672	2.0195	13.0697	2.0195
Min	.4287	1.2003	.8573	.8745	1.7147	1.2384	.9526
Avg	.8848	1.6793	1.5558	1.4414	1.9052	2.5613	1.4659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184042 / MUSALGAON

Feeder No / Name : 202 / IND 2

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2585	.4001	.756	1.1153	.6737	1.1401	1.137
2	1.0566	.3567	1.4045	1.0818	.6356	.5411	.5594
3	1.1123	.4435	1.3138	1.1111	.6622	.5822	.9679
4	1.1595	.349	1.1874	1.2052	.4664	.4557	.4397
5	1.1523	.4405	1.1271	1.3695	.6226	.4062	.8497
6	1.089	.9838	.9785	1.1938	.6341	.3948	.5129
7	.6992	.7667	.8375	.727	.4298	.4542	.4786
8	.6515	.7766	1.5813	1.2224	.7407	.7179	1.3725
9	.6531	.8848	1.8313	1.4388	.9236	1.6933	1.5516
10	.362	1.8298	1.9036	1.9014	.9671	1.797	.7971
11	.3528	1.8717	1.5173	1.8938	.9549	1.7604	1.8434
12	.3986	1.6956	1.6872	1.7345	1.3215	1.4807	1.4174
13	.3178	1.6811	1.5699	1.3497	1.3863	1.4495	1.4555
14	.4519	1.7856	1.7962	1.4274	1.5745	1.4434	1.5508
15	.221	1.7078	1.541	1.534	1.4738	1.4395	1.3656
16	.3719	1.6964	1.7543	1.6713	1.4236	1.5493	1.5691
17	.3788	1.8442	1.4023	1.7162	1.9181	1.6309	1.4343
18	.2782	1.9075	1.672	.8977	.9153	1.6103	1.5649
19	.1989	1.5165	1.4769	.8162	.8642	1.3161	1.2068
20	.2462	1.2704	1.078	.6988	.5388	.9518	1.0478
21	.2751	1.1744	1.3752	.6577	.5327	1.0601	.9241
22	.3597	1.1896	1.3733	.6257	.4512	1.0708	.9561
23	.346	1.2795	.8977	.4458	.4481	.8962	.9526
24	.943	.7209	1.3268	.9881	.5045	1.0501	.4893
Max	1.2585	1.9075	1.9036	1.9014	1.9181	1.797	1.8434
Min	.1989	.349	.756	.4458	.4298	.3948	.4397
Avg	.5972	1.1905	1.3912	1.2010	.8776	1.1205	1.1018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184042 / MUSALGAON

Feeder No / Name : 203 / IND 3

Feeder KV- 11 / OUTGOING

**SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4877	.9534	2.053	3.4542	1.9136	3.8286	3.8013
2	3.4153	.9526	1.8351	3.2781	1.8549	1.8427	1.9197
3	3.365	.8985	3.5094	3.0324	1.5143	1.3893	3.7395
4	2.6097	.7796	3.2419	2.6928	1.3176	1.2254	1.3512
5	2.2077	.6523	1.0273	2.1269	1.1408	1.1675	3.0948
6	1.9704	.5914	.9015	1.7056	.9739	.9968	.9777
7	1.4358	1.3847	2.1902	2.0328	1.3474	1.3451	2.316
8	1.5608	1.6568	3.4263	2.7149	1.7215	1.8084	3.3539
9	1.3097	2.3922	4.5649	4.0825	2.412	4.5573	4.4795
10	.8116	5.0549	6.0768	4.9353	2.6017	5.3246	2.7191
11	.5464	5.1913	5.8573	4.167	2.8136	5.6242	5.8474
12	.6013	4.2799	4.4414	4.1176	3.8058	4.5343	3.8714
13	.5868	4.7623	4.9124	4.0481	4.007	4.3805	4.273
14	.631	5.7392	5.4298	4.7364	4.8537	5.4017	4.4863
15	.4199	5.2103	4.7508	2.3853	4.7981	5.66	5.1052
16	.3993	5.2546	5.0457	4.8644	4.3805	5.4931	4.9824
17	.125	5.2485	4.7752	5.7621	4.8979	5.1982	4.9059
18	.5296	4.9193	3.8367	2.1453	1.8427	4.5237	4.1049
19	.7423	3.8226	2.8185	1.8915	1.8054	3.5742	3.4929
20	.7316	3.0163	2.9523	1.6629	1.4403	3.0171	2.9393
21	.6493	3.9873	3.6119	2.1552	1.7467	4.0551	2.0348
22	.8291	4.2806	3.7167	2.0515	1.6629	3.9552	4.0596
23	.913	4.0428	3.5037	2.2535	2.2047	4.2661	3.7658
24	2.4665	2.3739	4.1145	3.693	2.3083	4.2356	2.0233
Max	3.4877	5.7392	6.0768	5.7621	4.8979	5.66	5.8474
Min	.125	.5914	.9015	1.6629	.9739	.9968	.9777
Avg	1.3477	3.2269	3.6914	3.1662	2.4736	3.6419	3.4852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184042 / MUSALGAON

Feeder No / Name : 204 / IND 4

Feeder KV- 11 / OUTGOING

**SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4111	1.2216	1.989	2.6977	1.3001	2.159	2.396
2	3.581	.8299	1.9852	3.3509	1.6545	1.6027	1.2163
3	3.5399	.9534	3.0545	3.3318	1.7162	1.5379	2.1864
4	3.2891	1.2201	1.2856	3.1649	1.6377	1.5341	1.6232
5	3.11	1.243	1.3192	3.2243	1.7741	1.5348	2.7862
6	3.1344	1.2468	2.9043	3.0132	1.8061	1.6133	1.6301
7	2.1795	1.6019	1.906	2.8769	1.8046	1.6209	2.9065
8	1.6849	1.7261	3.802	3.3455	1.9113	1.6865	3.4743
9	1.5512	1.8892	3.8988	3.5201	2.0279	3.5619	3.6862
10	.7506	3.8058	3.8584	3.565	2.1102	3.5589	1.5813
11	.7773	3.6359	3.9705	3.5056	2.0706	3.6176	3.2998
12	.7842	3.9484	3.8858	3.283	3.9354	3.5078	4.0924
13	.7369	3.7571	3.8646	3.4119	3.8965	3.6831	3.7517
14	.7324	3.9156	3.9529	3.4796	4.0452	3.6633	4.0574
15	.6661	4.1915	3.7761	3.5742	4.2211	3.6275	4.1839
16	.7301	4.6609	4.0513	3.8935	4.0756	4.0916	4.3629
17	.7567	4.484	3.7544	3.882	3.9636	3.7777	3.9887
18	.7918	4.1823	3.6108	1.7619	1.8915	3.5962	3.7083
19	.7872	3.7174	2.5332	1.3512	1.4335	3.0933	3.3756
20	.7888	3.7853	2.5118	1.3123	1.3977	2.9485	2.7572
21	.788	3.7449	2.5088	1.3832	1.3009	1.5981	2.5187
22	.7842	3.815	2.4935	1.3298	1.2696	2.6086	2.3495
23	.807	3.7068	2.2984	1.3237	1.2071	2.3045	2.3198
24	2.7641	1.9852	3.2868	2.5469	1.1439	2.4654	1.2879
Max	3.581	4.6609	4.0513	3.8935	4.2211	4.0916	4.3629
Min	.6661	.8299	1.2856	1.3123	1.1439	1.5341	1.2163
Avg	1.6219	2.8862	3.0209	2.8387	2.2331	2.7081	2.8975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184042 / MUSALGAON

Feeder No / Name : 206 / 11kV town ship

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543		.1524	.1543		.1372	.1715
2	.1543			.1543			
3	.1543			.1543			.1715
4	.1543		.1524	.1372			
5	.1543			.1543			.1524
6	.1543		.1715	.1543			
7	.1715			.1543			.1715
8	.1543		.1219	.1372			.1524
9	.1543		.1524	.12			.1524
10		.1524	.1524	.1524			
11		.1715	.1524	.1524			.1524
12		.1905	.1524		.1524		.1524
13		.1905	.1524		.1524		.1905
14		.1905	1.3527	.1524	.1715		.1715
15		.1905	.1715	.1715	.1715		.1715
16		.1715	.1524	.1524	.1524		.1715
17		.1715	.1372	.1524	.1715	.1715	.1715
18		.1715	.1543			.1905	.1715
19		.2058	.2058			.2096	.2058
20		.2477	.2058			.2477	.2058
21		.2286	.0171			.2286	.1886
22		.2096	.1886			.2286	.1886
23		.1715	.1715			.1905	.1886
24	.1543		.1067	.1715		.1543	
Max	.1715	.2477	1.3527	.1715	.1715	.2477	.2058
Min	.1543	.1524	.0171	.12	.1524	.1372	.1524
Avg	.1560	.1903	.2112	.1516	.1620	.1954	.1738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184042 / MUSALGAON

Feeder No / Name : 207 / 11 KV Sez

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171			.0343			.0191
2	.0171			.0343			
3	.0171			.0514			.0191
4	.0171		.0267	.0514			
5	.0171			.0686			.0191
6	.0171			.0686			
7	.0171		.0533	.0857			.0191
8	.0171		.0762	.1029			.0191
9	.0171		.0152	.0171			.0191
10		.0191	.0191	.0191			
11		.0572	.0191	.0191			.0381
12		.0953	.0191	.0191	.0191		.0953
13		.1143	.0191	.0191	.0191	.0381	.0953
14		.1143	.0191		.0191	.0953	
15		.0953	.0191	.0191		.0953	
16		.0953	.0191	.0191		.1143	.1143
17		.0953		.0191		.0953	.0857
18		.0762	.0171			.1143	.0857
19		.0267	.0171			.0953	.0171
20		.0191	.0171			.0191	.0171
21		.0191				.0191	.0171
22			.0171			.0191	.0171
23		.0152	.0343			.0191	.0171
24	.0171		.0114	.0343			
Max	.0171	.1143	.0762	.1029	.0191	.1143	.1143
Min	.0171	.0152	.0114	.0171	.0191	.0191	.0171
Avg	.0171	.0648	.0247	.0401	.0191	.0658	.0420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184042 / MUSALGAON

Feeder No / Name : 208 / 11KV IND 5

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715			.1543		.1905	.1905
2	.1715			.1543			
3	.1715			.1543			.1905
4	.1715		.1905	.1543			
5	.1715			.1715			.1905
6	.1715			.1543			
7	.1715		.1334	.1543			.1715
8	.1715		.1905	.1715			.2286
9	.1715		.2096	.2401		.2477	.2667
10		.2667	.2858	.2667			
11		.2858	.2858	.2858		.2286	.2858
12		.2096	.2667	.2667	.2096	.2096	.2286
13		.1905	.2667	.2477	.1715	.2286	.2667
14		.2096	.2667	.2667	.1905	.2286	.2858
15		.2477	.2286	.2286	.2096	.2286	.2858
16		.2667	.2858	.2286	.2477	.2858	.3048
17		.2286	.2572	.1905	.2096	.2858	.2401
18			.2229			.2667	.2401
19		.1905	.1886			.2096	.1886
20		.1524	.1886			.2096	.1715
21		.1715	.1543			.1715	.1715
22		.1715	.1543			.1715	.1715
23		.1715	.1543			.1715	.1715
24	.1715		.1905	.1543		.1905	
Max	.1715	.2858	.2858	.2858	.2477	.2858	.3048
Min	.1715	.1524	.1334	.1543	.1715	.1715	.1715
Avg	.1715	.2125	.2169	.2025	.2064	.2203	.2237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184042 / MUSALGAON

Feeder No / Name : 209 / 11 Kv Industrial no 6
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431			.8059		1.1431	1.0288
2	.9088			.7716			
3	.8402		.8764	.7545			1.0098
4	.7888			.7888			
5	.7373		.8192	.7202			
6	.823			.7373			
7	.823		.724	.7716			.8383
8	.8059		.9145	.9431			.8573
9	.9259		1.3717	.8573		1.5813	1.3717
10		1.3717	1.2574	1.3336		1.4861	
11		1.3336	1.2193	1.2193		1.6194	1.8671
12		1.1431	1.0669	1.3717	1.3908	1.2955	1.2003
13		1.2003	1.2384		1.467	1.467	1.2384
14		1.0669	1.3527	1.5051	1.3146	1.5051	1.3146
15		1.2955	1.2193	1.5242	1.2003	1.3717	1.1812
16		1.5432	1.0669	1.3146	1.0479	1.4289	1.4861
17		1.1431	1.0974	1.2384	1.6004	1.105	1.1488
18		1.3717	1.1145			1.1241	1.0974
19		.9907	.9259			1.1431	1.2689
20		1.0288	.7545			1.1812	.9088
21		.9335	.8745			.9717	.9945
22		.7811	.7716			1.0288	.9088
23		.8192	.8059			.8002	.9259
24	.9088		.8764	.7716		.9526	
Max	.9431	1.5432	1.3717	1.5242	1.6004	1.6194	1.8671
Min	.7373	.7811	.724	.7202	1.0479	.8002	.8383
Avg	.8505	1.1445	1.0174	1.0252	1.3368	1.2473	1.1470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184042 / MUSALGAON

Feeder No / Name : 401 / 33 KV WADANGALI

Feeder KV- 33 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					8.4019	
2		6.8587				
3		7.1331				8.2305
5		8.642				10.3452
6		9.6937				
7		12.4486				15.2607
8						15.8322
9		7.5903			8.802	2.4006
10	2.1719	2.1148	2.2291		1.9433	
11	8.7449	4.1724	7.0302		5.8871	6.0014
12	12.7458	12.0028	11.8313	8.4591	13.3745	11.717
13	14.7462	10.4595	11.2026	11.4884	14.0032	14.9749
14	6.973	14.5748	10.7453	9.145	12.5172	
15	11.717	5.8871	10.2881		12.6886	
16	10.7453	14.0604	11.717	10.4024	13.1459	12.7458
17	13.786		14.7462	13.546	16.1751	
18	10.8025				16.5181	
19	13.2602				14.5748	
20					5.144	
21	2.9607				4.5153	
22	4.1152				3.8866	
23	7.7732				3.8295	
24					22.7881	
Max	14.7462	14.5748	14.7462	13.546	22.7881	15.8322
Min	2.1719	2.1148	2.2291	8.4591	1.9433	2.4006
Avg	9.2725	8.8952	9.9737	10.6082	10.4821	10.8343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184053 / 33/11 KV Malegaon Sub

Station

Feeder No / Name : 202 / 11 Kv Industrial No 02

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1019	1.0658	.6737	.9221	1.1694	.5289	2.1461
2	1.0153	1.1371	.6752	.9099	1.0833	.4252	1.975
3	.892	1.145	.7621	.8626	.961	.4313	1.7573
4	.8577	1.0993	.7575	.8662	.8978	.4298	1.4891
5	1.0105	.9949	.6474	.8253	.8448	.4374	1.693
6	1.0304	1.1073	.6872	.7933	.8467	.4298	1.8152
7	1.0456	1.1043	.6752	.7324	.8671	.4603	1.8564
8	.2865	1.1839	.796	.9348	.9145	.5319	1.5101
9	.966	1.1286	1.4106	1.5596	.881	1.0181	2.2458
10	1.2129	1.5211	1.4273	1.5985	.8733	1.5257	2.1285
11	1.0307	1.4537	1.661	2.029	.9008	3.0432	2.4368
12	.4268	1.5772	1.6556	1.7029	2.0938	2.8121	2.4196
13	.3932	.4251	1.246	1.1938	1.8373	1.9136	2.0977
14	.3643	.5601	.953	.9358	1.7886	2.4665	1.8846
15	.3887	.785	1.5089	1.7634	2.3236	3.1985	2.3869
16	.6916	1.2053	1.6945	1.7505	1.643	3.2164	2.5758
17	.6257	1.0204	1.8347	1.6674	.6173	3.4793	2.3971
18	.6318	.2423	1.7078	1.5722	.7529	3.0681	2.1086
19	.9557	.6531	1.2155	1.4922	.628	1.5104	2.146
20	.9808	.8779	1.4232	1.233	.474	2.226	1.6271
21	1.1648	.8375	1.1321	1.2235	.4786	2.0146	1.7215
22	1.1256	.7323	1.1679	.8566	.823	2.7687	2.2693
23	1.1759	.2286	.4542	1.6225	.8505	2.7339	2.1925
24	1.5025	.5618	1.1321	1.2925	1.5602	1.2681	2.7553
Max	1.5025	1.5772	1.8347	2.029	2.3236	3.4793	2.7553
Min	.2865	.2286	.4542	.7324	.474	.4252	1.4891
Avg	.8699	.9437	1.1374	1.2642	1.0879	1.7474	2.0681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184053 / 33/11 KV Malegaon Sub

Station

Feeder No / Name : 203 / MIDC 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.1949	1.8861	1.9814	1.9616		1.6804
2	1.6975	1.1317	1.829	1.9814	1.8861		1.4937
3	1.4784	1.0349	1.7147	1.9433	1.7924		1.3203
4	1.2803	1.0242	1.6598	1.9239	1.7528		1.2936
5	1.2936	1.0242	1.2071	1.8861	1.829		1.4937
6	1.4784	1.1827	1.6598	1.9052	1.8861		1.4937
7	1.5089	1.3443	1.5844	1.8107	1.8671		1.4784
8		1.5684	2.037	2.037	2.0911		1.6632
9	1.2936	2.3899	2.5631	2.6139			2.0328
10	1.0974	2.6406	2.9721	2.9721			2.5149
11	1.4022	2.8197	3.2007	3.2769		2.8669	2.6673
12	1.166	2.7435	3.0483	3.2007	2.9424	2.9721	
13	1.2346	2.7435	3.0178	3.1245	2.7915	2.8959	2.2923
14	1.0974	3.0483	3.3532	3.2769	3.0933	2.9424	2.4646
15	1.2346	2.9721	3.0483	3.1245	3.1245	3.0483	2.7435
16	1.166	2.9721	3.1245	3.2769	3.1245	2.9424	2.7161
17	1.0974	2.8669	3.2007	3.0483		2.8959	2.4897
18	1.1096	2.3899		2.9721		2.6139	2.2405
19	1.262	2.2634	2.6406	2.6673		2.2177	1.848
20	1.3443	1.8671	2.4272	2.3624		2.0538	1.7924
21	1.2696	1.9616	2.4272	2.2634		2.0328	1.7924
22	1.2696	2.037	1.5278			1.8671	1.8107
23	1.3443			2.0911		1.848	1.7353
24	1.4937	1.2696	1.9616	1.9418	2.037		1.848
Max	1.8671	3.0483	3.3532	3.2769	3.1245	3.0483	2.7435
Min	1.0974	1.0242	1.2071	1.8107	1.7528	1.848	1.2936
Avg	1.3255	2.0213	2.3678	2.5079	2.2985	2.5536	1.9524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184053 / 33/11 KV Malegaon Sub

Station

Feeder No / Name : 204 / MIDC 4

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.2384	1.5089	1.5242	1.7147		1.7147
2	1.3336	1.1431	1.4712	1.5242	1.6575		1.5242
3	1.1431	1.105	1.419	1.4289	1.6194		1.3336
4	.9526	1.086	1.3817	1.4289	1.5623		1.3336
5	.9526	1.105	1.2449	1.2269	1.5813		1.5242
6	1.1431	1.1241	1.3203	1.2826	1.6194		
7	1.2384	1.2384	1.4563	1.307	1.6194		1.7147
8		1.4289	1.5089	2.037	1.6575		1.7147
9	1.3336	1.8099	1.8484	1.7737			2.2862
10	1.2765	2.1338	2.1529	2.0386			2.3053
11	1.2384	2.0957	2.1719	2.21		2.1148	2.3434
12	1.1812	2.1148	2.0957	2.3053	2.2862	2.1529	
13	1.1622	1.9433	2.0767	2.1148	1.7147	2.4006	2.1338
14	1.1431	1.9052	2.3243	2.7244	2.0957	2.6673	
15	1.1812	2.1338	2.1148	2.6101	2.1529	2.4387	2.191
16	1.1431	2.2291	2.0767	2.553	2.1529	2.21	2.5149
17	1.0479	2.4958	2.1529	2.2862		2.7816	2.2862
18	.9335	1.7924	2.2068			2.2862	1.9433
19	1.0288	1.773	1.9239	2.2481		2.0957	1.8296
20	1.0288	1.6991	1.6804	1.7909		2.0957	1.8671
21	1.0479	1.6032	1.6804	1.9993		2.0957	1.829
22	1.086	1.4146	1.5123			1.8099	1.7528
23	1.0669			1.7337		1.8099	1.6975
24	1.2384	1.0669	1.6032	1.5844	1.8099		1.9052
Max	1.5242	2.4958	2.3243	2.7244	2.2862	2.7816	2.5149
Min	.9335	1.0669	1.2449	1.2269	1.5623	1.8099	1.3336
Avg	1.1489	1.6382	1.7797	1.8969	1.8031	2.2276	1.8926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184053 / 33/11 KV Malegaon Sub

Station

Feeder No / Name : 207 / 11 KV MIDC 7

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0538	.5487	1.4146	1.5242	1.7918		1.1088
2	1.8861	.5144	1.4146	1.4289	1.7177		1.1317
3	1.1088	.5316	1.307	1.4289	1.6804		.9431
4	.7392	.5611	1.2136	1.3957	1.6817		.9335
5	.7316	.5914	.7356	1.3203	1.7164		1.0974
6	.5544	.6535	1.1317	1.3203	1.7718		1.2936
7	.5601	.6468	1.419	1.3817	1.773		1.4937
8		.8871	1.8484	1.7353	1.6975		1.307
9	.5544	1.829	2.0725	1.7737			1.6975
10	.3315	1.8671	1.9052	2.191			2.4577
11	.2928	1.9243	2.0767	2.3434		2.0182	2.1719
12	.2717	2.4006	1.6078	2.5339	2.6101	1.6804	
13	.2599	1.8861	2.0767	2.1691		1.9044	2.1879
14	.3018	1.905	2.2672	2.191	1.8298	1.9035	2.5766
15	.3109	1.8861	2.4709	2.8578	1.7364	2.0351	2.8769
16	.2138	.9896	2.8387	2.6783	2.0351	2.0328	2.5911
17	.2267	2.8197	2.7816	2.5019		2.5393	2.7054
18	.2926	1.643	2.1502	2.3954		1.848	3.5056
19	.3048	1.905	2.1658	2.2032		1.8671	2.1502
20	.3071	2.0538	1.7177	1.7372		1.8671	1.9605
21	.3366	1.8861	1.6975	1.7924		1.7737	1.9035
22	.326	1.6787	1.7164			1.6804	1.8858
23	.4214			1.8673		1.2936	1.6632
24	.6535	.4372	1.4377	1.4937	1.8298		1.2012
Max	2.0538	2.8197	2.8387	2.8578	2.6101	2.5393	3.5056
Min	.2138	.4372	.7356	1.3203	1.6804	1.2936	.9335
Avg	.5669	1.3933	1.8029	1.9245	1.8363	1.8803	1.8628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184053 / 33/11 KV Malegaon Sub

Station

Feeder No / Name : 209 / 11 KV PWW

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0566	.0648	.0857	.0532		.056
2	.0566	.056	.0648	.0857	.0526		.0566
3	.0366	.056	.0678	.0686	.0526		.0554
4	.0373	.0554	.0509	.0671	.052		
5	.0739	.056	.0514	.0724	.0693		.056
6	.0747	.0554	.0857	.056	.0739		.0754
7	.0739	.0747	.112	.0732	.0747		.0747
8		.0754	.1132	.0686	.0747		.0747
9	.0924	.0905	.0747	.0747	.0747		.0747
10	.1075	.0953	.0924	.0934			.0924
11		.0934	.0924	.0924		.0905	.0914
12	.0034	.0934	.0934	.0934	.0914	.0914	
13	.0924	.0934	.0924	.0914		.0914	.0934
14	.0914	.0924	.0924	.0914	.0924	.0905	.0924
15	.0924	.0934	.0914	.0924	.0914	.0914	.0686
16	.0924	.0511	.0924	.0934	.0924	.0924	.0701
17	.0934	.0533	.0924	.0924		.0716	.0709
18	.0924	.064	.0566	.0747		.0739	.0693
19	.0747	.0051	.0754	.0747		.0739	.0701
20	.0747	.0377	.0747	.0747		.0739	.0543
21	.0754	.0514	.0754	.0747		.0747	.0543
22	.056	.0514	.0754			.0554	.0537
23	.0554			.056		.0554	.0543
24	.0754	.056	.0358	.056	.0566		.0554
Max	.1075	.0953	.1132	.0934	.0924	.0924	.0934
Min	.0034	.0051	.0358	.056	.052	.0554	.0537
Avg	.0717	.0655	.0790	.0784	.0716	.0790	.0688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184053 / 33/11 KV Malegaon Sub

Station

Feeder No / Name : 211 / 11 kv Mohadari Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3326	.2987	.2614	.3361		.3361
2	.2987		.2987	.2801	.3395		.3361
3	.3018	.3361	.3018	.2987	.3772		.3395
4	.3326	.3696	.3395	.3018	.3734		.3696
5	.3658	.4066	.3395	.3395	.4066		.415
6	.4024	.4435	.4527	.3772	.4481		.4527
7	.4527	.4755	.4294	.4481	.415		.4805
8		.4108	.4527	.4115	.4527		.5281
9	.4805	.439	.5658	.4481			.3734
10	.4344	.439	.5914	.4344			.4656
11	.439	.3258	.3982	.394		.4024	.5175
12	.3224	.3224	.439	.3155	.3582	.3582	
13	.3224	.2454	.3582	.4024			.362
14	.439	.3224	.362	.3982	.4024	.3582	.3982
15	.4755	.2865	.439	.4435		.4344	.394
16	.4755	.2454	.5121	.4481	.0171	.4755	.4298
17	.5175	.3224	.6348	.415		.4656	.4435
18	.5487	.5228	.6036	.0747		.543	.4854
19	.5544	.4527	.4527	.4805		.5175	.415
20	.5228	.4481	.4904	.4481		.4481	.4854
21	.4904	.415	.4527	.4527		.4481	.4481
22	.4481	.415	.4527			.4527	.4805
23	.3772			.3772		.4066	.4481
24	.4481	.3361	.2614	.2641	.3361		.3734
Max	.5544	.5228	.6348	.4805	.4527	.543	.5281
Min	.2987	.2454	.2614	.0747	.0171	.3582	.3361
Avg	.4253	.3779	.4316	.3702	.3552	.4425	.4251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184075 / NIMGAON

Feeder No / Name : 201 / NIMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5014	.5487	1.1789	.7118	.6706	.3993	.4466
2	.4572	.5609	1.2163	.7331	.6965	.4009	.4512
3	.4786	.538	1.3077	.7499	.7225	.3932	.4618
4	.4984	.5807	1.4144	.8124	.7819	.4313	1.5585
5	.5502	.6462	1.6095	.916	.916	.4862	.5716
6	.6325	.727	1.8496	1.0334	1.0623	.6554	.7209
7	2.1414	1.1584	1.512	1.0105	.9663	.9587	1.2711
8	1.4815	1.3108	1.2628	.7423	.7788	1.1904	2.2656
9	1.9974	.9496	.8474	.8619	.4984	1.0532	1.1645
10	.5541	.6584	.6729	.7178	.4207	.3719	.5273
11	.4664	.4786	.5906	.5395	.2865	.253	.3246
12	.4694	.4359	1.7611	1.4297	.6478	.2271	.5525
13	.4191	.4824	.9297	1.403	.7026	.2484	.5212
14	.4047	.4664	1.8488	1.2117	.7103	.5319	.4968
15	.4344	.4687	1.6934	1.2468	.6356	.4755	.4511
16	.474	.4938	1.6743	1.4434	1.2879	.5273	.442
17	.4718	.5175	1.6758	1.5806	1.4297	.4237	.4831
18	.3216	.74	1.1355	.9556	.8886	.5739	.2942
19	.3719	1.118	2.1521	.9221	.8368	.7575	.4054
20	.6996	1.6545	1.3703	.7819	.7407	1.1568	.7148
21	.7407	1.672	.8444	.8048	.7788	.7865	.7392
22	.7026	1.5394	1.3184	.7423	.7072	.7362	.7255
23	.6904	1.48	1.893	.6859	.7026	1.5538	.6691
24	.5319	.7514	1.262	1.0471	.4283	.4466	1.3816
Max	2.1414	1.672	2.1521	1.5806	1.4297	1.5538	2.2656
Min	.3216	.4359	.5906	.5395	.2865	.2271	.2942
Avg	.6871	.8324	1.3759	.9618	.7624	.6266	.7350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272] BU 5452

Substation No/ Name :- 184075 / NIMGAON

Feeder No / Name : 203 / C & M

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0857				
2			.1029				
3			.12				
4			.1029				
5			.1029				
6			.1029				
7	.1334		.1372				
8			.12				
9	.1524		.12	.1334			
10	.1905	.0953	.1715	.1334			.1524
11	.1334	.1143	.1143	.1334			.1334
12	.1524	.1143	.0953	.1524			.1905
13	.1334	.1334		.1524			.1334
14	.1334	.1143	.1524	.1334		.1905	.1143
15	.1334	.1143	.1334	.1524		.1715	.1524
16	.1143	.1334	.1524	.1905	.1143	.1905	.1334
17	.1524	.1143	.1715	.1715	.1334	.1715	.1143
18		.1029	.1715				
19		.12	.1334			.1334	
20		.1029	.1524				
21		.1029	.1334			.1524	
22		.1029	.1715				
23		.1029	.1143				
24			.1029	.1334			.1143
Max	.1905	.1334	.1715	.1905	.1334	.1905	.1905
Min	.1143	.0953	.0857	.1334	.1143	.1334	.1143
Avg	.1429	.1120	.1289	.1486	.1239	.1683	.1376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184075 / NIMGAON

Feeder No / Name : 205 / 11 Kv PatPimpri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2743				
2			.2401				
3			.2058				
4			.4801				
5			.5487				
6			.6173				
7	.5144		.048				
8			.2743				.362
9	.5335		.2058	.2286			
10	.1524	.2286	.1715	.1334			
11	.1524	.1715	.1334	.1334			.1905
12	.1143	.1524	.2286	.1143			.1524
13				.1143			.2286
14	.1334	.1143	.1524	.1905		.1715	
15	.1524		.1905	.2286		.1905	.1143
16	.1143	.1524	.2096	.1905	.2286	.1524	.1334
17	.1334	.1524	.3429	.3048	.2477	.1905	
18		.2058	.381				
19		.3429	.3429				
20		.5144					
21		.583				.2858	
22		.5144					
23		.4115	.381			.2858	
24			.3429	.2096			.4763
Max	.5335	.583	.6173	.3048	.2477	.2858	.4763
Min	.1143	.1143	.048	.1143	.2286	.1524	.1143
Avg	.2223	.2953	.2886	.1848	.2382	.2128	.2368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184075 / NIMGAON

Feeder No / Name : 206 / 11 KV Hiwargaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9259				
2			.823				
3			.7888				
4			.6859				
5			.823				
6			.7202				
7	.6478		1.0974				
8			1.3717				.1524
9	.5716		1.1317	1.0669			
10	.2667	.2286	.2286	.2858			.2858
11	.2286	.2286	.1905	.2858			.2286
12	1.2955	1.0098	.2096	.1905			1.4098
13	1.1431	.9145					1.3717
14	1.1812	.8764	.1143	.1905		1.2193	1.3717
15	1.3336	.9335	.1143	.1524		1.1812	1.3336
16	1.3717	.9907	.1334	.2286	.2286	1.2955	1.2955
17	1.448	1.1812	.1905	.2477	.2477	1.5623	1.3336
18		.9602	.3429			1.6766	
19		.8916	.6668			1.6194	
20		.6516	.724			.724	
21		.7202	.6668			.5716	
22		.6859	.5716				
23		.6173	.8573			.2286	
24			1.0288	1.1431			.2858
Max	1.448	1.1812	1.3717	1.1431	.2477	1.6766	1.4098
Min	.2286	.2286	.1143	.1524	.2286	.2286	.1524
Avg	.9488	.7779	.6264	.4213	.2382	1.1198	.9069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184217 / Sonambe(Wadgaon)

Feeder No / Name : 201 / Wadgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144		.2374		.5335
2	.5144	.5335		.2374		.5335
3	.5335	.5335		.2543		.5525
4	.5716	.5335		.2458		.6097
5	.6097	.6097		.2429		.6859
6	.7621	.743		.4001		.8573
7	.7621	.6478		.6554		.6668
8	.6097	.6287		.7449		.6478
9	.5335	.4763	.381			.5144
10	.4191	.4001	.3239		.381	.381
11	.4801	.1698	.2858		.3429	.3239
12	.4973	.5182	.381		.4999	.3681
13	.4588	.4843	.381		.3864	.3437
14	.4218	.442	.4001		.3292	.2968
15	.4372	.3437	.381		.3286	.3086
16	.4161	.3906	.381		.431	.3593
17	.6249	.4999	.362	.4191	.5868	.4321
18		.5182	.4572	.4954	.7095	.578
19			.5716	.5144	.5498	.6859
20			.7049	.6668	.6859	.7621
21			.7049	.6668	.6668	.724
22			.6668	.6097	.6478	.7049
23			.6097		.5906	.4954
24	.5144			.2543		.5335
Max	.7621	.743	.7049	.7449	.7095	.8573
Min	.4161	.1698	.2858	.2374	.3286	.2968
Avg	.5378	.4993	.4661	.4430	.5097	.5374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184217 / Sonambe(Wadgaon)

Feeder No / Name : 202 / Sonambe

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7049		.3353	.3315		.8192
2	.6859	.724		.3353	.3647		.8192
3	.7049	.724		.3521	.3605		.8383
4	.8002	.7621		.3725	.3978		.9145
5	.9526	.9907		.3953	.4424		1.0288
6	1.1431			.5121	.4858		1.2193
7	.7049			.9069	.8482		1.0098
8	.743	.6859		.9442	.8749		.7811
9	.6097	.6668	.4001				.5716
10	.4001	.5335	.4763			.6287	.4191
11	.381	.2538	.5335			.5525	.4475
12	.663	.4489	.5144			.679	.5079
13	.6226	.4664	.5144			.5792	.5304
14	.5735	.4489	.5335			.447	.3768
15	.5967	.4108	.4763			.4652	.3521
16	.6226	.4515	.4382			.5647	.5121
17	.6802	.6249	.4572	.5716		.6573	.6882
18		.6472	.6668	.5525		.7287	.7209
19			.8954	.4763		.6472	.7621
20			1.105	.9907		1.105	1.1622
21			1.086	1.0669		1.1431	1.105
22			1.0669	1.0479		1.0479	1.0288
23			1.0288	.2713		.9526	.8192
24	.724			.3521	.3149		.8573
Max	1.1431	.9907	1.105	1.0669	.8749	1.1431	1.2193
Min	.381	.2538	.4001	.2713	.3149	.447	.3521
Avg	.6830	.5965	.6795	.5927	.4912	.7284	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184217 / Sonambe(Wadgaon)

Feeder No / Name : 203 / 11 KV KONAMBE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5967		.6097	.5716		.4588
2	.6219	.6036		.6097	.5906		.4588
3	.6219	.6371		.6097	.5906		.4696
4	.6516	.6443		.6287	.6097		.5182
5	.7164	.6706		.6287	.6859		.6226
6	.788	.7865		.724	.724		.8097
7	1.4198	1.3279		.6668	.6097		1.2176
8	1.3735	1.2631		.4763	.4763		1.0936
9	.2667	.381	.3239				.7287
10	.1524	.3048	.2667			.2286	.381
11	.1524	.1905	.2096			.2858	.2858
12	.1715	.2477	.9831			.2667	.2667
13	.2286	.2858	.9012			.2667	.2667
14	.2667	.2477	.7127			.2667	.2858
15	.2858	.1905	.6962			.2667	.3048
16	.2858	.1905	.7209			.3048	.2858
17	.3048	.2286	.7611	.7842		.2858	.3429
18		.2477	.6802	.8097		.3239	.381
19			.5967	.3429		.5144	.5525
20			.724	.6668		.6859	.7811
21			.7049	.7049		.7049	.7621
22			.7049	.7049		.6668	.6371
23			.6668	.6097		.6478	.3353
24	.6283			.6478	.5716		.4641
Max	1.4198	1.3279	.9831	.8097	.724	.7049	1.2176
Min	.1524	.1905	.2096	.3429	.4763	.2286	.2667
Avg	.5257	.5025	.6435	.6390	.6033	.4083	.5296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184233 / 33/11 KV STICE

Feeder No / Name : 203 / 11 KV STICE No 3

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4061	2.8957	3.5574	2.6671	3.316	.9145	4.4454
2	4.4076	2.8022	3.3745	3.0451	3.5809	.8383	3.7845
3	3.7256	3.0415	3.8653	2.3834	3.0866	1.2955	3.2013
4	4.2371	2.0454	3.5255	2.7629	2.6316	1.2193	3.6925
5	3.6879	2.3668	3.0721	3.0496	2.7825	1.0669	4.293
6	1.6863	2.7448	3.2205	3.3114	2.4626	.8383	3.2729
7	1.6116	3.2164	3.0235	3.236	2.2544	.8383	3.4065
8	2.345	3.1779	2.0881	3.2164	2.2559	.9145	3.3303
9	3.1967	2.2748	3.2709	3.8207	2.7433	1.7995	3.3092
10	2.8369	4.2371	3.9007	3.6539	3.8048	2.8233	1.3717
11	2.6482	4.0349	4.6725	4.5063	4.7283	4.4084	4.7841
12	1.7044	4.2098	2.9569	3.1274	3.0527	2.9018	4.5027
13	2.1594	2.3776	2.1986	3.5581	3.8222	2.1239	3.9354
14	1.7414	4.2737	2.4227	3.9172	4.957	4.1059	4.9019
15	2.3095	4.7495	2.234	4.3904	4.1785	4.3919	4.5593
16	1.5362	4.6396	2.5932	3.9731	2.8791	4.9374	4.8431
17	1.7044	3.1641	2.612	4.9004	1.6004	4.7125	4.2991
18	2.9704	3.0606	2.1775	4.5617	1.6004	2.5577	2.9592
19	1.7718	2.9629	2.1578	2.5207	1.2955	3.6147	2.652
20	1.8183	3.7982	1.9873	3.5928	.9145	3.9731	3.8395
21	2.0439	4.1244	2.4408	4.4281	1.5242	2.689	4.711
22	1.9685	3.73	2.007	3.8434	1.1431	2.3502	4.1821
23	1.7029	4.161	2.3465	2.7644	1.1431	4.6906	4.6151
24	3.8334	2.7887	3.3623	2.8037	2.9176	1.6004	4.7503
Max	4.4076	4.7495	4.6725	4.9004	4.957	4.9374	4.9019
Min	1.5362	2.0454	1.9873	2.3834	.9145	.8383	1.3717
Avg	2.5856	3.3699	2.8778	3.5014	2.6948	2.5669	3.9018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184233 / 33/11 KV STICE

Feeder No / Name : 401 / 33 KV Musalgaon

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.6389	3.4168	6.2243		6.1677		6.3375
2	8.2047	3.0556	5.715	5.8848	5.998		5.8282
3	6.7901	3.9043	6.1677	5.6019	5.7716		6.2809
4	6.3375	3.2819	5.036	5.6584	5.6019		5.6019
5	5.3755	2.9127	3.5648	5.0926	5.4321		5.4887
6	5.0926	3.3608	4.0741	5.036	5.3755		5.0926
7	3.7346	3.7912	4.2438	4.2438	6.3375		6.4506
8	3.5082	6.1054	6.1677	6.1111	6.677		6.7335
9	3.0247	7.0782	8.1482	7.2994	8.1219	8.4877	7.6955
10	2.5766	8.5791	9.1101	9.0535	9.1667	9.0535	
11	1.9239	8.4659	9.4496	8.8838	9.4102	10.2418	9.2233
12	2.7446	7.7103	8.6008	8.1482	7.8978	8.5443	7.6389
13	2.4897	6.9959	7.5823	7.8652	7.8418	8.6008	8.3179
14	2.2965	8.682	9.1101	8.4311	9.2798	7.7521	9.1101
15	1.6409	8.738	8.2047	8.4877	8.85	9.4496	8.8838
16	2.2634	8.8889	8.7706	9.7325	8.1779	9.6194	9.2798
17	2.3765	8.6643	9.3364	9.6194		9.3364	8.8838
18	2.6029	8.7963	8.3179	8.2047		8.2047	8.6008
19	2.6886	7.2531	6.2243	6.7901		6.9033	6.8467
20	2.32	7.7298	5.9414	5.6019		5.7716	6.9033
21	2.9424	6.8039	5.8848	6.4506		6.4506	6.0545
22	3.3608	6.1054	5.9414	6.7335		6.2243	5.8282
23	3.4517	6.2734	5.3755	5.8848		5.6584	5.2058
24	7.0165	7.0782	6.677	5.998	5.7716		7.0731
Max	8.2047	8.8889	9.4496	9.7325	9.4102	10.2418	9.2798
Min	1.6409	2.9127	3.5648	4.2438	5.3755	5.6584	5.0926
Avg	3.8501	6.4030	6.8279	6.9919	7.1694	8.0199	7.1026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184233 / 33/11 KV STICE

Feeder No / Name : 402 / 33 KV Ring Gear

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0751	.3961	.5093	.7356			1.358
2	1.2449	.5093	.5093	.7356			1.6409
3	.9054	.4527		.7922			1.7541
4	1.3014	.4527	.9619	.9054			1.5278
5	1.1883	.3961	1.358	.9054			1.7541
6	1.1317	.3961	.8488	1.5278			1.4146
7	.3395	.5093	1.0185	1.3014			1.1317
8	.2829	.0566	1.1883	1.0185			1.1317
9	.2829		.9619	1.358	.9619	1.1317	1.358
10	.2829		1.4712	1.358	1.9239	1.5844	
11	.3395		1.3014	1.4712	.8488	1.358	.3961
12	.3395		1.2449	1.358	1.1883	1.3014	.3395
13	.3395		1.5844	.8488	1.0185	.5658	1.5844
14	.2829		.2829	1.4146	1.0185	.3961	.5658
15	.3395			1.1883	.8488	2.1502	.6224
16	.3395			.9054	.8488	1.4146	.9619
17	.3395		1.1883	1.9805		1.2449	.5093
18	.3395		1.358	.2829		.4527	.7356
19	.3961		1.1883	.5658		1.2449	.4527
20	1.0751		1.4712	1.5844		.679	.2263
21	.0566		.7356	1.4712		1.358	.679
22	.3395		1.6409	1.9239		.9619	1.1883
23			.7356	.5093		.6224	1.4146
24	.9054	.2829	.9619	1.5278			.9619
Max	1.3014	.5093	1.6409	1.9805	1.9239	2.1502	1.7541
Min	.0566	.0566	.2829	.2829	.8488	.3961	.2263
Avg	.5855	.3835	1.0724	1.1529	1.0822	1.0977	1.0308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184233 / 33/11 KV STICE

Feeder No / Name : 403 / 33 KV Bellota

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566		.0566	.0566		.0566
2	.0566	.0566		.0566	.0566		.0566
3	.0566	.0566		.0566	.0566		.0566
4	.0566	.0566		.0566	.0566		.0566
5	.0566	.0566		.0566	.0566		.0566
6	.0566	.1132	.2241	.0566	.7922		.0566
7	.0566	.2829	.2058	.1132	1.0751		.1698
8	.0566	.2263	.3292	.3961	1.1883		.2263
9	.0566	.3961	.2195	.3395	1.2449	.2263	.3395
10	.0566	.3841	.3961	.3961	1.358	.2263	
11	.0566	.3292	.3961	.3395	1.3014	.2263	.4527
12	.0566	.3292	.3395	.2829	1.2449	.3395	.3395
13	.0566	.3841	.3961	.2263	1.1883	.2263	.3395
14	.0566	.2572	.3961	.3395	1.3014	.2263	.3961
15	.0566	.2172	.2263	.3395	1.1883	.1132	.3961
16	.0566	.2263	.3961	.3395	1.2449	.3961	.3961
17	.0566	.3841	.4527	.3395		.2829	.3961
18	.0566	.3841	.3961	.3961		.1698	.3395
19	.0566	.2829		.3395		.1698	.3395
20	.0566	.3292	.2263	.3395		.1698	.2829
21	.0566	.3292	.2829	.3395		.1698	.2829
22	.0566	.3361	.2829	.2829		.1698	.2829
23	.0566	.2801	.2829	.0566		.1698	.1698
24		.0566		.0566	.0566		.0566
Max	.0566	.3961	.4527	.3961	1.358	.3961	.4527
Min	.0566	.0566	.2058	.0566	.0566	.1132	.0566
Avg	.0566	.2421	.3205	.2334	.7922	.2188	.2411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184247 / 33/11 KV NEW MALEGAON SUB

STAT

Feeder No / Name : 208 / MIDC 8

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.3921	.5658	.5281	.5716		.5335
2	.5716	.4066	.5658	.5281	.4763		.4763
3	.5144	.3881	.547	.547	.381		.381
4	.4763	.4108	.547	.5658	.4191		.4191
5	.5335	.3921	.5658	.5847	.4954		.5144
6	.5525	.4108	.5847	.6036	.4763		.5335
7	.5335	.4481	.547	.6602	.5144		.5716
8	.381	.5041	.6413	.679	.5716		.7621
9	.4191	.6908	.7733	.8676	.8002	.9335	1.0098
10	.3584	.9997	1.1128	.9619		1.105	1.1431
11	.2829	.9808	.9997	.9997	1.1241	1.0098	1.0479
12	.3018	.9054	1.0185	.9808	.9145	1.0669	1.0098
13	.3584	.811	.811	.9431	.8383	.9145	.9335
14	.3584	.7733	.7922	.9619	.8954	.9526	.9717
15	.3584	.7922	.8488	.9808	.9335	.9335	1.0479
16	.3395	.5658	.9431	1.1694	.9907	.9717	1.1622
17	.3206	.9431	.9808	1.1694	.9145	.8002	1.0185
18	.3018	.9431	.7922	.9526		.9907	.9808
19	.3734	.7545	.679	.8002		.8573	.811
20	.3696	.679	.5847	.6668		.6668	.5847
21	.3734	.5658	.5847	.6097		.6097	.6224
22	.3921	.6224	.5847	.5716		.6668	.679
23	.3921		.5093			.6097	.6413
24	.381	.4108	.5847	.5281	.5716		.5335
Max	.6478	.9997	1.1128	1.1694	1.1241	1.105	1.1622
Min	.2829	.3881	.5093	.5281	.381	.6097	.381
Avg	.4121	.6431	.7152	.7765	.6993	.8726	.7662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184247 / 33/11 KV NEW MALEGAON SUB

STAT

Feeder No / Name : 210 / 11 KV MIDC No 10

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7528	.7682	1.6617	1.467	1.8099		1.6194
2	1.7147	.7865	1.6244	1.4289	1.7147		1.4289
3	1.6194	.7783	1.6057	1.4098	1.4289		1.2384
4	1.5623	.8596	1.587	1.3908	1.3717		1.3146
5	1.5242	.961	1.531	1.3717	1.3336		1.3717
6	1.5242	1.0164	1.4937	1.3717	1.3717		1.3336
7	1.2955	.9425	1.4003	1.4712	1.3146		1.3336
8	.9526	1.2696	1.6804	1.7528	1.6575		1.7147
9	.9145	1.5123	1.848	2.0957	2.191	2.2481	1.9433
10	.9231	2.4331	2.6673	2.7244		2.8387	2.4577
11	.7343	2.3577	2.7244	2.7625	2.7054	3.0293	1.7909
12	.6556	2.2862	2.3624	2.6101	2.3624	3.0864	2.21
13	.6516	2.3434	2.2481	2.3434		2.4958	2.3624
14	.7468	2.3053	2.4768	2.4768	2.3053	2.8769	2.572
15	.7762	2.2862	2.8769	2.9531	2.3815	2.8578	2.6673
16	.7947		2.8769	2.9912	2.4768	2.8006	2.7054
17	.7499	1.5813	2.572	2.8578	2.3434	1.6766	2.4768
18	.7762	1.4289	2.3815	2.572		2.2862	1.7147
19	.7947	1.8671	2.21	2.3243		2.1338	1.8099
20	.8316	1.7909	2.1148	2.0386		2.0386	1.6575
21	.8131	1.7718	1.9239	1.9433		2.0005	1.5466
22	.7682	1.7528	1.848	1.848		1.9433	1.467
23	.6516		1.5242			1.9052	1.6057
24	1.7147	.7499	1.6804	1.4861	1.9052		1.6194
Max	1.7528	2.4331	2.8769	2.9912	2.7054	3.0864	2.7054
Min	.6516	.7499	1.4003	1.3717	1.3146	1.6766	1.2384
Avg	1.0518	1.5386	2.0383	2.0735	1.9171	2.4145	1.8317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 184247 / 33/11 KV NEW MALEGAON SUB

STAT

Feeder No / Name : 212 / 11KV MIDC No 12

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6487	3.1112	5.1751	4.8733	5.1631	2.5911	4.3248
2	4.401	3.0739	5.0808	4.8356	5.0107	2.5911	4.382
3	4.1724	3.0365	5.0242	4.6644	4.4963	2.5911	4.1915
4	3.9819	3.1086	4.8341	4.7602	4.5344	2.4387	4.0961
5	3.7342	2.824	4.6062	4.5889	4.4773	2.4387	3.9818
6	3.5818	2.824	4.4915	4.2463	4.3629	2.2862	4.0771
7	3.4865	2.8429	4.3987	4.6062	4.42	2.2862	4.039
8	2.8197	3.2406	4.7382	4.5119	4.763	2.2862	4.3248
9	2.7625	5.4596	6.7844	6.7655	6.6682	6.5348	5.7537
10	2.5207	6.008	7.4476	7.1474	3.5056	7.2969	6.7254
11	2.6339	5.7644	7.7917	6.921	7.2398	7.5827	6.3253
12	2.5962	5.5727	7.2794	6.9007	6.8778	6.7635	5.7346
13	2.1986	5.6497	7.0704	6.9965	6.6873	6.4968	6.2109
14	2.5585	5.7832	7.1826	7.0683	7.0874	6.592	6.249
15	2.5396	5.9922	7.4303	7.4333	7.3541	7.0683	6.4396
16	2.5962	3.0483	7.6208	7.3541	7.5827	6.7825	6.0776
17	2.5962	2.2862	7.6408	7.7162	7.0493	5.7537	6.2563
18	2.5636	6.7105	6.7498	7.5827	3.658	6.7825	5.8021
19	2.5499	6.2201	6.5974	7.1826	3.658	6.1157	5.7266
20	2.6053	5.4626	5.3494	5.8108	3.0483	5.1821	4.4395
21	2.5869	4.8341	4.853	5.506	2.5911	4.7058	4.3987
22	2.5823	5.117	4.985	5.7156	2.5911	4.8583	4.9676
23	3.0147	2.7435	4.853	2.8959	2.5911	4.7249	4.7036
24	4.0962	4.1968	4.8718	5.2159	5.4108	2.4387	4.4773
Max	4.6487	6.7105	7.7917	7.7162	7.5827	7.5827	6.7254
Min	2.1986	2.2862	4.3987	2.8959	2.5911	2.2862	3.9818
Avg	3.0761	4.3713	5.9523	5.8875	5.0345	4.7995	5.1544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272] BU 5452

Substation No/ Name :- 187009 / SINNER

Feeder No / Name : 201 / INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.3048	1.2193	.6097	.9145	.9145	1.2193
2	.6097	.3048	1.2193	.6097	.9145	.9145	1.2193
3	.6097	.3048	1.2193	.6097	.9145	.9145	.9145
4	.6097	.3048	.9145	.6097	.9145	.9145	.9145
5	.6097	.3048	.6097	.6097	.9145	.9145	.9145
6	.6097	.3048	.6097	.6097	.9145	.9145	.9145
7	.6097	.6097	.6097	.6097	.9145	.9145	.9145
8	.3048	.6097	.6097	.9145	.9145	1.2193	1.2193
9	.3048	.9145	.9145	1.2193	1.2193	1.5242	1.5242
10	.3048	1.2193	.9145	1.2193	1.2193	1.5242	1.5242
11	.6097	1.2193	.9145	1.2193	1.2193	1.5242	1.5242
12	.6097	1.2193	.9145	1.5242	1.2193	1.5242	1.5242
13	.6097	1.5242	.9145	1.2193	1.5242	1.829	1.5242
14	.6097	1.5242	1.2193	1.2193	1.5242	1.829	1.829
15	.6097	1.5242	1.2193	1.2193	1.5242	1.829	1.829
16	.6097	1.5242	1.2193	1.5242	1.5242	1.5242	1.5242
17	.6097	1.829	1.2193	1.829	1.829	1.829	1.829
18	.6097	1.829	1.2193	1.829	1.829	1.829	1.829
19	.6097	1.829	.9145	1.5242	1.829	1.2193	1.5242
20	.3048	1.2193	.9145	1.2193	1.2193	.9145	1.2193
21	.3048	1.2193	.6097	1.2193	1.2193	.9145	1.2193
22	.3048	1.2193	.6097	1.2193	.9145	1.2193	1.2193
23	.3048	1.2193	.6097	1.2193	.9145	1.2193	.9145
24	.3048	1.2193	.6097	1.2193	.9145	1.2193	.9145
Max	.6097	1.829	1.2193	1.829	1.829	1.829	1.829
Min	.3048	.3048	.6097	.6097	.9145	.9145	.9145
Avg	.5081	1.0542	.9145	1.1177	1.2066	1.2955	1.3209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272]

BU 5452

Substation No/ Name :- 187009 / SINNER

Feeder No / Name : 202 / 11kV SINNER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	3.0483	3.3532	3.3532	3.3532	3.3532	3.3532
2	2.7435	2.7435	3.0483	3.0483	3.0483	3.0483	3.0483
3	2.7435	2.7435	3.0483	3.0483	3.0483	3.0483	3.0483
4	2.7435	2.7435	2.7435	2.7435	3.0483	3.0483	3.0483
5	2.7435	2.7435	3.0483	3.0483	3.0483	3.0483	3.0483
6	3.0483	3.0483	3.658	3.0483	3.3532	3.3532	3.3532
7	3.3532	3.3532	3.658	3.3532	3.3532	3.658	3.3532
8	3.3532	3.3532	3.3532	3.3532	3.3532	3.658	3.658
9	3.0483	3.3532	3.3532	3.3532	3.3532	3.3532	3.3532
10	3.0483	3.3532	3.3532	3.3532	3.658	3.3532	3.3532
11	3.0483	3.0483	3.0483	3.3532	3.658	3.3532	3.3532
12	3.0483	3.0483	3.0483	3.3532	3.3532	3.9628	2.7435
13	3.0483	3.3532	3.0483	3.3532	3.3532	3.9628	2.7435
14	3.0483	3.0483	3.0483	3.0483	3.3532	3.658	2.7435
15	3.0483	3.0483	3.3532	3.3532	3.658	3.3532	3.0483
16	3.0483	3.0483	3.3532	3.3532	3.9628	3.3532	3.658
17	3.3532	3.0483	3.3532	3.3532	3.9628	3.3532	3.3532
18	3.3532	3.3532	3.3532	3.658	3.9628	3.658	3.9628
19	3.658	3.658	3.3532	3.658	3.9628	3.658	3.9628
20	4.2676	4.5725	4.5725	4.5725	4.5725	4.5725	4.5725
21	4.2676	4.5725	4.2676	4.5725	4.5725	4.5725	4.5725
22	3.9628	4.2676	3.9628	4.2676	4.2676	4.2676	4.2676
23	3.9628	3.9628	3.9628	3.9628	4.2676	3.9628	3.9628
24	3.3532	3.658	3.658	3.658	3.658	3.658	3.9628
Max	4.2676	4.5725	4.5725	4.5725	4.5725	4.5725	4.5725
Min	2.7435	2.7435	2.7435	2.7435	3.0483	3.0483	2.7435
Avg	3.2515	3.3405	3.4167	3.4675	3.6326	3.5945	3.4802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272] BU 5452

Substation No/ Name :- 187009 / SINNER

Feeder No / Name : 203 / 11kV DEOPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.3048	.3048	.3048		
9			.3048	.3048	.3048		
13	.3048	.3048				.3048	.3048
14						.3048	.3048
18						.3048	.3048
19						.3048	
Max	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Min	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Avg	.3048	.3048	.3048	.3048	.3048	.3048	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SINNAR-I[272] BU 5452

Substation No/ Name :- 187009 / SINNER

Feeder No / Name : 207 / 11kV MALEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.3048		.3048	.3048	.3048	.3048	.3048
8	.3048	.3048	.3048	.3048	.3048	.3048	.3048
9	.3048	.3048	.3048	.3048	.3048	.3048	.3048
10	.3048	.3048	.3048	.3048	.3048	.3048	
11	.3048		.3048	.3048	.3048	.3048	.3048
12	.3048		.3048	.3048		.3048	
13	.3048		.3048				
17				.3048			
18	.3048		.3048	.3048	.3048		
19	.3048	.3048	.3048	.3048	.3048	.3048	.3048
20	.3048	.3048	.3048	.3048	.3048	.3048	.3048
21		.3048	.3048	.3048	.3048		
Max	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Min	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Avg	.3048	.3048	.3048	.3048	.3048	.3048	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SURGANA SUB-DIVISION[829] BU 4829

Substation No/ Name :- 184021 / surgana

Feeder No / Name : 203 / Borgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.5373	.6401	.6268		.543
2	.7164	.5373	.6401	1.4864		.5316
3	.7164	.591				
4	.7164	.591				.6401
5	1.0745	.7762				.7316
6	1.0745	.9145				.6767
7	1.086	1.0387				.9431
8	.8954	.4755				.9335
9	.8954		.3582	.5373		
10			.5373			
11			.5194			
12			.7164			
13			.6626			
14			.591			
15	.3582	.3475	.591		.4572	
16	.4298	.5175	.6089			.5028
17	.4477	.5228	.394		.5487	.6068
18	.5731	.5121	.5194		.6099	.6401
19	.6626	.724	.6984		.7947	.7011
20	.8775	.823	.6626		.9145	
21	.8417	.7865	.7164			.8669
22	.8059	.7164	.7164			.6241
23	.8059	.6335	.6268		.7682	.6154
24	.5373	.7164	.6335	.6268		.724
Max	1.086	1.0387	.7164	1.4864	.9145	.9431
Min	.3582	.3475	.3582	.5373	.4572	.5028
Avg	.7490	.6534	.6018	.8193	.6822	.6854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SURGANA SUB-DIVISION[829] BU 4829

Substation No/ Name :- 184021 / surgana

Feeder No / Name : 204 / Palsan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.4864		
3		1.0208				.3658
4	.7164	1.0208				.5121
5	.7164	1.134				.6535
6	.905	1.1888				.6401
7	.905	1.2851				.6767
8	1.0745	1.0974				.7316
9	1.0745	.9055				1.5415
10	1.182	1.7924				1.5581
11	1.3969	1.0425				
12	1.3969	1.5708			1.6461	
13	1.3969	1.4327			1.5546	
14	1.3969	1.4784			1.4327	
15	1.1641		1.1104			
16			1.5581			.9816
17			1.5043			
18			1.6476			
19			1.7909		1.2936	
20			1.7909			
21			1.7909			
22			1.7909			
23			1.6476			
24				1.5581		
Max	1.3969	1.7924	1.7909	1.5581	1.6461	1.5581
Min	.7164	.9055	1.1104	1.4864	1.2936	.3658
Avg	1.1105	1.2474	1.6257	1.5223	1.4818	.8512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SURGANA SUB-DIVISION[829] BU 4829

Substation No/ Name :- 184021 / surgana

Feeder No / Name : 205 / UMBERTHAN

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	1.6118	1.6289			1.6461
2	1.7909	1.576	1.5912			1.6827
3	1.7909		1.5223			
4			1.6263			
5			1.6461			
6			1.7013			
7			1.829	.985		
8			1.7926	.985		
9			1.2536	1.1283		
10			1.5581			
11			1.5581			
12	1.7909		.7343			
13			.7343			
14			.7343			
15	1.1641				.9694	.9536
16	1.97	.8779				2.0157
17	1.97	1.1888			1.2403	1.949
18	2.0595	1.0719			1.4937	1.8804
19	2.0595	2.1622			1.9204	2.1491
20	2.2028	2.2862			2.0328	1.4403
21	1.8099	2.2386				1.3603
22	1.7909	2.0328			2.1719	1.3592
23	1.7013	1.9204			2.0119	1.2631
24	1.97	1.1888	1.848			1.9404
Max	2.2028	2.2862	1.848	1.1283	2.1719	2.1491
Min	1.1641	.8779	.7343	.985	.9694	.9536
Avg	1.8473	1.6505	1.4506	1.0328	1.6915	1.6367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SURGANA SUB-DIVISION[829] BU 4829

Substation No/ Name :- 184213 / 33/11 KV BORGAON

Feeder No / Name : 201 / 11 KV SHINDE

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.5975	.3086	.3601	.3201		.6173
2	.7316	.8215	.3086	.3601	.3201		.6173
3	.7316	.8779	.3086	.3772	.3353		.6859
4	.7926	.9511	.3429	.3772	.442		.7202
5	.8383	1.0242	.3429	.5658	.4572		.823
6	.8688	1.1222	.4287	.583	.4572		.8916
7	.884	1.2696	.4801	.5144	.4877		1.0974
8	.8688	1.1888	.3429	.3601	.2591		.8916
9	.7011	.9328	.1715	.2572	.1829		.703
10	.2134	.2378	.1715				.1715
11	.2378	.2229	.1543	.1677			.1715
12	.1294	.12	.9088	.7468	1.0164		.1372
13	.1663	.12	.9088	.7468	1.0608		.1372
14	.128	.12	.9088	.7316	1.0136	.1372	.1543
15	.1478	.12	.9431	.6401		.12	.1543
16	.1463	.1372	.9431	.7011	.8048	.1372	.1372
17	.1867	.1543	.9431	.7164		.1372	.1715
18	.2587	.2401	1.0117	.6401		.2401	.2572
19	.3475	.2915	.8573	.5487		.3258	.2915
20	.3658	.3258	.3429	.4572		.3429	.3429
21	.3511	.3429	.3601	.3658		.3601	.3429
22		.3601	.3601	.3353		.3429	.3429
23	.3361	.3258	.3429	.3201		.3086	.3258
24	.6283		.3258	.3601	.3201		.6001
Max	.884	1.2696	1.0117	.7468	1.0608	.3601	1.0974
Min	.128	.12	.1543	.1677	.1829	.12	.1372
Avg	.4685	.5176	.5215	.4884	.5341	.2452	.4494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SURGANA SUB-DIVISION[829] BU 4829

Substation No/ Name :- 184213 / 33/11 KV BORGAON

Feeder No / Name : 202 / 11 KV SARAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963	.4755	.823	1.3889	.1219		.4287
2	.4268	.4298	.8573	1.3717	1.2193		.4287
3	.4572	.439	.8573	1.3889	1.2193		.4287
4	.5792	.5121	.9431	1.3717	1.2955		.4801
5	.5944	.543	1.0288	1.3717	1.3717		.5144
6	.4572	.6283	1.3717	1.5089	1.5089		.6001
7	.4572	.6697	1.5432	1.7661	1.5242		.5144
8	.442	.6161	1.3717	1.5775	1.387		.4115
9		.4435	1.1145	1.2003			.3944
10		.3511	.3086				.3086
11		.2915	.2572	.2439			.3086
12		.9602	.2229	.2286	.2218		1.1831
13	1.6095	1.166	.1715	.2134	.2172		1.0631
14	1.5565	1.166	.1715	.2286	.2378	1.286	1.0288
15	1.5339	1.1488	.1715	.2439		1.1488	.9259
16	1.4563	1.166	.2401	.3048	.2957	1.2003	.9602
17	1.475	1.406	.3429	.3353		1.406	1.166
18	1.4563	1.406	.4115	.4268		1.3375	1.0974
19	1.363	1.2689	.5658	.503		1.1317	.9945
20	.7095	.6344	.5658	.5792		.6001	.5658
21	.5914	.6344	.583	.5487		.583	.583
22		.5316	.5658	.4877		.5658	.5144
23	.5729	.4973	.4973	.5487		.4801	.4801
24	.5121		.823	1.3717	.9145		.4458
Max	1.6095	1.406	1.5432	1.7661	1.5242	1.406	1.1831
Min	.3963	.2915	.1715	.2134	.1219	.4801	.3086
Avg	.8761	.7559	.6587	.8352	.8873	.9739	.6594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SURGANA SUB-DIVISION[829] BU 4829

Substation No/ Name :- 184213 / 33/11 KV BORGAON

Feeder No / Name : 203 / 11 KV BORGAON(H)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.9593	.4801	.5144	.4572		.8916
2	.9907	1.0136	.4801	.5316	.4572		.8916
3	1.0517	1.2197	.5144	.5144	.4572		.9259
4	1.0974	1.2803	.5144		.4725		1.0631
5	1.1431	1.3394	.5144	.5658	.4877		1.2003
6	1.1888	1.286	.6001	.6516	.5487		1.3889
7	1.2041	1.39	.5316	.5658	.5639		1.5604
8	1.2955	1.5912	.4287	.463	.4572		1.406
9	.9907	1.1523	.3429	.3772	.2896		1.2003
10	.2591	.2772	.3429				.3429
11	.3174	.2401	.3429	.2591			.3429
12	.2378	.2572	1.3032	1.0669	1.4415		.3258
13	.2987	.3086	1.3375	1.1126	1.4083		.2915
14	.2957	.3086	1.3546	1.0669	1.46	.2401	.2915
15	.3077	.3086	1.406	1.0517		.2743	.2915
16	.3475	.3086	1.4403	1.1431	1.3213	.3429	.3258
17	.3658	.3429	.1372	1.2193		.3944	.3944
18	.4066	.4287	1.3203	1.1888		.4287	.4458
19	.5914	.5144	1.2174	1.0364		.6001	.4973
20	.7023	.6687	.5487	.5792		.6516	.5144
21	.5914	.6516	.583	.5487		.6173	.5487
22		.5487	.583	.4572		.5658	.5487
23	.5415	.5144	.4801	.442		.4973	.5487
24	.9328		.4801	.5144	.442		.8573
Max	1.2955	1.5912	1.4403	1.2193	1.46	.6516	1.5604
Min	.2378	.2401	.1372	.2591	.2896	.2401	.2915
Avg	.7021	.7352	.7202	.7214	.7332	.4613	.7123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SURGANA SUB-DIVISION[829] BU 4829

Substation No/ Name :- 184213 / 33/11 KV BORGAON

Feeder No / Name : 204 / 11 KV HATGAD

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2282	.2772	.3136	.314	.29	.1139	.4021
2	.2217	.2563	.3072	.2903	.285	.1086	.3721
3	.2263	.2583	.2997	.2858	.2812	.1035	.3569
4	.2233	.2652	.2942	.2791	.2947	.1033	.3462
5	.2523	.2913	.2965	.2929	.3117	.1008	.3254
6	.2789	.3311	.3254	.3029	.3709	.1257	.3578
7	.2909	.343	.3472	.3091	.3265	.1225	.3624
8	.3063	.3559	.3521	.3649	.4149	.1341	.4362
9	.3543	.4262	.3234	.4136	.4237	.1383	.4041
10	.2051	.3662	.3898	.1461	.153	.1551	.4552
11	.2663	.3452	.3752	.3527	.1507	.1475	.4331
12	.3534	.3353	.4016	.3477	.422	.1427	.3862
13	.3797	.3307	.439	.3662	.4197	.1497	.4649
14	.3742	.3441	.4441	.3703	.4313	.461	.4641
15	.3936	.3789	.4458	.3764	.1517	.5214	.5035
16	.4004	.4079	.4033	.3957	.5228	.3374	.5685
17	.3866	.4405	.3662	.4053	.5422	.3502	.5883
18	.4081	.4287	.3326	.3963	.1629	.4412	.5655
19	.3515	.3816	.3119	.2677	.1315	.4287	.4801
20	.3797	.363	.3077	.3003	.1469	.4418	.5016
21	.3669	.3708	.3234	.3128	.1456	.4282	.4942
22	.121	.3698	.3136	.3088	.1345	.375	.4854
23	.3587	.3599	.3272	.3198	.1212	.3778	.4902
24	.2999	.1155	.3123	.3235	.4168	.4431	.4045
Max	.4081	.4405	.4458	.4136	.5422	.5214	.5883
Min	.121	.1155	.2942	.1461	.1212	.1008	.3254
Avg	.3095	.3393	.3480	.3268	.2938	.2605	.4437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-APR-17 and 14-APR-17

NASIK ZONE[057]

NASIK (U) CIRCLE[595]

NASIK RURAL DIVISION[604]

SURGANA SUB-DIVISION[829] BU 4829

Substation No/ Name :- 184213 / 33/11 KV BORGAON

Feeder No / Name : 205 / 11 KV RTO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	08-APR-17	09-APR-17	10-APR-17	11-APR-17	12-APR-17	13-APR-17	14-APR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.125	.1379	.1745	.2309	.1703	.0583	.2118
2	.1239	.1431	.1775	.2309	.1551	.0472	.205
3	.1406	.1435	.1726	.2134	.1536	.0507	.2061
4	.141	.1428	.1612	.2145	.1539	.0533	.2111
5	.1292	.1608	.1604	.2145	.1379	.0472	.1913
6	.1409	.1608	.1562	.2137	.1219	.0469	.1753
7	.1212	.1159	.1387	.2057	.0667	.0133	.1242
8	.0823	.096	.0628	.0514	.0674	.0187	.1284
9	.0617	.0606	.114	.0686	.112	.0206	.1261
10	.1409	.1002	.0952		.0194	.0221	.1223
11	.1818	.0552	.0678	.0568	.0198	.0324	.1616
12	.0566	.0548	.1025	.0842	.1101	.0366	.1997
13	.0732	.0598	.1208	.0903	.1219	.0312	.1726
14	.0549	.059	.075	.0827	.0732	.123	.1996
15	.1262	.0621	.0857	.107		.1349	.2084
16	.157	.1166	.1448	.0351	.0549	.2126	.194
17	.1299	.1406	.1036	.1356	.1779		.1661
18	.1448	.1376	.1295	.1498	.045	.2279	.1627
19	.1699	.1273	.1463	.1871	.0187	.1661	.1581
20	.1566	.2134	.1684	.2088	.0575	.1909	.1707
21	.1612	.2149	.1741	.2035	.0583	.1902	.1722
22	.0469	.2156	.1825	.1974	.0556	.213	.1722
23	.1776	.2153	.2153	.1775	.0556	.2137	.1726
24	.1638	.0587	.2145	.2035	.1544	.0594	.2061
Max	.1818	.2156	.2153	.2309	.1779	.2279	.2118
Min	.0469	.0548	.0628	.0351	.0187	.0133	.1223
Avg	.1253	.1247	.1393	.1549	.0940	.0961	.1758