

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 203 / 11 KV RIDHORA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17
HR	Load (MW)	Load (MW)
1	.4115	.4115
2	.4115	.4115
3	.4115	.4115
4	.4268	.4268
5	.4115	.4268
6	.4268	.4268
7	.4268	.4268
8	.4268	.4115
9	.4268	.4268
10	.4268	.4268
11	.4268	.4268
12	.4268	.4268
13	.4115	.4115
14	.4115	.4115
15	.4115	.4268
16	.4115	.4268
17	.4268	.442
18	.4268	.4268
19	.4115	.4115
20	.4115	.4268
21	.4115	.4268
22	.4115	
23	.4115	
24	.4268	
Max	.4268	.442
Min	.4115	.4115
Avg	.4185	.4224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 206 / 11 KV Jai Gajanan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	1.1675	1.153	1.1286	1.105	1.102	1.1172
2	1.086	1.0959	1.1043	1.0501	1.0395	1.0471	1.0288
3	1.0319	1.0463	1.041	.9938	1.0052	1.0181	.9686
4	1.0159	1.0166	.9998	.9808	.961	.9777	.932
5	.9907	.9922	.9755	.9313	.916	.9389	.8924
6	.929	.948	.9427	.8932	.8855	.8855	.8543
7	.9335	.9389	.9069	.8749	.8665	.8596	.8238
8	.8855	.8657	.8627	.8269	.8558	.8467	.8124
9	.7948	.8116	.7766	.7537	.7674	.7644	.7682
10	.7834	.772	.7415	.7438	.7186	.7446	.7225
11	.7849	.7217	.7781	.724	.7407	.7339	.7522
12	.8009	.7865	.7697	.7209	.7141	.7316	.7842
13	.8665	.8444	.8055	.7301	.7628	.788	.8421
14	.9633	.8977	.9267	.7933	.8848	.865	.8916
15	.9892	.9496	.9465	.8413	.9526	.9137	.9511
16	1.0219	.9755	.9724	.881	.9343	.9114	.9617
17	1.0212	.9496	.948	.8688	.9366	.8893	.9625
18	.9305	.8604	.8924	.8322	.9076	.865	.8901
19	.9038	.9175	.8223	.8657	.8596	.8467	.791
20	.9869	.9671	.8871	.8985	.8939	.9008	.9297
21	1.0128	.9739	.9267	.9305	.916	.9526	.9236
22	1.1126	1.0258	.9861	1.0204	.996	.9838	.9602
23	1.2064	1.1667	1.1142	1.1096	1.1164	1.0646	1.086
24	1.2269	1.201	1.1515	1.137	1.1385	1.1591	1.1111
Max	1.2269	1.201	1.153	1.137	1.1385	1.1591	1.1172
Min	.7834	.7217	.7415	.7209	.7141	.7316	.7225
Avg	.9765	.9538	.9346	.8971	.9114	.9079	.9066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 203 / 11 KV PALSO

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7207	.7023	.7207	.6838	.7392	.7023	.7023
2	.7023	.6653	.7095	.6838	.7023	.6653	.1955
3	.7023	.6653	.7023	.6838	.7095	.6838	.6838
4	.7023	.6468	.6653	.6838	.7023	.6653	.6838
5	.6653	.6468	.6653	.6838	.6838	.6468	.6283
6	.5914	.5914	.5914	.5914	.6099	.5359	.5359
7	.4805	.4066	.4435	.4805	.462	.499	.4805
8	.4805	.4251	.462	.4805	.4805		.4805
9	.4755	.4024	.4572	.4481	.4755	.4755	.4207
10	.5121	.4572	.5121	.4854	.5601	.4755	.4668
11	.5121	.4938	.5228	.5415	.1934	.4572	.4572
12	.5788	.4938	.5487	.5304	.5487	.4572	.5487
13	.6348	.5611	.5487	.5415	.5487	.7133	.5487
14	.6535	.5792	.5601	.5487	.5853	.6767	.5853
15	.6722	.6161	.6535	.6401	.6161	.6535	.5853
16	.4793	.6401	.591	.5975	.5853	.6219	.5853
17	.6805	.6268	.5373	.6219	.5853	.567	.6219
18	.7164	.6626	.4835	.6535	.5487	.5487	.5487
19	.7522	.6268	.6089	.7095	.1494	.567	.6401
20	.7164	.788	.6984	.7682	.8048	.7947	.7207
21	.6984	.788	.7164	.7762	.7947	.8131	.7023
22	.7207	.7522	.7164	.7762	1.7926	.7762	.7392
23	.6984	.7343	.6984	.7762	.7577	.7577	.7207
24	.7392	.6984	.7164	.6805	.7577	.7392	.7207
Max	.7522	.788	.7207	.7762	1.7926	.8131	.7392
Min	.4755	.4024	.4435	.4481	.1494	.4572	.1955
Avg	.6369	.6113	.6054	.6278	.6414	.6301	.5835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 204 / 11 KV KANSHIVANI,AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.8383	.8383	.8573	.7811		.0185
3		.8764	.8954	.8192	.743		.0185
4		.8501	.8383	.8192	.724		.0185
5		.8192	.7811	.8002	.724		.0185
6		.8383	.743	.7811	.6287		.0185
7		.8954	.8002	.8002	.7049		.0185
8		.9717	.8383	.8954	.6859		
9	.0183	.8402	.7655	.8215	.5487		.0187
10	.0183	.0183	.0183	.0187	.5975	.5975	.5601
11	.0187	.0183	.0183	.0187	.5487	.5601	.8215
12	.0187	.0183	.0183	.0187	.5487	.5487	.6908
13	.0183	.0183	.0183	.0187	.5487	.5487	.6908
14	.0187	.0183	.0183	.0183	.5853	.5601	.6908
15	.0183	.0183	.0183	.0183	.5601	.5601	.7095
16	.0183	.0183	.0179		.5853	.5975	.7842
17	.0179		.0179	.0183	.6348	.6535	.8215
18	.0179		.0179	.0185	.0183		.0187
19	.0179	.0179	.0179	.0187	.0183		
20	.0179	.0179	.0179	.0187	.0187		
21	.0179	.0179	.0179			.0191	
22	.0179	.0179	.0179			.0191	
23	.0179	.0179	.0179			.0191	
24		.0179	.0179	.0179			
Max	.0187	.9717	.8954	.8954	.7811	.6535	.8215
Min	.0179	.0179	.0179	.0179	.0183	.0191	.0185
Avg	.0182	.3412	.2944	.3578	.5371	.4258	.3699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 206 / 11 KV Rajeshwar Express. NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0029	.0029	.0032	.0029	.0029	.0029	.0029
2	.0029	.0029	.0032	.0029	.0029	.0029	.0029
3	.0029	.0032	.0032	.0029	.0029	.0029	.0029
4	.0029	.0032	.0032	.0029	.0029	.0029	.0029
5	.0029	.0032	.0032	.0029	.0029	.0029	.0029
6	.0029	.0027	.0029	.0029	.0029	.0067	.0029
7	.0029	.0027	.0029	.0029	.0029	.0029	.0029
8	.0029	.0029	.0029	.0029	.0029	.0029	.0029
9	.0069	.0067	.0072	.0067	.0183	.0067	.0067
10	.0069	.0067	.0067	.0187	.0067	.0067	.0067
11	.0067	.0067	.0183	.0067	.0067	.0067	.0067
12	.0067	.0067	.0183	.0067	.0067	.0067	.0067
13	.0067	.0067	.0183	.0187	.0067	.0067	.0183
14	.0183	.0069	.0183	.0183	.0067	.0067	.0067
15	.0183	.0067	.0187	.0067	.0183	.0067	.0067
16	.0183	.0067	.0029	.0067	.0067	.0067	.0067
17	.0057	.0029	.0057	.0067	.0067	.0067	.0067
18	.0057	.0029	.0029	.0183	.0067	.0067	.0067
19	.0029	.0029	.0029	.0067	.0067	.0067	.0067
20	.0029	.0029	.0029	.0183	.0067	.0029	.0029
21	.0029	.0029	.0029	.0029	.0029	.0029	.0029
22	.0029	.0057	.0029	.0029	.0029	.0029	.0029
23	.0057	.0029	.0029	.0029	.0029	.0029	.0029
24	.0029	.0029	.0029	.0029	.0029	.0029	.0029
Max	.0183	.0069	.0187	.0187	.0183	.0067	.0183
Min	.0029	.0027	.0029	.0029	.0029	.0029	.0029
Avg	.0060	.0043	.0066	.0073	.0058	.0048	.0051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 207 / 11 KV KANSHIVANI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.3326	.3142	.3142	.3326	.2957	.2858
2	.4066	.3326	.2772	.2957	.3326	.2938	.2587
3	.4066	.3142	.2772	.2957	.3142	.2772	.0185
4	.4066	.3142	.2772	.2957	.3142	.2957	.2587
5	.3734	.3142	.2772	.2587	.3142	.2957	.2402
6	.3326	.2772	.2402	.2402	.2772	.2772	.2402
7	.3142	.2033	.2033	.2587	.2218	.2033	.2218
8	.3511	.2218	.2772	.2402	.2033	.2402	.2402
9	.3361	.0183	.2801	.2801	.2378	.2561	.2378
10	.3475	.2378	.2743	.2801	.2561	.2743	.2561
11	.3292	.2561	.3109	.2801	.2801	.2378	.2614
12	.3475	.2561	.2926	.2987	.2378	.2427	.2987
13		.2743	.2926	.2987	.2378	.2743	.2926
14		.2743	.2987	.2926	.2561	.2743	.3109
15		.2926	.3361	.0183	.2561	.2926	.3292
16		.2987	.3224	.3292	.2561	.2743	.2743
17	.197	.2865	.3224	.3292	.2561	.2926	.2561
18	.3403	.2865	.3045	.3361	.2743	.3292	.2427
19		.3582	.3761	.3696	.3361	.3475	.3547
20	.394	.3582	.3761	.4108	.3547	.3881	.4435
21	.3582	.3582	.3582	.3696	.3511	.3547	.3881
22	.3403	.3224	.3045	.3511	.3326	.3511	.3326
23	.3403	.3045	.3045	.3326	.3142	.3326	
24		.3403	.3045	.3045	.3326	.2957	.2957
Max	.4066	.3582	.3761	.4108	.3547	.3881	.4435
Min	.197	.0183	.2033	.0183	.2033	.2033	.0185
Avg	.3516	.2847	.3001	.2950	.2867	.2915	.2756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 208 / 11 kv BORGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.5123	1.531	1.4045	1.4937	1.4563	1.419
2	1.531	1.5684	1.6804	1.3676	1.2323	1.419	1.5497
3	1.531	1.3443	1.419	1.2883	1.2696	1.5684	1.4563
4		1.5154	1.5684	1.2567	1.3443	1.5123	1.4377
5		1.419	1.3817	1.1949	1.1949	1.419	1.3817
6		1.2323	1.2323	1.0829	1.1203	1.307	1.2696
7		1.0456	1.2323	.7842	.8131	1.3817	1.1203
8		1.0456	1.2696	.8962	.7842		1.0082
9	1.1576	.9709	1.1888	.9335	.8962	1.1576	1.1203
10	1.1576	1.2803	1.3535	1.419	.9709	1.1203	1.0974
11	1.2936	1.4632	1.4937	1.4937	1.2696	1.1203	1.0269
12	1.3443	1.3535	1.5684	1.531	1.307	1.1203	1.307
13	1.3443	1.3443	1.643	1.587	1.307	1.1203	1.307
14	1.4003	1.419	1.6804	1.5684	1.2696	.9335	.8215
15	1.4003	1.4937	1.643	1.6095	1.307	.8215	.8589
16	1.4998	1.4937	1.576	1.5364		1.1949	1.1576
17	1.4685	1.4327	1.5043	1.531	1.307	1.307	1.307
18	1.3253	1.0029	1.2536	1.3443	.9335	1.1576	1.1203
19	1.3253	1.1104	1.0387	1.1576	.9335	1.2437	1.1203
20	1.3253	1.2536	1.1104	.9709	1.0269	1.307	1.4045
21	1.4685	1.3969	1.3611	1.2323	1.307	1.2323	1.2136
22	1.5043	1.4685	1.3969	1.2696	1.5123	1.3443	1.3817
23	1.5043	1.6476	1.4327	1.6244	1.4937	1.3817	1.3443
24	1.6057	1.4685	1.4685	1.2536	1.419	1.531	1.4563
Max	1.6057	1.6476	1.6804	1.6244	1.5123	1.5684	1.5497
Min	1.1576	.9709	1.0387	.7842	.7842	.8215	.8215
Avg	1.4082	1.3451	1.4178	1.3057	1.1962	1.2677	1.2370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 405 / 33 KV AMIBIKA SOLVEX NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	.3944	.08	.9259	1.086	.9831	.3372
2	1.1203	.3144	.08	1.046	1.0517	.9774	.3658
3	.1672	.2686	.0972	.6173	1.046	1.0174	.1886
4	1.1088	.1658	.0743	.9488	1.0517	1.0002	.1658
5	1.1203	.1715	.0743	1.0517	1.0631	1.0059	.1543
6	1.0974	.0914	.0743	1.0574	1.0574	.9831	.12
7	1.2517	.1829	.0514	1.0517	1.0517	1.046	.1257
8	1.1488	.1429	.0629	1.0574	1.1374	1.0345	.2
9	.2913	.14	.2016		1.1203		.1624
10	.3025	.1481	.3473	1.1091	.6161	.8514	.168
11	.4481	.1904	.3896	1.0362	.6778	.4033	.4481
12	.4115	.1176	.717	1.0642	.8738	.2908	.689
13	.4115	.1064	.9746	1.0306	.8346	.2305	.717
14	.4257	.084	.8738	1.0425	.8458	.2241	.6946
15	.8794	.0784	.856	1.0206	.913	.2353	.6161
16	.885	.0784	.8488	1.0919	.9858	.3529	.7226
17	1.0185	.0679	.8488	1.1084	.9466	.4761	.773
18	1.0864	.0622	.8261	1.1483	.941	.8402	.7786
19	1.0977	.0622	.5206	1.0474	.8402	.829	.8176
20	1.0977	.0622	.5206	1.1203	.9522	.8402	.8573
21	.4979	.0849	.8601	.7659	.9717	.5544	.4801
22	.4527	.0849	.928	1.1546	.9774	.4801	.4687
23	.5658	.0849	.6734	1.1145	1.0174	.4287	.1943
24	1.1203	.928	.0849	.8771	1.0917	.9831	.3487
Max	1.2517	.928	.9746	1.1546	1.1374	1.046	.8573
Min	.1672	.0622	.0514	.6173	.6161	.2241	.12
Avg	.7967	.1714	.4611	1.0212	.9646	.6986	.4414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024003 / 33 KV WANI RAMBHAPUR

Feeder No / Name : 409 / J.J.Fine Spun

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2289	1.2289	.7945	1.3089	1.3032	1.1488	1.4003
2	1.2174	1.1431	.8288	1.1488	1.2803	1.2174	1.2346
3	1.2746	1.0059	.8402	1.2574	1.286	.9374	1.2803
4	1.366	1.0745	.8516	1.2631	1.3546	.9431	1.3375
5	1.2803	.9259	.7716	1.2689	1.2803	.9659	1.2517
6	1.3546	.9316	.8631	1.1717	1.2631	.9888	1.2517
7	1.2117	.8859	.8631	1.1774	1.366	1.0059	1.086
8	1.286	.9431	.7945	1.2746	1.4232	.9202	1.286
9	1.2547	1.4283	1.1248	1.3947	1.4395	1.3163	1.3891
10	1.1875	1.2675	1.1203	1.2715	1.1651	1.2603	1.1315
11	.9186	1.3275	1.3163	1.3555	1.2715	1.3331	1.2379
12	1.1091	1.2827	1.273	1.3219	1.0418	1.3331	1.2435
13	1.2211	1.2379	1.2995	1.3611	1.0586	1.2547	1.2491
14	.056	1.4115	1.4003	1.3051	1.0923	1.4563	1.3443
15	1.2547	1.2939	1.3608	1.3499	1.1371	1.3163	1.1315
16	1.1315	1.2155	1.4259	1.3333	1.3331	1.1987	1.3611
17	1.16		1.3693	1.2346	1.4787	1.4283	1.3219
18	1.3184	1.2788	1.3071	1.3219	1.2827	1.1427	1.2435
19	1.3128	1.3297	1.4203	1.2883	1.3443	1.4451	1.3443
20	1.3411	1.2166	1.0808	1.3723	1.3443	1.4175	1.2574
21	1.273	1.2166	1.2562	1.3146	1.1888	1.2289	1.2715
22	1.2052	1.16	1.2788	1.3775	1.0802	1.2289	1.3032
23	1.177	.8505	1.0015	1.4975	1.0688	1.2803	1.4518
24	1.246	1.1774	.9789	1.2335	1.286	1.086	1.2689
Max	1.366	1.4283	1.4259	1.4975	1.4787	1.4563	1.4518
Min	.056	.8505	.7716	1.1488	1.0418	.9202	1.086
Avg	1.1828	1.1667	1.1092	1.3002	1.2571	1.2023	1.2783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 201 / 11 KV GHUSAR FDR .

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.4854	.5228	.5175	.4668	.4805	.4854
2	.4805	.4854	.5228	.4805	.4668	.4805	.4854
3	.4805	.4668	.5228	.4805	.4668	.4805	.4481
4	.4805	.4481	.5041	.4805	.4668	.4805	.4481
5	.4435	.4481	.5041	.4805	.4668		.4481
6	.3326	.3361	.3921	.4435	.3734		.3361
7	.2587	.2614	.3174	.3696	.2801		.2801
8	.2957	.3174	.2614	.2772	.2801		.2987
9	.3174	.3326	.2987	.2957	.2801		.2614
10	.3174	.2772	.3174	.2957	.2743		.2926
11	.2987	.3142	.3361	.3142	.2561		.3292
12	.4108	.3696	.3734	.3696	.3475	.4572	.3292
13	.4294	.4066	.4108	.4066	.3292	.4572	.4024
14	.4294	.4066	.4294	.4294	.4207	.4572	.4024
15	.4294	.4066	.4481	.4108	.4207	.4525	.439
16	.4294	.4066	.4108	.4108	.4207	.4572	.4024
17	.3734	.3696	.3921	.3734	.3696	.3921	.3696
18	.3361	.2957	.3326	.3361	.2957	.3734	.3142
19	.5788	.4108	.3696	.4108	.3696	.4481	.3696
20	.5228	.5975	.5175	.5228	.5175	.5601	.5175
21	.5788	.5975	.5544	.5415	.5544	.5975	.5175
22	.7095	.5975	.5544	.5788	.5175	.5788	.5544
23	.5228	.5601	.5175	.5415	.4805	.5601	.5175
24	.5544	.4668	.5415	.5175	.5041	.4805	.5228
Max	.7095	.5975	.5544	.5788	.5544	.5975	.5544
Min	.2587	.2614	.2614	.2772	.2561	.3734	.2614
Avg	.4387	.4193	.4313	.4285	.4011	.4820	.4072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 202 / 11 KV MHAISANG FDR .
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.5853	.6161	.6219	.5788	.543	.5975
2	.3258	.5853	.5788	.5853	.5788	.5068	.5601
3	.3292	.5487	.5788	.5487	.5788	.4706	.5601
4	.3292	.5487	.5788	.5121	.5788	.4706	.5601
5	.3292	.5487	.5788	.4755	.5788	.4344	1.1203
6	.2926	.4755	.5041	.4435	.5228	.3982	.4668
7	.2378	.5121	.3734	.3658	.4108	.362	.4108
8	.2378	.4024	.3921	.3658	.4294	.362	.3734
9	.2195	.4066	.4481		.4108	.3658	.3921
10	.2195	.3658	.439	.1294	.4572	.3734	.4001
11	.2378	.4024	.439	.1294	.4572	.4001	.4001
12	.2561	.4024	.439		.4954	.4763	.4001
13	.2743	.4024		.439	.5335	.4763	.4763
14		.4024	.4938	.5228	.5335	.4763	.4763
15		.4024	.5121	.5041	.5525	.1715	.5144
16	.5121	.3982	.5228	.4668	.5525	.2801	.4763
17	.5121	.4024	.5121	.5228	.4755	.2987	.4344
18	.5121	.4024	.4344	.4854	.4344	.4108	.362
19	.6036	.4668	.5068		.4706	.5041	.4706
20	.6584	.6348	.6516	.6908	.5792	.6908	.6219
21	.6401	.6535	.6878	.6908	.6335	.6908	.6219
22	.6401	.6908	.7059	.6722	.6516	.6722	.6219
23	.6401	.6722	.6516	.6535	.5792	.6348	.5853
24	.3292	.6036	.6535	.6516	.6161	.5792	.6161
Max	.6584	.6908	.7059	.6908	.6516	.6908	1.1203
Min	.2195	.3658	.3734	.1294	.4108	.1715	.362
Avg	.3939	.4965	.5347	.4989	.5287	.4604	.5216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 203 / 11 KV Ghusar W/W Express. NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0791	.0164	.0158	.0316	.0316	.0316	.0158
2	.0791	.0164	.0158	.0316	.0316	.0316	.0158
3	.0791	.0162	.0158	.0316	.0316	.0316	.0158
4	.0791	.0164	.0158	.0316	.0316	.0316	.0158
5	.0791	.0164	.0158	.0316	.0316	.0316	.0158
6	.0791	.0164	.0158	.0316	.0316	.0316	.0158
7	.0791	.0164	.0474	.0316	.0316	.0316	.0158
8	.0791	.0819	.0316	.0316	.0316	.0316	.0158
9	.0819	.0791	.0316	.0316	.0316	.0316	.0158
10	.0819	.0791	.0328	.037	.0316	.0316	.0158
11	.0655	.0791	.0328	.0316	.0316	.0316	.0158
12	.0819	.0791	.0328	.0158	.0316	.0316	
13	.0819	.0791	.0328	.0158	.0316	.0316	.0158
14	.0819	.0791	.0328	.0158	.0316	.0316	.0016
15	.0819	.0791	.0328	.0158	.0316	.0316	.0016
16	.0819	.0791	.0328	.0316	.0316	.0316	.0158
17	.0819	.0791	.0328	.0316	.0316	.0316	.0158
18	.0819	.0791	.0316	.0316	.0316	.0158	.0158
19	.0819	.0791	.0316	.0316	.0158	.0158	.0158
20	.0819	.0791	.0316	.0316	.0158	.0158	.0158
21	.0655	.0791	.0316	.0316	.0158	.0158	.0158
22	.0655	.0791	.0316	.0316	.0158	.0158	.0158
23	.0492	.0791	.0316	.0316	.0316	.0158	.0158
24	.0791	.0328	.0158	.0316	.0316	.0316	.0158
Max	.0819	.0819	.0474	.037	.0316	.0316	.0158
Min	.0492	.0162	.0158	.0158	.0158	.0158	.0016
Avg	.0774	.0590	.0281	.0292	.0290	.0277	.0146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024021 / 33 KV APATAPA

Feeder No / Name : 204 / 11 KV Jaiguru Express.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.0189	
8				.0189			
11				.0566			
12				.0566			
13		.0566		.0554			
16		.1494					
20					.0189		.0189
21					.0189		
23			.0189		.0189		
24	.0189		.0189	.0189			.0189
Max	.0189	.1494	.0189	.0566	.0189	.0189	.0189
Min	.0189	.0566	.0189	.0189	.0189	.0189	.0189
Avg	.0189	.103	.0189	.0413	.0189	.0189	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 201 / 11 KV HINGNA FEED
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.724	.7202	.7316	.7621	.6859	.6401
2	.7133	.724	.7202	.6767	.724	.6516	.6401
3	.6767	.724	.6859	.6584	.724	.6516	.6219
4	.6767	.7621	.6859	.6584	.724	.6344	.6219
5	.6767	.7621	.7202	.6401	.724	.6344	.6584
6	.6584	.8383	.7888	.6401	.7621	.6173	.6584
7	.7316	.7621	.7373	.7316	.7621	.6516	.7682
8	.7316	.8002	.7545	.7316	.8002	.7545	.7316
9	.7682	.7621	.703	.7682	.8002	.7202	.7499
10	.7888	.9526	.9907	.8916	.8573	.9145	.7545
11	.6687	.8764	.8764	.8745	.823	.8383	.7202
12	.6687		.9145	.8573	.7888	.9145	.7545
13	.703	.8764	.9145	.8573	.8059	.8383	.7545
14	.7202	.8002	.9145	.7716	.7545	.8764	.7545
15	.7202	.9907	.9145	.9774	.9602	.9907	
16	.8402	1.0288	1.105		.8573	.8764	
17	.9526	.9431	1.1622	.9945		.823	.8764
18	.8573	.8745	.9717			.8413	.7621
19	1.0288	.9088	1.0242	1.0288	.8916	.8413	.8002
20	1.0288	.8916	1.0242	.9907		.8779	.8383
21	.8002	.823	.7499	.8383		.695	.8002
22	.8002	.7888	.8048	.8383		.695	.7621
23	.724	.7716	.7682	.8002	.7202	.6584	.7621
24	.7316	.724	.7373	.7682	.7621	.6859	.6401
Max	1.0288	1.0288	1.1622	1.0288	.9602	.9907	.8764
Min	.6584	.724	.6859	.6401	.7202	.6173	.6219
Avg	.7658	.8308	.8495	.8057	.7897	.7654	.7305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 203 / 11 KV RUHATIYA EXP.

FEEDER Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	
11	.0191	.0191	.0191	.0191	.0191	.0191	.0191
12	.0191	.0191	.0191	.0191	.0191	.0191	
13	.0171	.0191	.0191	.0191	.0191	.0191	.0191
14	.0191	.0191	.0191	.0191	.0191	.0191	.0191
15	.0171	.0191	.0191	.0171	.0191	.0191	
16	.0191	.0191	.0191	.0171	.0191	.0191	
17	.0191	.0191	.0191	.0191		.0191	.0191
18	.0191	.0191	.0191	.0191		.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191		.0191	.0191
21	.0191	.0191	.0191	.0191		.0191	.0191
22	.0191	.0191	.0191	.0191		.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0171	.0191	.0191	.0171	.0191	.0191	.0191
Avg	.0189	.0191	.0191	.0189	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 204 / 11 KV HINGANA-AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2286	.2401				
3	.3109	.2286	.2401				
4	.3109	.2667	.2401				
5	.2926	.2667	.2572				
6	.2858	.2667	.2743				
7	.2743	.3429	.2572				
8	.2926	.381	.3086				
9	.3658	.2667	.1715				
10				.3086	.3086	.3429	.2743
11				.3258	.3601	.3429	.2401
12				.3086	.3258	.381	.2229
13				.3429	.2743	.381	.2915
14				.3086	.2401	.3429	.3086
15				.3258	.3086	.3429	
16				.3258	.3429	.1905	
17				.3258	.4191	.2561	.381
Max	.3658	.381	.3086	.3429	.4191	.381	.381
Min	.2743	.2286	.1715	.3086	.2401	.1905	.2229
Avg	.3047	.2810	.2486	.3215	.3224	.3225	.2864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024023 / 33 KV Nimbi

Feeder No / Name : 207 / 11 K GAJANAN MAHARAJ
GINNING Feeder KV- 11 /
INCOMINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11	.0191	.0191	.0191	.0191	.0191	.0191	.0191
12	.0191	.0191	.0191	.0191	.0191	.0191	.0191
13	.0191	.0191	.0191	.0191	.0191	.0191	.0191
14	.0191	.0191	.0191	.0191	.0191	.0191	.0191
15	.0191	.0191	.0191	.0191	.0191	.0191	
16	.0191	.0191	.0191		.0191	.0191	
17	.0191	.0191	.0191	.0191		.0191	.0191
18	.0191	.0191	.0191	.0191		.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191		.0191	.0191
21	.0191	.0191	.0191	.0191		.0191	.0191
22	.0191	.0191	.0191	.0191		.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 203 / 11 KV RUHATIYA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4512	.4809	.4348	.4534	.4496	.458	.4546
2	.4633	.479	.4336	.4496	.4409	.4618	.4504
3	.4797	.4706	.4306	.4649	.4447	.4569	.4473
4	.4752	.4611	.4302	.4675	.4515	.4702	.4485
5	.4584	.4733	.4096	.4736	.4557	.4885	.4508
6	.4954	.4744	.4302	.4721	.4447	.4759	.4485
7	.4908	.4889	.4306	.4668	.4428	.474	.4424
8	.4858	.4561	.5041	.4584	.4973	.4515	.4531
9	.5014	.4401	.5209	.4462	.4611	.4755	.4553
10	.4538	.4428	.5483	.4672	.4618	.5182	.4454
11	.4599	.4489	.495	.4489	.4531	.538	.4466
12	.4614	.447	.4508	.5178	.4576	.527	.5148
13	.4572	.4523	.4466	.5357	.4481	.5289	.5247
14	.4523	.4405	.4534	.5281	.482	.5376	.5338
15	.45	.4485	.4439	.5293	.5018	.5434	.5133
16	.4992	.4405	.4797	.4607	.5037	.5597	.5144
17	.5216	.5171	.4725	.5441	.5117	.5609	.5201
18	.5201	.4923	.522	.5262	.4725	.5437	.5235
19	.5102	.4938	.5049	.5232	.4748	.5415	.5289
20	.487	.503	.4378	.4531	.4992	.4367	.4405
21	.4965	.4458	.4645	.4397	.49	.458	.4713
22	.5144	.4348	.4649	.4717	.4931	.5537	.4538
23	.4889	.4329	.4546	.4485	.4854	.4885	.4645
24	.4675	.4313	.4477	.4439	.4489	.4512	.471
Max	.5216	.5171	.5483	.5441	.5117	.5609	.5338
Min	.45	.4313	.4096	.4397	.4409	.4367	.4405
Avg	.4809	.4623	.4630	.4788	.4697	.5000	.4757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 204 / 11 kv shivapur feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1593	.1631	.1593	.1677	.1501	.157
2	.1494	.1585	.1608	.1593	.1638	.1501	.1555
3	.1478	.1585	.1593	.1585	.1623	.1562	.1547
4	.1486	.1562	.1593	.157	.1669	.1562	.1547
5	.1463	.1547	.157	.1631	.1677	.1524	.1532
6	.1494	.1547	.1562	.16	.1616	.1532	.1486
7	.1478	.1555	.1539	.1524	.157	.1417	.1288
8	.1669	.1486	.1509	.1677	.2012	.1654	.1593
9	.176	.1936	.1852	.2012	.2187	.1486	.1776
10	.1585	.2035	.218	.192	.205	.2439	.1791
11	.1913	.2301	.2195	.2103	.1768	.2263	.1981
12	.176	.2058	.1791	.1562	.218	.2347	.1669
13	.157	.1387	.1585	.1478	.1638	.1661	.1456
14	.1867	.1852	.2187	.2164	.2462	.2324	.2652
15	.1745	.1936	.1806	.2035	.1943	.2378	.2865
16	.234	.1936	.1951	.2233	.1791	.2027	.2629
17	.189	.2103	.1974	.2157	.1509	.237	.2888
18	.2332	.2172	.2423	.1638	.1448	.2446	.1547
19	.1715	.1722	.1707	.1623	.125	.1799	.1425
20	.1753	.1837	.1699	.1898	.1357	.1722	.1593
21	.1852	.1646	.1692	.1882	.1814	.1738	.1616
22	.1738	.1638	.1753	.1776	.1783	.1692	.1661
23	.1677	.1646	.1654	.1799	.1661	.1738	.1745
24	.1638	.1661	.1616	.1684	.1539	.157	.1707
Max	.234	.2301	.2423	.2233	.2462	.2446	.2888
Min	.1463	.1387	.1509	.1478	.125	.1417	.1288
Avg	.1716	.1764	.1778	.1781	.1744	.1844	.1797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 205 / 11 KV Chandur Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1814	.1036		.0968		.0777	
2	.1959	.109		.1082		.0777	
3	.2134	.1113		.1105		.0785	
4	.2263	.1318		.1326	.0137	.0838	
5	.3094	.1959		.2347	.0008	.0274	.0015
6	.3833	.282		.2667		.0594	
7	.5106	.2385		.2934	.013	.0838	
8	.5152	.2721		.2759	.0183	.0747	
9	.0053	.0076	.0945	.0008	.2888	.5822	.535
10	.0351	.0008	.0823		.3681	.6341	.5777
11	.0366	.0381	.0861		.4572	.6638	.5883
12	.0724	.0046	.0701	.045	.4847	.6401	.5975
13	.0419	.0091	.0876	.0015	.5197	.3818	.5594
14	.0846		.0236	.0305	.5197	.4191	.5365
15	.1021	.0023	.0358	.0335	.4092	.5456	.5418
16	.0107		.077	.0343	.4862	.6127	.4992
17	.0472	.0008	.0998	.1036	.0206	.2301	.1997
18	.0389		.1044	.0472	.0404	.0953	.0358
19	.0861		.109	.0724	.0823	.0831	.0023
20	.0876		.0983	.0206	.0785	.0785	.0846
21	.0884		.1014	.0724	.093	.0495	.0053
22	.0846		.1029		.0869	.0168	
23	.0823		.0991		.0808		.2134
24	.0846		.0968		.0793		.25
Max	.5152	.282	.109	.2934	.5197	.6638	.5975
Min	.0053	.0008	.0236	.0008	.0008	.0168	.0015
Avg	.1468	.1005	.0855	.1042	.2071	.2544	.3268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 206 / 11 KV GADGEBABA EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.2012	.1859	.1753	.1936	.1951	.1844
2	.1776	.2004	.1814		.1882	.189	.1806
3	.1753	.1981	.1791		.1936	.1859	.1806
4	.1783	.1989	.1776		.1799	.189	.1852
5	.1844	.1989	.1814		.1783	.192	.1859
6	.189	.1989	.1806		.1821	.1829	.1814
7	.1791	.205	.1829		.1859	.1844	.1882
8	.1799	.2088	.1791		.1844	.1837	.1905
9	.1776	.2035	.1783	.0998	.1875	.1875	.1905
10	.1936	.1898	.2004	.192	.2309	.1974	.1669
11	.1951	.2157	.2256	.221	.2271	.2134	.1623
12	.1814	.218	.2134	.2248	.2225	.2324	.1646
13	.189	.2012	.2073	.2263	.218	.237	.1631
14	.1981	.1981	.2286	.2157	.2195	.2263	.1608
15	.2058	.2119	.2294	.221	.1997	.2271	.1707
16	.1966	.2111	.2096	.2149	.2042	.2484	.173
17	.1844	.2088	.1951	.2103	.1905	.2202	.1852
18	.1814	.1791	.192	.1776	.1867	.1943	.205
19	.1791	.1882	.1829	.192	.1852	.1867	.1799
20	.1806	.1905	.1791	.1936	.1791	.1799	.1905
21	.1821	.1905	.1799	.192	.176	.1837	.1959
22	.1745	.1943	.1852	.1959	.1738	.1753	.1844
23	.1753	.1859	.1776	.1951	.1738	.1814	.1806
24	.1791	.1905	.1738	.192	.1753	.1722	.1951
Max	.2058	.218	.2294	.2263	.2309	.2484	.205
Min	.1745	.1791	.1738	.0998	.1738	.1722	.1608
Avg	.1839	.1995	.1919	.1964	.1932	.1986	.1811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 201 / 11 kv Sangvi Mohadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6516	.5973	.567	.5973	.5853	.5853
2	.6401	.6516	.6036	.567	.5853	.5853	.5792
3	.6219	.6268	.5853	.5487	.5853	.567	.5611
4	.6036	.5973	.5792	.5304	.5792	.567	.5611
5	.5853	.6154	.5611	.5304	.5792	.5487	.543
6	.567	.5792	.4938	.5121	.5304	.5487	.5304
7	.5853	.4706	.543	.4572	.5068	.5853	.5611
8	.543	.4344	.5487	.4755		.5853	.5611
9	.5731	.5068	.6036	.5304		.567	.5249
10	.6154	.5304	.5853	.543		.543	.543
11		.5249	.5853	.5068		.543	.5068
12		.5611	.6036	.3982			.4344
13		.5068	.5853	.543		.4656	
14		.5249	.567	.5014	.4344	.5731	
15		.543	.5487	.4706	.6154	.5792	
16	.6154	.543	.5304	.5068	.5853	.5792	
17	.7602	.5304	.5304	.5249	.567	.5611	
18	.543	.567	.4938		.5853	.6036	.6154
19	.5792	.6335	.5304	.724	.0914	.6584	.724
20	.7602	.724	.6219	.7421	.128	.8145	.7522
21	.7602	.724	.6767	.6878		.7783	.7602
22	.6878	.7059	.695	.6767	.6219	.724	.6878
23	.6516	.6516	.6401	.6516	.6036	.6516	.6516
24	.6584	.6516	.6154	.5853	.5973	.5853	.6036
Max	.7602	.724	.695	.7421	.6219	.8145	.7602
Min	.543	.4344	.4938	.3982	.0914	.4656	.4344
Avg	.6311	.5857	.5802	.5557	.5172	.6000	.5940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 202 / 11 kv Ugwa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.8059	.8688	.8779	.8145	.8596	.7865
2	.7865	.7522	.8413	.8596	.7865	.823	.7602
3	.7682	.7343	.8413	.8413	.7865	.8048	.7602
4	.7499	.7164	.8145	.823	.7602	.7865	.724
5	.7316	.6984	.7964	.7865	.7602	.7682	.724
6	.6767		.6401	.7499	.6219	.6036	.567
7	.5853	.4298	.5068	.5121	.4887	.567	.4706
8	.5194	.4119	.5487	.4938	.4477	.5731	.4525
9	.4656	.4163	.5121	.5121	.5014	.6036	.5194
10	.591	.439	.6036	.5731	.5014	.5731	.5552
11	.2865	.2715	.5853	.5373	.5373	.591	.5731
12	.6268	.5611	.6219	.6089	.6089		.591
13		.6335	.6584	.6805	.6805	.6984	.7164
14		.6335	.6767	.6984	.6984	.394	.7522
15		.6878	.6584	.7164	.7164	.7522	.7522
16	.7164	.6878	.6401	.6626	.6584	.7164	.6984
17	.3224	.6335	.5853	.543	.6219	.6516	.6984
18	.6805	.6036	.567	.5611	.6401	.6036	.591
19	.8059	.7059	.6036	.6516	.6767	.6767	.6447
20	.7701	.8507	.8596	.8413	.8779	.8145	.8059
21	.788	.9412	.8596	.8145	.8962	.8507	.8238
22	.8059	.9412	.8962	.8962	.9145	.8869	.8238
23	.8238	.9412	.8962	.8688	.8962	.8507	.788
24	.8413	.8059	.8869	.8962	.8326	.8779	.823
Max	.8413	.9412	.8962	.8962	.9145	.8869	.8238
Min	.2865	.2715	.5068	.4938	.4477	.394	.4525
Avg	.6736	.6653	.7070	.7086	.6969	.7099	.6834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024037 / 33KV PACHMORI S/Si

Feeder No / Name : 203 / 11 kv Gandhigram

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0362	.0373	.0181
2		.0366	.0366	.0181
3		.0366	.0373	.0181
4		.0362	.0373	.0181
5		.0362	.0373	.0181
6		.0366	.0373	.0183
7		.0362	.0373	.0181
8		.0358	.0373	.0181
9		.0358	.0373	.0179
10		.0358	.0358	.0358
11		.0358	.0358	.0179
12		.0358	.0358	.0179
13		.0358	.0358	
14	.0143	.0358	.0358	.0179
15	.0197	.0358	.0358	.0179
16	.0161	.0373	.0362	.0179
17	.0271	.0373	.0362	
18	.029	.0373	.0366	.0179
19	.0362	.0549	.0366	.0179
20	.0362	.0549	.0181	.0179
21	.0362	.0366	.0181	.0179
22	.0366	.0366	.0181	.0179
23	.0362	.0366	.0181	.0179
24		.0362	.0373	.0183
Max	.0366	.0549	.0373	.0358
Min	.0143	.0358	.0181	.0179
Avg	.0288	.0379	.0335	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 201 / 11 kv sarawa gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2743	.3048	.2743	.2572	.2915	.2743
2	.3048	.2743	.2858	.2743	.2572	.2947	.2743
3	.2858	.2743	.2667	.2561	.2572	.2915	.2743
4	.2858	.2743	.2667	.2561	.2572	.2915	.8059
5	.3048	.2743	.2858	.2561	.2743	.2915	.2743
6	.3429	.2915	.3048	.3475	.2743	.3601	.2743
7	.3429	.3429	.381	.3292	.2743	.2743	.2915
8	.3429	.3429	.4572	.3292	.4458	.2401	.3601
9	.2896	.3601	.381	.2915	.543	.3048	.5487
10	.2896	.5716	.4191	.3772	.4887	.3841	.5716
11	.2353	.6097	.4382	.5658	.5434	.3841	.6478
12	.2353	.6668	.499	.5144	.4918	.5973	.6859
13	.181	.5144	.4805	.4458	.543	.4344	.6097
14	.2804	.5525	.5175	.3601	.4163	.567	.6097
15	.3155	.6478	.5788	.4287	.6201	.5359	.5906
16	.3475	.6097	.5544	.4801	.5434	.6535	.6478
17	.3544	.4382	.5716	.4287	.5434	.5544	.6097
18	.2835	.5335	.394	.4287	.463	.5601	.5525
19	.3258	.4572	.3292	.3258	.4287	.3921	.4954
20	.3258	.362	.2926	.2915	.3772	.3696	.3239
21	.3429	.3429	.2926	.2743	.3601	.3429	.3239
22	.3258	.3429	.2926	.2743	.3294	.3258	.3048
23	.3258	.3429	.2926	.2743	.3258	.3086	.3048
24	.3239	.2743	.3239	.2926	.2572	.3086	.2915
Max	.3544	.6668	.5788	.5658	.6201	.6535	.8059
Min	.181	.2743	.2667	.2561	.2572	.2401	.2743
Avg	.3048	.4156	.3838	.3490	.3988	.3899	.4561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 202 / 11 kv eranda gavthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1886	.2096	.2096	.1886	.1886	.1886
2	.1905	.1886	.1905	.2096	.1886	.1543	.1886
3	.1905	.1886	.1905	.2096	.1886	.1543	.1886
4	.1905	.1886	.1905	.2096	.1886	.1543	.1886
5	.2096	.1886	.2096	.2096	.1886	.1543	.1886
6	.2286	.1715	.1905	.2096	.1715	.1715	.1715
7	.2286	.1715	.2096	.2096	.2058	.12	.1886
8	.2096	.2058	.2286	.2286	.2058	.0686	.1886
9	.1715	.1715	.1524	.2058	.2172		.2572
10	.1715	.1715	.2667	.2743	.2172	.2667	.2286
11	.2477	.2096	.2286	.2229	.2229	.298	.2858
12	.2477	.3429	.2149	.2401	.2401	.394	.2096
13	.381	.2096	.2477	.2572	.1715	.2715	.2858
14	.2477	.2286	.2858	.2743	.1905	.2896	.2286
15	.2096	.2286	.2477	.1886	.1905	.298	.1715
16	.2096	.2286	.2286	.2915	.1905	.2507	.1715
17	.2096	.2667	.2858	.2572		.2858	.1715
18	.1715	.1524	.1715	.2058	.1715	.1524	.1524
19	.1905	.1905	.2096	.1886	.2229	.2286	.1524
20	.2477	.2667	.2858	.2401	.2401	.2286	.2667
21	.2229	.2286	.2477	.2229	.2229	.2401	.2477
22	.1886	.2096	.2286	.2058	.2058	.2229	.2286
23	.6344	.2096	.2096	.2058	.2058	.2058	.2096
24	.2096	.1886	.2096	.2096	.1886	.2058	.1886
Max	.6344	.3429	.2858	.2915	.2401	.394	.2858
Min	.1715	.1524	.1524	.1886	.1715	.0686	.1524
Avg	.2341	.2081	.2225	.2244	.2010	.2176	.2062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024038 / 33 kV VIZORA

Feeder No / Name : 203 / 11 kv katkeda ag
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6344	.6287	.5182	.5144	.4973	.5144
2	.6668	.6344	.6097	.503	.5144	.4973	.5144
3	.6287	.6344	.6097	.503	.5144	.4973	.5144
4					.5144	.4973	.5144
5						.4973	.5144
6					.6001	.7716	.7202
7					.5487	.8059	.9145
8					.7545	.7888	.945
9					.6859	.7773	.8916
10	1.2384	1.2193	1.1812	1.166			
11	.9783	.9907	1.2193	1.0288			
12	.945	.8764	.8993	.9431			
13	.7926	.9717	.6836	.823			
14	.6895	.8954	.6097	.8573			
15	.6249	.8573	.5639	.503			
16	.7468	.9145	.6687	.7545	.7011		.7811
17	.9031	1.105	.8688	.9259	.9602		.9717
18	.8993	1.1622	.9701	1.0288	1.2517	.945	1.1431
19	.7621	1.105	.8535	.9602	1.0288	.7621	.9907
20	.6401	.9145	.5639	.7545	.6859	.7011	.7811
21	.6859	.7621	.5944	.6516	.6859	.6859	.7621
22	.6859	.724	.5792	.6344	.5658	.6516	.6287
23	.6344	.6287	.5487	.583	.5144	.6001	.6097
24	.6668	.6344	.6287	.5182	.5487	.5144	.5316
Max	1.2384	1.2193	1.2193	1.166	1.2517	.945	1.1431
Min	.6249	.6287	.5487	.503	.5144	.4973	.5144
Avg	.7708	.8702	.7378	.7587	.6817	.6556	.7357

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

AKOLA (R) SUB-DN[280] BU 2801

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 203 / AKOT ROAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7987	.7118	.7956	.7796	.8002	.7743	.8154
2	.7994	.7057	.756	.7659	.7636	.7415	.8398
3	.7743	.6767	.7339	.7468	.7324	.7141	.8086
4	.7644	.6592	.7164	.7316	.727	.7064	.74
5	.7567	.6485	.7164	.7255	.7125	.7171	.7209
6	.7621	.6508	.708	.7385	.7278	.7057	.6706
7	.7202	.6036	.6516	.6729	.7049	.6645	.6196
8	.6394	.4877	.5388	.6569	.6127	.6028	.5807
9	.5914	.4824	.5045	.5655	.5685	.6066	.663
10	.5891	.5053	.5693	.5685	.5746	.6043	.6462
11	.6036	.5258	.5815	.6287	.6089	.6386	.6607
12	.6401	.5594	.6013	.6295	.6363	.6287	.6462
13	.679	.5685	.6569	.6127	.6523	.5967	.6264
14	.6737	.5883	.6729	.628	.6447	.5586	.6417
15	.6958	.6257	.6523	.647	.6059	.6531	.6318
16	.6798	.6554	.6401	.6775	.6409	.6081	.6371
17	.6813	.6554	.6478	.6501	.6196	.5677	.6501
18	.6401	.5792	.6226	.663	.6249	.5228	.6211
19	.6379	.6737	.599	.7004	.6767	.5708	.6295
20	.7827	.7804	.7644	.8352	.8055	.7339	.7476
21	.7842	.8048	.7773	.852	.8474	.8665	.8063
22	.7247	.8497	.7987	.8718	.8368	.8672	.8025
23	.6973	.8657	.8383	.8436	.833	.8688	.8459
24	.7263	.8535	.8291	.8505	.8154	.8512	.807
Max	.7994	.8657	.8383	.8718	.8474	.8688	.8459
Min	.5891	.4824	.5045	.5655	.5685	.5228	.5807
Avg	.7018	.6549	.6822	.7101	.6989	.6821	.7024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 201 / 11 KV BALAPUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.5472	2.8197	5.7712	5.7727	2.8197	5.7712	2.8197
2	5.4523	2.8197	5.6203	5.6219	2.8197	5.6287	2.7435
3	5.4336	2.7435	5.5068	5.4336	2.6673	5.5156	2.6673
4	5.3201	2.6673	5.0945	5.2641	2.6673	5.4024	2.5911
5	5.2828	2.5911	5.0572	5.1692	2.5911	5.3171	2.5149
6	5.2066	2.5911	4.9436	5.1319	2.5149	5.0183	2.5149
7	4.7166	2.3624	4.6029	4.8643	2.2862	4.4894	2.21
8	4.4879	2.1338	4.2638	4.1518	2.1338	4.2249	2.0576
9	1.9814	2.1338	3.9994	3.9994	1.9814	3.9232	1.9814
10		2.0576	4.0741	2.0576	2.0576	4.1114	2.0576
11		4.3743	4.3743	4.4048	2.1338	4.4132	2.21
12	4.5572	4.5267	4.4879	4.478	4.5039	2.2862	2.21
13	4.7432	4.5267	2.21	4.6304	4.4277	4.827	4.452
14	5.1151	4.8286	2.3624	4.6304	4.6909	4.9033	4.452
15	5.3376	2.5149	.8383	4.8926	4.9174	2.5149	4.6029
16	5.1181	2.5149	.1524	4.9657	4.9913	5.205	4.7539
17	2.5911	4.8674	.9145	2.5911	4.9543	5.0183	4.8286
18	2.21	4.9763	2.5911	2.3624	4.654	4.6029	4.4894
19	2.3624	5.1273	2.5911	2.3624	5.1022	5.0884	4.7134
20	2.7435	5.471	2.8197	2.7435	5.4416	5.3933	5.3186
21	2.8959	5.3948	2.8197	2.6673	5.5156	2.8197	5.5441
22	2.4387	5.5083	5.9983	2.8959	5.7788	2.8959	5.7697
23	2.9721	5.8101	5.9983	3.0483	5.855	2.8959	5.6592
24	2.9721	2.9721	5.8848	5.9983	2.9721	5.8158	5.583
Max	5.5472	5.8101	5.9983	5.9983	5.855	5.8158	5.7697
Min	1.9814	2.0576	.1524	2.0576	1.9814	2.2862	1.9814
Avg	4.0675	3.6806	3.8740	4.1724	3.7699	4.5034	3.6977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 202 / 11 KV PARAS

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6577
2					.4824	.7301	.6562
3					.5784	1.0051	.6371
4					.5754	1.0044	.6363
5					.5624	1.0646	.6287
6					.5647	1.0684	.6386
7					.7011	1.1065	.7164
8					.7331	1.3176	.8459
9					.7766	1.5082	.9214
10	1.0585	.4534	1.262	.5136	.7583	.9008	.7781
11	1.5455	.5883	1.6941	1.5623			
12	1.5066	1.1736	1.6796	1.4807			
13	.6752	1.451	.9335	1.4236			
14	.2385	1.4137	.8009	.692			
15	.5852	.7339	.7011	.1753			
16	.6005	.7026	.692	.6775			
17	.6158	1.3443	.8093	.7545			
18	.7209	.727	.8604	.82			
24						.1844	
Max	1.5455	1.451	1.6941	1.5623	.7766	1.5082	.9214
Min	.2385	.4534	.692	.1753	.4824	.1844	.6287
Avg	.8385	.9542	1.0481	.8999	.6369	.9890	.7116

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 203 / 11 KV VYALA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2087	1.1264	1.044	1.1858	1.1164	1.0585	1.1881
2	1.1248	1.1012	1.0837	1.1629	1.0875	1.0326	1.1584
3	1.1073	1.0783	1.057	1.1523	1.0578	1.0098	1.1332
4	1.0844	1.0562	1.041	1.1264	1.0555	.9884	1.0799
5	1.0738	1.028	1.0364	1.1058	1.0326	.9739	1.0783
6	1.0555	1.025	1.0227	1.0875	1.0166	.9511	1.0654
7	.9998	.961	.9396	1.0037	.9427	.8932	.9511
8	.8269	.8269	.7956	.8383	.8025	.7415	.8299
9	.7202	.708	.6897	.7171	.6562	.6363	.7042
10	.6592	.6363	.6493	.6752	.6775	.631	.5937
11	.6836	.6318	.6432	.727	.6981	.676	.6264
12	.6897	.6813	.6851	.6676	.7354	.708	.7247
13	.7636	.7537	.7346	.7994	.8009	.7766	.7583
14	.865	.8253	.7903	.8169	.8177	.8589	.8101
15	.9137	.8848	.8368	.1821	.8688	.8954	.8551
16	.9259	.9427	.7209	.9831	.9229	.8977	.8787
17	.9183	.945	.7598	.9396	.8749	.8893	.8718
18	.8726	.8482	.8634	.8703	.8345	.836	.8253
19	.8352	.7682	.7842	.8535	.8116	.7667	.7705
20	.9861	.9221	.8253	.9427	.929	.9198	.9076
21	1.0181	.9884	1.0387	1.0242	1.0181	1.0524	1.0341
22	1.1355	1.1012	1.1927	1.1233	1.0822	1.1713	1.1218
23	1.1728	1.1256	1.246	1.1477	1.1012	1.2308	1.1805
24	1.1645	1.1706	1.2361	1.1439	1.1012	1.2163	1.2132
Max	1.2087	1.1706	1.246	1.1858	1.1164	1.2308	1.2132
Min	.6592	.6318	.6432	.1821	.6562	.631	.5937
Avg	.9502	.9223	.9048	.9282	.9184	.9088	.9317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 204 / 11 KV PALASI GAUTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263		.2241	.2641		.2241	
2	.2263		.2241	.2641		.1867	
3	.1886		.2241	.2452		.1867	
4	.1886		.2241	.2452		.1867	
5	.1886		.2241	.2075		.2427	
6	.1886		.2241	.2075		.2241	
7	.1886		.2241	.2075		.2241	
8	.1886		.1867	.2075		.1867	
9	.1886		.1867	.2075		.1867	
10	.132		.1867			.1867	
11	.1848	.1886	.2054	.12		.2054	
12	.1848	.1886	.1867	.0857	.2054		
13	.2218	.1886		.0857	.2218	.2452	.2263
14	.2218	.2263		.0686	.2402	.218	.2641
15	.2587			.1715	.2402		.1829
16	.2587			.2058	.2402	.2263	.1677
17		.2241			.2033	.2263	.1619
18		.2241			.1848	.1886	.1829
19		.2241			.1848	.2267	.2263
20		.2614			.2957	.2267	.2641
21		.2614			.2587		.2452
22		.2241	.2641		.2587		.2452
23		.2241	.2641		.2587		.2263
24			.2241	.2641		.2587	.2263
Max	.2587	.2614	.2641	.2641	.2957	.2587	.2641
Min	.132	.1886	.1867	.0686	.1848	.1867	.1619
Avg	.2022	.2214	.2182	.1911	.2327	.2135	.2183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 206 / 11 KV MANN EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187		.0486	.0168		.0492	
2	.0168		.0162	.0168		.0191	
3	.0168		.0162	.0168		.0191	
4	.0168		.0191	.0168		.0191	
5	.0168		.0191	.0168		.0191	
6	.0168		.0191	.0168		.0191	
7	.0168		.0191	.0168		.0191	
8	.0168		.0191	.0503		.0191	
9	.0503		.0492	.0503		.0497	
10	.0566		.0492			.0497	
11	.0503	.0503	.0492	.0503		.0497	
12	.0503	.0503	.0492	.0503	.0503		
13	.0503	.0503		.0503	.0503	.0503	.0486
14	.0503	.0503		.0503	.0503	.0503	.0503
15	.0503			.0503	.0503		.0503
16	.0503			.0503	.0503	.0503	.0503
17		.048			.0503	.0503	.0486
18		.048			.0503	.0503	.0503
19		.0492			.0503	.0486	.0503
20		.0492			.0503	.0486	.0503
21		.0492			.0671		.0503
22		.0492	.0503		.0671		.0503
23		.0492	.0168		.0671		.0168
24			.0486	.0168		.0671	.0168
Max	.0566	.0503	.0503	.0503	.0671	.0671	.0503
Min	.0168	.048	.0162	.0168	.0503	.0191	.0168
Avg	.0341	.0494	.0326	.0336	.0545	.0394	.0444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 207 / 11 KV VYALLA AGRICULTURE
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189		.0191	.0189		.0191	
2	.2263		.192	.2263		.0191	
3	.2263		.2561	.2263		.0191	
4	.2263		.2561	.2263		.0191	
5	.2263		.192	.2263		.0191	
6	.2263		.208	.2263		.0191	
7	.2263		.192	.2263		.0191	
8	.2263		.2561	.2987		.0191	
9	.3018		.2561	.2987		.0191	
10	.0189		.0191			.2561	
11	.0191	.0189	.0191	.0191		.2561	
12	.0191	.0189	.0191	.0191	.2056		
13	.0191	.0189		.0191	.253	.2012	.1943
14	.0191	.0189		.0191	.253	.2012	.1943
15	.0191			.0191	.253		.1943
16	.0191			.0191	.253	.1943	.1943
17		.0191			.253	.1943	.1943
18		.0191			.0191	.0189	.0189
19		.0191			.0191	.0189	.0189
20		.0191			.0191	.0189	
21		.0191			.0191		.0189
22		.0191	.0189		.0191		.0189
23		.0191	.0162		.0191		.0189
24			.0191	.0189		.0191	.1886
Max	.3018	.0191	.2561	.2987	.253	.2561	.1943
Min	.0189	.0189	.0162	.0189	.0191	.0189	.0189
Avg	.1274	.0190	.1293	.1317	.1321	.0816	.1141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 208 / 11 KV PALASI AGRICULTURE
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132		.1524	.1132		.1715	
2	.2263		.3048	.3018		.1334	
3	.2263		.2591	.3018		.1334	
4	.3018		.2591	.3395		.1334	
5	.3018		.2591	.3395		.1334	
6	.3018		.2591	.3772		.1334	
7	.4527		.4534	.5281		.1334	
8	.4527		.5182	.4858		.1524	
9	.5281		.5182	.5365		.1524	
10	.132		.1143			.4428	
11	.1334	.0972	.1524	.1143		.4111	
12	.1334	.0972	.1524	.1143	.4428		
13	.1334	.1134		.1143	.3795	.5365	.3887
14	.1334	.1134		.1143	.3795	.5365	.3887
15	.1143			.1143	.3479		.3239
16	.1524			.1334	.3163	.2591	.3353
17		.1334			.4428	.1943	.3239
18		.1334			.1334	.0972	.081
19		.1334			.1334	.0972	.081
20		.1524			.1524	.0972	.081
21		.1524			.1524		.1006
22		.1524	.1134		.1715		.1006
23		.1524	.1134		.1423		.1006
24			.1524	.1132		.1715	.1677
Max	.5281	.1524	.5182	.5365	.4428	.5365	.3887
Min	.1143	.0972	.1134	.1132	.1334	.0972	.081
Avg	.2410	.1301	.2521	.2588	.2662	.2168	.2061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 209 / 11 KV BALAPUR AGRICULTURE

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503		.0497	.0486		.0686	.2218
2	.0503		.0497	.0486	.3749	.6836	.221
3	.0503		.0497	.0324	.5136	.7651	.1966
4	.0503		.0497	.0324	.503	.9015	.192
5	.0503		.0497	.0324	.5007	.8901	.2027
6	.0503		.0497	.0324	.4702	1.0404	.2218
7	.0335		.0332	.0324	.5853	1.2292	.3391
8	.0335		.0332	.0335	.6501	1.3767	.4146
9	.0335		.0332	.0335	.7865	1.3742	.4336
10	1.2399	.5144	1.1788	.522	.791	.7831	.7514
11	1.6838	1.5302	1.6703	1.5452		.0332	
12	1.6964	1.6003	1.6541	1.5909	.0324		
13	1.5524	1.4754	.8749	1.4876	.0324	.0168	.0324
14	1.3582	1.254	.772	1.3491	.0324	.0168	.0324
15	1.3609	.6341	.7247	1.263	.0324		.0324
16	1.3447	.663	.679	1.2546	.0324	.0335	.0324
17	.7225	.0358	.7697	.6821	.0324	.0335	.0324
18	.6988	.3513	.756	.6622	.0324	.0335	.0324
19					.0486		.0324
20	.0008	.0166			.0831	.0162	.0486
21		.0497			.1479		.0503
22		.0497	.0503		.1502		.0511
23		.0566	.0503		.1448		.0503
24			.0497	.0503	.061	.1082	.0503
Max	1.6964	1.6003	1.6703	1.5909	.791	1.3767	.7514
Min	.0008	.0166	.0332	.0324	.0324	.0162	.0324
Avg	.6348	.6332	.4585	.5649	.2744	.5225	.1669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024007 / 33 KV BALAPUR S/S

Feeder No / Name : 401 / 33KV Balapur/Wadegaon NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.487	5.487	11.2277	5.487	5.487	10.7956	5.487
2	6.8587	6.8587	13.2373	5.487	5.487	10.5007	5.487
3	6.8587	6.8587	13.8752	5.487	5.487	10.5007	5.487
4	6.8587	6.8587	13.1413	5.487	5.487	9.9109	5.487
5	6.8587	6.8587	13.4603	5.487	5.487	9.9109	5.487
6	6.8587	8.2305	15.1509	5.487	5.487	9.9109	5.487
7	9.6022	9.6022	17.1606	4.1152	4.1152	7.9492	4.1152
8	9.6022	9.6022	18.5323	4.1152	2.7435	7.6543	2.7435
9	9.6022	9.6022	18.5323	4.1152	2.7435	5.487	2.7435
10	8.2305	9.6022	13.4294	8.2305	6.8587	14.4513	8.2305
11	5.8985	4.1152	8.2613	19.616	10.974	17.2291	10.974
12	5.8985	2.7435	8.2613	17.9561	17.38	10.974	10.974
13	7.1605	2.7435	4.1152	17.6681	15.1441	9.6022	8.2305
14	9.4787	2.7435	4.1152	17.38	13.9918	8.2305	8.2305
15	10.535	2.7435	5.487	16.0083	13.1962	8.2305	6.8587
16	10.8505	4.1152	5.487	16.0083	13.1962	8.2305	8.2305
17	5.487	8.8992	5.487	9.6022	14.9246	9.6022	8.2305
18	4.1152	10.9191	4.1152	9.6022	11.9754	9.6022	9.6022
19	4.1152	11.3443	4.1152	4.1152	9.0123	4.1152	5.487
20	5.487	12.7161	5.487	5.487	10.9603	5.487	5.487
21	5.487	13.2373	5.487	5.487	11.2483	5.487	5.487
22	5.487	11.8656	6.8587	5.487	11.2483	5.487	5.487
23	6.8587	13.2373	6.8587	6.8587	11.0906	5.487	5.487
24	5.487	5.487	11.5467	5.487	5.487	10.7956	6.8587
Max	10.8505	13.2373	18.5323	19.616	17.38	17.2291	10.974
Min	4.1152	2.7435	4.1152	4.1152	2.7435	4.1152	2.7435
Avg	7.0485	7.7696	9.7262	8.7609	9.1338	8.9846	6.5158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 201 / 11 KV NIMBA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.0514	.5144	.6173	.0514	.4115	.4801
2	.4801	.0429	.5144	.6173	.0514	.4115	.3201
3	.4801	.0429	.4801	.6173	.0514	.3772	.4801
4	.4801	.0429	.4801	.6173	.0514	.3772	.4115
5	.4801	.048	.4458	.6173	.0429	.3772	.4115
6	.4801	.048	.4458	.4801	.0429	.3772	.4458
7	.4801	.0343	.5144	.4801	.0412	.3772	.3201
8	.4801	.0343	.5144	.4801	.0412	.3772	.4801
9	.4801	.0377	.5144	.4287	.0412	.4115	.4801
10	.048	.0412	.4801	.4115	.0412	.4801	.4458
11	.0412		.4801		.4115	.4801	.4458
12	.0412		.4801	.048	.4801	.4801	.5144
13	.048		.5144	.048	.5487	.4801	.5487
14	.048		.5487	.048	.5487	.5144	.5487
15	.048		.5487	.048	.5487	.5144	.5144
16	.048		.5487	.048	.5487	.5144	.4801
17	.048			.048	.5144	.5144	.4801
18	.048		.4801	.048	.4801	.5144	.5144
19	.0514		.6173	.048	.4458	.5487	.5487
20	.0617		.6859	.0514	.5144	.583	.5487
21	.0617		.6859	.0583	.5144	.583	.5487
22	.0617		.6173	.0617	.5487	.5487	.5144
23	.0566		.6173	.0566	.5487	.5144	.5144
24	.5487	.0514	.5144	.048	.0514	.4801	.5144
Max	.5487	.0514	.6859	.6173	.5487	.583	.5487
Min	.0412	.0343	.4458	.048	.0412	.3772	.3201
Avg	.2340	.0432	.5323	.2620	.2984	.4687	.4796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 202 / 11 KV KARANJA RAMJANPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.0514	.4801	.4801	.0514	.3772	.4458
2	.4115	.0377	.3772	.4801	.0514	.3772	.3429
3	.4115	.0377	.3429	.4801	.048	.3086	.3086
4	.4115	.0377	.3086	.4801	.048	.3086	.3086
5	.4115	.0377	.3086	.4801	.048	.3086	.3086
6	.4115	.0343	.3086	.4801	.0412	.3086	.3086
7	.4115	.0343	.3086	.3429	.0412	.3086	.3429
8	.4115	.0343	.1715	.3429	.0412	.3429	.3429
9	.3772	.0343	.1715	.3772	.0412	.3429	.3429
10	.0412	.0343	.3429	.4115	.0412	.3429	.3429
11	.0377		.3429		.4801	.2515	.3429
12	.0343		.3429	.0412	.4801	.4115	.4115
13			.3772		.4801	.4115	.4801
14	.0343		.4115		.4801	.4115	.4801
15	.0412		.4115		.4801	.4115	.4115
16	.0412		.4115		.4801	.4115	.3772
17			.4115	.0412	.4801		.3772
18	.0343		.3429	.0446	.3772		.3772
19	.0429		.4801	.048	.3772	.4801	
20	.048		.5487	.048	.4115	.5144	.3772
21	.048		.4801	.0514	.4458	.5144	.4115
22	.048		.5487	.0549	.4801	.4801	.4801
23	.0514		.4801	.0514	.4801	.4801	.4801
24	.4801	.0514	.4801	.4801	.0514	.4115	.4801
Max	.4801	.0514	.5487	.4801	.4801	.5144	.4801
Min	.0343	.0343	.1715	.0412	.0412	.2515	.3086
Avg	.2114	.0386	.3829	.2745	.2682	.3871	.3861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024010 / 33 KV KARANJA RAMJANPUR

Feeder No / Name : 204 / 11 KV ANTARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.0634	.6687	.6516	.0617	.583	.6516
2	.6173	.0634	.6516	.6516	.0617	.5144	.6516
3	.583	.06	.6516	.6516	.0617	.5144	.583
4	.583	.06	.6516	.6516	.0617	.5144	.5487
5	.583	.06	.6173	.6516	.0514	.5144	.5487
6	.583	.0549	.583	.5658	.0514	.5144	.5487
7	.583	.0514	.6001	.5316	.0514	.5144	.583
8	.583	.0497	.6001	.5316	.0497	.583	.583
9	.6344	.06	.6001	.583	.0549	.6516	.583
10	.0634	.0652	.6001	.583	.06	.6859	.6173
11	.0634		.6344		.6173	.7202	.6173
12	.0634		.6001	.0566	.7202	.7202	.703
13	.0669		.6001	.0532	.7202	.7202	.703
14			.6173	.0514	.7202	.6516	.703
15	.0669		.6173	.06	.7202	.6173	.703
16	.0669		.6173	.0686	.7202	.6173	.5487
17	.0669		.5658	.0652	.7373	.6001	.6173
18	.0652		.6173	.06	.7373	.6001	.6516
19	.072			.0566	.7373	.6516	.6859
20	.0789		.7202	.0634	.7373	.7202	.6859
21	.072		.7716	.0686	.7202	.7716	.6859
22	.0703		.7373	.0703	.7202	.7716	.6516
23	.0686		.6516	.0652	.7202	.703	.6516
24	.6687	.0634	.6687	.6516	.0617	.583	.6687
Max	.6687	.0652	.7716	.6516	.7373	.7716	.703
Min	.0634	.0497	.5658	.0514	.0497	.5144	.5487
Avg	.3009	.0592	.6367	.3236	.4148	.6266	.6323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 201 / 11 KV NIMKARDA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.2606
2				.2058	.096	.2058	.2469
3				.2058	.192	.2332	.2469
4				.192	.2332	.2606	.2469
5				.1646	.2743	.2606	.2743
6				.2195	.3018	.2743	.3155
7				.2469	.3155	.2606	.3155
8				.3018	.3429	.3429	.2881
9				.3292	.3429	.3704	.3841
10	.4115	.3155	.3292				
11	.3429	.3429	.3155				
12	.3155		.3155				
13	.2743	.2881	.3155				
14	.2743	.2881	.3155				
15	.2469	.2743	.3429				
16	.3018	.2743	.3429				
17	.3429		.3429				
24							.2606
Max	.4115	.3429	.3429	.3292	.3429	.3704	.3841
Min	.2469	.2743	.3155	.1646	.096	.2058	.2469
Avg	.3138	.2972	.3275	.2332	.2623	.2761	.2839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 202 / 11 KV IOC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1698	.2075	.1698	.1886	.2263	.1886
2	.1698	.1698	.2641	.1886	.1886	.2263	.1886
3	.1886	.1698	.2263	.1886	.1509	.2263	.1886
4	.1886	.1509	.1886	.1886	.1509	.2263	.1886
5	.1698	.1509	.1886	.1886	.1524	.2263	.1509
6	.0754	.0754	.1132	.1509	.1143	.0754	.0754
7	.0754	.0754	.0754	.0943	.1143	.0754	.0754
8	.0943	.0754	.0754	.1132	.0762	.1132	.0754
9	.0943	.1132	.2641	.2641	.1524	.1509	.0754
10	.2452	.2641	.2641	.2641	.3239	.2096	.0943
11	.2829	.2263	.3018	.2641	.362	.2096	.1132
12	.3395		.2263	.2263	.3239	.3048	.1698
13	.3018	.3018	.3018	.2263	.2858	.3048	.2263
14	.1886	.3584	.2829	.2263	.3048	.3239	.1886
15	.1886	.3584	.3018	.1886	.2858	.2667	
16	.1509	.2829	.2641	.3018	.2858	.3429	.1886
17	.1509	.3018	.1886	.2641	.2477	.3048	.1509
18	.1132	.1698	.132	.2829	.1509	.1886	.0754
19	.1509	.1509	.1132	.2829	.1886	.1886	.0943
20	.1698	.1886	.1886	.1886	.1886	.1886	.1698
21	.1698	.1698	.1886	.1886	.1886	.1886	.1698
22	.1698	.1698	.1886	.1886	.2075	.1886	.1509
23	.1698	.1698	.1698	.1886	.2075	.1886	.2075
24	.1886	.1698	.1698	.1698	.1886	.2263	.1886
Max	.3395	.3584	.3018	.3018	.362	.3429	.2263
Min	.0754	.0754	.0754	.0943	.0762	.0754	.0754
Avg	.1753	.1927	.2036	.2083	.2095	.2155	.1476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 203 / 11 KV GAIGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0103	.0229	.0141				
3	.0107	.0229	.0141				
4	.0206	.0229	.0141				
5	.0206	.0229	.0282				
6	.0257	.0229	.0352				
7	.0257	.0229	.0423				
8	.0343	.0305	.0423				
9	.0352	.0457	.0352				
10				.0564	.0987	.0686	.061
11				.0634	.061	.0686	.0686
12				.0634	.0457	.061	.0686
13				.0564	.0533	.061	.061
14				.0564	.061	.0533	.061
15				.0564	.061	.061	.061
16				.0705	.061	.0914	.0686
17				.0775	.061	.0686	.072
Max	.0352	.0457	.0423	.0775	.0987	.0914	.072
Min	.0103	.0229	.0141	.0564	.0457	.0533	.061
Avg	.0229	.0267	.0282	.0626	.0628	.0667	.0652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 204 / 11 KV HATRUN FEEDER

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	20-MAY-17
HR	Load (MW)
10	.2229
11	.1932
12	.208
13	.1635
14	.1932
15	.1932
16	.1932
17	.1783
Max	.2229
Min	.1635
Avg	.1932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024011 / 33 KV GAIGAON

Feeder No / Name : 205 / 11 KV NIMKARDA G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.848	1.7372	1.7372	1.7556	1.7002	1.7556	1.5708
2	1.8296	1.7002	1.7187	1.7556	1.7002	1.7002	1.5524
3	1.8296	1.6632	1.7002	1.7741	1.6632	1.7556	1.5524
4	1.848	1.6263	1.7002	1.7372	1.6632	1.6263	1.5339
5	1.7556	1.5893	1.6263	1.7556	1.5339	1.5708	1.5154
6	1.6448	1.5708	1.5708	1.4784	1.4045	1.5524	1.4784
7	1.3491	1.3491	1.2936	1.2567	1.2567	1.3121	1.2197
8	1.2567	1.2936	1.4969	1.1458	1.1827	1.1458	1.1827
9	1.2197	1.1088	1.2567	1.1643	1.1827	1.2012	1.2012
10	1.2936	1.1088	1.2567	1.2012	1.2567	1.2936	1.2567
11	1.3203	1.1088	1.2936	1.2012	1.2936	1.2382	1.3306
12	1.3306		1.2752	1.2197	.961	1.0349	1.2936
13	1.4784	1.4045	1.4045	1.2197	1.0534	1.423	1.4045
14		1.4784	1.4045	1.2567	1.5708	1.5154	1.4415
15	1.5893	1.4784	1.2752	1.386	1.5339	1.5154	1.4415
16	1.386	1.3491	1.423	1.386	1.5154	1.423	1.423
17	1.3306	1.3491	1.4045	1.3306	1.386	1.2012	1.4415
18	1.386	1.2382	1.3491	1.4415	1.1458	1.2197	1.3491
19	.8686	1.4415	1.5708	1.8111	1.5154	1.4045	1.5339
20	1.7187	1.9035	1.848	1.848	1.848	1.7556	1.9404
21	1.885	1.885	1.848	1.848	1.885	1.8665	1.9035
22	1.9035	1.848	1.885	1.848	1.885	1.9404	1.8665
23	1.8296	1.8111	1.8111		1.8296	1.848	1.8296
24	1.885	1.7926	1.7926	1.8111	1.7556	1.7926	1.5708
Max	1.9035	1.9035	1.885	1.848	1.885	1.9404	1.9404
Min	.8686	1.1088	1.2567	1.1458	.961	1.0349	1.1827
Avg	1.5559	1.5146	1.5393	1.5057	1.4884	1.5038	1.4931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 201 / 11 KV WADEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2883	.3052					
3	.2883	.3052	.3795				
4	.3391	.3052	.4858				
5	.39	.3121	.5121				
6	.4748	.5087	.5441				
7	.6274	.6588	.578				
8	.6274	.503	.5851				
9	.6783	.6203	.5921				
10				.6443	.7362	.6958	.8328
11				.7122	.6661	.703	.4917
12				.6443	.5959	.6722	
13				.5765	.5258	.5121	.4748
14				.5256	.5258	.4531	.4578
15				.5426	.4733	.5138	
16				.4917	.5847	.4531	.4917
17		.1898		.5087	.5959	.6478	.4748
Max	.6783	.6588	.5921	.7122	.7362	.703	.8328
Min	.2883	.1898	.3795	.4917	.4733	.4531	.4578
Avg	.4642	.4120	.5252	.5807	.5880	.5814	.5373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 202 / 11 KV TAMSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.1417		.1357	.1372	.125	.1417
2	.3052	.3052	.3841	.1357	.1417	.1107	.1387
3	.3391	.3052	.4534	.1357	.1463	.1107	.128
4		.3052	.4687	.1311	.1448	.0633	.128
5	.4239	.3052	.5182	.1357	.1417	.0791	.1227
6	.5087	.3944	.5624		.124	.08	.1086
7	.6613	.6344	.6093	.0848		.0781	.0934
8	.5087	.788	.6964	.0829	.0876	.0625	.0905
9	.763	.6539	.5921	.0876	.0526	.064	.0732
10	.0848	.0633	.0838	.8987	.7712	.7116	.6783
11	.0848	.0791	.0934	.8648	.6878	.6958	.6952
12	.1017	.0937			.4733	.5281	
13		.096	.1187	.4409	.4908	.4062	.4359
14	.1187		.1017	.407	.4733	.3521	
15	.1187		.1187	.4239	.4733	.4031	
16	.1017	.0781	.1147	.5596	.5083	.4161	.5087
17	.1029	.096	.0934	.5426	.6836	.5441	.6344
18	.0886	.08	.0857	.0857	.0648	.0876	.4578
19	.12	.16	.12		.096	.1227	.3772
20	.1372	.1562	.1372	.1029	.1265		.1526
21	.1543	.1562	.1526	.1526		.1067	
22	.1372	.1406	.1372	.1372	.1423	.1219	.1457
23	.1372	.1423	.1543	.1372	.144	.1219	.1629
24	.1357	.1219	.1265	.1219	.1219	.125	.1372
Max	.763	.788	.6964	.8987	.7712	.7116	.6952
Min	.0848	.0633	.0838	.0829	.0526	.0625	.0732
Avg	.2395	.2408	.2692	.2764	.2833	.2398	.2705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 203 / 11KV BELURA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3881	1.3811	1.0722	1.374	1.3367	1.2151	1.044
2	1.6242	1.6712	1.422	1.3466	1.3184	1.1963	1.3233
3	1.2192	1.2902	.679	1.3256	1.3154	1.166	1.3107
4	1.2154	1.2719	1.1126	1.3112	1.3046	1.1326	1.2922
5	1.2938	1.2826	1.1536	1.308	1.3075	1.0617	1.2735
6	1.4327	1.4594	1.31	1.2666	1.2772	1.0968	1.2528
7	1.7474	1.6811	1.4281	1.1051	.9069	1.0488	1.1311
8	1.8332	1.7246	.9236	.9646	.9455	.9028	.7979
9	1.8854	.9648	1.8294	.8017	.8162	.7506	.7407
10	.9275	1.0341	1.0384	1.4707	1.5821	.6607	1.4994
11		.7621	.7655	1.9321	2.0287	1.0521	1.983
12		.7438	.6257	1.8254	1.044	1.8134	1.0517
13		.4138	1.0183	1.6162	1.6072	1.754	1.5756
14	.3222	.1772	1.0258	1.5108	1.1836	1.5539	1.4429
15	1.3308	.3742	1.0543	1.4033	.3285	1.4502	.7377
16	1.2201	1.0187	1.0734	1.4013	.2492	1.4396	1.527
17	1.2197	.7964	1.0347	1.487	.4329	1.6164	1.6581
18	1.1315	1.0235	.9763	.9796	.6562	1.1591	1.0132
19	1.0807	1.1043	.9495	.7655	.9801	.9377	.6009
20	1.2294	1.257	1.1237	1.1748	.9038	1.0242	1.1731
21	1.3995	1.086	1.3717	1.3701	1.3043	1.4517	1.3983
22	1.4159	1.3714	1.4098	1.403	1.3529	1.4129	1.4013
23	1.4609	1.4058	1.4822	1.4304	1.3306	1.4243	1.4652
24	1.4232	1.3824	1.3748	1.3755	1.323	1.3195	1.377
Max	1.8854	1.7246	1.8294	1.9321	2.0287	1.8134	1.983
Min	.3222	.1772	.6257	.7655	.2492	.6607	.6009
Avg	1.3238	1.1116	1.1356	1.3312	1.1181	1.2350	1.2529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BALAPUR SUB-DN[284] BU 2844

Substation No/ Name :- 024025 / 33 KV WADEGAON S/SN

Feeder No / Name : 204 / 11 KV WADEGAON G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9835	1.0099	.9374	1.0117	.9709	.8749	1.0425
2	.9665	.9431	.9172	.9665	.9745	.8697	1.0425
3	.8817	.9431	.8436	.9602	1.0269	.7811	1.0317
4	.8478	.9054	.7811	.9326	.985	.7499	.985
5	.8478	.8785	.759	.9156	.9568	.7682	.905
6	.9012	.8745	.7186	.8383	.9335	.703	.815
7	.7969	.7545	.7125	.763	.9955	.68	.7499
8	.6783	.6299	.6882	.6783	.7316	.5468	.7421
9	.6783	.7122	.6325	.6687	.6859	.6562	.7316
10	.6783	.6562	.7291	.6952	.8048	.6093	.7291
11	.763	.6874	.7545	.7122	.7888	.6483	.78
12	.7969	.68		.78	.8596	.7611	
13	.8478	.7907	.8309	.8648	.905	.68	.8215
14	.8987	.8223	.8648	.9156	.929	.8642	.8048
15	.8817	.7907	.8987	.9326	.929	.9774	
16	.9326	.7811	.8886	.8987	.9568	.8482	.8478
17	.8573	.7907	.9088	.8817	.8326	.7362	.8817
18	.8063	.7682	.8573	.8573	.6642	.823	.78
19	.9088	.9014	.9187	.9496	.7116	.929	.8987
20	1.0277	.9686	.9431	1.0631		.9145	.9991
21	1.0517	.953	1.0288	1.0288	.9488	1.1043	.8688
22	.945	.953	.945	.9297	.9646	.9145	1.1041
23	.9297	.9686	1.0631	.945	.9602	.9145	.9555
24	1.0174	.9145	.9374	.9145	.8688	.9061	.884
Max	1.0517	1.0099	1.0631	1.0631	1.0269	1.1043	1.1041
Min	.6783	.6299	.6325	.6687	.6642	.5468	.7291
Avg	.8719	.8366	.8504	.8793	.8863	.8025	.8818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 201 / 11 KV WAGHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.439	.439	1.2003	.4115	.4115	.439
2	1.3717	1.4632	1.4632	1.2003	.4115	.4115	.439
3	1.3717	1.4632	1.4632		.4115	.4115	.439
4	1.3717	1.4632	1.4632	1.2346	.4115	.4115	.3658
5	1.3717	1.4998	1.4266	1.3032	.4115	.3772	.3658
6	1.4403	1.5364	1.4266	1.3717	.3429	.3429	.2926
7	1.406	1.6095	1.39	1.406	.2743	.2058	.2195
8	1.3717	1.4632	1.39	1.4403	.2058	.2058	.2195
9	1.3717	1.5364	1.4632		.2058	.1372	.2195
10	.2058	.2195	.2058	.2058	1.4403		1.4632
11	.2195	.2195	.2743	.2058	1.3717	.8779	1.3717
12	.2263	.2195	.2743	.2058	1.3717	1.4632	1.3717
13	.2561	.2561	.2743	.3429	1.3375	1.4632	1.3032
14	.2926	.2561	.2743	.3429	.12	1.5364	1.3032
15	.2926	.2926	.2743	.3429	1.2689	1.5364	1.2346
16	.2926	.2926	.2743	.2743	1.2346	1.4632	1.3717
17	.2926	.2926	.2743	.2058	1.3032	1.4632	1.3717
18	.2926	.2195	.2058	.2058	.2743	1.2437	.2058
19	.3658	.3658	.4115	.3429	.3429	.2926	.3429
20	.439	.439		.4801	.4801	.5121	.4801
21	.5121	.5281	.4801	.4801	.4801	.5121	.4801
22	.5121	.4755	.4115	.4458	.4801	.5121	.4801
23	.439	.439	.3429	.4115	.463	.4755	.4115
24	.4458	.439	.439	.3429	.4115	.4115	.439
Max	1.4403	1.6095	1.4632	1.4403	1.4403	1.5364	1.4632
Min	.2058	.2195	.2058	.2058	.12	.1372	.2058
Avg	.6905	.7262	.7105	.6360	.6444	.7251	.6929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 202 / 11 KV KOTHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9877	.9877	.8916	.9088	.9088	.9145
2	1.0288	1.0974	1.0608	.9945	.8573	.8573	.9145
3	1.0631	1.0974	1.0608	.9945	.823	.7888	.9145
4	1.0631	1.0974	1.0974	.9945	.823	.7888	.8779
5	1.0974	1.0974	.6173	.9945	.823	.7545	.8779
6	1.2003	1.134	1.0974	.9602	.7888	.7202	.8048
7	1.2003	1.2803	1.0242	.9774	.6344	.6344	.5853
8	1.2517	1.2254	1.0974	***	.5316	.6001	.5853
9	.9431	1.0608	.9877	.9431	.5144	.5316	.5487
10	.583	.5853	.5144	.5144	1.2689		1.0974
11		.6219	.5316	.5316	1.3375	1.3535	1.0631
12	.6219	.5853	.583	.5487	1.1145	1.2071	1.0117
13	.6584	.5853	.583	.6173	1.0631	1.0974	.9774
14	.695	.6219	.6722	.6516	.9602	1.0608	
15	.7167	.6584		.6516	1.0288	1.0608	.9431
16	.679	.5853	.6344	.6344	1.046	1.0242	1.0117
17	.6219	.5853	.583	.5658	1.166	.9511	.9945
18	.5853	.5853	.583	.5144	.5144	.7682	.5487
19	1.134	1.0974	.7545	.7716	.8916	.7682	.7164
20	1.2071	1.134	1.286	1.1145	1.166	1.0974	1.0802
21	1.2071	1.134	1.0974	1.1145	1.0974	1.134	1.046
22	1.0974	1.0974	1.0288	1.1317	1.0631	1.0242	1.0288
23	1.0608	1.0608	.9602	.9774	.9431		.9602
24	.9431	1.0242	1.0242	.9602	.9431	.9259	.9877
Max	1.2517	1.2803	1.286	10.5967	1.3375	1.3535	1.0974
Min	.583	.5853	.5144	.5144	.5144	.5316	.5487
Avg	.9385	.9183	.8638	1.2353	.9295	.9117	.8909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 203 / 11 KV MAHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118	1.7375	1.7375	1.6118	1.5604	1.5604	1.2437
2	1.5775	1.7375	1.7193	1.5775	1.5432	1.1831	1.2437
3	1.5775	1.6827	1.7193	1.5432	1.5432	1.2003	1.2437
4	1.5432	1.6827	1.6461	1.5089	1.4746	1.2003	1.2071
5	1.4746	1.6827	1.6461	1.4746	1.2346	1.2003	1.2071
6	1.4746	1.6827	1.5729	1.4746	1.046	1.2003	1.1888
7	1.3203	1.4632	1.4815	1.406	1.0802	1.2174	1.39
8	1.286	1.39	1.3535	1.3375	1.2003	1.2689	1.262
9	1.3375	1.4083	1.39		1.1145	1.166	1.2437
10	1.5432	1.4266	1.3717	1.4746	1.286		1.4083
11	1.5364	1.4449	1.3717	1.5089	1.3203	1.6278	1.2689
12	1.4998	1.4449	1.166	1.2689	1.3375	1.5364	1.2517
13	1.4632	1.4266	1.166	1.2174	1.3717		
14	1.4266	1.3535	1.166	1.2003	1.406	1.5546	1.3203
15	1.2803	1.3169	1.1488	1.166	1.3717	1.5364	1.3375
16	1.2986	1.2803	1.1317	1.1488	1.3546	1.5181	1.3203
17	1.3169	1.2437	1.2346	1.046	1.3717	1.4998	1.406
18	1.5181	1.4449	1.3717	1.3889	1.406	1.4266	1.3375
19	1.829	1.829	1.7147	1.1145	1.6461	1.6827	1.6289
20	2.0302	1.9753	1.9033	1.0631	1.8176	1.9022	1.8004
21	1.9753	1.9387	1.8519	1.749	1.8176	1.9204	1.8347
22	1.829	1.8656	1.8004	1.7318	1.7833	1.9022	1.8004
23	1.8107	1.829	1.6804	1.7147	1.6632	1.829	1.6118
24	1.6118	1.7193	1.7558	1.6632	1.6118	1.6118	1.1888
Max	2.0302	1.9753	1.9033	1.749	1.8176	1.9204	1.8347
Min	1.2803	1.2437	1.1317	1.046	1.046	1.166	1.1888
Avg	1.5488	1.5836	1.5042	1.4083	1.4318	1.4884	1.3802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 204 / 11 KV Donod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.439	.439	.3772	.3772	.3772	1.4632
2	.3429	.3658	.3658	.3429	1.3717	1.406	1.4632
3	.3429	.3658	.3658	.3429	1.3717	1.406	1.4632
4	.3086	.3658	.3292	.3086	1.3717	1.406	1.4632
5	.3086	.3658	.3292	.3086	1.3717	1.406	1.5364
6	.3086	.3292	.2926	.3086	1.2346	1.406	1.5729
7	.2401	.2926	.2561	.2058	1.3717	1.4403	1.7193
8	.2058	.2195	.2195	.1715	1.406	1.5089	1.7558
9	.2058	.1829	.1829	.2058	1.406	1.4403	1.6095
10	2.0576	2.0485		2.0576	.2401		.2195
11	2.1582	2.2314	1.7833	1.8861	.2572	.2926	.2401
12	2.1216	2.0119		2.0576	.2743	.2926	.2743
13	1.829	1.829	1.5432	1.7833	.2743	.2926	.2743
14	1.7924		1.7147	1.5432	.2743	.3292	.2743
15	2.0119	1.7924	1.7147	1.5432	.2743	.3292	.2743
16	1.9753	1.829	1.7147	1.5432	.2743	.3292	.2743
17	1.9022	1.9022	.6859	1.5432	.2572	.2561	.2743
18	.2926			.2058	.2401	.2195	.2401
19	.439	.439	.4458	.3429	.3429		.3772
20	.5121	.5121	.4801	.4458	.3772	.4024	.4801
21	.5121	.5121	.4801	.4458	.4115	.4755	.4801
22	.4755	.5121	.4458	.4458	.4458	.4755	.4458
23	.439	.439	.4115	.3772	.4115	.439	.4115
24	.3944	.439	.439	.4115	.3772	.3944	1.39
Max	2.1582	2.2314	1.7833	2.0576	1.406	1.5089	1.7558
Min	.2058	.1829	.1829	.1715	.2401	.2195	.2195
Avg	.8981	.8829	.6971	.8002	.6673	.7420	.8324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024004 / 33 KV MAHAN S/S

Feeder No / Name : 401 / 33 KV W/W

Feeder KV- 33 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9033	2.1948	2.0851	1.5432	1.5432	2.2119	2.1948
2	1.9547	2.1948	1.9204		1.5432	2.0576	2.1948
3	1.9547	1.9204	1.6461	1.5432	1.5432	2.0576	2.1948
4	1.9547	1.9204	1.6461	1.5432	1.5432	2.0576	2.1948
5	1.8519	1.9204	1.6461	1.5432	1.5432	1.8519	2.1948
6	1.8519	1.9204	1.6461	1.5432	1.5432	1.8519	2.4691
7	1.5947	1.2071	1.6461	2.0576	1.5432	2.4177	2.4691
8	2.0576	1.9204	2.3045	2.0576	2.0576	2.3663	2.4691
9	2.0062	2.4143	2.1948	2.2405	2.0576	2.3663	2.4691
10	2.2119	2.3045	2.0576	2.0576	2.0576	2.3663	2.5789
11	2.1948	2.3045	2.0576	2.0576	2.0576	2.1948	2.3148
12	2.1948	2.4143	2.0576	2.0576	2.0576	2.1948	2.3148
13	2.1948	2.4691		2.0576	2.0576	2.1948	2.3148
14	2.1948	2.4691	2.0576	2.0576	2.0576	2.1948	
15	2.1948	2.4691	2.0576	2.0576	2.0576	2.1948	2.3148
16	2.1948	2.1948		2.0576	2.0576	2.1948	2.3148
17	2.1948	1.9204	2.0576	2.0576	2.1091	1.9753	
18	1.6461	1.6461	1.5432	2.0576	1.6461	1.9204	1.5432
19		1.6461	1.5432	1.5432	1.8519	.9877	1.5432
20	1.6461	1.6461	1.5432	1.5432	1.8004	1.9204	1.6804
21	1.6461	1.6461	1.5432	2.0576	1.749	1.6461	1.5432
22	1.6461	1.6461	1.5432	2.0576	1.6975	2.1948	1.5432
23	1.6461	1.6461	1.6804	2.0576	2.2634	2.4691	2.0576
24	.5658	2.1948	2.1948	1.5432	2.0576	2.2119	2.4691
Max	2.2119	2.4691	2.3045	2.2405	2.2634	2.4691	2.5789
Min	.5658	1.2071	1.5432	1.5432	1.5432	.9877	1.5432
Avg	1.8914	2.0096	1.8487	1.8866	1.8540	2.0875	2.1538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 201 / 11 KV PATUR-NANDAPUR
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0903	1.0269	1.1088	.9335		.9335	
2	1.0164	1.0082	.7577	.6379		.7087	
3	1.0164	1.0082	.7762	.6379		.7087	
4	1.0164	.9709	.7762	.6379		.7164	
5	1.0164	.9335	.8131	.7087		.7164	
6	1.0164	.9335	.8871	.7087		.7087	
7	1.0164	1.1203	.9055	.7796		.7087	
8	1.0534	1.1203	.961	.7796		.8505	
9	.7577	1.1203	.924	.7796		.8962	
10	.8402	.7796	.823	.8402		.7468	
11	.823	.7796	.7202	.9335		.9335	
12	.7468	.823	.7796		.7468		.9055
13	.8962	.8916	.8859		.8215		.9425
14	.8962	.823	.8859		.9335		
15	.8505	.823	.7796		.9335		.8871
16	.8505	.823	.7796		.9335		.8871
17	.8505	.8916	.7796		.9709		.9979
18	.8962	1.0349	.8215		1.0269		1.0349
19	1.1203	1.0349	.9335		.9709		1.0164
20	1.307	1.1458	1.307		1.307		1.2752
21	1.307	1.1458	1.307		1.307		1.3121
22	1.307	1.2012	1.1576		1.307		1.3121
23	.9335	1.1827	1.1576		1.1576		1.2012
24	1.1088	1.0269	1.1273	1.1203		1.0631	
Max	1.307	1.2012	1.307	1.1203	1.307	1.0631	1.3121
Min	.7468	.7796	.7202	.6379	.7468	.7087	.8871
Avg	.9889	.9854	.9231	.7915	1.0347	.8076	1.0702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 202 / 11 KV PINJAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0534	.9335	.9795	1.0269		.9335	
2	.7545	.6733	.7373	.9335		.9335	
3	.7716	.6733	.7373	.9335		.9335	
4	.7716	.6733	.7373	.9335		.9335	
5	.7888	.6733	.7545	.9335		.9335	
6	.8402	.7087	.7716	.8402		.8402	
7	.8573	.7973	.823	.8402		.7468	
8	.8916	.7087	.7545	.7468		.8402	
9	.7373	.7087	.7888	.7468			
10	.8871	.7468	.8871	.9335		.8859	
11	.8871	.7468	.8501	.9745		.8859	
12	.8402	.8686	.7468		.6733		.7545
13	.8402	.8131	.7468		.6379		.7373
14	.8962	.8501	.7095		.6379		
15	.9335	.8316			.7087		.6687
16	.9335	.8871			.7973		.6859
17	.9335	.8501	1.1203		.7796		.7373
18	.9709	.8316	1.1203		.9335		.8871
19	1.0269	.9979	1.1203		.9335		1.0349
20	1.1949	1.0719	1.1949		1.1949		1.2012
21	1.1949	1.2012	1.1949		1.1949		1.1088
22	1.1949	1.1088	1.1763		1.1949		1.0719
23	1.1203	1.0719	1.1203		1.1203		1.0534
24	1.0719	1.1203	1.0164	1.1203		1.0269	
Max	1.1949	1.2012	1.1949	1.1203	1.1949	1.0269	1.2012
Min	.7373	.6733	.7095	.7468	.6379	.7468	.6687
Avg	.9330	.8562	.9131	.9136	.9006	.8994	.9037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 203 / 11 KV MAHAN (PINJAR)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.7095	.7577	.7468		.7655	
2	.7207	.7095	.5544	.5228		.4835	
3	.7207	.7095	.5144	.4961		.4784	
4	.7207	.7095	.5544	.4961		.5316	
5	.7207	.6722	.5487	.567		.6722	
6	.7207	.6722	.7577	.6379		.7095	
7	.7023	.6535	.6283	.6733		.7442	
8	.5914	.3734	.6468	.7442		.691	
9	.5544	.5041	.6283	.7087		.7087	
10	.703	.6379	.6344	.5788		.5601	
11	.7202	.7265	.7202	.6535		.6161	
12	.7265	.5144	.691		.6348		.5544
13	.6379	.4973	.6201		.6161		.5175
14	.691	.463	.6379		.6348		
15	.6201	.4801	.6201		.6348		.499
16	.7087	.6001	.5493		.6348		.5544
17	.7095	.6344	.6379		.5788		.5914
18	.5975	.4435	.5601		.6722		.5729
19	.7282	.6838	.7468		.7468		.6838
20	.8215	.9055	.8962		.9149		.8871
21	.8029	.924	.9335		.9335		.8501
22	.7842	.8686	.9149		.8962		.8871
23	.7468	.8131	.8029		.8402		.7947
24	.7577	.8029	.7762	.7655		.8215	
Max	.8215	.924	.9335	.7655	.9335	.8215	.8871
Min	.5544	.3734	.5144	.4961	.5788	.4784	.499
Avg	.7061	.6545	.6805	.6326	.7282	.6485	.6720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 204 / 11 KV MAHAGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5359	.5601	.7392	.7468		.7842	
2	.6001	.5041	.7947	.7468		.7282	
3	.7023	.5041	.7545	.7468		.7282	
4	.6344	.5041	.7545	.7468		.7282	
5	.6344	.5041	.7888	.7468		.7468	
6	.8131	.6161	.8916	.6161		.7655	
7	.8059	.3361	.7888	.7842		.7095	
8	.7888	.4668	.7545	.5975		.6348	
9			.7545	.6161			
10	.4251	.8859	.5359	.8589		.7796	
11	.4805	.9335		.8682		.815	
12	.4108	.3881			.7087		.6344
13	.4108	.4251			.7087		.6838
14	.7282	.7207			.6733		
15	.5788				.6556		.5658
16	.5975	.7202			.6733		.5316
17		.7716	.7468		.6556		.6001
18	.8402	.8059	.8589				.6468
19	.8775	.9259	.9522		.7842		.8686
20	.9709	.9425	.9335		1.0829		.961
21	.9149	.8686	.8589		.9335		.9055
22	.8402	.9055	.8402		.9335		.8686
23	.6161	.7947	.8215		.8402		.8316
24	.5359	.5788	.7762	.7468		.7842	
Max	.9709	.9425	.9522	.8682	1.0829	.815	.961
Min	.4108	.3361	.5359	.5975	.6556	.6348	.5316
Avg	.6701	.6665	.7970	.7352	.7863	.7458	.7362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 205 / 11 KV BAHIRKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0164	.8029	1.1458	.6908		1.531	
2	.9979	.9522	.8316	.7087		1.825	
3	.9979	.9522	.8316	.7087		1.825	
4	.9979	.9522	.8316	.7619		1.9136	
5	1.0349	.8962	.8501	.7973		2.0022	
6	1.0349	.9896	.9979	.9391		2.268	
7	.8871	.6535	1.8861	1.0985		2.1794	
8	.7207	.7655	1.8519	.8859		1.6832	
9	.6468	.7842	1.869	.8505		1.8427	
10	.9945	.8859	.9259	.6535		1.5769	
11	1.1488	1.0099	1.1488	.6722		.6161	.7762
12	1.0631	.8402	1.1517		.6687		.7577
13	1.0631	.7888	.815		.6348		.7762
14	.9391	.703	.815		.6722		
15	.9036	.6687	.9391		.6535		.7947
16	.8859	.7716	.9568		.6908		.9055
17	.9214	.823	.9214		1.6832		.7762
18	.6908		.5601		1.1576		.8131
19	.8589	.8131	.8402		1.2323		.9979
20	1.1203	.8501	.9149		1.8111		1.1088
21	1.1016	.8686	.8402		1.8484		1.2012
22	.9335	.8871	.8775		1.8298		1.2012
23	.9149	.8871	.7468		1.6244		1.0534
24	1.0534	.8215	.9979	.6908		1.5497	
Max	1.1488	1.0099	1.8861	1.0985	1.8484	2.268	1.2012
Min	.6468	.6535	.5601	.6535	.6348	.6161	.7577
Avg	.9553	.8420	1.0228	.7882	1.2089	1.7344	.9302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024005 / 33 KV PINJAR

Feeder No / Name : 206 / 11 KV GHOTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2382	1.2136	1.2752	1.2323			
2	1.0974	.9568	.9945	1.6617			
3	1.1317	.9568	1.166	1.643			
4	1.1145	.9922	1.1831	1.5684			
5	1.1145	1.0985	1.166	1.4937			
6	1.5089	1.3112	1.2517	1.5123			
7	1.3889	1.3289		1.1016			
8	1.3203	1.2403		1.1949			
9	1.286	1.3112		1.251			
10	1.2012	1.0456	1.0534	1.3289			
11	1.4045	1.3256	1.2382	1.5061		1.134	
12	1.5684	1.4045	1.2883		1.2934		1.0288
13	1.4937	1.4784	1.307		1.0631		1.166
14	1.5684	1.4969	1.251		1.1163		
15	1.531	1.46	1.3443		1.1871		1.0117
16	1.531	1.423	1.307		1.1871		.9088
17	1.531	1.386	1.307				1.0974
18	1.307	1.3121	1.1016				1.0534
19	1.4937	1.3676	1.3443				1.4784
20	1.587	1.5893	1.4377				1.5893
21	1.4563	1.5339	1.419				1.7002
22	1.419	1.423	1.4563				1.7187
23	1.3443	1.423	1.419				1.5154
24	1.3491	1.2696	1.3121	1.307			
Max	1.587	1.5893	1.4563	1.6617	1.2934	1.134	1.7187
Min	1.0974	.9568	.9945	1.1016	1.0631	1.134	.9088
Avg	1.3744	1.3062	1.2677	1.4001	1.1694	1.134	1.2971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 201 / 11 KV KANHERI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377		.0312	.0497	.132	.0162	.6554
2	.3658		.0324	.4144	.7964	.6478	.6554
3	.3658		.0625	.4144	.7449	.6478	.6478
4	.362		.0781	.4475	.8413	.6478	.7209
5	.362		.0937	.4475	.8097	.6478	.8413
6	.3982		.0937	.4807	.9069	.7287	.7865
7	.439		.0937	.4973	.9555	.8097	.8192
8	.4755		.0937		.9555	.8421	.8192
9	.724		.125		.4858	.8583	.5243
10	.8145		.7655		.4424		.6219
11	.7125	.6081	.7625	.724	.4372		.5801
12	.7125	.7202	.779	.8413	.4372		.5967
13	.7287	.7202	.8288	.9069	.4534		.5801
14	.7287	.7042	.8619	.9145	.4534		.5304
15	.7287	.7042	.9116	.9412	.4372		.5304
16	.7449	.7042	.8785	.6478	.4534		.5304
17	.7287	.7362	.779	.6316	.4534		.5304
18	.0162	.032		.0377	.0162	.5487	.0332
19	.0324	.032	.064	.1132	.0162	.5853	.0497
20	.0324	.032	.0663	.1698	.0162	.5506	.0663
21	.0324	.032	.0663	.1698	.0162	.6554	.0663
22	.0324	.032	.0497	.1698	.0162	.7316	.0663
23	.0324	.032	.0497	.1509	.0162	.6554	.0663
24	.0754	.0324	.0312	.0497	.132	.0162	.6226
Max	.8145	.7362	.9116	.9412	.9555	.8583	.8413
Min	.0162	.032	.0312	.0377	.0162	.0162	.0332
Avg	.4035	.3658	.3303	.4390	.4344	.5993	.4975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 202 / 11 KV DHABA BT

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.181
2				.1989	.1132	.2591	.1829
3				.1989	.1086	.1619	.1867
4				.1989	.1829	.2591	.1829
5				.2321	.2195	.2591	.2195
6				.2486	.2926	.2915	.2561
7				.2818	.3077	.3239	.2715
8					.3109	.3239	.2743
9					.3109	.3239	.2743
10	.2785		.3041				
11		.25	.2321				
12		.25	.1989				
13		.25	.2321				
14		.25	.2486				
15		.25	.2652				
16		.2343	.2984				
17		.2343	.2321				
24							.1097
Max	.2785	.25	.3041	.2818	.3109	.3239	.2743
Min	.2785	.2343	.1989	.1989	.1086	.1619	.1097
Avg	.2785	.2455	.2514	.2265	.2308	.2753	.2139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 203 / 11 KV REDWA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0162	.0497	.0189	.0162	.6882
2			.0162	.0497	.6554	.6802	.6554
3			.0162	.0497	.6802	.6802	.6554
4					.6964	.7287	.6554
5					.7125	.7773	.6554
6					.7287	.8097	.6882
7					.7935	.8583	.6964
8					.7935	.8097	.7045
9					.6478	.7449	.8029
10	.8413		1.004				
11	.7773	.7287	.9116	1.0688			
12	.7773	.8421	.779	1.0688			
13	.7773	.9069	.7956	1.1706			
14	.8097	.9069	.7956	1.004			
15	.8097			.9831			
16	.8097	.9069		.9175			.0332
17	.8421	.9069	.8619				.0332
18		.0162	.9945	.0189	.0162		.0332
19		.0162	.0497	.0189	.0162		.0332
20		.0162	.0497	.0189	.0162	.0189	
21		.0162	.0497	.0189	.0162	.0189	.0332
22		.0162	.0497	.0189	.0162	.0189	.0332
23		.0162	.0497	.0189	.0162	.0189	.0332
24			.0162	.0497	.0189	.0162	.7209
Max	.8421	.9069	1.004	1.1706	.7935	.8583	.8029
Min	.7773	.0162	.0162	.0189	.0162	.0162	.0332
Avg	.8056	.4413	.4035	.4078	.3652	.4426	.4209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 204 / 11 kv Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904		.5658	.6535	.5281	.547	.5658
2	.4527		.5658	.6535	.5281	.5281	.5601
3	.4108		.5281	.6535	.5281	.5281	.5281
4	.415		.4904	.7095	.4904	.5281	.5175
5	.3772		.5281	.7095	.4904	.5658	.5281
6	.3772		.5658	.7095	.4904	.5658	.547
7	.3584		.5658	.7095	.4481	.5658	.547
8	.3584		.5847		.4435	.5281	.547
9	.3772		.5658		.439	.5093	.5228
10	.4294		.7733		.4481	.4527	.5228
11	.415	.5281	.7095	.5975	.4527	.4527	.5228
12	.4338	.5658	.6722	.6036	.415	.439	.5228
13	.415	.5658	.6535	.6036	.415	.439	.5228
14	.3961	.4715	.6535	.5975	.3961	.4755	.4668
15	.3772	.4904	.6535	.5544	.3772	.4755	.4668
16	.415	.5281	.5975	.5487	.3961	.5093	.4481
17	.3961	.5281	.5601	.5601	.3772	.4938	.4294
18	.4338	.4527	.5788	.5658	.415	.5281	.5228
19	.4338	.4715	.5975	.5601	.5093	.5415	.5601
20	.4527	.4715	.6535	.5658	.5281	.5658	.6161
21	.5281	.4904	.6722	.547	.5281	.5487	.5975
22	.5658	.5658	.6535	.547	.5658	.5487	.6161
23	.5658	.5658	.6535	.547	.5658	.5729	.5975
24	.5281	.5847	.5658	.7095	.547	.547	.5847
Max	.5658	.5847	.7733	.7095	.5658	.5729	.6161
Min	.3584	.4527	.4904	.547	.3772	.439	.4294
Avg	.4335	.5200	.6087	.6146	.4718	.5190	.5359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 205 / 11 kv Dagadparwa Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294		.2829	.2801	.1646	.2829	.2195
2	.1966		.2829	.2801	.1646	.2829	.2218
3	.2172		.2641	.2427	.1475	.2267	.2195
4	.2172		.2641	.2241	.1646	.2641	.1829
5	.2172		.2641	.2054	.1646	.2452	.1829
6	.181		.2263	.1867	.1475	.2452	.1829
7	.181		.2263	.2054	.1646	.2452	.1646
8	.1829		.1698		.1646	.1886	.1646
9	.1646		.1698		.1646	.1698	.1829
10	.1463		.1698		.1646	.1698	.2012
11	.1296	.1886	.168	.128	.1698	.2075	.2241
12	.1509	.1886	.1867	.128	.1698	.1829	.2054
13	.1698	.1886	.1867	.128	.1886	.181	.2054
14	.1509	.1698	.1867	.128	.1886	.1829	.1867
15	.1698	.1886	.1867	.1463	.1886	.181	.168
16	.1886	.2075	.1867	.1646	.1886	.1829	.1867
17	.2263	.1886	.168	.1829	.1886	.1829	
18	.2641	.2263	.168	.2172	.2263	.2195	.2614
19	.2829	.2641	.2427	.2641	.2829	.2534	.2987
20	.3018	.3018	.3174	.2896	.3395	.2926	.3174
21	.3018	.3206	.3361	.2926	.2753	.2926	.3174
22	.3018	.3206	.3174	.2926	.3018	.2926	.2987
23	.3018	.3206	.3174	.2561	.3018	.2561	.2801
24	.3475	.3018	.2829	.2987	.1457	.2829	.2561
Max	.3475	.3206	.3361	.2987	.3395	.2926	.3174
Min	.1296	.1698	.168	.128	.1457	.1698	.1646
Avg	.2175	.2412	.2321	.2162	.1987	.2296	.2230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024006 / 33 KV BARSHI TAKLI S/S

Feeder No / Name : 206 / 11 kv Barshitakali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9662		2.2634	2.1472	1.9662	2.3388	2.0729
2	1.8023		2.2405	1.9044	1.6385	2.1691	1.6385
3	1.6385		2.2032	1.8298	1.6385	2.1691	1.749
4	1.6385		2.1472	1.7737	1.6385	2.0748	1.6194
5	1.6385		2.0911	1.7177	1.829	1.8861	1.6194
6	1.6385		2.0538	1.7364	1.7558	2.0182	1.6057
7	1.5546		1.8484	1.7177		1.8484	1.5402
8	1.5074		1.6804		1.8023	1.9805	1.5074
9	1.6385		1.9044		1.8023	2.0748	1.4575
10	1.6712		2.0538		1.8023	2.0936	1.4746
11	1.9805	1.9605	1.8298	1.7375	2.0936	1.9239	1.7177
12	1.9805	2.0165	1.6617	1.7924	2.0748	1.9909	1.7737
13	1.9616	2.0559	1.9044	1.8099	1.9805	1.8099	1.8298
14	1.9616		1.9978	1.6194	1.9616	1.6194	1.9044
15	1.9805		2.0351	1.8656	1.9616	1.8023	1.9044
16	2.0182	2.2779	2.0911	1.9022	1.9239	1.704	1.9605
17	2.1125	2.2032	2.0165	1.704	1.9805	1.7204	1.8484
18	2.037	2.0911	1.9418	2.1719	2.2634	1.9909	1.9978
19	2.3011	2.3152	2.0165	2.3777	2.452	1.9662	2.0271
20	2.3765	2.4272	2.1472	2.1376	2.4897	2.13	2.2218
21	2.3765	2.4272	2.0911	2.3777	2.4709	2.13	2.2779
22	2.3577	2.4459	2.1845	2.0729	2.4709	2.0972	2.3525
23	2.3577	2.3899	2.2779	2.0729	2.4143	2.0645	2.2779
24	1.9757	2.3388	2.2965	2.2965	2.0481	2.3388	1.9757
Max	2.3765	2.4459	2.2965	2.3777	2.4897	2.3388	2.3525
Min	1.5074	1.9605	1.6617	1.6194	1.6385	1.6194	1.4575
Avg	1.9363	2.2458	2.0408	1.9412	2.0200	1.9976	1.8481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 201 / 11 KV DHABA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1715	.1543	.1715	.1543	.1715	.1543
2	.1372	.1372	.1372	.1715	.1543	.1543	.1543
3	.1372	.1543	.1372	.1543	.1372	.1543	.1543
4	.1372	.1372	.1372	.1372	.1372	.1372	.1543
5	.1372	.1029	.1543	.1372	.1372	.1372	.12
6	.1372	.1029	.1543	.1372	.1372	.1372	.12
7	.1029	.1029	.12	.1029	.1029	.1029	.1029
8	.0857	.0914	.0686	.1029	.1029	.1029	.1029
9	.1029	.0857	.0857	.0857	.1029	.1029	.1029
10	.1029	.1029	.0857	.0857	.1029	.1029	.12
11	.0686	.1097	.1029	.1029		.1052	.1029
12	.0857	.1086	.1029	.1029	.0686	.1402	.1029
13	.0857	.1086	.1029	.1029	.1372	.1402	.1029
14	.1029	.1086		.12	.12	.1402	
15	.1029	.1075	.1029	.1029	.1372	.1448	.1029
16	.0857	.1097	.1029	.1029	.1372	.1448	.0857
17	.1029	.1029	.1029	.12	.1029	.1029	.1052
18	.12	.1029	.12	.12	.1029	.12	.0876
19	.1886	.1372	.1715	.1372	.1372	.1543	.1075
20	.2058	.1886	.1886	.1715	.1886	.1886	.1791
21	.2058	.2058	.1715	.1543	.2058	.1886	.1433
22	.2058	.1886	.1715	.1715	.1886	.1886	.1433
23	.1715	.1543	.1715	.1715	.1715	.1715	.1494
24	.1543	.1715	.1543	.1715	.1543	.1543	.1543
Max	.2058	.2058	.1886	.1715	.2058	.1886	.1791
Min	.0686	.0857	.0686	.0857	.0686	.1029	.0857
Avg	.1293	.1289	.1305	.1308	.1357	.1411	.1240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 202 / 11 KV Punoti Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2401	.2572	.2915	.2743	.3086	.2401
2	.3258	.2401	.2572	.3086	.2915	.3086	.2401
3	.3086	.2401	.2401	.3086	.2915	.2743	.2401
4	.3086	.2058	.2401	.3086	.2743	.2743	.2401
5	.2915	.2058	.2229	.2743	.2743	.2743	.2058
6	.2915	.2058	.2229	.2401	.2401	.2743	.2058
7		.1886	.1715	.1543	.1543	.1715	.1715
8	.1715	.1886	.1543	.1543	.1543	.1543	.1543
9	.1886	.1886	.1372	.1372	.1543	.1543	.1543
10	.1886	.1886	.1372	.1372	.1715	.1543	.1543
11	.2229	.0895	.1715	.1543	.2058	.1772	.1715
12	.1886		.1886	.1886	.2058	.2103	.2058
13	.2229		.1715	.1715	.2401	.2103	.2229
14	.2401	.1991	.2229	.1715	.2401	.2103	
15	.2401	.1791	.2229	.1886	.2229	.2126	.2229
16		.1463	.2058	.1715	.2229	.2126	.2058
17	.2401	.1715	.1715	.1886	.2058	.1715	.2058
18	.12	.1715	.1715	.2058	.2058	.1715	.1886
19	.2572	.2572	.3086	.2572	.2401	.2401	.2058
20	.3429	.3258	.3429	.3429	.2915	.3601	.3681
21	.3258	.3429	.3258	.3429	.3086	.3601	.3506
22	.2915	.3086	.3258	.3258	.3258	.3429	.3506
23	.2915	.3086	.3258	.3086	.3086	.3086	.3109
24	.3086	.2743	.2743	.2915	.3086	.3086	.2915
Max	.3429	.3429	.3429	.3429	.3258	.3601	.3681
Min	.12	.0895	.1372	.1372	.1543	.1543	.1543
Avg	.2588	.2212	.2279	.2343	.2422	.2436	.2307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

BARSHI TAKLI SUB-DN[756] BU 4756

Substation No/ Name :- 024028 / 33 KV DHABA

Feeder No / Name : 203 / 11KV NIMBI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762					.061
2		.061	.0343				.061
3		.061	.0514	.0324			.061
4		.1829	.0514	.0324			.061
5		.061	.0514	.0514			.061
6		.0914	.0686	.0514			.061
7		.0914	.0686	.0686			.061
8		.0914	.1029	.0686			.061
9		.061	.1029	.0686			.061
10		.061		.0857	.0972	.0857	.061
11				.0686	.061	.0743	.081
12				.0514	.061	.0743	.0648
13				.0514	.0305	.0305	.0648
14				.0343	.0305	.0324	
15				.0343	.0305	.0324	.0324
16					.0305	.0532	
17			.0914	.0648	.0514	.061	.0305
18			.0914			.061	
19	.0762		.0914			.061	
20	.0762		.0914			.061	
21	.0762		.0914			.061	
22	.0762		.0914			.061	
23	.0762		.0914			.061	
24		.0762		.0914			.2591
Max	.0762	.1829	.1029	.0914	.0972	.0857	.2591
Min	.0762	.061	.0343	.0324	.0305	.0305	.0305
Avg	.0762	.0831	.0781	.0570	.0491	.0578	.0714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 201 / 11 KV KOLSARA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7499	.8002	.793	.8215	.7621	.8573	
2	.6965	.8002	.7285	.8215	.7621	.8002	
3	.4054	.8002	.7209	.7468	.7621	.8002	
4	.6557	.8002	.6921	.7468	.6668	.7621	
5	.6264	.7621	.6921	.7095	.6668	.6859	
6	.5902	.6668	.6219	.6722	.6287	.6859	
7	.5533	.6097	.5527	.5415	.6097	.5335	
8		.6097	.5335	.5906	.5415	.6097	
9		.5601	.6478	.5335	.5228	.5487	
10		.5601	.6097	.6097	.5415	.5902	
11	.439	.5228	.6478	.6097		.5871	
12	.5487	.6161	.6859	.4954	.6535	.6089	.724
13	.7316	.6348	.724	.724	.5788	.6468	.8383
14	.7499	.5658	.7621	.724	.6348	.6776	.8002
15	.6767	.6161	.724	.724	.7095	.6849	.8002
16	.7049	.5527	.6859	.6859	.7621	.6908	.8002
17	.6859	.5447	.5788	.6668	.6097	.5788	.7621
18	.6478	.5498	.5788	.743	.6859	.5415	.6859
19	.8002	.6849	.7468	.8764	.6859	.6535	.8383
20	.9526	.9107	.9149	.9526	.8764	.9522	.9717
21	.9526	.9231	.9709	.9526	.8764	.9335	.9717
22	.9335	.9362	.9335	.9145	.9907	.9709	.9907
23	.8954	.8779	.9149	.9145	.9145	.9335	.9526
24	.7468	.8002	.8291	.8589	.7621	.8573	.8589
Max	.9526	.9362	.9709	.9526	.9907	.9709	.9907
Min	.4054	.5228	.5335	.4954	.5228	.5335	.6859
Avg	.7020	.6960	.7204	.7348	.7045	.7163	.8458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 202 / 11 KV BHATORI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7514	.7621	.7865	.8589	.8573	.9526	
2	.739	.7621	.7832	.8215	.8573	.8573	
3	.7186	.7621	.7346	.7842	.724	.8573	
4	.7186	.7621	.6375	.7842	.724	.7621	
5	.7209	.7621	.6612	.7468	.724	.7621	
6	.7186	.6478	.6557	.7095	.6859	.7621	
7	.5749	.5525	.5578	.5415	.6287	.6859	
8		.5335	.6097	.6097	.6535	.6097	
9		.5788	.5716	.6097	.6722	.6557	
10		.5975	.6097	.6097	.6722	.6488	
11	.5487	.5788	.6859	.6097		.7444	
12	.7209	.7095	.6859	.724	.7282	.7066	.8383
13	.7339	.6908	.724	.7621	.8029	.6219	.8764
14	.6632	.6908	.7621	.7621	.168	.8291	
15	.7339	.6722	.7621	.8002	.6908	.7832	.8383
16	.7621	.7339	.7621	.8002	.7049	.8402	.7621
17	.6478	.6827	.5788	.7621	.8383	.6908	.9526
18	.7049	.5929	.5788	.8573	.724	.6348	.7621
19	.8573	.7468	.7468	.8764	.8383	.7842	1.086
20	.9717	.9069	1.0082	.9907	1.105	1.0269	1.0669
21	.9145	.9481	1.0082	.9717	1.105	.9896	1.086
22	.9335	.9431	.9896	.9907	1.105	.9709	1.086
23	.9145	.9107	.9149	.9335	1.0669	.9335	1.086
24	.775	.7621	.8291	.9149	.8573	.9526	.8962
Max	.9717	.9481	1.0082	.9907	1.105	1.0269	1.086
Min	.5487	.5335	.5578	.5415	.168	.6097	.7621
Avg	.7535	.7204	.7352	.7846	.7797	.7943	.9447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 203 / 11 KV JAMBHA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	21-MAY-17
HR	Load (MW)
22	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024019 / 33 KV DURGAWADA SUB-STATION

Feeder No / Name : 204 / 11 KV POHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1442	.1334	.1183	.1494	.1334	.1715	
2	.1258	.1334	.1275	.1494	.1334	.1524	
3	.1255	.1334	.1014	.1307	.1334	.1524	
4	.1231	.1334	.1031	.1307	.1334	.1334	
5	.1231	.1334	.0869	.1307	.1334	.1334	
6	.1256	.1334	.0869	.112	.1143	.1334	
7	.1078	.1334	.0901	.112	.1143	.1524	
8		.1334	.1143	.1143	.112	.1334	
9		.0934	.1143	.0953	.112	.127	
10		.112	.1143	.1334	.112	.1262	
11		.0934	.1143	.1143		.1262	
12	.1284	.112	.1334	.1143	.0934		.1334
13	.1182	.112	.1334	.1334	.1307	.1437	.1334
14	.107	.0934	.1334	.1524	.1494	.1442	
15	.1081	.112	.1334	.1524	.1307	.1442	.1334
16	.1143	.1101	.1334	.1524	.1524	.1494	.1334
17	.1143	.1014	.0934	.1334	.1524	.1307	.1143
18	.1143	.0847	.0934		.1334	.112	.1143
19	.1524	.1024	.1307	.1524	.1715	.168	.1524
20	.1524	.1347	.1494	.1715	.1905	.168	.1715
21	.1524	.1425	.168	.1715	.1905	.1867	.1715
22	.1715	.1583	.1494	.1715	.1905	.168	.1715
23	.1715	.1457	.1494	.1524	.1715	.168	.1715
24	.1347	.1715	.1258	.1494	.1334	.1715	.168
Max	.1715	.1715	.168	.1715	.1905	.1867	.1715
Min	.107	.0847	.0869	.0953	.0934	.112	.1143
Avg	.1307	.1228	.1207	.1382	.1401	.1477	.1474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 201 / 11 KV MANA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.7373	.7202	.703	.7202	.7373	.703
2	.7545	.7202	.7202	.703	.703	.703	.6859
3	.6859	.703	.703	.6859	.6859	.6859	.6859
4	.6859	.703	.703	.6859	.6859	.6859	.6687
5	.6173	.6687	.6859	.6687	.703	.6344	.6344
6	.6173	.463	.6173	.6001	.6001	.5658	.583
7	.6516	.4973	.583	.5144	.5658	.5316	.5316
8	.6173	.5144	.583	.6001	.5316	.4973	.4973
9		.6173	.5658	.6173	.6001	.5658	.5658
10		.6687	.6001	.5316	.6344	.463	.5658
11		.583	.5658	.5487	.6173	.6001	.5487
12	.6001	.583	.5487	.5658	.583	.463	.5658
13	.7202	.6516	.5487		.6001	.6344	.6001
14	.6687	.6516	.6001	.6344	.6516	.6173	.6001
15	.6859	.6344	.6001	.6687	.6344	.6344	.6001
16	.6859	.5316	.6001	.6344	.6687	.6173	.6344
17	.6516	.5487	.5658	.6344	.5658	.5658	.583
18	.5658	.5487	.5487	.5487	.5144	.5487	.583
19	.7202	.7202	.6344	.7202	.5487	.6344	.6344
20	.7888	.7888	.8059	.7545	.8059	.7888	.7716
21	.7373	.7888	.7545	.7545	.7716	.7716	.7716
22	.7716	.7888	.7716	.7545	.7545	.7545	.7716
23		.7716	.7373	.7545	.7202	.7716	.7373
24		.7373	.7202	.7202	.7202	.7545	.7373
Max	.7888	.7888	.8059	.7545	.8059	.7888	.7716
Min	.5658	.463	.5487	.5144	.5144	.463	.4973
Avg	.6805	.6509	.6451	.6523	.6494	.6344	.6359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 202 / 11 KV KURUM AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.1372	.0995	.1029	.0686	.0663
2	.6001	.8059		.9945	.7888	.0686	.0663
3	.6001	.7888		.9945	.8573	.0686	.0663
4	.6001	.7888		.9614		.0686	.0663
5	.6001	.7888		.9282		.0686	.0497
6	.5144	.8916		.9614	.6001	.0514	.0497
7	.6001	.9774		1.0774	.583	.0514	.0497
8	.6173	1.0288		.9779	.583	.0343	.0497
9		.9774		.9614	.4458	.0497	.0497
10		.0343	.6133	.0663	1.1488	1.2431	1.1145
11		.0343	.547		1.1145	1.2597	1.2689
12	.0171	.0343	1.094		1.1317	1.3094	
13	.0343	.0343	1.6575		.9602	1.1437	1.046
14	.0343	.0686	1.6409	.0332	.8059	1.0111	1.046
15	.0171	.0343	1.7072	.116	.7716	.8951	1.046
16	.1029	.1372	1.7238	.0514	.9431		1.0288
17	.12	.1029	1.6575	.0686	1.0802	1.21	1.2346
18	.0343	.1029	.0829	.0686	.0686	.0663	.0514
19	.0857	.0514	.0829	.0686	.0857	.0663	.0857
20	.0686	.1029	.0829	.0857	.0686	.0663	.0857
21	.0514	.1029	.0995	.0857	.0857	.0663	.0857
22	.0514	.1372	.0995	.0857	.0686	.0497	.1029
23	.0514	.1372	.0995	.0857	.0686	.0663	.1029
24		.0514	.1372	.0829	.0857	.0686	.0663
Max	.6173	1.0288	1.7238	1.0774	1.1488	1.3094	1.2689
Min	.0171	.0343	.0829	.0332	.0686	.0343	.0497
Avg	.2527	.3444	.7164	.4216	.5658	.3936	.3860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 203 / 11 KV JAMATHI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.12	.0857	.12	.0857	.0857	.3601
2	.0857	.0686	.0857	.1029	.0686	.3258	.3601
3	.0857	.0686	.1029	.0857	.0686	.3944	.3429
4	.0857	.1029	.1372	.0857	.0686	.3772	.3429
5	.0857	.1029	.0857	.0857	.0686	.3772	.3772
6	.0857	.1029	.0857	.1029	.0857	.4458	.4287
7	.0857	.1029	.0857	.1372	.0857	.5487	.4287
8	.12	.12	.0857	.0686	.1029	.5487	.4458
9		.12	.1029	.0857	.1029	.4115	.3772
10		.5658		.4458	.0857	.1029	.0686
11		.4287		.5144	.12	.1029	.0514
12	.583	.5316		.5144	.0686	.1029	.0514
13	.5658	.2743		.463	.0686	.0857	.0343
14	.5316	.2915		.2915	.0343	.0857	.0343
15	.583	.4287		.4287	.0686	.0686	.0343
16	.5487	.5144		.463	.0857	.0686	.0514
17	.5487	.5144		.5144			.0686
18		.0514		.0686	.12		.0686
19	.0343	.0686	.0686	.0857	.1029		.0686
20	.12	.0857	.12	.1372	.1029		.0686
21	.1543	.0857	.1029	.1372	.1543	.12	.0686
22	.12	.0857	.1372	.1372	.1543	.1372	.0686
23	.12	.0857	.1372	.1372	.1029	.12	.0686
24		.12	.0857	.1372	.0857	.1029	.3429
Max	.583	.5658	.1372	.5144	.1543	.5487	.4458
Min	.0343	.0514	.0686	.0686	.0343	.0686	.0343
Avg	.2436	.2100	.1006	.2229	.0909	.2306	.1922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 204 / 11 KV NAWASAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7716	.7545	.8059	.7545	.7373	.703
2	.7373	.7545	.7545	.7716	.7373	.7202	.6859
3	.6859	.7545	.7545	.7545	.7373	.7202	.6859
4	.6859	.7545	.7545	.7545	.7202	.703	.6687
5	.6859	.7373	.7545	.7545	.7373	.703	.6687
6	.6859	.703	.7545	.583	.6344	.6001	.583
7	.583	.6173	.6344	.5658	.4801	.5658	.5144
8	.4973	.5658	.5658	.6344	.5658	.5487	.4973
9		.6344	.6001	.583	.5658	.583	.463
10		.6344	.5658	.5316	.5658	.6344	.4973
11		.6344	.5658	.6173	.6687	.6173	.5144
12	.3086	.6687	.583	.5487	.6344	.7373	.583
13	.703	.6687	.703	.6859	.703	.7373	.5658
14	.7716	.703	.6859	.6687	.7202	.6687	.6344
15	.7373	.6859	.6344	.6516	.6516	.703	.6344
16	.7373	.6001	.5658	.6344	.6344	.6516	.6344
17	.6516	.4801	.6516	.5658	.5658	.6173	.6173
18	.6344	.4801	.5487	.5487	.4801	.5316	.4973
19	.7716	.703	.7202	.703	.7202	.6173	.6173
20	.9259	.8402	.8402	.823	.8059	.7716	.7202
21	.8745	.8402	.8573	.8059	.6859	.7888	.7888
22	.9088	.8573	.8573	.823	.8573	.8059	.823
23	.8573	.8402	.7888	.8059	.7888	.7888	.7888
24		.823	.7545	.7716	.7545	.7373	.7202
Max	.9259	.8573	.8573	.823	.8573	.8059	.823
Min	.3086	.4801	.5487	.5316	.4801	.5316	.463
Avg	.7075	.6980	.6937	.6830	.6737	.6787	.6294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024020 / 33KV S/S MANA

Feeder No / Name : 205 / 11 KV RAJURA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3944	.3944	.3944	.3944	.4115	.3944
2	.3944	.3944	.3772	.3944	.3772	.3944	.3944
3	.3086	.3944	.3772	.3944	.3772	.3944	.3772
4	.3086	.3772	.3772	.3944	.3772	.3944	.3601
5	.3086	.3601	.3429	.3944	.3772	.3772	.3601
6	.3086	.2743	.2915	.3086	.3086	.2915	.2915
7	.2401	.2058	.2058	.2058	.1886	.2058	.2058
8	.2229	.2229	.2229	.2058	.1886	.2229	.2058
9		.2229	.2058	.1543	.1886	.2229	.1886
10		.2058	.2572	.2058	.2229	.2401	.2229
11		.2401	.2229	.2401	.2401	.2572	.2401
12	.2915	.3086	.2915	.2915	.2743	.2572	.2572
13	.3944	.3429	.3601	.3429	.3086	.3601	.3429
14	.3944	.3429	.3772	.3429	.3429	.3772	.3429
15	.3944	.3429	.3429	.3601	.3429	.3772	.3429
16	.3601	.2229	.3258	.2915	.3258	.3429	.3258
17	.2915	.2058	.2915		.0686	.1715	.2743
18	.2401	.2058	.2572	.2229	.2229	.1543	.2229
19	.3258	.2743	.3086	.2743	.3258	.2915	.2915
20	.463	.3944	.4115	.3944	.4458	.3944	.4287
21	.463	.4287	.4287	.4287	.4458	.4458	.4287
22	.463	.4287	.4458	.4287	.4458	.463	.4287
23	.4287	.4115	.4287	.4115	.4287	.4287	.4115
24		.4115	.3944	.4115	.3944	.4115	.4115
Max	.463	.4287	.4458	.4287	.4458	.463	.4287
Min	.2229	.2058	.2058	.1543	.0686	.1543	.1886
Avg	.3498	.3172	.3308	.3258	.3172	.3287	.3229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 201 / 11 KV DAHATONDA AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1658	.2155	.3734				
3	.1989	.2155	.3696				
4	.2012	.218	.3696				
5	.1989	.2347	.3734				
6	.2486	.3315	.3734				
7	.3149	.4024	.462				
8	.2984	.3688	.462				
9		.2587	.2486				
10				.5144	.4973	.5144	.3018
11				.5144	.503	.5601	.3018
12				.4801	.407	.5601	.3326
13				.3429	.3353	.4748	.3326
14				.3086	.3018	.3353	.1867
15				.3086	.2543	.4239	.3696
16				.3429	.2883	.5087	.2218
17					.3052	.5087	.2218
Max	.3149	.4024	.462	.5144	.503	.5601	.3696
Min	.1658	.2155	.2486	.3086	.2543	.3353	.1867
Avg	.2324	.2806	.379	.4017	.3615	.4858	.2836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 202 / 11 KV SHIVAN FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3185	.3222	.8573	1.1105	.3696	.2915	.3391
2	.2652	.3222	.8573	1.094	.3696	.3052	.3391
3	.2652	.3222	.8573	1.1065	.3696	.3052	.3391
4	.2683	.3222	.8573	1.1065	.3696	.3052	.3391
5	.2652	.3052	.8573	1.0774	.3696		.3391
6	.2818	.3052	.8573	1.2574	.3696		.3052
7	.2683	.3222	1.1145		.3326		.3052
8	.2683	.407	1.0288		.3326		.3315
9		.462			.3326		.3315
10		.4115			.3239		.407
11		.2614	.8817		.0105		.407
12	.3052	.3734	.9326		.3239		.4435
13	.3052	.2772	.9665				.4435
14	.2713	.2218		1.3717			.3696
15	.3258	.1478	.8817	1.3717	.3353		.3734
16	.3222		1.1191		.3239		.3696
17	.3052	.2772			.4024		.3696
18	.373			.3772	.4578	.2713	.0739
19	.3561			.4435	.4578	.3391	.3772
20	.39	1.1145	1.2346	.3696	.4049	.3391	.4435
21	.373	1.2003	1.2689	.3696	.3239	.3391	.4066
22	.3391		1.3375	.3696	.3563	.3391	.4066
23	.3391		1.2689	.3696	.3391	.373	.3696
24	.2743	.3222	.8573	1.1271	.3696	.3018	.373
Max	.39	1.2003	1.3375	1.3717	.4578	.373	.4435
Min	.2652	.1478	.8573	.3696	.0105	.2713	.0739
Avg	.3086	.4051	1.0020	.8615	.3475	.3191	.3584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 203 / 11 KV UMRI FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8139	.8139		.9431	.8478	.9614
2	.8139	.8745		.9431	.8478	.9614
3	.8048	.8478		.9431	.8478	.9614
4	.8048	.823		.9431	.8478	.9614
5	.8139	.823		.9431	.9335	.9614
6	.9496	.8573		1.0288	.9665	.9945
7	.9496	.9835		1.2003	1.0513	.9945
8	1.073	1.2209		1.1145	1.0174	.9945
9		1.046		1.2003	1.153	1.0174
10		1.0288		1.2887	1.2003	1.1401
11		.703		1.0852	1.307	1.1934
12	1.0631	.703		1.2039	1.307	1.1145
13	.9602	.6859		1.0174	.9389	1.1145
14	.9088			1.0059		.8573
15	1.0513			.9496		.8573
16	1.0802			.9614		1.0288
17	1.166			.9945	1.073	1.0288
18	1.1022		1.286	1.153	1.1401	1.0288
19	1.0974		1.3717	1.1191	1.1401	1.166
20	1.0631		1.2003	1.1191	1.073	1.1145
21	.9602		1.0288	1.0513	1.0059	1.0288
22	.9088		1.0288	1.0174	1.0174	.9945
23	.8059		.9431	.9156	.9835	.9602
24	.823	.7888		.9431	.9619	.9614
Max	1.166	1.2209	1.3717	1.2887	1.307	1.1934
Min	.8048	.6859	.9431	.9156	.8478	.8573
Avg	.9530	.8714	1.1431	1.0452	1.0315	1.0165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 204 / 11 KV KHANDALA W/W EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.024	.1494	.1494	.0747	.1372	.0663
2	.12	.0236	.1494	.1494	.0754	.1372	.0663
3	.12	.0221	.1478	.1494	.0754	.1372	.0663
4	.12	.0349	.1478	.1494	.0754	.1357	.0995
5	.12	.0349	.1494	.1494	.0754	.1017	.116
6	.12	.0503	.1494	.0747	.0754	.0509	.116
7	.1372	.132	.0747	.1307	.0754	.1357	.116
8	.1372	.1698	.0747	.1307	.0754	.1372	.116
9		.1494	.1509	.1307	.0377	.1357	.116
10		.1307	.1509	.056	.1357	.1372	.0995
11		.056	.1509	.1494	.1341	.1326	.1341
12	.061	.1494	.1509	.1494	.1357	.0497	.1494
13	.0781	.168	.1132	.0747	.1086	.1326	.1478
14	.1029	.1494	.0526	.168	.0857		.0747
15	.1698	.1494	.1698	.168	.0625		.112
16	.1509	.1494	.1698	.0747	.0648		
17	.1698	.0739	.0488	.0747	.1494	.0663	.0747
18	.0587		.0394	.0747	.0648	.0663	.056
19	.0594	.0747	.0518	.1307	.1187	.0663	.0747
20	.0625	.0747	.0518	.0747	.1134	.0663	.0747
21	.0972	.0747	.0511	.0739	.1174	.0663	.0747
22	.1698	.0747	.0526	.0747	.0526	.0995	.0747
23	.1698	.1494	.1509	.0747	.1494	.1326	.0747
24	.12	.132	.1494	.1326	.0747	.1357	.0663
Max	.1698	.1698	.1698	.168	.1494	.1372	.1494
Min	.0587	.0221	.0394	.056	.0377	.0497	.056
Avg	.1173	.0977	.1145	.1152	.0920	.1076	.0942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 205 / 11 KV MURAMBA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9097	.8001	.8763	.8001	.8642	.7163
2	.5933	.8962	.8001	.8763	.8001	.8642	.7163
3	.754	.82	.7239	.855	.7468	.8687	.7163
4	.7457	.8154	.7239	.8596	.7506	.8642	.7163
5	.6995	.8154	.8001	.855	.7506	.8642	.7163
6	.381	.743	.7239	.381	.7506	.7201	.6828
7	.5731	.6272	.7239	.6197	.582	.6134	.5731
8	.5449	.743	.7239	.57	.6744	.6439	.5395
9	.2286	.4319	.7034	.619	.6782	.6439	.6066
10		.6929	.6306	.6374	.6306	.61	.57
11		.6374	.6306	.6374	.6306	.57	.4969
12	.3353	.6782	.6306	.6374	.6487	.5369	.6005
13	.2572	.6782	.6889	.7506	.7068	.6032	.6005
14	.5001	.7506	.7792	.7876	.6523	.6032	.6744
15	.9876	.7506	.7249	.7876	.6706	.57	.7876
16	.9459	.7506	.7392	.7506	.6487	.5761	.7136
17	.9407	.7506	.7611	.6782	.6487	.57	.6374
18	.8554		.7792	.6374	.634	.6066	.6409
19	.8516	.8268	.8516	.843	.8017	.381	.8478
20	1.0584	1.0563	1.0822	1.0479	1.0403	1.0029	.9373
21	1.0765	1.0479	1.0584	1.0479	1.0456	.9645	.8859
22	1.0584	1.0479	1.0765	1.0136	1.0403	.8596	.9377
23	1.0403	.9192	1.0403	.9955	.964	.8596	.8859
24	.6287	.9586	.9192	.9047	.9192	.8811	.7498
Max	1.0765	1.0563	1.0822	1.0479	1.0456	1.0029	.9377
Min	.2286	.4319	.6306	.381	.582	.381	.4969
Avg	.7170	.7977	.7965	.7779	.7590	.7142	.7062

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 206 / 11 KV BIDGAON GF

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1886	.1867	.1677	.1867	.1696	.0829
2	.1677	.1698	.1867	.1677	.1848	.1696	.0829
3	.1658	.1698	.1867	.1677	.1867	.1696	.0829
4	.1696	.1698	.1867	.1677	.1867	.1696	.0829
5	.1509	.1698	.1867	.1844	.1848	.1696	.0829
6	.1326	.1698	.1494	.1677	.1294	.1357	.0663
7	.0995	.1132	.1307	.116	.1307	.1017	.0332
8	.0934	.0566	.1294	.1006	.112	.1187	.0663
9		.0187	.0943	.112	.112	.0848	.0829
10		.0187	.0943	.0934	.1132	.0857	.0503
11		.1494	.1132	.112	.0943	.0663	.0663
12	.0943	.0924	.0943	.112	.0943	.0995	.0934
13	.1132	.1307	.1132	.112	.112	.1006	.0934
14	.132	.1307	.132	.1307	.1509	.0995	.112
15	.132	.1494	.1132	.1307	.0754	.0995	.112
16	.132	.1307	.132	.1307	.132	.0995	.112
17	.132	.112	.132	.1307	.1509	.1006	.112
18	.1509		.1132	.1307	.132	.0663	.112
19	.1886	.2218	.1698	.1494	.1886		.1543
20	.2075	.2218	.1698	.1715	.1886	.0829	.168
21	.2075	.2241	.1886	.1867	.1886	.0671	.1867
22	.2075	.2241	.2075	.1848	.1886	.0663	.1867
23	.2075	.1867	.1886	.1867	.2075	.0838	.1494
24	.1867	.1886	.1848	.1658	.1867	.1696	.0829
Max	.2075	.2241	.2075	.1867	.2075	.1696	.1867
Min	.0934	.0187	.0943	.0934	.0754	.0663	.0332
Avg	.1543	.1481	.1493	.1450	.1507	.1120	.1023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024026 / 33 KV MORAMBA

Feeder No / Name : 207 / 11 KV DHANORA P GF

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6371	.6979	.5144	.6874	.6001	.7922	.6859
2	.6299	.679	.5144	.663	.6001	.7733	.6859
3	.6371	.679	.5144	.663	.6001	.7733	.6859
4	.7095	.679	.5144	.6706	.6001	.7733	.6859
5	.6908	.6602	.5144	.5801	.6001	.7545	.6859
6	.6161	.547	.5144		.5144	.6224	.5658
7	.4854	.5093	.5144	.4694	.4287	.5281	.1389
8	.2614	.4527	.4287	.4527	.4287	.5093	.4458
9		.4115	.4715	.463	.4287	.547	.4458
10		.3772	.4715	.4287	.4338	.463	.3944
11		.3944	.3584	.4458	.4527		.4458
12	.6224	.4115	.4527	.463	.5281		.4801
13	.5847	.5144	.5658	.5144	.5281	.1886	.4801
14	.6036	.4801	.6036	.5144	.5658		.5487
15	.6036	.5144	.5847	.5144	.5658		.5487
16	.547	.5144	.547	.5144	.5658		.5144
17	.4527	.3944	.4715	.4287	.4715	.5144	.4287
18	.4904		.4338	.4287	.3961	.4973	.4287
19	.6979	.6001	.679	.6859	.6224	.7202	.6859
20	.811	.6859	.7356	.7716	.7356	.8573	.7545
21	.811	.6859	.7545	.7716	.8299	.8059	.7545
22	.7922	.6859	.8488	.7716	.9054	.7545	.7545
23	.7356	.6859	.8299	.6859	.8488	.7202	.7202
24	.7282	.7167	.6859	.6962	.6859	.7922	.703
Max	.811	.7167	.8488	.7716	.9054	.8573	.7545
Min	.2614	.3772	.3584	.4287	.3961	.1886	.1389
Avg	.6261	.5642	.5635	.5776	.5807	.6519	.5695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 201 / 11 KV SIRSO AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0312	.0602	.0594				
3	.0625	.0753	.0594				
4	.0625	.0753	.0594				
5	.0781	.0602	.0743				
6	.0781	.0753	.104				
7	.0937	.1656	.1486				
8	.1562	.1806	.1505				
9	.1286	.1355	.1783				
10				.1656	.1656	.1524	.2286
11				.1656	.1656	.1656	.208
12				.1635	.1677	.1806	.2229
13				.104	.1524	.1505	.1635
14				.1054	.1524	.1355	.208
15				.1219	.1524	.1505	.1882
16				.125	.1656	.1656	.1907
17				.1204	.1656	.1981	.2201
Max	.1562	.1806	.1783	.1656	.1677	.1981	.2286
Min	.0312	.0602	.0594	.104	.1524	.1355	.1635
Avg	.0864	.1035	.1042	.1339	.1609	.1624	.2038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 202 / 11 KV HIRPUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.3982	.462	.3258	.3982	.462	.4435
2	.4344	.362	.4435	.3258	.3658	.4435	.4435
3	.4344	.3439	.4066	.3258	.3292	.4435	.3696
4	.4344	.3258	.4066	.3258	.2926	.4251	.3696
5	.4344	.3258	.3696	.3258	.3292	.4251	.3696
6	.3439	.3077	.3511	.3258	.3292	.3292	.2957
7	.2534	.3077	.2378	.2715	.2378	.2353	.2195
8	.2172	.1991	.181	.5014	.2012	.2865	.2328
9	.2481	7.4932	.1991	.1991	.2378	.2353	.2149
10	.2328	.2353	.1991	.2353	.2686	.2353	
11	.2481	.2353	.2172	.2353	.2507	.2715	.2534
12	.2865	.2896	.2534	.2926	.3045	.2896	.2686
13	.3366	.3258	.2534	.3439	.3258	.3258	.3012
14	.3761	.3439	.2715	.3658	.3258	.3475	.3292
15	.3582	.362	.3439	.3658	.3658	.3658	.2926
16	.3403	.362	.3258	.3439	.3439	.3475	.2743
17	.2896	.3258	.2715	.2865	.2896	.2715	.2534
18	.2534	.2353	.2353	.2353	.2353	.2172	.2561
19	.362	.2896	.3258	.2353	.3045	.2896	.2896
20		.4024	.4344	.4344	.439	.3841	.362
21	.4163	.4251	.4344	.4344	.4207	.4251	.3982
22	.4525	.4805	.4344	.4344	.462	.462	.4344
23	.4706	.4805	.4706	.4525	.4805	.462	.4344
24	.4525	.4525	.462	.4525	.4525	.462	.4435
Max	.4706	7.4932	.4706	.5014	.4805	.462	.4435
Min	.2172	.1991	.181	.1991	.2012	.2172	.2149
Avg	.3526	.6379	.3329	.3364	.3329	.3518	.3282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024036 / 33 KV SIRSO

Feeder No / Name : 203 / 11 KV PUNDLIK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9153	1.0852	.9494	1.0086	.9183	.7857	1.0181
2	.8997	.921	.9144	.9579	.8539	.7708	.9454
3	.876	.8333	.8991	.9377	.8385	.7655	.9176
4	.8638	.8265	.8718	.9183	.8108	.7186	.8334
5	.8517	.7802	.8703	.9084	1.3618	.7129	.8212
6	.8553	.7725	.8593	.7714	.7849	.6464	.7832
7	1.0071	.9654	1.0179	.9215	.9719	.7166	.7783
8	1.0109	.9478	1.0898	1.0285	1.0113	.7701	.8284
9	1.2463	1.1919	1.233	1.1768	1.0892	1.0522	.943
10	1.3759	1.2953	1.278	1.2801	1.1551	1.2953	.5251
11	1.4502	1.3394	1.2953	1.3784	1.1914	1.3287	1.075
12	1.4367	1.4407	.6984	1.3796	1.1658	1.3199	1.0464
13	1.52	1.4744	1.4049	1.3796	1.1959	1.3142	1.0315
14	1.3904	1.3649	1.4206	1.2754	1.0307	1.4038	1.0936
15	1.4005	1.2382	1.2327	1.2319	.8047	1.3855	1.0959
16	1.3881	1.2114	1.2152	1.2335	.6798	1.4175	1.1
17	1.3586	1.2081	1.1944	1.2079	.6039	1.2766	1.0225
18	1.1863	1.1641	1.0997	1.0803	.5744	1.0136	.9701
19	1.2612	1.057	1.0334	1.631	.6153	1.0435	.9795
20	.639	1.0955	1.0464	1.0927	.6641	.9907	1.0154
21	1.1618	1.0105	1.0694	1.0098	.748	.9455	.9446
22	1.1097	1.0529	1.0309	1.0253	.7954	1.0247	1.002
23	1.1408	1.0915	1.0654	.9993	.8368	1.0883	1.0424
24	1.0507	1.1149	1.0292	1.0271	.8794	.9467	1.0431
Max	1.52	1.4744	1.4206	1.631	1.3618	1.4175	1.1
Min	.639	.7725	.6984	.7714	.5744	.6464	.5251
Avg	1.1415	1.1034	1.0758	1.1192	.8992	1.0306	.9523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 201 / 11 KV KHADAKA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4656	1.0749	1.0791	.9054	1.0387	1.0166	.4458
2	.4656	1.0056	1.0317	.8383	1.0029	1.0166	.4578
3	.4656	1.0056	1.0642	.8215	1.0029	.9816	.4239
4	.4656	.9431	.985	.823	.9671	.9259	.407
5	.4656	.8916	.8939	.823	.9313	.8916	.4024
6	.4031	.8916	.8764	.7969	.8413	.7716	.4191
7	.3506	.6836	.7537	.6783	.703	.7202	.407
8	.3688	.7202	.6859	.6706	.6952	.6687	.4578
9		.7716	.7042	.6962	.6952	.6299	.4024
10		.703	.7202	.7127	.6952	.7042	.4807
11		1.6476	.7377	.6203	.7461	.7209	.4752
12	.4359	1.6476	.7461	.6539	.7888	.7716	.4588
13	.4973	.4287	.7888	.7377	.3601	.8063	.4534
14		.4115	.8417	.7537	.463	.8413	
15	.9955	.4973	.8775	.7865	1.0117	.8764	
16	.9593	.463	.9145	.8356	.9156		.421
17	.7282		.8413	.8059	.8383	.3258	.4359
18	.8785		.8779	.7011	.779	.3601	.4001
19	.8215	.905	.8764	.8238	.9116	.39	.4191
20	.9945	.985	.9088	.9492	.9835	.5087	.6201
21	.9602	1.0974	.9431	.985	1.0288	.5316	.5847
22	1.0631	1.1706	1.0974	1.0924	1.0517	.4801	.5258
23	1.1096	1.1222	1.0852	1.0924	1.0517	.5144	.5201
24	.5014	1.1096	1.1041	.9724	1.1222	1.0341	.4458
Max	1.1096	1.6476	1.1041	1.0924	1.1222	1.0341	.6201
Min	.3506	.4115	.6859	.6203	.3601	.3258	.4001
Avg	.6698	.9171	.8931	.8157	.8594	.7169	.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 202 / 11KV SONORI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4161	.4801
2	.4572			.4458	.4161	.5182
3	.4572			.4458	.4287	.5506
4	.4572			.5053	.4287	.5898
5	.503			.5792	.5268	.5571
6	.578			.7316	.6472	.6226
7	.7343			.8436	.7407	.7865
8	.703			.6321	.7499	.7209
9				.6859	.6455	.6154
10		.7701				
11		.9175				
12	.4548	.8192	.5792			
13	.6859	.7373	.703			
14		.6882	.5944			
15	.5937		.6874			
16	.6249		.5487			
17	.5937	.679	.6405			
18		.6401				
19		.503				
24						.4481
Max	.7343	.9175	.703	.8436	.7499	.7865
Min	.4548	.503	.5487	.4458	.4161	.4481
Avg	.5702	.7193	.6255	.6087	.5555	.5889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 024044 / 33/11 KV Sonori S/S

Feeder No / Name : 203 / 11 KV KURANKHED AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.12	.1257	.2241			
3	.1509	.1486	.2241			
4	.1696	.1886	.2401			
5	.1823	.1915	.2458			
6	.1989	.2425	.2785			
7	.2915	.3525	.4096			
8	.3401	.3616	.3605			
9	.2915	.3334	.3647			
10			.2968	.4062	.3948	.4938
11			.3361	.3749	.3666	.4218
12			.2591	.2812	.3155	.3749
13			.2753	.2968	.2934	.3281
14			.2915	.2343	.2801	.3077
15			.2591	.2031	.2462	.3077
16			.2591	.2812	.298	.3401
17			.3334	.3906	.3628	.3384
Max	.3401	.3616	.4096	.4062	.3948	.4938
Min	.12	.1257	.2241	.2031	.2462	.3077
Avg	.2181	.2431	.2911	.3085	.3197	.3641

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 201 / 11KV NAGOLI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4501	2.4501	3.0084	2.7587	2.6406	2.6604	2.7537
2	2.5663	2.6025	2.8559	2.6749	2.6063	2.6688	2.697
3	2.5301	2.5663	2.7617	2.6604	2.4196	2.6265	2.6253
4	2.3415	2.5301	2.6886	2.5926	2.3594	2.6063	2.6253
5	1.2193	2.5663	2.652	2.5586	2.3045	2.572	2.4371
6	2.3053	2.6749	2.6154	2.4782	2.2706	2.2824	2.3655
7	1.2193	2.6886	2.439	1.2193	2.0614	2.0485	2.1414
8	2.2375	2.6253	2.4013	2.3045	2.0504	2.0698	2.0805
9	1.0669	2.4062	2.2801	2.3167	2.0957	2.1277	2.0614
10		2.0332	.9511	1.8214	2.1071	2.1277	2.0119
11		.7621	.0366	1.7375	2.13	1.7375	1.7718
12		1.9242	.0366	1.7718	1.2715	2.463	1.829
13	2.5225	1.7718	.0366	1.7718	2.4112	2.4196	1.829
14	1.2193	2.1521	2.4325	2.0957	2.4329	2.1795	2.1643
15	2.3053	2.1643	2.2435	2.0957	2.5087	2.0614	2.1277
16	2.3777	1.0669	2.3167	2.13	2.3723	2.1277	2.1643
17	2.1529	1.0669	2.3167	2.0271	2.3655	2.1091	2.0805
18	2.2329	.9145	1.2193	1.829	2.1773	2.2824	1.8099
19	2.4996	.9145	1.0669	1.7718	2.2847	2.5804	2.3339
20	2.4996	1.3717	1.3717	2.2672	2.7111	2.8044	2.697
21	2.463	1.3717	1.3717	2.4196	2.6749	2.7183	2.6387
22	2.5362	2.9146	2.7892	2.7892	1.3717	1.3717	2.6387
23	2.6829	3.048	2.9771	2.9417	2.9771	2.9771	2.9569
24	2.612	2.7999	3.0285	2.8044	2.8708	2.9062	2.9062
Max	2.6829	3.048	3.0285	2.9417	2.9771	2.9771	2.9569
Min	1.0669	.7621	.0366	1.2193	1.2715	1.3717	1.7718
Avg	2.1924	2.0578	1.9957	2.2432	2.3115	2.3554	2.3228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 203 / 11 KV TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5077	3.3989	3.2921	3.0712	3.0251	3.0285	4.1838
2	2.2596	1.749	3.2064	3.0247	3.0144	2.9454	3.9323
3	4.2276	3.0811	3.0731	2.9107	2.7991	2.6795	3.8751
4	2.0957	1.5089	2.9417	2.8311	2.6806	2.7709	3.7665
5	3.8847	2.8006	2.8159	2.6723	2.521	2.6196	3.6027
6	1.9814	1.4861	2.7031	2.551	2.5442	2.54	1.8252
7	3.3326	2.6169	2.4943	1.2917	2.4166	2.4203	2.9988
8	3.0712	2.3358	2.3129	2.1414	2.1723	2.247	2.8121
9	1.547	2.1758	2.319	2.2733	2.1041	1.1584	2.7344
10	1.608	1.1431	2.3861	2.3959	2.37	2.2001	2.694
11			2.5873	2.5141	2.5015	2.5926	2.9226
12		1.1869	2.7503	2.6444	2.4844	2.9203	3.0925
13	2.3967	3.272	2.9424	2.851	2.6833	2.9492	3.3036
14	2.4387	4.0299	3.0872	2.9797	3.1101	3.1314	3.5407
15	1.909	4.2531	3.1885	3.1215	3.1265	3.1802	3.6054
16	1.8252	2.2862	3.1802	3.1207	3.0856	3.7022	4.0264
17	3.3714	2.2634	3.0635	3.1474	3.0446	3.677	3.8561
18	3.0475	2.111	1.6232	2.902	2.9302	3.6827	2.0157
19	2.8563	1.4899	1.4937	2.7938	2.9398	3.6522	1.8633
20	3.2632	1.5889	1.5813	2.9797	3.094	3.8351	3.7437
21	3.235	1.6423	1.6309	2.9889	3.0789	4.0314	3.8256
22	3.2838	3.0098	3.0342	3.0075	1.5775	2.0462	3.9179
23	3.3383	3.0723	3.1204	3.1089	3.0784	4.0775	4.0078
24	3.9837	3.3029	3.2637	3.158	3.0849	3.6945	4.1183
Max	4.5077	4.2531	3.2921	3.158	3.1265	4.0775	4.1838
Min	1.547	1.1431	1.4937	1.2917	1.5775	1.1584	1.8252
Avg	2.8847	2.4263	2.6705	2.7700	2.7278	2.9909	3.3444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 204 / 11KV Goyanaka fdr

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1788	2.4493	1.2384	2.2519	2.1796	2.2821	2.0919
2	1.0936	1.2384	2.3301	2.1038	2.1452	2.2595	1.9601
3	2.0028	2.2329	2.2344	2.0424	2.0916	2.0309	1.8937
4	1.0098	1.086	2.127	2.0089	2.034	1.928	1.8214
5	1.861	1.9304	1.086	1.0364	1.933	1.848	1.6385
6	1.0021	.945	1.9181	1.848	1.8195	1.6915	1.4982
7	1.7269	1.7558	.9602	.9221	1.6286	1.6415	.7849
8	1.6179	1.5775	1.5615	1.5623	1.5055	1.6758	1.4213
9	.8345	1.4442	1.6865	1.499	1.5086	1.5295	1.3802
10	.7849	.7506	1.5798	1.4914	1.501	1.4975	1.4327
11			1.5257	1.5089	1.4625	1.6682	1.4723
12		.78	.8345	1.6065	1.6107	1.6408	1.5318
13	1.3336	2.2257	1.4655	1.7742	1.8175	1.8557	1.624
14	1.185	2.199	1.9304	1.8762	1.9647	1.9166	1.8465
15	1.1736	2.066	2.0416	2.0051	2.1106	2.1483	2.0104
16	1.2193	1.105	2.0309	2.0759	2.069	2.1807	2.2214
17	2.1765	1.1164	1.9776	1.9639	2.1281	2.0348	2.1053
18	1.9562	1.0326	1.0593	1.8184	1.8995	1.9616	1.0707
19	1.9342	.945	.9793	1.8015	1.7299	1.8404	.9183
20	1.9723	.9793	.9526	1.8244	1.8405	1.7726	1.8347
21	2.0546	.9945	.9259	1.7444	1.9033	1.7962	1.7928
22	2.1582	1.967	2.0603	1.8842	1.0402	.9717	1.877
23	2.3533	2.3038	2.3038	2.2378	2.3011	2.087	1.9589
24	2.3205	2.3838	2.4078	2.2557	2.3407	2.1959	2.0286
Max	2.3533	2.4493	2.4078	2.2557	2.3407	2.2821	2.2214
Min	.7849	.7506	.8345	.9221	1.0402	.9717	.7849
Avg	1.6341	1.5438	1.6341	1.7976	1.8569	1.8523	1.6757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 205 / 11 KV MIDC IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0343	.0343	.0339	
2				.0339	.0343	.0339	.0362
3				.0347	.0339	.0343	.0362
4				.0347	.0339	.0339	.0362
5				.0347	.0339	.0339	.0362
6				.0351		.0335	.0362
7					.0343	.0339	.0362
8				.0343	.0343	.0354	
9		.0347	.0381	.0381	.0343	.0381	.0381
10			.0381	.0381	.0339	.0381	.0381
11			.0381	.0381	.0343	.0381	.0381
12			.0381	.0381	.0343	.0381	.0381
13		.0343	.0381	.0381	.0343	.0381	.0381
14		.0339	.0381	.0381	.0343	.0381	.0381
15		.0347	.0381	.0381	.0343	.0381	.0381
16			.0381	.0381	.0343	.0381	.0381
17	.0381		.0343	.0381		.0366	.0362
18	.0381			.0381			
19	.0381			.0381		.0366	.0354
20	.0381			.0381			.0362
21	.0381			.0381		.0366	.0354
22	.0366	.0339		.0354			.0354
23	.0354			.0354	.0354	.0354	.0354
24	.0354	.0354				.0354	.0354
Max	.0381	.0354	.0381	.0381	.0354	.0381	.0381
Min	.0354	.0339	.0343	.0339	.0339	.0335	.0354
Avg	.0372	.0345	.0377	.0367	.0343	.0361	.0367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 206 / 11 KV Water /W EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2145	.224	.224	.2149	.0728	.1398	.2123
2	.2229	.1143	.2145	.216	.072	.2255	.2123
3	.1143	.224	.224	.216	.072	.216	.2134
4	.224	.0667	.2145	.216	.0728	.2123	.2123
5	.1143	.074	.2145	.2183	.0732	.2088	.2123
6	.2145	.0191	.2145	.2172	.072	.21	.2134
7	.1143	.0747	.2145	.1143	.072	.2077	.2111
8	.224	.0739	.2123	.1482	.0724	.1943	.1406
9	.1143	.0724	.2145	.0857	.0728	.1715	.0747
10		.072	.1962	.0762	.0732	.1715	.0762
11		.0724	.1867	.0762	.0728	.1715	.0762
12		.072	.1867	.1524	.1421	.1143	.0762
13	.0667	.072	.1962	.2191	.2195	.0953	.1143
14	.1048	.141	.1962	.2191	.1395	.0953	.2
15	.0381	.2065	.1509	.2286	.2088	.0857	.1619
16	.0667	.1143	.0857	.1524	.216	.0762	.218
17	.2145	.1143	.1905	.0842	.1509	.0747	.2134
18	.2145	.1048	.0953	.0842	.0938	.0747	.1048
19	.1223	.1048	.0953	.0842	.0842	.0747	.0762
20	.0842	.0381	.0381	.0747	.0747	.0747	.0743
21	.0842	.0381	.0381	.0747	.0747	.0747	.0743
22	.0762	.072	.0735	.0735	.0286	.0381	.0739
23	.0735	.0735	.0735	1.4556	.0735	.0735	.0735
24	.1825	.1444	.2016	.1456	.0735	.0735	.0735
Max	.224	.224	.224	1.4556	.2195	.2255	.218
Min	.0381	.0191	.0381	.0735	.0286	.0381	.0735
Avg	.1374	.0993	.1647	.2020	.0991	.1314	.1412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 207 / 11 KV ANBHORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.2706	2.2062		2.3015
2				2.1719	2.1719		1.1431
3				2.1605	2.0504		1.1431
4				2.0843	2.0271		2.1529
5				2.0504	1.9242		2.1818
6				1.9825	1.8899		1.1431
7		.0762		.9907	1.6183		1.8595
8		.7621		1.5585	1.6613		1.6995
9		1.1431		1.6271	1.5166		1.8061
10				1.4823	1.4743		1.6271
11				1.5585	1.5509		1.9052
12				1.8061	1.6183		2.1643
13			.1524	2.018	1.7707		2.2405
14			.8383	1.9814	1.7795		2.2039
15	1.9243		1.1584	1.7924	2.0614	.7438	2.2405
16	1.2193		1.5242	2.1643	.4572	1.0059	.381
17	2.351	.381	.9907	2.069		.1524	
18	2.069		1.9166	1.9784		.7704	
19	2.0957		1.0669	2.0149		1.688	
20	2.5301		1.2955	2.351		2.7512	
21	1.3717		1.1431	2.4272		2.715	
22			2.4649	2.5358		1.3717	
23	.1524		2.394	2.5003		2.4649	
24			1.2193	2.3297	1.134	1.2193	1.1694
Max	2.5301	1.1431	2.4649	2.5358	2.2062	2.7512	2.3015
Min	.1524	.0762	.1524	.9907	.4572	.1524	.381
Avg	1.7142	.5906	1.3470	1.9961	1.7007	1.4883	1.7272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 208 / 11KV J.K. GINING

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8777	.743	3.0445	.7582	.381	2.4485	.381
2	1.5242	.381	3.0084	.754	.7201	2.3807	.7034
3	2.715	.7468	2.8598	.7239	.7201	2.3563	.6306
4	1.3717	.381	2.7874	.7239	.6862	2.3704	.5944
5	2.4691	.7102	2.7512	.6477	.6862	2.2824	.5555
6	1.448	.3048	2.652	.6931	.7201	2.2009	.3048
7	2.21	.82	2.3563	.3048	.6904	2.0031	.5555
8	.8383	.663	2.2938	.5106	.6066	1.8503	.5913
9	.2286	.5422	2.018	.4115	.4321	1.848	.4344
10		1.8519	1.9784	.4115	.4321	1.9784	.2286
11		2.6826	2.0546	.4115	.4321	2.2009	
12	.381	2.6826	2.2039	.4115	.4321	2.2824	.2621
13	.6097	2.9043	1.2193	.3353	.466	2.207	.4847
14	.6097	2.7367	.1463	.4115	.4687	1.2193	.5212
15	.381	2.7855	.634	.4115	.4687	.4847	.4847
16	.381	1.2193	.7102	.4115	2.1689	.4481	2.2771
17	.7102	.7621	.3048	.4115	2.1567	.4096	2.3777
18	.6736	1.3717		.2987	2.0843	.4096	1.2193
19	.5791	1.448		.3315	2.3377	.4481	1.2193
20	.6896	1.5242	.381	.4115	1.5242	.5243	2.9683
21	.6134	1.0669	.3048	.4847	1.5242	.4847	3.0846
22	.7925	3.3467	.6237	.7354	2.8998	.3048	3.0179
23	.7708	3.3475	.8062	.7354	2.7999	.7354	3.0887
24	1.7276	1.9902	1.9048	.775	1.7261	1.5858	1.8024
Max	2.8777	3.3475	3.0445	.775	2.8998	2.4485	3.0887
Min	.2286	.3048	.1463	.2987	.381	.3048	.2286
Avg	1.1183	1.5422	1.6838	.5215	1.1485	1.4777	1.2082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 403 / 33 KV O/G -I (To Mana S/S) NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3575	2.3348	2.2857	2.2634	2.1605	2.2085	2.5789
2			2.2325	2.1605	2.0062	2.0348	2.4977
3	1.9004	2.2262	2.1794	2.1365	2.0576	2.1033	2.4714
4			2.073	2.1605	2.3137	2.0348	2.364
5	2.1399	2.3891	2.0199	2.572	2.3926	2.2382	2.2805
6			1.9667	2.7778	2.1605	2.2885	2.3348
7	2.4143	2.9081	1.5947		2.0856	2.0348	2.0416
8	2.2497	2.7109	1.6118	2.7263	2.1091	2.0953	1.9342
9		2.7469	1.701	2.7984	2.0348	2.3045	1.9204
10		2.2382	2.4143	2.1399	2.6852	2.3045	3.0178
11		2.2382	1.5912	2.2497	2.7469	3.5117	2.963
12		2.3148	3.4019	2.4691	2.7978	3.2922	1.6461
13	1.8461	2.3148	3.5117	2.4143	2.0576	3.3471	1.6461
14	2.7149	1.9033	3.8409	2.4143	2.7263	3.2922	3.1276
15	2.8778		3.9506	2.524	2.7263	3.2373	3.0727
16			3.8409	2.3594	2.8487	1.9204	3.1824
17	2.4977		3.3808	2.4143	2.552	2.9864	3.0624
18	1.6461			1.6461	1.5203	1.4661	
19	2.2497			1.9204	.9877	1.9547	1.6118
20	2.5789			2.4691		2.2805	2.2565
21	2.524			2.4691	2.4434	2.3348	2.2262
22		2.3908	2.4451	2.9767			2.2805
23	2.4451	2.4983	2.392	2.392	2.2857	2.392	2.3348
24		2.392	2.3388	2.2382	2.2857	2.2325	2.5514
Max	2.8778	2.9081	3.9506	2.9767	2.8487	3.5117	3.1824
Min	1.3575	1.9033	1.5912	1.6461	.9877	1.4661	1.6118
Avg	2.2459	2.4005	2.5386	2.3779	2.2720	2.4302	2.4088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

MURTIZAPUR SUB-DN[283] BU 2836

Substation No/ Name :- 025007 / 33 KV MURTIZAPUR

Feeder No / Name : 404 / 33 KV O/G -II (To Kherda S/S) Feeder KV- 33 / OUTGOING NON SHEDDABLE WATER SUPPLY AND UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.0065	8.0264	5.7939		8.7494	9.8766	9.1335
2			5.7488			9.7805	8.9186
3	5.7407	7.8138	5.5813		8.2305	8.7449	8.9186
4			6.1128		8.4877	8.6477	8.5963
5	5.5813	8.059	6.7507		9.2078	8.546	8.7037
6			9.7782		9.5633		9.1873
7	6.6444	9.5096	9.241		10.1738	9.3622	9.828
8	9.4616	10.8968	9.1427	4.6799	10.072	9.5679	10.4253
9			2.6337	2.1948		3.9506	3.9506
10		9.9703	.8779	2.3045	9.6708	3.4019	3.9506
11		8.5905	2.8532	2.4143	9.6708	3.0727	3.9506
12		8.139	2.8532	2.4143	10.3264	3.7311	3.9506
13	8.6643	7.9733	2.6337	2.4143	7.376	3.5117	3.2922
14	8.9832	5.8128	2.3045	4.3896	8.902	1.9753	.439
15	11.2157	9.928	3.7311	4.3896	8.902	2.1948	1.9753
16			4.1701	2.4143	6.0185	1.0974	3.7311
17	4.3896		6.0185	2.4143	10.7373	7.7075	8.7037
18	3.5117			3.2922	8.6111	6.6444	5.7407
19	3.7311			3.7311	9.7805	7.9733	7.7103
20	3.9506			3.9506	9.3553	8.558	8.4162
21	3.7311			3.7311	9.8337	8.1327	7.9515
22		5.6973		8.3453			7.8189
23	9.4084	6.1128	9.8868	9.6211	9.7805	8.1859	7.548
24	6.8039	8.9832	5.8471		9.4616	10.3121	9.0895
Max	11.2157	10.8968	9.8868	9.6211	10.7373	10.3121	10.4253
Min	3.5117	5.6973	.8779	2.1948	6.0185	1.0974	.439
Avg	6.5216	8.2509	5.3663	3.9188	9.1862	6.5898	6.7471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 201 / 11 KV PATUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2443	1.1462	2.1948	2.1357	2.1216	2.0485	2.0271
2	2.1582	1.1222	2.1216	2.0995	2.0698	1.9387	1.9909
3	2.0485	1.7909	2.0485	2.0633	2.0119	1.9387	2.0119
4	2.0485	1.7909	2.0271	2.0271	1.9959	1.9387	1.8823
5	1.9959	1.7909	2.0271	2.0271	1.9959	1.9387	1.8656
6	1.9022	1.7193	2.0271	1.9909	1.9022	1.9753	1.7741
7	1.8099	1.576	1.9753	1.8823	1.7737	1.829	1.7558
8	1.6827	1.6289	1.7924	1.7193	1.829	1.9022	1.7193
9	1.6651		1.9022	1.701	1.9022	1.8461	1.7909
10	1.7193			1.7528	1.9547	1.8099	1.8267
11	1.5927	2.2443		1.6827	1.7193	1.8625	1.6476
12	1.7551	2.0553		1.6827	1.7193	1.7909	1.7364
13	1.7909	1.9909	2.1849	1.6827	1.7551	1.8461	1.6301
14	1.8625	1.9547	2.0332	1.7878	1.7909	1.8983	1.6476
15	1.8461	1.8823	1.9845	1.8427	1.8625	1.9342	1.7364
16	1.8823	1.8823	2.0199	1.8427	1.8625	1.8823	1.7909
17	1.8983	2.0633	1.8073	1.7718	1.7909	1.7909	1.6301
18	1.7924	2.0774	1.8427	1.7528	1.7551	1.7177	1.6655
19		2.2443	2.4356	2.1719	1.9547	2.0058	2.0553
20	2.3777	2.3411	2.4615	2.2443	2.268	2.1582	2.1948
21	2.3777	2.3411	2.2923	2.1948	2.3045	2.1948	2.268
22	2.4508	2.3411	2.3891	2.268	2.3777	2.1719	2.2314
23	2.4143	2.3777	2.3891	2.268	2.3411	2.2314	2.2314
24	2.2443		2.3045	2.2443	2.1216	2.2314	2.1216
Max	2.4508	2.3777	2.4615	2.268	2.3777	2.2314	2.268
Min	1.5927	1.1222	1.7924	1.6827	1.7193	1.7177	1.6301
Avg	1.9809	1.9220	2.1077	1.9515	1.9658	1.9534	1.8847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 202 / 11 KV KARLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.7167	.6859	.7167	.7545	.6371	.5636
2	.679	.7167	.6859	.5898	.7293	.6299	.6036
3	.679	.679	.6859	.583	.7122	.663	.6104
4	.679	.679	.6859	.5506	.6962	.7293	.57
5	.6413	.679	.6478	.5441	.7377	.7865	.6036
6	.6413	.6036	.6478	.5441	.8962	.852	.9175
7	.5658	.4527	.5281	1.0242	.9804	.9831	.9374
8	.4527	.415	.415	.9061	.9804	.9393	.679
9	.3772	.3772	.415	.7407	.759	.9282	.6562
10	1.0562	.8855	.8962	.3772	.4527	.415	.415
11	1.278	.9488	.9686	.415	.4527	.4527	
12	1.0814	.8962	.9259		.4854	.4527	.4527
13	.8848	.8421	.7499	.4904	.4854	.4904	.4854
14	.8322	.7773	.7274	.5228	.4854	.5228	.4854
15	1.004	.7625	.6722	.5228	.4854	.5228	.4805
16	.8421	.7274	.6562	.4904	.4854	.4854	.4481
17	.9282	.8192	.8223	.4904	.4854	.4904	.4481
18	.4805	.4108	.4024	.415	.4435	.3734	.4108
19	.679	.5281	.5975	.5658	.6036	.6036	.5228
20	.8589	.8299	.8215	.8215	.7545	.8589	.8299
21	.8299	.9054	.8299	.8962	.8676	.8589	.9054
22	.8299	.8383	.8215	.8676	.8676	.8299	.8299
23	.7545	.7545	.7842	.7922	.7922	.8299	.7545
24	.679	.7545	.7167	.7545	.7545	.7167	.5765
Max	1.278	.9488	.9686	1.0242	.9804	.9831	.9374
Min	.3772	.3772	.4024	.3772	.4435	.3734	.4108
Avg	.7669	.7083	.6996	.6357	.6728	.6688	.6168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 203 / 11 KV SHIRLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.8962	.8764	.8215	.8871	.7362	.5693
2	.7095	.8589	.8383	.6401	.5937	.7362	.5761
3	.7095	.8589	.8002	.6325	.5864	.7682	.5506
4	.6722	.8676	.8002	.6249	.5693	.7907	.5506
5	.6722	.8215	.7621	.6249	.5761	.7907	.5761
6	.6036	.7468	.7621	.6249	.8124	.8223	.7125
7	.4854	.5601	.5281	.8642	1.0623	.9922	.9259
8	.3772	.5281	.4481	1.142		1.2803	1.0364
9	.415	.5228	.4854	1.1111	1.2018	.9374	.945
10	1.2308	1.0623	1.1227		.5228	.2987	.4481
11	1.2163	1.0623	1.0753		.5228	.3361	.5601
12	1.0494	.8749	.8749	.6653	.6653	.6722	.6283
13	.8642	1.0059	.759	.7023	.7023	.6722	.6653
14	.8333	.7186	.6249	.7316	.7392	.5975	.7023
15	.7099	.5761	.6097	.6653	.7392	.5914	.6653
16	.8025	.6325	.6958	.7392	.7023	.6722	.6653
17		.8223	.8855	.6653	.6653	.6722	.5914
18	.6283	.5487	.3326	.6283	.6283	.6283	.5914
19	.7762	.6348	.6653	.7023	.6722	.7468	.6653
20	.9709	.8962	.8962	.9335	.8962	.8962	.8589
21	.9335	.8962	1.0082	1.0082	.9335	.9335	.9335
22	.9709	.9907	.9709	.8962	.9709	.9335	.8215
23	.8962	.9335	.9335	.8871	.8962	.8962	.8215
24	.8962	.8871	.8962	.8962	.8871	.8589	.583
Max	1.2308	1.0623	1.1227	1.142	1.2018	1.2803	1.0364
Min	.3772	.5228	.3326	.6249	.5228	.2987	.4481
Avg	.79	.8001	.7772	.7821	.7579	.7608	.6935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 204 / 11 KV KHANAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4415	1.7372	1.643	1.848	1.848	1.8111	1.8671
2	.823	1.3413	1.6766	1.7924	1.8671	1.8111	1.7924
3	.9362	1.3413	1.7238	1.7551	1.8111	1.7741	1.7924
4	.9259	1.4586	1.757	1.7551	1.7924	1.7551	1.7372
5	1.0056	1.3748	1.7901	1.7177	1.7924	1.6804	1.7177
6	1.1317	1.5912	1.8233	1.7177	1.6057	1.643	1.5684
7	1.2887	1.6956	1.576	1.2323	1.1949	1.2696	1.2323
8	1.326	1.9662	1.4918	1.1203	1.1949	1.1949	1.1203
9	1.2597	1.9227	1.8679	1.1203	1.0829	1.1203	.9709
10	.1867	.961	1.1088	2.146	2.0119	2.1548	1.7238
11	.1848	1.1458	1.1088	2.4078	2.079	2.3807	2.2801
12	.7392	1.1827	1.1827	2.3739	2.0119	2.146	2.3061
13	1.4784	1.2567	1.2197	2.1026	1.9669	1.9784	1.8107
14	1.5524	1.2936	1.3169		1.2929	1.8233	1.9448
15	1.5154	1.3443	1.3169	1.6766	1.5242	1.8896	
16	1.4784	1.3306		1.9669	1.7772	1.7238	1.4586
17		1.2936		2.0222	1.9448	1.8564	1.2266
18	1.4083	1.2197	1.4632	1.5912	1.2071	1.1827	1.153
19	1.8244	1.2567	1.7002	1.4784	1.3676	1.5154	1.3306
20	1.9669	1.9791	1.9959	1.9418	1.9589	1.9959	1.9959
21	1.9959	1.922	2.2177	1.9959	2.0698	2.1437	2.0698
22	1.922	1.848	2.1068	1.9959	2.1068	2.0698	2.0698
23	1.848	1.7741	1.9589	1.848	1.922	1.922	1.922
24	1.4784	1.7558	1.7741	1.885	1.885	1.848	1.848
Max	1.9959	1.9791	2.2177	2.4078	2.1068	2.3807	2.3061
Min	.1848	.961	1.1088	1.1203	1.0829	1.1203	.9709
Avg	1.2921	1.4997	1.6282	1.8040	1.7215	1.7788	1.6930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024008 / 33 KV PATUR S/S

Feeder No / Name : 205 / ww patur

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0377	.0377	.0377
2	.0377	.0377	.0377	.0377	.0377	.0377	.0377
3	.0377	.0377	.0377	.0377	.0377	.0377	.0377
4	.0377	.0377	.0377	.0377	.0377	.0377	.0377
5	.0377	.0377	.0377	.0377	.0377	.0377	.0377
6	.0377	.0377	.0377	.0377	.0377	.0377	.0377
7	.0366	.0377	.0377	.0377	.0377	.0377	.0377
8	.0377	.0377	.0377	.0377	.0377	.0377	.0377
9	.0377	.0377	.0377	.0377	.0377	.0377	.0377
10	.0377	.0377	.0377	.0377	.0377	.0377	
11	.0377	.0377	.0377	.0377	.0377	.0377	.0377
12	.0377	.0377	.0377	.0377	.0377	.0377	.0377
13	.0377	.0377	.0377	.0377	.0377	.0377	.0377
14	.0377	.0377		.0377	.0377	.0377	.0377
15	.0377	.0377	.0377	.0377	.0377	.0377	.0377
16	.0377	.0377	.0377	.0377	.0377	.0377	.0377
17		.0377	.0377	.0377	.0377	.0377	.0377
18	.0377	.0377	.0377	.0377	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0377	.0377	.0377	.0377	.0377	.0377
21	.0377	.0377	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	.0377	.0377	.0377
23	.0377	.0377	.0377	.0377	.0377	.0377	.0377
24	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Min	.0366	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0377	.0377	.0377	.0377	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 201 / 11 KV SASTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2801	.3921	.2801	.2801	.2614	.2572
2	.2743	.4108	.3921	.2801	.2801	.2241	.2572
3	.2743	.3734	.3921	.2801	.2801	.2241	.2572
4	.3086	.3734	.3921	.2614	.2241	.2241	.2401
5	.3429	.3734	.3921	.2427	.2241	.2058	.2229
6	.3429		.4108	.2054	.2241	.2241	.1886
7	.3772	.3361	.3921	.168	.2054	.1867	.1372
8	.3086	.3361	.5041	.168	.168	.1494	.1372
9	.3361	.3734	.5041	.1494	.168	.168	.1372
10	.1867	.1494	.168	.5041	.4481	.3734	.4481
11	.168	.168	.168	.4481	.4481	.3772	.4108
12	.1867	.1867	.168	.4481	.4481	.3429	.3734
13	.1867	.1867	.1867	.4481	.4108	.3772	.4108
14	.1867	.1494	.1867	.4481	.4108	.3772	.4108
15	.2054	.2054	.2054	.4481	.4108	.4115	.4108
16	.2054	.1867	.2054	.4481	.4481	.3429	.4481
17	.1867	.2054	.1867	.4481	.4481	.4115	.4481
18	.168	.168	.168	.168	.168	.1372	.1494
19	.1867	.1867	.2054	.2614	.2241	.1715	.1867
20	.2614	.2614	.2614	.2614	.2801	.2229	.2427
21	.2801	.2987	.2801	.2614	.2801	.2401	.2801
22	.2987	.2987	.2801	.2614	.2801	.2572	.2801
23	.2987	.2987	.2801	.2987	.2987	.2743	.2801
24	.2801	.2801	.3921	.2801	.2987	.2801	.2572
Max	.3772	.4108	.5041	.5041	.4481	.4115	.4481
Min	.168	.1494	.168	.1494	.168	.1372	.1372
Avg	.2545	.2646	.2964	.3112	.3065	.2694	.2863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 202 / 11 KV CHANNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2054	.168	.1867	.2054	.2054	.1372
2	.1886	.1867	.1494	.2614	.2614	.4854	.2058
3		.1867	.1494	.2614	.2614	.4854	.2401
4	.1715	.1867	.1494	.2987	.2614	.4854	.2743
5	.1543	.168	.168	.3361	.2987	.5228	.2058
6	.1543		.168	.3361	.3734	.5601	.3429
7	.1372	.1307	.1494	.4108	.6348	.5975	.5144
8	.12	.1494	.1307	.4854	.6161	.5975	.4458
9	.1307	.1307	.1307	.5228	.5601	.4108	.4115
10	.5601	.3547	.5228	.1494	.112	.1494	.112
11	.5601	.4854	.4481	.1307	.1307	.12	.112
12	.6348	.3547	.4108	.1307	.1494	.12	.112
13	.3734	.3547	.3734	.1494	.1494	.12	.112
14	.3734	.3547	.3734	.1494	.1494	.1372	.1494
15	.3547	.3547	.3361	.1494	.1494	.1372	.1494
16	.3547	.3547	.3361	.1307	.1494	.1372	.1494
17	.3547	.3734	.3361	.1307	.1307	.1372	.1307
18	.1307	.1307	.112	.112	.112	.1029	.112
19	.168	.1867	.168	.168	.1867	.1543	.168
20	.168	.2054	.1867	.2241	.1867	.1715	.2054
21	.2054	.2054	.2054	.2241	.2241	.1886	.2054
22	.2054	.2054	.2054	.2241	.2241	.1886	.2054
23	.2054	.2054	.1867	.2241	.2054	.1886	.2054
24	.2054	.2054	.1867	.1867	.2054	.2054	.2058
Max	.6348	.4854	.5228	.5228	.6348	.5975	.5144
Min	.12	.1307	.112	.112	.112	.1029	.112
Avg	.2652	.2468	.2396	.2326	.2474	.2754	.2130

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 203 / 11 KV KHETRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4668	.5041	.5228	.5041	.5415	.4801
2	.8139	1.531	1.5684	.5228	.5041	.5228	.4801
3	.9259	1.4003	1.5684	.5228	.5041	.5228	.4801
4	1.0288	1.419	1.587	.5601	.5601	.5228	.5144
5	1.153	1.4937	1.5684	.5601	.5601	.5228	.5144
6	1.4083		1.5684	.5601	.5788	.4854	.5144
7		1.6057	1.5684	.4668	.5415	.4668	.4458
8	1.4419	1.6057	1.587	.4294	.5041	.4854	.4287
9	1.5684	1.5684	1.5123	.4108	.2987	.4294	.3601
10	.3361	.3921	.3734	1.7551	1.6804	1.6057	1.643
11	.3361	.3734	.3734	1.7737	1.0456	1.5089	1.7551
12	.3734	.3734	.3734	1.6804	.9335	1.576	1.643
13	.3734	.4294	.3921	1.4937	.9335	1.5089	1.587
14	.4108	.4294	.4108	1.307	1.3817	1.4754	1.4937
15	.4294	.3921	.4294	1.3817	1.3817	1.3413	1.4003
16	.4294	.4108	.4108	1.419	1.4937	1.4754	1.6057
17	.4108	.4108	.4294	1.4937	1.5684	1.4419	1.6804
18	.4108		.4294	.4108	.3921	.3601	
19	.5228	.5601	.5975	.5415	.5601	.4801	.5601
20	.5228	.5601	.5788	.5601	.5601	.4801	.5601
21	.5228	.5601	.5788	.5601	.5788	.5144	.6161
22	.4854	.5601	.5601	.5601	.5788	.5144	.5601
23	.4854	.5228	.5228	.5601	.5601	.4801	.4668
24	.4668	.4668	.4854	.5228	.5601	.5601	.4801
Max	1.5684	1.6057	1.587	1.7737	1.6804	1.6057	1.7551
Min	.3361	.3734	.3734	.4108	.2987	.3601	.3601
Avg	.6646	.7969	.8324	.8573	.7818	.8259	.8813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024009 / Sasti

Feeder No / Name : 204 / 11 KV WADEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3734	.4108	.4108	.4108	.4108	.78
2	.1886	.3921	.4108	.7468	.7468	.8589	.78
3	.3772	.3921	.4108	.7468	.8402	.8962	.8478
4	.3429	.3734	.4108	.9335	.8402	.8962	.8817
5	.3429	.3174	.4108	1.0082	.9335	.9335	.9156
6	.3429		.3361	1.1576	1.0082	1.0829	.9496
7	.2572	.2801	.2614	1.1203	1.0082	1.1203	.8478
8	.2058	.2241	.2241	1.0829	1.2323	1.1576	.8478
9	.1867	.2241	.2241	1.0082	1.2323	.9709	.9156
10	1.3443	1.2696	1.2696	.2427	.2241	.2241	.2241
11	1.4003	1.251	1.2323	.2614	.2427	.2058	.2427
12	1.3817	1.0642	1.1949	.2614	.2987	.2572	.2987
13	1.1949	1.1203	1.1203	.2987	.2987	.2743	.2987
14	1.2136	.9335	1.1203	.3361	.3361	.2915	.3361
15	1.1576	1.0082	.7095	.2987	.3174	.3086	.3361
16	1.2323	1.0269	1.1203	.2987	.2987	.3086	.2987
17	1.2323	1.2323	1.1576	.2614	.2801	.2743	.2801
18	.2614	.2614	.2241	.2614	.2614	.2572	.2614
19	.2987	.3361	.2801	.2801	.2427	.2572	.2801
20	.3734	.3734	.3734	.3921	.3734	.3429	.3361
21	.4108	.4108	.4108	.3921	.4108	.3772	.3734
22	.4108	.4108	.4108	.3921	.4108	.3772	.4668
23	.4108	.4108	.4108	.3921	.4108	.3772	.4108
24	.3734	.3734	.4108	.4108	.3921	.4108	.78
Max	1.4003	1.2696	1.2696	1.1576	1.2323	1.1576	.9496
Min	.1867	.2241	.2241	.2427	.2241	.2058	.2241
Avg	.6382	.6113	.6061	.5415	.5438	.5363	.5412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 201 / 11 KV CHONDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8779	.8962	.8954	.9145	.8383	.8383	1.3969
2	.8779	.9145	.8859	1.7147	1.9951	.8886	1.3523
3	.8779	.8779	.8573	1.7147	1.9281	1.6263	1.3375
4	.7888	.8962	.823	1.8176	1.9281	1.643	1.406
5	.7888	.8962	.9114	1.8861	1.9784	1.6766	1.5089
6	.7973	.8962	.7362	1.9547	2.1125	1.7604	1.5604
7	.5548	.6767	.7164	1.989	2.0957	1.8778	1.5947
8	.4854	.6036	.6219	1.9376	1.7269	1.9784	1.6124
9	.4458	.5415	.4973	1.7532		1.7101	1.576
10	1.4754	2.2405	2.0157	.4938	.4481	.4481	.4161
11	2.1085	2.2207	2.0416	.439	.4668	.4294	.4607
12	2.1033	1.9204	1.8679	.4755	.4668	.4344	.439
13	2.1765	1.9418	1.8679	.5093	.4854	.4298	.439
14	2.0376	1.9418	1.917	.4904	.4481	.4908	.439
15		1.8839	1.8679	.4904	.4668	.4801	.439
16	1.7737	1.8111	1.8023	.4904	.4854	.4694	.439
17	1.5927	1.8111	1.8679	.4578	.4854	.4458	.4066
18	.5611	.7762	.5373	.5935	.5041	.6805	.5228
19	.8779	.8048	.8596	.6706	.9709	.815	.5788
20	1.0608	.8413	1.0745	.7042	.9896	.9015	.8962
21	1.0974	.9671	1.134	.8886	1.0642	.8718	.9877
22	1.1157	.9536	1.0974	.9724	1.0829	.8383	1.0425
23	1.0608	.9431	.9877	.9221	1.0269	.7712	.9511
24	.9362	1.0608	.8916	.9145	.8551	1.0269	1.2209
Max	2.1765	2.2405	2.0416	1.989	2.1125	1.9784	1.6124
Min	.4458	.5415	.4973	.439	.4481	.4294	.4066
Avg	1.1510	1.2216	1.1990	1.0498	1.0804	.9805	.9593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 202 / 11 KV ALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	1.0242	.5895	.6447	1.2323	1.1203	.8478
2	.8589	.9511	.5895	.6447	1.1949	1.0829	.8478
3	.8238	.8962	.6024	.6447	1.1203	1.0829	.8383
4	.815	.7682	.5895	.6447	1.0829	1.0642	.8718
5	.7442	.695	.5853	.5959	.9896	1.0456	.9156
6	.7712	.6401	.6767	.5959	.8718	1.1016	.8764
7	.7545	.7682	.6516	.4908	.6706	1.0456	.7362
8	.7716	.8048	.7164	.4207	.7545	.9335	.7762
9	.7712	.7842		.4115	.8383	.9335	.7522
10	.7282	.9145		.5243	.7712	.6706	.7712
11	.6379	.8688	.7442	.4915	.7712	.5868	.7701
12	.7316	.8402	.7202	.503		.7122	.7202
13	.7602	.8402	.7202	.503		.7442	.6859
14	.7964	.7922	.7011	.4862	.7209	.7343	.6859
15	.8413	.7922	.7011	.4694	.6874	.703	.6516
16	.9145	.8059	.7011	.4694	.6706	.7343	.6516
17	1.0608	.8059	.7362		.6874	.6859	.6859
18	1.0974	.823	.6661		.7042	.7973	.8238
19		.8764	.7164	.9054	.7042	.8063	.8596
20	1.0608	.961	.7164	.8886	.9724	.8954	.8954
21	1.1888	.961	.7164	.8551	1.0395	.9259	.9145
22	1.7924	.9816	.6805	.8383	1.1065	.9568	.9511
23	1.1888	.9602	.6805	.9724	1.1233	.9015	.9313
24	1.0829	1.134	.6447	.6447	1.073	1.8442	.9015
Max	1.7924	1.134	.7442	.9724	1.2323	1.8442	.9511
Min	.6379	.6401	.5853	.4115	.6706	.5868	.6516
Avg	.9157	.8620	.6748	.6202	.8994	.9212	.8067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA RURAL DIVISION[611]

PATUR SUB-DIVISION[814] BU 4814

Substation No/ Name :- 024022 / 33 KV ALEGAON

Feeder No / Name : 203 / 11 KV AMBASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6126	1.8107	1.749	1.8858	1.6933	1.6598	1.1888
2	1.6126	1.6278	1.749	1.56		1.6766	1.1269
3	1.595	1.6461	1.8073	1.5775	1.6598	1.6933	1.1145
4	1.595	1.6644	1.8625	1.5775	1.4922	1.643	1.134
5	1.5947	1.6644	1.8031	1.5775	1.3413	1.4754	1.134
6	1.56	1.6827	1.5261	1.5074	1.0562	1.3748	1.39
7	1.4403	1.3169	1.382	1.3375	1.358	1.1904	1.419
8	1.2174	1.2254	1.258	1.3496	1.3077	1.3916	1.475
9	1.2536	1.251	1.1946	1.1919	1.2742	1.1361	1.3203
10	1.6301	1.5912	1.4706	1.2136	1.251	1.0852	1.2826
11	1.773	1.4998	1.4373	1.3443	1.307	1.1191	1.307
12	1.576	1.4327	1.3496	1.4003	1.3256	1.2483	1.3817
13	1.4299	1.4632	1.3032	1.419	1.3443	1.3969	1.4563
14	1.1222	1.4563	1.1831	1.4563	1.3817	1.382	1.4563
15		1.1576	1.1831	1.475	1.419	1.3523	1.419
16		1.2696	1.166	1.4146	1.4003	1.3696	1.419
17	1.2437	1.1919	1.166	1.3769	1.4003	1.4632	1.3121
18	1.4118	1.3672	1.2254	1.4712	1.3443	1.531	1.5684
19	1.647	1.5257	1.8298	1.5655	1.4937	1.5497	1.587
20	2.009	1.9022	2.0165	1.8296	1.8111	1.9342	1.8656
21	1.8656	1.9418	1.9753	1.905	1.9231	1.8404	1.9022
22	1.9387	1.9791	1.9387	2.0559	2.0351	1.8004	1.957
23	1.8656	1.858	1.9022	1.9805	2.0725	1.9163	1.9204
24	1.7101	1.829	1.7878	1.8858	1.9616	2.0538	1.1789
Max	2.009	1.9791	2.0165	2.0559	2.0725	2.0538	1.957
Min	1.1222	1.1576	1.166	1.1919	1.0562	1.0852	1.1145
Avg	1.5775	1.5564	1.5528	1.5566	1.5067	1.5118	1.4298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 201 / 11 KV Rajeshwar Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9677	1.9974	1.9639	1.9563	1.9639	1.9502	3.761
2	1.8404	1.941	1.8755	1.8999	1.8808	1.9014	3.6256
3	1.781	1.8854	1.8259	1.8473	1.8061	1.8358	3.5838
4	1.7299	1.8023	1.7498	1.768	1.755	1.7832	3.4678
5	1.7056	1.7421	1.7033	1.7428	1.7102	1.7184	3.3171
6	1.6095	1.6522	1.6248	1.5935	1.6956	1.6332	3.1671
7	1.5562	1.5874	1.5249	1.6019	1.6019	1.5104	3.047
8	1.5135	1.4731	1.4494	1.5386	1.5783	1.4022	2.9583
9	1.5707	1.355	1.3367	1.4655	1.4868	1.3641	2.8923
10	1.5485	1.2544	1.323	1.361	1.5028	1.3369	2.927
11	1.4464	1.2285	.6783	1.3047	1.4068	1.3407	2.9331
12	1.4136	.6882		1.3839	1.4441	1.3632	2.967
13	1.4876	1.3322		1.4533	1.4952	1.4444	3.0968
14	1.6248	1.4998		1.5501	1.5409	1.5453	3.2885
15	1.7169	1.5608	1.8716	1.6636	1.5996	1.6553	3.3689
16	1.6919	1.6194	1.8015	1.6912	1.6347	.8665	3.3805
17	1.6507	2.982	1.8381	1.6583	1.6065	1.6221	3.2998
18	1.5699	.7735	1.6705	1.5607	1.518	1.5463	3.0451
19	1.5615	1.7116	1.5059	1.4906	1.4723	1.4982	2.3834
20	1.7733	1.7954	1.781	1.7741	1.6873	1.7052	1.7469
21	1.9304	1.9426	1.7954	1.8336	1.7756	1.8128	1.8134
22	2.0183	1.9235	1.9083	1.9128	1.8991	1.9252	1.8395
23	2.0835	2.0699	2.0051	2.0333	2.0142	2.9814	1.9902
24	2.0325	2.0584	1.9936	2.0127	2.0142	3.0232	2.9176
Max	2.0835	2.982	2.0051	2.0333	2.0142	3.0232	3.761
Min	1.4136	.6882	.6783	1.3047	1.4068	.8665	1.7469
Avg	1.7010	1.6615	1.6775	1.6707	1.6704	1.6986	2.9507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 204 / 11 KV Renuka Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4266	1.4815	1.3717	1.4083	1.423	1.4632	1.3491
2	1.3169	1.4632	1.2803	1.3535	1.3169	1.3937	1.2936
3	1.2803	1.4118	1.3169	1.3121	1.2437	1.3032	1.2567
4	1.2803	1.3535	1.1888	1.262	1.134	1.262	1.2012
5	1.262	1.2308	1.2071	1.2382	1.1888	1.2071	1.0745
6	1.1888	1.1706	1.1706	1.134	1.134	1.1888	1.0425
7	1.134	1.1157	1.0791	1.1157	1.0974	1.1157	1.0425
8	1.0208	1.0136	.9511	.9412	.9231	.9412	.905
9	1.0208	.9231	.9328	.9412	.8962	.9231	.8238
10	.9671	.8775	.8775	.8962	.8775	.8954	.9242
11	.9313	.8775	.8326	.8688	.8954	.8688	.8869
12	.9492		.9412	.8869	.9593	.9593	.9593
13	1.086	1.0498	1.0029	1.0534	1.0608	1.086	1.0242
14	1.1946	1.134	1.1104	1.1222	1.134	1.086	1.134
15	1.1946	1.1888	1.1946	1.2071	1.1888	1.086	1.2136
16	1.2437	1.1584	1.2489	1.2071	1.1888		1.2323
17	1.1222		1.134	1.1222	1.134	1.1041	1.1584
18	1.0808	1.0808	1.1157	1.0387	1.0387	1.0208	1.0498
19	1.1462	1.1462	1.1462	1.1104	1.1283	1.1666	1.1283
20	1.3256	1.2851	1.2489	1.2437	1.2489	1.1946	1.2308
21	1.3169	1.3352	1.3352	1.3213	1.3352	1.3394	1.2489
22	1.5123	1.4815	1.4449	1.4815	1.4632	1.4266	1.3535
23	1.5223	1.5729	1.5524	1.5524	1.5181	1.6095	1.4266
24	1.5181	1.5181	1.4815	1.4969	1.4784	1.4632	1.4769
Max	1.5223	1.5729	1.5524	1.5524	1.5181	1.6095	1.4769
Min	.9313	.8775	.8326	.8688	.8775	.8688	.8238
Avg	1.2101	1.2213	1.1736	1.1798	1.1669	1.1784	1.1432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 205 / 11 KV Shivsena Vasahat

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.1657	4.2956	1.9167	1.8924	1.8964	1.9696	1.8921
2	4.0222	4.1724	1.8763	1.8496	1.8321	1.901	1.8233
3	4.012	4.0756	1.8549	1.8328	1.7991	1.8911	1.7872
4	4.0147	4.0314	1.8896	1.829	1.8146	1.8721	1.7789
5	4.0101	4.0447	1.8932	1.8672	1.8551	1.8919	1.7857
6	3.9366	3.9108	1.9492	2.0251	2.1125	1.9882	1.9444
7	3.9542	4.0672	2.0298	2.1578	2.1574	2.055	1.9688
8	4.2105	4.0375	2.1837	2.1742	2.2641	2.1517	1.9556
9	4.1034	3.938	2.0672	2.093	2.2971	1.1302	2.0706
10	3.8477	3.7636	1.9	1.9658	2.1159		1.8924
11	3.7791	3.6524	1.9014	1.865	2.0473	.0732	1.9078
12	3.838	2.528	1.9277	1.8429	1.97	2.2369	1.8578
13	3.7297	1.7293	1.7505	1.8006	1.9053	2.0351	1.7802
14	3.7006	1.6536	1.6774	1.7768	1.7354	.9526	1.6509
15	3.7418	1.6655	1.6149	1.6292	1.6398	1.6221	1.5582
16	3.7456	1.6393	1.6294	1.6393	1.6697	.8406	1.6734
17	3.7279	.836	1.7383	1.7057	1.727	1.6583	1.6062
18	3.8416	1.8014	1.7932	1.7309	1.7878	1.7367	1.6196
19	4.1451	2.1922	2.0847	1.8932	2.1044	1.9871	1.9566
20	4.6857	2.3967	2.3922	2.3107	2.378	2.2461	2.2744
21	4.5056	2.359	2.3693	2.1613	2.3352	2.2872	2.1748
22	4.4689	2.2848	2.1845	2.1395	2.2515	2.0698	2.2172
23	4.6864	2.1567	2.1039	2.0671	2.1475	1.998	2.1075
24	4.4439	3.1529	1.986	1.9852	2.0094	2.0149	2.0214
Max	4.6864	4.2956	2.3922	2.3107	2.378	2.2872	2.2744
Min	3.7006	.836	1.6149	1.6292	1.6398	.0732	1.5582
Avg	4.0549	2.9327	1.9464	1.9264	1.9939	1.7656	1.8877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 241 / 11KV DABKI I/C NO.1

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				2.347			3.3065
2				2.3655			3.1047
3				2.4394			3.2341
4				2.1807			
5				2.4579			
6	2.9081			2.2916	2.3101		
7		3.1047		2.2546			2.7721
8			2.1472	2.1807			2.6612
9				2.1437			2.6797
10	2.8715	2.8166					
11		2.963			2.2177	1.1827	
12		2.0302		2.1622		2.2916	
13	2.9081		1.4045	2.1437			
14	2.9995			2.2546		2.1622	2.9014
15	2.1719	2.2314				2.1437	
16	3.0493	2.1765				2.1807	
17	2.9995			2.2361		2.1992	
18			2.1437			2.2177	
19			2.2916			2.384	
20	3.5482		2.6242		2.6057	2.6427	2.4579
22	3.6594		2.7351				
23			2.6797				
24	3.4751	3.4385	2.782	2.4025	2.5133	2.3101	3.3251
Max	3.6594	3.4385	2.782	2.4579	2.6057	2.6427	3.3251
Min	2.1719	2.0302	1.4045	2.1437	2.2177	1.1827	2.4579
Avg	3.0591	2.6801	2.351	2.2757	2.4117	2.1715	2.9381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 242 / 11 KV DABKI I/C NO.2

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5652	2.5713	2.5149	4.8396	2.4402	2.4829	4.8202
2	2.4722	2.4768	2.4036	4.6693	2.3792	2.3945	4.5055
3	2.4387	2.3868	2.3365	4.5222	2.2725	2.3304	4.3062
4	2.3457	2.2893	2.2619	4.3149	2.1978	2.2116	2.079
5	2.2542	2.1933	2.1856	4.1336	2.1018	2.1018	1.9768
6	4.2244	2.1064	2.0241	3.978	3.9796	2.0561	1.9098
7	1.9464	3.853	1.9189	3.7904	1.8808	1.893	3.6449
8	1.8625	1.7955	3.4072	3.3346	1.6979	1.7299	3.2567
9	1.7482	1.7452	1.7101	3.3163	1.6827	1.6857	3.2224
10	3.4416	3.2443	1.6842	1.6629	1.6964	1.6796	1.7238
11	1.8366	3.3208	1.7528	1.6796	3.2671	3.2793	1.7878
12	2.0454	3.6341	1.9403	3.3943	1.9585	3.5608	1.9174
13	3.9355	2.0881	3.5288	3.7049	2.0927	2.0469	2.1247
14	4.4463	2.2024	2.1963	3.954	2.1689	4.0222	4.2433
15	4.5283	4.2625	2.1963	2.0972	2.1536	4.1792	2.2527
16	4.4078	4.1571	2.1338	2.0546	2.1049	4.0683	2.1765
17	3.9845	1.8183	3.8889	3.8923	2.0271	3.8589	1.9677
18	2.2146	2.2146	3.8778	2.0424	2.0957	3.9176	2.0911
19	2.3442	2.3152	4.0527	2.2329	2.2237	4.2557	2.2283
20	4.6765	2.3807	4.3774	2.3564	4.4551	4.4833	4.3499
21	2.7039	2.6414	2.5575	2.5652	2.5804	2.4691	2.4356
22	5.4725	2.7999	5.1541	2.7115	2.7145	2.7435	2.6429
23	2.8334	2.7953	5.3311	2.6703	2.681	2.7267	2.5774
24	5.2782	5.2447	5.105	5.1157	5.1075	5.011	4.8473
Max	5.4725	5.2447	5.3311	5.1157	5.1075	5.011	4.8473
Min	1.7482	1.7452	1.6842	1.6629	1.6827	1.6796	1.7238
Avg	3.1670	2.7724	2.9392	3.2930	2.4983	2.9662	2.8787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 401 / 33KV I/C APATAPA TO DABKI
SOUR Feeder KV- 33 / INCOMING

SHEDDABLE RURAL

DATE	21-MAY-17
HR	Load (MW)
19	18.2328
20	***
21	27.492
22	27.2063
23	28.578
24	29.0352
Max	36.1431
Min	18.2328
Avg	27.7812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024001 / 33 KV Dabki Sub Station

Feeder No / Name : 403 / 33 KV I/C KHADKI TO DABKI

Feeder KV- 33 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.0247	8.0076	7.013	15.0206	6.9787	6.7558	16.7399
2	7.6989	7.6132	6.6015	14.5891	6.6873	6.5844	15.9956
3	7.4417	7.4246	6.3958	14.5073	6.4986	6.3615	15.4697
4	7.2188	7.2531	6.07	13.8157	6.2929	6.2243	6.773
5	7.0816	6.9616	5.9156	13.7591	6.1728	6.1728	6.4643
6	15.3201	6.8073	5.8642	13.3751	13.227	5.9671	6.2757
7	6.653	14.4684	5.6584	12.4737	5.7613	5.7099	13.3962
8	6.31	6.3272	12.0576	11.905	5.4527	5.5384	12.6413
9	6.0871	6.07	5.3155	11.2894	5.2641	5.1612	12.308
10	12.7773	12.9324	5.0755	4.9726	5.024	4.4582	5.4184
11	5.6242	12.5572	4.8868	4.8868	11.334	9.1267	5.4527
12	12.7773	11.9913	4.4925	11.0494	5.0583	11.3443	5.5384
13	5.8985	11.5884	10.4801	10.7648	5.2298	12.068	5.6584
14	14.5147	12.2257	4.8697	11.9102	5.4184	12.2256	13.6351
15	14.8734	12.4172	5.9499	5.5384	5.7099	12.8087	6.2243
16	14.9211	12.9116	5.9842	5.7613	5.7956	12.8744	6.4129
17	14.8114	7.3217	13.2802	12.7092	5.8128	12.4589	6.3443
18	6.2243	5.144	12.5801	5.5384	5.6242	11.9485	6.1214
19	6.19	5.4527	12.3286	5.3327	5.4184	12.4658	3.0521
20	15.755	6.2071	13.8992	6.1214	13.9712	12.823	
21	7.0816	6.3272	14.1598	6.2929	6.2757	14.0803	
22	17.3446	6.6015	15.0749	6.5501	6.4986	6.5329	
23	8.0247	7.1331	15.6607	6.8759	6.8416	6.7558	
24	18.2202	17.1708	15.6242	15.5853	15.5933	16.3341	9.5064
Max	18.2202	17.1708	15.6607	15.5853	15.5933	16.3341	16.7399
Min	5.6242	5.144	4.4925	4.8868	5.024	4.4582	3.0521
Avg	10.2864	9.1215	8.9683	10.0260	7.1642	9.2825	8.9714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 201 / 11KV RPTS Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8959	2.9805	2.9805	2.9619	2.8617	2.9805	2.8445
2	2.7512	2.8483	2.867	2.867	2.7512	2.867	2.7512
3	2.7169	2.811	2.867	2.867	2.734	2.8297	2.6406
4	2.7169	2.7347	2.8483	2.772	2.734	2.7534	2.6063
5	2.6406	2.8483	2.8483	2.772	2.734	2.7907	2.6063
6	2.7512	2.8483	2.9043	2.7347	2.734	2.8297	2.5891
7	2.7855	2.8857	2.867	2.7534	2.8197	2.9043	2.6063
8	2.7683	3.0739	3.0179	3.0179	2.8959	2.9417	2.6063
9	2.6826	2.9245	2.8685	2.811	2.8483	2.9432	2.6063
10	2.4862	2.7923	2.6787	2.6413	2.716	2.6429	2.6787
11	2.4516	2.6025	2.6025	2.5465	2.716	2.4443	2.5651
12	2.6025	2.716	2.5838	2.6398	2.716	2.5129	2.5061
13	2.5091	2.6585	2.772	2.4615	2.6973	2.5301	2.7534
14	2.4329	2.5651	2.716	2.351	2.5091	2.3586	2.5278
15	2.5465	2.4516	2.7534	2.351	2.6025	2.351	2.5465
16	2.6211	2.7518	2.7923	2.3338	2.7907	2.351	2.6398
17	2.716	2.6398	2.6585	2.5301	2.8297	2.4272	2.6973
18	2.6787	2.7145	2.7534	2.5129	2.716	2.4443	2.5651
19	2.8654	2.979	2.9977	2.8197	2.9417	2.692	2.6025
20	3.1314	3.2061	3.2636	3.1093	3.1874	2.9302	2.9619
21	2.9805	3.1314	3.0179	3.0064	3.0179	2.6483	2.7923
22	3.0179	3.0552	3.0179	2.9302	3.0179	2.8197	2.923
23	3.0179	3.0926	3.0739	3.0236	3.0552	2.9302	2.9992
24	2.8959	3.1127	3.0552	3.0365	2.8959	3.0179	2.8959
Max	3.1314	3.2061	3.2636	3.1093	3.1874	3.0179	2.9992
Min	2.4329	2.4516	2.5838	2.3338	2.5091	2.351	2.5061
Avg	2.7359	2.8510	2.8669	2.7438	2.8134	2.7059	2.6880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 204 / 11 KV Cotton Market

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6539	2.6109	2.66	2.6413	2.5377	2.6483	2.4558
2	2.5416	2.5804	2.5126	2.5431	2.4425	2.5431	2.3948
3	2.4939	2.4939	2.4634	2.5126	2.3948	2.4939	2.3643
4	2.4463	2.4329	2.4634	2.4939	2.3643	2.4634	2.3167
5	2.4158	2.3464	2.4329	2.4516	2.3338	2.4329	2.2862
6	2.2481	2.3091	2.4821	2.4889	2.3033	2.4024	2.3033
7	2.3338	2.3091	2.5804	2.4211	2.2862	2.316	2.3815
8	2.3167	2.3396	2.4142	2.4074	2.2176	2.3396	2.4253
9	2.2519	2.3582	2.3091	2.4024	2.3396	2.3396	2.4806
10	2.1872	2.3533	2.199	2.4634	2.3837	2.2787	2.2767
11	2.1548	2.5804	2.3091	1.2498	2.6178	1.3699	2.2787
12	2.3091	2.5804	2.3091	1.2517	2.6669	2.3777	2.2482
13	2.5804	2.7465	2.3837	2.7359	2.6787	2.5073	2.2226
14	2.4939	2.6787	2.3091	2.6063	2.4447	2.5073	2.2787
15	2.5853	2.4006	2.3091	2.572	2.4447	2.4768	2.2482
16	2.5804	2.5666		2.4463	2.6669	2.3472	2.1243
17	2.6787	2.716		2.6749	2.6856	2.5167	2.0614
18	2.6109	2.6483	3.0483	2.633	2.6109	2.5073	2.4006
19	2.5313	2.7043	3.3196	2.5167	2.6856	2.4768	2.3464
20	2.7465	2.7465	3.3245	2.6673	2.716	2.572	2.4311
21	2.5666	2.5736	3.0651	2.4768	2.5804	2.4082	2.3396
22	2.5499	2.5686	2.7907	2.5111	2.5008	2.5073	2.3837
23	2.5853	2.6973	2.7465	2.572	2.6669	2.5416	2.4006
24	2.6406	2.5804	2.6718	2.7092	2.6063	2.716	2.5111
Max	2.7465	2.7465	3.3245	2.7359	2.716	2.716	2.5111
Min	2.1548	2.3091	2.199	1.2498	2.2176	1.3699	2.0614
Avg	2.4793	2.5384	2.5956	2.4354	2.5073	2.4204	2.3317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 205 / 11 KV Tajnapeth Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.8131	.8589	.8131	.7545	.8589	.7716
2	.7202	.8131	.8215	.8131	.7202	.7842	.7545
3	.6859	.7762	.7842	.8131	.6859	.7468	.6859
4	.6859	.7392	.7842	.7947	.6859	.7468	.6859
5	.6859	.7023	.8215	.7762	.6859	.7468	.6859
6	.6859	.6653	.7468	.7392	.6859	.7468	.6859
7	.6687	.6653	.7468	.7392	.6516	.7468	.6859
8	.6859	.7207	1.1203	.7392	.7716	.7468	.6859
9	.7716	.7207	.8215	.7392	.7468	.7468	.7716
10	.6516	.5975	.6838	.6468	.7468	.7468	.6468
11	.6468	.6535	.6468	.6468	.6722	.5658	.6653
12	.6468	.6348	.6283	.6653	.7468	.6687	.5544
13	.6653	.6535	.6468	.6344	.7468	.5487	.5914
14	.6653	.6722	.6653	.6173	.7095	.6344	.5914
15	.6838	.6722	.7392	.6173	.6722	.6344	.5544
16	.6838	.6722	.6838	.6859	.7468	.6516	.6468
17	.6653	.7468	.6838	.6859	.7468	.6859	.7392
18	.7023	.6722	.6653	.6516	.6348	.6173	.6653
19	.6283	.7095	.8131	.7716	.5975	.6173	.7023
20	.7023	.7468	.7392	.6859	.7468	.6516	.7392
21	.7095	.7468	.8131	.6859	.7468	.6516	.7023
22	.7762	.7468	.8131	.6859	.7468	.6859	.7392
23	.7392	.8215	.8131	.7202	.8962	.6859	.7392
24	.7888	.8131	.8402	.8131	.7545	.8589	.7888
Max	.7888	.8215	1.1203	.8131	.8962	.8589	.7888
Min	.6283	.5975	.6283	.6173	.5975	.5487	.5544
Avg	.6965	.7156	.7659	.7159	.7208	.6990	.6866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 241 / 11KV MOHATA I/C NO.1

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4563	1.4563	1.4377	1.3375	1.4563	1.3203
2	1.3032	1.4003	1.419	1.419	1.3032	1.419	1.3032
3	1.2689	1.363	1.419	1.39	1.286	1.3817	1.2689
4	1.2689	1.363	1.4003	1.3717	1.286	1.3817	1.2346
5	1.2689	1.4003	1.4003	1.3717	1.286	1.419	1.2346
6	1.3032	1.4003	1.4563	1.3352	1.286	1.3817	1.2174
7	1.3375	1.4377	1.419	1.3535	1.3717	1.4563	1.2346
8	1.3203	1.5497	1.4937	1.4937	1.3717	1.4937	1.2346
9	1.2346	1.4003	1.3443	1.363	1.4003	1.419	1.2346
10	1.1145	1.3443	1.307	1.2696	1.3443	1.1949	1.307
11	1.2323	1.307	1.307	1.251	1.3443	1.1488	1.2696
12	1.307	1.3443	1.2883	1.3443	1.3443	1.2174	1.363
13	1.2136	1.363	1.4003	1.166	1.3256	1.2346	1.3817
14	1.2136	1.2696	1.3443	1.1317	1.2136	1.0631	1.2323
15	1.251	1.2323	1.3817	1.1317	1.307	1.1317	1.251
16	1.3256	1.4563	1.3443	1.1145	1.419	1.1317	1.3443
17	1.3443	1.3443	1.363	1.2346	1.3817	1.1317	1.3256
18	1.307	1.419	1.3817	1.2174	1.3443	1.1488	1.2696
19	1.4937	1.531	1.5497	1.3717	1.4937	1.3203	1.307
20	1.531	1.6057	1.587	1.5089	1.587	1.406	1.4377
21	1.4563	1.531	1.4937	1.406	1.4937	1.2003	1.3443
22	1.4937	1.531	1.4937	1.406	1.4937	1.3717	1.475
23	1.4937	1.5684	1.5497	1.4232	1.531	1.406	1.475
24	1.3717	1.5123	1.531	1.5123	1.3717	1.4937	1.3717
Max	1.531	1.6057	1.587	1.5123	1.587	1.4937	1.475
Min	1.1145	1.2323	1.2883	1.1145	1.2136	1.0631	1.2174
Avg	1.3261	1.4221	1.4221	1.3344	1.3718	1.3087	1.3099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 242 / 11 KV MOHATA I/C NO. 2

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0233	2.0911	2.1472	2.0911	1.9204	2.1658	1.8861
2	1.9204	2.0911	2.0538	2.0538	1.8519	2.0165	1.869
3	1.869	1.9978	1.9978	2.0538	1.8004	1.9605	1.8004
4	1.8519	1.9605	1.9978	2.0165	1.8004	1.9605	1.7833
5	1.8519	1.8671	2.0351	2.0165	1.8004	1.9605	1.7833
6	1.7147	1.7924	1.9791	2.0165	1.8004	1.9605	1.8004
7	1.7833	1.7924	2.0165	1.9791	1.749	1.9605	1.8176
8	1.7833	1.8484	2.3152	1.9044	1.8004	1.8671	1.8004
9	1.8347	1.8671	1.9418	1.9605	1.8671	1.8671	1.9719
10	1.6804	1.7924	1.7924	1.8671	1.9418	1.8671	1.6804
11	1.6804	1.9231	1.7737	.6468	1.9791	.9602	1.7924
12	1.7556	1.9044	1.7551	2.0351	2.0725	1.7661	1.6804
13	1.9418	1.9978	1.8484	1.9376	2.0538	1.7147	1.6617
14	1.8858	1.9791	1.7924	1.8519	1.9044	1.8004	1.7177
15	1.9044	1.7924	1.8671	1.8176	1.8671	1.8004	1.6804
16	1.9605	1.8671	.6838	1.8519	2.0725	1.749	1.6804
17	2.0165	2.0911	.6838	1.989	2.0911	1.8004	1.6804
18	1.9791	1.9791	2.1658	1.8519	1.9044	1.7833	1.7924
19	1.8858	2.0725	2.4646	1.8861	1.9418	1.7833	1.8671
20	2.0538	2.0911	2.3339	1.9204	2.0911	1.8519	1.8671
21	1.9044	1.9791	2.2405	1.8519	2.0165	1.749	1.8298
22	2.0538	2.0351	2.2405	1.8861	1.9978	1.8519	1.9418
23	1.9605	2.1472	2.1658	1.9204	2.2218	1.8861	1.8671
24	2.0576	2.0911	2.1098	2.1285	1.989	2.2032	1.989
Max	2.0576	2.1472	2.4646	2.1285	2.2218	2.2032	1.989
Min	1.6804	1.7924	.6838	.6468	1.749	.9602	1.6617
Avg	1.8897	1.9604	1.9334	1.8973	1.9390	1.8453	1.8017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 401 / 33KV APATAPA TO MOHATA S/S

I/C Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.3272	6.653	6.7215	6.653	6.1728	6.7215	5.9156
2	6.0185	6.4312	6.4975	6.3203	5.9156	6.2174	5.6584
3	5.7613	6.154	6.1614		5.607	6.0494	5.4012
4	5.7099	5.9322	6.0494	6.0431	5.5041	5.8814	5.144
5	5.5041	5.7105	5.8814	5.8768	5.4012	5.6013	4.9897
6	5.1955	5.4887	5.6013	5.655	5.1955	5.5453	4.9383
7	5.0412	5.3224	5.4893	5.4332	4.9897	5.3212	4.7325
8	4.9897	5.3778	5.8814	5.4332	5.0412	5.3772	4.7325
9	4.9897	5.2115	3.8649	5.3778	5.3772	5.2652	4.8354
10	4.784	5.3772	5.7105	5.4332	5.5453	5.3772	4.8788
11	5.4332	5.6013	5.655	4.3799	5.7693	4.321	5.0452
12	5.7659	5.9374	8.3162	5.8768	5.8814	5.3498	5.0452
13	6.0431	6.1614	8.8706	5.6584	6.1054	5.4527	5.3778
14	6.0985	6.3855	6.3203	5.7613	5.9934	3.7037	5.4887
15	6.2649	6.2734	6.4312	5.8128	6.1614	5.7613	5.5996
16	6.4312	6.4975	5.2669	5.8128	6.4975	5.7613	5.655
17	6.154	6.2734	5.1006	5.8128	6.4415	5.5556	5.4887
18	5.8213	5.9374	6.2094	5.5556	5.9374	5.2984	5.3224
19	6.1614	6.1614	6.653	5.6584	6.1054	5.3498	5.4332
20	6.3203	6.4415	6.5975	5.9156	6.4415	5.607	5.7105
21	6.2649	6.3295	6.4866	5.9156	6.1614	5.2984	5.655
22	6.5421	6.5535	6.5975	5.9671	6.3855	5.7099	6.0431
23	6.8747	7.0016	6.8747	6.4301	6.9456	6.07	6.2094
24	6.3272	6.7638	6.8896	6.8747	6.4301	6.9456	6.1214
Max	6.8747	7.0016	8.8706	6.8747	6.9456	6.9456	6.2094
Min	4.784	5.2115	3.8649	4.3799	4.9897	3.7037	4.7325
Avg	5.8677	6.0824	6.2553	5.8112	5.9169	5.5642	5.3926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024029 / 33 KV Mohata Sub Station

Feeder No / Name : 402 / 33KV MOHATA TO VIDYUT B
S/S O/ Feeder KV- 33 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.5974	13.8272	13.5277	13.3471	13.4602	13.0944	12.4314
2	12.8772	12.8739	12.867	12.7983	12.6887	12.3685	11.6084
3	12.0542	12.2634	12.0039	11.845	11.8828	11.7078	10.8196
4	11.454	11.4472	11.3432	11.4129	11.1969	11.094	10.1166
5	10.7339	10.9053	10.7979	10.8024	10.4767	10.3338	9.6194
6	10.1509	10.3292	10.0377	10.192	9.8252	9.7977	8.9335
7	9.345	9.4925	9.3427	9.3896	9.225	8.8192	8.179
8	8.522	8.7654	8.7598	8.5803	8.4363	8.2922	7.596
9	8.4191	8.5254	6.973	8.6009	8.6786	8.2362	7.4074
10	8.6592	8.6191	4.7942	9.2318	9.1335	8.778	7.8395
11	10.1372	9.4513	10.9808	10.048	10.0435	9.8251	8.251
12	11.1591	10.6447	16.0357	10.4801	10.1464	10.1852	8.5117
13	11.7558	11.1682	22.7435	10.9396	11.0437	10.9911	9.321
14	12.2771	12.1902	20.583	11.8656	11.6359	9.7565	10.1715
15	12.8327	13.1938	13.3676	12.5858	12.228	11.5741	10.8505
16	13.4157	13.4808	13.834	12.7916	12.4897	12.3457	11.2071
17	12.9493	12.9733	13.4773	12.5172	12.5366	12.26	10.9053
18	11.8519	12.0542	12.3251	11.7284	11.8793	11.4884	10.1372
19	10.8025	11.15	11.2757	11.0597	11.0905	10.2538	9.6228
20	11.214	10.9408	11.262	11.094	11.1808	10.3567	9.9246
21	11.7558	11.5455	11.3855	11.3169	11.206	10.4253	10.3909
22	12.4142	11.8164	11.4952	11.6941	11.4175	10.7511	10.7613
23	13.5528	12.7012	12.8189	12.7229	12.6577	11.8313	11.5981
24	14.0261	13.6832	13.6958	13.6968	13.0315	12.8852	11.9685
Max	14.0261	13.8272	22.7435	13.6968	13.4602	13.0944	12.4314
Min	8.4191	8.5254	4.7942	8.5803	8.4363	8.2362	7.4074
Avg	11.4982	11.4184	12.3220	11.2809	11.1496	10.7271	9.9238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 201 / 11KV Washim NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17
HR	Load (MW)	Load (MW)
1	1.3336	1.3336
2	1.3336	1.3336
3	1.3336	1.3336
4	1.2955	1.3336
5	1.2574	
6	1.2193	
7	1.2193	
8	1.2193	
9	1.1431	
10	1.105	
11	1.1812	
12	1.2384	
13	1.2384	
15	1.2574	
16	1.2384	
17	1.2574	
18	1.2384	
19	1.3336	
20	1.3336	
21	1.4289	
22	1.3717	
23	1.3717	
24	1.3717	1.3336
Max	1.4289	1.3336
Min	1.105	1.3336
Avg	1.2748	1.3336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 241 / 11 KV COLLECTOR OFFICE I/C

NO. Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17
HR	Load (MW)	Load (MW)
1	1.3336	1.3336
2	1.3336	1.3336
3	1.3336	1.3336
4	1.2955	1.3336
5	1.2574	
6	1.2193	
7	1.2193	
8	1.2193	
9	1.1431	
10	1.1241	
11	1.2003	
12	1.2574	
13	1.2574	
15	1.2574	
16	1.2384	
17	1.2574	
18	1.2384	
19	1.3336	
20	1.3336	
22	1.3717	
23	1.3717	
24	1.3717	1.3527
Max	1.3717	1.3527
Min	1.1241	1.3336
Avg	1.2713	1.3374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 242 / 11KV COLLECTOR OFFICE I/C
NO.2 Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17
HR	Load (MW)	Load (MW)
1	.0191	.0191
2	.0191	.0191
3	.0191	.0191
4	.0191	.0191
5	.0191	
6	.0191	
7	.0191	
8	.0191	
9	.0191	
10	.0191	
11	.0191	
12	.0191	
13	.0191	
15	.0191	
16	.0191	
17	.0191	
18	.0191	
19	.0191	
20	.0191	
21	.0191	
23	.0191	
24	.0191	.0191
Max	.0191	.0191
Min	.0191	.0191
Avg	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024045 / 33/11 KV Collector Office

Feeder No / Name : 401 / 33KV APATAPA TO COLLECTOR

I/C Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17
HR	Load (MW)	Load (MW)
1	1.3146	1.4861
2	1.3146	1.4861
3	1.3146	1.4861
4	1.2574	1.4861
5	1.2574	
6	1.2003	
7		1.4289
8	1.3146	
9	1.3146	
10	1.3146	
11	1.2003	
12	1.2003	
13	1.3146	
15	1.2574	
16	1.3146	
17	1.3146	
18	1.3146	
19	1.3146	
20	1.4289	
21	1.4289	
22	1.4289	
23	1.4289	
24	1.3717	1.4861
Max	1.4289	1.4861
Min	1.2003	1.4289
Avg	1.3146	1.4766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 201 / 11KV Bhim Nagar Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.8745	.8573	.8573	.8573	.8573	.8573
2	.8573	.8573	.8573	.8573	.8402	.8402	.823
3	.823	.8573	.8573	.8402	.823	.8402	.823
4	.823	.8402	.8573	.823	.823	.823	.7888
5	.8402	.823	.8059	.8059	.823	.8059	.7888
6	.823	.7888	.823	.7716	.7888	.7545	.8059
7	.7888	.7716	.823	.7545	.7716	.7545	.7888
8	.7545	.7545	.8059	.7545	.7202	.7716	.7202
9	.6859	.703	.0686	.7373	.7202	.7202	.7202
10	.6516	.6516	.6859	.6344	.6859	.6516	.6516
11	.6344	.6516	.703	.6859	.6173	.6516	.5144
12	.6859	.6859	.703	.6859	.6687	.6859	.5658
13	.6516	.6687	.6859		.6173	.6687	
14	.6859	.703	.6687	.6687	.6344	.6687	.6516
15	.703	.6516	.7202	.6516	.6687	.6516	.6516
16	.6859	.6859	.6859	.6516	.6687	.6687	.6516
17	.6859		.6859	.6516	.6859	.6173	.6173
18	.6859	.6344	.703	.6516	.6516	.6173	.4458
19	.7202	.7545	.7716	.7373	.7545	.7202	
20	.7888	.823	.823	.823	.7888	.7545	.7545
21	.7888	.823	.8059	.823	.8059	.7888	.7545
22	.8573	.8916	.8402	.8573	.8573	.823	.7888
23	.9259	.9259	.8745	.8916	.8745	.9259	.823
24	.9259	.8916	.8916	.8745	.8745	.8916	.8916
Max	.9259	.9259	.8916	.8916	.8745	.9259	.8916
Min	.6344	.6344	.0686	.6344	.6173	.6173	.4458
Avg	.7652	.7701	.7502	.7604	.7509	.7480	.7217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 204 / 11KV Bhandpura Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	21-MAY-17
HR	Load (MW)
19	1.5089
20	2.332
21	2.2634
22	2.1948
23	2.1948
Max	2.332
Min	1.5089
Avg	2.0988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
staFeeder No / Name : 205 / 11 KV Ganesh Nagar Feeder
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1262	2.0919	1.9719	1.9719	2.0576	2.0405	1.989
2	2.0576	1.9719	1.9719	1.8861	1.989	1.9719	1.8519
3	1.989	1.8861	1.9719	1.8004	1.8861	1.8861	1.7147
4	1.9204	1.8519	1.9719	1.749	1.8176	1.8004	1.6461
5	1.7318	1.8004	1.6632	1.7318	1.7318	1.7147	1.6118
6	1.5604	1.5947	1.4918	1.5089	1.6118	1.5089	1.4403
7	1.4232	1.5089	1.406	1.4403	1.4232	1.4918	1.3889
8	1.4232	1.4746	1.4232	1.406	1.3546	1.4575	1.3546
9	1.406	1.3889	1.3717	1.3375	1.3717	1.3889	1.406
10	1.3032	1.3032	1.3375	1.3375	1.3375	1.3546	1.286
11	1.286	1.3889	1.3546	1.3546	1.3546	1.3717	1.3375
12	1.4746	1.4746	1.3717		1.5432	1.5432	1.4232
13	1.5604	1.5775	1.4918	1.5261	1.5432	1.5261	1.5261
14	1.8004	1.7147	1.7147	1.6975	1.6975	1.6632	1.6632
15	1.8347	1.6461	1.7833	1.8176	1.8176		1.7318
16	1.8347	1.7661	1.869	1.8347	1.7661	1.8347	1.6975
17	1.6975		1.6632	1.6289	1.6118	1.6118	1.6289
18	1.5604	1.6632	1.5432	1.4575	1.5089	1.4746	1.3032
19	1.6804	1.6804	1.6289	1.6118	1.6461	1.6289	1.6461
20	1.8519	1.7833	1.7661	1.7661	1.8004	1.7833	1.7147
21	1.9033	1.8519	1.7661	1.8519	1.869	1.8176	1.749
22	2.0576	1.989	1.9719	1.989	2.0062	1.9204	1.9033
23	2.2291	2.1948	2.1262	2.1262	2.1434	2.0919	2.0748
24	2.2119	2.2462	2.1434	2.0919	2.1262	2.1262	2.1091
Max	2.2291	2.2462	2.1434	2.1262	2.1434	2.1262	2.1091
Min	1.286	1.3032	1.3375	1.3375	1.3375	1.3546	1.286
Avg	1.7468	1.7326	1.6990	1.6923	1.7090	1.6960	1.6332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
sta

Feeder No / Name : 206 / 11 KV Shivcharan Peth

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5316	.5144	.5144	.5144	.5316	.5144
2	.5316	.5144	.5144	.4801	.4973	.5144	.4801
3	.4973	.5144	.5144	.4801	.4973	.4973	.4801
4	.4973	.4973	.5144	.463	.4801	.4801	.4458
5	.4801	.4801	.4458	.4458	.463	.4801	.4458
6	.4458	.463	.3944	.3772	.4115	.4287	.4115
7	.3944	.4287	.3944	.3601	.3772	.4115	.3772
8	.3772	.4287	.3772	.3429	.3601	.3944	.3772
9	.3601	.3772	.3772	.3429	.3429	.3772	.3429
10	.3429	.3772	.3772	.3601	.3601	.3881	.3601
11	.4287	.4115	.3944	.3944	.3944	.3944	.3944
12	.4115	.4287	.4115	.4115	.4458	.4458	.4287
13	.463	.4458	.4458	.4287	.4458	.4287	.4115
14	.463	.4458	.463	.463	.463	.463	.4458
15	.463	.3772	.5144	.5144	.4973		.4287
16	.4801	.4801	.5144	.4801	.4973	.4973	.4287
17	.4801		.463	.463	.4458	.4287	.4458
18	.463	.4287	.463	.4458	.4458	.4287	.3086
19	.5144	.463	.4973	.4458	.463	.463	
20	.5316	.5144	.4973	.4801	.463	.4801	.6001
21	.5144	.4973	.463	.4973	.4458	.4801	.5658
22	.5487	.5658	.4973	.4801	.4801	.5144	.583
23	.5658	.5658	.5316	.583	.5316	.5487	.6173
24	.583	.5658	.5658	.5316	.5487	.5487	.5487
Max	.583	.5658	.5658	.583	.5487	.5487	.6173
Min	.3429	.3772	.3772	.3429	.3429	.3772	.3086
Avg	.4751	.4697	.4644	.4494	.4530	.4620	.4540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-I S/DN[275] BU 4275

Substation No/ Name :- 024048 / 33/11 KV Shivaji Nagar Sub-
sta

Feeder No / Name : 401 / 33 KV INCOMER

Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4979	3.3436	3.0864	3.2407	3.2922	3.1379	3.1893
2	3.3436	3.2407	3.0864	3.0864	3.1893	3.0864	2.9835
3	3.1893	3.1379	3.3436	2.9835	3.0864	2.9835	2.8807
4	3.0864	3.0864	3.3436	2.9321	2.9835	2.9321	2.7778
5	2.9835	2.9835	2.7263	2.8807	2.8807	2.7778	2.6749
6	2.7263	2.7778	2.572	2.572	2.7263	2.572	2.572
7	2.5206	2.6235	2.4691	2.4177	2.5206	2.4691	2.4691
8	2.4691	2.572	2.4177	2.3663	2.4691	2.4177	2.3148
9	2.2119	2.4177	2.4177	2.3148	2.2634	2.3663	2.3663
10	2.2119	2.2634	2.3148	2.2634	2.3148	2.2634	2.2634
11	2.1605	2.3663	2.3663	2.3663	2.3148	2.3148	2.1605
12	2.4691	2.4691	2.3663	2.3663	2.3148	2.3663	2.2634
13	2.572	2.572	2.572	1.8519	2.4177	2.4691	2.4177
14	2.7778	2.6749	2.7263	2.6749	2.6235	2.6749	2.6749
15	2.8292	2.6235	2.8807	2.8292	2.7778		2.6749
16	2.8292	2.7778	2.9321	2.7778	2.7778	2.8292	2.6749
17	2.7263		2.7778	2.6749	2.6749	2.572	2.5206
18	2.5206	2.3663	2.5206	2.4691	2.5206	2.3663	2.3148
19	2.6749	2.9321	2.6749	2.6235	2.7263	2.6749	2.7778
20	3.1893	2.9321	2.9321	2.8807	2.8807	2.8807	5.3498
21	3.1893	2.9835	2.8807	3.035	2.8807	2.8292	5.1955
22	3.2407	3.1893	3.1379	3.1893	3.0864	3.0864	5.3498
23	3.2922	3.3951	3.2922	3.3951	3.2922	2.7263	5.5556
24	3.6008	3.4979	3.2922	3.2922	3.3951	3.2922	3.2922
Max	3.6008	3.4979	3.3436	3.3951	3.3951	3.2922	5.5556
Min	2.1605	2.2634	2.3148	1.8519	2.2634	2.2634	2.1605
Avg	2.8464	2.8359	2.7971	2.7285	2.7671	2.6995	3.0714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 201 / 11 KV KHADKI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.959	5.9507	5.892	6.1085	6.092	5.9839	5.9027
2	5.8263	5.708	5.5548	5.8859	5.8581	5.7366	5.6241
3	5.7263	5.4534	5.3521	5.6771	5.6386	5.5601	5.4382
4	5.3791	5.1635	5.1738	5.479	5.3581	5.216	5.2042
5	5.2385	4.9988	5.0429	5.026	5.0725	5.0397	4.8873
6	4.9973	4.8045	4.7354	4.7402	4.7638	4.638	4.4079
7	4.6591	4.2722	4.2953	4.2821	4.2204	4.2318	3.9956
8	3.9419	3.8798	3.9333	3.8676	3.8493	3.7548	3.687
9	1.9608	3.6496	3.6705	3.8005	3.8561	3.682	3.6187
10	3.7712	3.8242	3.794	3.6976	3.8502	3.7349	3.6565
11	3.8409	3.8496	3.7228	3.7357	3.8675	3.5616	3.6454
12	2.0828	4.0474	3.9292	3.8789	4.0748	3.8797	3.9705
13	2.3144	4.4454	4.3126	4.0748	4.4917	4.3511	4.2798
14	2.5453	4.7416	4.707	4.8796	4.8728	4.6784	4.6845
15	2.6787	4.952	4.9371	5.0716	5.041	4.9764	5.0526
16	2.7587	2.5766	4.947	5.064	5.0383	5.1644	5.0914
17	5.0138	4.9849	4.8088	4.7725	4.7813	2.569	5.0225
18	4.499	4.4601	4.3881	4.2844	4.5648	2.3716	4.5614
19	4.6937	4.6807	4.51	4.3507	4.5809	2.3129	4.4945
20	5.2991	5.3736	4.9996	5.2031	5.2435	2.6741	5.0276
21	5.7263	5.7626	5.6828	5.4908	5.66	2.8327	5.218
22	6.2307	6.0243	6.092	6.1081	6.0342	3.043	5.5014
23	6.531	6.2681	6.4145	6.5341	6.3074	3.2922	5.8284
24	6.2148	6.294	6.1359	6.3531	6.3557	6.1523	5.9911
Max	6.531	6.294	6.4145	6.5341	6.3557	6.1523	5.9911
Min	1.9608	2.5766	3.6705	3.6976	3.8493	2.3129	3.6187
Avg	4.4954	4.8402	4.8763	4.9319	4.9780	4.1432	4.7830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 202 / 11 KV MALKAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6196	.6378	.5704	.612	.6485	.6553	.5766
2	.5765	.5913	.5575	.6139	.6157	.62	.5466
3	.5574	.5559	.5502	.2995	.6051	.5681	.5052
4	.522	.5297	.5323	.2843	.5495	.5133	.4633
5	.5106	.4957	.5072	.2667	.5293	.4873	.4173
6	.4755	.4729	.4734	.253	.4672	.4474	.4005
7	.2446	.4645	.4601	.2454	.4527	.4561	.3898
8	.4092	.4375	.453	.2347	.4573	.4405	.3376
9	.2202	.4515	.3928	.2088	.4134	.4276	.3814
10	.3784	.4391	.3879	.3769	.3811	.4197	.4081
11	.3689	.4544	.3989	.3799	.3906	.4313	.3849
12	.2058	.4726	.4119	.455	.391	.4435	.3963
13	.2667	.4923	.4626	.4656	.431	.4713	.5053
14	.2843	.4938	.516	.5112	.5085	.5053	.5381
15	.2873	.4969	.5445	.5135	.5311	.5122	.5378
16	.2865	.2835	.516	.5061	.5403	.4855	.5266
17	.4588	.4403	.4917	.4645	.4908	.2439	.5178
18	.4149	.4595	.4382	.4645	.4652	.2416	.538
19	.5022	.4969	.4938	.5193	.5388	.2774	.5188
20	.5681	.4952	.578	.5841	.5982	.3048	.5422
21	.6424	.5607	.5912	.6314	.636	.3262	.5731
22	.65	.6257	.6601	.68	.6809	.3437	.5906
23	.6607	.6154	.6971	.6684	.7171	.3643	.5777
24	.6402	.6607	.3406	.6604	.6686	.671	.6057
Max	.6607	.6607	.6971	.68	.7171	.671	.6057
Min	.2058	.2835	.3406	.2088	.3811	.2416	.3376
Avg	.4480	.5052	.5011	.4541	.5295	.4441	.4908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 241 / 11 KV INCOMER NO-I

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.1523	5.8668	5.6897	6.0501	5.94	5.9138	5.6333
2	3.12	5.6946	5.4892	5.8604	5.7244	5.6359	5.4268
3	6.0542	5.4638	5.2803	5.7301	5.5724	5.4478	5.2317
4	2.9401	5.2225	5.16	5.547	5.2513	5.1155	4.9878
5	5.6272	5.0598	4.8823	5.1757	4.8996	4.8083	4.657
6	2.6414	4.7737	4.4829	4.7936	4.4347	4.3146	4.0908
7	4.9245	4.478	4.0859	4.4913	3.9919	4.0074	3.7235
8	4.8591	4.0996	3.8272	4.2232	3.8031	3.6763	3.5864
9	1.9768	3.7673	3.7258	3.9678	3.9363	4.2078	3.9605
10	3.8074	3.8211	3.8416	3.7056	4.3766	4.7843	4.5732
11	3.8958	3.9826	3.8024	3.7887	4.8366	4.6725	4.7165
12	2.3076	4.2845	4.2246	3.9815	2.7176	5.1608	5.1065
13	2.5347	4.6586	4.5287	4.5831	5.551	2.806	5.4831
14	2.6566	4.8941	4.8922	5.0617	3.0102	5.4489	5.6767
15	2.742	5.0221	4.9741	5.0691	5.8749	5.8219	5.9763
16	2.681	2.5271	4.8636	5.0914	5.66	5.9138	5.6135
17	4.7656	2.3365	4.5892	4.4765	5.2671	2.7023	5.2644
18	4.4924	2.3853	2.2695	4.3202	4.5112	2.3228	4.4198
19	5.0278	5.061	4.9154	4.7787	4.9508	2.6612	4.8587
20	5.4798	2.9172	2.8441	5.4188	5.3963	2.806	2.6871
21	6.0441	5.8787	3.0559	5.7145	5.8958	3.0087	5.4092
22	6.4594	6.2017	3.2556	6.4381	6.2586	3.251	3.1139
23	6.5394	3.2693	3.2297	6.5203	6.3043	3.1885	3.184
24	6.017	6.1751	6.0235	6.2574	6.2491	6.0623	5.9184
Max	6.5394	6.2017	6.0235	6.5203	6.3043	6.0623	5.9763
Min	1.9768	2.3365	2.2695	3.7056	2.7176	2.3228	2.6871
Avg	4.3228	4.4934	4.3306	5.0435	5.0172	4.3224	4.7208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 242 / 11 KV INCOMER NO-II

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9875	1.909	.9602	1.7284	1.0166	.9945	.8745
2	1.0059	1.8576	1.8541	1.7005	.9991	.9602	.8573
3	1.869	1.8404	.9602	1.6826	.9496	.9259	.8573
4	.9602	1.7776	1.8259	1.619	.9568	.8916	.823
5	1.8347	1.7604	.9145	1.5746	.9465	.9431	.8059
6	.9145	1.7604	1.7277	1.5194	.929	.9088	.8059
7	1.789	1.7489	.8688	1.4737	.9134	.8916	.8402
8	1.789	1.6975	1.7627	1.4815	1.0374	.9088	.8059
9	.9602	1.869	1.0059	1.8557	.9882	.9138	.8962
10	1.8718	1.9094	2.0004	1.9871	.9465	1.0277	.9145
11	1.7696	1.9631	2.0347	1.9397	.964		.9522
12	.9602	1.8099	1.9318	1.8919		1.0056	.8328
13	.9145	1.8279	1.8233	2.0347	.929		.9242
14	1.0517	1.9471	2.0634	2.248		1.134	1.1431
15	1.0059	1.9471	2.0291	2.2672	1.0229	1.0985	1.1128
16	1.0974	1.0059	1.9833	2.2447	1.0341	1.0288	1.1317
17	2.0462	1.7741	1.0517	2.0291	1.0288		2.3095
18	2.0176	.9602	2.0158	2.0004	.9431		2.0233
19	1.9547	1.7724	1.9753	1.9661	.8916		1.9894
20	2.0291	.9145	1.9936	2.1262	.9431		1.0517
21	2.0805	1.7793	1.9936	2.1091	.9945		1.8993
22	2.0805	1.9046	2.0942	2.1034	1.046		1.0059
23	2.0634	1.0517	2.1125	2.0834	1.0288		1.0517
24	2.0225	2.0634	1.9699	2.1003	1.0277	1.0117	1.989
Max	2.0805	2.0634	2.1125	2.2672	1.046	1.134	2.3095
Min	.9145	.9145	.8688	1.4737	.8916	.8916	.8059
Avg	1.5865	1.7021	1.7064	1.9069	.9789	.9763	1.1624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 401 / 33KV I/C Khadki feeder

Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		12.7572		14.0924	14.5954	13.9918	13.1402
2	12.7572	12.3971	13.8295	13.9346	14.3759	13.6831	13.0316
3		11.9342		13.5665	13.8603	13.3231	12.8144
4	12.1188	11.677	12.5675	13.2356	13.3882	12.9115	12.6515
5		11.4198		12.5978	13.0842	12.5	12.4886
6		10.9568	11.7787	12.0662	12.5297	11.8313	12.38
7	11.0425	10.4424		11.4283	9.7668	11.4712	12.0542
8	10.0309	9.928	11.0265	11.0563	10.6996	10.9568	11.5112
9		9.465	10.1338	10.9499	8.7814	7.9218	11.5112
10	10.4253	9.2021	10.8025	11.1934	10.4641	8.8769	11.7827
11	9.8686	9.5679	10.1338	10.974	11.7261		11.9456
12		8.7814	10.4938	11.358		10.727	12.5652
13		10.5693	10.6996	11.358	12.252		13.0316
14		12.3571	12.1914	12.38		11.1111	13.7917
15	9.9932	12.5149	12.6029	13.3031	13.2356	11.5158	11.9456
16			12.7058	13.1687	13.2356	12.2497	12.2171
17	10.6996	13.1687	13.0287	11.8313	12.4486		11.7787
18	10.3395		12.013	11.4198	11.5226		3.3653
19	11.0597	13.2705	12.8944	12.2428	12.3457		3.2247
20	11.8827		13.3951	13.4259	13.3231		
21	12.3457	13.8295	13.9798	13.5288	13.6831		3.5231
22	13.3745	14.0432	14.6708	15.3018	14.3519		
23	13.9918		15.096	15.8562	14.8663		
24	12.7572	13.4259	14.4593	14.3027	15.3635	14.3519	13.3574
Max	13.9918	14.0432	15.096	15.8562	15.3635	14.3519	13.7917
Min	9.8686	8.7814	10.1338	10.9499	8.7814	7.9218	3.2247
Avg	11.5125	11.5854	12.4251	12.6905	12.7227	11.8282	11.1482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 402 / 33 KV DABAKI-NIMBI O/G NON SHEDDABLE WATER SUPPLY AND
FEEDER Feeder KV- 33 / INCOMING UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.1495	9.0021	11.2026	10.5304	10.8642	10.1338	9.3936
2		8.7449		10.3692	10.6447	9.9794	9.2307
3	9.5782	8.4362	10.0995	10.1006	10.2058	9.7737	9.1335
4		8.3333		9.7245	9.8766	9.6194	9.1873
5	8.6877	8.1276	9.3827	9.4022	9.6571	9.2593	9.3936
6		7.7161		9.0798	9.2181	8.7963	9.4479
7	7.9561	7.3045		8.7037	6.9136	8.5905	9.3393
8	6.893	7.0988	8.6877	8.3814	7.9561	8.2819	8.6877
9		6.7387	7.5617	8.0796	6.1128	5.1955	8.742
10	6.9102	6.7507	7.9218	8.5048	7.4417	5.5813	8.6877
11	6.857	6.9633	7.4589	8.2533	8.65		8.8506
12		6.2191	7.6132	8.4499		7.2817	9.0135
13		7.7606	7.7161	8.0659	8.7289		9.2307
14		9.3021	8.8477	8.7963		7.7298	9.7737
15		9.249	9.2593	9.5565	9.3021	7.7075	7.8732
16			9.4136	9.1221	9.4616	8.1664	8.2533
17	7.4074	9.1564		8.642	8.6934		7.9927
18	7.3045			8.3848	8.4877		.1017
19	7.8189	9.6742	9.8766	9.2078	9.2593		
20	8.3333		10.4801	9.8251	9.8766		
21	8.4877	10.1486	10.2058	9.8766	9.928		.1052
22	9.2593	10.4544	10.6842	11.1386	10.3395		
23	9.7737		11.1094	11.4129	10.8025		
24	9.1021	9.3622	10.727	10.7453	11.3032	10.3395	9.3393
Max	9.7737	10.4544	11.2026	11.4129	11.3032	10.3395	9.7737
Min	6.857	6.2191	7.4589	8.0659	6.1128	5.1955	.1017
Avg	8.2346	8.3271	9.3471	9.3481	9.2602	8.4291	8.0889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.1516	13.1516	10.1338	13.1893	13.155	13.0659	12.8133
2	10.0995	12.5858	12.196	12.7435	12.5846	12.4828	12.1456
3	12.8944	12.2085	9.2421	12.3252	12.0656	12.0199	11.6147
4	9.7565	11.797	11.5198	12.0473	11.4347	11.4884	11.1357
5	12.1571	11.3684	8.6591	11.3752	11.1089	11.1283	10.5893
6	9.2593	11.0597	10.5761	10.9534	10.5704	10.5282	9.8211
7	11.1797	10.3738	7.6646	10.5178	9.5113	9.5336	9.034
8	10.3395	9.5507	8.9249	9.5783	8.6122	8.7106	11.3329
9	7.8532	8.6592	8.1791	9.201	6.2757	8.0419	7.8361
10	9.289	8.426	8.2476	8.6626	6.5672	8.5768	8.2613
11	8.1024	8.043	8.1619	7.8406	9.3942	7.7675	9.7943
12	6.3958	8.2253	8.1961	8.035	7.2188	10.5282	10.279
13	6.7387	8.8729	8.762	8.5545	10.8254	8.642	11.0426
14	7.5789	9.6147	9.7051	9.7994	8.8306	11.8176	11.7227
15	8.2476	10.1852	10.4253	10.4869	12.34	11.9478	12.3457
16	8.642	8.0247	10.6653	10.7459	12.1759	12.5321	12.5806
17	10.9739	8.1104	10.4458	10.4252	11.9341	9.7565	12.2554
18	10.1681	7.7846	9.8576	9.7566	11.3855	9.7051	9.3964
19	9.7051	7.2531	9.3175	8.9849	9.6193	7.2702	7.5446
20	11.0597	8.0418	10.4355	10.4252	10.7511	8.1619	8.0076
21	11.7284	11.7375	11.3443	11.2655	11.6084	8.882	11.1214
22	12.5857	9.465	9.3279	12.3	12.3628	9.2936	9.0364
23	13.6146	10.2023	13.131	13.3374	13.2716	9.9794	9.808
24	13.4396	13.5631	13.1025	13.6419	13.486	13.5116	12.7955
Max	13.6146	13.5631	13.131	13.6419	13.486	13.5116	12.8133
Min	6.3958	7.2531	7.6646	7.8406	6.2757	7.2702	7.5446
Avg	10.2067	9.9293	9.9259	10.6747	10.7121	10.2238	10.5131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024024 / 33 KV KHADKI S/SN

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO- SHEDDABLE RURAL
II Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9774		.8413	1.0208	.9774	.9522
2		.9259	.8939	.8413	1.0208	.9774	.8962
3	.8745	.9259		.8413	1.0317	.9259	.9522
4		.9259	.9036	.7888	.9774	.8745	.8962
5		.8745			.9568	.9259	.8402
6		.8745	.9231	.6836	.9568	.9259	.8962
7	.8745	.9259		.6836	.9134	.8745	.8962
8	.8745	.8745	.8939	.691	1.0185	.9259	.8402
9		.9259	.823			.9259	.8962
10	.9054	.9328	.9774	1.0185		1.0099	.9522
11	.8551	.9774	.8745	.9979	.9362		.9425
12		.8688	.9259	.9979		.9665	.8688
13		.9231	.9259	1.0185	.9036		.9054
14		.8779	1.0288	1.1317			1.1317
15		.9231	.9774	1.1317	1.0517	1.0517	1.1317
16			.9774	1.1317	1.0517	1.0517	1.1317
17	.9774		1.0082	.9774	1.0288		1.0402
18	1.0288		2.1845	.9774	.9259		
19	1.0288		.9328	.9774	.8745		
20	.9774		7.572	1.0288	.9259		
21	1.0288	.8842	8.7792	1.0288	.9774		.8939
22	3.0864		9.3279	1.0631	1.0288		
23	1.0288		9.6571	1.0425	1.0288		
24	.9665	1.0288	.9465	.9465	1.0317	1.0288	.9522
Max	3.0864	1.0288	9.6571	1.1317	1.0517	1.0517	1.1317
Min	.8551	.8688	.823	.6836	.8745	.8745	.8402
Avg	1.1023	.9204	2.5767	.9473	.9831	.9601	.9482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 201 / 11 KV FEEDER NO.1

Feeder KV- 11 / OUTGOING

DATE	17-MAY-17	18-MAY-17
HR	Load (MW)	Load (MW)
1		.4001
9		.5144
17	1.0098	
Max	1.0098	.5144
Min	1.0098	.4001
Avg	1.0098	.4573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 204 / TRANSPORT NAGAR

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381			.0191	.019	.019
2		.0381			.0191		.019
3		.0191			.0191		.019
4		.0191			.0191		.019
5		.0191			.0191	.019	
6		.0191			.0191		
7		.0191			.0191		
8					.0191		
9			.0191				
10		.0381	.0191				
11	.0381	.0381		.038	.0381	.0572	
12	.0381	.0381			.0381		
13	.0381	.0404	.0191	.038	.0404	.0572	.0191
14	.0381	.0404	.0191	.038	.0381	.0381	.0191
15	.0381	.0381	.0396	.038	.0381	.0381	.0191
16	.0381	.0381	.0381	.0381	.0381	.0572	.0191
17	.0381	.0381	.0572	.038	.038	.0381	.0191
18	.0381	.0572	.0572	.0381	.038	.0381	.0381
19	.0381	.0381	.0381	.0381	.038	.0381	.0381
20		.0381	.0381	.0381	.038	.0381	.0381
21	.0381	.0191	.0381	.0381	.038	.0381	.0191
22	.0381	.0191	.0381	.0381	.038	.038	.0191
23	.0381	.0191	.0191		.038	.019	.0191
24		.0381			.0191	.019	.019
Max	.0381	.0572	.0572	.0381	.0404	.0572	.0381
Min	.0381	.0191	.0191	.038	.0191	.019	.019
Avg	.0381	.0323	.0338	.0381	.0304	.0368	.0226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 205 / 11KV NARAYAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6645	.6112	.5677	.6074	.5654	.5891	.5494
2	.663	.6181	.5708	.599	.554	.5883	.5441
3	.6585	.6226	.5731	.6028	.551	.5967	.5205
4	.6554	.6082	.5708	.5998	.5472	.5906	.5182
5	.6592	.6066	.5692	.5975	.5449	.5914	.5198
6	.6607	.6279	.5883	.5753	.554	.5853	.5175
7	.6806	.6104	.5639	.5944	.5304	.6058	.5296
8	.6783	.6043	.5593	.6165	.5708	.6348	.5289
9	.676	.346	.3216	.7643	.3597	.791	.7079
10	.6737	.961	.9274	1.2453	1.2208	1.0837	1.0593
11	.6691	1.2209	1.355	1.5462	1.5241	1.3664	.6638
12	.6546	1.3961	.7743	.8505	1.5326	1.4358	.8002
13	.6645	1.2917	1.4503	1.4434	1.3634	1.2277	1.4997
14	.6485	1.1782	1.2567	1.3382	1.2537	1.1691	1.1012
15	.6371	1.2636	1.4594	1.5608	1.3992	1.3619	1.3725
16	.6287	1.2521	1.541	1.5401	1.5165	1.4503	1.5203
17	.6355	1.3123	1.5051	1.541	1.5554	1.4251	1.3809
18	.634	1.2057	1.3367	1.5074	1.6522	1.4625	1.3946
19	.6378	1.073	1.1317	1.3291	1.3604	1.3093	1.1713
20	.3346	.8946	.9373	.9693	.9609	.8924	.8566
21	.6249	.6759	.6973	.74	.6881	.5434	.6714
22	.6143	.5929	.5975	.6035	.6142	.5433	.6081
23	.6051	.57	.6074	.3117	.6714	.5441	.6013
24	.6279	.5952	.6104	.6104	.5799	.5701	.5868
Max	.6806	1.3961	1.541	1.5608	1.6522	1.4625	1.5203
Min	.3346	.346	.3216	.3117	.3597	.5433	.5175
Avg	.6369	.8641	.8780	.9456	.9446	.9149	.8427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 206 / 11 KV B.K. FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1143	.1905	.2286	.2096	.2286	.2477
2	.2096	.1143	.1905	.2286	.2096	.2286	.2477
3	.2096	.1334	.1905	.2286	.2096	.2286	.2477
4	.2096	.1905	.1905	.2286	.2096	.2286	.2477
5	.2096	.1905	.1905	.2286	.2096	.2286	.2477
6	.2096	.1334	.1715	.2286	.2096	.2286	.2286
7	.1905	.1334	.1905	.2096	.2096	.2286	.2286
8	.1715	.1334	.1905	.2286	.2286	.2477	.2477
9	.1715		.2286	.3048		.2286	.3429
10	.1905	.3429	.4191	.4763	.4572	.4001	.4954
11	.1715	.362	.5335	.5525	.4382	.4954	
12	.1715	.4191		.5906	.5335	.5144	
13	.1905	.381	.5144	.4954	.3429	.5144	.5716
14	.1715	.3048	.4763	.5335	.4191	.4382	.5335
15	.1715	.4382	.4954	.5144	.4954	.4572	
16	.2096	.4954	.5144	.5335	.4954	.4763	.5716
17	.1905	.4382	.5335	.5716	.4373	.5335	.5906
18	.1715	.4382	.4954	.5525	.5134	.5906	.5144
19		.4382	.4572	1.1431	.4373	.5716	.5335
20	.1715	.2858	.4001	.8192	.3613	.4954	.3429
21	.1143	.1905	.2477	.2477	.2662	.3239	.2667
22	.1143	.1905	.2286	.2477	.2472	.3048	.2286
23	.1334	.1905	.2286		.2472	.2858	.2286
24	.2286	.1334	.1905	.2477	.2286	.2472	.2852
Max	.2286	.4954	.5335	1.1431	.5335	.5906	.5906
Min	.1143	.1143	.1715	.2096	.2096	.2286	.2286
Avg	.1831	.2692	.3247	.4191	.3311	.3636	.3547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 207 / 11KV DADAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.1905	.4001	.4572	.5144	.3048	.381
2	.2858	.1905	.3048	.4954	.4763	.3048	.3429
3	.2858	.1905	.2667	.3429	.3429	.3048	.3239
4	.2858	.1905	.2477	.3048	.3429	.3048	.3239
5		.1905	.2477	.2858	.3429	.3048	.3239
6	.2858	.1905	.2477	.2858	.3239	.3048	.3048
7	.2667	.2096	.2477	.2858	.3429	.3048	.3239
8	.2096	.2096	.2286	.3048	.362	.3239	.3429
9	.2096		.5525	.6478		.7049	.5716
10	.1905	.9145	.9335	1.0669	.4572	1.0098	.8383
11	.1905	.9526	1.0669	1.086	1.2193	1.0479	
12	.2096	1.0479		1.1622	1.3336		
13	.1905	.7811	1.0288	.9907	.8764	.9526	.9526
14	.1905	.8573	1.0669	1.0098	.9907	1.0669	.8764
15	.2096	1.1622	1.0479	1.3146	1.1431	1.2574	.9526
16	.2096	1.1241	1.0479	1.1812	1.2574	1.3908	1.0098
17	.1905	1.2765	1.2193	1.2574	1.1408	1.2003	.9526
18	.2096	1.1431	1.0098	1.2574	1.0268	1.1431	.743
19	.2096	.9907	1.0669		.9887	.9907	.7811
20		.8002	.6859	.3429	.4944	.8573	.4954
21	.2096	.4763	.4763	.6859	.3613	.6859	.3429
22	.2096	.5335	.5335		.3042	.5525	.3239
23	.1905	.4954	.5335		.3042	.5335	.3239
24	.3429	.1905	.4382	.4572	.5144	.3042	.5894
Max	.3429	1.2765	1.2193	1.3146	1.3336	1.3908	1.0098
Min	.1905	.1905	.2286	.2858	.3042	.3042	.3048
Avg	.2312	.6221	.6478	.7249	.6722	.7024	.5646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 208 / 11KV YEVATA ROAD

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.1334	.1143	.2096	.2286	.1715	.1334
2	.1905	.1334	.1143	.1524	.2286	.1715	.1334
3	.1905	.1334	.1143	.1524	.1334	.1524	.1334
4	.1905	.1334	.1143	.1524	.1334	.1524	.1334
5	.1905	.0762	.1143	.1524	.1334	.1334	.1334
6	.2667	.1524	.1905	.1905	.2096	.2096	.1715
7	.2286	.1524	.1905	.2096	.2286	.1715	.1715
8	.1905	.1334	.1524	.1905	.2286	.1905	.1715
9	.1905		.1715	.2286		.2096	.1715
10	.1524	.2286	.381	.3048	.4001	.4191	.2286
11	.1143	.4001	.4954	.4382	.3429	.4763	
12	.0953	.362		.5144	.381	.381	
13	.0953	.3048	.4763	.4572	.3429	.362	.3048
14	.0762	.3239	.381	.3429	.3048	.381	.2667
15	.0762	.381	.4572	.4382	.362	.4954	.3429
16	.0953	.4001	.4954	.4191	.4191	.4191	.362
17	.0953	.4191	.5335	.4572	.4183	.3239	.381
18	.0953	.4001	.4191	.381	.3042	.3239	.4001
19		.4001	.4191	.381	.3613	.3048	.3239
20	.1715	.381	.381		.3232	.3429	.362
21	.1334	.2477	.2477	.1905	.2092	.2858	.2286
22	.1334	.1524	.2096	.1524	.1521	.1905	.1524
23	.1143	.1334	.2286		.1521	.1524	.1524
24	.1524		.1524	.1715	.2477	.2092	.1331
Max	.2667	.4191	.5335	.5144	.4191	.4954	.4001
Min	.0762	.0762	.1143	.1524	.1334	.1334	.1331
Avg	.1516	.2537	.2849	.2858	.2715	.2762	.2269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 241 / 11 KV INCOMER NO-I

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3239		.2858	.2858		.2858
2	.3239	.3239		.2858	.2667	.3048	.7049
3	.3239	.3239		.2858	.2667	.3048	.7049
4	.3239	.3239		.2858	.2667	.3048	.2667
5	.3239	.3239		.2858	.2858	.3048	.2477
6	.3239	.3048		.2667		.2858	.2477
7	.3239	.2858		.2858	.2667	.3048	.2667
8	.3239	.2858	.2667	.2858		.3239	.2667
9	.3239			.381		.4191	.381
10	.3239	.5716	.5144	.6478		.6287	.5716
11		.6478	.6668	.7811	.7811	.7621	
12	.3429	.7049		.7621	.724	.7621	
13		.5525		.7049	.5716	.5144	.743
14		.5906	.5716	.6668	.5716	.6097	.5525
15		.6478		.8002	.724	.724	.6668
16	.3429	.5906	.724	.743	.743	.743	.7621
17		.6478	.743	.724	.7606	.6668	.6097
18	.3429	.5906	.6097	.6668	.8366	.6859	.6478
19			.5335	.6097	.6084		.4954
20	.3429		.381		.3803	.381	.362
21	.3239		.3048	.3239	.3042		.3239
22	.3239		.3239	.3048	.3423	.3048	.3239
23	.4382		.3048		.3423	.2858	.3048
24	.3048	.3429	.2858	.2858	.2477	.3042	.3042
Max	.4382	.7049	.743	.8002	.8366	.7621	.7621
Min	.3048	.2858	.2667	.2667	.2477	.2858	.2477
Avg	.3334	.4657	.4792	.4850	.4788	.4726	.4564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 242 / 11 KV INCOMER NO-II

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.4382		.8954		.7049	.7621
2	.6859	.4382		.8764		.7049	.724
3	.6859	.4572		.724		.6859	.7049
4	.6859	.5144		.6859		.6859	.7049
5	.6859	.4572		.6668		.6668	.7049
6	.7621	.4763		.7049		.743	.7049
7	.6859	.4954		.7049	.7811	.7049	.724
8	.5716	.4763	.5716	.724		.7621	.7621
9	.5716			1.1812		1.1431	1.086
10	.5335	1.4861	1.7337	1.848		1.829	1.5623
11		1.7147	1.7147	2.0767	2.0005	2.0195	
12	.4763	1.829		2.2672		2.1338	
13		1.467		1.9433	1.5623	1.829	1.829
14		1.4861	1.9243	1.8861	1.7147	1.8861	1.6766
15		1.9814		2.2672	2.0005	2.21	
16	.5144	2.0195	2.0576	2.1338	2.1719	2.2862	
17		2.1338	2.2862	2.2862	2.0005	2.0576	1.9243
18	.5335	1.9814	1.9243		1.848	2.0576	1.6575
19			1.9433	2.0386	1.7909	1.6956	1.6385
20	.5525		1.467		1.1812	1.6956	1.2003
21	.4572		.9717	1.1241	.8383		.8383
22	.4572		.9717	.9145	.7049	1.0479	.7049
23	.4382		.9907		.7049	.9717	.2286
24	.724	.4572	.7811	.8764	.8383	.7621	1.0098
Max	.7811	2.1338	2.2862	2.2862	2.1719	2.2862	1.9243
Min	.4382	.4382	.5716	.6668	.7049	.6668	.2286
Avg	.6002	1.1283	1.4875	1.3726	1.4384	1.3601	1.0574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 401 / 33 KV INCOMER NO-I

Feeder KV- 33 / INCOMING

SHEDDABLE FEEDER MIDC EQUIVALENT

HAVING WEEKLY STAGGERING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5154	2.9378	3.9895	4.904	4.8925	4.0446	4.9383
2	3.0178	2.3091	3.8751	4.641	4.6982	4.0446	4.5267
3	2.8807	2.9378	4.0123	4.5267	4.4011	3.9189	4.4011
4	2.8121	2.995	3.4065	4.5382	4.0581	3.8504	4.0581
5	2.8121	2.995	3.3379	4.1267	3.9209	3.8524	3.9209
6	4.0352	2.995	3.4522	3.8524	3.9209	3.9095	3.9209
7	3.978	3.0636	3.5208	3.9209	4.0466	4.0466	3.9209
8	3.6123	3.075	3.4065	4.1152	4.2295	4.1038	3.9095
9	3.6351	2.6063	4.1267	5.1097	3.7037	4.9726	4.984
10	3.2121	6.5273	7.0988	8.1391	8.6877	7.8761	7.6704
11	3.3264	8.7906	10.0824	11.294	11.0997	10.4824	6.9273
12	3.2693	10.2653	8.5048	9.2593	11.957	11.3512	7.8189
13	3.2579	9.7509	11.0654	11.8999	11.2369	11.1911	10.391
14	3.2693	9.2593	10.8368	11.2826	10.3795	11.0883	9.4308
15	3.2008	9.7623	8.2991	11.454	10.2881	11.6256	9.7279
16	3.2579	11.134	11.8656	12.0485	11.557	12.22	10.8482
17	3.2693	11.1682	8.8477	12.5057	11.5172	11.9342	10.8825
18	3.2693	11.3169	11.8084	12.6772	11.323	11.9342	10.4824
19	2.4006	10.5053	10.7568	11.8885	10.9006	11.1112	9.7966
20	3.4522	9.1678	9.7165	10.3909	9.0847	10.0137	8.1276
21	3.2693	7.3617	7.8418	8.6306	7.1079	8.0476	6.5615
22	3.1322	4.9154	5.2927	5.7956	4.5247	4.8697	4.5953
23	3.0064	4.6525	4.9154	3.9781	4.0446	5.3726	4.1152
24	3.2236	4.0924	4.8583	4.8468	4.3438	3.9781	4.3984
Max	4.5154	11.3169	11.8656	12.6772	11.957	12.22	10.8825
Min	2.4006	2.3091	3.3379	3.8524	3.7037	3.8504	3.9095
Avg	3.2965	6.4410	6.8716	7.7427	7.3302	7.4933	6.6814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 402 / 33 KV INCOMER NO-II

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	19-MAY-17
HR	Load (MW)
12	6.7444
Max	6.7444
Min	6.7444
Avg	6.7444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.0572		.2858	1.2574	.9127	.8573
2	.3429			.2858	1.2003	.9127	.8573
3	.3429			.2858	.9717	.9127	.8002
4	.3429			.2858	.9717	.9127	.8002
5	.3429			.2858	.8002	.9145	.743
6	.3429			.2858	.8573	.8573	.743
7	.3429			.2858	.8002	.9145	.8002
8	.3429	.8573		.2858	.9145	.9717	.8002
9	.3429			.4001		1.2574	1.1431
10	.3429	.5716	1.5432	1.9433	.6287	.6287	
11		.6287	2.0005	2.3434	.8002	.743	
12		.6859		2.2862	.743	.743	
13		.5716	2.0005	1.9433	.5716	.5144	2.2291
14		.5716	1.7147	2.0005	.5716	.6287	
15		.6287		2.4006	.743	.743	
16		.5716	2.1719	2.2291	.743	.743	2.2862
17		.6287	2.2291	2.1719	2.2817	.6859	1.829
18	1.0288	.5716	.6287	2.0005	2.5098	2.0576	.6287
19			.5144		1.8253	1.7147	.5144
20			.2858	1.1431	1.1408		.3429
21				.9717	.9127	.8573	.3429
22			.3429		1.0268	.9145	.3429
23			.2858		1.0268	.8573	.2858
24	.2858	.9717		.2858	.5144	.9127	.9127
Max	1.0288	.9717	2.2291	2.4006	2.5098	2.0576	2.2862
Min	.2858	.0572	.2858	.2858	.5144	.5144	.2858
Avg	.3953	.6097	1.2470	1.1622	1.0353	.9265	.9084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024040 / 33 KV MIDC Phase IV Akola

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO- SHEDDABLE RURAL
II Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	1.3146		2.7435	2.8578	2.1105	2.2862
2	.6859			.8573	2.7435	2.1105	2.1719
3	.6859			.743	2.0576	2.0535	2.1148
4	.6859			.6859	2.0576	2.0535	2.1148
5	.6859			.6859	2.0576	2.0005	2.1148
6	.743			.6859	2.2291	2.2291	2.1148
7	.6859	1.4861		.6859	2.3434	2.1148	2.1719
8	.5144	.743		.6859	2.4577	2.2862	2.2862
9	.5716			1.2003		3.4294	3.2579
10	.5144	1.3717	5.2012	5.5441	1.8861	1.829	6.4015
11		1.7147	5.144	6.23	2.0005	2.0005	
12		1.829		6.8016	2.2291		
13		1.4861	6.0585	5.8299	1.5432	1.829	2.2291
14		1.4861	5.7728	5.6584	1.7147	1.8861	
15		1.9433		6.8016	2.0005	2.2291	
16		2.0005	6.1728	6.4015	2.1719	2.2862	2.2862
17		2.1148	6.8587	6.8587	5.9894	2.0576	5.7728
18	1.4289	2.0005	1.829	6.4015	5.533	6.1728	1.6575
19			1.9433		5.3619	5.6013	1.6575
20			1.4861	4.5725	3.5366		1.2003
21			.9717	3.3722	2.5098	3.8866	.8573
22			.9717		2.1105	3.1436	.6859
23			.9717		2.1105	2.915	.6859
24	.743	1.3146			.8573	2.2817	3.0232
Max	1.4289	2.1148	6.8587	6.8587	5.9894	6.1728	6.4015
Min	.5144	.743	.9717	.6859	.8573	1.829	.6859
Avg	.7288	1.6004	3.6151	3.6723	2.6243	2.6594	2.3545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 201 / 11KV TUKARAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.143	4.0323	3.9445	3.9058	3.9195	3.8967	3.8125
2	3.9338	3.8208	3.7652	3.7275	3.6694	3.673	3.5745
3	3.7639	3.5829	3.5756	3.5305	3.4933	3.5	3.3714
4	3.5532	3.3666	3.3394	3.3522	3.2994	3.2918	3.1227
5	3.2918	3.1432	3.1272	3.0522	3.0114	3.078	2.8658
6	2.8617	2.8251	2.6814	2.6347	2.6159	2.5949	2.5261
7	2.4995	2.5029	2.2804	2.3612	2.3008	2.2787	2.159
8	2.2651	2.3396	2.1893	2.2188	2.1695	2.1089	2.0563
9	2.236	2.2112	2.1451	2.1087	2.1388	2.1163	2.0245
10	2.2306	2.2049	2.1306	2.1586	2.1722	2.0624	2.0077
11	2.211	2.2337	2.1716	2.192	2.263	2.1988	2.2251
12	2.4004	2.4425	2.2724	2.3027	2.2975	2.4052	2.1118
13	2.8098	2.6974	2.6401	2.6246	2.6384	2.6065	2.4467
14	3.1251	3.0312	3.0049	3.0084	3.0312	2.9842	2.8272
15	3.3769	3.3352	3.2632	3.1904	3.2973	3.2897	3.198
16	3.4621	1.7063	3.2026	3.1929	3.2817	3.2051	3.2716
17	3.1692	3.1211	3.084	3.0552	3.0644	3.0198	3.047
18	2.7954	2.7811	2.7186	2.674	2.767	2.5818	2.5639
19	2.8691	2.8628	2.6915	2.7773	2.7355	2.6536	2.553
20	3.3542	3.2495	3.1004	3.182	3.1576	2.9569	2.9918
21	3.4535	3.339	3.3624	3.336	3.3125	3.2548	3.1336
22	3.7848	3.6884	3.5975	3.6711	3.6225	3.5029	3.4072
23	4.3413	4.104	4.1243	4.0662	4.1327	3.9994	3.7993
24	4.312	4.1727	4.1323	4.0868	4.0758	4.0306	3.9211
Max	4.3413	4.1727	4.1323	4.0868	4.1327	4.0306	3.9211
Min	2.211	1.7063	2.1306	2.1087	2.1388	2.0624	2.0077
Avg	3.1768	3.0331	3.0227	3.0171	3.0195	2.9704	2.8757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 202 / 11KV KOTHARI WATIKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0136	.9955	.9774	.9955	.9955	.9955	.9593
2	.9955	.9593	.9412	.9593	.9412	.9774	.905
3	.9412	.905	.905	.905	.905	.905	.8688
4	.9231	.8688	.8507	.8688	.8507	.8688	.8145
5	.8688	.8326	.8326	.8145	.7602	.8326	.7602
6	.724	.7421	.6878	.724	.6878	.724	.6878
7	.6878	.6335	.6335	.6516	.6154	.6335	.5792
8	.6154	.5973	.5973	.5973	.5792	.6516	.5792
9	.5792	.5792	.543	.5249	.5792	.6335	.5792
10	.6335	.6154	.5792	.5973	.5792	.5973	.543
11	.5973	.5973	.5792	.5792	.5792	.4706	.6154
12	.6154	.6154	.5973	.6335	.6516	.6878	.6335
13	.7421	.6516	.6697	.7059	.7059	.7421	.6878
14	.7964	.7602	.7682	.7783	.7421	.7964	.7964
15	.8869	.7964	.8507	.8145	.8145	.8145	.8507
16	.8688	.8326	.8145	.7964	.8326	.8145	.8145
17	.7964	.7421	.7602	.7783	.724	.7421	.7602
18	.6878	.6335	.6516	.6335	.6878	.6516	.6516
19	.7682	.7783	.7783	.7602	.7421	.7421	.7059
20	.8779	.8688	.8688		.8145	.8326	.8145
21	.9328	.905	.905	.9231	.8688	.8688	.8507
22	1.0059	.9955	.9955	.9955	.9955	.9593	.9774
23	1.1157	1.086	1.0679	1.1041	1.1041	1.086	1.0498
24	1.0679	1.0679	1.0317	1.0498	1.0498	1.0317	.9955
Max	1.1157	1.086	1.0679	1.1041	1.1041	1.086	1.0498
Min	.5792	.5792	.543	.5249	.5792	.4706	.543
Avg	.8226	.7941	.7869	.7909	.7836	.7941	.7700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 203 / 11KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191		.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0381	.0389	.1562	.237	.2439	.0381
10	.0191	.3894	.3376	.2942	.4215	.3726	.0381
11		.4329	.4634	.3308	.4252	.4573	.1159
12	.0191	.4039	.4291	.2911	.4382	.4611	.1464
13	.0191	.3825	.4047	.2172	.4283	.4626	.1166
14	.0191	.3917	.3635	.3574	.4306	.4626	.058
15	.0191	.4527	.3917	.4046	.3933	.4382	.16
16	.0191	.4504	.3971	.234	.4046	.4412	.2355
17		.4008	.3696	.4596	.4138	.4245	.2645
18	.0191	.2797	.3117	.2926	.3247	.3368	.2028
19	.0191	.2042	1.3733	.1837	.1586	.2058	.1364
20	.0191	.0884	.1334	.0199	.0191	.0679	.0191
21	.0191	.0191	.0663	.0191	.0191	.0275	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0191	.4527	1.3733	.4596	.4382	.4626	.2645
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.1727	.2204	.1446	.1872	.1922	.0734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 204 / 11KV CHAITANYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9366	1.828	1.7918	1.8099	2.2081	2.1357	2.0995
2	1.8099	1.7556	1.7918	1.6832	2.0814	2.0452	1.9547
3	1.6289	1.6289	1.7194	1.5384	1.8823	1.9547	1.7556
4	1.448	1.448	1.4661	1.4842	1.6832	1.8099	1.6289
5	1.3032	1.3394	1.3394	1.3394	1.5203	1.5023	1.4299
6	1.1584	1.1403	1.086	1.1946	1.2851	1.2851	1.3032
7	1.0679	1.0317	1.0317	1.0317	1.1946	1.2127	1.1403
8	1.0136	.9955	.9955	.9593	1.1946	1.1041	1.0498
9	.9955	.9955	1.0498	.9231	1.2489	1.1222	1.0679
10		.905	.4525	.8869	1.1584	1.0498	1.0317
11	1.1403	.9231	.4525	.9774	1.2308	1.1041	1.086
12	1.1041	1.0136	.4525	.9955	1.3032	1.3213	1.1946
13	1.267	1.1403	1.4118	1.4118	1.4661	1.3213	1.2489
14	1.4118	1.3394	1.4842	1.5203	1.6289	1.5565	1.4661
15	1.4842	1.4118	1.6108	1.7013	1.7375	1.6651	1.6289
16	1.4842	1.4661	1.5384	1.6289	1.7375	1.6108	1.6108
17	1.3213	1.3213	1.4661	1.5203	1.5927	1.4299	1.5023
18	1.1946	1.1765	1.1946	1.3213	1.448	1.2851	1.267
19	1.2127	1.2308	1.1765	1.3213		1.267	1.3213
20	1.4299	1.3756	1.3394	1.5023	1.5384	1.4118	1.448
21	1.5565	1.4661	1.4661	1.647	1.647	1.5927	1.5203
22	1.828	1.7013	1.647	1.9728	1.9728	1.8642	1.7918
23	1.9909	1.9004	1.8461	2.2443	2.19	2.1357	2.009
24	2.009	2.0271	1.9547	1.9366	2.3167	2.3529	2.2262
Max	2.009	2.0271	1.9547	2.2443	2.3167	2.3529	2.2262
Min	.9955	.905	.4525	.8869	1.1584	1.0498	1.0317
Avg	1.4259	1.3567	1.3235	1.4397	1.6203	1.5475	1.4909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 205 / 11 KV FEEDER NO.5

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	19-MAY-17
HR	Load (MW)	Load (MW)
8		.0191
13	.7621	
Max	.7621	.0191
Min	.7621	.0191
Avg	.7621	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 241 / 11 KV INCOMER NO-I

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9366	1.828	1.8642	1.8099	2.2081	2.1357	2.0995
2	1.8099	1.7556	1.7737	1.6832	1.9909	2.0452	1.9547
3	1.6289	1.6289	1.647	1.5384	1.8823	1.9547	1.7556
4	1.448	1.448	1.4661	1.4842	1.6832	1.8099	1.6289
5	1.3032	1.3394	1.3394	1.3394	1.5203	1.5023	1.4299
6	1.1584	1.1403	1.086	1.1946	1.2851	1.2851	1.3032
7	1.0679	1.0317	1.0317	1.0317	1.1946	1.2127	1.1403
8	1.0136	.9955	.9955	.9593	1.1946	1.1041	1.0498
9	.9955	.9955	1.0498	.9231	1.2489	1.1222	1.0679
10		.905	.543		1.1584	1.0498	1.0317
11	1.1403	.9231	.4525	.9774	1.2308	1.1041	1.086
12	1.1041	1.0136	.4525	.9955	1.3032	1.3213	1.1946
13	1.267	1.1403	1.4118	1.4118	1.4661	1.3213	1.2489
14	1.4118	1.3394	1.4842		1.6289	1.5565	1.4661
15	1.4842	1.4118	1.6108	1.7013	1.7375	1.6651	1.6289
16	1.4842	1.4661	1.5384	1.6289	1.7375	1.6108	1.6108
17	1.3213	1.3213	1.4661	1.5203	1.5927	1.4299	1.5023
18	1.1946	1.1765	1.1946	1.3213	1.3394	1.2851	1.267
19	1.2127	1.2308	1.1765	1.3213		1.267	1.3213
20	1.4299	1.3756	1.3394	1.5023	1.5384	1.4118	1.448
21	1.5565	1.4661	1.4661	1.647	1.647	1.5927	1.5203
22		1.7013	1.647	1.9728	1.9728	1.8642	1.7918
23	1.9909	1.9004	1.8461	2.2443	2.19	2.1357	2.009
24	2.009	2.0271	1.9547	1.9366	2.3167	2.3529	2.2262
Max	2.009	2.0271	1.9547	2.2443	2.3167	2.3529	2.2262
Min	.9955	.905	.4525	.9231	1.1584	1.0498	1.0317
Avg	1.4077	1.3567	1.3265	1.4611	1.6116	1.5475	1.4909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 242 / 11 KV INCOMER NO-II

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0862	3.0123	2.9081	2.9081	2.9384	2.9081	2.8349
2	2.9569	2.8645	2.8166	2.7984	2.7536	2.7801	2.652
3	2.8275	2.6797	2.6886	2.6337	2.6427	2.6337	2.5057
4	2.6981	2.5503	2.4874	2.524	2.4764	2.4691	2.3411
5	2.4949	2.384	2.3594	2.3045	2.2361	2.3228	2.1399
6	2.0883	2.1068	1.9204	1.9753	1.9404	1.9204	1.9022
7	1.922	1.9035	1.7375	1.829	1.7556	1.7558	1.6278
8	1.7372	1.7372	1.6644	1.6827	1.4784	1.6827	1.6095
9	1.7187	1.6827	1.6278	1.6644	1.7926	1.7924	1.6095
10	1.7558	1.8839	1.7194	1.7924	1.8656	1.7924	1.5729
11	1.6644	1.9022	1.8473	1.7924	1.9022	1.7558	1.7924
12	1.829	2.0485	1.8642	1.8839	1.9753	2.2497	1.7193
13	2.1582	2.1582	2.1176	2.0668	2.2131		1.9387
14	2.3777	2.4508	2.371	2.4508	2.4326	2.4874	2.268
15	2.5789	2.652	2.6063	2.5789	2.6155	2.6337	2.6155
16	2.5789	2.6886	2.5339	1.6461	2.6155	2.5606	2.5423
17	2.347	2.396	2.4394	2.4764	2.3777	2.3594	2.3411
18	2.0302	2.0119	2.0668	1.9589	2.1216	1.957	1.8656
19	2.2177	2.2497	2.1948	2.1582	2.1216	2.1033	1.9936
20	2.5688	2.5057	2.4326	2.4949	2.4143	2.3228	2.3228
21	2.6797	2.5789	2.5972	2.6242	2.524	2.5057	2.4143
22	2.9199	2.8532	2.7984	2.8645	2.8166	2.7069	2.6886
23	3.308	3.1459	3.1459	3.1602	3.1824	3.091	2.9447
24	3.2341	3.2156	3.0727	3.0727	3.0678	3.0544	2.9813
Max	3.308	3.2156	3.1459	3.1602	3.1824	3.091	2.9813
Min	1.6644	1.6827	1.6278	1.6461	1.4784	1.6827	1.5729
Avg	2.4074	2.4026	2.3341	2.3059	2.3442	2.3411	2.2177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 402 / 33 KV INCOMER (TUKARAM
SST) Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	21.3511	20.8436	20.6218	20.3418	21.8679	21.8536	20.8819
2	20.1989	19.8012	19.5611	19.2759	16.0494	20.6904	19.8417
3	19.2593	18.7037	18.3986	18.4128	19.6989	19.5274	18.5214
4	17.9698	17.38	17.4412	17.304	18.4614	18.5357	17.1325
5	16.8382	16.3306	16.0123	15.9237	16.4038	16.9896	15.9637
6	15.0206	14.705	14.4662	14.1861	14.8977	14.972	14.1976
7	12.9424	12.6818	12.1656	12.1656	12.9458	12.843	12.1857
8	11.749	11.8656	11.454	11.5769	12.1857	12.0971	11.4941
9	11.5776	11.5141	11.3169	11.1997	12.56	12.1714	11.3026
10	7.3731	11.7198	11.114	11.4112	13.0059	12.0342	11.3426
11	12.3085	12.0199	9.7422	11.7741	13.1287	12.2257	12.1228
12	12.3143	12.6486	9.9137	12.0685	13.806	12.8315	12.4171
13	14.1061	13.8603	14.9549	14.4491	15.3721	11.1797	13.546
14	15.938	15.5636	16.5981	16.501	16.9868	15.998	15.6665
15	16.9325	16.8982	17.6441	17.8899	18.2871	17.9585	17.4726
16	17.1726	17.1926	17.6927	18.0213	18.4929	17.8842	17.767
17	16.0866	16.5238	16.8725	17.2697	17.5498	16.9896	17.0097
18	14.4033	14.6234	14.8348	15.615	15.8322	15.0749	14.8634
19	14.2267	14.4205	13.9289	14.4005	14.6405	14.0318	13.6689
20	16.6199	16.1523	15.8923	16.3438	16.3781	15.8037	15.5979
21	17.4034	17.0011	17.0354	17.6641	17.5755	17.0697	16.4267
22	19.6382	18.8271	18.5472	19.573	19.7645	19.0872	18.3614
23	22.0102	20.9762	20.559	22.3308	22.1594	21.4821	20.6133
24	22.1742	21.3992	21.2163	22.0879	22.5709	22.0222	21.0562
Max	22.1742	21.3992	21.2163	22.3308	22.5709	22.0222	21.0562
Min	7.3731	11.5141	9.7422	11.1997	12.1857	11.1797	11.3026
Avg	16.0673	15.9855	15.7493	16.1578	16.6925	16.3064	15.8106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 421 / 33 KV INCOMER TO P.T. NO-I

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0005	1.9433	1.9433	1.773	2.2291	2.1491	2.1148
2	1.7353	1.6827	1.829	1.6118	2.1148	2.0416	1.893
3	1.5775	1.5775	1.7147	1.6575	2.0005	1.8804	1.7353
4	1.5432	1.5432	1.4861	1.6004	1.7718	1.7193	1.6655
5	1.3717	1.3717	1.3717	1.2357	1.6004	1.5043	1.4506
6	1.2003	1.2003	1.1431	1.0745	1.3717	1.2894	1.4289
7	1.0288	1.086		.9671	1.2003	1.182	1.2003
8	1.086	1.0288	.9717	.9134	1.2003	1.0745	1.1431
9	1.0288	1.0288	1.086	1.0288	1.3717	1.0802	1.1431
10		.9717	.5144	.9717	1.2574	1.086	1.1431
11	1.0311	.9717	.4572	1.0288	1.3146	1.1431	1.1431
12	.9374	1.1431	.4572	1.0288	1.3717	1.2574	1.2574
13	1.2094	1.2003	1.5432	1.4289	1.4198	1.3717	1.3146
14	1.3672	1.3717	1.6004	1.6004	1.5775	1.6004	1.5432
15	1.4198	1.4861	1.7147	1.829	1.6827	1.7147	1.7147
16	1.4198	1.4861	1.6575	1.7147	1.829	1.6575	1.7147
17	1.3717	1.3717	1.4198		1.5947	1.5432	1.6004
18	1.2574	1.2003	1.1568	1.4289	1.4352	1.3717	1.3717
19	1.3146	1.3146	1.1317	1.4289	1.3146	1.3146	1.3717
20	1.4289	1.4289	1.286	1.5432	1.4883	1.4861	1.5432
21	1.6004	1.4861	1.5432	1.7147	1.5581	1.6575	1.5432
22	1.8861	1.7718	1.6118		1.8804	1.9433	1.8861
23	2.1148	2.0005	1.8267	2.3434	2.1719	2.2291	2.0576
24	2.0576	2.1148	2.0005	1.9342	2.2805	2.3102	2.3434
Max	2.1148	2.1148	2.0005	2.3434	2.2805	2.3102	2.3434
Min	.9374	.9717	.4572	.9134	1.2003	1.0745	1.1431
Avg	1.4343	1.4076	1.3681	1.4481	1.6265	1.5670	1.5551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 024041 / 33 KV Tukaram Chowk Akola

Feeder No / Name : 422 / 33 KV INCOMER TO P.T. NO- SHEDDABLE RURAL
II Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2007	3.0864	2.8778	2.8532	2.8475	2.8172	2.915
2	2.8235	2.7401	2.7692	2.6886	2.6863	2.6578	2.6606
3	2.7692	2.5789	2.6063	2.5789	2.5789	2.4983	2.4434
4	2.6063	2.6292	2.4977	2.572	2.364	2.392	2.2805
5	2.572	2.3102	2.3348	2.2862	2.1491	2.2805	2.2291
6	2.1719	2.0416	1.9004	1.9342	1.8804	1.8604	2.0005
7	2.0005	1.8267	1.7193	1.773	1.7193	1.701	1.7147
8	1.6655	1.6478	1.6118	1.701	1.6118	1.5947	1.6575
9	1.7193	1.829	1.5947	1.6655	1.773	1.7193	1.5415
10	1.701	1.8267	1.7193	1.773	2.0005	1.773	1.6118
11	1.701	1.9342	1.8804	1.8267	2.0005	1.773	1.7193
12	1.8073	2.0416	1.8804	1.8267	2.1148	2.1491	1.7193
13	2.1176	2.1491	2.1491	2.0633	2.2805	2.2565	1.9879
14	2.4434	2.4714	2.364	2.4434	2.4977	2.2565	2.3102
15	2.552	2.6326	2.5789	2.6063	2.6606	2.5789	2.5252
16	2.552	2.6326	2.5789	2.6063	2.6606	2.5789	2.5789
17		2.4434	2.4434	2.4714	2.3891	2.3891	2.3102
18	2.1719	2.009	2.0633	2.0416	2.1176	1.9547	1.8804
19	2.2862	2.2805	2.1176	2.0953	2.2028	2.1176	1.9879
20	2.6863	2.4977	2.4434	2.4177	2.4434	2.3348	2.3348
21	2.8006	2.6063	2.6063	2.6326	2.6337	2.552	2.4434
22	3.0864	2.8235	2.7984	3.0624	2.8532	2.7149	2.6606
23	3.2579	3.1493	3.0727	3.0624	3.083	3.0407	2.8778
24	3.315	3.2579	3.0407	3.0178	2.955	2.9235	2.9321
Max	3.315	3.2579	3.0727	3.0624	3.083	3.0407	2.9321
Min	1.6655	1.6478	1.5947	1.6655	1.6118	1.5947	1.5415
Avg	2.4351	2.3936	2.3187	2.3333	2.3543	2.2881	2.2218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 201 / 11 KV GORAKSHAN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5242	1.5242	1.5242
2	1.829	1.5242	1.5242	1.2193
3	1.5242	1.2193	1.2193	1.2193
4	1.5242	1.2193	1.2193	1.2193
5	1.5242	1.2193	1.2193	.9145
6	1.2193	.9145	.9145	.9145
7	.9145	.9145	.9145	.6097
8	.9145	.9145	.6097	.6097
9	.9145	.9145	.6097	.6097
10	.9145	.9145	.9145	.6097
11	.6097	.9145	.9145	.6097
12	.6097	.9145	.9145	.6097
13	.9145	.9145	.9145	.9145
14	1.2193	1.2193	.9145	.9145
15	1.2193	1.2193	1.2193	.9145
16	1.2193	1.2193	1.2193	.9145
17	1.2193	1.2193	1.2193	.9145
18	1.2193	1.2193	.9145	.9145
19	.9145	.9145	.9145	.9145
20	.9145	.9145	.9145	.9145
21	.9145	.9145	.9145	.9145
22	1.2193	1.2193	.9145	.9145
23	1.5242	1.2193	1.2193	1.2193
24	1.5242	1.5242	1.2193	1.2193
Max	1.829	1.5242	1.5242	1.5242
Min	.6097	.9145	.6097	.6097
Avg	1.1531	1.1177	1.0415	.9272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 205 / 11 KV BIRLA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.702	4.6944	4.5268	4.4658	4.4124	4.4887	4.2295
2	4.4734	4.4505	4.2829	4.2753	4.2676	4.2372	3.9704
3	4.2829	4.2524	4.0619	4.0085	4.0238	4.0009	3.7647
4	4.0543	3.9704	3.8409	3.7799	3.7799	3.7875	3.5437
5	3.7799	3.7266	3.6199	3.5894	3.5361	3.5437	3.2998
6	3.4903	3.4903	3.3836	3.3303	3.216	3.2846	3.0407
7	3.2465	3.0864	2.6825	2.8959	3.0026	2.8578	2.6749
8	2.713	2.7968	2.5835	2.6139	2.8197	2.5835	2.3624
9	2.5149	2.5682	2.4768	2.4463	2.6444	2.431	2.271
10	2.4844	2.431	2.4234	2.3624	2.5072	2.3015	2.2481
11	2.5682	2.5301	2.5149	2.5225	2.5758	2.4158	
12	2.9569	2.713	2.6444	2.6368	2.6825	2.6139	
13	3.1398	2.934	2.7587	2.8807	2.8349	2.7435	3.4903
14	3.5513	3.216	3.3836	3.2617	3.155	3.1245	3.7494
15	3.818	3.6427	3.6351	3.5742	3.4294	3.4141	3.7037
16	4.0771	3.8028	3.7875	3.7494	3.658	3.6961	3.7723
17	4.0009	3.7723	3.7875	3.7342	3.658	3.8028	3.6808
18	3.5361	3.5589	3.4294	3.3836	3.4598	3.4141	3.4141
19	3.2998	3.1779	3.0026	3.1017	3.2084	2.9797	3.0026
20	3.658	3.4598	3.3532	3.3227	3.3836	3.1703	3.1703
21	3.7342	3.5589	3.3455	3.4141	3.4979	3.2465	3.2084
22	3.8637	3.6732	3.5437	3.5284	3.6732	3.3684	3.3532
23	4.4124	4.1305	3.94	4.0619	4.0314	3.719	3.7113
24	4.7478	4.5115	4.3972	4.4048	4.4658	4.2143	3.9933
Max	4.7478	4.6944	4.5268	4.4658	4.4658	4.4887	4.2295
Min	2.4844	2.431	2.4234	2.3624	2.5072	2.3015	2.2481
Avg	3.6294	3.5062	3.3919	3.3894	3.4135	3.3100	3.3480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 208 / 11 KV CHITRA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.2362	.1981	.1981
8				.0457	.2515	.2439	.16
9				.0533	.2134	.221	.0076
10	.0914	.0305	.0381	.0991	.16	.1829	
11	.3429	.1905	.1829				
12	.282	.16	.1448				
13	.2286	.0381	.1677				
14	.1981		.0229				
15	.1829						
16	.1905						
17	.1753						
18	.0457						
Max	.3429	.1905	.1829	.0991	.2515	.2439	.1981
Min	.0457	.0305	.0229	.0457	.16	.1829	.0076
Avg	.1930	.1048	.1113	.0660	.2153	.2115	.1219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 210 / AKOLA TOWN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0331	3.0026	2.9492	2.934	2.9264	2.9035	2.774
2	2.9188	2.9035	2.8578	2.8426	2.8426	2.8426	2.7282
3	2.7816	2.7587	2.6978	2.713	2.6825	2.6978	2.5911
4	2.6825	2.652	2.5835	2.6063	2.5835	2.5606	2.4691
5	2.5606	2.553	2.4996	2.5072	2.4615	2.4768	2.3624
6	2.4768	2.4844	2.4234	2.3853	2.3777	2.3853	2.2862
7	2.3167	2.3091	2.3015	2.2634	2.2253	2.2253	2.1033
8	2.1795	2.1795	2.1491	2.21	2.1414	2.111	2.0271
9	2.2177	2.1033	2.1719	2.2634	2.2177	2.1948	1.9662
10	2.4615	2.3929	2.3624	2.934	2.3853	2.2939	2.0957
11	2.934	2.8426	2.8502	3.7037	2.8578	2.7511	2.2558
12	3.6046	3.5056	3.5208	4.5496	3.5665	3.4141	2.4691
13	3.8714	3.879	3.719	4.824	3.818	3.6351	2.6673
14	4.0314	3.9857	3.8333	4.9154	3.818	3.6885	2.7435
15	4.0314	3.9171	.7926	3.8485	3.818	3.7266	2.8426
16	4.1305	4.0238	4.2981	4.0162	4.0466	3.7952	2.8502
17	4.1533	4.0238	4.3286	4.0085	4.0085	3.8714	2.873
18	4.1152	3.9857	4.0009	3.9171	3.9933	3.7494	2.8502
19	3.9171	3.6808	3.8104	3.5894	3.7571	3.4522	2.5301
20	3.9095	3.818	3.818	3.719	3.7723	3.6046	2.7206
21	3.8637	3.7342	3.658	3.6046	3.658	3.4827	2.7282
22	3.3913	3.2693	3.1931	3.1474	3.155	3.094	2.6444
23	3.0636	2.9188	2.8959	2.8883	2.8197	2.8121	2.5606
24	3.0788	2.9721	2.9645	2.9569	2.9188	2.7892	2.6673
Max	4.1533	4.0238	4.3286	4.9154	4.0466	3.8714	2.873
Min	2.1795	2.1033	.7926	2.21	2.1414	2.111	1.9662
Avg	3.2385	3.1623	3.0283	3.3062	3.1188	3.0232	2.5336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 211 / 11 KV UMRI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8138	1.7528	1.7528	1.768	1.6842	1.7071	1.6918
2	1.5851	1.4937	1.608	1.5623	1.5318	1.5775	1.547
3	1.4708	1.4251	1.4861	1.4098	1.4327	1.4632	1.4251
4	1.4251	1.3413	1.4403	1.3946	1.3489	1.4251	1.3641
5	1.3184	1.2498	1.387	1.3184	1.3032	1.3413	1.2955
6	1.2498	1.1888	1.3184	1.2269	1.2193	1.2727	1.1279
7	1.0974	1.0822	1.2041	1.1126	1.0974	1.1584	1.0364
8	.9831	.9755	.9526	1.0288	1.044	1.0669	.9069
9	.945	.9602	.9755	.9831	1.0212	1.044	.9602
10	1.0364	1.1126	1.044	1.0136	1.105	1.0288	.9983
11	.381	1.326	1.2117	1.1584	1.2422	1.166	1.1203
12		1.387	1.387	1.1431	1.3489	1.326	1.2422
13	.4268	1.448	1.0593	1.4632	1.3794	1.4098	1.3184
14	1.7299	1.5165	1.5623	1.4251	1.5242	1.448	1.3413
15	1.7452	1.6232	1.6461	1.5851	1.6004	1.5775	1.448
16	1.7985	1.7147	1.7528	1.7223	1.7452	1.5775	1.4708
17	1.7909	1.6842	1.7147	1.5851	1.7147	1.6994	1.4327
18	1.7147	1.5699	1.5242	1.5318	1.5699	1.5623	1.3032
19	1.5699	1.5089	1.387	1.4556	1.4403	1.4022	1.1584
20	1.5242	1.4327	1.4632	1.4327	1.4403	1.3641	1.2422
21	1.4937	1.4556	1.448	1.4403	1.4022	1.3794	1.2651
22	1.5242	1.5699	1.4632	1.448	1.4861	1.4861	1.3336
23	1.6918	1.768	1.7071	1.7299	1.7071	1.6537	1.5013
24	1.7375	1.768	1.7528	1.7528	1.7375	1.7223	1.5546
Max	1.8138	1.768	1.7528	1.768	1.7452	1.7223	1.6918
Min	.381	.9602	.9526	.9831	1.0212	1.0288	.9069
Avg	1.3936	1.4314	1.4270	1.4038	1.4219	1.4108	1.2952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 241 / 11 KV INCOMER NO-I
GORKSHAN S/ Feeder KV- 11 /
INCOMING

SHEDDABLE RURAL

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***	***
2	***	***	***	***	***	***	***
3	***	***	***	***	***	***	***
4	***	***	***	***	***	***	***
5	***	***	***	***	***	***	***
6	***	***	***	***	***	***	***
7	***	***	9.8461	***	9.968	9.7851	9.2364
8	9.4498	9.5717	9.2669	9.3279	9.2974	8.9925	8.5963
9	9.2364	9.2364	9.1754	9.145	9.2669	8.4134	8.5658
10	9.7546	9.6022	9.7241	***	9.8461	8.6572	8.6572
11	***	***	8.5658	***	***	***	7.316
12	***	***	***	***	***	***	8.2609
13	***	***	***	***	***	***	***
14	***	***	***	***	***	***	***
15	***	***	***	***	***	***	***
16	***	***	***	***	***	***	***
17	***	***	***	***	***	***	***
18	***	***	***	***	***	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	***	***	***	***	***	***	***
23	***	***	***	***	***	***	***
24	***	***	***	***	***	***	***
Max	16.1866	15.9427	16.0646	15.7903	15.6379	15.394	13.1992
Min	9.2364	9.2364	8.5658	9.145	9.2669	8.4134	7.316
Avg	13.3059	13.0989	12.5349	13.0621	12.8931	12.4943	11.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 025006 / 132KV GORAKSHAN

Feeder No / Name : 242 / 11 KV INCOMER NO-II
GORKSHAN S Feeder KV- 11 /
INCOMING

SHEDDABLE RURAL

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	***	***	***
2	***	***	***	***	***	***	***
3	***	***	***	***	***	***	***
4	***	***	***	***	***	***	***
5	***	***	***	***	***	***	***
6	***	***	***	***	***	***	***
7	***	***	***	***	***	***	9.7546
8	***	***	***	***	***	***	9.145
9	***	***	***	***	***	***	9.023
10	***	***	***	7.8342	***	***	9.023
11	8.7487	9.2059	***	7.6208	***	***	9.1754
12	7.2245	5.5479	***	***	***	***	9.4803
13	5.6089	5.7613	***	***	***	***	***
14	***	***	***	***	***	***	***
15	***	***	***	***	***	***	***
16	***	***	***	***	***	***	***
17	***	***	***	***	***	***	***
18	***	***	***	***	***	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	***	***	***	***	***	***	***
23	***	***	***	***	***	***	***
24	***	***	***	***	***	***	***
Max	15.7598	15.7293	15.394	15.333	14.8453	14.8453	13.2602
Min	5.6089	5.5479	10.6082	7.6208	10.5472	10.4557	9.023
Avg	12.4930	12.3203	12.6277	12.2758	12.4143	12.6023	10.9066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 027002 / 132 MIDC

Feeder No / Name : 201 / 11 kv Phase II/ OLD MIDC
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	1.6766	1.9814	1.9814	1.829	1.9814	1.9814
2	1.6766	1.6766	1.9814	1.9814	1.6766	1.9814	1.9814
3	1.6766	1.6766	1.9814	1.829	1.6766	1.829	1.829
4	1.6766	1.6766	1.829	1.829	1.6766	1.829	1.829
5	1.6766	1.5242	1.9814	1.829	1.6766	1.829	1.829
6	1.6766	1.5242	1.829	1.829	1.6766	1.829	1.829
7	1.5242	1.5242	1.829	1.829	1.5242	1.829	1.829
8	1.5242	1.5242	1.829	1.829	1.6766	1.829	1.829
9	1.3717	1.6766	1.829	1.9814	1.829	2.1338	1.829
10	1.2193	2.1338	2.4387	2.4387	2.2862	2.5911	2.1338
11	1.2193	2.5911	2.8959	2.8959	2.7435	3.0483	2.5911
12	1.2193	2.8959	2.8959	3.0483	2.8959	3.2007	2.7435
13	1.2193	2.7435	2.8959	3.0483	2.7435	3.0483	2.5911
14	1.2193	2.7435	2.7435	2.8959	2.5911	2.8959	2.4387
15	1.2193	2.8959	3.0483	3.0483	2.8959	3.0483	2.5911
16	1.2193	3.0483	3.2007	3.2007	3.0483	3.2007	2.7435
17	1.2193	3.0483	1.3717	3.0483	3.0483	2.8959	2.7435
18	1.2193	3.0483		2.8959	2.8959	2.8959	2.5911
19	1.2193	2.7435	2.5911	2.5911	2.5911	2.5911	2.2862
20	1.3717	2.5911	2.5911	2.5911	2.5911	2.5911	2.4387
21	1.5242	2.2862	2.2862	2.2862	2.2862	2.1338	2.2862
22	1.3717	1.829	1.829	1.9814	1.829	1.829	1.829
23	1.5242	1.6766	1.829	1.829	1.829	1.829	1.829
24	1.3717	1.829	1.829	1.829	1.829	1.829	1.829
Max	1.829	3.0483	3.2007	3.2007	3.0483	3.2007	2.7435
Min	1.2193	1.5242	1.3717	1.829	1.5242	1.829	1.829
Avg	1.4162	2.1910	2.2399	2.3561	2.2227	2.3624	2.1846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 027002 / 132 MIDC

Feeder No / Name : 206 / 11 KV NEW MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2651	1.2498	1.2651	1.2346	1.2346	1.2498	.884
2	1.2651	1.2498	1.2651	.9298	1.2498	1.2498	.884
3	1.2651	1.2498	1.2651	1.2651	1.2498	1.2346	.884
4	1.2651	1.2498	1.2803	1.2498	1.2498	1.2498	.884
5	1.2651	1.2498	1.2498	1.2498	1.2498	1.2346	.884
6	1.2803	.945	1.2803	1.2498	1.2498	.9298	.884
7	1.2803	.9603	1.2955	1.2803	.9755	.9145	.8993
8	.9755	1.2803	.9755	1.2498	1.2803	1.2651	.8993
9	.945		.9145	1.2498	1.2651	1.6003	1.2041
10	.9603	.9755	1.2193	1.6308	1.5241	1.951	1.5241
11	.945	1.89	1.5242	1.951	1.8595	2.3015	1.8595
12	.9298	1.9205	2.21	2.3167	1.8748	2.271	1.829
13	.9755	1.9357	2.2405	2.3167	1.9052	2.271	1.8443
14	1.2498	1.9357	1.9814	1.9814	1.9357	1.9357	1.5089
15	1.2498	2.2862	2.3015	2.271	2.271	2.2405	1.829
16	1.2651	2.271	2.3015	2.3015	2.2862	2.2558	1.7833
17	1.2651	1.9357	2.3472	2.2862	2.2862	2.2405	1.4632
18	.9298	1.9357	2.3472	2.3167	2.271	1.9357	1.4632
19	.9298	1.8748	1.951	1.9967	1.951	1.9357	1.1279
20	1.2651	1.8748	1.6003	1.5546	1.9052	1.5241	1.1279
21	1.2498	1.5851	1.5851	1.2346	1.5546	1.2041	1.1736
22	1.2498	.9145	1.2498	1.2346	1.2498	1.2193	1.1736
23	1.2498	.9298	1.2651	1.2651	1.2498	1.2041	1.1736
24	1.2498	1.2498	1.2498	1.2651	1.2498	1.1888	.8688
Max	1.2803	2.2862	2.3472	2.3167	2.2862	2.3015	1.8595
Min	.9298	.9145	.9145	.9298	.9755	.9145	.8688
Avg	1.1571	1.5195	1.5902	1.6201	1.5991	1.6086	1.2524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-II S/DN[570] BU 4570

Substation No/ Name :- 027002 / 132 MIDC

Feeder No / Name : 208 / 11KV PH III

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	.9145		.9145	1.2193	1.2193
2	1.2193			.9145	1.2193	1.2193
3	1.2193			.9145	1.2193	1.2193
4	.9145			.9145	1.2193	.9145
5	.9145			.9145	1.2193	1.2193
6	.9145			.9145	1.2193	1.2193
7	.9145			.9145	1.2193	1.2193
8	.9145			1.2193	1.2193	1.2193
9	.9145			1.5242	1.5242	1.5242
10	.9145			2.4387	2.4387	2.4387
11	.9145			3.0483	3.0483	2.7435
12	.9145			3.0483	3.0483	3.0483
13	.9145			3.0483	3.0483	3.0483
14	.9145			2.4387	2.4387	2.4387
15	.9145			3.0483	3.0483	2.7435
16	.9145			3.0483	3.0483	3.0483
17	.9145			3.0483	3.0483	2.7435
18	.9145		2.7435	3.0483	3.0483	2.7435
19	.9145		2.7435	2.7435	2.7435	2.4387
20	.9145		2.4387	2.4387	2.4387	2.4387
21	.9145		1.829	1.5242	1.829	1.829
22	.9145		1.2193	1.2193	1.2193	1.2193
23	.9145		1.2193	1.2193	1.2193	1.2193
24	.9145		1.2193	1.2193	1.2193	1.2193
Max	1.2193	.9145	2.7435	3.0483	3.0483	3.0483
Min	.9145	.9145	1.2193	.9145	1.2193	.9145
Avg	.9526	.9145	1.9161	1.9052	2.0068	1.9306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 201 / 11 KV PKV FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3439	.3439	.3439	.3258	.3658	.3258	.3258
2	.3439	.3439	.3439	.3258	.3658	.3258	.3258
3	.3439	.3439	.3439	.3258	.3658	.3258	.3258
4	.3077	.3439	.3077	.3258	.3439	.3077	.3077
5	.3077	.3077	.3077	.3258	.3258	.3077	.2896
6	.2896	.3077	.2896	.3077	.3174	.2926	.3439
7	.2896	.2896	.2896	.2896	.2896	.2896	.2715
8	.2896	.2715	.3077	.2896	.2896	.2896	.2715
9	.3077	.3077	.362	.3077	.2896	.2896	.2601
10	.3801	.3982	.3982	.3801	.3439	.362	.2896
11	.5249	.4887	.4163	.4344	.4525	.4525	.2896
12	.543		.5792	.5249	.5249	.4525	
13	.5068	.4706	.5792	.5611	.4887	.4887	.2896
14	.4887	.4706	.5249	.5249	.4887	.4525	.3077
15	.5249	.5249	.5249	.5068	.4887		.3077
16	.5304	.5175	.3475	.5249	.543	.4887	.2926
17	.5487	.5175	.5121	.5249	.5068		.2896
18	.439	.3841	.4024	.3801	.3982	.3801	.2896
19	.3658	.3258	.2896	.3258	.3439	.3439	.3077
20	.3658	.3439	.3658	.3439	.3292	.3439	.3292
21	.3658	.362	.3077	.3658	.362	.3439	.3258
22	.394	.3982	.3841	.4024	.3841	.3841	.362
23	.3801	.3801	.3658	.4024	.3658	.3439	.362
24	.362	.362	.3475	.3439	.3841	.3439	.3439
Max	.5487	.5249	.5792	.5611	.543	.4887	.362
Min	.2896	.2715	.2896	.2896	.2896	.2896	.2601
Avg	.3977	.3828	.3851	.3904	.3899	.3607	.3091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 202 / 11 KV PANCHSHIL FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9877	1.0242	.9511	.9335	1.0082	.9709	.9709
2	.9877	1.0242	.9511	.9335	1.0082	.9709	.9709
3	.9511	.9877	.9145	.9335	1.0082	.9709	.9335
4	.9145	.9511	.9145	.8962	.9335	.9335	.9335
5	.9145	.8413	.8413	.8215	.8215	.8215	.8215
6	.823	.8048	.7316	.7468	.7468	.7468	.6653
7	.7133	.5304	.6219	.7095	.6722	.6653	.6283
8	.6036	.5121	.567	.6348	.5729	.6283	.5729
9	.5973	.5249	.5611	.5611	.543	.5792	.5304
10	.5973	.4706	.5249	.5611	.543	.543	.543
11	.5611	.4706	.5611	.543	.5973	.5973	.567
12	.6154		.6154	.6154	.6335	.6335	.5304
13	.6878	.5611		.6697	.7421	.7059	.6878
14	.7602	.6516		.7783	.7964	.7964	.7964
15	.8145	.543		.7964	.8145	.7964	.7783
16	.8589	.6722	.9896	.8048	.7865	.7865	.7865
17	.8029	.7655	.8589	.7316	.7602	.7316	.7421
18	.7468	.6653	.8402	.6767	.6805	.695	.7133
19	.8029	.7655	.8215	.695	.7421	.695	.7499
20	.8402	.8215	.9149	.8413	.823		.7865
21	.9335	.7023	.9149	.8596	.8962	.8779	.8326
22	.9694	1.0059	1.0456	.8916	1.0456	.9896	.9231
23	1.0974	1.0059	1.1203	1.0456	1.0456	1.0456	.9774
24	1.0425	1.0608	.9511	1.0269	1.0456	1.0082	.9896
Max	1.0974	1.0608	1.1203	1.0456	1.0456	1.0456	.9896
Min	.5611	.4706	.5249	.543	.543	.543	.5304
Avg	.8176	.7549	.8196	.7795	.8028	.7908	.7680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 203 / 11 KV SUDHIR COLONY FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0407	3.0087	2.3167	3.062	3.062	3.0247	2.9874
2	2.7692	3.0045	2.7511	3.062	3.062	3.0247	2.9874
3	2.6063	2.8959	2.7435	2.8006	2.9874	2.9874	2.5393
4	2.5339	2.733	2.5606	2.6139	2.8753	2.6886	2.2405
5	2.2131	2.1491	2.4977	2.2405	2.0538	2.5393	2.0538
6	2.0814	2.0302	2.19	2.0538	1.8671	2.0538	1.8671
7	1.7556	1.7737	1.828	1.7551	1.8298	1.8671	1.7177
8	1.6832		1.7375	1.7177	1.7737	1.8298	1.6057
9	1.7194	1.6108	1.647	1.6108	1.5927	1.7013	1.5364
10	1.647	1.6651	1.6832	1.5565	1.7375	1.6289	1.6108
11	1.6832	1.6832	1.6651	1.5746	1.7737	1.647	1.6461
12	1.7918		1.7013	1.7013	1.7375	1.7375	1.7558
13	2.1033	2.0119	1.9909	1.9004	1.9728	1.9185	1.9185
14	2.3228	2.1948	2.19	2.3348	2.2443	2.2624	2.19
15	2.4874	2.3411	2.4072	2.4072	2.3529	2.3348	2.371
16	2.5579	2.3525	2.4832	2.4253	2.4072	2.2986	2.371
17	2.2218	2.2032	2.2405	2.1033	2.2624	2.1176	2.19
18	2.0165	1.9605	2.1658	1.9909	1.9909	1.8656	1.8823
19	2.1285	2.1658	2.1098	2.0485	1.9909	1.9909	2.1176
20	2.4459	2.3899	2.3339	2.2262	2.3228	2.2131	2.1719
21	2.5766	2.5019	2.4646	2.3167	2.4508	2.3228	2.2262
22	2.7759	2.7511	2.838	2.6886	2.782	2.6326	2.5789
23	3.1855	2.9864	3.1181	3.0994	3.062	2.9874	2.9081
24	3.095	3.095	3.0178	3.1181	3.1554	3.0807	3.006
Max	3.1855	3.095	3.1181	3.1181	3.1554	3.0807	3.006
Min	1.647	1.6108	1.647	1.5565	1.5927	1.6289	1.5364
Avg	2.3101	2.3413	2.2784	2.2670	2.3061	2.2815	2.1866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 204 / 11kv feeder no. 3

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.4266	1.4118	1.419	1.3817	1.419	1.3817
2	1.2851	1.2986	1.3756	1.419	1.3817	1.419	1.3817
3	1.2178	1.2986	1.2851	1.419	1.3817	1.419	1.307
4	1.2308	1.2986	1.2851	1.1949	1.307	1.3443	1.2323
5	1.1946	1.2308	1.2308	1.1203	1.2323	1.2323	1.1203
6	1.1403	1.1706	1.086	1.0829	1.1203	1.1203	1.0456
7	.9412	1.0974	1.0136	1.0269	.9522	1.0829	.9335
8	.8413	.905	.905	.9149	.8589	.9709	.9709
9	.7964	.8779	.9231	.905	.9774	.8688	.8413
10	.7783	.8779	.9231	.8688	.8507	.905	.7964
11	.9774	.9145	.905	.905	.8688	.8869	.8413
12	1.0136		.9774	.9231	.9774	.9593	.9412
13	1.134	1.0425	1.1041	1.0136	1.0679	1.1041	1.0317
14	1.2254	1.0608	1.1403	1.1584	1.1946	1.1946	1.1222
15	1.2986	1.0608	1.2127	1.1765	1.2127	1.2127	1.2308
16	1.2323	1.0829	1.2696	1.1706	1.1765	1.1765	1.1946
17	1.1763	1.0082	1.1949	1.1523	1.1584	1.086	1.1584
18	1.2323	1.1576	1.1949	1.0136	1.0608	1.0059	1.0498
19	1.2696	1.251	1.1576	1.1222	1.1888	1.1946	1.086
20	1.3817	1.363	1.2883	1.2986	1.3352	1.3032	1.1765
21	1.419	1.4563	1.419	1.2803	1.3535	1.3535	1.2489
22	1.5402	1.448	1.4937	1.531	1.531	1.4937	1.386
23	1.5402	1.5203	1.6244	1.5684	1.531	1.531	1.4784
24	1.5364	1.4842	1.448	1.4937	1.4937	1.4937	1.4377
Max	1.5402	1.5203	1.6244	1.5684	1.531	1.531	1.4784
Min	.7783	.8779	.905	.8688	.8507	.8688	.7964
Avg	1.2021	1.1884	1.2029	1.1741	1.1914	1.1991	1.1414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 210 / 11 kv Incomer No.1

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7401	2.7401	2.6684	2.6886	2.7633	2.726	2.6886
2	2.5789	2.6147	2.6326	2.6886	2.7633	2.726	2.6886
3	2.4893	2.5514	2.5072	2.6886	2.7633		2.5766
4	2.4177	2.5431	2.4714	2.4272	2.5953	2.726	2.4832
5	2.3819	2.371	2.371	2.2779	2.3899	2.5953	2.2405
6	2.2207	2.2624	2.0774	2.1472	2.1845	2.1658	2.0165
7	1.9163	1.8804	1.9185	2.0351	1.9231	2.0538	1.8484
8	1.7013	1.701	1.7551	1.8298	1.7364	1.9044	1.8298
9	1.7193	1.7741	1.8656	1.7556	1.7737	1.7375	1.6118
10	1.7741	1.7558	1.8656	1.8099	1.7375	1.8099	1.6289
11	2.0851	1.8839	1.9022	1.8823	1.9185	1.9366	1.701
12	2.1948		2.1948	2.0633	2.1357	2.0452	1.7741
13	2.3411	2.0851	1.6832	2.2443	2.2986	2.2986	2.009
14	2.4874	2.1948	1.6651	2.4615	2.4796	2.4434	2.2497
15	2.652	2.1399	1.7375	2.4796	2.5158	2.009	2.3167
16	2.6326	2.2779	2.8006	2.4535	2.4714	2.4177	2.2386
17	2.5393	2.2965	2.5766	2.4143	2.3998	1.7718	2.167
18	2.4272	2.2218	2.4459	2.0595	2.1132	2.0416	1.825
19	2.4459	2.3525	2.2779	2.1132	2.2148	2.2386	2.1132
20	2.5953		2.5766	2.4097	2.4356	2.3998	2.2565
21	2.726	2.5393	2.6513	2.4535	2.5882	2.5252	2.3565
22	2.8833	2.7818	2.9313	2.9127	2.9687	2.8753	2.6703
23	2.959	2.8349	3.062	3.0247	2.95	2.9313	2.8166
24	3.0226	2.8654	2.7873	2.8753	2.9313	2.8567	2.782
Max	3.0226	2.8654	3.062	3.0247	2.9687	2.9313	2.8166
Min	1.7013	1.701	1.6651	1.7556	1.7364	1.7375	1.6118
Avg	2.4138	2.3031	2.3094	2.3415	2.3771	2.3146	2.2037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024002 / 33 KV UMRI

Feeder No / Name : 211 / Incomer No.2

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0087	2.9767	2.3167	3.062	3.062	3.0247	2.9874
2	2.7692	2.9729	2.7221	3.062	3.062	3.0247	2.9874
3	2.5789	2.8349	2.6863	2.8006	2.9874	2.9874	
4	2.5072	2.7042	2.5072	2.6139	2.8753	2.6886	2.2405
5	2.167	2.1491	2.4714	2.2405	2.0538	2.5393	2.0538
6	2.0595	1.9879	2.167	2.0538	1.8671	2.0538	1.8671
7	1.7372	1.7551	1.8088	1.7551	1.8298	1.8671	1.7177
8	1.6478	1.6655	1.6118	1.7177	1.7737	1.8298	1.6057
9	1.7375	1.6278	1.647	1.6108	1.5927	1.7013	1.5043
10	1.6644	1.6827	1.6832	1.5565	1.7375	1.6289	1.5939
11	1.701	1.701	1.6651	1.5746	1.7737	1.647	1.6461
12	1.8107		1.7013	1.7013	1.7375	1.7375	1.7375
13	2.1033	2.0119	1.9909	1.9004	1.9728	1.9185	1.9185
14	2.3228	2.1948	2.19	2.3348	2.2443	2.2624	2.19
15	2.4874	2.3411	2.4072	2.4072	2.3529	2.3348	2.371
16	2.5579	2.3525	2.4832	2.3998	2.3819	2.2744	2.3211
17	2.2218	2.2032	2.2405	2.0376	2.2148	2.0953	2.167
18	2.0165	1.9605	2.1658	1.97	1.97	1.8267	1.8625
19	2.1285	2.1658	2.1098	2.0058	2.1312	1.949	2.1176
20	2.4459	2.3899	2.3339	2.2028	2.2744	2.167	2.1262
21	2.5766		2.4646	2.2923	2.4253	2.2744	2.2028
22	2.7759	2.7221	2.838	2.6886	2.782	2.6326	2.5789
23	3.1184	2.955	3.1181	3.0994	3.062	2.9874	2.9081
24	3.0624	3.0298	2.955	3.1181	3.1554	3.0807	3.006
Max	3.1184	3.0298	3.1181	3.1181	3.1554	3.0807	3.006
Min	1.6478	1.6278	1.6118	1.5565	1.5927	1.6289	1.5043
Avg	2.3003	2.2902	2.2619	2.2586	2.3050	2.2722	2.1614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 201 / WOMEN HOSPITAL EXPRESS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0762	.0762	.0572	.1288	.0762	.1143
2	.0953	.0762	.0762	.0572	.0892	.0762	.1265
3	.0953	.0762	.0762	.0572	.0671		.1204
4	.0953	.0762	.0762	.0572	.0572		.0762
5	.0953	.0762	.0762	.0953	.0648		.0762
6	.0762	.0815	.0762	.0953	.0976	.0823	.0777
7	.0762	.1562	.1196	.1372	.1441	.125	.1661
8	.058	.1501	.0953	.1197	.1616	.1135	.1669
9	.077	.077	.0831	.0907	.0564	.1105	.1097
10	.1593	.1631	.1776	.2157	.1776	.1722	.1608
11	.2286	.1906	.189	.2263	.2271	.1806	.1684
12	.2629	.2271	.1875	.2271	.2317	.1821	.1334
13	.2568	.2347	.1897	.2248	.224	.2073	.1936
14	.2599	.237	.2081	.2149	.224	.1982	.1951
15	.2423	.2309	.1852	.2027	.2141	.1822	.1791
16	.2477	.2218	.2005	.2218	.1997	.2065	.1897
17	.2202	.2172	.2111	.2271	.2103	.2134	.17
18	.2187	.2141	.205	.1722	.1906	.2103	.1807
19	.1417	.1783	.173	.1295	.138	.1128	.1288
20	.0953	.1273	.138	.1425	.1616	.0991	.0762
21	.0953	.1204	.1456	.0999	.1273	.0762	.0762
22	.0762	.1181	.1349	.1113		.0762	.0762
23	.0762	.0968	.1615	.0792		.0762	.0762
24	.0961	.0762	.0839	.1554	.0572	.0762	.0762
Max	.2629	.237	.2111	.2271	.2317	.2134	.1951
Min	.058	.0762	.0762	.0572	.0564	.0762	.0762
Avg	.1434	.1458	.1394	.1424	.1477	.1359	.1298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 202 / RAMDASPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.8921	4.9208	4.9634	4.8693	4.8895	4.8087	4.5923
2	4.6559	4.6197	4.7294	4.5386	4.5668	4.4239	4.3591
3	4.4374	4.2623	4.4574	4.1084	4.2435	4.0112	4.0787
4	4.2589	3.8553	4.3004	3.844	3.9568	3.8498	3.8896
5	4.068	3.7121	3.962	3.6061	3.7006	3.6217	3.456
6	3.6732	3.5193	3.6047	3.4347	3.3935	3.4135	3.1565
7	3.3038	3.2763	3.2617	3.1802	3.1832	3.1207	2.9005
8	3.0642	3.0544	2.998	3.0209	2.9683	2.8898	2.7054
9	2.9403	2.9492	1.547	3.0193	2.9451	2.7633	2.6452
10	2.9836	2.8053	2.0866	3.0544	2.9712	3.0499	2.6174
11	3.2464	2.9584	3.6452	3.1529	3.1893	3.2248	2.6406
12	3.6001	3.3753	3.4362	3.2459	3.3524	3.2956	2.7839
13	3.8195	3.5452	3.6511	3.4733	3.4904	3.6818	3.2732
14	4.0215	3.9964	4.1548	3.6976	3.7982	3.8973	3.5856
15	4.164	4.3629	4.3621	4.052	4.0627	4.188	3.7639
16	4.3918	4.3728	4.3581	4.1876	4.1549	4.1659	3.8927
17	4.0977	4.2211	4.1237	4.0489	4.0466	3.9533	3.789
18	3.3979	3.8767	3.7784	1.973	4.0215	3.6229	3.4656
19	3.5741	3.5216	3.581	3.4402	3.5186	3.3897	3.0852
20	3.8233	3.5978	3.7319	1.8435	3.6907	3.6374	3.3381
21	4.0855	3.8676	3.8934	3.847	3.8007	3.6572	3.5507
22	2.2359	4.103	4.1511	4.1834	2.0812	3.9727	3.6279
23	2.5004	4.6754	4.7844	4.767	2.3967	4.5023	4.0834
24	5.0785	5.0167	5.0137	4.9692	4.984	4.8149	4.5061
Max	5.0785	5.0167	5.0137	4.9692	4.984	4.8149	4.5923
Min	2.2359	2.8053	1.547	1.8435	2.0812	2.7633	2.6174
Avg	3.7631	3.8527	3.8573	3.6482	3.6419	3.7482	3.4911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 204 / D. P.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5731	.5975	.5487	.567	.6219	.5487	.4938
2	.5552	.5788	.5121	.5304	.5792	.5121	.4572
3	.5373	.5601	.5121	.5068	.5544	.4572	.4572
4	.5194	.5601	.5121	.4706	.4887	.4024	.4207
5	.4656	.4668	.439	.4344	.4435	.4024	.3658
6	.4477	.3734	.3658	.3982	.3439	.3696	.3109
7	3.2773	.3734	.3109	.3258	.3439	.3658	.3109
8	.3142	.3361	.3292	.3439	.3077	.3292	.3109
9	.3439	.4108	.3292	.3258	.362	.3109	.3109
10	.362	.462	.4024	.4298	.3801	.3658	.3077
11	.4755	.4525	.4755	.4668	.4755	.4477	.3696
12	.5121	.4706	.5249	.5601	.5121	.4887	.4572
13	.5487	.4887	.5792	.6535	.5487	.5068	.4755
14	.5853	.5973	.6401	.6401	.5487	.5068	.4755
15	.5853	.5611	.6878	.6401	.5853	.5249	.462
16	.5487	.5611	.6447	.6468	.5853	.5249	.462
17	.5121	.5068	.6219	.5853	.5601	.4656	.4572
18	.499	.5121	.567	.695	.5601	.439	.4938
19	.5544	.5487	.5611		.5228	.4755	.5249
20	.5544	.5487	.5792		.5601	.5121	.5373
21	.5729	.5121	.5249	.5792	.5601	.5121	
22		.5487	.5249	.5731		.5121	.5731
23		.5487	.6036	.5731		.5121	.5792
24	.5731	.5914	.5487	.5853	.6089	.5487	.5304
Max	3.2773	.5975	.6878	.695	.6219	.5487	.5792
Min	.3142	.3361	.3109	.3258	.3077	.3109	.3077
Avg	.6326	.5070	.5144	.5241	.5024	.4600	.4410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 207 / 11KV ICON HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.1905	.1715	.1905	.1715	.1905
2	.2096	.1905	.1715	.1715	.1905	.1524	.1715
3	.1905	.1905	.1715	.1715	.1905	.1524	.1715
4	.1905	.1905	.1715	.1715	.1905	.1715	.1715
5	.1715	.1715	.1715	.1524	.1715	.1715	.1524
6	.1715	.1715	.1715	.1524	.1715	.1524	.1715
7	.1663	.1905	.1905	.1524	.1715	.1905	.1524
8	.1991	.2096	.1524	.1524	.1905	.2096	.1334
9	.2286	.2286	.2096	.2286	.2286	.1905	.1905
10	.2353	.2477	.2477	.2477	.2667	.2286	.1905
11	.2477	.2286	.2218	.2096	.2667	.2477	.2286
12	.2286	.2477	.2286	.2667	.2667	.2667	.2286
13	.2286	.2477	.2286	.2096	.2667	.2667	.2286
14	.2286	.2667	.2667	.2286	.2667	.2667	.2286
15	.2286	.2096	.2858	.2477	.2667	.2667	.2096
16	.2096	.2667	.2667	.2477	.2667	.2667	.1905
17	.2096	.2477	.2477		.2667	.2477	.1905
18	.2667	.2477	.2096		.2667	.2667	.1905
19	.2477	.2477	.2286		.2858	.2667	.1905
20	.2096	.2477	.1715		.2286	.2477	.1905
21	.2096	.1905	.1715	.2286	.2096	.2477	.1629
22		.2096	.2096	.1905		.2286	.1715
23		.1829	.1905	.1905		.2096	.1629
24		.2286	.1905	.1715	.1829	.1715	.1905
Max	.2667	.2667	.2858	.2667	.2858	.2667	.2286
Min	.1663	.1715	.1524	.1524	.1715	.1524	.1334
Avg	.2137	.2204	.2069	.1981	.2274	.2191	.1858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 210 / 11 kvIncommer 1

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4253	2.4508	2.4508	2.3594	2.4394	2.3594	2.268
2	2.2923	2.2314	2.3777	2.1399	2.2361	2.1216	2.1948
3	2.1849	2.0119	2.268		2.0271	1.8656	2.0851
4	2.1312	1.8107	2.1948	1.7741	1.9774	1.8107	2.0485
5	2.0237	1.7741	1.9936	1.701	1.848	1.7193	1.7193
6	1.7193	1.7002	1.7558	1.6461	1.6108	1.6278	1.5364
7	1.5223	1.6448	1.6095	1.5181	1.5043	1.5524	1.4266
8	1.4685	1.5524	1.4815	1.5364	1.5154	1.4784	1.39
9	1.4784	1.4998	.0732	1.4815	1.4685	1.3717	1.3535
10	1.5384	1.4266	1.8656	1.5912	1.5384	1.6095	1.3394
11	1.7193	1.5181	1.773	1.6644	1.6827	1.6832	1.39
12	.6584	1.7741	1.7193	1.6644	1.8107	1.7013	1.4266
13	2.0668	1.8839	1.8823	1.8473	1.9022	1.9342	1.7741
14	2.1582	2.1399	2.2081	1.9022	1.9753	2.0237	1.9204
15	2.1582	2.2497	2.2207	2.0851	2.1216	2.0633	1.9387
16	2.2862	2.2314	2.1132	2.1216	2.1582	2.0774	1.9387
17	1.9753	2.0851	1.9547	2.0302	2.0302	1.9004	1.8839
18	1.4815	1.9022	1.829	1.7375	2.1033	1.7193	1.7375
19	1.9387	1.7924	1.829	2.0302	1.7924	1.7375	1.5746
20	2.0119	1.957	1.8656	1.9004	1.8656	1.9022	1.773
21	2.1399	2.0119	2.0119	1.9366	1.9204	1.9022	1.8642
22	2.268	2.1216	2.1399	2.1132		2.0851	1.9004
23	2.5606	2.4691	2.5057	2.4177		2.3594	2.0814
24	2.5252	2.524	.823	2.5133	2.4977	2.4874	2.3777
Max	2.5606	2.524	2.5057	2.5133	2.4977	2.4874	2.3777
Min	.6584	1.4266	.0732	1.4815	1.4685	1.3717	1.3394
Avg	1.9472	1.9485	1.8727	1.9005	1.9103	1.8789	1.7893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 211 / Incommmer No.2

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8131	.8501	.7682	.7499	.8238	.7499	.7133
2	.7701	.7947	.7133	.7133	.8326	.695	.6584
3	.7343	.7762	.7133	.6878		.6401	.6584
4	.7164	.7762	.7133	.6516	.7059	.6099	.6219
5	.6447	.6653	.6401	.5973	.6268	.6099	.5487
6	.6268	.5729	.567	.567	.543	.5487	.5121
7	.5068	.5914	.5304	.4938	.5729	.5914	.4938
8	.5194	.5729	.5121	.5068	.7762	.567	.4755
9	.5552	.6908	.5853	.5487	.6268	.5601	.5304
10	.6335	.7682	.695	.7602	.7343	.6468	.5249
11	.823	.724	.7947	.7577	.8413	.7682	.6283
12	.8779	.8145	.8326	.9425	.8779	.8501	.7207
13	.9145	.8326	.8596	.9795	.9145	.8507	.7392
14	.9511	.9593	.9774	.9795	.9145	.8507	.7392
15	.9511	.8779	1.0425	.9979	.9511	.8596	.7023
16	.8962	.9231	.9774	.9979	.9511	.8688	.6838
17	.8596	.8507	.9412	.905	.924	.8145	.6838
18	.8596	.8596	.8596	.985	.9055	.8048	.7133
19	.8962	.8779	.8688	.8775	.8589	.823	.7421
20	.8413	.8779	.8326	.8507	.8215	.823	.7602
21	.8501	.7316	.7059	.8413		.7865	.7783
22	.8686	.7865	.7499	.788		.7682	.7783
23	.8501	.7682	.7964	.7964		.7499	.7783
24	.8131	.8501	.7682	.7682	.8326	.7499	.7499
Max	.9511	.9593	1.0425	.9979	.9511	.8688	.7783
Min	.5068	.5729	.5121	.4938	.543	.5487	.4755
Avg	.7822	.7830	.7685	.7810	.8018	.7328	.6640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 401 / 33KV VIDYUT BHAVAN I/C

Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.8689	13.786	13.6283	13.3797	13.698	13.1413	12.7229
2	13.2442	12.9287	13.0247	12.8326	12.9538	12.4211	11.9753
3	9.465	12.2977	12.3114	11.7901	12.1948	11.5775	11.2826
4	11.7941	11.4266	11.6187	11.1935	11.4461	10.9877	10.6447
5	11.1168	10.8848	10.967	10.6378	10.6653	10.487	9.8834
6	10.439	10.3087	10.2126	10.0823	9.9223	9.808	9.1153
7	9.5611	9.6914	9.4787	9.3347	9.4021	9.0329	8.4362
8	8.6489	8.9643	8.7175	8.6352	8.67	8.327	7.7641
9	8.5671	8.7792	7.1605	8.5117	8.6111	8.1961	7.6617
10	8.7906	8.5734	4.9795	9.2867	9.1735	8.7312	7.7646
11	10.1921	9.4033	10.9539	9.9589	10.1029	9.988	8.3059
12	11.2894	10.5007	12.8401	10.5898	10.3704	10.3978	8.5871
13	11.8655	11.0768	19.9503	11.1865	11.1523	11.2597	9.417
14	12.3869	12.1468	20.659	11.9616	11.653	11.6952	10.3361
15	12.8327	13.0385	13.4088	12.7435	12.2977	11.3031	10.7956
16	13.4705	13.4705	13.6917	13.0385	12.5926	12.42	11.2071
17	13.0041	13.0796	13.307	12.7744	12.5309	12.3514	11.0151
18	11.7216	12.3663	12.3594	12.0085	12.2085	11.6461	10.3395
19	10.9122	11.262	11.3992	11.5198	11.1248	10.6036	9.6833
20	11.3237	11.0494	11.262	11.3135	11.1797	7.9904	10.0355
21	11.8655	11.4884	11.3855	11.4404	11.3169	10.8025	10.5544
22	12.4898	11.7558	11.5501	11.9513	8.4705	11.3032	10.7602
23	13.5528	12.5995	12.9287	12.8258	9.4307	12.1468	11.5581
24	14.2708	13.7586	13.6489	13.6968	13.2573	12.8738	12.3183
Max	14.2708	13.786	20.659	13.6968	13.698	13.1413	12.7229
Min	8.5671	8.5734	4.9795	8.5117	8.4705	7.9904	7.6617
Avg	11.5281	11.4432	12.1435	11.3622	11.0177	10.8121	10.0902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 410 / T/F no.1

Feeder KV- 33 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4949		2.4691	2.3045	2.384	2.3594	2.3045
2	2.3102		2.4143	2.0851	2.1719	2.1399	2.1948
3	2.2028		2.3045	1.9753	2.009	1.8656	2.0851
4	2.1491		2.1948	1.7558	1.9547	1.8107	2.0851
5	2.0416		2.0302	1.701	1.7918	1.7558	1.7558
6	1.7193		1.7558	1.5912	2.2177	1.6461	1.5364
7	1.5043		1.6461	1.4815	2.0513	1.5364	1.4266
8	1.4661		1.4815	1.4266	1.9959	1.4815	1.4266
9	1.4415		.1097	1.4969	1.1203	1.3717	1.3575
10	1.5203	1.4266	1.8656	1.4815	1.4661	1.6461	1.3575
11	1.7558	1.5364		1.701	1.701	1.6832	1.4266
12	1.9753	.7682	1.7193	1.701	1.8107	1.7375	1.4266
13	2.0851	1.8656	1.9004	1.8656	1.9204	1.9547	1.8107
14	2.1948	2.1399	2.1719	1.9204	1.9753	2.0416	1.9204
15	2.1948	2.2497	2.2262	2.0851	2.1399	2.0416	1.9753
16	2.3045	2.1948	2.1719	2.1622	2.1948	2.0416	1.9753
17	1.9753	2.0851	2.0302	2.0302	2.0302	1.9004	1.9753
18	1.4815	1.9204	1.701	1.7375	2.1399	1.7558	1.7375
19	1.9753	1.8107	1.8107		1.8296	1.7558	1.5746
20	2.0302	1.9753	1.8656		1.885	1.9204	1.7918
21	2.1399	2.0302	1.8656	1.9959	1.9204	1.9204	1.8461
22		2.1399	2.0302		2.4691	2.0851	1.9004
23		2.4691	2.3045	2.4977	2.5789	2.3594	2.009
24	2.6057	2.524	2.524	2.3045	2.4977	2.524	2.4143
Max	2.6057	2.524	2.524	2.4977	2.5789	2.524	2.4143
Min	1.4415	.7682	.1097	1.4266	1.1203	1.3717	1.3575
Avg	1.9804	1.9424	1.9388	1.8715	2.0107	1.8889	1.8047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024030 / VIDYUT BHAVAN S/S

Feeder No / Name : 411 / T./F NO. 2

Feeder KV- 33 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059		.7682	.7133	.8145	.7682	.7133
2	.7602		1.8107	.6584	.8059	.7133	.6584
3	.6984		.7133	.7133	.7602	.6584	.6584
4	.6516		.7133	.679	.6984	1.701	.6584
5	.6447		.6584	.6036	.6447	.6036	.5487
6			.6036	.5487	.5544	.5487	.5487
7	.5373		.5487	.4938	.543	1.701	.4938
8	.543		.5487	.439	.5373	.6036	.4938
9	.5373		.6036	.4938	.6653	.5601	.543
10	.6447	.7762	.7133	.6584	.7602		.5487
11	.823	.7682	.8145	.7682	.8779	.7602	.6653
12	.8779	.7602	.8145	.9425	.8779	.8145	.7133
13	.9328	.823	.8688	.9979	.9328	.8596	.7762
14	.9877	.9328	.9774	.9979	.9328	.8596	.7762
15	.9877	.8779	1.0317	.9979	.9877	.8596	.7207
16	.9328	.9328	.9979	2.9938	.9877	.8596	.7133
17	.8871	.8145	.9231	.9134	.9522	.8059	.7207
18	.8871	.8779	.8779	.9877	.9522	.823	.7133
19	.9425	.8779	.8688		.9425	.823	.7682
20	.8779	.8779	.8145		.8962	.823	.7602
21	.8871	.7682	.7059		.8402	.823	.9231
22		.823	.7059		.8316	.7682	.7602
23		.7682	.7133	.8059	.7682	.6584	.7602
24	.8145	.8871	.7682	.7133	.8059	.7682	.7682
Max	.9877	.9328	1.8107	2.9938	.9877	1.701	.9231
Min	.5373	.7602	.5487	.439	.5373	.5487	.4938
Avg	.7934	.8377	.8152	.8560	.8071	.8332	.6835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 201 / DAMANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6084	.6098	.6427	.5898	.6066	.6156	.6233
2	.6015	.6037	.6119	.5799	.5982	.6011	.6058
3	.5768	.5775	.6021	.5776	.5758	.5741	.5773
4	.5932	.5737	.5982	.5723	.572	.5889	.5743
5	.5761	.5767	.5967	.57	.5666	.5734	.5674
6	.5776	.549	.5796	.5356	.554	.557	.5449
7	.5116	.5204	.5053	.4941	.5053	.483	.5289
8	.4502	.4489	.4416	.417	.4224	.4289	.4668
9	.4258	.437	.4001	.3686	.3919	.3903	.4146
10	.3995	.3959	.4066	.3728	.3866	.4075	.4081
11	.3995	.4123	.4121	.4136	.4377	.4152	.3957
12	.4377	.4545	.4136	.4558	.4453	.4671	.4531
13	.4808	.4583	.4375	.4813	.4861	.4621	.4821
14	.5036	.4845	.4965	.5029	.4945	.4605	.4813
15	.5044	.4891	.525	.5034	.4983	.5147	.4904
16	.52	.5036	.5179	.4958	.5082	.5406	.4927
17	.5029	.5239	.4981	.4958	.5052	.5421	.5182
18	.4876	.493	.4735	.4703	.4697	.4596	.4886
19	.4792	.5037	.4739	.4713	.4625	.4652	.4709
20	.5523	.5739	.5916	.5697	.576	.57	.5543
21	.5851	.6569	.6081	.5868	.622	.6089	.5874
22	.627	.6722	.629	.6005	.665	.6344	.6064
23	.6445	.6821	.6566	.6457	.6756	.6558	.6349
24	.6282	.6426	.6428	.6252	.6386	.6471	.6375
Max	.6445	.6821	.6566	.6457	.6756	.6558	.6375
Min	.3995	.3959	.4001	.3686	.3866	.3903	.3957
Avg	.5281	.5351	.5317	.5165	.5277	.5276	.5252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 202 / GOYANAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1334	3.1293	3.0697	3.0857	3.1211	3.1135	3.0675
2	3.0184	3.0178	2.9626	3.0087	2.9895	3.0017	2.9447
3	2.9727	2.9436	2.8883	2.9498	2.9268	2.9575	2.905
4	2.918	2.906	2.8883	2.9417	2.8885	2.9323	2.8068
5	2.8984	2.887	2.8986	2.928	2.8525	2.9009	2.8689
6	2.8288	2.9093	2.8955	2.7899	2.9032	2.8484	2.7889
7	2.8357	2.873	2.9133	2.877	2.8723	2.8024	2.7305
8	2.8476	2.8338	2.8515	2.865	2.7955	2.8519	2.71
9	2.7315	2.674	2.6974	2.7412	2.7265	2.6848	2.7643
10	2.5546	2.4291	2.4995	2.5537	2.4616	2.4949	2.5015
11	2.3433	2.3868	2.476	2.5347	2.5474	2.4042	2.4548
12	2.3033	2.5617	2.599	2.6635	2.5626	2.5479	2.6196
13	2.4538	2.5181	2.6465	2.6457	2.6266	2.5787	2.6343
14	2.4267	2.5107	2.5873	1.3237	2.5329	2.5393	2.5396
15	2.4346	2.4897	2.556	2.3327	2.4468	2.4791	2.5008
16	2.4435	2.5093	2.5538	2.6234	2.4597	2.5421	2.5475
17	2.5129	2.6206	2.6303	2.6536	2.6065	2.5589	2.6348
18	2.4551	2.6389	2.6839	2.6427	2.5805	2.4817	2.7052
19	2.7833	2.9247	2.8791	2.8799	2.8853	2.7784	2.7307
20	3.3023	3.3219	3.2581	3.3676	3.3428	3.2417	3.1992
21	3.2356	3.2459	3.2173	3.2984	3.2572	3.1737	3.1663
22	3.1775	3.2366	3.1838	3.2242	3.0487	3.1023	3.1311
23	3.3153	3.2876	3.2569	3.2508	3.227	3.229	3.2863
24	3.2351	3.2276	3.1909	3.2003	3.1886	3.1741	3.2029
Max	3.3153	3.3219	3.2581	3.3676	3.3428	3.2417	3.2863
Min	2.3033	2.3868	2.476	1.3237	2.4468	2.4042	2.4548
Avg	2.7984	2.8368	2.8452	2.8076	2.8271	2.8091	2.8101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 204 / PANKAJ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7608	.7569	.7207	.7385	.7316	.72	.7133
2	.7423	.72	.7282	.7222	.7207	.72	.695
3	.6866	.7015	.6838	.7052	.695	.6831	.695
4	.7052	.7015	.6653	.6845	.6838	.6831	.6584
5	.6866	.6831	.6838	.6915	.7023	.6646	.6584
6	.6495	.6646	.6415	.6309	.6468	.6461	.6099
7	.6309	.6092	.6048	.5938	.6219	.5908	.5729
8	.6124	.5908	.5853	.5646	.592	.5908	.6099
9	.5938	.5908	.5853	.6124	.6277	.5723	.6036
10	.5567	.5169	.5304	.5567	.5908	.5723	.5914
11	.5381	.5723	.5354	.5354	.5567	.5381	.5908
12	.5938	.5908	.5908	.5908	.6124	.5567	.5723
13	.5567	.4985	.5908	.6092	.5753	.5938	.6092
14	.6309	.6309	.6461	.6092	.6124	.5753	.6092
15	.6309	.6277	.6461	.6092	.6124	.5938	.6277
16	.6124	.5938	.6277	.6277	.6309	.5908	.6092
17	.6309	.6309	.6277	.6277	.6495	.6124	.6092
18	.6092	.668	.5938	.6277	.6124	.5567	.5908
19	.6646	.6653	.6461	.6584	.668	.6219	.6199
20	.72	.7023	.7015	.7023	.7569	.7316	.6831
21	.7569	.7468	.72	.695	.7385	.7316	.7423
22	.8123	.7392	.7015	.7133	.7754	.7499	.7385
23	.7754	.7577	.7754	.7762	.7754	.7682	.7423
24	.7794	.7754	.7577	.7385	.7499	.7569	.7499
Max	.8123	.7754	.7754	.7762	.7754	.7682	.7499
Min	.5381	.4985	.5304	.5354	.5567	.5381	.5723
Avg	.6640	.6556	.6496	.6509	.6641	.6425	.6459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 205 / NEW TAPADIYA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.55	1.5379	1.5264	1.5242	1.5295	1.515	1.4556
2	1.4784	1.4481	1.4426	1.4706	1.4502	1.4557	1.4052
3	1.4387	1.3849	1.374	1.422	1.3793	1.3864	1.3648
4	1.4115	1.3643	1.3366	1.3572	1.3412	1.362	1.2994
5	1.3716	1.3133	1.3039	1.2817	1.3168	1.3034	1.2628
6	1.3259	1.2836	1.297	1.2177	1.2643	1.2189	1.1828
7	1.2215	1.1991	1.166	1.1811	1.1759	1.1253	1.0951
8	1.1086	1.1328	1.0227	1.0605	1.0476	1.0308	.9838
9	1.0079	1.0346	.98	.9779	.9769	.9501	.9594
10	1.0172	.9562	.9434	.969	.9586	.9524	.9
11	.9698	.9523	.9622	.925	.9863	.9741	.9257
12	.9741	.9927	.9988	.9691	.9432	.9697	.9729
13	1.1026	1.0507	1.0536	1.0301	1.0438	1.053	1.0346
14	1.1971	1.164	1.1473	1.0932	1.1144	1.1404	1.1389
15	1.2611	1.2566	1.2303	1.1724	1.187	1.2554	1.1892
16	1.2779	1.2139	1.2288	1.2706	1.2516	1.2321	1.2318
17	1.2527	1.1778	1.1961	1.2965	1.2176	1.1795	1.1938
18	1.2207	1.1207	1.1712	1.1961	1.175	1.1431	1.1199
19	1.2104	1.1889	1.2051	1.1774	1.175	1.1012	1.1744
20	1.3079	1.2871	1.2844	1.243	1.2775	1.2255	1.2425
21	1.365	1.3702	1.3332	1.2811	1.3574	1.259	1.2159
22	1.4913	1.4586	1.4099	1.4403	1.4221	1.3527	1.3252
23	1.4877	1.5813	1.5241	1.5935	1.5682	1.4853	1.451
24	1.5677	1.5919	1.5531	1.5617	1.573	1.5348	1.4853
Max	1.5677	1.5919	1.5531	1.5935	1.573	1.5348	1.4853
Min	.9698	.9523	.9434	.925	.9432	.9501	.9
Avg	1.2757	1.2526	1.2371	1.2380	1.2389	1.2169	1.1921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 206 / Ashok nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8317	3.8146	3.8037	3.7868	3.8234	3.7654	3.6869
2	3.7126	3.6933	3.6371	3.7112	3.7113	3.654	3.5924
3	3.65	3.6253	3.5002	3.6287	3.6374	3.5587	3.514
4	3.6004	3.5544	3.5094	3.579	3.568	3.5236	3.4538
5	3.5866	3.5476	3.4827	3.5507	3.5711	3.5268	3.45
6	3.5438	3.452	3.4405	3.4289	3.4118	3.3724	3.1954
7	3.4895	3.3161	3.3875	3.3509	3.3295	3.1994	3.1246
8	3.3693	3.1826	3.152	3.2155	3.3655	3.1079	3.1687
9	3.1787	3.0635	3.0277	3.0433	3.26	2.9559	2.9096
10	2.8866	3.128	2.8365	2.7557	3.0732	2.8315	2.9981
11	2.7678	2.952	2.566	2.7584	2.9575	2.7197	3.0083
12	2.7265	2.8279	2.7029	2.8347	2.9947	2.8139	1.4281
13	2.808	2.8751	2.8454	2.8957	3.1243	2.8665	2.9584
14	2.9053	2.9453	2.9163	1.5173	3.0315	2.9298	3.0599
15	2.9459	2.8407	2.9866	2.9172	2.9535	2.8781	3.1257
16	2.9146	2.9768	2.94	2.9598	2.9475	2.9026	3.1341
17	2.8764	2.9466	2.9757	2.969	2.9076	2.8963	3.0523
18	2.8614	2.9629	2.9397	2.9117	2.8862	2.8366	2.9263
19	3.2166	3.2798	3.1616	3.1123	3.2892	2.9873	3.0158
20	3.6224	3.7666	3.7027	3.7182	3.6839	3.4972	3.6095
21	3.7217	2.6535	3.7277	3.7532	3.7892	3.6222	3.6651
22	3.8293	3.8447	3.7533	3.8683	3.8372	3.719	3.7682
23	4.0224	3.9605	3.9392	3.9498	3.9036	3.8477	3.8826
24	3.9832	3.9596	3.9037	3.9281	3.9224	3.8395	3.8187
Max	4.0224	3.9605	3.9392	3.9498	3.9224	3.8477	3.8826
Min	2.7265	2.6535	2.566	1.5173	2.8862	2.7197	1.4281
Avg	3.3354	3.2987	3.2849	3.2560	3.3741	3.2438	3.2311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 210 / 11KV Incommer no.I NTN

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.2135	5.1889	5.144	5.1307	5.1497	5.1593	5.0308
2	5.0241	4.9987	4.9097	4.9585	4.9326	4.9555	4.8617
3	4.9012	4.8391	4.7233	4.8589	4.7782	4.8392	4.7577
4	4.8544	4.776	4.7371	4.7823	4.7005	4.8107	4.5885
5	4.7535	4.7095	4.6971	4.6804	4.6365	2.3571	4.5782
6	4.6985	4.6718	4.6593	4.4488	4.601	4.5451	4.4124
7	4.4924	2.3	4.4742	4.4673	4.4433	4.3037	4.1964
8	4.3355	4.3626	4.2296	4.2347	4.2084	4.2334	4.0604
9	4.1202	4.1063	3.9952	4.0093	4.0333	3.9531	4.0513
10	3.9319	3.7161	3.7757	3.841	3.7394	3.7885	3.7197
11	3.6337	3.6791	3.7642	3.8109	3.8876	3.7466	3.7154
12	3.6496	3.9489	3.9534	4.0281	3.8294	3.912	3.9834
13	3.9796	3.9609	4.0865	4.1003	4.0437	4.0089	4.1025
14	4.0551	4.0624	4.1496	2.8485	4.061	4.0268	4.0589
15	4.1365	4.1805	4.2334	3.9491	4.0414	4.3935	4.0688
16	4.1787	4.1262	4.2216	4.2967	4.133	4.2388	4.1919
17	4.1997	4.2179	4.2574	4.3713	4.2454	4.1813	4.248
18	4.0987	4.1802	4.2343	4.2252	4.1558	3.989	4.2363
19	4.4163	4.5308	4.497	4.3778	4.459	4.2524	4.3063
20	5.1069	5.1029	5.0635	5.1126	5.1093	4.96	4.9192
21	5.0857	5.1429	5.0411	5.0651	5.1572	4.9337	4.8793
22	5.2231	5.2377	5.1417	5.1578	5.0251	4.9703	4.9703
23	5.3169	5.4195	5.3652	5.3749	5.3813	5.2652	5.2898
24	5.293	5.3534	5.2778	5.1442	5.2995	5.2548	5.2138
Max	5.3169	5.4195	5.3652	5.3749	5.3813	5.2652	5.2898
Min	3.6337	2.3	3.7642	2.8485	3.7394	2.3571	3.7154
Avg	4.5291	4.4505	4.5263	4.4698	4.5022	4.3783	4.4350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 211 / 11KV Incommer no.2 NTN

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3046	3.2624	3.2739	3.2841	3.3105	3.2074	3.2739
2	3.2474	3.1341	3.1459	3.2291	3.2007	3.2074	3.2007
3	3.174	3.1158	3.091	3.3784	3.1459	3.0608	3.0727
4	3.174	3.0241	3.0544	3.12	3.0727	3.0425	3.0361
5	3.1569	3.0241	3.0361	3.1384	3.1093	3.0608	2.9995
6	3.0646	2.8408	2.9081	2.9169	2.9264	2.8958	2.652
7	2.8984	2.6392	2.6703	2.9723	2.7984	2.6209	2.524
8	2.7877	2.5317	2.5423	2.5661	2.6998	2.6026	2.6886
9	2.6215	2.4743	2.524	2.5477	2.6584	2.5109	2.5057
10	2.3631	2.5293	2.3594	2.4554	2.88	2.4193	2.652
11	2.3815	2.6026	2.291	2.4743	2.5292	2.2934	2.7125
12	2.3815	2.456	2.5476	2.5476	2.5846	2.3826	2.5843
13	2.3851	2.4	2.5843	2.5843	2.6769	2.4554	2.7492
14	2.5846	2.5476	2.6392	1.1913	2.6769	2.4923	2.6942
15	2.5869	2.5293	2.6942	2.7125	2.5477	2.4376	2.7859
16	2.5846	2.6215	2.6576	2.7125	2.5846	2.4926	2.7492
17	2.5869	2.0492	2.6026	2.6942	2.6584	2.4923	2.6392
18	2.5109	2.6886	2.5846	2.6759	2.5846	2.4035	2.5659
19	3.0241	3.1093	2.8592	2.9938	2.9691	2.7618	2.8042
20	3.2624	3.3288	3.2257	3.4004	3.3724	3.3105	3.2441
21	3.2807	3.3471	3.323	3.2922	3.3513	3.3836	3.2624
22	3.3724	3.4385	3.3174	3.4568	3.4457	3.3836	3.3196
23	3.4457	3.4934	3.5261	3.5117	3.464	3.4385	3.4126
24	3.4707	3.354	3.3471	3.3392	3.4202	3.299	3.3471
Max	3.4707	3.4934	3.5261	3.5117	3.464	3.4385	3.4126
Min	2.3631	2.0492	2.291	1.1913	2.5292	2.2934	2.5057
Avg	2.9021	2.8559	2.8669	2.8831	2.9445	2.8190	2.8948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 401 / 33 kv I/C Appatapa to New
Tapd Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.9434	5.7253	5.8162	5.7493	5.8162	5.6708	5.7613
2	5.6946	5.5617	5.5418	5.628	5.6516	5.6163	5.5967
3	5.5303	5.4527	5.3772	5.5303	5.487	5.3982	5.4321
4	5.5303	5.3436	5.4321	5.4641	5.3772	5.4038	5.2675
5	5.4755	5.2891	5.3772	5.4208	5.4321	5.3436	5.3224
6	5.3113	5.1255	5.2675	4.9827	5.2126	5.071	4.7737
7	4.9827	4.7984	4.8285	4.928	4.9383	4.6348	4.5542
8	4.8185	4.6348	4.6091	4.5447	4.6542	4.6893	4.6639
9	4.5447	4.3621	4.4445	4.4352	4.5447	4.4167	4.6091
10	4.2162	4.2531	4.1701	4.2709	4.5447	4.1986	4.4993
11	4.1067	4.4167	4.1986	4.3076	4.4352	4.1067	4.4712
12	4.1614	4.4213	4.4712	4.5257	4.4899	4.3257	4.5803
13	4.3804	4.2531	4.5803	4.5803	4.5995	4.3621	4.7438
14	4.5447	4.5305	4.6893	1.963	4.6445	4.4899	4.6893
15	4.5995	4.5447	4.7438	4.7984	4.4899	4.4712	4.7438
16	4.5447	4.5995	4.6893	4.8529	4.5447	4.5257	4.7984
17	4.6542	4.1614	4.6893	4.8529	4.709	4.4712	4.6893
18	4.4712	4.709	4.6542	4.7438	4.5447	4.2162	4.5803
19	5.2346	5.487	5.1255	5.2669	5.2565	4.9931	5.0348
20	5.7798	5.8711	5.7253	5.9877	5.8889	5.7613	5.7253
21	5.7253	5.9259	5.7253	5.7613	5.8889	5.8162	5.6163
22	5.9434	6.0905	5.8344	6.0905	5.8889	5.8711	5.7253
23	6.0525	6.2003	6.107	6.2003	6.107	6.0905	6.0525
24	6.0231	5.9434	5.9259	5.9136	6.0357	5.8344	5.9259
Max	6.0525	6.2003	6.107	6.2003	6.107	6.0905	6.0525
Min	4.1067	4.1614	4.1701	1.963	4.4352	4.1067	4.4712
Avg	5.0945	5.0709	5.0843	5.0333	5.1326	4.9908	5.0774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 410 / Transformer no.1

Feeder KV- 33 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5188	2.524	2.524	2.4589	2.524	2.524	2.4691
2	2.4769	2.4691	2.4143	2.4218	2.4143	2.4143	2.4143
3	2.4369	2.3594	2.3045	2.4218	2.3594	2.3594	2.3594
4	2.4042	2.3594	2.3594	2.4218	2.3045	2.4143	2.2497
5	2.3668	2.3045	2.3594	2.3668	2.3045	2.3045	2.3045
6	2.3117	2.3045	2.3594	2.0916	2.3045	2.1948	2.1399
7	2.1466	2.1948	2.1948	2.2016	2.1399	2.0302	2.0302
8	2.0916	2.1399	2.0302	1.9815	1.9815	2.0851	1.9753
9	1.9324	1.9204	1.9204	1.9264	1.9324	1.9204	2.0851
10	1.8714	1.7558	1.8107	1.8656	1.7063	1.8107	1.8107
11	1.7613	1.8107	1.9204	1.8656	1.9264	1.8107	1.8107
12	1.8164	1.9753	1.9753	2.0302	1.9164	1.9204	2.0302
13	1.9815	1.9204	2.0302	2.0302	1.9733	1.9753	2.0302
14	1.9609	2.0302	2.0851	.823	1.9877	2.0217	2.0302
15	2.0365	2.0365	2.0851	2.1399	1.9753	2.0851	1.9753
16	2.0365	2.0302	2.0851	2.1399	2.0302	2.0851	2.0851
17	2.0894	2.0851	2.0851	2.1948	2.0916	2.0302	2.0851
18	1.9753	2.0302	2.0829	2.0851	2.0302	1.8656	2.0302
19	2.2497	2.3594	2.3237	2.2731	2.2949	2.1948	2.2016
20	2.524	2.5789	2.524	2.6057	2.5789	2.4691	2.524
21	2.4691	2.5789	2.4923	2.4949		2.4143	2.4143
22	2.6337	2.6337	2.5789	2.6337	2.4691	2.524	2.4691
23	2.6337	2.7435	2.6886	6.2003	2.6886	2.6886	2.6886
24	2.5628	2.6337	2.5789	2.2567	2.6337	2.5789	2.5789
Max	2.6337	2.7435	2.6886	6.2003	2.6886	2.6886	2.6886
Min	1.7613	1.7558	1.8107	.823	1.7063	1.8107	1.8107
Avg	2.2203	2.2408	2.2422	2.3305	2.1986	2.1967	2.1997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024042 / 33Kv New TapdiyaNagar S/S

Feeder No / Name : 411 / Transformer no.2

Feeder KV- 33 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.323	3.2205	3.2922	3.2785	3.2922	3.1692	3.2922
2	3.2238	3.1113	3.1276	3.1692	3.1824	3.1692	3.1824
3	3.1145	3.1113	3.0727	3.1145	3.1276	3.0599	3.0727
4	3.1145	3.0021	3.0727	3.0599	3.0727	3.0053	3.0178
5	3.1145	3.0053	3.0178	3.0599	3.1276	3.0599	3.0178
6	3.0053	2.8413	2.9081	2.8413	2.9081	3.2238	2.6337
7	2.8413	2.6228	2.6886	2.7321	2.7984	2.6228	2.524
8	2.7321	2.5135	2.524	2.5135	2.6774	2.5681	2.6886
9	2.5681	2.4563	2.524	2.5135	2.6228	2.5135	2.524
10	2.3496	2.5109	2.3594	2.4042	2.8413	2.4042	2.6337
11	2.3496	2.5681	2.2925	2.4589	3.0599	2.2949	2.6774
12	2.3496	2.4589	2.5135		2.5135	2.3496	2.5681
13	2.3496	2.3496	2.5681	2.5681	2.6228	2.4042	2.7321
14	2.5681	2.5135	2.6228	1.2021	2.6228	2.4589	2.6774
15	2.5681	2.5135	2.6774	2.6774	2.5135	2.4143	2.7867
16	2.5135	2.5681	2.6228	2.6774	2.5135	2.4589	2.7321
17	2.5681	2.0217	2.5681	2.6774	2.6228	2.4589	2.6228
18	2.4563	2.7054	2.5681	2.6774	2.5135	2.3496	2.5681
19	3.0053	3.1276	2.8413	2.963	2.9506	2.7435	2.7867
20	3.2205	3.3471	3.2238	3.3471	3.3331	3.2922	3.2238
21	3.275	3.3819	3.2785	3.2922		3.4019	3.2238
22	3.3296	3.4568	3.2785	3.4568	3.4424	3.4019	3.2785
23	3.4388	3.5117	3.4424	3.5117	3.4424	3.4568	3.3878
24		3.3296	3.3471	3.3331	3.4019	3.2785	3.3471
Max	3.4388	3.5117	3.4424	3.5117	3.4424	3.4568	3.3878
Min	2.3496	2.0217	2.2925	1.2021	2.5135	2.2949	2.524
Avg	2.8426	2.8437	2.8513	2.8491	2.9219	2.815	2.8833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 201 / 11 KV ITI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.46	1.5154	1.4784	1.4969	1.4415	1.3676	1.2936
2	1.386	1.4415	1.3491	1.46	1.2936	1.3121	1.2012
3	1.3306	1.386	1.2382	1.2936	1.2382	1.2382	1.1088
4	1.2567	1.3121	1.2012	1.2382	1.1643	1.1458	1.0534
5	1.1643	1.2567	1.1458	1.2012	1.0903	1.1088	.9979
6	1.0903	1.1827	1.1273	1.1643	.9795	1.0903	.961
7	1.0719	1.1458	1.0534	1.0719	.961	.9795	.961
8	1.0903	1.1458	1.0164	1.0719	1.0534	1.0534	.9795
9	1.2012	1.3676	1.0719	1.1088	1.0534	1.1643	.961
10	1.3121	1.4045	1.2012	.3881	1.2012	1.2382	1.0534
11	1.7002	1.6632		.4066	1.4415	1.4969	1.2197
12	1.9589	1.8296	1.848	.462	1.6632	1.6632	1.4045
13	2.1253	1.9774	1.9404	.8316	1.7556	1.7741	1.4045
14	2.1068	2.0144	.5359	1.7926	1.7741	1.8296	1.423
15	2.0698	2.1437	1.885	1.8665	1.848	1.9589	1.4415
16		2.1068	2.1068	1.8111	1.8111	1.9404	1.5154
17	1.9959	2.0698	1.8665	1.7002	1.6817	1.8296	1.4784
18	1.848	1.8665	1.848	1.6263	1.5893	1.6263	1.2936
19	1.9589	1.9959	1.922		1.7002	1.7926	1.3121
20	2.0328	1.9774	1.9589	1.848	1.7926	1.885	1.4045
21	1.8111	1.8111	1.7926	1.7741	1.7556	1.7187	1.386
22	1.6632	1.7002	1.6448	1.6078	1.4784	1.4969	1.46
23	1.6632		1.6078	1.6263	1.4969	1.5154	1.3306
24	1.5708	1.5893	1.6448	1.5524	1.5339	1.4045	1.423
Max	2.1253	2.1437	2.1068	1.8665	1.848	1.9589	1.5154
Min	1.0719	1.1458	.5359	.3881	.961	.9795	.961
Avg	1.6030	1.6480	1.4993	1.3218	1.4499	1.4846	1.2528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 202 / 11 KV MHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3326	.2957	.3142	.3142	.3142	.2772
2	.3142	.3142	.2587	.3142	.2772	.2772	.2587
3	.2957	.2957	.2587	.2772	.2402	.2402	.2587
4	.2772	.2772	.2402	.2402	.2218	.2402	.2402
5	.2587	.2402	.2218	.2402	.2033	.2218	.2218
6	.2033	.2033	.2218	.2218	.2033	.2218	.2033
7	.2033	.2033	.2033	.1848	.1848	.2033	.2218
8	.2587	.1848	.2218	.1663	.2402	.1848	.1848
9	.2402	.1663	.1848	.1663	.2033	.1478	.1478
10	.1663	.1848	.1663	.1663	.1663	.1294	.1478
11	.2033	.1848		.1848	.1663	.1663	.1663
12	.2218	.2033	.2218	.1848	.1848	.2033	.2033
13	.2218	.2218	.2402	.2402	.2402	.2402	.1848
14	.2402	.2587	.2587	.2402	.2957	.2587	.2218
15	.2772	.2957	.2957	.2772	.2957	.3326	.2957
16		.3142	.2957	.3326	.2743	.2772	.2957
17	.2402	.2402	.2218	.2402	.2402	.2772	.2587
18	.2402	.2033	.1848	.2218	.2033	.1848	.2033
19	.2033	.2218	.1848		.2033	.2033	.1848
20		.2402	.2033	.2218	.2402	.2218	.1663
21	.2402	.2218	.2587	.2033	.2587	.2402	.1848
22	.3142	.2772	.2957	.2772	.3142	.2957	.2587
23	.3696		.3511	.3326	.3511	.2772	.2957
24	.3696	.3511	.3326	.3326	.3511	.3696	.3326
Max	.3696	.3511	.3511	.3326	.3511	.3696	.3326
Min	.1663	.1663	.1663	.1663	.1663	.1294	.1478
Avg	.2587	.2451	.2443	.2426	.2447	.2387	.2256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 203 / 11 KV SHITALA MATA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.6401	.5487	.6036	.5853	.6036	.5487
2	.6099	.6036	.5121	.5853	.5304	.5487	.4755
3	.5544	.567	.4755	.5121	.4938	.4572	.4207
4	.5175	.5304	.4755	.4755	.4755	.4207	.3658
5	.4805	.4755	.439	.439	.4755	.4024	.3475
6	.4251	.439	.439	.4024	.3841	.3841	.3292
7	.3511	.3841	.3841	.3658	.3841	.3475	.2561
8	.3696	.4207	.3658	.3658	.3475	.3658	.2743
9	.3511	.3841	.4207	.3658	.3696	.3658	.2743
10	.4805	.4755	.4755	.4435	.4755	.3841	.2561
11	.5544	.5544		.5544	.5487	.4938	.2743
12	.6401	.567	.6219	.6468	.6036	.5304	.3841
13	.7133	.6401		.6653	.6401	.567	.4755
14	.7133	.6584	.7133	.6838	.6767	.6767	.5304
15	.7499	.7316	.7316	.7392	.7316	.7133	.5487
16		.7133	.7316	.7207	.695	.7133	.567
17	.7133	.7133	.5853	.6767	.6767	.6584	.4938
18	.6036	.6036	.5487	.439	.567	.6036	.4572
19	.6584	.6767	.6584		.6584	.6036	.4938
20	.6283	.6219	.6219	.6036	.695	.6036	.4572
21	.5487	.5853	.5121	.5304	.5487	.5304	.439
22	.6283	.5853	.5487	.567	.567	.5304	.4572
23	.6584		.6036	.6401	.6036	.5853	.5487
24	.6653	.6584	.6401	.6584	.6584	.6401	.6036
Max	.7499	.7316	.7316	.7392	.7316	.7133	.6036
Min	.3511	.3841	.3658	.3658	.3475	.3475	.2561
Avg	.5774	.5752	.5479	.5515	.5580	.5304	.4283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOLA URBAN DIVISION[150]

AKOLA U-III S/DN[592] BU 4592

Substation No/ Name :- 024047 / 33/11 kv SUBSTATION ITI

AKOLA

Feeder No / Name : 207 / 11 KV INCOMMER

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4579	2.4949	2.3285	2.396	2.347	2.2916	2.1253
2	2.3101	2.3655	2.1253	2.3411	2.1068	2.1437	1.9404
3	2.1807	2.2546	1.9774	2.0668	1.9774	1.9404	1.7926
4	2.0513	2.1253	1.922	1.9589	1.8665	1.8111	1.6632
5	1.9035	1.9774	1.8111	1.885	1.7741	1.7372	1.5708
6	1.7187	1.8296	1.7926	1.7926	1.5708	1.7002	1.4969
7	1.6263	1.7372	1.6448	1.6263	1.5339	1.5339	1.4415
8	1.7187	1.7556	1.6078	1.6078	1.6448	1.6078	1.4415
9	1.7926	1.922	1.6817	1.6448	1.6263	1.6817	1.386
10	1.9589	2.0698	1.848	.9979	1.848	1.7556	1.46
11	2.4579	2.4025		1.1458	2.1622	2.1622	1.6632
12	2.8275	2.6057	2.6981	1.2936	2.4579	2.4025	1.9959
13	3.0678	2.846		1.7372	2.6427	2.5873	2.0698
14	3.0678	2.9384	1.5154	2.7166	2.7536	2.7721	2.1807
15	3.1047	3.1786	2.9199	2.8829	2.8829	3.0123	2.2916
16		3.1417	3.1093	2.8645	2.7905	2.9384	2.384
17	2.9569	3.0308	2.652	2.6242	2.6057	2.7721	2.2361
18	2.6981	2.6797	2.5606	2.2916	2.3655	2.4209	1.9589
19	2.8275	2.9014	2.7435		2.5688	2.6057	1.9753
20	2.9014	2.846	2.7618	2.6797	2.6797	2.7166	
21	2.6057	2.6242	2.5423	2.5133	2.5688	2.4949	2.0144
22	2.6057	2.5688	2.4949	2.4579	2.3655	2.3285	2.1807
23	2.6981		2.5688	2.6057	2.4579	2.384	2.1807
24	2.6057	2.6057	2.6242	2.5503	2.5503	2.4209	2.3655
Max	3.1047	3.1786	3.1093	2.8829	2.8829	3.0123	2.384
Min	1.6263	1.7372	1.5154	.9979	1.5339	1.5339	1.386
Avg	2.4410	2.4740	2.2695	2.1165	2.2562	2.2592	1.905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024012 / KUTASA

Feeder No / Name : 201 / 11 KV KUTASA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2614	.2587	.2402	.2427	.2587	.2427
2	.2614	.2402	.2587	.2402	.2452	.2587	.2427
3	.2402	.2452	.2402	.2218	.2218	.2402	.1848
4	.2402	.2241	.2402	.2218	.2241	.2402	.1478
5	.2054	.2054	.2218	.2033	.2033	.2218	.112
6	.2054	.1663	.1848	.1663	.168	.2033	.112
7	.112	.112	.1663	.1478	.112	.1294	.0934
8	.0934	.0924	.0924	.0924	.0934	.1109	.0934
9	.0934	.0924	.0924	.1109	.0934	.1109	.1307
10	.1109	.1294	.1109	.112	.0924	.112	.1109
11	.1494	.1109	.1294	.1294	.1294	.1307	.1307
12	.1646	.1294	.1478	.1494	.1663	.168	.1478
13	.1867	.1848	.1663	.1848	.1663	.1867	.1867
14	.2033	.2218	.1848	.1867	.1848	.2054	.2054
15	.2054	.2033	.2033	.2033	.1848	.2054	.2218
16	.1829	.1848	.1663	.1848	.1848	.2054	.1867
17	.1494	.1478	.1294	.1494	.1478	.1307	.1478
18	.1307	.1109	.0924	.1494	.1109	.1307	.1109
19	.132	.1478	.1109	.1307	.1294	.1307	.132
20	.1867	.2033	.1848	.2241	.2033	.2054	.2054
21	.2587	.2402	.2402	.2263	.2033	.2427	.2452
22	.2427	.2772	.2402	.2614	.2587	.2614	.2427
23	.2614	.2957	.2402	.2641	.2402	.2614	.2481
24	.2614	.2641	.2587	.2402	.2427	.2587	.2614
Max	.2614	.2957	.2587	.2641	.2587	.2614	.2614
Min	.0934	.0924	.0924	.0924	.0924	.1109	.0934
Avg	.1891	.1871	.1817	.1850	.1770	.1921	.1726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024012 / KUTASA

Feeder No / Name : 202 / 11KV Dahihanda

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7655	.7167	.6838	.6838	.7167	.7392	.6908
2	.7282	.7095	.6838	.6838	.7095	.6838	.6908
3	.6468	.6722	.6653	.6468	.6653	.6838	.6283
4	.6283	.6602	.6653	.6283	.6348	.6653	.5544
5	.5975	.5975	.6653	.5914	.6161	.6468	.5228
6	.5601	.4668	.6283	.5359	.5228	.5175	.4668
7	.4481	.3547	.5544	.4251	.3881	.4435	.4108
8	.3734	.3326	.3881	.4435	.3734	.3696	.3734
9	.3547	.3511	.3881	.4251	.4251	.3881	.3734
10	.4435	.4251	.4435	.4108	.4251	.4668	.3881
11	.4668	.4251	.462	.462	.4805	.4481	.4481
12	.5121	.499	.5175	.5041	.5175	.4854	.462
13	.5788		.5544	.5729	.462	.5975	.5788
14	.6099	.5729	.6099	.6161	.4805	.6348	.6161
15	.6219	.6099	.6099	.6099	.499	.583	.5975
16	.5788	.6099		.5914	.499	.5975	.5359
17	.5415	.5544	.5175	.4854	.462	.5228	.5228
18	.4904	.462	.4435	.4854	.462	.4668	.4435
19	.5601	.5359	.4805	.5228	.5544	.5041	.4854
20	.7282	.6468	.6653	.7167	.7207	.6348	.6602
21	.7282	.7207	.7392	.7468	.7392	.7468	.7468
22	.7468	.7392	.7577	.7733	.7207	.7468	.7468
23	.7468	.7392	.6838	.7545	.7392	.7282	.6024
24	.7655	.7468	.7023	.7207	.7282	.7392	.7282
Max	.7655	.7468	.7577	.7733	.7392	.7468	.7468
Min	.3547	.3326	.3881	.4108	.3734	.3696	.3734
Avg	.5926	.5717	.5874	.5849	.5642	.5850	.5531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 201 / 11 KV TAKLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3696	.3696	.362	.3696	.3801	.3801
2	.3475	.3734	.3658	.3547	.3696	.3582	.3658
3	.3475	.3734	.3658	.3475	.3361	.362	.362
4	.3326	.3734	.3658	.3511	.3292	.362	.3511
5	.3547	.3547	.3258	.3511	.3258	.3801	.3326
6	.2772	.2801	.2715	.2743	.2507	.0848	.2896
7	.2353	.2378	.2279	.1991	.1734	.0686	.1949
8	.1949	.2126	.1753	.1907	.1646	.0693	.1772
9	.1772	.5316	.1772	.1772	.1829	.2374	.1907
10	.1991	.1907	.1949	.197	.1595	.218	.197
11	.1991	.2126	.2012		.1791	.2401	.2149
12	.2172		.2353	.2195	.2303	.2353	.2353
13	.2378		.2715	.2743	.2353	.2743	.2715
14	.3109		.2896	.3109	.2743	.3077	.3077
15	.2947		.2743	.2743	.2865	.298	.3224
16	.2658		.2715	.2715	.2534	.2149	.2865
17	.2353		.2303	.2328	.2103	.197	.2658
18	.1928		.1772	.1949	.1886	.2254	.2835
19	.2865	.2587	.2601	.2865	.2303	.2658	.3012
20	.3658	.3982	.3439	.3982	.3898	.362	.362
21	.4066	.4024	.3841	.4024	.3982	.3801	.3658
22	.4066	.4024	.3881	.3658	.3982	.439	.439
23	.3881	.4024	.4024	.3696	.394	.4066	.4024
24	.3734	.3696	.3658	.3658	.3696	.3801	.3982
Max	.4066	.5316	.4024	.4024	.3982	.439	.439
Min	.1772	.1907	.1753	.1772	.1595	.0686	.1772
Avg	.2917	.3379	.2890	.2944	.2791	.2811	.3041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 202 / 11 KV RAIL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7577	.7499	.7392	.6767	.7316	.7282	.695
2	.7468	.7392	.7207	.6653	.695	.7023	.7095
3	.7392	.7392	.7282	.6401	.7023	.7023	.6908
4	.7282	.7392	.7095	.6468	.6838	.695	.6653
5	.7392	.7133	.6838	.6653	.6173	.695	.6584
6	.5914	.5973	.5914	.5359	.5415	.5487	.5544
7	.5487	.5068	.4066	.3841	.4207	.4252	.439
8	.439	.3898	.362	.362	.3881	.4298	.4119
9	.4607	.4298	.3841	.2865	.4251	.3856	.4344
10	.4477	.3856	.3801	.4344	.439	.394	.4207
11		.4119	.4163	.4525	.4572	.3658	.443
12	.4607		.5121	.4572	.4938	.3511	.4755
13	.567		.5068	.5121	.462		.5121
14	.4081		.5304	.5175			.5487
15	.6335	.2881	.5068	.543		.4477	.5729
16	.567	.2858	.2957		.3841	.4207	.543
17	.4733	.2782	.4207		.3403	.3801	.4887
18	.3721		.4887	.4887	.4557	.4784	.4656
19	.5792	.5853	.5914	.6401	.5731	.5853	.543
20	.7343	.7762	.6653	.7682	.724	.7577	.695
21	.7964	.7392	.6722	.7392	.7865	.7577	.7095
22	.8779	.7762	.7282	.7947	.7947	.7392	.7207
23	.8596	.7762	.7207	.7842	.7947	.7499	.7207
24	.7499	.7682	.7392	.6838	.7316	.7392	.7392
Max	.8779	.7762	.7392	.7947	.7947	.7577	.7392
Min	.3721	.2782	.2957	.2865	.3403	.3511	.4119
Avg	.6208	.5838	.5625	.5763	.5746	.5672	.5774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 203 / 11 KV CHOHATA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.8596	.7865	.7842	.8048	.7947	.8131
2	.8029	.8326	.7682	.7468	.8048	.7682	.7922
3	.7682	.8326	.7762	.7207	.7602	.7682	.7682
4	.7682	.823	.7316	.7133	.7602	.7682	.7468
5	.7762	.8145	.7164	.7316	.7164	.7682	.691
6	.6283	.6626	.6805	.6089	.5731	.6626	.6001
7	.5487	.5609	.5434	.5493	.5201	.5609	.5487
8	.5138	.4961	.463	.5487	.4973	.5487	.4508
9	.4835	.5138	.5256	.5658	.5658	.5548	.4908
10	.6036	.5658	.6241		.6024	.5895	.5138
11	.6733		.6859	.6201	.6556	.6935	.567
12	.7265		.6836	.6379	.6878	.815	.6268
13	.8238		.7164	.7442	.7602	.788	.6878
14	.8596		.7682	.7701	.823	.7701	.724
15	.8413		.7947	.8059	.8145	.7362	.7164
16	.8505		.7343	.7619	.8145	.7442	.6733
17	.8413		.3988	.7442		.7011	.6241
18	.3721		.6201	.6241	.7461	.6001	.6661
19	.8413	.7468	.3109	.7455	.8063	.7712	.691
20	1.0136	.8779	.3326	.9214	.905	.8869	.8954
21	.9511	.8686		.9134	.9511	.8596	.8779
22	.9511	.8779	.8869		.9145	.8596	.8413
23		.8779	.8596	.8326	.8413	.8596	.823
24	.7947	.8596	.8048	.8048	.8145	.8048	.8048
Max	1.0136	.8779	.8869	.9214	.9511	.8869	.8954
Min	.3721	.4961	.3109	.5487	.4973	.5487	.4508
Avg	.7498	.7544	.6614	.7225	.7452	.7364	.6931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024013 / 33 KV CHOHATA

Feeder No / Name : 204 / 11 KV KELIVELI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.3696	.3772	.3658	.3921	.3772	.3658
2	.3841	.3696	.3772	.3696	.3734	.3772	.3696
3	.3921	.3658	.3772	.3511	.3772	.3772	.3475
4	.3696	.3475	.3547	.3547	.3734	.3734	.3547
5	.3921	.3439	.3547	.3547	.3547	.3361	.3292
6	.3326	.2715	.3174	.2957	.2987	.2987	.2772
7	.2926	.2149	.2218	.2241	.2241	.2218	.1829
8	.2172	.2149	.2033	.2218	.1991	.2149	.2033
9	.2481	.1991	.1829	.2218	.2149	.2172	.2012
10	.2353	.2303	.2033	.2241	.2195	.2218	.2054
11	.2715	.2149	.2241	.2353	.2241	.2587	.2241
12	.2896	.2149		.2658	.2218	.2987	.2481
13	.2915	.2218	.2587	.2835	.2801	.3326	.2835
14	.3121	.2241	.2743	.3045	.3326	.3326	.3012
15	.3121	.2614	.2743	.3224	.3109	.3326	.3077
16	.2658	.2587	.2957	.3258	.3109	.2926	.3077
17	.2353	.2195	.2054	.2658	.2896	.2561	.2743
18	.2058	.2378	.2378	.2012	.2507	.2353	.2957
19	.3189	.2715	.3109	.2957	.2715	.2452	.3142
20	.4066	.3734	.3921	.3475	.3841	.4066	.3921
21	.4108	.415	.3921	.3841	.4066	.3921	.3841
22		.4108	.3921	.3841	.4108	.4108	.3982
23		.3961	.3881	.3921	.4108	.3658	.3982
24	.4066		.3772	.3734	.3921	.3734	.3921
Max	.4108	.415	.3921	.3921	.4108	.4108	.3982
Min	.2058	.1991	.1829	.2012	.1991	.2149	.1829
Avg	.3174	.289	.3040	.3069	.3135	.3145	.3066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 201 / 11 KV UMARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.6154	.567	.6219	.3658	.6036	.4755
2	2.1582	1.8138	1.9387	.6219	.2926	.6036	.4207
3	2.1948	1.8138	1.9204	.6219	.2926	.6036	.4024
4	2.1948	1.8138	1.8839	.5853	.2561	.6036	.3658
5	2.1948	1.9433	1.8656	.5853	.2561	.5487	.3292
6	1.829	1.9433	1.829		.2561	.3658	.2926
7	1.829	1.6248	1.829	.2743	.2561		.2743
8	2.0485	1.7814	1.829	.2195	.2561	.2195	.2743
9	2.0119	1.7814	1.6827	.2195	.2743	.2195	.2926
10	.1943	.2743	.2195	2.0485	1.829	2.0119	2.0119
11	.2591	.2743		2.0851	2.0302	2.1948	1.7814
12	.2591	.3292		2.0851	2.0851	2.3045	1.7814
13	.3239	.3292	.3658	2.1216	2.0851	2.268	1.7814
14	.3239	.2926	.4024	2.1216	2.0302	2.1582	1.7814
15	.3239	.2926	.439	2.1033	2.0119	2.0485	1.7814
16	.2591	.2561	.439	2.1033	1.9387	2.0485	1.7814
17	.2591	.2561	.4024	2.0119	1.9936	2.0485	1.7814
18	.2896	.3109		.4755	.3109	.5853	.3258
19	.5068	.4024		.439	.4024	.4024	.3982
20	.5792	.5487		.5487	.5487	.5853	.5792
21	.6516	.567	.6401	.6584	.6219	.6219	.5792
22	.6516	.5853		.6584	.6219	.6219	.6154
23	.6516	.5853	.6401	.6401	.6219	.6219	.6154
24	.5853	.6154	.5853	.4572	.6219	.6036	.5487
Max	2.1948	1.9433	1.9387	2.1216	2.0851	2.3045	2.0119
Min	.1943	.2561	.2195	.2195	.2561	.2195	.2743
Avg	.9652	.8771	1.0822	1.0568	.9275	1.0823	.8863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 202 / 11 KV KASOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4904	.4755	.4715	.4572	.4904	.4755
2	1.0562	.8383	1.0059	.4904	.4572	.4527	.4024
3	1.1128	.8383	1.0242	.4904	.439	.4527	.3841
4	1.1128	.8383	1.0425	.4904	.4207	.4527	.3658
5	1.1317	.9221	1.0608	.4715	.3658	.4527	.3292
6	1.1694	.9724	1.0974	.3772	.2926	.3395	.2926
7	1.226	1.0322	1.1523	.2641	.2561	.2452	.2561
8	1.3014	1.0364	1.134	.1886	.1829	.2263	.2012
9	1.2826	.9998	1.0791	.2075	.2012	.1886	.2195
10	.2452	.2743	.1886	1.226	1.1888	1.3014	.9145
11	.3018	.2561	.2641	1.3169	1.3203	1.2803	1.0898
12	.3395	.2926	.2641	1.3169	1.4146	1.2986	1.0898
13	.3772	.2926	.3395	1.2071	1.3957	1.2986	1.1065
14	.3772	.2926	.3584	1.2254	1.2803	1.2803	1.1065
15	.3772	.3109	.3772	1.2437	1.3392	1.1888	1.1065
16	.3395	.3475	.3772	1.2803	1.3203	1.2071	1.1065
17	.3206	.3109	.2641	1.2071	1.2826	1.2254	1.0898
18	.2641	.2561		.2561	.2452	.2378	
19	.415	.3109	.3772	.3109	.2641	.3109	.3395
20	.4527	.4572	.4338	.439	.4338	.4024	.4527
21	.5281	.4755	.5093	.4572	.4715	.4572	.4715
22	.5281	.4755	.6036	.5121	.4904	.4755	.5093
23	.5281	.4755	.4904	.4938	.4904	.4938	.5093
24	.4904	.4904	.4755	.4715	.4755	.4904	.4938
Max	1.3014	1.0364	1.1523	1.3169	1.4146	1.3014	1.1065
Min	.2452	.2561	.1886	.1886	.1829	.1886	.2012
Avg	.657	.5536	.6259	.6840	.6869	.6771	.6223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 203 / 11 KV BORDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.4527	.3841	.3481	.3841	.3315	1.39
2	.2321		.3841	1.2929	1.4449	1.3592	1.4632
3	.2321		.3658	1.3426	1.4632	1.3592	1.5729
4	.2321		.3292	1.3592	1.4998	1.3592	1.5729
5	.2321		.3292	1.3592	1.5364	1.3592	1.6095
6	.1823		.2743	1.4586	1.7558		1.6461
7	.1326	.2263	.1646	.2652	1.829	1.5912	1.6827
8	.116	.2263	.1463	1.442	1.7558	1.5415	1.701
9	.0995		.1463	1.5415	1.7558	1.5581	1.7558
10	1.166	1.7558	1.7238	.1989	.2012	.1658	.1829
11	1.6842	1.9387	1.757	.2195	.1989	.2195	.2263
12	1.9433	1.9753	1.7736	.2012	.2321	.2378	.2641
13	1.8785	2.0119	1.757	.2012	.2321	.2926	.2641
14	1.8461	2.0119	1.7404	.1829	.2321	.2926	.2641
15	1.8138	1.9753	1.6741	.1829	.2486	.2743	.2641
16	1.8138	1.9753	1.6907	.2195	.2321	.2743	.2263
17	1.8138	1.9753	1.6575	.1646	.2321	.2378	.2263
18	.2263	.1829	.1658	.2195	.1658	.1829	.1886
19	.3018	.2561	.2818	.3109	.2321	.2378	.2641
20	.3772	.3841	.3481	.3841	.3149	.3109	.3772
21	.4527	.4024	.3647	.4024	.3647	.3658	.3772
22	.4527	.4024	.2096	.4024	.3647	.3658	.415
23	.4527	.4024	.3647	.3841	.3481	.3658	.415
24		.4527	.3841	.3481	.3841	.3315	1.3352
Max	1.9433	2.0119	1.7736	1.5415	1.829	1.5912	1.7558
Min	.0995	.1829	.1463	.1646	.1658	.1658	.1829
Avg	.7789	1.0560	.7674	.6013	.7254	.6354	.8202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024014 / 33 KV UMARA

Feeder No / Name : 204 / 11 KV ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.543	.5853	.5487	.6036	.5487	1.7375
2	.5121	.4534	2.3045	1.1706	1.7558	1.1888	1.6827
3	.5121	.4534	2.3045	1.1706	1.7193	1.1888	1.6644
4	.5121	.4534	2.268	1.1706	1.6827	1.1888	1.6095
5	.5121	.3239	2.2314	1.2071	1.6461	1.1888	1.5364
6	.3658	.2267	2.2314	1.1706	1.6095	1.3717	1.4998
7	.3658	.2267	2.1948	1.1523	1.5364		1.4632
8	.3292	.2267	2.1948	1.3535	1.4632	1.39	1.3535
9	.3292	.1619	2.0851	1.1523	1.4632	1.39	1.4266
10	1.166	1.39	1.3717	.2195	2.1948	.2012	2.268
11	1.166	1.4632	1.3169	2.0851	.2012	2.1948	.2591
12	1.166	1.5364	1.2803	2.3411	.3658	2.4874	.2591
13	1.1336	1.6095	1.3352	2.4143	.3658	2.4508	.2915
14	1.166	1.6461	1.39	2.4143	.3658	2.3594	.2915
15	1.166	1.6461		2.396	.3658	2.268	.3239
16	1.1984	1.6827		2.3777	.439	2.2862	.2591
17	1.1984	1.6827		2.268	.3658	2.3045	.2267
18	.2896		1.4449	.4755	.2743	.5853	.2896
19	.4344	.4207	1.1157	.4755	.3475	.4024	.362
20	.5068	.5487	.5487	.5487	.4755	.5853	.5068
21	.543	.567	.5853	.6036	.567	.6219	.5068
22	.543	.5853	.5853	.6584	.567	.6219	.5792
23	.543	.5853	.2321	.6401	.5487	.6219	.5792
24	.5487	.543	.5853	1.3535	.6219	.4938	1.7924
Max	1.1984	1.6827	2.3045	2.4143	2.1948	2.4874	2.268
Min	.2896	.1619	.2321	.2195	.2012	.2012	.2267
Avg	.6982	.8250	1.4377	1.3070	.8977	1.3018	.9487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 201 / 11 KV PANAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9719	2.0858	1.9033	2.0851	1.8229	2.1582	2.0271
2	1.7804	1.9456	1.8604	2.0119	1.7528	2.1582	1.9936
3	1.7295	1.9281	1.8642	2.0119	1.7177	2.0485	1.9022
4	1.7703	1.9105	1.8461	1.9753	1.6476	2.0485	1.848
5	1.6975	1.9281	1.8823	1.957	1.6827	2.0119	1.8298
6	1.7147	1.9456	1.8642	1.6827	1.6126	1.7375	1.7924
7	1.869	1.9806	1.9631	1.6461	1.4198	1.3535	1.363
8	2.0285	1.9806	1.9806	1.3535	1.3847	1.3717	1.3032
9	1.9938	1.9806	1.9719	1.3535	1.2795	1.3717	1.3756
10	1.448	1.3496	1.1584	2.0271	2.1559	1.8347	2.0748
11	1.3672	1.448	1.3352	2.0508	2.1735	2.1434	2.1033
12	1.3146	1.4403	1.5203	1.858	2.0683	2.1434	2.1559
13	1.6651	1.5604	1.6651	1.9281	2.0683	2.0919	2.1033
14	1.4723	1.5604	1.7194	1.9456	2.0683	2.0111	2.1209
15	1.5074	1.5775	1.7194	1.9806	2.0332	2.0458	2.0508
16	1.595	1.5947	1.7194	2.0157	2.0631	2.0458	2.1033
17	1.4548	1.4737	1.5384	2.0508	2.0631	2.0458	2.0858
18	1.2445	1.2308	1.5546	1.3146	1.4266	1.3213	1.262
19	1.6301	1.6289	1.5912	1.5249	1.4815	1.3756	1.4723
20	1.8755	1.9879	2.2177	1.9281	2.1807	1.7737	1.9105
21	2.0332	2.1091	2.2177	2.0332	2.1807	2.0157	1.9281
22	2.1735	2.2119	2.2916	2.0858	2.2916	2.2624	2.0858
23	2.1559	2.2291	2.268	2.1384	2.268	2.2986	1.9982
24	2.1085	2.1209	1.8861	2.1399	2.0858	2.1948	2.1399
Max	2.1735	2.2291	2.2916	2.1399	2.2916	2.2986	2.1559
Min	1.2445	1.2308	1.1584	1.3146	1.2795	1.3213	1.262
Avg	1.7334	1.8004	1.8141	1.8791	1.8720	1.9110	1.8762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 202 / 11 KV AKOLI J

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.065	1.1142	1.0814	1.1305	.9667	1.1142	.9339
2	1.0486	.8848	1.0159	.8848	.9339	1.0814	.9503
3	.9831	.9339	1.0486	.8848	.9175	1.0814	.9831
4	.9503	.852	.9503	.9012	.9831	1.065	1.0322
5	.9175	.8192	.8684	.9012	.8688	1.0486	.9995
6	.9012	.8029	.9012	.9995	.9831	.9339	1.0486
7	.8192	.7701	.7537	1.065	1.0814		1.1633
8	.6882	.6718	.5898	1.1888	1.0978		1.2125
9	.6554	.6554	.6062	1.065	.9012		1.1633
10	1.1469	1.0978	.9667	.6554	.7209	1.0322	.6882
11	1.2452	1.2289	1.0978	.639	.7373	1.065	.7209
12	1.2125	1.1633	.1966	.6718	.7537	.8029	.6882
13	1.2289	1.0814	1.0486	.8192	.852	.9012	.8192
14	1.2452	1.065	1.0486	.7865	.9175	.8848	.9175
15	1.2125	1.1142	1.0159	.8192	.9175	.9012	.852
16	1.2452	1.1469	.9667	.8848	.852	.9175	.8029
17	1.2616	.9831	1.0814	.7865	.7865	.7865	.7865
18	.6226	.5735	.9503	.639	.7045	.6062	.6062
19	.7537	.7373	.8192	1.0486	.6718	.7373	.7045
20	1.0159	1.065	1.0486	1.0814	.9175	1.0322	1.1469
21	1.1961	1.0978	1.1469	1.1305	1.1142	1.1961	1.1305
22	1.2125	1.1469	1.1797	1.1142	1.1633	1.1633	1.1633
23	1.1797	1.1305	1.1797	1.1633	1.1633	1.1797	1.1142
24	1.1142	1.1469	1.1142	1.1305	1.1469	1.1305	.9012
Max	1.2616	1.2289	1.1797	1.1888	1.1633	1.1961	1.2125
Min	.6226	.5735	.1966	.639	.6718	.6062	.6062
Avg	1.0384	.9701	.9449	.9329	.9230	.9839	.9387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024015 / 33 KV PANAJ

Feeder No / Name : 203 / 11 KV RUIKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2439	.2134	.2439	.2439	.2134	.2591	.2286
2	1.5699	1.7833	1.7833	.2439	.2134	.2591	.2286
3	1.6461	1.829	1.7528	.2439	.2439	.2439	.1981
4	1.6766	1.8442	1.7375	.2439	.2286	.2439	.2134
5	1.7071	1.829	1.7223	.2591	.2134	.2286	.1981
6	1.7223	1.829	1.7375	.1981	.1829	.1829	.1829
7	1.8138	1.8442	1.768	.1981	.1677	.1677	.1677
8	1.8442	1.8442	1.7528	.1677	.1524	.1372	.1677
9	1.829	1.7528	1.7071	.1219	.1219	.1372	.1372
10	.1524	.1524	.1219	1.7985	1.7071	1.829	1.8442
11	.1524	.1524	.1677	1.7528	1.8138	1.7528	1.768
12		.1677	.1829	1.7985	1.8442	1.829	1.7985
13	.1829	.1981	.1829	1.768	1.829	1.89	1.7223
14	.1677	.1981	.1829	1.7375	1.829	1.8747	1.7071
15	.1829	.1981	.1829	1.6766	1.8138	1.9052	1.6766
16	.1829	.1981	.1829	1.6461	1.8138	1.829	1.6461
17	.1677	.1524	.1677	1.6766	1.8138	1.89	1.6309
18	.1524	.1219	.1524	.1219	.1524	.1372	.1219
19	.1981	.1677	.1524	.2134	.1524	.1677	.1372
20	.2591	.2743	.2134	.2896	.2591	.2591	.1981
21	.3048	.2896	.2743	.3048	.2743	.2896	.2286
22	.2743	.2896	.2743	.2439	.2743	.2591	.2743
23	.2896	.2743	.2743	.2591	.2743	.2743	.2439
24	.2439	.2439	.2591	.2591	.2439	.2591	.2439
Max	1.8442	1.8442	1.7833	1.7985	1.8442	1.9052	1.8442
Min	.1524	.1219	.1219	.1219	.1219	.1372	.1219
Avg	.7376	.7437	.7157	.7278	.7430	.7627	.7068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 201 / 11 KV BORDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7392	.7468	.6859	.7392	.7468	.7621
2	1.1469	1.1279	1.0669	.5487	.7392	.7468	.7621
3	1.1469	1.1279	1.0669	.6173	.7392	.7468	.7621
4	1.1736	1.1279	1.0669	.6173	.7392	.7468	.6722
5	1.1469	1.1279	1.0669	.6173	.5975	.6722	.6722
6	1.2452	1.1439	1.0669	.6173	.5228	.5228	.5914
7	1.2163	1.1439	1.0669	.5601	.4668	.4481	.4435
8	1.2803	1.0856	.0533	.381	.3696	.4481	.4854
9	1.2742	1.0562	1.1203	.3772	.3734	.4481	.3429
10	.381	.394	.4481	1.0814	1.0669	1.1203	1.07
11	.4481	.4854		1.0669	1.0974	1.1203	1.0936
12	.5041	.4854	.5144	1.0669	1.1248	1.1469	1.0936
13	.5121	.5975	.5487	1.0669	1.1203	1.1469	1.0837
14	.5121	.5975	.5487	1.0536	1.1203	1.0974	1.1138
15	.499	.5975	.5975	1.0364	1.1203	1.0974	1.1138
16	.5175	.5228	.6097	1.0364	1.1469	1.1279	1.07
17	.5175	.4854	.5716	1.0364	1.1469	1.0974	1.07
18	.4024	.4481	.5144	.4066	.5601	.5601	.3982
19	.5975	.7468	.5335	.5975	.6722	.5335	.7095
20	.6908	.7468	.7621	.7095	.7468	.7621	.7095
21	.7095	.7468	.7621	.7392	.7468	.7621	.7468
22	.7762		.8002	.7392		.8002	.8029
23	.7655		.7621	.7468		.7621	.7842
24		.7468	.7468	.7392	.7392	.7468	.7621
Max	1.2803	1.1439	1.1203	1.0814	1.1469	1.1469	1.1138
Min	.381	.394	.0533	.3772	.3696	.4481	.3429
Avg	.7924	.7855	.7409	.7560	.8044	.8087	.7965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 202 / 11 KV RAMAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1524	.1494	.1524	.1494	.1494	.1524
2	1.6766	1.6461	1.6766	.1524	.1494	.1494	.1524
3	1.7147	1.6255	1.6766	.1143	.1494	.1494	.1524
4	1.7147	1.6255	1.6766	.1143	.1494	.1143	.1524
5	1.7147	1.6644	1.6766	.1143	.1494	.0762	.0762
6	1.8515	1.7017	1.6766	.1029	.0934	.0762	.0762
7	1.8842	1.7604	1.7071	.1143	.0362	.0762	.0857
8	1.9006	1.7604	1.6004	.0747	.0381	.0572	.1143
9	1.7604	1.7375	1.5623	.0381	.0572	.0572	.0857
10	.0762	.0362	.1143	1.9006	1.829	1.3717	1.448
11	.0762		.1143	1.829	1.7985	1.4746	
12	.0953	.0572	.1524	1.829	1.7985	1.6385	1.6766
13	.0953		.1524	1.7833	1.7604	1.6766	1.5844
14	.0953		.0953	1.7535	1.7604	1.6575	1.5844
15	.0953	.0762		1.709	1.7604	1.8671	1.4118
16	.0953		.0953	1.6644	1.7604	1.467	1.2689
17	.0953		.0953	1.8061	1.7394	1.6766	1.1126
18	.0572	.0762	.0762	.0709	.1494	.0572	.0549
19	.1143	.1494	.0762	.0924	.1494	.0762	.0953
20	.1494	.1494	.1143	.112	.1494	.0953	.1143
21	.1494	.7468	.1524	.1494	.1494	.1143	.1494
22	.1524		.1524	.1494		.1524	.1494
23	.1524		.1524	.1494		.1524	.1494
24	.1334	.1524	.1494		.1494	.1494	.1143
Max	1.9006	1.7604	1.7071	1.9006	1.829	1.8671	1.6766
Min	.0572	.0362	.0762	.0381	.0362	.0572	.0549
Avg	.6652	.8893	.6563	.6946	.7239	.6055	.5201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 203 / 11 KV POPATKHEDE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0056	1.0288	1.0631	1.1568	1.0288	1.1203
2	1.0288	1.0056	1.0288	1.0288	1.1568	1.0402	.9335
3	1.0288	1.0056	1.0288	1.0288	1.1568	1.0402	.9335
4	1.0288	1.0056	1.0288	1.0288	1.1218	1.0402	.9335
5	1.0288	.823	1.0288	1.0288	1.0402	1.0402	.924
6	.8573	.7545	.8573	.8954	.9465	1.0402	.7282
7	.8573	.6859	.7545	.823	.8288	.6859	.8215
8	.8573	.7545	.6173	.823	.8619	.8573	.8962
9	.8916	.78	.6173	.8573	.7712	.8573	.823
10	.9709	.7865	.7888	.8573	.9709	.8573	.8916
11	.8573		.8573	.8573	.8478	.9335	.7888
12	1.0288	.8916	.8573		.9259	.9335	.7888
13	1.0974		.8573		1.0288	.9335	.8669
14	1.0631		.9335	1.0631	1.0288	.9335	.8322
15	1.0402	.8916	.9816	1.0631	1.0288	.9335	.7888
16	1.0402		1.0402	1.0985	.8573	.9335	.7716
17	1.0056		.8916	1.0517	.8573	.9335	.7545
18	.8421	.9945	.8916	.8951	1.0402	.8962	.7537
19	.9709	1.0288	.9259	1.0288	1.0517	.9709	.8573
20	1.0517	1.0288	1.0288	1.1218	1.0867	.8916	1.0631
21	1.0517	1.0288	1.0517	1.182	1.0867	1.1203	1.0745
22	1.0631	1.0631	1.0288	1.2536		1.1203	1.0745
23	1.0631		1.0288	1.2178		1.1203	1.0387
24	1.0288	1.0056	1.0288	1.1104	1.2048	1.0402	1.1203
Max	1.0974	1.0631	1.0517	1.2536	1.2048	1.1203	1.1203
Min	.8421	.6859	.6173	.823	.7712	.6859	.7282
Avg	.9909	.9189	.9243	1.0172	1.0026	.9659	.8991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 204 / 11 KV MOHADA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.9071
2				2.572	2.5095	2.3472	1.9281
3				2.572	2.5434	2.3472	1.9281
4				2.572	2.5434	2.3472	1.8861
5				2.572	2.5149	2.3472	1.9071
6				2.572	2.5194	2.4006	1.9204
7				2.7435	2.5194	2.0119	2.2405
8				2.572	2.4577	1.8442	2.2291
9				2.5034	2.5149	1.9662	2.0576
10	3.1893	2.2634	2.6882				
11	3.2922		2.915				
12	3.155	2.6216	3.0521				
13	3.155		3.1207				
14	3.155		3.0864				
15	3.155	2.5301	2.8292				
16	3.12		2.8635				
17	3.034		3.0178				
24							1.9547
Max	3.2922	2.6216	3.1207	2.7435	2.5434	2.4006	2.2405
Min	3.034	2.2634	2.6882	2.5034	2.4577	1.8442	1.8861
Avg	3.1569	2.4717	2.9466	2.5849	2.5153	2.2015	1.9959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024031 / 33KV LAKHAMAPUR

Feeder No / Name : 205 / water supply express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1494	.1734	.1307	.1307	.1867	.1494
2	.1029	.1494	.1734	.1307	.1307	.1867	.1478
3	.1029	.1494	.1734	.112	.1307	.1867	.1478
4	.1029	.1494	.1734	.1307	.1307	.1867	.1494
5	.1029	.1494	.1734	.1307	.1307	.1791	.1307
6	.1029	.1494	.1734	.1307	.112	.1753	.1307
7	.1029	.1478	.1387	.1307	.1494	.1463	.1307
8	.112	.1463	.1387	.1029	.1307	.1463	.12
9	.0934	.1433	.1387	.0934	.1307	.1463	.12
10	.0934	.128	.1387	.1029	.1307	.1463	.056
11	.0934		.1029	.112	.112	.112	.0747
12	.0934	.1029	.1029	.112	.1075	.112	.0732
13	.0934		.112	.1307	.1052	.112	.0914
14	.0934		1.0288	.112	.104	.112	.0549
15	.0934	.1029	.112	.112	.1052	.112	.0549
16	.0934		.112	.112	.1052	.0747	.0549
17	.112	.1029		.112	.1052	.112	.0549
18	.112	.1029	.112	.0747	.1494	.056	.0732
19	.112	.1886	.112	.0934	.1494	.056	.056
20	.112	.1886	.112	.112	.1494	.112	.0373
21	.128	.1886	.112	.112	.1494	.1494	.0187
22	.1463		.1307	.112		.168	.0187
23	.1478		.1294	.112		.1494	.0747
24	.1029	.1494	.1734	.1307	.1307	.1867	.1494
Max	.1478	.1886	1.0288	.1307	.1494	.1867	.1494
Min	.0934	.1029	.1029	.0747	.104	.056	.0187
Avg	.1064	.1438	.1760	.1144	.1263	.1379	.0904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 201 / 11 KV RUIKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5281	.5281	.5014	.6036	.4854	.4481
2	1.2483	1.2955	1.1843	.5014	.5658	.4854	.4481
3	1.2483	1.2955	1.2163	.5014	.5281	.4854	.4481
4	1.2163	1.3123	1.2163	.394	.4527	.4854	.415
5	1.3123	1.3123	1.2803	.2865	.4527	.4527	.415
6	1.3443	1.3443	1.2803	.2865	.3772	.4527	.3772
7	1.3763	1.4403	1.4083	.2865	.3018	.3772	.2641
8	1.4723	1.4403	1.3763	.2865	.3018		.2641
9	1.5364	1.3123	1.3443	.3018	.2641		.2263
10	.2614	.3018	.2507	1.4403	1.6964		1.7078
11	.3395		.3582	1.6324	1.6872		1.7604
12	.3772	.3772	.3582	1.6644	1.6872	1.3599	
13	.3772	.4108	.3582	1.6644	1.6872	1.6762	1.7604
14	.415	.4108	.3395	1.6644	1.7078	1.6129	1.7604
15	.4108	.4108	.3395	1.6324	1.7078	1.6446	1.6004
16	.3772	.4108	.3395	1.6644	1.7711	1.6446	1.6004
17	.3395	.3326	.3395	1.6004	1.7394	1.4083	1.6004
18	.3018	.3018	.3395	.3018	.2641	1.4403	.2865
19	.3772	.3018	.4527	.3395	.415		.2561
20	.5281	.5281	.4904	.4527	.5228	.4904	.5014
21	.5658	.5658	.4904	.4904	.5601	.4904	.5014
22	.5658	.5658	.5281	.4904	.5601	.4854	.5014
23	.5658	.5658	.5281	.5658	.5228	.4854	.5014
24	.4904	.5281		.5014	.6036	.4854	.4481
Max	1.5364	1.4403	1.4083	1.6644	1.7711	1.6762	1.7604
Min	.2614	.3018	.2507	.2865	.2641	.3772	.2263
Avg	.7307	.7519	.7107	.8105	.8742	.8657	.7866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024033 / 33 kv RUIKHED

Feeder No / Name : 203 / 11 KV VASTAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.4755	.5544	2.1491	.5175	.4694	1.4864
2	.4805	.4805	.5175	1.9204	1.6964	1.6446	1.4864
3	.439	.439	.4805	1.9204	1.7284	1.6129	1.4998
4	.4435	.4024	.4805	1.9204	1.8138	1.6446	1.4998
5	.4435	.4024	.4805	2.0805	1.8564	1.6644	1.531
6	.3658	.3658	.4435	2.0805	1.8564	1.6762	1.6129
7	.3658	.2561	.3326	2.0805	1.9204	1.6762	1.7711
8	.3696	.2561	.2957	2.0805	1.8564	1.6644	1.8027
9	.3326	.2195	.2957	2.0729	1.8244	1.7394	1.906
10	2.0485	2.0165	2.0805	.2195	.2926	.2347	.2683
11	2.2405	2.0485	2.2725		.3018	.2683	.3224
12	2.1765	2.0165	2.2725	.2561	.2683	.2683	.2865
13	2.119	2.0165	2.2725	.2534	.3018	.2683	.2865
14	2.0805	2.0485	2.0485	.2534	.3018	.2683	.2865
15	2.0805	2.0165	2.0485	.2561	.3018	.2683	.2865
16	2.1125	2.0165	2.0241	.2561	.3018	.2347	.2865
17	2.3045	2.0485	2.0485	.2561		.2321	.2865
18	.3658	.3326	.3292	.3326	.3353	.2683	.4298
19	.5121	.4435	.5121	.4024	.4024	.3688	.4298
20	.5792	.5914	.5068	.4755	.503	.4694	.5373
21	.6219	.6283	.5487	.5853	.57	.503	.5373
22	.5853	.5853	.5121	.5853	.5365	.5365	.5373
23	.5487	.5914	.5121	.543	.503	.503	.2686
24	.4805	.4755	.5544	.3681	.5121	.4694	1.4548
Max	2.3045	2.0485	2.2725	2.1491	1.9204	1.7394	1.906
Min	.3326	.2195	.2957	.2195	.2683	.2321	.2683
Avg	1.0240	.9656	1.0177	1.0151	.8914	.7897	.8792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024034 / 33 kv SAWARA

Feeder No / Name : 201 / 201 -11 kv sawara gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1683	1.2498	1.4043	1.2125		1.491	1.5402
2	1.1248	1.2346	1.2346	1.2452	1.3108	1.4563	1.5402
3	1.1248	1.2193	1.2037	1.2803	1.2498	1.387	1.5043
4	1.1279	1.1888	1.142	1.3717	1.2193	1.1574	1.4842
5	1.0431	1.1431	1.0002	1.2971	1.1888	.9869	1.4148
6	.9054	.9069	.9198	1.1919	1.0669	.9198	1.1946
7	.727	.5944	.616	.9671	.663	.6508	.9671
8	.6382	.4687	.5927	.9391	.583	.6043	.8954
9	.6935	.4458	.616	.7773	.6059	.6276	.9134
10	.7316	.6059	.6276	.7331	.6173	.6741	.8682
11	.6744	.6741	.6737	.8954	.6392	1.0679	.583
12		.6741	.7404	.9922	.4761	.9877	.663
13		.7316	.7914	.663		1.0029	.8402
14		.8792	.868	.7087			.8535
15	1.1584	.8928	.881	.8402	.9198	1.1946	
16	1.0551	.8928	.8162	.743	.8522	1.0566	.8802
17	.8802	.6857	.7531	.6287	.8522	.9991	.6173
18	.8269	.6276	.6737	.5944	.616	.8987	.5716
19	1.1736	.8792	.8779	.8802	.9334	1.0099	.8402
20	1.4022	1.5083	1.1797	1.2193	1.4737	1.5581	1.2498
21	1.3413	1.5083	1.2378	1.2346	1.4737	1.6297	1.2651
22	1.4327	1.543	1.2517	1.2651	1.6297	1.6301	1.3108
23	1.3565	1.4217	1.21	1.2651	1.543	1.576	1.326
24	1.1797	1.2955	1.439	1.1961	1.2346	1.491	1.5592
Max	1.4327	1.543	1.439	1.3717	1.6297	1.6301	1.5592
Min	.6382	.4458	.5927	.5944	.4761	.6043	.5716
Avg	1.0365	.9696	.9479	1.0059	1.0071	1.1329	1.0818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024034 / 33 kv SAWARA

Feeder No / Name : 202 / 11 kv sawara ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383			1.0288			.6859
2	.4995	.4572	.4372	1.0288			.6859
3	.5068	.4344	.4275				.6859
4	.4934	.4458	.4178	1.0288			.6859
5	.5335	.423	.4081	1.0288			.6859
6	.5441	.423	.4178	1.0288			.6859
7	.583	.5258	.4572	1.0288			.6859
8	.6255	.6059	.6624	1.0288			.6859
9	.7773	.6401	.6276	1.0288			.6859
10	1.1431			.823	.6059	.3206	.2921
11			1.0288	.727	.6043	.4664	.3772
12			1.0288	.6447		.4734	.5144
13			1.0288	.4001		.6908	.5487
14			1.0288	.4687		.4729	.5601
15			1.0288	.4915	.2422	.4527	.5487
16			1.0288	.5144	.2343	.487	.5373
17			1.0288	.5487	.3304		.6287
18			1.0288			.6859	
19			1.0288			.6859	
20			1.0288			.6859	
21			1.0288			.6859	
22			1.0288			.6859	
23			1.0288			.6859	
24	.8383			1.0288			.6859
Max	1.1431	.6401	1.0288	1.0288	.6059	.6908	.6859
Min	.4934	.423	.4081	.4001	.2343	.3206	.2921
Avg	.6712	.4944	.8205	.8163	.4034	.5753	.6037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 201 / Pimpri(kh)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3757	.4668	.4749	.3865	.4668	.4668	.3865
2	1.5415	1.5283	1.5013	.4041	.4677	.4696	.3818
3	1.5758	1.5497	1.5967	.3677	.4696	.4706	.4003
4	1.4582	1.5348	1.5725	.3251	.4531	.4486	.3765
5	1.4425	1.5228	1.53	.2966	.3768	.37	.2942
6	1.4703	1.495	1.7748	.2213	.3018	.2635	.2606
7	1.5876	1.3818	1.6667	.184	.1884	.1898	.1757
8	1.6785	1.3812	1.296	.1884	.1884	.1485	.184
9	1.5242	1.3856	1.3987	.1501	.1901	.1819	.1869
10	.2243	.2614	.2085	1.5016	1.2018	1.4095	1.2686
11	.241	.1871	.2236	1.4614	1.2862	1.3923	1.3272
12	.2984	.2252	.2259	1.4355	1.326	1.3923	1.3343
13	.2987	.2254	.2911	1.432	1.3477	1.3597	1.3376
14	.299	.2252	.3254	1.3992	1.3443	1.2346	1.2639
15	.2981	.2243	.3364	1.3923	1.3066	1.3288	1.2761
16	.2786	.2254	.2993	1.4043		1.3468	1.2824
17	.2778	.225	.2204	1.3855	1.37	1.348	1.2531
18	.2432	.3364	.2133	.2252	1.3066	.2254	.2405
19	.2832	.3734		.2824	1.2583	.3162	.3374
20	.4145	.4486	.3601	.4158	.3003	.3589	.4154
21	.4682	.4701	.4417	.4884	.4133	.423	.5087
22	.5062	.4625	.4731	.5077	.4692	.4596	.5249
23	.5067	.4879	.4894	.4859	.4805	.4785	.5021
24		.4864	.4422		.4696	.4859	
Max	1.6785	1.5497	1.7748	1.5016	1.37	1.4095	1.3376
Min	.2243	.1871	.2085	.1501	.1884	.1485	.1757
Avg	.7518	.7129	.7549	.7105	.7384	.6904	.6747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 202 / Shahapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1298	.1699	.1848	.1694	.1689	.1848	.791
2	.1092	.1684	.1896	.9865	.8596	.8985	.8488
3	.108	.1503	.1684	1.0229	.8551	.8928	.8579
4	.1102	.1501	.1687	1.0962	.8329	.8641	.8796
5	.1199	.15	.1704	1.0927	.8374	.8641	.7945
6	.1103	.1315	.1295	1.0764	.8516	.8674	.8391
7	.0552	.1132	.1126	1.0779	.9096	.9556	.9659
8		.0939	.0934	.9888	.96	1.017	1.013
9	.0558	.0752	.0736	.9362	.8481	.9321	.9321
10	1.1179	.96	1.1448	.0925	.0748	.0878	.0751
11	1.1713	1.332	1.1307	.0935	.0747	.0911	.0932
12	1.1698	1.3915	1.0656	.0942	.0929	.0939	.1121
13	1.1599	1.4118	1.0576	.094	.0937	.093	.0942
14	1.1867	1.0931	.9629	.093	.0926	.1092	.1126
15	1.1706	1.0785	1.0696	.0935	.0936	.1043	.1131
16	1.1514	1.0416	1.0816	.0938	.0943	.09	.0939
17	1.1353	.9911	1.0829	.0933	.0944	.0745	.0933
18	.0746	.1118	.0729	.1113	.1128	.0367	.0939
19	.1315	.1504	.107	.1303	.1126		.1118
20	.1698	.1848	.1844	.168	.1318	.1092	.1687
21	.1886	.1869	.1882	.1699	.1521	.1506	.1869
22	.1888	.1856	.1564	.1698	.1848	.1439	.1882
23	.1884	.1852	.1583	.1701	.1875	.1506	.1684
24		.1698	.1655		.168	.7735	
Max	1.1867	1.4118	1.1448	1.0962	.96	1.017	1.013
Min	.0552	.0752	.0729	.0925	.0747	.0367	.0751
Avg	.5001	.4865	.4550	.4397	.3702	.4167	.4186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024039 / 33 KV JITAPUR S/S AKOT

Feeder No / Name : 203 / Shivpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.396			.3713
2				.462	.3832	.3864	.3514
3				.429	.3817	.3576	.3708
4				.4385	.3807	.34	.3759
5				.4385	.368	.3294	.3698
6				.4698	.3539	.2976	.3554
7				.4698	.3676	.3935	.3293
8				.4887	.3848	.4065	.3713
9				.4675	.4081	.4332	.3649
10	.4332	.4633	.5213				
11	.4447	.481	.4855				
12	.4715	.5215	.4887				
13	.4728	.5432	.4635				
14	.4591	.5268	.4698				
15	.4728	.5241	.495				
16	.4865	.4487	.4704				
17	.4858	.3585	.4619				
Max	.4865	.5432	.5213	.4887	.4081	.4332	.3759
Min	.4332	.3585	.4619	.396	.3539	.2976	.3293
Avg	.4658	.4834	.4820	.4511	.3785	.3680	.3622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 201 / M.I.D.C Lohari road
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1094	.2401	.2058	.2086	.2058	.1572
2	.2195	.1172	.2401	.184	.1858	.2058	.16
3	.2164	.1086	.208	.184	.1829	.18	.1572
4	.2103	.1057	.1787	.192	.1772	.18	.1572
5	.1829	.1057	.1515	.2058	.1743	.1686	.16
6	.1467	.1128	.1515	.2058	.1686	.1686	.1467
7	.144	.1128	.1457	.1886	.1707	.1686	.16
8	.12	.1086	.1572	.2658	.1627	.18	.1654
9	.2058	.2622	.2172	.2896	.2683	.2229	.2458
10	.2683	.3086	.3109	.3258	.3224	.2683	.2713
11	.285	.333	.3801	.3258	.3292	.3052	.3086
12	.3018	.3429	.3544	.3155	.2915	.3294	.3155
13	.285	.3641	.3761	.3086	.2683	.333	.3403
14	.2429	.3077	.3681	.3086	.3086	.3155	.3185
15	.2561	.3429	.3681	.3086	.3544	.3052	.2846
16	.2656	.3841	.3222	.2743	.3258	.3294	.2846
17	.2721	.3506	.3439	.3052	.3155	.3403	.2881
18	.3018	.3696	.2947	.3224	.3292	.3511	.3155
19	.3121	.3506	.3142	.3439	.3174	.3439	.3155
20	.3189	.3277	.3174	.2743	.3012	.2881	.2949
21	.3121	.2709	.2378	.2709	.2559	.2753	.2332
22	.128	.2164	.2086	.2103	.2201	.1658	.1886
23	.125	.1886	.1915	.168	.2172	.1629	.1972
24	.2347	.1257	.18	.2086	.2115	.2229	.16
Max	.3189	.3841	.3801	.3439	.3544	.3511	.3403
Min	.12	.1057	.1457	.168	.1627	.1629	.1467
Avg	.2327	.2386	.2608	.2580	.2528	.2507	.2344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 202 / Hiwarkhed Road industry

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3083	.836	2.0965	2.3411	2.9216	2.3392	2.6807
2	2.1902	.8375	2.0979	2.3213	2.9056	2.2481	2.6093
3	2.1316	.8513	1.9993	2.335	2.8574	2.2351	2.5791
4	2.156	.8912	2.0675	2.3282	2.8515	2.2062	2.3937
5	2.1636	.8912	2.0614	2.2524	2.9226	2.2123	2.0081
6	2.0721	.884	1.8105	2.2295	2.8254	2.1483	2.0843
7	2.0347	.8726	1.5881	1.9601	2.5772	2.1422	2.0635
8	2.0039	.9021	1.5173	1.824	2.4897	1.9539	1.6871
9	1.7758	.9839	1.3382	1.728	1.9174	1.4899	1.3984
10	.7889	1.0933	1.9382	1.4533	1.3184	1.3862	1.3024
11	.6833	1.1484	1.9003	1.5064	1.1942	1.2155	1.3399
12	.6904	1.1759	1.9837	1.4639	1.1819	1.0265	1.1667
13	.7125	1.1682	1.837	1.4792	1.041	1.0281	1.0258
14	.6809	1.048	1.6084	1.4172	1.0463	.9724	1.018
15	.6893	1.195	1.7139	1.4183	1.0387	1.0631	1.0456
16	.6984	1.2712	1.9204	1.518	.996	1.0559	1.0776
17	.6809	1.2117	2.0153	1.4869	1.004	1.0223	1.1008
18	.6943	1.231	1.9129	1.4544	.9652	.9793	1.067
19	.7163	1.2002	1.7497	1.3509	.9795	1.0502	1.0372
20	.7781	1.809	2.0751	1.9387	1.6439	1.7303	1.5234
21	.8661	2.2184	2.1312	2.7016	2.0852	2.3785	2.143
22	.8875	2.2413	2.5011	3.062	2.4531	2.4991	2.4108
23	.8551	2.2996	2.4916	3.0255	2.4581	2.8412	2.5251
24	1.7205	1.3954	2.2901	2.6738	2.6345	2.625	2.6201
Max	2.3083	2.2996	2.5011	3.062	2.9226	2.8412	2.6807
Min	.6809	.836	1.3382	1.3509	.9652	.9724	1.018
Avg	1.2908	1.2357	1.9436	1.9696	1.9295	1.7437	1.7462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 203 / 11KV Water supply
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2054	.1991	.1311	.1886	.1886	.1886
2	.1886	.2054	.2012	.1311	.1886	.1886	.1886
3	.1886	.2054	.2012	.1311	.1886	.1886	.1886
4	.1886	.2054	.1991	.125	.1886	.1886	.1867
5	.1886	.2054	.2012	.1189	.1886	.1886	.1867
6	.2075	.2241	.1991	.1189	.2096	.1886	.1509
7	.2075	.2427	.2172	.1189	.2075	.2241	.1509
8	.2286	.2218	.3206	.1823	.2075	.2033	.1509
9	.2286	.2801	.3174	.1907	.2427	.2241	.2033
10	.2286	.3206	.3206	.1829	.2829	.2402	.2241
11	.2286	.362	.362	.2614	.2614	.2801	.2427
12	.2427		.3772	.2614	.2263	.3206	.2987
13	.2452	.3018	.3772	.2987	.1886	.3361	.3511
14	.2286	.3881	.2829	.2987	.2801	.3361	.2801
15	.2477	.2858	.1886	.2987	.3511	.3881	.1848
16	.2641	.2987	.2075	.2772	.3881	.3547	.2241
17	.2641	.3018	.2829	.3361	.3734	.3547	.2561
18	.2641	.2258	.2641	.3734	.3772	.3584	.2743
19	.2641	.2858	.2614	.2926	.3395	.3584	.2801
20	.2614	.2829	.2561	.2452	.3395	.2614	.2829
21	.2614	.2402	.2126	.2241	.3395	.2402	.2641
22	.2241	.2218	.1389	.2263	.3018	.2241	.2263
23	.2241	.2033	.1174	.2075	.2241	.2218	.2075
24	.2075	.2033	.2054	.1311	.1886	.1886	.1886
Max	.2641	.3881	.3772	.3734	.3881	.3881	.3511
Min	.1886	.2033	.1174	.1189	.1886	.1886	.1509
Avg	.2288	.2573	.2463	.2151	.2614	.2603	.2242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 204 / 11KV Wadali-S

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887	.4887	.5068	.4887	.4887	.5068	.4706
2	.4706	.4887	.5068	.4706	.4706	.4887	.4706
3	.4525	.4887	.4887	.4706	.4706	.4706	.4706
4	.4525	.4887	.4887	.4706	.4706	.4706	.4706
5	.4525	.4706	.4525	.4344	.4525	.4706	.4344
6	.362	.3982	.3801	.3982	.362	.3982	.3801
7	.3439	.3258	.3077	.3258	.3258	.3258	.3258
8	.3077	.2896	.2896	.2896	.3258	.3258	.3077
9	.3258	.3077	.3077	.2896	.3077	.2715	.2896
10	.3258	.3077	.2896	.2896	.2715	.2715	.2896
11	.3258	.3258	.2715	.3258	.3077	.2896	.2896
12	.3439	.3258	.3077	.362	.3258	.2896	.3258
13	.362	.3439	.3077	.362	.3258	.3258	.3439
14	.3801	.3439	.3258	.362	.362	.3439	.3439
15	.362	.3801	.3439	.362	.3801	.3801	.362
16	.3801	.3439	.3439	.362	.362	.3439	.3439
17	.362	.2896	.3258	.3258	.362	.2715	.2896
18	.3801	.2534	.2715	.2715	.362	.2715	.2534
19	.362	.362	.3077	.3439	.362	.3077	.3258
20	.5068	.4706	.4706	.4706	.4706	.4706	.4344
21	.5068	.4706	.5068	.4887	.5068	.4887	.4887
22	.543	.4887	.5249	.5068	.5068	.4887	.4887
23	.5249	.5068	.5249	.5068	.5068	.4887	.4887
24	.4887	.4887	.5068	.4887	.4887	.5068	.4887
Max	.543	.5068	.5249	.5068	.5068	.5068	.4887
Min	.3077	.2534	.2715	.2715	.2715	.2715	.2534
Avg	.4088	.3937	.3899	.3944	.3990	.3861	.3824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 024046 / AKOT M.I.D.C

Feeder No / Name : 205 / 11KV Mundgoan AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.176
2				.1905	.1448	.1189	.1738
3				.1486	.1467	.1486	.176
4				.1486	.1448	.1486	.1783
5				.1486	.1635	.1486	.176
6				.1783	.176	.1783	.2317
7				.208	.2172	.208	.2347
8				.2229	.2378	.2229	
9				.2378	.2347	.2675	.2347
10	.2347	.3353	.2709				
11	.2462	.2968	.2675				
12	.2675	.2675	.2494				
13	.2709	.2675	.2801				
14	.2378	.2286	.2107				
15	.2408	.2347	.2027				
16	.2347	.2675	.2347				
17	.2378	.2559	.2027				
24							.176
Max	.2709	.3353	.2801	.2378	.2378	.2675	.2347
Min	.2347	.2286	.2027	.1486	.1448	.1189	.1738
Avg	.2463	.2692	.2398	.1854	.1832	.1802	.1952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 201 / 11 KV POPATKHED

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12			1.9364			1.8724
13	1.7814			2.0891	2.251	
14		1.9433				
Max	1.7814	1.9433	1.9364	2.0891	2.251	1.8724
Min	1.7814	1.9433	1.9364	2.0891	2.251	1.8724
Avg	1.7814	1.9433	1.9364	2.0891	2.251	1.8724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281] BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 202 / 11 KV SAWARA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12			2.0729			2.2186
13	2.3594			2.3482	2.251	
14	1.7976	1.9595				
Max	2.3594	1.9595	2.0729	2.3482	2.251	2.2186
Min	1.7976	1.9595	2.0729	2.3482	2.251	2.2186
Avg	2.0785	1.9595	2.0729	2.3482	2.251	2.2186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 203 / 11 KV AKOT-I

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9035	2.9111	2.8426	2.995	2.9035	3.0255	2.8502
2	2.774	2.8273	2.7892	2.8273	2.7968	2.8045	2.7587
3	2.6597	2.7359	2.6978	2.7968	2.713	2.6825	2.7054
4	2.5987	2.652	2.6063	2.7054	2.6063	2.6825	2.6139
5	2.5225	2.5377	2.4844	2.553	2.5377	2.5987	2.4387
6	2.4691	2.4615	2.4158	2.553	2.4463	2.6216	2.3929
7	2.2862	2.2862	2.3701	2.4615	2.431	2.5453	2.2024
8	2.2786	2.3548	2.2177	2.3167	2.332	2.431	2.0652
9	2.0805	2.2862	2.2024	2.2558	2.2024	2.2634	2.0043
10	2.1719	2.4006	2.2177	2.1567	2.1719	2.4844	1.9966
11	2.2862	2.5758	2.5225	2.3472	1.9357	2.6063	1.989
12	2.4539	2.774	5.1099	2.5682		4.8986	2.3015
13	5.3708	2.8349	2.713	5.0589	3.1093	2.7435	2.3624
14	2.8197	4.1562	2.774	2.8349	3.0788	2.8426	2.5072
15	2.8578	3.094	2.8349	2.9111	3.0331	3.0559	2.7435
16	2.873	3.0712	2.934	3.1093	3.1169	3.0712	2.8349
17	2.9111	2.9264	2.9035	3.1779	3.1017	3.0788	2.7587
18	2.8273	2.8883	2.9264	2.9492	2.934	2.8426	2.713
19	2.6597	2.6673	2.7282	2.7816	2.6901	2.8045	2.553
20	2.9797	2.9492	2.9797	3.0026	2.9111	3.0559	2.8121
21	3.0407	2.9645	3.0331	2.9874	3.0026	3.0255	2.8654
22	3.0407	2.9264	2.9721	2.9111	3.0178	2.9188	2.8197
23	2.9797	2.8883	2.9797	2.8578	5.0659	2.8578	2.7587
24	2.934	2.9111	2.9874	2.9416	3.0788	2.8959	2.8045
Max	5.3708	4.1562	5.1099	5.0589	5.0659	4.8986	2.8654
Min	2.0805	2.2862	2.2024	2.1567	1.9357	2.2634	1.989
Avg	2.7825	2.7950	2.8018	2.8358	2.8355	2.8682	2.5355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 204 / 11 KV AKOT -II

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.824	4.7935	4.4887	4.7554	4.7478	4.6868	4.6716
2	4.6106	4.5953	3.6732	4.6258	4.6106	4.5725	4.5649
3	4.4887	4.4734	4.542	4.4734	4.5115	4.4201	4.4353
4	4.4124	4.3896	4.3515	4.3972	4.3286	4.3362	4.3591
5	4.3667	4.3439	4.2676	4.2981	4.2524	4.2676	4.2448
6	4.382	4.3058	4.2524	4.2676	4.2981	4.2448	4.1991
7	4.3134	4.1914	4.2219	4.1686	4.1914	4.1686	3.9933
8	4.1762	4.0009	4.1229	4.0466	4.0466	3.9628	3.8485
9	4.0314	3.8866	4.0847	3.8866	3.9933	3.8485	3.7266
10	3.8104	3.7494	3.879	3.7571	3.818	3.6656	3.6808
11	3.8409		3.818	3.818	3.8409	3.658	3.7571
12	3.7799	2.9416	3.8485	3.6732	3.8714	7.098	3.6351
13	7.4928	4.3134	7.2337	7.2124	3.8409	3.7723	3.5437
14	3.9552	7.8921	3.94	3.8409	3.8866	3.7342	3.8333
15	4.0924	4.039	4.0924	4.0238	3.9552	3.9247	3.9171
16	4.1229	4.1533	4.2067	4.1457	4.0924	3.94	4.0771
17	4.2067	4.1991	4.321	4.2143	4.1457	4.039	4.161
18	4.0924	4.1533	4.3286	4.1914	4.1229	3.9628	4.1457
19	3.9552	2.2634	4.039	.442	3.8714	3.7647	3.9857
20	4.3439	4.2753	4.4734	4.8392	4.3058	3.7799	4.4429
21	4.5725	5.0983	4.6944	4.9992	4.6944	4.4582	4.6792
22	4.6411	4.8087	4.6944	4.6563	4.6563	4.5039	4.4429
23	4.824	4.9688	4.8468	4.8621	8.546	4.8087	4.6411
24	4.9154	4.9992	4.9002	4.8697	4.9002	4.8163	4.7782
Max	7.4928	7.8921	7.2337	7.2124	8.546	7.098	4.7782
Min	3.7799	2.2634	3.6732	.442	3.818	3.658	3.5437
Avg	4.4271	4.3841	4.3884	4.2694	4.3970	4.2681	4.1568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281] BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 205 / 11 KV MUNDGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12			1.2127			1.1222
13	1.3575			1.2127		
14		1.1765				
23					1.1765	
Max	1.3575	1.1765	1.2127	1.2127	1.1765	1.1222
Min	1.3575	1.1765	1.2127	1.2127	1.1765	1.1222
Avg	1.3575	1.1765	1.2127	1.2127	1.1765	1.1222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281]

BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 207 / 11 KV Akot 3

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1033	2.0576	2.0195	2.0424	2.0271	2.05	2.0195
2	2.0271	2.0348	1.9738	1.9814	1.9509	1.9738	1.9204
3	1.9814	1.9966	1.89	1.9052	1.8823	1.8976	1.89
4	1.9052	1.9585	1.8366	1.8366	1.8214	1.8366	1.829
5	1.8366	1.8823	1.7909	1.768	1.7528	1.7833	1.7452
6	1.7833	1.7909	1.6994	1.7071	1.6613	1.7375	1.6537
7	1.669	1.6309	1.5927	1.5851	1.547	1.608	1.5013
8	1.4937	1.5013	1.4556	1.4784	1.4403	1.4937	1.4327
9	1.4632	1.4098	1.387	1.3794	1.387	1.4251	1.3413
10	1.4403	1.4556	1.3641	1.3946	1.3946	1.3794	1.3641
11	1.448	1.5089	1.3946	1.4327	1.4556	1.4327	1.3946
12	1.5318	1.5242	2.8319	1.4708	1.5165	2.9058	1.4098
13	3.1916	1.5699	1.5623	2.9721	1.5927	1.5851	1.5165
14	1.7528	1.7375	1.6918	1.6766	1.6994	1.6994	1.6309
15	1.8366	1.7223	1.8138	1.7833	1.7985	1.7909	1.7909
16	1.8823	3.3459	1.89	1.8061	1.8442	1.8366	1.8214
17	1.8519	1.829	1.8366	1.829	1.8442	1.8138	1.7985
18	1.7528	1.7375	1.768	1.768	1.7147	1.7375	1.7071
19	1.6613	1.6461	1.6613	1.7147	1.6461	1.669	1.6537
20	1.9052	1.9052	1.9052	1.9052	1.9052	1.8747	1.8976
21	1.9738	1.9357	1.9204	1.9052	1.9204	1.9204	1.8823
22	1.989	1.9204	1.89	1.9204	1.9585	1.9662	1.9052
23	2.1414	2.0271	2.0271	2.0195	3.4393	2.0195	2.0424
24	2.1338	2.0729	2.0805	2.0805	2.1033	2.0729	2.1033
Max	3.1916	3.3459	2.8319	2.9721	3.4393	2.9058	2.1033
Min	1.4403	1.4098	1.3641	1.3794	1.387	1.3794	1.3413
Avg	1.8648	1.8417	1.8035	1.8068	1.8043	1.8129	1.7188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

AKOT SUB DN[281] BU 2810

Substation No/ Name :- 027003 / 132 KV AKOT S/S

Feeder No / Name : 209 / SOOTGIRNI 1

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12			.9031			.9934
13	.8429			1.0686	1.0536	
14		.9783				
Max	.8429	.9783	.9031	1.0686	1.0536	.9934
Min	.8429	.9783	.9031	1.0686	1.0536	.9934
Avg	.8429	.9783	.9031	1.0686	1.0536	.9934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 201 / 11 KV GADEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7461	.8238	.788	.695	.7602	.964	1.1765
2	.7964	.7545	.7042	.6661	.724	.9774	1.0867
3	.7362	.7282	.6554	.6706	.7164	.9511	1.1584
4	.7087	.6706	.6478	.6882	.7888		1.0631
5	.7011	.6299	.5693	.6554	.8048	.8573	1.0288
6	.5426	.5898	.4744	.6882	.8573		.9602
7	.4481	.4858	.3353	.6371	.6706	.7716	.9724
8	.3048	.3658	.2408	.6478	.6882	.9012	.852
9	.3353	.3353	.2675	.6554	.6882	.8718	.8192
10	.8048	.8718	.9774	.3201	.426	.2949	.4161
11	.8192	1.0059	1.0745	.3795	.5304	.3647	.4801
12	.8288	.9175	1.0166	.421	.5243	.426	
13	.9054	.9945	1.0288	.4858		.4694	
14		.9724	.9945	.5735	.503	.4973	
15	.9724	.8383	1.0288		.4694	.5365	
16	.9175	.7865	.9602	.4588	.4973	.503	.5636
17	1.0517	1.0174	.9374	.4572	.4961	.431	.4915
18	.4298	.3582	.4382	.4382	.5373		.4207
19		.4344	.5121	.4344	.6154		.4115
20	.5792	.6584	.695	.6584	.724		.5765
21	.7602	.7682	.7762	.7682	.8048	.8048	.7164
22	.788	.823	.823	.8048	.8326	.8688	.6783
23	.8048	.8596	.7202	.7712	.823	.8505	.7964
24	.7682	.8238	.8059	.6783	.7712	.7888	1.1517
Max	1.0517	1.0174	1.0745	.8048	.8573	.9774	1.1765
Min	.3048	.3353	.2408	.3201	.426	.2949	.4115
Avg	.7159	.7297	.7280	.5936	.6632	.6911	.7910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 202 / 11 KV BELKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						2.0157	2.0908
2	.4298	.3429	.3353	1.5089	1.2887	2.0271	1.9281
3	.4252	.3814	.3239	1.4083	1.3077	1.9909	2.0595
4	.3856	.3353	.3239	1.3603		1.9547	1.8861
5	.394	.3315	.3163	1.2803	1.3108	1.7528	1.6461
6	.3772	.2949	.2846	1.278	1.3108	1.5432	1.4413
7	.3429	.2915	.2439	1.278	1.1843	1.3226	1.2266
8	.3048	.2439	.2641	1.166	1.2071	1.1797	1.1336
9	.3048	.2439	.2675	1.0936	1.166	1.1603	1.4083
10	1.1869	1.5623		.3239	1.4091	.3932	.3841
11	1.6004	1.587	1.5402	.3521	.4641	.4641	.4481
12	1.5089		1.6476	.3437	.4588	.426	.4572
13	1.4685	1.6004	1.6461	.3887		.4694	.535
14	1.6095	1.7814	1.7147	.4096	.3688	.4481	.5376
15	1.5402	1.8244	1.6617	.381	.503	.4915	.5304
16	1.4723	1.7924	1.6461	.3932	.2984	.4588	.5967
17	1.5775	1.95	1.5203	.6097	.3506	.4694	.5441
24							2.0157
Max	1.6095	1.95	1.7147	1.5089	1.4091	2.0271	2.0908
Min	.3048	.2439	.2439	.3239	.2984	.3932	.3841
Avg	.9330	.9709	.9157	.8485	.9020	1.0922	1.1594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 203 / 11 KV TELHARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8652	2.1849	2.0058	1.6766	1.8023		
2	1.9547	1.9547	1.7604				
3	1.9909	1.9071	1.6194				
4	1.8404	1.7772	1.6194				
5	1.7718	1.6244	1.5181				
6	1.5432	1.4232	1.4232				
7	1.4575	1.3603	1.2498				
8	1.0669	1.2193	1.0837				
9	1.0105	1.1584	1.0402				
10				1.1336	1.4091	1.4091	1.2163
11				1.3283	1.5249	1.5581	1.2803
12				1.3603	1.6385	1.5729	1.3108
13				1.4746		1.6766	1.278
14				1.6057	1.4083	1.6244	1.5181
15				1.5242	1.6766	1.6095	1.6575
16				1.5729	1.6244	1.5402	1.6575
17				1.6385	1.576	1.5927	1.531
18	1.3611	1.6118	1.5061	1.4022	1.5223	1.3763	1.2803
19	1.6827	1.6651	1.7375	1.6289	1.6651	1.7147	1.4403
20	1.9909	1.9204	2.0119	1.9022	2.0119	2.0119	1.7147
21	2.1719	2.0851	2.1807	2.0119	2.1582	2.1033	1.8519
22	2.1491	2.1948	2.2314	2.0485	2.1948	2.0271	1.8442
23	2.1216	2.0595	1.9662	1.9334	2.1719	2.0908	1.9006
24	2.0814	2.1132	2.0058	1.7695	1.8778	2.0683	
Max	2.1719	2.1948	2.2314	2.0485	2.1948	2.1033	1.9006
Min	1.0105	1.1584	1.0402	1.1336	1.4083	1.3763	1.2163
Avg	1.7537	1.7662	1.6850	1.6257	1.7508	1.7317	1.5344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024016 / 33 KV TELHARA S/STN

Feeder No / Name : 205 / Tudgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3582	.2865	.3982	.4024	.3856	.4525
2	.9412	.8573	.8383	.4024	.4024	.362	.4207
3	.8859	.8669	.8097	.3429	.3734	.3856	.4344
4	.8764	.8048	.7773	.2949	.3658	.3856	.4207
5	.8322	.7956	.7449	.3086	.3292	.3772	.3772
6	.8669	.7865	.7274	.298	.3582	.298	.3391
7	.7449	.7449	.7716	.2572	.2614	.1715	.2012
8	.7499	.6706	.724	.2515	.1638	.1638	.1966
9	.6687	.6401	.5053	.1844	.1753	.1989	.8192
10	.2401	.2401	.0724	.6478	.9175	.8539	.8002
11	.2204	.2713	.2865	1.012	1.0608	.9945	.7362
12	.2743	.2743	.2454	1.0526	1.0159	1.0486	.7316
13	.3258	.2743	.2743	1.0159		1.073	.8916
14	.3506	.3155	.3086	.9831	.9389	1.0277	.9488
15	.3429	.2804	.2743	.9145	1.0395	1.0059	.9614
16	.3772	.2743	.2743	1.0159	.9945	1.0395	.9282
17	.3506	.2195	.2372	1.0486	.9955	.9724	.8002
18	.3582	.2561	.1753	.1753	.1791	.1638	.2149
19	.1829	.2561	.2743	.2534	.2353	.2229	.2195
20	.3258	.3292	.4024	.3292	.3292	.3658	.3086
21	.3658	.4024	.4435	.3658	.4024	.439	.3658
22	.3292	.823	.4344	.4024	.439	.4525	.4024
23		.3224	.4207	.4024	.3982	.4252	.4024
24	.3258	.3582		.4119	.439	.3856	.4382
Max	.9412	.8669	.8383	1.0526	1.0608	1.073	.9614
Min	.1829	.2195	.0724	.1753	.1638	.1638	.1966
Avg	.4904	.4759	.4482	.5320	.5312	.5499	.5338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 201 / 11 KV HKD feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.355	3.4751	3.3703	3.6496	3.5074	3.5818	1.5655
2	3.5128	3.5056	3.5227	3.4903	3.3604	3.5886	1.4937
3	3.3836	3.7578	3.6275	2.3015	3.6884	3.7037	1.531
4	3.3379	3.4987	3.4903	2.3235	3.8104	3.6732	1.4937
5	3.4903	3.2293	3.275	1.973	3.659	3.6832	1.4003
6	3.2893	2.833	2.8399	1.0737	3.3808	3.3341	1.307
7	2.6749	2.4512	2.1281	.967	2.0157	3.1322	1.0829
8	2.5339	2.3205	2.0348	.0678	.967	2.6425	1.0456
9	2.0683	2.3766	1.6095	1.9586	.967	1.8785	1.0269
10	1.9906	2.0348	1.848	1.9129	.967	1.7078	1.0082
11	1.9906	1.1591	1.8328	2.0687	.9518	1.9006	1.0082
12	2.2025	2.8258	2.3854	2.5853	2.5587	2.0919	1.1694
13	1.307	2.8105	2.5888	2.6021	2.6368	2.3907	1.2136
14	1.3817	3.0056	2.6635	2.7207	2.8974	2.9821	1.2637
15	2.9904	3.0243	2.0317	3.0159	2.6181	2.7687	1.307
16	2.9531	3.0243	2.1148	2.9279	2.5164	2.8395	1.3443
17	2.8597	2.8749	2.5141	2.8361	2.4501	2.5819	1.307
18	2.7969	2.6307	1.387	2.6768	2.4669	2.614	1.086
19	2.9988	2.9614	3.0903	2.9836	2.6025	2.5244	1.2136
20	2.5434	2.4554	3.3055	2.7028	2.3453	1.4937	1.307
21	2.4672	2.4234	3.4362	2.4082	2.4234	1.531	1.5089
22	3.2685	3.2788	3.5532	3.3924	3.2026	1.587	1.587
23	3.6123	3.7533	3.9171	3.7595	3.8378	1.6244	1.587
24	3.8885	3.5498	3.77	3.5041	3.9952	1.4937	1.587
Max	3.8885	3.7578	3.9171	3.7595	3.9952	3.7037	1.587
Min	1.307	1.1591	1.387	.0678	.9518	1.4937	1.0082
Avg	2.7874	2.8858	2.7640	2.4959	2.6594	2.5562	1.3102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 202 / GORDHA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.7291	.6554
2				.6613	.763	.7122	.6783
3				.6783	.763	.7122	.6783
4				.6783	.663	.7122	.6783
5				.6443	.663	.6783	.6783
6				.6783	.6783	.6783	.6783
7				.6613	.639	.7122	.6783
8				.6783	.6783	.7461	.5765
9				.6274	.6952	.763	.5935
10	.8309	.78	.7969				
11	.8478	.7461	.8478				
12	.8478	.6783	.7461				
13	.8478	.7122	.8817				
14	.8478	.7291	.8478				
15	.8309	.6783	.8478				
16	.8478	.7122	.8478				
17	.8478	.6783	.763				
24						.1357	.6952
Max	.8478	.78	.8817	.6783	.763	.763	.6952
Min	.8309	.6783	.7461	.6274	.639	.1357	.5765
Avg	.8436	.7143	.8224	.6634	.6929	.6579	.6590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 203 / SAUNDALA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0328	.0328	.0328	.0373	.0328	.0324
2	1.587	1.278	1.3108	.0328	.0373	.0328	.0328
3	1.587	1.278	1.3108	.0328	.0373	.0328	.0328
4	1.4937	1.2452	1.3108	.0328	.0373	.0328	.0328
5	1.4937	1.2125	1.278	.0328	.0373	.0328	.0328
6	1.4937	1.1469	1.2616	.0328	.0373	.0328	.0328
7	1.1797	1.2289	1.2616	.0328	.0339	.0328	.0328
8	1.1469	1.278	1.4255	.0328	.0328	.0328	.0328
9	.9175	1.2289	1.278	.0328	.0328	.0328	.0328
10	.0328	.0328	.0328	1.286	1.278	1.3108	1.4413
11	.0328	.0328	.0328	1.3717	1.3108	1.3108	1.6804
12	.0328	.0328	.0328	1.3717	1.3108	1.3927	1.6975
13	.0328	.0328	.0328	1.406	1.3927	1.3927	1.6289
14	.0328	.0328	.0328	1.531	1.4746	1.4419	1.5432
15	.0328	.0328	.0328	1.5089	1.278	1.3927	1.4575
16	.0328	.0328	.0328	1.3717	1.3108	1.2289	1.448
17	.0328	.0328	.0328	1.6289	1.3108	1.4255	1.5384
18	.0328	.0328	.0328	.0328	.0328	.0328	.0377
19	.0328	.0328	.0328	.0328	.0328	.0328	.0377
20	.0328	.0328	.0328		.0328	.0328	.0377
21	.0328	.0328	.0328	.0377	.0328	.0328	.0377
22	.0328	.0328	.0328	.0377	.0328	.0328	.0328
23	.0328	.0328	.0328	.0377	.0328	.0328	.0328
24	.0377	.0328	.0328	.0328	.0377	.0328	.0328
Max	1.587	1.278	1.4255	1.6289	1.4746	1.4419	1.6975
Min	.0328	.0328	.0328	.0328	.0328	.0328	.0324
Avg	.4764	.4342	.4567	.5210	.4677	.4759	.5408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 204 / Wari express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267	.032	.032	.032	.0267	.032	.0309
2	.0248	.032	.032	.032	.0259	.032	.032
3	.0267	.032	.032	.032	.0248	.032	.032
4	.0267	.032	.032	.032	.0267	.032	.032
5	.0248	.032	.032	.032	.0267	.032	.032
6	.0267	.032	.032	.032	.0267	.032	.032
7	.032	.032	.032	.032	.0324	.032	.032
8	.032	.032	.032	.032	.032	.032	.032
9	.032	.032	.032	.032	.032	.032	.032
10	.032	.032	.032	.0267	.032	.032	.0267
11	.032	.032	.032	.0248	.032	.032	.0259
12	.032	.032	.032	.0267	.032		.0248
13	.032	.032	.032	.0259	.032	.032	.0267
14	.032	.032	.032	.0267	.032	.032	.0267
15	.032	.032	.032	.0251	.032	.032	.0259
16	.032	.032	.032	.0248	.032	.032	.0248
17	.032	.032	.032	.0267	.032	.032	.0267
18	.032	.032	.032	.032	.032	.032	.0267
19	.032	.032	.032	.032	.032	.032	.0267
20	.032	.032	.032	.032	.032	.032	.0267
21	.032	.032	.032	.0267	.032	.032	.0267
22	.032	.032	.032	.0267	.032	.032	.032
23	.032	.032	.032	.0259	.032	.032	.032
24	.0259	.032	.032	.032	.0259	.032	.032
Max	.032	.032	.032	.032	.0324	.032	.032
Min	.0248	.032	.032	.0248	.0248	.032	.0248
Avg	.0303	.032	.032	.0293	.0303	.032	.0291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 205 / DIWANZARI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1658	.1658	.1492	.1867	.1658	.1658
2	2.452	1.8233	2.0719	.1492	.1867	.1658	.1658
3	2.3777	1.989	2.0719	.1492	.181	.1658	.1658
4	2.452	2.0222	2.0719	.1492	.1509	.1492	.1658
5	2.1719	1.989	1.989	.1492	.1509	.1492	.1326
6	2.2405	1.989	1.989	.1326	.1132	.1326	.1326
7	1.989	2.1879	1.989	.0995	.0829	.0829	.0995
8	1.989	2.1548	2.1548	.0663	.08	.0663	.0995
9	1.8233	2.1548	2.0719	.0663	.0829	.0663	.0995
10	.116	.0829	.0995	2.3148	2.1548	2.0719	2.3148
11	.116	.0829	.0829	2.4348	2.1216	2.1879	2.2291
12	.0663	.0995	.0829	2.4348			2.2291
13	.0995	.116	.0995	2.4006	2.1879	2.1548	2.5579
14	.0995	.0995	.0995	2.4006	1.989		2.3529
15	.0995	.116	.116	2.5463	1.989	2.0719	2.5766
16	.0829	.0995	.0995	2.3891	1.989	2.0719	2.6139
17	.0829	.0995	.0829	2.2291	2.1382	1.989	2.4006
18	.0829		.0663	.1492	.0663	.1326	.0943
19	.1492	.1326	.116	.116	.116	.0995	.1132
20	.1823	.1658	.1326	.1326	.1326	.0995	.1132
21	.1989	.1658	.1658	.1886	.1658	.1823	.112
22	.1823	.1823	.1658	.1886	.1823	.1823	.1823
23	.1658	.1823	.1658	.1886	.1823	.1658	.1658
24	.2075	.1658	.1658	.1658	.1886	.1823	.1658
Max	2.452	2.1879	2.1548	2.5463	2.1879	2.1879	2.6139
Min	.0663	.0829	.0663	.0663	.0663	.0663	.0943
Avg	.8180	.7942	.7632	.8913	.7312	.6698	.8937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024017 / HIWARKHED S/S

Feeder No / Name : 206 / KHANDALA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						2.3482	2.4291
2				2.4939	2.7435	2.2672	2.4291
3				2.4291	2.4863	2.2672	2.2672
4				2.4291	2.5434	2.2672	2.2672
5				2.3644	2.3739	2.2024	2.2672
6				2.2672	2.3739	2.2024	2.1862
7				2.2672	2.5434	2.2672	2.2672
8				2.2672	2.4291	2.4291	2.4291
9				2.3482	2.4291	2.5911	2.4291
10	2.915	2.5911	2.5911				
11	2.753	2.672	2.834				
12	2.834	2.5911	2.753				
13	2.753	2.5911	2.753				
14	2.5911	2.4291	2.5911				
15	2.6558	2.5101	2.6558				
16	2.6558	2.5911	2.5911				
17	2.5911	2.5911	2.6882				
24							2.4291
Max	2.915	2.672	2.834	2.4939	2.7435	2.5911	2.4291
Min	2.5911	2.4291	2.5911	2.2672	2.3739	2.2024	2.1862
Avg	2.7186	2.5708	2.6822	2.3583	2.4903	2.3158	2.3401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 201 / 11 KV KHARKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.5487		
4	.5487						
6	.3391		.3429		.6001	.3429	
7			.3429				1.9547
8	.5087		.3086	.5087	.583	.3086	.5487
9		.583		.5087		.3086	.5087
10		1.3375	1.6461	1.0288	1.6461		1.4403
11	2.0919	1.4746		1.406	1.9547	1.5089	1.989
12		1.6118			1.9547		1.989
13					1.8176		1.9547
14	2.1605	1.5775		1.7147			
15	2.0919	1.6118		1.6118	1.8176	1.6118	1.989
16		1.5775			1.7833		1.9547
17		1.5432					1.989
18				1.5775	1.8176		
19	2.0576	1.5775		1.6461	1.749	1.4746	1.9547
20			1.8176	1.6461			1.8519
21	1.8991			1.6804			
22	1.989	1.6461	1.7833	1.6461	1.8176	1.5775	1.7833
23	1.9204						
24	1.3717		.3429	1.749	1.7833	.3429	
Max	2.1605	1.6461	1.8176	1.749	1.9547	1.6118	1.989
Min	.3391	.583	.3086	.5087	.5487	.3086	.5087
Avg	1.5435	1.4541	.9406	1.3937	1.5287	.9345	1.6852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 203 / 11KV ADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3052						
6	.3429		.3601		1.1022	1.2003	
7			.3429				1.0974
8	.3391	.3086	.3429	1.1191	1.0631	1.2689	.9156
9		.3361		.763		1.2003	.8478
10		.3601	1.0974	.3353	.3391		.3772
11	1.0974	.3772		.3353	1.2689	.3429	.3429
12		1.2346		.3688	.3772		.3258
13				.3018	.4115		.2401
14	1.4746	1.2346					
15	1.2003	1.2003		.3353	.4115	.3429	.4115
16		1.2346		.3018	.3772		.3772
17		1.2689					.3601
18				.3018	.3772		
19	.4115	.3772		.3052	.4115	.4115	.3944
20			.3429	.3018			.4115
21	.407			.3018			
22	.3772	.4287	.4115	.3222	.4287	.3429	.4287
24	.3353	.3086	.4115	.3086	1.0174	.4115	
Max	1.4746	1.2689	1.0974	1.1191	1.2689	1.2689	1.0974
Min	.3052	.3086	.3429	.3018	.3391	.3429	.2401
Avg	.6291	.7225	.4727	.4073	.6321	.6902	.5023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 204 / 11 KV CHITTALWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.0898						
6	1.1145		1.2689		.5935	.9602	
7			1.2689				.6001
8	1.1022	1.6118	1.3032	.6783	.5087	.8916	.6443
9		1.0974		.6783			.5144
10		1.2346	.6173	1.0059	1.0631		1.4918
11	.583	1.2517		1.0898	1.0288	1.5432	1.6975
12		1.0631		1.1869	1.0631		1.5775
13				1.1022	1.0631		1.6118
14	.6859	1.166		1.1869			
15	.583	1.0974		1.0174	1.2003	1.1317	1.6118
16		1.0631		1.1022	1.2689		1.6632
17		1.0974					1.6804
18				.5087	1.0288		
19	1.0288	.9945		.5087	.9602	1.0974	.9259
20			1.0974	.5087			.9602
21	1.1022			.5087			
22	1.0974	1.0631	1.1317	.5426	1.1145	.7716	1.0288
24	.5144	1.0288	1.0631	.823	.5087	1.0631	
Max	1.1145	1.6118	1.3032	1.1869	1.2689	1.5432	1.6975
Min	.5144	.9945	.6173	.5087	.5087	.7716	.5144
Avg	.8901	1.1474	1.1072	.8299	.9501	1.0655	1.2314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024018 / 33 KV ADGAON S/S

Feeder No / Name : 205 / 11 KV Water Supply Express NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0168						
6	.0335		.0686		.0503	.0343	
7			.0686				.0514
8	.0503	.0686	.0686	.0678	.0335	.0857	.0509
9		.0686		.0678		.0514	.0514
10		.0686	.0686	.0343	.0339		.0514
11	.0686	.0171		.0335	.0343	.0686	.0343
12		.0343		.0339	.0343		.0343
13				.0339	.0343		.0343
14	.0686	.0343		.0339			
15	.0686	.0171		.0339		.0514	.0343
16		.0343		.0339	.0343		.0343
17		.0343					.0171
18				.0168	.0343		
19	.0171	.0343			.0171	.0171	.0343
20				.0168			.0171
21				.0168			
22		.0514	.0171	.0168	.0343		.0171
24	.0168		.0171		.0168	.0171	
Max	.0686	.0686	.0686	.0678	.0503	.0857	.0514
Min	.0168	.0171	.0171	.0168	.0168	.0171	.0171
Avg	.0425	.0421	.0514	.0339	.0325	.0465	.0356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024027 / 33 KV MANATRI

Feeder No / Name : 201 / 11 KV PANCHAGAVHAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.5604	1.4918	1.5432	1.5089	1.4746	1.4575
2	1.6289	1.4232	1.4918	1.4232	1.5089	1.4746	1.4575
3	1.6461	1.4232	1.4918	1.3717	1.4403	1.4746	1.4575
4	1.6118	1.406	1.4746	1.3375	1.3717	1.4746	1.3546
5	1.5432	1.406	1.4746	1.3203	1.3032	1.3717	1.2003
6	1.4575	1.3717	1.4746	1.3032	1.2174	1.2346	1.1488
7	1.4575	1.3375	1.3717	1.2003	1.0631	.9774	.9602
8	1.1145	1.286	1.406	1.1145	.8916	.9431	.9259
9	1.1831	1.2346	1.3717	.9431	.9602	1.0631	.8916
10	1.2003	.9602	.9602	1.3889	1.5432	.9431	.8573
11	1.1145	1.0288	.9259	1.4575	1.5432	.9259	.9431
12	1.1145	1.0288	.9774	1.4575	1.4746	.9259	1.0288
13	1.2174	1.0631	1.1145	1.5261	1.6289	.9431	1.0288
14	1.286	.463	1.1145	1.5432	1.6632	.9088	1.046
15	1.2689	.4801	1.1488	1.5432	1.6461	.8573	1.046
16	1.2346	1.2689	1.166	1.5775	.6687	.8745	1.046
17	1.2174	1.2003	.6001	1.5947	.7202	.9088	1.046
18	1.0117	1.0974	1.0288	1.0802		.9602	.8573
19	1.3203	1.2003	1.2003	1.2346	1.1831	1.3375	.8745
20	1.5261	1.5947	1.4575	1.5604	1.2346	1.5261	1.286
21	1.6461	1.5775	1.5775	1.5604	1.6804	1.6118	1.5261
22	1.6461	1.5775	1.6118	1.5604	1.5432	1.6289	
23	1.6289	1.5432	1.6118	1.5432	1.5089	1.5947	
24	1.6975	1.7924	1.5089	1.5947	1.5432	1.4746	1.4746
Max	1.6975	1.7924	1.6118	1.5947	1.6804	1.6289	1.5261
Min	1.0117	.463	.6001	.9431	.6687	.8573	.8573
Avg	1.3946	1.2635	1.2939	1.4075	1.3412	1.2046	1.1325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024027 / 33 KV MANATRI

Feeder No / Name : 203 / 11 KV DAHIGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.1317	1.0288	1.0631	1.1145	1.6461	1.8861
2	1.1145	.8573	1.0288	1.0288	1.0974	1.6461	1.8861
3	1.0288	.8745	1.0288	.9945	1.0802	1.6461	1.8861
4	.9431	.8573	1.0288	.9774	1.0288	1.6461	1.8519
5	.8573	.8402	.8573	.9431	.9602	1.6118	1.7318
6	.7716	.7716	.8573	.9259	.8916	1.5432	1.5775
7	.5658	.6001	.5487	.9602	.8402	1.3717	1.5089
8	.5487	.5316	.4115	.9774	.7716	1.3032	1.4575
9	.5144	.4801	.4458	.9945	.8402	1.3032	1.4232
10		1.0288	.9602	.5487	.6173	1.1488	1.1145
11	.8916	1.1317	1.0974	.583	.583	1.3032	1.3717
12	1.0974	1.0288	1.1145	.6001	.6859	1.286	1.406
13	1.1317	.9945	1.1145	.7716		1.3546	1.3889
14	1.1317	.9088	1.1145	.823		1.3203	1.3717
15	1.1317	.8916	1.5432	.8402		1.286	1.3717
16	1.1145	.9602	1.6461	.7888		1.2689	1.3717
17	1.0974	.9945	.9602	.7716		1.1488	1.3717
18	.5316	.6173	.6001	.463		.5144	.6173
19	.8573	.6516	1.1145		.9774	.7716	.6859
20	1.046	.9602	1.166	.9945	1.1145	1.0631	.9431
21	1.1317	1.0631	1.2003	1.0288	1.2346	1.0631	1.0117
22	1.1317	1.0631	1.2003	1.0974	1.2346	1.1831	1.166
23	1.1317	1.0631	1.2003	1.1145	1.2003	1.1831	1.166
24	1.1488		1.0631	1.1488	1.1145	1.1488	1.9204
Max	1.1488	1.1317	1.6461	1.1488	1.2346	1.6461	1.9204
Min	.5144	.4801	.4115	.463	.583	.5144	.6173
Avg	.9580	.8827	1.0138	.8886	.9659	1.2817	1.3953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 201 / 11 KV Danapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.583	.6859	.6668	.6173	.7049	.6173
2	.8078	.7316	.884	.6001	.6001	.6859	.6173
3	.7926	.7316	.8688	.5658	.5487	.5716	.0514
4	.7621	.7621	.945	.5487	.5144	.5716	.6173
5	.7316	.7926	.884	.5316	.463	.4954	.5487
6	.6706	.823	.8535	.3772	.3772	.4191	.3601
7	.6401	.8535	.8383	.2915	.3429	.381	.3086
8	.6706	.884	.8383	.2915	.2743	.3429	.2401
9	.6706	.9145	.823	.884	.2401	.3048	.2572
10	.3429	.3048	.3429	.884	1.0288	1.0059	.9145
11		.3429	.3772	1.0288	.945	1.0822	.9755
12	.6287	.4954	.4458	.945	.9755	1.0974	1.0364
13	.6478	.5335	.5144	.9755	.9145	1.0822	1.0517
14	.6668	.5335	.6001	.9755	.945	1.1279	1.0669
15	.6668	.5335	.6344	.945	.9907	1.0822	1.0517
16		.5525	.6001	.9297	1.0517	1.0669	1.0364
17			.463	.9297	1.0364	1.0059	1.0212
18		.4954		.3772	.4191	.4001	.4191
19	.6516	.5525	.4287	.5487	.4763	.6097	.5716
20	.6859	.6097	.6859	.6859	.7811	.7621	.6668
21	.7716	.724	.7621	.7202	.724	.8002	.743
22	.6516	.724	.7621	.6344	.7049	.8383	.7621
23	.6173	.7049	.6859	.6344	.724	.7049	.6173
24	.583	.6344	.6668	.6859	.6344	.6859	.6173
Max	.8078	.9145	.945	1.0288	1.0517	1.1279	1.0669
Min	.3429	.3048	.3429	.2915	.2401	.3048	.0514
Avg	.6622	.6442	.6778	.6940	.6804	.7429	.6737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 202 / 11 KV Warkhed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2401	.2858	.2667	.2401	.7926	.6706
2	.2229	.2058	.2858	1.0364	.8383	.8383	.6706
3	.2058	.2058	.2667	.9755	.8535	.7926	.6706
4	.1715	.2058	.2667	.9145	.9774	.7926	.6706
5	.1372	.1715	.2286	.8916	.884	.7468	.6554
6	.1372	.1372	.1905	.7621	.8993	.7468	.6401
7	.12	.12	.1524	.7011	.8993	.7164	.6097
8	.1029	.1029	.1143	.8078	.8993	.7164	.5944
9	.1029	.0857	.1143	.7468	.9088	.6401	.6706
10	1.2498	1.0822	1.0212	.12	.3258	.1143	.1029
11	1.3108	1.1279	1.0974	.1372		.1334	.1372
12	1.2803	1.0669	1.286	.1372	.0686		.1372
13	1.1888	1.0974	1.1431	.1715	.1543		.1715
14	1.1888	1.0669	1.1431	.1715	.2058	.1715	.1715
15	1.1584	1.1126	1.1279	.1715	.2058	.1905	.1715
16	1.1888	1.0822	1.1431	.1372	.1886	.1524	.1715
17	1.2498	1.0669	1.1431	.1372	.1543	.1524	.1372
18	.2229	.1715	.1372	.12	.1905	.1334	.1143
19	.2229	.1677	.1715	.2058	.2096	.2286	.1524
20	.2572	.2477	.2858	.2743	.2477	.2667	.2667
21	.2743	.2667	.3239	.2915	.2858	.3048	.3048
22	.2743	.2667	.3048	.2572	.3048	.3048	.3048
23	.2229	.2477	.2858	.2572	.3048	.2667	.2572
24	.2229	.2401	.2667	.2667	.2401	.2743	.6706
Max	1.3108	1.1279	1.286	1.0364	.9774	.8383	.6706
Min	.1029	.0857	.1143	.12	.0686	.1143	.1029
Avg	.5390	.4911	.5327	.4149	.4559	.4307	.3802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 203 / 11 KV Hingani

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2743	.3048	.2743	.2743	.2743
2	1.6156	1.4632	1.6632	.2743	.2743	.2401	.2743
3	1.5851	1.4937	1.5546	.2743	.2743	.2401	.2743
4	1.5242	1.5242	1.5851	.2743	.2401	.2401	.2743
5	1.6461	1.6156	1.5242	.2743	.2401	.2058	.2058
6	1.4937	1.6461	1.4632	.1715	.2058	.1715	.1372
7	1.4327	1.6461	1.4022	.1029	.1715	.1029	.1029
8	1.3717	1.6766	1.4327	.0857	.0857	.0686	.0857
9	1.3413	1.6766	1.3717	.0857	.0857	.0686	.0857
10	.1029	.1029	.1029	1.9052	1.6766	1.768	1.768
11	.12	.1372	.1372	2.0119	1.6766	1.8595	1.829
12	.1372	.1715	.1372	2.0729	1.6766	1.89	1.8595
13	.1372	.1886	.1715	2.0119	1.9509	2.0119	1.89
14	.1886	.1715	.2058	1.9814	1.9509	1.9204	1.829
15	.1886	.1886	.2058	1.9509	1.9509	1.6766	1.7985
16	.2058	.1886		1.9204	1.9204	1.6461	1.768
17	.1372	.1372		1.8595	1.7833	1.6156	1.7375
18	.1715	.1372		.1029	.1029	.0857	.0953
19	.2058	.1372	.1372	.2058	.1372	.1905	.1334
20	.1715	.0154	.1905	.2401	.2058	.2667	.1905
21	.2743	.2058	.3048	.2743	.2743	.3048	.2667
22	.2743	.2743	.3048	.2743	.2743	.3429	.3048
23	.2743	.2743	.3048	.2743	.2743	.3429	.2743
24	.2743	.2743	.2743	.3048	.2743		.2915
Max	1.6461	1.6766	1.6632	2.0729	1.9509	2.0119	1.89
Min	.1029	.0154	.1029	.0857	.0857	.0686	.0857
Avg	.6312	.6509	.7023	.8016	.7492	.7623	.7396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024032 / 33 KV Danapur

Feeder No / Name : 204 / balhadi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4801	.4115	.4954	.4458	2.3472	2.1033
2	.4458	.4458	.4115	1.9509	1.9814	2.3015	2.1033
3	.4115	.4458	.3772	1.9052	2.0119	2.3167	2.1033
4	.3772	.4115	.3429	1.9052	2.0729	2.2862	2.1033
5	.3429	.3429	.3429	1.9052	2.1338	2.2405	2.0729
6	.2401	.2743	.2058	1.9204	2.1643	2.1186	1.9814
7	.2058	.2401	.0857	1.9509	2.2253	2.1643	2.1338
8	.1715	.2058	.1715	1.9966	2.2558	2.2253	2.2862
9	.1715	.1715	.12	1.9052	2.1033	2.2558	
10	2.6063	2.6825	2.5911	.1715	.1524	.1715	.1715
11	2.713	2.7282	2.5911	.1715	.1715	.2229	.2058
12	2.6673	2.5911	2.5911	.2401		.2401	.2572
13		2.4691	2.5606	.2743	.3086	.2743	.3086
14	2.8349	2.4387	2.5606	.3086	.3086	.2743	.3086
15	2.7435	2.4691	2.4996	.2743	.3086	.1029	.3086
16	2.6216	2.4387	2.7092	.2743	.3086	.2743	.2401
17	2.5911	2.4082	2.3167	.2401	.2401	.2572	.1372
18	.2058	.1543	.1715	.2058	.2058	.2058	.1524
19	.2743	.2915	.2058	.2743	.2743	.381	.3048
20	.3772	.3601	.381	.4115	.3258	.4954	.381
21	.4458	.4115	.4954	.4458	.4287	.5144	.4572
22	.4801	.4458	.4954	.4801	.4801	.5335	.4954
23	.4458	.4801	.4954	.4801	.463	.5335	.4801
24	.4458	.4801	.4801	.4954	.4458		2.1491
Max	2.8349	2.7282	2.7092	1.9966	2.2558	2.3472	2.2862
Min	.1715	.1543	.0857	.1715	.1524	.1029	.1372
Avg	1.0550	1.0778	1.0672	.8618	.9485	1.0755	1.0107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 201 / Talegaon Bz SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.7811	.7811	.7621	.7811	.8383
2	1.3279	1.6787	1.3927	.7621	.724	.7621	.8002
3	1.3279	1.6448	1.3927	.724	.724	.724	.8002
4	1.2955	1.6289	1.3603	.6859	.6859	.6859	.7621
5	1.2955	1.5775	1.3603	.6097	.6859	.6097	.7621
6	1.2308	1.5261	1.3765	.5525	.5525	.5335	.5716
7	1.4899	1.6804	1.5061	.4191	.4191	.381	.4191
8	1.5708	1.6804	1.6032	.362	.362	.362	.362
9	1.6032	1.6632	1.5384	.381	.362	.362	.362
10	.3239	.3429	.362	1.543	1.587	1.5912	1.7814
11	.4191	.381	.362	1.6118	1.7318	1.7465	1.8299
12	.5525	.4572	.4382	1.6118	1.6975	1.8004	1.7814
13	.5525	.5144	.5335	1.6289	1.7318	1.7661	1.7814
14	.5716		.5906	1.5261	1.6975	1.7833	1.7652
15	.5716		.6097	1.5939	1.7147	1.7661	1.7814
16	.5335		.5906	1.5939	1.6804	1.7953	1.7814
17	.4572	.4191	.4954	1.5939	1.6975	1.668	1.6518
18	.4382	.4954	.4572	.4191	.4001	.381	.4001
19	.5716	.5716	.5144	.4954	.381	.5525	.4954
20	.743	.7811	.6668	.7049	.7049	.743	.743
21	.8002	.7811	.7621	.7811	.8002	.8192	.8002
22	.8002	.8192	.8002	.8002	.8383	.8383	.8764
23	.8192	.8192	.8002	.7811	.8192	.8764	.8383
24	.7621	.7811	.7811	.7811	.7811	.7811	.8573
Max	1.6032	1.6804	1.6032	1.6289	1.7318	1.8004	1.8299
Min	.3239	.3429	.362	.362	.362	.362	.362
Avg	.8675	1.0003	.8781	.9477	.9809	1.0046	1.0351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 202 / industrial feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.1334	.1905	.1715	.1905	.1334
2	.1143	.1334	.1334	.1905	.1715	.1905	.1334
3	.1143	.1334	.1334	.1905	.1715	.1905	.1334
4	.1143	.1334	.1334	.2096	.1715	.1905	.1334
5	.1143	.1334	.1334	.2096	.1715	.1905	.1334
6	.1334	.1334	.1334	.1524	.1334	.1905	.1334
7	.1334	.1334	.1334	.1524	.1334	.1715	.1334
8	.1334	.1334	.1334	.1334	.1143	.1715	.1334
9	.1334	.1334	.1143	.1143	.1334	.1524	.1143
10	.1334	.1143	.1143	.1334	.1334	.1524	.1143
11	.1334	.1143	.1143	.1334	.1334	.1334	.1334
12	.1334	.1334	.1334	.1334	.1334	.1334	.1334
13	.1334	.1334	.1334	.1334	.1334	.1334	.1334
14	.1334	.1334	.1334	.1334	.1143	.1334	.1143
15	.1334	.1334	.1334	.1334	.1334	.1334	.1143
16	.1334	.1334	.1334	.1334	.1143	.1334	.1143
17	.1334	.1334	.1334	.1334	.1143	.1143	.1143
18	.1334	.1334	.1334	.1334	.1143	.1143	.1334
19	.1334	.1334	.1334	.1334	.1334	.1143	.1905
20	.1334	.1143	.1334	.1334	.2096	.1143	.1143
21	.1334	.1143	.1334	.2096	.1905	.1143	.1334
22	.1334	.1524	.2096	.1905	.2477	.1334	.1715
23	.1334	.1334	.1334	.1905	.2096	.1334	.1715
24	.1334	.1334	.1334	.1715	.1905	.1905	.1334
Max	.1334	.1524	.2096	.2096	.2477	.1905	.1905
Min	.1143	.1143	.1143	.1143	.1143	.1143	.1143
Avg	.1294	.1310	.1342	.1572	.1532	.1508	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024035 / Khandala

Feeder No / Name : 203 / Borwa

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.743	.743	.724	.724	2.4348	2.3529
2	.6859	.724	.724	2.2977	2.6787	2.4348	2.3167
3	.6478	.6668	.724	2.2721	2.6787	2.3739	2.3167
4	.6478	.6478	.6859	2.2382	2.6425	2.34	2.3167
5	.6097	.6097	.6668	2.2382	2.6425	2.323	2.2805
6	.5716	.5716	.5335	2.332	2.552	2.3061	2.2805
7	.4191	.3048	.4382	2.452	2.5701	2.0388	2.5158
8	.362	.3048	.362	2.2721	2.5701	2.5206	2.6244
9	.362	.3239	.3429	2.4691	2.5701	2.3663	2.7511
10	2.9321	2.5377	2.6244	.362	.3429	.3429	.362
11	2.8578	2.6006		.4001	.4001	.381	.381
12	2.5587	2.5892	2.753	.4763	.4572	.4382	.4572
13	2.5749	2.4478	2.8673	.5144	.4954	.6097	.4954
14	2.6558	2.3644	2.5101	.5525	.5335	.6097	.5716
15	2.6235	2.4291	2.4646	.5525	.5335	.6478	.5716
16	2.672	2.2996	2.4291	.4954	.4954	.5296	.5144
17	2.5911	2.3739	2.4291	.4382	.4572	.4572	.4001
18	.4191	.4191	2.4129	.4191	.4001	.4001	.3429
19	.5525	.4954	.4954	.4572	.5144	.4763	.4763
20	.7049	.6478	.6859	.6668	.6859	.6097	.6668
21	.7811	.6859	.743	.743	.724	.743	.7049
22	.7621	.743	.7811	.7621	.743	.743	.7621
23	.743	.724	.743	.7621	.743	.743	.743
24	.724	.743	.724	.724	.743	.724	2.3529
Max	2.9321	2.6006	2.8673	2.4691	2.6787	2.5206	2.7511
Min	.362	.3048	.3429	.362	.3429	.3429	.3429
Avg	1.2977	1.2082	1.2993	1.1509	1.2457	1.2331	1.3149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 201 / 11 KV KODRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0572	.0217	.0762				
3	.0714	.0217	.0476				
4	.0714	.0434	.0572				
5	.0857	.0434	.0667				
6	.1	.0652	.0572				
7	.1		.0572				
8	.0381		.0429				
9	.0286	.0217	.0429				
10				.0762	.076	.1	.0857
11				.0977	.1286	.1143	.1
12				.0098	.1	.1286	.0977
13				.0977	.0857	.1143	.0977
14				.076	.0857	.1143	.0869
15				.0652	.1	.1143	.076
16				.076	.1143	.1143	.0869
17				.0869	.1286	.1143	.0977
Max	.1	.0652	.0762	.0977	.1286	.1286	.1
Min	.0286	.0217	.0429	.0098	.076	.1	.076
Avg	.0691	.0362	.0560	.0732	.1024	.1143	.0911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 202 / Wadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	1.0288	.9717	1.0479	1.0098	.8745	.8583
2	1.0288	1.0288	.9717	.7701	.7716	.8745	.8482
3	1.0288	.9907	.9717	.7611	.7716	.8065	.8065
4	.9526	.9526	.9526	.7611	.7716	.7499	.8223
5	.9145	.9145	.9526	.7522	.7716	.7316	.8223
6	.8002	.7621	.6668	.6539	.7099	.7716	.7716
7	.6097	.4572	.4954	.643	.7562	.7716	.8025
8	.4763		.362	.6485	.7716	.7773	.7468
9	.4382	.4001	.4001	.7042	.7716	.743	.7811
10	.7095	.7253	.8383	.5144	.4382	.4572	.4001
11	.7225	.7253	.8173	.5716	.4382	.5906	.5525
12	.7716	.7343	.8905	.6478	.6859	.6668	.6668
13	.8488	.7499	.8333	.743	.8383	.8002	.743
14	.7562	.7343	.8488	.7621	.8383	.8192	.7621
15	.9145	.703	.8697	.7621	.8383	.8002	.8192
16	.7716	.6874	.8436	.6668	.7621	.7811	.6859
17	.8025	.7407	.7074	.5716	.6478	.4572	.5335
18	.4954	.4531	.5144	.4572		.5144	.4382
19	.8192	.6859	.6668	.6478	.6859	.724	.6668
20	.9526	.9717	1.0098	.9907	.9335	.9145	.9335
21	1.0479	1.105	1.0669	1.0669	1.0669	1.0288	1.0288
22	1.0479	1.105	1.1431	1.086	1.086	1.0479	1.086
23	1.0479	1.105	1.105	1.0669	1.0479	1.0669	1.0479
24	1.0669	1.0479	1.0479	1.086	1.0288	1.0288	.8642
Max	1.0669	1.105	1.1431	1.086	1.086	1.0669	1.086
Min	.4382	.4001	.362	.4572	.4382	.4572	.4001
Avg	.8363	.8178	.8311	.7660	.8018	.7833	.7703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

AKOLA ZONE[062]

AKOLA CIRCLE[610]

AKOT DIVISION[610]

TELHARA SUB-DN.[282] BU 2828

Substation No/ Name :- 024043 / 33 KV UKALI BZ S/STN

Feeder No / Name : 203 / Warud SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4191	.4954	.4572	.4954	.4572	.4382
2	.3481	.2881	.4049	.4191	.4763	.4763	.4382
3	.3688	.2881	.4049	.4191	.4382	.4763	.4191
4	.3563	.2881	.3887	.4191	.4382	.4382	.4001
5	.3795	.2881	.4049	.4382	.381	.381	.4001
6	.3704	.3201	.4001	.3239	.2858	.3429	.3429
7	.3475	.3201	.3763	.2667	.1715	.2858	.1715
8	.3286		.3913	.1334	.1905	.2096	.1715
9	.4012	.3041	.431	.1905	.2667	.2477	.2096
10	.2477	.2286	.2477	.5121	.4961	.442	.4475
11	.2477	.2477	.2477	.5281	.4531	.4938	.4784
12	.362	.3429	.362	.5441	.4531	.4744	.4902
13	.381	.4001	.4001	.5281	.4111	.502	.4961
14	.381	.381	.4001	.4801	.3795	.4475	.4801
15	.4191		.4191	.4161	.3858	.421	.4961
16	.381		.381	.4161	.4268	.4001	.4801
17	.3048	.3429	.3239	.4161	.4161	.3858	.4481
18	.2096	.2667	.2096	.2667		.2096	.2096
19	.381	.3239	.2858	.3239	.4001	.3429	.3239
20	.5335	.5144	.5144	.5335	.4954	.4954	.4954
21	.5525	.5525	.5144	.5335	.5335	.5716	.5525
22	.5335	.5335	.5525	.5335	.5335	.5525	.5335
23	.4954	.5335	.4763	.5335	.4954	.5144	.4572
24	.4763	.4572	.5144	.4572	.5144	.4572	.4763
Max	.5525	.5525	.5525	.5441	.5335	.5716	.5525
Min	.2096	.2286	.2096	.1334	.1715	.2096	.1715
Avg	.3852	.3638	.3978	.4204	.4147	.4177	.4107