

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 201 / TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.5396	.4287	.3429	.3429	
2		.3429	.5396	.4287	.0533	.3429	
3		.3429	.6158		.4001	.3429	
4		.3429	.6744	.5144	.4668	.6859	
5		.5144	.6744	.6859	.4572	.8573	
6		.5144	.6744	.8573	.6287	.8573	
7		.8573	.6744	1.2003	.4572	1.0288	
8		.8573	.6744		.5716	1.0288	
9	.8573	.8573	.6744	1.1145	.5716	.8573	.8573
10	.8573	.6744	.8573	.4572	.7716		.8573
11	.8573	.6744	.8573	.3429	.7716		.8573
12	.6859	.6744			.6859		.6859
13					.5144		.6001
14					.5144		.5144
15	.6859	.6744	.6859		.5144	.7697	.5144
16	.6859	.6744	.6001	.4572	.6859	.7697	.6859
17	.8573	.6744		.5144		.6744	.7716
18	.8573	.7621		.6859		.7697	.8573
19	.8573	.6744			1.2003	.7697	.9431
20	.6859	.7668	.8573	.5335	.8573	.7697	.8573
21	.5144	.7697	.6859	.4572	.5144	.7697	.6001
22	.3429	.6744	.6001	.4763	.5144	.7697	.5144
23	.3429	.6744	.5144	.2858	.3429	.7697	.4287
24		.3429	.7697	.5144	.2858	.3429	.3079
Max	.8573	.8573	.8573	1.2003	1.2003	1.0288	.9431
Min	.3429	.3429	.5144	.2858	.0533	.3429	.3079
Avg	.6990	.6220	.6761	.5856	.5510	.7115	.6783

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 202 / TOWN2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5144	.8093	.5144	.9335	.5144	
2	.5144	.5144	.9236		.8669	.5144	
3	.6859	.5144	.9442	.5144	.0867	.5144	
4	.0686	.8573	.9442	.5144	.9335	.5144	
5	.743	1.0288	.9442	.6859	.8002	.8573	
6	.9335	1.0288	1.2193	1.1145	1.1336	1.0288	
7	.8002	1.0288	1.0791	1.4575	1.0669	1.3717	
8	1.0669	1.3717	.9442		.9335	1.3717	
9	1.2003	1.2003	.8093	1.7147	.6859	1.2003	1.2003
10	1.1145	.8093	1.0288	.8002	1.1145		1.0288
11	1.1145	.8093	.9431	.6859	1.1145		.9431
12	.8573	.8093	.7716		.6859		.8573
13		.8093			.6859		.6859
14					.6001		.6859
15		.8093	.8573		.6001	.9236	.6001
16	.8573	.8093	.8573	.5716	.6001	.9236	.6859
17	.8573	.8093		.5239		.9236	.7716
18	1.0288	.8093		.6859		.9236	.8573
19	1.0288	.8093		.6001	1.3717	.9236	1.0288
20	1.0288	.8093	.8573	.7335	1.2003	.9236	.8573
21	.8573	.8093	.7716	.6859	.9431	.9236	.7716
22	.6859	.8093	.6859	.5335	.6859	.7697	.6859
23	.5144	.8093	.6859	.4572	.3429	.7697	.6001
24	.4001	.5144	.8093	.6001	.0667	.5144	.6744
Max	1.2003	1.3717	1.2193	1.7147	1.3717	1.3717	1.2003
Min	.0686	.5144	.6859	.4572	.0667	.5144	.6001
Avg	.8007	.8302	.8887	.7441	.7933	.8635	.8084

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 203 / BORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.6097	.3048	.2286	.1905	.6158
2	1.3717	.2286	.5396	.3048	.2286	.1905	.6158
3	1.7147	.2286	.5396	.3048	.3334	.1905	.6158
4	1.9433	.4572	.5396	.2286	.2858	.1905	.6158
5	2.8006	.5716	.5396	.2286	.2667	.2858	.6158
6	2.8006	.5716	.2698	.1905	.2667	.2858	.6158
7	2.6292	.5716		.3048	.3334	.2858	.6158
8	2.572	.4572					.5396
9	3.0007	.3429					.6097
10	.1143	2.3091	2.915	2.0005	1.6004	.1677	1.829
11	.1143	2.0233	3.0864	2.1719	1.8004	2.3091	2.572
12	.1143	2.0233	3.0864	1.829	2.5911	2.463	2.572
13	.1143		3.2579	1.7147	2.1338	2.1582	2.4863
14	.1143			1.9433	2.0005	2.463	2.915
15	.1143		3.0864	2.1719	2.0005	2.463	3.0864
16	.1143	2.0233	3.0864	2.0576	2.0005	2.463	2.4006
17	.1143	1.8884		1.7147		2.0233	.6859
18	.2286	1.8884		.3429		.6158	.6097
19	.2286	.6135		.2667	.2858	.6158	.6097
20	.2286	.5396	.381	.2286	.1905	.6158	.4572
21	.2286	.5396	.3048	.2858	.1905	.6158	.381
22	.2286	.5396	.3048	.1143	.2667	.3079	.3048
23	.2286	.5396	.3048	.1715	.1905	.0335	.3048
24	.9145	.2286	.5396	.3048	.1715	.1905	.6158
Max	3.0007	2.3091	3.2579	2.1719	2.5911	2.463	3.0864
Min	.1143	.2286	.2698	.1143	.1715	.0335	.3048
Avg	.9580	.8959	1.3760	.8721	.8683	.9602	1.1371

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 204 / GOLAPANGRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6668	2.3091	2.0576	2.2862	1.0669	1.3855
2	.1143	.6668	2.1582	2.2291	2.1719	1.0669	2.1552
3	.1143	.9335	2.7709	2.2291	2.1719	1.2193	2.463
4	.1143	1.0669	2.428	1.286	2.4006	1.3336	2.463
5	.1429	1.2003	2.6978	1.5432	2.6292	2.4006	3.0788
6	.0953	1.2003	2.8327	1.7147	2.8006	2.6673	3.0788
7	.0953	1.7337	.3121	2.6292	3.0674	2.6673	3.2327
8	.2	2.2672	3.0788	3.0674	2.934	2.934	3.2327
9		2.6673	2.6978	2.8006	2.8006	2.934	3.4294
10	2.1338	.6158		.1143	.3429	.5396	.2286
11	3.4294	.5396		.1715	.3429	.6158	.2286
12	2.6673	.6158		.1143	.2286	.5396	.2286
13	2.6673			.1143	.2286	.6158	.2286
14	2.6673			.1715	.1143	.6158	.2286
15	2.6673	.0335		.1715	.1143		.2286
16	2.6673	.2698		.2286	.0953		.2286
17	2.1338	.0594		.1715			.2286
18	.4572	.5396		.1334		.6158	.4572
19	.4572	.5396		.1905	.5716	.6158	.5335
20	.4572	.5396	.4572	.4001	.2858		.4572
21	.3429	.5396	.4572		.2858	.6158	.381
22	.2286	.5396	.4572	.1715	.3429	.6158	.381
23	.2858	.0594	.4572	.2286	.2858	.6158	.3429
24	.1715	.6668	1.0791	.4001	2.0576	.8002	1.0791
Max	3.4294	2.6673	3.0788	3.0674	3.0674	2.934	3.4294
Min	.0953	.0335	.3121	.1143	.0953	.5396	.2286
Avg	1.1050	.8164	1.7281	.9712	1.2981	1.2548	1.2492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 205 / SHAHAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	.4572	.5396	.4572	.1715	.3429	
2	1.7147	.4572	.6158	.4572	.2858	.3429	
3		.4572	.615	.4572	.2858	.3429	
4	1.7147	.3429	.6158	.4572	.2858	.5716	
5	2.0576	.5716	.5396	.5335	.2286	.5716	
6	2.1719	.5716	.5396	.7621	.4001	.6859	
7	2.0576	.8002	.5396	.9145	.4001	.6859	
8	2.2862	.9335	.4047	.9145	.2858	.6859	
9	2.6673	.8002	.2698	.9145	.3429	.6859	.9145
10	.1143	2.6978	2.7435	1.9433	1.6004	1.5394	2.572
11	.1715	2.8327	3.0007	1.6004	1.8671	2.463	2.915
12	.1143	2.9675	3.5151		2.2672	2.7709	3.0864
13	.1143	2.6978	3.5151	2.5339	2.2672	3.0788	3.1722
14	.1143	2.6978	3.5151	2.8006	2.2672	2.6978	2.915
15	.1143	2.6978	.3429	2.4577		2.463	2.7435
16	.1143	2.6978	3.2579	2.8006	2.2862	2.7709	2.915
17	.1143	2.6978		2.4006		2.7709	2.8292
18	.2286	.5396		.2667		.6158	.7621
19	.9335	.5396		.5335	.8002	.6158	.9145
20	.9335	.5396	.8573	.4001	.6668	.6158	.8573
21	.6668	.5396	.6097	.3429	.5716	.6135	.6097
22	.6668	.0671	.5335	.1715	.4572	.6158	.6097
23	.6668	.5396	.4572	.1715	.4572	.6158	.5144
24	1.2574	.5716	.6158	.4572	.2286	.3429	.4047
Max	2.6673	2.9675	3.5151	2.8006	2.2862	3.0788	3.1722
Min	.1143	.0671	.2698	.1715	.1715	.3429	.4047
Avg	1.0023	1.2798	1.3163	1.0760	.8773	1.2294	1.7960

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 206 / EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.1524	.3079	.1715	.2858	.1524	
2	.2286	.1524	.2698	.1715	.3429	.1524	
3	1.6004	.1524	.2698	.1715	.3429	.1524	
4	.2858	.1524	.0305	.1715	.2858	.1715	
5		.1524	.2698	.1715	.2286	.1524	
6	.2	.1524	.3079	.1715	.2286	.1524	
7	.2286	.1524	.3079	.3429	.2286	.1524	
8	.2286	.2	.2698	.3429	.2667	.3048	
9	.2286	.2286	.2698	.3429	.2858	.2667	.3429
10	.2286	.3079	.3429	.2286	.3048	.3079	.3429
11	.2	.2698	.3429		.2667	.3079	.4287
12	.2572	.2698	.3429	.1715	.3048	.3079	.4287
13	.2667	.2698	.3429	.2382	.3429	.3079	.4287
14		.2698	.3429	.1715	.3429	.3079	.4287
15	.2667	.2698	.3429	.1143	.2667	.3079	.4287
16	.2667	.2698	.3429	.1143		.3079	.4287
17	.2667	.3048		.1715		.3079	.4287
18	.2667	.3048		.2		.3079	.4287
19	.2667	.2698		.2667	.3048	.3079	.4287
20	.1334	.2698	.3429	.2667	.2286	.3079	.4287
21	.1334	.0297	.3429	.1429	.2286	.3079	.4287
22	.1334	.2698	.2572	.1143	.1524	.3079	.2572
23	.1334	.2698	.1715	.1905	.1524	.0335	.2572
24	.2858	.1524	.2698	.1715	.2382	.1524	.3079
Max	1.6004	.3079	.3429	.3429	.3429	.3079	.4287
Min	.1334	.0297	.0305	.1143	.1524	.0335	.2572
Avg	.2897	.2205	.2899	.2009	.2681	.2436	.3890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 207 / TOWN NO-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.4287	.4047	.2572	.2286	.2572	
2	.2286	.4287	.4047		.2858	.2572	
3	.2858	.4287	.4047	.2572	.1429	.2572	
4	.1429	.4287	.4047	.2572	.2286	.3429	
5	.3429	.4287	.4047	.3429	.2286	.3429	
6	.2858	.4287	.4047	.5144	.2858	.3429	
7	.2858	.5144	.4047	.6001	.2858	.4287	
8	.3429	.5144	.4601	.6001	.3429	.5144	
9	.5144	.5144	.4047	.5144	.2858	.5144	.5144
10	.5144	.4047	.5144	.3334	.4287		.5144
11	.4287	.4047	.5144	.3429	.4287		.5144
12	.4287	.4047	.5144	.5716	.4801		.5144
13	.3429	.4047	.4287	.2858	.3429		
14	.3429		.3429		.3429		.5144
15	.3429	.2698	.3429	.3429	.3429	.4618	.5144
16	.3429	.4047	.5144	.2858	.3429	.4618	.4287
17	.4287	.4618		.2858		.4618	.5144
18	.4287	.4047		.4001		.4618	.5144
19	.5144	.4047		.3334	.6859	.4618	.5144
20	.5144	.4047	.4287	.4001	.6001	.4618	.5144
21	.4801	.4047	.4287	.2858	.4287	.4618	.4287
22	.4287	.4047	.3429	.0238	.3429	.3079	.3429
23	.4287	.4047	.3429	.3429	.3429	.3079	.3429
24	.3429	.4287	.0446	.3429	.2286	.2572	.3079
Max	.5144	.5144	.5144	.6001	.6859	.5144	.5144
Min	.1429	.2698	.0446	.0238	.1429	.2572	.3079
Avg	.3737	.4229	.4027	.3600	.3479	.3875	.4663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 201 / WADIGORI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0669	.4001	.6097	.6097
2		1.2003	.4001	.6668	.6478
3		1.2193	.4572	.6668	
4		1.2574	.5144	.7049	.6859
5		1.3336	.5525	.743	
6		1.3717	.5906	.7621	.7621
7		1.4098	.6478	.8383	
8		1.448	.7811	1.105	.7621
9		1.3336	.9335	1.1812	
10		1.0098	.8573	1.3717	1.0098
11		1.1812	1.3717	1.448	1.3336
12		1.3336	1.8099	1.4861	1.848
13		1.3527	1.848	1.5242	1.829
14		1.3717	1.8861	1.5051	
15		1.3146	1.8861	1.5242	
16		1.2384	1.7528	1.5623	
17		1.1241	1.6385	1.4861	1.6385
24	.9717	.6668	.362	.5335	.6668
Max	.9717	1.448	1.8861	1.5623	1.848
Min	.9717	.6668	.362	.5335	.6097
Avg	.9717	1.2352	1.0383	1.0955	1.0721



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 202 / NALEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.2477	.3048	.3048
2		.4954	.2477	.3429	
3		.5525	.362	.362	.362
4		.6287	.4572	.4382	
5		.6859	.5906	.4954	.5716
6		.724	.743	.5525	
7		.7621	.8573	.5716	
8		.743	.7811	.5335	.5716
9		.6097	.724	.5144	
10		.4572	.4954	.2286	.4191
11		.2858	.381		
12		.1905	.2667	.381	
13		.1715	.2286	.1524	.2096
14		.1524	.1905	.1905	
15		.1524	.1524	.1905	
16		.1715	.2286	.1524	
17		.3239	.2667	.1905	.1715
18		.4191	.5335	.4954	
19		.743	.5716	.6097	.1905
20		.6097	.5716	.4572	
21		.4572	.4382	.381	
22		.3048	.381	.2667	
23		.2286	.3429		.362
24	.4572	.4763	.2286	.3048	.2477
Max	.4572	.7621	.8573	.6097	.5716
Min	.4572	.1524	.1524	.1524	.1715
Avg	.4572	.4501	.4287	.3689	.3410

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 203 / GONDI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3048	.3048	.3048
2		.381	.3429	.3239	.3048
3		.4572	.4001	.381	.3429
4		.4954	.5525	.7049	.4954
5		.5716	.6668	.7621	.5716
6		.743	.8002	.8383	.8383
7		.8383	1.0288	.9526	.9145
8		1.0288	.9907	.9335	
9		.9335	.9717	.8954	
10			.5716	.8002	
11		.4763	.4191	.8383	
12		.362	.3239		
13		.3048	.3048	.0953	.2477
14		.2858	.2477	.2667	
15		.3429	.2667	.3048	
16		.4572	.381	.381	
17		.5144	.4382		.3048
18		.6097	.381	.6478	
19		.7811	.743	.8192	
20		.7049	.724	.6859	.381
21		.5144	.4954	.5525	
22		.4001	.2858	.2667	.362
23		.3239	.3048		
24	.6097	.381	.3239	.2667	.2667
Max	.6097	1.0288	1.0288	.9526	.9145
Min	.6097	.2858	.2477	.0953	.2477
Avg	.6097	.5326	.5112	.5725	.4445

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 204 / SHAHAGAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048	.4572	.4191	.5906
2		.3429	.4572	.6097	.6287
3		.362	.5144	.6478	
4		.381	.5906	.6668	.6287
5		.4191	.6668	.6668	
6		.4001	.7049	.6859	.6859
7		.381	.743	.743	
8		.4001	.9145	.8002	.743
9		.4572	.9526	.8764	
10		.9907	.362	.381	.362
11		1.1622	.4572	.4191	.4191
12		1.2955	.5144	.4001	.4382
13		1.3146	.4763	.4382	.381
14		1.3336	.4572	.4572	
15		1.4098	.4572	.4191	
16		1.3146	.4763	.4763	
17		1.2765	.4954	.4572	.381
18		.0381	.0381	.0381	
19		.0381	.0191	.0381	.0191
20		.0381	.0191	.0381	.0191
21		.0381	.0191	.0191	
22		.0381	.0191	.0191	
23		.0191	.0191		.0191
24	.3048	.3048	.4382	.5335	.5716
Max	.3048	1.4098	.9526	.8764	.743
Min	.3048	.0191	.0191	.0191	.0191
Avg	.3048	.5858	.4279	.4456	.4205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 205 / SHAHAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097	.6668	.6478
2		.6478	.7049	.6668
3		.6478	.743	.724
4		.743	.8383	.8002
5		.8573	.9145	.8383
6		.8764	1.0288	1.1812
7		.9526	1.2384	1.3336
8		1.2384	1.6956	
9		1.2384	1.8099	
11	1.448			
12	1.6004			
13	1.6194			
14	1.6385			
15	1.6194			
16	1.6194			
17	1.5813			
24	1.2003	.5906	.6478	.5716
Max	1.6385	1.2384	1.8099	1.3336
Min	1.2003	.5906	.6478	.5716
Avg	1.5408	.8402	1.0288	.8454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 206 / SHAHAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6287	.2858	.4001	.3048
2		.6478	.3429	.4001	.3429
3		.6859	.362	.4572	.362
4		.743	.362	.5335	.4572
5		.8002	.6097	.6097	.5525
6		.9145	.9335	.743	1.0669
7		.9526	1.0669	1.0288	
8		.9717	1.0288	1.0669	
9		1.0288	1.0098	1.0669	
10		.7049	.743	.743	
11		.4763	.4001	.5335	
12		.4572	.3048	.381	
13		.4572	.2858	.3429	.5716
14		.4382	.2667	.2667	
15		.381	.2286	.2858	
16		.3239	.3048	.3429	
17		.3429	.3048	.381	.3048
18		.5144	.362	.9145	
19		.743	.9145	1.0669	
20		.8002	.3048		.3429
21		.5906	.362	.5716	
22		.4001	.4001	.8002	.4954
23		.3429	.3429		
24	.6859	.5716	.3429	.3239	.2667
Max	.6859	1.0288	1.0669	1.0669	1.0669
Min	.6859	.3239	.2286	.2667	.2667
Avg	.6859	.6216	.4946	.6027	.4607

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 201 / JAMKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.5144	.5144	.5144	.5487	.5601	.5144
2	.8573	.6001	.5144	.5144	.5487	.5601	.5144
3	1.0288	.6859	.5144	.6001	.5487	.5487	.6001
4	1.0288	.6859	.6859	.6859	.724	.7316	.6859
5	1.2003	.8059	.7716	.6859	.905	.9335	.8573
6	1.3546		.9431	.8059	1.0974	1.1203	1.0288
7	1.5432						
8	1.8861						
9	1.869	1.0974					.8573
10	.7716		1.7147	1.3336	1.6461	1.5432	1.7147
11	.6344		1.8861	2.0119	1.5546	1.6289	1.7147
12	.6687		1.5432	2.0119	1.4784	1.7147	1.6289
13		1.8004	1.7147	1.829	1.4632	1.7147	1.6289
14	.583		1.7147	1.829	1.4632	1.6289	1.6289
15	.6173		1.6289	1.4632	1.4632	1.6289	1.5432
16	.583	1.1145	1.5432	1.6461	1.7353	1.5432	1.5432
17	.6001	1.2003	1.4575	1.6461		1.3717	1.3717
18	.8745	1.7147	1.2003	.7316		.6859	.6859
19	.9088	.8573	1.0288	.9145	1.0974	.6859	.8573
20	.8402	.9431	.8573	.823	1.1203	.8573	.9431
21	.6859	.8573	.8573	.7316	.9145	.6859	.6859
22	.6001	.6859	.6859	.7316	.7316	.6859	.6001
23	.4973	.6001	.5144	.6401	.7316	.6001	.5144
24	.8745	.5144	.5144	.5144	.543	.5144	.5144
Max	1.8861	1.8004	1.8861	2.0119	1.7353	1.7147	1.7147
Min	.4973	.5144	.5144	.5144	.543	.5144	.5144
Avg	.9289	.9174	1.0860	1.0792	1.0692	1.0449	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 202 / ROHILAGAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	1.9719	1.7147	1.7147	2.0119	1.829	1.3717
2	.1372	1.9719	1.8861	1.9719	2.1948	2.2177	
3	.6001	1.9719	1.8861	2.0576	2.1719	2.2291	1.7147
4	.6859	2.0576	2.0576		2.7435	2.3777	1.6289
5	1.0288	2.2462	2.4006	2.7435	2.8959	2.5606	1.7147
6		2.452	2.4006	2.7435	3.1093	2.5606	1.9719
7		2.915	3.0864	3.0864	.0362	3.3836	3.0864
8		3.2407	3.4294	3.4294	3.786	3.8043	3.2579
9		3.275	3.4294	3.2579	3.658	3.5848	3.5151
10	2.0748	.6859				.6859	.6001
11	2.6063	.6859				.6859	.6001
12	2.8464					.6001	.5144
13	2.452				.5487	.3429	.4287
14	2.7435		.3429	.7316	.4572	.3429	.4287
15	2.5034		.4287	.5487	.4572	.3429	.4287
16	2.692	.5144	.5144	.7316	.5487	.3429	.5144
17	2.4006	.5144	.5144	.7316		.3429	.5144
18		1.2003	1.7147	.9145		1.0288	.6859
19	1.4746	1.3717	1.7147	1.4632	2.1948	1.2003	1.3717
20	1.4232	1.7147	1.7147	1.6461	2.1948	1.8861	1.4575
21	1.3889	1.7147	1.6289	1.6461	1.829	1.6289	1.3717
22	1.3889	1.7147	1.3717	1.4632	1.4632	1.3717	1.2003
23	1.3889	1.3717	1.3717	1.2803	1.4632	1.3717	1.2003
24	.5658	1.7147	1.7147	1.7147	1.5546	1.7147	1.7147
Max	2.8464	3.275	3.4294	3.4294	3.786	3.8043	3.5151
Min	.1372	.5144	.3429	.5487	.0362	.3429	.4287
Avg	1.6317	1.7653	1.7661	1.7830	1.8589	1.6015	1.3606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 203 / NANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.3429	.3429	.2743	.362	.3429
2		.2572	.3429	.2572	.2743	.3658	.2572
3		.3429	.3429	.2572	.3658	.4572	.2572
4		.4287	.3429	.3429	.4525	.5487	.3429
5		.5487	.6859	.3429	.5487	.7316	.5144
6		.6859	.6287	.6001	.543	.823	.7716
7		.6859		.6859			
8		.8402					
9		.703					
10		2.3148	2.4006	2.3777	1.7924	2.0576	2.4006
11		2.7435	2.8292	2.8006	2.1948	2.2291	2.4863
12		3.0864		2.894	2.5789	2.4006	2.4006
13	.2401	3.0864	2.915	2.5606	2.5606	2.0576	2.4006
14	.2229		2.915	2.5606	2.5606	2.0576	2.4006
15	.2058		2.7435	2.7435	2.1948	2.0576	2.4006
16	.2572	2.4006	2.7435	2.3777	2.5606	2.0576	2.4006
17	.3429	2.4006	2.4863	2.7435		2.2291	2.4006
18	.583	2.2291	.5144	.543		.5144	.3429
19	.6173	.4287	.6859	.7316	.5487	.5144	.5144
20	.5658	.4287	.6859	.5487	.7316	.4572	.5144
21	.5144	.6001	.5144	.4572	.5487	.5144	.4287
22	.4287	.5144	.3429	.4572	.5487	.5144	.4287
23	.3258	.4287	.3429	.3658	.3658	.3429	.3429
24		.3429	.3429	.3429	.2715	.3429	.3429
Max	.6173	3.0864	2.915	2.894	2.5789	2.4006	2.4863
Min	.2058	.2572	.3429	.2572	.2715	.3429	.2572
Avg	.3913	1.1707	1.2574	1.2424	1.1535	1.1255	1.1758



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 202 / SIRNER GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.2972	.0297	.0572	.0857	.0857	.1715
2	.0857	2.9835	.0029	.0572	.0857	.0857	.1715
3	.0857	.0029	.0057	.0572	.1715	.0857	.1715
4	.2572	.0572	.0572	.0572	.2572	.1715	.1715
5	.3429	.0086	.0583	.0857	.3429	.3429	.2572
6	.4287	.0143	.1143	.1143	.4287	.4287	.3429
7	.5144	1.4403	.1429	.1715	.5144	.5144	.3429
8		.1143	.1143				.5144
9		.0572	.0572	.1143			
10	.3429	.0057	.0572	.2572	.2572	.3429	.1715
11		.0572	.0572	.1715	.1715	.0857	.1715
12	.0572	.0572		.0857	.1715	.0572	.0857
13	.0572	.0572		.0857	.0857	.0572	.0857
14	.0572		.0572	.0857	.0857	.0572	.0857
15	.0572		.0286	.0857	.0857	.0286	.0857
16	.0572	.0572	.0572	.1715	.0857	.0286	.0857
17	.0572	.0572	.0572	.1715		.0572	.1715
18	.0114	.1143	.0857	.3429		.0857	.2572
19	.0143	.1429	.1429	.4287	.3429	.1143	.4287
20	.1429	.1143	.1143	.3429	.3429	.1429	.3429
21	.0572		.0857	.2572	.2572	.0572	.2572
22	.0286	.0686	.0572	.1715	.1715	.0572	.1715
23	.0286	.0286	.0572	.0857	.9098	.1715	.1715
24	.0286	.0286		.0572	.0857	.0857	.1715
Max	.5144	2.9835	.1429	.4287	.9098	.5144	.5144
Min	.0114	.0029	.0029	.0572	.0857	.0286	.0857
Avg	.1332	.2745	.0686	.1528	.2470	.1429	.2125

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 203 / SHIRNER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1238	.4763	.4763	.3048	.0286	.0381	.3429
2	.1238	.4763	.4763	.2286	.0286	.0381	.3429
3	.1334	4.8202	4.8011	.2286	.0286	.0381	.3429
4	.1334		.0381				
5	.1524						
6	.1715						
7	.2286	.0381	.4763				
8	.362	3.7151	.4763				
9	.362						
10		3.7151	2.1338	.2667	.2286	.2191	1.8861
11		3.7151	2.7435	.3239	.3429	2.5149	2.7435
12		3.7151	2.9721	.3334	.3334	2.8197	3.0007
13		3.7151	2.9721	.3048	.3144	2.8197	3.0007
14			2.9721	.381	.3239	2.7435	2.915
15			2.9721	.381	.3144	2.5911	2.915
16		3.7151	2.8959	.3715	.3048	2.5911	2.7435
17		3.7151	2.8959	.362		2.2862	2.4006
18						2.2862	
19						.3048	
20	.5716	.5716	.4572	.0667	.0667	.381	.4287
21	.5716		.381	.0572	.0476	.381	.4287
22	.4763	.4763	.381	.0572	.0381	.3048	.3429
23	.4763	.4763	.3048	.0476	.0381	.3429	.3429
24	.4763	.4763		.3048	.0286	.0381	.3429
Max	.5716	4.8202	4.8011	.381	.3429	2.8197	3.0007
Min	.1238	.0381	.0381	.0476	.0286	.0381	.3429
Avg	.3116	2.2545	1.7126	.2512	.1645	1.2632	1.5325

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 204 / CHINCHKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3429	.3429	.4287	.3734	.3734	.4287
2	.3734	.3429	.3429	.4287	.3734	.3734	.4287
3	.3734	.3429	.381	.5144	.4668	.4668	.5601
4	.8402	.5144	.0514	.6859	.6535	.7468	.6859
5	1.2136	.8573	.0995	.8573	.9709	1.1203	.8573
6	1.4003	1.2003	1.3375	1.0288	1.307	1.307	1.0288
7	1.6804	1.3717	1.3717	1.3717	1.587	1.587	1.2003
8		1.3336	1.0288				1.2003
9		.9526	.8573	1.1203			
10	1.2136	.7621	.6859	.8402	.9335	1.0269	.6859
11	.0686	.6859	.5144	.5601	.6535	.6859	.5144
12	.6859	.6859		.5601	.5601	.6001	.4287
13	.2286	.6859	.4287	.3734	.4668	.5144	.4287
14	.3048		.5144	.4668	.3734	.4287	.4287
15	.3048		.4287	.4668	.3734	.3429	.4287
16	.3048	.6859	.4287	.5601	.5601	.3429	.5144
17	.0857	.6859	.5144	.7468		.6859	.6859
18	1.0288	1.2003	1.0288	1.1203		1.0288	.8573
19	***	1.3717	1.2003	1.307	1.307	1.2003	1.4003
20	1.3717	1.2003	.8573	1.0269	1.1203	.8573	1.0288
21	.6859	.6859	.6859	.7468	.8402	.6859	.6859
22	4.3261	.3429	.5144	.4668	.5601	.5144	.6001
23	.0343	.3429	.5144	.3734	.4668	.4287	.5144
24	.3429	.0343		.5144	.3696	.3734	.4287
Max	13.7689	1.3717	1.3717	1.3717	1.587	1.587	1.4003
Min	.0343	.0343	.0514	.3734	.3696	.3429	.4287
Avg	1.4096	.7558	.6422	.7202	.7158	.7132	.6966

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 201 / TADHADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.5381	.4858	.3772	.5335	.5068	.3429
2	.3429	.5381	.4858	.3734	.6097	.5249	.3429
3	.3429	.615	.502	.3429	.6142	.543	.4287
4	.4287	.615	.502	.4287	.0763	.5611	.5144
5	.5144	.615	.5533	.5144	.7678	.5731	.6001
6	.6001	.691	.5868	.583	.7678	.591	.6344
7	.7888	.7687	.7042	.8402	.8477	.8775	.6859
8	.6859	.7687	.8383	.9602	.8688	.8745	.6859
9	.7316	.6919	.9221	.9945	.7985	.8745	.6859
15							.2303
16	.2306	.0686	.12		.0543	.1715	.2303
17	.3075	.112	.1543	.3277		.2401	.2303
18	.3075	.5228	.3429	.3048		.415	.2303
19	.3844	.567	.3772	.3071	.5487	.4527	.3071
20	.3844	.4854	.3772	.381	.567	.3772	.3839
21	.3844	.3921	.3772	.381		.3772	.3839
22	.4612	.3041	.3395	.381	.3511	.3772	.0424
23	.4612	.2957	.3395	.4607	.3511	.3772	.4607
24	.3429	.4595	.4534	.3772	.4607	.4887	.3772
Max	.7888	.7687	.9221	.9945	.8688	.8775	.6859
Min	.2306	.0686	.12	.3048	.0543	.1715	.0424
Avg	.4468	.5027	.4701	.4903	.5478	.5113	.4104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 202 / PANGERKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9225	.6859	.6859	.7678	.6413	.8488
2	.9431	.9225	.7202	.6859	.7678	.6722	.7716
3	.8573	.9225	.7202	.6859	.8383	.7023	.8573
4	.9431	.9994	.7373	.7716	.9145	.7842	.9431
5	1.0288	.9225		.8573	.9214	.8589	.8573
6	1.0288						
10	2.2405	1.6912	2.0348	1.7375	1.597	1.9719	1.6892
11	2.3216	2.4646	2.5911	1.8427	1.7604	2.2862	1.8442
12	2.46	2.6155	2.5911	2.3034	1.7604	2.2862	1.9809
13	2.6137		2.5911	2.5232	1.8107	2.3167	2.1498
14	2.6906	2.3537	2.5911	2.3034	1.7101	2.2862	2.073
15	2.7829	2.7846	2.5911		1.7604	2.2862	2.0037
16	1.4606	2.5652	2.572	2.2238	1.7772	1.829	2.073
17	1.5375	2.452	2.2805	2.3802		1.829	
18	.615	.9877	1.0288	.6097		.8871	.7678
19	.7687	1.1458	1.0288	.0678	1.0608	.924	.9214
20	.9225	1.0534	1.0288	.691	.8688	.8573	.9214
21	1.0762	1.0164	.8573	.7678	.7602	.9431	.9214
22	1.0762	.8402	.8688	.7678	.6584	.8488	.9214
23	1.23	.8048	.7545	.8446	.6653	.8488	.9214
24	.9431	.9225	.6859	.6859	.9145	.5914	.8488
Max	2.7829	2.7846	2.5911	2.5232	1.8107	2.3167	2.1498
Min	.615	.8048	.6859	.0678	.6584	.5914	.7678
Avg	1.4516	1.4941	1.5242	1.2334	1.1841	1.3325	1.2798

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 203 / RUI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.1425	.6802	.6001	.9145	.905	.5144
2	.8573	1.3717	.7042	.6001	1.2193	.9412	.5144
3	1.0288	1.382	.7202	.6859	1.3717	.9774	.6859
4	1.2003	1.382	.7701	.7716	1.448	1.0136	.4763
5	1.3717	1.6892	.8718	.8573	1.6004	1.0387	1.0288
6	1.5432	1.6892	.9724	.9431	1.6766	1.0745	1.286
7	1.5242	.1966	1.358	1.3717	1.829	1.6126	1.5432
8	1.6766	1.9987	1.7654	2.2634	2.0957	2.0576	2.0119
9	1.7985	2.073	2.0287	2.3663	1.7985	2.332	2.0576
16	.3075	.181	.2572	.3075		1.829	.2286
17	.3075	.2715	.2743	.3075		.2058	.215
18	.3844	.5914	.3429	.3071		.6413	.3839
19	.3849	.6697	.3429	.381	.543	.6979	.3839
20	.4612	.567	.543	.43	.5487	.5144	.3839
21	.615	.5175	.5658	.4268		.5144	.041
22		.3521	.5658	.4268	.4344	.5658	.3839
23	.615	.362	.5658	.4572	.3841	.5658	.4607
24	.8573	1.2254	.6478	.6001	.4572	.8596	.5144
Max	1.7985	2.073	2.0287	2.3663	2.0957	2.332	2.0576
Min	.3075	.1425	.2572	.3071	.3841	.2058	.041
Avg	.9289	.9257	.7765	.7835	1.1658	1.0193	.7285

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 201 / EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351		.048	.0438	.0385	.0621	.0492
2	.0351	.0351	.1074	.0175	.0351	.0789	
3	.0351	.0175	.0827	.0674	.0347	.0789	.0507
4	.0351	.0175	.035	.067	.0351	.0789	.0507
5	.0351			.0175	.0351	.0797	.0507
6	.0351	.0175	.0839	.0175	.0351	.0816	
7	.0351		.1003	.0175	.0351	.0892	.0613
8	.0351	.0351	.003	.0175	.0351	.0923	.0652
9	.0351	.0351	.0869	.0175	.0351	.0629	.0453
10	.0351	.0351	.0698	.0426	.0351	.1205	.0613
11	.0701	.0701	.0808	.1346	.0351	.1372	.0869
12	.0701	.0701	.0899	.1742	.0351	.1037	.1033
13	.0701	.0972	.0701	.1163	.0175	.13	.0983
14		.0693	.0701	.1227	.0655	.1269	.0629
15		.1132	.0701	.2046	.1696	.1646	.0823
16	.0701	.0838	.0526	.2088	.1753	.1178	
17		.0995	.0351	.1743	.0934	.1372	
18	.0701	.08	.0351	.0797	.0359	.1136	.0351
19		.1197	.0351	.0351	.0175	.0351	.0351
20	.0526	.0023		.0351	.0175	.0351	.0351
21		.0408	.0351	.0595		.0351	.0351
22		.0861	.0351	.0919	.0175	.0633	.0344
23		.1368	.0175	.0873	.0175	.0858	
24	.0351	.1044	.0351	.0682	.0351	.067	.0351
Max	.0701	.1368	.1074	.2088	.1753	.1646	.1033
Min	.0351	.0023	.003	.0175	.0175	.0351	.0344
Avg	.0464	.0651	.0581	.0799	.0472	.0907	.0567

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 203 / S.PIMPLEGON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2483						
2	1.2955						
3	1.2955						
4	1.3603						
5	1.4413						
6	1.5238						
7	1.5565						
8	1.6907						
9	1.6842						
10		1.6385	2.3758	2.1338	2.1285	2.5194	2.1403
11		2.0481	2.4387	2.5396	2.6379	2.6543	2.3434
12		2.4249	2.5149	2.6566	2.8675	2.7199	2.6246
13		2.4249	2.5453	2.5934	2.9007	2.6566	2.6092
14			2.5911	2.6408	2.6707		2.7199
15		2.5396	2.4387	2.7199	2.8012	2.6246	2.6886
16			2.609	2.6008	2.8344	2.769	2.5621
17		2.4577	2.5	2.356	2.8344	2.7035	2.5309
24	1.2163	2.4249					
Max	1.6907	2.5396	2.609	2.7199	2.9007	2.769	2.7199
Min	1.2163	1.6385	2.3758	2.1338	2.1285	2.5194	2.1403
Avg	1.4312	2.2798	2.5017	2.5301	2.7094	2.6639	2.5274



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 204 / GINING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0206			.0036	.1187	.004	.156
2	.0282	.1509	.0943	.0036	.1187	.004	.1726
3	.0297	.1509		.0036	.1227	.004	.1578
4	.0486	.1509	.1132	.0036	.124	.004	.1629
5	.0486			.0036	.1063	.004	.1402
6	.0505	.132	.1132	.0036	.008	.004	.1417
7	.0505		.1132	.0036	.008	.004	.004
8	.0505	.0034		.0036		.004	.0038
9	.0053	.0034	.0034	.0036	.0107	.0812	.0042
10	.005	.0034	.0034	.0036	.0107	.0486	.0069
11	.0034	.0034	.0034	.0034	.0055	.1017	.0072
12	.0034	.0034	.0034	.003	.0053	.0886	.0072
13	.0034	.0034	.0034	.0034	.0055	.0886	.004
14	.0034		.0034	.003	.005	.0914	.0076
15		.0034	.0034	.0032	.0055	.0701	.004
16	.0034		.0034	.0042	.0048	.0876	.0034
17	.0034	.0034	.0036	.0034	.0048	.086	.004
18	.0034		.0036	.0072	.0048	.0914	.0084
19		.0034	.0036	.008	.005	.0709	.0069
20	.1509		.0036	.1417	.0048	.12	.008
21			.0036	.1417	.0048	.1552	.0077
22			.0036	.1463	.004	.1772	.0072
23		.0943	.0036	.1267	.004	.181	.008
24	.0189	.1509	.0943		.1227	.0048	.1463
Max	.1509	.1509	.1132	.1463	.124	.181	.1726
Min	.0034	.0034	.0034	.003	.004	.004	.0034
Avg	.0280	.0574	.0290	.0274	.0354	.0657	.0492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 205 / PATHARWALA(GAOTHAN)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753			.1886	.1494	.1753	.1494
2	.1753	.1867	.1867	.1886	.168	.1753	.1494
3	.2126	.1867		.1886	.1867	.1753	.1867
4	.2534	.1867	.2241	.2641	.1867	.2353	.2241
5	.3292			.3018	.2218	.3077	.3174
6	.3921	.2987	.3734	.415	.3174	.3658	.3841
7	.4527		.5601	.5093	.3772	.4066	.4715
8	.4715	.5228		.4338	.4294	.4527	.3921
9	.4108	.5228	.4854	.3772	.2743	.3961	.3174
10	.4338	.3734	.2801	.3395	.2103	.2715	.2801
11	.2987	.2987	.2587	.1829	.2743		.2241
12	.2241	.1867	.1848	.168	.2195		.168
13			.1478	.1267	.1578	.1478	.0934
14	.0876		.1294	.128	.1372	.1307	.0934
15		.168	.1294	.1267	.12	.1307	
16	.2241		.1478	.1867	.2195	.1494	
17	.3547	.1867	.1886	.2195	.3326	.168	
18	.3547		.3584	.0187	.4527	.2801	.3206
19		.4854	.4854	.2715	.4715	.3547	.2801
20	.3174		.3206	.2801	.4715	.2801	.2801
21			.2641	.2241	.2743	.2241	.2241
22			.2241	.1867	.2103	.1867	.1867
23		.1867	.1886	.1886	.1753	.1867	
24	.1753	.1867	.1867	.1886	.168	.1753	.168
Max	.4715	.5228	.5601	.5093	.4715	.4527	.4715
Min	.0876	.168	.1294	.0187	.12	.1307	.0934
Avg	.2969	.2841	.2662	.2376	.2586	.2444	.2455

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 206 / MAHAKALA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3437	.3475	.301	.2462
2		.4915	.3932	.3437		.3353	.2824
3		.4915		.3749	.3906	.3858	.3041
4		.5441	.4481	.4062	.427	.3858	.3311
5				.4687	.4344	.4475	.362
6		.5761	.5121	.5468	.4687	.5312	.4344
7			.5601	.6249	.5042	.6093	.5624
8		.6401		.7499	.5647	.6718	.5401
9		.6401	.7042	.6859	.6642	.6562	.5761
10	.5281						
11	.8192						
12	.9175						
13	.9172						
14	.8855						
16	.7907						
17	.7274						
24		.4915	.3277	.3048	.382	.301	.2462
Max	.9175	.6401	.7042	.7499	.6642	.6718	.5761
Min	.5281	.4915	.3277	.3048	.3475	.301	.2462
Avg	.7979	.5536	.4909	.4850	.4648	.4625	.3885

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 208 / S- PIPALGAO GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401			.6535	.6516	.5853	.6984
2	.7133	.7095	.7095	.6535	.724	.6401	.6878
3	.8779	.7468		.0187	.7522	.695	.9412
4	1.0425	.7842	.8962	.7468	1.0317	.8962	1.1222
5	1.2752			1.1203	1.1462	1.2071	1.3213
6	1.6263	1.1203	1.307	1.4937	1.5023	1.39	1.701
7	1.8111		1.9791	1.9605	1.7556	1.701	2.0883
8	2.0165	1.9791		1.8671		2.1313	1.7556
9	2.1033	1.8671	1.7737	1.6617	1.5912	1.7541	1.5729
10	1.7193	1.4937	1.307		1.3213	1.2986	1.267
11	1.1576	.9335	.8402	.8869	.9694	.8145	
12	.7842	.6908	.7468	.695	.6401	.5853	
13			.7095	.5611	.6401	.5373	.5792
14			.6535	.6335			.6401
15		.5601	.6722	.7087	.6335	.5973	.5611
16	.8589		.6722	.823	.6584	.6767	.724
17	1.1203	.8962	.6859	1.0242	.9145	.9231	.8326
18	1.4937			1.4632	1.475	1.4842	
19		1.6804	1.7002	1.2932	1.587	1.5546	1.3169
20	1.2323		1.307	1.2071	1.643	1.3575	1.3032
21			1.0829	.9511	1.0059	1.3032	1.0974
22			.8215	.8507	.8413	1.2127	.9593
23		.7095	.7468	.7059	.6878	.924	.823
24	.6401	.7468	.6348	1.4003	.5959	.6036	.6219
Max	2.1033	1.9791	1.9791	1.9605	1.7556	2.1313	2.0883
Min	.6401	.5601	.6348	.0187	.5959	.5373	.5611
Avg	1.2419	1.0656	1.0129	1.0165	1.0349	1.0814	1.0769

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 201 / SUKHAPURI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.6335	.6535	.7468	.7392	.6535	.724
2	.8059	.724	.7468	.8402	.823	.6535	.8059
3	.8059	.724	.924	.924	.763	.7392	.8859
4	.9536	.8859	.924	1.0059	.8573	.7316	.964
5	.9431	1.0288	1.086	1.0974	.9945	1.0974	1.2003
6	1.0288	1.1869	1.1765	1.2803	.9831	1.4632	1.3413
7	1.3413	1.4746	1.6118	1.8004	1.5813		1.7814
8	1.9433	1.8623	2.1434	2.3148	2.1605	1.95	2.2672
9	2.1052	2.0243	2.1434	2.3148	2.3758	1.989	2.3482
10	.724	.6335	.7468	.5601	.7545		
11	.6335	.4668	.4668		.4763	.4668	
12	.362	.4668			.4715	.362	.362
13	.362	.4668	.3734	.381	.381	.362	.362
14	.362		.3734	.3772	.3734	.2715	.362
15	.362		.3734	.3772	.2801	.2715	.2715
16	.362		.3734	.381	.3734	.362	.362
17	.6335		.5601	.4715		.362	.6335
18	.543	.4668		.4668		.4525	.543
19	.724	.5601	.5601	.5935	.6535	.724	.6335
20	.543	.3734	.4668	.6535	.4668	.543	.4525
21	.362	.3734	.3734	.4715	.3734	.4525	.4525
22	.362	.3734	.3734	.462	.3734	.362	.362
23	.2715	.2801	.2801	.3772	.2801	.362	.362
24	.543		.6535	.6535	.6468	.5601	.6335
Max	2.1052	2.0243	2.1434	2.3148	2.3758	1.989	2.3482
Min	.2715	.2801	.2801	.3772	.2801	.2715	.2715
Avg	.7379	.7898	.7902	.8432	.7810	.6905	.8232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 202 / BELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.2715	.3734	.3734	.3734	.2801	.362
2	.4525	.2715	.3734	.4668	.3696	.2801	.362
3	.4525	.2715	.3734	.4668	.3772	.3734	.4525
4	.4525	.362	.4668	.4668	.4287	.7468	.4525
5	.4525	.362	.5601	.5601	.5601	.8402	.543
6	.6335	.362	.7468	.6535	.5935	.7468	.724
7	.6335	.362	.9335	.8402	.6935		.724
8	.6335	.362	.7468	.6535	.6935	.8402	.724
9	.6335	.4525	.7468	.5601	.6335		.6335
10	1.2003	1.2003	1.1145	1.1145	.9831	1.1145	1.286
11	1.6194	1.5432	1.5432	1.4918	1.3765	1.7147	1.5565
12	1.7814	1.5432	1.5432	1.7004		1.8623	1.6108
13	1.8623	1.8004	.924	1.6604	1.3927	1.7814	1.6194
14	1.9433	1.8004	.7716	1.7814	1.5432	1.7004	1.7004
15	1.9433	1.7147	1.7147	1.7394	1.286	1.2717	1.6194
16	1.7814	1.8004	1.5432	1.5813	1.5432	1.6194	1.7004
17	1.5927	1.6289	1.6289	1.5746		1.6108	1.6194
18	.543	.5601	.5601	.5544		.6335	.6335
19	.543	.8402	.7468	.5935	.5601	.724	.724
20	.543	.5601	.5601	.6401	.4668	.543	.6335
21	.4525	.5601	.4668	.3734	.4668	.543	.4525
22	.4525	.4668	.4668	.3772	.3734	.362	.4525
23	.4525	.3734	.2801	.3734	.2801	.362	.4525
24	.4525	.4525	.2801	.2801	.3772	.2801	.362
Max	1.9433	1.8004	1.7147	1.7814	1.5432	1.8623	1.7004
Min	.4525	.2715	.2801	.2801	.2801	.2801	.362
Avg	.9150	.8301	.8110	.8699	.7320	.9196	.8917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 203 / WADIKALYA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.4525	.3734	.5228	.3772	.4668	.362
2	.4525	.4525	.3734	.3734	.3734	.3734	.4525
3	.4525	.4525	.3734	.3734	.3696	.4668	.4525
4	.543	.4525	.3734	.4668	.4572	.5601	.4525
5	.543	.543	.5601	.4668	.543	.6535	.543
6	.724	.6335	.6535	.6535	.6135	.8402	.4525
7	.543	.362	.7468	.8402	.3734		.4525
8	.4525	.362	.2801	.3734	.3734	.4668	.4525
9	.2715	.362	.2801	.4668	.3658	.3734	.362
10	1.2003	1.5089	1.4575	1.3717	1.2431	1.286	1.1269
11	1.7004	1.7147	1.8004	1.7147	1.5565	1.7147	1.4918
12	1.8623	2.1434	1.9719	1.8404	1.7604	1.7004	1.6108
13	1.7814	2.1434	1.8861	1.6604	1.8404	1.7814	1.6194
14	1.7004	1.8004	1.9719	1.7966	1.8861	1.5565	1.7814
15	1.9433	2.0576	1.8861	1.6804	1.7147	1.6385	1.7814
16	1.9433	1.9719	1.9719	1.5432	1.7147	1.6194	1.5261
17	1.8623	1.7147	1.6289	1.5565		1.4575	1.6194
18	.543	.5601	.5601	.4668		.543	.543
19	.6335	.6535	.7468	.7545	.7468	.6335	.6335
20	.543	.6535	.5601	.7316	.5601	.543	.4525
21	.4525	.4668	.3734	.462	.4668	.4525	.362
22	.4525	.4668	.3734	.3734	.3734	.4525	.362
23	.362	.3734	.3734	.3696	.2801	.362	.362
24	.4525	.4525	.2801	.2801	.3772	.2801	.362
Max	1.9433	2.1434	1.9719	1.8404	1.8861	1.7814	1.7814
Min	.2715	.362	.2801	.2801	.2801	.2801	.362
Avg	.9111	.9481	.9107	.8808	.8349	.8792	.8173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 201 / HASNAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.2715	.0305	.3353	.3429	.6773	.1467
2	.0762	.3429	.3353	.381	.3841	.7164	.2667
3	.0762	.3572			.4934	.7316	.1886
4		.4115	.0381	.0381	.4793	.6859	.2096
5		.4268	.4572	.4572	.4793	.7164	.262
6		.4012	.6859		.4934	.7716	.3144
7		.4784		.6097	.5075	.7316	.3668
8		.5247	.7621	.0686	.7468	.0953	.503
9		.6636	.7621		.787	.7482	.4925
10	.5075						
11	.4572						.0572
12	.643						
13	.7011						
14	.7164						
15	.7133						
16	.6687				.0572		
17	.6081						
18	.0572	.061		.0572	.0762	.0572	.0572
19	.0762	.061	.061	.0762	.0762	.0953	
20	.0762	.061	.061	.0953	.0953		.0762
21	.0762	.0061	.0061	.0762	.0762	.0953	.0572
22	.0762	.061		.0953	.0762	.0953	.0572
23	.0572	.061	.0457	.0953	.0762	.0953	
24	.2029		.3048	.3048	.257	.0953	
Max	.7164	.6636	.7621	.6097	.787	.7716	.503
Min	.0572	.0061	.0061	.0381	.0572	.0572	.0572
Avg	.3259	.2793	.2958	.2069	.3238	.4272	.2182



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 202 / GHUNGARDE HADGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12						
2	.1734						
3	.2029						
4	.2267						
5	.2401						
6	.16						
7	.2435						
8	.257						
9	.1734						
10		.16		.2572	.2743	.2105	.1572
11		.3048	.3048	.3161	.3652	.2267	
12		.381	.3353	.381	.3841	.3887	.3039
13		.4572	.3353	.4365	.423	.4372	.5716
14		.4572		.5792	.3001	.4534	.1781
15		.4572	.0381	.3948	.3858	.4696	.2829
16		.4572	.381	.3384	.3517	.4696	.2934
17		.381		.3525	.3858	.4372	.2934
Max	.257	.4572	.381	.5792	.423	.4696	.5716
Min	.12	.16	.0381	.2572	.2743	.2105	.1572
Avg	.1997	.3820	.2789	.3820	.3588	.3866	.2972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 203 / GONDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2881	.0572	.0152	.0152	.0381		.0572
2	.3292	.0572		.0152	.0381		.0572
3	.4572		.0152		.0381		.0572
4	.4512						.0572
5	.4089						
6	.3334						
7	.3923						
8	.423					.0191	
9	.3467						
10		.3704	.381	.3384	.3155		.241
11		.381	.0457	.5401	.3652	.4858	.0381
12			.5335	.6327	.5075	.583	.3248
13		.061	.6097	.6944	.5573	.5506	.3353
14		.061	.6859	.5716	.4167	.5182	.3772
15		.6097	.6859	.6144	.5218	.4858	.3877
16			.6859	.5573	.5247	.5344	.3982
17	.0381	.6097		.5216	.571	.5182	.4087
18	.0381	.0152		.0381	.0381	.0191	.0191
19	.0381	.0152	.0152	.0381	.0381	.0191	.0381
20	.0381	.0152	.0152	.0381	.0572		.0381
21	.0381			.0381	.0572	.0572	.0381
22	.0381	.0152	.0152		.0572	.0572	.0381
23	.0572	.0152	.0015	.0572		.0572	
24		.0381	.0152	.0152	.0381		.0572
Max	.4572	.6097	.6859	.6944	.571	.583	.4087
Min	.0381	.0152	.0015	.0152	.0381	.0191	.0191
Avg	.2322	.1658	.2657	.2954	.2459	.3004	.1649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134054 / EKLAHARA

Feeder No / Name : 201 / KARANJALA

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
10	.0191	.1905	.2031
11	.1905	.2812	
12	.1905	.2688	
13	.2096	.2846	
14	.2286	.2372	
15	.2286	.2743	
16	.2286	.2846	
17	.2286	.2846	
18		.0419	
24	.0229	.0023	
Max	.2286	.2846	.2031
Min	.0191	.0023	.2031
Avg	.1719	.215	.2031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134054 / EKLAHARA

Feeder No / Name : 202 / BHARDI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
10	.2667	.2667	.4321
11	.0267	1.1702	
12	.0267	1.0279	
13	.0282	.8855	
14	.0286	1.1544	
15	.029	1.1702	
16	.0286	1.186	
17	.0286	.9804	
18		.1467	
24	1.3336	1.4289	.2324
<b>Max</b>	<b>1.3336</b>	<b>1.4289</b>	<b>.4321</b>
<b>Min</b>	<b>.0267</b>	<b>.1467</b>	<b>.2324</b>
<b>Avg</b>	<b>.1996</b>	<b>.9417</b>	<b>.3323</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134054 / EKLAHARA

Feeder No / Name : 203 / EKLAHARA AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0734	.0267	
2		.0267	
3	.0953	.0267	
4	.0762	.0305	
5	.0914	.0305	
6	.0953	.0343	
7		.0362	.4586
8	.1067	.362	
9	.0229	.3429	1.5023
24	.0724	1.1431	.4172
Max	.1067	1.1431	1.5023
Min	.0229	.0267	.4172
Avg	.0792	.2060	.7927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134054 / EKLAHARA

Feeder No / Name : 204 / EAKLAHARA GACTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0029	.0038	.0438
2	.0029	.0048	
3	.0038	.0057	.0362
4	.0042	.0067	.0438
5	.0553	.0076	.0657
6	.0072	.0084	.096
7	.0076	.0088	.1715
8	.08	.0171	.6802
9	.0762	.0171	.7116
10	.0781	.1981	.6009
11	.0067	.0762	
12	.6859	.0429	
13	.6668	.0333	
14	.6668	.0381	
15	.6668	.0263	
16	.6859	.0396	
17	.6668	.0495	
18		.2477	
19		.1867	
21	.0114	.0892	
22	.0095	.0892	
23	.0076	.0743	
24	.0069	.0057	.1829
Max	.6859	.2477	.7116
Min	.0029	.0038	.0362
Avg	.2095	.0555	.2633

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 201 / HARATHKHEDA AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.7621	.7621	.7621	.7621	.7621	.7621
2	.2858	.7621	.7621	.7621	.7621	.7621	.7621
3	.381	.7621	.7621	.7621	.8573	.8573	.7621
4	.4763	.9526	.7621	.7621	.8573	.8573	.7621
5	.4763	.9526	.9526	.8573	.9526	.9526	.7621
6	.6668	1.1431	1.1431	1.0479	1.0479	1.0479	1.0479
7	.9526	1.3336	1.4289		1.4289	1.3336	1.4289
8	.8573	1.7147	1.8099		1.4289	1.5242	1.6194
9	.7621	1.7147	1.8099		1.6194	1.6194	1.6194
10	.8573	.5716	.381		.1905	.5716	.5716
11	1.5242	.381	.2858	.381	.1905	.1905	.2858
12	1.6461	.2858	.1905	.2858	.1905	.1905	.1905
13	1.5242	.1905	.1905	.1905	.1905		.1905
14	1.5242	.1905	.1905	.1905	.0953		.1905
15	1.5242	.1905	.1905	.1905	.0953	.1905	.1905
16	1.4289	.1905	.1905	.1905	.0953	.1905	.1905
17	1.4289		.1905	.1905		.2858	.1905
18	.5716	.5716	.5716	.5716		.5716	.381
19	.7621	.5716	.7621	.6668	.7621	.5716	.7621
20	.5716	.5716	.4763	.6668	.7621	.381	.5716
21	.4763	.381	.381	.381	.4763	.381	.381
22	.2858	.381	.2858	.2858	.381	.381	.381
23	.2858	.381	.2858	.2858	.2858	.381	.2858
24	.2858	.7621	.7621	.5716	.381	.5716	.7621
Max	1.6461	1.7147	1.8099	1.0479	1.6194	1.6194	1.6194
Min	.2858	.1905	.1905	.1905	.0953	.1905	.1905
Avg	.8267	.6834	.6470	.5001	.6279	.6625	.6271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 202 / SHEVGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.2858	.381	.2858	.2858	.2858	.2858
2	.8573	.2858	.381	.2858	.2858	.2858	.2858
3	.9526	.2858	.381	.2858	.2858	.2858	.2858
4	1.0479	.2858	.381	.2858	.381	.2858	.2858
5	1.2384	.381	.381	.4763	.4763	.381	.2858
6	1.4289	.5716	.7621	.5716	.5716	.5716	.381
7	1.5242	.7621	.7621	.6668	.6668	.6668	.7621
8	2.0005	.7621	.7621	.7621	.7621	.6668	.7621
9	2.191	.5716	.7621	.5716	.5716	.7621	.7621
10	.5716	1.7147	2.0005	1.5242	1.4289	.9526	1.2384
11	.381	2.3815	2.191	2.2862	2.4768	2.191	1.9052
12	.2858	2.4768	2.4768	2.4768	2.4768	2.191	2.0957
13	.1905	2.4768	2.572	2.0957	2.191	2.191	2.0957
14	.1905	2.4768	2.6673	2.191	2.0005	2.2862	1.9052
15	.1905	2.2862	2.4768	1.9052	2.0005	2.191	1.9052
16	.2858	2.2862	2.3815	2.0957	2.0957	2.191	2.0005
17	.381		2.3815	2.191		2.0005	1.9052
18	.6668	.5716	.6668	.4763		.5716	.5716
19	.7621	.6668	.7621	.6668	.7621	.381	.7621
20	.4763	.6668	.4763	.4763	.7621	.381	.5716
21	.4763	.381	.381	.381	.4763	.381	.4763
22	.2858	.381	.2858	.381	.381	.2858	.381
23	.2858	.381	.3429	.381	.2858	.2858	.2858
24	.7621	.2858	.381	.2858	.2858	.2858	.2858
Max	2.191	2.4768	2.6673	2.4768	2.4768	2.2862	2.0957
Min	.1905	.2858	.2858	.2858	.2858	.2858	.2858
Avg	.7581	1.0272	1.1415	1.0002	.9959	.9566	.9367



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 203 / DHANGAR PIMPRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.7621	.7621	.7621	.7621	.6668	.7621
2	.2858	.7621	.7621	.7621	.8573	.7621	.7621
3	.2858	.7621	.7621	.7621	.9526	.7621	.7621
4	.381	.9526	.7621	.7621	1.0479	.7621	.7621
5	.4763	1.0479	1.1431	.8573	1.1431	.8573	.7621
6	.5716	1.1431	1.3336	1.0479	1.1431	.8573	.7621
7	.6668	1.3336	1.7147	1.1431	1.5242	1.1431	1.1431
8	.5716	1.7147	1.9052	1.5242	1.5242	1.5242	1.5242
9	.5716	1.7147	1.9052	1.7147	1.7147	1.5242	1.5242
10	1.2384	.1905	.2858	.381	.381	.381	.381
11	1.5242	.1905	.1905	.1905	.2858	.2858	.2858
12	1.7147	.1905	.1905	.1905	.1905	.1905	
13	1.7147	.1905	.1905		.1905	.1905	
14	1.9204	.1905	.1905	.1905	.1905	.1905	
15	1.9052	.1905	.1905	.1905	.1905	.1905	.1905
16	1.7147	.1905	.1905	.1905	.1905	.1905	.1905
17	1.8099		.1905	.2858		.1905	.2858
18	.381	.381	.381	.381		.381	.381
19	.4763	.4763	.4763	.4763	.4763	.381	.5716
20	.381	.4763	.4763	.381	.4763	.381	.4763
21	.381	.381	.381	.2858	.381	.381	.2858
22	.2858	.381	.2858	.2858	.381	.381	.2858
23	.2858	.381	.2858	.2858	.2858	.381	.2858
24	.2858	.7621	.7621	.5716	.5716	.5716	.6668
Max	1.9204	1.7147	1.9052	1.7147	1.7147	1.5242	1.5242
Min	.2858	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.8381	.6420	.6549	.5923	.6755	.5636	.6215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 204 / DATA AGRO EXPRESS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	18-JAN-17
HR	Load (MW)
12	.1905
Max	.1905
Min	.1905
Avg	.1905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 202 / 11 KV KARJAT-A

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4763	.6859	.4763	.3479	.6668
2		.4763	.6859	.5716	.3353	.6668
3		.5335	.6859	.6097	.3201	.7621
4		.5335	.6001	.6668	.3201	.8383
5		.5716	.5144	.7621	.3437	.8573
6		.6097	.5144	.9717	.381	.9526
7		.6668	1.0288	1.105	.6097	.9907
8		.724	1.0288	1.1812	.9755	1.0479
9		.8573	1.1431	1.2384	.884	.9907
10	.6325					
11	.8002					
12	.9717					
13	1.086					
14	1.1812					
15	1.105					
16	1.0479					
17	1.105					
24		.4763	.4287	.4763	.3906	
Max	1.1812	.8573	1.1431	1.2384	.9755	1.0479
Min	.6325	.4763	.4287	.4763	.3201	.6668
Avg	.9912	.5925	.7316	.8059	.4908	.8637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 203 / 11 KV DHANGAR PIMPALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.5716		.6859	.6668	.3953	.6668
2	.2858	.6097		.6001	.724	.3479	.6668
3	.2858	.6097		.6001	.7621	.3048	.7621
4	.2858	.6668		.6859	.8002	.3048	.7621
5	.3429	.7621		.6859	.8573	.3906	.9526
6	.4763	.8002		.6001	1.105	.4572	1.0479
7	.6668	.9145		1.0288	1.1812	.6401	1.1431
8	.6668	1.1812		1.2003	1.3336	1.2803	1.2003
9	.5716	1.2955		1.3336	1.4289	1.2346	.1905
10	.703	.3429		.381	.4763	.1905	.1905
11	1.0288	.4191		.2429	.3048	.1905	
12	1.2193	.381		.1619	.3048	.1905	.1905
13	1.2384	.381	.1715	.1296		.1524	.1905
14	1.105		.1715	.1296	.1905	.1334	.2286
15	1.1812		.1715	.1296	.1905	.1334	.2286
16	1.1812		.1715	.1296	.2286	.1524	.1905
17	1.1431	.2286	.1715	.2429		.2286	.1905
18	.381	.3048	.4287	.3125		.2858	.381
19	.4049	.4382	.5144	.4858	.4572	.4763	.4954
20	.4049	.381	.5144	.5182	.4954	.381	.4763
21	.3239	.3239	.6001	.5668	.4763	.3429	.4191
22	.2915		.5144	.4534	.3429	.2477	.3048
23	.2429		.5144	.2429	.3048		.2667
24	.2858	.5716	.5716	.6859	.6668	.3906	.1905
Max	1.2384	1.2955	.6001	1.3336	1.4289	1.2803	1.2003
Min	.2429	.2286	.1715	.1296	.1905	.1334	.1905
Avg	.6251	.5886	.3763	.5097	.6332	.3849	.4929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 201 / 11KV BOLEGAON FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5716	1.1431	1.2003	1.2003	1.5242	1.5242
2	.6859	.8573	1.3336	1.2003	1.2003	1.5242	1.5242
3	.6859	.8573	1.5242	1.2003	1.2003	1.5242	1.9052
4	.6859	.8573	1.5242	1.3717	1.2003	1.9052	1.9052
5	.8573	1.0288	2.2862	1.3717	1.3717	1.9052	1.9052
6	.8573	1.2003	2.2862	1.5432	1.5432	2.0957	2.0957
7	.8573	1.3717	2.2862	2.2291	2.0576	2.0957	2.2862
8	.8573	1.8861	2.4768	2.2291	2.2291	2.4768	2.6673
9		2.0576	2.4768	2.2291	2.2291	2.6673	2.8578
10		.6859	.5716	.5716	.7621	.7621	.5716
11		.381	.381	.381	.7621	.381	
12	1.0288	.1905	.2858	.2858	.5716	.381	
13	2.4006	.1905	.2858	.2858	.5716	.381	.3429
14	2.4006	.1905	.2858	.2858	.381	.381	
15	2.0576	.2858	.2858	.2858	.381	.381	
16	2.0576	.2858	.2858	.2858	.381	.381	
17	2.0576	.381	.4763	.4763	.381	.4763	.3429
18	.8573	.7621	.9526	.7621	.7621	.7621	.8573
19	1.0288	.9526	1.1431	1.1431	.5716	1.1431	1.0288
20	1.0288	1.1431	1.0479	.8573	.7621	.8573	.8573
21	.8573	.9526	.7621	.7621	.5716	.7621	.6859
22	.8573	.7621	.7621	.7621	.5716	.7621	.6859
23	.6859	.5716	.7621	.6668	.5716	.7621	.6859
24	.6859	1.0288	1.2384	1.1145	1.3336		1.1431
Max	2.4006	2.0576	2.4768	2.2291	2.2291	2.6673	2.8578
Min	.6859	.1905	.2858	.2858	.381	.381	.3429
Avg	1.1513	.8105	1.1193	.9792	.9820	1.1431	1.3617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 202 / 11KV MCHINCHOLI FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6859	.5716	.5716	.5716	.5716	.5716
2	.5144	.6859	.5716	.5716	.5716	.5716	.5716
3	.5144	.6859	.7621	.5716	.5716	.5716	.7621
4	.6859	.8573	.7621	.5716	.5716	1.1431	.7621
5	.6859	1.0288	1.1431	.7621	.7621	1.1431	.9526
6	1.0288	1.3717	1.2384	.8573	1.0479	1.3336	.9526
7	1.2003	1.2003	1.1431	1.1431	1.1431	1.1431	.9526
8	1.5432	1.2003		1.1431	1.1431	1.1431	.7621
9			1.1431	.9526	.9526	.5716	
10		2.0576	2.2291	2.0576	1.8861	2.2862	2.0957
11		2.4006	2.6578	2.4006	2.4768	2.572	2.4006
12	.3429	2.7435	2.915	2.6578		2.7435	2.572
13	.3429	2.915	2.8292	2.915	2.4768	2.7435	2.572
14	.3429	2.915	3.0007	2.7435	2.8578	2.572	2.572
15	.5144	2.915	2.8292	2.7435	2.8578	2.4006	2.572
16	.5144	2.915	2.7435	2.572	3.0483	2.4006	2.572
17	.8573	2.7435	2.7435	2.572	2.8578	2.4006	1.2003
18	1.0288	.9526	1.0479	1.0479	1.1431	.7621	.8573
19	1.2003	1.2384	1.1431	1.1431	1.1431	1.1431	.8573
20	1.2003	1.1431	.9526	1.1431	1.1431	1.0479	1.0288
21	1.0288	.9526	.8573	.8573	1.1431	.8573	1.0288
22	.8573	.9526	.7621	.7621	.9526	.7621	1.0288
23	.6859	.7621	.6668	.6668	.7621	.7621	.8573
24	.6859	.6859	2.8292	.5716	.5716		.5716
Max	1.5432	2.915	3.0007	2.915	3.0483	2.7435	2.572
Min	.3429	.6859	.5716	.5716	.5716	.5716	.5716
Avg	.7757	1.5656	1.6323	1.4166	1.4198	1.4629	1.3510

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 203 / 11KV GHANSAWANGI FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.8573	1.1431	.6859	.8573	1.5242	1.5242
2	.5144	.8573	1.5242	.6859	.8573	1.7147	1.5242
3	.6859	.8573	1.5242	.6859	.8573	1.7147	1.9052
4	.6859	.8573	1.9052	.8573	1.5432	1.9052	1.9052
5	.8573	1.0288	1.9052	.9431	1.5432	1.9052	2.2862
6	1.3717	1.0288	2.0957	1.0288	1.7147	2.0957	2.4768
7	1.3717	1.5432	2.8578	2.4006	1.8861	2.2862	2.8578
8	1.3717	2.0576	2.572	2.572	2.572	3.0483	2.8578
9	1.2003	2.2291	2.572	2.4006	2.6578	3.2388	2.572
10	1.7147	1.2003	.9526	.9526	.9526	.7621	.9526
11	1.7147	1.1431	.8573	.7621		.9526	1.0288
12	2.4006	.9526	.7621	.7621		.6859	1.0288
13	2.4006	.9526	.7621	.7621	.5716	.7621	.8573
14	2.4006	.7621	.6668	.6668	1.1431	.7621	.8573
15	2.4006	.6668	.5716	.5716	.9526	.9526	.8573
16	2.0576	.7621	.6668	.5716	.9526		.8573
17	2.2291	.9526	.7621	.7621	.9526	.9526	1.0288
18	1.2003	1.1431	.9526	.9526	1.1431	.9526	.12
19	1.2003	1.2384	1.1431	1.1431	1.1431	1.1431	1.2003
20	1.2003	1.1431	.9526	1.0479	1.1431	1.1431	1.2003
21	1.0288	.9526	.7621	.9526	1.1431	.9526	1.0288
22	1.0288	.9526	.7621	.7621	.9526	.9526	1.0288
23	1.0288	.7621	.5716	.5716	.9526	.9526	.8573
24	.6859	.8573	.9526	.6859	1.1431		1.3336
Max	2.4006	2.2291	2.8578	2.572	2.6578	3.2388	2.8578
Min	.5144	.6668	.5716	.5716	.5716	.6859	.12
Avg	1.3860	1.0733	1.2582	1.0078	1.2561	1.4254	1.4228

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 204 / 11KV TANUWADI FDR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.3429	.381	.381	.1905	.5716	.381
2	.8573	.3429	.381	.1905	.1905	.5716	.381
3	.8573	.3429	.381	.1905	.1905	.5716	.381
4	.8573	.3429	.381	.1905	.1905	.5716	.5716
5	1.0288	.5144	.5716	.1905	.1905	.5716	.5716
6	1.0288	.5144	.5716	.381	.381	.5716	.5716
7	1.3717	.5144	.5716	.5716	.5716	.7621	.5716
8	1.3717	.5144	.381	.5716		.5716	
9	1.3717	.3429		.381	.381	.5716	.1524
10	.5144	1.3717	1.7147	1.5432	1.2003	1.5242	1.5242
11	.3429	2.0957	2.0576	2.0576	1.7147	2.0957	1.7147
12	.3429	1.9052	2.2291	2.4006	1.5242	2.4768	1.8861
13	.3429	2.0957	2.4006	2.4006	1.7147	2.6673	1.8861
14	.3429	2.2862		2.4006	1.7147	2.4768	1.8861
15	.3429	2.2862	2.2291	2.4006	1.7147	2.6673	2.0576
16	.3429	2.2862	2.0576	2.2291	1.9052	.9526	2.0576
17	.5144	2.0957	2.0576	2.2291	1.9052	2.2862	2.0576
18	.5144	.5716	.5716	.5716	.5716	.5716	.5144
19	.5144	.5716	.5716	.381	.5716	.7621	.6859
20	.5144	.5716	.5716	.381	.5716	.5716	.3429
21	.3429	.381	.381	.381	.5716	.5716	.3429
22	.3429	.381	.381	.381	.5716	.5716	.3429
23	.3429	.381	.381	.381	.5716	.5716	.3429
24	.8573	.3429	.381	.381	.5716		.5716
Max	1.3717	2.2862	2.4006	2.4006	1.9052	2.6673	2.0576
Min	.3429	.3429	.381	.1905	.1905	.5716	.1524
Avg	.6716	.9748	.9820	.9820	.8557	1.1349	.9476



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 201 / 11KV R.U.GAON-AG FDR SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.307					
2	1.1145	1.307					
3	1.5432	1.4003					
4	1.8861	1.4784					.6535
5	1.9719	1.4784					
6	1.8861	1.7556					
7	1.9719	1.848					
8		1.848					
9	2.0576	1.9774					
10				2.5873			2.3101
11			1.2752	2.9864		1.9605	2.5873
12		2.8292	2.2546	3.0769	2.572	2.1807	2.9264
13			2.4949	3.0769		2.2916	2.9264
14			2.6326	3.0769	2.572	2.2731	2.8349
15			2.7351	3.1674	2.572		.2401
16			2.809	3.0769		2.2731	2.8959
17			2.95			2.5206	2.7873
18		1.8861					
20					.6001		
21					.6001		
22					.3429		
23					.3429		
24	1.1831		.3429			.3772	2.3899
Max	2.0576	2.8292	2.95	3.1674	2.572	2.5206	2.9264
Min	1.1145	1.307	.3429	2.5873	.3429	.3772	.2401
Avg	1.6461	1.7378	2.1868	3.0070	1.3717	1.9824	2.2552

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 202 / 11KV PANEWADI-AG FDR  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6535		.5144	.6535
2			.6908		.6001	.6722
3			.6653		.6001	.6535
4			.7655		.8573	.6535
5			.7023		.8573	.7468
6			.7392		.8573	.8402
7			.8145		.8573	
8			.9709		.9431	1.0719
9					.9431	1.1088
10	.7468				.9431	
11	1.0164					
12	1.1088					
13	1.1458					
14	1.1203					
15	1.0456					
16	1.0269					
23				.5144		
24		.6001	.6335		.3772	
Max	1.1458	.6001	.9709	.5144	.9431	1.1088
Min	.7468	.6001	.6335	.5144	.3772	.6535
Avg	1.0301	.6001	.7373	.5144	.7591	.8001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 203 / 11KVTALEGOAN-AG FDR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2136					
2		1.307					
3		1.307					
4		1.4003					
5		1.5708					
6		1.6632					
7		1.6632					
8		1.9404					
9		2.0328					1.6632
10				1.9204	2.0576	1.8111	1.885
11			2.3655	2.5606		2.1068	1.8656
12		2.4006	2.2262		2.572	2.2592	2.0119
13			2.0883	2.652	2.1434	2.4646	2.1582
14			2.384	2.6244	2.1434	2.0748	2.1033
15			2.7073	2.7435	1.8004	2.1253	2.0553
16			3.0807	2.7435		2.2443	2.2862
17			3.1047			2.4394	2.3777
23					.4287		
24	1.1145		.3429				
Max	1.1145	2.4006	3.1047	2.7435	2.572	2.4646	2.3777
Min	1.1145	1.2136	.3429	1.9204	.4287	1.8111	1.6632
Avg	1.1145	1.6499	2.2875	2.5407	1.8576	2.1907	2.0452

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 204 / 11KV SHINDEWADGAON-AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2012		.6859	1.386
2			1.2308	1.1317	1.0479	1.4415
3			1.307	1.2346	.9431	1.423
4			1.3491		1.1145	1.5154
5			1.3443	1.286	1.1145	1.6448
6			1.4045	1.3717	1.1145	1.6461
7			1.4003	1.4575	1.3717	1.6461
8			1.4969	1.6289	1.286	1.6827
9			1.587	1.5432	1.3717	1.7375
10	1.848				1.3717	
11	1.9404					
12	2.1033					
13	2.1948					
14	2.1253					
15	1.848				.2614	
16	1.9404					
17	1.848				.4344	
18					.4801	
23				.9431		
24	.3429	.6859	1.1145	1.0288	.9431	
Max	2.1948	.6859	1.587	1.6289	1.3717	1.7375
Min	.3429	.6859	1.1145	.9431	.2614	1.386
Avg	1.7990	.6859	1.3436	1.2917	.9672	1.5692

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 205 / RUGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.4294		.4887	.5144	.5144	.3734
2		.4668		.4207		.4287	.3734
3		.5601		.5121	.6001	.5144	.5228
4		.7095		.5359	.6173	.6687	
5		.7842		.5975	.7716	.6859	.7468
9		.6535		.3641	.6001	.5144	.5975
10	.6722			.5975	.6001		.5601
11	.5601		.3761	.4854	.6001	.4696	.3734
15	.3734			.3734		.4239	.3734
16	.4854		.4334	.4481		.543	.4294
17	.6535		.4784			.5434	.5601
18	.7095	.6859	.5028			.5611	.6722
19	.7468		.5375			.5121	
20			.4908			.4887	
21			.5083			.5548	
22			.4706			.4801	
23			.4207		.2572		
24	.6001		.3641	.4525	.3772	.5144	
Max	.7468	.7842	.5375	.5975	.7716	.6859	.7468
Min	.3734	.4294	.3641	.3641	.2572	.4239	.3734
Avg	.6001	.6128	.4583	.4796	.5487	.5261	.5075

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 206 / SHINDEWADGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668		.4163		.5487	.4854
2		.4668		.4344	.5144	.5144	.5228
3		.5601		.4887	.5144	.6001	.5228
4		.6535		.5544	.6001	.6001	.5601
5		.7095		.5792	.6859	.6859	
9		.5975		.4344	.4801	.5487	.5601
10	.5544			.3734	.5144	.3077	.4668
11	.3734		.3258	.3361	.6001	.4344	.3361
15	.2987		.208	.2801	.5144		.2614
16			.4908	.3921			.3361
17	.4108		.3681				.4668
18	.5788	.4287	.3982				.5788
19	.6908		.5068		.6001		
20			.543		.6001		
21			.5611		.6001		
22			.5068		.6001		
23			.4733		.2572		
24	.6001		.6001	.4049	.4287	.6001	
Max	.6908	.7095	.6001	.5792	.6859	.6859	.5788
Min	.2987	.4287	.208	.2801	.2572	.3077	.2614
Avg	.501	.5547	.4529	.4267	.5364	.5378	.4634

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 207 / TALEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3734		.2915	.3086	.0343	.2801
2		.3734		.2896	.3086		.2614
3		.4481		.3045	.3429		.3361
4		.5228		.3641	.4801		.4668
5		.4572		.3429	.5144	.4973	.4854
7				.2715			
8				.3077			
9		.4668		.3258	.3429	.4973	.4294
10	.3734			.2801	.4287	.1806	.3395
11	.3361			.2241		.2172	.2452
12		.2858					
15	.1867		.1656	.1867	.3429	.1806	.1867
16	.2614		.2454			.2279	.2614
17	.3361		.3077			.2801	.2987
18	.4108		.3439			.3258	.3921
19	.4854		.3761		.3429	.3439	
20			.298			.3561	
21			.2896		.3772	.3292	
22			.298		.3772	.2686	
23			.2629		.3772	.2715	
24	.4287		.4287	.2947	.2572	.4287	
Max	.4854	.5228	.4287	.3641	.5144	.4973	.4854
Min	.1867	.2858	.1656	.1867	.2572	.0343	.1867
Avg	.3523	.4182	.3016	.2903	.3693	.2959	.3319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 208 / PANEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373		.0486		.0343	
2		.0373		.052		.0343	
3		.0373		.0486		.0343	
4		.0373		.0693		.0343	
5		.056		.0678			
9		.0373		.0543		.0343	
10	.056			.056		.0543	.0373
11	.056		.0486	.056		.0543	.0373
14	.056						
15	.056		.0543	.0373		.0543	.0373
16	.0373		.0543	.0377		.0543	.0377
17	.0373		.0701			.0543	.0377
18	.0373	.0857	.0678			.0543	.056
19	.056		.0876			.0724	
20			.0486			.0537	
21			.0492				
22			.0514				
23			.0347		.0343	.0019	
24	.0514		.0514	.0486		.0343	
Max	.056	.0857	.0876	.0693	.0343	.0724	.056
Min	.0373	.0373	.0347	.0373	.0343	.0019	.0373
Avg	.0493	.0469	.0562	.0524	.0343	.0440	.0406



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 209 / 11KV EXPRESS FEEDER UTTARA NON SHEDDABLE EXPRESS HV FEEDERS  
 FOO Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373		.0362	.0343	.0343	.0373
2		.0377		.0324	.0343	.0343	.0373
3		.0373		.0347	.0381	.0343	.0373
4		.0373		.0328	.0343	.0343	.0373
5		.0373		.0362	.0343	.0381	.0373
6		.0373		.0343	.0343		.0373
7		.0373		.0358	.0343		.0373
8		.0373		.0351	.0343	.0343	
9		.0377		.0351	.0343	.0343	.0373
10	.0373			.0373			
11	.0373		.0358	.0373			.0373
12	.0373		.037	.056			.0373
13	.0373		.0362	.0377			.0373
14	.0373		.0358	.0373			.0373
15	.0373		.0351	.0373			.0373
16	.0373		.0362	.0373			.0373
17	.0373		.0362				.0373
18	.0373		.0301				.0373
19	.0373		.0526				
20			.0339				
21			.0362				
22			.0362				
23			.0362				
24	.0514	.0343	.0362	.0324	.0343	.0343	
Max	.0514	.0377	.0526	.056	.0381	.0381	.0373
Min	.0373	.0343	.0301	.0324	.0343	.0343	.0373
Avg	.0386	.0371	.0367	.0368	.0347	.0348	.0373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 201 / 11KV RAJA TAKALI-AG FDR SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6668	.6097		.6001	.7621	.6097
2		.6668	.6097	.7716	.6173	.9526	.6097
3		.6668	.6097	.8573	.6859	1.1431	.6097
4		.6668	.6097	1.0288	.7888	1.1431	.6097
5		.7621	.7621	1.0288	.8745	1.3336	.6097
6		.7621	.9145	1.2003	.9774	1.3336	.6097
7		.7621	.9907	1.2003	1.0631	1.5242	.9907
8		.8573	.8669	1.286	1.1317	1.6194	1.1336
9		.8573	.9335	1.3546	1.166	1.5242	1.0002
10	1.286						
11	1.6194						
12	1.7147						
13	1.7147						
14	1.7147						
15	1.8099						
16	1.7147						
17	1.5242						
24		.5716	.5335		.5658	.5716	.6097
Max	1.8099	.8573	.9907	1.3546	1.166	1.6194	1.1336
Min	1.286	.5716	.5335	.7716	.5658	.5716	.6097
Avg	1.6373	.7240	.744	1.0910	.8471	1.1908	.7392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 202 / JAMB-AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173						
2	.6687						
3	.7716						
4	.9602						
5	1.0974						
6	1.2003						
7	1.3032						
8	1.7833						
9	1.749						
10		1.1336	1.3717	1.0288	.9945	1.0669	1.2003
11		1.5337	1.3717	1.5089	1.5242	1.467	1.5432
12		1.9338	2.6578	1.7318	2.0957	1.7337	1.7318
13		.1867	2.572	1.8861	2.2862	1.6004	1.7318
14		1.6671	2.6578	1.7318	2.2862	1.5337	1.7147
15		1.3336	2.4006	1.6461	2.191	1.3336	1.7147
16		1.5337	2.2291	1.7833	2.0957	1.4003	1.7337
17		1.5337		1.5432	1.7147	1.3336	1.4575
24	.5316					1.5337	
Max	1.7833	1.9338	2.6578	1.8861	2.2862	1.7337	1.7337
Min	.5316	.1867	1.3717	1.0288	.9945	1.0669	1.2003
Avg	1.0683	1.3570	2.1801	1.6075	1.8985	1.4448	1.6035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 203 / 11KV MURTI-AG FDR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.4572	.5144	.583	.7621	.381
2		.5716		.5144	.6001	.9526	.381
3		.7621	.4572	.5487	.6859	1.1431	.381
4		.7621	.0457	.6001	.7545	1.1431	.381
5		.8573	.5335	.6001	.8573	1.2384	.381
6		.8573	.6668	.6859	.9774	1.3336	.4572
7		.8573	.8002	.7716	1.0974	1.3336	.8383
8		.9526	.8669	1.0288	1.2517	1.4289	1.0002
9		1.1431	.8669	1.1145	1.166	1.1431	.8669
10	1.0288						
11	1.5242						
12	1.6194						
13	1.6194						
14	1.5242						
15	1.467						
16	1.4289						
17	1.3336						
24		.5716	.381	.5144	.583	.9526	.381
Max	1.6194	1.1431	.8669	1.1145	1.2517	1.4289	1.0002
Min	1.0288	.5716	.0457	.5144	.583	.7621	.381
Avg	1.4432	.7907	.5639	.6893	.8556	1.1431	.5449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 204 / KPGAON -AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572						
2	.2572						
3	.2915						
4	.3258						
5	.3429						
6	.4115						
7	.4287						
8	.6859						
9	.703						
10		.6097	.5144	.5144	.5144	.5335	.5144
11		.7335	.5144	.703	.9526	.7716	.6001
12		.8002	1.0288	.7716	.9526	.7621	.6001
13		.8669	1.1145	.8059		.7621	.823
14		.8002	1.1145	.7888	.9526	.6668	.9526
15		.8002	1.0288	.8573		.6668	.8573
16		.8002	.9431	.8402	.9526	.6001	.823
17		.6001	1.0288	.7545	.6668	.5335	.8573
24	.2572						
Max	.703	.8669	1.1145	.8573	.9526	.7716	.9526
Min	.2572	.6001	.5144	.5144	.5144	.5335	.5144
Avg	.3961	.7514	.9109	.7545	.8319	.6621	.7535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 206 / RAJATAKLI- GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.6859	.2572	.4287	.5144	.5144	.2572
2	.4287	.743	.2572	.4287	.6001	.5716	.2572
3	.4801	.7621	.2572	.4287	.6859	.6668	.2572
4	.5487	.8002	.4287	.6001	.703	.8002	.3429
5	.8059	.8573	.6859	.6001	.7716	.7621	
6		.8764	.7716	.6859	.823	.7049	.6859
7	.7716	.8954	.7716	.6001	.7545	.7049	.7621
8	.703	.8002	.6859		.7888	.724	.6859
9	.6344	.7621	.6859	.6001	.6859	.6097	.6859
10	.6859			.5144		.5144	.5144
11	.6859		.5144	.3601		.3429	.3429
12	.5144				.4191	.2572	.3429
13	.4763			.2572	.381	.1715	.2058
14				.2058	.381	.1715	.1715
15	.2858		.5144	.2572	.362	.1715	.2572
16	.3239		.5144	.2572	.3429	.2572	.2915
17	.5525	.4287	.6001	.3601	.4572	.2572	.3429
18		.6001	.6001	.6173	.5525	.6001	.4287
19	.6859	.6859	.6859	.5487	.6859	.6859	.5144
20		.5144	.5144	.583	.724	.6001	.6173
21	.5716	.4287	.4287	.4287	.7049	.5144	.5144
22	.5335	.3429	.3086	.3772		.4287	.5144
23		.2572	.3086	.3258	.5716	.3429	.4287
24	.3086	.5716	.2572	.3086	.3086	.5335	.2572
Max	.8059	.8954	.7716	.6859	.823	.8002	.7621
Min	.2858	.2572	.2572	.2058	.3086	.1715	.1715
Avg	.5451	.6478	.5024	.4443	.5818	.4962	.4208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 207 / 11KV JAMB- GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.4954	.3429	.3429	.4973	.381	.3429
2	.4287	.5335	.3429	.3429	.5144	.5716	.3429
3	.463	.5716	.3429	.3429	.583	.6097	.3429
4	.463	.6097	.4287	.4287	.6859	.6859	.3429
5	.5144	.6097	.5144	.5144	.6859	.7049	.4287
6	.6001	.5716	.5144	.6001	.6173	.724	.6001
7	.5144	.5144	.5144	.6859	.6001	.7049	.6001
8	.4458	.4572	.5144		.4115	.6478	.5144
9	.4115	.4191	.5144	.6001	.4801	.5716	.6859
10	.4801	.4287	.4287	.5144	.4287	.463	.5144
11	.4954	.4287	.4287	.4973	.4191	.4287	.4287
12	.4763			.3601	.381	.3429	.3429
13	.4572			.2915	.3429	.3429	.2743
14			.5144	.2743	.3239	.3429	.3429
15	.4191	.3429	.5144	.3086	.3239	.2572	.3429
16	.4191	.3429	.5144	.3772	.3048	.4287	.3944
17	.6287	.6001	.6001	.4287	.4191	.3429	.4287
18		.6001	.5144	.6516	.4954	.6001	.4287
19	.6478	.5144	.6001	.6687	.5716	.5144	.4287
20		.5144	.5144	.463	.5144	.4287	.4973
21	.5716	.4287	.4287	.4115	.4572	.3429	.4287
22	.4954	.3429	.3086	.3944		.3429	.4287
23		.3429	.3086	.3772	.381	.3429	.4287
24	.0257	.4763	.3429	.3429	.3086	.4287	.3429
Max	.6478	.6097	.6001	.6859	.6859	.724	.6859
Min	.0257	.3429	.3086	.2743	.3048	.2572	.2743
Avg	.4642	.4831	.4567	.4443	.4673	.4813	.4272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 208 / 11KV MURTY-GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.7049	.3429	.4287	.4801	.5716	.3429
2	.5144	.8002	.3429	.4287	.6173		.381
3	.6516	.8954	.3429	.5144	.6859		.3429
4	.7716	.9526	.5144	.5144	.7202		.5144
5	.823	.9526	.7716	.6001	.8059		.7716
6	.9431	.8573	.0943	.7716	.9431		.8573
7	.9431	.8002	.9431	.7716	.8745	.6478	.9431
8	.9259	.7621	.8573		.8745	.743	.9431
9	.7202	.7621	.7716	.6859	.823	.6097	.7716
10	.6687		.6859	.6001	.5658	.4801	.6001
11	.6478	.3429	.6001	.4115	.5716		.3772
12	.6097	.3429		.3086	.3429		.3429
13	.5716			.2743	.3239		.2401
14				.2401	.3239		.2572
15	.381	.2572	.5144		.3429	.2572	.381
16	.4191	.3429	.5144	.3258	.3429	.3429	.3601
17	.4954	.4287	.6001	.4287	.4954	.4287	.4287
18		.6001	.6001	.6687	.5906	.6859	.4287
19	.7049	.7716	.7716			.7716	.5144
20		.5144	.5144	.583	.6859	.6859	.5658
21	.5716	.0429	.4287		.6478	.6001	.5144
22	.5716	.3429	.3429	.3601		.5144	.5144
23		.3429	.3429	.3429	.5716	.3429	.5144
24	.2915	.5716	.3429	.3429	.3258	.5525	.3429
Max	.9431	.9526	.9431	.7716	.9431	.7716	.9431
Min	.2915	.0429	.0943	.2401	.3239	.2572	.2401
Avg	.6319	.5899	.5352	.4801	.5889	.5490	.5104



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON

Feeder No / Name : 209 / 11KV SINDHKHED-GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.381	.2572	.3429	.3086		.2572
2	.3772	.4191	.2572	.3429	.3258	.5144	.2572
3	.4458	.4572	.2572	.3086	.3772	.5335	.2572
4	.5144	.5335	.3429	.5144	.463	.5716	.3429
5	.583	.5335	.5144	.6001	.5144	.5906	.5144
6	.6344	.4954	.6001	.6001	.9945	.5716	.6001
7	.6516	.4572	.5144	.4287	.6173	.5525	.5144
8	.5658	.4191	.5144		.5316	.5525	.4287
9	.5316	.4191	.4287	.2572	.3429	.5144	.5144
10	.3429	.3429	.3429	.3429	.3772	.2572	.4287
11	.5144	.3429	.3429	.3086	.381	.1715	.3429
12	.4572	.2572			.2286	.1715	.2572
13	.4191				.1905		.1715
14					.2286	.2572	.1715
15	.2286	.1715	.3429		.2858	.2572	.3048
16	.2667	.2572	.4287	.3086	.3048		.3048
17	.4191	.3429	.4287	.3772	.4572	.2572	.2572
18		.4287	.4287	.5316	.5144	.4287	.2572
19	.5335	.4287	.6001	.5316	.5335	.5144	.3429
20		.3429	.5144	.3258	.5144	.4287	.4287
21	.4763	.3429	.5144	.3601	.4572	.4287	.4287
22	.4191	.2572	.4287	.3258		.3429	.5144
23		.2572	.4287	.3086	.4191	.3429	.4287
24	.2915	.381		.3429	.2743	.381	.2572
Max	.6516	.5335	.6001	.6001	.9945	.5906	.6001
Min	.2286	.1715	.2572	.2572	.1905	.1715	.1715
Avg	.4499	.3758	.4244	.3926	.4192	.4114	.3576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 201 / 11KV Deodi Hadgaon SP FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.5658	.5144	.394	.2743	.3429	.3429
2	.7545	.6001	.5144	.5014	.2743	.3429	.4287
3	.823	.6001	.5144	.5792	.2915	.3429	.4287
4	.8573						
5	.9259						
6	1.0288						
7		1.8004	1.406	1.3032	1.166	1.3717	1.1145
8		.2023	1.6289	1.749	1.7078	1.6289	1.3717
9		2.0576	2.2462	2.0805	2.1776	1.7147	1.5432
10		2.0233	1.9719	2.1776	2.0081	1.8004	1.6289
11		2.0576	2.2085	2.4459	2.1262	1.7318	1.8604
12		2.1434	2.0978	2.1262	2.0576	1.8004	1.3672
13	.8573	2.1434	2.3034	2.1704	2.0233	1.5432	1.6827
14	1.3717	2.0576	1.7528	1.8947	1.9204	1.3717	1.6651
15	1.286				.2572	.2743	
16	1.2346				.3429	.2572	
17	1.2346				.4287	.3429	
18	1.166	.6516	.5316	.5144	.5144	.5144	.5316
19	.0943	.6001	.5895	.5144	.5487	.5144	.6001
20	.6516	.5487	.4382	.4973	.4801	.6001	.6001
21	.6001	.5316	.5194	.4801	.4287	.4287	.5316
22	.5658	.5316	.4525	.4287	.4115	.3429	.5316
23	.5658	.5144	.4344	.3944	.3772	.2286	.3898
24	.7716	2.1434	.5144	.394	.2743	.3772	.2572
Max	1.3717	2.1434	2.3034	2.4459	2.1776	1.8004	1.8604
Min	.0943	.2023	.4344	.394	.2572	.2286	.2572
Avg	.8645	1.2096	1.1466	1.1470	.9567	.8511	.9376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 202 / 11KV Dhakefal SP FDR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.2572	.4801	.394	.4115	.4287	.2572
2	.3429	.2572	.4801	.3982	.3772	.4287	.2572
3		.2743	.4801	.4344	.3772	.4287	.2743
4		.3086	.5144	.4298	.4115	.5144	.2572
5		.3086	.5144	.4961	.4287	.5144	.2915
6		.3086	.5144	.4908	.4458	.6001	.3429
7	1.7147	.4287	.5144	.5487	.4801	.6001	.5144
8	1.7147	.4801	.5487	.6001	.5144	.6859	.6001
9	1.8519						
10	1.8519						
11	1.8861						
12	1.8519						
13	1.7147						
14	1.5775						
15		1.7147	1.7177	1.5023	1.8861	2.0576	1.8088
16		1.8004	1.6124	1.6248	1.7147	2.0576	1.6476
17		1.8861	1.4899	1.7223	1.6289	1.2574	1.5257
18	.2058	1.8004	1.4575	1.6804	1.5432	1.6289	1.5089
19	.3086	1.7147	1.1789	1.1869	1.3717	1.3717	1.406
20	.3429	1.5432	1.1744	1.0174	1.2003	1.1145	1.0288
21	.3429	1.3717		.9555	1.0288	.9431	.9431
22	.3086	1.0974	.724	.6859	1.0288	.8573	.7716
23	.3086	.4801	.4344	.3429	.4287	.2286	.3898
24	.3601	.3086	.4801	.4298	.4458	.2572	
Max	1.8861	1.8861	1.7177	1.7223	1.8861	2.0576	1.8088
Min	.2058	.2572	.4344	.3429	.3772	.2286	.2572
Avg	1.0026	.9078	.8421	.8300	.8735	.8875	.8132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 203 / 11KV Avalgaon AG FDR  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1145	.9945	.985	1.1812	1.0117	.8573
2		1.1145	.9945	.9671	1.046	1.0288	.8573
3		1.0974	1.0288	.9593	1.0288	1.0288	.8573
4		1.0974	1.0288	.9568	.9259	1.0288	.9431
5		.9945	.9431	.9465	.8573	1.0631	.9431
6		.9945	.9431	.9816	1.0631	1.0288	1.1145
15	1.8004						
16	2.0748						
17	2.3663						
18	2.3663						
19	1.8004						
20	1.2689						
21	1.166						
22	1.1831						
23	1.1831	.8573	.905	1.0513	1.0288	.7621	1.0985
24			.9431	1.0029	1.004	1.0288	.9431
Max	2.3663	1.1145	1.0288	1.0513	1.1812	1.0631	1.1145
Min	1.166	.8573	.905	.9465	.8573	.7621	.8573
Avg	1.6899	1.0386	.9726	.9813	1.0169	.9976	.9518

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 201 / 11 KV SADEGAON AG FDR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.8059	.9774	.8688	.8688	.823	.8916	1.0117
11	1.0288	1.2003	.9602	.9755	.9602	1.1145	1.0631
12	1.0974	1.2003	1.0669	1.0364	1.0802	1.0669	1.0631
13	1.1145	1.2346	1.0669	1.0669	1.0631	1.0974	1.0974
14	1.1831	1.286	1.0364	1.0822	1.046	1.2689	1.1145
15	1.166	1.2517	1.0517	1.0974	.9431	1.2689	1.1317
16	1.166	1.2346	1.0059	1.0669	1.0288	1.2517	1.166
17	1.2003	.9259	.9755	1.0364		1.2346	1.166
Max	1.2003	1.286	1.0669	1.0974	1.0802	1.2689	1.166
Min	.8059	.9259	.8688	.8688	.823	.8916	1.0117
Avg	1.0953	1.1639	1.0040	1.0288	.9921	1.1493	1.1017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 202 / 11KV Sadegaon Gaothan

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2286	.3086	.2591		.2743	.2743
2	.3353	.2286	.3086	.3353	.2743	.3048	.3048
3	.381	.3201	.3772	.3658	.3201	.3963	.3658
4	.5316	.4877	.4801	.4268	.3353	.5316	.442
5	.7202	.7316	.6859	.6401	.4877	.6859	.6344
6	.9945	.823	.9945	.9755	.823	.8402	.8402
7	1.166	.9907	.9145	.9145	.9145	.9602	.9088
8	1.046	.7773	.8535		.7621	.9088	.8402
9	.9431	.7164	.5792	.6249	.5335	.7716	.6516
10	.7373	.583	.3658	.442	.442	.5658	.5144
11	.3944	.4458	.3048	.2896	.2743	.2896	.3601
12	.3086	.3429		.2439	.2134	.2591	.2743
13	.2743			.2286	.1829	.2134	.2572
14				.2286	.2286	.2591	.2743
15	.3086	.3086	.1829	.2286	.2439	.1677	.2743
16	.5144	.3429	.2743	.3048	.3353	.2286	.3086
17	.6001	.4115	.381	.4115		.3506	.4115
18	.8573	.7545	.5487	.6249		.6344	
19	.823	.823	.6706	.7621	.8402	.7716	.823
20	.5335	.583	.5335	.5335	.6344	.442	.5487
21	.381	.4801	.3658		.4268	.3353	.3772
22	.3048	.3086	.2743	.2743	.3201		.3429
23	.2439	.3086	.2439	.2591	.2439		.2915
24	.2591	.2286	.2915	.2591	.2439	.2439	.2439
Max	1.166	.9907	.9945	.9755	.9145	.9602	.9088
Min	.2439	.2286	.1829	.2286	.1829	.1677	.2439
Avg	.5629	.5102	.4733	.4378	.4324	.4743	.4593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 203 / 11KV Gangachincholi AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.442	.463	.4877	.4572	.4268	.442
2	.5316	.442	.4801	.5487	.4877	.442	.5144
3	.5316	.4572	.1543	.6097	.5182	.5144	.5487
4	.5144	.4877	.5144	.6401	.5487	.5487	.583
5	.5144	.5182	.5144	.7011	.6401	.5658	.6001
6	.5658	.5182	.583	.7316	.7011	.6516	.6516
7	.6687	.5639	.6097	.823	.7164	.7202	.703
8	.7888	.5792	.7621	.7926	.7773	.8573	.7716
9	.7545	.6249	.8078	.7621	.7621	.7773	.8402
24	.5487	.4268		.4572	.4572	.4268	.442
Max	.7888	.6249	.8078	.823	.7773	.8573	.8402
Min	.5144	.4268	.1543	.4572	.4572	.4268	.442
Avg	.5967	.5060	.5432	.6554	.6066	.5931	.6097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 204 / 11KV EXPRESS FDR Jogladevi NON SHEDDABLE EXPRESS HV FEEDERS  
Bar Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	20-JAN-17
HR	Load (MW)
12	.2591
Max	.2591
Min	.2591
Avg	.2591



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134068 / 33KV S/S SINDKHED

Feeder No / Name : 201 / Limboni Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4858	.5506	.4534	.4049	.4049	.4049
2		.5668	.6154	.5182	.4858	.4858	.4858
3		.6478	.7449	.6154	.4858	.4858	.4858
4		.7287	.8097	.7125	.5668	.4858	.5668
5		.8097	.8745	.7449	.5668	.5668	.6478
6		.8745	1.0688	.7773	.6478	.6478	.7202
7		1.004	1.1336	.8421	.8002	.8097	.9602
8		1.1012	1.3765	1.166	1.2803	1.2955	1.2803
9		1.1336	1.1984	1.1336	1.4403	1.3765	1.3603
10	1.1012						
11	1.5546						
12	1.6194						
13	1.5546						
14	.9717						
15	1.2146						
16	1.3927						
17	1.2955						
24		.4049	.4858	.3887	.4049	.4049	.4049
Max	1.6194	1.1336	1.3765	1.166	1.4403	1.3765	1.3603
Min	.9717	.4049	.4858	.3887	.4049	.4049	.4049
Avg	1.3380	.7757	.8858	.7352	.7084	.6964	.7317

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134068 / 33KV S/S SINDKHED

Feeder No / Name : 202 / Sindkhed Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955						
2	1.2955						
3	1.2955						
4	.9717						
5	.9717						
6	.9717						
7	1.2955						
8	1.5546						
9	1.4575						
10		.8907	1.0526	.8745	1.1203	.9717	.9602
11		1.6194	1.6194		1.6004	1.6194	1.2955
12		1.8785	1.749		1.6804	1.9433	1.4575
13		2.1052	1.8785		1.6004	1.8623	1.7814
14		2.0405	1.587		1.6004	1.7814	1.8785
15		1.9433	1.587		1.6004	1.7004	1.9433
16		1.8138	1.7166	1.6194	1.6004	1.7004	1.9433
17		1.5546	1.5223	1.6194	1.1336	1.7004	1.6194
24	.9717						
Max	1.5546	2.1052	1.8785	1.6194	1.6804	1.9433	1.9433
Min	.9717	.8907	1.0526	.8745	1.1203	.9717	.9602
Avg	1.2081	1.7308	1.5891	1.3711	1.4920	1.6599	1.6099

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 201 / 11KV ANTARWALI -T AG FDR FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8124	.9907	1.0479	.6401	.9907		
2	.8124	1.0288	1.105	.7316	.9907		
3	1.0623	1.0479	1.1431	.7316	1.0669		
4	1.0155	1.105	1.1812	.7316	1.1431		
5	1.0467	1.2384	1.2384	.8383	1.1431		
6	1.0936	1.6194	1.3336	.9374	1.2193		
7	1.1561	1.7147	1.6385	1.2955	1.2955		
8	1.7497	2.0957	1.8099	1.5546	1.3717		
9	1.8747	2.0957	1.9052	1.4937	1.4632		
10						1.1092	1.8138
11						1.531	2.1338
12						1.8747	2.2862
13						1.7985	2.1338
14						1.7528	2.4387
15						1.9997	2.6673
16						2.0622	2.5911
17						2.1872	2.4387
24		.8573	.9907	.6401			
Max	1.8747	2.0957	1.9052	1.5546	1.4632	2.1872	2.6673
Min	.8124	.8573	.9907	.6401	.9907	1.1092	1.8138
Avg	1.1804	1.3794	1.3394	.9595	1.1871	1.7894	2.3129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134085 / ANTERWALI TEMBHI

Feeder No / Name : 205 / 11KV Antarwali-T Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.5335	.5335	.6249	.5335	.5335	.4268
2	.4268	.5716	.5716	.6859	.5335	.5335	.4572
3	.4687	.6097	.5716	.6859	.5335	.5335	.4572
4	.4999	1.2955	.6097	.7316	.6097	.6097	
5	.5937	1.3336	.6668	.9907	.7621	.7621	.8535
6	.8124	1.3717	1.467	1.1888	1.1431	1.1431	.9145
7	1.0936	1.4861	1.467	1.0974	1.0669	1.0936	1.1431
8	1.0974	1.3908	1.4861		.9907	1.0155	1.1092
9	1.1336	1.3336	1.448	1.0059	1.2193	.8592	.9907
10	.8383	.9717	.9145	.7926	.9145	.6859	.7621
11		.6478	.4877	.8383	.5487	.5487	.5335
12	.8764	.6097		.6859	.4725	.4268	.381
13				.4572	.4572	.3906	.381
14				.381		.3906	.5335
15	.7621	.5906	.3353	.3353	.4115	.4268	.7621
16	.9717	.6668	.4572	.4572	.7621	.3963	.9145
17	1.086	.8573	.7926	.7621	.7621	.6401	
18	1.2765	1.2955	1.1126	.7621	1.1431	.8383	
19	1.1622	1.3146	1.0364	1.1431	1.0669	.945	.9145
20	.743	.8573	.8383	.9145	.8383	.7926	.7621
21	.6668	.5906	.7316		.6097	.5792	.5639
22	.5716	.5716	.5335		.5335	.381	.4572
23	.5525	.5335	.4572		.4572	.3353	.4572
24	.4858	.5335	.5335	.4572	.5335	.3353	.3658
Max	1.2765	1.4861	1.4861	1.1888	1.2193	1.1431	1.1431
Min	.4268	.5335	.3353	.3353	.4115	.3353	.3658
Avg	.7879	.9076	.8120	.7499	.7349	.6332	.6734

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 201 / 11 KV RANJANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224	.2572	.3361	.2477	.2229	.3475	.3801
2	.4163	.2572	.3395	.4458	.2229	.3801	.4938
3	.5121	.3086	.547	.6762	.2401	.4344	.6099
4	.6036	.3982	.6224	.7362	.3429	.5847	.7282
5	.7023	.8145	.7733	.9745	.7716	.6478	.8402
6	.8029	.961	1.0479	1.0751	.8916	.8383	.9619
7	.8962	1.1203	1.1812			1.105	1.1622
8	1.1317	1.2071	1.1128		1.0288	1.226	1.1317
9	.8962	1.0562	.9522	1.2071	.9431	1.1763	.9335
10	.8029	.8865	.8029	.9709	.8029	.8962	.6722
11	.6535	.6602	.5906	.7655	.6413	.8775	.5316
12	.5415	.5847			.4715	.6908	.4458
13							.3429
14							.2743
15	.5544	.4294	.499	.5544	.4481		.3086
16	.6099			.6099	.547	.543	.3086
17	.7282	.6908	.7842	.7133	.5601	.7655	.5316
18	.8413	.9149	.5975	.9055	.8775	.9425	.7202
19	.8316	.5914	.6653	.9522	.7655	.9335	.7888
20	.6036	.6722	.6099	.6161	.6348	.6767	.5316
21	.5014	.5975	.4755	.4938	.4854	.5194	.3772
22	.3856	.4755	.3658	.3544	.4755	.3772	.3258
23	.2743	.3658	.3258	.2774	.3772	.3155	.2572
24	.2328	.2572	.3734	.2477	.2229	.3584	.2715
Max	1.1317	1.2071	1.1812	1.2071	1.0288	1.226	1.1622
Min	.2328	.2572	.3258	.2477	.2229	.3155	.2572
Avg	.6293	.6432	.6501	.6749	.5702	.6970	.5804

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 202 / 11 KV RANJANI AG FDR SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543						
2	.1907						
3	.2279						
4	.2629						
5	.3012						
6	.3366						
7	.3761						
8	.4163						
9	.4706						
10		.2507	.2601	.2481	.1543	.2774	.2743
11		.4334	.4161	.4287	.4024	.3944	.5316
12		.4908	.5365	.4801	.5201	.463	.4801
13		.4908	.5256	.5256	.5596	.5194	.4973
14		.5014	.5087	.5658	.4973	.5373	.4973
15		.4161	.5144	.5316	.4908	.2126	.4458
16			.5316	.463	.5201	.4607	.4458
17		.2713	.4748	.5083	.4508	.4607	.4458
24	.12						
Max	.4706	.5014	.5365	.5658	.5596	.5373	.5316
Min	.12	.2507	.2601	.2481	.1543	.2126	.2743
Avg	.2857	.4078	.4710	.4689	.4494	.4157	.4523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 203 / 11 KV KRISHNAPUR AG FEEDER SEPERATION/PURE AG  
 FEEDER Feeder KV- 11 /  
 OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6241	.5502	.4841	.6401	.6019	.4858
2		.6241	.873	.5868	.6401	.8162	.5357
3		.6859	.8436	.6984	.6401	.8429	.639
4		.7621	1.0623	.8025	.6859	.8916	.6859
5		.8383	1.0136	.9181	.7316	1.0852	.7811
6		.8993	1.0669	1.0364	.9145	1.1797	.8642
7		.9907	1.166	1.1431		1.2643	1.0202
8		1.1574	1.5181	1.3426	1.2955	1.3125	1.3283
9		1.3283	1.3748	1.3757	1.2498	1.3889	1.2967
10	.9755						
11	1.1591						
12	1.0974						
13	1.6356						
14	1.5043						
15	1.6518						
16	1.5844						
17	1.3443						
24		.5721	.514	.4344	.5182	.5719	.4089
Max	1.6518	1.3283	1.5181	1.3757	1.2955	1.3889	1.3283
Min	.9755	.5721	.514	.4344	.5182	.5719	.4089
Avg	1.3691	.8482	.9983	.8822	.8129	.9955	.8046

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 204 / 11 KV CHITRAWADGAON AG. FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.514						
2	.5487						
3	.6344						
4	.695						
5	.7628						
6	.8619						
7	.9332						
8	1.1279						
9	1.2186						
10		.8741	1.3603	.8431	1.186	1.186	1.0536
11		1.3916	1.6876	1.6385	1.5123	1.4723	1.4175
12		1.5708	1.6518	1.6872	1.4937	1.4403	1.4175
13		1.5813	1.4998	1.6446	1.4335	1.3426	1.4022
14		1.5339	1.5181		1.3643	1.3441	1.387
15		1.4327	1.4548	1.0288	1.3123	.7385	1.3108
16			1.5043	1.4685	1.1561	1.0551	1.3108
17		.7676	1.5061	1.4529	1.3123	1.1589	1.326
24	.4801						
Max	1.2186	1.5813	1.6876	1.6872	1.5123	1.4723	1.4175
Min	.4801	.7676	1.3603	.8431	1.1561	.7385	1.0536
Avg	.7777	1.3074	1.5229	1.3948	1.3463	1.2172	1.3282



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 205 / 11 KV EXPRESS FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Ranjani Feeder KV- 11 / STAGGERING (MIDC, EQUIVALENT)  
 OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572			.061	.0572	.0591	
2	.0572				.0572	.0591	
3	.021				.0572	.0591	
4	.0191				.0572	.0648	
5	.021				.0572	.0648	
6	.021				.0572	.0648	
7	.0248					.0686	
8	.021						
9	.0171	.0191		.0229	.0191		
10	.0191		.0362	.0248	.0248	.0533	.0229
11	.0191			.0229	.0267	.0419	.0267
12			.0343		.0248	.0248	.0267
13			.0362	.0229			.0267
14	.0191	.0191	.0343		.021		.0286
15		.0171	.021	.0248	.021		
16				.04			
17			.0191	.0191	.0171		
18	.0191	.0191	.0191		.0229		
19			.0191				
20			.0191		.0648		
21			.0191	.0648	.0591		
22			.0191	.0724	.0572		
23			.0191	.0724	.0553		
24	.0591				.0572	.061	
Max	.0591	.0191	.0362	.0724	.0648	.0686	.0286
Min	.0171	.0171	.0191	.0191	.0171	.0248	.0229
Avg	.0282	.0186	.0246	.0407	.0429	.0565	.0263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 206 / PARADGAON GFS.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0566	.0754	.0754		.0943	.0754
2	.0943	.0566	.0754	.0943	.0686	.132	.0943
3	.1132	.0566	.0754	.1132	.0686	.132	.1132
4	.132	.0754	.0943	.132	.0686	.132	.132
5	.1509	.0943	.0943	.1886	.0857	.1698	.1509
6	.1698	.1132	.0943	.2829	.1372	.2075	.1886
7	.1886	.1886	.0943			.2829	.2263
8	.2263	.0943	.1132		.2572	.2641	.2263
9	.2075	.132	.2263	.2452	.2229	.2075	.1886
10	.1509	.132	.132	.2263	.2075	.132	.1698
11	.0943	.0754	.1509	.1132	.132		.0857
12	.0943			.0754	.1132	.0754	.0686
13				.0566	.0943	.0754	.0514
14				.0566	.0754	.0566	.0514
15	.0566	.0943	.132	.0566	.0754	.0189	.0514
16	.0566		.132	.0943	.0943	.0754	.0686
17	.1132	.0943	.1698	.1132	.0943	.1698	.0857
18	.132	.132	.1698	.0943	.2075	.1886	.2401
19	.1132	.2075	.1698	.2075	.1886	.2263	.12
20	.1132	.0943	.1509	.1132	.0943	.1698	.12
21	.0754	.0943	.132	.1132	.0754	.1132	.0857
22	.0754	.0754	.1132	.0943	.0754	.0754	.0514
23	.0566	.0943	.0943	.0754	.0754	.0566	.0514
24	.0566	.0566	.0943	.0566	.0686	.0754	.0566
Max	.2263	.2075	.2263	.2829	.2572	.2829	.2401
Min	.0566	.0566	.0754	.0566	.0686	.0189	.0514
Avg	.1157	.1009	.1230	.1217	.1173	.1361	.1147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 201 / 11KV BORGAON GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3056	.292	.2985	.072	.1259	.129
2	.3224	.333	.3077	.3119	.0766	.1336	.1469
3	.1509	.3433	.3643	.3574	.1048	.1753	.1633
4	.1509	.4017	.4553	.4405	.1421	.2333	.2112
5	.1509	.5749	.6651	.6505	.2039	.3486	.2499
6	.1698	.7624	.8703	.8042	.2385	.4888	.506
7	.469	.7647	.7647	.7888	.2961	.5518	.4782
8	.7057	.5924	.8221		.4423	.5175	.4176
9	.771	.3372	.7304	.8246	.3989	.3995	.3162
10	.5476	.5805	.4964	.5829	.2972	.3366	.2457
11	.3536	.37	.2496	.285	.1824	.2171	.1831
12	.2651		.2252	.0991	.1629	.1654	.1545
13	.0743		.2208	.0488	.1276	.1464	.148
14			.204	.162	.123	.1563	.1514
15	.2352		.2067	.1384	.1291	.1574	.1507
16	.2985		.284	.142	.1781	.2045	.1617
17	.5125		.4119	.2529	.2544	.2402	.194
18	.632	.6807	.6455	.393	.3477	.3741	.2896
19	.7794	.8581	.8146	.4473	.4953	.4378	.3453
20	.6926	.6432	.6594	.3593	.3619	.3505	.3334
21	.5215	.4256	.4351	.1398	.2196	.2339	.2657
22	.3934	.3445	.3609	.1193	.1758	.1833	.1979
23	.3082	.3096	.1726	.1594	.153	.0785	.1302
24	.3235	.3863	.297	.146	.1264	.1267	.1256
Max	.7794	.8581	.8703	.8246	.4953	.5518	.506
Min	.0743	.3056	.1726	.0488	.072	.0785	.1256
Avg	.3975	.5008	.4565	.3457	.2212	.2660	.2373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 202 / 11 KV KANDARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.2286	.2286		.2286	.2096
2	.2096	.2286	.2286	.2286		.2286	.2096
3	.2096	.2286	.2286	.2286		.2286	.2096
4	.2477	.2286	.2286	.2477		.2477	.2286
5	.2858	.2286	.2477	.2667		.2858	.2667
6	.3239	.2667	.3429	.3048		.362	.1905
7	.362	.2858	.3429	.3048		.362	.1715
8	.3239	.2858	.3239		.2477	.2858	.1524
9	.2858	.2286	.2858	.3429	.2286	.4001	.2477
10	.362	.2858		.2858	.3048	.3048	.2096
11	.1524	.1524	.1905	.2286	.2096	.2477	.1524
12	.1524	.1524	.1715	.2286	.2096	.1715	.0762
13			.1143	.1905	.1715	.1334	.0762
14			.1143	.0762	.1524	.1143	.0762
15	.1524	.1143	.1143	.0953	.1334	.0953	.0762
16			.1524	.1143	.1905	.1334	.0572
17	.2477	.1905	.2286	.1334	.2667	.1715	.1524
18	.2096	.3429	.2096	.3239	.2477	.1715	.1524
19		.4001	.2477	.3048	.3048	.2096	.1905
20	.381	.3429	.2667	.2858	.3048	.2286	.2667
21		.2477	.2667		.2858	.2477	.2286
22	.2667	.2286	.2477				.2286
23	.2286	.2286	.2286	.2286	.2286	.1905	.2096
24	.3048	.2286	.2858	.2286	.2477	.2096	.2096
Max	.381	.4001	.3429	.3429	.3048	.4001	.2667
Min	.1524	.1143	.1143	.0762	.1334	.0953	.0572
Avg	.2587	.2440	.2303	.2322	.2334	.2286	.1770

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 203 / 11 KV BORGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2335	.0311	.0934	.109		.0934	.0934
2	.2646	.0311	.0934	.109		.0934	.0778
3	.2957	.0311	.0934	.1245		.0934	.0623
4	.3113						
10		.0623	.716	.6693	.5292	.5137	.4981
11		.5604	.9339	.7004	.9339	.8405	.7783
12		.8561	.3891	.7627	1.0896	.7783	.8872
13		.9806	.9651	.7938	1.0429	.6071	
14		.9651	.9339	.9495	.8094	.8561	.9339
15		.9962	.8872	.9495	.825	.7004	.9495
16	.0156		.825	.9651	1.0118	.716	.8717
17	.0156	.3891	.8094	.8872	.9495	.7316	
18	.0311	.2024	.1245	.109	.1245	.1712	
19	.0311	.1868	.1557	.1245	.1245	.1557	.1557
20	.0311	.1557	.1401	.1245	.109	.1401	.1401
21	.0311	.1401	.1401		.0934	.1401	.109
22	.0311	.109	.0934			.1245	.109
23	.0311	.109	.0934		.0934		.0934
24	.1712	.0311	.0934	.0934	.0934	.0934	.1245
Max	.3113	.9962	.9651	.9651	1.0896	.8561	.9495
Min	.0156	.0311	.0934	.0934	.0934	.0934	.0623
Avg	.1149	.3434	.4211	.4981	.5593	.4029	.3923

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 204 / 11 KV KANDARI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4858	.5182	.5182		.7125	.5344
2		.4858	.5506	.5215		.7125	.5344
3		.5182	.5506	.5506		.7287	.5344
4		.502	.583	.583		.7449	.5344
5		.5506	.664	.6154		.7773	.5506
6		.7449	.7125	.664		.8907	.7287
7		.9069	.9717	1.0688		1.2146	1.166
8		1.004	1.2631	1.2793	1.3927	1.587	1.4737
9		1.004	1.1984	1.1822	1.4575	1.6194	1.5061
10	.7287						
11	1.3927						
12	1.3765						
13	1.749						
14	1.7166						
15	1.5384						
16	1.5223						
17	1.2955						
24		.4858		.5182		.5506	.5344
Max	1.749	1.004	1.2631	1.2793	1.4575	1.6194	1.5061
Min	.7287	.4858	.5182	.5182	1.3927	.5506	.5344
Avg	1.4150	.6688	.7791	.7501	1.4251	.9538	.8097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 205 / 11 KV PANGRA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001						
2	.4961						
3	.5921						
4	.6722						
5	.7682						
6	.8642		.2881				
7	.9602						
8	1.3763						
9	1.2323						
10		.7362		1.2323	.7842	.7042	.7042
11		1.2483	1.8404	1.4883	1.4403	1.1203	1.2163
12	.128	1.4723	1.8244		.7362	1.2163	1.3283
13		1.6484	1.5684	1.5043	1.6004	1.1683	1.4403
14		1.6324	1.4243	1.5844	1.3603	1.1043	1.4243
15		1.5203		1.4403	1.2003	.8642	1.3443
16			1.3923	1.4083	1.2643	.9282	1.2803
17			1.2643	1.1683	1.0562	.9722	1.0562
24			1.2163				
Max	1.3763	1.6484	1.8404	1.5844	1.6004	1.2163	1.4403
Min	.128	.7362	.2881	1.1683	.7362	.7042	.7042
Avg	.7490	1.3763	1.3523	1.4037	1.1803	1.0098	1.2243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 206 / 11 KV Maherjawla gaothan GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1334	.1334		.1524	.1334
2	.1334	.1334	.1334	.1334		.1524	.1334
3	.1334	.1334	.1524	.1334		.1524	.1334
4	.1334	.1524	.1905	.1905		.1905	.1715
5	.1334	.1905	.2096	.2667		.2477	.2477
6	.1715	.2286	.2858	.3239		.4001	.4001
7	.2096	.2286	.2477	.3429		.4191	.4191
8	.381	.2858	.3239		.2667	.381	.3429
9	.2667		.2858	.2858	.2477	.3239	.3429
10	.2096	.2096	.1524	.1715	.2286	.1905	.2477
11	.1334	.1524		.1334	.1334	.0953	.0953
12	.0953	.0953	.0572		.1143	.0762	.0762
13			.0572		.0572	.0762	
14			.0572	.0762	.0572	.0762	.0762
15	.0762	.0762	.0762	.0762	.0762	.0572	.0762
16	.0953		.0762	.0762	.0762	.1524	.0953
17	.1715	.1334	.1334	.1715	.1524	.1524	
18	.2667	.3048	.2286	.2858	.3048	.3429	.3048
19	.2667	.3048	.2477	.2858	.3048	.3048	.3239
20	.2858	.2286	.2096	.2858	.2286	.2286	.3048
21	.2667	.1334	.1524		.1524	.1715	.2286
22	.1524	.1334	.1334			.1524	.1905
23	.1334	.1334			.1334		.1524
24	.1334	.2858	.1334	.0762	.1524	.1524	.1334
Max	.381	.3048	.3239	.3429	.3048	.4191	.4191
Min	.0762	.0762	.0572	.0762	.0572	.0572	.0762
Avg	.1810	.1839	.1672	.1916	.1679	.2021	.2104



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 207 / 11 KV MASHEGAON AG FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4321		.4321		.5247	.463
2		.4321	.3704	.4321		.5247	.463
3		.4475	.3704	.463		.5247	.463
4		.4475	.4012	.463		.5556	.463
5		.463	.4012	.5247		.5864	.4784
6		.5864	.4321	.6173		.5864	.571
7		.7099	.6481	.6481		.6636	.6019
8		1.0648	1.0185	.7407	.7716	1.1111	1.1265
9		1.0648	1.0648		.8405	1.358	1.3735
10	.6481						
11	.8025						
12	.8872						
13	1.0185						
14	1.0031						
15	.8796						
16	.8642						
24		.4167		.3704		.3704	.463
Max	1.0185	1.0648	1.0648	.7407	.8405	1.358	1.3735
Min	.6481	.4167	.3704	.3704	.7716	.3704	.463
Avg	.8719	.6065	.5883	.5213	.8061	.6806	.6466

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 201 / TALNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	.8916	1.3375	1.2689	1.2003	1.2003	1.166
2	1.3717	.9259	1.3717	1.3717	1.2346	1.2003	1.1317
3	1.5775	1.0117	1.406	1.4403	1.4575	1.3717	1.1831
4	1.6632	1.3032	1.406	1.5432	1.5432	1.7147	1.3032
5	1.749	1.3717	1.5089	1.6118	1.5775	1.7318	1.3717
6	1.8176	1.5089	1.5775		1.2003	.6859	1.4746
7	1.2003	1.0288	1.7147		1.0288	1.5432	1.1317
8	1.4403	1.6461	1.8176		1.6118	1.6118	1.7833
9	1.4746	1.7147		1.7147	1.7833	1.749	1.8861
10	1.406		1.8519	1.3717	1.2689	1.6804	1.5775
11	1.3717			1.3375	1.1317	1.4403	1.4746
13			1.3717				
14	2.0576	1.4403	1.5775	1.3717		1.3032	1.4746
15	2.2977		1.5432	1.5775	1.4746	1.2003	1.5089
16	1.8861		1.3717	1.6118	1.406	1.3717	1.406
17	1.3717	1.2003		1.5432	1.406	1.2346	1.2346
18	1.6804	1.166	.9259	.8745	.583	1.8861	1.0288
19	1.989	1.6118	1.3717	1.8519	1.8176	1.8176	1.5775
20	1.8519	1.749	1.5432	1.7147	1.6804	1.7318	1.5432
21	1.6461	1.6118	1.3717	1.5432	1.6118	1.4403	1.5089
22	1.5089	1.3717	1.2003	1.3717	1.5089	1.3375	1.4403
23	1.0288			1.2003	1.2689	1.2346	1.3717
24	1.2003	1.3375	1.2003		1.0631	1.1317	1.2003
Max	2.2977	1.749	1.8519	1.8519	1.8176	1.8861	1.8861
Min	1.0288	.8916	.9259	.8745	.583	.6859	1.0288
Avg	1.5861	1.3465	1.4457	1.4622	1.3742	1.4372	1.3990

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 202 / IDOLI (ARDA)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.1715	.2401	.2572	.1543	.1543	.1715
2	.3258	.2058	.2915	.2743	.1543	.1543	.1886
3	.3601	.2401	.2915	.2915	.1543	.1543	.2401
4	.3944						
5	.4287						
6	.4973						
7	.6687						
8	.8059				.1543		
9	.7545						
10			.3258	.6859	.4801	.5316	.3772
11				.8402	.2058	.7373	.7888
12		.8573		.8059	.1715	.703	.8916
13		.8573	.8059	.8402	.1543	.583	.8059
14		.823	.7716			.6001	.7545
15		.7888	.7888	.703	.703	.6173	.7888
16	.1715		.8059	.7373	.7373	.6344	.6859
17	.2915	.6859		.6859	.823	.5144	.5658
18	.3429	.6173	.3429	.2915	.3086	.2229	.3429
19	.3601	.5144	.3772	.2743	.4115	.3772	.3944
20	.3086	.3429	.3429	.2572	.3429	.3086	.3086
21	.2401	.2401	.2743	.1715	.2572	.2572	.2229
22	.1886	.1715	.2058	.1372	.2229	.2058	.2058
23	.1715				.1715	.1715	.1715
24	.2572	.2058	.2401		.1372	.1543	.1543
Max	.8059	.8573	.8059	.8402	.823	.7373	.8916
Min	.1715	.1715	.2058	.1372	.1372	.1543	.1543
Avg	.3801	.4801	.4360	.4835	.3191	.3934	.4477

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 203 / PATHODA (HEALS)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.5487	.583	.6859	.6687	.4801	.5144
2	.5487	.6173	.6173	.7545	.823	.5144	.6173
3	.6859	.7202	.6516	.8573	.823	.5487	.7202
4	.7888	.7888	.6859	.9088	.8745	.8573	.7888
5	.9259	.9259			.8745	.8745	.8402
6	.9431	.9431					.8745
12	1.6804	.7888		1.286	1.2003	1.046	1.0288
13	1.5775	1.0288	1.3717	1.406	1.4403	1.1317	1.5775
14	1.5261	1.3717	1.3717	1.2003		1.0288	1.4746
15	1.3717		1.2689	1.0631	1.046	.5487	1.5089
16	1.2346		1.2003	.9945	1.0288	.823	1.046
19	.7202	.6516	.5487	.6859	.7373	.7202	1.1831
20	.6173	.6859		.7545	.8573	.7888	.9259
21	.5487	.6516	.583	.6859	.7888	.6687	.7888
22	.5487	.5487	.5316	.5316	.6173	.5144	.5144
23	.4973			.4287	.4458	.4287	.4458
24	.4115	.5487	.6173		.4287	.4458	.3772
Max	1.6804	1.3717	1.3717	1.406	1.4403	1.1317	1.5775
Min	.4115	.5487	.5316	.4287	.4287	.4287	.3772
Avg	.8866	.7728	.8359	.8745	.8436	.7137	.8957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 204 / AMBHODA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1831	1.0802	1.2003	1.0288	1.166	1.2003	1.1488
2	1.2174	1.1488		.9945	1.2689	1.3375	1.1831
3	1.2689	1.1831	1.2346	.8573	1.2003	1.3717	1.2346
4	1.3203	1.2689	1.2689	.6859	1.3717	1.5432	1.3203
5	1.406	1.3032	1.3375	.5487	1.4403	1.5604	1.3717
6	1.6804	.8059	1.4403		1.5089	.6173	1.4403
7	1.8176	.7888	1.6118		.6859	1.5432	.9602
8	2.332	1.3717	1.7147		1.6804	1.6118	1.4746
9	2.5377	1.6118		1.2003	1.749	1.6804	1.749
10	2.0919		1.4746	.8573	1.2517	1.2174	1.2346
11	1.5775			.9602	.9602	1.0117	1.0288
13		2.572	1.5432				
14	1.3717	2.572	2.2291	2.0576		1.6289	2.3663
15	1.6461	2.4006	2.2977	2.3834	2.332	1.6804	2.4006
16	1.406		2.4006	2.2977		1.8861	2.4006
17	1.2003	2.0576		1.7147	2.1605	1.6804	1.8176
18	1.1831	1.8861		1.2174	1.9376	1.5775	1.6461
19	1.4746	1.6118	1.5432	1.7147	1.749	1.6804	1.6804
20	1.6118	1.4746	1.4746	1.5604	1.5604	1.5775	1.5432
21	1.5432	1.2003	1.3717	1.3717	1.3546	1.3717	1.4746
22	1.2689	1.166	1.2689	1.286	1.406	1.3032	1.4232
23	1.1488			1.166	1.2689	1.2003	1.3717
24	1.0974	1.166	1.2003		1.0974	1.2346	1.166
Max	2.5377	2.572	2.4006	2.3834	2.332	1.8861	2.4006
Min	1.0974	.7888	1.2003	.5487	.6859	.6173	.9602
Avg	1.5175	1.5089	1.5654	1.3279	1.4575	1.4325	1.5198

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 205 / MANTHA TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0857	.0857	.1029	.1029	.0343
2	.0343	.0343	.1029	.0857	.1029	.1029	.0343
3	.0343	.0343	.0857	.0686	.1029	.1029	.0343
4	.0343	.0343	.0686	.0857	.1029	.1029	.0343
5	.0343	.0343	.0686	.1029	.1029	.1029	.0343
6	.0343	.0514	.0857		.1029	.1029	.0514
7	.0343	.0857	.0857		.1029	.1029	.0686
8	.1029	.0857	.0857		.1029	.1029	.0857
9	.0857	.0857		.0857	.1029	.1029	.0857
10	.0857		.1029	.1029	.0857	.0857	.0857
11	.0857			.0857	.0857	.0686	.0857
12	.0857	.0857		.0686	.0686	.0857	.0857
13	.0857	.1029		.0686	.0686	.0857	.0857
14			.1029	.7716			
15			.1029		.1372		
16	.0857		.1029	.12	.1029	.1029	.0857
17	.0857	.1029		.12	.1029	.1029	.0857
18	.1029	.1029	.1029	.12		.1029	.1029
19	.0857	.1029	.1029	.1029	.1029	.1029	.1029
20	.0857	.0857	.0857	.1029	.1029	.1029	.0857
21	.0686	.1029	.1029	.1029	.1029	.0686	.0686
22	.0514	.1029	.1029	.1029	.1029	.0514	.0514
23	.0343			.1029	.1029	.0514	.0343
24	.0343	.0857	.0857		.1029	.1029	.0343
Max	.1029	.1029	.1029	.7716	.1372	.1029	.1029
Min	.0343	.0343	.0686	.0686	.0686	.0514	.0343
Avg	.0639	.0753	.0924	.1309	.0998	.0928	.0662

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 206 / INDUSTRIAL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.1372	.4458	.4801	.5144	.5144	.3429
2	.5487	.1715	.4115	.4458	.3429	.4801	.3944
3	.5144	.2058	.3772	.4115	.3429	.4801	.4115
4	.5487	.2401	.3772	.3772	.5144	.4801	.4458
5	.5144	.2743	.3772	.3772	.3429	.4801	.3944
6	.5487	.2743	.3429		.3429	.5144	.3772
7	.4801	.2743	.3772		.3429	.4801	.3429
8	.4458	.2743	.4115		.3086	.2743	.3772
9	.2743	.2401		.6001	.0343	.1372	.3086
10	.2401		.3086	.3429	.1029	.1372	.2743
11	.2058			.4115	.3086	.1372	.3086
12	.2401	.2401		.5144	.3429	.1372	.2743
13	.2743	.2743	.2743	.583	.4115	.1029	.5487
14	.2058	.2401	.3086	.5487		.1029	.4458
15	.2401		.3429	.5144		.0343	.5487
16	.2401		.3772	.5144	.5144	.0343	.5144
17	.2743	.2743		.4287	.5487	.0343	.5144
18	.2058	.2401	.2743	.4801	.5487	.0343	.5487
19	.2401	.3086	.2743	.5144	.3429	.0343	.4458
20	.2743	1.4746	.3086	.4458	.5144	.0343	.4801
21	.2401	.3772	.4115	.4801	.5144	.0686	.4458
22	.1372	.4458	.4801	.4801	.5144	.2401	.3772
23	.1372			.5144	.4801	.3086	.3429
24	.5144	.4115	.4458		.5144	.5144	.3086
Max	.583	1.4746	.4801	.6001	.5487	.5144	.5487
Min	.1372	.1372	.2743	.3429	.0343	.0343	.2743
Avg	.3387	.3357	.3646	.4732	.3975	.2415	.4072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 207 / MANTHA TOWN-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.6859	.823	.6516	.6173	.583
2	.6173	.7888	.6859	.823	.6859	.6516	.6173
3	.8573	.8573	.6173	.8573	.6859	.6859	.8059
4	.8916	.9602	.583	.823	.6859	.7545	.9602
5	.9259	1.0117	.7545	.7888	.6859	.7888	1.1317
6	.9602	1.2003	1.0288		1.3717	.8573	1.2346
7	1.0631	1.3375	1.6461		1.6118	1.7147	1.4746
8	1.7147	1.4403	1.6461		1.6118	1.749	1.6461
9	1.5775	1.5089		1.5775	1.5432	1.6804	1.4746
10	1.5432		1.3717	1.6289	1.4746	1.6118	1.3717
11	1.5089			1.5432	1.4403	1.5432	1.3032
12	1.406	1.166		1.3032	1.5432	1.3717	1.2003
13	1.2346			.9945	1.0631	1.3032	1.0974
15			1.0288		.9602		
16	1.1145		1.2346	1.2689	1.3032	1.3032	1.3032
17	1.166	1.3717		1.286	1.3375	1.3717	1.3717
18	1.3375	1.2003	1.4746	1.3032	1.2346	1.406	1.406
19	1.2003		1.2003	1.0974	1.3032	1.3032	1.4746
20	1.0974	1.0288	1.0974	1.0288	1.0288	1.2003	1.0631
21	1.0288	.9259	1.0288	.8573	.6859	.9945	.9602
22	.7545	.7545	.7888	.7888	.7888	.7202	.6859
23	.6173			.6859	.6516	.6173	.6516
24	.5144	.7545	.8573		.583	.583	.5487
Max	1.7147	1.5089	1.6461	1.6289	1.6118	1.749	1.6461
Min	.5144	.5487	.583	.6859	.583	.583	.5487
Avg	1.0764	1.0535	1.0429	1.0822	1.0840	1.1286	1.1075



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 202 / DAHIFAL SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.8573	.9431	.7716	.6687	.6516	.5144
2	.7202	.8573	1.0288	.7716	.7716	.6859	.5658
3	.823	.8573	1.0288	.8916	.8573	.823	.6687
4		.9431	1.2003	1.2517	1.0288	1.0288	.7716
5		1.0288	.6859	1.286	1.5432	1.2346	1.0288
6		1.2003	1.5432	1.5432	2.0576	1.5432	1.2346
7		1.5432	1.9719	1.9547	1.7147	2.0576	1.3717
8		2.2291	2.572	2.7606	2.4348	2.6063	1.7147
9		2.0576	2.3663	2.3663	2.5034	2.2291	1.5432
15							.6516
16		.5144	.6859	.583	.5144	.583	.6516
17	1.2003	.5144	.6859	.823	.7888	.7545	.7888
18	.8573	.8573	1.0288	1.286	1.2346	.9259	1.0288
19	.8573	.8573	.8573	1.3375	1.3375	1.0631	1.3375
20	.8573	.8573	.8059	1.166	1.1317	.8916	1.1317
21	.8573	.8573	.7202	.9945	1.0288	.7888	.9602
22	.8573	.8573	.6859	.8573	.8916	.6859	.823
23	.8573	.8573	.6859	.7545	.7545	.6173	.7545
24	.7202	.8573	.9431	.7716	.6173	.6173	.4801
Max	1.2003	2.2291	2.572	2.7606	2.5034	2.6063	1.7147
Min	.7202	.5144	.6859	.583	.5144	.583	.4801
Avg	.8480	1.0336	1.1355	1.2317	1.2155	1.0993	.9485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 203 / KOKARSHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.1715	.3429	.3429	.2229	.2229	.2229
2	.3601	.1715	.3429	.3429	.2229	.2229	.2229
3	.463	.1715	.3429		.2401	.2401	.2401
4	.463						
5	.6687						
6	.6516						
7	.9259						
8	1.2346						
9	1.2346						
10		.6173	1.0288	.823	.6859	.823	.6859
11		.8573		1.0631	1.0288	1.0631	.7888
12		.8573	1.0288	1.0974	1.0974	1.0631	.9602
13		1.0288	1.0288	1.0288	1.0631	.9602	1.0288
14		.9431	1.2003	.9259	1.0631	.9259	.6859
15		.9431		.8916	.9259	.8573	.8573
16		.8573	1.0288	.8916	.8916	.7202	.8573
17	.1715	.7716	1.0288	.823	.823	.7202	.8916
18	.1715	.4287	.1715	.2743	.2229	.2743	.2572
19	.1715	.4287		.3086	.3258	.2915	.3086
20	.1715	.3429	.1715	.2743	.2915	.2572	.2743
21	.1715	.3429	.1715	.2572	.2572	.2572	.2229
22		.3429	.2743	.2401	.2401	.2401	.2058
23	.1715	.3429	.3429	.2229	.2229	.2229	.2058
24	.3601	.1715	.3429	.3429	.2229	.2229	.2229
Max	1.2346	1.0288	1.2003	1.0974	1.0974	1.0631	1.0288
Min	.1715	.1715	.1715	.2229	.2229	.2229	.2058
Avg	.4844	.5439	.5898	.5971	.5582	.5325	.5077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 204 / PEWA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.6859	.6859	.6859	.5144	.6001	.6173
2	.7202	.6859	.7716	.7716	.5658	.6516	.6687
3	.7716	.7716	.7716	.7716	.6516	.7202	.7202
4		.8573	1.0288		.7716	.823	.823
5		1.0288	1.0288		.9945	1.0288	1.0288
6		1.0288	1.2003		1.4918	1.286	1.2346
7		1.286	1.286		1.3032	1.5261	1.4746
8		1.7147	2.0576		1.8347	1.9033	2.0233
9		1.5432	1.8861	1.8004	1.5604	1.5775	1.5432
11	1.0288						
12	1.0288						
16	1.0288	.3429	.5144	.6687	.6516	.6687	.703
17	1.0288	.3429	.5144	.9431	.9431	.9259	.823
18	.6859	.6859	.5487	1.2346	1.1317	1.2689	1.2003
19	.6859	.6859	.583	1.0974	1.3375	1.2346	1.2346
20		.6859		1.0631	1.0974	.9431	.9945
21		.6859		.9259	.9431	.823	.8745
22		.6859		.8402	.8745	.7545	.8059
23		.6859		.7716	.7888	.703	.7373
24	.7202	.6859	.6859	.6859	.463	.5658	.583
Max	1.0288	1.7147	2.0576	1.8004	1.8347	1.9033	2.0233
Min	.6859	.3429	.5144	.6687	.463	.5658	.583
Avg	.8419	.8383	.9688	.9431	.9955	1.0002	1.0050

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 201 / LAWANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9387	1.6876	1.2944	1.2944		2.726
2		1.8298	1.6876	1.5729	1.6244		2.7069
3		1.8296	.0358	1.7736	1.6244		2.6797
4		1.7013	2.1051	1.7736	1.9393		2.552
5		1.7551	2.2542	2.1879	2.1125		2.6147
6		1.6478	2.3472	2.4646	2.1125		3.1276
7		1.9936	2.3472	2.4478	2.3266		3.0247
8		2.0119	2.3472	2.4249	2.2775	2.8006	2.6155
9		1.9044	1.6933	2.0719	2.2447	2.2965	2.7069
11				.0572			
12	1.7737						
16	1.7558		.2012	.2452	.2402	.2427	.1867
17			.2507	.2829	.2801	.2772	.2241
18		.2987		.3961	.3439	.2801	.2572
19		.3547	.5041	.4294	.3292	.695	.3206
20	.695	.3547	.3174	.0523	.3547	.7207	.3547
21		.3584	.5228	.4294	.4435	.6348	.3547
22		.3395	.3734	.4294	.7133	.7133	.3361
23		.3395	.3361	.4108	.7577		.0336
24	.6283	.7282	1.2308	1.2452	1.1765	.5601	.4938
Max	1.7737	2.0119	2.3472	2.4646	2.3266	2.8006	3.1276
Min	.6283	.2987	.0358	.0523	.2402	.2427	.0336
Avg	1.2132	1.2116	1.1907	1.1573	1.2331	.9221	1.5175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 202 / PANGARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373	.0179	.0179			
2		.0366	.0179	.0179	.0358		.0381
3		.0373		.0179	.0183		.0373
4		.0377	.0366	.0183	.0183		.0572
5		.0373	.0366	.0366	.0179		.0747
6		.0373	.0366	.0358	.0358		.0366
7		.0934	.0366	.0358	.0716		.0724
8		.0373	.0358	.1254	.0716	.0373	.0373
9			.0716	.1791	.0716	.0373	.0373
12	.112						
16	.0373		.037	.0189	.037	.0377	.037
17			.0187	.0189		.0187	.056
18		.0189		.0189	.0183	.0366	.0366
19		.0183	.0377	.0189	.0373	.056	
20	.0373	.0189	.0189	.0189	.0373	.056	.0019
21		.0189	.0189	.0189	.037	.0373	.0189
22		.0189	.0189	.0189	.0377	.0549	.0189
23		.0189	.0189	.0189	.0373		.0189
24	.0373	.112	.0358		.0358	.0373	.0377
Max	.112	.112	.0716	.1791	.0716	.056	.0747
Min	.0373	.0183	.0179	.0179	.0179	.0187	.0019
Avg	.0560	.0386	.0309	.0374	.0387	.0409	.0386

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 203 / Dahifal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1389	.4715	.4668	4.9105		.695
2		1.1888	.4715	.4715	.4668		.6908
3		1.1584	.4715	.4715	.4668		.7947
4		.6535	.4715	.4668	.4668		.8413
5		.6653	.4854	.5093	.4668		.8775
6		.6219	.5041	.5041	.5041		
7		.5788					
9	3.1276						
10			2.4939	2.4863	2.5265	3.006	2.8349
11			3.1687	3.1369	2.9172	3.3421	
12		2.7639		3.0996	3.0346	3.2674	2.9172
13			3.1367	2.6189	2.7831		3.0011
14		3.0167	3.1741	.2768	2.9843	2.649	3.0346
15				2.9508	2.8502	2.8178	2.6322
16	.1494		3.0121	3.0011	2.9172	2.8837	2.9504
17			3.2594	2.8502	2.8669	2.5857	2.8837
18		.4854		.4294	1.8991	.9054	1.0288
19		.4854	.4854	.4854	.3174	1.7737	.4904
20	1.1763	.4854	.5175	.4854	.4805	1.5546	.5093
21		.5281	.5175	.4854	.7133	1.4815	.4854
22		.4854	.5228	.4854	1.0791	.8589	.4854
23		.4854	.5041	.4668	1.1576		.4854
24	1.5364	.5788	.4668	.5041	.4668	.8962	.7947
Max	3.1276	3.0167	3.2594	3.1369	4.9105	3.3421	3.0346
Min	.1494	.4854	.4668	.2768	.3174	.8589	.4854
Avg	1.4974	.9575	1.3408	1.2692	1.7274	2.1555	1.4965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 204 / SHESH NARYAN

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0549	.1132	.016	.1494		.0549
2		.0716	.1132	.0168	.1494		.0747
3		.0549	.112	.016	.1494		.0354
4		.0709	.1132	.016	.1463		.0732
5		.0537	.1132	.016	.1463		.056
6		.0747	.0895	.0537	.1075		.0747
7		.0914	.0895	.0526	.0351		.1132
8		.0526	.0339	.0351	.0351	.0373	.0514
9	.0537	.0549	.0343	.0351	.0373	.0373	.0693
10			.0312	.0347	.0152	.0373	.0351
11			.0312	.0154		.112	
12	.0747	.1132		.0177	.0332	.0857	.0838
13			.0343	.112	.0328		.0686
14		.0924	.0339	.1132	.0171	.0678	.0351
15				.168	.0343	.0463	.0463
16	.0747		.0347	.1494	.0347	.0663	.0316
17			.0351	.0151	.0354	.0457	.0486
18		.0914		.1509	.0351	.0617	.0171
19		.0732	.0152	.032	.0373	.112	.132
20	.0373	.0747	.032	.032	.0554	.056	.132
21		.0934	.032	.032	.0373	.0747	.132
22		.0914	.032	.0351	.0747	.0549	.1509
23		.0914	.0158	.0351	.056		.1494
24	.0373	.0373	.1132	.016	.0914	.0366	.0373
Max	.0747	.1132	.1132	.168	.1494	.112	.1509
Min	.0373	.0373	.0152	.0151	.0152	.0366	.0171
Avg	.0555	.0743	.0596	.0507	.0672	.0621	.0740

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 206 / wadhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1389	.0504	.5729	.5415		1.0082
2		1.1523	.5041	.0554	.5415		1.0242
3		1.2136	.5041	.5601	.5415		
4		1.1317	.5041	.5601	.5228		.8596
5		1.134	.5041	.5788	.5415		1.0498
6		1.1576	.5415				
7		1.094					
9	3.6214						
10			3.0476	2.769	2.5265	3.0434	3.6969
11			1.1736	2.967	3.0476	3.0434	
12		2.2405		3.0803	1.1904	2.7435	1.1145
13			1.0004	3.0476	1.1401		1.0791
14		3.0247	1.0517	3.0476	.9231	3.1207	1.134
15				3.0996	.985	3.2236	.9774
16	.6535		.8238	3.083	1.0631	2.857	.9745
17			1.1616	3.0346	1.0517	2.7566	.823
18		.5415		.5415	2.7263	2.915	.8413
19		.5415	.5601	.5914	1.1888	1.5565	.5415
20	1.6644	.5729	.5975	.6468	1.2357	1.4632	.5601
21		.0554	.5975	.5975	1.3169	1.3169	.5658
22		.5544	.5975	.5788	1.1016	1.1949	.0525
23		.5601	.5601	.5788	.9522		.5415
24	1.9605	1.1389	.5228	.5601	.5601	1.0164	.9412
Max	3.6214	3.0247	3.0476	3.0996	3.0476	3.2236	3.6969
Min	.6535	.0554	.0504	.0554	.5228	1.0164	.0525
Avg	1.9750	1.0783	.7946	1.5275	1.1849	2.3270	.9881



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134050 / JAIPUR

Feeder No / Name : 201 / V.WADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	1.0349	.8954	1.0269	.9412	.6653	.7975
2	.788	.9877	.9134	1.0608	.9694	.695	.8505
3	.9745	.9412	.9391	1.0692	1.0229	.8962	.8573
4	1.283						
5	1.6617						
6	2.0056						
7	2.17						
8	2.0309						
9	2.1914						
10		.6668		1.8861	1.7924	1.3717	1.1869
11		.5716		2.0405	1.4922	1.8652	1.3599
12		.5525		1.9826	1.656	1.7736	1.8404
13		.5415	2.1765	1.8107	1.576	1.4403	1.7695
14			2.1548	1.6617	1.4217	1.3748	1.6804
15		2.0287	2.0517	1.2489	1.2003	1.3413	1.5565
16	1.0269		2.0576	1.7337	1.4373	1.5257	1.5249
17	1.2071		2.0405	1.6975	1.5775	1.647	1.6324
18	1.2795	1.9071	1.5775	1.086	.6241	1.0498	.9431
19	1.1488	1.3245	1.3611	.985	.8322	1.307	1.153
20	1.1269	1.1488	1.2803	.905	.8669	1.1789	1.0749
21	1.0517	1.0059	1.1946	.7973	.8413	.8495	.8573
22	.8059	.763	1.1088	.631	.7392	.7362	.7712
23	.6935	.7975	1.0269	.7164	.7316	.7087	.7842
24		.691	.9335		.6535	.695	.7545
Max	2.1914	2.0287	2.1765	2.0405	1.7924	1.8652	1.8404
Min	.6935	.5415	.8954	.631	.6241	.6653	.7545
Avg	1.3045	.9975	1.4474	1.3141	1.1320	1.1734	1.1886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134050 / JAIPUR

Feeder No / Name : 202 / WAZAR S.

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.6653	.7392	.7468	.6283	.7468	.6935
2	.6089	.6661	.7682	.8048	.6733	.7167	.695
3	.6661	.7316	.7865	.9313	.7108	.7316	.7011
4		.7964	.8859	.9536	.8573	1.4784	
5		1.0454	1.0517	.9945	1.0174	1.7551	
6		1.1963	1.3696	1.0898	1.0562	1.7353	1.1789
7		1.286	1.5432	1.278	1.4746	1.848	
8		1.3927	1.8233	1.5043	1.7901	1.7878	1.5775
9		1.2269	.9054	1.4746	1.7368	1.8378	1.6991
10	.9831						
11	1.3435						
12	1.5604						
13	1.3748						
14	1.2955						
15	1.3592						
16	1.358		.4954	.5906	.5228	.4904	.4572
17	1.3375		.5658	.6097	.6653	.7811	.5975
18	.7164	.7621		.7577	.7207	.8002	.695
19	.7392	.6859	.7011	.8316	.7095	.724	.7522
20	.695	.6097	.695	.7316	.6584	.5975	.6584
21	.631	.5544	.5601	.6447	.5601	.5487	.5487
22	.6626	.4706	.5093	.567	.5544	.5228	.503
23	.6516	.4706	.4572	.4656	.4904	.5544	.5304
24		.5975	.5601		.5138		.5765
Max	1.5604	1.3927	1.8233	1.5043	1.7901	1.848	1.6991
Min	.4915	.4706	.4572	.4656	.4904	.4904	.4572
Avg	.9691	.8223	.8481	.8810	.8522	1.0386	.7909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 203 / IDOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9088	.8573	.6516	.6859	.4801	.6001	.5316
2	.9774	.8573	.6687	.6859	.5144	.6173	.5144
3	1.0288	.8745	.703	.7716	.6173	.6173	.5316
4	1.0802						
5	1.5432						
6	1.7661						
7	2.1262						
8	2.4006						
9	2.2462						
10		1.7833	2.1776	1.2536	2.0576	.9259	1.0631
11		2.4177	2.6749	1.8861	2.3834	2.0576	
12		2.5892	2.6749	2.2119	2.7606	2.2805	2.5206
13		2.6749	2.7435	2.572	2.7435	2.1605	2.5034
14		2.5892	.2658	2.4006	2.3148	2.0748	1.3203
15		2.2291	2.4272	2.4006	2.1776	2.0576	2.1091
16	1.166	2.5034		2.2786	2.2291	2.0576	2.2119
17	1.5089	.4458	2.3491	2.332	2.1434	1.9719	2.0405
18	1.5775	.7545	1.0288	.6687	.823	.5144	.7716
19	1.3203	.9602	.9945	.6859	.7202	.5144	.823
20	1.3375	.9774	.8573	.6859	.8059	.5487	.8059
21	1.1145	.9431	.8402	.6859	.7716	.5144	.7202
22	1.046	.8402		.7373	.6687	.5316	.6859
23	.9088	.7716		.6859	.6173	.5487	.6859
24	.8573	.8402	.6859	.9259	.6001	.6173	.5144
Max	2.4006	2.6749	2.7435	2.572	2.7606	2.2805	2.5206
Min	.8573	.4458	.2658	.6687	.4801	.5144	.5144
Avg	1.3841	1.4394	1.4495	1.3641	1.4127	1.1784	1.1973

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 204 / express water supply  
INDUSTRIA Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	16-JAN-17
HR	Load (MW)
3	.0171
Max	.0171
Min	.0171
Avg	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134070 / Talni

Feeder No / Name : 201 / TALNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.3944	.5144	.3772	.3772	.3601	.3429
2	.8059	.3429	.5144	.4115	.3601	.3258	.3944
3	.8745	.3429	.5658	.5487	.4801	.4115	.4801
4	.8573						
5	.9945						
6	1.3717						
7	1.5089						
8	1.6804						
9	1.5432						
10		1.1831	1.2689	1.2174	1.2346	1.1317	1.3203
11		1.2174	1.3375	1.3203	1.3375	1.1831	1.4232
12		1.286	1.3546	1.3889	1.3203	1.286	1.5089
13		1.3375	1.3546	1.3717	1.4403	1.3717	1.4575
14		1.3546	1.2517	1.3717	1.3889	1.3546	1.3546
15		1.2003	1.2689	1.3375	1.3717	1.3032	1.2689
16	.6859	1.3032	1.3032	1.3889	1.2346	1.1317	1.2003
17	.7373	1.3889	1.4403	1.4746	1.4232	1.2174	1.2689
18	.823	.7373	.7202	.7373	.6344	.6516	.703
19	.8059	.7716	.6516	.7888	.6001	.7888	.7373
20	.703	.6687	.5658	.583	.5658	.6344	.6516
21	.6173	.583	.5316	.5658	.5658	.5487	.5144
22	.5316	.5316	.4973	.5144	.463	.4801	.4801
23	.3601	.4973	.3772	.4115	.4287	.3944	.4287
24	.7716	.3944	.4973	.3429	.463	.3772	.3944
Max	1.6804	1.3889	1.4403	1.4746	1.4403	1.3717	1.5089
Min	.3601	.3429	.3772	.3429	.3601	.3258	.3429
Avg	.9145	.8631	.8897	.8973	.8716	.8307	.8850

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 201 / pangari 11 kv

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315	.5079	.3048	.2743	.7459	.2785	.2614
2	.2915	.502	.2743	.3174	.8421	.2785	.2286
3	.2486	.5935	.2743	.3174	.9831	.285	.3963
4		.5535		.3361	.9288	.6706	.2439
5		.5935	.4572	.3475	1.1336	.6706	.2896
6		.6062	.7316	.567	1.0898	.8383	.4725
7		.6783	.884	1.2254		.9995	.823
8		.8848	.7926	1.4266	.9945	1.4243	1.1576
9		.9156	.6706	1.2254	1.0774	.9878	1.4937
10	.6062						
11	.7291						
12	.9339						
13	.8855						
14	.8987						
15	.6325						
16	.6554		.4108	.3429	.7209	.3506	.5138
17	.6443		.5788	.6371	.6718	.3963	.5138
18	.5935	.7655	.5487	.7459	.7461	.5182	.4144
19	.5256	.6908	.724	.2858		.3048	.4191
20	.2713	.5415	.5487	.3315	.3391	.3506	.3688
21	.2622	.3658	.439	.4024	.5256	.2896	.285
22	.2652	.3048	.3292		.4902	.2743	.2984
23	.2652	.1981	.2926		.4902	.2439	.3353
24	.2829	.5256		.2378	.5801	.3391	.3048
Max	.9339	.9156	.884	1.4266	1.1336	1.4243	1.4937
Min	.2486	.1981	.2743	.2378	.3391	.2439	.2286
Avg	.5180	.5767	.5163	.5638	.7725	.5278	.49

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 202 / wai

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6443	.3361	.3048	.4024	.3018	.3561	.2743
2	1.0774	.3441	.3963	.4024	.3315	.1696	.3201
3	1.2071	.6274	.442	.4207	.2458	.1696	.3506
4	1.2717						
5	1.0774						
6	1.1431						
7	1.1949						
8	1.1271						
9	1.1603						
10		.7373	.6249		1.2289	.8775	.5801
11			1.5123	1.2717	1.186	1.419	1.2574
12		1.3077	1.5364	1.358	1.2125	1.587	1.2431
13		1.3717	1.307	1.326	1.2125	1.419	1.2742
14		1.2517	1.3108	1.2574	1.382	1.4377	1.0059
15		1.3203	1.2437	1.2407	1.1227	1.1763	.9614
16	.6718		1.419	1.2717	1.3077	1.4377	1.2431
17	.6554		1.2986	1.1233	1.3395	1.251	1.2717
18	.5316	1.251	.6219	.4694	.4401	.5788	.3353
19	.5316	.7095	.6584	.2972		.4572	.2515
20	.5079	.381	.5601	.3572	.3479	.3658	.3353
21		.381	.5121	.3763	.3605	.3506	.431
22	.4973	.381	.4572		.3479	.3048	.3353
23	.4973	.3353	.4572		.3561	.2896	.3315
24	.4915	.5087	.3353	.4207	.2458	.2972	.3048
Max	1.2717	1.3717	1.5364	1.358	1.382	1.587	1.2742
Min	.4915	.3353	.3048	.2972	.2458	.1696	.2515
Avg	.8405	.7496	.8332	.7997	.7629	.7747	.6726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 202 / TOWN-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.8002	.7682	1.1145	.7621	.8383	1.0479
2	1.3336	.8002	.7682	1.2003	.7621	.8383	1.1431
3	1.2384	.8002	.8048	1.3336	.7621	.8573	1.2384
4	1.3336	.8383	.9877	1.286	.8383	.9145	1.0479
5	1.4289	.9145	1.4266	1.166	.9907	1.0288	1.1431
6	1.1241	1.3717	1.829	1.3527	1.3336	1.5623	1.3717
7	1.5432	1.9052	2.0302	1.7318		2.1338	1.829
8	2.191	2.3624	1.9022	2.3434	2.3243	2.2862	2.2291
9	2.21	2.0576	1.7375	2.1529	1.9052	2.21	1.9243
10	2.0576	1.6827	1.5623	1.7528	1.8671	1.9052	1.6278
11	1.7528	1.4815	1.5623	1.4861	1.6766	1.7718	1.4998
12	1.3717	1.3535	1.4289	1.5623	1.4861	1.6194	1.2803
13	1.4098	1.2803	1.3717	1.3717	1.2955	1.2574	1.2803
14	1.2193	1.1706	1.1812	1.2384	1.2193	1.3146	1.262
15	1.1812	1.0791	1.2384	1.2193	1.1431	1.1431	1.2437
16	1.3717		1.1812	1.4098	1.2384	1.1622	1.3169
17	1.6575		1.4098	1.5242	1.4098	1.3146	1.3535
18	1.6575	1.8473	1.7718	1.6766	1.6385	1.6766	1.5729
19	1.6766		1.9052	1.8861	1.8671	1.848	1.7741
20	1.448	1.6278	1.6004	1.5623	1.6004	1.6004	1.4266
21	1.2574	1.262	1.3336	1.3336	1.3336	1.2765	1.2071
22	1.0669		1.086	1.1431	1.1431	1.086	
23	.8573			.9145	.9145	.8573	
24		.8002	.7682		.8002	.8383	.7621
Max	2.21	2.3624	2.0302	2.3434	2.3243	2.2862	2.2291
Min	.8573	.8002	.7682	.9145	.7621	.8383	.7621
Avg	1.4579	1.3387	1.3763	1.4679	1.3179	1.3892	1.3901



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 203 / SAIBABA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	1.5432	1.7909	2.0576	1.9719	1.9204	1.7147
2	1.9052	1.5432	1.7909	1.5432	1.9719	1.9204	1.8861
3	1.5242	1.5432	1.7909	1.6289	1.9719	1.9204	1.9204
4	1.5242	1.6118	2.2207	1.7147	2.0748	1.9719	1.9719
5	1.8099	1.6975	2.5431	2.4006	2.2291	2.2977	2.0576
6	2.4387	2.4006	2.8296		2.4691	2.7435	
7	2.1434	2.7092	3.2594	3.275		3.0521	2.7263
8	.463	1.3717	1.1104	.4458	.8916	2.1605	3.3093
9	1.7833	2.6749	1.0425	2.6235	.9431	2.6063	.7202
10	2.1605	2.6147	.8192	2.4691	.8573	2.4006	.9492
11	2.0576	2.5252	1.7661	2.0233	.8573	2.3663	.9313
12	1.4575		.724	1.1431		.6859	.1715
13	1.8004	1.0288	.6478	.5716			.4191
14	.9602	.724	.5906	.6478			.8764
15	.9774	.5906	.5525	.6668	1.7528		.9145
16	1.0117		.724	.6478	1.7909		1.0669
17	.7202		.8383	1.3336	1.8671	1.086	1.2003
18	.8573	.2477	2.3434	2.4768	2.4768	2.5339	2.1338
19	2.4691	.6097	2.7816	2.553	2.8578	2.4768	2.7816
20	2.0576	1.829		2.191	2.4768		2.3624
21	1.9052	1.7147		2.0957	2.0957	1.9814	2.0195
22	1.7909		2.0576	1.9052	1.5242	1.6575	
23	1.5623			1.7718	1.448	1.5242	
24		1.5432	1.7909		1.9547	1.7833	1.5089
Max	2.4691	2.7092	3.2594	3.275	2.8578	3.0521	3.3093
Min	.463	.2477	.5525	.4458	.8573	.6859	.1715
Avg	1.6294	1.6065	1.6197	1.7357	1.8241	2.0573	1.6020

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 204 / KAWAJAWALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.3048	.3048	.381	.3429	.3429	.381
2	1.0288	.3048	.3048	.3772	.3429	.3429	.381
3	.8573	.3048	.3048	.362	.3429	.3429	.3429
4		.381	.3429	.3086	.381	.381	.381
5	1.0288	.4572	.381	.381	.4763	.4572	.4763
6	1.1317	.5716	.4572	.5525	.5716	.6097	.5525
7	1.3546	.4763	.5525	.6097		.6859	.6287
8	1.9204	.381	.5335	.6478	.6668	.6478	.6478
9	1.6804	.2858	.5144	.5716	.5335	.5716	.5906
10	.4572	1.7909	1.6632	1.9204	1.7147	.1372	1.8267
11	.2858	2.0953	2.2977	2.3148	2.2634	.1972	2.0416
12	.2858	2.1132	2.3148	2.4691	2.332	.216	2.1132
13	.2858	2.167	.2229	2.4691	2.1262	2.0576	2.0774
14	.2477	2.2565	.2332	2.4006	2.2291	1.9719	2.0595
15	.1905	2.2923	2.332	2.332	2.0233	2.0576	2.0416
16	.2096		2.2119	2.1776	2.0576	.1989	2.0595
17	.2667		.2229	2.1262	2.0919	2.0233	2.0416
18	.4382	.4191	.4001	.4382	.4001	.4001	.3429
19	.4763	.4954	.5144	.5335	.5144	.5144	.5144
20	.4382	.4572	.4191	.4191	.4763	.4572	.4191
21	.4001	.381	.381	.4001	.4191	.381	.381
22	.362		.3239	.4001	.362	.3429	
23	.3239			.3429	.3429	.2858	
24		.3048	.3048		.3429	.3429	.2858
Max	1.9204	2.2923	2.332	2.4691	2.332	2.0576	2.1132
Min	.1905	.2858	.2229	.3086	.3429	.1372	.2858
Avg	.6642	.912	.7625	1.0841	1.0154	.6652	1.0266

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 205 / ANANDWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	1.6118	1.7013	1.7147	1.8861	1.749	1.2003
2	.6668	1.6118	1.7013	1.5432	1.8861	1.749	1.3717
3	.7621	1.6118	1.7013	1.6289	1.8861	1.749	1.3717
4	.7621	1.6289	1.7551	1.4575	1.9204	1.8176	1.286
5	.8002	1.6804	1.8983	1.6289	2.0233	2.0405	1.5432
6	.8002	1.8176	2.4714	1.8519	2.0576	2.2977	1.6975
7	.8002	2.6578	2.7042	2.2634		2.8807	2.0576
8	1.2765	3.2579	3.1878	2.9492	3.2922	3.3608	2.572
9	1.1622	3.2236	2.9012	3.0178	3.3951	2.6406	3.0178
10	1.8861	.8002	1.0098	1.105	.9907		.9526
11	2.9835	.6478	.8764	.9145	1.105		.9145
12			.9717		1.0479		.8954
13	1.0288			.8002	.9907		.8383
14	2.0233	.8002		1.0288	.9526	.6478	.8002
15	2.1262	.7811		.9907	1.1431	.9717	1.1241
16	2.1434		.9335	1.1431	1.105	1.086	1.0669
17	1.9204		.9907	1.1812	1.086	1.1812	1.0288
18	1.1431	1.3527	1.2955	1.2193	1.1812	1.3717	1.2574
19	1.1812	1.448	1.3146	1.3717	1.105	1.3146	1.4098
20	1.105	1.2765	1.1241	1.105	.9907	1.105	1.2574
21	1.0288	1.1812	1.086	.9526	.8764	1.105	1.086
22	.9145		.9526	.9145	.9145	.9907	
23	.8573			.8383	.8002	.8764	
24		1.6118	1.7013		1.869	1.7147	1.166
Max	2.9835	3.2579	3.1878	3.0178	3.3951	3.3608	3.0178
Min	.6668	.6478	.8764	.8002	.8002	.6478	.8002
Avg	1.2788	1.6112	1.6139	1.4373	1.5002	1.6325	1.3598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 207 / 11 KV AMBA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573						
3	1.1145						
4	1.0631						
5	1.2003						
6	1.4232						
7	1.6118						
8	2.3834						
9	1.2174						
10				1.3375	1.3717	1.2193	1.2536
11		1.182		1.6804	1.7833	1.4746	1.2894
12		1.2357	1.3032	2.0062	1.9719	.1783	1.8804
13		1.2894	1.3203	2.0576	1.9204	.1852	1.8625
14			.1406	1.9547	1.7833	1.7147	1.8446
15			1.4232		1.9204	1.8176	1.8625
16			1.869	1.7833	1.8861	1.8004	1.8088
17			.1852	1.8861	1.7833		1.7909
Max	2.3834	1.2894	1.869	2.0576	1.9719	1.8176	1.8804
Min	.8573	1.182	.1406	1.3375	1.3717	.1783	1.2536
Avg	1.3589	1.2357	1.0403	1.8151	1.8026	1.1986	1.6991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 208 / 11KV water supply express SHEDDABLE RURAL  
feed Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.0351	.0191	.0343	.0171	.0191
2		.0514	.0351		.0343	.0343	.0191
3		.0514			.0343	.0343	.0191
4		.0514	.0351		.0343	.0343	.0191
5	.0572	.0514	.0526		.0343	.0343	.0191
6	.0381	.0514	.0526	.0191	.0343	.0343	.0381
7	.0381	.0514	.0526	.0381		.0686	.0381
8	.0572	.0514	.0526	.0953	.12	.12	.0191
9	.1524	.1372	.1402	.0191	.1372	.12	.0191
10	.1543	.1227	.1715	.1372	.12		.1402
11	.1543	.1227	.1334	.1372	.12	.0572	.1402
12	.1372	.1227	.1524	.1372	.12		.0526
13	.1372	.1227	.1143	.1372	.1372	.0572	.0526
14	.1372	.0351	.0381	.12	.0171	.0953	.1052
15	.1372	.0175	.0381	.12		.0572	.1052
16	.1372		.0572	.12	.0171	.1143	.0876
17	.0686		.0381	.12	.0171	.0191	.0526
18	.0343	.1402		.0171	.0171	.0191	.1052
19	.0514	.0351	.0953	.0343	.0343	.0381	.1227
20	.0514	.0351	.0381	.0343	.0343	.0381	.1227
21	.0514	.0351	.0381	.0343	.0343	.0381	.1227
22	.0514		.0381	.0514	.0343	.0381	
23	.0514			.0343	.0343	.0381	
24		.0514	.0351		.0343	.0343	.0381
Max	.1543	.1402	.1715	.1372	.1372	.12	.1402
Min	.0343	.0175	.0351	.0171	.0171	.0171	.0191
Avg	.0893	.0694	.0687	.0750	.0561	.0519	.0663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 201 / ASHATI TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2572	.2572	.3601	.3429	.3086	.2743
2	.3601	.3086	.2743	.3772	.3429	.3086	.3086
3	.4115	.2915	.4287	.4115	.3429	.3429	.3429
4	.4801	.4458	.5487	.5144	.4287	.4458	.4287
5	.6516	.6001	.6859	.6344	.6859	.583	.5658
6	.823	.823	.7888	.8916	.8916	.7888	.7716
7	.9945	1.0288	1.0288	1.0802	1.0288	.9431	.9602
8	.9774	1.1317	1.0631		1.1145	1.0288	1.046
9	.8573	.9945	.9945	1.0631	.9602	1.0117	.9431
10	.8916	.8916	.8916	.8573	.7888	.823	.7888
11	.9259	.6859	.7202	.823	.6859	.8402	.6173
12	.5658			.6687	.583	.6516	.5487
13				.583	.5316	.6344	.4973
14	.5144	.5144		.5487	.463	.6001	.5658
15	.6173	.6001	.6859	.5144	.5144	.4801	.463
16	.6344	.7202	.7202	.5144	.5487	.5658	.4973
17	.7888	.8059	.7545	.7545	.6859	.7716	.7202
18	.8573	.8573	.8402	.8573	.7888	.8573	.8573
19	.8059	.823	.7545	.9088		.823	.9088
20	.7202	.6344	.4801	.6516	.7716	.7716	.6687
21	.5144	.5658	.583	.583	.583	.5487	.583
22	.4801	.5144	.3772	.463	.4801	.4458	.5144
23	.4287	.3772	.3772	.3772	.3601	.4115	.3944
24	.3086	.3086	.3429	.3258	.3429	.0326	.3086
Max	.9945	1.1317	1.0631	1.0802	1.1145	1.0288	1.046
Min	.3086	.2572	.2572	.3258	.3429	.0326	.2743
Avg	.6501	.6445	.6475	.6419	.6203	.6258	.6073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 202 / KARALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6859	1.2193	1.166	1.1888	1.0974	.9907
2	.7545	.7926	1.2498	1.1279	1.1584	1.1584	1.0974
3	.823	.8383	1.3717	1.2193	1.2041	1.2193	1.2193
4	.8573	.945	1.4937	1.4022	1.2955	1.3413	1.448
5	.8916	1.1431	1.6004	1.5546	1.3413	1.4022	1.4937
6	.9945	1.2193	1.829	1.7223	1.7071	1.6766	1.7528
7	1.0288	1.5242	2.2862	2.2405	2.0576	2.2805	2.1338
8	.8916	1.6004	2.4387	2.6673	2.3777	2.4387	2.5301
9	.8573	1.7528	2.2558	2.3777	2.3777	1.2193	1.9814
10	1.829	.8573	.7545	.7888	.6097	.9431	.7716
11	2.2862	.4973	.8573	.6001	.5658	.5658	.6344
12	1.9814		.6859	.6516	.4287	.4287	.5316
13	1.9814		.6344	.5316	.4458	.4458	.5144
14	2.3167		.4973	.5316	.4801	.4287	.5144
15	2.3472		.5487		.5144	.4973	.6001
16	2.3167		.6687	.7545	.5658	.6344	.6859
17	1.3717	.823	.8059	.7888	.8402	.8059	.8402
18	.9431	1.0288	1.0631	1.166	1.0631	.8573	1.0288
19	1.1145	1.1145	1.2174	1.1317	1.0117	1.166	1.1145
20	1.0631	1.166	1.1145	1.0631	.9602	1.1145	1.0288
21	1.0288	1.1317		.9774	.8573	.9774	.9945
22	.9945	1.0288	.9259	.9088	.823	.8916	.8573
23	.8573	.7545	.8916	.823	.7716	.823	.7373
24	.6859	.6859	1.1431	.9259	1.1431	1.0059	.9145
Max	2.3472	1.7528	2.4387	2.6673	2.3777	2.4387	2.5301
Min	.6859	.4973	.4973	.5316	.4287	.4287	.5144
Avg	1.2904	1.0310	1.1980	1.1792	1.0745	1.0591	1.1006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 203 / WAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	1.0669	1.2955	1.1888	1.0669	.9907	.823
2	1.0631	1.0974	1.4022	1.3413	1.3108	1.0974	.8993
3	1.166	1.2955	1.4937	1.3717	1.4937	1.2193	1.0059
4	1.2003	1.3717	1.6766	1.5242	1.7071		1.0669
5	1.2346	1.5089	1.7985	1.7223	1.829		1.4327
6	1.1888	1.829	1.9052	2.0729	2.0119		1.9814
7	1.2193	2.4387	2.5911	2.8045	2.2405		2.21
8	1.1431	2.7435	2.8959	3.0178	2.4387		2.6673
9	1.0288	2.5911	3.2236		2.2558		2.2862
10	1.9052	.9431	1.0288		.9088	1.768	.8916
11	2.5911	.7716	.7202		.7202	1.6766	.6859
12	2.2862	.6859	.6001		.7888		.6173
13	2.2862	.6516	.6001		.6859	.6859	.6001
14	3.1245	.5487	.5316		.5487	.6344	.5316
15	2.8959	.5144	.6516		.6001	.6859	.6516
16	1.8576	.7202	.7545	.9945	.7545	.7716	.7202
17	1.5242	.8573	.8573	.9774	.8573	.7716	.7545
18	1.0288	1.0802	1.1317	.9602	.7202	.8573	.8573
19	1.1145	1.1145	1.2003	1.0631	.9945	1.1145	1.046
20	1.0288	1.166	.9945	.9602	.8916	1.0288	.9945
21	.9945	1.0288	1.166	.7545	.7716	.9431	.8916
22	.9431	.8916	.9945	.7716	.7545	.823	.8573
23	.8573	.7716	.9259	.703	.7202	.7202	.7716
24	.8402	.9907	1.1736	.9945	.8535	.8535	.7621
Max	3.1245	2.7435	3.2236	3.0178	2.4387	1.768	2.6673
Min	.8402	.5144	.5316	.703	.5487	.6344	.5316
Avg	1.4799	1.1950	1.3172	1.3660	1.1635	.9789	1.0836



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 204 / WATER SUPPLY FEEDER  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	18-JAN-17	19-JAN-17
HR	Load (MW)	Load (MW)
11		.0857
15		.0762
16		.0762
17	.0762	
18	.0762	.0762
19	.0953	.0572
22	.0953	
23	.0762	
Max	.0953	.0857
Min	.0762	.0572
Avg	.0838	.0743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 205 / RAIGWAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.884	.3772	.3772	.4801	.4458	.4287	.3429
2	1.166	.4287	.4287	.4973	.4458	.4287	.4287
3	1.1888	.5144	.6516	.5487	.4287	.463	.5316
4	1.2041	.7716	.7888	.6516	.4458	.5487	.6859
5	1.3413	.9259	.9945	.7716	.4973	.6516	.8059
6	1.4327	1.1145	1.1145	1.0802	.7888	1.0631	.9945
7	1.5089	1.0631	.9431	1.166	1.166	1.046	1.1145
8	2.0271	.9259	.6859	.6344	1.1317	1.0117	.703
9	1.7528	.7716	.8916	.5487	.8916	.7716	.9259
10	.7545	1.2955	1.4632	1.2803	1.3413	1.0364	1.4327
11	.5658	1.4937	2.2862	1.5699	2.1491	1.6004	1.9814
12		1.6004	2.3472	1.3108	2.1948	1.6918	2.2862
13		1.5546	2.3472	1.7223	2.1338	1.6613	2.2405
14	.4287	1.6766	2.4844	1.5394	2.0729	1.6766	2.21
15	.4458	1.6766	2.6063	1.7375	2.0424	1.448	2.1338
16	.4287	1.6004	2.2862	1.7071	2.1186	1.5242	2.1643
17	.5658	1.3717	2.21	1.6918	1.6613	1.4022	2.1491
18	.7716	.7202	.7888	.6859	.6687	.5487	.6173
19	.8573	.7716	.7202	.9259	.823	.823	.8573
20	.7716	.6859	.5316	.7716	.6173	.7716	.6859
21	.6173	.6516	.6001	.6173	.5658	.6173	.6001
22	.5487	.6001	.5316	.5144	.5144	.5487	.5487
23	.5144	.4458	.4458	.4458	.463	.5144	.3429
24	.823	.463	.4287	.4115	.4458	.4458	.4287
Max	2.0271	1.6766	2.6063	1.7375	2.1948	1.6918	2.2862
Min	.4287	.3772	.3772	.4115	.4287	.4287	.3429
Avg	.9363	.9792	1.2064	.9713	1.0856	.9468	1.1338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 201 / MAPEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.3353	.3521	.3521	.3856		.3688
2	.5868	.3688	.4694	.3521	.3856	.503	.3688
3	.5868	.4024	.503	.3521	.3856		.3688
4	.6539	.4694	.5365	.4191	.4191	.6706	.3856
5	.6874	.5868	.6036	.5197	.57	.8383	.4191
6	.8215	.6706	.9221	.6036	.6371	.8383	.4862
7	.8718	.7042		.7377	.7545	.9221	.57
8	1.1401	.6706	.9556	.8718	.5197	.8886	
9	1.0227	.5197	.788	.7209	.57	.7545	.7209
10	.5197	.4191	.8718	.9724	.788	.788	.8048
11	.3688	1.1065	1.3413	1.1904	.8886	1.0898	1.0395
12	.4024	1.1736	1.3245	1.2574	1.0059	1.1568	1.1065
13	.4024	1.291	1.358	1.2742	.9724	1.1401	1.291
14	.3856	1.2742	1.3916	1.3077	.9054	1.1233	1.2071
15	.4191	1.2574	1.4083	1.3413	.8383	1.1401	1.2574
16	.4024	1.2742	1.4922	1.3413	.8886	1.1233	1.2407
17	.4359	1.3077	1.3748	1.3077	.9221	1.0227	1.2071
18	.5365	.503	.4694	.4862	.4862	.5197	.4694
19	.4527	.6706	.57	.6036	.5868	.6874	.5868
20	.5365	.503	.6371	.5197	.5533	.57	.5533
21	.3688	.4024	.5365	.4694	.4024	.5197	.503
22	.3353	.3521	.4024	.4191	.3688	.4024	.4191
23	.3018	.3521	.3856	.3856	.3688	.3688	.3688
24	.57	.3185	.3018	.3521	.3856	.3521	1.291
Max	1.1401	1.3077	1.4922	1.3413	1.0059	1.1568	1.291
Min	.3018	.3185	.3018	.3521	.3688	.3521	.3688
Avg	.5582	.7056	.8259	.7566	.6245	.7918	.7406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 202 / SATONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.4359	.3856	.3688	.3856		.3521
2	.3353	.4694	.503	.3688	.3856		.3018
3	.3688	.4359	.5868	.3856	.4191	.5868	.3521
4	.4191	.3856	.6706	.4359	.4862	.8383	.4191
5	.5197	.4024	.9221	.57	.6203	1.0059	.6203
6	.6203	.6371	.9556	.7209	.8215	1.073	.8215
7	.6539	.7042	1.0898	.8718	1.0395		.9724
8	.7377	.503	.9221	.8551	.8886		
9	.7545	1.073	1.0898	.7712	.9724	1.1401	.8383
10	.7545	.6371	.5868	.7377	.5868	.7377	.6706
11	.6706	.7377	.7042	.7545	.7377	.788	.7377
12	.7545	.8383	.7209	.7545	.8383	.8048	.8383
13	.788	.6874	.7377	.7209	.8551	.7545	.7042
14	.7042	.7209	.7042	.7209	.7545	.7209	.6706
15	.6706	.6539	.6371	.7042	.7209	.7209	.7209
16	.7209	.7209	.6874	.6874	.7545	.6874	.7545
17	.788	.7377	.6706	.6874	.8048	.7545	.7042
18	.8048		.5197	.8215	.7042	.8886	.7377
19	.7545	.9054	.6203	.9724	1.0395	.9892	.9724
20	.6706	.7545	.6539	.7042	.7209	.8048	.9221
21	.6203	.6371	.5533	.57	.503	.6874	.6371
22	.503	.503	.4694	.4862	.4694	.5197	.4694
23	.4191	.4191	.4191	.4359	.4191	.3856	.4191
24	.3353	.3688	.4024	.3688	.3856	.3856	.3856
Max	.8048	1.073	1.0898	.9724	1.0395	1.1401	.9724
Min	.3353	.3688	.3856	.3688	.3856	.3856	.3018
Avg	.6126	.6247	.6755	.6448	.6797	.7637	.6531

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 203 / SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	1.2071	1.0059	.9389	1.0227		.9389
2	.3856	1.2574	1.1568	.9556	1.0227		.9389
3	.3856	1.2407	1.1736	1.0227	1.0395	.9054	.9724
4	.4191	1.2574	1.1736	1.1904	1.1904	.9221	.9892
5	.4862	1.3413	1.2071	1.2407	1.2742	.9221	1.1401
6	.6036	1.3748	1.2407	1.358	1.4083	.9389	1.2742
7	.6706	1.4922		1.861	1.643	1.5089	1.4922
8	.7545	2.0957	1.9951	2.2466	2.079	1.8945	
9	.6036	2.079	2.0119	2.1293	2.079	2.0119	1.4754
10	1.6095	.503	.3688	.3521	.4191	.5365	.4862
11	2.1293	.2515	.1677	.2515	.3353	.3856	.3856
12	2.2131	.2012	.2012	.2012	.2012	.2515	.3353
13	2.2969	.2347	.1844	.1509	.1677	.2012	.1844
14	2.2466	.2347	.1677	.1844	.1174	.1677	.1677
15	2.1795	.2515	.1677	.2012	.1341	.1844	.1844
16	2.1125	.2012	.2012	.218	.2347	.218	.3353
17	2.0454	.3353	.2515	.2515	.4191	.285	.2515
18	.3018	.4359	.3688	.3688	.3688	.57	.4191
19	.3688	.6371	.6036	.7712	.7377	.6706	.5868
20	.4359	.6203	.6371	.6203	.7209	.6371	.5365
21	.4694	.503	.5197	.5197	.4191	.5868	.503
22	.4191	.4359	.4359	.4694	.3353	.5197	.4191
23	.3688	.4024	.4024	.4024	.4359	.4191	.3688
24	.3856	1.0395	1.8442	.9054	.9724	.9054	.8718
Max	2.2969	2.0957	2.0119	2.2466	2.079	2.0119	1.4922
Min	.3018	.2012	.1677	.1509	.1174	.1677	.1677
Avg	1.0115	.8180	.7603	.7838	.7824	.7110	.6633

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 205 / DEVLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.2515	.2012	.2012	.1844	.2012	.2012
2	.0671	.285	.2347	.2012	.2012	.503	.2012
3	.0678	.3185	.2347	.2012	.218	.2347	.2012
4	.0838	.3018	.3018	.2515	.2515	.2515	.2515
5	.1341	.3521	.3018	.3018	.285	.2683	.3018
6	.1844	.3353	.3018	.3018	.3018	.2683	.3353
7	.2012	.3688	.4024	.3353	.3521	.2012	.3856
8	.2347	.4024	.4191	.3688	.4024	.4694	.3856
9	.1844	.4191	.3856	.3521	.3856	.503	.4191
10	.3018	.1006	.0838	.0838	.0335	.1006	.1174
11	.2012	.0838	.0838	.0671	.0335	.0838	.0503
12	.3018	.0671	.0671	.0671	.0503	.0838	.0838
13	.3688	.0671	.0671	.0503	.0503	.0503	.0838
14	.4191	.0503	.0503	.0503	.0503	.0503	.0671
15	.4024	.0503	.0503	.0503	.0503	.0503	.0671
16	.4191	.0503	.0671	.0503	.0838	.0503	.1006
17	.4359	.1341	.0838	.0838	.2347	.0838	.1341
18	.1677	.1174	.1006	.1341	.2347	.1509	.0671
19	.2012	.1677	.1341	.1677	.1677	.1844	.1677
20	.218	.1174	.0848	.1341	.0838	.1509	.1174
21	.2347	.0838	.0838	.0838	.0671	.1174	.0838
22	.1006	.0671	.0678	.0671	.0503	.0838	.0671
23	.0671	.0503	.0503	.0671	.0503	.0671	.0671
24	.0671	.2012	.2012	.1677	.1844	.1844	.1844
Max	.4359	.4191	.4191	.3688	.4024	.503	.4191
Min	.0671	.0503	.0503	.0503	.0335	.0503	.0503
Avg	.2138	.1851	.1691	.1600	.1670	.1830	.1726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 207 / Express Kedarwakdi  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174	.1174	.0838	.0838	.1174		.1341
2	.1174	.1341	.1006	.0838	.1174	.1509	.1341
3	.1187	.1677	.1006	.0838	.1174	.1677	.1509
4	.1341	.1677	.0838	.0838	.1341	.2347	.1509
5	.1865	.1526	.0838	.1006	.1677	.2515	.1677
6	.218	.1341	.0838	.1006	.1844	.2683	.1341
7	.2347	.1174	.1006	.1006	.2012	.2012	.1006
8	.1844	.0838	.0838	.1006	.0838	.0838	.0838
9	.1006	.0838	.0838	.1006	.1006	.0838	.0838
10	.1006	.0838	.1006	.1006	.0838	.0838	.0838
11	.0838	.0838	.0838	.1006	.1006	.0838	.0838
12	.1006	.1006	.0838	.1006	.0838	.0838	.1006
13	.1174	.1174	.0838	.1006	.1006	.0838	.1006
14	.1174	.1174	.1006	.0838	.0838	.0838	.0838
15	.1006	.1174	.1006	.0838	.0671	.0838	.1006
16	.1174	.1006	.1006	.0838	.0838	.0838	.1174
17	.1341	.1174	.1006	.0838	.1006	.0838	.1174
18	.1006	.1006	.0838	.0838	.1006	.1006	.1006
19	.1174	.0838	.0838	.0838	.1006	.1006	.1174
20	.1006	.0838	.0838	.1006	.2012	.1006	.1174
21	.0838	.1006	.0838	.1006	.218	.1187	.2347
22	.0838	.1174	.0838	.1174	.0838	.1174	.1677
23	.0838	.0838		.1174	.1509	.1174	.1174
24	.1174	.1006	.1006	.0838	.1174	.1341	.1341
Max	.2347	.1677	.1006	.1174	.218	.2683	.2347
Min	.0838	.0838	.0838	.0838	.0671	.0838	.0838
Avg	.1238	.1112	.0904	.0943	.1209	.1262	.1216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 201 / SHRISHTI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7926						
5	.884						
6	.9145						
7	.9297						
8	1.0517						
9	1.0822						
16		1.5432	1.1736	1.4918	1.1888	1.0059	1.1431
17		1.5432	1.326	1.4575	1.2498	.9907	1.2193
18		1.286	1.2346	1.3717	1.2955	1.1279	1.2193
19		1.1145	1.0669	.8573	1.0669	.884	1.1736
20		1.1145	1.0517	.8573	.9145	.8383	1.1431
21		.7716	1.0212	.7716		.7621	1.1279
Max	1.0822	1.5432	1.326	1.4918	1.2955	1.1279	1.2193
Min	.7926	.7716	1.0212	.7716	.9145	.7621	1.1279
Avg	.9425	1.2288	1.1457	1.1345	1.1431	.9348	1.1711



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 202 / PATODA Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1431	1.0288	1.3565	1.2003	1.1888	1.0669
2		1.2193	1.0288	1.3717	1.2003	1.1888	1.0669
3		1.2498	.9945	1.3717	1.2346	1.2193	1.1431
4		1.3108	.9945	1.3717	1.2003	1.3717	1.1431
5		1.2803	1.0288	1.4937	1.2346	1.4022	1.1888
6		1.3717	1.0631	1.5699	1.2346	1.3717	1.2193
7		1.4022	1.2346	1.6461	1.3546	1.448	1.2193
8		1.4022	1.406	1.6309	1.5775	1.4937	1.2803
9		1.3717	1.4746	1.6918	1.5947	1.4632	1.326
10	1.2193						
11	1.4937						
12	1.5699						
13	1.5546						
14	1.6004						
15	1.6156						
16	1.5851						
17	.9907						
24		1.1584	.945		.8573	1.2193	.9907
Max	1.6156	1.4022	1.4746	1.6918	1.5947	1.4937	1.326
Min	.9907	1.1431	.945	1.3565	.8573	1.1888	.9907
Avg	1.4537	1.2910	1.1199	1.5004	1.2689	1.3367	1.1644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 203 / DATHANA Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3429	.2572	.3429	.1715	.3048	.3429
2	.381	.381	.2229	.3429	.1715	.2667	.381
3	.4382	.4763	.2058	.362	.2401	.3048	.362
4	.4763	.6668		.4954	.3429	.3429	.4191
5	.6478	.7621	.4287	.6668	.5144	.4763	.4763
6	.6287	.8002	.6859	.6668	.6859	.5716	.5716
7	.6668	.8002	.7202	.6859	.7202	.7621	.724
8	.6287	.7621	.6516		.6859	.7621	.7049
9	.6668	.6478	.5487	.5906	.5144	.6668	.6478
10	.4763	.5716	.3429	.5906	.4763	.6097	.4763
11	.3429	.3429	.2858	.2401	.2667	.4191	.2477
12	.3429	.2229		.1886	.2286	.4191	.2477
13				.1715		.3429	.2286
14				.1715		.1715	.2477
15	.2286	.1886	.1715	.1715		.1715	.2286
16	.2477	.2058	.2477	.2058	.3048	.1715	.2667
17	.2286	.2572	.2858	.2401	.381	.2286	.3048
18	.4763	.3772	.4191	.3772	.4382	.4382	.4572
19	.4954	.5144	.5525	.5144	.5716	.5716	.5144
20	.4572	.5144	.4954	.4287	.4763	.4763	.5525
21	.381	.3429	.5525	.3429	.4763	.381	.4763
22	.3429	.2915	.362	.2572	.362	.3429	.362
23	.3429	.2572	.3239	.2229	.3429	.362	.3429
24		.3048	.3048		.2058	.3429	.362
Max	.6668	.8002	.7202	.6859	.7202	.7621	.724
Min	.2286	.1886	.1715	.1715	.1715	.1715	.2286
Avg	.4409	.4559	.4032	.3762	.4084	.4128	.4144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 204 / YENORA Gao

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.1715	.1715	.1715	.1543	.1715	.1715
2	.2743	.1715	.1715	.1715	.1543	.1886	.2058
3	.2743	.2572	.1715	.1715	.1715	.1715	.1886
4	.2915	.3429	.2572	.2401	.2572	.2572	.2401
5	.3086	.4458	.3429	.3258	.3429	.3429	.3429
6	.3601	.7202	.5144	.3944	.4287	.3772	.4115
7	.3429	.4801	.4801	.4287	.4458	.4287	.4287
8	.2572	.4458	.4458		.5144	.4801	.4115
9	.2743	.3772	.3601	.3944	.4287	.3086	.3429
10	.2667	.3429	.2401	.3772	.3086	.3086	.2572
11	.2058	.2229	.1372	.1715		.2401	.1886
12	.2058	.1715		.1372	.2058	.2058	.12
13				.1715	.1715	.1715	.12
14				.1372	.1372	.1029	.1372
15	.1372		.12	.1372	.1029	.12	
16	.1372	.1715	.1886	.1715	.1372	.1372	.1543
17	.1715	.1715	.2229	.2058	.1715	.1715	.1715
18	.3429	.2572	.3086	.2743	.2743	.2915	.2229
19	.3086	.3429	.3258	.3772	.3429	.3429	.2743
20	.2401	.3429	.3429	.3086	.4801	.2572	.3772
21	.2058	.2572	.3086	.2058	.3429	.2058	.3944
22	.2058	.2229	.1715	.1715	.3086	.1715	.3258
23	.1886	.1715	.1715	.1715	.2572	.1715	.3258
24		.1715	.1715	.1715	.1715	.1715	.2915
Max	.3601	.7202	.5144	.4287	.5144	.4801	.4287
Min	.1372	.1715	.12	.1372	.1029	.1029	.12
Avg	.2511	.2980	.2678	.2386	.2743	.2415	.2654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 205 / Ashti Water Supply  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0171				.0191
2			.0171				.0191
3			.0171	.0191			.0191
4			.0171	.0191			.0191
5	.0191		.0171				.0191
6			.0171	.0191		.0191	.0191
7	.0191		.0171			.0191	.0191
8			.0171				.0191
9	.0191	.0191	.0171				.0191
10	.0191	.0191	.0171		.0191		
11	.0191	.0171		.0171	.0191		
12	.0191	.0171		.0171	.0191	.0191	
13	.0191	.0171			.0191	.0191	
14	.0191				.0191	.0191	
15	.0191			.0171	.0191	.0191	
16	.0191	.0171		.0171	.0191	.0191	
17		.0171		.0171	.0191	.0191	
18	.0191			.0171	.0191	.0191	
19	.0191	.0171	.0191		.0191	.0191	
20	.0191	.0171				.0191	
21	.0191	.0171	.0191			.0191	
22	.0191					.0191	
23	.0191					.0191	
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0171	.0171	.0171	.0191	.0191	.0191
Avg	.0191	.0175	.0174	.0178	.0191	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION

Feeder No / Name : 201 / LONI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	1.0898	.5335	1.4089	1.2955	.5792	.6226
2	.3239	1.1012	.7164	1.3889	1.3426	.5792	.6401
3	.381	1.2574	.7343	1.5203	1.3748	.7116	.6401
4	.4763	1.4413	1.1544	1.6194	1.4089	.8802	.763
5	.5144	1.442	1.2651	1.7394	1.5089	1.0082	.8288
6	.4763	1.4918	1.7869	1.9281	1.5384	1.1873	.8356
7	.5144	1.6766	.2	1.6857	1.6766	1.3441	.7926
8	.2858	1.7814	2.0729	2.1792	1.9433	.0533	.9181
9	.5144	1.8138	.192	1.9814	2.1548	.0442	
10	1.6004	.1524	1.0277	.1334	.1905	.1143	.1143
11	2.4034	.1143			.0953		
12	2.3472	.0762			.0953		
13	2.4366				.0953	.1334	
14	2.5149				.0953	.1334	.1524
15	2.4813				.0953	.1334	.1524
16	2.3158				.1334	.1334	.1334
17	1.4575				.1143	.1334	.1524
18	.0762	.4382	.2477	.2286	.2286	.1334	.1715
19	.3048	.4763	.381	.3048	.4001	.4382	.3048
20	.3353	.4763	.4763	.3858	.4763	.2858	.2858
21	.2932	.381	.381	.3086	.4954	.2667	.2667
22	.2846	.362	.362	.2812	.4954	.2286	.2858
23	.2881	.3239	.3429	.2343	.4763	.2667	.2667
24	.3048	.0351		1.2193	.0457		.5801
Max	2.5149	1.8138	2.0729	2.1792	2.1548	1.3441	.9181
Min	.0762	.0351	.192	.1334	.0457	.0442	.1143
Avg	.9681	.8385	.7421	1.0910	.7407	.4185	.4454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION

Feeder No / Name : 202 / CHANGATPURI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.381	.381	.381	.5716	.4763	.5335
2	.6554	.381	.381	.4954	.7049	.4763	.5716
3	.6019	.5144	.5144		.8383	.4191	.6097
4	.703	.6668	.6668	.724	.9145	.6097	.724
5	.8535	.7621	.7621	.7621	.9526	.8192	.8573
6	.9448	.8573	.9526	.8573	1.0479	.9526	.9526
7	.8951	.8573	1.0098	1.0288	1.1431	.9907	1.0288
8		1.0479	1.0098	.9526	1.0479	.9145	.9907
9		.8002	.9335	.9526	.7621	.8573	.8002
10		.7712		.8642	.8583	.9503	.9667
11	.4191	1.0235	.8993	1.1336	1.085	1.0936	1.0212
12	.4382	1.2483	1.0402	1.2146	1.1233	1.1069	1.1736
13	.362	1.2334	1.2811	1.2186	.1123	.9297	1.0526
14	.2858	1.2163	1.2498	1.2651	.0957	1.094	.9646
15	.3429	1.3527	1.0822	1.2651	.0991	1.3336	1.3336
16	.381	1.1544	1.1888	1.2186	1.1683	1.3108	1.2003
17	.381	.1136	1.2193	1.2631	1.2793	1.4413	1.0364
18	.8192	.6097	.8573	.6287	.2858	.743	.5716
19	.8002	.8764	.7621	.9145	.8954	.7621	.8764
20	.6287	.4763	.7049	.8573	.8192	.7049	.7621
21	.5335	.5716	.6668	.5906	.724	.6668	.8002
22	.4572	.4954	.5716	.5335	.5716	.5716	.6668
23	.4191	.4572	.4763	.4572	.4572	.5335	.4763
24	.4877	.381		.4763	.4763		.4954
Max	.9448	1.3527	1.2811	1.2651	1.2793	1.4413	1.3336
Min	.2858	.1136	.381	.381	.0957	.4191	.4763
Avg	.5709	.7604	.8459	.8719	.7514	.8590	.8528

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 201 / TAKALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.0857	.1029	.0137	.1372	.1715	.1372
2	.2439	.0857	.12	.1543	.1543	.1715	.1372
3	.2591	.0857	.1543		.1715	.1715	.1715
4	.2896	.0857	.2058	.1886	.2058	.1715	.2058
5	.3353	.1715	.3086	.2058	.2572	.2572	.2743
6	.3963	.1715	.3601	.2229	.3429	.2572	.3429
7	.4877	.2572	.4287	.3429	.5487	.2572	.4115
8	.7011	.2743	.4458		.3772	.3258	.2915
9	.7011	.2743	.3429	.0154	.2401	.2572	.2401
10	.1715	.381	.3658	.381	.381	.3353	.3353
11	.0857	.5792	.6097	.6249	.6097	.5335	.4877
12	.0686	.7621	.6859	.6706	.6706	.5792	.5335
13	.0857	.7773	.7316	.7316	.6097	.6554	.5335
14	.0857	.7316	.7621	.6554	.6249	.6401	.5487
15	.0857	.7011	.0762	.6401	.5335	.5944	.5335
16	.1029	.7468	.7164	.5792	.5487	.5487	.5335
17	.1029	.6554	.6249	.5639	.503	.5182	.061
18	.1886	.2058	.0206	.1372	.1372	.1886	.1067
19	.3086	.3429	.3429	.3429	.2743	.3086	.2915
20	.2572	.2743	.2286	.2401	.2229	.1543	.2572
21	.2058	.1372	.1715	.1543	.1886	.1543	.2229
22	.1715	.1372	.1543	.1372	.1543	.1543	
23	.1372	.12	.1372	.12	.12	.1543	.0171
24		.0857	.12	.1372		.1372	.1372
Max	.7011	.7773	.7621	.7316	.6706	.6554	.5487
Min	.0686	.0857	.0206	.0137	.12	.1372	.0171
Avg	.2478	.3387	.3424	.3300	.3484	.3207	.2961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 202 / KHANDVI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4572	.5487	.5792	.5335	.5335	.5487
2	.5487	.4572	.5792	.6401	.5487	.5335	.5487
3	.5144	.4572	.6401		.0579	.6097	.5792
4	.6344	.7621	.7011	.6554	.6097	.8383	.6097
5	.8573	.9145	1.0364	.7621	.8383	1.2193	.9145
6	.9431	1.0288	1.1584	.884	1.0669	1.5242	1.1584
7	1.0974	1.0669	1.5089	1.5242	1.448	1.829	1.3108
8	1.2174	1.326	1.8138		1.7833	1.8747	1.89
9	1.0631	1.5699	1.7528	1.5851	1.7833	1.7223	1.7833
10	1.1279	.4973	.5487	.4458	.5487		.6173
11	1.6766	.3944	.3429	.2915	.2572		.3429
12	.9755	.3258	.2743	.2058	.2743		.3429
13	1.3717	.2743	.2915	.2572	.2572		.2134
14	1.4327	.2229	.2743	.2401			.2401
15	1.4327	.2229	.2743	.2743	.3772		.2743
16	1.6918	.3258	.3086	.3258	.3772	.4973	.3258
17	.8078	.463	.4287	.4115	.4287	.5487	.4287
18	.7373	.6516	.703	.6516	.6516	.7373	.6001
19	.8916	.8916	.9259	.9088	.9431	.9259	.8402
20	.7545	.7888	.8573	.7202	.7373	.7716	.7373
21	.6859	.6516	.6344	.583	.6516	.6516	.703
22	.6859	.5487	.0566	.5487	.5316	.583	
23	.5144	.5144	.5487	.4973	.5144	.5144	.4801
24		.4572	.4877	.4877		.4877	.4877
Max	1.6918	1.5699	1.8138	1.5851	1.7833	1.8747	1.89
Min	.5144	.2229	.0566	.2058	.0579	.4877	.2134
Avg	.9642	.6363	.6957	.6127	.6918	.9112	.6947



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 203 / USMANPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.1372	.1372	.1715	.2058	.1715	.1715
2	.5182		.1372	.1715	.0257	.1715	.1715
3	.5487	.1372	.1715		.2915	.1715	.2058
4	.5792	.1715	.2229	.2229	.3086	.2572	.2572
5	.6401	.2572	.3772	.2401	.3772	.2572	.3772
6	.7316	.3429	.5316	.3944	.4287	.3429	.5487
7	.8078	.5144	.6173	.6344	.5144	.4287	.6344
8	1.2955	.583	.463		.5144	.463	.6344
9	1.4175	.3429	.463	.3944	.3772	.2915	.4973
10	.2743	.9602	1.0364	.945	.9297	.7011	1.0212
11	.1715	1.5394	1.4937	1.4632	1.448	1.2346	1.4632
12	.1372	1.6461	1.6309	1.6461	1.4937	1.3717	1.6309
13	.12	1.7528	1.6156	1.6613	1.4784	1.387	1.5546
14	.12	1.6613	1.6613	1.5699	1.4784	1.4022	1.4937
15	.12	1.5851	1.5851	.1478	1.5242	1.2498	1.5242
16	.1886	1.6461	1.5851	1.5394	1.5242	1.4022	1.4632
17	.2058	1.5851	.1677	1.5089	1.5242	1.3565	1.326
18	.2401	.2743	.3258	.2572	.2743	.3429	.2743
19	.4115	.5144	.4973	.3944	.3258	.4458	.4973
20	.3429	.3944	.3601	.3429	.2915	.2915	.3772
21	.2401	.2229	.2572	.2401	.2058	.2401	.2743
22	.1715	.1886	.2229	.1715	.1543	.1886	
23	.0857	.1715	.1886	.1543	.1543	.1715	.1715
24		.0857	.1543	.1715		.1715	.1715
Max	1.4175	1.7528	1.6613	1.6613	1.5242	1.4022	1.6309
Min	.0857	.0857	.1372	.1478	.0257	.1715	.1715
Avg	.4285	.7267	.6626	.6565	.6891	.6047	.7279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 201 / TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429	.3429	.381	.3048	.381
2	.3429	.3429	.3429	.3429	.381	.3048	.381
3	.4287	.3429	.3429	.3429	.381	.381	.381
4	.5144		.4287	.6001	.4572	.5335	.4572
5	.6001	.4287	.6001		.5335	.6097	.5335
6	.6859		.6859	.7716	.6097	.6859	.6097
7	.9431		.9431		.7621	.8383	.7621
8	1.0288				.9907	.9907	.9907
9	1.0288	1.0288	.9431	.9431	.7716	1.1145	1.1145
10	.9431	.8573	.7716	.8573	.7716	1.0288	.8573
11	.7716	.7716	.7716	.7716	.6859	.9431	.6859
12	.7716	.6859	.7716	.6859	.6001	.7716	.6859
13	.6859	.6001	.6859	.6859	.6001	.6859	.6859
14	.6001	.6001	.6859	.6001	.6001	.6001	.6859
15	.5144	.6001	.6859	.6001	.6859	.6001	.6859
16	.5144	.6859	.6001	.6001	.7716	.6859	.6859
17	.6097	.7621	.6097	.8573	.8573	.8573	
18	.7621	.8383	.7621	.9431	.9431	.8573	
19	.6859	.7621	.8383	.9431	.9431	1.0288	
20	.6859	.6859	.7621	.8573	.7716	.7716	
21	.6097	.6097	.6859	.7716	.7716	.6859	
22	.5335	.5335	.5335	.6001	.5144		
23	.4572	.4572	.4572	.5144	.5144		
24	.4287	.4287	.4572	.6001	.4287	.4287	
Max	1.0288	1.0288	.9431	.9431	.9907	1.1145	1.1145
Min	.3429	.3429	.3429	.3429	.381	.3048	.381
Avg	.6454	.6182	.6395	.6777	.6553	.7140	.6615

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 202 / RAMKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9431		1.0288	.8383	.7621	.7621
2	.8573			.743	.9907	.9145	.7621
3	.9431	.8573		1.2003	1.1431	1.0669	.9145
4							.9907
5							1.1431
6							1.2193
7							1.5242
8							1.829
9							1.9719
10	1.5432	1.5432	1.6289	1.5432	1.7147	1.3717	
11	1.8861	1.8861	1.8861	1.8861	1.8861	1.9719	
12	1.8861	1.8861	1.9719	1.9719	1.8861	1.9719	
13	1.8861	1.8861	1.9719		1.8861	1.7147	
14	1.8004	1.7147	1.7147	1.5432	1.8861	1.6289	
15	1.8004	1.7147	1.7147	1.7147	1.8004	1.6289	
16	1.8004	1.8004	1.5432	1.8004	1.8004	1.6289	
17	1.5242	1.5242	1.448	1.8861	1.6289	1.6289	
18	1.0669	.9907	1.1431	1.4575	1.0288	1.2003	
19	1.0669	1.0669	1.3717	1.3717	1.1145	1.286	
20	.9907	1.1431	1.0669	1.1145	1.1145	1.2003	
21	.9145	.9145	.9145	.9431	1.0288	.8573	
22	.8383	.7621	.6859	.8573	.7716		
23	.6859	.6859	.6097	.7716	.6859		
24	.6859	.6097	.6097	.6097	.7716	.6859	
Max	1.8861	1.8861	1.9719	1.9719	1.8861	1.9719	1.9719
Min	.6859	.6097	.6097	.6097	.6859	.6859	.7621
Avg	1.2797	1.2899	1.3521	1.3202	1.3320	1.3449	1.2352

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 203 / AMBADGAON-AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6859		.5144	.6097	.5335	
2	.6859	.6001		.5144	.6097	.5335	
3	.6859	.7716		.6001	.6859	.6097	
4	.7716	.8573		.7716	.7621	.7621	
5	.9431	.8573		.7716	.8383	.8383	
6	1.0288	1.0288		1.0288	.9145	.9145	
7	1.3717	1.286		.8573	1.2193	1.2193	
8	1.6289			1.0288	1.5242	1.3717	
9	1.6289	1.5432		1.0288	1.4575	1.5432	
10							1.1145
11							1.3717
12							1.5432
13							1.6289
14							1.7147
15							1.5432
16							1.4575
24	.5144	.4572	.4572	.6001	.6001	.6001	
Max	1.6289	1.5432	.4572	1.0288	1.5242	1.5432	1.7147
Min	.5144	.4572	.4572	.5144	.6001	.5335	1.1145
Avg	.9859	.8986	.4572	.7716	.9221	.8926	1.4820

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 204 / KUSALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	1.2003	.5144	.5144	.5335	.5335	.7621
2	.8573	1.1145	.6001	.4287	.6097	.6097	.7621
3	.8573	1.2003			.6859	.7621	.8383
4							.8383
5							.9145
6							.9145
7							1.2193
8							1.5242
9							1.7147
10	1.8861	1.7147	1.8004	1.7147	2.0576	1.5432	
11	2.4006	1.8861	1.8861	2.2291	2.0576	2.2291	
12	2.4863	2.2291	2.2291	2.2291	1.8861	2.3148	
13	2.4863	2.2291	2.2291	2.2291	1.8861	2.2291	
14	2.4863	2.0576	2.2291	2.3148	1.8861	1.8861	
15	2.4863	1.8861	2.2291	2.2291	1.8004	1.5432	
16	2.4863	1.9719	2.0576	2.2291	1.7147	1.5432	
17	1.7528	1.5242	1.6766	1.9719	1.6289	1.5432	
18	.6097	.8383	.8383	1.8004	.7716	1.0288	
19	.9145	.9907	.9907	1.2003	.9431	1.0288	
20	.8383	1.0669	.9145	1.1145	1.0288	1.0288	
21	.8383	.9145	.7621	.8573	1.0288	.9431	
22	.6859	.6097	.6097	.7716	.6001		
23	.6097	.5335	.5335	.7716	.6001		
24	.5144	.5335	.6859	.5335	.6001	.6001	
Max	2.4863	2.2291	2.2291	2.3148	2.0576	2.3148	1.7147
Min	.5144	.5335	.5144	.4287	.5335	.5335	.7621
Avg	1.4427	1.3612	1.3404	1.4788	1.2400	1.3354	1.0542

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 205 / ROSHANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.6859		.4287	.381	.381	.2286
2	.3429	.7716		.3429	.381	.381	.3048
3	.4287	.6859		.4287	.4572	.4572	.3048
4	.6001	.6001		.5144	.6097	.5335	
5	.7716	.6001		.6859	.6859	.6097	
6	.8573	.6859		.7716	.7621	.6859	
7	1.0288	.9431		1.2003	.9907	.8383	
8	1.1145	1.2003		1.2003	1.1431	.9907	
9	1.0288	1.1145	1.2003	1.2003	1.1145	1.1145	
13							1.2003
14							1.286
16							1.3717
18	.381	.381	.381	.4287	.2572	.5144	
19	.4572	.4572	.4572	.5144	.6001	.6001	
20	.4572	.5335	.4572	.6001	.5144	.5144	
21	.381	.381	.381	.5144	.5144	.4287	
22	.3048	.3048	.3048	.3429	.2572		
23	.2286	.2286	.2286	.3429	.2572		
24	.3429	.3048	.3048	.3048	.4287	.4287	
Max	1.1145	1.2003	1.2003	1.2003	1.1431	1.1145	1.3717
Min	.2286	.2286	.2286	.3048	.2572	.381	.2286
Avg	.5668	.6174	.4644	.6138	.5847	.6056	.7827

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 206 / AMBADGAON (G)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.1524
2							.1524
3							.1524
4							.2286
5							.3048
6							.381
7							.381
8							.4572
10	.2572	.1715		.2572	.0857	.2572	
11		.1715			.0857	.1715	
12		.0857			.0857		
13	.1372				.0857	.0857	
14				.0857	.0857		
15	.0857	.0857		.0857	.0857	.0857	
16	.0857	.0857		.0857	.1715	.0857	
17	.1524	.1524		.1715		.0857	
18	.3048	.2286		.2572	.1715	.3429	
19	.3048	.2286	.3048	.2572	.2572	.2572	
20	.3048	.1524	.3048	.1715	.2572	.3429	
21	.2286	.1524	.2286	.1715	.2572	.1715	
22	.2286	.1524	.1524	.1715	.1715		
23	.1524	.0762	.1524	.1715	.1715		
Max	.3048	.2286	.3048	.2572	.2572	.3429	.4572
Min	.0857	.0762	.1524	.0857	.0857	.0857	.1524
Avg	.2038	.1453	.2286	.1715	.1517	.1886	.2762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 207 / WARUDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	1.0288		.5144	.4572	.381	.3048
2	.6001	.8573	.4287		.4572	.381	.381
3	.6859	.7716	.5144	.6001	.5335	.4572	.4572
4	.7716		.6859	.8573	.5335	.5335	
5	.8573	.6001	.7716	.6001	.6097	.6859	
6	.9431			.7716	.6859	.7621	
7	1.3717		1.2003	1.286	.9145	1.0669	
8	1.6289			1.4575	1.1431	1.2955	
9			1.5432	1.4575	1.4575	1.4575	
10		1.5432					.6859
11							1.2003
12							1.5432
13							1.4575
14							1.3717
15							1.3717
16							1.3717
18	.5335	.6097	.6097	.5144	.6859	.8573	
19	.6859	.6859	.8383	.7716	.7716	.9431	
20	.6859	.7621	.7621	.8573	.7716	.8573	
21	.6097	.6097	.6097	.6859	.6859	.6859	
22	.4572	.4572	.4572	.5144	.5144		
23	.381	.3048	.381	.5144	.5144		
24	.3429	.8573	.8573	.5144	.4287	.6001	
Max	1.6289	1.5432	1.5432	1.4575	1.4575	1.4575	1.5432
Min	.3429	.3048	.381	.5144	.4287	.381	.3048
Avg	.7379	.7573	.7430	.7945	.6978	.7832	1.0145



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 208 / COTTEX GINNING  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	17-JAN-17
HR	Load (MW)
13	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 209 / BAGADIYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857		.0857	.1524	.1524	.0762
2	.0857	.0857		.0086	.1524	.1524	.0762
3	.0857	.0857		.0086	.1524	.1524	.0762
4	.0857	.1715		.1715	.1524	.1524	.0762
5	.0857	.1715		.1715	.1524	.1524	.0762
6	.0857	.1715		.1715	.1524	.1524	.0762
7	.1715			.1715	.1524	.1524	.0762
8	.1715			.1715	.1524	.1524	.0762
9	.1715	.1715		.1715	.1715	.1715	.1715
10	.1715	.1715		.1715	.2572	.1715	.2572
11		.1715	.1715	.2572	.2572	.1715	.1715
12	.0857	.1715	.2572		.2572	.2572	.1715
13	.0857	.1715	.1715	.2572	.2572	.1715	.1715
14	.0857	.1715	.1715	.2572	.2572	.0857	.1715
15	.1715	.1715	.1715	.2572	.1715	.0857	.1715
16		.1715	.2572	.2572	.1715		.1715
17	.1524	.1524	.2286	.1715	.1715	.0857	
18	.1524	.1524	.1524	.1715	.1715	.0857	
19	.1524	.1524	.1524	.1715	.1715	.1715	
20	.1524	.1524	.1524	.1715	.1715	.0857	
21	.1524	.1524	.1524	.1715	.1715	.0857	
22	.1524	.1524	.1524	.1715	.1715		
23	.1524	.1524	.1524	.1715	.1715		
24	.1715	.1524	.1524	.1524	.1715	.1715	
Max	.1715	.1715	.2572	.2572	.2572	.2572	.2572
Min	.0857	.0857	.1524	.0086	.1524	.0857	.0762
Avg	.1303	.1529	.1783	.1714	.1830	.1438	.1292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013430 / 33KV DABHADI

Feeder No / Name : 201 / DABHADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.8954	1.6804	1.1736	.9156	2.0805	1.4563
2	.924	.905	1.7556	1.1869	.9945	2.1033	1.4563
3	1.086	1.086	1.7556	1.3077	1.0174	2.1262	1.531
4	1.1088	1.0631	1.8804	1.4251	1.1904	1.7909	1.531
5	1.3575	1.3717	2.1672	1.6575	1.4089	1.8099	1.7737
6	1.6461	1.5261	2.4006	1.989	2.0481	1.829	2.2177
7	2.0328	2.0348	2.5034	2.2939	2.4291	1.9404	2.7149
8	2.8054	2.1795	2.3148	2.372	2.3472	1.9605	2.3908
9	1.6461	2.4291	2.2291	2.2653	1.5432	2.2177	1.6766
10	1.0974	2.4691	1.7204	1.5432	1.7528	2.3285	1.2269
11	1.134	2.4006	1.6385	1.4746	1.7909	2.5606	1.3413
12	1.0745	2.4619	1.4575	1.2269	1.7194	2.1948	1.1145
13	1.0745	2.2148	1.3923		1.7375	2.1253	1.2269
14	1.0059	1.8804	1.2146	1.2003	2.1033	1.9404	1.1517
15	.9412	1.8804	1.0814	1.1022	2.1262	1.9404	1.0517
16	.905	1.8099	1.1934	1.2003	1.97	1.8671	1.0517
17	1.8861	1.7194	1.4083	1.6827	2.0328	1.7737	1.7737
18	.4477	.9335	1.0174	.6859	.724	.9431	.7392
19	.7468	1.1389	1.3748	1.0517	.7316	1.2449	1.4632
20	.9145	1.1317	1.1869	.9259	1.1088	1.1694	.905
21	.823	1.0751	1.0059	.724	1.1088	1.0374	.905
22	.0747	1.0374	.9221	.724	1.4175	.9431	.8145
23	.5601	.9431	.6036	.7316	1.4327	.9431	.6859
24	.8573	.8145		1.1401	.9156	1.448	1.4003
Max	2.8054	2.4691	2.5034	2.372	2.4291	2.5606	2.7149
Min	.0747	.8145	.6036	.6859	.724	.9431	.6859
Avg	1.1246	1.5584	1.5611	1.3515	1.5236	1.7633	1.4000

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013430 / 33KV DABHADI

Feeder No / Name : 202 / CHIKHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.6535	.8488	.6584	.543	1.0174	.9619
2	.9831	.6535	.8488	.7207	.8316	1.0174	.9054
3	.9831	.924	.7733	.7762	.9425	.9945	.8316
4	1.2431	.924	.9054	.8962	1.0974	.9945	.905
5	1.5261	1.0974	1.1317	.9335		.6944	1.0745
6	2.0348	1.0974		1.0082		.6944	1.2003
7	2.5434	1.2136		1.1088		.703	
8	2.572						
9	3.0346						
10	.2572		2.0165	2.0576	1.9204	2.2405	1.5775
11	.3658	2.7149	2.4691	1.7604	1.9204	2.2405	1.8004
12	.3361	2.8172	2.2891	2.3148	1.4575	2.3285	1.8004
13	.3361	2.7938	2.2119	2.5606	1.4918	2.2177	1.7528
14	.3292	2.7938	1.989	1.8404	1.8604	2.1068	2.0119
15	.3658	2.7401	1.7814	1.773	1.9004	2.1285	1.3546
16	.7468	2.7149	1.7284	1.9281	2.1033	1.9605	1.5775
17	.823	2.552	1.749	2.1719	2.1491	1.8671	2.6139
18	1.1203	.8402	.7459	.7164	.5258	.8488	.5544
19	1.1088			1.448	.5316	1.1317	1.6289
20	1.4632	1.0751	1.0642	1.2269	.9231	1.1883	1.4784
21	1.307	1.0751	.9145	.8145	.8842	1.1317	1.4784
22	1.1203	.9619	.7602	.7602	1.0974	1.0562	1.0456
23	.7468	.9054	.6653	.543	1.0517	1.0562	.9175
24	1.1317	.6535	.9431	.6653	.543	1.0631	.9619
Max	3.0346	2.8172	2.4691	2.5606	2.1491	2.3285	2.6139
Min	.2572	.6535	.6653	.543	.5258	.6944	.5544
Avg	1.1442	1.5601	1.3598	1.3038	1.2513	1.3946	1.3539

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 201 / NANEGAON-AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.2829	.2801	.2427	.2452	.2075	.2452
2	.0934	.2829	.3734	.2801	.2641	.2452	.2829
3	.0934	.3018	.3734	.2614	.2829	.2452	.2829
4		.3206	.3734	.3174	.2641	.2641	.3206
5		.3206	.4108	.3361	.3206	.3018	.3395
6		.3961	.5601	.5228	.4715	.3206	.3772
7		.4715	.6535	.6348	.6036	.3772	.5658
8		.5658	.6535	.7468	.6602	.5847	.5658
9		.5658	.6722	.7282	.5847	.6036	.5281
10	.4715						
11	.6602						
12	.7545						
13	.811						
14	.7922						
15	.6602						
16	.7545	.056	.0747	.0566	.0754	.0566	.0934
17	.7545	.0747	.0747	.0754	.1132	.0754	.112
18	.0943	.0747	.168	.132	.1509	.1698	.1307
19	.132	.0747	.1307	.132	.1886	.132	.168
20	.1132	.0934	.112	.1132	.2075	.1132	.1494
21	.1132	.0934	.112	.1132	.132	.132	.112
22	.0943	.0934	.0934	.1132	.1132	.0943	.0934
23	.0754	.0934	.0934	.1132	.1132	.0943	.0934
24	.0934	.2829	.2801	.1132	.1886	.1698	.2263
Max	.811	.5658	.6722	.7468	.6602	.6036	.5658
Min	.0754	.056	.0747	.0566	.0754	.0566	.0934
Avg	.3697	.2469	.3050	.2796	.2766	.2326	.2604

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 202 / NANEGAON (G)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0566	.0934	.0747	.0566	.0566	.0566
2	.0934	.0566	.0934	.0747	.0566	.0566	.0566
3	.0934	.0566	.0934	.0747	.0754	.0566	.0566
4	.0934	.0754	.0934	.0934	.0943	.0754	.0754
5	.112	.0943	.112	.112	.1132	.1132	.0943
6	.1494	.132	.1494	.1494	.1509	.1509	.132
7	.1867	.132	.1867	.2054	.1886	.1886	.1509
8	.0934	.1132	.1867		.1698	.1698	.1698
9	.0934	.132	.1307	.168	.132	.1509	.1132
10	.0754	.0934	.1307	.0943	.0943	.0754	.0934
11	.0754	.0373	.0934	.0754	.0754	.0754	.0747
12	.0566	.056		.0566	.0566	.0566	.056
13				.0377	.0377	.0566	.056
14				.0566	.0377	.0377	.0373
15	.0566	.0934	.0747	.0377	.0377	.0566	.0373
16	.0754	.0747	.0747	.0566	.0377	.0566	.056
17	.0943	.112	.0934	.0943	.0566	.0566	.0747
18	.0943	.1494	.1307	.1132	.0943	.0943	.1494
19	.132	.1494	.1494	.132	.132	.1509	.168
20	.1132	.0934	.1867	.1132	.1132	.1509	.1867
21	.1132	.0934	.1494	.0754	.0943	.132	.1307
22	.0943	.0934	.1307	.0754	.0754	.1132	.112
23	.0566	.0934	.112	.0566	.0754	.0566	.0934
24	.0934	.0566	.0934	9.4288	.0566	.0754	.0566
Max	.1867	.1494	.1867	9.4288	.1886	.1886	.1867
Min	.0566	.0373	.0747	.0377	.0377	.0377	.0373
Avg	.0972	.0929	.1218	.4981	.0880	.0943	.0953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 203 / SAIGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734						
2	.4108						
3	.4294						
4	.4668						
5	.4668						
6	.5601						
7	.6535						
8	.9896						
9	1.1203						
10		.9335	.7842	.7356	.679	.7545	.7655
11		1.1203	.9709	.9054	.9242	.9431	.9522
12		1.2136	1.1763	.9431	1.094	1.0374	1.1203
13		1.2136	1.2883	.9431	1.0562	.9808	1.1763
14		1.2136	1.307	.9808	1.1128	1.0751	1.1576
15		1.1203	1.0456	1.0374	1.0562	1.1694	.8589
16		1.2136	1.0829	1.1128	.9431	1.1317	.9149
17		1.2696	1.0456	.9242	1.0562	1.1317	1.0456
24	.3734						
Max	1.1203	1.2696	1.307	1.1128	1.1128	1.1694	1.1763
Min	.3734	.9335	.7842	.7356	.679	.7545	.7655
Avg	.5844	1.1623	1.0876	.9478	.9902	1.0280	.9989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 201 / SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	1.3003	1.6766	1.5432	1.4575	1.5089	1.4737
2	.985	1.3717	1.6575	1.4737	1.5261	1.5089	1.647
3	1.0631	1.4575	1.8233	1.6651	1.6108	1.6108	1.8004
4	1.1517	1.5261	1.8233	1.7147	1.7604	1.6575	2.0348
5	1.3146	1.5927	2.1548	2.0576	1.9281	1.989	2.3472
6		1.6766	2.6216	2.6282	2.2634	2.2939	2.652
7		2.2377	3.0769	3.0521	2.8502	2.8826	2.9835
8		2.8673	4.0238	3.5227	3.2769	3.476	3.6046
9		2.8178	3.8952	3.5208	2.9492	3.0178	3.0664
10	2.7435	1.307	1.0974	1.0631	1.307	.9745	1.2803
11	3.0178		.7316	.724	.7545	.7973	.823
12	2.9835		.5601	.6335	.6535	.6268	.7316
13	2.7664		.5601		.5601	.5316	.6535
14	2.7664	.3734	.5544	.543	.5658	.5316	.6401
15	2.2291	.3734	.5601	.543	.6535	.6201	.6335
16	2.5692	.6535	.6401	.6335	.6535	.7087	.7316
17	2.5987	.7468			.8488	.964	
18	1.4022	1.307	1.4003	1.3289	1.3432	1.4022	1.2012
19	1.3717	1.4937	1.4784	1.387	1.448	1.4022	1.4632
20	1.3717	1.4937	1.4937	1.4175	1.448	1.4022	1.4632
21	1.0631	1.4003	1.4003	1.3289	1.2803	1.3146	1.3717
22	1.0631	1.1203	1.2803	1.0631	1.2803	1.0631	1.0974
23	.8859	1.1203	1.1888	.985	.9335	.8859	.985
24	.8954	1.1145	1.448	1.2003	1.3717	1.4022	1.1393
Max	3.0178	2.8673	4.0238	3.5227	3.2769	3.476	3.6046
Min	.8859	.3734	.5544	.543	.5601	.5316	.6335
Avg	1.7569	1.3977	1.6151	1.5468	1.4468	1.4405	1.5576



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 202 / RAJEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1795	1.1517	.9431	1.2136	1.0288	.9335	.8859
2	2.1795	1.2403	.9335	1.2012	1.2269	.9335	1.0059
3	2.2634	1.3146	1.2136	1.2803	1.2269	1.2136	1.1888
4	2.3472	1.4022	1.307	1.4003	1.3146	1.4937	1.3717
5	2.4863				1.4022		1.4632
6	2.6216						
7	3.0769						
8	1.6956						
9	1.7147	1.2269					1.2536
10	.8145	2.7349	2.0576	2.2634	1.7604		1.7147
11	.7164	1.0402	3.0521	2.6825	3.2322	2.2291	2.4006
12	.5373	2.0348	2.4006	3.4408	3.315	2.9673	2.2043
13	.443	1.6766	3.2322	3.2769	3.4808	2.7978	.4477
14	.443	1.6766	3.3532	3.1131	3.315	2.7664	.4477
15	.4382	2.8673	3.5208	3.3589	3.2769	2.713	.3353
16	.7973	3.195	3.2579	3.2693	3.1131	2.5149	.4239
17	.7888	3.2388	3.1722	3.0178	3.1131	2.431	1.8652
18	1.2269	1.1203	1.2936	1.0631	1.1765	.985	1.0059
19	1.387	1.4937	1.4937	1.387	1.4003	1.4175	1.4937
20	1.3146	1.4937	1.386	1.448	1.448	1.3289	1.2803
21	1.2269	1.307	1.307	1.3289	1.2136	1.2403	1.2803
22	1.1393	1.2136	1.2012	1.2403	1.2803	1.0631	1.086
23	1.0517	.865	1.2136	1.1517	1.1203	.9745	1.0974
24	1.7604	1.0631	.9335	1.0059	1.0631	.9335	.8859
Max	3.0769	3.2388	3.5208	3.4408	3.4808	2.9673	2.4006
Min	.4382	.865	.9335	1.0059	1.0288	.9335	.3353
Avg	1.4438	1.6678	1.9617	2.0075	1.9754	1.7187	1.1970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 203 / BAJARANG CRUSHER FEEDER  
Feeder KV- 11 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0183	.0175	.0181	.0189	.0175	.0185
2	.0189	.0185	.0175	.0181	.0189	.0175	.0185
3	.0189	.0185	.0175	.0183	.0189	.0175	.0185
4	.0189	.0183	.0175	.0183	.0187	.0175	.0183
5	.0189	.0183	.0175	.0183	.0187	.0175	
6	.0189	.0183	.0175	.0183	.0187	.0175	.0185
7	.0189	.0183	.0175	.0183	.0187	.0175	.0185
8	.0189	.0183	.0175	.0181	.0187	.0175	
9	.0189	.0183	.0175	.0514	.037	.0175	.0183
10	.0185	.0354	.0181	.0187	.0177	.0905	.0181
11	.0185	.0709	.0183	.0187	.0177	.124	.0867
12	.1595	.0177	.0701	.0554	.0537	.1448	.104
13	.037	.0354	.0686	.0549	.0532	.1448	.12
14	.0724	.1254	.0351	.0185	.0175	.1086	.0857
15	.0724	.0175	.052	.0187	.1063	.0724	.0686
16	.0549	.0709	.12	.0187	.1063	.1267	.0686
17	.0185	.0709	.0514	.0187	.0532	.1433	.0857
18	.0183	.0175	.0354	.037	.0175	.0905	.0686
19	.0183	.0175	.0354	.0187	.0354	.0366	.0358
20	.0185	.0175	.0351	.0187	.0175	.0366	.0179
21	.0183	.0175	.0351	.0187	.0175	.0362	.0181
22	.0185	.0175	.0183	.0189	.0175	.0181	.0179
23	.0185	.0175	.0183	.0189	.0175	.0185	.0181
24	.0187	.0185	.0175	.0183	.0189	.0175	.0183
Max	.1595	.1254	.12	.0554	.1063	.1448	.12
Min	.0183	.0175	.0175	.0181	.0175	.0175	.0179
Avg	.0313	.0305	.0328	.0237	.0314	.0569	.0437

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 201 / KANDARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3239	.5658	.2315	.2429	.4096	.3772
2	.3239	.3201	.6268	.2343	.3239	.4534	.415
3	.4049	.3841	.7164	.3163	.3201	.4858	.4715
4	.4372	.421	.7888	.4144	.4534	.5182	
5	.4858	.4858	.8764	.503	.5506	.5571	
6	.8097	.8097	1.0288	.8478	.8097	.6154	
7	1.166	1.004	1.17	1.1145	.9717	.9717	
8	1.5043	1.3927	1.4089	1.6289	1.5061	1.4575	
9	1.3927	1.4243	1.4752	1.3565	1.3765	1.7004	
10							.7773
11							.9069
12							1.2146
13							1.2955
14							1.3603
15							1.0526
16	.2241	.1509	.1524	.1867	.1143	.1509	.9717
17	.2614	.2452	.2858	.2241	.1524	.2263	.9717
18	.4668	.4715	.4763	.3921	.3429	.415	.3361
19	.6348	.6036	.6668	.6161		.5658	.6348
20	.4668	.5093	.4763	.4108	.4338	.5658	.5601
21	.3734	.4715	.381	.3361	.4715	.4527	.4668
22	.2801	.3772	.2858	.2801	.3048	.415	.3361
23	.2241	.3395	.2286	.2427	.2572	.3206	.2801
24	.3239	.2915	.2829	.2343	.2429	.2458	.2801
Max	1.5043	1.4243	1.4752	1.6289	1.5061	1.7004	1.3603
Min	.2241	.1509	.1524	.1867	.1143	.1509	.2801
Avg	.5613	.5570	.6607	.5317	.5220	.5848	.7060

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 202 / KHADAKWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.5658	.381	.3734	.4763	.7164
2	.5601	.4715	.6602	.381	.4668	.5716	.924
3	.7095	.6602	.6602	.4763	.5601	.5716	1.1088
4							1.2269
5							1.5261
6							1.8442
7							1.989
8							2.0481
9							2.3482
10	1.9433	1.989	2.1195	1.6004	1.8023	1.7004	
11	2.5911	2.2939	2.3205	1.1203	2.4291	2.2377	
12	2.5911	2.4006	2.5149	1.1336	2.672	2.2939	
13	2.5911	2.451	2.3758	1.1336	2.7206	2.1548	
14	2.5101	2.4006	2.2672	1.1336	2.915	1.989	
15	2.4291	2.2672	2.13	1.2955	2.672	2.0719	
16	2.2672	2.1548	1.989	2.4291	2.3482	2.1548	.1867
17	2.2672	2.2377	1.9281	2.1862	2.3482	2.1548	.2801
18	.6535	.5658	.6668	.5601	.6602	.5658	.4668
19	.8402	.8488	.8573	.8402	1.0374	.9431	.8402
20	.7468	.9431	.6668	.6535	.8488	.8488	.6535
21	.6535	.7545	.4763	.4668	.5658	.7545	.4715
22	.4715	.6602	.381	.3734	.3772	.5658	.3734
23	.3772	.5658	.381	.3734	.2858	.4715	.3734
24	.3734	.3734	.5658	.381	.3734	.1886	.4858
Max	2.5911	2.451	2.5149	2.4291	2.915	2.2939	2.3482
Min	.3734	.3734	.381	.3734	.2858	.1886	.1867
Avg	1.3861	1.3562	1.3070	.9399	1.4142	1.2619	.9924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 203 / WALHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9717	1.0745	.9259	.9717	1.0174	.3772
2	1.0526	1.0526	1.3717	1.0155	1.0526	.9717	.3772
3	1.1203	1.1336	1.6575	1.1069	1.1336	1.2289	.4715
4	1.2003	1.2955	1.989	1.326	1.2955	1.4575	
5	1.2955	1.4575	2.13	1.4251	1.4575	1.4575	
6	1.6194	1.6385	2.2672	1.6956	1.6194	1.7004	
7	1.9433	1.9433	2.2119	2.1434	1.9204	1.9433	
8	2.2672	2.1862	2.2672	2.572	2.2672	2.1862	
9	2.1052	2.2405	2.1548	2.3739	2.1052	2.672	
10							1.7004
11							2.1862
12							2.2672
13							2.1862
14							2.2672
15							2.1052
16	.3734	.2829	.381	.3734	.2858	.1886	2.1862
17	.4668	.4715	.4763	.3734		.3772	2.1862
18	.8402	.8488	.8573	.6535	.7545	.8488	.5601
19	1.1203	1.0374	1.1431	1.0269	1.0288	1.1317	1.0269
20	.7468	.9431	.7621	.7468	.8488	.8488	.8402
21	.5601	.8488	.4763	.4668	.5658	.7545	.5601
22	.4715	.7545	.4763	.3734	.4715	.5658	.4668
23	.3772	.6602	.381	.3734	.2858	.4715	.3734
24	.9717	.9717	.7468	.9374	.9717	1.0898	.3734
Max	2.2672	2.2405	2.2672	2.572	2.2672	2.672	2.2672
Min	.3734	.2829	.381	.3734	.2858	.1886	.3734
Avg	1.0835	1.1521	1.268	1.1061	1.1198	1.1618	1.2506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 204 / UJJAINPURI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.4715	.381	.3734	.4763	.4668
2	.4668	.4668	.5658	.4763	.4668	.5335	.4835
3	.5601	.5601	.7545	.5716	.5601	.6478	.5487
4							.6335
5							.7164
6							.8764
7							.9536
8							.9015
9							.5182
10	.8097	.7164	.695	.5601	.5506	.6802	
11	.5668	.9991	.8288	.7202	.7373	.7888	
12	.9717	1.1145	.9221	.9717	.8097	.8669	
13	1.0526	1.0174	.9012	.8907	.8583	.7802	
14	.9602	.9465	.8907	.8907	.8029	.7975	
15	.9393	.8589	.8192	1.0288	.8356	.7888	
16	.8907	.8669	.7459	.8097	.7701	.7888	.1867
17	.8907	.8063	.6706	.6478	.6478	.7888	.2614
18	.5228	.5281	.5144	.4108	.3584	.4715	.3734
19	.6348	.6602	.6287	.5975		.679	.5975
20	.5601	.5658	.4763	.5228	.5281	.4715	.4854
21	.4854	.5093	.4763	.4854	.4458	.3961	.4481
22	.415	.4338	.4763	.4481	.4715	.3772	.3734
23	.3734	.3772	.381	.4108	.4572	.3584	.3239
24	.3772	.3734	.3772	.381	.3734	.4572	.3239
Max	1.0526	1.1145	.9221	1.0288	.8583	.8669	.9536
Min	.3734	.3734	.3772	.381	.3584	.3584	.1867
Avg	.6584	.6763	.6442	.6225	.591	.6194	.5262

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 201 / TADEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.3717		.9431	1.0288		1.3717
2	1.2003	1.3717		.9431	1.0288		1.3717
3	1.2003	1.3717		.9431	1.2003		1.3717
4	1.3717	1.5432		1.1145	1.2003		1.5432
5	1.7147	1.7147		1.286	1.3717	1.8861	1.5432
6	2.1434			1.8004	1.5432	2.0576	1.7147
7				2.1434	1.5432		2.0576
8					1.2003		2.2291
9							2.2291
10	1.9719		1.8861	1.2003		1.5432	.8573
11	1.9719		1.5432	2.0576		2.0576	.3429
12	2.3148		1.9719	2.0576		2.0576	.3429
13	1.6289		2.1434	1.8861		2.0576	.2572
14	2.3148		1.9719	1.8861		2.0576	.2572
15	2.0576		1.8861	1.7147		1.8861	.3429
16	1.0288		1.9719	1.8861		1.8861	.6001
17	1.1145		1.7147	1.7147		1.7147	.8573
18	1.4575		1.4575	1.3717	1.5432	1.3717	1.286
19	1.9719		1.6289	1.5432		1.7147	1.8861
20	1.8861		1.5432	1.7147		1.7147	1.7147
21	1.7147		1.3717	1.5432	1.5432	1.7147	1.5432
22	1.6289		1.1145	1.3717		1.5432	1.4575
23	1.3717		1.0288	1.3717		1.5432	1.2003
24	1.2003	1.3717		.9431	1.8861	1.2003	1.3717
Max	2.3148	1.7147	2.1434	2.1434	1.8861	2.0576	2.2291
Min	1.0288	1.3717	1.0288	.9431	1.0288	1.2003	.2572
Avg	1.6412	1.4575	1.6596	1.5198	1.3717	1.7651	1.2396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 202 / BHOKARDAN TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859		.7716	1.0288		1.0288
2	.6859	.6859		.7716	1.0288		1.0288
3	.6859	.7716		.7716	1.2003		1.2003
4	.6859	.8573		.7716	1.2003		1.2003
5	1.1145	1.0288		.8573	1.3717	1.2003	1.5432
6	1.3717	1.5432		1.6289	1.5432	1.7147	1.3717
7	1.7147	1.7147		2.0576	1.7147	2.2291	1.7147
8	2.0576	1.9719		2.0576	1.8861	2.2291	1.8861
9	1.8861		2.2291	1.7147		1.8861	1.9719
10	1.6289		1.8004	1.5432		1.7147	1.8004
11			1.5432	1.3717		1.5432	1.4575
12	1.5432		1.4575	1.3717		1.3717	1.3717
13	1.3717		1.3717	1.2003		1.2003	1.3717
14	1.2003		1.3717	1.8861		1.2003	1.1145
15	1.1145		1.3717	1.2003		1.2003	1.286
16	1.2003		1.3717	1.2003		1.2003	1.3717
17	1.4575		1.4575	1.3717		1.3717	1.4575
18	1.6289		1.5432	1.5432	1.7147	1.3717	1.7147
19	1.7147		1.7147	1.5432		1.5432	1.8861
20	1.4575		1.4575	1.5432		1.5432	1.5432
21	1.2003		1.286	1.3717	1.3717	1.3717	1.3717
22	1.0288		1.0288	1.2003		1.2003	1.2003
23	.8573		.8573	1.2003		1.2003	1.0288
24	.6859	.6859		.7716	1.8861	.8573	1.0288
Max	2.0576	1.9719	2.2291	2.0576	1.8861	2.2291	1.9719
Min	.6859	.6859	.8573	.7716	1.0288	.8573	1.0288
Avg	1.2599	1.1050	1.4575	1.3217	1.4497	1.4575	1.4146



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 203 / Sipora BZ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.0288		1.0288	.8573		1.2003
2	1.1145	1.0288		1.0288	.8573		1.2003
3	1.1145	1.0288		1.0288	1.0288		1.2003
4	1.2003	1.2003		1.286	1.0288		1.3717
5	1.286	1.3717		1.6289	1.2003	1.3717	1.3717
6	1.4575	1.4575		1.8861	1.3717	1.5432	1.5432
7	1.6289	1.7147		2.1434	1.5432	2.0576	1.5432
8	2.2291	2.3148		2.3148	1.7147	2.4006	1.5432
9	2.2291		2.4006	2.2291		2.2291	1.286
10	1.3717		.9431	.8573		1.0288	1.3717
11	1.0288		.7716	.6859		.8573	1.5432
12	.9431		.6859	.6859		.8573	1.4575
13	.8573		.6859	.6859		.6859	1.4575
14	.7716		.6859	.6859		.6859	1.286
15	.7716		.6859	.6859		.6859	1.286
16	1.0288		.9431	.6859		.8573	1.286
17	1.286		1.286	.8573		1.0288	1.3717
18	1.8004		1.5432	1.2003	1.7147	1.2003	1.286
19	1.2003		1.7147	1.5432		1.3717	1.5432
20	1.4575		1.6289	1.5432		1.5432	1.286
21	1.3717		1.4575	1.5432	1.3717	1.3717	1.3717
22	1.2003		1.286	1.3717		1.2003	1.4575
23	1.1145		1.2003	1.2003		1.2003	1.286
24	1.0288	1.0288		.8573	1.7147	1.3717	1.0288
Max	2.2291	2.3148	2.4006	2.3148	1.7147	2.4006	1.5432
Min	.7716	1.0288	.6859	.6859	.8573	.6859	1.0288
Avg	1.2753	1.3527	1.1946	1.2360	1.3094	1.2774	1.3574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 204 / Malkapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.3429		.1715	.5144		.5144
2	.1715	.3429		.1715	.5144		.5144
3	.1715	.3429		.1715	.6859		.6859
4	.2572	.4287		.2572	.6859		.6859
5	.6001	.6001		.6001	.8573	.5144	.8573
6	.7716	.7716		1.1145	.8573	.6859	.8573
7	.8573	1.1145		1.3717	.8573	1.0288	1.0288
8	1.5432	1.4575		1.7147	1.0288	1.3717	.8573
9	1.4575		1.3717	1.3717		1.2003	.6001
10	.4287		.4287	.6859		.8573	.6859
11	.2572		.1715	.5144		.6859	1.1145
12	.2572		.1715	.5144		.6859	1.0288
13			.1715	.5144		.6859	.9431
14	.3429		.1715	.5144		.6859	.8573
15	.3429		.1715	.5144		.6859	.6859
16	.3429		.1715	.5144		.6859	.7716
17	.6001		.4287	.6859		.8573	.7716
18	.8573		.6859	.8573	.8573	.8573	.6001
19	.8573		1.1145	1.0288		1.0288	.6859
20	.6859		.6859	1.2003		1.0288	.6859
21	.6859		.6001	1.0288	.6859	.8573	.6001
22	.6001		.4287	.8573		.6859	.6001
23	.5144		.2572	.6859		.5144	.5144
24	.1715	.3429		.1715	.6859	.5144	.5144
Max	1.5432	1.4575	1.3717	1.7147	1.0288	1.3717	1.1145
Min	.1715	.3429	.1715	.1715	.5144	.5144	.5144
Avg	.5629	.6382	.4687	.7180	.7482	.8059	.7359

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 205 / Fattepur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6001		.5144	.5144		.3429
2	.6001	.6001		.5144	.5144		.5144
3	.6001	.6001		.5144	.5144		.5144
4	.7716	.7716		.6001	.6859		.5144
5	1.1145	.9431		.9431	.6859	1.2003	.6859
6	1.3717	1.4575		1.286	.8573	1.2003	.6859
7	1.4575	1.3717		1.4575	1.0288	1.0288	1.0288
8	1.3717	1.4575		1.1145	1.2003	1.2003	1.0288
9	1.2003		1.0288	1.0288		1.0288	1.1145
10	.7716		.6859	.8573		.8573	.5144
11	.8573		.8573	1.0288		1.0288	
12	.9431		.9431	.8573		1.0288	
13	.9431		1.2003	.8573		.8573	
14	.7716		.8573	.8573		.8573	.3429
15	.6859		.6859	.6859		.8573	.3429
16	.7716		.7716	.5144		.8573	.3429
17	.8573		.8573	.6859		.8573	.5144
18	1.1145		.9431	.6859	1.2003	.8573	.8573
19	1.286		1.1145	.8573		1.0288	1.286
20	1.0288		1.0288	1.0288		1.2003	1.1145
21	.8573		.8573	.8573		1.0288	.8573
22	.6859		.6001	.6859		.8573	.6859
23	.6001		.5144	.5144		.6859	.6001
24	.6001	.6001		.5144	.8573	.5144	.3429
Max	1.4575	1.4575	1.2003	1.4575	1.2003	1.2003	1.286
Min	.6001	.6001	.5144	.5144	.5144	.5144	.3429
Avg	.9109	.9335	.8630	.8109	.8059	.9516	.6777

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 207 / Perjapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2572		.1715	.5144		.5144
2	.1715	.2572		.1715	.5144		.5144
3	.1715	.2572		.1715	.5144		.5144
4	.2572	.3429		.2572	.6859		.6859
5	.3429	.5144		.3429	.6859	.5144	.6859
6	.3429	.6859		.4287	.6859	.5144	.6859
7	.3429	.6859		.5144	.8573	.5144	.8573
8	.6001	.8573		.8573	1.0288	.8573	.8573
9	.6001		.6001	.8573		.8573	.5144
10	.3429		.2572	.5144		.5144	.3429
11	.2572		.1715	.3429		.5144	.6001
12	.1715		.1715	.5144		.5144	.6859
13	.1715		.1715	.5144		.3429	.6859
14	.1715		.1715	.3429		.3429	.6001
15	.1715		.1715	.3429		.3429	.3429
16	.1715		.1715	.3429		.5144	.3429
17	.2572		.2572	.5144		.6859	.3429
18	.3429		.4287	.6859	.3429	.8573	.3429
19	.5144		.6001	.8573		1.0288	.5144
20	.5144		.4287	.8573		1.0288	.5144
21	.4287		.3429	.6859	.3429	.8573	.4287
22	.3429		.2572	.5144		.6859	.3429
23	.3429		.1715	.3429		.5144	.3429
24	.1715	.2572		.1715	.5144	.2572	.3429
Max	.6001	.8573	.6001	.8573	1.0288	1.0288	.8573
Min	.1715	.2572	.1715	.1715	.3429	.2572	.3429
Avg	.3072	.4572	.2915	.4715	.6079	.6130	.5251

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 201 / KHAMKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.4287	1.2003	.6859	1.2003	.5144	1.0288
2	.5716	.5144	1.2003	1.0288	1.3717	.6859	1.0288
3	.5716	.6859	1.3717	1.1145		.8573	1.0288
4	.6668	.8573	1.5432	1.3717		1.2003	1.2003
5	.7621	.9431	1.7147	1.8861		1.3717	1.3717
6	.8573	.8573	1.7147	1.8861		1.4575	1.3717
7	.8954	.7373	1.8861	1.9719		1.4403	1.5432
8	.8954	1.5261	1.8861	1.9719	1.3717	2.0576	1.7147
9	.7621	1.5432	1.8861	1.7147	1.5432	1.7147	1.8861
10	1.0288	.3239	.5144	.362	.5716	.4954	.381
11	1.286	.2286	.2286	.1905		.381	
12	1.3717	.2858	.2667	.2286			.3429
13	1.3375	.2667	.1905	.2667			.3429
14	1.5432	.1905		.3048	.1905		.381
15	1.5261	.2096		.2096	.2286		
16	1.286		.3429	.381	.4954		.1905
17	1.5432	.1905	.5716	.2286			.2858
18	.7621	.4763	.7621	.5716	.8573	.5716	.7621
19	.9526	.6668		.8573	1.2384	.6859	.9526
20	.9907	1.0098		1.1431		.6668	.8573
21	.8573	.9526		.9526		.743	.7621
22	.7621	.8573	.6478	.7621		.6668	.743
23	.6097	.8573	.5716	.6478		.6668	.5716
24	.5716	.8573		.4115	.8573	.4801	1.0288
Max	1.5432	1.5432	1.8861	1.9719	1.5432	2.0576	1.8861
Min	.5716	.1905	.1905	.1905	.1905	.381	.1905
Avg	.9576	.6724	1.0277	.8812	.9024	.9254	.8989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 202 / Chandai Th

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.4763	.5716		.5716	.381	.5716
2	1.2003	.4763	.5716		.5716	.381	.5716
3	1.3717	.5716	.6668		.5716	.4763	.7621
4	1.5432	.6668	.8573		.8573	.5716	.9526
5	1.7147	.8573	.9526		.9526	.6668	.9526
6	1.7147	.9526	.9526		.9526	.7621	1.1431
7	1.8861	1.1431	1.0479		1.0479	.9526	1.1431
8			1.0479		1.1431		1.0479
9	1.8861		.8573		.7621	.5716	.6668
10	.6668	1.2689	1.2003		1.5432	1.286	1.5432
11	.381	2.0576	1.8004	1.0288	1.7661	1.6289	1.7147
12	.2858	2.0233	1.7318	1.286	1.7147	1.4746	1.7661
13	.2667	1.9719	1.7147	1.0631	1.6289	1.5947	1.7147
14	.2858	2.0062	1.6804		1.5775	1.286	1.8861
15	.2286	1.8861	1.5261	1.7147	1.7147	1.3717	1.8004
16	.3429	1.7318	1.5604	1.5775	1.8861	1.6118	1.6289
17	.381	1.7147		1.3717	1.9204	1.5432	1.8861
18	.6668	.6668	.5716	.9717	.7621	.5716	.7621
19	.8573	.7621	.7621	.9526	1.0288	.5716	.9335
20	.8954	.8192	.9526	.9717		.6668	.7621
21	.7621	.7621	.7621	.7621		.7621	.6668
22	.5716	.6668	.5335	.6668		.6668	.6097
23	.5335	.5716	.4763	.5716		.6668	.5716
24	.8573	.5716			.5716	.5525	.6668
Max	1.8861	2.0576	1.8004	1.7147	1.9204	1.6289	1.8861
Min	.2286	.4763	.4763	.5716	.5716	.381	.5716
Avg	.8913	1.1193	1.0363	1.0782	1.1772	.9138	1.1135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 203 / Rajur Town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2012	.2572	.1831	.2572	.2012	.2572
2	.2572	.2012	.2572	.1829	.2572	.2012	.2572
3	.2572	.3292	.3429	.2743	.2572	.2743	.3429
4	.3429	.4024	.5144	.3658	.3429	.3658	.5144
5	.4287	.4572	.6001	.4572	.5144	.4572	.6001
6	.5144	.5853	.6001	.5853	.5144	.5853	.6859
7	.6001	.6767	.6859	.6219	.6001	.6767	.6859
8	.6001	.6584	.6859	.6584	.6001	.6401	.6001
9	.5144	.5487	.5144	.4572		.5487	.3429
10	.4287	.439	.4287	.3109	.5144	.4572	.3429
11	.4024	.4572	.3475	.2195	.3109	.3658	.3086
12	.3292	.3658	.3772	.2743	.3658	.2743	.3772
13	.3658	.4024	.2572		.2572	.4024	.3429
14	.2915	.3292	.3086	.2195	.3429	.3658	.3601
15	.3658	.3841	.3109	.2926		.3841	.4287
16	.4572	.3475	.2743	.4572		.4572	.3772
17	.5487	.3109		.4024		.3109	.4458
18	.5853	.3544	.6036	.4287	.5487	.3429	.5487
19	.5487	.5144	.6219	.5144	.5487	.4287	.5853
20	.4755	.5144	.5487	.4287		.5144	.5487
21	.3658	.4287	.4572	.3429		.4287	.4572
22	.3109	.3429	.2743	.3429		.3429	.3292
23	.2743	.2572	.2012	.2572		.2572	.2743
24	.2572	.2572		.1829	.2572	.2263	.2572
Max	.6001	.6767	.6859	.6584	.6001	.6767	.6859
Min	.2572	.2012	.2012	.1829	.2572	.2012	.2572
Avg	.4075	.4069	.4304	.3678	.4056	.3962	.4279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 204 / LONGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.381	.5716	.724	.5716	.4763
2	.4763	.4763	.4763	.5716	.724	.5716	
3	.5716	.5716	.6668	.7621	.724	.6668	.4763
4	.9526	.7621	.7621	.8573	.7621	.7621	.6668
5	1.0479	.9526	.7621	.9526	.8002	.8573	.7621
6	1.0479	1.0479	.8573	1.0479	.8573	.9526	.8573
7	1.0288	1.2384	.8573	.7621	.8573	.8954	.8573
8	1.1431		.8573	.7049	.7621	.8573	.6668
9	1.7147	.381	.6668	.5716	.5716	.5716	.4763
10	1.8861	.5144	.5716		.4763	.3429	.4763
11	1.7318		.381		.2858	.2858	.381
12	1.7147		.4763		.2286	.1905	
13	1.4575		.1905		.1905	.2286	
14	1.5432	.3048	.2858		.2858	.2667	.2858
15	1.6804	.4191	.2286		.2286	.1905	
16	1.7147	.5716	.3429		.3239	.3429	
17		1.7147		1.7147	1.9719	1.9719	2.191
18	.5716	1.8861		1.8861	1.7147	2.0576	1.7147
19	.6668			1.5432	1.4575	2.0576	1.4575
20	.7621	1.7147		1.5432		1.8861	1.2003
21	.6668	1.5432				1.7147	1.0288
22	.5716	1.3717				1.5432	.9774
23	.5716	1.2003				1.5432	.8573
24	.4763	1.0288		.6001	.7716	.7716	1.5432
Max	1.8861	1.8861	.8573	1.8861	1.9719	2.0576	2.191
Min	.4763	.3048	.1905	.5716	.1905	.1905	.2858
Avg	1.0641	.9566	.5477	1.0064	.7359	.9208	.9133



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 205 / TAPOWAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6001	1.2003	.6859	.1372	.6859	1.2003
2	.5716	.6859	1.2003	.7716	1.3717	1.0288	1.2003
3	.5716	.6859	1.3717	.8573	1.3717	1.2003	1.2003
4	.6668	.8573	1.7147	1.0288	1.5432	1.286	1.3717
5	.7621	1.0288	1.7147	1.2003	1.7147	1.4575	1.5432
6	.7621	1.0288	1.8861	1.6289	1.8861	1.5432	1.5432
7	.8573	.9945	1.8861	1.7147	1.8861	1.5947	1.7147
8	.8573	1.0974	1.8861	1.5432	1.8861	1.5432	1.8861
9	.8573	.381	.381	.381	.381	.5716	.4763
10		.3429	.381	.3048	.4763		.4763
11		.4191	.3429	.2858	.3429		.381
12		.381	.381	.2477	.2858		.362
13	.381		.362	.2667	.2286		.381
14	.4763		.1905	.2858	.3429		.3048
15	.5335	.1905	.2858	.381	.1905	.1905	
16	.4191	.2858	.2286	.4191	.4191	.2858	
17		.381		.381	.381	.381	.381
18	.8573	.4763	.5716	.5716	.7621	.4763	.5716
19	.9431	.5716	.7621	.6668	.8002	.5716	.8573
20	.823	.7621	.8573	.7621		.6668	.6668
21	.7716	.724		.6668		.6668	.5716
22	.7545	.5716	.4572	.5716		.5716	.4191
23	.6859	.4763		.4287		.5716	.381
24	.6859	.583		.4001	.381	.3429	.5716
Max	.9431	1.0974	1.8861	1.7147	1.8861	1.5947	1.8861
Min	.381	.1905	.1905	.2477	.1372	.1905	.3048
Avg	.6904	.6148	.9031	.6855	.8394	.8230	.8391

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 206 / CHANDAI EKKO

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.4763	.4763	.381	.5335	.4763	
2	1.3717	.4763	.4763	.381	.5335	.4763	
3	1.3717	.5716	.4763	.4763	.5335	.5716	
4	1.5432	.7621	.5716	.5716	.5716	.7621	
5	1.8861	.9526	.5716	.6668	.6668	.8573	
6	1.8861	1.0479	.6668	.8954	.7621	.7621	
7	2.0576	.9907	.6668	.7621	.8573	.724	
8	2.0576	.8002	.6668	.5716	.8573	.5906	
9	.4191	1.7147	2.0576	1.5432	1.7147	1.2003	
10	.381	2.0576	2.0576	1.8004	1.7147	1.5432	
11	.4763	2.2291	1.8861	1.7318	1.4575	1.8004	
12	.4572	2.0576	1.9719	1.7147	1.3375	1.8861	
13	.4191	2.1434	2.0062	1.7318	1.406	1.7147	
14	.5716	2.2977	1.9719	1.6632	1.3546	1.3717	
15	.5335	2.1948	1.6289	1.7147	1.6632	1.6289	
16	.4763	1.7147	1.7147	1.7318	1.3717	1.286	
17		.3429	.5335	.1524	.2286	.2667	
18	.7621	.5716	.5716		.7621	.381	
19	.8573	.6668	.7621	.8573	1.0288	.5716	
20	.8002	.7621	.6668	.8954	.9526	.6668	
21	.7621	.6668	.5716	.8573	.7621	.7621	
22	.6668	.5716	.5335	.8573	.6668	.5716	
23	.5335	.4382	.4763	.5716	.5716	.5716	
24	.6859	.5144	.4763	.4763	.5335	.4763	.5716
Max	2.0576	2.2977	2.0576	1.8004	1.7147	1.8861	.5716
Min	.381	.3429	.4763	.1524	.2286	.2667	.5716
Avg	.9716	1.1259	1.0191	1.0002	.9517	.9133	.5716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 201 / ANWA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.7316	.7316		.905	.7545	.5716
2	.5601	.7316	.5601		1.0745	.5658	.5716
3	.5601	.7316	.7316		1.4022	.5658	.5716
4	.7316	.905	.905		1.4022	.7468	.7545
5	.7316	1.086	1.086		1.4175	.905	.9431
6	1.086	1.5775			1.4022	1.0402	.9431
7	1.4022	1.7147			1.4022	1.3203	1.3203
8						1.3717	1.8671
9						1.3717	1.6975
10	1.1317	1.2003		1.086	1.0402	1.1317	.7316
11	1.3203	1.2003		1.0974		.9431	.7316
12	1.5089	1.6975		1.2403	1.0402	.7545	.7316
13	1.3203	1.0517		1.2536	1.0402	.7545	.7316
14	1.1317	1.0517		1.086	1.0517	.5658	.7316
15	1.1317	1.0517	1.3203	.905	1.0517	.5658	.7316
16	1.1317	1.0517		1.086	1.2003	.5658	.7316
17	1.1317	1.0517		1.086	.8764	.9431	.905
18	1.6975	1.2003		1.7147	1.2003	1.3203	1.4022
19	1.3203	1.2003		1.7147	1.2003	1.5089	1.4022
20	1.1317	1.2003		1.7147	1.2003	1.6975	1.2403
21	.9431	1.0517		1.7147	1.1203	1.5089	1.2403
22		.905		1.7147	.905	1.1317	.905
23		.905		.905	.7545	.7545	.7316
24	.7545	.7545	.905	.9431	1.0402	.7545	.381
Max	1.6975	1.7147	1.3203	1.7147	1.4175	1.6975	1.8671
Min	.5601	.7316	.5601	.905	.7545	.5658	.381
Avg	1.0643	1.0933	.8914	1.2841	1.1299	.9809	.9404

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 202 / JALGAON SAPKAL

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	15-JAN-17	16-JAN-17	19-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)
9		1.6975	
12			.381
13			.381
23	.5716		
24		.381	
Max	.5716	1.6975	.381
Min	.5716	.381	.381
Avg	.5716	1.0393	.381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 203 / WAKDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.905	.9145		1.0745	.5658	.381
2	.5658	.905	1.086		.905	.381	.381
3	.5658	.905	1.2403		.905	.381	.381
4	.5658	1.086	1.4022		.905	.5658	.381
5	.7316	1.4022	1.5432		.9145	.7468	.5716
6	.9145	1.5775	1.5432		.905	.9145	.5716
7	1.086	1.5775	1.5432		1.0745	1.2003	1.1317
8						1.0288	1.3203
9						1.0288	.9431
10	.7545	.5658		.7316	.5658	.381	.5601
11	.7545	.7545		.7316	.7468	.381	.5601
12	1.1317	.7545		.7316	.7468	.1905	.3772
13	.9431	.7545	.7392	.7316	.7468	.1905	.3772
14	.9431	.7545		.7316	.7468	.1905	.3772
15	.9431	.7545	.5601	.7316	.8669	.1905	.3772
16	.9431	.7545		.7316	1.0402	.1905	.5601
17	.9431	.7545		.7316	.8764	.7545	.7316
18	1.5089	1.2003		1.4022	1.2003	1.1317	1.2403
19	1.6975	1.6975		1.4022	1.2003	1.3203	1.2403
20	1.3203	1.2003		1.4022	1.2136	1.5089	1.2403
21	1.1317	1.0517		1.4022	1.1203	1.1317	1.0745
22		1.0517		1.4022	.9335	.9431	.905
23		.905		1.4022	.5658	.5658	.5601
24	.5658	.9431	1.0517	.9431	.5601	.5658	.1905
Max	1.6975	1.6975	1.5432	1.4022	1.2136	1.5089	1.3203
Min	.5658	.5658	.5601	.7316	.5601	.1905	.1905
Avg	.9288	1.0116	1.1624	1.0139	.9006	.6854	.6848

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 204 / KALYANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.5601		.3772	.5658	.1905
2	.3772	.3772	.5601	.3772	.3772	.381	.1905
3	.3772	.3772	.5601	.3772	.3772	.381	
4	.3772	.3772	.5601	.3772	.5601	.381	.381
5	.3772	.3772	.5601	.3772	.7468	.5716	.5658
6	.3772	.3772	.7468	.9145	.7316	.7545	.5658
7	.7316	.7316	.7468		.7316	.7468	.5658
8						.7468	.9335
9						.9145	.7545
10	.1886	.5658		.3772	.5658	.381	.1886
11	.381	.7545		.3772	.5658	.381	.1886
12	.381	.7545		.3772	.7545	.1905	.1886
13	.381	.7545		.3772	.5658	.1905	.1886
14	.381	.7545		.3772	.5658	.1905	.1886
15	.381	.7545	.3696	.3772	.5658	.1905	.1886
16	.381	.7545		.3772	.7545	.1905	.1886
17		.7545		.3772	.5658	.381	
18	.7621	.5658		.7316	.3772	.7545	.1886
19	.7621	.7545		.7316	.5658	.7545	.5658
20	.5716	.7545		.7316	.5658	.7545	.5601
21	.5716	.905		.5658	.5658	.5658	.7316
22	.5716	.7545		.5601	.5658	.5658	.5658
23	.5716	.5658		.3772	.3772	.381	.3772
24	.3772	.381		.3772	.3772	.3772	.1905
Max	.7621	.905	.7468	.9145	.7545	.9145	.9335
Min	.1886	.3772	.3696	.3772	.3772	.1905	.1886
Avg	.4599	.6147	.5830	.4758	.5546	.4872	.3931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 205 / HISODA BK

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	1.086	.9145		1.086	.7545	.5716
2	.5601	1.0974	.7316		1.0974	.5658	.5716
3	.7316	1.086	.905		1.086	.5658	.5716
4	.905	1.2536	1.2536		1.4022	.7468	1.1317
5	1.0974	1.5775	1.2403		1.4022	.9335	1.5089
6	1.5775	1.7147	1.4022		1.4022	1.0402	1.6804
7	2.4006	1.8861	1.8861		1.7147	1.3717	1.8671
8	2.5434	2.0576		2.6292	1.8861		
9	2.0576	1.7147		1.949	1.7147		
10	.3772	.7545		.7316	.381	1.5089	1.7147
11	.5658	.3772		.5601	.381	1.5089	1.8861
12	.7545	.3772		.3772	.381	1.8861	1.7147
13	.381	.3772		.3772	.381	1.8861	1.7147
14	.381	.3772		.3772	.381	2.0748	1.7147
15	.381	.3772	.3772	.5601	.381		
16	.5716	.3772		.5601	.5658	1.6975	
17	.9431	.7545		.7316	.7468	1.8861	
18	1.5089	1.2003		1.4022	1.1203	1.1317	1.2403
19	1.3203	1.0517		1.086	1.0631	1.1317	1.086
20	.9431	.905		1.0745	1.0631	.9431	1.0745
21	.7545	.7545		.905	.9431	.9431	.5601
22	.7545	.7545		.7316	.9335	.7545	.5601
23	.5658	.7545		1.086	.7545	.5658	.7316
24	.5658	1.1317	1.0402	1.3203	1.0745	.7545	.5716
Max	2.5434	2.0576	1.8861	2.6292	1.8861	2.0748	1.8861
Min	.3772	.3772	.3772	.3772	.381	.5658	.5601
Avg	.9667	.9916	1.0834	.9682	.9726	1.1739	1.1827

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 201 / HASNABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.1619	.3734	.1829	.3772
2	.3772		.3239	.3734	.1829	.3772
3	.3772		.3239	.3734	.1829	.3772
4	.3772		.3239	.3734	.1829	.3772
5	.5658		.4858	.5658	.3658	.5658
6	.7545		.4858	.7545	.5487	.7468
7	.9335		.4858	.9335	.5487	.5658
8	1.1203		.4858	.5601	.5487	.5601
9	1.307	.3658	.5658		.5487	.7545
10	1.2803	.3658	.5601	.5601	.3658	.1619
11		.1619	.3734	.1829	.5601	.1619
12		.1619	.3734	.1829	.3734	.1619
13		.1619	.3734	.1829	.3734	.1619
14		.1619	.3734	.1829	.3772	.1619
15		.8097	1.307	.9145	1.4937	1.1336
16		.8097	1.307	1.0974	1.5089	1.1336
17			1.3203	1.0974	1.3203	.9717
18		.8097	1.1203	.9145	1.1317	.9717
19		.6478	.9335	.7316	.9431	.8097
20		.8097	.7468	.5487	.7545	.6478
21		.7773	.7468	.5487		.6478
22		.8097	.5601	.3658	.7545	.6478
23			.3734	.1829	.3772	.3239
24	.3772	.1619		.3734	.1829	.3772
Max	1.307	.8097	1.3203	1.0974	1.5089	1.1336
Min	.3772	.1619	.1619	.1829	.1829	.1619
Avg	.7134	.5011	.6135	.5380	.6004	.5490



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 202 / LATIFPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.6478	.9335	.9145	.7545
2	.3772		.6478	.9335	.9145	.7545
3	.3772		.8097	.9335	.9145	.7545
4	.3772		.9717	.9335	.9145	.7545
5	.7545		.9717	1.1317	1.0974	.9431
6	.9335		1.1336	1.307	1.2803	1.1317
7	1.1203		.6478		.9145	.7468
8	.9431		.4858	.9335	.9145	.7468
9	.7468	.7316	.5658	.7545	.7316	.7545
10	.5487	.5487	.5658	.5601	.5487	.3239
11		.3239	.3734	.3658	.3734	.3239
12		.3239	.3734	.1829	.3734	.1296
13		.1619	.3734	.1829	.3734	
14		.1943	.3734	.1829	.3772	.3239
15		.1619	.3734	.1829	.3734	
16		.1619	.3734	.1829	.3772	.4534
17		.3239	.5601	.5487	.3772	.4858
18		.4858	.7468	.5487	.7545	.6478
19		.4858	.9335	.9145	.9431	.6478
20		.4858	.7468	.7316	.7545	.6478
21		.3239	.5601	.5487	.5658	.4858
22		.3239	.3734	.3658	.5658	.3239
23			.9431	.9145	.7545	.8097
24	.3772	.8097		.9335	.9145	.7545
Max	1.1203	.8097	1.1336	1.307	1.2803	1.1317
Min	.3772	.1619	.3734	.1829	.3734	.1296
Avg	.6303	.3898	.6327	.6612	.7093	.6227

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 204 / NIMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829		.1619	.2614	.2926	.2452
2	.2641		.1619	.2614	.2926	.2452
3	.2829		.3239	.2614	.3658	.2641
4	.3395		.4858	.3361	.439	.3395
5	.5281		.6478	.5281	.7316	.5281
6	.7468		.8097	.7922	.8413	.7468
7	1.307		.4858	.9335	.7316	.7842
8	1.4937		.6478	.5228	.6219	.6979
9	1.4937	.439			.4755	.4904
10	1.4632	.2561	.2427	.2614	.2926	.1619
11		.1296	.1867	.1829	.1867	.1457
12		.0972	.1494	.1097	.1494	.0972
13		.1296	.112	.1097	.1494	.1134
14		.0972	.112	.1097	.1509	.0972
15		1.2955	1.1203	1.0974	1.6804	1.6194
16		1.2955	1.4937	1.3535	1.8861	1.6032
17		1.2955	1.6804	1.2803	1.6975	1.1336
18		1.2955	1.4937	1.3169	1.6975	.9717
19		.9717	1.307	1.0974	1.3203	1.1336
20		.8097	1.1203		1.1317	.9717
21		.8097	1.1203	.9145	.9431	.8097
22		.8097	.9335	.8048	.9431	.8097
23			.2614	.2926	.2452	.4858
24	.2829	.1619		.2614	.2926	.2452
Max	1.4937	1.2955	1.6804	1.3535	1.8861	1.6194
Min	.2641	.0972	.112	.1097	.1494	.0972
Avg	.7713	.6596	.6845	.5950	.7316	.6142

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 205 / KHADKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975		.3239		.5487	.5658
2	1.6221		.3239	.5415	.5487	.5658
3	1.5466		.4858	.5415	.5853	.5658
4	1.5089		.6478	.5975	.6584	.7167
5	1.6975		.8097	.8676	.8779	.9808
6	1.7924		.9717	1.2449	1.1706	1.1317
7	1.1949		1.6194	.7468	2.0119	
8	1.1203		1.6194	1.9605	2.1216	
9	.9896	2.7069	2.2634	2.3388	2.3045	
10	.823	2.524	2.2634	2.3777	2.3045	1.4575
11		2.4291	2.3152	2.1948	2.3152	1.4575
12		1.9433	2.1658	2.1216	2.2965	1.5061
13		.1619	2.0725	1.8656	2.0351	1.4899
14		1.2955	1.7364	1.7193	1.9993	1.6194
15		.2429	.2241	.2561	.2614	.1296
16		.1619	.2614	.2926	.2829	.1619
17		.4049	.4108	.5121	.5093	.4858
18		.7287	.8402	.8413	.8865	.4858
19		.7287	1.1203	1.1523	1.2071	.4858
20		.7287	.9335	.9145	.9431	.5668
21		.4858	.7655	.8413	.7545	.4049
22		.4049	.6722		.6036	.4049
23			.5788	.5487	.5658	.3239
24	1.8861	.4858			.5487	.5658
Max	1.8861	2.7069	2.3152	2.3777	2.3152	1.6194
Min	.823	.1619	.2241	.2561	.2614	.1296
Avg	1.4435	1.0289	1.1054	1.1656	1.1809	.7653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 206 / RAJALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.8097	.9335	1.0974	1.1317
2	.3772		.8097	.9335	1.2437	1.1317
3	.415		.8097	.9335	1.2803	1.1317
4	.4904		1.1336	1.1203	1.2803	1.1317
5	.6413		.3401	1.3203	1.2803	1.3203
6	.8029		1.4575	1.5089	1.4632	1.4937
7	.8962		.6478	.6908	.7682	.8029
8	.9335		.4858	.6161	.5487	.6979
9	.5601	.439	.4527	.3584	.4755	.5658
10	.3841	.3292	.2829	.2987	.2926	
11		.1619	.1867	.1829	.2241	
12			.2241	.1829	.1867	.1619
13		.1619	.2241	.1829	.2241	.1619
14		.1619	.2241	.2195	.2263	.1296
15		.1619	.2801	.2195	.2614	.1943
16		.1619	.2987	.2926	.2829	.2591
17		.3239	.3361	.4024	.4338	.4049
18		.4858	.6348	.5487	.679	.4858
19		.4858	.8029	.7682	.7922	.4049
20		.4858	.5415	.6584	.6413	.4858
21		.4858	.5228	.5487	.5658	.5668
22		.3239	.4108	.439		.4858
23			.9335	.9145	1.1317	1.4575
24	.3961	1.2955		.9335	1.2803	1.1317
Max	.9335	1.2955	1.4575	1.5089	1.4632	1.4937
Min	.3772	.1619	.1867	.1829	.1867	.1296
Avg	.5704	.3903	.5587	.6337	.7243	.7153

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 201 / DHAWDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3601	.3086	.2743	.3429	.3086	.2401
2	.3429	.3086	.3258	.3258	.3772	.3429	.2743
3	.5144	.3429	.3429	.3772	.3772	.0446	.3086
4	.7716	.5487	.5144	.4801	.5144	.583	.5144
5	.8573	.6859	.6859	.583	.5487	.5487	.6001
6		.0789	.7373	.7716	.583	.6859	.6516
7		.8745	.823	.9088	.583	.7545	.6859
8					.6687	.8916	.7545
9		.463			.6344	.9259	.703
10	.5144	.3772		.4973	.5658	.8916	.6859
11	.5487	.3601		.4973	.6859	.7373	.6516
12	.5144	.4115	.5144	.4115	.583	.6859	.5487
13		.3944	.4801	.463	.4973	.6001	.4801
14		.3944	.4458	.4973	.3772	.4115	.4115
15	.5144	.4115	.3772	.4287	.4458	.4287	.3601
16	.5487	.4458	.4458	.463	.5658	.5144	.5487
17	.5144	.5316	.5487	.5658	.5487	.6687	.8059
18	.5487	.6001	.7716	.6687	.7545	.8745	.7545
19	.6687	.6344	.7373	.7373	.7888	.823	.703
20	.5144	.5144	.583	.6173	.6173	.6859	.6859
21	.5316	.4287	.5487	.4458	.0549	.5658	.5487
22	.463	.3258	.3944	.3944	.3772	.5487	.4801
23	.3601	.2915	.3429	.3772	.3086	.5144	.4115
24	.3429	.3772	.2743	.1886		.3086	.2058
Max	.8573	.8745	.823	.9088	.7888	.9259	.8059
Min	.3429	.0789	.2743	.1886	.0549	.0446	.2058
Avg	.5230	.4418	.5101	.4988	.5131	.5977	.5423

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 202 / WALSAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.5487	.4458	.4801	.5144	.583	.5487
2	.8573	.6173	.4801	.5487	.6173	.5487	.6001
3	.8573	.703	.5144	.583	.6859	.5658	.6859
4	.8916		.583	.6516	.7545	.6173	.8573
5	.7888	.8402	.703	.7202	.8573	.6516	.8916
6	1.1145	1.0974	.7545	.823	.9259	.703	.9945
7	1.2003	1.0631	1.0631	1.166	1.0117	.9088	1.0288
8	1.2517	1.0288		1.3375	.9088	.9774	.8745
9	.823	1.0974		1.1317	.6516	.8573	.7202
10	.5144	.5487		.463	.9602	.6173	1.2003
11	.4973	.5316		.4115	1.3717	1.286	1.2346
12	.3429	.2743		.3258	1.3889	1.406	1.3546
13		.2572		.3086	1.4232	1.3717	1.3375
14		.2572	.3772	.2572	1.4403	1.3375	1.2689
15		.2743	.4115	.2572	1.4403	1.2517	1.0802
16	.3429	.3772	.5144	.3258	1.3717	1.166	1.046
17	.5487	.583	.6001	.5316	1.3889	1.0288	1.0288
18	.6687	.6859	.4973	.7888	.9774	.8573	.7202
19	.583	.7373	.5487	.8745		.823	.7545
20	.5144	.6001	.4458	.703	.8573	.7202	.703
21	.4458	.5487	.4115	.6001	.7202	.6173	.6859
22	.3601	.5658	.3429	.583	.5316	.583	.5487
23	.583	.5487	.4458	.5487	.5658	.5487	.5144
24	.5144	.0874	.4458	.5316		.5487	.5487
Max	1.2517	1.0974	1.0631	1.3375	1.4403	1.406	1.3546
Min	.3429	.0874	.3429	.2572	.5144	.5487	.5144
Avg	.6932	.6032	.5325	.6230	.9711	.8573	.8845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 203 / BHORKHEDA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2058	.2058	.2229	.1029	.1029	.0857
2	.4115	.3086	.2401	.2743	.1543	.0686	.0857
3	.5144	.3601	.2743	.3086	.1715	.0857	.1029
4	.7202	.4458	.3086	.3601	.2058	.12	.1029
5	.6516	.5487	.3429	.3944	.2743	.1372	.1372
6	.7716	.0617	.3601	.4801	.3086	.1715	.2058
7	1.0288	.7202	.823	.8059	.3429	.2743	.2915
8	1.0974	.7373		.9945	.2743	.2229	.2229
9	.8573	.6859		.7202	.2229	.2058	.1372
10	.1029	.6173		.0686	.5316	.4115	.5144
11	.0857	.1029		.0686	.6344	.5144	.5487
12	.0857	.0514		.0343	.703	.823	.6516
13		.0514	.0686	.0171	.8573	.7373	.6859
14		.0514	.0686	.0171	.823	.7373	.7202
15	.0514	.0343	.0686	.0343	.7888	.7716	.5144
16	.0686	.0686	.1029	.0343	.6516	.6344	.5144
17	.12	.12	.12	.1029	.6859	.6001	.463
18	.2229	.1715	.2401	.2058	.1715	.2058	.2058
19	.2743	.2058	.2743	.2572	.2401	.1715	.1715
20	.2058	.1372	.1543	.2058	.2058	.1372	.1372
21	.1715	.1029	.1372	.1543	.1029	.12	.12
22	.1029	.1029	.1029	.1372		.1029	.1029
23	.1029	.1029	.1029	.1029	.0572	.0857	.0857
24	.1886	.1886	.1886	.1029		.1029	.0857
Max	1.0974	.7373	.823	.9945	.8573	.823	.7202
Min	.0514	.0343	.0686	.0171	.0572	.0686	.0857
Avg	.3718	.2576	.2202	.2543	.3868	.3144	.2872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 204 / JAIDEVWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3601	.2743	.3086	.4458	.3086	.4801
2	.4115	.3429	.3086	.3772	.5144	.3429	.5144
3	.3772	.3086	.3258	.4115	.5487	.3944	.6173
4	.5487	.2915	.3429	.6173	.6859	.4458	.8573
5	.6173	.3944	.6001	.6516	.703	.5487	.9431
6	.6516	.0617	.6687	.7716	.7202	.0617	.9602
7	.6859	.703	.6859	.7888	.7202	.7888	.9602
8	.7202	.4973			.7888	.9945	1.166
9	.4458	.4458			.6516	1.0288	.8916
10	.5144	.463		.6859	.4287	.2743	.3258
11	.6001	.6001		.7202	.2915	.2229	.3086
12	.6173	.8916	.7545	.7545	.2229	.1715	.2229
13		.9088		.7888	.1886		.2058
14		.8573		.7888	.1886		.1715
15		.7888	.823	.6859	.2229		.1886
16	.5487	.703	.7716	.7202	.2572		.2229
17	.6173	.5487	.6516	.583	.2743	.463	
18	.5487	.4287	.4458	.6173	.583	.6859	.3429
19	.583	.4458	.7373	.5144	.7545	.6001	.3772
20	.5487	.3944	.6344	.4801	.6344	.5144	.3601
21	.5144	.3429	.583	.4458	.5487	.463	.3429
22	.4287	.2743	.4287	.4115	.4458	.4458	.3086
23	.3601	.2401	.3772	.3772	.3429	.4115	.2915
24	.3429	.3258	.2401	.2915		.0154	.4458
Max	.7202	.9088	.823	.7888	.7888	1.0288	1.166
Min	.3429	.0617	.2401	.2915	.1886	.0154	.1715
Avg	.5250	.4841	.5363	.5814	.4853	.4591	.5002



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 201 / Relgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.6401	.0625	.6097	.6554
2		.6554	.6706	.5944	.6706	.6706
3		.6401	.6859	.6097	.7316	.6859
4		.6249	.7316	.6554	.7773	.7011
5		.6706	.8078	.6706	.8078	.7164
6		.7164	.9145	.7468	.8383	.7316
7		.8535	1.1431	.8383		.9907
8		1.2498	1.326	1.4784		1.0822
9		1.6309	1.6309	1.4784	1.3108	1.4784
10	2.21		1.6156	1.4327	1.4327	1.5242
11	2.1643		1.5546	1.4632	1.4632	1.5394
12	1.9357		1.5699	1.5089	1.5089	1.5851
13	1.6918		1.5394	1.448	1.448	1.5242
14	1.6613		1.5546	1.448	1.4175	1.4327
15	1.6004		1.4632	1.3565	1.3565	1.2193
16	.7164			.2439	.2439	.1981
17	.6859			.442	.4572	.4115
18	.7621		.5182	.6859	.5639	.5182
19			.5639	.7011	.5639	.4572
20			.7468	.7316	.5487	.4877
21			.7316	.7011	.5335	.503
22			.7164	.6706	.442	.5335
23			.5944	.6401	.442	.5792
24		.6554		.6097	.5944	.4268
Max	2.21	1.6309	1.6309	1.5089	1.5089	1.5851
Min	.6859	.6249	.5182	.0625	.2439	.1981
Avg	1.4920	.8383	1.0342	.8841	.8528	.8605

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 202 / Pimpalgaon R

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.3963	.3963	.4572		.503
2		.3963		.4115	.3201	.3048	.5182
3		.442		.442	.3353	.3353	.5335
4		.4725		.4725	.3658	.4268	.5487
5		.5182		.4725	.4115	.4268	.5639
6		.7164		.4877	.4725	.6097	.5944
7		.8383		.381	.4115	.6706	.5792
8		.7164		.3506	.3353	.6401	.5487
9		.6401		.5639	.3048	.6249	.6859
10	.442	.6401		.503	.3353	.5182	.5792
11	.4268			.4725	.381	.4572	.3353
12	.4115	.3506		.4572	.3353	.4268	.2591
13	.3963			.6097	.3353	.442	.381
14	.5792			.6554	.5944	.4572	.5944
15	.5639			.6401	.5792	.442	.0564
16	.5792			.6097	.5487	.4115	.5182
17	.5639			.6097	.5182	.442	.503
18	.5182			.6249	.503	.4725	.5335
19				.5944	.4572	.381	.4572
20				.5639	.4268	.3048	.4877
21				.4725	.3048	.2591	.2743
22				.4268	.2743	.2743	.2591
23				.4877	.2896		.2743
24		.442	.3963		.4725	.3048	.4572
Max	.5792	.8383	.3963	.6554	.5944	.6706	.6859
Min	.3963	.3506	.3963	.3506	.2743	.2591	.0564
Avg	.4979	.5487	.3963	.5089	.4071	.4378	.4602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 203 / LEHA/SHELUD FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.884	.6401	.4725	.6097
2			.7926	.6097	.5182	.6401
3			.823	.6249		.6706
4			.884	.7468	.6706	.6859
5			.7468	.8078	.8078	.7011
6			.7621	.8993		.7316
7			.8078	.7926	1.0517	.7621
8			.8535	.8535	.9907	.884
9			.7011	.7621	.8383	.8535
10	.7316		.6706	.8383	.5487	
11	.7164		.6249	.4115	.3353	
12	.7164		.442	.2591		
13	.6706		.2743	.2439	.2134	.2286
14	.2286		.2286	.2286	.1829	.2134
15	.2134		.2591	.3353	2.2862	.2743
16	1.8595		2.332	2.1338	2.4387	2.5911
17	1.7071		2.5758	2.1643	2.2862	2.3167
18	1.7833		2.0881	2.0271	2.1643	2.1948
19			1.8442	1.5242	1.7528	1.5851
20			1.8595	1.2651	1.3717	1.5242
21			2.0881	1.2193	1.1431	1.2803
22			2.1338	1.1431	.9907	1.2498
23			1.8595	1.2041	.8535	1.2193
24		.7468		.5335	.4572	.3658
Max	1.8595	.7468	2.5758	2.1643	2.4387	2.5911
Min	.2134	.7468	.2286	.2286	.1829	.2134
Avg	.9585	.7468	1.1537	.9278	1.0655	1.0277

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 204 / PARADH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5546	1.2955	1.2803		1.3717
2		1.6309	1.3717	1.3108	1.0364	1.4022
3		1.6613	1.4175	1.3717	1.0669	1.448
4		1.6918	1.4937	1.448	1.1126	1.4937
5		1.7071	1.2651	1.5089		1.5089
6		1.6613	1.2955	1.5394		1.5242
7		1.6613	1.2193	1.6004		1.6004
8		1.0212	1.1431	1.1431	1.4175	1.0059
9		.7773	.945	.7773	.945	.8688
10	.823		.7773	.8383		.6097
11	.7926		.6554	.5487	.6401	.7316
12	.7621		.4725	.442	.5792	.503
13	.6401		.4115	.4268	.503	.4725
14			.3658	.3963	.4572	.4877
15	.4115		.4115	.4268		.4572
16	.3201		.4877	.4572		.4268
17	.5639		.6097	.6249		.5944
18	.8993		.8383	.7926	.7621	.8688
19			.8993	.823	.6859	.823
20			.945	.8535	.6097	.7621
21			.8688	.7316	.5335	.6401
22			.8535	.5639		.6249
23			.6401	.5944	.4268	.6401
24		1.4784		1.2651	.9297	1.2651
Max	.8993	1.7071	1.4937	1.6004	1.4175	1.6004
Min	.3201	.7773	.3658	.3963	.4268	.4268
Avg	.6516	1.4845	.8993	.9069	.7804	.9221

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 205 / Awghadrao sawangi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.2743	.3048		.1677
2		.3963	.3048	.2896	.3048	.1829
3		.4115	.3353	.3048	.3353	.1981
4		.3963	.3506	.3353		.2134
5		.442	.3201	.3506	.3963	.2401
6		.4725	.3963	.381		.3048
7		.4877	.4572	.4725	.5487	.381
8		.5182	.5792	.5182		.5182
9		.503	.5182	.4725	.5335	.442
10	.4725		.5335	.4572	.4268	.4572
11	.4725		.5182	.442	.4268	.442
12	.4572		.4115	.3963	.4115	.2286
13	.3963		.3353	.4115		.3048
14	.2591		.2286	.4268	.1372	.2286
15	.2439		.2591	.3048	.381	.2591
16	.2286		.3353	.2591	.4572	.2743
17	.4115		.4268	.4268	.5182	.442
18	.6401		.3963	.5182	.5487	.503
19			.4877	.5182	.503	.4877
20			.5944	.5182	.4268	.4572
21			.5792	.4268	.3658	.3658
22			.5335	.2896	.2286	.381
23			.4877	.2591	.1677	.4268
24		.4115		.3201	.2134	.1677
Max	.6401	.5182	.5944	.5182	.5487	.5182
Min	.2286	.381	.2286	.2591	.1372	.1677
Avg	.3980	.442	.4201	.3918	.3859	.3364

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 201 / KEDARKHEDA ag1

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097						
2	.4607						
3	.4755						
4	.5335						
5	.5335						
6	.6097						
7	.7655						
8	1.0774						
9	1.0227						
10		.8206				.6984	.8097
11		1.1431				.9686	1.0322
12		1.2176			1.5242	.9842	1.0814
13		1.2492				.8749	1.065
14		1.0364				.8436	.9145
15		.9762		1.0479		.7164	
16		.7316	.9145			.7468	
17		.9189	.8764	.7621	.8162	.7407	.7407
Max	1.0774	1.2492	.9145	1.0479	1.5242	.9842	1.0814
Min	.4607	.7316	.8764	.7621	.8162	.6984	.7407
Avg	.6765	1.0117	.8955	.905	1.1702	.8217	.9406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 202 / DEOLGAON TAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.6859	.7773	.8065	.7316	.8192	.8764
2	.4001	.7011	.8078	.7907	.8535	1.0479	1.0098
3	.4763	.7468	.8078	.7907	.9488	1.2003	1.0883
4		.8124	.8905	.9488	1.0437	1.2146	1.2163
5		.8592	.9686	.9717	1.1822	1.3077	1.3108
6		.9374	1.2955	1.1336	1.2955	1.3916	1.3599
7		1.3123	1.5384	1.4582	1.4586	1.4419	1.4586
8		1.7814	1.8187	1.9227	1.8896	2.1963	1.8515
9		1.8461				2.1125	1.8842
10	1.1843						
11	.8192						
12	1.6964						
13	1.6762						
18				.1524	.1143	.2286	
19	.4001		.3429	.4572	.381	.4191	.4001
20	.4001	.3048	.3048	.4954		.362	.362
21	.4191		.3048	.2858		.2858	.2667
22	.4001	.2667	.2858	.2477	.2667	.2858	.2667
23	.381		.3239	.2477	.2667	.2477	.2096
24		.7316		.6249	.6249	.6093	.6093
Max	1.6964	1.8461	1.8187	1.9227	1.8896	2.1963	1.8842
Min	.381	.2667	.2858	.1524	.1143	.2286	.2096
Avg	.7211	.9155	.8051	.7556	.8505	.9481	.9447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 203 / KEDARKHEDA AG 2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429						
2	.3239						
3	.362						
4	.4001						
5	.4382						
6	.4382						
7	.4954						
8	.4572						
9	.5138						
10		.506				.4572	.5525
11		.5441				.6668	.6097
12		.6167			.6668	.6859	.5716
13		.5851				.6478	.5335
14		.6241				.5716	.5144
15		.5921		.4763		.4763	
16		.4696	.5335			.4572	
17		.5197	.4191	.4801	.3479	.3637	.3749
Max	.5138	.6241	.5335	.4801	.6668	.6859	.6097
Min	.3239	.4696	.4191	.4763	.3479	.3637	.3749
Avg	.4191	.5572	.4763	.4782	.5074	.5408	.5261



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 204 / DEOLGAON TAD G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	.1334	.1143		.1524	.1524
2	.1334	.1334	.1334	.1334	.1905	.1905	.1905
3	.1715	.1334	.1524	.1715	.3429	.2858	.3048
4	.2477	.2286	.2096	.2286	.4954	.4382	.4954
5	.4191	.4001	.3429	.381	.5335	.4763	.5335
6	.5525	.4763	.5144	.5716	.5716	.5335	.5335
7	.4382	.5144	.5716	.5525	.5716	.5525	.5716
8	.3429	.4763	.4763		.5144	.5144	.5335
9	.4001	.4382				.3429	.4001
10	.381	.2477				.2096	.2096
11	.1143	.1143				.1143	.1143
12	.0953	.0762			.381	.0953	.1143
13	.0953						.1334
14						.0953	.0953
15				.1143		.1143	
16		.1334	.1905			.2096	
17		.2286	.1905	.2096	.2096	.2667	.1715
18		.3429	.4001	.3239	.362	.3048	.3239
19	.4954		.5525		.5525	.5525	.5335
20	.3429	.1905	.362	.4001		.362	.362
21	.2286		.2286	.2286	.2096	.1905	.2286
22	.1715	.1524	.1905	.1524	.1715	.1715	.1905
23	.1334		.1334	.1334	.1524	.1524	.1524
24		.1143		.1524	.1334	.1524	.1334
Max	.5525	.5144	.5716	.5716	.5716	.5525	.5716
Min	.0953	.0762	.1334	.1143	.1334	.0953	.0953
Avg	.2720	.2509	.2989	.2578	.3595	.2816	.2945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 205 / KEDARKHEDA G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.4572	.3429	.4001	.4191	.4191	.4763
2	.3429	.4382	.3429	.381	.5335	.5335	.6287
3	.381	.4763	.381	.4763	.6859	.724	.743
4	.4763	.5716	.7049	.6859	.7621	.8573	.8596
5	1.1203	1.086	.8573	.8954	.9145	1.1523	1.0059
6	1.4003	1.307	1.134	1.2136	1.0456	1.2437	1.2696
7	1.3817	1.3443	1.2803	1.1949	1.1763	1.307	1.307
8	1.363	1.1812	1.1888		1.307	1.2323	1.251
9	1.1812	1.0288				1.1203	1.0642
10	.8573	.4763				.6668	.7049
11	.5335	.381				.381	.4191
12	.4001	.3048			.4763	.2858	.3048
13	.3048					.2477	.2858
14						.2477	.2286
15				.3048		.2286	
16		.4382	.3239			.3048	
17		.5716	.6478	.5716	.724	.5335	.5335
18		.9717	.9907	.9145	.9526	.9145	.9335
19	1.2193		1.251	1.3146	1.2574	1.3146	1.2574
20	.9907	.8192	.9145	.9717		.9335	.9717
21	.7049		.6668		.6287	.6859	.7049
22	.5716	.4763	.4954	.4763	.4001	.4191	.5335
23	.4954		.4382	.362	.4001	.4001	.4001
24		.2858		.4001	.362	.362	.4001
Max	1.4003	1.3443	1.2803	1.3146	1.307	1.3146	1.307
Min	.3048	.2858	.3239	.3048	.362	.2286	.2286
Avg	.7805	.7009	.7475	.7042	.7528	.6881	.7401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 201 / Surangli AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001			.1715	.2058		.2572
2	.583			.1715	.2572		.3429
3	.583			.2572	.3772		.4287
4	.6687						
5	.8402						
6	.8916						
8	.463						
9	.5316						
10		.8573	1.0631	1.0117		1.0288	1.0117
11		1.2689	1.2689	1.0974		1.3717	1.1145
12		1.8004	1.4403	1.1831		1.4575	1.2174
13		1.7147	1.4918			1.4575	1.2689
14		1.286	1.3032	1.4403		1.3717	1.1831
15		1.3717	1.286	1.2689	1.4523	1.286	1.1145
16	.2058		1.3375	1.2174		1.2003	1.1488
17			1.1145	1.2346		1.1145	1.1488
18			.3944			.4287	.4115
19			.463	.4458		.4801	.5316
20		.3429	.3772	.3258		.4287	.3772
21		.2915	.3086	.2572		.3429	.3258
22			.2572	.2229		.2572	.2572
23			.2058	.2058			.2401
24	.2058	.2229	.2572	.4287	.2058		.2401
Max	.8916	1.8004	1.4918	1.4403	1.4523	1.4575	1.2689
Min	.2058	.2229	.2058	.1715	.2058	.2572	.2401
Avg	.5573	1.0174	.8379	.6837	.4997	.9404	.7011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 202 / KATHORA BAZAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018			.2829	.3584		.3772
2	.3018			.2829	.3772		.415
3	.3395			.3395	.415		.4115
4	.4527			.4715	.4715		.5144
5	.5658			.7167	.6036		.6602
6	.6224			.811	.7545		.7922
7	.6602			.6979	.7922		.6602
8	.5281				.7545		.4904
9	.6224		.5144	.6036	.5658		.4338
10	.5144		.415	.4715	.3429	.5281	.3584
11	.3429	.2641		.3961		.4287	.3395
12	.2829	.2263					.2641
13						.3086	.2075
14				.2263		.2829	.2263
15		.2401	.3395	.1509		.2401	.2075
16			.4715	.2263		.3429	.3018
17			.5281			.4287	.3086
18			.811			.6602	.6602
19			.7733	.7733		.7545	.7733
20		.5281	.547	.5281		.4801	.5281
21		.4287	.4338	.4715		.3772	.4527
22			.3772	.4338		.3772	.3961
23			.3018	.3584			.3395
24	.3772	.3772	.3961	.679	.3584		.3086
Max	.6602	.5281	.811	.811	.7922	.7545	.7922
Min	.2829	.2263	.3018	.1509	.3429	.2401	.2075
Avg	.4548	.3441	.4924	.4695	.5267	.4341	.4345

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 203 / Dagadwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514			.1029	.1886		.2572
2	.0514			.1029	.2058		.3429
3	.0686			.1715	.2401		.4115
4				.1372	.3258		.4287
5				.1372	.583		.5144
6				.1715	.6001		.6001
7				.5316	.6687		.6859
8				.7716	.6516		.7202
9			.8573	.5144	.6173		.6173
10	.3772						
11	.5144						
12	.5487						
13	.5144						
14	.5144						
16	.6001		.1029	.0514			.0514
17			.1715	.0857		.0857	.0686
18			.0686			.1029	.12
19			.1029	.1543		.1029	.12
20		.0857	.1029			.0857	.1029
21		.0857	.0857	.0857			.1029
22			.0857	.0686		.0686	.1029
23			.0686	.0686			.0686
24	.6001	.1715	.0857	.1372	.1543		.2572
Max	.6001	.1715	.8573	.7716	.6687	.1029	.7202
Min	.0514	.0857	.0686	.0514	.1543	.0686	.0514
Avg	.3841	.1143	.1732	.2058	.4235	.0892	.3096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 205 / Danapur GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452			.1698	.1509		.3772
2	.2829			.1698	.1698		.415
3	.3395			.2263	.2641		.4527
4	.5093			.5281	.4527		.4715
5	.6036			.6036			.5144
6	.679			.7356	.7922		.7545
7	.8676			.9808	.9054		.703
8	.8299				.7733		.5658
9	.7922		.4287	.7733	.6979		.4715
10	.5658	.4287	.2075	.4115	.4287	.3772	
11	.3772	.2572		.3772		.2572	.3429
12	.2401	.2229		.2641		.2058	
13		.2229		.2452		.2263	.132
14				.1509		.1886	.132
15		.2572	.2641	.1509		.1886	.1132
16	.2572		.3206	.2263		.2075	.1543
17			.415	.3772			.2641
18			.7545			.6001	.6036
19			.7356	.8488		.7545	.6979
20		.6859	.4338	.5658		.6602	.3395
21		.4287	.3584	.3584		.4287	.2263
22			.3018	.2641		.2058	.132
23			.2263	.2075			.0943
24	.2452	.415	.415	.7356	.1698		.3772
Max	.8676	.6859	.7545	.9808	.9054	.7545	.7545
Min	.2401	.2229	.2075	.1509	.1509	.1886	.0943
Avg	.4882	.3648	.4051	.4259	.4805	.3584	.3789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 206 / GODRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2743	.3772	.2572
2				.3258	.3944	.2572
3				.3429	.3944	.2743
4				.3429	.4115	.3086
5				.3772	.4973	.4287
6				.5144	.703	.5144
7				.9945	1.166	.9774
8				1.6289	1.166	1.3717
9			1.3375	1.166	1.4746	1.2689
10	.8916					
11	1.1145					
12	1.286					
13	1.2174					
14	1.2003					
16	1.0288					
24	1.0288	.1715	.3429		.3944	.2572
Max	1.286	.1715	1.3375	1.6289	1.4746	1.3717
Min	.8916	.1715	.3429	.2743	.3772	.2572
Avg	1.1096	.1715	.8402	.6630	.6979	.5916

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 207 / KARKHANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0686	.1029		.0857
2				.0857	.1029		
3				.1029	.12		.1029
4				.1029	.12		.12
5				.1372	.1543		.1372
6				.1372	.2743		.1715
7				.3772	.3086		.2572
8				.5144	.3429		.5144
9			.4115	.4458	.4801		.3772
10	.1886						
11	.2572						
12	.3429						
13	.3429						
14	.3086						
16	.2915						
24	.2915	.0857	.0857		.12	.12	.0857
Max	.3429	.0857	.4115	.5144	.4801	.12	.5144
Min	.1886	.0857	.0857	.0686	.1029	.12	.0857
Avg	.2890	.0857	.2486	.2191	.2126	.12	.2058



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 208 / KATHORA BAZAR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2689						
2	1.3032						
3	1.2346						
4	1.3889						
5	1.4746						
6	1.5261						
7	1.8176						
8	1.9204						
9	1.6461						
10		1.3717	1.8861	1.7318		1.7147	1.5261
11		1.8861	2.2291	1.8519	1.7833	1.9719	1.749
12		1.9719	2.2634	1.989		2.0576	1.8519
13			2.4006	2.0576	1.8861	2.0919	1.9033
14		2.0576	2.1091	2.0919		1.8519	1.9204
15		2.1434	2.2291	2.0748		1.8519	1.8347
16			2.3148	2.0919	1.8861	1.7147	1.8176
17			2.0233	1.7318		1.5432	1.8004
Max	1.9204	2.1434	2.4006	2.0919	1.8861	2.0919	1.9204
Min	1.2346	1.3717	1.8861	1.7318	1.7833	1.5432	1.5261
Avg	1.5089	1.8861	2.1819	1.9526	1.8518	1.8497	1.8004

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 201 / NALNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.9221	.9724	.788	.9945	.8048	1.1736
2	.4191	.8718	1.0059			.8215	1.2071
3	.503	.8383	1.0395	.8383		.8886	1.2742
4	.503	.8551	1.0898	1.0059		1.1401	1.358
5	.5868	.8383	1.1401	1.0898		1.3748	1.3413
6	.6706	.9556	1.1736	1.3077		1.4419	1.4586
7	.7545	1.2239	1.3916	1.5089	1.1603	1.8945	1.7772
8	.7545	1.2239	1.4251	1.5927	1.1603	1.9616	1.7939
9	.7209	.6706	.7209	.4191		.8215	.6874
10	.6706	.6371	.6371			.7545	
11	.5801	.5365	.4862	.4191		.6203	
12	.4144	.3688	.4191	.4694		.4694	
13	.3812	.4359	.4191	.503		.3688	
14	.3812	.3856	.4191	.3688	.2486	.3856	.3353
15	.3315	.3353	.4191	.3688	.3315	.3688	.4191
16	.2984	.3688	.4527	.4024	.4807	.4191	.4694
17	1.9062	.4527	.4527	.6036	.5967		.503
18	1.643	.6874	.6706	.7042	.8383	.7377	
19	1.3077	.6539	.6706	.8048	.8551	.8718	.8383
20	1.2071	.4862	.503	.5868	.7377	.6874	.6706
21	1.0059	.3688	.4191	.503	.6539	.6036	.4024
22	1.0059	.3353	.3353	.3353	.4359		.3353
23	.9724	.218	.285	.2347	.4024		.3353
24	.8192	.6539	.2012	.7042	.2347	.3688	.3353
Max	1.9062	1.2239	1.4251	1.5927	1.1603	1.9616	1.7939
Min	.2984	.218	.2012	.2347	.2347	.3688	.3353
Avg	.7607	.6385	.6979	.7072	.6522	.8479	.8798

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 202 / PIMPALGAON BARAV

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.5868	.3353	.503	.503	.4527	.503
2	.9831	.5365	.503	.503	.503	.4359	.503
3	1.065	.6371	.503	.503	.503	.5365	.503
4	1.1469	.788	.6706	.5868	.5868	.6539	.6706
5	1.3108	.9221	.8383	.5868	.7545	.7712	.6706
6	1.6385	.8383	.8383	.6706	.8383	.9221	.8383
7	1.7204		.8383	.7545	.9221	.788	.8383
8	1.8023	.7712	.8383	.6706	.6706	.4694	.6706
9	.6706	2.079	1.8442	1.5089	1.6766	1.7604	1.6766
10	.503	2.2466	2.0119	1.6766	1.8442	1.7939	1.6766
11	.431	2.1795	2.0119	1.7604	1.7404	1.7604	1.5089
12	.3149	2.0119	1.8442	1.8778	1.7939	1.6766	1.3413
13	.431	2.1795	1.6766	1.7604	1.7238	1.5089	1.5089
14	.431	2.0119	1.6766	1.6766	1.5912	1.3413	1.5089
15	.431	1.8442	1.8442	1.5424	1.6078	1.5089	1.5089
16	.4475	1.8442	1.6766	1.5089	1.6078	1.1736	1.3413
17	.5967	.3353	.3353	.3353	.431	.1677	.3353
18	.8048	.6706	.6706	.6706	.7712	.6706	.6706
19	.9221	.8383	.9221	.9724	.788	.8383	.9724
20	.8718	.6706	.6706	.7042	.7712	.6706	.8383
21	.7712	.6706	.6706	.5868	.6874	.503	.6706
22	.6203	.6706	.503	.503	.6036		.6706
23	.6036	.503	.503	.503	.503		.5868
24	.503	.6706	.503	.503	.503	.4359	.503
Max	1.8023	2.2466	2.0119	1.8778	1.8442	1.7939	1.6766
Min	.3149	.3353	.3353	.3353	.431	.1677	.3353
Avg	.8335	1.1525	1.0304	.9529	.9969	.9473	.9382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 203 / KHAPERKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3856	.2012	.2012	.2012	.2515	.2012
2	.4191	.3521	.1677	.2012	.2012	.285	.1844
3	.4191	.3856	.1844	.2347	.1677	.285	.1677
4	.4191	.4359	.2347	.285	.2347	.3185	.2012
5	.503	.4862	.2515	.3353	.2347	.3688	.285
6	.503	.6036	.2683	.503	.3353	.3856	.3018
7	.5868	.6203	.4024	.6706	.4694	.503	.3521
8	.5243	.6371	.4862	.5868	.5365	.5533	.3688
9	1.5074	.6036	.4527	.503	.5365	.5868	.3688
10	1.5565	.4527	.3185	.4191	.4191	.4024	.3521
11	1.6409	.3688	.3688	.4191	.431	.2683	.2683
12	1.7736	.3688	.3353	.3688	.4144	.2683	.285
13	1.6741	.3018	.3353	.3353	.431	.2515	.3018
14	1.5083	.3185	.3353	.3688	.431	.2347	.2515
15	1.6409	.3018		.3353	.4144	.2515	.2012
16	1.5912	.1844		.3353	.3647	.1509	.1677
17	.3812	1.9281	.3353	1.6741	1.6244	1.9113	1.9281
18	.5365	1.7604	1.6766	1.7072	1.7604	1.7604	1.6766
19	.5868	1.358	1.2574	1.326	1.5592	1.1904	1.3413
20	.5365	1.2574	1.1736	1.1736	1.1904	1.0562	1.1736
21	.4694	1.0898	1.0059	.9945	1.1401	.9724	1.0898
22	.4191	1.0898	.8383	.9945	1.073		1.0059
23	.3856	1.0562	.8048	.9945	1.0227		.9724
24	.4191	.3688	1.0059	.7545	.9945	.9724	.9054
Max	1.7736	1.9281	1.6766	1.7072	1.7604	1.9113	1.9281
Min	.3812	.1844	.1677	.2012	.1677	.1509	.1677
Avg	.8509	.6965	.5655	.6551	.6745	.6013	.5980

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134064 / 33 kv Pimpalgaon KO

Feeder No / Name : 201 / Pimpalgaon Ko SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.7621	.5487	.6859	.6859	.6554	.6097
2	.6249	.7926	.6097	.7621	.7621	.6859	.6554
3	.6859	.8078	.7316	.8383	.823	.7621	.7164
4	.7621	.884	.9145	.9145	.884	.9602	.7621
5	.8535	1.0364	1.0517	1.0517	.9907	1.0364	
6	1.0364	1.0517	1.0669	1.0669	1.0517	1.0517	
7	1.0669	1.0517			1.0364	1.0517	1.0669
8	1.2955		.7621	.8688	1.0517	1.0669	
9	1.4022	.9755	.8535	.9907	.945	.9145	1.0364
10	1.3108	.823	.5944	.7468	.6859	.823	.9145
11	1.1126	.4572		.5487		.4725	.4725
12	1.1279	.3201		.4115	.4572	.4572	.2743
13	1.1736	.2743	.3201	.2743	.381	.1219	
14	1.0517	.2743	.381	.2743	.3506		.2743
15	.3201	1.3565	1.0364	1.2193	1.2041	1.2955	.8383
16	.3658		1.0212	1.2955	1.4022	1.448	1.1736
17	.5792	1.4632	1.1888	1.448	1.3565	1.448	1.2955
18	1.0364	1.4632	1.0822	1.2955	1.2498	1.387	1.1279
19	1.0517	1.3108	1.0669	1.2803	1.2955	1.2498	.9907
20	1.0212	1.0974	.8993	1.1431	1.0669	1.0669	.6401
21	.9145	.8383	.884	.9602	.9145	.9602	.5792
22	.8535	.6859	.7926	.8535	.7468	.6554	.503
23	.8078	.6097	.6401	.6401	.6401	.6554	.6097
24	.7621	.5792		.6097	.6554	.6249	.4725
Max	1.4022	1.4632	1.1888	1.448	1.4022	1.448	1.2955
Min	.3201	.2743	.3201	.2743	.3506	.1219	.2743
Avg	.9107	.8598	.8223	.8774	.8973	.9065	.7507

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134064 / 33 kv Pimpalgaon KO

Feeder No / Name : 203 / Vazirkheda SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.3048	.2591	.3353	.2743	.3048	.2743
2	.4572	.3201	.2439	.3963	.3048	.3353	.2591
3	.4877	.3506	.3048	.4572	.3658	.3658	.3048
4	.6859	.4572	.381	.503	.4268	.442	.5335
5	.7926	.6401	.5792	.5792	.4877	.5944	.7011
6	.9145	.8078	.7926	.6401	.6097	.7164	.7926
7	.7926	.8383	.7164	.5335	.5792	.7316	.503
8	.8688	1.1431	.9907	.9145	.9145	.9297	.7621
9	.7621	1.3413	.7926	1.0212	.8383	.9907	.7621
10	.5792	1.3717	1.0059	.9145	.884	.9297	
11	.3658	1.3717	.945	.7621	.8078	.7621	.823
12	.3201	1.2193	.8688	.7316	.7316	.6859	.823
13	.1829	1.0669	.8078	.7316	.7011	.5944	.8383
14	.2896	.9145	.6859	.5487	.5792	.5487	.6401
15	.3048	.1067	.0914	.1219	.1524	.1372	.2286
16	.3353	.2286	.1677	.1524	.2439	.1829	.1829
17	.4115	.3201	.2743	.2591	.2896	.2439	.2591
18	.6097	.5487	.5487	.4572	.4877	.4725	.4572
19	.8535	.7621	.8688	.8383	.823	.7621	.7468
20	.6097	.6097	.6859	.6401	.6401	.6249	.7164
21	.4268	.4572	.442	.5335	.4877	.5182	.4572
22	.3658	.3201	.3201	.3353	.3506	.3201	.3048
23	.3048	.3048	.2896	.2896	.3201	.2743	.2743
24	.4877	.2743		.2591	.2743	.2896	
Max	.9145	1.3717	1.0059	1.0212	.9145	.9907	.8383
Min	.1829	.1067	.0914	.1219	.1524	.1372	.1829
Avg	.5309	.6700	.5679	.5398	.5239	.5316	.5293

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134065 / MALKHEDA

Feeder No / Name : 201 / AVANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	.8488	.9054	.823	.7545	.5853	.5853
2	1.094	.8488	.9431	.8688	.7922	.7133	.7133
3	1.1128	.9431	.9259	.905	.7922	.724	.823
4	1.094	.9431	.9431	.905	.9054	.8326	.9694
5	1.1317	.9431	1.0974	1.2071	1.094	1.0679	1.0317
6		.7545	1.3375	1.2803	***	1.3394	1.0679
7		.8488	1.4232	1.3352		1.7737	1.6832
8		.8676		1.828	2.037	1.8107	1.4842
9		.811	1.2346	1.226	1.6975	1.8656	1.8461
10	1.226	.8488	.9511	.9431	.8048	.9511	.8488
11	.811	.547	.4572	.5847	.3658	.5487	.679
12	1.0185	.4338	.439	.3772	.3801	.3841	.4904
13	1.5089	.3206	.4066	.3961	.3841	.3961	.4527
14	1.226	.3395	.3881	.4527	.4207	.3658	.5281
15	1.1317	.4527	.3881	.4338	.4435	.5121	.4904
16	1.0374	.5658	.5544	.4338	.6468	.5487	.5281
17	.9997	1.0562	.8501	.9997	.8413	.9795	.8676
18	1.0374	1.1317	1.46	1.1317	1.46	1.46	1.358
19	1.1694	1.358	1.46	1.1317	1.46	1.46	1.358
20	1.1317	1.0562	1.46	1.1317	1.4415	1.4712	1.094
21	1.0374	1.0185	1.4415	1.0751	1.4083	1.4266	1.0185
22	.9619	.9431	1.4045	1.094	1.3535	1.39	.9808
23	.8865	.9054	1.3676	1.0374	1.3169	1.2803	.9431
24	.9431	.9431	.7922	.7133	1.8484	.3475	.9808
Max	1.5089	1.358	1.46	1.828	16.749	1.8656	1.8461
Min	.811	.3206	.3881	.3772	.3658	.3475	.4527
Avg	1.0798	.8221	.9839	.9298	1.7129	1.0098	.9509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134065 / MALKHEDA

Feeder No / Name : 203 / IBRAHIMPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.7545	.7545	.7316	1.0185	.7316	.7499
2	.5658	.7545	.8676	.8048	1.0374	.8596	.8596
3	.6602	.8488	1.0185	.8962	1.094	.9593	1.0059
4	.8488	1.1317	1.226	1.0679	1.1694	1.1389	1.1706
5	.8488	1.4146	1.358	1.1888	1.358	1.2489	1.2851
6	.7922	1.4146	1.4335	1.2254	1.4901	1.3394	1.3032
7	.9431		1.4712	1.2437			
8	.9808			1.3575	1.4335	1.0425	.8688
9	1.0751	.9431	1.094	1.1317	1.2071	1.1523	1.1584
10	.9619	1.286	.6401	.4338	.567	.6401	.5144
11	.8299	1.3717	.9511	.7545	.2743	.6401	.679
12	.5658	1.286	.823	.9808	.7783	.823	.7922
13	.4715	1.1317	.8686	.8488	.7499	.7682	.7356
14	.5281	.9774	.7392	.7733	.7316	.7316	.6602
15	.4527	.823	.7392	.7545	.7392	.5853	.6224
16	.4904	.7545	.5914	.6602	.6468	.5853	.5847
17	.6979	.7545	.6838	.6602	.5853	.5729	.6413
18	1.094	.9054	.7762	1.1506	.7392	.8501	.9054
19	1.226	1.2637	1.4045	1.358	1.2567	1.2936	1.2071
20	1.1317	.9997	1.2752	1.3203	1.0719	1.1317	1.1128
21	1.0374	.8488	.8316	.8676	.9145	1.0059	.8865
22	.0737	.8299	.7392	.7922	.8596	.7577	.7922
23	.7545	.7167	.7023	.7545	.7499	.695	.7167
24	.4715	.7167	.7167	.6653		.7133	.6219
Max	1.226	1.4146	1.4712	1.358	1.4901	1.3394	1.3032
Min	.0737	.7167	.5914	.4338	.2743	.5729	.5144
Avg	.7512	.9967	.9437	.9343	.9306	.8811	.8641



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134065 / MALKHEDA

Feeder No / Name : 204 / 11 KV express feeder  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.0943	.1086	.0073	.1698	.0732	.0073
2	.1509	.0943	.0905	.0073	.1509	.0732	.0073
3	.132	.0943	.1086	.0091	.132	.0724	.0073
4	.1132	.0943	.1086	.0091	.0754	.0724	.0072
5	.0943	.0754	.0905	.0091	.0943	.0724	.0072
6	.0943	.0377	.0905	.0183	.0754	.0905	.0072
7	.0189	.1132	.1086	.0183		.0905	.0181
8	.0189	.1132		.0181	.0943	.1463	.0181
9	.0189	.1509	.0905	.1886	.1698	.1646	.1629
10	.1509	.1448	.1463	.1698	.128	.1463	.1448
11	.1509	.1448	.1463	.1509	.1463	.1646	.1448
12	.0566	.181	.1829	.1509	.1448	.1646	.1448
13	.0377	.181	.1848	.1509	.1267	.1448	.1267
14	.0377	.181	.1478	.1698	.128	.1463	.1267
15	.0566	.1267	.1848	.1698	.1294	.1463	.1267
16	.0377	.1267	.1848	.1698	.1478	.1463	.1448
17	.0377	.181	.1478	.1886	.1463	.1478	.1448
18	.0566	.181	.1478	.1448	.1478	.1294	.1448
19	.0377	.1629	.1478	.1448	.1478	.1478	.0181
20	.0362	.2172	.1478	.1629	.1663	.1267	.0181
21	.0181	.2715	.1294		.2012	.128	.009
22	.0943	.1086	.1109	.1886	.0732	.0092	.0905
23	.0754	.1086	.0092	.1886	.0732	.0091	.1086
24	.0754	.0754	.1086	.2263	.0754	.0754	.0091
Max	.1509	.2715	.1848	.2263	.2012	.1646	.1629
Min	.0181	.0377	.0092	.0073	.0732	.0091	.0072
Avg	.0730	.1358	.1271	.1157	.1280	.1120	.0727

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 201 / ALAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3239	.3239	.3239	.4475	.4268	.442
2	.3239	.4049	.3239	.4049	.4475	.4725	.5182
3	.4049	.4049	.4049	.4049	.4641	.4725	.5792
4	.4858	.4858	.4858	.4858	.4973	.5335	.6097
5	.6478	.5668	.6478	.7287	.8288	.7621	.8097
6	.7287	.6478	.8097	.8097	1.0111		.9779
7	.8907	.8097	.9717	.9717	1.0277		
9	2.0567						
10	2.5911	2.753	2.5911		2.5692	3.0483	2.7846
11	2.8664	2.9959	2.8664		2.652	3.4294	
12	2.8178	2.8826	1.4089		2.8178	3.4675	
13	2.8178	2.672	2.915		2.652	3.3913	
14	2.9312	2.753	2.4291			3.3341	
15	2.915	2.672	2.4615				
16	2.834	2.753	3.0167				
17	2.915	2.753	2.7846				
18	.8583	.8122	.8288				
19	.8097	.7459	.6464				
20	.7287	.663					
21	.5506	.5182	.5401				
22	.4144	.4641					
23	.3315	.4144					
24	.3239	.3315	.4144		.431	.3963	
Max	2.9312	2.9959	3.0167	.9717	2.8178	3.4675	2.7846
Min	.3239	.3239	.3239	.3239	.431	.3963	.442
Avg	1.4160	1.3558	1.4142	.5899	1.3205	1.7940	.9602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 202 / JANEFAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.4973	.4973	.5801	.3978	.3647	.3725
2	.4144	.4973	.5801	.663	.3978	.3978	.3563
3	.4973	.381	.663	.663	.4144	.4144	.3812
4	.4973	.663	.7459	.8288	.4973	.5801	.4372
5	.5801	.8288	1.6078	.9945		.663	
6	.663	1.1603	.9945	1.1603	.6796	.5801	.6464
7	.7459	1.21	.9945	1.2597	1.1271	1.326	1.1437
8	1.1603	.1608			1.6078	1.5415	1.4752
9		1.1603	1.6078		1.442	1.326	1.3094
16	.3315	.2652	.2591				
17	.5801	.4858	.5668				
18	.8619	.6964	.6316				
19	.8619	.7956	.7611				
20	.7127	.0663	.6464				
21	.0597	.4973	.5636				
22	.4973	.4144					
23	.4144	.0332					
24	.4144	.3315	.3315		.3481	.3481	
Max	1.1603	1.21	1.6078	1.2597	1.6078	1.5415	1.4752
Min	.0597	.0332	.2591	.5801	.3481	.3481	.3563
Avg	.5710	.5636	.7634	.8785	.7680	.7542	.7652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 203 / BHARAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315	.2486	.2984	.0249	.2652	.3812	.3812
2	.3315	.3315	.3315	.2486	.2652	.4641	.431
3	.4144	.3315	.4144	.3315	.2652	.4973	.4973
4	.4973	.4144	.4973	.3315	.4144	.663	.663
5	.5801	.4973	.5801	.4144	.5801	.8288	.7459
6	.663	.5801	.663	.4973	.7127	.8951	.8619
7	.663	.7459	.0663	.6464	.6962	.9116	
8	.0497	.0663			.0497	.0663	.0332
9	.663	.0829	.0663		.0663	.0663	.0663
10	1.3923	1.1603	1.4089		.0829	1.1603	1.0774
11	3.083	1.4255	1.4089		1.326	1.2803	
12	1.873		1.4089		1.326	1.3923	
13	1.5083	2.672	1.4089		1.2431	1.2929	
14	1.6741	1.3592	1.0774			1.2431	
15	1.6575	1.2929	1.3592				
16	1.2597	1.442	1.3094				
17	1.1934	1.3757	.5801				
18	.6299	.5801	.6464				
19	.4641	.4973	.663				
20	.4641	.4144	.4641				
21	.0332	.0332	.3149				
22	.2984	.2984					
23	.2486	.2486					
24	.2486	.2486	.2486		1.2431	.3481	
Max	3.083	2.672	1.4089	.6464	1.326	1.3923	1.0774
Min	.0332	.0332	.0663	.0249	.0497	.0663	.0332
Avg	.8426	.7107	.7246	.3564	.6097	.7660	.5286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 204 / ASAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4144	.5801	.4973	.663	.4475	.4973	.3978
2	.4144	.663	.663	.663	.4973	.0564	.4144
3	.4973	.663	.663	.8288	.4973	.663	.4973
4	.5801	.8288	.7459	.9116	.5801	.7459	.663
5	.663	.9945	.9116	.9945	.663	.7459	.7459
6	.8288	1.0774	.9945	.4973	.8122	.8619	.779
7	.9945	1.2929	1.1603	1.1934	1.1271	.8453	1.0111
8	1.2431	1.757			1.5746	1.5249	1.5083
9		1.4918	1.5746		1.4586	1.2431	1.2266
15		.2155					
16	.3315	.2155	.2321				
17	.4973	.4144	.4973				
18	.9116	.5801	.779				
19	.7956	.8288	.8288				
20	.6796	.663	.663				
21	.5801	.4973	.5636				
22	.4973	.4973					
23	.4144	.4144					
24	.4144	.4144	.431		.4475	.3647	
Max	1.2431	1.757	1.5746	1.1934	1.5746	1.5249	1.5083
Min	.3315	.2155	.2321	.4973	.4475	.0564	.3978
Avg	.6328	.7415	.747	.8217	.8105	.7548	.8048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 205 / TEMBHURNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1626	2.9912	2.8578	3.6199	3.2388	3.4979	3.5131
2	3.3722	3.2769	3.0103	3.9437	2.934	3.6656	3.6504
3	3.677	3.4293	3.2008	4.0962	3.1245	3.7723	4.0009
4	4.1343	3.2198	3.3341	4.3439	3.4865	4.0009	4.4581
5	4.6106	3.658	3.6389	4.763	3.8294	4.5343	4.6868
6	5.3346	4.1915	4.5344	5.6584	4.6868	6.0814	5.0983
7	5.487	5.5822	6.4015	7.0492	6.5539	7.3769	5.5194
8	6.0205	7.6398	6.7063	6.2872	8.1365	7.8694	6.9652
9	2.7816	3.4675	6.8016	5.868	7.297	7.5694	7.1226
15				.0381			
16	.8002	1.6575	1.1431	1.2955	.9907	1.0669	.6859
17	2.4005	2.2481	2.2672	1.7528	1.7909	1.9433	1.9814
18	3.5056	3.5056	3.1436	2.7816	2.8959	3.315	3.0102
19	3.8675	3.0293	3.8675	2.7435	3.0483	3.2769	3.0864
20	3.277	3.1436	3.2008	2.5149	2.3624	3.1245	2.7435
21	2.6101	3.0103	2.572	2.3624	2.7435	2.4768	2.8959
22	2.2481	2.2481	2.0195	1.7909	2.21	2.21	2.4768
23	2.0957	2.0576	1.7147	1.5242	2.1338	1.6766	2.0957
24	2.8197	3.0102	3.1817	2.7816	3.4293	3.416	2.0195
Max	6.0205	7.6398	6.8016	7.0492	8.1365	7.8694	7.1226
Min	.8002	1.6575	1.1431	.0381	.9907	1.0669	.6859
Avg	3.4558	3.4093	3.5331	3.4324	3.6051	3.9375	3.6672

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 206 / JAFRABAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.5601	.5601	.5601	.5601	.5415	.5228
2	.7468	.6535	.6535	.6535	.5601	.5415	.5228
3	.8402	.7468	.7468	.6535	.5601	.5415	.5601
4	.9335	1.1203	.9335	.7468	.7468	.6535	.7095
5	1.1203	1.1203		1.1203	1.2136	1.1203	1.1203
6	1.4937	1.4937	1.8858	1.2696	1.6057	1.7177	1.531
7	1.7924	1.8671	1.8858	2.0165	2.0538	2.0165	2.0165
8	1.8484	1.8671			2.0351	1.8111	1.5083
9	1.8671	1.8298	1.8298		1.7737	1.7177	1.7364
10	1.7177	1.3443			1.643	1.9044	1.6804
11	1.6804	1.3443	1.8484		1.4937	1.8298	
12	1.1949		1.4937		1.307	1.307	
13	1.1763		1.3443		1.1203	1.2136	
14	.9896		1.0269			1.1203	
15	.9335	1.4937	1.1203				
16		1.4937					
17	1.5123	1.6057	1.6804				
18	1.7364	1.8298	1.7551				
19	1.587	1.4937	1.6244				
20	1.307	1.4003	1.307				
21	.9709	1.0269	1.0642				
22	.8402	.8029					
23	.7468	.6535					
24	.5601	.5601	.6535		1.1203	.5415	
Max	1.8671	1.8671	1.8858	2.0165	2.0538	2.0165	2.0165
Min	.5601	.5601	.5601	.5601	.5601	.5415	.5228
Avg	1.2282	1.2527	1.3008	1.0029	1.2710	1.2385	1.1908

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 202 / AKOLADEO

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.9955	1.1765	1.1888	1.848
2	.3429		1.086	1.267	1.1145	1.848
3	.4001		1.1765	1.7194	1.2174	2.0328
4	.4572		1.3937	1.7737	1.406	1.848
5	.6668		1.6108	1.8099	1.5432	2.3101
6	.9526		1.8099	2.1719	2.0062	2.2546
7	.9907		2.0271	2.2262	2.2291	2.5873
8	.8954			2.3529	2.3491	2.6139
9	.8383			2.3148	.4287	2.3434
10	1.6632			1.6461	.2987	.4191
11	1.9204			.1886	.2801	.2286
12				.12		.1905
13				.1372	.0914	.1143
14		.1448		.1372	.112	.1524
15		.1629			.1478	.1143
16		.181		.1063	.1494	.1905
17		.4525		.1886	.2957	.2286
18		.7059		.4287	.6335	.5335
19		.6878		.4287	.6161	.8764
20		.4706		.4938	.4854	.5335
21		.3801		.4458	.4024	.4001
22		.3258		.4287	.3696	.3239
23		.3258		.443	.2987	.2858
24	.2858		.8145	1.1765	.8916	1.2012
Max	1.9204	.7059	2.0271	2.3529	2.3491	2.6139
Min	.2858	.1448	.8145	.1063	.0914	.1143
Avg	.8099	.3837	1.3643	1.0079	.8068	1.0616



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 203 / PAPAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.543	.6335	.6001	1.2136
2	.2858		.6335	.6878	.6001	1.6263
3	.3429		.6878	.724	.6859	1.848
4	.381		.724	.8145	.7362	1.848
5	.5144		.8145	.905		2.0328
6	.6668		.9955	.9774	.9774	1.8111
7	.7621		1.1765	1.4842	1.0288	1.8111
8	.724			1.8099	1.382	2.0538
9	.6859	1.5023		1.6827	1.7833	1.9052
10	1.1145	.181		.1543	.1494	.2477
11	1.5432	.1629		.1372	.0934	.2096
12		.1448		.1029	.112	.1334
13		.1086		.1029	.0924	.1143
14		.1629		.12	.1494	.1334
15		.1991		.1372	.181	.1334
16		.2172		.1543	.1867	.1524
17		.4344		.2229	.3475	.2096
18		.6335		.3086	.5601	.4001
19		.5792		.3601	.5601	.724
20		.4163		.4287	.4854	.5144
21		.2896		.3429	.3734	.2858
22		.2715		.3429	.2987	
23		.2534		.3898	.4066	.2667
24	.2286		.5068	.6335	.463	1.2936
Max	1.5432	1.5023	1.1765	1.8099	1.7833	2.0538
Min	.2286	.1086	.5068	.1029	.0924	.1143
Avg	.6232	.3704	.7602	.5691	.5327	.9117

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 204 / BHATODI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002		.4525	.4525	.6859	.4066
2	.8192		.543	.4163	.7202	.3696
3	.8573		.6335	.3982	.7202	.3326
4	.9335		.8688	.5068	.8573	.3696
5	.9526		.9955	.6335		.3696
6	1.105		.9955	.8145	.9602	.4805
7	1.3717					.4108
8	1.5813					.462
9	1.7147					.8573
10	.6859	1.1765		1.1145	1.2696	1.1812
11	.463	1.448		1.3203	1.5089	1.4861
12		1.5384		1.7558	1.4003	1.5242
13		1.6108		1.5432	1.643	1.6766
14		1.5927		1.5089	1.6804	1.6385
15		1.5746		1.406	1.643	1.5432
16		1.5203		1.3717	1.3717	1.4098
17		1.448		1.3375	.9412	1.3336
18		.9412		.4801	.9709	.743
19		.8688		.6516	.9335	1.0479
20		.6335		.703	.8215	.7811
21		.5973		.6859	.7392	.6668
22		.4525		.6859	.6653	.6287
23		.362		.6661	.5544	.6097
24	.724		.362	.4706	.5144	.5544
Max	1.7147	1.6108	.9955	1.7558	1.6804	1.6766
Min	.463	.362	.362	.3982	.5144	.3326
Avg	1.0007	1.1260	.6930	.9011	1.0301	.8701

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 205 / AMBEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477		.2715	.3258	.3086	.5544
2	.2858		.362	.362	.2401	.6099
3	.2858		.4525	.362	.3012	.5914
4	.3048		.5068	.3982	.3429	.6516
5	.3239		.5068	.4344	.3429	.7392
6	.4382		.543	.4706	.3601	.7468
7	.5144		.543	.7964	.5144	.8131
8	.4763			.905	.5658	.8962
9	.3048	.5792		.6859	.7202	.8573
10	.3506	.0362			.1867	.1524
11	.6135	.0543			.1867	.0953
12		.0543			.1494	.0762
13		.0543			.0914	.0762
14		.0543			.1132	.0762
15		.0724			.1494	.0762
16		.0724				.0762
17		.2172			.1867	.1143
18		.3077			.2801	.2286
19		.3439		.1772	.4668	.4763
20		.2534		.3258	.4024	.4382
21		.2715		.3429	.3696	.3429
22		.2353		.3898	.2987	.3239
23		.2172		.3772	.3326	.3048
24	.2477		.2715	.3258	.2915	.4854
Max	.6135	.5792	.543	.905	.7202	.8962
Min	.2477	.0362	.2715	.1772	.0914	.0762
Avg	.3661	.1882	.4321	.4453	.3131	.4085

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 206 / DAWARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764		.543	.8145	.6859	.8131
2	.8764		.6335	.905	.6859	.924
3	.9145		.7059	.9412	.7202	1.0164
4	.9335		.7964	1.086	.7716	.961
5	.9907		1.0136	1.2308	.7716	1.2197
6	1.2574		1.3937	1.448	1.0288	1.2936
7	1.7528		1.5565	1.3937	.9431	1.2012
8	2.3243			1.3575	.9431	1.251
9	2.191	.9774		.6859	.9259	.8573
10	.2858	1.6289		1.5947	1.8671	1.3908
11	.2401	2.0271		1.949	1.8671	1.9433
12	.3189	2.0814		2.2119	.1867	2.1148
13	.3189	2.1176		2.2291	2.0328	2.2481
14		2.0814		2.0233	1.8671	2.0957
15		1.8671		1.9376	2.0119	1.9052
16		1.9185		1.8861	1.9791	1.848
17		1.8099		1.749	1.8671	1.7528
18		1.1765		.6173	1.1576	.9717
19		1.1765		.9945	1.0974	1.1431
20		.9774		.9602	1.0059	1.105
21		.8869			.924	.8954
22		.8145		.7202	.8215	.724
23		.6878		.7202	.7392	.6287
24	.8573		.5068	.8145	.7202	.7762
Max	2.3243	2.1176	1.5565	2.2291	2.0328	2.2481
Min	.2401	.6878	.5068	.6173	.1867	.6287
Avg	1.0099	1.4819	.8937	1.3161	1.1509	1.2950

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 201 / WARUD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.253	.3391	.2926	.3077	.3772	.3109	.3258
2	.2721	.3353	.2926	.3258	.4287	.3475	.3721
3	.3201	.4096	.3109	.3582	.4748	.3761	.4252
4	.506	.5087	.3109	.3761	.5426	.3761	.463
5	.583	.5668	.3582	.567	.6443	.5014	.5487
6	.6081	.6783	.4835	.631	.7042	.7164	.5868
7	.6554	.7712	.8059	.964	.779	.9745	.8122
8	.7682	1.0288	1.1641	1.0974	1.0974	1.1218	.8745
9	.6722	.8478	.985	1.0288	.8848	.8764	.9014
16	.3239	.3658	.3224	.2543	.3403	.3142	.2372
17	.431	.4938	.4075	.4239	.3224	.3761	.3749
18	.503	.6036	.6135	.5935	.439	.6024	.4696
19	.5426		.8063	.5365	.7316	.7202	.68
20	.5967	.5373	.6024	.4694	.591	.5609	.5851
21		.4477	.4706	.4191	.4938	.443	.4428
22		.439	.3658	.39	.394	.3475	.3563
23			.2715	.3391	.3224	.2926	.2846
24	.1943	.3429	.2926	.3077	.2572	.2926	.2896
Max	.7682	1.0288	1.1641	1.0974	1.0974	1.1218	.9014
Min	.1943	.3353	.2715	.2543	.2572	.2926	.2372
Avg	.4820	.5447	.5087	.5216	.5458	.5306	.5017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 202 / ADHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.2209	1.2803	1.2346	1.2071	1.3169	1.1984
2	1.2003	1.2548	1.2894	1.2517	1.2239	1.3253	1.2146
3	1.2483	1.2887	1.3432	1.2574	1.3226	1.3432	1.2163
10	1.4586	1.4632		1.3283	1.4685	1.3203	1.3283
11	1.6057	1.6118		1.5769	1.6301	1.3203	1.5061
12	1.8233	1.7541	1.5524	1.6108	1.7528	1.5893	1.5181
13	1.7204	1.7013	1.4706	1.5074	1.7013	1.5565	1.5023
14	1.6575	1.576	1.4746	1.4752	1.6301	1.5729	1.4899
15	1.5746		1.2955	1.3904	1.5223	1.4586	1.4706
16	1.4922	1.4327	1.2929	1.3599	1.4022	1.4243	1.3283
17	1.4083	1.3717	1.1736	1.2597	1.3672	1.2071	1.4232
18	1.0174	1.0745	1.0099	.9116	.8954	.9991	.8642
19	1.166		1.1336	1.3226	1.2536	1.1831	.9804
20	1.2174	1.2894	1.1934	1.2887	1.2894	1.1603	1.1305
21		1.2178	1.2431	1.2209	1.3432	1.1961	1.1203
22		1.2536	1.1233	1.2039	1.2894	1.1843	1.0279
23			1.2239	1.2039	1.2715	1.2146	.9962
24	1.0936	1.2039	1.1523	1.6108	1.1869	1.2986	1.2125
Max	1.8233	1.7541	1.5524	1.6108	1.7528	1.5893	1.5181
Min	1.0174	1.0745	1.0099	.9116	.8954	.9991	.8642
Avg	1.3900	1.3810	1.2658	1.3342	1.3754	1.3150	1.2516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 203 / WANKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.192	.3163	.1829	.1848	.1898	.1829	.1829
2	.2214	.3239	.2012	.2012	.253	.2195	.2172
3	.25	.3163	.2012	.2172	.2915	.2507	.2715
4	.3201	.4049	.2195	.3258	.3953	.394	.3721
5	.421	.4534	.3292	.3721	.4481	.4656	.4207
6	.4744	.4588	.394	.7011	.4744	.5014	.4557
7	.5535	.4915	.5373	.7888	.4801	.6268	.5487
8	.5801	.6554	.591		.6478	.7164	.6859
9	.5304	.6554	.6089	.7362	.6325	.8059	.7716
10	.1581	.1433	.1829	.1829	.1433	.1494	.1829
11		.128	.1494	.1619	.1402	.1494	.1581
12	.1638	.1463	.1307	.1638	.1753	.1663	.0819
13	.1581	.128	.1307	.1581	.1612	.1478	.0791
14	.1581	.128	.112	.1638	.1402	.1294	.081
15	.1619	.1097	.1294	.1638	.1612	.1478	.0791
16	.8192	.5373		.1619		.2896	.1619
17	.8097	.8059		.6478	.9114	.6733	.8907
18	.6401	.5373	.7164	.6783	.8954	.5609	.7116
19	.4744			.4915	.3582	.3721	.4049
20	.1638	.2686	.2743	.3239	.3224	.3258	.2372
21		.2561	.2195	.1619	.2686	.2715	.2343
22		.2195	.1848	.1638		.2658	.2401
23			.1848	.1696	.2149	.2195	.2486
24	.2372	.1581	.4656	.2033	.1638	.2012	.2012
Max	.8192	.8059	.7164	.7888	.9114	.8059	.8907
Min	.1581	.1097	.112	.1581	.1402	.1294	.0791
Avg	.3744	.3474	.2927	.3271	.3577	.3430	.3300

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 206 / BHARADKHEDA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6009	.7537	.8779	.8505	.663	.8059	.7973
2	.6642	.8192	1.0059	.964	.7459	.985	.9816
3	.759	.9503	1.0745	1.1269	.7865	1.2178	1.166
9	1.7444	1.8351	1.9281	1.9062	1.8821	2.0774	1.7072
10	1.8023	2.0058	2.0062	1.8107	1.8804	1.8482	1.6385
11	1.8187	1.9879	1.8347	1.5729	1.7528	1.8176	1.7284
12	1.7368	1.9281	1.6644	1.7101	1.8404	1.8107	1.6804
13	1.7072	1.8804	1.6804	1.7072	1.97	1.7635	1.6518
14	1.7072	1.7909	1.6632	1.5261	1.8804	1.7604	1.6288
15	1.7004	1.7909	1.6632	1.6078		1.6766	1.7328
16	1.6787	1.6118	1.5604	1.5074	1.7909	1.5947	1.6644
18	.6882	1.1641	1.1163	1.0682	.9145	1.0631	.8745
19	.7773		1.1797	1.0174	1.0745	1.153	1.1385
20	.9503	1.0608	.9602	.9496	.985	.9816	.8962
21		1.0059	.9259	.9156	1.0059	.9214	.8619
22		.9145	.8589	.9012		.8939	.7865
23			.8505	.8192	.8059	.8682	.7373
24	1.2334	.7865	.823	.8238	.8192	.8779	.8859
Max	1.8187	2.0058	2.0062	1.9062	1.97	2.0774	1.7328
Min	.6009	.7537	.823	.8192	.663	.8059	.7373
Avg	1.3046	1.3929	1.3152	1.2658	1.2998	1.3398	1.2532



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 201 / 11 KV PIMPALGAON KAD SINGLE PHASING

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.8596	.8573	.5144	.06	.7621	.6859
2	.7202	.9492	.9362	.6001	.0669	.8688	.7716
3	.823	1.0208	1.0117	.6859	.0806	.9907	.8573
4	.0892	1.0517	1.1145	.7716	.0909	1.0669	.9431
5	.1012	1.0631	1.2003	.8573	.1012	1.1584	.9431
6	.0995	1.3032	1.2346	.9431	.1029	1.2193	1.0288
7	.1063	1.3375		1.0288	.1046	1.1736	.9774
8	.1063			1.0974	.1046	1.0974	1.0631
9	.108	.9431	.7545	.8916	.1029	.8688	.9088
10	.9088		1.2003	.0977	.7621	.7888	.0943
11	1.4243	1.1145	1.1145	.1063	1.0364	1.0802	.0977
12	1.5089	1.3523	1.2003	.1183	1.2193	1.2517	.1012
13	1.4575	1.2656	1.2346	.1235	1.1888	1.0288	.1029
14	1.3735	1.2003	1.2003	.1252	1.1431	1.0802	.1063
15	1.286	1.046	1.1145	.1166	1.0212	.9431	.108
16	.9088	.823	1.0288	1.046	.945	.8745	.0874
17	1.0402	.823	.8402	.0857	1.0517	.8573	.0772
18	1.1641	1.0642	.9088	.036	1.0974	1.0288	.0429
19	.8688	1.2536	1.0288	.0497	1.0974	1.0631	.0532
20	.815	1.1041	1.1145	.0652	.9755	1.0802	.06
21	.7602	1.0136	1.0288	.072	.8993	1.0631	.0549
22	.8059	.9145	.8402	.0806	.8383	1.0802	.06
23	.8962	.8688	.7716	.0892	.7926	.8573	.0669
24	.0806	.7964	1.1145	.6859	.0874	.7621	.7716
Max	1.5089	1.3523	1.2346	1.0974	1.2193	1.2517	1.0631
Min	.0617	.7964	.7545	.036	.06	.7621	.0429
Avg	.7298	1.0531	1.0386	.4287	.6238	1.0019	.4193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 203 / 11 KV WADALA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.072	.6089	.583	.5144	.0532	.6097	.5144
2	.0772	.6516	.5487	.5144	.06	.7164	.6001
3	.0772	.6878	.5487	.6001	.0652	.7164	.6859
4	.0686	.6859	.6173	.6001	.0772	.7621	.7716
5	.0737	.8322	.7716	.6859	.084	.7926	.8573
6	.0686	1.1488	.9945		.0874	.8383	.9431
7	.072	1.2346		.7202	.0892	.8993	.8573
8	.0772			.7888	.0909	.8535	.7716
9	.072	.7282	.5256	.6687	.06	.5944	.7716
10	.9945		.7716	.0772	.5639		.1286
11	1.3904	1.2346	1.0288	.0823	.7011	.8573	.1355
12	1.4413	1.3032	.8573	.084	.8383	.9431	.1372
13	1.4232	1.3523	.6859	.0857	.9145	.7716	.1372
14	1.4403	1.2346	.8573		.2134	.6001	.1389
15	1.3565	1.1488	.9431	.0892	.2286	.5658	.1389
16	1.2209	.8573	.9431	.0909	.2591	.5144	
17	1.1218	.8573	.8573	.0943	.823	.5144	
18	.7202	.8326	.1715	.0257	.7621	.2572	
19	.924	.9593	.6859	.0326	.7621	.4287	.0463
20	.8596	.6089	.7716	.0394	.6249	.4287	.048
21	.7164	.5194	.4287	.0497	.5944	.3429	.0497
22	.6653	.543	.3429	.0549	.5335	.3429	.0532
23	.5914	.5373	.3086	.06	.4877		.0549
24	.3772	.5014	.5487	.2743	.0514	.3086	.3086
Max	1.4413	1.3523	1.0288	.7888	.9145	.9431	.9431
Min	.0686	.5014	.1715	.0257	.0514	.2572	.0463
Avg	.6626	.8667	.6724	.2833	.3760	.6208	.3881

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 204 / 11KV MHASARUL FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0772	.4525	.4801	.5144	.0652	.5335	.6001
2	.0806	.5068	.4458	.6001	.0772	.5639	.6516
3	.084	.4706	.4801	.7716	.8745	.5944	.7716
4	.0892	.5201	.6001	.8573	.9431	.6097	.8573
5	.0943	.5548	.7202	1.0288	.0995	.6706	.9431
6	.9945	.6516	.7545	1.1145	.1115	.7011	1.0288
7	.1046	.6859		1.3032	.1183	1.1888	1.0288
8	.108			1.3375	.132	1.4022	1.2346
9	.1097	1.166	1.2763	1.2346	.1252	1.1126	1.0288
10	.3052		.3086	.0189	.3963	.3258	.0257
11	.2515		.2743	.0154	.3353	.1543	.0257
12	.2035		.1715	.0154		.1543	.0223
13	.1865	.1715	.12	.0137	.1524	.1372	.0206
14	.1715	.1715	.12	.0137	.1677	.12	.0189
15	.2915	.1715	.12	.0154	.1829	.1715	.0171
16	.2915	.4458	.4287	.0171	.2286	.1886	.0257
17	.4382	.4458	.4287	.0171	.3963	.2229	.0189
18	.5731	.7499	.5658	.0171	.4572		.0703
19	.8871	.6584	.6173	.024	.4572	.5144	.0257
20	.9593	.5609	.6001	.0326	.4268	.5144	
21	.5487	.4784	.463	.036	.381	.4287	.0033
22	.5544	.4572	.3772	.0394	.3658	.3601	.0394
23	.5068	.439	.3429	.0429	.3353		.0497
24	.0377	.5138	.4458	.4458	.0412	.3601	.3944
Max	.9945	1.166	1.2763	1.3375	.9431	1.4022	1.2346
Min	.0377	.1715	.12	.0137	.0412	.12	.0033
Avg	.3312	.5136	.4610	.3969	.2987	.5013	.3871

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 205 / 11KV BELORA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.072	.4908	.5144	.5144	.0703	.6097	.6859
2	.0823	.5373	.5658	.6001	.0772	.6859	.7716
3	.084	.5784	.5895	.7716	.0857	.7164	.8573
4	.0892	.6001	.6859	.9431	.0977	.7621	1.0288
5	.0943	.7888	.7545	1.1145	.1063	.823	1.1145
6	.0977	.9774	.823	1.2003	.1166	.8535	1.2003
7	.0995	1.0288		1.3203	.1217	1.1888	1.2517
8	.1063			1.6289	.1303	1.3717	1.4403
9	.1063	1.1963	1.21	1.5604	.1457	.9145	1.286
10	.4115		1.286	.0326	.3963	.4115	.0326
11	.2347	.3121	.2229	.0309	.3353	.3429	.0291
12	.1696	.2401	.2572	.0309	.2743	.2572	.0291
13	.2035	.2254	.2915	.0291	.1981	.2229	.0309
14	.2229		.2743	.0183	.2286	.1886	.0274
15	.2572	.2427	.2572	.036	.2286	.2229	.0257
16	.3429	.5144	.5144		.2591	.2572	.024
17	.6859	.5144	.5487	.0532	.442	.3429	.0274
18	.815	.8596	.7716		.7316	.6859	.3258
19	.9231	.8775	.8573	.0617	.7316	.7716	
20	.8238	.695	.7716	.0549	.6401	.6859	.036
21	.6335	.6335	.4973	.0497	.5335	.6001	.0377
22	.543	.5731	.4801	.048	.4725	.5144	.0377
23	.5121	.5249	.4115	.0446	.442		.0377
24	.048	.4119	.4641	.5144	.048	.5144	.5658
Max	.9231	1.1963	1.286	1.6289	.7316	1.3717	1.4403
Min	.048	.2254	.2229	.0183	.048	.1886	.024
Avg	.3191	.6106	.5931	.4845	.2880	.6063	.4741

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 206 / 11KV INDUSTRIAL FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0017	.0181	.0173	.0171	.0017	.0152	.0171
2	.0017	.0185	.0171	.0171	.0017	.0152	.0171
3	.0017	.0187	.0171	.0171	.0017	.0152	.0171
4	.0017	.0173	.0171	.0171	.0017	.0152	.0514
5	.0017	.0175	.0171	.0171	.0017	.0152	.0514
6	.0017	.0171	.0171	.0171	.0017	.0152	.0343
7	.0017	.0171		.0171	.0017	.0152	.0171
8	.0017			.0171	.0017	.0152	.0171
9	.0017	.0171	.0171	.0171	.0017	.0152	.0171
10	.0171		.0171	.0017	.0152	.0171	.0171
11	.0171	.0171	.0171	.0011	.0152	.0171	.0017
12	.017	.0171	.0171	.0017	.0152	.0171	.0017
13	.017	.0171	.0171	.0017	.0152	.0171	.0017
14	.0171	.0171	.0171	.0017	.0152	.0171	.0017
15	.0339	.0171	.0171	.0017	.0152	.0171	.0017
16	.0526	.0171	.0171	.0017	.0152	.0171	.0017
17	.0514	.0171	.0171	.0017	.0152	.0171	.0017
18	.0886	.0514	.0686	.0017	.0762	.0171	.0017
19	.0747	.0514	.0686	.0017	.0762	.0514	.0017
20	.037	.0181	.0171	.0017	.0762	.0686	.0011
21	.0358	.0358	.0171	.0017	.061	.0857	.0017
22	.0934	.0185	.0171	.0017	.061	.0857	.0017
23	.0905	.0187	.0171	.0017	.0305		.0017
24	.0034	.0183	.017	.0171	.0017	.0686	.0171
Max	.0934	.0514	.0686	.0171	.0762	.0857	.0514
Min	.0017	.0171	.017	.0011	.0017	.0152	.0011
Avg	.0276	.0215	.0218	.0081	.0217	.0283	.0123

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 201 / POKHRI - AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.661	.1543	.0926	.0772	.0772	.1543	.108
2	1.7977	.1543	.0926	.0772	.0772	.108	.1543
3	1.8504	.1543	.0926	.0772	.0772	.108	.1543
4	1.9066	.1543	.1235	.0772	.0772	.1235	.1235
5	2.0225	.1543	.1235	.0772	.0772	.1389	.1543
6	2.2618	.1543	.1235	.0772	.1543	.1543	.1543
7	3.0783	.1543	.1235	.0772	.1543	.1543	.1543
8	4.0733						
9	4.9725						
10	2.9317	1.6975		1.6975	1.5432	1.6975	1.6975
11	.5251	4.3782		4.8582	4.1231	4.4325	4.2374
12		5.6806		6.1355	5.3536	5.4498	5.2393
13		5.809		5.6093	5.5502	5.5712	5.4576
14		5.7579		5.7095	5.374	5.4675	5.1132
15		5.4264		5.7972	5.4365	4.8305	4.4907
16	.1543	5.177	.7716	5.8659	5.3755	4.8792	4.5592
17	.1543	4.8945	5.0317	5.7373	4.4109	4.3073	4.2827
18	.1543	2.8149	3.4136	3.1969	1.4784	2.3712	2.2644
19	.1543	.6703	1.1586	.2656	1.0913	.7502	.4758
20	.1543	.108	.0772	.1543	.1543	.1543	.0772
21	.1543	.108	.0772	.1543	.1543	.1543	.0772
22	.1543	.108	.0772	.0772	.1543	.1543	.0772
23	.1543	.108	.0772	.0772	.1543	.1543	.0772
24	.6944	.1543	.0926	.0772	.0772	.1543	.1543
Max	4.9725	5.809	5.0317	6.1355	5.5502	5.5712	5.4576
Min	.1543	.108	.0772	.0772	.0772	.108	.0772
Avg	1.4505	1.9988	.7218	2.0888	1.8694	1.8850	1.7856

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 203 / NIVDUNGA - AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3513	1.4003	1.2025	1.5428	1.5908	1.6971	1.6796
2	.349	1.5028	1.2513	1.5885	1.6571	1.8613	1.8766
3	.3551	1.4857	1.3565	1.771	1.8198	1.9299	1.9375
4	.3566	1.664	1.3976	1.9093	1.9048	2.1571	2.0561
5	.3833	1.7673	1.4129	2.1708	2.2173	2.5194	2.2844
6	.4228	2.1346	1.8888	2.652	2.4806	3.136	2.7519
7	.4258	2.5983	2.7221	4.0588	3.3009	4.0402	4.2421
8		3.4748	2.4417	5.2271	.6944	5.0202	5.016
9		3.3886		5.1437	4.8941	5.407	5.4294
10	2.3026	1.5219		2.1468	2.114	2.588	2.0393
11	3.1585						
12	4.0146						
13	4.1861						
14	4.4288						
15	4.0699						
16	3.7151	.2179	.1566	.3246	.216	.0781	.2084
17	3.8119	.2774	.1878	.1654	.3018	.229	.2084
18	1.8572	.304	.3132	.309	.3033	.3277	.2313
19	.317	.33	.3338	.3418	.3307	.346	.2526
20	.389	.3338	.3307	.3433	.3315	.3475	.258
21	.314	.3307	.33	.3418	.3338	.3521	.2648
22	.3109	.2965	.3269	.3364	.3292	.3406	.2663
23	.3094	.3246	.3208	.3342	.3261	.3353	.261
24	.6607	1.3485	1.1324	1.3687	1.3801	1.5516	1.4899
Max	4.4288	3.4748	2.7221	5.2271	4.8941	5.407	5.4294
Min	.3094	.2179	.1566	.1654	.216	.0781	.2084
Avg	1.6586	1.3001	1.0062	1.6882	1.3961	1.8034	1.7239

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 204 / NIVADUNGA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.2263	.2263	.2075	.2054	.2614	.2614
2	.1494	.2452	.2263	.2075	.1867	.2614	.2614
3	.168	.2801	.2641	.2263	.2241	.3018	.2987
4	.168	.3658	.3584	.2641	.2614	.3174	.3292
5	.2218	.462	.3961	.3206	.3326	.3658	.4207
6	.2592	.5249	.3395	.3921	.4435	.3982	.4656
7	.3841	.5228	.4715	.4207	.4024	.4435	.4525
8	.439	.4715			.3658	.4715	.3982
9	.3734	.3206		.3258	.3326	.4108	
10	.2427	.2378		.2587	.2402	.2801	.2801
11	.2012	.1478		.2054	.168	.1867	.1663
12	.1267	.1463			.1294	.112	.1646
13	.1075			.1494	.112	.0934	.1294
14				.1494	.1109	.112	.1463
15	.112	.1075		.1109	.1097	.0747	.1109
16	.1867	.1612	.112	.1494	.1663	.0934	.1267
17	.2427	.2218	.2218		.2353	.1494	.2012
18	.3361	.3696	.3547	.4572	.3326	.2987	.3696
19	.415	.3921	.4338	.4572	.4207	.4481	.4108
20	.3206	.3142	.3395	.3511	.3921	.3696	.3174
21	.2641	.2772	.2641	.2957	.3361	.3326	.2641
22	.2241	.2587	.2452	.2801	.2772	.2987	.2452
23	.2263	.2587	.2263	.2054	.2614	.2801	.2452
24	.1494	.2241	.2241	.2075	.2054	.2801	.2801
Max	.439	.5249	.4715	.4572	.4435	.4715	.4656
Min	.1075	.1075	.112	.1109	.1097	.0747	.1109
Avg	.2377	.2971	.2940	.2687	.2605	.2767	.2759



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 205 / POKHARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2452	.2054	.1886	.2241	.2801	.2427
2	.2241	.2402	.2263	.1886	.2241	.2641	.2427
3	.2614	.2614	.2263	.2075	.2614	.2801	.2614
4	.2926	.3189	.3584	.2641	.3326	.3511	.2957
5	.3982	.4207	.415	.3206	.4572	.4572	.4024
6	.4508	.5359	.547	.3961	.5068	.543	.5121
7	.5895	.5041	.4904	.462	.5434	.5487	.5895
8	.5434	.4108			.4557	.5281	.4908
9	.4706	.3206		.3841	.4382	.567	
10	.3658	.2195		.2957	.3258	.432	.3326
11	.2926	.1949		.2218	.2378	.2402	.2378
12	.2947	.1991		.2033	.3012	.2241	.181
13	.285			.2772	.2629	.1867	.1227
14				.1663	.2601	.2241	.1063
15	.2172	.2058		.2195	.2507	.2054	.1227
16	.3077	.2804	.112	.2218	.2427	.1494	.1629
17	.4024	.3544	.3511	.2926	.3721	.2957	.1848
18	.4435	.4525	.4435		.5138	.5121	
19	.5729	.5228	.5093	.6335	.5375	.6516	.6535
20	.4108	.3801	.3961	.5121	.4961	.4938	.5228
21	.3109	.2926	.2641	.4066	.3475	.3629	.3961
22	.2378	.2353	.2452	.3174	.3142	.3174	.3395
23	.2402	.1829	.2075	.2801	.2801	.2427	.2641
24	.2427	.2427	.2641	.2195	.2427	.2829	.2427
Max	.5895	.5359	.547	.6335	.5434	.6516	.6535
Min	.2172	.1829	.112	.1663	.2241	.1494	.1063
Avg	.3521	.3191	.3289	.3036	.3512	.3600	.3139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 201 / BORAGAON MATH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0829	.6081	1.1765	.8749	.5731	.905
2		1.3443	.6882	1.1765	.9998	.5373	.9412
3		1.475	.7682	.8145	1.1043	.4961	.9231
4		1.5893	.7865	.8326	1.1248	.6805	1.5565
5		1.8296	1.0883	1.267	1.2963		1.5565
6		2.1807	1.8023	1.7013	1.4582	.7164	1.7194
7		2.1807	1.8023	2.0633	1.6057	.7522	1.9004
8		2.7446		2.5701	2.1464	.7701	2.5701
9	.3113	1.8484	2.1125	2.1357	1.8351	1.2071	2.3167
10	1.9728						
16	.6062	.5041	1.0498	.5079	.4755	.362	.4049
17	.8684	.8871	.8145	.6554	.8215		.7449
18	.7373	1.0608	1.2308	.852	1.2254	.9955	.9717
19	.8356	1.1523	.9774	.7907	1.0029	.9231	.8259
20	.8413	.9328	.7783	.9012	.7865		.7935
21	.8682	.9335	.6335	.787	.7343	.724	.7287
22	.8131	.7865	.5792	.6882	.7316	.6335	.6478
23	.7023	.7842	.5792	.6325	.7392	.543	.5344
24	.7282		.5243	.6093		.6661	.5506
Max	1.9728	2.7446	2.1125	2.5701	2.1464	1.2071	2.5701
Min	.3113	.5041	.5243	.5079	.4755	.362	.4049
Avg	.8441	1.3716	.9896	1.1201	1.1154	.7053	1.1440

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 202 / PASODI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4167	.3921	.2896	.2315	.3292	.3258
2		.3241	.3921	.3258	.2778	.3018	.362
3		.2778	.4108	.4344	.3241	.3658	
10	1.1797	1.0364	.9412	.8642	.8002	1.0136	1.1336
11	1.3927	1.3123	1.267	1.1111	1.0814	1.267	1.1603
12	1.1469	1.2342	1.267	1.0957	1.1797	1.3394	1.2125
13	1.3599	1.1873	1.3575	1.1265	1.0202	1.2127	1.1405
14	1.3108	1.2616	1.3032	1.0648	.9602	1.1946	1.21
15	1.1797	1.2163	1.1765	.547	.9217	1.1584	1.1544
16	1.1469	1.1797	1.0498	.9722	.9922	1.0679	.9568
17	1.0277	1.1203	1.086	.8642	.9231		.9393
18	.3978	.4477	.2353	.2372	.3772	.3439	.3395
19	.431	.5041	.4163	.2778	.5304	.4706	.2778
20	.3856	.3881	.362	.3704	.4298	.6878	.2932
21	.4119	.4207	.3982	.2896	.4338	.6335	.2623
22	.3315	.4108	.362	.3395	.4108	.362	.2469
23	.2984	.3772	.3439	.2984	.3734	.3439	.4807
24	.3403		.3734	.2652		.3658	.2321
Max	1.3927	1.3123	1.3575	1.1265	1.1797	1.3394	1.2125
Min	.2984	.2778	.2353	.2372	.2315	.3018	.2321
Avg	.8227	.7715	.7297	.5985	.6628	.7328	.6899

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 203 / KHASAGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.253	.3772	.4887	.2915	.3772	.4706
2		.2214	.3584	.543	.2591	.3772	.4887
3		.2372	.3584	.5792	.3077	.415	.543
10	.5801	.4001	.6878	.4428	.4801	.5249	.6464
11	.8785	.5735	.8145	.6327	.4999	.5792	.6133
12	.6133	.5868	.7602	.6299	.5601	.724	.3704
13	.779	.5407	.724	.5636	.4001	.6878	.5335
14	.6962	.5601	.724	.5138	.3521	.6516	.3401
15	.8288	.5281	.6878		.3521	.6335	.1823
16	.7127	2.0576	.6878	.4807	.3201	.543	.9804
17	.7459	.5121	.724	.6464	.5121		.6173
18	.1475	.7316	.3258	.1966	.5658	.543	.2429
19	.1802	.5658	.543	.2315	.7164	.724	.2753
20	.3403	.5601	.4344	.213	.5487		.2267
21	.3761	.5658	.4525	.2622	.3658		.2315
22	.2949	.5658	.362	.2458	.415	.543	.1943
23	.2622	.3772	.362	.2294	.3772	.5068	.3563
24	.3582		.3734	.2622		.3734	.3441
Max	.8785	2.0576	.8145	.6464	.7164	.724	.9804
Min	.1475	.2214	.3258	.1966	.2591	.3734	.1823
Avg	.5196	.5786	.5421	.4213	.4308	.5469	.4254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 201 / 11 KV RAM MANDIR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2829	.3772		.3772	.3772	.3772
2				.3772			.4715
3					.5658	.3772	.6602
4				.6602			.7545
5		.8488		.7545	.7545	.8488	.8488
6		.9431	.9431	.8488	.8488	.9431	.9431
7		1.0374		1.0374	1.0374	1.1317	1.0374
8		.9431		1.3203	1.226	1.0374	1.226
9	.905	.8507			.8869	.9313	.9511
10	.7602				.6878	.9313	.8059
11	.6697				.543	.6268	.5373
12	.5792				.4887	.5373	.4119
13	.5249				.4706	.394	.3582
14	.4525				.3982	.4119	.362
15	.3982				.3439	.3734	.3077
16	.4163			.3734	.3982		.3224
17	.4854		.4887	.4668	.4525	.4163	.4887
18	.6535		.6878	.6535	.6154	.6335	.6335
19	.9335		.8145	.8402	.7421	.7602	.7602
20	.8402		.6878	.8402	.6516	.7059	.6516
21	.6535		.543	.6535	.5611		.543
22	.5601		.4706		.5068		.4163
23							.3258
24		.2829	.3772	.3772	.3772	.3772	.3109
Max	.9335	1.0374	.9431	1.3203	1.226	1.1317	1.226
Min	.3982	.2829	.3772	.3734	.3439	.3734	.3077
Avg	.6309	.7413	.5989	.7079	.6159	.6564	.6044

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 202 / MEDICAL COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668	.4668		.4668	.4668	.4668
2				.5601			.5601
3					.6535	.7468	.6535
4				1.0269			.8402
5		.8402	1.1203	1.1203	1.0269	1.2136	1.0269
6		1.1203	1.1203	1.2136	1.1203	1.307	1.1203
7		1.2136		1.4003	1.4003	1.4003	1.4003
8		1.4003		1.6804		1.587	1.6804
9	1.448	1.086			1.267	1.2083	1.4003
10	.1176				1.086	1.0269	1.1641
11	.9955				.8145	.7682	.8402
12	.905				.8145	.7164	.7164
13	.8145				.724	.5487	.5975
14	.543				.6335	.4668	.5601
15	.543				.543		.5975
16	.543			.6535	.6335		.6401
17	.9335		.724	.7095	.724	.6335	.724
18	1.0269		.905	.8402	.905	.905	.905
19	1.2136		1.086	1.0829	1.086	1.1765	1.086
20	1.0269		.9955	1.1203	.9955		.9955
21	.8402		.8145	.8402	.905		.8145
22			.6335		.724		.6335
23							.543
24		.4668	.4668	.4668	.4668	.4668	.4668
Max	1.448	1.4003	1.1203	1.6804	1.4003	1.587	1.6804
Min	.1176	.4668	.4668	.4668	.4668	.4668	.4668
Avg	.8424	.942	.8333	.9781	.8495	.9149	.8514

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 203 / SATELLITE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3696			.3696	***	.462
2				.3696		***	.5544
3					.462	***	.8316
4				.6468		***	.924
5		.924	.924	.924	.924	***	1.0164
6		1.0164		1.0164	1.0164	***	1.0164
7		1.1088		1.386	1.2936	***	1.2012
8		1.2012		1.5708	1.5708	***	1.448
9	1.1765	1.086			1.1765	***	1.2803
10	.1086				.9955	***	1.0387
11	.0995				.724	***	.7682
12	.8145				.6335	***	.6401
13	.6335				.6335	***	.5731
14	.543				.543	***	.5121
15	.543				.4525	***	.4938
16	.543			.4668	.543	***	.4835
17	.6535		.543	.5228	.543	***	.6335
18	.8402		.8145	.7842	.8145	***	.8145
19	1.0269		.9955		1.086	***	1.086
20	.9335		.905		.9955	***	.9955
21	.7842		.8145	.7468	.8145	***	.8145
22			.6335		.724	***	.6335
23						***	.543
24		.3696	.462	.3696	.3696	***	.462
Max	1.1765	1.2012	.9955	1.5708	1.5708	156.3979	1.448
Min	.0995	.3696	.462	.3696	.3696	42.4479	.462
Avg	.6692	.8679	.7615	.8003	.7945	84.9819	.8011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 205 / MEDICAL EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0905			.0905	.0905	.0905
2				.0905			.0905
3					.0905	.0905	.0905
4				.0905			.0905
5		.0905		.0905	.0905	.0905	.0905
6		.0905	.0905	.0862	.0905	.0905	.0905
7		.0905		.0905	.0905	.0905	.0905
8				.0905	.0905	.0905	.0905
9	.0905	.0905			.0476		.0895
10	.0905				.0905	.0019	.0895
11	.0905				.0905	.0335	.0895
12	.0905				.0905	.0332	.0895
13	.0905				.0905	.0004	.0895
14	.0905				.0905	.0042	.0895
15	.0905				.0905		.0895
16	.0905				.0905	.003	.0895
17	.0934		.0905	.0934	.0905	.0924	.0905
18	.0934		.0905	.0934	.0905	.0905	.0905
19	.0934		.0905	.0934	.0905	.0924	.0905
20	.0934		.0905		.0905	.0057	.0905
21	.0934			.0934	.0905		.0905
22			.0905		.0905	.0046	.0905
23						.0042	.0905
24		.0905	.0905	.0905	.0905	.0905	.0905
Max	.0934	.0905	.0905	.0934	.0905	.0924	.0905
Min	.0905	.0905	.0905	.0862	.0476	.0004	.0895
Avg	.0916	.0905	.0905	.0912	.0885	.0526	.0902



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 206 / COLLECTOR OFFICE (EXP)  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0377		.0377	.0377	.0377
2				.0377			.0377
3					.0377	.0377	.0377
4				.0377			.0377
5		.0377		.0377	.0377	.0377	.0377
6		.0377	.0377	.0377	.0943	.0377	.0377
7		.0377		.0377	.0377	.0377	.0377
8				.0377	.0377	.0377	.0377
9	.0362	.0362			.0362	.0716	.0358
10	.0362	.0362			.0362	.0732	.0537
11	.0362				.0362		.0537
12	.0362				.0724		.0716
13	.0362				.0724		.0716
14	.0362				.0724		.0716
15	.0362				.0724		
16	.0362	.0747		2.2779	.0724	.0716	.0537
17	.0373	.056	.0543	.0747	.0724	.0724	.0543
18	.0373	.056	.0362		.0724	.0362	.0362
19	.0373	.0373	.0362	.0346	.0724	.0362	.0362
20	.0373	.0373	.0362	.0373	.0362		.0362
21	.0373	.0373	.0362	.0346	.0362		.0362
22	.0373	.0373	.0362		.0362		.0362
23							.0362
24		.0377	.0377	.0377	.0377	.0377	.0537
Max	.0373	.0747	.0543	2.2779	.0943	.0732	.0716
Min	.0362	.0362	.0362	.0346	.0362	.0362	.0358
Avg	.0367	.0426	.0387	.2269	.0532	.0481	.0452

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 208 / Railway station Express NON SHEDDABLE EXPRESS HV FEEDERS  
feeder Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566	.0566		.0566	.0566	.0377
2				.0566			.0566
3					.0566	.0566	.0566
4				.0566	.0543		.0566
5		.0566	.0566	.0566	.0566	.0566	.0566
6		.0566	.0566	.0566	.0566	.0566	.0566
7		.0566		.0566	.0566	.0566	.0566
8				.0566	.0566	.0566	.0566
9	.0543	.0543		.0537	.0543	.0543	.0537
10	.0543	.056		.0543	.0543	.0716	.0537
11	.0543			.0543			.0537
12	.0543				.0543		.0537
13	.0543				.0543		.0549
14	.0543						.0537
15	.0543				.0543		
16	.0543	.056		.056	.0543	.0358	.0358
17	.056	.056	.0543	.056	.0543	.0543	.0543
18	.056	.056	.0543	.056	.0543	.0543	.0543
19	.056	.056		.056	.0543	.0543	.0543
20	.0519	.056	.0543	.056	.0543		.0543
21	.056	.056	.0543	.056	.0543		.0543
22	.056	.056	.0517		.0543		.0543
23							.0543
24		.0566	.0566	.0566	.0566	.0566	.0366
Max	.056	.0566	.0566	.0566	.0566	.0716	.0566
Min	.0519	.0543	.0517	.0537	.0543	.0358	.0358
Avg	.0547	.0561	.0550	.0559	.0551	.0554	.0526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 209 / 11 KV SAMRTH NAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2686	.1791		.1791	.2686	.1791
2				.2686			.1791
3					.2686	.2686	.2686
4				.3582			.2686
5		.4477		.4477	.4477	.4477	.3582
6		.4835	.4477	.4477	.4477	.5373	.4477
7		.5373		.5373	.6268	.5373	.5373
8				.6268	.7164	.6268	.7164
9	.0633	.5792	.5684		.5973	.6268	.5373
10	.543				.5068	.5373	.4887
11	.0471		.4477		.3982		.4477
12	.4344				.3801		.3258
13	.3801				.3258		.3582
14	.362				.3258		.3582
15	.3439				.3258		.2865
16	.3439			.2801	.3801		.2865
17	.3921		.2896	.3174	.4887	.3982	.4163
18	.5041		.4887	.4108		.4887	.4887
19	.5975		.5611	.6161	.5611	.5792	.543
20	.5601		.543	.5975	.5249		.5249
21	.5041		.5249	.5601	.5068		.4887
22	.4481		.4887		.4706		.4163
23							.362
24		.2686	.2686	.2686	.2686	.2829	.2865
Max	.5975	.5792	.5684	.6268	.7164	.6268	.7164
Min	.0471	.2686	.1791	.2686	.1791	.2686	.1791
Avg	.3946	.4308	.4370	.4413	.4373	.4666	.3988

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 210 / 11 KV TV centre New  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1448	.181	.1086
2				.1267			.1267
3					.181	.181	.1448
4							.181
5					.2172	.2715	.2715
6					.2353	.2715	.2715
7					.2715	.362	.362
8					.4163	.3801	.4525
9	.3801	.3982			.4163		
10	.3258				.2353		
11	.2534				.1991		
12	.1991				.181		
13	.1629				.1448		
14	.1081				.1448		
15	.1448				.1267		
16				.1307	.1629		
17			.1991	.1372	.1991		.1991
18			.2715	.2241	.2534	.2896	.2353
19			.3258	.2572	.3077	.3439	.3077
20			.4706	.2801	.2353		.2534
21			.1991	.2054	.181		.181
22	.168		.1629		.1629		.1629
23							.1448
24			.1267		.1267	.2353	.1086
Max	.3801	.3982	.4706	.2801	.4163	.3801	.4525
Min	.1081	.3982	.1267	.1267	.1267	.181	.1086
Avg	.2178	.3982	.2508	.1945	.2163	.2795	.2195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 211 / Daregaon new

GAOTHAN FEEDER

Feeder KV- 11 / INCOMING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2172	.181	.181
2				.2353			.181
3					.2715	.362	.2715
4							.362
5					.5068	.543	.4525
6			.5611		.4887	.6335	.4525
7					.4525	.543	.362
8					.2172	.4344	.4525
9	.362	.2896			.3801		
10	.3801				.362		
11	.4163				.3258		
12	.3439				.2896		
13					.2172		
14					.1991		
15	.1991				.181		
16	.1448				.2353	.0716	
17			.3982		.2896	.2534	.3258
18	.5041		.4887		.3982	.3801	.4163
19	.5228		.6154		.543	.5973	.543
20	.3734		.4706		.4525		.4706
21	.3734		.3258		.362		.3801
22	.3547		.2715		.2896		.3077
23							.2534
24					.2353	.2172	.2534
Max	.5228	.2896	.6154	.2353	.543	.6335	.543
Min	.1448	.2896	.2715	.2353	.181	.0716	.181
Avg	.3613	.2896	.4473	.2353	.3292	.3833	.3541

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 213 / 11 KV YOGESH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.181	.181	.181
2							.181
3					.181	.2715	.2715
4							.362
5			.362		.362	.4525	.4525
6					.4525	.543	.4525
7					.543	.6335	.6335
8					.6335	.724	.724
9	.6516	.6154			.543		
10	.5249				.4163		
11	.3801				.3258		
12	.3439				.2715		
13	.3439				.2172		
14	.0308				.1991		
15	.2896				.1991		
16	.2896				.2172		
17	.3734		.2896	.3174	.2353	.2172	.3801
18	.4294		.3801	.4108	.3801	.3439	
19	.5228		.4887	.4668	.5249	.4344	.5249
20	.3979		.3982	.4294	.4344		.4163
21	.3547		.3258	.4108	.362		.3258
22			.2896		.3077		.2715
23							.2172
24					.181	.181	.181
Max	.6516	.6154	.4887	.4668	.6335	.724	.724
Min	.0308	.6154	.2896	.3174	.181	.181	.181
Avg	.3794	.6154	.362	.4070	.3413	.3982	.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134030 / Pole Factory Sub-station

Feeder No / Name : 201 / 11KV Industrial, Pole  
 factory Feeder KV- 11 /  
 OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
 STAGGERING (MIDC, EQUIVALENT)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5281	.4527	.7545	.5658	.8676	.5658
2	.5658	.4904	.415	.7545	.5658	.8299	.5281
3	.5847	.4904	.4715	.6413	.5658	.8299	.5658
4	.5847	.4527	.4904	.6413	.6413	.7922	.547
5	.6224	.5658	.5281	.679	.7167	.7545	.5847
6	.7167	.6036	.5658	.7167	.7922	.7545	.7545
7	.7167	.6413	.6413	.7922	.9242	.7167	.9619
8	.7167	.7356	.679	.9054	.9808	1.1317	1.1317
9	.9431	.7545	1.1317	1.3203		1.4335	1.4335
10	1.0562	.7167	1.358	1.358	1.5844	1.5089	1.6221
11	1.1317	.679	1.358	1.5466	1.5466	1.5844	1.6221
12	1.0185	.679	1.4712	1.5466	1.1694	1.6221	1.5466
13	1.0185	.679	1.3957	1.4335	1.4335	1.5466	1.4335
14	.9431	.6036	1.358	1.4335	1.3203	1.5089	1.3957
15	1.094	.679	1.4712	1.5844	1.4335	1.5466	1.3957
16	1.094	.679	1.4335	1.5089	1.4712	1.5089	1.2449
17	.9808	.547	1.2071	.8299	1.4335		1.2449
18	.9808	.547	1.2071	1.5089	1.3957	1.5466	1.3203
19	.9054	.5093	1.1883	1.358	1.2826	1.358	1.1694
20	.7545	.5093	.9619	1.0562	1.1317	1.1694	.9054
21	.6036	.4904	.8676	.8676	.8676	1.1128	.8299
22		.4904	.8676	.8299	.8676	1.0185	.7545
23	.5281	.4715	.7545	.679	.8676		.679
24	.6036	.547	.7545	.6036	.8676		1.3203
Max	1.1317	.7545	1.4712	1.5844	1.5844	1.6221	1.6221
Min	.5281	.4527	.415	.6036	.5658	.7167	.5281
Avg	.8256	.5871	.9596	1.0562	1.0620	1.1972	1.0649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 201 / RLY STN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4572	.4572	.4572	.4572	.4572	
2	.5144	.4572	.4572	.4572	.4572	.4572	
3	.5144	.3658	.4572	.4572	.4572	.4572	
4	.4973	.5487	.5487	.5487	.5544	.5487	
5	.6001	.6401	.6401	.6401	.7316	.823	
6	.7716	.823	1.0974	.9145	.9145	1.0059	
7	1.0117	1.0974	1.3717	1.0974	1.1888	1.1888	
8	1.2689	1.3717	1.6461	1.3717	1.4632	1.4632	
9	1.7924	1.4998	1.4998	1.5729	1.4998	1.7193	1.4998
10	1.6827		1.4266	1.2803	1.3169	1.4998	
11	1.3535	1.4266	1.2437	1.1706	1.5364	1.2803	
12	1.3169	1.134	1.134	1.1706	1.3535	1.1706	
13	1.1706	.9877	.9877	1.134	.9877	1.134	.9511
14	.8779	.9511	.9511	.9877	.9511	1.0608	
15	.8048	.8779	.8779	.8779	.9145	.8326	
16	.9511	1.134	.9145	.7682	.8048	.8779	
17	1.0059	1.2437	1.0059	1.0059	.9145	1.0059	1.0974
18	1.0974	1.386	1.2012	1.2936	1.1888	1.1888	1.2803
19	1.2803	1.5154	1.5708	1.6632	1.4784		1.5708
20	1.1888	1.386		1.0164	1.2012		1.386
21	1.0974	1.1888	1.0059	1.2803			.9145
22	.9145	1.0059	1.0059	.9145	.9145		.7316
23	.7316	.7316	.7316	.7316	.7316		
24	.6161	.5487	.5487	.7682	.5487	.5487	
Max	1.7924	1.5154	1.6461	1.6632	1.5364	1.7193	1.5708
Min	.4973	.3658	.4572	.4572	.4572	.4572	.7316
Avg	.9837	.9904	.9905	.9825	.9812	.9853	1.1789



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 202 / BUS STAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2743	***	.2743	.2743	***	
2	.2572	.2195	***	.2743	.2743	***	
3	.2572	.2743	***	.2195	.2743	***	
4	.2572	.2743	***	.2743	.3658	***	
5	.3429	.3658	***	.3658	.4572	***	
6	.3429	.3658	***	.5487	.5487	***	
7	.5144	.5487	***	.6401	.6401	***	
8	.6001	.823	***	.7316	.7316	***	
9	.9335	1.0269	***	.9335	.7468	***	.8402
10	.8402	.8402	***	.8402	.7468	***	
11	.6535	.8402	***	.8402	.6535	***	
12	.4668	.6535	***	.6535	.6535	***	
13	.4668	.5601	***	.4668	.4668	***	.5601
14	.3734	.4668	***	.4668	.3734	***	
15	.3734	.3734	***	.3734	.3734	***	
16	.3734	.3734	***	.3734	.3734	***	
17	.4572	.6401	***	.6401	.6335	***	.6335
18	.6401	.9145	***	1.0059	.9145	***	.7316
19	.823	1.2936	***	1.2936	1.2012	***	1.2012
20	.7316	1.0164	***	1.0059	.6401	***	1.0164
21	.6401	.6401	***	.9145		***	.9145
22	.4572	.4572	***	.7316	.5487	***	.7316
23	.3658	.3658	***	.3658	.4572	***	
24	.3429	.3658	***	.3658	.3658	4.6334	
Max	.9335	1.2936	133.3135	1.2936	1.2012	127.8008	1.2012
Min	.2572	.2195	45.0084	.2195	.2743	4.6334	.5601
Avg	.4903	.5822	86.6877	.6083	.5528	84.3145	.8286

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 203 / KADRABAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.5365	.2378	.6035	.2743	.2743	
2	.2572	.5205	.2195	.5541	.2561	.2743	
3	.2401	.5083	.2195	.5373	.2561	.2926	
4	.2572	.5404	.2561	.5768	.2926	.3658	
5		.6089	.3292	.7042	.3658	.439	.4199
6	.3944	.8131	.439	.9228	.5487	.5121	.4954
7	.4973	1.1629	.5853	1.2216	.6584	.5853	.6843
8	.6344	1.4617	.7316	1.3976	.7316	.7316	.7491
9	.724	1.5844	.6878	1.4945	.6878	.6878	1.3135
10	.6878	1.4876	.6516	1.3588	.6154	.6154	.7423
11	.6516	1.4354	.5792	1.275	.6154	.5792	.6325
12	.5792	1.1142	.5792	1.1637	.5792	.543	
13	.5792	1.0452	.543	.9945	.4706	.4706	1.4697
14	.5068	.9534		.9065	.4706	.3982	1.2902
15	.4344	.8661	.4344	.9077	.4344	.3982	1.4929
16	.362	.8863	.3982	.8562	.362	.362	1.3413
17	.4207	.9274	.4344	.9206	.4344	.4163	3.7914
18	.5853	1.1172	.5487	1.0745	.5487	.5121	4.2493
19	.6219	1.6416	.6401	1.3473	.7023		4.6154
20	1.243	.7316	.5853	1.2925	.5121		4.302
21	1.1713	.5853	.5304	1.2041			3.7327
22	.9984	.4755	1.0562	.439	.4024		3.3768
23	.8398	.3658	.8688	.3658	.3292		1.5226
24	.6576	.2561	.6896	.2926	.2926	.2743	1.2635
Max	1.243	1.6416	1.0562	1.4945	.7316	.7316	4.6154
Min	.2401	.2561	.2195	.2926	.2561	.2743	.4199
Avg	.5913	.9011	.5324	.9338	.4713	.4596	1.9729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 204 / 11KV PWW FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0914	.0914	.0914	.0914	.0914	
2	.0857	.0914	.0914	.0914	.0914	.0914	
3	.0857	.0914	.0914	.0366	.0914	.0914	
4	.0857	.0914	.0914	.0914	.0914	.0366	
5	.0857	.0914	.0914	.0914	.0914	.0914	
6	.0857	.0914	.0914	.0914	.0914	.0914	
7	.0857	.0914	.0914	.0914	.0914	.0914	
8	.0857	.0914	.0914	.0914	.0914	.0914	
9	.0934	.0934	.0934	.0934	.0905	.0934	.0934
10	.0934	.0934	.0934	.3982	.0934	.0934	
11	.0934	.0934	.3982	.0934	.0934	.0934	
12	.0934	2.151	.7031	.0934	.0934	.0934	
13	.0934	.0934	.0934	.0934	.0934	.0934	.7793
14	.0934	.0934	.0934	.0934	.0934	.0934	
15	.0934	.0934	.0934	.0934	.0934	.0934	
16	.0934	.0934	.0934	4.2848	.0934	.2458	
17	.0914	.0905	.0905	.0905	.0905	6.1871	.0905
18	.0914	.0914	.0914	.0914	.0905	.0905	.0905
19	.0914	.0914	.0914	.0914	.0914		.0914
20	.0914	.0914	.0914	.0914	.0914		.0914
21	.0914	.0914	.0914	.0914			.0914
22	.0914	.0914	.0914	.0914	.0914		.0914
23	.0914	.0914	.0914	.0914	.0914		
24	.0857	.0914	.0914	.0934	.0914	.0914	
Max	.0934	2.151	.7031	4.2848	.0934	6.1871	.7793
Min	.0857	.0905	.0905	.0366	.0905	.0366	.0905
Avg	.0899	.1778	.1301	.2772	.0919	.4182	.1774

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 205 / JINDAL COMPLEX(EXP)

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0914	.0914	.0914	.0914	.0914	
2	.0857	.0914	.0914	.0914	.0914	.0914	
3	.0857	.0914	.0914	.0914	.0914	.0914	
4	.0857	.0914	.0914	.0914	.0914	.0914	
5	.0857	.0914	.0914	.0914	.0914	.0914	
6	.0857	.0914	.0914	.0914	.0914	.0914	
7	.0857	.0914	.0914	.0914	.0914	.0914	
8	.0857	.0914	.0914	.0914	.0914	.0914	
9	.0905	.0905	.0905	.0905	.0905	.0905	.0905
10	.0905	.0905	.0905	.0905	.0905	.0905	
11	.0905	.0905	.0905	.0905	.0905		
12	.0905	.0905	.0905	.0905	.0905	.0905	
13	.0905	.0905	.0905	.0905	.0905	.0905	.0905
14	.0905	.0905	.0905	.0905	.0905	.0905	
15	.0905	.0905	.0905	.0905	.0905	.0905	
16	.0905	.0905	.0905	.0905	.0905	.0905	
17	.0914	.0905	.0905	.0905	.0905	.0905	.0905
18	.0914	.0914	.0914	.0914	.0905	.0905	.0905
19	.0914	.0914	.0914	.0914	.0914		.0914
20	.0914	.0914	.0914	.0914	.0914		.0914
21	.0914	.0914	.0914	.0914			.0914
22	.0914	.0914	.0914	.0914	.0914		.0914
23	.0914	.0914	.0914	.0914	.0914		
24	.0857	.0914	.0914	.0914	.0914	.0914	
Max	.0914	.0914	.0914	.0914	.0914	.0914	.0914
Min	.0857	.0905	.0905	.0905	.0905	.0905	.0905
Avg	.0890	.0911	.0911	.0911	.0910	.0910	.0910

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 206 / Mangal Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.4572	.4572	.439	.5487	1.1309
2	.4458	.4572	.439	.439	.4755	1.0455
3	.4287	.4572	.4572	.4207	1.044	.4572
4	.4458	.6219	.6584	.5304	1.1576	.5487
5	.6344	.8048	.9145	.8048	1.483	.8048
6	.8573	1.0974	1.1706	1.0974	2.1019	1.0974
7	1.2346	1.3535	1.4632	1.3535	2.8913	1.3535
8	1.6804	1.6461	1.6461	1.6461	3.5925	1.7193
9	1.7924	1.7177	1.643	1.6057	3.5597	.6878
10	1.5684	1.4563	1.4415	1.3443	3.0826	1.6804
11	1.307	1.4563	1.2696	1.2696	2.4569	1.3443
12	1.1576	1.1576	1.1949	1.1949	2.1117	1.2696
13	1.0456	.8589	.9709	.9335	1.749	1.1576
14	.8962	.8215	.9335	.8962	1.6445	1.0829
15	.8589	.7468	.8215	.7842	1.7108	.7468
16	.9335	.8962	.7842	.7842	1.6377	.7842
17	1.0242	.9877	.9511	1.0059	1.8983	.9694
18	1.2803	1.2197	1.3306	1.2197	2.4097	1.2071
19	1.4449	.7316	1.4415	1.3306	2.9238	
20	1.2803	1.1827	1.2567	1.2197	2.495	
21	1.0608	.9877	1.0242	.9145	1.2468	
22	.9145	.8779	.9145	.8048	1.9638	
23	.8048	.7316	.8048	.7316	1.656	
24	.4973	.5121	.5487	.5853	1.3032	.5853
Max	1.7924	1.7177	1.6461	1.6461	3.5925	1.7193
Min	.4287	.4572	.439	.4207	.4755	.4572
Avg	1.0024	.9682	1.0224	.9732	1.9643	1.0354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 207 / NARIMAN NAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1646	.1646	.1646	.1829	.1646	
2	.1372	.1646	.1463	.1646	.1646	.1646	
3	.1372	.1646	.1463	.1463	.1646	.1829	
4	.1372	.2012	.1829	.2012	.2012	.2012	
5	.1715	.2378	.2378	.2561	.2743	.2561	
6	.2058	.2926	.2926	.3109	.2926	.2926	
7	.2572	.3658	.3658	.3841	.3841	.3658	
8	.3601	.4024	.4024	.4207	.4207	.4207	
9	.4163	.4163	.4163	.3801	.4344	.4525	.3801
10	.3982	.362	.3258	.3258	.362	.4163	
11	.3801	.362	.3258	.3801	.2715	.3439	
12	.3439	.3077	.3258	.362	.2534	.2896	
13	.3077	.2715	.3077	.3077	.2896	.3077	.2896
14	.2534	.2534	.2896	.2534	.2896	.2896	
15	.2534	.2353	.2534	.2715	.2715	.2172	
16	.2353	.2534	.2534	.2534	.2353	.2534	
17	.2561	.2896	.2896	.3109	.2715	.2715	.3077
18	.3292	.3658	.3658	.3658	.3292	.3077	.3439
19	.3841	.2012	.4207	.4207	.4024		.4024
20	.3658	.3658	.3841	.3658	.3475		.3658
21	.3292	.3109	.3292	.2926			.2926
22	.2561	.2561	.2743	.2561	.2926		.2561
23	.1829	.2012	.2561	.2195	.2561		
24	.168	.1829	.1829	.1829	.2012	.1829	
Max	.4163	.4163	.4207	.4207	.4344	.4525	.4024
Min	.1372	.1646	.1463	.1463	.1646	.1646	.2561
Avg	.2668	.2762	.2891	.2915	.2866	.2832	.3298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134036 / 33/11 KV Rohanwadi

Substaion

Feeder No / Name : 201 / 11 kv Sarswati Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.2324	.5201	.0235	.2353	.1629	.3732
2	.0163	.3915	.5096	.0217	.2172	.1629	.3709
3	.0163	.4106	.5104	.0217	.2172	.181	.4018
4	.0235	.4959	.4735	.0253	.2715	.2172	.4902
5	.029	.6163	.5697	.0362	.3258	.2715	.6392
6	.0344	.7173	.7305	.0434	.4344	.3982	.8675
7	.0434	.9301	.9589	.0561	.5611	.4887	1.0574
8	.0543	1.1576	1.1706	.067	.6516	.5249	1.1835
9	.0579	1.3335	1.2536	.0633	.5792	.543	1.2978
10	.0615	1.2664	1.3641	.4887	.5249	.5611	.7177
11	.5792	1.4064	1.1877	.5611	.5611	.6268	.7206
12	.5973	1.4224	1.0244	.5611	.0597	.5611	.6431
13		1.3097	.6828	.5611	.5792	.5068	.6124
14		1.1574	.3761	.4706	.543	.4706	.5618
15		1.1433	.4961	.543	.5068	.5068	.5458
16	1.0545	1.1894	.5373	.543	.4887	.5068	.5867
17	1.2527	1.1706	.2507	.5611	.5068	.362	.5613
18	1.1125	1.2106	.0271	.5068	.3982	.3077	.5976
19	.9193	1.0214	.0398	.5068	.362	.3439	.5314
20	.8589	.8372	.0344	.3801	.3439	.3439	.51
21	.7099	.7228	.029	.3439	.2534	.2172	.4322
22	.5992	.6196	.029	.2896	.2172	.1991	.3586
23	.5096	.5695	.0253	.2534	.2172	.1991	.3032
24	.265	.4954	.2534	.0235	.2353	.1629	.4447
Max	1.2527	1.4224	1.3641	.5611	.6516	.6268	1.2978
Min	.0163	.2324	.0253	.0217	.0597	.1629	.3032
Avg	.4197	.9095	.5439	.2897	.3871	.3678	.6170

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134036 / 33/11 KV Rohanwadi

Substaion

Feeder No / Name : 202 / 11 KV Bholeshwar Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0795	1.6322	1.6524	.9408	1.6643	.8131	.8029
2	.0776	1.5634	1.6295	.9047	1.5901	.7762	.7655
3	.0795	1.5604	1.6156	.9021	1.5947	.7762	.8962
4	.0887	1.7254	1.7522	.961	1.7772	.8871	1.0829
5	.1257	2.3247	2.146	1.1571	1.0903	1.1088	1.251
6	.1756	3.2538	3.2015	1.7261	1.4045	1.4415	1.5497
7	.1848	4.1756	4.1745	2.4316	2.0328	2.0698	2.0538
8	.2384	4.9061	5.0672	2.7487	2.4579	2.4209	2.4086
9	.2384	4.6531	4.6838	2.6436	2.2177	2.2916	2.3152
10	.2199	4.128	4.2025	4.0946	1.848	1.9959	.1774
11	1.7372	3.2209	3.5021	3.3804	1.5708	1.8858	.1515
12	1.6263	2.9458	2.9386	3.0544	.1349	1.7364	.1386
13		2.7603	2.6803	2.6515	1.2012	1.587	.1257
14		2.2943	1.2323	2.3342	1.0349	1.4563	.1109
15		2.2101	1.1949	2.2371	.961	1.1016	.1146
16	3.0234	2.3937	1.1389	2.5172	1.0719	1.2136	.1164
17	3.3816	2.825	1.531	3.0201	1.3491	1.1389	.1405
18	3.6846	3.5101	.1608	3.6402	1.6632	1.7177	.1756
19	4.1358	3.7683	2.0576	4.2638	1.9589	1.9605	.1959
20	3.5233	3.4693	2.0977	3.6965	1.7187	1.7551	.1737
21	3.2664	3.1245	1.8363	3.1447	1.4415	1.475	.1534
22	2.6663	2.6995	1.5906	2.7885	1.3121	1.2696	.1331
23	2.1793	2.1473	1.2763	2.1578	.961	1.0269	.0998
24	1.0118	1.7345	1.8473	1.0464	.8316	.8871	.8589
Max	4.1358	4.9061	5.0672	4.2638	2.4579	2.4209	2.4086
Min	.0776	1.5604	.1608	.9021	.1349	.7762	.0998
Avg	1.5116	2.8761	2.3004	2.4351	1.4537	1.4497	.6663



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 201 / 11 KV Gokulnagari feeder SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3337	.333	.6427	.2966	.3522	.333	.3333
2	.311	.333	.6275	.2966	.3522	.333	.3333
3	.3337	.37	.6244	.2966	.3522	.3515	.3333
4	.3337	.37	.6518	.2966	.3522	.3515	.4074
5	.4078	.407	.9752	.3708	.4449	.407	.5185
6	.5561	.518	.5479	.5561	.6674	.555	.6296
7	.7044	.814	1.6081	.8157	.8157	.7585	.7778
8	.8342	.8325	1.8377		.8342	.888	.8519
9	.7955	1.5806	.8148		.777	.7778	.8148
10	.5735	1.4608			.4625	.6667	.6488
11	.555	1.1655	.723	.7971	.4625	.5185	.5005
12	.5365	.9855	.5747	.5932	.4625		.4449
13	.4255	.4702	.5376	.5191	.407	.4815	.3708
14	.3885	1.6112	.4078		.407	.4074	.3708
15	.37	.7271	.4078		.37	.3704	.3337
16		.3589		.7044	.333	1.1111	.3893
17	.481	.5604	.4634	.6674	.444	.4082	.3893
18	.592	1.1794	.5932	.668	.518	.5556	.5191
19	.666	1.5639	.6303	.668	.666	.6296	.6674
20	.6105	1.4273	.6303		.629	.5926	.6488
21	.518	1.2407	.5561	.5932	.5567	.5556	.5932
22	.407	1.0129	.482	.4825	.4825	.4444	.5191
23	.4082	.8566	.3711	.3893	.407	.3704	.3893
24	.3337	.7404	.3708	.2966	.3522	.333	.3333
Max	.8342	1.6112	1.8377	.8157	.8342	1.1111	.8519
Min	.311	.333	.3708	.2966	.333	.333	.3333
Avg	.4989	.8716	.6854	.5171	.4962	.5304	.5049

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 202 / 11 KV Dukhi Nagar SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8907	.8907	1.0021	.7802	.8843	.9278	.8907
2	.8907	.8907	1.0021	.7802	.8907	.9278	.8907
3	.8907	.8907	1.0021	.7802	.8907	1.0021	.8536
4	.8907	1.0763	1.1134	.7802	.8907	1.1505	1.0021
5	1.0021	1.3361	1.3361	.8173	1.0392	1.3732	1.2247
6	1.1505	1.633	1.5588	1.2631	1.3732	1.6144	1.4474
7	1.7814	1.9856	2.0412	1.969	2.1526	2.0598	1.967
8	2.1919	2.3753	2.0783		2.2268	2.3938	2.2268
9	2.4309	2.2268	2.3381		2.1526	2.4495	2.1155
10	2.1155	1.8928			1.7629	2.2268	1.9133
11	1.8557	1.7814	2.2662	2.3753	1.8557	1.9299	1.6718
12	1.7443	1.5588	1.8018	1.9856	1.7072		1.6701
13	1.4103		1.5232	1.6701	1.3732	1.8557	1.2817
14	1.3361	1.1876	1.2631	1.4103	1.299	1.4845	1.2817
15	1.299	1.1134	1.1517	1.2619	1.2619	1.2247	1.0774
16				1.1876	1.2247	1.1134	1.3003
17	1.633	1.4474	1.4489	1.4103	1.4845	1.3361	1.5232
18	1.8928	1.967	1.9319	1.7814	1.8	1.7814	1.7647
19	1.8557	1.967	2.0062	1.8186	1.9299	1.8557	1.9319
20	1.6701	1.7072	1.709		1.7072	1.6701	1.6347
21	1.4474	1.5216	1.5604	1.5216	1.4845	1.4103	1.4861
22	1.1505	1.1876	1.2631	1.1876	1.2401	1.2619	1.3003
23	1.1134	1.0763	1.0021	.9835	1.1134	1.0392	1.0774
24	.8907	.9278	1.0392	.7802	.8907	.9278	.9649
Max	2.4309	2.3753	2.3381	2.3753	2.2268	2.4495	2.2268
Min	.8907	.8907	1.0021	.7802	.8843	.9278	.8536
Avg	1.4580	1.4837	1.5200	1.3272	1.4432	1.5225	1.4374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA

Feeder No / Name : 201 / TOWN-4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097		.6097		.6097
2		.3048		.3048		.3048
3		.3048		.3048		.3048
4		.3048		.3048		.3048
5		.3048		.3048		.3048
6		.6097		.6097		.6097
7		.6097		.6097		.6097
8		.9145		.9145		.9145
9		.9145		.9145	.9145	.9145
10		.9145		1.2193	.9145	.9145
11		.9145	.9145		.9145	.9145
12		.9145	.9145		.9145	.9145
13		.9145	.9145		.9145	.9145
14		.9145	.9145		.9145	.9145
15		.6097	.9145		.9145	.9145
16	.6097		.6097		.6097	
17	.9145		.9145		.6097	
18	.9145		.9145		.9145	
19	1.2193		.9145		.9145	
20	1.2193		.9145		1.2193	
21	.9145		.9145		.9145	
22	.9145		.9145		.9145	
23	.6097		.6097		.6097	
24	.6097		.6097		.6097	
Max	1.2193	.9145	.9145	1.2193	1.2193	.9145
Min	.6097	.3048	.6097	.3048	.6097	.3048
Avg	.8806	.6706	.8492	.6097	.8574	.6910

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA

Feeder No / Name : 204 / TOWN-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097	.6097	.6097		.6097
2		.6097	.6097	.6097		.6097
3		.6097	.6097	.6097		.6097
4		.6097	.6097	.6097		.6097
5		.6097	.6097	.6097		.6097
6		.9145	.9145	1.2193		.9145
7		1.5242	1.5242	1.829		1.5242
8		2.1338	1.829	2.1338		1.829
9		2.1338	2.1338	2.1338		1.829
10		1.829	1.829	1.829		1.829
11		1.5242	1.2193	1.5242	1.2193	1.2193
12	1.2193	1.2193	1.2193	1.2193	.9145	1.2193
13	.9145	.9145	.9145	.9145	1.2193	.9145
14	.9145	.9145		.9145	.9145	.9145
15	.6097	.9145		.6097	.9145	
16	.6097	.9145		.6097	.6097	
17	.9145	.9145	.9145		.9145	
18	1.2193	1.2193	1.2193		1.2193	
19	1.5242	1.5242	1.5242		1.5242	
20	1.5242	1.5242	1.5242		1.5242	
21	1.2193	1.2193	1.5242		1.2193	
22	1.2193	1.2193	1.2193		1.2193	
23	.9145	.9145	.9145		.9145	.9145
24	.9145	.6097	.6097		.6097	.9145
Max	1.5242	2.1338	2.1338	2.1338	1.5242	1.829
Min	.6097	.6097	.6097	.6097	.6097	.6097
Avg	1.0552	1.1304	1.1468	1.1241	1.0669	1.0669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA

Feeder No / Name : 205 / TOWN-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	16-JAN-17	17-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2193		1.2193
2		.9145		.9145
3		.9145		.9145
4		.9145		.9145
5		1.2193		1.2193
6		1.5242		1.5242
7		2.4387		2.4387
8		3.3532		3.0483
9		3.3532		3.0483
10		3.3532		3.3532
11		3.0483		2.7435
12		2.4387		2.7435
13		2.4387		2.1338
14	1.829			2.1338
15	1.829			1.829
16	1.829		1.829	
17	1.829		1.829	
18	2.4387		2.1338	
19	3.3532		2.7435	
20	3.3532		3.3532	
21	3.0483		3.0483	
22	2.4387		2.4387	
23	1.829		1.829	
24	1.5242		1.5242	
Max	3.3532	3.3532	3.3532	3.3532
Min	1.5242	.9145	1.5242	.9145
Avg	2.3001	2.0869	2.3032	2.0119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA

Feeder No / Name : 402 / INCOMER SURVEY NO. 488 NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
 Feeder KV- 33 / OUTGOING (NON CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1113	1.773	1.0425	1.0143	1.0477	1.5415	1.6341
2	3.0762	1.5509	1.076	1.0151	1.0409	1.3786	1.5517
3	2.9759	1.5698	1.0588	1.0039	1.0503	1.4249	1.4266
4	3.131	1.6358	1.052	1.0297	1.0297	1.3864	1.3666
5	3.095	1.5338	1.0596	1.0254	1.0323	1.4541	1.6083
6	3.3917	1.3768	1.2534	1.3057	1.1831	1.6872	1.6761
7	3.1515	1.4737	1.0339	1.0502	1.0126	1.3932	1.5783
8	3.5125	1.0116	1.3383	1.2834	1.2774	1.6958	1.7061
9	6.0983	1.1823	1.2937	1.2319	3.8195	1.6144	1.7112
10	5.9217	1.2251	1.2045	1.2628	3.6308	1.5964	1.695
11	5.6053	1.1677	1.0905	1.0871	3.792	1.5784	1.6564
12	5.9122	1.1703	1.202	1.0846	3.0229	1.6229	1.8707
13	5.8162	1.0751	1.262	1.2131	4.129	1.7027	1.6332
14	6.2062	1.2174	1.2045	1.1557	4.1366	1.5689	1.5398
15	5.9971	1.2972	1.1728	1.1823	4.0964	1.4935	1.6204
16	5.8351	1.0203	.9594	.9182	3.8443	1.5389	1.5552
17	5.7271	.9971	.9705	.9045	3.5965	1.5286	1.4755
18	5.6791	1.0426	1.003	.8462	3.6308	1.3272	1.4849
19	3.5511	.9739	.9825	.9191	3.6694	1.5561	1.4617
20	2.8884	1.0425	.9765	.9834	3.6515	1.4695	1.4892
21	2.32	1.0468	.9568	.986	1.5766	1.4806	1.4909
22	1.9804	1.0434	.9611	.9774	1.4095	1.4506	1.5278
23	1.8476	1.0279	.9808	1.0228	1.4969	1.5021	1.4541
24	1.8664	1.0571	1.0151	1.0545	1.5141	1.6178	1.4412
Max	6.2062	1.773	1.3383	1.3057	4.1366	1.7027	1.8707
Min	1.8476	.9739	.9568	.8462	1.0126	1.3272	1.3666
Avg	4.1124	1.2297	1.0896	1.0649	2.4871	1.5254	1.5690

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 201 / GOVT POLYTECH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5242	1.2193		1.2193		1.5242
2		1.2193	1.2193		1.2193		1.2193
3		1.2193	1.2193		1.2193		1.5242
4		1.5242	1.5242		1.5242		1.5242
5		1.829	1.829		1.829		1.829
6		2.4387	2.4387		2.7435		2.7435
7		3.3532	3.3532		3.658		3.658
8		4.2676	3.9628		4.2676		3.9628
9		4.2676	3.9628		4.2676		3.9628
10		3.658	1.2193		3.9628	3.9628	3.9628
11		3.3532		3.9628	3.658	3.9628	3.9628
12	3.3532	2.7435	3.658	3.9628	.9145	3.658	3.658
13	3.3532	3.0483	3.3532	3.658			3.3532
14	3.0483	2.7435	3.0483	3.3532			
15	3.0483	3.0483	3.0483				
16	3.0483	.6097		3.0483		3.658	
17				3.3532		3.658	
18	3.0483			3.3532		3.658	
19	3.3532	3.3532		3.658		3.658	
20	3.3532	3.3532		3.658		3.3532	
21	2.7435	2.7435		3.0483		2.7435	
22	2.1338	2.1338		2.1338		2.4387	
23	1.829	1.829		1.829		1.829	
24	1.5242	1.5242		1.2193		1.5242	
Max	3.3532	4.2676	3.9628	3.9628	4.2676	3.9628	3.9628
Min	1.5242	.6097	1.2193	1.2193	.9145	1.5242	1.2193
Avg	2.8197	2.5357	2.5040	3.0952	2.5403	3.1754	2.8373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 202 / RAVIRAJ FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	16-JAN-17	17-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2193	1.5242		1.829
2		1.2193	1.829		1.5242
3		2.4387	2.1338		2.4387
4		1.829	1.829		2.4387
5		2.4387	2.1338		2.4387
6		2.1338	2.4387		1.829
7		2.4387	2.4387		2.4387
8		2.4387	1.5242		1.829
9		2.1338	2.1338	1.2193	1.829
10		1.829	1.2193	1.2193	1.829
11		2.7435	2.4387	1.829	1.829
12		1.829	1.2193	1.829	1.5242
13		1.2193	1.5242	2.4387	1.5242
14	2.1338		1.829	1.829	1.829
15	1.5242		2.4387	2.1338	1.5242
16	2.1338		2.4387	1.2193	1.5242
17	1.5242		2.1338	2.1338	1.5242
18	1.2193		2.1338	1.829	
19	2.1338		2.1338	1.2193	
20	1.2193		2.1338	1.829	
21	1.5242		1.2193	2.1338	
22	2.1338		1.2193	1.829	
23	1.829		1.2193	1.829	
24	1.5242		1.2193	1.829	
Max	2.1338	2.7435	2.4387	2.4387	2.4387
Min	1.2193	1.2193	1.2193	1.2193	1.5242
Avg	1.7181	1.9931	1.8544	1.7718	1.8649



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 203 / SARASWATI 11KV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048		.3048	.3048	.3048
2		.3048		.3048		.3048
3		.3048		.3048		.3048
4		.3048		.3048		.3048
5		.3048		.3048		.3048
6		.3048		.3048		.3048
7		.3048		.3048		.3048
8		.3048		.3048		.3048
9		.3048		.3048	.3048	.3048
10				.3048	.6097	.6097
11		.6097		.6097	.6097	.9145
12	.3048	.6097		.6097	.6097	.9145
13	.3048	.9145		.6097	.6097	.9145
14	.3048			.6097	.6097	.6097
15	.3048			.6097	.6097	.9145
16	.3048		.9145	.6097	.6097	
17	.3048		.9145	.6097	.9145	
18	.3048		.9145	.6097	.6097	
19	.3048		.6097	.6097	.6097	
20	.3048		.3048	.6097	.6097	
21	.3048		.3048	.3048	.3048	
22	.3048		.3048	.3048	.3048	
23	.3048		.3048	.3048	.3048	.3048
24	.3048		.3048	.3048	.3048	.3048
Max	.3048	.9145	.9145	.6097	.9145	.9145
Min	.3048	.3048	.3048	.3048	.3048	.3048
Avg	.3048	.4064	.5419	.4318	.5200	.4841

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 204 / 11KV SHAKTI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097	.9145	.9145		.6097
2		.6097	.9145	.9145		.6097
3		.6097	.9145	.9145		.6097
4		.6097	.9145	.9145		.6097
5		.6097	.9145	.9145		.6097
6		.9145	.9145	.9145		.6097
7		.9145	.9145	.9145		.9145
8		.9145	.9145	.9145		.9145
9		.9145	.9145	.9145		.9145
10		.9145	.9145	1.2193		.9145
11		1.2193	1.2193	1.5242		1.2193
12		1.2193	1.5242	1.5242		1.2193
13		1.2193	1.2193		1.2193	1.2193
14	.9145	.9145	1.2193		1.2193	
15	.9145	1.2193	.9145		1.2193	
16	.9145	1.2193	.9145		1.2193	
17		1.2193	.9145		1.2193	
18		.9145	.9145		1.2193	
19	.9145	.9145	.9145		.9145	
20	.9145	.9145	.9145		.9145	
21	.9145	.9145	.9145		.9145	
22	.6097	.9145	.9145		.6097	
23	.6097	.9145	.9145		.6097	
24	.6097	.9145	.9145		.6097	
Max	.9145	1.2193	1.5242	1.5242	1.2193	1.2193
Min	.6097	.6097	.9145	.9145	.6097	.6097
Avg	.8129	.9272	.9780	1.0415	.9907	.8442

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 206 / GEDORE 11KV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6097		.6097		.6097
2		.6097		.6097		.6097
3		.6097		.6097		.9145
4		.6097		.9145		.6097
5		.6097		.6097		.6097
6		.6097		.6097		.9145
7		.6097		.6097		.9145
8		.6097		.6097		.6097
9		.6097		.6097		.9145
10		1.2193		1.5242		1.5242
11		1.5242	1.5242	1.829	1.5242	1.829
12		1.5242	1.829	1.829	1.829	1.829
13		1.829	1.5242	1.829	1.829	1.829
14		1.5242	1.5242	1.2193	1.5242	
15		1.5242	1.5242	1.829	1.5242	
16	.6097		1.829		1.5242	
17	.6097		1.5242		1.5242	
18	.6097		1.5242		1.829	
19	.6097		1.5242		1.5242	
20	.6097		.9145		1.2193	
21	.6097		.6097		.6097	
22	.6097		.9145		.6097	
23	.6097		.6097		.6097	
24	.6097		.9145		.6097	
Max	.6097	1.829	1.829	1.829	1.829	1.829
Min	.6097	.6097	.6097	.6097	.6097	.6097
Avg	.6097	.9755	1.3065	1.0568	1.3065	1.0552

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 207 / SURENDRA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193		.9145		.9145	
2	1.2193		.9145		1.2193	
3	1.2193		.9145		1.2193	
4	1.2193		.9145		1.2193	1.2193
5	1.2193		.9145		1.2193	1.2193
6	1.2193		.9145		1.2193	1.2193
7	1.2193		.9145		1.2193	1.2193
8	1.2193		.9145		1.2193	1.2193
9	1.829		1.5242		1.829	1.829
10	2.1338		1.5242		2.1338	2.4387
11	2.7435		2.1338	2.7435	2.1338	2.4387
12	2.7435		2.4387	2.7435		2.7435
13	2.7435		2.4387	2.4387		2.7435
14	2.7435		2.1338	2.1338		2.7435
15	2.7435		2.4387	2.4387		
16	2.7435	.9145		2.4387		
17	2.7435	.9145		2.7435		
18	2.7435	.9145		2.4387		
19		.9145		2.1338		
20		.9145		2.1338		
21		.9145		1.5242		
22		.9145		.9145		
23		.9145		.9145		
24		.9145		.9145		
Max	2.7435	.9145	2.4387	2.7435	2.1338	2.7435
Min	1.2193	.9145	.9145	.9145	.9145	1.2193
Avg	1.9814	.9145	1.4632	2.0467	1.4133	1.9121

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 401 / KALIKA

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.7435			2.7435		2.7435
2	2.7435	2.7435			2.7435		2.7435
3	2.7435	2.7435			2.7435		2.7435
4	2.7435	2.7435			2.7435		2.7435
5	2.7435	2.7435			2.7435		2.7435
6	2.7435	2.7435			2.7435		2.7435
7	2.7435	2.7435			2.7435		2.7435
8	2.7435				2.7435		2.7435
9	2.7435	2.7435	2.7435		2.7435		2.7435
10	2.7435	2.7435	2.7435	2.7435			2.7435
11	2.7435	2.7435	2.7435	2.7435			2.7435
12	2.7435			2.7435			2.7435
13	2.7435			2.7435			2.7435
14	2.7435			2.7435		2.7435	
15	2.7435			2.7435		2.7435	
16	2.7435			2.7435		2.7435	
17	2.7435			2.7435		2.7435	
18	2.7435			2.7435		2.7435	
19	2.7435			2.7435		2.7435	
20	2.7435			2.7435		2.7435	
21	2.7435			2.7435		2.7435	
22	2.7435			2.7435		2.7435	
23	2.7435			2.7435		2.7435	
24	2.7435			2.7435		2.7435	
Max	2.7435	2.7435	2.7435	2.7435	2.7435	2.7435	2.7435
Min	2.7435	2.7435	2.7435	2.7435	2.7435	2.7435	2.7435
Avg	2.7435	2.7435	2.7435	2.7435	2.7435	2.7435	2.7435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION

Feeder No / Name : 403 / MATSYODARI FEEDER  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		24.6914		***	***	27.4349
2		27.4349		***		24.6914
3		27.4349		***		***
4		24.6914		***		***
5		24.6914		27.4349		***
6		27.4349		***		***
7		27.4349		***		27.4349
8		27.4349		***		***
9		24.6914		***		***
10		27.4349		***		***
11		27.4349	***	***		24.6914
12	24.6914	27.4349	***	27.4349		***
13	24.6914	24.6914	24.6914	***		24.6914
14	24.6914	27.4349	24.6914	***		27.4349
15	24.6914	24.6914	21.9479	27.4349	24.6914	24.6914
16	24.6914		21.9479	24.6914	27.4349	24.6914
17	27.4349		21.9479	24.6914	27.4349	
18	27.4349		27.4349	21.9479	***	
19	24.6914		27.4349	24.6914	27.4349	
20	24.6914		27.4349	19.2044	***	
21	27.4349		27.4349	24.6914	27.4349	
22	24.6914		27.4349	***	***	
23	27.4349		***	***	***	
24	24.6914		***	***	***	
Max	27.4349	27.4349	30.1784	35.6653	32.9219	38.4088
Min	24.6914	24.6914	21.9479	19.2044	24.6914	24.6914
Avg	25.5356	26.3375	26.6510	29.3782	29.4302	29.1496

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134014 / SEOLI 33/11 KV S/S

Feeder No / Name : 201 / PIMPALWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	1.0269		1.4632	.9431	1.2136	
2	.3658	1.1203		1.4784		1.2136	
3	.3658	1.1203		1.3717		1.1203	
4	.5487	1.2136		1.5708		1.1203	
5	.6401	1.2136		1.6461		1.2136	
6	.7316	1.2136	1.1393	1.6461		1.2136	
7		1.4003		1.7375		1.7737	
8		1.4003		1.829		2.0538	1.9281
9		1.587		1.8861	1.6289	2.0538	1.7528
15	2.0538						
16	2.0538		.3658	.1715	.1867	.1753	.3658
17	2.0538		.4572	.2572	.4668	.1753	.4572
18	1.7737	.4382	.5487	.4287	.3734	.3506	.5487
19	1.4937	.6135	.7316	.5144	.5601	.5258	.5544
20	1.1203		.6401	.4287	.4668	.4382	.4572
21	1.0269	.3506	.4572	.4287	.4668		.3696
22	1.0269	.3506	.3658	.3429	.2801	.3856	.3658
23		.2629	.3658	.2572	.2801		.3658
24			1.4784		.7716	.8402	1.0974
Max	2.0538	1.587	1.4784	1.8861	1.6289	2.0538	1.9281
Min	.2772	.2629	.3658	.1715	.1867	.1753	.3658
Avg	1.1094	.9508	.6550	1.0270	.5840	.9917	.7512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134014 / SEOLI 33/11 KV S/S

Feeder No / Name : 202 / SEOLI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2772		.2772	.2772	.6468	
2	.2772	.3696		.2772		.6468	
3	.3734	.3696		.4668		.7392	
4	.462	.6468		.5601		.7392	
5	.6535	.6468		.7468		.7392	
6			.6135				
8							.7011
9					.8316		.7888
10	.7392	.924	.7011		.7392	.8764	.9145
11	.7392	.6468	.5544		.6468	.7011	
12	.7392	.462		.5544	.3696	.6135	
13	.5544			.5544	.3696	.5258	
14	.5544			.462	.3696		
15	.5544		.056	.462	.462		.5487
16	.462		.5544	.462	.462	.4382	.6468
17	.6468		.7392	.5544	.462	.5258	.724
18	.8316	.7011	.9335	.6468	.8316	.6135	.823
19	.7392	.6836	.0832	.7392	.8316	.7888	.8316
20	.5544		.7392	.6468	.5544	.4382	.6401
21	.462	.3506	.6535	.462	.462		.5601
22	.3696	.3506	.4668	.3696	.3696	.5258	.3734
23			.2801	.462	.3696		.3734
24			.2801		.2772	.2772	.4668
Max	.8316	.924	.9335	.7468	.8316	.8764	.9145
Min	.2772	.2772	.056	.2772	.2772	.2772	.3734
Avg	.5551	.5357	.5119	.5120	.5109	.6147	.6456



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134014 / SEOLI 33/11 KV S/S

Feeder No / Name : 203 / BORGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5708	.6201		.5487	.6001	.6201	
2	1.5708	.7087		.7392		.5316	
3	1.6461	.7087		.8316		.8859	
4	1.7556						
5	1.6632						
6	1.7556						
7	1.6632						
8	1.5947						
9	1.7718						
10	1.5947	2.8349	2.1033		2.1262	1.5775	2.7435
11	1.4175	2.8349	3.3265		2.6578		2.9264
12	1.1517	2.6578	3.2341	2.572	2.8349	3.155	2.9264
13	1.2403		3.2341	2.8292	3.0121	3.8561	2.8349
14	1.2403		3.1417	2.6578	2.6578		2.7435
15			3.0493	2.572	2.392	2.6292	2.7435
16			2.9569	2.6578	2.3034	2.7168	2.652
17			2.8645	2.4863	2.3034	2.6292	2.4025
18		2.8045	1.0164	.7716	.7087	.7888	1.0164
19	1.5947	2.4539	1.0164	.8573	1.0631	.8764	.924
20	.7973		.924	.7716	.7973	1.0517	.924
21	.7087	2.1033	.8316	.8573	.7087		.8316
22	.6201	1.9281	.7392	.8573	.7973	1.0517	.7392
23			.6468	.7716	.6201		.7392
24			.6468		.6001	.5316	.6468
Max	1.7718	2.8349	3.3265	2.8292	3.0121	3.8561	2.9264
Min	.6201	.6201	.6468	.5487	.6001	.5316	.6468
Avg	1.4087	1.9655	1.9821	1.5188	1.6364	1.6358	1.8529

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 201 / BHATEPURI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3658	.5144	.4287	.4287	.4572
2			.3658	.5144	.463	.4287	.4572
3			.3658	.5144	.5144	.4287	.4572
4		.3658	.4572		.6859	.4287	.6401
5		.4572	.4572	.6859	.6859	.6001	.823
6		.4572	.4572	.8573	.8573	.6859	.823
7		.4572	.5487	1.2003	.9259	.9431	.823
8		1.0059	1.0974	1.2003	.9259	.9431	1.0974
9		1.0059	1.1888	1.286	1.1145	1.0288	
10	.5144						
11	.8596						
12	.7682						
13	1.0974						
14	1.0974						
15	1.0059						
16	.823						
17	.823						
24			.2743	.4287		.4287	.1829
Max	1.0974	1.0059	1.1888	1.286	1.1145	1.0288	1.0974
Min	.5144	.3658	.2743	.4287	.4287	.4287	.1829
Avg	.8736	.6249	.5578	.8002	.7335	.6345	.6401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 202 / RAMNAGAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859						
2	.6859						
3	.6859						
4	1.0288						
5	1.2003						
6	1.5432						
7	1.7147						
8	1.8861						
9		.9145	1.0974		.7716		1.2803
10		1.2803	1.0974		1.0288		1.0974
11		1.4632	1.2003		1.7147		1.0974
12		1.2803	1.3717		1.7147		.5144
13		1.2803	1.3717		1.5432	1.6461	1.2003
14		1.6461	1.2003	.6859	2.0576	1.6461	1.3717
15		1.6461	1.2003		1.8861	1.6461	1.3717
16		1.6461	1.2003	.6859		1.6461	1.2003
Max	1.8861	1.6461	1.3717	.6859	2.0576	1.6461	1.3717
Min	.6859	.9145	1.0974	.6859	.7716	1.6461	.5144
Avg	1.1789	1.3946	1.2174	.6859	1.5310	1.6461	1.1417

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 205 / BHATEPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.7316	.4572	.3429	.4572	.3429	.3658
2	.3429	.7316	.4572	.3429	.6859	.3429	.3658
3	.3429	.7316	.4572	.3429	.7716	.3429	.3658
4	.3429	.7316	.6401	.5144	.0857	.4287	.7316
5	.6001	.9145	.6401	.6859	.9431	.5144	1.0974
6	.7716	.9145	.6401	.9431	1.0288	1.0288	1.0974
7	.9431	.9145	1.0974		1.0802	.9431	1.1888
8	.8573	.823	1.0974		1.1145	.8573	1.0974
9	.6859	.6401	.9145		.8573	.8573	.9145
10	.6001	.5487	.5487				.695
11	.567	.3292	.3429	.2572			.3658
12		.1829	.3429	.2572	.3429		.3429
13			.2572	.3086	.3429	.2743	.3429
14	.3658		.2572	.2743	.3429	.2743	.2572
15	.3658	.3658	.3429	.3086	.2572	.2743	.2572
16	.4572	.4572	.4287	.3772	.3429	.2743	.3429
17	.5487	.4572	.5144	.5658	.5144	.3658	.3429
18	.8779	.7316	.6001	.5658	.6001	.7316	.5144
19	.9145	.9145	.6859	.6344	.6859	.9145	.6859
20	.5487	.6584	.6859	.583	.6001	.6036	.7716
21	.5487	.5487	.6001	.463	.5144	.5487	.7716
22		.5487	.5144	.0429	1.0288	.4572	.6859
23		.3658	.5144	.4287		.3658	.5144
24	.3429		.3658	.3429	.3258	.3429	.3658
Max	.9431	.9145	1.0974	.9431	1.1145	1.0288	1.1888
Min	.3429	.1829	.2572	.0429	.0857	.2743	.2572
Avg	.5683	.6306	.5584	.4291	.6154	.5279	.6034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 206 / RAMNAGAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3658	.4572	.4287	.5144	.4287	.5487
2	.3429	.3658	.4572	.4287	.5144	.4287	.5487
3	.3429	.6401	.5487	.4287	.6001	.4287	.6401
4	.5144	.6401	.5487	.5144	.8573	.4287	.9145
5	.6859	.7973	.7316	.6859	1.0288	.7716	.9145
6	1.0288	.9145	.7316	.9431	.4801	.8573	.9145
7	1.0288	.9145	1.0974	1.0288	1.0802	.8573	1.0059
8	.8573	.823	1.0974		1.0631	.8573	.9145
9	.6859	.9145	.9145		.7888	.9431	.7316
10	.7716	.7316	.6401		.6344		.6401
11	.6401	.5853	.4024	.5144	.5144		.6036
12	.4938	.4572	.3429		.5144		.5144
13	.5121		.3429		.4287	.4572	.4287
14	.5487		.3429		.4287	.4572	.4287
15	.6401	.4572	.4287	.4973	.4287	.4572	.4287
16	.6401	.5487	.5144	.583	.5144	.5487	.5144
17	.8048	.7316	.6859		.6859	.7316	.6859
18	.9145	1.0059	.9431	.6687	.9431	1.0608	.8573
19	1.0425	1.0059	1.0288	1.1831	1.1145	1.134	1.0288
20	.9145	.8779	.8573	.703	.8573	.8596	.9431
21	.6401	.7133	.8573	.5316	.6859	.7316	.8573
22		.7316	.6859	.5144	.5144	.5487	.6859
23		.6401	.5144	.4287	.4287	.5487	.6001
24	.3429	.3658	.6401	.4287	.4115	.4287	.5487
Max	1.0425	1.0059	1.0974	1.1831	1.1145	1.134	1.0288
Min	.3429	.3658	.3429	.4287	.4115	.4287	.4287
Avg	.6698	.6922	.6588	.6183	.6680	.6650	.7041

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 207 / Bajiumrad

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861						
2	1.0288						
3	1.0288						
5	1.2003						
6	1.5432						
7	1.8861						
8	2.2291						
10		1.5947	1.4632		.1783	1.3717	1.3169
11		2.6886	2.2291		2.4006		1.9204
12		2.7435	2.7435		2.7435		2.0576
13		3.2922	2.7435		2.8292	2.5606	2.2291
14		2.7435	2.7435	2.7092	2.7435	2.1948	2.2291
15		2.5606	2.572		2.4006	2.1948	2.0576
16		2.3777	2.4006	2.7092	2.2291	2.1948	2.0576
17		2.3777	2.4006	2.7092	2.1434	1.829	2.0576
24	1.0288						
Max	2.2291	3.2922	2.7435	2.7092	2.8292	2.5606	2.2291
Min	1.0288	1.5947	1.4632	2.7092	.1783	1.3717	1.3169
Avg	1.4789	2.5473	2.412	2.7092	2.2085	2.0576	1.9907

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 202 / KAJALA

Feeder KV- 11 / INCOMING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7116	.8665	.772	.8185	.7857	1.6469	.8169
2	1.6674	.8276	.8246	.8093	.82	1.6674	.836
3	1.7017	.833	.8055	.7552	.7842	1.6804	.7933
4	1.7086	.9008	.8711	.8009	.8147	1.7314	.8391
5	1.7795	.8909	.8573	.8421	.8497	1.6865	.8436
6	1.8496	.8871	.884	.8391	.8299	1.7695	.9008
7	1.7924	.8185	.833	.8459	1.0402	1.765	.8612
8	1.6956	.8299	.7956	.8246	1.8595	1.6842	.8185
9	1.7337	.8566	.7537	.8131	1.7612	1.8237	.807
10	1.6933	.833	.8238	.8269	1.7299	1.8016	.8139
11	1.6682	.8276	.7926	.8185	1.6903	.8368	.8474
12	1.6606	.7956	.775	.7865	1.7231	.8939	.7964
13	1.7124	.7651	.7697	.7766	1.7139	.7811	.7811
14	1.6751	.7872	.7773	.788	1.6499	.7514	.6661
15	1.7238	.8269	.7491	.7537	1.7314	.8017	.1616
16	1.7299	.7667	.7385	.7552	1.7032	.7697	.16
17	1.643	.8543	.7948	.8368	1.7886	.8581	.1783
18	1.8092	.8299	.8124	.8307	1.6773	.8855	.1959
19	1.7718	.8528	.775	.7827	1.6263	.8345	.1608
20	1.7215	.8482	.82	.8855	1.6766	.82	.1608
21	1.7238	.8474	.7842	.8512	1.5783	.868	.1608
22	1.4053	.8794	.8177	.865	1.5927	.8581	.1578
23	.8375	.836	.7689	.7918	1.6484	.8444	.1578
24	.8284	.82	.8307	.823	1.6187	.8093	.1585
Max	1.8496	.9008	.884	.8855	1.8595	1.8237	.9008
Min	.8284	.7651	.7385	.7537	.7842	.7514	.1578
Avg	1.6352	.8367	.8011	.8134	1.4456	1.2029	.5447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 204 / GOLAPANGHRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.7621	.7621	.6859	.7373	.743	.743
2	.5144	.7621	.7621	.6859	.7373	.743	.743
3	.5144	.743	.7621	.7202	.7373		.724
4	.6001	.724	.9907	.6859	.7716	.7621	.6859
5	.6859	.7621	.8573	.072	.8573	.8573	.6859
6	.7373	.8002		.703	.9431	.9526	.8573
7	.823	.7811		.7373	1.0288	1.0479	1.0288
8	.8573	.8383	1.3717			1.2574	1.2003
9	1.0117	1.1431	1.5089	1.0288	1.3889	1.5242	1.2517
10	1.0288	1.4289	1.3717	1.286	1.6385	1.5242	1.2003
11	1.448	1.3717	1.5947	1.7833	1.7528	1.5242	1.2346
12		1.2574		.3944	1.6956	1.7147	1.6804
13					1.829	1.6766	1.3717
14				1.9204	1.4289	1.5242	1.6289
15	2.0957		1.7147	1.9204	1.3717	1.4098	1.6975
16	2.0957	1.3336	1.8861	1.9376	1.4289	1.3527	1.7147
17	2.191		1.9376	1.9719		1.3336	1.7147
18			1.4575	1.2346		.9526	1.2689
19	1.3336	1.4861	1.1145	1.1145	1.105	.9526	1.0288
20	1.2193	1.1431	1.0288	.9774	1.0288	.8764	.8573
21	1.0479	1.0098	.9431	.9431	.9526	.7621	.823
22	.9526	.9526	.8573	.9431	.8573	.5716	.823
23	.7621	.8764	.823	.9088	.8192	.2667	.0789
24		.8383		.7373	.743		.7888
Max	2.191	1.4861	1.9376	1.9719	1.829	1.7147	1.7147
Min	.5144	.724	.7621	.072	.7373	.2667	.0789
Avg	1.0754	1.0007	1.2080	1.0633	1.1359	1.1059	1.0763



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 205 / mali pimpalgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3239	.2858	.2572	.2572	.2667	.2858
2	.3086	.381	.2858	.2572	.2572	.2667	.381
3	.4287	.381		.2743	.2572	.2667	.381
4	.4287	.5716	.5716	.6001	.3429	.5716	.6859
5	.8573	.7621		.0857	.4287	1.1431	.8573
6	1.0117	1.1431		1.2003	1.046	1.3336	1.0288
7	1.3375	1.4098	1.7147	1.3375	1.5089	1.6575	1.2003
8	1.3717	1.6766	1.5432			1.8099	1.3717
9	1.4403	1.2384	1.286	1.406	1.286	1.6194	1.3889
10	1.3336	1.0098	1.0288	1.0288	.7621	1.086	.8573
11	.8573	.8002	.6001	.6859	.6478	.5525	.6001
12		.4763		.3944	.381	.4763	.4287
13	.6668			.3429	.3239	.3048	.3772
14				.2572	.3048	.2858	.3429
15	.4382	.3429	.3258	.2572	.3048	.3429	.3086
16	.7049	.4763	.3429	.2743	.362	.4001	.4287
17	.8573	.7621	.6173	.5144		.5335	.6001
18			1.1145			1.0479	1.0631
19	1.0479	1.5242	1.3203	1.3546	1.467	1.0098	1.286
20	.8383	.8573	.8573	.8402	.8383	1.0288	.0857
21	.5716	.5335	.5487	.6001	.5716	.7621	.5316
22	.381	.381	.4287	.4287	.381	.381	.3429
23	.3429	.3048	.3086	.3086	.2858	.381	.3086
24		.2858		.2743	.2667		.2572
Max	1.4403	1.6766	1.7147	1.406	1.5089	1.8099	1.3889
Min	.3086	.2858	.2858	.0857	.2572	.2667	.0857
Avg	.7766	.7448	.7753	.5900	.5848	.7621	.6416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 207 / ROHANWDI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3048	.3048	.2572	.2572	.381	.381
2	.3086	.3048	.3048	.2572	.2572	.381	.381
3	.3086	.3239		.2572	.2572	.381	.4001
4	.3086	.381	.381	.3086	.3429	.4763	.3429
5	.3429	.4191	.4191	.3429	.4287	.5716	.3429
6	.4801	.4763	.4954	.4287	.5487	.6668	.3772
7	.5316	.5144	.5716	.4801	.7373	.6668	.4287
8	.5144	.5525	.5316			.6287	.4801
9	.463	.4954	.5144		.6001	.5716	
10	.5716	.4763	.4115	.4115	.4572	.4572	.2572
11	.4763	.4572	.3429	.3601	.4382	.4382	.3258
12	.381	.362		.2915	.381	.381	.3258
13	.3239			.2572	.381	.3239	.2915
14				.2572	.3429	.2858	.2572
15	.381	.3429	.2401	.2401	.362	.3239	.2743
16	.4001	.3429	.2572	.2229	.381	.381	.3086
17	.4954		.2572	.3258		.4572	.3429
18			.4287	.5144		.5335	.4458
19	.4954	.5335	.463	.6001		.5716	.5316
20	.4572	.5335	.3944	.5487	.5716	.6478	.5144
21	.4191	.4382	.3429	.5144	.4763	.5716	.3429
22	.4191	.381	.3086	.4287	.4191	.4763	.3258
23	.381	.3429		.3772	.381	.381	.3429
24		.3239	.3048	.3944	.381		.3601
Max	.5716	.5525	.5716	.6001	.7373	.6668	.5316
Min	.3086	.3048	.2401	.2229	.2572	.2858	.2572
Avg	.4175	.4153	.3828	.3671	.4201	.4763	.3644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 207 / Daregaon feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3451	1.121	1.1927	1.3405	1.278
2		1.3817	1.1591	1.3039	1.3428	1.3253
3		1.4129	1.1538	1.371	1.3794	1.3192
4		1.3862	1.15	1.403	1.4342	1.3352
5		1.4137	1.0212	1.4472	1.4304	1.3527
6		1.5181	1.1568	1.5516	1.5143	1.4426
7		1.9486	1.6682	2.0736	1.8633	1.864
8		2.617	2.4455	2.8578	2.806	2.5774
9		2.7503	2.5835	2.902	2.95	2.6917
10		2.4265	2.2222	2.5911	2.3106	2.4287
24	1.0151	.9633		.8695	.9381	
Max	1.0151	2.7503	2.5835	2.902	2.95	2.6917
Min	1.0151	.9633	1.0212	.8695	.9381	1.278
Avg	1.0151	1.7421	1.5681	1.7785	1.7554	1.7615

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 202 / HIVRAROSHANGAON-AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5487	.5487	.5487	.5601	.5601
2		.5487	.5487	.5487	.5601	.5601
3		.5487	.5487	.5487	.5601	.5601
4		.5487	.7316	.7316	.6535	
5		.5853	.7316	.9145	.7468	.7095
6		.5853	.823	1.0974	1.1203	.9335
7		.7316	.9145	1.1888	1.4003	.9335
8		1.0974		1.3717		1.4937
9		1.0974		1.4266		
10	.8573					
11	.8573					
13	1.3717					
14	1.3717					
15	1.3717					
16	1.3717					
17	1.3717					
24		.5487	.5487	.5487	.5601	.5601
Max	1.3717	1.0974	.9145	1.4266	1.4003	1.4937
Min	.8573	.5487	.5487	.5487	.5601	.5601
Avg	1.2247	.6841	.6744	.8925	.7702	.7888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 203 / HIWRA ROSHANGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.6348	.6219	.4572		.5601	
2	.7468	.6348	.6219	.4572		.5601	
3	.8402	.6348	.6219	.4572		.5601	
4	.8402	.8215	.7316	.5487		.6535	
5	.9335	.8215	.7316	.6401		.6535	
6	.9335	.8402	.823	.7316		.724	
7	.9335	.8402	.823			.7468	
8	.8402	.8402	.9145			.7468	
9	.8402	.905	.9145				
10	.8059	.9335	.7316				
11	.8059	.9335	.5487				
12		.8402	.5487		.8402		.3429
13	.823				.8402		.2572
14	.823				.8402		.2572
15	.7716	.7316			.9335		.5144
16	.7716	.823			.9335		.5144
17	.7716	.9145	.9145		1.0269		.6859
18	1.0288	1.0059	1.1888		.9335		.8573
19	1.0288	1.0974	1.1888				6.9102
20	.6516	.9145	.823		.9335		.6344
21	.6516	.823	.695		.8402		.6001
22	.583	.7316	.6401		.7468		.6001
23	.583	.6219	.4207		.5601		.6001
24	.7468	.6348	.6219	.4572			
Max	1.0288	1.0974	1.1888	.7316	1.0269	.7468	6.9102
Min	.583	.6219	.4207	.4572	.5601	.5601	.2572
Avg	.8044	.8172	.7563	.5356	.8571	.6506	1.0645

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 204 / BAPKAL AG FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867					
2	.1867					
3	.1867					
4	.1867					
5	.2801					
6	.2801					
7	.3734					
8	.4668					
9	.7095					
10			.3658	.3734	.3734	.6001
11		.4668	5.5418	.4668	.4668	.6001
12		.4668	.5487	.4668	.4668	.5144
13		.5601	.5487	.3734	.5601	.5144
14		.5601	.6401	.3734	.5601	.5144
15		.4668	.5487	.3734		.5144
16		.4668	.5487		.6535	.5144
17		.3658	.5487		.4668	.5144
24	.1867	.3734			.5601	
Max	.7095	.5601	5.5418	.4668	.6535	.6001
Min	.1867	.3658	.3658	.3734	.3734	.5144
Avg	.3043	.4658	1.1614	.4045	.5135	.5358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 205 / PIMPRI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1372	.1829	.1829		.1867	.1715
2	.1867	.1372	.1829	.1829		.1867	.2058
3	.7842	.1372	.1829	.1829		.1867	.2987
4	.2614	.2058	.2195	.2749		.2614	.3361
5	.3361	.3086	.2561	.3658		.2987	.3921
6	.4668	.3086	.3658	.5487		.3734	
7	.5601	.4115	.5487	.6584		.4668	
8	.5041	.4115	.4938	.5487		.3734	
9	.4481	.3601	.4572	.439		.3734	
10	.3086	.2614	.2743		.2614	.2427	.2915
11	.3086	.1867	.1829		.1867	.1867	.12
12		.1867	.1646		.112	.0934	.12
13	.1372		.1463		.112	.0934	.12
14	.1372		.1463		.112	.0934	.1029
15	.1372	.112	.1463		.112	.0934	.1029
16	.1372	.1494	.1463		.112	.1494	.1029
17		.2241	.2743		.1867	.2241	.1886
18	.4115	.2987	.3658			.2801	.2572
19		.3734	.3658		.3361	.3361	.3601
20	.2058	.4294			.2987	.3921	.3601
21	.2058	.3361	.2561		.2614	.2987	.1715
22	.1372	.2614	.2195		.2241	.2614	.1372
23	.1372	.1867	.1829		.1867	.1867	.1372
24	.1372	.1372	.1829	.1829	.3361	.1867	.1867
Max	.7842	.4294	.5487	.6584	.3361	.4668	.3921
Min	.1372	.112	.1463	.1829	.112	.0934	.1029
Avg	.2921	.2528	.2584	.3567	.2027	.2427	.2082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 206 / SOLGAVAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3361	.1829	.1829	.1867	.1494
2		.3361	.1829	.1829	.1867	.1494
3		.1867	1.8839	.1829	.1867	.1494
4		.1867	.1829	.1829	.1867	.1867
5		.2801	.1829	.1831	.2801	.1867
6		.2801	.1829	.2743	.2801	.1867
7		.2801	.2743	.3658	.2801	.2801
8		.2801		.3658	.2801	.2801
9		.2801	.1829	.3658	.1867	.3734
10	.1715					
11	.1715					
15	.2572					
16	.2572					
17	.2572					
24		.1867	.1829	.1829	.1867	
Max	.2572	.3361	1.8839	.3658	.2801	.3734
Min	.1715	.1867	.1829	.1829	.1867	.1494
Avg	.2229	.2633	.3821	.2469	.2241	.2158



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 201 / HISWAN-AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.0486	.0486		.0486	.081	.0486
2	.0486	.0486	1.4575		.081	.081	.0486
3	.0486	.0486	.0486	.081	.081	.081	.0486
8		.4858	.487		.4858		.4858
9		.6478	.8097		.6478	.5668	.6478
10		.7287	.8097	.6478	.6478	.6478	.6478
11			.7287	.8097	.6478	.7287	
12			.7811	.8097	.8097		
13		.9717	.8097	.8097	.8907	.9717	
14		.9717	.8907	.8097	.8097	.9717	
15		.8097		.6478	.6478	.8097	
16	1.2955						
17	1.3765						
18	.9717						
19	.5668	.0486		.0486	.0486	.081	
20	.5668	.0486	.081	.0648	.081	.081	
21	.4858	.0486		.081	.081		
22	.4858	.0486	.081	.081	.081	.081	
23	.4858	.0486	.081	.081	.081	.081	
24	.4858	.9717	.0486	.081	.081	.081	.6478
Max	1.3765	.9717	1.4575	.8097	.8907	.9717	.6478
Min	.0486	.0486	.0486	.0486	.0486	.081	.0486
Avg	.5722	.3984	.5116	.3887	.3677	.3817	.3679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 202 / TANDULWADI AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296	.6478	.9717		.8097	.8097	.8097
2	.1296	.6478	1.1336		.9717	.8907	.8097
3	.1296	.7287	1.1336	.8097	1.2955	.8907	1.2955
4		.7287	1.2955		1.2955	.8907	1.2955
5		.7287	1.2955		1.4575	.9717	1.4575
6		.7287	1.4575		1.4575	.9717	1.4575
7		.8907	1.4575		1.4575	1.1336	1.4575
8	1.2955						
9	1.7814						
10	.9717						
11	1.5384						
12	1.5384						
13	1.7814						
14	1.7814						
15	1.7004						
19	.1619			.1619	.2429	.2429	.1619
20	.1619	.1619	.1619	.3239	.2429	.2429	
21	.2429	.081		.3239	.2429	.2458	
22	.2429	.081	.081	.3239	.2429	.2429	1.6194
23	.1619	.081	.1619	.3239	.2429	.8097	.2429
24	.2429	.6478	.5668	.6478	.8097	.7287	.8097
Max	1.7814	.8907	1.4575	.8097	1.4575	1.1336	1.6194
Min	.1296	.081	.081	.1619	.2429	.2429	.1619
Avg	.8230	.5128	.8833	.4164	.8284	.6978	1.0379

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 203 / PUNEGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.2429	.2429		.1619	.1619	.081
2	1.1336	.2429	.2429		.1619	.1619	.081
3	1.2955	.2429	.2429		.1619	.1619	.081
4	1.2955						
5	1.2955						
6	1.2955						
7	1.2955						
16		2.1052	1.7814	.8097	2.0243		
17		2.1052	1.8623	1.9433		2.1052	
18		1.6194	1.9433			1.7814	
19	.3239			1.7814	1.2146	1.2955	1.9433
20	.3239		1.9433	1.2955	1.2955	.9717	
21	.3239			1.2955	1.2955	.9831	
22	.3239	1.1336	1.4575	1.1336	1.2146	.8097	
23	.3239	1.1336	1.5384	.9717	.8907	.8097	1.2955
24	.8097	.2429	.1619	.1619	.1619	.1619	.1619
Max	1.2955	2.1052	1.9433	1.9433	2.0243	2.1052	1.9433
Min	.3239	.2429	.1619	.1619	.1619	.1619	.081
Avg	.8471	1.0076	1.1417	1.1741	.8583	.8549	.6073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 205 / PUNEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.4858	.4858		.6478		.4858
2	.6478	.4858	.4858		.6478		.4858
3	.8097	.5668	.6478	.4858	.6478	.5668	.5668
4	.8097	.5668	.6478				
5	.8097		.6478				
6			.6478				
7			.6478				
8			.9717				
9			.9717				
10		.6478	.6478	.4858		.6478	
11			.5668	.4858	.4858	.6478	
12			.4858	.3239	.4049		
13			.4858	.3239	.4049		
14			.5668	.3239	.3239	.3239	
15				.3239	.3239	.0191	
16	.4858						
17	.5668						
18	.7287						
19	.6478	.9717		.7287	.6478	.9717	.4858
20	.5668	.8097		.7287	.7287	.9717	
21	.5668	.8097		.6478	.4858	.8097	
22	.4858	.5668	.5668	.4858	.4858	.4858	.4858
23	.4858	.4858	.4858	.8097	.4858	.4858	.5668
24	.5668	.5668	.4049	.5668	.4049	.4049	.4858
Max	.8097	.9717	.9717	.8097	.7287	.9717	.5668
Min	.4858	.4858	.4049	.3239	.3239	.0191	.4858
Avg	.6188	.6330	.6097	.5170	.5090	.5759	.5089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 206 / GADE SAWARGAON

Feeder KV- 11 / INCOMING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.081	.081		.081	.081	.081
2	.081	.081	.081		.081	.081	.081
3	.081	.081	.081	.081	.081	.081	.081
9							.2429
10	.2429	.1619	.1619	.1619	.2429	.2429	
11	.3239		.2429	.3239	.2429	.2429	
12	.3239		.3239	.3239	.3239	.3239	
13	.4049	.3239	.3239	.3239	.2429	.3239	
14	.4049	.3277	.4049	.3239	.3239	.2429	
15	.4049	.4049		.3239	.3239	.2429	
16	.3239	.4049			.2429		
17	.3239	.4049		.3239		.2429	
18	.0648	.081				.2429	
19	.0648	1.4575		.0648	.0486	.0324	.0324
20	.0648	1.2955	.081	.081	.081	.081	
21	.081	1.1336		.081	.081	.081	
22	.081	.081	.0324	.081	.081		.0324
23	.081	.081	.081	.081	.081	.081	.0324
24	.081	.081		.081	.081	.081	.081
Max	.4049	1.4575	.4049	.3239	.3239	.3239	.2429
Min	.0648	.081	.0324	.0648	.0486	.0324	.0324
Avg	.1953	.4051	.1723	.1897	.1650	.1690	.0830

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 201 / DHALDI - AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.7545	.1677	.6706	.8573	.8192	.6706
2	.6516	.7545	1.3413	.6706	.9431	.8478	.6783
3	.5144	.8383	1.3413		.9431	.8802	.8383
4	.5144	1.3413	1.6766	.9221	1.0288	1.0526	1.1736
5	.5144	1.3413	1.6766	1.1736	1.1145	1.1736	1.1736
6		1.5089	1.8442	1.4251	1.3717	1.4746	1.5089
7		1.8442	2.3472		2.1434	2.2891	1.6766
8		2.1795	2.3472	2.5149	2.431	2.7035	2.3472
9				2.5149	2.3472	2.5987	2.5149
12	.6706						
13	1.4251						
14	1.3413						
15	1.3413						
16	2.3472						
17	2.0119						
19	.6706	.6706	.503	.9526	.6173	.503	.9526
20	.5868	.6706	.503	.7621	.6173	.503	.6668
21	.503	.5868	.503		.6478	.503	.6668
22	.503	.503	.503	.6668	.6325	.4191	.6706
23	.8383	.6706	.5868	.5144	.6783	.6706	.8383
24	.5144	2.1795	.6706		.6859	.6944	.1677
Max	2.3472	2.1795	2.3472	2.5149	2.431	2.7035	2.5149
Min	.503	.503	.1677	.5144	.6173	.4191	.1677
Avg	.9096	1.1317	1.1437	1.1625	1.1373	1.1422	1.1030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 202 / WANJAR UMRAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.2515	.1677	.1677	.2286	.1696	
2	.4191	.2515	.1677	.1677	.2858	.1581	.1677
3	.503	.2515	.1677	.1677	.2858	.1619	
4	.503				.2858	.2486	.1677
5	.503				.2858	.2458	
6	.6706						
7	1.1736						
8	2.0119						
10		.9945	.9488	.9221	.7545	.8383	.8383
11		1.6575	1.2631	1.4251	1.1574	1.1736	1.1736
12		1.5604		1.5089	1.4842	1.2574	1.5927
13		1.6385	1.3279	1.4251	1.5089	1.5089	1.2289
14		1.6956	1.6204		1.2793	1.3413	
15		1.4251	1.4918	1.3413	1.1279	1.3413	1.1736
16		1.2574	1.326	1.2574	1.0574	1.3413	1.3413
17		1.2574	1.0402	1.2574	.9031	1.4251	1.1736
19	.2515	.1677	.2515	.2286	.3125	.1677	.2858
20	.2515	.2515	.2515	.2858	.2458	.1677	.2858
21	.2515	.2515	.2515	.2858	.2458	.1677	.2858
22	.2515	.1677	.2515	.2858	.2401	.1677	.2858
23	.2515	.1677	.1677	.2858	.1581	.1677	.2858
24	.4191	.1677		1.3413	.2286	.1658	.1677
Max	2.0119	1.6956	1.6204	1.5089	1.5089	1.5089	1.5927
Min	.2515	.1677	.1677	.1677	.1581	.1581	.1677
Avg	.5629	.7891	.713	.7721	.6355	.6429	.6969

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 203 / WAGHRUL (J)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.1677	.1677	.1562	.2858	.16	.1677
2	.503	.2515	.1677	.1677	.2858	.1429	.1677
3	.503	.2515	.1677	.1677	.2858	.1658	.1677
4	.503				.2858	.1734	.1848
5	.6706				.2858	.1696	
6	.8383						
7	1.6766						
8	2.0119						
10		1.3441	1.3413	1.0898	1.0059	1.0059	1.2574
11		1.5813	1.9766	1.8442	1.5051	1.5089	1.4251
12		1.6204		2.1795	1.6385	1.5927	
13		1.9281	1.8061	2.0957	1.7004	1.5089	1.5565
14		1.4746	1.808	1.8442	1.2346	1.1736	1.448
15		1.6766	1.7861	1.6766	1.4232	1.1736	1.3413
16		1.3413	1.6404	1.6766	1.4746	1.1736	1.4251
17		1.5089	1.4299	1.5089	1.4403	1.1736	1.3413
19	.2515	.1677	.2515	.2858	.2515	.1677	.2286
20	.2515	.2515		.2858	.2315	.1677	.2858
21	.2515	.2515	.2515	.2858	.2486	.1677	.2858
22	.2515	.1677	.1677	.2858	.2315	.1677	.2858
23	.1677	.1677	.1677	.2286	.16	.1677	.2858
24	.4191	.1677	.1848	.1677	.2858	.1696	1.3565
Max	2.0119	1.9281	1.9766	2.1795	1.7004	1.5927	1.5565
Min	.1677	.1677	.1677	.1562	.16	.1429	.1677
Avg	.6287	.8423	.8876	.9380	.7506	.6385	.7771



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 204 / WAGHUL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.1848	.1848	.1848	.1658	.1848
2	.1848	.1677	.1848	.1848	.1848	.1842	.1848
3	.1715	.1677	.1848	.1848	.1848	.2649	.1848
4	.1848	.2772	.2772	.1848	.2772	.3708	.1848
5	.3696	.2772	.2772	.2772	.3696	.4487	.2772
6							.2515
8			.1848		.1524		
9		.1848		.1848	.1848	.0921	.1848
10		.1856	.2766	.1848	.2772	.1848	.3696
11		.176	.1844	.2772	.1793	.1848	.2772
15	.1848	.0924	.093	.0924	.0915	.1848	.0924
16	.2772	.1848	.1779	.1848	.1854		.0924
17	.2772	.1848	.1856	.1848	.1852	.1848	.1848
18	.3696	.0924	.2772	.1848	.2746		.3696
19	.3353	.1848	.3696	.462	.3719	.2772	.3696
20	.2772	.2772	.2772	.381	.2401	.2772	.3696
21	.2772	.2772	.1848	.2858	.2592	.1848	.2772
22	.1848	.1848		.1905	.2781	.1848	.1848
23	.1848	.1848	.1848	.1848	.1854	.1848	.1848
24	.1848	.1848		.1848	.1848	.1848	.1848
Max	.3696	.2772	.3696	.462	.3719	.4487	.3696
Min	.1715	.0924	.093	.0924	.0915	.0921	.0924
Avg	.2432	.1927	.2190	.2222	.2237	.2225	.2321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 205 / WANJAR UMRAD GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.0914	.0914	.0914	.0939	.0914
2	.0914	.0914	.0914		.0914	.0928	.0914
3	.0924	.0838	.0914	.0914	.0914	.0929	.0914
4	.0914	.1829	.1829	.0914		.1816	.0838
5	.2743	.1829	.1829	.0914	.1829	.3456	.1829
8			.0914				
9		.0914		.0914	.0914	.0941	.0914
10		.0897	.0929	.0914	.1829	.0914	.1829
11			.0897	.0914	.0921	.0914	.0914
15	.0924	.0914	.0938	.0914	.0932	.0914	
16	.0914	.0914	.0928	.0914	.0903	.0914	.0914
17			.0935	.0914	.18	.0914	.0914
18	.1829	.0914	.1829	.0914	.1856	.1829	.0914
19	.1829	.1829	.1848	.1829	.2778	1.6095	.2858
20	.0914	.1829	.1829	.1905	.2706	.1829	.1829
21	.0838	.1829	.0914	.1905	.2735	.1829	.0914
22	.0914	.0914	.0838	.0953	.16	.0914	.0914
23	.0914	.0914	.0914	.0914	.1856	.0886	.0953
24	.1829	.0914	.0928	.0914	.0914	.0941	.0914
Max	.2743	.1829	.1848	.1905	.2778	1.6095	.2858
Min	.0838	.0838	.0838	.0914	.0903	.0886	.0838
Avg	.1237	.1194	.1169	.1087	.1548	.2106	.1188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 201 / KADVANCHI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	1.0402	1.4175		.5544	.5601	
2	1.0402	1.0402	1.7909		.5601	.5544	
3	1.0402	1.0402	2.1033		.5601	.5544	
4	1.0402	1.2136	2.1033		.5601	.6468	
5	1.2136	1.387	2.2786		.7468	.7468	
6	1.2136	1.7147	2.2786		.9335	.8316	
7	1.7337	2.572	2.4272		.9145	.924	
8			2.4272		1.0974		
9					2.3034		
10				.4452	2.4806		
11				2.572	2.3282		
12					2.3529		
13				2.4863	2.1719		
14				2.4006	2.1719		
15				2.2539			
16							1.2136
17							2.8607
18		.3658					3.1207
19	.3467	.5487					1.0402
20	.3467	.5601			.8316		.8669
21	.5201	.5544		.9145	.7316		1.7337
22	.5201	.5544		.823	.7392		1.7337
23	.5201	.5544		.7392	.5544		1.5604
24	1.2136	1.2269		.248	.6468	.5544	.4253
Max	1.7337	2.572	2.4272	2.572	2.4806	.924	3.1207
Min	.3467	.3658	1.4175	.248	.5544	.5544	.4253
Avg	.9068	1.0266	2.1033	1.4314	1.2231	.6716	1.6172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 202 / NAVHA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3506	1.448			1.7909	
2	.3506	.3506	1.7909			1.829	
3	.3506	.3506	1.7718			1.829	
4	.3506		1.9281			1.97	
5	.3506	.3506				2.1491	
6	.3506	.3506				2.3529	
7	.7011	.3506				2.5339	
8	1.4022	1.4022					
9	3.155	2.6292	2.8349				
10	3.4179	3.155	2.3282				
11	3.3303						
12	3.155						
13	3.155						
14	3.155						
15	3.155						
16				1.0745			
17				3.6008			
18		.3696			2.915		.7011
19	.3506	.5544			2.6578		.7011
20	.3506	.6401			2.4806		.7011
21	.3506				2.1491		.7011
22	.3467	.6468			1.97		.7011
23	.3506	.5544			1.7909		.7011
24	.3467	.3506	.543	.3996		1.7909	
Max	3.4179	3.155	2.8349	3.6008	2.915	2.5339	.7011
Min	.3467	.3506	.543	.3996	1.7909	1.7909	.7011
Avg	1.3727	.8271	1.8064	1.6916	2.3272	2.0307	.7011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 203 / BORKHEDI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0802	1.0802	1.4632		.6468	.7392	
2	1.0802	1.0802	1.448		.6401	.7316	
3	1.0802	1.2346	1.8099		.6535	.7468	
4	1.0802	1.3889	1.7909		.6535	.8316	
5	1.0802	1.5242	2.0576		.7468	1.0164	
6	1.2346	1.829	2.1033		1.1088	1.1088	
7	1.6766	2.4387	2.4539		1.0974	1.1203	
8			2.4806		1.0974		
9					2.6578		
10				.463	2.6578		
11				2.7435	2.5339		
12				2.915	2.7149		
13				2.915	2.6578		
14				2.572	2.5692		
15				2.4272			
16		.3658					1.2346
17							2.2862
18		.3658					2.4387
19	.3086	.5487			1.1088		1.6975
20	.3086	.6468			1.1088		1.5432
21	.3125	.6401		.9145	1.0974		1.3889
22	.3086	.5544		.924	.924		1.3889
23	.3125	.5544		.924	.924		1.3889
24	.9259	.9259	.9335	2.915	.7392	.7392	1.3117
Max	1.6766	2.4387	2.4806	2.915	2.7149	1.1203	2.4387
Min	.3086	.3658	.9335	.463	.6401	.7316	1.2346
Avg	.8299	1.0118	1.8379	1.9713	1.4169	.8792	1.6310

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 201 / BAWNEPANGRI-AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848		.1829				
2			.1829				
3	.1848		.1829				
4			.2743				
5	.2772		.2743				
7	.4572						
8	1.0059						
10		1.2803	.9145	.9145			
11		1.2803	1.2795	1.0974	1.2254		
12		1.2803	1.5655	1.4632	1.3717		1.2254
13		1.1888	1.5775	1.4632	1.3352		1.4937
14		1.0974	1.4899	1.2803	1.1888		1.386
15		1.1888	1.1022	1.2803	1.1888		1.2567
16		.9145	1.3146	1.2803	1.5364		1.3491
17		.7316	1.1145	1.3717	1.2437		1.0974
19		.2743	.2743	.2743		.1848	.1867
20	.1848	.2743	.2743	.2743			.1867
21	.1829	.1829	.1829	.1829			.1867
22			.1829	.1829			.1867
23							.1867
24							.1867
Max	1.0059	1.2803	1.5775	1.4632	1.5364	.1848	1.4937
Min	.1829	.1829	.1829	.1829	1.1888	.1848	.1867
Avg	.3539	.8812	.7276	.9221	1.2986	.1848	.7440

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 202 / MANDEULGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7316			
2			.7316			
3	.1848		.7316			
4			1.0974			
5			1.0974			
6			1.4632			
7			1.829			
8			2.3777			
9			2.1948			
10	1.0059					
12	1.829					
14	2.1948					
16	1.829		.4024			
19		.2743	.3658	.3658	.1848	.1867
20	.1848	.1829	.3658	.3658		.1867
21		.1829	.2743	.2743		.1905
22			.1829	.2743		.1886
23						.1867
24						.3734
Max	2.1948	.2743	2.3777	.3658	.1848	.3734
Min	.1848	.1829	.1829	.2743	.1848	.1867
Avg	1.2047	.2134	.9890	.3201	.1848	.2188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 203 / MANDEULGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462		.2743				
2			.2743				
3	.4572		.2743				
4			.3658				
5	.462		.5487				
6			.5487				
7	.5487		.7316				
8	.823		.7316				
9			.6401				
10	.6401	.5487	.5658	.6401			
11		.3658	.3109	.5487	.462		
12	.6401	.3658		.4572	.3696		.462
13		.3658		.3658	.2772		.2241
14		.2743		.3658	.2218		.2427
15		.2743	.3018	.3658	.2218		.3174
16	.5487	.3658		.3658	.1848		.3658
17		.5487	.4938	.3658			.4668
18	.6401	.5487	.6401	.6401			.6535
19		.3658	.7316			.8779	.924
20	.6401	.4572	.7316	.7316			.6099
21		.5487	.5487	.6401			.4668
22			.4572	.5487			.3734
23							.2801
24							.2801
Max	.823	.5487	.7316	.7316	.462	.8779	.924
Min	.4572	.2743	.2743	.3658	.1848	.8779	.2241
Avg	.5862	.4191	.5095	.5030	.2895	.8779	.4359



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 204 / BAWANE PANGHARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848		.1829				
2			.1829				
3	.1848		.1829				
4			.1829				
5	.1848		.2743				
6			.3658				
7	.1848		.4572				
8	.3696		.2743				
9			.1829				
10	.1848	.1829	.1886	.2743			
11		.1829	.1886	.1829	.1791		
12	.1848	.1829		.1829	1.3717		.1848
13		.1829		.1829	.1294		.0934
14		.1829		.1829			.0934
15		.1829	.1886	.1829			.1307
16	.1848	.1829	.1886	.1829	.1478		.0934
17		.1829		.1829	.1848		.0943
18	.1848	.1829	.2743	.2743			.1829
19		.2743	.3658	.3658		.5175	.2801
20	.3696	.3658	.4572	.5487			.3734
21	.3696	.3658	.4572	.4572			.2801
22			.1829	.2743			.1886
23							.1886
24			.1829				.1867
Max	.3696	.3658	.4572	.5487	1.3717	.5175	.3734
Min	.1848	.1829	.1829	.1829	.1294	.5175	.0934
Avg	.2352	.221	.2611	.2673	.4026	.5175	.1823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 202 / ASARKHEDA - AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0892	.0251	.032	.0427	.0053
2			.0892	.0671	.0808	.0137	.013
3		.0008	.0922	.0472	.0754	.016	.0716
4		.0008	.0907		.0815	.0107	.0884
5		.003	.0953	.0465	.0793	.0678	.0838
6		.0907	.1029	.109	.1082	.0922	.112
7		.112	.1364	.1905	.1478	.1425	.1532
8		.2896	.3117	.5556	.3208	.3528	.3635
9		.3574	.3429	.551	.3871	.5068	.474
10	.0869	.2644		.4374	.3391	.4214	.3521
11	.2477						
12	.234						
13	.1837						
14	.1684						
15	.1341						
16	.1532						
17	.2096						
18	.1402						
24		.0846	.0061	.0038	.0351	.0152	
Max	.2477	.3574	.3429	.5556	.3871	.5068	.474
Min	.0869	.0008	.0061	.0038	.032	.0107	.0053
Avg	.1731	.1337	.1357	.2033	.1534	.1529	.1717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134059 / DAMBRI

Feeder No / Name : 201 / VIREGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.6706	1.0059	.7545	1.0059	1.0059	1.1736
2	.5868	.6706	1.0059	.6706	1.0059	1.0059	1.1736
3	.5868	.6706	1.0059	.6706	1.0059	1.0898	1.1736
4	.0671						
5	.7545						
6	.9221						
7	1.0898						
8	1.1736						
10	1.5089						
11	1.0059						
12		.2515	.2515	.3353	.3353	1.0059	.2012
13		.2515	.2515	.3353	.3353	1.0059	.2012
14		.2515	.2515	.3018	.3353	.3353	.2012
15		.2683	.2515	.2515	.3353	.3353	.2515
16		.3018	.2515	.2515	.2515	.218	.2515
17		.4191	.2515	.3018	.2515	.2515	.2515
18	.9221	.8383	.9221	1.0898	.8383	.9221	.7545
19	.9221	.9221	1.0059	1.0059	.0838	1.0059	.9221
20	.6706	.8383	.9221	1.0059	1.0059	.9221	.9221
21	.6706	1.0059	.9221	1.0059	1.0898	1.0898	.9221
22	.6706	1.1736	.8383	1.0059	1.0898	1.0059	.8383
23	.5868	1.1736	.8383	1.0059	1.0059	.9221	.8383
24	.5868	.5868	1.0898	.7545	1.0059	1.0059	.8383
Max	1.5089	1.1736	1.0898	1.0898	1.0898	1.0898	1.1736
Min	.0671	.2515	.2515	.2515	.0838	.218	.2012
Avg	.7831	.6434	.6916	.6717	.6863	.8205	.6822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134059 / DAMBRI

Feeder No / Name : 202 / PIMPALGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868		.6706	.503	.5868	.4191	.4191
2	.5868		.6706	.4191	.5868	.4191	.4191
3	.5868		.6706	.4191	.5868	.4191	.4191
4			.8383	.5868	.9221	1.0059	.8383
5			1.2574	.8383	1.2574	1.0059	1.0059
6			1.4251	1.0898	1.4251	1.1736	1.0059
7			1.5089	1.5927	1.5089	1.3413	1.8442
8			2.1795	1.9281	2.0957	1.8442	1.9281
9			2.2634	1.0059	2.1795	1.8442	1.8442
10		.1677	2.0957		2.0957	1.6933	1.7604
11			1.5089	1.2574	2.0119	1.2407	1.6766
12	.503					.5868	
13	1.7604						
14	1.6766						
15	1.6766						
16	1.5927						
17	1.3413						
18	1.3413	1.0898	.9221	.9221	.6706	.7545	.8383
19		1.0898	.8383	.8383	.8383	.8383	.9221
20		1.0059	.8383	.7545	.7545	.6706	.6706
21		1.0059	.5868	.6706	.5868	.6706	.5868
22		.8383	.5868	.6706	.5868	.0503	.5868
23		.7545	.503	.6706	.503	.503	.503
24	.5868		.6706	.4191	.5868	.0419	.4191
Max	1.7604	1.0898	2.2634	1.9281	2.1795	1.8442	1.9281
Min	.503	.1677	.503	.4191	.503	.0419	.4191
Avg	1.1126	.8503	1.1131	.858	1.0991	.8696	.9826

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134059 / DAMBRI

Feeder No / Name : 203 / DAMBRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.1677	.2515	.1677	.1677	.1677	.1844
2	.3353	.2515	.2515	.1677	.1677	.1677	.1844
3	.3353	.2515	.2515	.1677	.2012	.1677	.1844
12		.8383		.8383	.5868	.6539	.5868
13		.8383	.7545	.8383	.5868	.7209	.7545
14		.8383	.6706	.7545	.6706	.7209	.7545
15		.9221	.7545	.7545	.6706	.6874	.6706
16		.9221	.7545	.7545	.6706	.6203	.6706
17		.7545	.7545	.6706	.6706	.5868	.6706
18	.4191	.7545	.6706	.7545	.0587	.5868	.503
19	.3353	.6706	.5868	.6706	.503	.503	.3353
20	.3353	.3353	.2515	.2515	.2515	.2515	.2515
21	.2515	.3018	.2515	.2012	.2012	.2515	.2515
22	.2515	.2515	.2515	.2012	.2012	.2515	.2515
23	.2515	.2515	.2515	.1677	.1677	.2515	.1677
24	.3353	.1677	.2515	.1677	.1677	.1677	.1677
Max	.4191	.9221	.7545	.8383	.6706	.7209	.7545
Min	.2515	.1677	.2515	.1677	.0587	.1677	.1677
Avg	.3269	.5323	.4639	.4705	.3715	.4223	.4118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 202 / PAREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.3048	.362	.381	.362	.3429	.3429
2	.1334	.3429	.362	.381	.381	.3429	.3429
3	.1524	.3429	.362	.381	.4001	.3429	.3429
4		.3429	.4001	.6668	.4572	.381	.381
5		.381	.4572	.6668	.5335	.4763	.4191
6		.4001	.5716	.724	.6097	.6668	.6668
7		.5716	1.105	.8764	.8764	.9526	1.1241
8		1.0669	1.2955	1.4289	1.4289	1.3146	1.4289
9		.9526	1.2574	1.4289	1.2574	1.2955	1.3717
10	.6097						
15	1.3527						
16	1.2574	.1334	.0953	.0762	.0953	.0762	.1143
17	.9717	.1524	.0953	.0762	.1143	.0762	.1334
18	.1905	.1905	.0953	.1524	.1334	.1334	.2096
19	.2286	.2477	.1905	.1715	.2286	.1905	.1524
20	.2096	.2096	.2286	.1715	.2096	.1905	.1524
21	.1905		.1524	.1524	.2096	.1905	.1334
22	.1524	.1715	.1524	.1334	.2096	.1905	.1715
23	.1524	.1524	.1524	.1334	.1905	.1715	.1524
24	.2858		.3239	.362		.3429	.3429
Max	1.3527	1.0669	1.2955	1.4289	1.4289	1.3146	1.4289
Min	.1143	.1334	.0953	.0762	.0953	.0762	.1143
Avg	.4287	.3727	.4255	.4647	.4528	.4265	.4435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-JAN-17 and 21-JAN-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 203 / SAWANGI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-JAN-17	16-JAN-17	17-JAN-17	18-JAN-17	19-JAN-17	20-JAN-17	21-JAN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.5906	.6478	.6668	.5906	.5716	.5716
2	.2858	.5906	.6478	.6668	.6097	.5716	.5716
3	.381	.6478	.6478	.7621	.6859	.5716	.6668
4		.6859	.7049	.7621	.7621	.5716	.724
5		.7811	.743	.8573	.9145	.724	.7621
6		.8383	.8764	1.0479	.9717	.8573	.9526
7			1.2384	1.2193	1.1622	1.1431	1.2384
8		1.2765	1.467	1.3527	1.4289	1.3336	1.448
9		1.1622	1.4098	1.3908	1.3336	1.2384	1.1812
10	1.1241						
11	.9526						
12	1.105						
13	1.1622						
14	1.2574						
15	1.3146						
16	1.3146	.2667	.2858	.2667	.3048	.2477	.1715
17	1.2574	.4191	.362	.362	.381	.362	.362
18	.3429	.7049	.6859	.6097	.6478	.5335	.6668
19	.6097	.6859	.724	.6478	.6668	.5716	.7049
20	.4572	.381	.381	.5716	.5716	.6097	.6097
21	.381		.2858	.4572	.4191	.5716	.4763
22	.3048	.2477	.2858	.3429	.3429	.4191	.2477
23	.2667	.2286	.2858	.2477	.2858	.2858	.2286
24	.5716		.6287	.5716		.5716	.5716
Max	1.3146	1.2765	1.467	1.3908	1.4289	1.3336	1.448
Min	.2286	.2286	.2858	.2477	.2858	.2477	.1715
Avg	.7398	.6338	.6838	.7113	.7105	.6531	.6753