

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324013 / 33 KV AUNDHA NAGNATH

Feeder No / Name : 206 / 11 KV GOLEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488			.6602	.8488		
2	.8488			.6602	.8488		
3	.9431			.7545	.9431		
4	1.0374			.9431	1.1317		
5	1.1317			1.226	1.3203		
6	1.226		1.3203	1.1317			
7				.9431			
8	.9431						1.1317
10		.9431		.5658			
11			.7545	.9431			
12		.7545	1.3203	.8488		.8488	
13			.7545				
14		.6602	.6602			.8488	
15			.8488	.7545			
16			.7545				
18			.9431	1.1317			
19			1.0374	1.1317			
20				1.1317			
21				1.0374		1.226	
22		1.0374		.9431			
23			.8488	.8488			
24	.8488		.8488	.6602	.8488		.9431
Max	1.226	1.0374	1.3203	1.226	1.3203	1.226	1.1317
Min	.8488	.6602	.6602	.5658	.8488	.8488	.9431
Avg	.9785	.8488	.9174	.9064	.9903	.9745	1.0374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324036 / 33 KV SHIRAD SHAHAPUR

Feeder No / Name : 201 / 11 KV PANGRA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5487	.5601	.6219	.1494		.6535
2	.5601	.5853	.5601	.5853	.1494		.6535
3	.5975	.6584	.6722	.8316	.1494		.6535
4	.7468	.6584	.7095	.8686	.1867		.7842
5	.924	.924	.6908	.8686	.2427		.9335
6		.924	.7468				
10	.4755	.2427		.7282	.7762	.8402	.7468
11	.5121	.2218		.7468	.7468	.7468	.6535
12		.1867	.5853	.7468	.6535	.7468	.6535
13		.168	.5487	.5601	.5601	.7468	.6535
14		.1494	.6584	.6535	.5228	.7468	.7095
15	.5853	.1867	.6219		.5415	.7095	.7468
16		.2801	.5853	.7762	.5228	.6535	.7468
17		.2614	.6219	.7392	.4854	.9335	.7095
18		.3734	.6584	.924		.924	.9335
19		.2801	.7392		.7468	.8501	.924
20	.7392	.2614	.7947	.2241	.6535	.7392	.8402
21	.7762		.7577	.2054	.5975	.7842	.7468
22	.6219	.168	.6219	.1867	.5601	.7468	.7095
23	.5853	.1494	.6219	.1494	.4668	.7392	.6535
24	.5601	.5487	.5415	.6219	.1494		.7095
Max	.924	.924	.7947	.924	.7762	.9335	.9335
Min	.4755	.1494	.5415	.1494	.1494	.6535	.6535
Avg	.6342	.3888	.6472	.6132	.4664	.7791	.7408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324036 / 33 KV SHIRAD SHAHAPUR

Feeder No / Name : 202 / 11 KV UMAEA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2195	.1307	.1829	.1867	.2054	.1867
2	.1867	.2195	.112	.1829	.1867	.1867	.1867
3	.1867	.2195	.1867	.4435	.1867	.2241	.1867
4	.3174	.5121	.2801	.5121	.2987	.2801	.2987
5	.4481	.5304	.5041	.5544	.4108	.3734	.4108
6		.5487	.3734			.3921	
10	.2012				.2054	.2801	.2241
11	.1829		.2987	.1867		.2241	.2054
12	.1829	.2241	.2195	.1867		.2054	.1867
13	.2561	.5601	.1829	.168		.2241	.1867
14	.1829		.1829	.1867		.1867	.1867
15	.2195	.1867	.1829	.2054		.1494	.2054
16		.2801	.1829	.2427		.2241	.1867
17		.2614	.2195	.2614		.2801	.2427
18		.3734	.2561	.3361		.3361	.3361
19		.2801	.2926	.3734		.3734	.4294
20	.2926	.2614	.2772	.3734		.3361	.3734
21	.2926	.1867	.2561	.2801		.2614	.2801
22	.2561	.168	.1829	.2241		.2054	.2427
23	.2378	.1494	.1829	.1867		.1867	.2054
24	.1867	.2378	.1494	.1829	.1867	.2241	.1867
Max	.4481	.5601	.5041	.5544	.4108	.3921	.4294
Min	.1829	.1494	.112	.168	.1867	.1494	.1867
Avg	.2386	.3011	.2327	.2774	.2374	.2552	.2474

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324064 / 33 KV SIDHESHWAR

Feeder No / Name : 201 / 11 KV DHEGAJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1888	1.448	1.448	1.3717		1.2193
18	1.1888	1.3717	1.2193			1.0669	1.0974
19	1.2193	1.448	1.2193	1.0974	1.3717	1.1431	1.2193
20	1.2498	1.448	1.2498	1.2193		1.3717	1.2955
21	1.1431	1.448	1.3717	1.2193		1.3717	1.2193
22	1.1431	1.448	1.3717	1.2955		1.2955	1.2955
23	1.0974	1.448	1.448	1.3717		1.3413	1.3717
24		1.1736	1.448	1.3717	1.2955		1.1888
Max	1.2498	1.448	1.448	1.448	1.3717	1.3717	1.3717
Min	1.0974	1.1736	1.2193	1.0974	1.2955	1.0669	1.0974
Avg	1.1736	1.3718	1.3470	1.2890	1.3463	1.2650	1.2384

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324064 / 33 KV SIDHESHWAR

Feeder No / Name : 203 / 11 KV LOHGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.1219	.0762	.0762	.0762		.0762
2	.945	.884	.8383	1.0669	.9907		.9907
3	.9602	.945	.8383	.9907	1.0669		1.0059
4	.9907	1.0212	.8383	1.0669	.9602		1.0059
5	.9907	1.0669	.9145	1.1431	.9907		.9907
6	1.0364	.884	.9145	1.2193	1.0669		1.0517
7	1.0669	.9907	.9907	1.2955	1.1431	1.0669	1.0669
8	.9145	.945	.9907	.9907	1.0669		.9907
9	.8535	.9907	.6097	.6859		.5144	.9145
19	.0762	.0762	.0762	.1067	.0762	.0762	.0762
20	.0914	.0762	.0762	.0762		.0762	.0914
21	.0762	.0762	.0762	.061		.0762	.1067
22	.1067	.0762	.0762	.0762		.0762	.0762
23	.1219	.0762	.0762	.0914		.0762	.0762
24	.8383	.1219	.0762	.0762	.0914		.0762
Max	1.0669	1.0669	.9907	1.2955	1.1431	1.0669	1.0669
Min	.0762	.0762	.0762	.061	.0762	.0762	.0762
Avg	.6655	.5568	.4979	.6015	.7529	.2803	.5731

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324079 / 33 KV BORJA

Feeder No / Name : 201 / 11 KV YEHELGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.6554	.6554	.6554	.3277	.6554	.3277	.4915
11	.8192	.8192	1.0322	.4915	1.0159	.6554	.8848
12	.8192	.9335	1.0486	.6554	.9831	.7045	.8356
13	.8192	.8192	.8848	.8684	.8192	.3277	.8029
14	.6554	.8192	.8848	.9012	.7045	.4915	.2622
15	.4915	.6554	.8848	.3113	.7045	.3277	.4915
16	.8192	.6554	.9175		.4588	.4915	.5243
17	.8192	.6554	.4915		.4915	.8192	.852
Max	.8192	.9335	1.0486	.9012	1.0159	.8192	.8848
Min	.4915	.6554	.4915	.3113	.4588	.3277	.2622
Avg	.7373	.7516	.8500	.5926	.7291	.5182	.6431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324079 / 33 KV BORJA

Feeder No / Name : 203 / 11 KV BORJA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3734	.3547	.3734	.3734		.3921
2	.3547	.3547	.3547	.3734	.3734		.3734
3	.3734	.3734	.3734	.3734	.3734		.3734
4	.4294	.4294	.3921	.4108	.4108		.4294
5	.5041	.5228	.4668	.5041	.5041		.5601
6	.6908	.6722	.6348	.6908	.7095		.8029
7	.6535	.6908	.7095	.6908	.7282	.7095	.6908
8	.5601	.5601	.6348	.5788	.5601		.5228
9	.4294	.4294	.3547	.5041	.5228	.5601	.3734
10	.3547	.3174	.3734	.4108	.3734	.3921	.3547
11	.2614	.2241	.3174	.2987	.2801	.2987	.2801
12	.1867	.2241	.2987	.2801	.2801	.2987	.2801
13	.1867	.2427	.2987	.2987	.2801	.2801	.2614
14	.1867	.2614	.2987	.2614	.3174	.2987	.2614
15	.2987	.2614	.2987	.2614	.3174	.3174	.2801
16	.3361	.2987	.3361		.3361	.3361	.2987
17	.3547	.3734	.3734		.3734	.3734	.3734
18	.3734	.4294	.4294			.4108	.3734
19	.5228	.4854	.5601	.6722		.5228	.5228
20	.5601	.5601	.5975	.5601		.5228	.5041
21	.4481	.4481	.4854	.4668		.4668	.4294
22	.4108	.3921	.4481	.4294		.4294	.4481
23	.3921	.3734	.3921	.4108		.4108	.4108
24	.3734	.3734	.3547	.3921	.3921		.3921
Max	.6908	.6908	.7095	.6908	.7282	.7095	.8029
Min	.1867	.2241	.2987	.2614	.2801	.2801	.2614
Avg	.3999	.4030	.4224	.4401	.4170	.4143	.4162

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324082 / 33 KV SALNA

Feeder No / Name : 201 / 11 KV ANKHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.086	.8954	.9507	1.0951		.9145
2	1.307	1.1765	.8954	.9507	1.0951		1.0059
3	1.307	1.2536	.985	1.1408	1.0951		.9955
4	1.4784	1.3432	1.0745	1.1408	1.2776		1.086
5	1.6461	1.5223	1.3146	1.2776	1.4601		1.3575
6	1.6832	1.5775	1.5775	1.6427	1.4601		1.4327
7	1.6263	1.7528	1.6651	1.6427	1.6427	1.6427	1.4022
8	1.4969	1.7528	1.6651	1.4601	1.6427	1.6427	1.4022
10				.1905			
17	.7621	.381	.5716	.5716		.7621	.5716
18	.5716	.5716	.5716	.5716		.7621	.7621
19	.5716	.6668	.5716	.5716		.7621	.9431
20	.5716	.7621	.5716	.5716		.5716	.9431
21	.5716	.5716	.5716	.5716		.5716	.7621
22	.5716	.381	.5716	.5716		.5716	.5716
23	.381	.381	.5716	.5716		.381	.381
24	1.1431	.381	.381	.381	.5716		.381
Max	1.6832	1.7528	1.6651	1.6427	1.6427	1.6427	1.4327
Min	.381	.381	.381	.1905	.5716	.381	.381
Avg	1.0520	.9726	.9034	.8693	1.2600	.8519	.9320



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324082 / 33 KV SALNA

Feeder No / Name : 202 / 11 KV GOJEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.5716	.5716	.5716		.5716
2	.7621	.381	.5716	.5716	.5716		.381
3	.7621	.5716	.7621	.5716	.5716		.5716
4	.7621	.9431	.9431	.5716	.5716		.8573
9	.7621	.7621	.7621	.5716	.5716	.5716	.7621
10	.7621	.5716	.5716	.5716	.381	.5716	.5716
11	.5716	.381	.5716	.381	.381	.381	.5716
12			.5716	.381	.381	.381	.5716
13		.381	.5716	.381	.381	.381	.381
14		.381	.5716	.381	.381	.381	.381
15		.381					
17	3.2217	2.4006	3.4678			2.8826	3.0521
18	3.2217	3.0864	3.4678	3.2853		3.0178	3.1017
19	3.2217	2.7435	3.4678	3.1028		3.3532	3.1855
20	3.2217	2.7435	3.4678	3.1028		3.1369	3.1855
21	2.915	2.7435	3.4678	2.9203		2.8292	3.0864
22	2.7435	2.8045	3.6199	2.7378		2.774	2.8292
23	2.6578	2.7168	3.2388	2.7378		2.6873	2.7435
24	.5716	2.572	2.572	2.9203	2.7378		2.6578
Max	3.2217	3.0864	3.6199	3.2853	2.7378	3.3532	3.1855
Min	.5716	.381	.5716	.381	.381	.381	.381
Avg	1.7819	1.5075	1.8466	1.5153	.6819	1.7960	1.6368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324082 / 33 KV SALNA

Feeder No / Name : 203 / 11 KV SALANA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905		.1905
2	.2858	.1905	.1905	.1905	.1905		.1905
3	.381	.381	.381	.1905	.1905		.381
4	.381	.5716	.5716	.1905	.1905		.381
9	1.1431	1.0745		1.2776	1.0951	.7301	1.086
10	1.2696	.985	1.2536	1.2776	1.0951	.5716	1.086
11	1.0517	.8954	1.2776	.9126	1.0951	.8954	.9955
12	.985	.8954	1.2776	.9126	1.0951	.8954	.905
13	.985	.8954	1.2776	.9126	1.0951	1.0517	.905
14	.8954	.8059	1.2776	.9126	1.0951	1.0745	.8145
15	.8954	.8954	1.2776	.9126	1.0951	1.0745	.7316
16	.8954	.8954	1.0951		1.0951	1.0745	
17			1.2776				
19	.381	.381		.381		.381	.381
20	.381	.381		.381		.1905	.381
21	.1905		.1905	.1905		.1905	.1905
22	.1905	.1905	.1905	.1905		.1905	.1905
23	.1905	.1905	.1905	.1905		.1905	.1905
24	.1905	.1905	.1905	.1905	.1905		.1905
Max	1.2696	1.0745	1.2776	1.2776	1.0951	1.0745	1.086
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.6046	.5888	.7569	.5532	.7472	.6547	.5406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324091 / 33 KV METHA

Feeder No / Name : 201 / 11 KV METHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5716	.4763	.543	.4572	.381		.381
3	.6097	.5335	.543	.4954	.381		.381
4	.6287	.5716	.6878	.5335	.4191		.4191
5	.6668	.6478	.8145	.5335	.4763		.4572
6	.6668	.6859	.905	.724	.4763		.6859
7	.6668	.9526	.905	.8764	.6668	.5068	.6859
8	.8383	1.0479	.905	.8764	.7621		.8002
9	.9145	.8764	.724	.9907	.8002	.6154	.8002
Max	.9145	1.0479	.905	.9907	.8002	.6154	.8002
Min	.5716	.4763	.543	.4572	.381	.5068	.381
Avg	.6954	.724	.7534	.6859	.5454	.5611	.5763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324091 / 33 KV METHA

Feeder No / Name : 202 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.362	.4887	.381	.381		.4191
2	.381	.381	.543	.4191	.4763		.4191
3	.4382	.4763	.5792	.4572	.5716		.4572
4	.6097	.5716	.5973	.4191	.5716		.4572
5	.6668	.6859	.6154	.5716	.6668		.6097
6	.7049	.7621	.6335	.8764	.7621		.8383
7	.6668	.5716	.6516	.8383	.7621	.7602	.724
8	.7049	.4763	.2896	.5716	.724		.5716
9	.381	.381	.2353	.4954	.5716	.5068	.5335
10	.381	.362	.3048	.381	.4525	.3048	.381
11	.381	.2172	.381	.381	.2172	.3048	.381
12	.381	.2715	.3429	.381	.2534		.381
13	.381	.2715	.381	.381	.3258	.2667	.2858
14	.381	.2715	.3048	.2667	.2715	.3048	.2858
15	.3239	.2715	.381		.2896	.3048	.3429
16	.381	.2715	.3429		.4525	.3048	.381
17	.381	.2534			.2896		.4763
18	.4191	.4344	.5716			.4954	.5716
19	.4954	.5973	.6097	.2096	.724		.5716
20	.5335	.6335	.5716	.5716		.6859	.5716
21	.4763	.543	.5335	.5144		.5716	.4763
22	.4001	.5068	.4572	.4763		.4763	.4763
23	.381	.4887	.4191	.4191		.4572	.381
24	.381	.381	.4525	.381	.381		.4191
Max	.7049	.7621	.6516	.8764	.7621	.7602	.8383
Min	.3239	.2172	.2353	.2096	.2172	.2667	.2858
Avg	.4588	.4351	.4647	.4696	.4813	.4419	.4755

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

AUNDHA NAGNATH S/DN.[798] BU 4798

Substation No/ Name :- 324091 / 33 KV METHA

Feeder No / Name : 203 / 11 KV LAKH AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.7621	.4344	.8764	1.1431	.4887	.724	.5716
11	.8573	1.086	1.2193	1.2384	1.267	.7621	.7621
12		1.1765	1.1812	1.2384		.8383	.8573
13	1.2384	1.086	1.2193		1.086	.6859	.7621
14	1.1431	.9955	1.0669	1.0669	1.086	.7621	.6668
15	1.0479	.8145	1.0669	.7621	.9955	.8383	.8002
16	1.1431	.6335	1.1812		.9955	.8764	.9526
17	1.2384	.724			.9955	.8573	.9907
Max	1.2384	1.1765	1.2193	1.2384	1.267	.8764	.9907
Min	.7621	.4344	.8764	.7621	.4887	.6859	.5716
Avg	1.0615	.8688	1.1159	1.0898	.9877	.7931	.7954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 201 / 11 KV TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5104	2.8485	2.914	2.8342	2.8936	1.5981	2.9212
2	2.827	2.7412	2.8418	2.7023	2.7614	1.5013	2.8451
3	2.7189	2.6403	2.7374	2.5808	2.6124	1.4083	2.7823
4	2.6615	2.6299	2.6666	2.5751	2.6559	1.3626	2.7978
5	2.7677	2.7387	2.7104	2.6957	2.7374	1.339	2.8251
6	2.9439	2.8349	2.8201	2.8646	2.8227	1.39	2.9013
7	3.078	3.0582	2.9386	2.9706	3.0537	1.5455	3.0232
8	3.1138	3.0948	3.1009	2.9679	3.0346	1.5889	3.0666
9	3.0925	3.0491	3.0327	2.9048	3.0734	3.1976	2.9936
10	2.9847	2.875	3.0198	2.8325	3.1397	3.0517	3.0567
11	3.0417	2.8376	3.0148	3.0185	3.1103	3.1029	3.1013
12	1.3664	2.8098	3.1302	3.1321	3.1085	3.2217	3.0194
13	3.3676	2.6368	2.9866	3.1212	3.1235	3.2747	2.8468
14	3.3505	2.8796	3.0387	3.1563	1.6278	3.1951	2.9034
15	3.2465	2.9561	3.1371	3.1656	3.1752	3.1621	3.015
16	3.2091	3.0689	3.2148	3.2215	3.2785	3.1699	3.0102
17	3.2335	3.2525	3.3817	3.3375	3.3402	3.3486	3.146
18	3.2738	3.2038	3.4935	3.5544	1.7223	3.5208	3.3779
19	3.5589	3.5979	3.5863	3.6983		3.7083	3.61
20	3.7171	3.8942	3.8089	3.641	2.0881	3.8857	3.8043
21	3.5909	3.7441	3.6462	3.4861	1.9395	3.7971	1.9867
22	3.3987	3.4497	3.3901	3.279	1.9227	3.4972	1.496
23	3.1211	3.16	3.1268	3.1394	1.6057	3.2804	2.9431
24	3.0056	2.995	2.9904	3.0125	3.126	1.6575	3.219
Max	3.7171	3.8942	3.8089	3.6983	3.3402	3.8857	3.8043
Min	1.3664	2.6299	2.6666	2.5751	1.6057	1.339	1.496
Avg	3.0075	3.0415	3.1137	3.0788	2.6936	2.6585	2.9455

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 202 / 11 KV MONDHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	3.3783	3.3646	3.2921	3.2502	1.8526	3.4821
2	3.2914	3.1711	3.2108	3.1618	3.1257	1.7368	3.3714
3	3.1946	3.0626	3.0826	3.0013	3.0544	1.6491	3.1997
4	3.1345	3.0086	3.0156	2.9828	3.063	1.5821	3.1611
5	3.3272	3.1245	3.1588	3.328	3.2884	1.685	3.3259
6	3.789	3.9378	3.7723	3.7546	3.7033	1.9243	3.7936
7	3.7745	3.5461	3.7562	3.9685	3.7456	1.9806	4.116
8	3.7555	3.8813	3.7723	3.8866	1.7642	1.8968	3.8874
9	3.7144	3.6389	3.7144	3.6961	3.6568	4.0455	3.6336
10	3.5301	3.4046	3.5789	3.4903	3.5737	3.7441	1.8435
11	3.3581	3.6557	3.4966	3.368	3.5429	3.5295	3.4922
12	3.4661	3.6076	3.3966	3.3977	3.6709	3.5584	3.3311
13	3.3478	3.5963	3.4608	3.3969	3.7052	3.6042	3.3356
14	3.3611	3.521	3.3649	3.3829	3.5293	3.3684	
15	3.4091	3.6839	3.505	3.552	3.5484	3.6245	3.9857
16	3.2601	3.7121	3.5065	3.6641	3.6679	3.6991	4.1882
17	3.4082	3.7258	3.5581	3.6412	3.7753	3.6995	4.1407
18	3.5292	3.6591	3.6567	3.8521		3.7512	3.9834
19	3.7846	4.1076	3.7997	3.9325		4.1388	4.1118
20	3.9201	4.0276	4.0101	3.9599		4.2235	3.5859
21	3.9254	3.9224	3.8188	3.7281	2.2512	3.9979	3.9441
22	3.8469	3.7921	3.7446	3.5985	2.1475	3.8799	3.9245
23	3.7258	3.7151	3.6787	3.6892	1.9837	3.8426	3.8803
24	3.5392	3.4815	3.4889	3.4495	3.6427	1.8717	3.5749
Max	3.9254	4.1076	4.0101	3.9685	3.7753	4.2235	4.1882
Min	1.7147	3.0086	3.0156	2.9828	1.7642	1.5821	1.8435
Avg	3.4628	3.5984	3.5380	3.5489	3.2233	3.0369	3.6214

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 203 / 11 KV KAUTHA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0059	1.0608	.9593	.9412		1.0719
2	.9774	.961	1.0164	.905	.9145		1.0164
3	.9412	.9511	1.0164	.8507	.8596		.9511
4	.8869	.961	1.0059	.8779	.8686		.9511
5	.9511	1.0059	1.0719	.8779	.924		.9412
6	1.134	1.1643	1.0974	1.1458	1.1203		.9745
7	1.1088	1.2012	1.1088	1.2012	1.1088		1.1203
8	1.1157	1.0974	1.0164	.9877	1.0974		1.1088
9	1.0136	1.086	1.1157	1.0059	1.0208	1.086	1.0425
10	.9745	1.0208	1.0317	.9671	1.0029	.985	1.1222
11	.9114		.985	.8417	1.0498	.9745	.9774
12	.985		1.0136	.8682	1.0136	1.0387	.9412
13	1.0679	1.1403	1.0317	.9492	1.0136	1.086	.9214
14	1.0099	.985	.9671	.8954	.9671	1.0974	.8954
15	1.0387	1.0317	.985	1.0317	1.0387	1.0745	1.0099
16		1.0387	1.0136	1.0498	1.0867	1.0974	1.0387
17		1.0099	1.0387	1.0059	1.0692	1.1393	.9955
18	1.1096	1.0923	.9945	1.1104		1.1317	.9991
19	1.2403	1.1999	1.1043	1.1088	1.2536	1.1694	1.1517
20	1.2308	1.2254	1.1523	1.2012		1.2851	1.1584
21	1.1765	1.2308	1.1523	1.1088		1.2127	1.086
22	1.1765	1.1765	1.1403	1.086		1.2127	1.0387
23	1.0974	1.0974	1.086	1.0974		1.0974	1.086
24	1.0387	1.0498	1.0498	1.0029	1.0059		1.0631
Max	1.2403	1.2308	1.1523	1.2012	1.2536	1.2851	1.1584
Min	.8869	.9511	.9671	.8417	.8596	.9745	.8954
Avg	1.0565	1.0787	1.0523	1.0057	1.0188	1.1125	1.0276



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 204 / 11 KV RURAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.132	.1509	.1509		.1509
2	.1509	.1509	.132	.1509	.132		.1509
3	.1509	.1509	.132	.1509	.132		.1509
4	.1509	.1886	.1509	.1509	.1509		.1698
5	.1698	.2075	.2075	.1886	.1886		.1886
6	.2263	.2075	.2075	.1886	.2075		.2263
7	.2452	.2641	.2263	.1886	.2263		.2452
8	.2263	.2263	.2641	.2641	.2829		.2263
9	.2075	.2452	.2075	.2075	.1886	.2263	.2263
10		1.0802	.5487	1.1336	1.1822	.9602	
11	1.1984	1.4419	.5693	1.3603	1.2003	1.3603	1.1012
12	1.4089	1.3763	1.2616	1.4089	1.3108	1.1717	1.1822
13	1.3765	1.3435	1.4091	1.3763	1.2955	1.247	1.0402
14	1.2289	1.3765	1.4586	1.2955	1.2483	1.2003	1.012
15	1.2616	1.3603	1.3599	1.2803	1.2955	1.1069	.6173
16	1.0279	1.2955	1.3763	1.2955	1.2616	1.1203	.8592
17	1.1336	1.2631	1.3927	1.2955	1.2163	1.1012	.5624
18	.1886	.1886	.1886	.2263		.1509	.1886
19	.2075	.2641	.2452	.2452		.2075	.2263
20	.2075	.2641	.2075	.2452			.2075
21	.2075	.2075	.1698	.1698		.2641	.1698
22	.2075	.1886	.1698	.1886		.1886	.1698
23	.1886	.1698	.1698	.1509		.1698	.1698
24	.1509	.1509	.1509	.1509	.1509		.1509
Max	1.4089	1.4419	1.4586	1.4089	1.3108	1.3603	1.1822
Min	.1509	.1509	.132	.1509	.132	.1509	.1509
Avg	.5237	.5735	.5141	.5610	.6567	.7482	.4084

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 206 / 11 KV WATER WORKS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.1294	.1334	.132		.132
2	.132	.0943	.1132	.132	.132		.1132
3	.132	.132	.0943	.132	.1132		.132
4	.132	.0943	.0943	.132	.132		.132
5	.132	.0754	.0754	.132	.1132		.128
6	.1132	.132	.132	.1334	.132		.1132
7	.112	.132	.132	.1334	.1715		.132
8	.1132	.1334	.132	.1334	1.7924		.1509
9	.1132	.132	.132	.132	.0953	.1524	.1334
10	.112	.1524	.208	.132	.1646	.1509	.1543
11	.1829	.1808	.2027	.2	.1858	.1619	.176
12	.1629	.1509	.1494	.1734		.216	.1509
13	.2143	.2058	.1898		.1974	.1966	.1478
14	.132	.1433	.132	.128	.1494	.132	.1132
15	.1635	.1663	.1572	.1957	.1898	.176	.132
16	.1957	.1783		.1882	.1635	.1898	.1334
17	.1957	.1875	.1806	.1581	.1802	.1551	.1509
18	.1585	.1132	.1966	.1709	.132	.0975	.1307
19	.1709	.1966	.1928	.1619	.12	.1833	.1307
20	.124	.132	.132	.1957		.112	.1494
21	.1132	.132	.132	.1509		.1307	.132
22	.132	.1097	.132	.1646		.132	.1509
23	.1509	.1848	.132	.1509		.1509	.132
24	.1132	.1698	.1509	.132	.0953		.1509
Max	.2143	.2058	.208	.2	1.7924	.216	.176
Min	.112	.0754	.0754	.128	.0953	.0975	.1132
Avg	.1435	.1434	.1445	.1520	.2311	.1558	.1376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 402 / 33kv incomer 1

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4335	1.3992	1.4335	1.5089		1.4632
2	1.4232	1.3717	1.286	1.4575	1.3375		1.5432
3	1.3923	1.2963	1.2323	1.4415	1.3146		1.4403
4	1.4083	1.2654	1.358	1.3226	1.3375		1.4083
5	1.4083	1.4243	1.3923	1.3735	1.4198		1.4083
6	1.5415	1.5415	1.4198	1.4723	1.5581		1.5604
7	1.5947	1.6644	1.5947	1.5947	1.6095		1.5432
8	1.6478	1.5432	1.6118	1.5415	1.5729		1.6095
9	1.5415	1.5249	1.5581	1.4198	1.5769	1.6461	1.5432
10	1.5083	1.4403	1.5912	1.4918	1.7004	1.5655	1.6129
11	1.5432	1.5261	1.6461	1.5947	1.6827	1.6095	1.6095
12	.0943	1.4752	1.5432	1.6598	1.5769	1.749	1.5432
13	1.8004	1.5592	1.5604	1.7295	1.8004	1.7404	1.4918
14	1.6787	1.5655	1.6301	1.6787	1.6409	1.6221	1.5546
15	1.6461	1.7101	1.6278	1.7204	1.6787	1.7204	1.6324
16	1.7404	1.7404	1.7684	1.8313	1.749	1.7004	1.5238
17	1.7101	1.7204	1.8204	1.8313	1.7204	1.7101	1.6409
18	1.761	1.6667	1.8278	1.9364	.128	1.8861	1.669
19	2.0165	1.9433	1.8724	2.0119		2.0833	1.9216
20	1.933	2.0062	1.8896	1.9456		1.989	2.0153
21	1.8461	1.8399	1.8244	1.8313		1.8982	.6481
22	1.6604	1.6324	1.6941	1.6221		1.8056	1.4803
23	1.5804	1.5546	1.5432	1.6129		1.669	1.6941
24	1.7404	1.5203	1.5404	1.5015	1.6907		1.5604
Max	2.0165	2.0062	1.8896	2.0119	1.8004	2.0833	2.0153
Min	.0943	1.2654	1.2323	1.3226	.128	1.5655	.6481
Avg	1.5746	1.5819	1.5930	1.6273	1.5055	1.7596	1.5466

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324010 / 33 KV BASMAT

Feeder No / Name : 403 / 33kv incomer2

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.6578	2.6292	2.7109	2.7149		2.7641
2	2.6326	2.6063	2.4434	2.5789	2.6337		2.6863
3	2.5789	2.5789	2.2565	2.364	2.3891		2.6063
4	2.5789	2.4977	2.3045	2.3891	2.4714		2.6337
5	2.552	2.552	2.3891	2.6063	2.6337		2.6606
6	2.963	3.095	1.8107	2.9864	2.9081		3.0178
7	3.0178	3.095	2.9081	3.3122	2.9864		3.2579
8	2.9864	2.955	2.9864	3.095	3.0624		3.1161
9	2.955	2.8475	3.0087	2.7938	2.9767	3.083	2.9767
10	2.7109	3.9735	3.1893	3.6523	3.722	3.9735	1.0288
11	3.8152	3.1687	3.2948	3.9095	4.0238	4.0238	3.6717
12	4.0238	3.083	3.7723	3.9232	4.0238	3.8226	3.6717
13	4.0695	4.0238	4.0741	3.9735	4.0695	3.9283	3.9735
14	3.8152	4.0238	4.0186	3.7643	3.8729	3.8226	1.9433
15	3.9678	3.9735	4.0238	3.9232	4.0238	3.8729	3.3699
16	2.5149	4.0741	4.0695	4.0695	4.0741	3.9232	3.722
17	2.8669	4.0238	4.1712	4.0186	4.1244	3.9735	3.3951
18	2.9321	2.8607	2.8807	3.0498		2.7978	2.9321
19	3.155	3.2956	3.0687	2.955		3.2076	3.1893
20	3.1699	3.3122	3.2236	2.7435		3.3311	3.2236
21	3.1699	3.2236	3.1161	3.095		3.1893	2.9767
22	3.0298	3.0624	3.0624	2.9321		3.083	2.9767
23	2.9235	2.9235	2.9767	2.9012		3.1024	2.9767
24	2.5149	2.7869	2.8172	2.8172	2.7938		2.9235
Max	4.0695	4.0741	4.1712	4.0695	4.1244	4.0238	3.9735
Min	2.5149	2.4977	1.8107	2.364	2.3891	2.7978	1.0288
Avg	3.0845	3.1956	3.1040	3.1902	3.3058	3.5423	2.9873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 201 / 11 KV HATTA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	09-MAY-17	11-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
12		2.0957	
16	1.5242	2.0957	1.7147
Max	1.5242	2.0957	1.7147
Min	1.5242	2.0957	1.7147
Avg	1.5242	2.0957	1.7147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 202 / 11 KV RAHATI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	09-MAY-17
HR	Load (MW)
13	1.749
Max	1.749
Min	1.749
Avg	1.749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 203 / 11 KV SATEPHAL AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	11-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)
12	1.9052	
16	1.9052	1.7147
Max	1.9052	1.7147
Min	1.9052	1.7147
Avg	1.9052	1.7147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 204 / 11 KV ADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	10-MAY-17	11-MAY-17	12-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
6	1.2193		
8			1.5432
12		2.2862	
Max	1.2193	2.2862	1.5432
Min	1.2193	2.2862	1.5432
Avg	1.2193	2.2862	1.5432



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 205 / 11 KV SATEPHAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5216	.514	.5266	.5818
2	.5167	.5117	.5197	.5571
3	.5155	.5155	.5075	.5567
4	.567	.5605	.5449	.6081
5	.6645	.6813	.6634	.6805
6	.7613	.8459	.7434	.8669
7		.7602		.8897
8				.4409
9			.7766	
10	.7381	.5586	.7072	.6013
11	.6596	.6123	.6371	.6493
12	1.1705	.5258	.5563	.5426
13	.5247	.5072	.4957	.426
14	.4976	.4889	.5209	.4279
15	.4889	.5117	.5346	.4355
16	1.3672	.5453	.6428	1.1789
17	.7106	.6222	.7064	.6283
18	.7282	.6546	.5083	.6943
19	.7785		.8128	.6828
20	.7457	.024	.8345	.0625
21	.7446	.0972	.7735	.7792
22	.6485	.6691	.6847	.7045
23	.5925	.6337	.6352	.5735
24	.5277	1.1675	.5944	.551
Max	1.3672	1.1675	.8345	1.1789
Min	.4889	.024	.4957	.0625
Avg	.6890	.5718	.6330	.6139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 206 / 11 KV HATTA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	.9271	.969
2	.8962	.9012	.8989	.9362
3	***	***	.8825	.9297
4	***	***	.932	.9587
5	1.033	1.0383	1.0334	1.1035
6	***	***	1.3596	1.5013
7	***	***	1.6522	1.685
8	1.6678	1.6747	1.6381	1.6956
9	***	***	1.5203	1.6274
10	***	***	1.3938	1.3847
11	1.2109	1.0856	1.1561	1.1279
12	***	***	.9168	.9214
13	***	***	.8634	.8554
14	.7747	.7754	.8139	.7571
15	***	***	.8208	.7667
16	***	.8265	.9073	.7872
17	1.001	.9633	1.038	.8924
18	***	1.0479	1.1138	.9835
19	***		1.4849	.977
20	1.6396	1.2814	1.6606	1.5207
21	***	1.6198	1.6217	1.5009
22	***	1.3249	1.2856	1.2639
23	1.0555	1.0985	1.1366	1.041
24	***	.9892	1.0254	.9964
Max	24.9715	24.9715	1.6606	1.6956
Min	.7747	.7754	.8139	.7571
Avg	17.0343	11.4931	1.1701	1.1326

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 207 / 11 KV ADGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.487	.4858	.4729	.4896
2	.4828	.4698	.4694	.4839
3	.4607	.4435	.4572	.4698
4	.4828	.45	.4637	.4721
5	.5921	.5346	.5491	.5552
6	.8162	.7857	.7587	.7548
7	.9415	.9126	.8859	.9431
8	.924	1.5745	.5979	.9233
9	.8051	.8615	.8554	.8124
10	.7918	.4066	.6649	.7324
11	.6241	.6504	.5929	.5921
12	.8162	.4896		.4001
13	.394	.4672		.3334
14	.3974	.1014	.029	.3197
15	.4035	.434	.4237	.3296
16	.8597	.4062	.503	.7312
17	.4832	.4957	.5601	.4492
18	.5308	.5079	.6203	.5697
19	.5929		.687	.6535
20	.0457	.6607	.6664	.6878
21	.8905	.8695	.8432	.7815
22	.6626	.6718	.6508	.6584
23	.5548	.5476	.5727	.5662
24	.519	.9419	.5102	.5068
Max	.9415	1.5745	.8859	.9431
Min	.0457	.1014	.029	.3197
Avg	.6066	.6160	.5834	.5923

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324014 / 33 KV HATTA

Feeder No / Name : 208 / 11 KV COLLEGE  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	11-MAY-17	12-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
8		.0015	
12	.0953		
16	.0953		.0953
24		.0015	
Max	.0953	.0015	.0953
Min	.0953	.0015	.0953
Avg	.0953	.0015	.0953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324017 / 33 KV KURUNDA

Feeder No / Name : 201 / 11 KV KURUNDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	10-MAY-17	11-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.5201
6	.5144		.5201
10			.8478
11		1.0174	
13			.8383
16		.8478	
20		.5258	.5201
Max	.5144	1.0174	.8478
Min	.5144	.5258	.5201
Avg	.5144	.797	.6493

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324017 / 33 KV KURUNDA

Feeder No / Name : 203 / 11 KV SOMTHANA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	08-MAY-17	10-MAY-17	11-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
5	.8573		.6859
6	.8573		.8669
11		.5144	
13			.5087
16		.5144	
20		.8669	.8573
Max	.8573	.8669	.8669
Min	.8573	.5144	.5087
Avg	.8573	.6319	.7297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324017 / 33 KV KURUNDA

Feeder No / Name : 205 / 11 KV DONWADA GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-17	10-MAY-17	11-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
5	.6935		.6935
10			.5144
11		.3467	
16		.3429	
20		.7011	.5201
Max	.6935	.7011	.6935
Min	.6935	.3429	.5144
Avg	.6935	.4636	.576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324017 / 33 KV KURUNDA

Feeder No / Name : 206 / 11 KV Momhadpur Wadi AG SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	10-MAY-17	11-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
5	.1734		.1753
6	.1734		.1753
10			1.1869
11		1.3565	
13			1.5089
16		1.1736	
20		.1753	.1753
Max	.1734	1.3565	1.5089
Min	.1734	.1753	.1753
Avg	.1734	.9018	.6443



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324029 / 33 KV GIRGOAN

Feeder No / Name : 201 / 11 KV GIRGOAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2401	.2119	.2096	.2375	.2172
2	.2667	.2401	.2401	.2119	.2096	.2111	
3	.3212	.3201		.2383	.262	.2648	
4	.3761	.3734	.3201		.3406	.3467	
5	.4313	.4268	.3734	.3972	.3929	.4329	.4072
9	.3201	.3201	.2667	.2648	.2903	.3258	.3258
10	.2667	.2134	.2401	.2383	.2639	.2715	
11	.2134			.2119	.2111		
12	.1867		.1854	.1854	.1847		
13	.1867	.1867			.1847		
14	.2134	.1867	.1854		.184		
15	.2134				.1834	.19	
16	.2134	.2134	.2383		.2096	.2172	.2172
17	.2934	.2667	.2648	.2882	.261	.2715	
18	.3201					.2858	
19	.3467	.3467					.3529
20	.3467		.2648				
21	.2667	.2667	.2383				
22	.2401	.2401					
23	.2401	.2401	.2119		.8573	.2172	.2443
24	.2401	.3201	.2401	.2119		.7716	.2172
Max	.4313	.4268	.3734	.3972	.8573	.7716	.4072
Min	.1867	.1867	.1854	.1854	.1834	.19	.2172
Avg	.2735	.2751	.2507	.2460	.2830	.3110	.2831

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324029 / 33 KV GIRGOAN

Feeder No / Name : 203 / 11 KV PARDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.6859	.6859	.6859	.8573	.8573		.6859
11	.8573	1.0288	1.1145	1.2003	1.0288		
12	.8573		1.1145	1.2003	1.0288		
13	.8573			1.0288	.8573		
14	.8573	1.0288	1.0288	1.0288	.8573		
15				1.0288	.8573		
16	.6859	1.0288	1.0288	1.0288	.8573	.8573	1.0288
17	.8573	1.0288	1.0288	1.0288	.8573	.8573	
Max	.8573	1.0288	1.1145	1.2003	1.0288	.8573	1.0288
Min	.6859	.6859	.6859	.8573	.8573	.8573	.6859
Avg	.8083	.9602	1.0002	1.0502	.9002	.8573	.8574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324029 / 33 KV GIRGOAN

Feeder No / Name : 204 / 11 KV KINOLA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		.8573	.6859	.8573	1.0288		.8573
11				1.2003	1.3717		
12		1.1145	1.1145	1.2003	1.3717		
13	1.0288			1.2003	1.2003		
14	1.0288	1.0288	1.2003	1.2003	1.2003		
15			1.2003	1.0288	1.2003		
16	1.0288	1.0288	1.1145	1.0288	1.2003	.8573	1.0288
17	1.0288	1.0288	1.0288	1.0288	1.0288		
Max	1.0288	1.1145	1.2003	1.2003	1.3717	.8573	1.0288
Min	1.0288	.8573	.6859	.8573	1.0288	.8573	.8573
Avg	1.0288	1.0116	1.0574	1.0931	1.2003	.8573	.9431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324029 / 33 KV GIRGOAN

Feeder No / Name : 205 / 11 KV WADGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3429	.1715	.1715	.1715	.1715	.3429	.3429
3	.3429	.1715	.1715	.1715		.3429	
4	.6859	.3429			.3429	.3429	
5	1.0288	.5144	.5144		.5144	.6859	
6	1.3717	.8573	.6859	.8573	.8573	1.0288	
7	1.7147	1.3717	1.3717	1.8861	1.7147	1.2003	
8	1.7147		1.7147	1.7147	1.3717	1.3717	1.7147
9	1.5432	1.7147	1.7147	1.7147	1.7147	1.2003	1.7147
Max	1.7147	1.7147	1.7147	1.8861	1.7147	1.3717	1.7147
Min	.3429	.1715	.1715	.1715	.1715	.3429	.3429
Avg	1.0931	.7349	.9063	1.0860	.9553	.8145	1.2574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324050 / 33 KV WAPTI

Feeder No / Name : 203 / 11 KV PANGRA GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	09-MAY-17	10-MAY-17	12-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
6		.6249	
7	1.2117	.6554	
9			.8573
12	.0419		
13	.1029		
14	.1105		
15	.0381		
19	.0572		
20	.1372		
21	.1219		
23	.0495		
24		.0419	
Max	1.2117	.6554	.8573
Min	.0381	.0419	.8573
Avg	.2079	.4407	.8573

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324065 / 33 KV MALWATA

Feeder No / Name : 202 / 11 KV BORALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.1431	1.1431	1.1431	1.2384	1.1431	1.1431
2	1.0059	1.0059	1.0898	1.1603	1.5089	1.2384	.9012
3	1.2498	1.1203	1.1603	1.4419	1.6766	1.2384	.9717
4	1.2651	1.2651	1.3927	1.5402	1.8023	1.3336	1.0774
5	1.6766	1.5623	1.6385	1.5893	1.9662	1.5242	1.3765
6	2.0119	1.9204	1.8233	2.1051	2.13		2.0719
7	2.13	2.2377	2.0481	2.3482	2.2405	1.848	2.1605
8	2.0805	2.13	2.1605	1.9433	2.0805	1.6575	2.1822
9	2.0005	2.0119	2.13	2.0809		1.8842	2.0243
10		.8573					.8383
11		.7621					.6859
12		.7621					.7621
13		.7621					.8002
14		.8002					.7811
15		.8573					.9526
16		.9526					1.0479
17		1.0479					
18		1.2384	1.9052	1.9052		1.2384	1.7147
19	1.9624	1.4289	2.0005	2.0005	1.5242	1.4289	1.6766
20	1.9052	1.6194	1.7147	1.7147	1.6194	1.6194	1.6766
21	1.7147	1.5242	1.5242	1.5242	1.5242	1.5242	1.6766
22	1.5242	1.4289	1.3336	1.4289	1.4289	1.4289	1.3336
23	1.3336	1.2384	1.2955	1.2384	1.3336	1.1431	1.2384
24	1.1431	1.2384	1.2384	1.1812	1.2384	1.2384	1.2384
Max	2.13	2.2377	2.1605	2.3482	2.2405	1.8842	2.1822
Min	1.0059	.7621	1.0898	1.1431	1.2384	1.1431	.6859
Avg	1.6098	1.2881	1.5999	1.6466	1.6652	1.4326	1.3188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324065 / 33 KV MALWATA

Feeder No / Name : 203 / 11 KV PALASGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517	1.0745	1.1469	.9717	1.2003	1.2803	1.1393
2	1.0745	1.0745	1.0774	1.166	1.1736	1.1765	1.2536
3	1.0745	1.2803	1.2003		1.3413	1.0288	1.1765
4			1.4327	1.3253	1.3927	1.0898	1.4632
5				1.4266	1.5089		1.6118
6				1.6632	1.5432		1.6632
7				1.4998	1.2574		1.7194
8				1.2127	1.1736		1.7924
9				.9877			
10	1.989		2.1548	1.8404	1.5432	1.7194	1.8023
11	2.13	2.3758	2.3205	2.2405	2.0481	1.8842	2.2611
12	2.0805	2.3967	2.4577	2.4577	2.1605	1.9559	2.3266
13	2.0805	2.2939	2.2939	2.2939	1.9662	1.8842	2.13
14		2.1605	2.2672	2.2119	2.0005	1.7814	2.0645
15	.6478	2.13	2.17	2.13	1.9433	2.0005	2.0805
16		2.2672	2.3537	2.13	1.9528	2.1862	2.1506
17		2.2377	2.2939	2.2405	2.0557	2.2611	
18		1.4575	1.6095	1.7375		1.448	
19	1.3413	1.5775	1.6118	1.6118		1.6461	1.2178
20	1.0936	1.5223	1.5364	1.6118	1.7909	1.6118	1.3611
21	.9831	1.4022	1.4083	1.3717	1.6461	1.5223	1.3466
22	.9831	1.286	1.2003	1.286	1.448	1.448	1.2536
23	.9831	1.2239	1.1488	1.2003	1.3432	1.3146	1.0387
24	1.0517	1.0517	1.1603	1.0722	1.2003	1.3575	1.1145
Max	2.13	2.3967	2.4577	2.4577	2.1605	2.2611	2.3266
Min	.6478	1.0517	1.0774	.9717	1.1736	1.0288	1.0387
Avg	1.3260	1.6948	1.7287	1.6387	1.6043	1.6103	1.6175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324065 / 33 KV MALWATA

Feeder No / Name : 204 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-17	09-MAY-17	10-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1867	.128	.1886	.1494	.1448
2	.0838	.1867	.1478	.1886	.1307	.1267
3	.0762	.1848	.112	.1886	.1448	.1433
4	.0762	.1848	.1307	.1867	.1307	.1372
5	.1715	.1867	.128	.1867	.1463	.1638
6	.2263	.1886	.1494	.1867		.1524
7	.2572	.1886	.1829	.1829	.1307	.1296
8	.2458	.1867	.1867	.1829	.1509	.1075
9	.2458	.1886	.2241	.1791	.2801	.181
10	.4715	.6535	.3921	.2686	.4668	.3547
11	.4668	.7468	.4527	.3734	.6535	.4854
12	.462	.7468	.4527	.3772	.7316	.5544
13	.3696	.6535	.4435	.2829	.5975	.2957
14	.3772	.5914		.3734	.4715	.2263
15	.5658	.5601	.3292	.4572	.5601	.5228
16		.4715	.6036	.5228	.6602	.5601
17		.4066	.4805	.3395	.6602	
18		.3734	.4527		.5601	.3734
19	.2772	.2829		.1867	.4715	.3734
20	.3734	.1886	.3429	.2241	.3772	.3326
21	.2829	.1867	.1989	.2263	.1867	.2957
22	.2829	.2195		.1886	.1829	.2987
23	.2829	.1254		.1867	.181	.2452
24	.1886	.2829	.1086		.1886	.1663
Max	.5658	.7468	.6036	.5228	.7316	.5601
Min	.0762	.1254	.1086	.1791	.1307	.1075
Avg	.2838	.3405	.2824	.2581	.3571	.277



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324066 / 33 KV JNV

Feeder No / Name : 204 / 11 KV AKOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.5975	1.2929	.6036	1.3279	.4877	.6413
2		.8383	1.3765	.7459	1.3748	.7287	.8078
3	1.326	.9482	1.576	.8619	1.3735	.8124	.9031
4	1.5083	1.1443	1.5777	.9945	1.4089	.9488	1.0848
5	1.6057	1.2163	1.3717	1.065	1.6804	1.0814	1.3032
6	1.7204	1.4335	1.5061	1.4251	1.5466	1.5091	1.3611
7	1.8187	1.4803	1.5746	1.6194	1.7318	1.6975	1.4289
8	1.5729	1.438	1.6356	1.6057	1.5466	1.8861	1.438
9	1.4746	1.0997	1.5074	1.5203	1.6194	.6802	1.4521
10	.7545	.6224	.5658	.811	1.4563	.7373	.6224
11	.6979	.5975	.6224	.7545		.5258	.6413
12		.6413		.6602	.5975		.6722
13	.7468	.5975	.6602	.679	.5847	.5658	
14	.7842	.5601	.679	.6979	.6535	.6535	.7282
15	.8962	.6348	.7167	.6602	.6979	.6859	.7842
16	.9795	.7023	.7545	.7922	.8402	.8775	.7655
17		.7842	1.0751	.9431	.9055		.8299
18	.9522	.8589	1.2071	.6767		.7947	.9808
19	.8686	.8686	1.2449	.6859		.7842	1.2071
20	.7842	.6554	1.1317	.5935	.7947		.8488
21	.7468	.9878	.8488	.703	.7164		.7545
22	.7095	.9326	.679	.5487	.6478	.7545	.6224
23	.6908	.7545	.6413	.5247		.6979	.6413
24	.679	.6348	.8478	.6413	.5182	.5182	.6602
Max	1.8187	1.4803	1.6356	1.6194	1.7318	1.8861	1.4521
Min	.6602	.5601	.5658	.5247	.5182	.4877	.6224
Avg	1.0465	.8762	1.0910	.8672	1.1011	.8714	.9208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324073 / 33 KV KHANDEGOAN

Feeder No / Name : 202 / 11 KV SUTGIRNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	14-MAY-17
HR	Load (MW)
11	.1905
Max	.1905
Min	.1905
Avg	.1905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324075 / 33 KV PARDI BAGAL

Feeder No / Name : 201 / 11 KV PARDI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.3189	.298		.3224		.2865
2	.3189	.3366	.3239		.3224		.3045
3	.3544	.3544	.4207		.3761		.3224
4	.443	.4252	.4908		.4656		.4477
5	.5847	.5493	.5609	.5373	.591		.6268
9	.3898	.4477	.4382	.4835	.4382	.4557	.4298
10	.3721	.3506	.4119	.4119	.3681	.3856	.3045
11	.2481	.3506	.3189	.3403	.298	.3012	.197
15		.3077	.3189	.3224	.3761	.3224	.2865
16	.3544	.333	.3544	.3403	.3681	.3224	.2865
17	.3544	.3856	.3898	.4477		.3582	
18	.3898	.4207	.4477	.5014		.4477	.2149
19	.4607	.4733	.5373	.4477		.4477	.4477
20	.4607	.4908	.4477	.4477		.394	.4477
21	.4075	.4382	.4119	.4119		.3582	.4119
22	.3544	.3681	.394	.394		.3045	.3582
23	.3366	.3506	.3582	.3403		.2865	.3045
24	.3544	.3189	.3155		.3224		.2865
Max	.5847	.5493	.5609	.5373	.591	.4557	.6268
Min	.2481	.3077	.298	.3224	.298	.2865	.197
Avg	.3825	.3900	.4022	.4174	.3862	.3653	.3508

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324075 / 33 KV PARDI BAGAL

Feeder No / Name : 203 / 11 KV SOMTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5801	.5735	.5668	.5801	.5407		.4973
2	.663	.5735	.6154	.663	.5407		.5801
3	.7459	.5735	.6154	.663	.6554		.663
4	.7459	.7373	.7287	.7459	.7373		.7459
5	.8288	.8192	.9393	.8288	.8684		.8288
10	2.2939	1.7814	1.7966	1.9662	2.1052	1.3279	1.8023
11	2.7035	2.1052	2.4863	2.4577	2.4996	1.4918	2.0481
12	2.7035	2.2672	2.652	2.4577	2.5777	1.6575	1.8842
13	2.5396	2.2672	2.4863	2.4577	2.3434	1.8233	1.9662
14	2.4577	2.2672	2.3205	2.2119	2.3434	1.8233	2.0481
15	2.2939	1.7814	1.9814	2.2939	2.1872	1.9662	2.0481
16	1.9662	2.2672	2.1548	2.4577	2.3434	1.9662	2.13
17	1.9662	2.2672	2.4034	2.4577		1.8233	
18	.6226	.6478	.663	.5735		.663	
19	.7045	.7287	.7459	.7373		.8288	
20	.7045	.7287	.8288	.7373		.8288	
21	.6554		.7459	.6554		.7459	.3315
22	.6554		.663	.6554		.663	.3315
23	.5735		.663	.5735		.5801	.3315
24	.5801	.5735	.5182	.5801	.5735		.4973
Max	2.7035	2.2672	2.652	2.4577	2.5777	1.9662	2.13
Min	.5735	.5735	.5182	.5735	.5407	.5801	.3315
Avg	1.3492	1.3506	1.3287	1.3377	1.5628	1.2992	1.1709

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324078 / 33 kV BORI SAWANT

Feeder No / Name : 201 / 11 KV KARANJALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9465	1.286	.964	1.262	.9114	1.0117	1.1393
17		1.9204	2.0576	2.1605		2.0576	
24	1.1831	2.0348	1.5261	1.3717	1.6289	1.9547	1.5432
Max	1.1831	2.0348	2.0576	2.1605	1.6289	2.0576	1.5432
Min	.9465	1.286	.964	1.262	.9114	1.0117	1.1393
Avg	1.0648	1.7471	1.5159	1.5981	1.2702	1.6747	1.3413

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324078 / 33 kV BORI SAWANT

Feeder No / Name : 202 / 11 kV DAREPHAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		1.3032	1.2003	1.0802	.9431	1.0974	1.0288
10	1.094						
16	1.6461	.9774	1.0117	1.046	.8402	.9259	
Max	1.6461	1.3032	1.2003	1.0802	.9431	1.0974	1.0288
Min	1.094	.9774	1.0117	1.046	.8402	.9259	1.0288
Avg	1.3701	1.1403	1.106	1.0631	.8917	1.0117	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324078 / 33 kV BORI SAWANT

Feeder No / Name : 203 / BORI(S) GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3439	.4477	.3841	.3439	.3801	.2715	.4119
10	.2713						
16	.3544	.181	.197	.1086	.1991	.2172	
24	.2353	.2328	.2012	.197	.2896	.2534	.181
Max	.3544	.4477	.3841	.3439	.3801	.2715	.4119
Min	.2353	.181	.197	.1086	.1991	.2172	.181
Avg	.3012	.2872	.2608	.2165	.2896	.2474	.2965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324086 / 33 kV HAYATNAGAR

Feeder No / Name : 202 / 11 KV HAYATNAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	09-MAY-17
HR	Load (MW)
1	.9907
2	.9145
3	.8383
4	.9526
24	.9717
Max	.9907
Min	.8383
Avg	.9336



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324087 / 33 kV WAKHARI

Feeder No / Name : 201 / 11 KV BABHULGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.543	.4854	.5716	.543		.4641
2	.439	.543	.4854	.5228	.5611		.5525
3	.5544	.5611	.5228	.5487	.5611		.4858
4	.8215	.5792	.6219	.695	.5792		.6097
5	.961	.6335	.8238	.8779	.7421		.724
6	1.1203	.9945	.9945	1.0719	1.0288		.9335
7	1.0082	1.0117	1.0395	1.2197	.9602		1.2003
8	.8962	.8573	.9945	1.1576	.9231		.8356
9	.6722	.7059	.8764	.961	.4525	.5601	.7207
10	.5228	.4706	.695	.5853	.4525	.4668	
11		.4854	.5975	.5914	.3921	.5487	.4108
12	.5601	.4294		.4525	.4668		.5601
13	.4854	.4294	.4904	.4706	.4668		.5228
14	.4854	.4481	.5487	.4706			.3475
15	.6348	.5228	.5487	.5611			.4054
16	.8501	.5853	.6348	.6335		.9145	
17	.9709	.7343	.8871	.7716		.852	1.0242
18	.9709	.7888	1.0082	.8916		.9339	1.0242
19	.823	.9816	1.094	1.0631		1.0974	.9979
20	.7202	.8596	.9335	.8573		.8573	.8501
21	.6173	.6584	.7545	.7602		.6226	
22	.5973	.6036	.6478	.6516		.5716	.4435
23	.5792	.5975	.6097	.5973		.5304	.4481
24	.5335	.543	.5601	.5716	.5792		.5144
Max	1.1203	1.0117	1.094	1.2197	1.0288	1.0974	1.2003
Min	.439	.4294	.4854	.4525	.3921	.4668	.3475
Avg	.7087	.6486	.7328	.7315	.6220	.7232	.6702

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324087 / 33 kV WAKHARI

Feeder No / Name : 202 / 11 KV WAKHARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.743	.7011	.8063	.8002	.6097		.6554
3	.8859	.7926	.7888	.9267	.7011		.7287
4	.9846	.9145	.8413	1.1294	.7316		.9145
5	1.2163	1.0669	1.1065	1.379	.7621		.9907
6	1.4377	1.5242	1.4251	1.7535	.9145		1.1431
7	1.6347	1.7985	1.8903	.7335	1.3717		1.6766
8	1.7158	1.7528	1.8435	1.6347	1.4175		1.4403
9	1.7071	1.6613	1.8138	1.4449	1.3108	1.4922	1.1888
Max	1.7158	1.7985	1.8903	1.7535	1.4175	1.4922	1.6766
Min	.743	.7011	.7888	.7335	.6097	1.4922	.6554
Avg	1.2906	1.2765	1.3145	1.2252	.9774	1.4922	1.0923

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324087 / 33 kV WAKHARI

Feeder No / Name : 203 / 11 KV BABHULGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.8823	1.7528	1.89	1.8823	1.7375		
11	2.5263	2.3015	2.3777	2.4074	2.0729		.4858
12	2.6155	2.2862	2.4371	2.4966	1.6598		.5213
13	2.5286	2.2862	2.4082	2.4074	1.8299		.4054
14	2.4082	2.2253	2.3777	2.3777	1.8138		.439
15	2.2862	2.1795	2.2885	1.768			.3765
16	2.2577	2.2253	2.0805	2.0729		1.531	
17	2.2878	2.3167	2.2588	2.0729		1.7147	.9267
18						1.7368	
Max	2.6155	2.3167	2.4371	2.4966	2.0729	1.7368	.9267
Min	1.8823	1.7528	1.89	1.768	1.6598	1.531	.3765
Avg	2.3491	2.1967	2.2648	2.1857	1.8228	1.6608	.5258

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324090 / 33 kV BORALA

Feeder No / Name : 201 / 11 KV DHAMANGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4403				
2	1.6289	1.326	1.4175	1.8004		1.6975	1.8004
3	1.8004	1.4937	1.4632	1.9719	1.89	1.7318	1.9719
4	1.9719	1.6766	1.6004	2.1434	2.1033	1.6461	2.1434
5	1.9052	1.89	1.829	2.0576	2.1491	1.9662	2.1338
6	2.1338	1.9814	1.89	2.2862	2.2862	2.2862	2.3624
7	2.3624	2.2253	2.1948	2.4387	2.4691	2.4691	2.5149
8	2.2862	2.3929	2.2862	2.3624	2.3777	2.5301	2.3624
9	2.1338	2.1033	2.2558	2.2862		2.4691	2.21
Max	2.3624	2.3929	2.2862	2.4387	2.4691	2.5301	2.5149
Min	1.6289	1.326	1.4175	1.8004	1.89	1.6461	1.8004
Avg	2.0278	1.8862	1.8197	2.1684	2.2126	2.0995	2.1874

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324090 / 33 kV BORALA

Feeder No / Name : 202 / 11 KV RURAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5658	.6001	.6001	.5658	.5316	.6001
2	.6516	.6173	.6001	.6859	.6687	.4973	.6516
3	.7202	.6859	.6516	.7716	.7202	.5658	.7716
4	.823	.7373	.7164	.8573	.8745	.8059	.8916
5	.9602	.823	.8078	.9431	.9945	.9774	.9145
6	.9907	.8916	.945	.9145	1.1145	1.1317	1.0669
7	.9145	.823	1.0059	.9431	1.1488	.9774	.9907
8	.9431	.8402	.6859	.8573	1.0631	1.0288	.9145
9	.8573	.5658	.9088	.7716	.9602	.7716	.8573
10		.5316	.7716	.9145	.7773	.7202	.7716
11	1.1584	.5144	1.0288	1.0822	1.0669		1.2346
12	1.3108	1.0974	1.2193		1.2955		1.1888
13	1.3108	1.2498	1.2498	1.1888	1.1431	1.1145	1.1431
14	1.2651	1.1888	1.2955	1.3108	.9145	1.2498	1.286
15	1.2803	1.1126	1.2498	1.1584	.8993	1.3108	1.0669
16	.7468	1.2346	1.2803	1.1888	1.1584	1.3717	1.0669
17	1.2803	1.3717	1.2955	1.2193		1.448	1.4175
18	1.326	.6859	1.2803			1.0288	1.326
19	1.4784	.9088	1.2193	.9945		.9431	1.2803
20	.7373	.8059	.7716			.8573	1.3375
21	.6687	.703	.6859		.583	.7888	1.0288
22	.6173	.5792	.6516		.5487	.7202	.9602
23	.583	.583	.6001		.5144	.6687	.9774
24	.6516	.583	.5487	.5487	.5487	.5144	.6173
Max	1.4784	1.3717	1.2955	1.3108	1.2955	1.448	1.4175
Min	.583	.5144	.5487	.5487	.5144	.4973	.6001
Avg	.9511	.8208	.9196	.9417	.8780	.9102	1.0151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324090 / 33 kV BORALA

Feeder No / Name : 203 / 11kv bhendegaon

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0171	.0171	.0171
2	.0171	.0171	.0171	.0171	.0171	.0171	.0171
3	.0171	.0171	.0171		.0171	.0171	.0171
4	.0171	.0171	.0171		.0171	.0171	.0171
5	.0171	.0171	.0171		.0171	.0171	.0171
10	.2229	.2058	.2058		.1029	.1029	.2058
11	.2572	.3086	.2591		.1372	.1029	.2572
12	.2743	.3601	.2439	.0686	.12	.2058	.2743
13	.3086	.2743	.2439	.12		.2439	.2572
14	.2915	.2572	.2572	.0857	.3601	.2743	.2058
15	.2401	.3086	.2439	.0686	.4115	.2896	.2229
16	.0686	.2572	.2439	.12	.3601	.2591	.1886
17	.2058	.2572	.2572	.0686		.2572	.2572
18				.0686			
19	.0171	.0171	.0171	.0171		.0171	.0171
20	.0171	.0171	.0171			.0171	.0171
21	.0171	.0171	.0171		.0171	.0171	.0171
22	.0171	.0171	.0171		.0171	.0171	.0171
23	.0171	.0171	.0171		.0171	.0171	.0171
24	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Max	.3086	.3601	.2591	.12	.4115	.2896	.2743
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.1083	.1272	.1128	.0608	.1097	.1013	.1083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324092 / 33 kV WAI CHOUNDI

Feeder No / Name : 201 / 11 KV AMBA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1772			
2		.1886			
3		.1829			
4		.2058			
5		.282			
6		.3201			
10	.9088	.3353		.7202	
11		.5716	.9945	.8402	
12		.663	.9882		
13		.4287	.9945		
14		.5716	.6588		
15		.5716	.8916		
16		.8002	1.0852		.8002
17		.663			
18		.5944			
19		.6516			
24		.1829			
Max	.9088	.8002	1.0852	.8402	.8002
Min	.9088	.1772	.6588	.7202	.8002
Avg	.9088	.4347	.9355	.7802	.8002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324092 / 33 kV WAI CHOUNDI

Feeder No / Name : 202 / 11 KV WAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	12-MAY-17	13-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.3856
2			1.1145
3			1.286
4			1.5432
5			1.6108
6			1.9113
7			1.9281
8			1.8143
9	1.6766	1.5927	1.8519
10	.3467	.4334	.4382
24			.3856
Max	1.6766	1.5927	1.9281
Min	.3467	.4334	.3856
Avg	1.0117	1.0131	1.2972



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324092 / 33 kV WAI CHOUNDI

Feeder No / Name : 203 / 11 KV MARSOOL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0248		.2481	
2				.2481	
3				.2481	
4				.2629	
5				.3155	
10	.9088		.4854	.6001	
11			.9088	.9259	
12			.9945		
13			.9945		
14			.9665		
15			1.0174		
16			1.0343		.8002
24		.0229		.2454	
Max	.9088	.0248	1.0343	.9259	.8002
Min	.9088	.0229	.4854	.2454	.8002
Avg	.9088	.0239	.9145	.3868	.8002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324093 / 33/11 KV KAUTHA ROAD BASMATH

Feeder No / Name : 202 / 11 KV KUMBHARWADA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.5788	.6413	.5658	.6535		.6224
2	.5975	.5601	.5281	.5658	.6348		.6036
3	.7095	.5601	.5281	.5281	.7095		.6036
4	.7842	.6161	.6036	.6036	.8215		.6224
5	.8962	.6722	.7545	.6979	.8962		.7167
6	.9709	.7842	.793	.8307	.9335		.811
7	.9709	.9335	.8676	.9997	.9709		.9619
8	.9709	.9335		.9431	.8962		1.0374
9	.9335	.7842	.9431	.9431	.8029	.8962	.8676
10	.7733	.6722	.8029	.6535	.7922	.7922	.6908
11	.5281	.6348	.6722	.6348	.7545	.679	.6161
12	.5281	.5975	.6161	.6161	.7545	.6602	.5975
13	.547	.5788	.6908	.5975	.7167	.6413	.5975
14	.5281	.5601	.6348	.6161	.7167	.6413	.5788
15	.547	.5975	.6348	.6348	.679	.6036	.5788
16	.4904	.6722	.7655	.6908	.679	.6602	.6348
17	.7545	.7167	.8299	.7842		.7167	.6722
18	.7468	.8299	.9242	.9522		.9997	.9242
19	.8589	.9808	.9808	1.1016		.9808	.9997
20	.8215	.8676	.8676	.9709		.7545	.8676
21	.7468	***	.7733	.7842		.6979	.7545
22	.7095		.7167	.7282		.679	.7167
23	.6348	.7167	.6602	.7095		.6413	.6224
24	.6535	.5975	.6413	.6036	.6722		.6413
Max	.9709	11.713	.9808	1.1016	.9709	.9997	1.0374
Min	.4904	.5601	.5281	.5281	.6348	.6036	.5788
Avg	.7224	1.1808	.7335	.7398	.7696	.7363	.7225

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324093 / 33/11 KV KAUTHA ROAD BASMATH

Feeder No / Name : 203 / 11 KVKALNKAI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6632	1.6632	1.7002	1.6632	1.7372		1.7741
2	1.6263	1.6632	1.6078	1.6632	1.7002		1.7741
3	1.7372	1.6632	1.6632	1.6632	1.7556		1.7926
4	1.9404	1.8296	1.848	1.6632	1.8111		1.8296
5	2.0698	1.885	1.848	1.8111	1.8665		1.848
6	2.2177	2.1068	2.1012	2.1756	2.0698		2.1068
7	2.4025	2.2731	2.2177	2.2177	2.1992		2.3101
8	2.384	2.2916	2.4209	.2587	2.2177		2.32
9	2.1992	2.2177	2.4025	2.0698	2.1992	2.2546	2.2916
10	1.6632	1.9774	2.1807	1.8665	2.0144	2.1068	1.9404
11	1.6632	1.8111	1.9589	1.7556	1.8665	1.7926	1.7556
12	1.6632	1.6817	1.8111	1.5708	1.7556	1.7372	1.5893
13	1.6078	1.6448	1.7002	1.5893	1.7002	1.4969	1.5893
14	1.6078	1.6078	1.7556	1.6078	1.7002	1.7002	1.3491
15	1.7002	1.6817	1.7556	1.6263	1.7556	1.7556	1.1088
16	1.5154	1.7741	1.9035	1.7187	1.7741	1.8111	1.7926
17	1.848	1.9035	2.0328	1.9404		1.9589	2.0513
18	2.0144	2.1068	1.9774	2.2731		2.1437	2.0513
19	2.2546		2.1622	2.2916		2.4025	
20	1.9959	2.0144	2.0513	2.2361		2.1992	2.384
21	1.9589	2.0144	1.848	1.922		1.8296	2.1253
22	1.8665	2.0144	.7023	1.848		1.9774	2.0328
23	1.8111	1.8111	1.8111	1.8111		1.922	1.8665
24	1.7002	1.7002	1.7002	1.7741	1.7741		1.8296
Max	2.4025	2.2916	2.4209	2.2916	2.2177	2.4025	2.384
Min	1.5154	1.6078	.7023	.2587	1.7002	1.4969	1.1088
Avg	1.8796	1.8842	1.8817	1.7924	1.8763	1.9392	1.8919

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 324093 / 33/11 KV KAUTHA ROAD BASMATH

Feeder No / Name : 204 / 11 KV MOHGAON FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0602	.061	.061	.0762	.0753		.061
2	.5268	.4572	.6401	.4572	.6321		.8383
3	.6773	.7164	.7621	.4572	.7225		.8535
4	.8278	.8993	.9145	.4877	.8128		.8535
5	1.2041	1.0364	1.0669	.823	1.1288		.9145
6	1.2191	1.0974	1.1406	1.233	1.3245		.945
7	1.4449	1.3413	1.3717	1.6309	1.3847		1.5546
8	1.4449	1.5242	1.5546	1.6004	1.6105		1.5546
9	1.3998	1.448	1.5242	1.5242	1.5653	1.4022	1.2803
10	.061	.0753	.0903	.061	.0762	.061	.0762
11	.061	.0602	.0602	.0457	.061	.061	.0457
12	.061	.0452	.0602	.0457	.061	.061	.0305
13	.061	.0602	.0602	.0457	.061	.061	.0457
14	.061	.0753	.0602	.0457	.061	.061	.061
15	.0305	.0602	.0753	.0457	.061	.0914	.0457
16	.061	.0602	.0903	.061	.061	.0762	.061
17	.0762	.061	.1067	.0602		.0762	.061
18	.1067	.1219	.7164	.1054			.0762
19	.1372	.1372	.1372	.1355		.1372	.1219
20	.1067		.0762	.1054			.1219
21	.0914	.0914	.0762	.1054		.1067	.1219
22	.0762	.0762	.0762	.0903		.0762	.0762
23	.061	.0762	.0762	.0753		.061	.061
24	.0602	.061	.061	.0762	.0753		.061
Max	1.4449	1.5242	1.5546	1.6309	1.6105	1.4022	1.5546
Min	.0305	.0452	.0602	.0457	.061	.061	.0305
Avg	.4132	.4192	.4524	.3914	.5749	.1794	.4134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

BASMAT (R) S/DN.[451] BU 2364

Substation No/ Name :- 327007 / 132 KV Basmat

Feeder No / Name : 401 / 33KV Basmath

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	29.904	***	***	***	***	28.6009	***
2	28.6694	29.0124	29.1496	28.5323	28.8752	29.081	29.7668
3	***	***	29.9726	27.0234	29.6297	***	***
4	29.9726	***	28.8752	28.9438	29.8354	29.081	***
5	***	***	28.738	29.081	***	29.3553	***
6	***	***	***	***	***	***	***
7	***	***	***	***	***	***	***
8	***	***	***	***	***	***	***
9	***	***	***	***	***	***	***
10	***	***	***	***	***	***	***
11	***	***	***	***	***	***	28.6694
12	***	***	***	***	***	***	***
13	***	29.904	***	***	***	***	***
14	***	***	***	***	***	***	27.8464
15	***	***	***	***	***	***	23.3196
16	***	***	***	***	***	***	29.2181
17	***	***	***	***	***	***	***
18	***	***	***	***	***	***	***
19	***	***	***	***	10.631	***	***
20	***	***	***	***	23.8683	***	28.6009
21	***	***	***	***	23.7998	***	***
22	***	***	***	***	28.1208	***	26.8862
23	***	***	***	***	***	***	29.2181
24	***	***	***	***	28.0522	***	***
Max	40.9466	40.0549	40.8094	41.0151	43.7586	43.8272	41.5638
Min	28.6694	29.0124	28.738	27.0234	10.631	28.6009	23.3196
Avg	34.1193	34.2965	34.2507	34.3079	32.6475	35.2138	32.5360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324021 / 33KV ADGAON

Feeder No / Name : 201 / 11KV MALHIVRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6097			.6097			.6401
8		.5639	.6401		.3506		
10	.4572	.4572			.7926	.5335	
13		.2572					
16	.5182	.4572	.823		.381	.6097	.4115
18			.6249				
19						.6097	
20						.3658	
Max	.6097	.5639	.823	.6097	.7926	.6097	.6401
Min	.4572	.2572	.6249	.6097	.3506	.3658	.4115
Avg	.5284	.4339	.696	.6097	.5081	.5297	.5258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324021 / 33KV ADGAON

Feeder No / Name : 202 / 11KV AMBALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	1.0517			1.9814			1.0974
7							.4572
8	1.4937	1.2498	.945	.9297	.8993		
10	.8383	.5335			.884	.5792	
16	1.5546	.8993	1.5394		.8078	1.0059	1.2955
18			.884			1.0212	
Max	1.5546	1.2498	1.5394	1.9814	.8993	1.0212	1.2955
Min	.8383	.5335	.884	.9297	.8078	.5792	.4572
Avg	1.2346	.8942	1.1228	1.4556	.8637	.8688	.9500

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324021 / 33KV ADGAON

Feeder No / Name : 203 / 11KV BHINGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3048			.6097			.4268
7							1.0669
8	1.6766	1.2498	1.0059	1.0059	.884		
9							1.0059
10	1.7528	1.2193			.9145	1.0212	
12			.884			.884	
16	.3048	.3048	.4877		.3048		.3658
18			.3048				
19						.3048	
20						1.0822	
Max	1.7528	1.2498	1.0059	1.0059	.9145	1.0822	1.0669
Min	.3048	.3048	.3048	.6097	.3048	.3048	.3658
Avg	1.0098	.9246	.6706	.8078	.7011	.8231	.7164



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324032 / 33KV LIMBALA

Feeder No / Name : 201 / 11KV DIGRAS WATER WORKS NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 11 / OUTGOING UTILITY

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0934	.0934	.0943	.0934		.0953
2	.0943	.0934	.0934	.0953	.0934		.0038
3	.0943	.0934	.0934	.0943	.0934		.0038
4	.0943	.0934	.0934	.0943	.0934		.0943
5	.0943	.0934	.0934	.0943	.0934		.0943
6	.0943	.0934	.0934		.0934		.0943
7	.0943	.1867	.0934		.0934		.0943
8	.1867	.1867	.0934		.1867		.0943
9	.1867	.1867	.0934		.1867	.0934	.1867
10	.1867	.1867	.1867	.1867	.1867	.0934	.1867
11	.1886	.1867	.1867	.1867	.1867	.0943	.1867
12	.1886	.1867	.1848	.1867	.1867	.1867	.1867
13	.1867	.1867	.1848	.1886	.0934	.1867	.1867
14	.1867	.1867	.1867	.1867	.0934	.1867	.1867
15	.1867	.1867	.1867	.1867	.0934	.1867	.1867
16	.1867	.0934	.1867	.1867	.0934	.1867	.1867
17	.1867	.0934	.1867	.1867	.0934	.1867	.1867
18	.1867	.0934	.1867	.0934		.1867	.1867
19	.1867	.0934	.1867	.0934		.1886	.0943
20	.0934	.0934	.0934	.0934		.1886	.0934
21	.0934	.0934	.0934	.0934		.0943	.0943
22	.0934	.0934	.0943	.0934		.0943	.0934
23	.0934	.0934	.0943	.0934		.0943	.0934
24	.0943	.0934	.0934	.0943	.0934		.0943
Max	.1886	.1867	.1867	.1886	.1867	.1886	.1867
Min	.0934	.0934	.0934	.0934	.0934	.0934	.0038
Avg	.1405	.1284	.1322	.1311	.1193	.1499	.1252

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324032 / 33KV LIMBALA

Feeder No / Name : 203 / 11KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1886	.3734	.2772	.1886		.2772
2	.1867	.1886	.3734	.1848	.1886		.2772
3	.1867	.1886	.3658	.1867	.1886		.2743
4	.1867	.0038	.3734	.181	.1886		.2772
5	.1867	.1886	.3734	.1848	.1886		.2772
6	.1848	.1886	.3734	.1848	.1886		.1848
7	.1867	.1886	.3734	.2772	.1886		.1848
8	.1867	.3772	.2743	.2772	.1886		.2772
9	.2772	.3772	.1867	.1867	.3772	.4668	.462
10	.2829	.5487	.1848	.1867	.4572	.4572	.7545
11	.2829	.5601	.1829	.1886	.5601	.5487	.5658
12	.3772	.5601	.3658	.1886	.5601	.5487	.5658
13	.3772	.5601	.2743	.1886	.3734	.5487	.5658
14	.3772	.5601	.1829	.1867	.3734	.4572	.5658
15	.3772	.3734	.1829	.1886	.3658	.543	.5658
16	.3772	.3734	.1829	.1886	.3734	.5487	.5658
17		.1867	.1829	.1886	.4572	.5487	.5658
18		.2801	.181	.1886		.4572	.5658
19		.2801	.1848	.1886		.4572	.5658
20	.3772	.3734	.3696	.2829		.4477	.3772
21	.3772	.3734	.3658	.2829		.3658	.3772
22	.2829	.3658	.2772	.2829		.3658	.3772
23	.1886	.3734	.2772	.2829		.3696	.3772
24	.2772	.1886	.3734	.2772	.1886		.2772
Max	.3772	.5601	.3734	.2829	.5601	.5487	.7545
Min	.1848	.0038	.181	.181	.1886	.3658	.1848
Avg	.2726	.3270	.2848	.2180	.3108	.4754	.4219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324032 / 33KV LIMBALA

Feeder No / Name : 401 / 33 kV SHIVAPARVATI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0114	.0113	.0113	.0114	.0113		.0114
2	.0114	.0113	.0113	.0114	.0113		.0114
3	.0114	.0113	.0113	.0114	.0113		.0114
4	.0114	.0113	.0113	.0114	.0113		.0114
5	.0114	.0113	.0113	.0114	.0113		.0114
6	.0114	.0113	.0113	.0114	.0113		.0114
7	.0114	.0113	.0113	.0114	.0284		.0114
8	.0114	.0113	.0113	.0114	.3542		.0114
9	.0114	.0113	.0113	.0114	.3371	.0113	.0114
10	.0113	.0113	.0114	.0113	.3885	.0114	.0113
11	.0113	.0113	.0114	.0113	.4789	.0114	.0113
12	.0113	.0113	.0114	.0284	.4789	.3886	.0113
13	.0113	.0113	.0114	.0113	.4789	.3886	.0113
14	.0113	.0113	.0114	.0113	.3714	.0114	.0113
15	.0113	.0113	.0114	.0113	.0113	.0114	.0113
16	.0113	.0113	.1143	.0113	.1828	.0114	.0113
17	.0113	.0113	.32	.0113	.0113	.0114	.0113
18	.0113	.0113	.0114	.0113		.0114	.0113
19	.0113	.0113	.0114	.0113		.0114	.0113
20	.0113	.0113	.0114	.0113	.3601	.0114	.0627
21	.0113	.0113	.0114	.0113		.0114	.0113
22	.0113	.0113	.0114	.0113		.0114	.0113
23	.0113	.0113	.0114	.0113		.0114	.0113
24	.0114	.0113	.0113	.0114	.0113		.0114
Max	.0114	.0113	.32	.0284	.4789	.3886	.0627
Min	.0113	.0113	.0113	.0113	.0113	.0113	.0113
Avg	.0113	.0113	.0285	.0121	.1874	.0617	.0135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 201 / 11KV PAHENI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10			.8573	1.0288	1.2003	1.2003	1.2003
11	1.0288	1.3717	1.3717	1.2003	1.3717	1.2003	1.2003
12	1.3717	1.0288	1.3717	1.3717	1.3717	1.2003	
13	1.3717	1.0288		1.2003	1.3717	1.2003	
14	1.3717	1.0288	.3772	1.2003	1.3717	1.2003	.6859
15	1.0288	.3429	.4287	1.0288	1.2003	1.2003	.6859
16	.8573	1.0288		1.2003	1.2003	1.2003	.6859
17	1.2003		.4801	1.2003		1.2003	
18	1.2003		.6001				
19			.6859				
Max	1.3717	1.3717	1.3717	1.3717	1.3717	1.2003	1.2003
Min	.8573	.3429	.3772	1.0288	1.2003	1.2003	.6859
Avg	1.1788	.9716	.7716	1.1789	1.2982	1.2003	.8917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 202 / 11KV GHOTA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.5144		.3429
3	.4801	.4287		.5144		.3429
4	.5144			.5144		.3429
5	.5144			.5144		.3429
6	.5144	.5144		.5144		.5144
7	.8573			.5144	.4287	.5144
8		.6859		.6859	.5144	
9	.8573	.6859			.5144	.5144
10		.6859	.8573			
11			.5144	.6859		
12			.5144	.6859		
13			.5144			
14			.5144			
15			.3429			
Max	.8573	.6859	.8573	.6859	.5144	.5144
Min	.4801	.4287	.3429	.5144	.4287	.3429
Avg	.6230	.6002	.5430	.5716	.4858	.4164

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 203 / 11 KV PAHENI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.3429	.4287	.3429		.3429
2	.3772		.4287	.5144	.3429		.5144
3	.5144		.6001	.6001	.5144		.5144
4	.6001		.7202	.8573	.5144		.3429
5	.7716		.9431	.9431	.5144		.5144
6	.8745		1.0288	1.0288	.6859		.6859
7	.6859			1.0288	.8573	.8573	.8573
8			.6859		.6859	.8573	.8573
9	.5144		.5144	.3429	.5144	.6859	.6859
10	.1715		.5144	.3429	.3429	.3429	.3429
11	.1715	.3429	.3429	.3429	.3429	.3429	.3429
12	.1715	.3429	.3429	.3429	.3429	.3429	
13	.1715	.3429	.3429	.3429	.3429	.3429	
14	.3429	.3429		.3429	.5144	.3429	.3429
15	.3429			.3429	.5144	.5144	.3429
16	.3429			.3429	.5144	.5144	.3429
17	.3429			.5144	.5144	.5144	.8573
18	.5144			.5144			.5144
19	.5144			.6859	.5144	.5144	.5144
20	.5144		.3429	.6859		.5144	.6859
21	.5144	.4287	.3429	.5144		.5144	.6859
22	.5144	.3429		.3429		.5144	.5144
23	.5144			.3429		.3429	.4287
24					.3429		.3429
Max	.8745	.4287	1.0288	1.0288	.8573	.8573	.8573
Min	.1715	.3429	.3429	.3429	.3429	.3429	.3429
Avg	.4466	.3572	.5352	.5339	.4873	.5037	.5261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 204 / 11 kV GHOTA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.8562	.8996	.8509	.3849	.8535
2	.4801		.8859	.9499	.8478	.3768	.8653
3	.4801		.9297	.9953	.8482	.3593	.8939
4	.4973		.988	.3532	.8623	.3692	.9084
5			1.1161	1.1066	.9099	.4481	1.0662
6			1.3737	1.3436	1.2681	.6398	1.2258
7			.6626	1.4354	1.3436	1.2266	1.4148
8			1.132	1.2304	1.1431	1.0745	.6432
9	.4801		.9469	1.0963	.8676	.9617	1.1268
10			.658	1.0688	.9777	.9171	.8733
11	.4801	.0446	.3384	.9191	.9008	.3978	.4344
12	.4458	.4115	.6752	.7358	.7941	.7804	.8177
13	.4458	.3772	.3559	.8851	.7723	.9789	.3307
14	.4458	.3772	.5983	.8939	.7861	.9835	.8108
15	.4801		.8409	.8383	.7609	.9431	.8775
16	.5144	.3429	.3639	.9179	.7525	1.0528	.8562
17	.5144		.1673	.0453	.8604	1.1382	.9583
18	.583		.5148	.9012	.9335	.5316	1.1233
19	.5144		.8485	.9343	.3841	1.1401	1.0921
20	.5487		.9039	1.033	.3075	1.0757	1.2178
21	.5487	.5144	.8535	1.0635	.458	1.0837	1.2434
22	.5144	.5144	.4717	.9709	.4611	1.012	1.004
23	.5144		.4043	.9088	.4363	.911	.8677
24			.3776	.3456	.9156	.4191	.8158
Max	.583	.5144	1.3737	1.4354	1.3436	1.2266	1.4148
Min	.4458	.0446	.1673	.0453	.3075	.3593	.3307
Avg	.5001	.3689	.7193	.9113	.8101	.8002	.9300

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324035 / 33KV NARSI(N)

Feeder No / Name : 206 / SANT NAMDEO FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915		.3429	.3429	.3086		.2572
2	.3086		.3601	.3429	.3086		.2401
3	.3258		.3601	.3772	.3086		.2401
4	.3258		.3772	.3772	.3429		.2401
5	.3429		.3772	.3944	.3258		.3429
6			.3944	.3944			.3772
8			.2915				
9	.3258		.2915	.3429		.3258	.2743
10	.3429	.3429	.2915	.1886	.3601	.2743	.2572
11	.2229	.2915	.2915	.2743	.2743	.2743	.2572
12	.2572	.2915	.2743	.2572	.2572	.2572	
13	.2572	.2572	.2743	.2572	.2743	.2572	
14	.2401	.2401	.2743	.2572	.2401	.2572	.2401
15	.2572		.2915	.2743	.2401	.2743	.5487
16	.3086			.3086	.2401	.2915	.2743
17	.3429		.3258	.3429	.2743	.2915	.3086
18	.3429		.3258	.3086	.2743		.3086
19	.3772		.3258	.2743		.3086	.3086
20	.3772			.3086		.3429	.3772
21	.3429	.3772	.3429	.3429		.2743	.3772
22	.3429	.3429		.3429		.2743	.3429
23	.3429			.3429		.2743	.3258
24					.3429		.2572
Max	.3772	.3772	.3944	.3944	.3601	.3429	.5487
Min	.2229	.2401	.2743	.1886	.2401	.2572	.2401
Avg	.3138	.3062	.3229	.3168	.2915	.2841	.3078



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324067 / 33 KV PEDGAON

Feeder No / Name : 201 / 11 KV SIRSAM BK AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	14-MAY-17
HR	Load (MW)
19	.4066
20	.4435
21	.4066
Max	.4435
Min	.4066
Avg	.4189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324067 / 33 KV PEDGAON

Feeder No / Name : 203 / 11 KV LIMBI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0934	.112		.1097
2	.168					.168	.1463
3	.1494						.1646
4	.1494						.168
5	.168						.1829
6	.1494		.168	.1494	.1867	.168	.1829
7	.168						.2195
8	.1494		.1494	.1494	.2241	.1867	.2012
9	.1494				.2241	.1867	.1848
15	.112				.0686		.0914
16	.0934		.0934	.0747	.112		.1097
17	.0747					.0934	.0924
18	.0934			.0934	.0934	.1097	.0732
19	.112		.0934	.0934		.1097	.0732
20	.0112					.0914	.0914
21	.0924				.0934	.128	.0914
22	.0924					.0914	.0914
23	.1109		.0934	.112	.0934	.1097	.0914
24	.0934	.0739	.168	.0934	.1307	.112	.1097
Max	.168	.0739	.168	.1494	.2241	.1867	.2195
Min	.0112	.0739	.0934	.0747	.0686	.0914	.0732
Avg	.1187	.0739	.1276	.1074	.1338	.1296	.1303

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324067 / 33 KV PEDGAON

Feeder No / Name : 205 / 11 KV PEDGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3045	.3361	.2987	.3547	.3734	.462
2	.2987	.3077	.3361	.3174	.3361	.3921	.462
3	.3361	.2926	.3547	.3361	.3361	.3734	.4435
4	.3361	.3142	.3547	.3361	.3921	.3734	.499
5	.4108	.3881	.4108	.3174	.3921	.4481	.462
6	.4294	.4251	.3921	.3921	.4108	.4668	.499
7		.3696					
12	.2614	.2241	.2241	.2427		.2614	.2218
13	.2241	.2218	.2241	.2241		.2614	.2401
14	.2241	.1848	.2241	.2241		.2801	.2587
15	.2054	.2033	.2427	.2241		.2427	.2402
16	.2054	.1848	.2241	.1867	.2614	.2054	.2402
19	.3511	.4066	.3921	.3547	.4108	.3734	.4108
20	.3881	.4066	.4108	.4108	.4481	.4481	.4435
21	.3881	.3511	.3547	.3734	.4481	.3881	.4066
22	.3142	.3361	1.587	.3734	.3734	.4251	.4251
23	.2772	.3361	.3361	.3547	.3174	.4435	.4066
24	.2987	.2629	.3174	.3174	.3547	.3547	.4668
Max	.4294	.4251	1.587	.4108	.4481	.4668	.499
Min	.2054	.1848	.2241	.1867	.2614	.2054	.2218
Avg	.3098	.3067	.3954	.3108	.3720	.3595	.3875

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324067 / 33 KV PEDGAON

Feeder No / Name : 206 / 11 KV PARDA BASAMBA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.0082	.7499	.4668	.7468	.8962	1.0642	.924
11	1.0269	.7762	.4668	.7842	.8962	1.0456	.9425
12	1.0082	.7392	.4854	.9149	.9335	.9335	.9055
13	.9149	.7392	.8589	.9896		.9709	.9425
14	.8962	.7577	.8962	1.0642	.9522	.9335	.9425
15	.6535	.7762	.7842	.9149	.9335	.9149	.8686
16	.7282	.4024	.5975	.8962	.7468	.8962	.6468
17	.2801		.5601	.8775	.9522	.9149	.6653
Max	1.0269	.7762	.8962	1.0642	.9522	1.0642	.9425
Min	.2801	.4024	.4668	.7468	.7468	.8962	.6468
Avg	.8145	.7058	.6395	.8985	.9015	.9592	.8547

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324071 / 33KV KHATKALI

Feeder No / Name : 203 / 11KV KHOTHLAJ

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.9907	.9717	.9907	1.0155	.9602
10	1.0364	.9145	.9145	1.0279	.8907
11	1.0802	.9602	.884		.9061
12	1.0494	.9783	.884		
13	.9907	.945	.8278		.8383
14	.9907	.9259	.8128		.7526
15		.9907			.7621
16		1.0669			.7621
Max	1.0802	1.0669	.9907	1.0279	.9602
Min	.9907	.9145	.8128	1.0155	.7526
Avg	1.0230	.9692	.8856	1.0217	.8389

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324071 / 33KV KHATKALI

Feeder No / Name : 204 / 11KV SRP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.9955	1.0387	.9955	.9774	.905
10	.8954	1.0517	.8859	.905	
11	.9745	.8764	.8059	1.0279	
12	.9745	.7011	.7164		
13	.9114	.7522	.5373		.9745
14	.8764	.8059	.5373		.8859
15		.8596			.8954
16		.8954			.8954
Max	.9955	1.0517	.9955	1.0279	.9745
Min	.8764	.7011	.5373	.905	.8859
Avg	.9380	.8726	.7464	.9701	.9112

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324071 / 33KV KHATKALI

Feeder No / Name : 206 / 11 KV Bus Stand

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	2.2546		2.1491	2.2405	2.1253
10	2.0119	1.848	1.829	2.0328	2.0328
11	1.9204	1.7556	1.7924		1.9204
12	1.829	1.6632	1.7556		1.7924
13	1.7375	1.5708	1.7375		1.6632
14	1.6118	1.4784	1.6827		1.5708
15		1.4784			1.5524
16		1.4632			1.5708
Max	2.2546	1.848	2.1491	2.2405	2.1253
Min	1.6118	1.4632	1.6827	2.0328	1.5524
Avg	1.8942	1.6082	1.8244	2.1367	1.7785

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324071 / 33KV KHATKALI

Feeder No / Name : 207 / NEW NAIK NAGAR

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5517	.5487	.6059	.5243	.5243	.5426	.5502
2	.5251	.5182	.5121	.5022	.49	.5258	.5197
3	.5159	.5007	.4969	.487	.4771	.5075	.4999
4	.4854	.4771	.4885	.4725	.471	.4923	.4885
5	.4771	.4717	.4687	.4611	.4557	.4755	.487
6	.4931	.4954	.4702	.4656	.4542	.4946	.4786
7	.5007	.4999	.4733	.4771	.4992	.4946	.4862
8	.4824	.5205	.4847	.4672	.5144	.4908	.4778
9	.9448	.5091	.9326	.9585	.9686	.9577	.4748
10	.9313	.5068	.8288	.9219	.8616	.9614	.4512
11	.9127	.4649	.7758	.9099	.3917	.9493	.4115
12	.9173	.4656	.7792	.8662	.3803	.7788	.4245
13	.9242	.4191	.7697	.8692	.4161	.8288	.442
14	.9539	.4351	.8169	.8959	.5228	.8463	.4512
15	.4809	.4633	.9016	.4763	.5754	.8692	.455
16	.4748	.4755	.9524	.4672	.4755	.9206	.4694
17	.4473	.4367	.4801	.458	.4626	.5037	.4915
18	.4298	.4207	.4458	.4793	.4336	.5129	.5068
19	.2812	.4077	.4496	.4641	.4595	.5045	.4588
20	.346	.4786	.4999	.487	.4984	.5197	.5266
21	.6287	.4992	.5136	.5197	.5235	.5243	.5502
22	.5761	.5014	.5357	.5335	.5213	.5434	.5327
23	.6173	.5426	.5799	.5632	.5754	.5807	.5586
24	.5754	.5693	.5517	.5426	.5578	.5693	.5952
Max	.9539	.5693	.9524	.9585	.9686	.9614	.5952
Min	.2812	.4077	.4458	.458	.3803	.4755	.4115
Avg	.6030	.4845	.6172	.5946	.5213	.6414	.4912



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324076 / 33 KV PANGRI

Feeder No / Name : 204 / 11 kV PANGARI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6478	.724	.6859	.5335	.6859
2	.6478	.6859	.6478	.724	.6478	.5335	.6859
3	.6478	.6478	.6478	.6859	.6478	.5335	.724
4	.6859	.6478	.6859	.724	.6859	.5335	.0381
5	.8002	.7621	.8002	.8383	.8383	.724	
6	1.1812	1.0669	1.1812	1.0669	1.105	.9907	
7	1.0669	1.0669	1.105	1.0669	1.0288	.8764	
8	.724	.6859	.6859	.6097	.6859	.6478	.8383
9	.6097	.3048	.5716		.5716	.4954	.724
10	.5335	.381	.4954	.5716	.5335	.381	.5716
11	.3429	.3048	.4572	.5335	.5335	.4954	.4572
12	.4954	.4572	.4572	.5335	.4954	.4572	.5335
13	.4954	.4954	.4572	.4954	.4954	.4954	.5335
14	.4954	.4954	.4572	.4954	.5335	.4954	.4954
15	.4954	.4572	.4954	.4954	.5716	.4954	.2667
16	.5335	.0381	.4572	.5335	.381	.5335	.4954
17	.5335		.4191	.6097		.6097	.5716
18	.6097		.6478	.6478	.3048	.724	.6478
19	.6859	.4572	.724	.6859	.724	.8002	.7621
20	.8002	.8002	.8764	.8383	.8764	.8764	.8764
21	.8002	.6478	.8383	.8764	.8002	.8383	.8764
22	.8002	.7621	.8002	.8383	.8002	.8002	.8002
23	.724	.6859	.8002	.8002	.5716	.7621	.7621
24	.724	.6859	.7621	.7621	.5716	.724	.724
Max	1.1812	1.0669	1.1812	1.0669	1.105	.9907	.8764
Min	.3429	.0381	.4191	.4954	.3048	.381	.0381
Avg	.6716	.6010	.6716	.7025	.6561	.6399	.6224

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324077 / 33 KV KHANAPUR CHITTA

Feeder No / Name : 201 / 11 KV KHANAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.4801	.4973	.5658	.7733		.6173
2	.5731	.5487	.5316	.5281	.7545		.5316
3	.591	.5658	.5658	.7545	.7356		.583
4	.6268	.583	.583	.7922	.7733		
5	.6697	.4115	.4801	.8299	.8299		.823
6	.6878	.5487	.5316	.8676	.8488		.8745
7	.5668						
13	.3601	.583	.4527	.3018	.5658	.5316	.3395
14	.4115		.4904	.3772	.583	.6516	.3772
15	.3772	.3601	.5281	.4527	.6001	.7545	.4527
16	.4287	.4115	.679	.4527	.6516	.703	.5658
17	.823		.6668	.679	1.0631	1.1488	.8002
18	.7202	.8745	.7468	.7545	1.0974	1.0974	.8269
19			.6668	.8488		1.0802	.8135
20	.6859	.9259	.6401	.9054			.7468
21	.703		.6135	.5697			.7202
22	.6516	.8745	.5868	.5441		.8745	.6668
23	.703	.9259	.5868	.5959			.6401
24	.5014	.6859	.9945	.5868	.5571		.8916
Max	.823	.9259	.9945	.9054	1.0974	1.1488	.8916
Min	.3601	.3601	.4527	.3018	.5571	.5316	.3395
Avg	.5899	.6271	.6023	.6337	.7564	.8552	.6630

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324077 / 33 KV KHANAPUR CHITTA

Feeder No / Name : 202 / 11 KV HINGANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.6173	.6516	.4954	.5182	.6859
2	.7068	.583	.583	.4923	.5441	.6173
3	.6573	.703	.6344	.4664	.57	.6516
4	.7362	.6516	.7545	.5053	.583	
5	.6573	.6859	.8402	.5959	.5959	1.046
6	.6836	1.0974	1.0631	.6219	.8669	1.1831
7	.8002	1.0631	1.3375	.8421	.9412	1.0974
8	.815	.9259	1.1488	.9328	1.2437	1.0288
Max	.815	1.0974	1.3375	.9328	1.2437	1.1831
Min	.6573	.583	.583	.4664	.5182	.6173
Avg	.7161	.7909	.8766	.6190	.7329	.9014

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324077 / 33 KV KHANAPUR CHITTA

Feeder No / Name : 203 / 11 KV ISAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.6859	.6859	.7167	.7167		.703
2	.823	.7202	.7888	.679	.679		.6859
3	.8779	.7888	.7716	.8299	.7922		.7202
4	.9511	.8402	.8573	.8676	.8676		
5	1.1523	1.0288	.8745	.9431	1.0562		.9945
6	.6878		1.0117	.9808	1.094		.9945
9	1.0802	.9945	.8939	.8916	.8535	1.2346	.881
10	.9431	.9259	.9869	.8935	.9069	1.166	.8135
11	.823	.9945		.7659	1.0974	1.2003	.7068
12	.7888	1.046		.7404	1.0288		.6668
13	.7545	1.0631	.6935	.6893	1.0631	1.1488	.6535
14	.8059		.6668		.9774	.7202	.6401
15	.823	.9945	.7202	.6382	.9602	.9774	.6668
16	.7545	.9088	.8002	.6893	1.166	1.0974	.8535
17	.5144		.7545				
18	.5487		.9054				
19	.823		.9808	1.0562		.823	.7545
20	.8916	.8059	.9431				.8676
21			.9054	.9054			.9054
22	.7888		.9054	.8676		.703	.8488
23	.7202	.7545	.7922	.8299			.811
24	1.0822	.703	.7202	.7922	.7356		.7545
Max	1.1523	1.0631	1.0117	1.0562	1.166	1.2346	.9945
Min	.5144	.6859	.6668	.6382	.679	.703	.6401
Avg	.8295	.8836	.8329	.8209	.9330	1.0079	.7854

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324077 / 33 KV KHANAPUR CHITTA

Feeder No / Name : 204 / 11 KV KHANAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.4801	.5144	.543	.5068		.5144
2	.6697	.5487	.4801	.5792	.5611		.5144
3	.724	.703	.4801	.6878	.6154		.5658
4	.7964	.7888	.5658	.724	.7059		
5	.905	.8573	.703	.8507	.8507		
6	1.0136	.9945	.8059	.8869	.8326		
9			.5611				
10	.7716		.6447	.6516	.6154	.583	
11	.5487	.583	.5792	.6335	.5487	.5144	.7059
12	.5144	.5316	.6154	.6154	.5144	.583	.6516
13	.4973		.6154	.543	.5144	.5316	.5792
14	.4801	.583	.5792	.543	.5487	.6001	.543
15	.463	.5316	.543	.543	.5144	.6516	.5068
18							.5249
19	.7888	.583	.5792	.6516		.6859	.8326
20	.7545		.7059				1.0679
21	.6344		.6516	.6878			1.0317
22	.6173	.5658	.6154	.6154		.6516	.8145
23	.5487	.5144	.5792	.543		.6001	.7059
24	.6335	.4801	.5658	.543	.543		.5316
Max	1.0136	.9945	.8059	.8869	.8507	.6859	1.0679
Min	.463	.4801	.4801	.543	.5068	.5144	.5068
Avg	.6633	.6246	.5992	.6378	.6055	.6001	.6727

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324081 / 33 KV YASHWANT NAGAR

HINGOLI

Feeder No / Name : 201 / 11 kv TOWN-2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7456	3.8313	3.6208	3.6504	3.496	1.9662	3.7494
2	3.5037	3.6466	3.4483	3.5589	3.4312	1.909	3.6808
3	3.316	3.4617	3.3416	3.3608	3.2464	1.7947	3.5779
4	3.2436	3.3893	3.4188	3.2617	3.3245	1.7071	3.4398
5	3.3094	3.4446	3.4036	3.216	3.3951	1.669	3.413
6	3.5779	3.5361	3.4178	3.2655	3.5208	1.7528	3.6685
7	3.6503	3.4789	3.5379	3.2122	3.5818	1.8176	3.6808
8	3.4025	3.3608	3.5522	3.3169	3.496	1.8861	3.7389
9	3.3852	3.5036	3.2598	3.3112	3.5141	1.989	3.7018
10	3.2663	3.4569	3.4446	3.2541	3.353	1.8442	3.7208
11	3.2827	3.4265	3.4084	3.2902	3.5455	1.8252	3.5379
12	3.3018	1.7871	3.2807	3.4417	1.8519	1.6766	3.4065
13	3.4093	3.8895	3.1607	3.5341	3.8411	1.7109	3.1303
14	3.4569	3.617	3.216	3.4655	3.8037	.804	3.2941
15	3.5217	3.5913	3.2045	3.4084	3.7246	2.0195	3.3741
16	3.6751	3.3748	3.3245	3.5513	3.3588	3.6808	3.4827
17	3.6847	3.0966	1.7109	1.8138	2.0805	3.6732	3.5351
18	3.6085	3.1217	2.4388	3.4293	1.9662	3.8304	3.6732
19	3.7189	1.6347	3.9391	3.978	1.8747	3.9173	3.757
20	4.0047	4.1573	4.0409	4.1095	2.0386	4.0333	3.8847
21	3.738	4.0038	3.9314	4.039	1.989	3.9619	3.8839
22	3.8408	3.9117	3.8667	3.8656	1.9814	3.9048	3.8781
23	3.9933	3.9744	3.8789	3.8504	2.0424	3.9914	3.8913
24	3.981	3.9056	3.8647	3.858	3.7418	2.0614	3.2912
Max	4.0047	4.1573	4.0409	4.1095	3.8411	4.0333	3.8913
Min	3.2436	1.6347	1.7109	1.8138	1.8519	.804	3.1303
Avg	3.5674	3.4417	3.4047	3.4601	3.0083	2.4761	3.5997

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324081 / 33 KV YASHWANT NAGAR

HINGOLI

Feeder No / Name : 202 / 11 kv TOWN-1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8447	3.9418	3.7254	3.6294	3.7284	1.9776	3.7731
2	3.6138	3.7418	3.418	3.4179	3.5951	1.8557	3.7236
3	3.4088	3.5874	3.332	3.3836	3.4332	1.8099	3.5033
4	3.2343	3.5341	3.3983	3.2065	3.3874	1.7375	3.3707
5	3.2983	3.5627	3.277	3.1569	3.357	1.6804	3.3097
6	3.3966	3.515	3.2542	3.0483	3.3303	1.6766	3.2754
7	3.2983	3.4122	3.258	3.1265	3.195	1.688	3.416
8	3.2335	3.2636	3.4548	3.0064	3.1245	1.6728	3.2281
9	3.4645	3.2183	3.2865	3.014	3.364	3.1436	3.1398
10	3.6237	3.3173	3.4675	3.096	3.3869	3.2541	3.2827
11	3.9917	3.4576	3.7437	3.4065	1.7871	2.1338	3.496
12	4.1175	3.719	3.9132	3.6415	4.0097	2.2215	3.3741
13	4.2806	3.9163	3.8275	3.9	4.0745	2.1072	3.4408
14	4.2882	3.9734	3.3341	3.8447	4.0821	2.1948	3.6245
15	4.3263	3.8905	4.0066	3.8295	4.1691	2.0881	3.656
16	4.3073	3.7579	3.8028	3.7533	4.2606	4.1785	3.7647
17	3.9838	3.7038	3.6307	3.7609	2.2024	4.018	3.8657
18	3.9971	3.2396	1.8595	3.8466	3.8428	3.8066	3.7693
19	3.9971	3.8885	3.8428	3.9609	2.0424	3.9799	3.7312
20	4.2753	4.3638	4.292	4.2028	2.2405	4.3229	3.9667
21	4.3438	4.2945	4.1868	3.9933	2.2138	4.0847	4.0763
22	4.3438	4.0839	4.0974	3.938	2.0957	3.8647	4.0457
23	4.3172	4.0268	3.9228	4.0847	2.1414	4.099	4.2124
24	4.1678	3.9437	3.9095	3.9324	3.8066	2.1834	4.0847
Max	4.3438	4.3638	4.292	4.2028	4.2606	4.3229	4.2124
Min	3.2335	3.2183	1.8595	3.0064	1.7871	1.6728	3.1398
Avg	3.8814	3.7231	3.5934	3.5909	3.2029	2.7408	3.6304

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324081 / 33 KV YASHWANT NAGAR

HINGOLI

Feeder No / Name : 203 / 11 kv GOREGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5525				
2	.6355		.5525	.6097	.8498	.0914	.6419
3	1.3561	.0953	1.2407	1.2727	1.2918	.6973	1.3735
4	1.4289		1.3629	1.3108	1.3261	.6592	1.3506
5	1.4594		1.3667	1.3984	1.4289	.6706	1.3011
6	1.6427		1.6026	1.4289	1.5547	.7659	1.4539
7	1.9635	.9907	1.9841	1.749	2.1948	.9831	1.8734
8	2.1278	2.0881	2.1721	2.1262	2.3586	1.0898	2.1175
9	2.2078	2.0401	2.4005	2.191	1.3413	1.0707	2.2176
10	1.2765	1.2727	1.3184	1.1584	2.3963	1.1241	1.1736
11		.1829	.0267	.3429	1.0631	.0152	.1105
17			.6897				
24			.5525				
Max	2.2078	2.0881	2.4005	2.191	2.3963	1.1241	2.2176
Min	.6355	.0953	.0267	.3429	.8498	.0152	.1105
Avg	1.5665	1.1116	1.2171	1.3588	1.5805	.7167	1.3614



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324081 / 33 KV YASHWANT NAGAR

HINGOLI

Feeder No / Name : 204 / 11 KV LOHGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.3875	.2469	.3429		.1303		.2286
11	1.0342	.7468	.5677		.6725	.3734	.7278
12	1.0304	.7849	.8421		.5144	.5182	.6592
13	.905	.666	.7925		.522	.5258	.6135
14	.8297	.612	.7697		.522	.5068	.5433
15	.8335	.6279	.7239	.7164	.503	.4801	.5792
16	.8335	.7392	.9297	1.2079	.4382	.7745	.6477
17	1.0859	.7225	.5792	1.1355	.522	.8184	.7545
18	.6363	.0876	.3353	1.0326	.4649	.6516	.4992
19				.9335	.4477	.3239	.0229
20				.7849			
21				.4153			
Max	1.0859	.7849	.9297	1.2079	.6725	.8184	.7545
Min	.3875	.0876	.3353	.4153	.1303	.3239	.0229
Avg	.8418	.5815	.6537	.8894	.4737	.5525	.5276

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324081 / 33 KV YASHWANT NAGAR

HINGOLI

Feeder No / Name : 205 / 11 kv TOWN-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	6.0802	5.9564	5.833	5.7747	3.1337	6.0601
2	5.8205	5.8299	5.8558	5.6223	5.535	3.0026	5.7751
3	***	5.6543	5.5861	5.4694	5.4481	2.8974	5.6806
4	***	5.572	5.6943	5.3932	5.4988	2.8197	5.6836
5	5.9733	5.8383	4.6197	5.6398	5.6687	2.8502	6.3939
6	***	6.5028	6.3969	6.2358	6.0014	3.152	6.5935
7	***	6.9376	6.7962	6.84	6.4865	3.501	7.0599
8	7.0212	6.9909	6.6743	6.8382	3.5513	3.5757	6.8907
9	***	6.6775	6.2499	6.5733	5.4584	3.4873	6.2555
10	***	6.1055	5.7407	6.0201	6.6971	3.2404	5.9747
11	5.5873	5.4318	5.2862	5.6203	6.2128	2.9371	5.6859
12	***	5.0811	5.0461	5.49	6.0064	2.6795	5.4923
13	***	4.9371	4.9399	5.2812	5.7308	2.7298	5.2801
14	5.1532	5.0003	4.9764	5.2134	5.5736	2.8075	5.5251
15	***	4.9088	5.085	5.17	5.6805	2.7724	5.2527
16	5.4837	4.8631	5.4413	5.2713	5.267	5.711	5.5403
17	5.6836	4.412	5.6668	5.5876	2.4341	5.9229	6.0067
18	5.9603	5.0747	4.42	5.8135	2.9218	6.1715	6.2232
19	6.1942	5.6791	3.3181	5.9621	3.0422	6.9456	6.7078
20	6.5173	6.1293	5.9533	5.2851	3.3242	6.9959	7.2398
21	6.5356	6.3466	7.3053	6.5443	3.4979	7.2809	7.2413
22	6.4563	6.2908	7.1391	6.7154	3.4766	3.5086	7.1407
23	6.4792	6.2659	6.4926	6.3767	3.4858	6.6834	6.8145
24	6.5007	3.1504	6.214	6.1382	6.0555	3.3425	6.4319
Max	103.3645	6.9909	7.3053	6.84	6.6971	7.2809	7.2413
Min	5.1532	3.1504	3.3181	5.17	2.4341	2.6795	5.2527
Avg	46.3927	5.6567	5.7023	5.8723	4.9512	4.0895	6.2062

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324084 / 33 kV LOHGAON

Feeder No / Name : 201 / 11 kV LOHGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.463		.4801
2					.463		.4801
3					.463		.4801
4					.4801		.4801
5					.4973		.5144
6					.5144		.7202
9	.3048		.4268	.5182	.4287	.6001	.5144
10					.3772	.463	.4287
11					.3086	.3601	.3772
12					.2915	.3601	.3601
13					.2915	.3601	.3258
14					.3086	.3601	.3258
15					.3086	.4115	.3429
16			.3963	.3429	.3258	.4287	.3429
17				.3772		.5144	.4458
18				.5487		.6001	.5487
19				.6001		.583	.6001
20						.5487	.5487
21				.6001		.5487	.5487
22				.5487		.5316	.5144
23				.5144		.5144	.4973
24	.3658	.3658	.4115	.4877	.463		.4973
Max	.3658	.3658	.4268	.6001	.5144	.6001	.7202
Min	.3048	.3658	.3963	.3429	.2915	.3601	.3258
Avg	.3353	.3658	.4115	.5042	.3990	.4790	.4715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

HINGOLI (R) S/DN[454] BU 2381

Substation No/ Name :- 324084 / 33 kV LOHGAON

Feeder No / Name : 202 / 11 KV BHOSHI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4572	.5182	.4268	.4268	.5658		.6001
3	.4572	.5792	.4572	.5182	.5487		.6344
4	.5792	.6401	.5182	.5487	.6001		.6687
5	.6401	.7468	.5792	.6554	.7716		.823
6		.8383	.6249	.8383	.8916		.823
7	.7926	.884	.5335	.9145	.9431		.8916
8	.7773	.9145	.5792	.9907	.8916		.9774
9	.823		.6097	.9907	.2743	.7716	.9945
10	.8993			.7621	.8573	.8916	.9431
11	.823		.9145		.8916	.9088	.8916
12			1.1279		.9259	.8573	.8916
13	.7773		1.0364		.8573	.823	.823
14	.7773		.7926		.7716	.823	.8573
15	.7773		.6097		.7373	.8573	.9259
16			.5335	.9945	.7202	.8916	.823
17	.4572		.4877	1.0631		.823	.6859
Max	.8993	.9145	1.1279	1.0631	.9431	.9088	.9945
Min	.4572	.5182	.4268	.4268	.2743	.7716	.6001
Avg	.6952	.7316	.6554	.7912	.7499	.8497	.8284

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324015 / 33/11 KV WARANGA

Feeder No / Name : 201 / 11 KV WARANGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				1.1431			
6		1.9052	1.5242	1.6194			1.5242
7	2.0005		1.4289	2.0957	2.0005		1.4289
8	1.7147	1.7147	2.0005	2.0957	2.191		
9	1.7147	1.6194	1.8099	1.8099	2.0957	1.1431	1.1431
10	.8573	.7621	.9526	.9526	.8573	.9526	1.0479
11			.8573	.7621	.7621		.7621
12	.7621		.8573	.7621	.7621	.7621	.7621
13	.7621		.8573	.8573	.7621	.8573	.8573
14			.8573	.7621	.7621		.8573
15			.7621		.7621	.9526	
16			.7621	.8573	.8573		1.1431
17	.9526		1.0479				1.1431
18			1.0479				1.1431
19	1.5242					1.5242	1.8099
20	1.5242			1.5242			
21	1.4289					1.5242	
22	1.4289						
23				1.3336		1.0479	
Max	2.0005	1.9052	2.0005	2.0957	2.191	1.5242	1.8099
Min	.7621	.7621	.7621	.7621	.7621	.7621	.7621
Avg	1.3337	1.5004	1.1358	1.2750	1.1812	1.0955	1.1352

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324015 / 33/11 KV WARANGA

Feeder No / Name : 202 / 11 KV DABHADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				.0171			
6		.0191	.0171	.0171			.0191
7	.0191		.0173	.0173	.017		.0381
8	.0191	.0191	.0171	.0171	.0166		
9	.0381	.0191	.0343	.017	.0343	.0381	.0191
10	.0572	.0381	.0072	.0107	.0154	.0762	.0572
11			.0063	.0251	.0166		.0297
12	.0572		.0171	.0366	.0347	.0381	.0514
13	.0381		.0158	.0347	.0366	.0191	.052
14			.017	.0171	.0347		.0343
15			.0171		.0347	.0381	
16			.017	.0343	.0366		.0381
17	.0191		.017			.0191	.0366
18			.0183				.0347
19	.0191					.0381	.0351
20	.0191			.0343			
21	.0381					.0381	
22	.0191						
23				.0053			
Max	.0572	.0381	.0343	.0366	.0366	.0762	.0572
Min	.0191	.0191	.0063	.0053	.0154	.0191	.0191
Avg	.0312	.0239	.0168	.0218	.0277	.0381	.0371

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324015 / 33/11 KV WARANGA

Feeder No / Name : 203 / 11 KV BALAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143				.0381	.0381
2		.1143				.0381	.0381
3		.1143				.0381	.0381
4		.1143				.0381	.0381
5		.1143				.0381	.0381
6		1.5432				.0762	.4572
7	1.2384					.0381	.0381
8	1.0479	1.3336				.0381	
9	.9526	.9526				1.1431	.2858
10	1.7147	2.0957				.9907	.1905
11				.0381	2.2862		.1905
12	3.0864		.0762	.0381	2.6101	.8573	.9526
13	3.1626	.0381	.1524	.0381	2.7054	.9907	1.1812
14	.1143	.0381	.1524	.0381	2.4768	.0381	1.086
15	.1143	.0381	.1143	.0381	2.4768	.9907	
16	.0762	.0381	.1143		2.572	.0381	1.0479
17	2.5149		.0762			1.1812	2.4768
18	.0381		.0762			.0381	2.7625
19	1.5051		.1143			1.5623	1.4289
20	1.4098		.0381			.0381	
21	1.2765					1.3336	
22	1.2384						
23						.0381	
24	.0762					.0381	
Max	3.1626	2.0957	.1524	.0381	2.7054	1.5623	2.7625
Min	.0381	.0381	.0381	.0381	2.2862	.0381	.0381
Avg	1.2229	.5115	.1016	.0381	2.5212	.4373	.7229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324015 / 33/11 KV WARANGA

Feeder No / Name : 204 / 11 KV MAHALINGI RURAL  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5				.8573			
6		1.2384	.7621	.9526			1.0479
7	1.1431		1.0479	1.1431	1.2384		1.1431
8	1.1431	.8573	1.1431	1.2384			
9	.9526	.8573	.8573	1.2384	1.0479	.8573	.8573
10	.6668	.5716	.6668	.5716	1.2384	.6668	.7621
11			.5716	.5716	.6668		.5716
12	.6668		.5716	.5716	.6668	.6668	.5716
13	.5716		.5716	.5716	.6668	.6668	.5716
14			.4763	.5716	.6668		.5716
15			.5716		.6668	.7621	.5716
16			.5716	.6668	.6668		.6668
17	.1905		.6668			.8573	.8573
18			.7621				1.0479
19	1.0479					1.0479	.9526
20	.9526			1.1431			
21	.8573					.9526	
22	.7621						
23				.7621			
Max	1.1431	1.2384	1.1431	1.2384	1.2384	1.0479	1.1431
Min	.1905	.5716	.4763	.5716	.6668	.6668	.5716
Avg	.8140	.8812	.7108	.8354	.8362	.8097	.7841



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324018 / 33/11 KV KALAMNURI

Feeder No / Name : 203 / 11 KV WAKODI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5281	.4481	.4854	.5228		.4854
2	1.6461	1.4251	.7621	.4572	1.3413		1.0669
3	1.7528	1.6385	1.2193	.5601	1.4251		1.2193
4	1.8663	1.6385	1.3717	.5601	1.5746		
5	1.9022	1.6194	1.6347	.5975	1.6385		1.4861
6	1.9319	1.8404	1.6347	.5975	1.9433		1.6347
7	1.9319	1.9524	1.6347	.5975	2.0243		.1635
8	1.9022	2.0557	1.8427	.5601	1.9204		1.8427
9	1.8576	1.9766	1.9433	1.4861	1.9433		1.8427
10	.5175	.8215	.5658	.3772			.5228
11	.5544	.3734	.5847	.3772	.3734		.5601
12	.5729	.3734		.3772	.3734	.3734	.5975
13	.5729	.3734	.5601	.415	.3734	.4108	.5975
14	.5788	.3734	.5658	.415		.415	.5914
15	.5601	.3734	.5658	.415	.3734	.415	.5729
16	.5544	.3734	.5658		.3734	.4904	.5729
17	.5658	.3734	.5658	.3772		.4854	.5914
18	.5658	.4481	.5658	.3772		.4854	.5914
19	.5847	.5975	.5975	.5281		.5975	.5729
20	.5847	.5975	.5975			.5975	.5729
21	.6036	.5601	6.0307			.5601	.5729
22	.5281	.5601	.5975	.5281		.5228	.5601
23	.5281	.4854	.5601	.5281		.5228	.5415
24	.5544	.5281	.4854	.4854	.5228		.5228
Max	1.9319	2.0557	6.0307	1.4861	2.0243	.5975	1.8427
Min	.5175	.3734	.4481	.3772	.3734	.3734	.1635
Avg	.9905	.9120	1.1261	.5287	1.1149	.4897	.7949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324018 / 33/11 KV KALAMNURI

Feeder No / Name : 204 / 11 KV MASOD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.8488	.8215	.9335	.9431		.9335
2	1.1561	1.0059	.9145	.9145	.5087		.9145
3	1.142	1.1065	.9145	1.0669	.5087		1.2193
4	1.2346	1.1603	1.0669	1.2193	.503		
5	1.3245	1.1603	1.1279	1.2193	.6706		1.3717
6	1.3546	1.3927	1.1888	1.3375	.6706		1.3375
7	1.3546	1.5074	1.1888	1.3375	.7545		1.3375
8	1.2483	1.5384	1.3375	1.4861	.763	1.3077	1.3375
9	1.1888	1.4746	1.3375	1.4266	.6706	1.2041	1.1888
10	.7023	.4108	.695	.5281	.7545		.5914
11	.7316	.7468	.7392	.5281	.5601	.415	.6283
12	.9511	.7468		.5658	.5601	.415	.6468
13	.9877	.6722	.5601		.5601	.4854	.6535
14	.9877	.6722	.5601		.6348	.4854	.6722
15	.961	.6722	.5658		.6348	.5228	.6722
16	.961	.6722	.5658		.6348	.5281	.6535
17	1.0374	.7468				.5975	.7023
18	.8488	.8215	.9431			.8589	
19	.9054	1.1949	1.0082	1.4335		1.1203	.7468
20	1.1203	1.1949	1.1949			1.1949	.8131
21	1.2826	1.1203	1.1949			1.1203	.8871
22	1.0374	.9335	1.1203	1.226		1.1203	.8686
23	.9431	.8215	.9335	1.1317		.9335	.8402
24	1.0349	.8488	.7545	.9335	1.0374		.9335
Max	1.3546	1.5384	1.3375	1.4861	1.0374	1.3077	1.3717
Min	.7023	.4108	.5601	.5281	.503	.415	.5914
Avg	1.0533	.9779	.9424	1.0805	.6688	.8206	.9068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324018 / 33/11 KV KALAMNURI

Feeder No / Name : 208 / ADMINISTRATIVE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1509	.1494	.1494	.1509		.1494
2	.1494	.1509	.1494	.1494	.1494		.1494
3	.1494	.1509	.1494	.1494	.1494		.1494
4	.1663	.1509	.1494	.1494	.168		
5	.1663	.168	.1494	.1494	.1698		.1494
6	.1848	.1867	.1867	.1494	.1698		.1867
7	.1848	.1867	.1867	.1867	.168		.1867
8	.1848	.1886	.1867	.1867	.1886	.1848	.1867
9	.1663	.168	.168	.1494	.1509	.1848	.1494
10	.1663	.1494	.1543	.1509	.1494	.1509	.1494
11	.1663	.1494	.168	.1509	.1494	.1132	.1494
12	.1494	.1494	.1494	.1509	.1494	.1132	.1494
13	.1478	.1494	.1494	.1509	.1494	.112	.1494
14	.1478	.1494	.1494	.1509	.1494	.1132	.1494
15	.1494	.1494	.1494	.132	.1494	.1132	.1663
16	.1494	.1494	.1494	.132	.1494	.1132	.1663
17	.1509	.1494	.1494	.132		.112	.1848
18	.1509	.1494	.1494	.1509		.1494	.1848
19	.1509	.1494	.1494	.1509		.1867	.1848
20	.1509	.1494	.1867			.1867	.1848
21	.1509	.1494	.1494			.1494	.1663
22	.1509	.1494	.1494	.1509		.1494	.168
23	.1509	.1494	.1494	.1494		.1494	.1494
24	.1494	.1509	.1494	.1494	.1494		.1494
Max	.1848	.1886	.1867	.1867	.1886	.1867	.1867
Min	.1478	.1494	.1494	.132	.1494	.112	.1494
Avg	.1577	.1560	.1574	.1510	.1565	.1426	.1634

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 201 / 11 KV KAMTHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		.3109		.4066	.4024	.3326	.3475
11	.4207	.3475	.2587	.5853	.439		.4435
12	.439	.4024	.5175	.7133	.7023	.3109	.4066
13	.4572	.2429	.5175	.7316	.4938	.3475	.4805
14	.2641	.3109	.5175	.4938	.6653	.2743	.4805
15	.3326	.3475	.5544		.6653	.2743	
16	.3584	.3658	.5914	.3658	.4938	.1463	.4805
17	.3658		.6653	.415			.5175
Max	.4572	.4024	.6653	.7316	.7023	.3475	.5175
Min	.2641	.2429	.2587	.3658	.4024	.1463	.3475
Avg	.3768	.3326	.5175	.5302	.5517	.2810	.4509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 204 / 11 KV PIMPRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		1.094	1.0269	1.0829	1.0562		.9054
11	1.4901	1.1506	1.1458	1.4712	1.2696		1.1203
12	1.6221	1.3769	1.4563		1.2696	1.0374	1.1576
13	1.4901	1.4901	1.4937	1.4335	1.2936	.9997	1.0719
14	1.5123	1.4335	1.2936	1.4712	1.2696	1.0374	1.1576
15	1.4937	1.358	1.2696		1.1949	.0943	
16	1.3769	1.358	1.3443		1.2323	.4904	1.0829
17			1.4937	1.1506			1.2696
Max	1.6221	1.4901	1.4937	1.4712	1.2936	1.0374	1.2696
Min	1.3769	1.094	1.0269	1.0829	1.0562	.0943	.9054
Avg	1.4975	1.3230	1.3155	1.3219	1.2265	.7318	1.1093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 206 / 11 KV PIMPRI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.4251	.4338	.3696	.4251		.5093
2	.4435	.5544	.415	.3696	.3921		.4904
3	.4805	.462	.4338	.4066	.4294		.4904
4	.5175	.499	.4527	.4435	.462		.5281
5	.5544	.5359	.4715	.4805	.499		.6036
6	.6283	.6283	.5847	.5544	.5788		.6979
7	.5175	.5544	.5658	.5544	.5175		.4338
8	.4805	.499	.5093	.4805	.499		.3961
9	.3696			.4066	.3696		
10	.3326	.3584		.2957	.3881		.3018
11	.2614	.2452	.3696	.3109	.2957		.2772
12	.2772	.2641	.3142	.3326	.3142	.4904	.2772
13	.2957	.2829	.2957		.3326	.5093	.3696
14	.2957	.2829	.3326	.3326	.3511	.4904	.4066
15	.3142	.3018	.3326		.3696	.4557	
16	.3174	.2829	.3174		.3511	.1463	.4435
17			.3696	.4435			.4066
18	.4251		.4481	.3326			.5175
19	.499		.5175	.5415		.6979	.5914
20	.5228	.547	.5544	.499		.679	.4805
21	.4854	.4481	.462	.4854		.5847	.4251
22	.4287	.5658	.4805	.462			.4251
23	.4481	.4527	.4435	.4294		.5281	.4066
24		.4251	.4338	.4066	.4108		.5093
Max	.6283	.6283	.5847	.5544	.5788	.6979	.6979
Min	.2614	.2452	.2957	.2957	.2957	.1463	.2772
Avg	.4228	.4308	.4336	.4256	.4109	.5091	.4540

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 207 / 11 KV KAMTHA GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.1362	.1753	.1663	.1115		.1698
2	.1663	.1115	.1132	.1478	.1115		.1698
3	.1848	.1238	.0111	.1663	.0974		.1698
4	.1848	.1132	.1166	.1848	.1115		.1698
5	.2033	.1362	.1238	.1848	.1238		.1886
6	.2402	.1238	.161	.2218	.161		.2263
7	.2218	.1362	.161	.1848	.1486		.2263
8	.2033	.1115	.1555	.1109	.1238		.2452
9	.1478	.0991	.1848	.1478	.1115	.1478	.1132
10	.1294	.1063	.1294	.1294	.0743	.1294	.0943
11	.128	.0648	.1294	.0867	.1109		.0924
12	.0789	.0789	.1109	.0743	.1109	.1463	.0924
13	.0743	.0892	.1109	.0867	.1109	.128	.0924
14	.088	.0892	.1109	.0991	.1109	.128	.1109
15	.1294	.0937	.1109		.1109	.1267	
16	.0743	.1094	.1109	.0991	.1109	.2503	.1109
17	.0867		.1109	.1115			.1109
18	.1021	.1457	.1294				.1109
19	.1257	.1943	.1478	.161		.2075	.1478
20	.1425	.1715	.1663	.1509		.2075	.1848
21	.1486	.1572	.1848	.1425		.2075	.2033
22	.1238	.1619	.1848	.1238			.1848
23	.1238	.1562	.1663	.1362		.1886	.1848
24		.1509	.1658	.1663	.1115		.1886
Max	.2402	.1943	.1848	.2218	.161	.2503	.2452
Min	.0743	.0648	.0111	.0743	.0743	.1267	.0924
Avg	.1424	.1244	.1363	.1401	.1148	.1698	.156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324041 / 33/11 KV AKHADA BALAPUR

Feeder No / Name : 209 / 11 KV BALAPUR URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.7928	.6815	.7682	.7649		.7788
2	.7407	.7232	.6537	.7682	.7371		.7788
3	.7407	.7371	.6537	.7956	.7232		.7788
4	.7682	.7232	.6676	.7956	.751		.7788
5	.7682	.7093	.6815	.823	.7788		.7928
6	.7956	.751	.6954	.823	.7788		.8067
7	.7407	.7788	.7093	.823	.7649		.7649
8	.8871	.7093	.7371	.7407	.7788		.7371
9	.6584	.6815	.6584	.6584	.751	.6584	.6676
10	.631	.6954	.5898	.6676	.7232	.7133	.6815
11	.5424		.6036	.7093	.6036		.631
12	.5841	.6259	.6584	.6815	.5487	.7788	.631
13	.598	.6398	.631	.7232	.6584	.6954	.7392
14	.5841	.6259	.6036	.751	.6996	.7232	.631
15	.6584	.6537	.631		.6584	.7232	
16	.6398		.6584	.7093	.631	.6676	.7133
17	.598		.6584	.7232			.7682
18	.6676	.8484	.7407	.7232			.7407
19	.7371	.8206	.7407	.751		.9875	.7407
20	.7232	.7928	.7407	.8067		.8623	.7133
21	.8206	.7232	.7682	.8067		.8345	.7407
22	.8067	.7232	.3429	.8067			.7545
23	.7788	.7093	.823	.8206		.8623	1.0349
24		.8067	.6954	.7956	.7788		.8345
Max	.8871	.8484	.823	.823	.7788	.9875	1.0349
Min	.5424	.6259	.3429	.6584	.5487	.6584	.631
Avg	.7060	.7272	.6677	.7596	.7135	.7733	.7495



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324053 / 33/11 KV SUKLI VEER

Feeder No / Name : 201 / 11 KV SUKLI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-MAY-17	11-MAY-17	12-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
11	.7087		
12			.9002
13		.7202	.9002
14		.7202	.9002
15			.6001
16		.7802	.7802
Max	.7087	.7802	.9002
Min	.7087	.7202	.6001
Avg	.7087	.7402	.8162

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324053 / 33/11 KV SUKLI VEER

Feeder No / Name : 204 / JAMGAVAHAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.0286			
12			.0143	
13		.013	.0286	.0274
14		.0126	.0297	
15			.0286	
16		.0244	.0278	
Max	.0286	.0244	.0297	.0274
Min	.0286	.0126	.0143	.0274
Avg	.0286	.0167	.0258	.0274

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324053 / 33/11 KV SUKLI VEER

Feeder No / Name : 205 / DONGARKADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	11-MAY-17	12-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
11	.2248		
12			.2477
13		.2572	.262
14		.262	.2667
15			.2572
16		.3086	.262
Max	.2248	.3086	.2667
Min	.2248	.2572	.2477
Avg	.2248	.2759	.2591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324053 / 33/11 KV SUKLI VEER

Feeder No / Name : 206 / 11 KV SUKALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381		.0381			.0381	.0381
2	.0381		.0381				.0381
3	.0381		.0381				.0381
4	.0381		.0381				.0381
5	.0381	.0381				.0381	.0381
6	.0381	.0381	.0381	.0381	.0381	.0381	.0381
7	.0381	.0381	.0381	.0381	.0381	.0381	.0381
8	.0762	.0381	.0762	.0381	.0762	.0381	
9	.0381	.0381	.0762	.0381	.0381	.0381	
10	.0381	.0381	.0381	.0381	.0381	.0381	
11	.0667	.0381	.0381		.0381	.0381	
12	.0381	.0381	.0381		.0686		
13	.0381	.0381	.0381	.0145	.0693	.0381	
14	.0381	.0381	.0381	.0141	.0686	.0381	
15	.0381	.0381	.0381		.0678	.0381	
16	.0381	.0381	.0381	.0152	.0667	.0381	
17		.0381	.0381	.0381	.0381	.0381	
18		.0381	.0381	.0381		.0381	.0381
19	.0381	.0381	.0381			.0762	.0381
20	.0381	.0381	.0381	.0381		.0762	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23		.0381		.0381	.0381	.0381	.0381
24		.0381			.0381	.0381	.0381
Max	.0762	.0381	.0762	.0381	.0762	.0762	.0381
Min	.0381	.0381	.0381	.0141	.0381	.0381	.0381
Avg	.0414	.0381	.0417	.0331	.0499	.0419	.0381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324068 / 33/11 KV GAUL BAZAR

Feeder No / Name : 201 / 11 KV GAUL BZ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3258	.9145	.2835		.3982
2	1.6385		1.358	1.2193	1.5775		1.4175
3	1.9204		1.4198	1.6004	1.7974		1.4327
4	1.9433		1.4815	.1677	2.1548		
5	2.2939		1.5741	1.8595	2.1548		
6	2.1605		1.9753	2.1338	2.1862		
7	2.3205		2.0062	2.2862	1.9925		1.4998
8	2.2611		2.2348	1.9052	2.332		1.9997
9	2.4863		2.17	2.3167	2.2672	1.7985	2.0805
19		.4527	.3353		.2439	.4435	.3544
20		.4481	.2743			.4481	.4481
21		.4066		.362		.4435	.4024
22	.3018	.3658	.2743	.3353			
23	.3018	.3258	.2743	.362			.3772
24			.3258	.2743	.3292		.3856
Max	2.4863	.4527	2.2348	2.3167	2.332	1.7985	2.0805
Min	.3018	.3258	.2743	.1677	.2439	.4435	.3544
Avg	1.7628	.3998	1.1450	1.2105	1.5745	.7834	.9815

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324068 / 33/11 KV GAUL BAZAR

Feeder No / Name : 202 / 11 KV SHIVANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1417	.0762	.0914	.088		.1254
2	.0914		.0743	.0914	.0854		.1296
3	.1105	.1417	.0894	.0914	.0709		.1296
4	.1105		.0991	.1219	.0823		.0823
5	.0991		.0991	.1219	.0846		.0823
6	.0772	.176	.0991	.0762	.0823		.0686
10	1.174		.9122	1.1736	.6954	1.2193	1.2193
11	1.7711		1.3717	1.1888	1.4327	1.3077	1.2498
12	1.6129	.9122	1.5242	1.1431	1.4632	1.3108	1.2651
13	.743	1.1873	1.5546	1.2146	1.3717	1.2793	1.2193
14	1.2445	1.4918	1.5546	1.3032	1.4022	1.2289	1.1888
15	1.2163	1.3889	1.4022		1.2803	.9717	1.1443
16		1.5741	1.5242	.8067	1.2498	1.0856	1.2483
17		1.358	1.5242			1.1294	1.3748
18			1.6194				
19		.0977	.1524		.1829	.2218	.1124
20		.0953	.1829			.0819	.1372
21		.1029		.0537		.1097	.1574
22	.1238	.0953		.1357			
23	.1326	.1048	.1829	.0975			.144
24		.1372	.1257	.1829	.0777		.1433
Max	1.7711	1.5741	1.6194	1.3032	1.4632	1.3108	1.3748
Min	.0772	.0953	.0743	.0537	.0709	.0819	.0686
Avg	.6544	.6003	.7457	.4934	.6433	.9042	.5906

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324068 / 33/11 KV GAUL BAZAR

Feeder No / Name : 204 / 11 KV GAUL BZ GATOHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0944	.0941	.0838	.0945	.0762	.0947
2	.0946	.0381	.0947	.0838	.0948	.0762	.1135
3	.0944	.0943	.0947	.0838	.0947	.0381	.1135
4	.1132	.0381	.0947	.1143	.1135	.0381	.1135
5	.1135	.0381	.1135	.1295	.1507	.0762	.1705
6	.1706	.1697	.1696	.0762	.2076	.0762	.2082
7	.2447	.2461	.245	.2057	.2078	.1143	.2463
8	.1883	.2082	.2263	.1905	.2447	.1143	.2275
9	.1512	.1323	.2067	.1372	.2081	.1905	.0762
10	.1497	.095	.1494	.1219	.151	.0808	
11	.0758	.1478	.0838	.0931	.0838	.0947	
12	.0936	.0366	.0838	.0942	.0838	.1128	.1092
13	.0754	.093	.0838	.0939	.0686	.1328	.0939
14	.0756	.093	.0838	.0938	.0686	.0947	.1109
15	.0749	.093	.0686	.0938	.0686	.1113	.0937
16	.0381	.093	.0686	.094	.0838	.1135	.0929
17	.0381	.1676	.0991	.0381	.0381	.1705	.1135
18	.0762	.1676	.1524	.0381	.1524	.1848	.1707
19	.0762	.1705	.1524		.1524	.1882	.1882
20	.0762	.1696	.16		.1143	.2077	.2255
21	.0762	.1516	.1219	.1694	.0762	.1509	.1688
22	.1516	.1135	.0838	.1507	.0762	.0762	.0762
23	.1135	.1128	.0838	.1505	.0762	.0381	.151
24	.0381	.0945	.1128	.1219	.1516	.0381	.0947
Max	.2447	.2461	.245	.2057	.2447	.2077	.2463
Min	.0381	.0366	.0686	.0381	.0381	.0381	.0762
Avg	.1016	.1191	.1220	.1117	.1193	.1081	.1388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324068 / 33/11 KV GAUL BAZAR

Feeder No / Name : 205 / 11 KV SHIVANI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4191	.8823	.7925	.4533	.4954	.8978
2	.8324		.8485	.7544	.4342	.4954	.9062
3	.8459		.8485	.7544	.3949	.4572	.868
4	.9366		.8485	.4572	.3768	.4572	.4572
5	1.0565		.98	.9526	.4138	.4954	.9038
6	1.3248		1.2632	1.3184	.4538	.724	1.3222
7	1.1967		1.2079	1.2422	.4165	.6859	1.1203
8	.9603		1.0757	1.105	.3334	.6478	.4572
9	.8814		.9389	.9679	.1524	.9907	.977
10	.7702		.7449	.7468	.9586	.6477	.8612
11	.6512		.602	.6078	.7544	.3959	.7294
12	.5238	.7544	.5801	.6106	.7239	.4549	.6932
13	.5069	.7491	.5715	.6622	.6477	.4713	.6264
14	.5204	.7068	.5715	.5769	.6401	.4713	.6254
15	.5024	.6868	.1143	.6587	.7239	.49	.6225
16	.2667	.7548	.7239	.6961	.7544	.6386	.6433
17	.3048	.8032	.9144	.3429	.4572	.7506	.843
18	.4572	.8354	1.0288	.381	1.0289	1.0881	1.0656
19	.4954	.9678	1.0898		1.2194	1.2834	.9149
20	.5716	1.1218	1.105		.6859	1.291	1.0689
21	.5335	.9907	.9526	.4286	.6097	1.1546	1.1256
22	.9627	.9622	.8002	.865	.5716	.6097	.5335
23	.9048	.9389	.8002	.5214	.5716	.5716	.9759
24	.4191	.4572	.8962	.4572	.8328	.5335	.8779
Max	1.3248	1.1218	1.2632	1.3184	1.2194	1.291	1.3222
Min	.2667	.4191	.1143	.3429	.1524	.3959	.4572
Avg	.7019	.7963	.8495	.7227	.6087	.6792	.8382



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324083 / 33/11 KV SALWA

Feeder No / Name : 201 / 11 KV SALVA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6283	.6283	.5914	.6283	.6468		.6653
2	.6283	.6099	.5914	.6283	.6283		.6653
3	.6468	.6099	.5914	.6283	.6283		.6653
4	.6653	.6283	.5914	.6283	.6653		.6653
5	.7023	.6653	.6653	.7023	.7762		.8131
6		.7392	.7762	.961	1.0164		.961
7	.961	.8871	.8501	.924	1.0164		.8501
8	.6145	.6838	.8131	.924	.8871		.7947
9	.6468	.6468	.7762	.7392	.7392	.7762	
10	.462	.4805	.5914	.6283	.6468	.6099	.5729
11	.462	.4066	.5544	.5544	.5359	.5175	.5359
12	.4066	.3696	.4805	.5175	.5544	.5175	.4805
13		.3696	.5175	.499		.5175	.4805
14	.462	.462	.4435	.5175	.5175		.5175
15	.4805	.4435	.4435	.499	.5359		.5359
16	.5175	.4805	.4805	.5544	.6099	.5914	.6099
17	.5729		.6283	.6283		.7392	.6838
18	.7023	.5914	.7392		.7762	.7762	.7947
19	.8501	.8131	.8501		.8871	.8871	.8686
20	.8131	.7762	.8131		.8686	.961	.9055
21	.7392	.7023	.8131	.8501		.8131	.7947
22	.7023	.6653	.7392	.7947		.7392	.7392
23	.6653	.6283	.7023	.7207		.7095	.6838
24	.6468	.6283	.5914	.6283	.6653		.6653
Max	.961	.8871	.8501	.961	1.0164	.961	.961
Min	.4066	.3696	.4435	.499	.5175	.5175	.4805
Avg	.6353	.6050	.6514	.6741	.7159	.7043	.6934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324083 / 33/11 KV SALWA

Feeder No / Name : 202 / 11 KV SALVA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2634	.2195	.2341	.2634	.2195		.2634
3	.2926	.2487	.2341	.2926	.2634		.2634
4	.3073	.2487	.2341	.2926	.2926		.2634
5	.4243	.2926	.2341	.3219	.3658		.4975
6		.556	.4682	.6145	.5121		.4975
7	.6438	.6292	.7023	.7609	.5853		.6145
8	.7755	.6731	.7316	.7609	.717		
9	.8871	.6438	.7023	.5853	.7316	.556	.6292
Max	.8871	.6731	.7316	.7609	.7316	.556	.6292
Min	.2634	.2195	.2341	.2634	.2195	.556	.2634
Avg	.5134	.4390	.4426	.4865	.4609	.556	.4327

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324085 / 33/11 KV DONGARKADA

Feeder No / Name : 201 / 11 KV DONGARKADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6097	.6097	.6097	.5335	.6097	.6859
2	.6097	.5335	.6097	.6097	.5335	.5335	.6859
3	.6097	.5335	.5335	.6097	.5335	.5335	.6097
4	.6097	.5335	.5335	.6097	.5335	.5335	.6859
5	.6859	.6097	.6097	.6097	.6097	.6097	.6859
6	1.8385	1.6305	.8383	.9145	.8383	.8383	.9145
7	1.917	.9145	.9907	.9145	.9907	.9907	1.0669
8	1.5983	1.5546	.9145	.8383	.9145	.9907	.9907
9	.8015	1.3119	.7621	.7621	.8383	.8383	.8383
10	1.0902	.5335	.6859	.6859	.6859	.5335	.6859
11	1.0325	1.0284	.5335	.5335	.5335	.6097	.5335
12	1.051	.9187	.5335	.5335	.5335	.5335	.9377
13	.996	.9387	.5335	.4572	.5335	.5335	.4572
14	.8638	.898	.5335	.5335	.5335	.5335	.9562
15	.9197	.9178	.5335	.4572	.5335	.5335	.9562
16	.5335	1.0309	.5335	.5335	.5335	.6097	.5335
17	1.0705	.5335	.6097	.6097	.5335	.6859	1.2196
18	1.2773	.5335	.7621	.6859		.7621	1.3327
19	1.3882	.7621	.8383			.7621	1.5903
20	1.4096	.9145	.9145	.2286		.9145	1.6907
21	1.3142	.7621	.8383	.6859	.6859	.9145	1.5406
22	1.2773	.7621	.7621	.6859	.6859	.7621	1.3519
23	.6097	.6859	.6859	.6097	.5335	.7621	1.3327
24	.6097	.6859	.6859	.6097	.6097	.6859	.6097
Max	1.917	1.6305	.9907	.9145	.9907	.9907	1.6907
Min	.5335	.5335	.5335	.2286	.5335	.5335	.4572
Avg	1.0333	.8390	.6827	.6229	.6315	.6923	.9538

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324085 / 33/11 KV DONGARKADA

Feeder No / Name : 202 / 11 KV WARUD AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1524	.2286	.1524	.1524	
2	.2286	.1524	.1524	.1524	.1524	
3	.2286	.1524	.1524	.1524	.1524	
4	.2286	.1524	.1524	.1524	.1524	
5	.2286	.1524	.1524	.1524	.1524	
6	.2286	.0762		.1524	.1524	
10	3.1607	1.6766	1.3717	.381	1.448	
11	5.013	5.0351	2.2862	2.7435	2.5911	
12	5.7361	5.0781	2.7435	2.7435	2.7435	
13	5.628	4.1414	2.5911	2.5911	2.3624	
14	4.401	4.048	2.8197	2.21	2.3624	
15	4.9475	4.4	2.3624	2.0576	2.21	
16	2.8959	4.5594	2.4387	2.3624	2.1338	
17	3.2162	2.5149	2.4387	2.5149	2.1338	3.8925
18	1.6004	2.1338	2.21	1.829		1.829
19	.1628	.1524	.0762			.2745
20	.3683	.2286	.1524	.1524		.3016
21	.3685	.2286	.1524	.1524		.3016
22	.3683	.1524	.1524	.1524		.3016
23	.2286	.2286	.1524	.1524		.2881
24	.2286	.2286	.2286	.1524		.1524
Max	5.7361	5.0781	2.8197	2.7435	2.7435	3.8925
Min	.1628	.0762	.0762	.1524	.1524	.1524
Avg	1.8903	1.6974	1.1507	1.0555	1.3500	.9177

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324085 / 33/11 KV DONGARKADA

Feeder No / Name : 203 / 11 KV BHATEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.0762	.0762	.0762	
2	.3048	.5335	.0762	.0762	
3	.381	.5335	.0762	.0762	
4	.4572	.6097	.5335	.4572	
5	.4572	.6859	.5335	.6097	
6	1.3164	1.5305	.7621	.8383	
7	1.7714	.9145	1.0669	1.0669	
8	1.5483	1.5498	1.0669	.9907	
9	1.7252	.595	.9907	1.0669	
10	1.0669	.7621	.9907	.3048	
18					1.0076
19	.0583	.0762	.0762		.7537
20	.1693	.0762	.0762		.1576
21	.2455	.0762	.0762	.0762	.1584
22	.2457	.0762	.1524	.0762	.1576
23	.1524	.0762	.0762	.0762	.1575
24	.0762	.1524	.0762		.0762
Max	1.7714	1.5498	1.0669	1.0669	1.0076
Min	.0583	.0762	.0762	.0762	.0762
Avg	.6330	.5203	.4191	.4455	.3527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

KALAMNURI (R) S/DN[453] BU 2399

Substation No/ Name :- 324095 / 33/11 KV SANDAS

Feeder No / Name : 202 / 11 KV SALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17
HR	Load (MW)
17	.5914
Max	.5914
Min	.5914
Avg	.5914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324016 / 33 KV SENGGAON

Feeder No / Name : 201 / 11 KV MAKODI AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17
HR	Load (MW)
10	.7545
Max	.7545
Min	.7545
Avg	.7545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324020 / 33 KV Goregaon

Feeder No / Name : 207 / 11 KV PALSHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.8256			.7339
6			.9174			.8256
12	.6021	.6421		.4833	.3288	
13		.6605				
14		.6788	.6735		.4036	
15						.6165
16					.9174	
17	.9634				.8273	
18		.8282			.8273	
19	.8602				.7399	
20		.8256			.8256	
22		.8256			.8256	
24			.8256			.7339
Max	.9634	.8282	.9174	.4833	.9174	.8256
Min	.6021	.6421	.6735	.4833	.3288	.6165
Avg	.8086	.7435	.8105	.4833	.7119	.7275



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324020 / 33 KV Goregaon

Feeder No / Name : 208 / 11 KV SAWANA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.7354			.6348
6			.8256			.765
12	1.4419	1.1926		1.2742	1.376	
13		1.376				
14		1.2843	1.0185		1.2843	
15						.7809
16		1.2883			1.1926	
17	.9724				1.1008	
18		1.1008			1.1008	
19	1.0395				1.1008	
20		.6788			.6006	
22		.6828			.6421	
24			.7339			.6421
Max	1.4419	1.376	1.0185	1.2742	1.376	.7809
Min	.9724	.6788	.7339	1.2742	.6006	.6348
Avg	1.1513	1.0862	.8284	1.2742	1.0498	.7057

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324072 / 33 KV HATTA PATI

Feeder No / Name : 204 / 11 KV SAKHARA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17
HR	Load (MW)
11	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324072 / 33 KV HATTA PATI

Feeder No / Name : 205 / 11 KV BRAMHWADI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	08-MAY-17
HR	Load (MW)
6	.7373
Max	.7373
Min	.7373
Avg	.7373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324072 / 33 KV HATTA PATI

Feeder No / Name : 208 / 11 KV ADOL AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	08-MAY-17
HR	Load (MW)
11	.7545
Max	.7545
Min	.7545
Avg	.7545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324080 / 33 kV KADOLI

Feeder No / Name : 203 / 11 kV MAZOD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							.7876
4							.8579
5							.884
6							1.065
7							1.166
8							1.3927
10	2.13		2.1052	1.7535	1.8842	1.6907	
11	2.2939	2.0481	2.1052	1.9265	1.9989	1.7532	
12		2.0153	2.0972	1.7833	2.0481	1.7204	
13	1.9662	1.917	1.9662	1.7459	1.8023	1.7532	
14	1.7532	1.7404	1.8515	1.6156	1.7695	1.5604	
15	1.8023	1.5546	1.8842	1.5242	1.8023	1.5804	
16	1.8842		1.7814	1.5653	1.8023		
17	1.8023		1.5565	1.5604	1.4918	1.3279	
Max	2.2939	2.0481	2.1052	1.9265	2.0481	1.7532	1.3927
Min	1.7532	1.5546	1.5565	1.5242	1.4918	1.3279	.7876
Avg	1.9474	1.8551	1.9184	1.6843	1.8249	1.6266	1.0255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-MAY-17 and 14-MAY-17

NANDED ZONE[066]

HINGOLI CIRCLE[636]

HINGOLI DIVSION[694]

SENGAON SUB-DIVISION[797] BU 4797

Substation No/ Name :- 324080 / 33 kV KADOLI

Feeder No / Name : 204 / 11 KV TAPOWAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	08-MAY-17	09-MAY-17	10-MAY-17	11-MAY-17	12-MAY-17	13-MAY-17	14-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8871	.8413	.8048	.8131	.8048		.8686
2	.8871	.8686	.8048	.8413	.8501		.9055
3	.9335	.9055	.9055	.8686	.8871		.9145
4	.9522	.9522	.9896	.4574	.9335		.9795
5	1.094	1.0642	1.1317	.9709	1.0082		1.0534
13	.5729	.6099	.6283	.7023	.7207	.7207	.7392
14	.6468	.6653	.7392	.6468	.7023	.7023	.6838
15	.6283	.6036	.7023	.6653	.6838	.6767	.6584
16	.6099		.5914	.5853	.5729		.6468
17						.5487	
19	.7023	.6099	.9335	.924		.6099	.9055
20	.8962	.9335	.9709	.9896		.7023	.9896
21	.8589	.9522	.8686	.9709		.8775	.9335
22	.8871	.9997	.8316	.8871		.9709	.9055
23	.8131	.8316	.7865	.8316		.8962	.8775
24	.8775	.8048	.8131	.7865	.7947		.8596
Max	1.094	1.0642	1.1317	.9896	1.0082	.9709	1.0534
Min	.5729	.6036	.5914	.4574	.5729	.5487	.6468
Avg	.8165	.8316	.8335	.7960	.7958	.7450	.8614