

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 201 / 11 kv Aurangapura Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0642	1.0562	1.1203	1.1203	1.4289	1.094	1.0642
2	1.0269	1.0185	1.0269	1.0269	1.0669	1.0669	1.0269
3	.9335	.9431	.9335	.9335	1.0374	1.0288	.9709
4	1.1016	1.094	1.0642	.9709	1.094	1.1431	1.1016
5	1.2136	1.226	1.2883	1.0642	1.1506	1.2955	1.1763
6	1.363	1.5089	1.531	1.2136	1.226	1.5655	1.363
7	1.7737	1.7556	1.7177	1.587	1.3203	1.7147	1.8671
8	1.7718	1.6644	1.8671	1.7737	1.6461	1.7918	1.8671
9	1.8861	1.7164	1.7375	1.7375	1.6461	1.5729	1.7718
10		1.5947	1.6461	1.6644	1.6095	1.6461	1.701
11	2.0748	1.8427	1.9022	1.829	1.7558	1.8427	1.7896
12	2.1125	2.0199	2.0302	1.9936	1.9387	1.9667	1.858
13	2.0936	2.0302	2.0485	1.7193	2.0302	1.825	2.0302
14	2.0936	2.0119	1.9753	1.6644	2.0668	1.9136	1.8839
15	1.9805	1.9022	1.9204	1.8656	1.8839	1.893	1.9022
16	2.1313	2.0668	1.9204	1.9022	2.037	1.8781	1.9313
17	2.0748	2.0725	2.0725	1.9993	2.0748	2.1472	2.0748
18	2.2634	2.2779	2.3339	2.1691	2.1879	2.4272	2.3045
19	2.7069	2.894	2.6139	2.7161	2.5789	2.8006	2.7618
20	2.6155	2.894	2.6139	2.6217	2.6972	2.8006	2.7435
21	2.584	2.4272	2.2405	2.4331	2.3577	2.5206	2.5463
22	1.8861	1.9605	1.7364	1.905	1.8484	1.8671	1.8673
23	1.3957	1.475	1.4377	1.4335	1.467	1.4377	1.4335
24	1.1576	1.226	1.2323	1.2136	1.1883	1.2384	1.2136
Max	2.7069	2.894	2.6139	2.7161	2.6972	2.8006	2.7618
Min	.9335	.9431	.9335	.9335	1.0374	1.0288	.9709
Avg	1.7959	1.7783	1.7504	1.6899	1.7224	1.7699	1.7604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 202 / 11 KV SAMARTH NAGAR FEEDR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4003	1.358	1.4937	1.4377	1.4146	1.3908	1.3443
2	1.363	1.3203	1.4003	1.4003	1.3336	1.3392	1.307
3	1.307	1.2826	1.307	1.307	1.2826	1.2955	1.2136
4	1.475	1.2826	1.4377	1.475	1.3392	1.2955	1.475
5	1.6651	1.4712	1.531	1.6244	1.3957	1.4523	1.7737
6	1.9605	1.8861	1.6804	1.8671	1.4901	1.773	1.9044
7	2.2405	2.1622	2.0725	2.0725	1.773	2.0957	2.1472
8	2.3034	2.1948	2.2965	2.2965	2.0748	2.2634	2.3712
9	2.4897	2.3411	2.2862	2.2862	2.0668	2.2314	2.3034
10	2.6783	2.2857	2.2862	2.396	2.1399	2.3228	2.4143
11	2.8669	2.5869	2.3777	2.524	2.3045	2.516	2.6755
12	2.8669	2.6223	2.4143	2.524	2.1216	2.4983	2.5591
13	2.6406	2.6155	2.3777	2.3411	2.0119	2.4274	2.5606
14	2.5463	2.5606	2.1033	2.1033	1.9753	2.392	2.4143
15	2.452	2.3777	2.0485	2.1033	1.8656	2.2786	2.3777
16	2.4709	2.4874	2.0668	2.0302	1.8861	2.3565	2.392
17	2.4897	2.6139	2.2405	2.1691	1.905	2.5206	2.6406
18	2.6406	2.6886	2.4272	2.1691	2.1313	2.3148	2.4874
19	3.1276	3.2114	2.894	2.9235	2.6703	3.0994	3.1642
20	3.0933	3.0807	2.8006	2.8481	2.6886	2.9874	3.0544
21	2.8292	1.9605	2.5206	2.6029	2.3577	2.7073	2.7726
22	2.2634	2.3339	2.0725	2.037	1.773	2.1845	2.2257
23	1.9239	2.0725	1.7737	1.8484	1.7909	1.8671	1.905
24	1.6244	1.6409	1.643	1.531	1.5466	1.5844	1.5746
Max	3.1276	3.2114	2.894	2.9235	2.6886	3.0994	3.1642
Min	1.307	1.2826	1.307	1.307	1.2826	1.2955	1.2136
Avg	2.2799	2.1849	2.0647	2.0799	1.8891	2.1331	2.2107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 203 / 11 kv city chowk feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.5281	.5975	.5975	.6097	.5658	.5601
2	.4668	.4527	.5601	.5601	.5716	.4904	.5041
3	.4108	.415	.0467	.4668	.4904	.4572	.4668
4	.5144	.5658	.5415	.5041	.6036	.6097	.5415
5	.6535	.679	.5975	.5975	.7545	.7167	.6535
6	.8029	.7545	.6908	.7282	.811	.7545	.7468
7	.9709	.924	.9335	.9335	.8488	.9619	.9335
8	1.0099	1.0242	1.2136	1.0269	1.0185	1.1317	1.1203
9	1.094	1.0425	1.2437	1.0059		1.0608	1.0631
10	1.1317	1.0277	1.2803	.9328	1.134	1.0974	1.0974
11	.9997	.9391	1.2437		1.0608	1.0099	.9922
12		.9036	1.1706	1.0059	1.0608	.8859	.9465
13	.8299	.8413	1.0425	.8413	.8413	.8682	.8962
14	.7356	.7499	.8413	.7316	.7499	.7796	.6767
15	.6602	.6767	.8048	.6584	.6401	.6556	.6584
16	.6602	.7499	.6767	.6584	.7167	.6379	.5847
17	.7733	.8215	.7468	.7545	.7733	.8145	.7167
18	.9808	.9335	.8775	.9054	.8676	1.0269	.9328
19	1.1157	1.1203	1.1203	1.1506	1.0974	1.1576	1.134
20	1.0425	1.1203	1.0642	1.0425	1.0242	1.1203	1.0974
21	.9619	.9335	.905	.9328	.8676	.8402	.9619
22	.8488	.8775	.8402	.8488	.811	.8688	.8865
23	.7545	.7282	.7095	.7545	.7621	.7282	.7545
24	.6535	.6602	.7468	.6535	.6036	.6224	.6535
Max	1.1317	1.1203	1.2803	1.1506	1.134	1.1576	1.134
Min	.4108	.415	.0467	.4668	.4904	.4572	.4668
Avg	.8076	.8112	.8540	.7953	.8138	.8276	.8158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 204 / 11 KV bus stand Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.8865	.8962	.8775	.9145	.9431	.9149
2	.8029	.8488	.8402	.8402	.8573	.8573	.8775
3	.7468	.7922	.7468	.7468	.8488	.8192	.8402
4	.8775	.8488	.7842	.8029	.7922	.8954	.8962
5	.9335	.9431	.8775	.8589	.8299	.9431	.9709
6	1.0642	1.094	.9896	.9431	.8488	1.0185	1.0269
7	1.307	1.2382	1.1576	1.2136	.9431	1.2071	1.307
8	1.2403	1.2437	1.4003	1.307	1.0974	1.2071	1.4003
9	1.3769	1.3169	1.4632	1.3169	1.2449	1.4083	1.382
10	1.5655	1.4529	1.5181	1.3717	1.1706	1.5364	1.5364
11	1.5655	1.4529	1.2986	1.3717	1.2071	1.3998	1.4529
12	1.4523	1.3466	1.2803	1.2986	1.134	1.3289	1.3672
13	1.3392	1.2803	1.2254	1.1888	1.0059	1.3112	1.3169
14		1.1706	1.2986	1.0791	.9328	1.2757	1.2803
15	1.2071	1.2071	1.2803	1.0974	.8779	1.2269	1.2803
16	1.2637	1.2437	1.1157	1.1523	.9431	1.3643	1.2403
17	1.3957	1.307	1.2136	1.1706	.9619	1.4003	1.358
18	1.5655	1.4377	1.3443	1.3203	1.1883	1.4937	1.39
19	1.6827	1.7177	1.587	1.6221	1.4335	1.7737	1.701
20	1.5181	1.587	1.4003	1.4083	1.2986	1.587	1.4815
21	1.3957	1.4003	1.307	1.2986	1.3203	1.4377	1.3957
22	1.2071	1.307	1.2136	1.1694	1.094	1.2136	1.3203
23	1.1317	1.2136	1.0642	1.0562	1.094	1.1203	1.1506
24	.9335	.9997	1.0269	.9709	.9431	.9145	.9709
Max	1.6827	1.7177	1.587	1.6221	1.4335	1.7737	1.701
Min	.7468	.7922	.7468	.7468	.7922	.8192	.8402
Avg	1.2353	1.2223	1.1804	1.1451	1.0409	1.2368	1.2441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 205 / 11 KV VASANT BHUVAN FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0269	1.094	1.0642	1.0269	1.0669	1.0185	1.0269
2	.9896	1.0562	1.0269	.9709	1.0479	.9808	.9709
3	.9335	1.0185	.9335	.9335	.9808	.9526	.9335
4	1.0456	1.1317	.9896	.9896	1.094	1.0669	1.0456
5	1.1203	1.4901	1.1016	1.0642	1.1694	1.1694	1.1389
6	1.3443	1.773	1.307	1.2323	1.2449	1.6975	1.3443
7	1.587	1.7187	1.4377	1.4003	1.2826	1.6598	1.4937
8	1.5415	1.5181	1.643	1.531	1.3957	1.5278	1.4937
9	1.6598	1.5181	1.6827	1.4632	1.6095	1.5181	1.4706
10	1.5181	1.4706	1.829	1.4449	1.6278	1.4266	1.5364
11	1.5655	1.5415	1.701		1.6461	1.5061	1.4883
12	1.5546	1.5769	1.701	1.2803	1.6278	1.5061	1.4723
13	1.5466	1.5546	1.5546	1.3717	1.4998	1.4529	1.5546
14	1.4335	1.4449	1.4632	1.39	1.39	1.39	1.3535
15	1.4335	1.3717	1.4266	1.2986	1.2437	1.262	1.3169
16	1.358	1.3717	1.2803	1.3169	1.3203	1.2403	1.2403
17	1.3392	1.4937	1.4003	1.3203	1.358	1.4937	1.358
18	1.773	1.6244	1.587	1.5655	1.3769	1.7737	1.6461
19	2.0748	2.0725	1.8671	1.9805	1.8861	2.0538	2.0668
20	1.9936	1.9978	1.8671	1.9387	1.7924	1.9605	2.0119
21	1.8673	1.7177	1.6804	1.8107	1.7164	1.7737	1.9239
22	1.6975	1.4003	1.3256	1.5089	1.3769	1.4003	1.6598
23	1.358	1.307	1.251	1.358	1.2574	.1307	1.4901
24	1.0269	1.1317	1.1203	.9861	1.1317	1.1431	1.1203
Max	2.0748	2.0725	1.8671	1.9805	1.8861	2.0538	2.0668
Min	.9335	1.0185	.9335	.9335	.9808	.1307	.9335
Avg	1.4495	1.4748	1.4267	1.3558	1.3810	1.3794	1.4232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 207 / ATM FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0189	.0187	.0187	.0191	.0189	.0187
2	.0187	.0189	.0187	.0187	.0189	.0189	.0187
3	.0187		.0187	.0187	.0189	.0189	.0187
4	.0187	.0189	.0187	.0187	.0189	.0191	.0187
5	.0187	.0189	.0187	.0187	.0189	.0189	.0171
6	.0187	.0189	.0187	.0187	.0189	.0189	.0187
7	.0187	.0554	.0187	.0187	.0189	.0189	.0187
8	.0177	.0183	.0187	.0187	.0183	.0189	.0187
9	.0189	.0183	.0183	.0183	.0183	.0183	.0177
10	.0189	.0177	.0183	.0183	.0183	.0183	.0183
11	.0189	.0177	.0183		.0183	.0177	.0177
12	.0189	.0177	.0183	.0183	.0183	.0177	.0175
13	.0189	.0183	.0183	.0183	.0183	.0177	.0183
14	.0189	.0183	.0183	.0183	.0183	.0177	.0183
15	.0189	.0183	.0183	.0183	.0183	.0175	.0183
16	.0189	.0183	.0183	.0183	.0189	.0177	.0177
17	.0189	.0187	.0187	.0189	.0189	.0187	.0189
18	.0189	.0187	.0187	.0189	.0189	.0187	.0183
19	.0189	.0187	.0187	.0189	.0183	.0187	.0183
20		.0187	.0187	.0183	.0183	.0187	.0183
21	.0189	.0171	.0187			.0187	.0189
22	.0566	.0187	.0187	.0189	.0189	.0187	.0189
23	.0189	.0187	.0187	.0189		.0187	.0189
24	.0189	.0189	.0187	.0187	.0189	.0191	.0187
Max	.0566	.0554	.0187	.0189	.0191	.0191	.0189
Min	.0177	.0171	.0183	.0183	.0183	.0175	.0171
Avg	.0204	.0200	.0186	.0186	.0186	.0185	.0184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 208 / Medical(jublipark water NON SHEDDABLE WATER SUPPLY AND
works) Feeder KV- 11 / OUTGOING UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0189	.0187	.0187	.0191	.0189	.0187
2	.0187	.0189	.0187	.0187	.0189	.0189	.0187
3	.0187	.0189	.0187	.0187	.0189	.0189	.0187
4	.0187	.0566	.0187	.0187	.0189	.0189	.0187
5	.0187	.0566	.0187	.0187	.0566	.0566	.0187
6	.0187	.0566	.056	.056	.0566	.0566	.0187
7	.056	.0554	.056	.056	.0566	.0566	.0187
8	.0532	.0183	.056	.0543	.0549	.0566	.056
9	.0566	.0549	.0549	.0549	.0549	.0549	.0532
10	.0549	.0177	.0183	.0549	.0183	.0183	.0549
11	.0566	.0177	.0549		.0183	.0177	.0177
12	.0566	.0532	.0549	.0549	.0549	.0532	.0526
13	.0566	.0549	.0549	.0549	.0549	.0532	.0549
14	.0566	.0549	.0549	.0549	.0549	.0532	.0549
15	.0566	.0549	.0549	.0549	.0549	.0532	.0549
16	.0566	.0549	.0549	.0549	.0566	.0532	.0532
17	.0566	.056	.056	.0566	.0566	.0187	.0566
18	.0566	.056	.0187	.0566	.0566	.0187	.0549
19	.0566	.056	.0187	.0566	.0549	.0187	.0549
20	.0549	.056	.056	.0549	.0549	.056	.0549
21	.0566	.056	.056	.0549	.0566	.0543	.0566
22	.0566	.056	.056	.0566	.0566	.056	.0566
23	.0566	.056	.056	.0566	.0572	.056	.0566
24	.0187	.0566	.0187	.0187	.0189	.0189	.0187
Max	.0566	.0566	.056	.0566	.0572	.0566	.0566
Min	.0187	.0177	.0183	.0187	.0183	.0177	.0177
Avg	.0452	.0463	.0417	.0459	.0450	.0398	.0414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 201 / UNIVERSITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0178	.0176	.0183	.0173	.0174	.0187	.0164
2	.0174	.0176	.0183	.0175	.0172	.0187	.0167
3	.0175	.0175	.0183	.0173	.0172	.0187	.0168
4	.0176	.0175	.0187	.0173	.0177	.0187	.0171
5	.0178	.0175	.0187	.0173	.0177	.0187	.017
6	.0175	.018	.0183	.018	.0176	.0187	.0164
7	.0175	.0179	.0183	.0172	.0183	.0183	.0181
8	.018	.018	.0187	.0181	.0172	.0187	.0187
9	.0317	.0168	.0183	1.0031	.188	.0187	.0032
10	.0892	.0876	.0351	.0175	.0171	.0867	.0924
11	.1227	.1372	.0351	.0351	.0171	.12	.1478
12	.1602	.12	.0351	.0351	.0175	.1543	.1494
13	.1242	.12	.0526	.0343	.0171	.12	.1478
14	.1247	.12	.0514	.0514	.0171	.1208	.1463
15	.128	.1372	.0351	.0532	.0171	.1384	.1663
16		.1494	.0171	.0351	.0181	.1381	.1663
17	.1414	.1494	.0175	.0363	.0183	.1208	.1463
18	.0873	.0934	.0173	.0354	.0183	.0691	.0895
19	.0364	.0373	.0182	.0369	.0187	.0365	
20	.0356	.0187	.0182	.0182	.0183	.0179	.0362
21	.036	.0183	.0179	.0181	.0187	.0178	.0177
22	.0354	.0187	.0179	.0177	.0187	.0176	.0179
23	.0176	.0183	.0179	.0179	.0187	.0178	.0351
24	.0174	.0173	.0183	.0176	.0174	.0187	.0166
Max	.1602	.1494	.0526	1.0031	.188	.1543	.1663
Min	.0174	.0168	.0171	.0172	.0171	.0176	.0032
Avg	.0578	.0584	.0238	.0668	.0249	.0568	.0659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 202 / MAQBARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6779	1.7719	1.7924	1.6924	1.7321	1.7177	1.7588
2	1.6797	1.7339	1.6617	1.6349	1.6238	1.6244	1.6332
3	1.6024	1.6924	1.6244	1.6289	1.6651	1.587	1.7194
4	1.7194	1.8214	1.587	1.6204	1.7231	1.7741	1.7831
5	1.8799	1.8578	1.8111	1.8924	1.7975	2.0538	1.8396
6	2.5437	2.1874	2.2779	2.3889	1.9877	2.3899	2.5129
7	2.7482	2.6729	2.9874	2.536	2.3106	2.838	2.6863
8	3.0682	2.8959	3.3421	2.8771	2.7586	2.9687	2.9364
9	2.9493	2.9838	3.5288	2.7718	3.0996	3.0247	2.9275
10	2.5706	2.6155	3.1642	2.5972	2.9264	2.7618	2.6326
11	2.5293	2.2862	3.1459	2.2862	2.6337	2.4143	2.4646
12	2.0807	2.1948	2.963	2.268	2.4143	2.0668	2.2779
13	1.9631	2.0119	2.5789	2.0851	2.0119	2.0119	2.0351
14	1.9164	1.9774	2.0485	2.0144	1.8665	1.9378	1.922
15	1.765	1.6817	1.5524	1.848	1.7187	1.8034	1.7372
16		1.7551	1.7187	1.8107	1.8296	1.8391	1.848
17	1.8492	1.9791	1.822	1.9998	2.0165	2.0164	2.0144
18	2.396	2.3712	2.0591	2.2267	2.2779	2.2614	2.3261
19	2.9692	3.062	2.6502	2.9386	3.0434	3.0061	2.874
20	2.8254	2.838	2.6447	2.81	2.95	2.9079	2.7366
21	2.5266	2.5206	2.391	2.4927	2.6513	2.5449	2.4666
22	2.3362	2.4086	2.2151	2.2396	2.2779	2.2839	2.3422
23	2.0421	2.0911	2.0293	2.0517	2.1845	2.0538	2.0612
24	1.828	1.9035	1.8858	1.7737	1.7556	1.8473	1.8764
Max	3.0682	3.062	3.5288	2.9386	3.0996	3.0247	2.9364
Min	1.6024	1.6817	1.5524	1.6204	1.6238	1.587	1.6332
Avg	2.2377	2.2214	2.3117	2.1869	2.2190	2.2390	2.2255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 203 / SAI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1901	.1899	.1867	.2083	.2079	.1867	.2066
2	.1898	.1899	.1867	.1711	.2077	.1867	.1884
3	.1898	.1898	.1867	.1708	.189	.2054	.1886
4	.1899	.1905	.2054	.1896	.1901	.2054	.189
5	.1899	.1905	.2241	.2087	.1901	.1867	.1894
6	.2094	.2662	.2241	.2275	.2083	.1867	.2467
7	.2286	.2477	.2054	.2092	.1905	.1867	.2096
8	.2474	.1905	.1867	.2092	.1905	.2054	.2096
9	.2646	.2467	.2241	.2092	.2094	.2614	.2649
10	.2818	.2829	.2829	.2641	.2075	.3584	.2987
11	.3573	.3961	.2829	.2829	.1886	.3547	.3142
12	.3566	.3361	.2075	.3018	.1698	.3174	.3881
13	.3562	.3206	.1886	.2829	.1886	.3174	.3921
14	.3742	.3547	.2075	.2641	.2075	.3395	.3326
15	.358	.3547	.1886	.2263	.1886	.332	.4066
16		.3174	.1886	.2263	.1867	.3193	.3511
17	.3566	.2987	.1715	.1901	.1867	.3398	.3024
18	.2279	.2427	.1713	.171	.1867	.244	.2838
19	.2824	.2614	.2092	.2459	.2378	.3012	.303
20	.2818	.2402	.2268	.2252	.2801	.2945	.3184
21	.2641	.2427	.2452	.2442	.2427	.2932	.2625
22	.2445	.2241	.2454	.2254	.2054	.3106	.2614
23	.2459	.2241	.2273	.2064	.1867	.2566	.243
24	.2092	.2054	.2054	.2071	.2071	.2054	.2064
Max	.3742	.3961	.2829	.3018	.2801	.3584	.4066
Min	.1898	.1898	.1713	.1708	.1698	.1867	.1884
Avg	.2650	.2585	.2116	.2236	.2023	.2665	.2732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 204 / LANI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3168	.3168	.2427	.3155	.3161	.2801	.333
2	.2987	.2984	.2241	.2969	.303	.2427	.3148
3	.2981	.2609	.2218	.2789	.3021	.2987	.0336
4	.3174	.2993	.2614	.2972	.2996	.3361	.3381
5	.3361	.3184	.3174	.3719	.2987	.3921	.354
6	.3961	.4145	.4294	.5036	.3562	.4668	.5409
7	.547	.4929	.4668	.4706	.378	.5415	.5077
8	.477	.5303	.4481	.4909	.4715	.4668	.5292
9	.4343	.4715	.4668	.4706	.4334	.4481	.415
10	.3941	.3734	.4108	.3921	.3921	.3921	.3696
11	.3168	.3361	.3547	.3174	.3361	.2054	.3142
12	.2407	.3174	.2614	.3174	.2987	.2987	.2587
13	.2213	.3174	.2427	.2241	.2987	.2402	.2614
14	.2407	.2801	.2614	.2427	.2614	.2579	.2402
15	.2627	.168	.2614	.2614	.2614	.2244	.2402
16		.2614	.168	.2427	.2801	.2574	.2614
17	.2772	.2801	.2412	.2783	.2614	.2975	.2603
18	.2763	.3174	.2741	.2755	.3174	.2769	.2766
19	.4281	.4294	.3889	.4242	.4108	.4458	.4078
20	.4458	.4294	.4066	.4251	.4481	.4091	.4281
21	.4095	.3921	.3897	.3885	.3921	.4074	.4074
22	.4103	.3696	.3704	.3893	.3921	.3901	.4078
23	.3909	.3734	.37	.3344	.3361	.3708	.3897
24	.3177	.3361	.3174	.3155	.3155	.3174	.3529
Max	.547	.5303	.4668	.5036	.4715	.5415	.5409
Min	.2213	.168	.168	.2241	.2614	.2054	.0336
Avg	.3502	.3493	.3249	.3469	.3400	.3443	.3434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 205 / 11 KV PANCHHKI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6488	.7232	.7842	.6669	.6842	.7095	.7514
2	.6488	.6871	.7468	.6141	.6468	.7282	.6288
3	.6495	.6509	.7282	.6321	.6502	.7842	.6849
4	.6863	.695	.8029	.7217	.6907	.8775	.724
5	.7507	.7308	.9149	.8145	.7103	.9896	.769
6	1.0374	.9474	1.2696	.9177	.8861	1.3256	1.0708
7	1.1305	1.1294	1.2883	.1064	1.0342	1.363	1.1682
8	1.2637	1.2599	1.251	1.1459	1.1835	1.2883	1.319
9	1.1835	1.1248	1.1949	1.2173	1.3512	1.2696	1.2023
10	1.1134	1.0242	1.1888	1.0242	1.2071	1.0974	1.0719
11	.7499	.8131	.9877	.9694	1.0791	.9511	1.0082
12	.8943	.9694	1.2071	.8871	1.0608	.924	.924
13	.8761	.9149	1.0425	.8871	.9425	.8413	.8871
14	.7865	.7577	.7947	.7842	.7762	.7522	.7947
15	.6619	.7577	.7207	.6908	.7282	.6694	.6908
16		.7468	.6653	.7207	.7207	.5829	.7468
17	.695	.8962	.7163	.6788	.8589	.8466	.8545
18	1.0091	1.0642	.844	.9328	.9709	1.0791	1.0338
19	1.2712	1.3443	1.1595	1.262	1.2883	1.3182	
20	1.2071	1.2696	1.173	1.1487	1.1949	1.2633	1.283
21	1.0814	1.1016	1.0007	1.0531	1.0456	1.0951	1.0951
22	.9877	1.0269	.9471	.9763	1.0269	.9471	.9835
23	.8396	.8962	.0833	.8334	.9709	.8915	.8869
24	.7255	.7278	.8402	.7059	.7413	.7655	.7913
Max	1.2712	1.3443	1.2883	1.262	1.3512	1.363	1.319
Min	.6488	.6509	.0833	.1064	.6468	.5829	.6288
Avg	.9086	.9275	.9313	.8496	.9354	.9733	.9291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044223 / 33 KV GHATI SUBSTATION

Feeder No / Name : 201 / Kohinoor

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2241	.2241	.2218	.2218	.2172	.2195
2	.2218	.2172	.2218	.2218	.2241	.2195	.2241
3	.2195	.2218	.2241	.2172	.2218	.2172	.2241
4	.2195	.2561	.3326	.2614	.2614	.2587	.2172
5	.2667	.2987	.3292	.2926	.2587	.2865	.2218
6	.2614	.3292	.3696	.3045	.3361	.3109	.2587
7	.2987	.4163	.3734	.3841	.3734	.3841	.3361
8	.3734	.439	.4435	.4344	.3734	.4298	.4066
9	.4481	.4477	.4805	.439	.4805	.4207	.3982
10	.4024	.4066	.4805	.4024	.439	.4163	.4481
11	.3658	.3734	.4066	.3696	.4024	.3696	.3696
12	.2561	.3696	.3696	.3361	.4066	.3292	.3361
13	.2587	.2587	.3326	.2926	.3658	.2926	.2926
14	.2587	.2587	.2957	.2926	.2926	.2957	.2957
15	.2218	.2218	.2561	.2195	.2587	.2218	.2218
16	.2218	.2241	.2587	.2218	.2587	.2195	.2241
17	.2743	.2218	.2926	.2614	.2743	.2987	.2926
18	.3582	.3696	.3326	.2587	.362	.2957	.3224
19	.4525	.4435	.4119	.3658	.3761	.3658	.4435
20	.439	.3696	.4066	.4024	.4108	.4481	.3801
21	.3403	.3361	.3258	.3326	.3326	.3696	.3439
22	.3109	.2957	.3109	.2957	.2957	.3326	.2957
23	.2715	.2614	.2614	.2957	.2686	.2957	.2614
24	.2587	.2534	.2614	.2402	.2241	.2427	.2195
Max	.4525	.4477	.4805	.439	.4805	.4481	.4481
Min	.2195	.2172	.2218	.2172	.2218	.2172	.2172
Avg	.3009	.3131	.3334	.3068	.3216	.3141	.3022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044223 / 33 KV GHATI SUBSTATION

Feeder No / Name : 202 / Ghati Medical Express
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.3077	.2614	.2507	.2587	.2926	.2561
2	.2587	.2926	.2587	.2561	.2614	.2587	.2587
3	.2561	.2865	.2614	.2587	.2241	.2614	.2587
4	.3292	.2957	.3048	.2561	.2218	.2534	.2534
5	.3395	.2926	.2926	.2614	.2614	.2926	.2534
6	.3734	.2896	.3326	.2715	.2614	.2865	.2614
7	.3734	.3224	.3361	.3077	.2987	.3582	.2926
8	.4108	.4119	.3292	.3403	.3361	.362	.3658
9	.4481	.4706	.3361	.362	.3326	.4706	.439
10	.439	.3696	.2987	.4024	.3292	.5121	.4854
11	.4854	.2614	.2957	.3696	.3658	.4805	.5175
12	.4435	.2195	.2957	.3658	.2926	.4755	.5228
13	.4435	.4024	.2957	.3658	.2926	.5121	.4755
14	.4024	.4066	.2957	.3658	.2926	.5175	.4805
15	.0448	.439	.2926	.3696	.2957	.499	.4854
16	.439	.462	.2926	.3326	.2926	.4755	.4854
17	.3582	.4435	.3258	.3361	.3403	.3734	.4477
18	.3439	.4481	.3258	.3326	.3292	.3658	.362
19	.3841	.4108	.3475	.3658	.3292	.3658	.3801
20	.362	.3696	.2896	.3658	.3326	.3361	.3658
21	.3403	.3361	.3109	.3696	.3045	.2957	.3696
22	.3224	.3361	.2865	.3326	.3258	.2926	.3582
23	.3142	.2987	.2686	.3326	.3109	.2957	.2987
24	.2957	.3292	.2614	.2743	.2614	.2896	.2772
Max	.4854	.4706	.3475	.4024	.3658	.5175	.5228
Min	.0448	.2195	.2587	.2507	.2218	.2534	.2534
Avg	.3528	.3543	.2998	.3269	.2980	.3718	.3730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044223 / 33 KV GHATI SUBSTATION

Feeder No / Name : 203 / CANCER HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.037				.0358	
2		.0366				.0373	
3		.0362				.037	
4		.0373				.0358	.1494
5		.0377				.0362	
6		.0358				.0362	.037
7	.0373	.0549		.0373	.0373	.037	.037
8	.1109	.0543		.0366	.0373	.0366	.037
9	.1494	.1307		.1433	.056	.112	.1478
10	.1494		.0377	.2218	.0554	.2218	.1494
11	.1663	.1307	.037	.1494	.0554	.1478	.2402
12	.1663	.1307		.1109		.1494	.2241
13	.1463	.0739		.0554		.1109	.128
14	.112	.0747		.0554		.1109	.1109
15	.1494	.0739		.0554		.1038	.1109
16	.1494	.056		.037		.0924	.0739
17	.1267	.056	.037	.0373	.037	.0934	.0554
18	.0739	.0554		.037	.0373	.0924	
19	.0934	.037	.0362	.0366	.0362	.0549	.0358
20	.0924	.0373	.0373	.037	.0377	.056	.037
21	.0549	.0373	.037	.037		.0554	.0373
22	.056			.037	.0373	.0373	.0362
23	.056			.0373	.0373	.0373	.037
24	.0377	.0537				.037	
Max	.1663	.1307	.0377	.2218	.056	.2218	.2402
Min	.037	.0358	.0362	.0366	.0362	.0358	.0358
Avg	.1034	.0608	.0370	.0683	.0422	.0752	.0936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 201 / 11 KV MIDC (SANJAWARTHA) SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1524	.1524	.1334	.1524	.1524
2	.1524	.1524	.1524	.1524	.1334	.1334	.1524
3	.1715	.1524	.1524	.1524	.1334	.1334	.1524
4	.1715	.1524	.1524	.1524	.1334	.1334	.1524
5	.1715	.1715	.1715	.1524	.1524	.1334	.1524
6	.1715	.1905	.1715	.1524	.1715	.1715	.1524
7	.1905	.1715	.1334	.1524	.1715	.2096	.1715
8	.2096	.1905	.1524	.1905	.1905	.2096	.1905
9	.3239	.2858	.1334	.2286	.2286	.2286	.2477
10	.4382	.4382	.2096	.4001	.3048	.3429	.362
11	.5525	.5525	.2096	.4572	.4191	.5906	.4001
12	.5716	.5716	.2858	.5525	.4001	.5716	.5716
13	.4572	.4572	.2096	.4572	.3239	.6097	.6287
14	.5144	.5144	.2858	.4191	.4001	.6478	.5525
15	.5335	.7049	.2858	.4954	.362	.6097	.5716
16	.5525	.6478	.3048	.4763	.381	.5525	.5335
17	.5144	.4954	.2667	.4191	.2667	.4382	.4954
18	.3239	.362	.1715	.2667	.2477	.2477	.2667
19	.2477	.2858	.1715	.2477	.2096	.2286	.2286
20	.2096	.2286	.1524	.2096	.1905	.1715	.2096
21	.2286	.2286	.1524	.1715	.1905	.1715	.2096
22	.1905	.1715	.1524	.1715	.1905	.1524	.1905
23	.1715	.1715	.1334	.1524	.1715	.1524	.1524
24	.1715	.1715	.1715	.1334	.1524	.1905	.1524
Max	.5716	.7049	.3048	.5525	.4191	.6478	.6287
Min	.1524	.1524	.1334	.1334	.1334	.1334	.1524
Avg	.3088	.3183	.1889	.2715	.2358	.2993	.2937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 202 / 11 KV I.T.I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.7147	1.6956	1.6194	1.6956	1.7909	1.7718
2	1.848	1.6766	1.6766	1.6385	1.6956	1.7337	1.7337
3	1.7528	1.6766	1.7909	1.6956	1.7528	1.7147	1.8099
4	1.7909	1.6956	1.7147	1.7909	1.8671	1.7528	1.7528
5	1.8861	1.9052	1.9433	1.9814	2.0767	1.9814	1.8861
6	2.7625	2.572	2.4577	2.7054	2.2862	2.5339	2.8197
7	3.296	3.2769	2.8959	3.0864	2.8197	3.1245	2.9531
8	3.2007	3.3341	3.1245	3.2388	3.1245	3.3341	3.0102
9	3.0674	3.296	3.2769	2.8578	3.2769	2.8387	3.1245
10	2.6101	2.6101	3.2388	2.915	2.9531	2.4768	2.7625
11	2.7816	2.2481	2.8578	2.6101	2.8197	2.4577	2.6101
12	2.4196	2.1338	2.3815	2.2481	2.4196	2.0957	2.4577
13	2.1338	2.21	2.4196	2.0386	2.0957	2.0957	2.3053
14	1.9052	2.0195	2.0195	1.8099	1.9624	2.0195	1.8671
15	1.9243	1.8861	2.1338	1.9814	1.7337	1.9433	1.848
16	1.9052	2.0195	2.0767	1.829	1.848	2.21	2.0386
17	2.3434	2.4006	2.0767	2.1148	2.2862	2.4006	2.3434
18	2.5911	2.8197	2.3815	2.6482	2.5339	2.553	2.5911
19	3.1626	3.2579	3.0864	3.0483	3.1817	2.915	3.1245
20	3.0102	3.2769	2.8387	3.0864	3.1626	3.2198	3.1436
21	2.7054	2.6482	2.6673	2.4768	2.6101	2.7244	2.6292
22	2.1719	2.4958	2.3434	2.2481	2.2672	2.2862	2.4006
23	2.1148	2.6673	1.9624	2.0195	2.0957	2.1338	2.0195
24	1.848	1.848	1.8099	1.8671	1.8099	1.829	1.8861
Max	3.296	3.3341	3.2769	3.2388	3.2769	3.3341	3.1436
Min	1.6194	1.6766	1.6766	1.6194	1.6956	1.7147	1.7337
Avg	2.3688	2.4037	2.3696	2.3148	2.3489	2.3402	2.3704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 203 / 11 KV KAMAL NAYAN BAJAJ SHEDDABLE FEEDER HAVING WEEKLY
 EXPR Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2096	.2096	.2096	.1905	.2096
2	.2477	.2286	.2096	.2096	.2096	.1905	.2096
3	.2286	.2286	.2096	.2096	.2096	.1905	.2096
4	.2477	.1905	.2096	.2096	.2096	.1905	.2096
5	.2286	.1905	.2096	.2096	.2096	.2096	.2096
6	.2286	.1905	.1905	.2096	.1905	.1905	.2286
7	.2286	.2477	.2096	.2286	.1905	.2286	.2477
8	.2477	.2667	.2667	.2286	.2096	.2477	.2667
9	.2858	.2858	.2858	.2286	.2858	.2667	.2667
10	.2477	.2477	.2477	.2096	.1334	.2667	.2667
11	.1905	.2286	.2286	.2286	.0953	.2477	.2477
12	.1905	.1905	.1524	.1905	.0762	.2667	.2667
13	.1524	.1905	.2096	.1715	.0572	.1905	.2858
14	.1715	.2096	.2096	.1905	.0762	.1715	.2096
15	.2096	.2096	.1905	.2096	.0762	.2096	.2286
16	.2477	.2858	.2286	.2286	.1334	.2096	.2477
17	.2858	.2858	.2667	.2286	.1715	.2667	.3239
18	.3048	.3048	.3239	.2858	.2096	.2858	.3239
19	.2858	.3239	.3048	.2858	.2477	.3048	.4001
20	.3048	.2667	.2858	.2477	.2286	.2667	.2858
21	.2858	.2477	.2858	.2477	.2667	.2477	1.3146
22	.2667	.2667	.2477	.2667	.2286	.3048	.2667
23	.2096	.2667	.2477	.2477	.1905	.2667	.2477
24	.2477	.2286	.2477	.2477	.2286	.1715	.2286
Max	.3048	.3239	.3239	.2858	.2858	.3048	1.3146
Min	.1524	.1905	.1524	.1715	.0572	.1715	.2096
Avg	.2405	.2421	.2366	.2263	.1810	.2326	.3001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 204 / 11 KV GOLWADI SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9145	.9145	.8573	.8764	.8573	.8383
2	.9526	.8573	.9335	.9145	.9145	.8764	.8573
3	.9907	.8764	.8764	.8764	.8764	.9145	.9145
4	1.0288	.9145	.9145	.9335	.9145	.8764	.8764
5	1.0479	1.0669	.9907	.9907	.9907	.9145	1.105
6	1.3146	1.2193	1.105	1.1431	1.0669	1.105	1.2574
7	1.5623	1.4861	1.3908	1.3717	1.4289	1.4098	1.5242
8	1.5813	1.6194	1.5623	1.5242	1.6385	1.4861	1.6766
9	1.5623	1.5242	1.6194	1.6004	1.6575	1.4098	1.2765
10	1.5242	1.6385	1.7337	1.2765	1.6385	1.4861	1.5623
11	1.5432	1.5813	1.5242	1.3717	1.5432	1.467	1.5432
12	1.4289	1.5051	1.5432	1.5813	1.5242	1.3717	1.448
13	1.3908	1.4289	1.3336	1.4098	1.3146	1.3336	1.3717
14	1.3336	1.3717	1.2384	1.3146	1.086	1.2765	1.3146
15	1.4098	1.2384	1.1622	1.4098	1.1622	1.3527	1.2955
16	1.3717	.9907	1.1431	1.4098	1.2193	1.2955	1.4098
17	1.2955	1.2193	1.2193	1.3717	1.3717	1.3336	1.448
18	1.3717	1.3146	1.3146		1.2193	1.4289	
19	1.5432	1.3717	1.4289	1.467	1.2193	1.5051	1.6004
20	.3048	1.3717	1.2955	1.2955	1.3527	1.3717	1.448
21	1.2955	1.2955	1.1812	1.2384	1.1431	1.3336	1.3146
22	1.1622	1.1812	1.0669	1.086	1.1241	1.2003	1.1431
23	1.0288	1.1431	.9717	.9907	.9907	1.086	1.086
24	.9717	.9526	.9145	.8954	.9145	.9145	1.5051
Max	1.5813	1.6385	1.7337	1.6004	1.6575	1.5051	1.6766
Min	.3048	.8573	.8764	.8573	.8764	.8573	.8383
Avg	1.2447	1.2535	1.2241	1.2317	1.2162	1.2336	1.2964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 206 / 11 KV RAHUL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.5242	1.6004	1.5242	1.6004	1.6385	1.6956
2	1.6956	1.4861	1.6956	1.5623	1.5623	1.6956	1.6385
3	1.7718	1.5051	1.6385	1.6004	1.6956	1.7147	1.6956
4	1.7909	1.6004	1.6956	1.6956	1.7147	1.7337	1.7909
5	1.9052	1.8671	1.8861	1.9433	1.7909	1.8861	1.8861
6	2.4768	2.3243	2.3243	2.3624	2.0576	2.3815	2.4387
7	3.2007	3.1055	3.0483	2.7244	2.8197	3.2007	3.0293
8	3.2007	3.1626	3.3722	3.0293	3.1055	3.2769	3.1626
9	3.1626	3.0483	3.677	2.8959	3.3341	2.8769	3.1055
10	2.7435	2.553	3.4484	2.6482	2.9721	2.6863	2.5911
11	2.3624	2.2291	3.0483	2.4387	2.7816	2.3053	2.4577
12	2.2672	1.9814	3.2198	1.9814	2.5149	1.9814	2.2481
13	1.9624	2.0386	2.3815	2.0005	2.21	1.9052	1.9433
14	1.8099	1.8671	2.1338	1.7718	1.9433	1.829	1.6385
15	1.6575	1.6575	1.6956	1.5623	1.7337	1.7718	1.6766
16	1.6004	1.6956	1.6194	1.7147	1.7909	1.8671	1.7528
17	1.848	1.9814	1.8099	1.6766	2.0767	2.0386	2.0957
18	2.4196	2.8197	2.191	2.0195	2.553	2.4768	
19	3.0483	3.0674	2.6863	2.9531	2.9531	2.9531	3.315
20	2.7625	2.8197	2.6863	2.8959	2.7625	2.7816	2.8197
21	2.3624	.8764	2.3815	2.4196	2.4387	2.3815	2.4196
22		2.2862	2.1338	2.0957	2.1148	2.1719	2.1719
23	1.8099	2.2672	1.9052	1.7909	1.8099	1.8671	1.8861
24	1.6956	1.5623	1.6575	1.6575	1.5813	1.5813	2.6482
Max	3.2007	3.1626	3.677	3.0293	3.3341	3.2769	3.315
Min	1.6004	.8764	1.6004	1.5242	1.5623	1.5813	1.6385
Avg	2.2274	2.1386	2.3307	2.1235	2.2466	2.2084	2.2655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 207 / 11 KV M.I.T. EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.0953	.0953	.0953	.0953	.0953
6	.0953	.0953	.0953	.0953	.0953	.0953	.0953
7	.0953	.0953	.0953	.0953	.0762	.0762	.0762
8	.0762	.0762	.0762	.0762	.0572	.0762	.0953
9	.0572	.0572	.0381	.0381	.0381	.0381	.0572
10	.0191	.0381	.0381	.0381	.0953	.0381	.0381
11	.0191	.0381	.0381	.0381	.1143	.0191	.0381
12	.0191	.0381	.0381	.0572	.1334	.0381	.0572
13	.0381	.0381	.0381	.0572	.1143	.0381	.0381
14	.0191	.0381	.0381	.0572	.0953	.0381	.0381
15	.0381	.0381	.0381	.0381	.0953	.0381	.0381
16	.0572	.0572	.0572	.0381	.0762	.0381	.0953
17	.0953	.0953	.0953	.0762	.0381	.0762	.1143
18	.1143	.1143	.0953	.0953	.0762	.0953	
19	.1143	.1334	.0953		.0953	.1143	.1143
20	.0953	.1143	.0953	.0953	.0953	.1143	.1143
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.1143	.0953	.0953	.1143	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0381	.0953	.0953	.0953	.0953	.1143
Max	.1143	.1334	.1143	.0953	.1334	.1143	.1143
Min	.0191	.0381	.0381	.0381	.0381	.0191	.0381
Avg	.0754	.0778	.0770	.0762	.0897	.0754	.0820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 208 / 11kV MIDC(NIRLAP)

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.5716	.5906	.5716	.6097	.6287	.743
2	.6859	.5335	.6097	.5906	.6287	.6478	.6478
3	.7049	.5716	.5716	.6097	.6478	.6668	.724
4	.743	.6097	.6478	.6668	.6287	.724	.7621
5	.7621	.5906	.7621	.724	.724	.8002	.8573
6	.8573	.6668	.7621	.7811	.7621	.7621	.9335
7	1.1812	.8764	.7811	1.0479	.9335	.9526	1.0288
8	1.2384	1.0479	.9145	1.1431	.9907	1.0288	1.105
9	1.3908	1.2384	1.0669	1.2765	1.2574	1.105	1.2384
10	1.6385	1.2765	1.2955	1.6004	1.3908	1.4098	1.5051
11	1.2574	1.4098	1.3146	1.4861	1.2574	1.4861	1.6004
12	1.3146	1.3527	1.2574	1.5813	1.3146	1.4098	1.467
13	1.4098	1.1622	1.1431	1.3146	1.2384	1.3717	1.5432
14	1.3527	1.4098	1.0288	1.467	1.1431	1.3527	1.5432
15	1.2384	1.3717	1.0288	1.1812	1.0669	1.5242	1.5051
16	1.1812	1.2955	1.0288	1.3717	.9717	1.3146	1.2955
17	1.2193	1.1622	.9145	1.4098	.9145	1.3336	1.4098
18	1.4289	1.2384	.8954	1.448	.9717	1.448	
19	1.3336	1.2574	.9335	1.2765	.9526	1.3527	1.1622
20	1.0669	1.0288	.8383	1.3336	.8764	1.2384	1.0098
21	1.0098	1.0669	.9145	1.0288	.8002	1.2384	1.0098
22	1.105	.9907	.8573	.8573	.8002	1.086	.9526
23	.8383	.9145	.724	.8192	.6859	1.105	.8192
24	.6859	.5906	.6668	.6478	.5906	.5525	1.448
Max	1.6385	1.4098	1.3146	1.6004	1.3908	1.5242	1.6004
Min	.6668	.5335	.5716	.5716	.5906	.5525	.6478
Avg	1.0963	1.0098	.8978	1.0931	.9232	1.1058	1.1439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 201 / 11 KV HOLYCROSS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8347	1.869	1.9774	1.9589	1.9589	1.9959	1.9589
2	1.6632	1.7833	1.9589	1.9022	1.885	1.9035	1.9035
3	1.6632	1.8004	1.848	1.8656	1.6632	1.885	1.9035
4	1.8004	1.8004	1.9404	2.0698	2.0538	1.9589	1.9035
5	2.1434	2.0576	2.4272	2.2731	2.4646	2.0698	2.1658
6	2.8978	2.8292	2.6513	2.809	2.6242	2.6427	2.95
7	3.2407	2.9664	3.0862	3.1786	2.8567	3.2487	3.3608
8	3.4294	3.3779	3.5852	3.6035	3.3608	3.4355	3.5475
9	3.155	3.4979	3.7529	3.5662	3.4728	3.4541	3.5101
10	3.0007	3.4374	3.3421	3.3573	3.1417	3.1367	3.1971
11	2.6749	3.1971	3.0308	2.8166		3.0123	3.006
12	2.0062	2.9014	2.7073	2.6242	2.7446	2.5503	2.838
13	2.5377	2.5688	2.4025	2.3285	2.4326	2.6612	2.7633
14	2.0919	2.4394	2.1765	1.9879	2.0302	2.5503	2.5019
15	2.2462	2.2291	2.0668	1.9774	1.957	2.4209	2.2634
16	2.1948	2.3148	1.9547	1.9404	1.9035	2.5318	2.2634
17	2.5873	2.4006	2.0233	2.1776	1.989	2.4006	2.3663
18	2.6797	2.5034	2.1091	2.4863	2.2634	2.5549	2.4863
19	3.2526	3.0521	2.7435	2.8464	2.7435	3.0864	3.1722
20	3.0994	2.9492	2.8292	2.7778	2.7778	2.8807	2.9664
21	2.8858	2.572	2.6235	2.572	2.4863	2.5892	2.6749
22	2.6699	2.5873	2.4006	2.3491	2.3834	2.4177	2.5034
23	2.0911	2.3101	2.3285	2.2916	2.2405	2.4025	2.4025
24	1.9204	1.9033	2.0698	2.0513	2.0513	2.0485	2.1253
Max	3.4294	3.4979	3.7529	3.6035	3.4728	3.4541	3.5475
Min	1.6632	1.7833	1.848	1.8656	1.6632	1.885	1.9035
Avg	2.4903	2.5562	2.5015	2.4921	2.4124	2.5766	2.6139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 202 / 11 KV CANTONMENT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.9259	1.0349	.961	.9694	.961	.9795
2	.823	.8916	.961	.961	.905	.961	.961
3	.8059	.8573	.8871	1.0631	.8688	.8871	.924
4	.8402	.8573	.961	1.0745	.8779	.8871	.8288
5	1.0288	.8573	1.0829	1.1203	.9511	1.0425	.9979
6	1.286	1.2174	1.2136	1.363	1.0534	1.2254	1.2567
7	1.4403	1.3546	1.423	1.5154	1.1643	1.4937	1.4784
8	1.406	1.3889	1.5524	1.587	1.5123	1.531	1.4563
9	1.3717	1.3717	.6348	1.5497	1.6409	1.4415	1.4563
10	1.3032	1.386	1.6409	1.3769	1.5708	1.3256	1.3121
11	1.0802	1.3352	1.4901	1.1888	1.4045	1.1643	1.1458
12	1.1888		1.1458	1.1706	1.1763	1.1157	.9979
13	.9431	1.0791	1.1888	1.0349	1.2437	1.0829	1.1088
14	1.046	.9774	.9492	.9774	1.0425	1.0456	1.1643
15	.9431	.9259	.9522	.9313	1.0029	.8688	.9259
16	.9431	.9088	.8573	.9979	1.0387	.9425	.9602
17	1.1888	.9431	.8916	1.0117	.9945	.9431	1.0631
18	1.2136	1.0631	.9945	1.1145	1.1317	1.1145	1.1488
19	1.6461	1.406	1.3717	1.4403	1.4746	1.3546	1.5432
20	1.6804	1.4746	1.4575	1.4403	1.4403	1.3717	1.5432
21	1.5466	1.4232	1.406	1.406	1.3889	1.406	1.4746
22	1.4523	1.2689	1.2517	1.2517	1.3032	1.3032	1.3717
23	1.2826	1.2382	1.2197	1.2197	1.2382	1.2936	1.3306
24	1.0117	.9774	1.1088	1.0534	1.0719	1.0534	1.0719
Max	1.6804	1.4746	1.6409	1.587	1.6409	1.531	1.5432
Min	.8059	.8573	.6348	.9313	.8688	.8688	.8288
Avg	1.1818	1.1360	1.1532	1.2004	1.1861	1.1590	1.1875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 203 / 11 KV M.E.S. EXPRESS
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3429	.3429	.3467	.3391	.3315	.373
2	.3429	.3429	.3429	.3429	.3429	.3315	.3353
3	.3429	.3429	.3086	.3772	.3086	.3353	.3391
4	.3772	.3429	.3052	.4458	.3086	.373	.373
5	.4115	.3429	.4458	.5895	.3772	.4115	.4801
6	.4973	.6001	.5731	.5258	.4908	.5731	.6154
7	.583	.6516	.6283	.5792	.5544	.6283	.6653
8	.6344	.6516	.7842	.6653	.5975	.6722	.7095
9	1.0288	.583	.6283	.6516	.7392	.5121	.5914
10	.5316	.543	.5853	.4268	.6283	.4733	.5373
11	.583	.3681	.4344	.4024	.5068	.5853	.5609
12	.5144	.298	.4163	.4207	.4668	.5175	.4066
13	.3429	.2591	.3681	.3506	.3155	.4251	.4108
14	.3086	.2915	.2591	.0953	.2835	.3258	.3292
15	.2743	.2915	.2332	.0953	.2629	.3109	.2743
16	.3258	.2743	.2915	.0953	.2374	.3012	.3086
17	.3155	.3429	.4287	.0171	.2915	.4287	.3086
18	.4115	.4287	.4458		.4287	.5144	.4115
19	.4793	.5487	.5487	.6687	.6001	.583	.6344
20	.4801	.6344	.6001	.6516	.6344	.6516	.6687
21	.4877	.6001	.583	.6516	.5316	.5487	.583
22	.3963	.4801	.4801	.4801	.4801	.5144	.4801
23	.2892	.3772	.3887	.4024	.4359	.407	.4024
24	.3601	.3772	.3429	.3467	.3772	.3277	.373
Max	1.0288	.6516	.7842	.6687	.7392	.6722	.7095
Min	.2743	.2591	.2332	.0171	.2374	.3012	.2743
Avg	.4449	.4298	.4486	.4186	.4391	.4618	.4655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 204 / MILIND COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6859	.5792	.5144	.5144	.5213	.5281
2	.6516	.6516	.4938	.3948	.5144	.5281	.5281
3	.6516	.6516	.4172	.5075	.4858	.5281	.535
4	.6859	.6516	.423	.5075	.4572	.6584	.5281
5	.7716	.6516	.423	.5716	.5007	.5792	.695
6	.8916	.9602	.6584	.6935	.5952	.6584	.7232
7	1.1317	.9945	.7545	.6539	.6539	.7545	.4146
8	1.0288	.5144	.7087	.6828	.7042	.7659	.7316
9	.9602	.9945	.8169	.6722	.743	.7042	.7042
10	.9259	.6563	.6969	.6836	.6962	.8916	.6836
11	.823	.6737	.743	.6573	.7183	.6287	.6737
12	.6036		.7042	.631	.6508	.6219	.6219
13	.7545	.7895	.5533	.6358	.6859	.5952	.6584
14	.6859	.823	.5411	.5952	.6203	.6203	.57
15	.6859	.8573	.5075	.5357	.9877	.5335	.6859
16	.6859	.7202	.6173	.5792	.5716	.4938	.6859
17	.5182	.7716	.6859	.703	.7202	.4572	.7202
18	.631	.8573	.7545	.8916	.8916	.7716	.9259
19	.8779	1.0974	.9945	1.0974	1.0974	1.0974	1.1317
20	.9374	1.0974	1.0288	1.0802	1.0802	1.0631	1.0974
21	.7895	.8459	.9602	.9602	.9602	.9602	.9774
22	.8535	.9431	.8573	.8745	.9088	.9259	.9431
23	.5053	.6767	.6203	.6203	.6287	.6371	.6859
24	.6344	.539	.5868	.5716	.6203	.5716	.5639
Max	1.1317	1.0974	1.0288	1.0974	1.0974	1.0974	1.1317
Min	.5053	.5144	.4172	.3948	.4572	.4572	.4146
Avg	.7640	.7871	.6719	.6798	.7086	.6903	.7089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 201 / 11 kV Dishanagari Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0635	.0597	.679	.6413	.0641	.6413	.0641
2	.0635	.0597	.679	.679	.0641	.6413	.0641
3	.0641	.0604	.679	.679	.0641	.6413	.0641
4	.0641	.0747	.6413	.7545	.0717	.679	.0679
5	.0679	.0859	.7167	.7922	.0784	.7545	.0754
6	.0981	.0943	.7922	.1132	.1056	.9431	.0943
7	.1132	.1072	1.1317	1.2826	.1132	1.2449	.1232
8	.1232	.1195	1.2449	1.1949	.1195	1.2323	.1158
9	.1109	.112	1.1576	1.1949	.1183	1.1203	.1109
10	.9335	.0914	.1035	.0951	.1146	.0941	.0988
11	.8501	.0878	.0914	.0833	.0951	.0833	.0961
12	.7392	.0732	.0833	.0688	.0833	.0724	.0813
13	.695	.0652	.076	.0652	.0768	.0658	.0628
14	.6584	.0652	.0724	.0652	.0695	.0622	.0695
15	.6219	.0652	.0688	.0652	.0695	.0652	.0724
16	.6219	.0652	.0688	.0652	.0732	.0695	.7682
17	.724	.076	.0732	.0681	.7682	.0752	.8048
18	.7602	.0833	.0732	.0796	.7964	.0805	.7964
19		.1035	.0934	.1035	1.0829	.1035	1.1088
20	1.1203	.1046	.1008	.1008	1.0082	.1072	1.1203
21	1.0082	.0971	.0971	.0971	1.0082	.1008	1.0082
22	.0896	.0934	.8962	.0896	.8962	.0934	.9709
23	.0822	.8589	.8215	.0822	.7468	.0747	.8589
24	.0672	.0672	.7167	.7468	.0754	.7167	.0672
Max	1.1203	.8589	1.2449	1.2826	1.0829	1.2449	1.1203
Min	.0635	.0597	.0688	.0652	.0641	.0622	.0628
Avg	.4235	.1154	.4649	.3836	.3235	.4068	.3652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 202 / 11 kV Deolai Chowk Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1083	.112	1.2826	1.1694	.1094	1.1317	.1132
2	.1083	.112	1.2826	1.1317	.1094	1.1317	.1132
3	.1094	.112	1.2449	1.1317	.1094	1.1317	.1132
4	.1132	.1307	1.1694	1.1694	.1207	1.1694	.1169
5	.1169	.1382	1.3203	1.2071	.1232	1.2449	.1245
6	.1509	.1509	1.4335	1.4712	.1698	1.5844	.1584
7	.1886	.194	1.8484	1.8484	.1811	2.1879	.2188
8	.1979	.1904	1.9993	1.8671	.1867	1.8671	.1979
9	.1867	.168	.2054	1.7924	.1885	1.643	.1663
10	1.5684	.1646	.1811	.1573	.1737	.1463	.1536
11	1.2197	.1463	.1589	.139	.1663	.1353	.139
12	1.1458	.128	.1317	.128	.1478	.1244	.1244
13	1.0974	.1244	.1207	.1171	.1244	.1134	.1171
14	1.0242	.1158	.1207	.1134	.1146	.1207	.1207
15	1.0242	.1134	.1171	.1134	.1146	.1207	.1231
16	1.3169	.1097	.1134	.1171	.112	.1183	1.2803
17	1.3535	.128	.1207	.1244	1.2197	.1244	1.2803
18	1.3676	.1353	.128	.128	1.2803	.1382	1.4266
19		.1848	.1643	.1755	1.7924	.183	1.8671
20	1.8671	.183	.1718	.1755	1.848	.1867	1.9044
21	1.7924	.1755	.168	.168	1.643	.1792	1.8671
22	.168	.1643	1.5684	.1531		.168	1.5684
23	.1531	.8676	1.307	.1307	1.3817	.1568	1.3817
24	.1344	.1307	1.3203	1.2323	.1811	1.3203	.1382
Max	1.8671	.8676	1.9993	1.8671	1.848	2.1879	1.9044
Min	.1083	.1097	.1134	.1134	.1094	.1134	.1132
Avg	.7180	.1742	.7366	.6651	.5043	.6845	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 203 / 11 kV Sara Siddhi Feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.112	1.3957	1.3203	.1245	1.2826	.132
2	.112	.1283	1.3203	1.3203	.1245	1.2826	.132
3	.1132	.112	1.3203	1.5466	.1245	1.2826	.132
4	.0754	.1307	1.358	1.3957	.1396	1.3957	.1509
5	.1433	.1494	1.5089	1.5466	.168	1.3957	.1735
6	.2188	.2037	1.8861	1.8861	.2226	2.2634	.1886
7	.2754	.2651	2.6406	2.6406	.249	2.6406	.2427
8	.2829	.2651	2.7161	2.6139	.2678	2.6139	.2651
9	.2166	.2166	2.726	2.3525	.2539	2.1658	.2128
10	.1774	.1885	.2241	.1942	.2241	.1792	.2033
11	.1589	.1552	.1848	.1589	.1922	.1552	.1755
12	.1339	.1368	.1552	.1368	.1663	.1353	.1456
13	.1303	.1317	.139	.1353	.1478	.1244	.1294
14	.1122	.1405	.1368	.128	.1331	.1244	.1331
15	.1097	.1405	.1317	.1294	.1368	.1331	.1368
16	.1317	.1441	.1331	.1331	.1368	.1405	1.3535
17	1.5203	.1463	.139	.139	1.6461	.1427	1.5729
18	1.6651	.1756	.1412	.1593	1.6651	.1719	1.6095
19	2.2405	.2241	.2054	.2315	2.2916	.2292	2.3525
20	2.4272	.239	.2166	.2241	2.3152	.2278	2.3525
21	2.0538	.2166	.2054	.2054	2.0911	.2054	2.2405
22	.1999	.1979	1.8671	.1904	1.8671	.1942	1.9044
23	.1718	1.7353	1.6804	.168	1.643	.1643	1.7177
24	.1307	.127	1.5089	1.4937	1.5089	1.2826	3.5765
Max	2.4272	1.7353	2.726	2.6406	2.3152	2.6406	3.5765
Min	.0754	.112	.1317	.128	.1245	.1244	.1294
Avg	.5380	.2368	.9975	.8521	.7433	.8305	.8847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 202 / IRB

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.5853	.6348	.6161	.5914	.5975	.5975
2	.5975	.5914	.5975	.5975	.5914	.6348	.5601
3	.6161	.6219	.5975	.5975	.6283	.5975	.5601
4	.6161	.6584	.6413	.5975	.6283	.6348	.5601
5	.7655	.7762	.7545	.7655	.7023	.7167	.7468
6	1.0829	1.0242	1.094	1.1389	.924	1.0185	1.0269
7	1.3443	1.2437	1.2826	1.307	1.1458	1.2696	1.307
8	1.307	1.2936	1.2696	1.307	1.307	1.307	1.2696
9	1.1203	1.0608	1.2567	1.1949	1.2323	1.1827	1.0719
10	.9145	.924	1.1706	1.0242	.9979	.924	.8413
11	.9145	.8326	.9877	.8048	.8779	.695	.8413
12	.7602	.7522	.9328	.7316	.815	.7316	.8326
13	.6805	.6733	.7421	.6447	.7522	.7164	.6447
14	.6805	.7087	.7522	.5609	.6878	.6805	.6268
15	.6805	.6733	.724	.6584	.6154	.7011	.6379
16	.7087	.6447	.7164	.6516	.724	.7011	.6516
17	.7712	.6379	.7522	.724	.6805	.7164	.788
18	.8413	.8954	.8326	.8238	.8505	.8507	.9214
19	1.0745	1.0029	.9709	1.0242	1.0974	1.1203	1.1088
20	1.0242	1.0349	1.0082	.9145	1.0349	.9896	.8962
21	.9145	.9335	.8589	.8413	.8871	.8589	.8589
22	.8413	.8215	.8215	.7316	.7762	.8215	.7842
23	.695	.7095	.7282	.6653	.6722	.7095	.7095
24	.6722	.6099	.6348	.6535	.6219	.5975	.8962
Max	1.3443	1.2936	1.2826	1.307	1.307	1.307	1.307
Min	.5975	.5853	.5975	.5609	.5914	.5975	.5601
Avg	.8441	.8212	.8651	.8157	.8267	.8239	.8225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 203 / Nathvalley

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.0242	1.0829	1.0456	.9877	1.0719	1.0829
2	1.0082	1.0059	1.0456	1.0082	.9694	1.0349	1.0456
3	1.0082	1.0164	1.0082	1.0082	1.0349	.9979	1.0456
4	1.0082	1.0534	1.0082	1.0082	1.0164	1.0349	1.0456
5	1.1576	1.1827	1.0829	1.1016	1.0349	1.1203	1.2323
6	1.6244	1.4632	1.4335	1.531	1.2936	1.4937	1.531
7	1.9418	1.848	1.6804	1.7737	1.6263	2.0165	1.8484
8	1.7177	1.9404	1.7924	1.9231	1.7187	1.7177	1.6057
9	1.6244	1.7924	1.7741	1.7364	1.5684	1.5927	1.6078
10	1.4632	1.5364	1.6651	1.6095	1.4784	1.39	1.4299
11	1.3535	1.3756	1.5181	1.3169	1.1584	1.3169	1.2437
12	1.2071	1.1462	1.3169	1.1706	1.1462	1.0974	1.2437
13	1.0029	1.0631	1.2308	1.0387	1.0029	1.0745	1.1462
14	1.0029	1.0517	1.0566	.9313	1.0136	1.0387	1.0745
15	.9922	.9922	.9955	.9313	.9774	.9816	.9816
16	1.0166	1.0277	1.0029	.9671	1.1827	1.0029	1.0387
17	1.182	1.1694	1.182	1.0745	1.4266	1.0745	1.0745
18	1.3032	1.2308	1.2127	1.1706	1.5203	1.2489	1.3253
19	1.5203	1.5043	1.4937	1.4327	1.6263	1.5684	1.5893
20	1.6263	1.5893	1.531	1.5729	1.5524	1.6244	1.5154
21	1.4632	1.4784	1.4563	1.4784	1.4632	1.5497	1.4415
22	1.3756	1.4045	1.4003	1.3169	1.3676	1.4563	1.3306
23	1.1584	1.2197	1.2323	1.1949	1.2323	1.2883	1.307
24	1.1016	1.0974	1.0829	1.0642	1.0242	1.0719	1.1389
Max	1.9418	1.9404	1.7924	1.9231	1.7187	2.0165	1.8484
Min	.9922	.9922	.9955	.9313	.9694	.9816	.9816
Avg	1.2877	1.3006	1.3036	1.2669	1.2676	1.2860	1.2886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 205 / Walmi EXPRESS
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0183	.0154	.0187	.0183	.0156	.0187
2	.0187	.0018	.0156	.0187	.0183	.0156	.0187
3	.0187	.0185	.0154	.0187	.0185	.0156	.0187
4	.0187	.0187	.0156	.0187	.0185	.016	.0187
5	.0187	.0187	.0158	.0187	.0185	.0162	.0187
6	.0187	.0183	.0185	.0187	.0185	.017	.0187
7	.0187	.0185	.0187	.0187	.0185	.0185	.0187
8	.0187	.0187	.0175	.0187	.0187	.0185	.0187
9	.0187	.0187	.0177	.0187	.0189	.0171	.0185
10	.0183	.0185	.0177	.0185	.0183	.0185	.0181
11	.0732	.0179	.0183	.0183	.0158	.0183	.0366
12	.0732	.0905	.0183	.0183	.0173	.0732	.0366
13	.0724	.0183	.0181	.0179		.0362	.0179
14	.0716	.0181	.0179	.0179	.0173	.0351	.0179
15	.0716	.0181	.0181	.0179	.0175	.0351	.0179
16	.0701	.0181	.0179	.0179	.0173	.0343	.0171
17	.0179	.0177	.0179	.0175	.0179	.0179	.0162
18	.0181	.0149	.0181	.0175	.0137	.0181	.0151
19	.0183	.0158	.0187	.0183	.0162	.0187	.016
20	.0183	.0162	.0187	.0185	.0156	.0187	.016
21	.0179	.0154	.0187	.0185	.0152	.0187	.016
22	.0183	.0152	.0187	.0185	.0171	.0187	.016
23	.0183	.0152	.0187	.0183	.0168	.0187	.016
24	.0187	.0183	.0156	.0187	.0183	.0156	.0187
Max	.0732	.0905	.0187	.0187	.0189	.0732	.0366
Min	.0179	.0018	.0154	.0175	.0137	.0156	.0151
Avg	.0319	.0199	.0176	.0184	.0174	.0227	.0192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 206 / Nakshatrawadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.8048	.8215	.8215	.8048	.8131	.8215
2	.8215	.7865	.8215	.8215	.7682	.8131	.8029
3	.8215	.823	.7842	.8215	.8131	.8131	.8029
4	.8215	.8871	.7842	.8215	.8316	.8501	.8215
5	.9896	1.0082	.9335	.9335	.8871	.9709	.9896
6	1.307	1.2936	1.307	1.2323	1.1088	1.3817	1.4003
7	1.6057	1.5684	1.4563	1.4937	1.4045	1.6057	1.643
8	1.7551	1.6804	1.6632	1.5497	1.643	1.7002	1.8298
9	1.6278	1.4937	1.5524	1.4937	1.6804	1.5364	1.6095
10	1.3432	1.39	1.4685	1.5339	1.5154	1.4784	1.4529
11	1.3169	1.2894	1.3112	1.448	1.3253		1.3169
12	1.1584	1.0985	1.182	1.2803	.7975	1.2178	1.2178
13	1.0277	1.0166	1.0576	1.182	1.1218	1.0745	1.1462
14	1.0166	.9709	.9882	1.0517	1.0517	1.0166	1.0517
15	1.0517	1.0749	1.0341	1.0387	1.0166	1.0517	1.0166
16	1.0745	1.0867	.9602	.9816	.8505	1.0745	1.0059
17	1.086	1.0517	1.0166	1.0387	.9465	.9602	.9602
18	1.182	1.0985	.9465	1.0745	1.0056	1.1163	1.0631
19	1.3394	1.4045	1.307	1.3032	1.267	1.3169	1.3306
20	1.4266	1.4045	1.2323	1.2803	1.39	1.363	1.3169
21	1.2071	1.2071	1.1949	1.134	1.2437	1.251	1.2197
22	1.086	1.1088	1.1016	1.0242	1.0349	1.0829	1.0719
23	.9511	.8871	.9896	.9145	.8871	.9328	.961
24	.8589	.8501	.8402	.8589	.8501	.8316	.8775
Max	1.7551	1.6804	1.6632	1.5497	1.6804	1.7002	1.8298
Min	.8215	.7865	.7842	.8215	.7682	.8131	.8029
Avg	1.1541	1.1369	1.1148	1.1306	1.0936	1.1414	1.1554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 201 / 11 KV DEOGIRI VALLEY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7266	.8291		.7266		.7266	.8299
2	.7266			.692		.7266	.7922
3	.692			.692		.692	.7545
4	.7612			.7266		.692	.7545
5	.8996			.8304		.7958	.8299
6	1.1417	1.094		.9688		1.0034	1.094
7	1.1417			1.2109		1.0726	1.3203
8		1.3203		1.2455		1.1071	1.3203
9	1.1763			1.1763		1.1071	1.2449
10	1.1317				1.2109	.9431	
11			1.038		1.0034	.9808	
12			1.0034		.9342	1.0562	
13			.9688		.8996	1.0562	
14			.8996		.8304	.8676	
15			.8304		.7958	.9431	
16			.7612		.7612	.9808	
17			.7958		.8304	1.0185	
18			.8996		.9688	1.094	
19			1.1763		1.1417	1.2071	
20			1.038		1.0726	1.1317	
21			1.0034		1.0034	1.0562	
22			.865		.865	.9808	
23			.7958		.7958	.9054	
24		.083	.7266		.7612		.8299
Max	1.1763	1.3203	1.1763	1.2455	1.2109	1.2071	1.3203
Min	.692	.083	.7266	.692	.7612	.692	.7545
Avg	.9330	.8316	.9144	.9188	.9250	.9628	.9770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 203 / 11 KV PRIYA COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7612	.0905		.7958		.7958	.9054
2	.7266	.8299		.7958		.7612	.8299
3	.7266	.7545		.7612		.7612	.7545
4	.7958	.7545		.7958		.7266	.7545
5	1.1417			.865		.7958	.9808
6	1.3493	1.358				1.5915	1.4335
7	1.5915			1.5569		1.5915	1.7353
8	1.6953	.1735		1.6261		1.6261	.1735
9	.1584	1.5844		1.5915		1.4531	.1584
10					1.4877	1.1317	
11	1.1317		1.2801		1.1763	.1132	
12			1.1763		1.038	.9808	
13			1.038		.9688	.9808	
14			.9688		.865	.8299	
15	.9054		.865		.7958	.9808	
16	.9054		.7612		.7612	.083	
17	.9054		.7266		.8304	.0905	
18	.9808		.9342		.9688	1.2826	
19	1.5844		1.3493		1.4877	.1372	
20	1.5089		1.3147		1.3147	1.4335	
21	1.358		1.2109		1.3147	1.4335	
22	1.1317		1.1071			.1283	
23	1.0562		1.0034		1.1071	1.1317	
24	.1433	.0892	.8304		.8996		.0981
Max	1.6953	1.5844	1.3493	1.6261	1.4877	1.6261	1.7353
Min	.1433	.0892	.7266	.7612	.7612	.083	.0981
Avg	1.0279	.7043	1.0404	1.0985	1.0726	.9061	.7824

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 204 / 11 KV PETHE NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8304	.8299		.7612		.7612	.8299
2	.7612			.7266		.7266	.7545
3	.7266	.7545		.692		.692	.7545
4	.7612			.692		.692	.7545
5	.9688	1.094		.7612		.8304	1.094
6	1.2109	1.5089		1.3147		1.5223	1.5089
7	1.5915			1.5915		1.6261	1.8107
8	1.7645	1.7353		1.6261		1.7645	.1811
9	1.5569			1.6261		1.4185	1.5844
10	1.8391				1.5223	1.2449	
11			1.3147		1.1417	1.1317	
12			1.1071		1.0726	.9054	
13			.865		1.0034	.9054	
14			.8304		.9342		
15			.7612		.865		
16			.692		.7958		
17			.7958		.8996		
18			1.0034		1.1763		
19			1.4185				
20			1.3839		1.4185		
21			1.2801		1.2455	1.6975	
22			1.1417		1.1417	1.358	
23			.9342		.9688	1.094	
24		.9054	.8304		.8304		.9054
Max	1.8391	1.7353	1.4185	1.6261	1.5223	1.7645	1.8107
Min	.7266	.7545	.692	.692	.7958	.692	.1811
Avg	1.2011	1.138	1.0256	1.0879	1.0726	1.1482	1.0178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 206 / 11 KV DARGA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2768	.3395		.3114		.2768	.3395
2	.2768			.3114		.2768	.3018
3	.2422	.3018		.2768		.2422	.3018
4	.3114	.3018		.2768		.2768	.3018
5	.346	.3018		.346		.3114	.3018
6	.4844	.4527		.4152		.519	.4527
7				.5536		.5536	.6036
8	.5882	.6036		.5882		.6228	.5658
9	.4498			.4498		.4498	.4904
10					.4498	.415	
11			.519		.4498	.2641	
12			.4844		.3806	.3772	
13			.4844		.346	.3772	
14			.4498		.3114	.3772	
15			.4152		.2768	.3772	
16			.346		.2768	.3395	
17			.2768		.3114	.415	
18			.3114		.3806	.4904	
19			.5882		.6228	.5658	
20			.519		.519	.5281	
21			.4844		.4498	.5281	
22			.4152		.3806	.4527	
23			.3806		.3114	.4527	
24		.3772	.346		.2768		.3772
Max	.5882	.6036	.5882	.5882	.6228	.6228	.6036
Min	.2422	.3018	.2768	.2768	.2768	.2422	.3018
Avg	.3720	.3826	.4300	.3921	.3829	.4126	.4036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 207 / 11 KV RAMGOPAL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1038	.1509		.1384		.1038	.1509
2	.1038	.1372		.1384		.1038	.1509
3	.1038	.0754		.1038		.1038	.1509
4	.1384	.1372				.1384	.1509
5	.173	.1509		.0187		.1384	.1509
6	.2076	.2263		.2076		.3114	.2263
7	.3114			.2422		.346	.3772
8	1.2109			.2768		.346	.3772
9	.3114			.2768		.2768	.3395
10	.2641				.2768	.2263	
11	.2263		.2768		.2422	.2263	
12	.2263		.2422		.2076	.2263	
13	.2263		.2422		.173	.1886	
14	.2263		.2076		.173	.1886	
15	.1886		.173		.173	.1886	
16	.1886		.173		.2076	.2263	
17	.1886		.1384		.2076	.2263	
18	.2641		.173		.173	.2641	
19			.2422		.2768	.2641	
20			.2076		.2076	.2263	
21			.2076		.2076	.2263	
22			.173		.173	.2263	
23			.1384		.1384	.1886	
24		.1509	.1384		.1039		.1509
Max	1.2109	.2263	.2768	.2768	.2768	.346	.3772
Min	.1038	.0754	.1384	.0187	.1039	.1038	.1509
Avg	.2591	.1470	.1952	.1753	.1961	.2157	.2226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 201 / 11 KV ROSHAN GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1718	.1606	1.7737	.1792	.1774	1.8671	.1792
2	.1456	.1494	1.6804	.1718	.168	1.7737	.1718
3	.14	.1456	1.4937	.1606	.1456	1.4937	.1587
4	.1438	.1456	1.587	.1643	.1512	1.4563	.1606
5	.1568	.155	1.6804	.168	.1531	1.4937	.1643
6	.1736	.1718	1.6804	.1736	.168	1.6617	.168
7	.2033	.1886	1.6804	.1886	.1867	1.7924	.1886
8	.2166	.1942	2.2405	.2128	.2128	2.0538	.2072
9	.2521	.2297	2.7446	.2297	.2483	2.2032	.2334
10	2.6326	2.3152	3.0807	2.3899	2.5579	2.4832	2.4272
11	2.5393	2.2032	3.2674	2.2965	2.6513	2.3899	2.4646
12	2.3525	2.5019	3.006	2.4272	2.782	2.4272	2.3899
13	2.2779	2.3712	3.1181	2.3339	2.5953	2.4832	2.3525
14	2.2405	2.0351	2.726	2.1658	2.3712	2.2592	2.2779
15	1.9791	2.0538	1.9978	1.9605	2.0165	2.0725	1.9978
16	1.9231	1.9231	.1998	1.9044	1.9418	.1998	1.9605
17	.2035	2.1285	.1998	.211	2.0538	.2016	2.0911
18	.2371	2.4459	.2147	.2483	2.3152	.2353	2.6513
19	.2875	3.0434	.2763	.292	2.838	.3081	3.0994
20	.3062	3.0247	.2857	.2894	2.8753	.3081	3.1367
21	.2838	2.6886	.2819	.2521	2.6139	.2763	2.6699
22	.2371	2.3712	.2334	.239	2.2779	.2465	2.5206
23	.2166	2.1845	.2128	.2128	2.1658	.2259	2.2779
24	.1942	.183	1.8671	.1904	.1923	2.0538	.196
Max	2.6326	3.0434	3.2674	2.4272	2.8753	2.4832	3.1367
Min	.14	.1456	.1998	.1606	.1456	.1998	.1587
Avg	.8131	1.4589	1.5637	.7942	1.4941	1.4153	1.5060

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 202 / 11 KV Nizamuddin Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1441	.127	1.4003	.1438	.14	1.643	.1456
2	.1288	.1195	1.3443	.1382	.1344	1.4937	.14
3	.1214	.1158	1.307	.1344	.127	1.307	.1363
4	.1363	.1288	1.4937	.14	.1288	1.1203	.1419
5	.1531	.1326	1.6804	.1568	.1307	1.1576	.1568
6	.1774	.1811	1.7737	.183	.1718	1.419	.1792
7	.2222	.2241	2.0911	.2222	.2091	1.8671	.2222
8	.255	.2595	2.8193	.2427	.2446	2.0911	.2483
9	.2707	.2241	3.1181	.2539	.2614	2.3339	.2614
10	2.5206	2.3339	2.9313	2.3339	2.6139	2.3712	2.5019
11	2.2405	1.8671	2.9874	2.3339	2.3339	2.1845	2.2592
12	1.9605	2.1472	2.838	2.1845	2.1845	2.0725	2.1472
13	1.9978	1.8671	2.2405	1.8671	2.0911	2.0351	1.8671
14	1.7737	1.7177	1.8484	1.6617	1.8858	1.7924	1.7177
15	1.587	1.4937	1.3443	1.4937	1.587	1.4937	1.587
16	1.6057	1.6244	.1438	1.6244	1.4937	.1494	1.6804
17	.1885	1.6804	.1662	.1867	1.8111	.1774	1.9044
18	.2278	1.8671	.1998	.2054	2.1285	.2241	2.3712
19	.2347	2.7073	.2483	.2633	2.4272	.2624	2.7073
20	.2502	2.4646	.2371	.2427	2.3339	.2521	2.4272
21	.2185	2.1472	.2091	.1998	2.0538	.2147	2.1472
22	.1848	1.8671	.2016	.1904	1.9044	.1886	1.9791
23	.1307	1.4937	.1774	.168	1.6991	.1699	1.6804
24	.1606	1.8671	1.4937	.1606	.1643	1.6632	.1571
Max	2.5206	2.7073	3.1181	2.3339	2.6139	2.3712	2.7073
Min	.1214	.1158	.1438	.1344	.127	.1494	.1363
Avg	.7038	1.2774	1.4290	.6971	1.2608	1.2368	1.2819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 203 / 11 KV MONDHA Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1568	.168	1.6804	.1624	.168	1.7737	.1624
2	.1288	.1624	1.587	.1531	.155	1.6804	.1531
3	.14	.1456	1.531	.1494	.1494	1.531	.1494
4	.1494	.1606	1.8671	.1568	.1494	1.4937	.1587
5	.1792	.168	2.2405	.183	.1531	1.5684	.196
6	.2091	.211	2.4272	.2128	.1848	2.0165	.2502
7	.2689	.2763	2.6513	.2446	.2427	2.6699	.2689
8	.2894	.2838	3.062	.2707	.2651	2.9874	.2894
9	.2969	.2801	3.2114	.2782	.2894	2.838	.2894
10	2.4646	2.6326	3.0807	2.6886	2.8006	2.5019	2.5953
11	2.5766	2.5953	2.894	2.4646	2.6139	2.4272	2.4832
12	2.4086	2.4459	2.6139	2.2218	2.3899	2.3152	2.4086
13	2.0538	2.2779	2.3339	2.0911	2.1098	2.1658	2.2405
14	.1922	2.0351	2.0725	1.9231	1.9418	2.0538	2.0351
15	1.9044	1.9791	1.8858	1.9231	1.7924	1.8858	1.9044
16	1.9605	2.0911	.1923	1.8858	1.8858	.1886	1.8858
17	.2222	2.2218	.1998	.2072	1.9605	.2091	2.1285
18	.2427	2.6139	.2147	.2427	2.2965	.2427	2.5579
19	.2894	2.9874	.2689	.2857	2.6886	.2894	2.95
20	.3062	2.9874	.2606	.2651	2.6886	.2894	2.838
21	.2483	2.4832	.2166	.2315	2.3339	.2521	2.4832
22	.211	2.1658	.211	.2035	2.1472	.2147	2.0911
23	.196	1.9978	.1942	.1904	1.9791	.1942	1.9418
24	.1774	.1774	1.7177	.1718	.1699	1.8671	.1736
Max	2.5766	2.9874	3.2114	2.6886	2.8006	2.9874	2.95
Min	.1288	.1456	.1923	.1494	.1494	.1886	.1494
Avg	.7197	1.4811	1.6089	.7836	1.3981	1.4857	1.4431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 201 / 11 KV Nehru Bhavan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6478	.6478	.6097	.6859	.6097	.6097
2	.5716	.6097	.6097	.5716	.6478	.5716	.5716
3	.5716	.5716	.5716	.5335	.6097	.5716	.5716
4	.5335	.5335	.5335	.5335	.5716	.5716	.5716
5	.6097	.5716	.5716	.5716	.5716	.6097	.6097
6	.6859	.6859	.6859	.6478	.5335	.6478	.6478
7	.8383	.8002	.7621	.724	.5716	.7621	.7621
8	.8002	.724	.8383	.7621	.724	.7621	.7621
9	.8002	.8383	.9526	.7811	.8383	.8383	.8383
10	.8002	.8764	1.0288	.7621	.8383	.8764	.8764
11	.8764	.9145	1.0288	.8002	.8764	.8764	.9526
12	.8002	.8764	1.1028	.8383	.8764	.9526	.8764
13	.8764	.8764	1.0669	.8383	.7621	.8764	.8764
14	.8192	.7621	.7621	.724	.7621	.8383	.8002
15	.724	.724	.6478	.6478	.6478	.724	.7621
16	.6859	.6859	.6097	.6478	.6859	.724	.724
17	.6478	.7095	.6584	.6859	.6584	.7167	.7621
18	.724	.8383	.6722	.6878	.695	.8383	.8002
19	1.1431	1.0669	.9808	.9431	.8779	.9877	1.0268
20	1.1431	.9511	.9145	.9808	.8413	.9511	1.0288
21	1.105	.8688	.8779	.8779	.7167	.9526	.9526
22	1.1431	.8764	.823	.9877	.7922	.7545	1.1028
23	1.0288	.8764	.8002	.9145	.724	.724	.9054
24	.724	.8002	.724	.724	.7621	.6668	.6668
Max	1.1431	1.0669	1.1028	.9877	.8779	.9877	1.1028
Min	.5335	.5335	.5335	.5335	.5335	.5716	.5716
Avg	.8026	.7786	.7863	.7415	.7196	.7668	.7941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 202 / 11 KV CityChowk Police SHEDDABLE URBAN
station Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.5242	1.5242	1.5242	1.6194	1.6194	1.6194
2	1.4861	1.448	1.4861	1.448	1.5242	1.5242	1.5242
3	1.4098	1.3717	1.448	1.3717	1.4289	1.448	1.448
4	1.3336	1.4098	1.4098	1.3336	1.4289	1.3717	1.3717
5	1.448	1.5242	1.4861	1.448	1.3717	1.3717	1.3717
6	1.7528	1.7909	2.2862	1.6004	1.4289	1.5242	1.6194
7	1.9052	1.9052	2.21	1.7528	1.5242	1.9052	2.0957
8	2.0576	2.0576	2.2481	1.9052	1.8099	1.9052	2.0957
9	2.2481	2.2414	2.4998	2.1274	2.2414	2.2481	2.2862
10	2.3506	2.2748	2.7161	2.2748	2.3506	2.2862	2.2862
11	2.4768	2.2748	2.89	2.2748	2.4265	2.4387	2.4387
12	2.4387	2.4973	3.0026	2.2369	2.4265	2.5149	2.5149
13	2.2862	2.3885	2.7915	2.2748	2.5755	2.1338	2.4387
14	2.2481	2.2748	2.2748	2.1296	2.3506	2.21	2.21
15	2.1338	2.1232	.6465	2.0957	2.0957	2.1338	2.1338
16	2.0576	2.0494	1.9052	1.829	2.0957	2.0576	2.0576
17	1.9052	1.9052	1.9805	1.829	2.0119	1.9547	2.2459
18	2.0576	2.5149	2.2862	2.1948	2.268	2.21	2.4644
19	3.0483	3.0807	3.0178	2.7435	2.9264	3.0178	3.0056
20	2.9531	2.8959	2.9264	2.7069	2.9264	2.7538	3.0117
21	2.6673	2.1948	2.6703	2.6406	2.5606	2.4768	2.7215
22	2.21	2.2862	2.1948	2.3624	2.1879	2.3815	2.3506
23	1.9814	1.9814	1.9052	2.191	1.9052	1.9052	2.2634
24	2.0576	1.7528	1.7528	1.7528	1.8099	1.6194	1.6766
Max	3.0483	3.0807	3.0178	2.7435	2.9264	3.0178	3.0117
Min	1.3336	1.3717	.6465	1.3336	1.3717	1.3717	1.3717
Avg	2.0881	2.0737	2.1483	2.0020	2.0540	2.0422	2.1355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 203 / 11KV Ganesh colony

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5623	1.5623	1.4861	1.448	1.448	1.448	1.5242
2	1.448	1.4861	1.4098	1.3717	1.3717	1.3717	1.448
3	1.3717	1.4098	1.3717	1.3336	1.3336	1.3336	1.3717
4	1.4098	1.448	1.4098	1.2955	1.3336	1.2955	1.3717
5	1.5623	1.5623	1.5242	1.4861	1.3336	1.2955	1.3717
6	1.829	1.8671	1.829	1.5623	1.4289	1.5242	1.6194
7	2.21	2.1338	2.2862	1.9052	1.5242	2.0957	2.0957
8	2.3624	2.21	2.4387	2.0576	1.9052	2.0957	2.191
9	2.5149	2.3506	2.7188	2.5023	2.4265	2.3624	2.4387
10	2.5023	2.4265	2.9364	2.2748	2.5729	2.4387	2.4768
11	2.4387	2.3127	3.0777	2.2748	2.4973	2.2862	2.4387
12	2.2481	2.0155	2.9651	2.199	2.3885	2.0957	2.2862
13	2.1338	2.0514	2.7915	2.1253	2.1632	2.1719	2.21
14	2.0576	2.0135	2.2369	2.0535	1.829	1.9052	1.829
15	1.829	1.7837	1.9052	1.7147	1.829	1.7528	1.7909
16	1.7528	1.7528	1.448	1.6766	1.6766	1.829	1.7528
17	1.8671	1.829	1.6032	1.6032	1.7375	1.7558	1.9814
18	1.9052	2.0911	1.9052	1.9753	1.9204	2.1216	2.2748
19	2.4768	2.7073	2.4874	2.4387	2.3777	2.5606	2.5755
20	2.4006	2.5606	2.5911	2.4143	2.3411	2.1948	2.5023
21	2.1338	2.1357	2.037	2.2257	2.1879	1.9052	2.3506
22	2.21	2.1338	1.9753	2.0576	1.9616	1.9052	2.3127
23	2.0576	2.0576	1.9433	1.7147	1.8099	1.8099	1.8861
24	1.829	1.7528	1.7528	1.7528	1.5242	1.6766	1.6766
Max	2.5149	2.7073	3.0777	2.5023	2.5729	2.5606	2.5755
Min	1.3717	1.4098	1.3717	1.2955	1.3336	1.2955	1.3717
Avg	2.0047	1.9856	2.0888	1.8943	1.8718	1.8846	1.9907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 204 / 11 KV ROJABAG FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6097	.6478	.724	.6859	.724	.6478
2	.6097	.5716	.5716	.6478	.6478	.6478	.6097
3	.5716	.5335	.5335	.6097	.5716	.6097	.5716
4	.5335	.5335	.5716	.5716	.5716	.5716	.5716
5	.6478	.724	.6478	.6859	.6097	.5716	.5716
6	.724	.8002	.7621	.7621	.6478	.6478	.6478
7	.9145	.8764	.8764	.8383	.7621	.8383	.7621
8	.9526	.8383	.9526	.8764	.7621	.8002	.8383
9	.9907	1.0669	.9526	1.0849	.8764	.9907	.9907
10	.9526	1.0288	1.0268	1.0288	.8573	1.0288	.9526
11	1.0098	.9717	.9887	1.0098	.8573	1.0288	.1143
12	.9907	.9335	.9887	1.0849	.8954	.9907	1.0288
13	.9145	.9526	.9897	1.0658	.8383	.9145	.8764
14	.8383	.8383	.8383	.9526	.724	.8383	.8383
15	.8002	.9145	.9526	.9145	.724	.8764	.8002
16	.8573	.8383	.8764	.9526	.7049	.7682	.8764
17	.7621	.8002	.8413	.9054	.7316	.8779	.8764
18	.8002	.8326	.8764	.9145	.8002	.7621	.9145
19	.9526	.9511	1.0242	.9907	.9145	.8779	1.0648
20	.9145	.9877	.8962	1.0288	.8779	.8488	1.0278
21	.8002	.9054	.7316	.9907	.8413	.8764	.9526
22	.8002	.8573	.823	.8488	.8048	.9054	.9526
23	.8002	.8002	.8764	.8192	.7621	.7621	.9054
24	.724	.6859	.724	.7621	.7621	.6668	.724
Max	1.0098	1.0669	1.0268	1.0849	.9145	1.0288	1.0648
Min	.5335	.5335	.5335	.5716	.5716	.5716	.1143
Avg	.8129	.8272	.8321	.8779	.7596	.8094	.7965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 205 / 11 KV Collector Office NON SHEDDABLE EXPRESS HV FEEDERS
 Express Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0381	.0381	.0381	.0381	.0381
5	.0381	.0381	.0381	.0381	.0381	.0381	.0381
6	.0381	.0381	.0381	.0381	.0381	.0381	.0381
7	.0381	.0381	.0381	.0381	.0381	.0381	.0381
8	.0381	.0381	.0381	.0381	.0381	.0381	.0381
9	.0381	.0381	.0381	.0381	.0381	.0381	.0381
10	.1143	.0953	.0381	.0381	.0381	.0381	.0381
11	.1715	.1143	.0381	.0381	.0381	.0381	.1143
12	.1524	.1143	.0381	.0381	.0381	.1524	.1334
13	.1524	.1143	.0381	.0381	.0381	.1524	.1524
14	.1524	.1143	.0381	.0381	.0381	.1524	.1524
15	.1524	.1143	.0381	.0381	.0381	.1524	.1143
16	.1524	.1143	.0381	.0381	.0381	.1463	.1524
17	.1143	.0747	.0377	.0366	.0381	.1097	.1143
18	.1143	.0724	.0381	.0377	.0366	.0953	.0762
19	.0762	.0362	.0381	.0377	.0366	.0754	.0381
20	.0381	.0366	.0366	.0366	.0366	.0754	.0381
21	.0381	.0366	.0377	.0366	.0381	.0377	.0381
22	.0381	.0381	.0377	.0381	.0377	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0377
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	.1715	.1143	.0381	.0381	.0381	.1524	.1524
Min	.0381	.0362	.0366	.0366	.0366	.0377	.0377
Avg	.0786	.0623	.0380	.0379	.0379	.0701	.0675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 201 / 11 KV SUREWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7095	.7167	.6722	.7095	.7167	.7095
2	.7095	.6722	.679	.6348	.6722	.679	.6722
3	.7095	.6348	.6413	.6348	.6722	.679	.6722
4	.7842	.7842	.7545	.7842	.7095	.7167	.7842
5	.8501	.9335	.9808	.9709	.7762	.8299	.9979
6	1.0349	1.0829	.9431	1.1203	.8779	1.0562	1.1088
7	1.2567	1.1949	1.1694	1.1949	.961	1.2071	1.1827
8	1.1949	1.2883	1.2449	1.1389	1.1458	1.2826	1.0974
9	1.0164	.9896	1.094	.9896	1.0242	1.0562	.961
10	.9709	.9242	1.0562	.9431	1.0642	.8029	.7842
11	.8589	.8865	.8488	.8676	.9709	.0747	.7842
12	.8029	.7842	.7922	.5975	.8589	.7095	.7842
13	.7468	.7842	.8215	.7655	.7922	.0691	.6535
14	.7733	.7655	.7655	.7282	.7842	.0709	.6722
15	.7468	.7545	.7392	.7095	.7095	.7095	.6722
16	.7356	.7922	.7356	.6979	.7167	.7095	.7167
17	.7655	.8676	.7095	.7468	.8299	.7282	.7545
18	.8962	.8676	.6722	.7095	.8299	.8131	.9054
19	1.0829	1.1203	1.0829	1.1088	1.0562	.961	1.2826
20	1.1576	1.0829	.9709	1.0349	1.0562	1.0903	1.1694
21	1.1203	1.0562	.9709	.8871	1.0456	.9979	1.1317
22	1.0269	1.0185	.9149	1.1203	1.0185	.961	1.0562
23	.9335	.9054	.7202	.9335	.8676	.8402	.9054
24	.7468	.7468	.7468	.7095	1.0642	.7545	.7577
Max	1.2567	1.2883	1.2449	1.1949	1.1458	1.2826	1.2826
Min	.7095	.6348	.6413	.5975	.6722	.0691	.6535
Avg	.9028	.9019	.8655	.8625	.8839	.7715	.884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 202 / 11kv mayur park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.5975	.5975	.5975	.6348	.6722	.5914
2	.5975	.5601	.5601	.5601	.5975	.6413	.5975
3	.5975	.5228	.5228	.5228	.5975	.6036	.5975
4	.6653	.7095	.679	.7095	.6722	.6413	.7392
5	.8962	.8962	.7468	.7842	.8215	.7468	.924
6	1.0349	1.1203	.9335	.9709	1.0082	1.0082	1.0829
7	1.2567	1.1949	1.1203	1.1576	1.1458	1.1203	1.2803
8	1.2696	1.3817	1.307	1.307	1.1949	1.1576	1.1088
9	1.0456	1.1203	1.094	1.1203	1.1458	.9709	.961
10	.8589	.9431	.9808	.8215	.9709	.7842	.7762
11	.7316	.8775	.8215	.7095	.8676	.7095	.6722
12	.6099	.6283	.5788	.6653	.7207	.5601	.5975
13	.6099	.6219	.6283	.6283	.6838	.5601	.5601
14	.5975	.5975	.6161	.5914	.961	.5228	.5975
15	.5729	.5788	.5975	.5729	.6348	.5601	.5601
16	.5601	.5975	.6161	.5601	.6161	.6348	.5975
17	.6348	.6722	.5975	.5975	.7095	.6348	.6348
18	.7842	1.2323	.6722	.7468	.7468	.8131	.7842
19	.9709	1.1949	1.0082	.9335	.9709	.961	.9709
20	1.1576	1.0829	.9335	1.0349	1.0829	.9979	1.0456
21	1.0082	.9709	.9335	.924	.9709	.961	.9335
22	.8962	.8962	.8589	.8589	1.1576	.8501	.8589
23	.7842	.7842	.7468	.7095	1.0082	.7023	.7468
24	.6348	.6348	.5975	.6348	.6283	.7095	.6348
Max	1.2696	1.3817	1.307	1.307	1.1949	1.1576	1.2803
Min	.5601	.5228	.5228	.5228	.5975	.5228	.5601
Avg	.8087	.8507	.7812	.7800	.8562	.7718	.7856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 205 / 11kV Aarti
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2987	.2987	.2987	.2614	.3361	.2987
2	.2987	.2614	.2641	.2614	.2614	.3018	.2987
3	.2987	.2241	.2614	.2241	.2587	.2829	.2987
4	.3361	.2987	.3018	.2987	.2987	.3018	.3734
5	.4435	.3734	.3734	.3734	.4108	.3772	.5175
6	.5121	.4481	.5228	.4854	.5975	.5228	.5914
7	.6653	.7095	.7095	.6722	.6653	.6722	.7392
8	.6722	.6722	.8215	.7842	.7095	.7095	.7392
9	.5914	.6348	.679	.6348	.7095	.5601	.6283
10	.4854	.4854	.6413	.4481	.5975	.5228	.5544
11	.462	.4066	.4481	.4251	.4854	.4854	.5228
12	.3511	.3696	.4527	.3881	.3921	.5228	.3361
13	.3475	.3547	.2987	.3142	.3696	.0448	.4108
14	.3395	.2957	.2772	.3142	.3326	.0373	.4108
15	.3109	.3109	.2241	.2896	.2926	.0336	.3734
16	.3292	.3734	.4481	.3292	.3142	.3326	.3734
17	.4108	.4481	.4108	.4481	.4108	.4481	.4481
18	.5228	.5228	.5601	.4854	.5041	.5975	.4854
19	.6722	.6348	.6722	.7023	.6722	.7023	.7095
20	.5601	.5658	.5975	.6283	.6348	.5914	.5975
21	.4854	.4854	.5228	.5175	.5228	.5175	.5601
22	.4108	.4527	.4854	.3734	.4481	.8316	.4108
23	.3734	.3734	.4108	.3361	.4108	.3734	.3734
24	.3361	.3361	.2218	.3734	.5975	.3395	.3361
Max	.6722	.7095	.8215	.7842	.7095	.8316	.7392
Min	.2987	.2241	.2218	.2241	.2587	.0336	.2987
Avg	.4381	.4307	.4543	.4336	.4649	.4352	.4745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 201 / 11KV JASWANTPURA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2826	1.307	1.3443	1.3203	1.3121	1.3769	1.3121
2	1.2637	1.2197	1.2323	1.2136	1.2071	1.251	1.2936
3	1.2449	1.2012	1.1949	1.1883	1.1883	1.2012	1.2382
4	1.4146	1.2136	1.1827	1.1763	1.1763	1.2012	1.2382
5	1.6032	1.2637	1.226	1.2071	1.226	1.3014	1.2752
6	1.7541	1.6598	1.6409	1.5655	1.5844	1.6975	1.5684
7	2.2068	2.1502	2.0559	2.0559	1.8107	2.1502	2.1313
8	2.4143	2.3011	2.6783	2.0936	2.2257	2.4143	2.4897
9	2.4331	2.5274	3.0178	2.3388	2.6406	2.5086	2.5652
10	2.452	2.3011	2.452	2.32	2.2822	2.3388	2.3954
11	2.3388	2.3388	3.1876	2.1879	2.2822	2.3011	2.3577
12	2.1313	2.0748	2.9235	2.0182	2.2634	2.0936	2.2634
13	1.9616	1.9616	2.6406	1.8861	2.037	1.9805	2.0748
14	1.8107	1.6787	2.0559	1.7353	1.9616	1.8673	1.7918
15	1.6975	1.5844	1.5655	1.6975	1.6598	1.773	1.5089
16	1.6787	1.6032	1.5466	1.6598	1.6598	1.5844	1.5844
17	1.4712	1.8107	1.6221	1.7353	1.8107	1.8673	1.8107
18	2.2257	2.1879	1.9616	2.2257	2.2068	2.3765	2.0936
19	2.584	2.6217	2.3765	2.5652	2.5086	2.7161	2.2068
20	2.3954	2.3765	2.2068	2.3765	2.3765	2.3765	2.3388
21	2.1691	2.1125	1.9993	2.0182	1.9427	1.8484	2.1125
22	2.0182	1.9427	1.7918	1.8107	1.773	1.7541	1.9427
23	1.8484	1.773	1.6598	1.6975	1.6975	1.8107	1.7737
24	1.5278	1.531	1.5655	1.5123	1.5466	1.5497	1.5497
Max	2.584	2.6217	3.1876	2.5652	2.6406	2.7161	2.5652
Min	1.2449	1.2012	1.1827	1.1763	1.1763	1.2012	1.2382
Avg	1.9137	1.8643	1.9637	1.8169	1.8492	1.8892	1.8715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 202 / 11 Kv JAKATNAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4481	.4481	.4338	.4108	.3921	.4251
2	.3772	.415	.3921	.3921	.3772	.3511	.4066
3	.3584	.3961	.3734	.3734	.3584	.3584	.3881
4	.4715	.3921	.3696	.3734	.3584	.3511	.3881
5	.4904	.4294	.4066	.3921	.3584	.3696	.462
6	.547	.5658	.5093	.547	.4527	.5093	.5601
7	.6224	.6979	.6036	.6224	.547	.679	.679
8	.679	.7356	.7922	.6036	.6224	.7356	.7545
9	.7167	.7733	1.0185	.6602	.7922	.811	.811
10	.7167	.7922	.8299	.7167	.7545	.7167	.7545
11	.811	.7733	.9808	.7356		.7356	.6979
12	.6602	.7356	.9619	.6602	.7356	.679	.7545
13	.6413	.6979	.9054	.6224	.679	.7167	.679
14	.7733	.6979	.679	.5847	.6413	.7545	.6224
15	.679	.6413	.547	.547	.547	.6602	.5658
16	.6413	.6224	.5281	.5281	.5281	.5847	.5228
17	.679	.6413	.5658	.5658	.6036	.6413	.6036
18	.7167	.7356	.6224	.679	.6224	.8299	.7733
19	.8676	.9242	.7733	.7922	.811	.9808	.8676
20	.7733	.8676	.7733	.7356	.7356	.8488	.7922
21	.811	.8299	.679	.7356	.6413	.7545	.7356
22	.7545	.7167	.6602	.6602	.6224	.6602	.679
23	.6224	.6036	.6036	.547	.6224	.6224	.5975
24	.5093	.5228	.5281	.5041	.4715	.4854	.5228
Max	.8676	.9242	1.0185	.7922	.811	.9808	.8676
Min	.3584	.3921	.3696	.3734	.3584	.3511	.3881
Avg	.6389	.6523	.6480	.5838	.5780	.6345	.6268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 203 / 11 KV AZAD CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1883	1.1949	1.2136	1.1763	1.1458	1.1576	1.1273
2	1.1694	1.1576	1.1389	1.1128	1.0829	1.0829	1.0903
3	1.1317	1.1088	1.1016	1.0829	1.0829	1.0534	1.0903
4	1.358	1.1317	1.0903	1.094	1.094	1.0642	1.0903
5	1.4712	1.1506	1.1317	1.094	1.1317	1.1128	1.1643
6	1.6221	1.4901	1.4712	1.4712	1.4901	1.5466	1.531
7	2.0748	1.8484	1.8861	1.8296	1.6975	1.9805	1.9993
8	2.3011	2.2257	2.4897	2.0182	2.1879	2.2822	2.1125
9	2.2068	2.1313	2.6217	1.9805	2.2822	2.2822	2.2634
10	2.1313	1.8861	2.7538	1.7353	2.2445	2.0748	2.0559
11	2.0182	1.8861	2.5463	1.6409		2.0559	1.9239
12	1.773	1.8861	2.3765	1.6409	2.1691	1.905	1.7164
13	1.6221	1.6975	2.1313	1.5089	1.5278	1.7353	1.5089
14	1.3957	1.4901	1.5278	1.3392	1.4712	1.4335	1.3957
15	1.3957	1.3392	1.1128	1.2826	1.2637	1.2826	1.2449
16	1.3957	1.3203	1.0751	1.2449	1.4146	1.3769	1.3443
17	1.5466	1.6032	1.226	1.6409	1.6032	1.5844	1.6221
18	1.9427	2.0936	1.7164	1.9616	1.9805	2.037	2.0748
19	2.32	2.3577	2.1313	2.3954	2.2634	2.3388	2.3388
20	2.0748	2.037	1.8484	2.037	1.9993	2.0182	1.9993
21	1.7918	1.773	1.6221	1.6787	1.7541	1.773	1.773
22	1.6975	1.6787	1.5466	1.5466	1.6032	1.6787	1.6787
23	1.5278	1.4523	1.4335	1.3957	1.5089	1.5089	1.4937
24	1.2637	1.307	1.3014	1.2883	1.2826	1.3256	1.2696
Max	2.32	2.3577	2.7538	2.3954	2.2822	2.3388	2.3388
Min	1.1317	1.1088	1.0751	1.0829	1.0829	1.0534	1.0903
Avg	1.6842	1.6353	1.6873	1.5499	1.6209	1.6538	1.6212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 204 / 11KV A'BAD TIMES COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2449	1.2136	1.2323	1.1949	1.1643	1.1949	1.2197
2	1.226	1.1458	1.1389	1.1317	1.1016	1.1317	1.1643
3	1.2071	1.1317	1.1088	1.094	1.0751	1.1128	1.1273
4	1.3203	1.1317	1.1088	1.094	1.0751	1.1016	1.1273
5	1.358	1.1883	1.094	1.1128	1.0751	1.1016	1.1273
6	1.6221	1.4146	1.226	1.1883	1.1694	1.226	1.307
7	1.5466	1.5466	1.3392	1.2826	1.2826	1.4335	1.4712
8	1.5466	1.6221	1.6598	1.4146	1.5655	1.5466	1.6409
9	1.7353	1.773	2.1125	1.5089	1.7164	1.7164	1.8107
10	1.9239	1.9239	2.6029	1.6975	1.8861	1.6975	1.8107
11	1.7918	1.7918	2.452	1.6787		1.6975	1.773
12	1.8296	1.7918	2.3011	1.6409	1.8107	1.6598	1.8107
13	1.7164	1.7353	2.32	1.6032	1.773	1.6032	1.6975
14	1.6975	1.6221	1.8107	1.5466	1.6221	1.6221	1.6598
15	1.5089	1.5089	1.4335	1.3769	1.358	1.3957	1.5089
16	1.3957	1.5089	1.4146	1.3769	1.358	1.2826	1.363
17	1.5089	1.4712	1.3203	1.0562	1.5089	1.358	1.3769
18	1.6975	1.6598	1.5089	1.6221	1.5844	1.6409	1.7164
19	1.8861	1.9993	1.7541	1.7541	1.9427	2.0182	2.037
20	1.8673	2.2634	1.8861	1.2449	1.8296	1.9427	2.0748
21	1.9239	1.9993	1.6598	1.7164	1.7353	1.9427	1.9239
22	1.7918	1.7918	1.5278	1.6221	1.6221	1.905	1.773
23	1.5844	1.6598	1.4335	1.4523	1.5466	1.7164	1.643
24	1.4335	1.4563	1.5089	1.3256	1.3203	1.363	1.4937
Max	1.9239	2.2634	2.6029	1.7541	1.9427	2.0182	2.0748
Min	1.2071	1.1317	1.094	1.0562	1.0751	1.1016	1.1273
Avg	1.5985	1.5980	1.6231	1.4057	1.4836	1.5171	1.5691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 201 / Jaman Jyoti

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2401	.2667	.2401	.2229	.2229	.2572
2	.2858	.2401	.2572	.2401	.2229	.2229	.2572
3	.2858	.2401	.2572	.2401	.2229	.2229	.2572
4	.3048	.2572	.2572	.2401	.2667	.2401	.2743
5	.3429	.2915	.3258	.2915	.2915	.3086	.3086
6	.4763	.3772	.3944	.3601	.3429	.3944	.4115
7	.6287	.5144	.5144	.4973	.5316	.5658	.583
8	.724	.703	.6344	.5658	.6687	.583	.0514
9	.724	.743	.6687	.8402	.7373	.5658	.703
10	.743	.703	.7049	.5487	.703	.6344	.6001
11	.6173	.5658	.6001	.5658	.6001	.5316	.5316
12	.6668	.5658	.583	.583	.5316	.5316	.4801
13	.7049	.5487	.4801	.6344	.4973	.4458	.5144
14	.5906	.5658	.5144	.6001	.5316	.463	.4801
15	.5487	.5658	.1715	.6344	.4801	.4801	.5316
16		.583		.4973	.4458	.5316	.4801
17	.5144	.583		.6001	.5316	.6173	.6173
18	.7621	.6516		.5144	.583	.703	.5658
19	.5316	.5144		.4801	.4458	.583	.4458
20	.4287	.4458	.2743	.3772	.3772	.4801	.4115
21	.3601	.3944	.3086	.2915	.3086	.3601	.3429
22	.3086	.2915	.3048	.3258	.2572	.3429	.3772
23	.3048	.3048	.2572	.2572	.2229	.2915	.2915
24	.2572	.2572	.2572	.2572	.2401	.2401	.2572
Max	.7621	.743	.7049	.8402	.7373	.703	.703
Min	.2572	.2401	.1715	.2401	.2229	.2229	.0514
Avg	.4943	.4645	.4016	.4451	.4276	.4401	.4179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 202 / 11 kv subhedari

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6344	.6516	.6516	.6344	.6516	.6516
2	.6344	.6173	.6173	.6173	.6001	.6173	.6173
3	.6173	.6001	.6173	.6001	.6001	.6001	.6001
4	.6001	.6001	.6344	.6173	.583	.6001	.6173
5	.6859	.6344	.6344	.6173	.6173	.6173	.6516
6	.8383	.7716	.703	.7373	.6516	.7202	.7373
7	1.0098	.8916	.8059	.8954	.703	.823	.8573
8	1.105	.9088	.9259	.9335	.8402	.9431	.8573
9	1.0479	.8745	1.0117	.8402	.9259	.9259	.8916
10	.823	.9088	.9774	.8745	.8916	.823	.8745
11	.823	.7888	.9431	.7716	.9088	.7373	.8745
12	.8383	.9145	.9602	.8059	.8402	.7373	.8059
13	.743	.7545	.8916	.8192	.8059	.7373	.8573
14	.8192	.7373	.7888	.7373	.7545	.7202	.7716
15	.8192	.703	.7545	.6344	.7202	.6516	.7716
16	.724	.6516	.7545	.6344	.7716	.6859	.7202
17	.743	.6687	.703	.703	.7545	.7545	.7373
18	1.0288	.8402	.7373	.8402	1.0117	.8573	.9602
19	1.0288	.9602	.9088	1.0288	1.0117	1.046	1.0974
20	.9945	.9431	.9431	.9602	.9774	1.0631	.9945
21	1.0288	.8916	.8916	.8573	.8573	.9259	.9088
22	.9907	.9526	.8402	.9526	.823	.9088	.8916
23	.8954	.8059	.7716	.7716	.7716	.8059	.823
24	.7202	.6859	.7373	.703	.7621	.703	.6859
Max	1.105	.9602	1.0117	1.0288	1.0117	1.0631	1.0974
Min	.6001	.6001	.6173	.6001	.583	.6001	.6001
Avg	.8421	.7808	.8002	.7752	.7841	.7773	.8023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 204 / 11 kv Delhi Gate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2517	1.2174	1.3717	1.2346	1.2384	1.1831	1.166
2	1.2174	1.166	1.2174	1.2003	1.1145	1.1145	1.1488
3	1.2174	1.1831	1.2346	1.2174	1.0974	1.1145	1.1317
4	1.286	1.3717	1.4289	1.2174	1.166	1.1488	1.2174
5	1.6575	1.6956	1.6575	1.6575	1.3203	1.3889	1.4918
6	2.1776	2.1091	2.3434	2.2672	1.8004	2.0233	2.0062
7	2.6235	2.7263	2.9721	2.6578	2.3491	2.7263	2.6235
8	2.7606	2.8978	3.4484	2.7778	2.7778	2.7263	2.8292
9	2.692	2.8387	3.5056	2.692	2.7435	2.3663	2.572
10	2.6482	2.1948	2.9492	2.0748	2.4177	2.1434	2.1948
11	2.2291	2.3053		1.9376	2.2119	1.869	1.989
12	1.8004	1.8176	2.191	1.8004	1.9719	1.6289	1.749
13	1.5947	1.8671	1.7661	1.5604	1.6461	1.4918	1.6632
14	1.406	1.4918	1.6004	1.6004	1.4232	1.3889	1.4403
15	1.5432	1.3717	1.5432	1.406	1.3032	1.3032	1.3375
16	1.6004	1.5089		1.4575	1.4403	1.4232	1.4403
17	1.6461	1.7318	1.7147	1.6289	1.6804	1.5947	1.6118
18	2.3053	2.0748	2.191	2.0062	1.9719	1.989	2.0233
19	2.572	2.4691	.1143	2.4691	2.5377	2.0576	2.5549
20	2.7244	2.3663	2.3834	2.2119	2.3491	2.2805	2.2119
21	2.1338	1.9033	1.9033	1.7833	1.869	1.8519	1.8861
22	1.9243	1.7147	1.8671	1.8099	1.6804	1.7147	1.6461
23	1.4918	1.4575	1.6194	1.3889	1.2003	1.4232	1.4918
24	1.3546	1.286	1.4289	1.286	1.1831	1.2174	1.2346
Max	2.7606	2.8978	3.5056	2.7778	2.7778	2.7263	2.8292
Min	1.2174	1.166	.1143	1.2003	1.0974	1.1145	1.1317
Avg	1.9108	1.8653	1.9296	1.8060	1.7706	1.7154	1.7776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 205 / 11 kv WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.2058	.2477	.2058	.2058	.2058
2	.2058	.2058	.2058	.2286	.2058	.2058	.2229
3	.2058	.2058	.2058	.2286	.2058	.2058	.2058
4	.2286	.2229	.2058	.2286	.1886	.2058	.2058
5	.2858	.2572	.2667	.2858	.2058	.3048	.2229
6	.4115	.3772	.3258	.4382	.2743	.4572	.3601
7	.5316	.4973	.463	.5335	.4458	.6097	.4973
8	.5658	.583	.583	.5658	.5144	.6516	.5658
9	.4973	.5144	.5316	.6097	.4973	.463	.5144
10	.4287		.4973	.4954	.4801	.3772	.4458
11	.3086	.3772	.3944	.381	.3944	.3429	
12	.2915	.2915	.4115	.362	.3601	.3086	.2915
13	.2401	.2915	.3258	.362	.2743	.2401	.2915
14	.2286	.2229	.2572	.2477	.2743	.2058	.2229
15	.2286		.2572	.2286	.2229	.2229	.2229
16	.2667	.2743	.2572	.2096	.2572	.2229	.2058
17	.2572	.2401	.2743	.3239	.2915	.2743	.2743
18	.3429	.3429	.3258	.4001	.3944	.3601	.3772
19	.4973	.4801	.4115	.4973	.4801	.4801	.4801
20	.5335	.4458	.3944	.4763	.4801	.4973	.4115
21	.3601	.3944	.3429	.4001	.4287	.3772	.3772
22	.362	.3258	.3258	.3429	.3258	.3086	.3258
23	.2572	.2743	.2572	.2667	.2401	.2743	.2572
24	.2743	.2229	.2229	.2477	.2286	.2058	.2229
Max	.5658	.583	.583	.6097	.5144	.6516	.5658
Min	.2058	.2058	.2058	.2096	.1886	.2058	.2058
Avg	.3347	.3297	.3312	.3587	.3282	.3337	.3221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 207 / 11 kv Kat kat Gate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.4403	1.4232	1.4575	1.3889	1.3889	1.3717
2	1.5432	1.3203	1.3375	1.3032	1.3032	1.3203	1.3203
3	1.5051	1.286	1.286	1.2689	1.2689	1.286	1.3203
4	1.5051	1.286	1.3375	1.2689	1.2689	1.286	1.3203
5	1.6194	1.4232	1.406	1.3546	1.3717	1.3717	1.4403
6	1.8347	1.8347	1.8176	1.749	1.6118	1.8347	1.8347
7	2.7435	2.3491	2.1605	2.2805	1.8519	2.5206	2.3663
8	3.0102	2.5892		2.5377	2.2291	2.6578	2.5549
9	2.9912	2.7092	.7373	2.6406	2.5892	2.7606	2.8635
10	2.7244	2.572	3.7209	2.6063	2.5892	2.5549	2.6406
11	2.7435	2.4177	3.4122	2.4177	2.7606	2.5034	2.4863
12	2.4577	1.9719	3.1207	2.1776	2.5034	2.332	2.3148
13	2.3624	2.0576	2.8635	2.0405	2.2119	2.1605	2.1262
14	2.1338	1.9547	2.2119	1.7661	2.1091	2.0919	1.9033
15	1.869	1.8519	1.7833	1.6975	1.7833	1.8861	1.749
16	1.9814	1.7833	1.7318	1.7147	1.7661	1.8004	1.7661
17	2.191	1.989	1.8347	1.9204	2.0919	2.0576	2.0233
18	2.6101	2.4863	2.1605	2.1948	2.4691	2.3491	.4801
19	3.1626	2.7778	2.5892	3.1055	2.8292	2.9321	2.915
20	3.1245	2.7435	2.5892	2.5892	2.6749	2.7435	2.6406
21	2.7244	2.5377	2.332	2.3148	2.3148	2.3491	2.3663
22	2.4006	2.1948	2.0748	2.1434	2.0919	2.0233	2.2634
23	2.1338	1.9204	1.869	1.869	1.8004	1.869	1.9204
24	1.6289	1.5947	1.6289	1.5775	1.5604	1.5261	1.5604
Max	3.1626	2.7778	3.7209	3.1055	2.8292	2.9321	2.915
Min	1.5051	1.286	.7373	1.2689	1.2689	1.286	.4801
Avg	2.2758	2.0455	2.0621	1.9998	2.0183	2.0669	1.9812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 209 / Bhim Tekdi
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1488	1.1317	1.1317	1.1317	1.2003	1.1317	1.1145
2	1.0974	1.0974	1.2193	1.0974	1.0631	1.0802	1.1145
3	1.2003	1.1145	1.0802	1.0802	1.046	1.0802	1.0974
4	1.2193	1.1145	1.2193	1.0974	1.0631	1.0974	1.1145
5	1.467	1.3546	1.3375	1.4289	1.2003	1.2517	1.3375
6	1.8004	1.9547	1.7318	1.9433	1.2346	1.8347	1.869
7		2.4348	2.5149	2.5339	2.0748	2.452	2.4348
8		2.4691	2.8769	2.3663	2.2291	2.452	2.5377
9		1.9719	2.6235	2.2805	2.1434	2.0233	2.1776
10		1.7147	2.2291	2.0195	1.8347	1.8004	1.869
11		1.4918	2.2291	1.7147	1.8861	1.5775	1.6975
12		1.5261	1.749	1.3889	1.6118	1.3889	1.4575
13		1.3717	1.829	1.448	1.4746	1.3032	1.3889
14		1.2003	1.4861	1.2517	1.4918	1.2174	1.3889
15		1.2346	1.3336	1.1317	1.2517	1.2174	1.2346
16		1.2003	1.2765	1.2003	1.2517	1.2003	1.3032
17		1.406	1.2689	1.3546	1.5604	1.3375	1.4403
18		1.7833	1.6194	1.5947	1.5947	1.5775	1.7147
19		2.0576	1.8519	2.0576	2.0576	2.0919	2.1262
20		2.0062	1.869	2.0062	2.0062	2.0748	1.9719
21		1.8004	1.7147	1.6804	1.6804	1.8176	1.7661
22		1.5947	1.5089	1.5432	1.5947	1.6804	1.6461
23		1.3889	1.3375	1.3375	1.3546	1.4403	1.4232
24	1.2003	1.2174	1.2346	1.1831	1.2955	1.1831	1.2174
Max	1.8004	2.4691	2.8769	2.5339	2.2291	2.452	2.5377
Min	1.0974	1.0974	1.0802	1.0802	1.046	1.0802	1.0974
Avg	1.3048	1.5682	1.6780	1.5780	1.5501	1.5546	1.6018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 210 / Bhagat Singh

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.6516	.6687	.6687	.6344	.6687	.6687
2	.743	.6516	.6687	.7049	.6344	.6516	.6687
3	.724	.6516	.6516	.6344	.6344	.6516	.6687
4	.743	.6859	.6859	.6516	.6516	.6687	.6859
5	.9335	.8402	.823	.7888	.7545	.8573	.8573
6	1.3336	1.4098		1.2384	.9774		1.2689
7	1.5432	1.5261	1.4232	1.4232	1.2517	1.5775	1.4575
8	1.3032	1.4746	.0572	1.3546	1.3032	1.286	1.286
9	1.2765	1.1317	1.467	1.3527	1.3203	1.166	1.1488
10	1.0288	.9088	1.5775	.9259	1.0288	.7716	.8402
11	1.086	.7716	.8916	.7716	.9945	.823	.8059
12	.7811	.7716	.7373	.8954	.8573	.7202	.7373
13	.724	.703	.7545	.7621	.7545	.703	.703
14	.6287	.5487	.6516	.6859	.703	.6687	.6859
15	.6859	.6687	.6859	.6516	.6001	.6344	.6859
16		.6173	.7373	.743	.7716	.6516	.7202
17	.7621	.703	.7202	.8059	.8402	.7202	1.2517
18	.7202	.9774	.7888	.8916	.9774	.8745	.9602
19	1.3146	1.1317	1.1431	1.2765	1.1831	1.1831	1.1317
20	1.2955	1.1831	1.0117	1.1317	1.166	1.166	1.0974
21	1.2003	1.0631	.9945	1.046	1.1241	1.0802	1.2003
22	1.0669	1.0117	.9774	.7545	.9602	1.0288	.9945
23	.8954	.8059	.7888	.7545	.8059	.8059	.8573
24	.7811	.6859	.7811	.7811	.6859	.7373	.703
Max	1.5432	1.5261	1.5775	1.4232	1.3203	1.5775	1.4575
Min	.6287	.5487	.0572	.6344	.6001	.6344	.6687
Avg	.9702	.8989	.8559	.9039	.9006	.8737	.9202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 201 / 11 KV E+H

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	2.6292	2.553	2.191	2.8769	2.5911	2.5149
2	2.4387		2.5149	2.2481	2.4958	2.572	2.5149
3	2.4196	2.6673	2.4958	2.21	2.5339	2.5149	2.4196
4	2.4196	2.6673	2.4768	2.21	2.5149	2.553	2.4577
5	2.4196	2.6482	2.3624	2.1719	2.6863	2.4196	2.4387
6	2.8769	2.6292		2.1529	2.7625	2.4577	2.4768
7	2.3053	2.4768	2.1148	2.2672	2.7244	2.4387	2.4387
8	2.8006	2.9531	2.1148	2.5149	2.6482	3.1436	3.0102
9	3.0293	3.2769	2.0957	2.7435	3.4865	3.6389	2.9531
10		4.4582	2.0195	3.1055	3.1626	3.8295	4.02
11		4.1914	2.1148	3.7151	3.8676	4.4963	4.039
12	3.7723	4.0962	2.1338	3.5627	3.7913	3.5437	3.0674
13		3.1245	2.191	3.6199	2.7435	4.0581	3.5246
14		3.9628	2.191	4.1914	3.2769	4.4963	4.2295
15		3.7342	2.1529	3.658		4.5915	3.4865
16	4.2295	4.1724	2.0005	4.0771	3.3722	4.0962	4.2867
17	4.1533	3.9628	2.3815	4.4772	3.4294	3.7342	4.0962
18	3.5246		2.2291	3.9819	3.0483	3.2769	3.1436
19	3.3913		2.3243	3.4484	2.934	2.915	2.8197
20	2.9721	2.6292	2.3243	2.6673	2.6101	2.4387	2.6292
21	2.915	2.6673	2.21	2.4387	2.8197	2.8387	2.5911
22	2.8197	2.5149	2.2481	2.934	2.6292	2.7244	2.8006
23	2.6863	2.915	2.4387	2.8197	2.7054	3.0102	
24	2.5149	2.5149	2.1148	2.2862	2.4387	2.4006	2.6482
Max	4.2295	4.4582	2.553	4.4772	3.8676	4.5915	4.2867
Min	2.3053	2.4768	2.0005	2.1529	2.4387	2.4006	2.4196
Avg	2.9561	3.1853	2.2523	2.9872	2.9373	3.1992	3.0699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 202 / 11 KV GARWARE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8769	2.9531	2.8006	1.829	2.8578	2.4387	2.8959
2	2.6863		2.7054	1.7147	2.6863	2.4006	2.8387
3	2.6673	2.6863	2.6101	1.6575	2.6673	2.3434	2.7625
4	2.6673	2.6863	2.5911	1.6385	2.6482	2.2672	2.7054
5	2.6292	2.6482	2.553	1.7528	2.6482	2.4577	2.6673
6	2.7816	2.8006		1.9433	2.5911	2.4387	2.7054
7	2.2862	2.5339	1.7909	2.2481	2.8578	2.2672	3.1245
8	3.6389	3.4865	2.0957	3.5437	2.7816	3.2007	3.5437
9	3.4865	4.039	2.0005	3.8295	3.0293	3.3913	3.677
10		3.9057	2.1148	3.9057	2.9531	3.5246	3.7913
11		4.02	2.0386	3.9438	3.2769	3.8104	4.02
12		3.7342	1.8099	3.8104	2.8578	3.5818	3.5818
13		3.6008	1.829	3.4675	2.9721	3.8676	3.3913
14		3.9247	2.0195	4.1914	3.296	4.039	3.7913
15		3.8866	1.7909	3.7342		3.8485	4.02
16		4.0009	1.829	3.7723	2.9721	3.8295	3.658
17	.8383	4.0009	1.7909	3.8295	3.0483	3.8676	9.2783
18	3.5056		1.6004	3.5818	2.7054	3.4484	3.315
19	3.3913		1.6956	3.1436	2.3624	2.934	2.8578
20	2.915	3.1436	1.6766	3.1245	2.4006	3.1436	3.0102
21	3.2579	3.0102	1.6766	3.0102	2.2481	3.0102	2.915
22	2.8769	2.9721	1.7147	2.9912	2.4387	3.1245	2.7625
23	2.8959	3.0102	1.7528	3.0483	2.2672	2.915	
24	3.9628	2.8959	1.9624	1.7528	2.8578	2.4387	2.8197
Max	3.9628	4.039	2.8006	4.1914	3.296	4.039	9.2783
Min	.8383	2.5339	1.6004	1.6385	2.2481	2.2672	2.6673
Avg	2.9038	3.3305	2.0195	2.9777	2.7576	3.1079	3.4840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 203 / 11 KV KESONA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.5432	1.5432	1.2193	1.5051	1.2384	1.5432
2	1.5242	1.5242	1.5432	1.2003	1.3717	1.2003	1.5051
3	1.5051	1.4861	1.5432	1.1812	1.3908	1.2384	1.4098
4	1.5051	1.467	1.5432	1.1431	1.3908	1.1812	1.3717
5	1.4861	1.5432	1.467	1.2955	1.448	1.3146	1.3336
6	1.4289	1.448		1.2193	1.3908	1.2765	1.3717
7	1.467	1.3527	1.3146	1.2193	1.2955	1.1812	1.5051
8	2.4006	2.4577	1.2765	2.1719	1.9814	2.0005	2.3815
9	2.7244	2.7054	1.3527	2.4387	2.1529	2.1148	2.5911
10		3.0483	1.4098	2.7054	2.1338	2.4958	2.7816
11		2.6673	1.4098	2.4768	2.1529	2.6863	2.8197
12		2.8578	1.448	2.8197	1.9052	2.3815	2.21
13		2.3815	1.1431	2.3243	1.8861	2.7435	2.3815
14		2.8387		2.8387	2.4196	3.0483	2.6863
15		2.7244	1.2955	2.6482		2.5911	2.6482
16	2.3434	2.8387	1.2574	2.6673	2.3624	2.3053	2.8769
17	2.8769	2.8006	1.2384	2.7054	2.3053	2.0195	2.6292
18	2.3243		1.105	2.553	1.6194	1.9243	2.0576
19	2.2481		1.1622	1.6766	1.6004	1.8671	1.4861
20	1.6194	1.467	1.105	1.5242	1.3336	1.5623	1.3717
21	1.6385	1.448	1.2574	1.5432	1.3146		1.4861
22	1.448	1.467	1.0669	1.5051	1.2765	1.4289	1.3527
23	1.5432	1.5051	1.1812	1.5242	1.2384	1.4098	
24	1.4861	1.4861	1.3717	1.2574	1.5051	1.2955	1.3336
Max	2.8769	3.0483	1.5432	2.8387	2.4196	3.0483	2.8769
Min	1.4289	1.3527	1.0669	1.1431	1.2384	1.1812	1.3336
Avg	1.8343	2.0481	1.3198	1.9108	1.6948	1.8480	1.9623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 204 / 11 KV HIRA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9243	2.0767	1.9433	1.4861	2.0005	1.5623	1.9624
2	1.7909	1.9243		1.467	1.9624	1.5242	1.9052
3	1.8099	1.7718	1.8671	1.467	1.9433	1.4861	1.9433
4	1.8099	1.6956	1.8099	1.448	1.9624	1.467	1.9624
5	1.7337	1.5623	1.6194	1.5242	1.9243	1.6956	1.9243
6	1.9243	1.6766		1.5242	2.0386	1.6385	1.9814
7	1.9052	1.7528	1.4098	1.3717	1.7147	1.6385	1.5242
8	2.0195	2.2291	1.3336	2.0005	1.8861	1.5432	1.9243
9	2.5911	2.4958	1.2574	2.1338	2.2672	2.0576	2.3243
10		2.6863	1.3908	2.4196	2.4577	2.1338	2.5339
11		2.7054	1.3527	2.4768	2.3053	2.6292	2.5339
12		2.7054	1.3717	2.6863	1.7718	2.3053	2.1148
13		2.3243	1.3908	2.0957	2.3053	2.572	1.8671
14		2.6292	1.3908	3.1817	2.3053	2.191	1.9624
15		2.553	1.3717	2.915		2.5339	2.2481
16		3.1436	1.3146	2.8197	2.2481	2.4958	2.1529
17	2.4768	2.553	1.3146	2.4958	2.2862	2.5149	2.3815
18	2.7435		1.3527	2.553	1.9052	2.3053	2.3243
19	2.5911		1.448	2.3624	1.5623	1.9624	1.848
20	1.7718	2.0767	1.4289	2.4006	1.7337	2.0576	1.7147
21	1.8099	2.2672	1.3336	2.191	1.9052	1.8671	1.6194
22	1.9052	2.0957	1.3908	2.3243	1.8671	2.2481	2.1148
23	1.9052	1.8861	1.3717	2.3624	1.6004	1.8099	
24	2.8578	2.0195	1.3146	1.467	1.8861	1.6575	1.8861
Max	2.8578	3.1436	1.9433	3.1817	2.4577	2.6292	2.5339
Min	1.7337	1.5623	1.2574	1.3717	1.5623	1.467	1.5242
Avg	2.0924	2.2196	1.4445	2.1322	1.9930	1.9957	2.0328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 205 / GANGA MAI I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191		.0191	.0191	.0191	.0191
2		.0191	.0191	.0191	.0191	.0191	.0191
3				.0191		.0191	
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191		.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8		.0191	.0191	.0191	.0191	.0191	.0191
9	.0381	.0381	.0191	.0381	.0381	.0381	.0191
10		.0191	.0191	.0381	.0381	.0381	.0191
11		.0381	.0191	.0572	.0191	.0381	.0381
12		.0381	.0191	.0572	.0381	.0381	.0381
13	.0191	.0381	.0191	.0381	.0381	.0381	.0381
14		.0381		.0572	.0381	.0572	.0381
15		.0381	.0191	.0381	.0381	.0381	.0381
16	.0381	.0381	.0191	.0381	.0381	.0381	.0381
17	.0191	.0381	.0381	.0572	.0381	.0572	.0381
18	.0191		.0191	.0381	.0191	.0381	.0381
19	.0191		.0191	.0381	.0191	.0381	.0381
20	.0191	.0191	.0191	.0381	.0381	.0191	.0191
21	.0191	.0191	.0191		.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0381	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	
24	.0381	.0381	.0191	.0572	.0381	.0381	.0191
Max	.0381	.0381	.0381	.0572	.0381	.0572	.0381
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0227	.0272	.0201	.0340	.0282	.0302	.0269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 207 / 11 KV ADEEP

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.3434	2.1338	1.9243	2.3624	1.7337	2.3624
2	2.0005	2.1148	2.0767	1.8671	2.0005	1.7147	2.3053
3	1.9433	2.1148	2.0957	1.7718	1.9814	1.6956	2.2291
4	1.9243	2.0957	2.0576	1.6956	1.9624	1.7337	2.0767
5	1.848	2.0957	2.0386	1.7147	1.9624	1.7337	2.0195
6	1.8671	2.0005		1.6385	1.9243	1.7528	1.9433
7	2.2672	2.0195	2.0957	1.9052	1.7147	2.2672	2.4768
8	2.6863	2.4958	1.8671	2.8387	1.8099	2.915	2.9531
9	2.934	3.2579	2.0767	2.8959	2.0767	3.3913	3.4484
10		3.2007	2.0767	3.0293	2.2291	3.5818	3.5437
11		3.3341	1.829	3.0483	2.4196	3.5056	3.2007
12		3.2769	1.9052	3.7723	2.2481	3.677	3.4675
13		3.1436	1.8861	3.1817	2.191	3.5056	3.296
14		3.6008	1.9243	3.6389	2.3434	3.7532	3.5818
15		3.0483	1.848	3.1626		3.3913	3.6008
16	3.4865	3.0674	1.9814	3.2007	2.3053	3.3341	3.4865
17	3.2388	3.0483	1.9052	3.1436	2.2862	3.2579	3.5818
18	3.1436		1.7909	3.1055	2.191	2.9721	3.1436
19	3.0483		1.6194	2.5339	1.9624	2.8197	2.7435
20	2.4958	4.5344	1.8099	2.6673	1.829	2.7054	2.7816
21	2.4958	2.4958	1.829	2.4577	1.6385	2.572	2.7435
22	2.4958	2.4958	1.9814	2.5911	1.8671	2.572	2.3434
23	2.21	2.4577	1.7337	2.4768	1.7528	2.5911	
24	3.4865	2.2481	2.3243	1.9433	2.3434	1.7337	2.4006
Max	3.4865	4.5344	2.3243	3.7723	2.4196	3.7532	3.6008
Min	1.848	2.0005	1.6194	1.6385	1.6385	1.6956	1.9433
Avg	2.5350	2.7495	1.9516	2.5919	2.0609	2.7046	2.8578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 208 / 11 KV RUCHA EXP

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.7811	.8002	.7049	.4572	.381	.8192
2	.8002	.8002	.8383	.743	.4572	.381	.8192
3	.8192	.8002	.8383	.7621		.381	.8383
4	.8192	.8002	.8383	.8002	.4763	.381	.8573
5	.8002	.8002	.8192	.8573	.4763	.381	
6	.743	.7811		.7621	.4763	.362	.8383
7	.7811	.8002	.7621	.8383	.4763	.6668	.8002
8	.9526	.5906	.9907	.8192	.381	.9145	.8002
9	.724	.7049	.8192	.8192	.362	.9526	.724
10		.724	.7621	.8573	.4382	.9526	.8764
11		.7621	.7811	.8002	.4382	.7621	.8002
12		.6668	.8192	.8764	.4001	.8383	.9526
13		.7811	.7621	.9717	.4001	.9717	.9526
14		.9907	.743	.8192	.6097	.7811	.9526
15		.8764	.8002	1.0669		1.0479	.8002
16		.9907	.8383	.9526	.5335	.9145	.9526
17		.8192	.8573	.8954	.5716	.8192	.8192
18	.8954		.8192	.7621	.362	.8002	.8764
19	.8764		.8764	.8383	.362	.4191	.8573
20	.8383	.8192	.8002	.8383	.381	.8192	.743
21	.8764	.8573	.9907	.8002	.362		.8383
22	.8383	.7621	.724	.7811	.381	.7621	.8383
23	.8002	.8573	.724	.7621	.381	.8002	
24	.8383	.7811	.7811	.724	.4572	.381	.8573
Max	.9526	.9907	.9907	1.0669	.6097	1.0479	.9526
Min	.724	.5906	.724	.7049	.362	.362	.724
Avg	.8276	.7976	.8167	.8272	.4382	.6900	.8461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 413 / Mylan

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.9721	2.572	2.0576	2.572	2.6863	2.7435
2	2.572	2.6292	2.572	2.2291	2.572	2.6863	2.6863
3	2.572	2.8578	2.572	2.3434	2.5149	2.6292	2.6292
4	2.572	2.7435	2.572	2.3434	2.572	2.572	2.6292
5	2.572	2.572	2.572	2.2862	2.6292	2.7435	2.572
6	2.6863	2.6292		2.1148	2.572	2.7435	2.7435
7	2.6292	2.572	2.5149	2.0005	2.4006	2.4577	2.6292
8	2.8578	2.7435	2.572	2.572	2.572	2.6863	2.9721
9	2.6863	3.0293	2.572	2.5149	2.572	2.6292	2.7435
10		3.0864	2.6292	2.572	2.572	2.7435	2.8006
11		3.2007	2.9721	2.6863	2.6292	2.7435	3.2579
12		3.1436	2.6292	2.8006	2.7435		2.915
13		3.0864	2.8578	2.8006	2.915	2.8578	3.3722
14		2.8006	2.572	2.7435	2.7435	3.1436	3.2007
15		2.9721	2.5149	2.8006	2.9721	2.8006	3.0864
16	2.915	3.0293	2.4006	2.8006	2.7435	3.0864	3.0864
17	2.7435	3.0293	2.4577	2.8578	2.8578	3.315	3.0864
18	2.5149		2.2291	2.6292	2.7435	2.9721	3.2007
19	2.4577		2.3434	2.6292	2.915	2.8006	3.0864
20	2.5149	2.6863	2.4006	2.915	2.6292	2.6292	2.915
21	2.7435	2.6292	2.6863	2.4006	2.6863	2.7435	2.8578
22	3.0293	2.5149	2.2862	2.572	2.6292	2.6863	2.8006
23	2.572	2.5149	2.4006	2.5149	2.6863	2.6863	
24	2.6863	2.7435	2.6292	4.7439	2.6292	2.6292	2.6863
Max	3.0293	3.2007	2.9721	4.7439	2.9721	3.315	3.3722
Min	2.4577	2.5149	2.2291	2.0005	2.4006	2.4577	2.572
Avg	2.6705	2.8266	2.5447	2.6220	2.6697	2.7683	2.9000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 414 / Varroc NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9721	2.9721	2.7435	2.6292	3.4294	1.9433	2.9721
2	2.6292	2.7435	2.8578	2.7435	2.7435	1.7147	2.7435
3	2.6292	2.8006	2.9721	2.8006	2.8578	1.6575	2.6292
4	2.6292	2.8578	2.9721	2.9721	2.8578	1.6004	2.8578
5	2.8578	2.9721	2.9721	4.1152	2.8578	1.7147	2.9721
6	3.315	2.572		2.6292	2.4006	1.829	2.6292
7	2.572	2.3434	2.572	2.2862	2.1719	1.9433	2.2862
8		3.5437	4.2295	3.5437	2.1719	2.9721	5.2584
9	5.3727	4.1152	4.0009	3.2007	2.0576	6.6301	5.8299
10		5.144	6.2872	3.658	1.9433	6.6301	5.9442
11		5.2584	5.7156	4.0009	2.0576	5.8299	6.0585
12		2.4006	2.6292	2.9721	2.1719	5.2584	5.144
13		3.658	6.4015	4.1152	2.1719	7.0873	5.7156
14		2.9721	5.0297	3.0864	1.9433	6.3443	2.8578
15		4.4582	5.3727	3.0864	2.1719	6.7444	5.7156
16	4.5725	6.6301	6.2872	3.315	2.1719	7.1445	6.0585
17	2.8578	5.0297	3.2007	2.5149	2.0576	7.4303	3.4294
18	3.5437		4.3439	3.7723	2.1719	4.8011	3.7723
19	3.4294		3.2007	2.6292	2.1719	2.8578	3.2007
20	2.8578	3.315	2.6292	2.6292	2.0576	2.6292	2.572
21	3.7723	2.8578	3.2007	2.8578	1.829	3.5437	2.572
22	2.7435	2.8578	2.7435	2.6292	1.7147	2.7435	2.572
23	3.2007	3.315	2.4006	2.7435	1.9433	3.0864	
24	4.6868	2.5149	2.7435	2.4006	2.4006	1.829	2.5149
Max	5.3727	6.6301	6.4015	4.1152	3.4294	7.4303	6.0585
Min	2.572	2.3434	2.4006	2.2862	1.7147	1.6004	2.2862
Avg	3.3319	3.5151	3.8046	3.0555	2.2719	3.9985	3.8394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 415 / Endurance NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.3146	2.4577	1.3717	1.5432	1.2003	2.2862
2	2.2291	1.8861	2.2862	1.3717	1.4289	1.2003	2.0005
3	2.2862	1.7147	2.1719	1.3717	1.3717	1.2003	1.829
4	2.3434	1.6575	2.2291	1.3717	1.3717	1.2003	1.7718
5	2.3434	1.5432	3.315	1.3146	1.4289	1.0288	1.6004
6	2.7435	1.4861		1.4861	1.3146	1.3146	1.6575
7	3.9438	1.829	1.086	1.829	1.2003	1.7147	1.829
8	2.7435	2.4006	1.3146	2.4006	1.2574	2.4006	2.2862
9	2.5149	2.3434	2.5149	2.8006	1.2574	2.3434	2.3434
10	2.7435	2.572	2.6863	2.572	1.3146	2.2291	2.4006
11		2.2862	2.6292	2.4006	1.3717	2.2862	2.1148
12	2.5149	2.572	2.6292	2.572	1.1431	2.3434	2.4577
13		2.5149	2.8578	2.4577	1.2003	2.6863	2.4577
14	2.5149	2.4577	2.4006	2.4006	1.1431	2.4577	2.572
15	2.8578	2.9721	2.572	2.6292	1.3146	2.8006	2.4577
16	2.572	2.915	2.6292	2.6292	1.3717	2.6863	2.572
17	2.572	2.8006	3.315	2.6863	1.3717	2.6863	2.5149
18	2.6863		2.7435	2.8578	1.3717	2.6863	2.1148
19	2.6292		2.5149	2.6292	1.1431	2.572	2.4577
20	2.5149	2.6863	2.2862	2.2862	1.0288	2.2862	2.4577
21	2.4006	2.572	2.3434	2.0576	1.086	2.4006	2.572
22	2.2862	2.6292	2.4006	2.0005	.8573	2.3434	2.1719
23	2.5149	2.5149	2.572	2.0576	.8573	2.6292	
24	1.829	1.8861	1.9433	1.829	1.7147	1.1431	1.8861
Max	3.9438	2.9721	3.315	2.8578	1.7147	2.8006	2.572
Min	1.5432	1.3146	1.086	1.3146	.8573	1.0288	1.6004
Avg	2.5149	2.2525	2.4304	2.1410	1.2693	2.0767	2.2092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 201 / KAIZEN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.3336	1.1431	.9335	1.2574	1.0288	1.3717
2	1.4098	1.2955	1.105	.9526	1.2765	1.0669	1.3336
3	1.448	1.2574	1.0669	.9145	1.2955	1.0669	1.3336
4	1.3717	1.2955	1.0288	.8764	1.2193	1.0669	1.2955
5	1.4098	1.2955	.9907	.9145	1.2574	1.2193	1.2384
6	1.4098	1.2955	.9145	.8764	1.2955	1.1431	1.2955
7	1.2384	1.1812	.7621	.8764	1.2574	1.105	1.1812
8	1.4098	1.2384	.9907	1.105	1.2955	1.3717	1.448
9	1.5242	1.2574	.9526	1.2955	1.2574	1.4861	1.5623
10	1.6385	1.448	.9526	1.3336	1.2955	1.448	1.448
11	1.4861	1.4098		1.6766	1.3717	1.3336	1.5242
12	1.4098	1.2955	.7621	1.6385	1.2384	1.3336	1.448
13	1.0669	.9907	.8383	1.5623	1.0288	1.2955	1.3908
14	1.5623	1.4098	1.1431	1.6004	1.3717	1.5623	1.6385
15	1.5242	1.5242	1.105	1.829	1.448	1.7147	1.6766
16	1.7147	1.4861	1.0669	1.9052	1.4861	1.7528	1.7718
17	1.829	1.6004	1.0479	1.7909	1.4861	1.6766	1.829
18	1.7528	1.6004	1.0288	1.6766	1.2574	1.6385	1.848
19	1.2574	1.2955	.9907	1.1812	1.2193	1.467	1.6385
20	1.2955	1.3336	.9907	1.4098	1.2955	1.4098	1.5623
21	1.4098	1.3336	1.0098	1.448	1.2193	1.3717	1.5242
22	1.5242	1.1812	1.3717	1.4098	.9526	1.3717	1.5242
23	1.4861	1.2193	1.1431	1.3717	1.0669	1.4861	1.448
24	1.448	1.448	1.1812	.9907	1.2955	1.0288	1.4098
Max	1.829	1.6004	1.3717	1.9052	1.4861	1.7528	1.848
Min	1.0669	.9907	.7621	.8764	.9526	1.0288	1.1812
Avg	1.4615	1.3344	1.0255	1.3154	1.2685	1.3519	1.4892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 202 / MDS ALLOYS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5525	.381	.1715	.5335	.5335	.5335
2	.4954	.5144	.3429	.1715	.5525	.4954	.4954
3	.5335	.5335	.3239	.1715	.4954	.4763	.4572
4	.4954	.4954	.3429	.1715	.5716	.4763	.4954
5	.5335	.4954	.4191	.1715	.6097	.3239	.5335
6	.4763	.4954	.4954	.1905	.5716	.4191	.4954
7	.5144	.4954	.4191	.2096	.4954	.5144	.5335
8	.5525	.6478	.1715	.3048	.5335	.5906	.5716
9	.6478	.6859	.1715	.4001	.5144	.7049	.6097
10	.6859	.8573	.1905	.5716	.6478	.724	.7621
11	.724	.8383		.6668	.6859	.6859	.8002
12	.8383	.7621		.6097	.6859	.6097	.8764
13	.6478	.7049	.1715	.6097	.4572	.6668	.724
14	.8383	.724	.1905	.6478	.4001	.6859	.7621
15	.6859	.743	.1905	.6478	.4572	.7621	.4572
16	.5335	.724	.1905	.6478	.5716	.8002	.6668
17	.7621	.5335	.1905	.6097	.6287	.7621	.6859
18	.6859	.7049	.1905	.5335	.6478	.7621	.6859
19	.5716	.5716	.1905	.5716	.5906	.5716	.4954
20	.4954	.5144	.1905	.5335	.5335	.5335	.5335
21	.5144	.5335	.1715	.5525	.5525	.4954	.4001
22	.4954	.4954	.1905	.4572	.4954	.381	.4954
23	.5525	.5335	.1715	.381	.5525	.3429	.4572
24	.5525	.5335	.4572	.1715	.4954	.5335	.4191
Max	.8383	.8573	.4954	.6668	.6859	.8002	.8764
Min	.4763	.4954	.1715	.1715	.4001	.3239	.4001
Avg	.5986	.6121	.2615	.4239	.5533	.5771	.5811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 203 / NATH FORGING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8383	.8002	.5716	.8002	.7621	.7621
2	.8002	.8002	.7811	.6097	.8383	.7621	.7621
3	.7621	.7621	.7811	.5716	.7621	.7621	.8002
4	.7621	.8002	.7621	.5335	.8002	.7621	.7811
5	.8002	.8002	.724	.5716	.8383	.743	.7621
6	.7621	.8002	.724	.6097	.8002	.8383	.724
7	.724	.8383	.6097	.6668	.8002	.8383	.9145
8	.8383	1.0288	.6668	1.0669	.9145	.5716	1.0669
9	.9145	1.105	.7621	1.1812	.8764	1.2193	1.1812
10	1.2955	1.2955	.6287	1.2193	1.0288	1.3336	1.2193
11	1.3717	1.2955		1.2574	.9526	1.2193	1.2955
12	1.1431	1.2193	.4572	1.0669	.9526	1.1431	1.2193
13	1.086	1.0669	.6097	1.105	.9907	1.0669	1.1241
14	1.6385	1.3717	.5716	1.6766	1.1431	1.448	1.3717
15	1.6004	1.4861	.6097	1.4861	1.2955	1.448	1.448
16	1.6385	1.448	.6097	1.3717	1.2955	1.5432	1.5242
17	1.5623	1.5242	.5716	1.3527	1.2955	1.448	1.5623
18	1.4098	1.2574	.6097	1.3717	1.2193	1.3336	1.2574
19	.9145	.9145	.5716	.9907	.8383	1.0288	.7811
20	.8002	.8383	.6097	.8002	.7049	.9526	.8002
21	.8192	.7621	.5716	.8383	.724	.8764	.743
22	.8002	.8383	.5716	.8002	.743	.7621	.724
23	.7811	.8383	.5906	.8383	.7621	.8192	.7811
24	.8383	.7621	.8383	.6097	.8383	.724	.8002
Max	1.6385	1.5242	.8383	1.6766	1.2955	1.5432	1.5623
Min	.724	.7621	.4572	.5335	.7049	.5716	.724
Avg	1.0375	1.0288	.6536	.9653	.9256	1.0169	1.0169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 204 / FOSTERS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.2574	1.1812	1.105	1.2574	.9907	1.2193
2	1.2955	1.2193	1.1431	1.1431	1.1812	.9526	1.1812
3	1.2574	1.1812	1.1431	1.105	1.2193	.9526	1.2193
4	1.3336	1.2574	1.1431	1.105	1.2384	.9526	1.2955
5	1.2955	1.2955	1.086	1.0479	1.2574	1.0288	1.2193
6	1.3717	1.2955	1.105	1.105	1.2193	1.0288	1.3336
7	1.0669	1.2193	.9526	1.1431	1.1812	1.0669	1.1431
8	1.5242	1.4098	1.1431	1.3717	1.2955	1.7147	1.5242
9	1.6385	1.448	1.1431	1.6004	1.3336	1.7528	1.7147
10	1.7147	1.6766	1.2193	1.829	1.3146	2.0195	1.9052
11	1.9052	1.6766		1.829	1.3146	1.9814	1.8671
12	1.5623	1.467	.6097	1.5242	1.3717	1.9052	1.8671
13	1.6004	1.7147	.7621	1.7528	1.3717	1.829	1.7147
14	1.6766	1.829	.9145	1.9814	1.4098	1.7909	1.7528
15	1.7528	1.7147	.9526	1.8861	1.3717	1.829	1.7147
16	1.6766	1.6004	.9907	1.829	1.2193	1.7147	1.7147
17	1.6766	1.6766	1.0479	1.7147	1.1431	1.7528	1.7528
18	1.5242	1.6766	.9907	1.5242	1.2955	1.7909	1.7147
19	1.448	1.3717	.9526	1.2193	1.105	1.3717	1.2574
20	1.2955	1.3146	.9145	1.2574	.9526	1.2955	1.2955
21	1.3527	1.0669	.8764	1.1812	.9907	1.3336	1.4098
22	1.3336	1.1812	.9907	1.1431	.9907	1.2955	1.2193
23	1.2955	1.2193	.9907	1.0669	.9907	1.2955	1.2193
24	1.2574	1.1431	1.1812	1.0288	1.2193	.9526	1.2574
Max	1.9052	1.829	1.2193	1.9814	1.4098	2.0195	1.9052
Min	1.0669	1.0669	.6097	1.0288	.9526	.9526	1.1431
Avg	1.4662	1.4130	1.0189	1.3956	1.2185	1.4416	1.4797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 205 / VARSA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.0669	1.0669	1.0098	1.0288	.9526	1.0669
2	.9145	1.0288	1.0669	1.0288	1.0669	.9526	1.0288
3	.8764	.9907	1.0669	.9907	.9907	.9526	1.0669
4	.9145	1.0288	1.0479	.9907	1.0288	.9526	1.0288
5	.9526	1.0288	1.0479	1.0288	.9907	.9526	1.0669
6	.9145	1.0288	1.0288	.9907	.9907	.9145	.9907
7	.9526	.9907	.9907	1.0288	1.0288	.9145	.9145
8	1.105	1.448	1.0288	1.2574	1.105	1.1431	1.1431
9	1.2574	1.5623	1.2193	1.3908	1.105	1.3717	1.4098
10	1.4861	1.4861	1.2193	1.448	1.3717	1.4861	1.467
11	1.4861	1.6004		1.4861	1.3717	1.6004	1.4861
12	1.4861	1.2955	.9526	1.3336	1.1431	1.5242	1.2765
13	1.2574	1.4098	1.0479	1.3717	1.1431	1.3717	1.2574
14	1.4861	1.6766	1.105	1.4098	1.2193	1.4098	1.3717
15	1.448	1.5242	1.105	1.448	1.2955	1.448	1.4098
16	1.3717	1.5242	1.1431	1.5242	1.105	1.3908	1.4098
17	1.4861	1.6004	1.086	1.4861	1.2193	1.3336	1.3717
18	1.2955	1.2574	1.0479	1.3717	1.1431	1.2955	1.3717
19	1.2574	1.2193	.9526	1.2955	.9145	1.3146	1.2003
20	.9526	1.105	.8764	1.1431	.8764	1.3336	1.0288
21	.9526	1.105	.8764	1.105	.9907	1.2193	1.105
22	.9145	1.0669	.8954	1.0669	.9907	1.2193	1.105
23	.9526	.9907	.8764	.9526	.9145	.9907	1.0669
24	.9907	1.0669	1.0479	.9145	.9907	.9526	1.105
Max	1.4861	1.6766	1.2193	1.5242	1.3717	1.6004	1.4861
Min	.8764	.9907	.8764	.9145	.8764	.9145	.9145
Avg	1.1527	1.2543	1.0346	1.2114	1.0844	1.2082	1.1979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 206 / RUBICON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.6097	.5335	.6287	.4954	.381	.6097
2	.724	.6478	.5144	.6478	.4191	.3429	.6859
3	.7621	.6668	.5144	.6097	.4572	.3429	.6478
4	.6859	.6097	.5335	.5716	.5335	.3429	.5716
5	.724	.6859	.5525	.6097	.4954	.3429	.5335
6	.6859	.6859	.5716	.5716	.4191	.3429	.6668
7	.4763	.4954	.4763	.5716	.381	.3429	.5335
8	.724	.6859	.7049	.6478	.3429	.7621	.7621
9	.8002	.7621	.9145	.7049	.381	.7621	.9145
10	.8573	.9907	.6859	1.0669	.4954	.9526	.9145
11	1.105	.8573		.9907	.4572	.8764	.9526
12	.6859	.8383	.4763	.8002	.4572	.8383	.8764
13	.9907	.9145	.6859	.8383	.381	.9335	.9526
14	.9526	1.0669	.7621	.9526	.4763	.9526	.9907
15	.9526	.7621	.8383	.9145	.4954	.9907	.9145
16	.9907	1.0288	.8764	.7621	.4572	.9717	.8573
17	.9145	1.105	.9145	.8764	.5144	.9145	.9145
18	.7621	.9145	.7621	1.0669	.4191	.8764	1.0098
19	.6478	.6859	.5335	.8383	.3429	.6287	.5716
20	.6478	.7049	.6668	.8383	.4191	.6097	.6097
21	.5335	.724	.6859	.5716	.4572	.6097	.7049
22	.4954	.5335	.5716	.5906	.4191	.5716	.6097
23	.5335	.6097	.5335	.5335	.5716	.5335	.724
24	.8002	.5716	.5716	.6478	.5335	.4191	.5716
Max	1.105	1.105	.9145	1.0669	.5716	.9907	1.0098
Min	.4763	.4954	.4763	.5335	.3429	.3429	.5335
Avg	.7589	.7565	.6470	.7438	.4509	.6517	.7542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 201 / 11KV TTK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5149	2.4387	2.2862	1.7528	2.21	2.4387	2.6673
2	2.5149	2.4006	2.2862	1.7528	2.1338	2.4006	2.5149
3	2.2862	2.4387	2.0576	1.7147	2.1338	2.4387	2.5911
4	2.2862	2.4387	2.0576	1.7147	2.1338	2.3624	2.4768
5	2.5149	2.4387	1.9814	1.7528	2.0957	2.3624	2.4006
6	2.5149	2.4006	1.9814	1.829	2.1338	2.3624	2.2862
7	2.5149	2.21	1.9814	1.829	2.1338	2.3624	2.2862
8	2.6673	3.1245	1.829	2.2862	2.2862	2.572	2.8959
9	3.658	3.8104	1.7528	2.8959	2.6673	3.2007	3.3913
10	3.7342	3.8104	1.9814	3.658	3.0483	3.5056	3.8104
11	4.1152	3.9628	1.9052	4.0009	3.2769	3.8104	4.1152
12	3.4675	3.2769	1.829	3.6199	3.1626	3.3532	2.8959
13	3.658	3.5818	1.7528	3.2769	3.2007	3.5056	3.4294
14	3.8104	3.7342	1.6766	3.8104	3.2007	3.8104	4.039
15	4.1152	3.8104	1.6004	4.039	3.2007	3.8104	3.8104
16	3.8104	3.8104	1.7528	3.8104	2.9721	3.4675	3.5056
17	3.9247	3.5818	1.9814	3.5818	2.8959	3.5056	2.8578
18	3.0483	3.2007	1.829	3.2007	2.8197	3.2769	2.7054
19	3.0483	1.6385	1.7528	2.7054	2.4768	2.7625	2.5149
20	2.8959	2.7435	1.829	2.2862	2.21	2.5911	2.5149
21	2.572	2.5911	1.829	2.2481	1.9814	2.3624	2.2862
22	2.4768	2.6673	1.7528	2.1338	1.9814	2.5911	2.5149
23	2.4387	2.5911	1.7528	2.21	2.6673	2.5911	2.5911
24	2.5911	2.4387	2.4768	1.829	2.1338	2.5149	2.7435
Max	4.1152	3.9628	2.4768	4.039	3.2769	3.8104	4.1152
Min	2.2862	1.6385	1.6004	1.7147	1.9814	2.3624	2.2862
Avg	3.0491	2.9642	1.9131	2.6641	2.5482	2.9150	2.9102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 202 / 11KV G Sector

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574	1.105	1.105	.9907	1.0288	.8383	.9907
2	1.2574	1.105	1.105	.9907	1.0288	.8764	1.0288
3	1.1812	1.0669	1.0288	.9526	.9526	.8383	.9907
4	1.1812	1.105	1.0288	.9526	.9526	.8764	.9526
5	1.1812	1.0669	.9526	.9145	.9907	.8383	.9526
6	1.105	1.105	.9526	.9145	.9907	.8002	.9145
7	1.105	1.1431	.9145	.9145	.9526	.9907	.9907
8	1.1812	1.3717	.8764	1.3336	.9526	1.3717	1.4861
9	1.8671	1.6766	.8764	1.6004	1.6766	1.7909	1.5623
10	1.7909	2.21	.7621	1.9814	1.7147	1.9052	1.5623
11	1.6004	1.7147	.8383	1.9052	1.7147	2.0576	1.6385
12	1.6004	1.6766	.7621	1.5623	1.5242	1.6004	1.5242
13	1.5623	1.7147	.724	1.2574	1.6004	1.7909	1.7528
14	1.829	1.829	.724	1.6004	1.7147	1.829	2.0576
15	2.0576	1.7909	.7621	1.7528	1.7147	1.9052	1.9433
16	1.9433	1.8671	.7621	1.9052	1.6004	1.829	1.9433
17	1.9433	1.7909	.8002	2.2481	1.7909	1.829	1.7147
18	1.829	1.7528	.9145	1.4098	1.7147	1.6004	1.7147
19	1.6004	1.6385	.9526	1.1431	1.448	1.3717	1.5623
20	1.2955	1.5242	.9145	1.0288	1.0288	1.3336	1.448
21	1.2574	1.3336	.9526	1.1431	1.105	1.2955	1.1431
22	1.2574	1.2574	.9526	1.1812	1.105	1.2193	1.1431
23	1.2193	1.2574	.9526	1.0288	.9907	1.0288	1.0288
24	1.2574	1.1431	1.1431	1.0288	1.0288	.9526	1.0669
Max	2.0576	2.21	1.1431	2.2481	1.7909	2.0576	2.0576
Min	1.105	1.0669	.724	.9145	.9526	.8002	.9145
Avg	1.4733	1.4686	.9066	1.3225	1.3051	1.3654	1.3797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 203 / Satyam

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6478	.6859	.5716	.724	.7049	.7049
2	.6097	.7621	.6859	.5716	.724	.7049	.6478
3	.6859	.7621	.724	.6097	.6478	.7049	.7049
4	.6859	.7621	.724	.6097	.6478	.7049	.7049
5	.6478	.7621	.6478	.6097	.6859	.7049	.6478
6	.6859	.7621	.6478	.6478	.724	.7049	.6478
7	.6478	.724	.6478	.6478	.724	.7621	.8764
8	.6859	1.0288	.6859	.8383	.724	.9145	.8764
9	1.1812	1.1812	.724	.9526	.8764	1.0669	1.2574
10	1.1812	1.2955	.6478	1.2574	1.0288	1.2574	1.2574
11	1.3717	1.2193	.724	1.1812	1.2193	1.3336	1.4098
12	1.1431	1.1431	.6478	1.1431	1.1622	1.1431	1.1812
13	1.0669	1.2193	.6097	1.0669	1.1431	1.2003	1.2574
14	1.2955	1.2574		1.1431	1.105	1.2193	1.2193
15	1.2384	1.2574	.6859	1.2193	1.0288	1.1431	1.1431
16	1.2193	1.3336	.6478	1.2574	.9526	1.1431	1.1431
17	1.2574	1.2574	.5716	1.2574	.9145	1.1431	1.0669
18	1.0288	1.1431	.5716	1.1431	.8192	1.086	.9907
19	.8192	.9907	.5716	.9526	.8192	.8383	.9526
20	.724	.8764	.6097	.8002	.7621	.7621	.8764
21	.724	.7621	.6097	.7621	.7621	.6859	.724
22	.6859	.6859	.5716	.6478	.7621	.6859	.6859
23	.6668	.724	.5716	.6859	.6859	.6478	.6859
24	.5716	.6859	.6859	.5716	.724	.6859	.6859
Max	1.3717	1.3336	.724	1.2574	1.2193	1.3336	1.4098
Min	.5716	.6478	.5716	.5716	.6478	.6478	.6478
Avg	.8931	.9685	.6478	.8812	.8486	.9145	.9312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 204 / Niton

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8002	.8002	.6859	.9526	.8383	.8383
2	.9145	.8383	.8002	.6859	.9526	.8002	.8002
3	.8764	.8002	.7621	.6859	.9145	.8383	.8002
4	.8764	.8383	.724	.724	.9145	.8383	.8383
5	.8383	.8383	.724	.724	.8764	.8383	.8383
6	.8764	.8383	.7621	.724	.9145	.8383	.8002
7	.8764	.8764	.7621	.724	.9145	.8764	.8002
8	.9145	.9907	.8383	.9145	.9526	.9907	.9907
9	1.1812	1.1431	.8383	.9907	1.0288	1.2193	1.0669
10	1.2193	1.2193	.9145	1.2955	1.0288	1.1812	1.2193
11	1.448	1.3717	.8383	1.2955	1.105	1.3717	1.2955
12	1.2574	1.1431	.8383	1.1812	1.0669	1.2193	.9145
13	1.2574	1.1431	.8764	1.1812	1.0669	1.2574	.9526
14	1.2955	1.1431	.7621	1.1812	1.0669	1.3336	1.1431
15	1.2955	1.1431	.7621	1.1431	1.0669	1.4098	1.1431
16	1.2193	1.1431	.724	1.1431	1.0669	1.3336	1.105
17	1.2193	1.1431	.724	1.105	1.0288	1.2955	1.0288
18	1.1431	1.1812	.6859	1.1431	1.0288	1.2574	.9907
19	1.0288	1.0669	.6859	1.0669	.8383	.9526	.9526
20	.8764	.9526	.6859		.8764	.8764	.9526
21	.8764	.8383	.6859	.9526	.7621	.8002	.9145
22	.8383	.8002	.6859	.9526	.7621	.8192	.8764
23	.8002	.7621	.6859	.9526	.8383	.8383	.9526
24	.8764	.8002	.7621	.6859	.9526	.8002	.8383
Max	1.448	1.3717	.9145	1.2955	1.105	1.4098	1.2955
Min	.8002	.7621	.6859	.6859	.7621	.8002	.8002
Avg	1.0383	.9923	.7637	.9625	.9574	1.0344	.9605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 205 / 11KV E Sector (LIP)
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.5335	.4572	.5335	.4572	.4572
2	.5716	.5716	.5335	.4572	.5335	.4572	.4191
3	.5335	.5716	.4954	.4954	.4954	.4572	.4954
4	.5335	.5716	.4954	.4954	.4954	.4572	.4572
5	.5335	.5335	.4572	.4954	.4954	.4572	.4572
6	.5335	.5716	.4572	.5335	.5335	.4572	.4572
7	.4954	.6097	.4572	.5335	.5335	.4954	.6287
8	.5716	.6859	.4191	.5716	.5335	.5716	.6287
9	.7621	.7621	.4191	.6097	.6859	.6859	.724
10	.8383	.8383	.4191	.6097	.6859	.7621	.8383
11	.8764	.8383	.4572	.8383	.8002	.8383	.8383
12	.7621	.8383	.4572	.8383	.724	.7621	.6859
13	.7621	.8383	.4572	.7621	.7621	.724	.7621
14	.9145	.8764	.4572	.8002	.8383	.2667	.7621
15	.9526	.8764	.4191	.7621	.8764	.8383	.7621
16	.9145	.9145	.4191	.8383	.6859	.7621	.7621
17	.9526	.9145	.4191	.7621	.6478	.7621	.7621
18	.9526	.9145	.4191	.6859	.7049	.7621	.724
19	.8002	.7621	.4191	.5716	.5716	.6478	.6859
20	.6859	.6478	.381	.5335	.5335	.5335	.6859
21	.6478	.5335	.381	.5716	.4572	.5335	.6097
22	.6668	.5335	.381	.4572	.4572	.5335	.5335
23	.6097	.5335	.381	.4954	.4572	.4954	.5335
24	.4572	.5716	.5335	.381	.5335	.4572	.4572
Max	.9526	.9145	.5335	.8383	.8764	.8383	.8383
Min	.4572	.5335	.381	.381	.4572	.2667	.4191
Avg	.7042	.7034	.4445	.6065	.6073	.5906	.6303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 206 / 11KV Ramnani
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	.9145	.9526	.9907	.9145	.6097	.9526
2	1.0669	.9145	.9526	.9526	.9145	.6097	.8764
3	1.0288	.8764	.9145	.8764	.8383	.6287	.9145
4	1.0288	.8764	.8764	.8764	.8383	.6097	.8764
5	.9526	.8383	.8764	.8383	.8764	.5716	.8764
6	.8383	.8764	.8002	.7621	.7621	.6097	.8383
7	.8764	.8383	.7621	.7621	.8383	.6097	.9145
8	.9145	.9526	1.0288	.9907	.8383	.8383	1.0669
9	1.1431	1.0669	1.1812	1.1431	.9907	.9526	1.105
10	1.2955	1.1431	1.0288	1.2574	.9145	1.0669	1.2193
11	1.2955	1.448	1.1431	1.1812	.8002	1.0669	1.3717
12	1.1431	1.1431	1.0669	1.1431	.8002	1.0288	1.2193
13	1.1431	1.1431	1.0288	.9907	.8383	1.0288	1.2574
14	1.1812	1.1812	1.0288	.9526	.7621	.9907	1.2955
15	1.2955	1.1812	.9907	.9145	.7621	1.0669	1.1431
16	1.0669	1.1812	.9907	.9526	.8002	1.0288	1.0669
17	1.105	1.1431	.9907	.9907	.7621	1.0288	1.0288
18	.9907	1.1431	.9526	.9145	.7621	1.0288	.9907
19	1.0288	1.0669	.9145	.9145	.724	.9526	.9907
20	1.105	.9907	.9907	.9145	.6859	.9526	.9526
21	1.0669	.9907	.9907	.7621	.6097	.9145	.9145
22	1.0288	1.0669	.9526	.6859	.6668	.9526	.9907
23	.9907	1.1431	.9526	.9145	.6097	.9907	.7621
24	1.0669	.9907	1.0669	.9907	.9145	.6097	.9907
Max	1.2955	1.448	1.1812	1.2574	.9907	1.0669	1.3717
Min	.8383	.8383	.7621	.6859	.6097	.5716	.7621
Avg	1.0717	1.0463	.9764	.9447	.8010	.8645	1.0256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 207 / IPCA EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.5242	1.5242	1.6004	1.6766	1.5242	1.5242
2	1.6004	1.5623	1.5242	1.5242	1.6766	1.5242	1.4861
3	1.5242	1.5623	1.448	1.5242	1.6004	1.4861	1.4861
4	1.5242	1.4861	1.448	1.5242	1.6004	1.4861	1.4861
5	1.5242	1.5242	1.4861	1.448	1.5242	1.4861	1.4861
6	1.5242	1.5242	1.4861	1.448	1.5242	1.4861	1.448
7	1.5242	1.6004	1.448	1.448	1.5242	1.448	1.448
8	1.5242	1.5242	1.6004	1.448	1.5242	1.448	1.448
9	1.6766	1.5242	1.7147	1.4861	1.6766	1.6004	1.448
10	1.7528	1.7528	1.7147	1.3717	1.7528	1.7528	1.448
11	1.7528	1.7528	1.8671	1.5242	1.7528	1.9052	1.5242
12	1.7147	1.9052	1.9052	1.6766	1.7147	1.829	1.7528
13	1.7909	1.829	1.9052	1.7528	1.7147	1.7909	1.6766
14	1.9052	1.7528	1.829	1.7528	1.6766	1.829	1.6004
15	2.0957	1.7147	1.829	1.7528	1.6766	1.829	1.5623
16	2.0576	1.7147	1.7909	1.6766	1.6385	1.7909	1.5242
17	1.9052	1.6766	1.829	1.6766	1.6766	1.7909	1.5242
18	1.6766	1.6004	1.7909	1.7528	1.6766	1.7528	1.5242
19	.1905	1.6004	1.7909	1.7528	1.7147	1.6766	1.6004
20	1.9052	1.6004	1.829	1.5242	1.6766	1.6004	1.6004
21	1.829	1.6004	1.7147	1.5242	1.6766	1.5242	1.6004
22	1.7909	1.5242	1.7147	1.5242	1.5242	1.5242	1.6766
23	1.7528	1.5242	1.6766	1.6766	1.5242	1.5242	1.6004
24	1.6004	1.6766	1.5242	1.6766	1.6766	1.5242	1.5242
Max	2.0957	1.9052	1.9052	1.7528	1.7528	1.9052	1.7528
Min	.1905	1.4861	1.448	1.3717	1.5242	1.448	1.448
Avg	1.6560	1.6274	1.6830	1.5861	1.6417	1.6306	1.5417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 208 / 11 KV NRB EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.0953	.1143	.1524	.2286	.1524	.1524
2	.2286	.0953	.1524	.1524	.2286	.1524	.1524
3	.1905	.0953	.1524	.1143	.1905	.1334	.1524
4	.1905	.0953	.1905	.1143	.1905	.1524	.1715
5	.2286	.0762	.1905	.1143	.1524	.1334	.1715
6	.1905	.0762	.1905	.1524	.1143	.1524	.1524
7	.2286	.0953	.1905	.1524	.1143	.1524	.1524
8	.2286	.1143	.1905	.1524	.1524	.1524	.2286
9	.3048	.1715	.1524	.1524	.2667	.2286	.2286
10	.2667	.2667	.2286	.2286	.2667	.3048	.2667
11	.3048	.2667	.1524	.2286	.3048	.3048	.2286
12	.2667	.2667	.1524	.2667	.2667	.2477	.2286
13	.2477	.2667	.1524	.2286	.2667	.2667	.2667
14	.3048	.2286	.1524	.1905	.2286	.3048	.2667
15	.3429	.2286	.1524	.1905	.2477	.3048	.2667
16	.3048	.2286	.1143	.2667	.2667	.2667	.2667
17	.3048	.2286	.1143	.381	.3048	.2667	.2667
18	.2477	.2667	.1524	.2286	.3048	.2667	.3048
19	.2286	.1905	.1905	.2286	.2286	.2477	.3048
20	.0953	.1524	.0762	.1905	.1524	.2667	.2286
21	.1905	.0762	.0762	.2286	.2286	.1524	.3048
22	.1524	.1524	.0762	.2286	.2286	.1524	.2286
23	.1524	.1524	.0762	.2286	.1524	.1524	.2286
24	.2286	.1524	.1143	.0762	.2286	.1905	.1524
Max	.3429	.2667	.2286	.381	.3048	.3048	.3048
Min	.0953	.0762	.0762	.0762	.1143	.1334	.1524
Avg	.2358	.1683	.1461	.1937	.2215	.2127	.2238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 209 / 11 KV Speciality Polyfilm NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.2667	.3048	.3048	.3239	.2667
2	.3048	.3239	.2667	.3048	.3048	.3239	.3048
3	.3429	.3429	.2286	.2667	.2286	.3239	.3048
4	.3429	.3239	.2286	.2667	.2286	.3429	.3048
5	.3048	.3239	.2667	.2667	.3048	.3239	.3048
6	.3429		.2286	.3048	.2286	.3239	.3048
7	.3429	.3048	.2286	.3048	.2667	.3048	.3239
8	.3429	.3429	.2667	.3048	.2667	.3048	.3239
9	.3048	.381	.3048	.3429	.3048	.3239	.3048
10	.3429	.2286	.3429	.3429	.2667	.3429	.3429
11	.3239	.2667	.2667	.3048	.3048	.381	.3429
12	.3048	.2286	.2667	.3048	.3048	.3429	.3048
13	.3048	.2667	.3048	.3429	.2858	.3429	.3429
14	.3048	.3048	.3048	.3048	.3429	.4191	.3429
15	.381	.3048	.3048	.3048	.3239	.4191	.3429
16	.381	.3429	.2667	.3048	.3048	.381	.3429
17	.3239	.3429	.3048	.2667	.381	.381	.3048
18	.2286	.3429	.3048	.3048	.3429	.3429	.3048
19	.2286	.3429	.3048	.3048	.3429	.3048	.3429
20	.2286	.3048	.3048	.3048	.2286	.3048	.2667
21	.2286	.3048	.3048	.3048	.3048	.2286	.2667
22	.8002	.3048	.3048	.2286	.3048	.2477	.3048
23	.2286	.3048	.3048	.3048	.3048	.2477	.3048
24	.3429	.2286	.3048	.3048	.3048	.3048	.2286
Max	.8002	.381	.3429	.3429	.381	.4191	.3429
Min	.2286	.2286	.2286	.2286	.2286	.2286	.2286
Avg	.3286	.3073	.2826	.3000	.2953	.3286	.3096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 210 / 11 KV Tata Tele Services NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953	.0953
4	.0953	.0953	.0953	.0953	.0953	.0953	.0953
5	.0953	.0953	.0953	.0953	.0953	.0953	.0953
6	.0953	.0953	.0953	.0953	.0953	.0953	.0953
7	.0953	.0953	.0953	.0953	.0953	.0953	.0953
8	.0953	.0953	.0953	.0953	.0953	.0953	.0953
9	.0953	.0953	.0953	.0953	.0953	.0953	.0953
10	.0953	.0953	.0953	.0953	.0953	.0953	.0953
11	.0953	.0953	.0953	.0953	.0953	.0953	.0953
12	.0953	.0953	.0953	.0953	.0953	.1143	.0953
13	.0953	.0953	.0953	.0953	.0953	.1143	.0953
14	.0953	.0953	.0953	.0953	.0953	.0953	.0953
15	.0953	.0953	.0953	.0953	.0953	.0953	.0953
16	.0953	.0953	.0953	.0953	.0953	.0953	.0953
17	.0953	.0953	.0953	.0953	.0953	.0953	.0953
18	.0953	.0953	.0953	.0953	.0953	.0953	.0953
19	.0953	.0953	.0953	.0953	.0953	.0953	.0953
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	.0953	.0953	.0953	.0953	.0953	.1143	.0953
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.0953	.0953	.0953	.0953	.0953	.0969	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 401 / NEW ENDURANCE EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 33 / (CONTINOUS PROCESS)(NO STAGGERING)
 INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.743	.6859	.5716	.6287	.4001	.743
2	.5716	.743	.6859	.5716	.6287	.4001	.6859
3	.5144	.743	.5716	.4572	.5716	.2858	.5716
4	.5144	.8002	.5716	.4572	.5716	.4001	.5716
5	.5716	.743	.5716	.4572	.5144	.4001	.5716
6	.5144	.743	.6859	.5144	.5144	.4001	.5716
7	.5716	.5716	.6859	.5144	.2858	.4572	.6859
8	.8002	.6859	.6859	.6859	.3429	.5716	.8002
9	.9145	.8002	.8002	.9717	.4001	.8573	.8573
10	.9717	.9145	.9145	1.0288	.4001	.8573	.8573
11	1.0288	1.0288	.9145	1.0288	.4001	.9145	.9717
12	1.0288	.6859	.8573	.9717	.4001	.9145	.9145
13	1.0288	.8002	.8573	.9145	.4001	.9145	.9145
14	.9145	.9145	.8573	.9145	.4572	.9717	1.0288
15	1.0288	.9145	.9145	.9145	.4001	.9145	.9717
16	.9145	.9145	.9145	1.0288	.4001	.9717	.9717
17	.9717	.8002	.9145	.9717	.4001	.9717	1.0288
18	.9145	.8002	.8002	.8573	.3429	.9145	1.0288
19	.8002	.8002	.743	.6859	.3429	.9717	.9717
20	.8002	.6859	.5716	.6287	.4001	.9145	.9145
21	.8002	.6859	.5716	.6287	.1715	.8002	.8002
22	.6859	.8002	.5716	.6287	.4001	.8002	.8573
23	.6859	.6859	.5716	.6287	.3429	.743	.8002
24	.5716	.6859	.6859	.5716	.6287	.3429	.6287
Max	1.0288	1.0288	.9145	1.0288	.6287	.9717	1.0288
Min	.5144	.5716	.5716	.4572	.1715	.2858	.5716
Avg	.7788	.7788	.7335	.7335	.4311	.7121	.8216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 201 / Indian Tool
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.9433	1.7528	1.4098	1.6766	1.4861	1.829
2	1.7909	1.8671	1.7147	1.3717	1.6575	1.5242	1.7909
3	1.7909	1.7337	1.6766	1.3336	1.6385	1.5242	1.7909
4	1.7147	1.6766	1.6004	1.3336	1.6004	1.5242	1.7147
5	1.6766	1.6766	1.4098	1.3336	1.5242	1.5623	1.6766
6	1.6004	1.6385	1.448	1.3336	1.5623	1.5623	1.6766
7	1.5623	1.5432	1.3336	1.3336	1.448	1.6385	1.6766
8	2.4768	2.3624	1.9433	2.0195	1.7147	1.9814	2.0957
9	2.4768	2.4196	1.9433	1.9433	1.7528	2.2862	2.21
10	2.934	2.8959	2.0957	2.6673	2.0195	2.6673	2.7054
11	2.7816	2.8197	2.0576	2.6673	1.8671	2.8959	2.553
12	2.3243	2.4387	1.6004	1.9052	1.8671	2.2862	2.0767
13	2.6673	2.8578		2.3624	1.9052	2.3624	2.6673
14	2.8197	2.553	1.2193	2.3815	1.9814	2.7816	2.4577
15	2.7435	2.934	1.9052	2.4768	1.829	2.7435	2.5911
16	2.8578	2.7435	1.9052	2.2481	1.9052	2.6673	2.3624
17	2.4768	2.5911	1.6004	2.0957	1.9814	2.6673	2.2481
18	2.4006	2.4006	1.6004	1.9624	1.7528	2.3624	2.3624
19	2.3624	2.21	1.1431	1.7909	1.6766	2.1338	2.1338
20	2.191	1.9814	1.3717	1.7147	1.448	1.829	1.9433
21	2.1338	1.9814	1.448	1.6385	1.448	1.7909	1.6385
22	2.0957	2.21	1.448	1.7909	1.5242	1.829	1.8671
23	2.0957	1.7528	1.448	1.6004	1.4098	1.9814	1.829
24	1.9052	1.9433	1.6004	1.448	1.6766	1.4098	1.9052
Max	2.934	2.934	2.0957	2.6673	2.0195	2.8959	2.7054
Min	1.5623	1.5432	1.1431	1.3336	1.4098	1.4098	1.6385
Avg	2.241	2.2156	1.6203	1.8401	1.7028	2.0624	2.0751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 202 / D Sector

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8383	.8002	.6478	.6287	.5335	.6859
2	.8002	.8383	.8002	.6859	.6287	.5335	.6478
3	.8002	.8192	.8002	.6859	.6478	.5335	.6478
4	.8002	.8383	.7621	.724	.6478	.5335	.6478
5	.8383	.8192	.724	.7621	.6668	.4954	.6478
6	.8383	.8002	.7621	.7621	.4191	.4572	.6478
7	.8764	.8954	.7621	.8383	.4191	.4954	.6478
8	1.3336	1.2765	.8002	.8002	.6097	1.1812	.9526
9	1.5242	1.3336	.8002	1.5242	.8764	1.5242	1.6194
10	1.6004	1.3717	.8383	1.5813	1.1622	1.5623	1.3527
11	1.8671	1.6385	.9907	1.5813	1.105	1.4861	1.6385
12	1.5623	1.3717	.8002	1.467	1.0288	1.2765	1.5432
13	1.5432	1.5623	.8383	1.5242	1.105	1.7147	1.1812
14	1.6385	1.6385	.9145	1.5432	1.3717	1.3336	1.6956
15	1.448	1.6004	.8383	1.1812	1.0669	1.4861	1.829
16	1.6004	1.2955	.7621	1.2574	1.0288	1.5242	1.8099
17	1.5623	1.3717	.724	1.2955	.7621	1.4861	1.8099
18	1.3717	1.3336	.6859	1.1241	.8383	1.5242	1.6766
19	.9907	1.0669	.4763	1.1431	.7621	.9335	1.0479
20	1.0288	.9907	.381	.9145	.5716	.8764	1.0288
21	.8764	.8764	.381	.6668	.6097	.7621	1.0098
22	.9526	.8383	.381	.6478	.5716	.7621	1.0098
23	.9145	.8764	.381	.743	.5335	.724	.7811
24	.9526	.8383	.7621	.6478	.6859	.6859	.724
Max	1.8671	1.6385	.9907	1.5813	1.3717	1.7147	1.829
Min	.8002	.8002	.381	.6478	.4191	.4572	.6478
Avg	1.1884	1.1304	.7153	1.0312	.7811	1.0177	1.1368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 203 / RKHVAL INDUSTRIES

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8002	.9145	.6859	.8192	.7621	.9526
2	.8383	.8002	.9145	.6478	.8192	.724	.8764
3	.8383	.8002	.8764	.6478	.8002	.724	.8383
4	.8383	.8192	.8383	.6478	.8002	.724	.8383
5	.8383	.8192	.8002	.724	.7811	.7621	.8383
6	.8383	.8383	.8383	.7621	.8002	.7621	.8383
7	.8383	.8383	.8764	.8383	.8573	.7621	.8383
8	.8383	.9145	.8764	.8002	.8383	.9145	.9145
9	.9907	.9717	.8764	.8764	.7621	.9907	.9526
10	1.2574	1.1241	.8764	.9526	.724	1.2574	1.2574
11	1.105	1.3336	.9907	1.1431	.724	1.3336	1.3336
12	.9335	1.0288	.9907	1.2003	.724	1.0288	1.086
13	.8383	1.2193	.8383	.8002	.724	1.0669	.8954
14	.9717	1.2574	1.0669	.8954	.6478	1.1812	1.2765
15	1.2193	1.1431	.9907	1.0098	.7621	1.1812	1.0669
16	.9907	1.0669	.8764	.9907	.7621	1.1812	1.1812
17	1.0288	1.1431	.8764	1.0669	.724	1.1431	1.105
18	.9717	1.1812	.9526	.9526	.724	1.105	1.0288
19	.8954	.8764	.9526	1.0288	.7621	.8764	.8002
20	.8192	.8383	.8573	.8954	.724	.9907	.8002
21	.8002	.9145	.8002	.8764	.724	.9526	.7811
22	.7811	.8002	.7621	.8954	.724	.9526	.7621
23	.7621	.8764	.7621	.8764	.724	.9526	.8002
24	.8764	.8002	.8383	.7621	.8764	.724	.9526
Max	1.2574	1.3336	1.0669	1.2003	.8764	1.3336	1.3336
Min	.7621	.8002	.7621	.6478	.6478	.724	.7621
Avg	.9145	.9669	.8851	.8740	.7637	.9605	.9590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 204 / 11 KV AURANGABAD ROTOPLAST SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.6097	.6097	.5335	.6668	.5716	.6097
2	.6478	.6287	.6097	.5335	.6668	.5716	.6478
3	.6478	.6478	.6097	.5525	.6478	.5335	.6478
4	.6478	.6478	.6097	.5335	.6478	.5335	.6859
5	.6859	.6668	.6097	.5716	.6478	.5335	.6859
6	.724	.6859	.6097	.6097	.6287	.6859	.724
7	.724	.7621	.5716	.6478	.7049	.6859	.7621
8	.9145	.9907	.6097	.8383	.743	.9526	.8383
9	1.1812	1.1431	.7621	1.0669	.8192	1.3336	.8383
10	1.448	1.6004	.9526	1.3717	.9907	1.3336	1.4098
11	1.6385	1.5623	1.0288	1.4861	1.1431	1.5623	1.6004
12	1.2955	1.3336	.9526	1.448	1.0669	1.3717	1.4098
13	1.2955	1.2955	.9526	1.2193	.9907	1.3336	1.2574
14	1.448	1.6004	.9907	1.2384	1.0669	1.5242	1.448
15	1.467	1.6004	1.0288	1.2955	1.0669	1.4861	1.5242
16	1.448	1.7147	1.0288	1.3527	1.0669	1.448	1.6004
17	1.2955	1.3336	.9907	1.2193	.9907	1.4098	1.2574
18	1.2955	1.1812	.724	1.1431	.9145	1.0669	1.2574
19	.8573	.8383	.6478	.7621	.724	.7621	.9145
20	.6859	.724	.6097	.6478	.6859	.6859	.8002
21	.6478	.6859	.6097	.6478	.6097	.6859	.7049
22	.6097	.6859	.5716	.6478	.6097	.6478	.7621
23	.6478	.6859	.5335	.6097	.6097	.6478	.6668
24	.6478	.6478	.6478	.5335	.6668	.6097	.6097
Max	1.6385	1.7147	1.0288	1.4861	1.1431	1.5623	1.6004
Min	.4191	.6097	.5335	.5335	.6097	.5335	.6097
Avg	.9717	1.0114	.7446	.8963	.8073	.9574	.9860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 205 / 11 KV HVDS PADHARPUR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4191	.4191	.4572	.4001	.4191	.4572
2	.4191	.4001	.4191	.4572	.381	.4191	.4572
3	.4191	.4001	.4191	.4572	.381	.4191	.4954
4	.4191	.4001	.4191	.4954	.381	.4191	.4954
5	.4572	.4763	.4191	.4954	.381	.4572	.5335
6	.5335	.5525	.5335	.5335	.4572	.4954	.5335
7	.5716	.5716	.4954	.5335	.4954	.5335	.5335
8	.4572	.4763	.5335	.4572	.5335	.4954	.4572
9	.5335	.5335	.4954	.5335	.5144	.4191	.5335
10	.4001	.4572	.5335	.4954	.5144	.4954	.4954
11	.4191	.4572	.5335	.4572	.4572	.4572	.4572
12	.4572	.4191	.4572	.4572	.4572	.4572	.4191
13	.4001	.381	.4954	.4191	.4572	.4572	.4382
14	.4572	.4191	.4572	.4191	.3429	.4191	.4191
15	.4191	.4191	.4572	.4001	.3429	.4191	.4191
16	.4572	.4191	.4954	.4572	.4191	.4572	.4572
17	.4763	.4572	.5335	.4572	.4572	.4572	.5335
18	.5525	.4954	.4954	.5335	.4954	.5716	.5335
19	.5716	.6097	.6478	.6097	.5335	.6478	.6478
20	.6097	.6097	.5716	.5906	.5716	.5716	.6097
21	.5335	.5335	.5716	.5335	.5335	.5716	.5525
22	.4954	.4954	.5335	.4763	.4954	.4954	.4954
23	.4954	.4572	.4572	.4572	.4191	.4572	.4954
24	.4191	.4382	.4191	.4572	.4191	.4191	.4572
Max	.6097	.6097	.6478	.6097	.5716	.6478	.6478
Min	.4001	.381	.4191	.4001	.3429	.4191	.4191
Avg	.4747	.4707	.4922	.4850	.4517	.4763	.4969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 206 / Tarraco

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.8002	.8383	.6478	.724	.5716	.6859
2	.724	.8002	.8002	.6478	.724	.5716	.6859
3	.724	.7811	.8002	.6097	.743	.6097	.6859
4	.6859	.7811	.6859	.6097	.7049	.6097	.6859
5	.6859	.7811	.724	.6478	.724	.6097	.6859
6	.6859	.7811	.724	.6478	.724	.6478	.6859
7	.6859	.6859	.6478	.6859	.6859	.6097	.6859
8	.7621	1.0479	.9145	1.1431	.724	1.0288	1.0288
9	1.0288	1.1241	.9526	1.1431	.7621	1.1812	1.1431
10	1.2955	1.5242	1.0288	1.3336	.9145	1.2193	1.2193
11	1.5242	1.4861	1.0669	1.5623	.8764	1.448	1.2955
12	.9526	.9907	.6859	1.448	.6478	.9907	.9526
13	1.448	1.448	.9526	1.1812	.8002	1.2955	1.467
14	1.3336	1.2193	.8383	1.2955	.9145	1.1812	1.2955
15	1.448	1.1812	.8383	1.4098	.7621	1.1431	1.3908
16	1.5242	1.3717	.8383	1.2574	.6478	1.1431	1.2955
17	1.2003	1.2574	.9145	1.1431	.6097	1.1812	1.2193
18	1.1431	1.1431	.724	1.1622	.5335	1.1431	1.1431
19	.8383	.8764	.724	.9526	.6097	.9145	.9526
20	.8764	.8002	.6478	.8383	.4954	.8002	.8954
21	.8573	.8002	.6478	.724	.6097	.8002	.8192
22	.9145	.8383	.6478	.8573	.5716	.8383	.8002
23	.8002	.8002	.6478	.9145	.6097	.8002	.7621
24	.6859	.8383	.8002	.6478	.7621	.6097	.6859
Max	1.5242	1.5242	1.0669	1.5623	.9145	1.448	1.467
Min	.6859	.6859	.6478	.6097	.4954	.5716	.6859
Avg	.9812	1.0066	.7954	.9796	.7034	.9145	.9653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 207 / 11 KV Water Works Express NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.8002	.8002	.7621	.8002	.7811	.8383
2	.8573	.8192	.8192	.8383	.8002	.8573	.8764
3	.8764	.8192	.8383	.8573	.8954	.8764	.8573
4	.9145	.8954	.8954	.8383	.9335	.8764	.8764
5	.9145	.9145	.9335	.9145	.9335	.8573	.8764
6	.8764	.9717	.9526	.9526	.8764	.9335	.8573
7	.8764	1.0288	.9335	.9907	.8954	.9335	.8573
8	.8764	1.0098	.9717	1.0098	.8764	1.0098	1.0098
9	.9335	1.0098	.9145	.9907	.9145	.9907	.9335
10	.9335	.9907	.9145	.9717	.5525	1.0098	.9717
11	1.0288	1.0288	.9145	.9335	.5525	.9526	.9526
12	1.0098	1.0098	.9907	.9145	.7049	.9526	.8954
13	.9907	.9526	.9526	.9526	.9717	.9717	1.0479
14	.9717	.9145	.9717	.9907	.9526	.9907	1.0479
15	.9526	.9526	.9526	1.0098	.9526	.9907	.9907
16	.9526	.9335	.9335	.9907	.8764	1.0288	.9717
17	.9526	.9526	.8002	.9526	.9335	1.0098	.8573
18	.9145	.9145	.7811	.9907	.9145	.8002	.8383
19	.743	.8383	.6478	.8383	.9335	.5144	.8383
20	.724	.8192	.4191	.7811	.9145	.4954	.8002
21	.6668	.8002	.4191	.7811	.7811	.4954	.7621
22	.7811	.7811	.381	.7811	.7811	.4954	.7049
23	.9145	.8002	.7811	.7811	.9145	.7621	.6668
24	.7811	.8002	.8002	.7811	.7811	.7621	.7621
Max	1.0288	1.0288	.9907	1.0098	.9717	1.0288	1.0479
Min	.6668	.7811	.381	.7621	.5525	.4954	.6668
Avg	.8843	.9066	.8216	.9002	.8518	.8478	.8788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 202 / 11 KV NIPUN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.6385	1.6385	1.5242	1.5242	1.5623	1.5623
2	1.6194	1.6385	1.6385	1.5242	1.5623	1.5813	1.5242
3	1.6385	1.6385	1.6194	1.5623	1.5623	1.6004	1.5242
4	1.6575	1.6194	1.6004	1.5623	1.5813	1.6194	1.5623
5	1.6766	1.6766	1.6004	1.5813	1.6385	1.6194	1.5813
6	1.6956	1.7147	1.6385	1.6004	1.6385	1.6194	1.6956
7	1.7147	1.7718	1.6766	1.6385	1.6194	1.6194	1.6956
8	1.7528	1.829	1.6194	1.8099	1.6194	1.9052	1.848
9	1.848	2.1338	1.5242	1.9243	1.6766	2.1338	2.2481
10	1.8861	2.4768	1.6766	2.5339	1.8099	2.4768	2.2672
11	2.3815	2.4196	1.7147	2.7816	1.829	1.9243	2.4387
12	2.191	2.3624	1.5051	2.1719	1.7909	2.1529	2.4006
13	2.1338	2.2291	1.5813	2.2862	1.7337	2.0957	
14	2.3053	2.4387	1.6194	2.4577	1.829	2.2862	2.3053
15	2.4387	2.3434	1.5623	4.8583	1.9433	2.4768	2.3624
16	2.3624	2.4577	1.448	2.4196	1.6004	2.3815	2.3624
17	2.3815	2.4768	1.5813	2.3053	1.6385	2.2481	2.3434
18	2.21	2.3434	1.5432	2.1529	1.6766	2.1338	
19	1.8861	2.0386	1.5242	1.7528	1.6194	1.7909	1.7528
20	1.6956	1.7528	1.4861	1.7337	1.5623	1.6575	1.6194
21	1.6956	1.7337	1.5432	1.6004	1.5813	1.6575	1.7337
22	1.6956	1.7147	1.5051	1.6385	1.5242	1.6956	1.5813
23	1.6575	1.6956	1.4861	1.6004	1.5242	1.6766	1.6575
24	1.6004	1.6385	1.6575	1.5051	1.5623	1.5432	1.5813
Max	2.4387	2.4768	1.7147	4.8583	1.9433	2.4768	2.4387
Min	1.6004	1.6194	1.448	1.5051	1.5242	1.5432	1.5242
Avg	1.9052	1.9909	1.5829	2.0219	1.6520	1.8941	1.8931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 203 / 11 KV VIJAY CO-POLYMER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5813	1.5813	1.5242	1.3908	1.6194	1.3908	1.6194
2	1.5813	1.5242	1.5623	1.467	1.6194	1.4289	1.5623
3	1.6766	1.5623	1.5813	1.467	1.6004	1.4289	1.4861
4	1.6385	1.5051	1.5242	1.448	1.6004		1.5432
5	1.6004	1.5813	1.6385	1.4861	1.5623	1.467	1.5813
6	1.6385	1.6004	1.5432	1.5051	1.3336	1.5432	1.6194
7	1.7147	1.6956	1.6004	1.4289	1.6575	1.6004	1.6004
8	1.7718	1.7528	1.6385	1.6956	1.6766	1.6194	1.7337
9	2.3434	2.1529	1.6575	2.0957	1.7337	1.4289	2.0386
10	2.5149	2.3434	1.7909	2.2481	1.9052	2.3434	2.3243
11	2.6482	2.5149	1.8861	2.3243	1.848	2.553	2.6863
12	2.4958	2.4958	1.7147	2.3053	1.8099	2.5149	2.4577
13	2.0957	2.0957	1.7147	1.9814	1.7909	2.1529	1.467
14	2.5149	2.4958	1.8671	2.2672	1.9052	2.572	2.4577
15	2.5339	2.5911	1.7528	2.2862	1.848	2.5149	2.6101
16	2.6101	2.4577	1.7909	2.5149	1.8099	2.6292	2.7244
17	2.5339	2.4768	1.7147	2.3434	1.7337	2.6292	2.21
18	2.4006	2.3243	1.6385	2.2481	1.6575	2.6292	2.4387
19	2.0005	2.0957	1.6766	1.9624	1.6385	1.9243	2.1719
20	1.6956	1.7528	1.5813	1.848	1.5242	1.7147	1.8099
21	1.6575	1.6766	1.6004	1.6575	1.5242	1.6956	1.6385
22	1.0288	1.7147	1.4098	1.6956	1.467	1.6194	1.6385
23	1.5242	1.7147	1.3908	1.6194	1.448	1.5813	1.6194
24	1.5813	1.5623	1.5813	1.4289	1.5813	1.4289	1.6194
Max	2.6482	2.5911	1.8861	2.5149	1.9052	2.6292	2.7244
Min	1.0288	1.5051	1.3908	1.3908	1.3336	1.3908	1.467
Avg	1.9743	1.9695	1.6409	1.8631	1.6623	1.9309	1.9441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 204 / 11 KV GUPTA CONCOST

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9624	1.6766	1.9814	1.9052	2.0767	1.5242	2.0005
2	1.9624	1.6766	1.9433	2.0005	1.9624	1.5432	2.2862
3	1.9433	1.6956	2.0957	1.9433		1.5623	2.6673
4	1.9052	1.9052	2.21	1.9814	2.0576	1.5813	2.7625
5	2.2862	2.4768	2.3815	1.9433	2.0957	1.5623	2.8959
6	2.4768	2.21	2.2291	2.2862	1.9052	1.7147	2.6101
7	2.5339	1.8861	2.0386	2.3624	1.8671	2.1338	2.3624
8	2.1338	2.0005	1.848	1.829	1.5623	2.2862	2.0386
9	2.3624	2.6292	1.6766	2.1529	1.5051	3.4675	3.2769
10	2.2862	3.296	1.8671	2.4768	1.6575	3.5627	
11	3.3913	3.2769	1.7528	3.1817	2.0195	3.0674	3.7913
12	3.315	3.315	1.448	2.0767	2.0195	2.3624	3.7723
13	3.2769	2.934	1.6956	3.4294	2.0386	3.3913	
14	3.4865	3.5246	1.829	3.5056	2.572	3.3341	4.1152
15	3.6961	3.7723	1.7337	2.8959	2.8197	2.7435	3.658
16	2.8578	3.1817	1.467	3.0674	2.2672	2.7625	2.6101
17	2.8387	3.4294	1.5242	2.9912	1.9433	3.7913	3.0864
18	2.0576	2.4006	1.5813	1.848	***	2.21	2.0957
19	2.3815	2.1338	1.6575	2.8197	2.191	2.9912	3.315
20	1.6766	1.829	1.6575	1.7528	1.7147	1.7718	1.7337
21	2.4768	1.9433	1.5242	1.6385	1.7147	2.0195	1.7909
22	1.848	2.2291	1.5432	1.6766	1.5432	1.5623	1.9052
23	2.3053	2.5339	1.6766	1.6385	1.5242	2.915	2.8197
24	1.9814	1.6766	1.9814	1.9624	2.1529	1.5813	1.9814
Max	3.6961	3.7723	2.3815	3.5056	16.5752	3.7913	4.1152
Min	1.6766	1.6766	1.448	1.6385	1.5051	1.5242	1.7337
Avg	2.4768	2.4847	1.8060	2.3069	2.5994	2.3934	2.7080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 206 / 11 KV BIRLA ERICSION
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4861	1.448	1.3146	1.2384	1.3146	1.3146	
2	1.5623	1.3336	1.5242	1.2765	1.2955	1.3336	1.467
3	1.3717	1.3717	1.467	1.2574	1.2765	1.3146	1.3527
4	1.4861	1.2765	1.3336	1.2574	1.2384	1.4098	1.3717
5	1.5051	1.3717	1.2765	1.2193	1.2003	1.2765	1.4098
6	1.2955	1.4289	1.4289	1.2955	1.2384	1.4289	1.3336
7	1.5242	1.3527	1.6004	1.3336	1.3908	1.467	1.4098
8	1.829	2.1338	1.5623	1.829	1.2384	1.8861	1.8099
9	2.0576	2.0767	1.6004	2.0767	1.2384	1.7718	1.6956
10	2.191	2.21	1.9624	2.2672	1.2384	2.0576	2.0957
11	2.1529	2.4577	1.8861	2.21	1.3146	2.0576	2.3815
12	1.5813	1.7337	1.5432	1.848	1.3527	1.6004	2.0005
13	1.9243	2.0576	2.1338	1.829	1.2003	1.7337	2.0195
14	2.3624	2.1719	1.7147	2.1529	1.2003	2.0005	2.0386
15	2.4577	2.2291	1.9814	1.9814	1.2193	2.1148	2.1529
16	2.1148	2.0005	1.7337	1.9243	1.3527	2.0957	2.0957
17	2.0767	2.0576	1.829	1.6004	1.3336	1.7718	1.9052
18	2.0005	1.9243	1.6575	1.8099	1.2765	1.9624	1.6956
19	1.6194	1.448	1.3146	1.4098	1.2955	1.4861	1.467
20	1.7718	1.4861	1.3717	1.2955	1.4289	1.5051	1.6004
21	1.4861	1.5051	1.1241	1.448	1.3146	1.3908	1.4861
22	1.4861	1.2003	1.2193	1.3527	1.2955	1.467	1.2765
23	1.4098	1.4098	1.2384	1.2765	1.3908	1.4289	1.3717
24	1.3717	1.4289	1.3527	1.3717	1.3336	1.3146	1.3336
Max	2.4577	2.4577	2.1338	2.2672	1.4289	2.1148	2.3815
Min	1.2955	1.2003	1.1241	1.2193	1.2003	1.2765	1.2765
Avg	1.7552	1.7131	1.5488	1.6067	1.2908	1.6329	1.6857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 207 / 11 KV DIPER INDIA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	2.191	1.6956	1.1431	1.6956	1.848	1.829
2	1.9052	2.191	2.0767	1.1622	1.7718	2.0195	1.8671
3	2.1338	2.3243	2.0195	1.105	1.8099	2.21	1.9433
4	1.9243	1.7909	1.6385	1.1241	2.0005	1.9433	1.7337
5	1.9243	2.0957	1.9243	1.3908	2.1529	2.0005	1.8099
6	1.8671	1.7147	1.9624	1.3908	1.9052	1.7718	1.8099
7	1.7337	1.7147	1.4861	1.467	1.6766	1.7909	1.8099
8	2.1338	2.2672	1.5242	1.7909	2.6101	2.2291	2.1719
9	2.8959	2.8769	1.4861	2.3815	2.4196	2.7244	2.6482
10	2.6863	2.5149	1.5242	2.7054	2.934	2.7816	2.8578
11	2.8387	2.572	1.467	2.2481	3.0293	2.5911	2.553
12	2.7435	2.3815	1.5432	2.2291	2.4768	2.4387	2.6673
13	2.9912	2.7244	1.5432	2.3434	2.6863	2.553	2.8959
14	2.8578	2.5339	1.4861	2.7435	2.6863	2.7625	2.8197
15	3.2007	2.553	1.448	2.7435	3.0102	2.6863	2.934
16	3.3341	2.4006	1.3146	2.8006	2.8959	2.8578	3.1626
17	2.8197	1.7528	1.2574	2.4196	2.2481	2.4006	2.4577
18	2.5339	1.6575	1.2765	2.1148	2.2481	2.0767	2.4006
19	1.9243	1.6766	1.2384	2.1529	2.1148	2.1338	2.0767
20	1.9624	2.191	1.2003	2.0576	1.6575	1.9624	1.9433
21	2.0386	2.2291	1.1812	2.21	2.3053	2.3815	2.1529
22	1.9433	2.1148	1.1812	2.0957	1.829	1.9433	2.1529
23	2.2481	1.6385	1.2384	1.8671	1.9814	2.0195	2.0957
24	1.829	1.6766	1.6385	1.2574	1.6766	1.6956	1.6766
Max	3.3341	2.8769	2.0767	2.8006	3.0293	2.8578	3.1626
Min	1.7337	1.6385	1.1812	1.105	1.6575	1.6956	1.6766
Avg	2.3505	2.1577	1.5147	1.9560	2.2426	2.2426	2.2696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 208 / 11 KV ARIAN ORGO.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8671	1.7337	1.6575	1.448	1.5623	1.7718	1.6004
2	1.829	1.6766	1.467	1.5432	1.5623	1.5432	1.448
3	1.6956	1.6575	1.467	1.4861	1.5432	1.467	1.5242
4	1.5813	1.5813	1.3908	1.4861	1.5242	1.4861	1.448
5	1.6194	1.6004	1.467	1.4861	1.5432	1.5242	1.5051
6	1.448	1.5242	1.5051	1.467	1.6004	1.6385	1.467
7	1.7909	1.5051	1.5432	1.6194	1.5432	1.6004	1.7718
8	2.4387	2.2672	1.5623	1.9243	2.1338	2.0957	2.3624
9	2.572	2.21	1.5623	2.3815	2.1529	2.2291	2.3434
10	3.0293	2.191	1.6194	3.0483	2.7625	2.934	2.6673
11	2.6482	3.0864	1.2574	2.8578	2.7435	2.934	2.7816
12	2.0767	2.3434	1.467	2.4196	1.9814	2.7244	2.6101
13	2.7054	2.8578	1.4289	2.915	2.0576	3.1817	2.7244
14	2.8578	3.3341	1.4289	2.4577	2.3624	3.1436	2.5911
15	2.8387	2.6482	1.6194	3.2007	2.4006	3.1436	2.4768
16	2.7816	2.7435	1.467	2.4387	2.0957	2.5149	2.6863
17	2.8197	2.9912	1.6385	2.4006	2.3243	2.7435	2.6292
18	2.6482	2.2672	1.4098	2.3815	2.3053	3.0864	2.0957
19	1.848	1.9433	1.5051	1.9814	1.7337	2.0386	2.0386
20	1.7337	1.7909	1.467	1.7909	1.6004	1.7337	1.5813
21	1.7718	1.6194	1.4861	1.7528	1.6575	1.7718	1.7528
22	1.6385	1.6194	1.4289	1.6004	1.6575	1.829	1.5051
23	1.6956	1.6385	1.4861	1.9433	1.7337	1.6385	1.6004
24	1.6766	1.3336	1.6385	1.4289	1.5623	1.6004	1.5432
Max	3.0293	3.3341	1.6575	3.2007	2.7625	3.1817	2.7816
Min	1.448	1.3336	1.2574	1.4289	1.5242	1.467	1.448
Avg	2.1505	2.0902	1.4988	2.0608	1.9227	2.1823	2.0314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 211 / 11 KV RESIDENTAIL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.191	2.0195	2.191	1.9052	2.0386	1.8484	2.0748
2	2.191	2.0195	2.0767	1.7147	2.0576	1.8296	2.0748
3	2.1719	2.0195	2.0195	1.7909	1.9624	1.8107	1.8861
4	2.1529	2.0195	1.9624	1.7147	1.9052	1.7918	1.8861
5	2.2862	2.1148	1.9433	1.829	2.0195	2.037	1.9616
6	2.3815	2.7244	2.2291	2.2862	1.9052	2.1948	2.3954
7	2.6101	2.8006	2.4577	2.4006	1.9052	2.6406	2.5086
8	2.6863	2.4387	2.4387	2.4768	2.3815	2.3011	2.3765
9	2.2672	2.2672	2.4006	2.0957	2.572	1.9993	1.9993
10	1.9052	1.9624	2.4006	1.8861	2.191	1.9805	1.8861
11	1.8671	1.9052	2.0767	1.8099		2.0748	1.9791
12	1.829	2.0005	2.1148	1.7909	2.0195	1.8296	1.9605
13	1.8671	2.0195	2.1338	1.7718	1.9243	2.0748	
14	1.8861	1.9814	2.0386	1.8099	1.9052	1.9993	1.8858
15	1.9243	2.0005	2.0195	1.7718	1.8861	1.9805	1.9805
16	1.9433	1.9624	2.1148	1.8099	2.0005	1.9993	2.037
17	1.9433		2.191	1.7147	2.191	2.1125	1.9791
18	2.3053		2.0576	2.0957	2.191	1.9959	2.1794
19	2.915		2.6292	2.6673	2.6292	2.6981	2.9014
20	2.9531		2.6673	2.7816	3.0674	2.7726	2.894
21	2.7435		2.6673	2.7816	2.6863	2.7161	2.8006
22	2.7435		2.4958	2.6292	1.9052	2.4646	2.8104
23	2.2862		2.2291	2.5911	2.0576	2.2032	2.2592
24	2.191	2.0195	2.2291	1.9624	2.191	2.2445	2.0936
Max	2.9531	2.8006	2.6673	2.7816	3.0674	2.7726	2.9014
Min	1.829	1.9052	1.9433	1.7147	1.8861	1.7918	1.8858
Avg	2.2600	2.1338	2.2410	2.0870	2.1562	2.1500	2.2091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 404 / Cosmo Films OLD

Feeder KV- 33 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.2291	2.1719	1.7718	2.6292	2.5149	2.6863
2	2.915	2.4577	2.8578	1.829	2.572	3.3722	2.5149
3	2.7435	3.7151	3.5437	1.829	2.572	1.6004	2.9721
4	2.572	2.7435	2.572	1.7147	2.5149	2.8578	2.6863
5	1.7718	2.7435	1.8861	1.7147	2.5149	2.3434	2.8006
6	2.6292	2.8006	1.8861	2.0005	2.4006	1.7147	2.2291
7	2.0576	2.2291	1.6004	1.8861	2.8006	2.915	1.4861
8	2.9721	3.2579	2.0005	2.2862	2.8006	2.2862	2.6863
9	3.1436	3.7151	1.9433	2.3434	1.8861	2.572	2.8006
10	3.2007	3.2579	2.1148	3.2579	2.8006	1.7147	2.9721
11	3.315	3.315	2.0005	2.4006	3.4865	2.2862	3.2007
12	2.6292	3.315	2.2291	3.315	3.4865	3.9438	3.0293
13	2.6863	3.4865	2.2862	2.572	3.315	3.2007	2.0576
14	3.4294	3.4865	2.0005	3.0293	2.7435	3.2007	2.0576
15	2.572	3.8866	2.0576	3.0864	1.8861	3.9438	2.1148
16	2.7435	2.5149	2.0005	3.2579	1.9433	2.572	2.1148
17	2.5149	3.2007	2.0576	2.572	3.315	2.4577	2.1148
18	2.4006	2.9721	1.8861	2.915	2.572	2.1148	1.8861
19	2.2291	3.2579	1.7147	2.1719	1.7718	1.8861	1.7718
20	3.6008	3.315	1.7718	2.2291	1.7718	2.0005	2.4006
21	3.8866	3.0293	1.7718	2.1148	1.7147	3.0864	2.4577
22	2.5149	2.915	1.7718	2.3434	1.6575	2.1719	2.4006
23	2.0576	2.915	1.829	3.4294	3.2007	3.2579	2.4006
24	2.8578	2.9721	2.7435	1.829	2.6292	1.8861	2.6292
Max	3.8866	3.8866	3.5437	3.4294	3.4865	3.9438	3.2007
Min	1.7718	2.2291	1.6004	1.7147	1.6575	1.6004	1.4861
Avg	2.7387	3.0721	2.1124	2.4125	2.5410	2.5792	2.4363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 406 / E SECTOR FEEDER

Feeder KV- 33 / INCOMING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	28-FEB-17
HR	Load (MW)
24	4.8583
Max	4.8583
Min	4.8583
Avg	4.8583

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 407 / NEW COSMO EXPRESSES FEEDER NON SHEDDABLE EHV INDUSTRIAL FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.6873	6.8587	6.9159	6.5729	5.144	6.5729	6.973
2	6.6301	6.8016	7.0873	***	5.2584	6.6873	6.9159
3	6.5729	6.4586	6.7444	6.8587	5.3727	6.6301	6.6873
4	6.8587	6.973	7.0873	6.8016	6.0014	6.7444	6.4586
5	6.7444	6.6873	6.9159	6.6873	7.3731	6.8016	6.6301
6	6.8587	6.8587	***	6.8587	7.0302	6.8587	6.9159
7	6.8587	7.1445	6.973	6.6873	7.2588	6.6301	6.8587
8	5.8871	7.2017	7.3731	6.8587	7.1445	7.1445	6.973
9	5.9442	7.3731	7.2017	7.0302	7.316	6.6873	7.0873
10	5.8299	7.2017	6.5158	7.0302	7.2588	7.2588	7.2017
11	6.5729	6.6873	6.6873	7.2588	7.1445	6.973	6.973
12	6.6301	6.973	7.316	7.2017	7.0302	7.0302	7.2017
13	6.5729	7.0873	7.1445	6.3443	6.8587	7.0302	7.2588
14	6.973	7.0873	7.4303	6.7444	7.2588	6.9159	6.9159
15	7.0302	7.3731	7.1445	7.2588	7.2017	7.1445	6.8016
16	7.2017	7.0302	7.2588	7.2588	7.2017	7.4303	7.1445
17	6.5158	7.2017	6.4586	6.8587	7.2017	7.0873	7.4303
18	6.5158	6.8016	6.973	6.4586	7.2588	6.6873	.8002
19	7.0302	7.0873	7.0873	7.1445	7.2588	6.973	7.0302
20	7.1445	7.0873	6.8587	6.973	7.2017	6.6873	6.8587
21	7.0302	6.8587	7.0302	6.0585	7.2017	6.5158	6.7444
22	6.8587	6.8587	6.7444	4.5153	6.8587	6.6301	6.5729
23	6.8587	7.0302	6.2872	4.5153	6.8587	6.7444	6.5158
24	6.2872	6.9159	6.7444	6.1157	4.6296	6.8016	6.3443
Max	7.2017	7.3731	36.8656	44.4674	7.3731	7.4303	7.4303
Min	5.8299	6.4586	6.2872	4.5153	4.6296	6.5158	.8002
Avg	6.6706	6.9849	8.2019	8.1900	6.7635	6.8611	6.6372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 408 / 33 KV D Sector

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	28-FEB-17
HR	Load (MW)
24	5.6013
Max	5.6013
Min	5.6013
Avg	5.6013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 409 / Bkt

Feeder KV- 33 / INCOMING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.9721	2.2862	1.7147	2.2862	2.5149	2.6292
2	1.9433	2.9721	1.7147	1.7147	2.5149	2.4006	2.5149
3	1.829		1.7147	1.9433	2.0576	2.2862	2.2862
4	1.829	2.8578	1.7147	2.1719	2.4006	2.1719	2.1719
5	1.7147	2.8578	1.7147	2.2862	2.5149	2.0576	1.829
6	1.7147	2.4006	1.7147	2.0576	2.7435	1.9433	2.5149
7	1.7147	2.6292	1.6004	1.9433	2.8578	1.9433	1.7147
8	3.315	2.7435	1.6004	3.658	2.9721	2.7435	3.5437
9	3.2007	2.9721	1.7147	3.2007	2.5149	2.8578	2.9721
10	2.7435	2.9721	1.6004	3.658	3.4294	3.2007	3.4294
11	2.7435	2.9721	1.6004	2.9721	3.7723	2.8578	3.0864
12	2.6292	3.0864	1.7147	2.7435	2.8578	2.5149	2.9721
13	3.4294	2.9721	1.4861	2.5149	2.9721	3.2007	2.7435
14	2.7435	2.5149	1.829	2.5149	2.2862	3.4294	2.7435
15	2.0576	1.7147	1.4861	2.0576	2.2862	2.7435	2.6292
16	3.315	2.9721	1.3717	2.0576	1.829	2.2862	2.8578
17	3.315	2.0576	1.3717	1.9433	2.8578	3.0864	2.5149
18	1.6004	1.829	1.0288	2.5149	2.4006	2.0576	2.2862
19	2.6292	2.0576	1.6004	2.5149	2.5149	2.5149	2.1719
20	1.829	2.2862	1.1431	2.9721	2.9721	2.6292	1.829
21	2.2862	2.1719	2.1719	2.1719	1.9433	2.3434	2.2862
22	2.4006	2.0576	1.1431	2.8578	1.7147	2.6292	2.1719
23	2.2862	1.9433	1.4861	2.5149	1.829	1.7147	1.9433
24	2.0576	2.9721	2.2862	1.829	2.4006	2.5149	2.6292
Max	3.4294	3.0864	2.2862	3.658	3.7723	3.4294	3.5437
Min	1.6004	1.7147	1.0288	1.7147	1.7147	1.7147	1.7147
Avg	2.3910	2.5646	1.6290	2.4387	2.5387	2.5268	2.5196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 410 / NEW ENDURANCE (B-2) EXP. NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.3717	1.2003	1.3717	1.1431		.5144
2	1.1431	1.3717	1.2003	1.2574	1.1431		.5716
3	1.1431	1.3717	1.2574	1.2574	1.2003		.5716
4	1.0288	1.2574	1.2574	1.3146	1.2574		.6859
5	1.0288	1.3146	1.3717	1.3146	1.2574		.6859
6	.9145	1.3717	.9145	5.6013	1.1431		.6859
7	.9145	1.1431	1.2003	.9145	1.1431		.6859
8	1.4861	1.1431	1.1431	1.3717			1.3717
9	1.1431	1.3717	1.3146	1.3146			1.3717
10	1.1431	1.1431	1.2574	1.2003			1.4289
11	1.2574	1.1431	1.2003	1.3717			1.4289
12	1.2003	1.1431	1.2003	1.5432			1.3717
13	1.3146	1.2574	1.4289	1.3717			1.3717
14	1.2574	1.1431	1.2003	1.2574			1.4289
15	1.2574	1.1431	1.2574	1.3717			1.3717
16	1.2574	1.1431	1.3717	1.3146			1.5432
17	1.2574	.6287	1.3146	1.2574			1.3146
18	1.4289	1.2574	1.2574	1.2003		25.4344	1.3717
19	1.3146	1.2574	1.3717	1.2003			1.5432
20	1.2574	1.3146	1.1431	1.3146			1.2574
21	1.4289	1.2574	1.4861	1.2574			1.5432
22	1.2003	1.2003	1.3146	1.3146		.4572	1.2574
23	1.2003	1.1431	1.4289	1.2574		.5144	1.1431
24	1.2003	1.3717	1.2003	1.3717	1.2574		.5144
Max	1.4861	1.3717	1.4861	5.6013	1.2574	25.4344	1.5432
Min	.9145	.6287	.9145	.9145	1.1431	.4572	.5144
Avg	1.2050	1.2193	1.2622	1.4718	1.1931	8.802	1.1264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 401 / 33 KV TAYO LUCID

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.2872	5.7728	5.7156	3.8866	5.7156	5.6584	6.6301
2	5.6013	5.6584	5.487	3.7151	5.6584	5.6584	6.6873
3	5.6584	5.7156	5.3727	3.7151	5.6013	5.6013	6.4015
4	5.7156	5.7156	5.2584	3.658	5.4298	5.6013	6.5158
5	5.7156	5.6013	5.6013	3.7151	5.2012	6.0014	6.4586
6	5.0297	5.7156		3.7723	5.3155	6.1728	10.5739
7	5.7156	5.8871	4.5153	4.2295	5.2012	5.487	6.3443
8	6.9159	7.2017	5.144	6.0014	5.7156	7.0302	6.9159
9	6.973	7.4303	5.487	6.3443	6.3443	7.7732	7.8875
10	7.6589	7.8304		6.8016	7.0302	7.8875	7.6589
11	7.5446	7.2017	4.5725	7.3731	6.9159	7.9447	8.2305
12	6.9159	7.316	2.2862	7.2588	7.1445	8.2305	7.7161
13	7.2588	7.2017	4.401	7.3731	6.8587	7.4874	7.6589
14	7.4874	7.3731	5.7728	7.8304	7.2017	8.1162	7.8875
15	7.4874	7.4874	5.487	7.6589	6.973	7.6017	8.2305
16	7.6017	6.973	5.3727	7.4303	6.973	8.2305	7.6017
17	6.4586	7.3731	5.0297	7.0873	7.0873	9.0306	8.0018
18	6.9159		4.6868	7.1445	6.5158	8.1162	7.0302
19	6.9159		4.4582	6.4586	6.2872	7.4874	6.8016
20	6.7444	6.2872	4.1724	6.2872	6.23	7.2017	6.4586
21	6.7444	6.4015	4.0581	6.0014	5.7156	7.3731	6.0014
22	6.4586	5.8299	4.1724	6.1157	5.7156	6.8587	6.23
23	6.9159	6.0014	4.4582	5.9442	6.0585	6.9159	
24	7.6017	6.2872	5.4298	7.3731	6.0585	5.6013	6.7444
Max	7.6589	7.8304	5.7728	7.8304	7.2017	9.0306	10.5739
Min	5.0297	5.6013	2.2862	3.658	5.2012	5.487	6.0014
Avg	6.6801	6.5574	4.8609	5.9657	6.2062	7.0445	7.2464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 402 / 33 KV SIEMENCE

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7723	5.2584	4.6296	9.0878	4.7439	3.6008	4.3439
2	4.5725	4.8011	4.6868	4.2295	4.5725	3.5437	4.2867
3	4.4582	4.8011		3.8866	4.5153	3.4294	4.1724
4	4.2867	4.6868	4.6868	3.4294	4.4582	3.2579	4.2295
5	3.8295	4.5153	4.8583	3.6008	4.401	4.1724	4.2295
6	4.0009	4.8583	4.4582	3.658	3.9438	3.0864	3.7723
7	3.8866	4.1152	3.3722	3.6008	3.2579	4.0581	4.0581
8	6.3443	5.0869	4.0581	4.7439	4.0581	5.0297	4.401
9	5.6584	5.7156	4.1724	5.144	4.4582	6.1728	5.0297
10		5.6013	4.401	5.5441	4.8583	6.4015	5.6013
11		5.7728	4.1152	5.144	5.144	6.0585	4.8583
12		5.4298	4.401	6.0014	4.8011	5.8299	5.3727
13		5.6013	4.3439	5.7728	4.7439	5.144	5.2584
14		6.4015	4.6296	5.2584	4.5153	6.4015	5.4298
15		6.2872	4.4582	5.8871	4.8011	5.144	4.6296
16	6.7444	6.0014	4.6868	5.9442	4.4582	5.8299	5.4298
17	6.4586	6.0585	4.2867	6.0585	4.5725	6.4586	5.5441
18	6.0014		4.2295	8.802	4.1152	6.1728	5.3727
19	5.144		4.1152	6.1157	4.0581	5.8871	4.5725
20	4.8583	4.6296	4.0581	5.9442	4.3439	5.487	4.3439
21	5.2012	5.0297	4.1152	5.487	4.2867	4.9154	4.9726
22	5.3727	4.8011	4.9726	5.0297	4.0009	5.144	4.1724
23	4.6868	4.7439	4.3439	4.8011	4.1152	9.145	
24	5.144	5.3155	4.401	4.4582	4.4582	3.2579	4.6868
Max	6.7444	6.4015	4.9726	9.0878	5.144	9.145	5.6013
Min	3.7723	4.1152	3.3722	3.4294	3.2579	3.0864	3.7723
Avg	5.0234	5.2506	4.3687	5.3179	4.4034	5.1512	4.7290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 403 / 33 KV STARLITE CKT NO I NON SHEDDABLE EHV INDUSTRIAL FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.4591	8.6306	8.6877		8.9163	9.2021	9.4307
2	8.6877	8.4591	8.6877	8.9735	8.802	9.0306	9.2021
3	8.6877	8.4019	8.6306	8.9163	8.6877	8.6306	9.3164
4	8.6877	8.5734	8.7449	8.802	8.6306	8.6306	9.2593
5	8.802	8.8592	8.7449	8.6877	8.4591	9.145	9.145
6	8.5162	8.9163		8.4591	8.4019	9.145	9.2593
7	8.7449	9.145	8.7449	8.5734	8.7449	8.9735	9.145
8	8.6877	9.145	9.3164	9.0878	8.7449	9.7737	9.7737
9	9.2021	8.7449	9.145	9.3736	8.7449	9.7165	9.5451
10	9.2593	9.145		8.9735	8.6306	9.6022	9.8308
11	9.4307	9.7165		9.4307	9.3736	10.0023	10.0023
12	8.9735	9.5451		9.4307	9.5451	9.6022	9.9451
13	8.8592	9.3736		9.2021	9.2593	10.1166	9.3164
14	4.9726	9.3736		8.9735	9.2593	10.1738	9.9451
15	9.8308	9.2021	8.8592	9.2593	9.2593	10.2881	9.888
16	9.3164	9.2021	9.4307	9.2021	9.9451	10.0595	9.5451
17	9.3164	9.0878	8.9735	9.6022	9.4307	10.0023	9.2593
18	9.0878		8.7449		9.4307	9.7165	8.7449
19	8.9163		9.0878	9.2593	8.6306	9.6022	8.7449
20	8.7449	9.0306	8.7449	8.9735	8.9163	.1143	8.8592
21	8.5734	9.3736	8.6877	8.8592	8.7449	8.5734	8.8592
22	8.3448	8.9163	8.5162	8.9735	8.9735	9.3736	8.7449
23	8.3448	8.9163	8.4591	9.0878	8.7449	.1143	8.4591
24	9.3164	8.6877	8.9735	8.9163	9.145	9.2021	8.6306
Max	9.8308	9.7165	9.4307	9.6022	9.9451	10.2881	10.0023
Min	4.9726	8.4019	8.4591	8.4591	8.4019	.1143	8.4591
Avg	8.7401	9.0203	8.8433	9.0462	8.9759	8.6996	9.2855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 404 / 33 KV STARLITE CKT NO II NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7435	2.572	2.4006	2.572	2.572	2.2862	2.2862
2	2.6863	2.572	2.2862	2.572	2.5149	2.3434	2.2862
3	2.7435	2.572	2.3434	2.572	2.4577	2.4006	2.2862
4	2.7435	2.5149	2.3434	2.572	2.4577	2.5149	2.2862
5	2.7435	2.5149	2.0005	2.572	2.4577	2.3434	2.2862
6	2.7435	2.572		2.8006	2.4577	2.3434	2.2862
7	2.915	2.572	2.6292	2.7435	2.6292	2.3434	2.2862
8	2.915	2.6292	2.6863	2.915	2.6863	2.3434	2.3434
9	2.8578	2.572	2.5149	2.8006	2.572	2.3434	2.2862
10	2.8578	2.572	2.5149	2.572	2.2862	2.4006	2.4006
11	2.8006	2.5149		2.5149	2.3434	2.5149	2.4577
12	2.8578	2.5149		2.6863	2.2862	2.2862	2.4577
13	2.572	2.4577		2.572	2.3434	2.5149	2.2862
14	2.6863	2.6292		2.5149	2.3434	2.4577	2.3434
15	2.6863	2.6292	1.086	2.572	2.3434	2.4577	2.4006
16	2.4577	2.572	2.5149	2.572	2.4006	2.5149	2.3434
17	2.5149	2.572	2.4577	2.572	2.4006	2.4577	2.4006
18	2.5149		2.4006	2.5149	2.2862	2.4006	2.4006
19	2.5149		2.4577	2.4577	2.2862	2.3434	2.4006
20	2.572	2.4577	2.4577	2.5149	2.2291	2.0576	2.3434
21	2.4577	2.4577	2.4006	2.4577	2.2862	2.2291	2.2862
22	2.4577	2.4577	2.4006		2.2862	2.2291	2.3434
23	2.4577	2.3434	2.572	2.4577	2.2291	2.2291	2.3434
24	2.7435	2.5149	2.4006	2.4577	2.6292	2.3434	2.2862
Max	2.915	2.6292	2.6863	2.915	2.6863	2.5149	2.4577
Min	2.4577	2.3434	1.086	2.4577	2.2291	2.0576	2.2862
Avg	2.6768	2.5357	2.3615	2.5894	2.4077	2.3625	2.3386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 408 / 33 KV WOCKHARDT BIO EXP NON SHEDDABLE EHV INDUSTRIAL FEEDERS
 Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.9154	4.7439	4.8011	4.3439	4.401	4.401	4.401
2	4.5725	4.6296		4.401	4.4582	4.401	4.4582
3	4.5153	4.5725	4.8011	4.5153	4.4582	4.401	4.5725
4	4.5153	4.5153	4.7439	4.5725	4.4582	4.401	4.5153
5	4.9154	4.7439	4.3439	4.7439	4.5153	4.4582	4.5725
6	4.9154	4.4582		4.8011	4.2867	4.6296	4.2867
7	5.144	5.0869	4.6868	3.9438	4.4582	4.6296	4.7439
8	5.144	4.9154	4.8011	4.8583	4.8011	4.8583	4.8011
9	5.2584	4.9154		4.9154	4.5725	4.9154	5.144
10	5.3155	4.9154	4.6868	4.9726	4.5725		5.0297
11		5.5441	4.9154	4.9154	4.9726	5.3727	5.487
12		5.2012	4.401	5.3727	4.9154	5.2584	5.3155
13		5.2584	5.0297	5.2584	4.8011	5.3727	5.144
14	5.2584	5.2584	5.144	5.0869	4.6296	5.3155	5.3727
15	1.6575	5.3727	5.0297	5.0297	4.9154	5.3155	5.2584
16	5.2584	5.4298	4.8011	4.2867	4.7439	5.487	5.0869
17	5.2012	5.3727	5.0297	4.6868	4.8583	5.3727	5.0869
18	5.3155		4.6296	4.4582	4.5725	5.144	5.144
19	5.2012		4.401	4.401	4.401	4.8011	4.7439
20	5.0297	4.8583	4.401	4.4582	4.7439	4.6868	4.401
21	4.9154	4.9154	4.5725	4.4582	4.3439	4.6868	4.8011
22	4.8583	4.7439	4.4582	4.8583	4.4582	4.4582	4.2867
23	4.8011	4.6296	4.4582	4.7439	4.6868	4.4582	4.4582
24	5.0297	4.9154	4.6296	4.4582	4.5725	4.5725	4.4582
Max	5.3155	5.5441	5.144	5.3727	4.9726	5.487	5.487
Min	1.6575	4.4582	4.3439	3.9438	4.2867	4.401	4.2867
Avg	4.8446	4.9544	4.7031	4.6892	4.6082	4.8434	4.8154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 409 / 33KV M-SECTOR EXP FEEDER

Feeder KV- 33 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.23	5.8299	5.6013	4.2867	5.7728	4.7439	5.6013
2	5.7156	5.5441	5.5441	4.2295	5.4298	4.5725	5.6013
3	5.6584	5.3727	5.487	4.1152	5.3155	4.5153	5.5441
4	5.6584	5.3155	5.487	4.0581	5.3155	4.4582	5.3727
5	5.6584	5.6584	5.6584	4.2295	5.487	4.6296	5.4298
6	5.6584	5.6013		4.0581	5.2584	4.9154	5.487
7	4.6296	5.144	4.6868	3.9438	4.7439	4.9726	6.0585
8	6.8587	6.9159	4.8583	6.1157	5.7156		
9	7.7161	7.316	4.9726	6.8587	5.7156		
10	7.7161	7.7732	5.0297	7.2588	6.4015		
11	8.2876	8.2305	4.9726	8.1733	6.4015		
12	7.6017	7.8875	4.1724	7.6017	6.0585		
13	7.4303	7.316	4.5153	7.2588	5.3727		
14	8.2876	8.6306	4.8011	8.1733	6.1728		
15	8.4019	8.1733	4.5725		6.6301		
16		8.4591	4.8011	8.059	6.6873	8.4591	8.5734
17		8.2876	4.7439	8.0018	6.5729	8.2305	8.8592
18			4.1724	7.5446	6.0014	7.4874	7.8304
19			4.0581	6.2872	5.0869	6.8587	6.0585
20		6.0014	4.0009	6.4586	4.6296	5.3727	6.1157
21		5.6013	2.572	5.6013	4.9154	5.3727	7.0302
22		5.5441	4.2867	5.6584	4.8011	5.6013	5.7728
23		6.0014	4.2867	5.7156	4.9726	5.7728	4.4582
24	5.7728	5.487	6.0014	4.2295	5.7728	4.8583	5.8299
Max	8.4019	8.6306	6.0014	8.1733	6.6873	8.4591	8.8592
Min	4.6296	5.144	2.572	3.9438	4.6296	4.4582	4.4582
Avg	6.7051	6.6405	4.7514	5.9964	5.6346	5.6763	6.2264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 410 / 33 KV E + H EXP.

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.1143	.0572	.0572	.0572	.0572
2		.0572		.0572	.0572	.0572	.0572
3	.0572			.0572		.0572	.0572
4	.0572	.0572	.0572	.0572	.0572	.0572	.0572
5	.0572	.0572	.0572	.0572	.0572	.0572	.0572
6	.0572	.0572		.0572	.0572	.0572	.0572
7	.0572	.1143	.0572	.0572	.0572	.1143	.1715
8	.1143	.1143	.1143	.0572	.0572	.1143	.1715
9	.2286	.4572	.2858	.0572	.0572	.4572	.4001
10	.1715	.4001		.0572	.0572	.6287	.4001
11	.1715	.4001	.2286	.0572	.0572	.4572	.4572
12	.2286	.4572		.0572	.0572	.5144	.4572
13	.1715	.3429		.0572	.0572	.5144	.6287
14	.2286	.4001	.3429	.0572	.0572	.4572	.5144
15	.4572	.4001	.4572	.0572	.0572	.5716	.5144
16	.4572	.4001	.4572	.0572	.0572	.4572	.4572
17	.2286	.4001	.4001	.0572	.0572	.5144	.4001
18	.2286		.2858	.0572	.0572	.2286	.1143
19	.1715		.1143	.0572	.0572	.1143	.1143
20	.1143	.0572	.1143	.0572	.0572		.1143
21	.0572	.0572	.0572	.0572	.0572	.1143	.1143
22	.0572	.0572	.0572	.0572	.0572	.0572	.1143
23	.0572	.0572	.0572	.0572	.0572		.1143
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	.4572	.4572	.4572	.0572	.0572	.6287	.6287
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.1541	.2123	.1842	.0572	.0572	.2598	.2358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 412 / 33 KV Orchid Feeder

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2007	3.2007	2.915	3.2007	3.4294	3.2007	3.4294
2		2.8578		3.0864	2.915	3.2007	3.3722
3	2.9721	2.915	2.9721	2.9721	2.8578	3.2007	3.315
4	2.915	2.9721	2.9721	2.9721	2.8578	3.2007	3.3722
5	2.9721	3.2007	3.2007	3.0864	3.1436	3.2007	3.315
6	3.1436	2.9721		2.9721	3.0293	3.2007	3.2007
7	2.8006	2.915	3.1436	2.9721	3.0293	2.9721	3.0864
8	3.0293	3.2007	3.315	3.2007	3.2007	2.9721	2.9721
9	3.315	3.0864	3.2007	2.9721	3.315	3.315	2.9721
10	3.315	3.5437	2.9721	3.2007	3.315	3.4294	3.0864
11	3.4294	3.315	3.0864	3.315	3.315	3.5437	3.0864
12	3.315	3.5437		3.315	3.4294	3.0864	3.4294
13	3.2007	3.4294	3.2007	3.5437	3.315	3.4294	3.4294
14	3.4294	3.658	3.2007	3.5437	3.5437	3.0864	3.5437
15	3.658	3.315	3.2007	3.4294	3.4294	3.4294	3.5437
16	3.4294	3.4865	3.315	3.315	4.2295	3.5437	3.7723
17	3.4294	3.315	3.0864	3.1436	4.0009	3.658	3.7151
18	3.4294		3.2007	3.315	3.4294	3.7723	3.4294
19	3.4294		3.2007	3.4294	3.315	3.8866	3.7151
20	3.4294	3.1436	3.0864	1.2574	3.4294	3.658	3.4294
21	3.0864	3.1436	3.0864	2.8578	3.315	3.658	
22	2.8578	2.8578	2.9721	3.2007	3.315	3.5437	3.3722
23	2.9721	3.1436	3.2007	3.0864	3.2007	3.2007	3.315
24	3.315	3.1436	3.4294	3.0864	3.2007	3.315	3.5437
Max	3.658	3.658	3.4294	3.5437	4.2295	3.8866	3.7723
Min	2.8006	2.8578	2.915	1.2574	2.8578	2.9721	2.9721
Avg	3.2206	3.1981	3.1408	3.1031	3.3150	3.3627	3.3672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 201 / 11KV SUBHASHRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.7621	.7621	.724	.8002	.7621
2		.7621	.7621	.7621	.724	.7621	.7621
3	.7621	.7621	.7621	.7621	.724	.7621	.724
4	.7621	.7621	.7621	.7621	.724	.7621	.724
5	.9526	.9526	.8764	.8573	.8002	.8002	.8573
6	1.5242	1.1431	.9526	1.0479	.8383	1.105	1.1431
7	1.3717	1.3336	1.2955	1.2384	1.105	1.3717	1.2384
8		1.2384	1.3336	1.2955	1.2574	1.3717	1.3336
9	1.1431	1.0288	1.1431	1.1812	1.2193	1.0669	1.1431
10	.9907	1.0288	1.1431	.9907	1.0669	.9145	1.0288
11	.8764	.8764	.9526	.8764	.9907	.8764	.8764
12	1.1812	.8002	.9526	.8002	.9526	.8002	.7621
13	.7621	.7621	.8573	.7621	.9145	.8002	.8002
14	.8002	.7621	.7621	.724	.8002	.7621	
15	1.0669	.7621	.7621	.724	.7621	.8002	.7621
16	.7621	.724	.8002	.7621	.7621	.8764	.724
17	.9526	.7621	.9526	.7621	.7621	.8764	.8383
18	.9526	.9145	1.1431	.8383	.8764	1.1431	.9145
19	1.1431	1.2193	1.1431	1.105	1.0669	1.3336	1.2193
20	1.2384	1.2574	1.3336	1.1431	1.1812	1.3336	1.2193
21		1.1812	1.1431	1.105	1.105	1.3336	1.1812
22		1.105	1.0669	1.0288	1.0288	1.0669	1.105
23		.9526	.9145	.8764	.9526	.9526	.9526
24	.8002	.8573	.8764	.8002	.8383	.8383	.8573
Max	1.5242	1.3336	1.3336	1.2955	1.2574	1.3717	1.3336
Min	.7621	.724	.7621	.724	.724	.7621	.724
Avg	.9897	.9463	.9772	.9153	.9240	.9796	.9534

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 202 / 11KV N5 CIDCO FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	.9526	.9526	.9526	.9145	1.0288	.9907
2		.9526	.9526	.9526	.9145	.9526	.9907
3	1.0479	.9526	.9526	.9526	.9145	.9526	.9907
4	1.0288	.9526	.9526	.9526	.9145	.9526	.9907
5	1.3336	1.2384	1.0669	1.3336	1.0288	1.0288	1.2384
6	1.5242	1.5242	1.2574	1.5242	1.448	1.2574	1.5242
7	1.7528	1.5242	1.4098	1.6194	1.6385	1.4098	1.7147
8	1.7147	1.6194	1.6766	1.5623	1.5623	1.5623	1.7147
9	1.5242	1.3336	1.6766	1.7528	1.4861	1.6766	1.7147
10	1.2955	1.3336	1.6194	1.5242	1.5623	1.3336	1.5242
11	1.4098	1.4289	1.5242	1.3336	1.448	1.3336	1.3336
12		1.1812	1.4289	1.2574	1.3336	1.2574	1.1812
13	1.105	1.0669	1.2384	1.1431	1.2193	1.1431	1.0288
14	1.0669	1.1431	1.1812	1.0288	1.2193	.9907	.9907
15		1.1812	1.1812	.9907	1.105	.9907	1.0669
16	1.0669	1.1431	1.1431	.9145	1.1812	1.0288	1.0669
17	1.1431	1.2955	1.3336	1.0669	1.1812	1.1812	1.0669
18	1.3336	1.4098	1.6194	1.105	1.2955	1.3336	1.3717
19	1.6194	1.6766	1.6194	1.5242	1.6766	1.7147	1.6766
20	1.6194	1.7147	1.6194	1.5623	1.5623	1.7528	1.7528
21		1.5623	1.5242	1.4861	1.448	1.6004	1.6004
22		1.4098	1.3717	1.3336	1.3336	1.3336	1.448
23		1.2193	1.2193	1.1431	1.1812	1.2384	1.2193
24	1.105	1.1431	1.105	1.0479	1.0288	1.0669	1.0479
Max	1.7528	1.7147	1.6766	1.7528	1.6766	1.7528	1.7528
Min	1.0288	.9526	.9526	.9145	.9145	.9526	.9907
Avg	1.3188	1.2900	1.3178	1.2527	1.2749	1.2550	1.3019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 203 / 11KV RAM MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4763	.4763	.5716	.5716	.5716	.5716
2	.4763	.4763	.4763	.5716	.5716	.5716	.5716
3	.4763	.4763	.4763	.5716	.5716	.5716	.5716
4	.4763	.4763	.4954	.5716	.5716	.5716	.5716
5	.6668	.6668	.6287	.6668	.6097	.6287	.7621
6	.7621	.7621	.6287	.7621	.6478	.743	.8573
7	.8573	.8573	.8002	.7621	.6478	.8764	.8573
8	.8573	.8573	.8764	.8573	.8192	.8383	.8573
9	.7621	.724	.8383	.8002	.8383	.8573	.8192
10	.7049	.724	.8573	.743	.8192	.7621	.724
11		.6668	.6668	.6668	.7621	.6478	.6097
12	.5716	.7049	.6668	.6287	.6668	.6097	.5716
13	.5716	.6287	.5716	.5716	.6287	.5716	.5906
14	.5716	.5716	.5716	.5906	.5716	.5144	.6097
15	.5335	.5525	.5716	.5716	.6097	.5335	.6097
16	.5716	.0381	.5716	.5716	.6097	.5335	.6097
17	.6668	.5906	.6668	.6097	.6097	.5335	.6287
18		.7621	.7621	.6478	.7049	.5716	.6668
19	.8573	1.0479	.8573	.8383	.7811	.9526	.9526
20	.9526	1.0288	.9526	.8573	1.0098	.9907	.9526
21		1.0098	.9526	.8383	.9907	.9526	.8764
22		.8192	.8002	.7621	.8002	.9526	.9907
23		.7621	.6668	.6478	.7049	.7621	.7621
24	.7621	.5716	.5716	.5716	.6097	.6287	.6668
Max	.9526	1.0479	.9526	.8573	1.0098	.9907	.9907
Min	.4763	.0381	.4763	.5716	.5716	.5144	.5716
Avg	.6618	.6771	.6835	.6772	.697	.6978	.7192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 204 / 11KV SHARADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.9526	.9526	1.0479	1.0288	1.1812	1.0479
2		.9526	.9526	1.0479	1.0288	1.1431	.9526
3	1.1431	.9526	.9526	1.0479	1.0288	1.1431	.9526
4	1.1431	.9526	.9526	1.0479	1.0288	1.1431	1.1431
5	1.3336	1.1431	1.2574	1.3336	1.4861	1.1812	1.3336
6	1.5242	1.5242	1.8671	1.5242	1.6385	1.4861	1.5242
7	1.7147	1.7147	1.6004	1.7147	1.5242	2.0957	1.7147
8	1.7147	1.7147	1.829	1.7147	1.7528	1.7909	1.7147
9	1.7147	1.5242	1.829	1.8099	1.7528	1.6766	1.7147
10	1.5242	1.5242	1.7147	1.6004	1.6194	1.5432	1.467
11	1.4098	1.448	1.5242	1.4861	1.5623	1.5623	1.3908
12	1.4098	1.3717	1.5242	1.3717	1.3908	1.4289	1.3527
13	1.2955	1.2955	1.4289	1.2574	1.3146	1.2765	1.3336
14	1.1812	1.2384	1.3336	1.2193	1.2384	1.2765	1.2574
15	1.2574	1.2955	1.2384	1.1431	1.2003	1.2384	1.2574
16	1.2574	1.2574	1.2384	1.2193	1.2955	1.2574	1.2955
17	1.3336	1.3527	1.3336	1.2955	1.3146	1.3527	1.3527
18		1.448	1.7147	1.3908	1.5242	1.5242	1.4861
19	1.7147	1.9814	1.829	1.9814	2.1338	1.8099	2.0576
20	2.0005	2.1338	1.9052	2.0576	2.0195	2.0005	2.1719
21		2.0195	1.9814	1.9433	1.9814	1.9624	2.0576
22		1.7528	1.8671	1.6766	1.6766	1.829	1.7909
23		1.4861	1.7528	1.3717	1.448	1.7147	1.4098
24	1.5242	1.1431	1.1431	1.2384	1.2955	1.2574	1.2384
Max	2.0005	2.1338	1.9814	2.0576	2.1338	2.0957	2.1719
Min	1.1431	.9526	.9526	1.0479	1.0288	1.1431	.9526
Avg	1.4389	1.4241	1.4884	1.4392	1.4702	1.4948	1.4591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 205 / 11 KV WATER SUPPLY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.1143	.1143	.1143	.1143	.1143
2	.1143	.0953	.1143	.1143	.1143	.1143	.1143
3	.1143	.0953	.1143	.1143	.1143	.1143	.1143
4	1.1431	.0953	.1143	.1143	.1143	.1143	.1143
5	.1143	.0953	.1143	.1143	.1143	.1143	.1143
6	.1143	.0572	.1143	.1143	.1143	.1143	.1143
7	.1143	.0572	.1143		.1143	.1143	.1143
8	1.3336	.0572	.1143	.1143	.1524	.1143	.1143
9	.1143	.0762	.1143	.1143	.1143	.1143	.1143
10	.0953	.1143	.1143	.1143	.1143	.1143	.1143
11	.1143	.0762	.1143	.1143	.0953	.0953	.1143
12	.0762	.0762	.1143	.0953	.0953	.0762	.1143
13	.0762	.0381	.1143	.0762	.0953	.0953	.0762
14	.0953	.0381	.1143	.0953	.1143	.0953	.1143
15	.0953	.0953	.1143	.0762	.0953	.0762	.0762
16	.0762	.0762	.1143	.0762	.0953	.1143	.0953
17	.0953	.0953	.1143	.0953	.0762	.0762	.1143
18	.0953	.1143	.1143	.0953	.1143	.0762	.1143
19	.0953	.1143	.1143	.1143	.1143	.1143	.1143
20	.0953	.1143	.1143	.1143	.1143	.1143	.1143
21		.1143	.1143	.1143	.1143	.1143	.1143
22		.1143	.1143	.1143	.1143	.1143	.1143
23		.1143	.1143	.1143	.1143	.1143	.1143
24	.1143	.0953	.1143	.1143	.1143	.1143	.1143
Max	1.3336	.1143	.1143	.1143	.1524	.1143	.1143
Min	.0762	.0381	.1143	.0762	.0762	.0762	.0762
Avg	.2096	.0881	.1143	.1060	.1103	.1056	.1103

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 203 / CIDCO-N4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.419	1.419		1.4003	1.3717	1.3769	1.4632
2	1.363	1.363		1.3817	1.2803	1.307	1.3717
3	1.3256	1.2936		1.2936	1.2071	1.2323	1.3352
4	1.4003	1.3306		1.3306	1.2437	1.2696	1.3169
5	1.5339	1.3535		1.386	1.2803	1.3306	1.4266
6	1.8296	2.4143		1.7187	1.6461	1.7741	1.7375
7	2.0851	2.2497		1.8656	1.957	2.1582	1.9022
8	2.1033	2.0485		1.9936	2.0851	2.0851	1.8839
9	2.1582	2.0668		1.9204		2.0119	
10	2.0538	1.829	2.0668	1.8839		1.9753	
11	1.8111	1.9022	1.7924	1.8473		1.7558	1.7193
12	1.7372	1.6827	1.6644	1.6461		1.7375	1.6644
13	1.6632	1.6461	1.5729	1.5546		1.6095	1.6095
14		1.6095	1.5546	1.4815		1.5729	1.5181
15	1.5708	1.6095	1.5181	1.4998		1.5364	1.5546
16	1.6263	1.6461	1.6278	1.4449		1.5729	1.6095
17	1.6461	1.6827	1.5364	1.5546	1.6461	1.6461	1.6461
18	1.7375	1.829	1.6461	1.5912	1.7558	1.829	1.8107
19	2.3285	2.2986	2.1399	2.2314	2.1765	2.3594	2.1033
20	2.4025	2.3348	2.2497	2.2131	2.2314	2.4143	2.3594
21	2.1437	2.19	2.1399	2.0668	2.1216	2.1948	2.2862
22	2.0144	1.9728	1.9753	1.9022	1.9404	2.0485	2.0119
23	1.7924		1.6991	1.6461	1.6991	1.7741	1.8107
24	1.4937	1.5123		1.4937	1.4632	1.5123	1.5912
Max	2.4025	2.4143	2.2497	2.2314	2.2314	2.4143	2.3594
Min	1.3256	1.2936	1.5181	1.2936	1.2071	1.2323	1.3169
Avg	1.7930	1.7950	1.7988	1.6812	1.6941	1.7535	1.7151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 204 / MUKUNDWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6617	1.6617		1.6804	1.5729	1.643	1.6461
2	1.6244	1.6244		1.6244	1.5546	1.587	1.6095
3	1.587	1.5154		1.5893	1.5181	1.5497	1.5546
4	1.643	1.5708		1.6263	1.5912	1.7177	1.6095
5	1.7741	1.9387		1.9035	1.7558	1.9231	2.2862
6	2.7721	2.7435		2.3101	2.0668	2.2361	2.652
7	3.2007	3.2007		3.1602	2.7984	3.0178	3.2007
8	3.3471	3.1276		3.1642	2.9995	2.963	3.0361
9	2.8715	2.7801		2.7069		2.5972	
10	2.4143	2.963	2.7801	2.2131		2.3228	
11	1.9387	1.7193	2.1948	1.7741		2.0302	1.6278
12	1.6644	1.7924	2.0302	1.4998		1.7741	1.6278
13	1.5546	1.7741	1.8839	1.3169		1.7375	1.6461
14		1.6461	1.7375	1.4632		1.8107	1.4815
15	1.6461	1.6278	1.6461	1.5364		1.5546	1.4449
16	1.6461	1.6278	1.5912	1.5546		1.5181	1.5912
17	1.7375	1.8107	1.6827	1.6461	1.7924	1.6461	1.5546
18	1.9204	1.9204	1.701	1.8839	1.9204	1.8656	1.9204
19	2.4691	2.7069	2.3411	2.4691	2.4874	2.5606	2.5606
20	2.7435	2.7252	2.4143	2.5423	2.6886	2.6703	2.7435
21	2.5972	2.4508	2.3777	2.3777	2.3228	2.4691	2.4691
22		2.2624	2.1948	2.1948	2.3285	2.268	2.2862
23	1.9605		1.9231	1.8839	1.9044	1.9753	2.0485
24	1.6991	1.7364		1.7364	1.6461	1.6804	1.7193
Max	3.3471	3.2007	2.7801	3.1642	2.9995	3.0178	3.2007
Min	1.5546	1.5154	1.5912	1.3169	1.5181	1.5181	1.4449
Avg	2.1124	2.1272	2.0356	1.9941	2.0592	2.0466	2.0144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 205 / High court Exp
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0373		.0373	.0366	.0377	.0366
2	.0377	.0373		.0373	.0366	.0377	.0366
3	.0373	.0373		.0373	.0366	.0377	.0366
4	.0377	.0373		.037	.0366	.0373	.0366
5	.0373	.0373		2.0165	.0366	.0373	.0366
6	.0373	.0373		.0187	.0366	.0373	.0366
7	.0187	.0187		.0187	.0183	.0187	.0366
8	.0187	.0187		.0373	.0183	.0187	.0183
9	.0366	.0549		.0366		.0183	
10	.128	.1463	.1646	.0366		.0914	
11	.2012	.1829	.1646	.0366		.1829	.1646
12	.2012	.1829	.1829	.0549		.1829	.1646
13	.2195	.1829	.1646	.0549		.1829	.1829
14	.1646	.1646	.1646	.0549		.1829	.1829
15	.1829	.1829	.1829	.0366		.1829	.1829
16	.1829	.1829	.1646	.0549		.1646	.1646
17	.1646	.1829	.1646	.0549	.0366	.1646	.1829
18	.0914	.1097	.1097	.0366	.0183	.1097	.1097
19	.0732	.0549	.0732	.0366	.0366	.0914	.0732
20	.0366	.0549	.0549	.0366	.0549	.0549	.0549
21	.0366	.0549	.0549	.0549	.0366	.0549	.0549
22	.0373	.0362	.0549	.0366	.0373	.0366	.0366
23	.0554		.0373	.0366	.0377	.0366	.0366
24	.0377	.0373		.0373	.0366	.0377	.0366
Max	.2195	.1829	.1829	2.0165	.0549	.1829	.1829
Min	.0187	.0187	.0373	.0187	.0183	.0183	.0183
Avg	.0880	.0901	.1242	.1223	.0344	.0849	.0865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 201 / MHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2911	.2741	.2914	.2723	.2723	.2911	.2729
2	.2899	.2537	.2531	.2529	.2529	.2534	.2531
3	.2534	.2534	.2526	.2523	.2518	.2521	.2518
4	.2905	.3268	.2896	.289	.2896	.2893	.2896
5	.3275	.4024	.3268	.3628	.3087	.3999	.3643
6	.4949	.5908	.5164	.5159	.365	.5481	.5527
7	.6668	.6535	.6528	.6535	.518	.6329	.592
8	.5525	.6728	.6756	.64	.6348	.6193	.6361
9	.5596	.559	.6908	.5584	.5607	.5041	.5021
10	.4074	.362	.4954	.4382	.5387	.362	.399
11	.3326	.3241	.4001	.3239	.3803	.3239	
12	.2577	.2539	.3429	.3239	.4183	.2667	.2542
13	.2555	.2537	.3048	.2667	.3772	.2667	.1989
14	.2547	.2515	.3048	.2477	.3423	.2667	.2358
15	.2561	.2563	.3048	.2477	.3036	.2667	.2561
16	.2749	.2905	.2858	.2667	.3395	.2667	.2363
17		.309	.2743	.2902	.3416	.2858	.2659
18	.3103	.3265	.2718	.3797	.3639	.3429	.3042
19	.4211	.4344	.3813	.439	.4376	.4001	.4183
20	.438	.4577	.4348	.4399	.4563	.4763	.4559
21	.4339	.399	.4141	.4145	.4167	.4572	.4554
22	.4028	.3801	.4045	.3833	.3978	.4191	.3799
23	.3292	.3658	.3292	.3292	.3313	.3313	.3486
24	.2905	.2911	.2923	.2908	.292	.2926	.2926
Max	.6668	.6728	.6908	.6535	.6348	.6329	.6361
Min	.2534	.2515	.2526	.2477	.2518	.2521	.1989
Avg	.3648	.3726	.3829	.3699	.3830	.3673	.3572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 202 / RAMNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	.9714	.8962	.8779	.9866	.9328	.9126
2	.8569	.9126	.8551	.8205	.9097	.8943	.8706
3	.7674	.925	.9069	.8516	.8688	.905	.8498
4	.9684	1.0608	.9825	.9461	.9976	1.0371	1.0157
5	1.3379	1.5091	1.2803	1.3141	1.1475	1.3535	1.3717
6	1.9569	2.1034	1.9835	1.9259	1.6263	2.1003	2.0164
7	2.2569	2.4646	2.3341	2.2218	1.9378	2.2779	2.2848
8	2.2592	2.2918	2.4094	2.1956	2.2684	2.2542	2.3341
9	2.0475	1.9998	2.2519	2.0538	2.1537	1.8877	1.9231
10	1.6347	1.5563	1.7718	1.6575	1.8484	1.5432	1.4722
11	1.2382	1.3646	1.5051	1.3717	1.4901	1.2574	
12	1.1261	1.0724		1.2955	1.3769	1.1241	1.1075
13	1.049	1.0436	1.1622	1.086	1.0918	1.0288	1.0894
14	.9734	.9613	1.105	1.0479	.9431	.9526	1.0221
15	1.0122	.9694	1.0098	.9717	.9127	.9335	.9997
16	1.0164	.8715	.9717	.9907	1.0637	.8002	1.0274
17	1.0168	1.0894	1.007	1.0619	1.1317	1.0479	1.2334
18	1.3141	1.2359	1.0242	1.5102	1.3422	1.3717	1.407
19	1.7394	1.8675	1.6392	1.7394	1.7793	1.8099	1.9166
20	1.8415	1.8261	1.7067	1.7756	1.9165	1.8099	1.9014
21	1.5664	1.5433	1.5401	1.5236	1.6078	1.6004	1.6194
22	1.4113	1.451	1.3226	1.3799	1.5	1.4289	1.4991
23	1.1422	1.2147	1.1192	1.2109	1.1273	1.1815	1.2699
24		.9877	.9744	.9491	1.0425	.9754	.9877
Max	2.2592	2.4646	2.4094	2.2218	2.2684	2.2779	2.3341
Min	.7674	.8715	.8551	.8205	.8688	.8002	.8498
Avg	1.3681	1.3872	1.3808	1.3658	1.3779	1.3545	1.3970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 203 / Dhoot Exp.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1327	.1481	.1488	.1485	.1483	.13	.1295
2	.1328	.1299	.1298	.1295	.1294	.1109	.1109
3	.1139	.1304	.13	.13	.1109	.1111	.1107
4	.095	.1307	.1303	.1302	.1299	.1115	.1296
5	.0949	.1314	.168	.1491	.1486	.1304	.1488
6	.095	.1694	.1506	.15	.1306	.15	.1503
7	.0949	.132	.1708	.1509	.1507	.1698	.1515
8	.1713	.1708	.2282	.1708	.1328	.1704	.1708
9	.1898	.2472	.2282	.2472	.1331	.1901	.2094
10	.2464	.2467	.2286	.2286	.1141	.2477	.2659
11	.2467	.2651	.3048	.2286	.152	.2286	
12	.3216	.2657	.2667	.2667	.1318	.2477	.3027
13	.2462	.2279	.2286	.2286	.1331	.2667	.2654
14	.2846	.2275	.2286	.2286	.095	.2667	.2467
15	.3039	.2273	.2477	.2477	.0941	.2858	.2659
16	.2844	.2459	.2286	.2477	.114	.3048	.2467
17	.1898	.2087	.2277	.2277	.1141	.2477	.2279
18		.171	.171	.2085	.0949	.2096	.2089
19	.1898	.1706	.1559	.2279	.114	.2286	.2071
20	.1704	.1831	.1901	.1901	.1139	.2096	.2075
21		.1517	.1634	.1708	.1328	.1715	.2092
22	.171	.171	.1518	.171	.133	.1524	.1711
23	.1494	.1494	.168	.1503	.112	.1867	.152
24	.1327	.1483	.1492	.1486	.1489	.1302	.1486
Max	.3216	.2657	.3048	.2667	.152	.3048	.3027
Min	.0949	.1299	.1298	.1295	.0941	.1109	.1107
Avg	.1844	.1854	.1915	.1907	.1255	.1941	.1929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 204 / 11 KV Chikalthana

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.4201	1.4045	1.386	1.291	1.3647	1.3421
2	1.3146	1.3237	1.3463	1.291	1.2489	1.2883	1.2803
3	1.2384	1.3832	1.3789	1.3605	1.2686	1.3647	1.3169
4	1.5623	1.6515	1.5644	1.5091	1.4002	1.591	1.566
5	2.0576	2.3453	2.1592	2.0513	1.8665	2.0991	2.0513
6	2.8769	3.1212	3.062	2.9813	2.7678	3.1554	3.2268
7	3.2769	3.4941	3.5235	3.4105	3.4342	3.6329	3.6706
8	3.5627	3.4894	3.7761	3.3041	3.5307	3.4363	3.4397
9	3.1436	3.0996	3.5082	2.9808	3.263	2.9394	2.7859
10	2.7054	2.5317	3.1817	2.572	2.8337	2.3434	2.4351
11		2.236	2.7054	2.0576	2.4709	2.0767	
12		1.8792	2.3624	1.7528	2.2202	1.8861	1.9918
13		1.7193	1.9433	1.7528	1.824	1.829	1.7448
14		1.6159	1.8671	1.6004	1.7837	1.8099	1.5846
15		1.5879	1.7147	1.6194	1.7285	1.6956	1.6129
16		1.5465	1.7718	1.7528	1.8235	1.848	1.5291
17		1.9124	1.7485	1.7485	1.9565	2.0195	2.0915
18		2.1099	2.1421	2.0224	2.2703	2.0767	2.3554
19		2.7961	3.0393	2.8753	2.8898	3.1055	3.1215
20	2.9294	2.9294	2.9933	2.6759	2.9569		2.5833
21	2.3301	2.3802	2.4042	2.1695	2.2197	2.4006	1.9388
22	2.057	2.0386	1.8962	1.8415	1.9064	2.2291	2.0704
23	1.6566	1.6684	1.6194	1.5636	1.6144	1.7924	1.6869
24	1.5242	1.5154	1.4645	1.4415	1.3903	1.4459	1.4615
Max	3.5627	3.4941	3.7761	3.4105	3.5307	3.6329	3.6706
Min	1.2384	1.3237	1.3463	1.291	1.2489	1.2883	1.2803
Avg	2.2443	2.1581	2.2740	2.0717	2.1650	2.1491	2.1255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 201 / LAXMI NGR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	1.2136	1.3256	1.307	1.2136	1.2696	1.2696
2	1.4003		1.2696	1.2883	1.2136	1.251	1.2136
3	1.2696		1.2136	1.2696	1.251	1.307	1.1203
4	1.307	1.307	1.307	1.2883	1.2883	1.4003	1.531
5	1.4937	1.6804	1.4937	1.4003	1.3817	1.6057	1.8484
6	1.7737	1.8298	1.6804	1.5497	1.587	1.7924	2.0911
7	1.8671	2.0538	2.0538	2.1472	1.8671	2.2405	2.3152
8	1.9605	2.3339	2.2405	2.2218	2.1658	2.1658	2.3339
9	2.1285	2.0911	2.3712	2.2032	2.1098	2.0351	1.8671
10	1.7364	1.7551	1.8671	1.7924	1.8298	1.7924	1.8111
11	1.587	1.6617	1.9044	1.587	1.7737	1.6057	1.531
12	1.363	1.4937	1.7737	1.4563	1.587	1.5497	1.419
13	1.2883	1.2136	1.4937	1.2696	1.4003	1.3256	1.3443
14	1.1203	1.2696	1.307	1.1949	1.1949	1.2883	1.2136
15	1.1203	1.2883	1.3443	1.2323	1.2323	1.2883	1.2323
16	1.1203	1.2883	1.2136	1.2323	1.2696	1.2696	1.3443
17	1.363	1.4003	1.3443	1.419	1.3443	1.307	1.4377
18	1.6057	1.6804	1.419	1.5497	1.6244	1.7364	1.6991
19	2.0538	2.1845	1.9044	2.0725	2.0351	2.1285	2.1098
20	1.9791	2.0725	1.9418	1.9418	1.9418	2.0538	2.0538
21	1.6804	1.8671	1.8671	1.7737	1.8671	1.8298	1.8671
22	1.5684	1.6991	1.6804	1.6617	1.6617	1.6804	1.6991
23	1.4003	1.4937	1.4563	1.4003	1.4563	1.4937	1.5123
24	1.4937	1.307	1.3817	1.2696	1.251	1.2883	1.2883
Max	2.1285	2.3339	2.3712	2.2218	2.1658	2.2405	2.3339
Min	1.1203	1.2136	1.2136	1.1949	1.1949	1.251	1.1203
Avg	1.5474	1.6448	1.6189	1.5637	1.5645	1.6127	1.6314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 202 / MORESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.1203	1.2696	1.2136	1.1203	1.1389	1.1203
2	1.0269		1.2136	1.1763	1.1203	1.1203	1.0269
3	.9522		1.1203	1.1763	1.1576	1.1016	.9522
4	1.0829	.9335	1.307	1.2136	1.1763	1.1949	1.1203
5	1.2136	1.1576	1.3443	1.2883	1.2883	1.307	1.2883
6	1.307	1.3443	1.4563	1.4377	1.307	1.531	1.5684
7	1.643	1.5497	1.643	1.6244	1.475	1.8671	1.8298
8	1.7737	1.7364	1.8111	1.6617	1.7551	1.643	1.8298
9	1.5497	1.363	1.7364	1.6804	1.6617	1.5684	1.6804
10	1.4003	1.531	1.6244	1.4563	1.6244	1.3443	1.4563
11	1.251	1.4003	1.4377	1.3256	1.4937	1.2323	1.3443
12	1.0269	1.1389	1.3443	1.1763	1.307	1.1576	1.2136
13	1.1203	1.0082	1.1203	1.1016	1.2323	1.1203	1.1016
14	1.0269	1.1016	1.1203	1.0829	1.1949	1.1016	1.0642
15	1.0456	1.1576	1.2323	1.1016	1.0829	1.1016	1.0269
16	1.0456	1.2136	***	1.0642	1.0829	1.0829	1.1203
17	1.2136	1.2323	1.1203	1.0082	1.2136	1.2136	1.1763
18	1.1949	1.363	1.2136	1.3256	1.307	1.4377	1.363
19	1.6804	1.7551	1.6244	1.7364	1.6804	1.8111	1.8111
20	1.7737	1.7924	1.643	1.7177	1.6991	1.8298	1.7924
21	1.6804	1.6617	1.6057	1.6057	1.6057	1.6244	1.6617
22	1.5123	1.4937	1.531	1.5123	1.475	1.4937	1.5123
23	1.4003	1.3817	1.2883	1.2883	1.3256	1.3256	1.4003
24	1.2136	1.307	1.307	1.1763	1.1203	1.1763	1.2323
Max	1.7737	1.7924	11.4826	1.7364	1.7551	1.8671	1.8298
Min	.9522	.9335	1.1203	1.0082	1.0829	1.0829	.9522
Avg	1.3023	1.3520	1.8165	1.3396	1.3544	1.3552	1.3622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 203 / RENUKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.6161	.6535	.6535	.6161	.6161	.6161
2	.6161		.6161	.6348	.6161	.6161	.5975
3	.5601		.5788	.6535	.5975	.6535	.5601
4	.7468	.7468	.7468	.6722	.6348	.7282	.7842
5	.8962	.9522	.8962	.7468	.7282	.8402	1.0829
6	1.0269	1.0082	1.0269	.9149	.8775	1.0082	1.2323
7	1.1203	1.1203	1.2696	1.2696	1.0642	1.251	1.3256
8	1.2136	1.1576	1.3256	1.2323	1.1763	1.307	1.2883
9	.8775	.9149	1.0642	1.0642	1.0456	.9896	1.1763
10	.7655	.7655	.8029	.7655	.8775	.7468	.7655
11	.7655	.7468	.7655	.7655	.7842	.6348	.8215
12	.6722	.6161	.7095	.6161	.6908	.5228	.8029
13	.6535	.5788	.5975	.6348	.6161	.4668	.6161
14	.5975	.5601	.5788	.5788	.5788	.4481	.6161
15	.5975	.6535	.5788	.5788	.6348	.4481	.5041
16	.5601	.5975	.5975	.5601	.4668	.4668	.5975
17	.6161	.6722	.6161	.7095	.5228	.5228	.7282
18	.7842	.8029	.6535	.8029	.8589	.7468	.8029
19	1.0269	1.0642	.9522	1.0082	1.1016	1.1016	1.0642
20	.9709	.9335	.9709	.9896	1.0082	1.0642	.9522
21	.8962	.9149	.9149	.8775	.9709	.9149	.8962
22	.8215	.8402	.8589	.8589	.8215	.8215	.8402
23	.7095	.7468	.7468	.7095	.7095	.7468	.7282
24	.7468	.6535	.7095	.6722	.6348	.6348	.6348
Max	1.2136	1.1576	1.3256	1.2696	1.1763	1.307	1.3256
Min	.5601	.5601	.5788	.5601	.4668	.4481	.5041
Avg	.7873	.8028	.8013	.7904	.7764	.7624	.8347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 204 / 11 KV DEOGIRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.1867	.2427	.2427	.2427	.2241	.2241
2	.2054	.168	.2241	.2427	.2241	.2241	.2054
3	.1867		.1867	.2241	.2241	.2054	.1867
4	.2241	.1867	.2241	.2241	.2054	.2427	.2241
5	1.2136	.2054	.2427	.2614	.2427	.2614	.2801
6	.2427	.2427	.2427	.2987	.2427	.3361	.3174
7	.2614	.2987	.2801	.3361	.2614	.4481	.3734
8	.2801	.3174	.5228	.2801	.3547	.3921	.3361
9	.2801	.2801	.3547	.2987	.3174	.3174	.3174
10	.2241	.2427	.2427	.2427	.2614	.2241	.2614
11	.2241	.2427	.2614	.2801	.2987	.2054	.2427
12	.2054	.2241	.2241	.2054	.2801	.112	.2054
13	.2054	.1867	.2241	.2054	.2427	.2241	.1867
14	.1867	.2054	.2054	.1867	.2241	.2241	.2054
15	.1867	.1867	.2241	.1867	.2054	.1867	.1867
16	.1867	.1867	.2054	.1867	.1867	.1715	.2241
17	.1867	.2054	.2054	.1867	.2054	.2054	.2241
18	.2054	.2427	.2241	.2241	.2241	.2427	.2801
19	.2987	.3361	.3174	.3547	.2987	.3547	.3361
20	.3734	.3361	.3174	.3361	.3734	.3547	.3547
21	.3361	.3361	.3174	.3361	.3361	.3547	.3361
22	.3174		.2987	.2987	.3174	.3174	.3174
23	.2614	.2987	.2801	.2801	.2801	.2801	.2987
24	.2801	.2241	.2614	.2427	.2427	.2054	.2427
Max	1.2136	.3361	.5228	.3547	.3734	.4481	.3734
Min	.1867	.168	.1867	.1867	.1867	.112	.1867
Avg	.2840	.2427	.2637	.2567	.2622	.2631	.2653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 201 / 11KV CHETNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5028	1.587	1.8766	1.6289	1.5028	1.5775	1.9705
2	1.4593	1.4937	1.8766	1.6461	1.4089	1.5089	1.8766
3	1.4653	1.5123	1.8766	1.6461	1.4075	1.4918	1.8766
4	1.4667	1.6244	1.9705	1.6804	1.4118	1.4918	2.0643
5	1.7265	1.7364	2.0643	1.7833	1.578	1.6118	2.2519
6	2.4396	2.0538	2.2144	2.0062	2.0309	2.0062	2.4396
7	2.7133	2.8006	2.4396	2.332	2.2707	2.4348	2.7211
8	2.7156	2.7446	2.8525	2.572	2.6326	2.5377	2.8149
9	2.7774	2.4691	3.0026	2.7774	2.572	2.6968	2.6326
10	2.3645	2.1776	2.7802	2.5334	2.3148	2.4446	2.2592
11	2.2519	2.0233	2.3923	2.2519		2.2023	2.0165
12	1.9705	1.9719	2.1559	1.9705	1.9719	2.0915	1.9231
13	1.8766	1.8004	2.0059	1.8766	1.749	1.9477	1.9219
14	1.8391	1.749	1.7112	1.7265	1.6289	1.8616	1.8842
15	1.7828	1.6289	1.7828	1.6514	1.5775	1.7792	1.8222
16	1.8671	1.8391	1.6461	1.689	1.5432	1.8766	1.8034
17	1.8671	1.9705	1.6804	1.8052	1.6461	1.8766	1.9219
18	2.0538	2.1581	1.8004	2.0997	1.7661	2.0643	2.3693
19	2.8006	2.7211	2.3148	2.7266	2.5034	2.8149	2.6299
20	2.7446	2.8149	2.4348	2.4446	2.4348	2.8149	2.536
21	2.5393	2.7774	2.2634	2.4584	2.3148	2.6648	2.5924
22	2.3712	2.4396	2.1605	2.1625	2.1605	2.5334	2.2122
23	2.2405	2.2519	1.9204	1.8541	2.0233	2.2519	1.9685
24	1.7453	1.7737	1.9765	1.6804	1.6327	1.8176	2.0643
Max	2.8006	2.8149	3.0026	2.7774	2.6326	2.8149	2.8149
Min	1.4593	1.4937	1.6461	1.6289	1.4075	1.4918	1.8034
Avg	2.1076	2.0883	2.1333	2.0418	1.9166	2.1000	2.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 204 / Paitan gate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8785	1.8298	2.0643	1.8347	1.9103	1.6804	1.9705
2	1.7453	1.7924	1.9705	1.8004	1.7658	1.6461	1.9705
3	1.6958	1.8298	1.9705	1.8004	1.6958	1.6461	1.9705
4	1.6838	1.9978	2.0643	1.8347	1.6872	1.6804	2.0643
5	2.0039	2.1472	2.2519	1.9204	1.8785	1.7833	2.3458
6	2.6059	2.7073	2.5334	2.2291	2.3386	2.2805	2.6273
7	3.0808	3.1927	3.2841	2.5377	2.5418	2.7606	3.0964
8	3.2928	3.2861	3.3404	2.9835	3.0401	2.9492	3.2278
9	3.2278	3.1722	3.528	3.0964	2.915	3.1152	3.1927
10	3.3404	3.0864	3.5576	3.1527	2.9492	3.1844	3.1554
11	3.1527	2.9492	3.3676	3.0401		3.0839	3.0247
12	3.0964	2.7435	3.1805	2.8149	2.5377	3.0056	2.9874
13	2.9651	2.6578	2.956	2.8149	2.5034	2.8279	2.8567
14	2.7399	2.572	2.5172	2.4396	2.3148	2.646	2.8006
15	2.7399	2.4348	2.4347	2.4771	2.2634	2.5897	2.7774
16	2.7633	2.7774	2.2805	2.4396	2.1948	2.5897	2.8121
17	2.7446	2.9088	2.3663	2.3645	2.2291	2.8149	2.8251
18	2.95	3.1903	2.6578	2.6941	2.2291	2.9651	3.0525
19	3.7715	3.7908	3.3265	3.4307	3.0864	3.6594	3.6104
20	3.5475	3.5656	3.2579	3.2808	2.9492	3.4718	3.5235
21	3.1927		3.0007	3.0901	2.8807	3.2466	3.0901
22	2.8753	2.9088	2.4348	2.5522	2.572	2.8149	2.767
23	2.2405	2.6273	2.1948	2.1559		2.2519	2.4984
24	2.0831	2.0538	2.4396	2.0062	1.9103	2.0576	2.0643
Max	3.7715	3.7908	3.5576	3.4307	3.0864	3.6594	3.6104
Min	1.6838	1.7924	1.9705	1.8004	1.6872	1.6461	1.9705
Avg	2.7257	2.7053	2.7075	2.5329	2.3815	2.6146	2.7630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 206 / Deva nagari

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.3674	6.4156	6.4487	6.3276	6.3029	6.3878	.9008
2	6.3014	6.3382	6.4734	6.3474	6.2586	6.3794	.8445
3	6.3295	6.3176	6.5036	6.3706	6.2694	6.3962	.8445
4	6.3288	6.3374	6.5548	6.4	6.2799	6.4396	.9008
5	6.4259	6.4027	6.5625	6.4064	6.3588	6.4693	.9758
6	6.659	6.6415	6.5152	6.502	6.4084	6.5805	1.0509
7	6.6683	6.6701	6.5607	6.5513	6.4946	6.6484	1.1635
8	6.6013	6.5943	6.5857	6.4827	6.5941	6.5608	1.2198
9	5.1156	4.9032	4.9287	4.9569	6.3809	5.1392	1.251
10	5.6523	5.5914	5.9238	5.6811	6.528	5.7106	1.1203
11	4.7161	4.9085	5.1279	5.0974	5.3971	4.8842	1.1389
12	5.0147	4.9939	5.0427	5.0116	6.422	5.0089	.9896
13	5.751	5.7015	5.7789	5.6983	5.5342	5.6627	.9522
14	4.8615	4.923	4.9617	4.9449	6.6118	4.8642	.9719
15	5.7158	5.5235	5.5363	5.6998	6.049	5.5626	.9986
16	5.5064	5.3462	5.295	5.4401	6.3207	5.3458	.9798
17	6.2863	6.3454	6.3515	6.3472	6.3367	6.2814	.8453
18	6.4834	6.4678	6.4601	6.4699	6.3412	6.42	1.0664
19	6.8081	6.8926	6.7601	6.8642	6.7829	6.8515	1.2813
20	6.7913	6.8128	6.7196	6.6977	6.6537	6.9195	1.2722
21	6.8175	6.8338	6.6781	6.8117	6.7276	6.9673	1.2186
22	6.7612	6.7608	6.6678	6.7617	6.6328	6.8741	1.126
23	6.7074	6.6513	6.563	6.6022	6.5996	6.7143	1.0103
24	6.5563	6.5424	6.6509	6.8608	6.4869	6.5264	.9383
Max	6.8175	6.8926	6.7601	6.8642	6.7829	6.9673	1.2813
Min	4.7161	4.9032	4.9287	4.9449	5.3971	4.8642	.8445
Avg	6.1344	6.1215	6.1521	6.1389	6.3655	6.1498	1.0442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 201 / 11 KV INDIRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.2858	.3048	.2858	.3239
2	.3048	.3048	.3048	.2858	.2858	.2858	.3048
3	.3048	.3048	.3048	.2858	.2858	.2858	.3048
4	.3429	.3239	.3429	.3048	.3048	.3048	.3048
5	.381	.4001	.381	.362	.3429	.362	.4001
6	.4382	.4954	.4954	.4763	.4382	.4954	.5525
7	.6097	.6478	.5716	.5525	.5144	.5906	.6478
8	.6859	.724	.6859	.6097	.6287	.6859	.7049
9	.6097	.6287	.743	.5906	.7049	.5716	.6478
10	.5525	.5335	.6668	.6097	.5716	.5144	.5335
11	.5335	.5716	.5716	.4763	.4763	.4763	.5906
12	.4763	.5144	.5335	.4954	.4763	.4572	.5525
13	.4382	.4572	.4954	.381	.4572	.4191	.4954
14	.4572	.4001	.4191	.381	.4191	.4382	.4572
15	.4382	.4001	.381	.4191	.381	.381	.4191
16	.4382	.4382	.4191	.4001	.4191	.4382	.4572
17	.5144	.4763	.4382	.4763	.4763	.4954	.4763
18	.5906	.5525	.4763	.5144	.5335	.4954	.5525
19	.6478	.7049	.5335	.5716	.5716	.6287	.6859
20	.6287	.6478	.5144	.5525	.5335	.5906	.6478
21	.4954	.5144	.4572	.4954	.4954	.5144	.4954
22	.4191	.4191	.362	.4191	.4001	.4572	.4191
23	.381	.381	.362	.381	.381	.381	.362
24	.3239	.3239	.3239	.3048	.3239	.3239	.3429
Max	.6859	.724	.743	.6097	.7049	.6859	.7049
Min	.3048	.3048	.3048	.2858	.2858	.2858	.3048
Avg	.4715	.4779	.4620	.4430	.4469	.4533	.4866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 202 / 11 KV STADIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0572	.0572	.0191	.0191	.0191
2	.0381	.0381	.0381	.0381	.0381	.0191	.0191
3	.0381	.0381	.0381	.0381	.0381	.0191	.0191
4	.0381	.0381	.0381	.0381	.0381	.0191	.0191
5	.0381	.0381	.0381	.0381	.0381	.0381	.0191
6	.0381	.0381	.0572	.0381	.0381	.0572	.0191
7	.0381	.0762	.0191	.0572	.0191	.0572	.0191
8	.0381	.0762	.0191	.0572	.0191	.0572	.0191
9	.0381	.0762	.0191	.0381	.0191	.0572	.0191
10	.0572	.0572	.0381	.0381	.0572	.0572	.0572
11	.0381	.0572	.0381	.0381	.0572	.0381	.0381
12	.0572	.0572	.0381	.0572	.0381	.0572	.0572
13	.0572	.0572	.0381	.0381	.0381	.0572	.0381
14	.0762	.0762	.0381	.0381	.0381	.0381	.0381
15	.0762	.0762	.0381	.0381	.0381	.0381	.0381
16	.0762	.0762	.0381	.0381	.0381	.0381	.0572
17	.0762	.0762	.0191	.0381	.0572	.0381	.0572
18	.0762	.0762	.0191	.0381	.0572	.0381	.0381
19	.0953	.0762	.0572	.0762	.0762	.0762	.0762
20	.0762	.0953	.0572	.0953	.0762	.0762	.0762
21	.0762	.0762	.0191	.0381	.0762	.0762	.0762
22	.0762	.0762	.0191	.0191	.0572	.0191	.0381
23	.0762	.0762	.0191	.0191	.0572	.0191	.0381
24	.0381	.0762	.0762	.0191	.0191	.0572	.0191
Max	.0953	.0953	.0762	.0953	.0762	.0762	.0762
Min	.0381	.0381	.0191	.0191	.0191	.0191	.0191
Avg	.0572	.0643	.0365	.0429	.0437	.0445	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 203 / 11 KV CHANAKYAPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.9717	.9907	.9335	.8954	.9145	.8954
2	.8764	.9145	.9526	.9145	.8764	.8764	.8764
3	.8764	.9145	.9335	.9145	.8954	.8764	.8764
4	.9717	.9335	.9145	.9717	.9335	.9335	.9145
5	1.105	.9907	.9907	1.0098	1.0288	.9907	.9907
6	1.1431	1.1622	1.0669	1.1622	1.086	1.2193	1.3146
7	1.4289	1.2955	1.1622	1.2574	1.1431	1.3527	1.4861
8	1.467	1.3908	1.448	1.3336	1.1812	1.3908	1.5051
9	1.4289	1.3527	1.5432	1.5242	1.4098	1.3717	1.4861
10	1.2955	1.3717	1.5242	1.3336	1.4289	1.2574	1.3717
11	1.1241	1.2384	1.3908	1.2765	1.2384	1.1812	1.2574
12	1.105	1.1622	1.4098	1.1431	1.2574	1.1431	1.2384
13	1.1241	1.1812	1.2574	1.1622	1.1431	1.1431	1.105
14	1.0479	1.086	1.1812	1.0669	.9717	1.105	1.1812
15	1.0669	1.086	.8383	1.1431	1.0479	1.0479	1.1431
16	1.0288	1.2003	1.105	1.1431	1.1431	1.086	1.105
17	1.1241	1.2955	1.1622	1.1812	1.2003	1.1431	1.1622
18	1.2955	1.2955	1.2003	1.2765	1.2003	1.2003	1.3336
19	1.5432	1.6004	1.5051	1.6004	1.3908	1.5623	1.6004
20	1.448	1.4861	1.448	1.467	1.4098	1.4861	1.5813
21	1.3717	1.3908	1.3717	1.4289	1.2955	1.4861	1.5432
22	1.3336	1.3527	1.3717	1.3336	1.2955	1.4098	1.5051
23	1.1812	1.1622	1.2384	1.1812	1.1431	1.2574	1.1622
24	1.0098	1.0479	1.086	1.086	1.0098	1.0098	1.0479
Max	1.5432	1.6004	1.5432	1.6004	1.4289	1.5623	1.6004
Min	.8764	.9145	.8383	.9145	.8764	.8764	.8764
Avg	1.1812	1.2035	1.2122	1.2019	1.1511	1.1852	1.2368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 204 / 11 KV MUTHA COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.9526	.9145	.8954	.9145	.9717	.9526
2	.9335	.9526	.9335	.9335	.8764	.9145	.9145
3	.8764	.9335	.9335	.9145	.8764	.8954	.9145
4	.9335	1.0098	.9907	.9717	.9335	.9335	.9335
5	1.1431	1.1622	1.2193	1.1812	1.1622	1.1431	1.1622
6	1.2574	1.3908	1.3527	1.3527	1.3146	1.4098	1.5813
7	1.5242	1.6004	1.5242	1.4861	1.4098	1.5623	1.6575
8	1.4098	1.6004	1.5623	1.4098	1.4861	1.4861	1.5051
9	1.3908	1.4098	1.4861	1.4289	1.4861	1.448	1.4289
10	1.2955	1.2574	1.4098	1.2574	1.3336	1.2955	
11	1.1241	1.1622	1.3336	1.1431	1.3336	1.105	1.1241
12	1.086	1.1431	1.1431	1.086	1.105	1.0479	.8573
13	1.1431	1.0669	1.086	1.0288	1.0288	.9335	.8573
14	.9335	1.0288	1.0479	.9907	1.105	.9717	1.0479
15	.9145	.9526	1.0098	.9526	.9907	1.0479	.9907
16	1.0479	1.0098	1.0479	.9717	.9717	.9717	1.0098
17	1.105	1.0669	1.105	1.0479	1.0288	1.0288	1.0669
18	1.2574	1.2384	1.1812	1.1812	1.1241	1.2384	1.2765
19	1.6766	1.6194	1.5623	1.5242	1.467	1.6004	1.5623
20	1.6194	1.5432	1.5242	1.5242	1.4289	1.5242	1.6004
21	1.467	1.467	1.4098	1.4098	1.4098	1.5051	1.5051
22	1.3527	1.3336	1.2955	1.2574	1.3146	1.3717	1.3717
23	1.2193	1.2003	1.2193	1.1622	1.1241	1.1812	1.1812
24	.9526	1.3908	1.0479	1.0288	.9907	1.0098	1.0479
Max	1.6766	1.6194	1.5623	1.5242	1.4861	1.6004	1.6575
Min	.8764	.9335	.9145	.8954	.8764	.8954	.8573
Avg	1.1915	1.2289	1.2225	1.1725	1.1757	1.1916	1.1978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 205 / 11 KV SUHAS COLONY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.6097	.6097	.5906	.5906	.5716	.6097
2	.6097	.6097	.6287	.6097	.5716	.5906	.5906
3	.6097	.6097	.6287	.6097	.6097	.6097	.6097
4	.6668	.6859	.6478	.6668	.6478	.6478	.6478
5	.7621	.8192	.7811	.8002	.8764	.8573	.8192
6	.8573	.9335	.9145	.8192	.9145	.9717	.9717
7	1.0479	1.0669	1.0098	.8573	.9526	1.0288	1.0479
8	.9907	1.0669	1.0669	1.0669	.9907	.9145	1.0098
9	.9526	.8954	1.0098	.9145	.9907	.8383	.8192
10	.7811	.743	.8954	.9145	.8573	.6097	.743
11	.6097	.6859	.7621	.7811	.7811	.6668	.7049
12	.6097	.6478	.5716	.6859	.6668	.5335	.6668
13	.6097	.5906	.6287	.6097	.6668	.5716	.5906
14	.5716	.5906		.5906	.7049	.5716	.5716
15	.5716	.6097	.6478	.5525	.6287	.5716	.5716
16	.6287	.5906	.6668	.5525	.6097	.5335	.5716
17	.5144	.6287	.6287	.6097	.6287	.6287	.6287
18	.743	.724	.6478	.6478	.7621	.6668	.724
19	1.0098	.9717	.8573	1.105	.9335	.8764	.9907
20	1.086	.9717	.8954	.9717	.9335	.9335	1.0098
21	.9717	.9335	.9145	.8954	.8954	.9526	.9145
22	.8764	.9145	.8383	.8192	.8383	.8764	.8954
23	.7621	.7811	.743	.724	.724	.7049	.8002
24	.6478	.6478	.6478	.6097	.6287	.6478	.6478
Max	1.086	1.0669	1.0669	1.105	.9907	1.0288	1.0479
Min	.5144	.5906	.5716	.5525	.5716	.5335	.5716
Avg	.7550	.7637	.7671	.7502	.7668	.7240	.7565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-FEB-17 and 28-FEB-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 206 / 11 KV GAJANAN MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-17	23-FEB-17	24-FEB-17	25-FEB-17	26-FEB-17	27-FEB-17	28-FEB-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.105	1.086	1.0669	1.105	1.086	1.1241
2	1.086	1.086	1.0669	1.0479	1.0669	1.0669	1.105
3	1.0669	1.0669	1.0669	1.0479	1.0479	1.0669	1.086
4	1.0479	1.105	1.1241	1.105	1.1241	1.105	1.105
5	1.3146	1.3146	1.2765		1.2765	1.2384	1.2193
6	1.4289	1.5432	1.6385	1.5623	1.3717	1.8671	1.6575
7	1.8099	1.7718	1.7718	1.829	1.467	1.8671	1.9052
8	1.848	1.7528	1.9052	1.7718	1.5623	1.8861	1.9243
9	1.6575	1.5813	1.8099	1.829	1.6575	1.7337	1.7528
10	1.6385	1.7337	1.5242	1.5623	1.467	1.4861	1.4861
11	1.6956	1.6766	1.4861	1.4861	1.3908	1.448	1.6004
12	1.6956	1.5813	1.467	1.5242	1.2955	1.5242	1.7147
13	1.5623	1.5813	1.4098	1.448	1.2384	1.448	1.467
14	1.5432	1.5242	1.3527	1.3527	1.1812	1.4098	1.3908
15	1.4289	1.4289	1.448	1.2765	1.0669	1.3336	1.3336
16	1.4861	1.5242	1.2003	1.4098	1.2765	1.4289	1.4098
17	1.5813	1.5623	1.4289	1.4098	1.3527	1.5432	1.4861
18	1.6956	1.7528	1.4861	1.5242	1.4289	1.6956	1.7337
19	2.1148	2.0957	1.9624	2.0195	1.7909	2.0957	2.1338
20	2.0957	2.0957	1.9814	1.9052	1.7909	2.0957	2.1719
21	1.9052	1.848	1.9052	1.7909	1.7528	1.9052	1.9243
22	1.6194	1.6385	1.6766	1.5623	1.5623	1.7528	1.7528
23	1.4861	1.3908	1.4289	1.3908	1.2765	1.4289	1.467
24	1.1812	1.2574	1.2574	1.3146	1.2193	1.1431	1.2574
Max	2.1148	2.0957	1.9814	2.0195	1.7909	2.0957	2.1719
Min	1.0479	1.0669	1.0669	1.0479	1.0479	1.0669	1.086
Avg	1.5448	1.5424	1.4900	1.4886	1.3654	1.5273	1.5504