

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194059 / 33/11 KV WALWAD S/S

Feeder No / Name : 201 / 11 KV WALWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.0457	.0486		.0762	.0457
9	.0486						
10	1.4413		1.4632				
11	1.587						
12	1.2955		2.2443				
13	1.2308						
14	1.4251						
15	1.9433						
16	2.0567	1.829	2.3777	1.9595	1.9814	1.8623	1.9509
17	2.251						
18		.061	.0762		.0762		.061
24	.0486	.0486	.061	.0762	.0486	.0914	.0486
Max	2.251	1.829	2.3777	1.9595	1.9814	1.8623	1.9509
Min	.0486	.0486	.0457	.0486	.0486	.0762	.0457
Avg	1.3328	.6462	1.0447	.6948	.7021	.6766	.5266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194059 / 33/11 KV WALWAD S/S

Feeder No / Name : 202 / 11 KV Ganegaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.9498	2.5911	2.8346	
9	.9175				
10	.9831		.3658		
11	.3605				
12	.2949		.4954		
13	.3277				
14	.2949				
15	.3113				
16	.3441	.3048	.4191	.3277	
17	.3768				
18		.4572	.4572		
24	1.065	1.6549	1.0669	1.2269	1.491
Max	1.065	1.9498	2.5911	2.8346	1.491
Min	.2949	.3048	.3658	.3277	1.491
Avg	.5276	1.0917	.8993	1.4631	1.491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194059 / 33/11 KV WALWAD S/S

Feeder No / Name : 203 / Walwad GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2012	.2347	.3048	.1696	.1905	.2667	.2134
9	.1677						
10	.1715		.2286				
11	.2012						
12	.218		.2126				
13	.2012						
14	.1677						
15	.1677						
16	.1509	.2667	.1753	.1715	.2286	.1543	.2286
17	.1543						
18		.2667	.1928		.2286		.2667
24	.2012	.1543	.1905	.1372	.1715	.1905	.2012
Max	.218	.2667	.3048	.1715	.2286	.2667	.2667
Min	.1509	.1543	.1753	.1372	.1715	.1543	.2012
Avg	.1821	.2306	.2174	.1594	.2048	.2038	.2275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194061 / 33/11KV SUB-STATION AMBHI

Feeder No / Name : 201 / AMBHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17
HR	Load (MW)	Load (MW)
1		.8642
2		.9819
3		1.1269
4		.9896
5		1.1965
6		1.3016
7		1.7709
16	.2789	
17	.2818	
18	.2758	
19	.3757	
20	.4696	
21	.4687	
22	.3628	
23	.3677	.3349
24		.8049
Max	.4696	1.7709
Min	.2758	.3349
Avg	.3601	1.0413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194068 / 33/11 KV SUKTA S/S

Feeder No / Name : 201 / 11 KV SUKTA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.2591	.004	.4572	.4001	.3353	.4191
2	1.2574	.2439	.004	.4191	.381	.3201	.4001
3	.2641	.2743	.0042	.4382	.3429	.2743	.4382
4	.4066	.3201	.0051	.4763	.3048	.2439	.4763
5	.5716	.4115	.0057	.5716	.6478	.3048	.5716
6	.7049	.4877	.0065	.724	.743	.4268	.724
7	.724	.5639	.0069	.7621	.724	.5792	.8002
8	.6287	.5639	.0065	.5716	.743	.5182	.6668
9	.5525	.3658	.0067	.4954	.5335	.4268	.5335
10	1.7909	1.3279	.0133	2.21	1.829		1.8004
11	2.0809	.0248	2.1719	2.553	2.0241	2.553	.0253
12	2.2348		2.3167	2.5911	2.2775	2.4768	.0253
13	2.251	.0238	2.2624	2.4768	2.1052	2.4387	
14	2.2775	.0229	2.1719	2.4006	2.1136	2.4768	.0232
15	2.2447	.021	2.1357		2.0645	2.5149	.0227
16	2.1862	.0238	2.3411		2.0481	2.5911	.0234
17	2.2283	.0248	2.5149	2.0195	1.9989	2.4768	.0234
18	.2896	.0029	.381	2.3624	.2214	.2286	.0034
19	.4877	.0059	.6287	.6097	.4268	.7621	.0044
20	.5792	.0069	.7621	.7811	.6249	.7811	.0061
21	.4572	.0061	.6097	.6478	.5487	.5716	.0061
22	.3963	.0055	.5335	.5525	.4268	.5144	.0072
23	.3506	.005	.4954	.4572	.381	.4763	.005
24	.4191	.2896	.0042	.4572	.4191	.3506	.4382
Max	2.2775	1.3279	2.5149	2.5911	2.2775	2.5911	1.8004
Min	.2641	.0029	.004	.4191	.2214	.2286	.0034
Avg	1.0735	.2296	.8080	1.1379	1.0137	1.0714	.3236

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194068 / 33/11 KV SUKTA S/S

Feeder No / Name : 203 / GhatNandur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.0021	.2286	.1905	.1829	.2286
2	.2096	.2134	.0025	.2143	.3429	.2286	.176
3	.4572	.2623	.0046	.2858	.4191	.2743	.2054
4	.4954	.3048	.0053	.3668	.5716	.3201	.2347
5	.5335	.3506	.0059	.4108	.6859	.4115	.3048
6	.6097	.4268	.0065	.4694	.7621	.5197	.4268
7	.6478	.5468	.0069	.5182	.724	.5335	.5792
8	.6859	.5312	.0069	.6097	.743	.6019	.6859
9	.6859	.5182	.0069	.5335	.7049	.5624	.7316
10	.2641	.1981	.003	.2667	.3429	.2286	.2858
11	.1677	.0032	.1905	.1905	.1677	.2286	.0023
12	.1524		.1334	.1905	.1524	.1905	.0023
13	.1524	.0017	.1334	.1715	.1524	.1905	
14	.1524	.0017	.1334	.1524	.1372	.1905	.0019
15	.1372	.0015	.1524	.1905	.1524	.1905	.0019
16	.1372	.0019	.1524	.1715	.1677	.1715	.0019
17	.1524	.0021	.1715	.1524	.1677	.1905	.0019
18	.1829	.0023	.2477	.2667	.1829	.2286	.003
19	.3201	.004	.4001	.4191	.2286	.6668	.0034
20	.3963	.0055	.6097	.6097	.4572	.6287	.0055
21	.3048	.0053	.5335	.2667	.3963	.4763	.0055
22	.2286	.004	.4191	.2667	.3048	.2667	.005
23	.1829	.0034	.3429	.2286	.2591	.2286	.003
24	.2286	.1677	.0025	.1905	.2096		.2286
Max	.6859	.5468	.6097	.6097	.7621	.6668	.7316
Min	.1372	.0015	.0021	.1524	.1372	.1715	.0019
Avg	.3198	.1613	.1530	.3071	.3593	.3353	.1793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194070 / 33/11 kv Antargaon

Feeder No / Name : 201 / ANTARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.5525	.0057	.0044	.6668	.5716
2	.5716		.5525	.0057		.5144	.5716
3	.5335		.5716			.4763	.5716
4	.5716		.6668			.5144	.6668
5	.5716		.7621			.6668	.7621
6	.6668		.9335			.6097	.8383
7	.724	.5868	.6668		.0067	.5765	.7049
8	.6287	.3315	.4954		.0061	.5197	.5525
9		.381	.381	.005	.0053		.4001
10		1.1336		1.6108	1.3672	1.6461	1.4918
11	2.7999	2.8464		1.7804	2.7999	2.9254	2.8673
12				2.0157	2.8675		2.4577
13	2.2045	2.372		2.2148	2.2874	2.4194	2.4577
14				2.4806	1.9662	2.3122	2.3758
15	2.2939	1.4706		2.6968		2.234	
16	2.6543			2.9864	2.3758	2.4669	2.7035
17		2.0778		3.0121		2.5621	2.4577
18	.3086			.0038	.3086		.2858
19		.6287			.6097	.4572	.5716
20	.724	.6668			.8002	.5335	.6668
21		.6668				.6478	.6668
22		.6668			.7811	.6478	.6097
23		.6287			.6668	.6097	.5716
24	.5716		.5525		.0048		.5716
Max	2.7999	2.8464	.9335	3.0121	2.8675	2.9254	2.8673
Min	.3086	.3315	.381	.0038	.0044	.4572	.2858
Avg	1.0931	1.1121	.6135	1.5682	1.0536	1.2003	1.1476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194071 / 33/11 kv warud sub-station

Feeder No / Name : 201 / 11 KV Warud SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2858		.362		.3048	
2	.3201	.2397		.2229	.2469	.2258	
3	.4607	.2858		.2675	.2778	.2896	
4	.5201	.3384		.301	.3281	.3506	
5	.5647	.4755		.4321	.5121	.4268	
6	.6097	.7164		.5155	.6554	.6019	
7	.6401	.8322		.6718	.7545	.7562	
8	.6859	.9012		.695	.6299	.8025	
9	.6859	.7682	.7621	.6602	.8718		.7133
10	.3239	.3048	.2858	.2667	.381		.2667
11	.2858	.2477	.2858	.3048	.3048		.2477
12	.2667	.2286	.2858	.2667	.2858		.2477
13	.2858	.2286	.2858	.2667	.2667		.2477
14	.2858	.2286	.362	.2477	.3429		.2667
15	.2667	.2477	.2858	.2477	.3048		.2667
16	.2858	.2858	.2667	.2667	.2477		.2858
17	.2858	.2858	.2477		.2667		.2858
18	.5335	.3048	.2477		.3048		.3239
19	.5335	.4763	.4954		.4954		.4954
20	.5716	.5716	.6097		.5716		.6097
21	.4954	.4954	.5335		.4954		.5335
22	.4191	.4572	.4572		.4191		.4191
23	.362	.4191	.4191		.381		.381
24	.3429			.381	.3239	.3429	
Max	.6859	.9012	.7621	.695	.8718	.8025	.7133
Min	.2667	.2286	.2477	.2229	.2469	.2258	.2477
Avg	.4307	.4185	.3887	.3751	.4204	.4557	.3727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194072 / 33/11 KV PATHRUD S/S

Feeder No / Name : 201 / 11 KV PATHRUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5487			.4801		.9602
2		.6173			.703		1.0802
3		.703			.9012		1.1288
4		.8097			.9945		1.1717
5		.9945			1.2003		1.1069
6		1.1517			1.3413		1.2346
7		.9488			1.1469		1.5203
8	1.0031	.9259	1.2803		1.2003		1.0155
9		.6249	1.2498		1.2003	1.1574	.8802
10		1.0155	1.4575		1.3117	.7811	1.0802
11		1.3889	1.5623		1.5565	1.1574	1.1888
12		1.3603	1.5813		1.5242	1.0402	1.0717
13		1.4842	1.4746		1.0279	.9374	.9335
14		1.4403	1.4232		1.0802	1.1574	1.0402
15		1.3889	1.4403		1.1069	1.2803	.9164
16		1.3441	1.4232		1.0669	1.1069	.9412
17	1.4661					1.2346	.9869
18	.6173			.5068		.9602	.7145
19	.6859			.6944		.7716	.9031
20	.7716			.7049		1.0402	1.1717
21	.703			.5411		1.1069	1.1203
22	.6944			.5106		.9145	1.0802
23	.602			.503		1.0031	1.012
24		.6401			.5258		1.0031
Max	1.4661	1.4842	1.5813	.7049	1.5565	1.2803	1.5203
Min	.602	.5487	1.2498	.503	.4801	.7716	.7145
Avg	.8179	1.0228	1.4325	.5768	1.0805	1.0433	1.0526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194072 / 33/11 KV PATHRUD S/S

Feeder No / Name : 203 / 11 KV Pathrud Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.2743			.181		.1734
2	1.1069	.2686			.1791		.1696
3	1.0402	.2658			.1753		.1791
4	1.1717	.2686			.2743		.2658
5	1.0536	.2715			.2686		.2601
6	.9907	.2743			.362		.2658
7	.9374	.3582			.3658		.2601
8	.1734	.3658	.1753		.4477		.1696
9		.2686	.2658		.3658	.2686	.1753
10		.2686	.2658		.2658	.1734	.2686
11		.2629	.2686		.2601	.1696	.181
12		.2686	.2743		.2686	.1753	.0191
13		.2601	.2715		.2658	.2601	.1791
14		.2629	.2686		.2601	.1791	.181
15		.2629	.2658		.2572	.1753	.1791
16		.2601			.2686	.181	.181
17	.3658					.1772	.1734
18	.362			.3658		.1753	.1791
19	.3658			.362		.1734	.1753
20	.462			.4477		.1791	.1734
21	.4525			.4572		.1734	.1791
22	.3582			.2686		.1772	.1772
23	.2743			.2629		1.0031	.1753
24	1.0155	.2715			.1829		.1791
Max	1.1717	.3658	.2743	.4572	.4477	1.0031	.2686
Min	.1734	.2601	.1753	.2629	.1753	.1696	.0191
Avg	.6910	.2784	.2570	.3607	.2735	.2427	.1883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

BHOOM (R) S/DN[428] BU 2640

Substation No/ Name :- 194072 / 33/11 KV PATHRUD S/S

Feeder No / Name : 204 / JAMB GFSS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.0191			.0191		.1905
2	.1905	.0191			.0191		.1905
3	.1905	.0191			.0191		.1905
4	.1905	.0191			.0191		.1905
5	.1905	.0191			.0191		.1905
6	.1905	.0191			.0191		.1905
7	.1905	.0191			.0191		.1905
8	.1905	.0286	.1905		.0191		.1905
9		.1905	.1905		.0191	.1905	.0191
10		.1905	.1905		.1905	.1905	.0191
11		.1905	.1905		.1905	.1905	.0191
12		.1905	.1905		.1905	.1905	.0191
13		.1905	.1905		.1905	.1905	.0191
14		.1905	.1905		.1905	.1905	.0191
15		.1905	.1905		.1905	.1905	.0191
16		.1905			.1905	.1905	.0191
17	.0191					.1905	.1905
18	.0191			.0095		.1905	.1905
19	.0286			.0191		.1905	.1905
20	.0286			.0286		.1905	.1905
21	.0191			.0286			.1905
22	.0191			.0191		.1905	.1905
23	.0191			.0191		.1905	.1905
24	.1905	.0191			.0191		.1905
Max	.1905	.1905	.1905	.0286	.1905	.1905	.1905
Min	.0191	.0191	.1905	.0095	.0191	.1905	.0191
Avg	.1167	.1003	.1905	.0207	.0897	.1905	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 201 / 11 KV YERMALA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.381				.3506	.3429
4	.381				.3506	.3429
6	.381		.3506		.3506	.381
7					.3506	
8	.381		.4207		.3506	.4572
9			.4115			
10			.407			
11					.4024	
12			.3391		.407	
13					.3688	
14			.373		.3688	
15					.4191	
16			.4191		.4191	
17					.4572	
19					.5716	
20					.5716	
21					.5335	
24	.4191	.381		.381	.4115	.381
Max	.4191	.381	.4207	.381	.5716	.4572
Min	.381	.381	.3391	.381	.3506	.3429
Avg	.3886	.381	.3887	.381	.4177	.381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 202 / 11 KV UMRA PANGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.5426			.5609	.6036
4	.5426			1.2536	.6706
6	1.1022		1.4232	1.5402	1.3748
7				1.2894	
8	1.3395		1.4685	1.3672	1.5424
11			.3239	.362	
12			.2858	.3048	
14			.2858	.3048	
15				.2667	
16			.2858	.2667	
17				.2858	
18				.362	
19				.4001	
20				.8573	
21				.7049	
24	.381	.381	.3521	.4119	.6036
Max	1.3395	.381	1.4685	1.5402	1.5424
Min	.381	.381	.2858	.2667	.6036
Avg	.7816	.381	.6322	.6586	.959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 203 / 11 KV RATNAPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2477				.16	.2477
4	.2477				.208	.2477
6	.381		.3441		.2561	.3429
7					.3277	
8	.362		.2401		.2785	.3429
10			.4917			
11					.6203	
12			.6613		.6203	
13					.5868	
14			.6104		.5868	
15					.57	
16			.5256		.5533	
17					.6613	
18					.1715	
19					.2667	
20					.381	
21					.362	
24	.2667	.2858	.2458	.2667	.2401	.2477
Max	.381	.2858	.6613	.2667	.6613	.3429
Min	.2477	.2858	.2401	.2667	.16	.2477
Avg	.3010	.2858	.4456	.2667	.4030	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 205 / 11 KV BANGARWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1524				.128	.1905
4	.1524					.1715
6	.2477		.2294		.2241	.1905
7					.2294	
8	.2286		.1905		.192	.2096
9			.16			
10			.3561			
11					.3391	
12			.5426		.6036	
13					.6203	
14			.5087		.57	
15					.5365	
16			.4917		.5256	
17					.5256	
18					.1143	
19					.1715	
20					.2858	
21					.2286	
24	.1524	.1905	.16	.2667	.1475	.1905
Max	.2477	.1905	.5426	.2667	.6203	.2096
Min	.1524	.1905	.16	.2667	.1143	.1715
Avg	.1867	.1905	.3299	.2667	.3401	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194004 / 33/11 KV SUB-STATION YERMALA

Feeder No / Name : 206 / 11 KV CHORAKHALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2713				.4801	.2683
4	.2713				.5487	.3391
6	.4748		.631		.7164	.6706
7					.7712	
8	.6443		.7522		.7164	.7621
9			.2949			
10			.3048			
11					.2286	
12			.2286		.2286	
13					.2286	
14			.2286		.2286	
15					.2286	
16			.2286		.2286	
17					.2286	
18					.3048	
19					.381	
20					.5335	
21					.381	
24	.3048	.2858		.2858	.3521	.2683
Max	.6443	.2858	.7522	.2858	.7712	.7621
Min	.2713	.2858	.2286	.2858	.2286	.2683
Avg	.3933	.2858	.3812	.2858	.3991	.4617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194006 / 33/11 KV SUB-STATION KALLAM

Feeder No / Name : 203 / 11 KV KALLAM URBAN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	2.0576	2.4025	2.4272	2.572	2.4272	2.3777
2	2.4006	2.0576	2.4025	1.7909	2.572	2.4272	2.3777
3	2.2291	1.7147	1.9909	1.6289	2.2291	2.4272	2.1948
4	2.2291	1.7147	1.9909	1.7909	2.2291	2.4272	1.8099
5	2.2291	2.0576	1.9909	2.0119	2.0576	2.4272	1.8099
6	2.4006	2.2291	2.1948	2.2177	2.2291	2.6139	2.0119
7	2.4006	2.7435	2.4025	2.4025	2.2291	2.6139	2.1948
8	2.572	2.572	2.5873	2.4025		2.8006	
9		2.7435	2.6139	2.0576		2.5873	2.2405
10		2.7435	2.6139	2.0576		2.3777	2.2405
11		2.7435	2.2405	2.2291		2.3777	2.2405
12		2.915	2.4272	2.2291		2.4025	2.2405
13		2.915		2.2291		2.1719	2.2405
14		2.7435	2.0538	2.2291		2.1719	2.2405
15		2.4006	2.0538	2.2291		2.1719	2.8006
16		2.5873	2.0538	2.2291		2.1948	2.2405
17		2.6139	2.2405		2.3339	1.949	2.4006
18		2.9874	2.9874		2.3339	2.1262	2.4006
19		2.9569	3.0807		2.8006	2.6139	2.2291
20		3.1741	3.1741		2.9874	2.8292	2.4006
21		3.2674	3.1741		3.0807	2.8006	2.3148
22		2.8006	2.8959		2.9874	2.8006	2.3663
23		2.5873	2.5606		2.9874	2.6797	2.2291
24	2.2291	2.572	2.6139	2.5606	2.7435	2.7073	2.5873
Max	2.572	3.2674	3.1741	2.5606	3.0807	2.8292	2.8006
Min	2.2291	1.7147	1.9909	1.6289	2.0576	1.949	1.8099
Avg	2.3434	2.5791	2.4672	2.1602	2.5582	2.4636	2.2691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194006 / 33/11 KV SUB-STATION KALLAM

Feeder No / Name : 205 / 11 KV EXPRESS JINNING

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1143	.1334	.1715	.0191	.0953
2	.0857	.0857	.1905	.0953	.1715	.0267	.0953
3	.1715	.1715	.3429	.1143		.0191	.0953
4	.1715	.1715	.4191	.3429	.1715	.0191	.1334
5	.1715	.1372	.4572	.4191	.1715	.0191	.1524
6	.1715	.1715	.1905	.381	.1715	.0191	.1905
7	.1715	.1715	.3048	.1524	.1715	.0191	.1524
8	.1715	.1715	.1524	.1524		.0191	
9		.1715		.1715		.1334	.0381
10		.1715		.1715		.1905	.0381
11		.1715		.1715		.1905	.0381
12						.1905	.0381
13		.1715		.1715		.1905	.0381
14		.1715		.1715		.1905	.0381
15		.1715		.1715		.1905	.0381
16		.0953				.1905	.0381
17		.0953			.0381	.1905	.1715
18		.1334			.0381	.1905	.1715
19		.1334			.0381	.1905	.1715
20		.1334			.0191	.1905	.1715
21		.1524				.1905	.1715
22		.1334	.0953		.0381	.1905	.1715
23		.0953	.1334		.0381	.1715	.1715
24	.1715	.1715	.1334	.1524	.1715	.1905	.1905
Max	.1715	.1715	.4572	.4191	.1715	.1905	.1905
Min	.0857	.0857	.0953	.0953	.0191	.0191	.0381
Avg	.1620	.1489	.2303	.1981	.1085	.1305	.1135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194018 / 33/11 KV SUB-STATION

DAHIPHAL

Feeder No / Name : 201 / 11 KV BARATEWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.5544		.5375
11	1.166		.9414	
12	1.166			
19	.4066			
Max	1.166	.5544	.9414	.5375
Min	.4066	.5544	.9414	.5375
Avg	.9129	.5544	.9414	.5375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194018 / 33/11 KV SUB-STATION

DAHIPHAL

Feeder No / Name : 203 / 11 KV DAHIPHAL FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.2717		1.2717
8				.9995
11			.1296	
13	.1214			
19	.2629			
Max	.2629	1.2717	.1296	1.2717
Min	.1214	1.2717	.1296	.9995
Avg	.1922	1.2717	.1296	1.1356

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194018 / 33/11 KV SUB-STATION

DAHIPHAL

Feeder No / Name : 204 / 11 KV GAUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		1.2209		1.8652
11			.3222	
13	.2883			
19	.4409			
Max	.4409	1.2209	.3222	1.8652
Min	.2883	1.2209	.3222	1.8652
Avg	.3646	1.2209	.3222	1.8652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194018 / 33/11 KV SUB-STATION

DAHIPHAL

Feeder No / Name : 206 / 11 KV SAPNAI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.4321		.4001
11			1.2003	
13	1.1174			
19	.421			
Max	1.1174	.4321	1.2003	.4001
Min	.421	.4321	1.2003	.4001
Avg	.7692	.4321	1.2003	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194021 / 33/11 KV SUB-STATION MOHA

Feeder No / Name : 201 / 11 KV MOHA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3795	.4268	.3429	.3201	.4287	1.4268	2.0576
2	1.1317	1.1873	1.1918	1.2803	1.2651	1.4596	2.3663
3	2.2405	1.6385	1.6644	2.7526	1.7814	1.6347	2.3807
4	2.6139	1.7814	1.8031	2.8464	1.9433	1.7391	2.4531
5	2.6139	2.2939	2.1972	2.8746	2.5606	2.1559	2.4577
6	2.95	3.0803	2.9657	3.1459	3.0803	2.8886	2.6886
7	1.9616	3.0445	3.4902	2.9264	3.2769	2.8921	2.7831
8	2.8753	3.0803	3.1751	2.4996	3.0445	2.7465	2.6886
9	2.3403	2.8978	3.1047	2.6216	2.9508	2.5873	2.3746
10	.4999		.4329	.5182	.3658	.5792	.5624
11	.3749		.423	.4062	.2926		.3749
12	.3749		.4755		.2743		.3658
13	.3749		.5053	.4744	.2808	.3765	.4268
14	.3658		.4458	.3749	.2881	.3765	.3658
15	.3749		.4572	.3795	.2881	.3814	.3658
16	.4062	.2743	.4058	.3795	.2743		.3749
17	.4428	.2506	.5068	.3749	.2949	.4515	.463
18	.5053		.6562	.4687	.3951	.4633	.4816
19	.6661	.4594	.7133	.5716	.5239	.823	.6241
20	.7145	.5638	.751	.743	.6828	.8642	.8124
21	.6241	.4694	.6584	.6767	.5679	.6706	.7186
22	.5792	.4344	.4534	.5792	.4619	.543	.5944
23	.4458	.3341	.4344	.4858	.4403	.4572	.5418
24	.3795	.4268	.3246	.423	.4572	1.2052	1.3321
Max	2.95	3.0803	3.4902	3.1459	3.2769	2.8921	2.7831
Min	.3658	.2506	.3246	.3201	.2743	.3765	.3658
Avg	1.0931	1.3320	1.1491	1.2227	1.0925	1.2725	1.2773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194021 / 33/11 KV SUB-STATION MOHA

Feeder No / Name : 202 / 11 KV KHERDA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.3048	.3048	.3048	.3048	.3048	.3048
2	.2667	.3048	.3048	.3048	.3048	.3048	.3048
3	.2667	.3048	.3048	.3048	.3048	.3048	.3048
4	.3048	.3429	.3429	.381	.381	.3429	.381
5	.381	.4572	.4191	.4191	.4572	.4191	.4954
6	.4954	.5716	.5335	.5335	.5335	.5335	.6097
7	.6097	.6097	.5716	.4572	.6097		.4954
8	.4191		.4191		.5716		.4954
9			.6097		.4572		.381
10	1.7909	2.2862	1.6766	1.6004	1.829	1.3717	1.829
11	1.7528		2.7816	2.5149	2.4387	2.6673	2.4387
12	2.5149	2.9721	2.4387	2.3624	2.2862	2.2862	2.4387
13	2.4006		2.2862	2.0195	1.9814		2.2862
14	2.2862		2.1719	1.9052	1.9814	1.6766	2.1338
15	2.0957		2.1719	1.9052	1.9814	2.0957	2.21
16	2.5149	3.0483	2.2862	2.2862	2.4387	2.4387	2.21
17	2.6673	3.2007	2.3624	2.5911	2.4387	2.6673	2.6673
18	.4191	.3429	.2667	.3048	.2667	.3048	.3048
19	.4954	.4572	.4572	.4954	.4191	.6478	.4191
20	.5716	.5335	.6097	.6097	.5335	.6859	.5716
21	.4954	.4954	.5335	.5335	.4954	.4572	.4954
22	.4191	.4191	.4191	.4191	.4191	.4191	.381
23	.3429	.3429	.3429	.381	.3429	.3429	.3048
24	.2667	.3048	.3048	.3048	.3429	.3048	.3048
Max	2.6673	3.2007	2.7816	2.5911	2.4387	2.6673	2.6673
Min	.2667	.3048	.2667	.3048	.2667	.3048	.3048
Avg	1.0454	.9611	1.0383	1.0427	1.0050	1.0288	1.0320

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194021 / 33/11 KV SUB-STATION MOHA

Feeder No / Name : 203 / 11 KV NAGZARWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1524	.1886	.1848	.1905	.1905	.1905
2	.1886	.1524	.1886	.1886	.1905	.1905	.1905
3	.1867	.1905	.1886	.1886	.1905	.1905	.1905
4	.1867	.2286	.2614	.2614	.2286	.2667	.2667
5	.2614	.3048	.2987	.3734	.3048	.3048	.3429
6	.3734	.4191	.3734	.4108	.3429	.381	.4572
7	.4527	.4572	.4435	.3696	.381		.4191
8	.3361		.3326	.3326	.4191		.381
9			.3326		.3429		.2667
10	1.2803	1.1584	1.1888	1.0574	1.141	.9736	1.2498
11	1.3443		1.4022	1.3927	1.3228	1.2803	1.3717
12	1.4723	1.54	1.3443	1.4403	1.2193	1.3413	1.5684
13	1.406		1.3603	1.2003	1.3812	1.4022	1.2811
14	1.2498		1.3443	1.1561	1.3815	1.358	1.3435
15	1.3413		1.1736	.8859	1.3203	1.3717	1.2498
16	1.406	1.4443	1.4632	1.1888	1.3812	1.4198	1.3108
17	1.5181	1.6882	1.5432	1.4232	1.3935	1.5432	1.4506
18	.1905	.1905	.2058	.1905	.1524	.2103	.1524
19	.3048	.2667	.3582	.3048	.2667	.394	.3429
20	.4191	.381	.3982	.4572	.4191	.4298	.4191
21	.2286	.2667	.3658	.3048	.2667	.362	.2667
22	.2286	.2286	.2587	.1905	.2286	.3048	.2286
23	.1905	.1905	.2195	.1905	.1905	.2286	.1905
24	.1829	.1905	.1867	.1829	.1905	.1905	.1905
Max	1.5181	1.6882	1.5432	1.4403	1.3935	1.5432	1.5684
Min	.1829	.1524	.1867	.1829	.1524	.1905	.1524
Avg	.6492	.5250	.6425	.6033	.6186	.6826	.6384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 201 / 11 KV MANDAWA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0953			1.0479	
2		1.0479	1.1431		1.1431	1.1431	
3		1.1431	1.3336		1.2384	1.2384	
4		1.1431	1.4289		1.3336	1.3336	
5		1.3336	1.5242		1.5242	1.5242	
6		1.6194	1.7147		1.8099	1.8099	
7		2.0957	1.9052		2.0005		
8		2.0005	1.9052		1.9052	1.1431	
9		1.5242	1.0479		1.7147	1.7147	
18	.0953				.0953		
19	.0953	.0953		.0953	.0953		
20	.0953	.0953		.0953	.0953		.0953
21	.0953	.0953		.0953	.0953		.0953
22	.0953	.0953		.0953	.0953		.0953
23	.0953	.0953			.0953		.0953
24		.0953	.0953			1.0479	
Max	.0953	2.0957	1.9052	.0953	2.0005	1.8099	.0953
Min	.0953	.0953	.0953	.0953	.0953	1.0479	.0953
Avg	.0953	.8914	1.2193	.0953	.9458	1.3336	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430]

BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 202 / 11 KV ITKUR AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0743	.0743	.0743	.0743	.0743	.0743	.3715
2	.0743	.0743	.0743	.0743	.0743	.0743	.3715
3	.0743	.0743	.0743	.0743	.0743	.0743	
4	.0743	.0743	.0743	.0743	.0743	.0743	.0743
5	.0743	.0743	.0743	.0743	.0743	.0743	.0743
10	.8916	1.1145	.9659	1.1145	1.0402	.8916	1.3375
11	1.4118	1.2631	1.3203	1.3375	1.2631	1.1888	1.3375
12	1.4003		1.4861	1.2631	1.4861	1.2631	1.3375
13	1.6347		1.6347	1.1888	***		1.3375
14	1.6347		1.3375		1.3375		1.3375
15	1.3375		1.2631	1.1145	.8916		1.3375
16	1.6347	1.3375	1.4861		1.2631		1.3375
17	1.6347	1.4118	1.4118		1.4118		1.3375
18	.0743			.0743	.0743		
19	.0743	.0743	.1486	.0743	.0743		.0743
20	.0743	.0743	.0743	.0743	.0743		.0743
21	.0743	.0743		.0743	.0743		.0743
22	.0743	.0743	.0743	.0743	.0743		.0743
23	.0743	.0743	.0743	.0743	.0743		.0743
24	.0743	.0743	.0743	.0743	.0743	.0743	
Max	1.6347	1.4118	1.6347	1.3375	142.6465	1.2631	1.3375
Min	.0743	.0743	.0743	.0743	.0743	.0743	.0743
Avg	.6236	.3963	.6513	.4065	7.6116	.4210	.7037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 203 / 11 KV KOTHALWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1638	.0572	.2743	.0476	2.2119	2.0805
2	2.1262	1.9662	2.0005	2.1033	2.0891	2.3758	2.0805
3	2.2786	2.2119	2.2672		2.1862	2.4577	2.3482
4	2.4006	2.4577	2.5149	2.4006	2.4291	2.6216	2.3482
5	2.7435	2.7854	2.7978	2.6292	2.6825	2.9492	2.753
6	3.1855	3.195	3.0864	3.0178	3.8142	3.4408	.1619
7	3.5608	3.2769	3.4294	3.3913	3.6866	3.6866	
8	3.6885	3.6866	2.652	3.0178	3.2278	3.6046	
9	2.7435	3.2769	2.652	2.915	2.9492	3.5227	
18	.1638				.1638		
19	.1638		.1867	.1753	.1638		.1715
20	.1638	.0572	.2715	.0476	.1638		.0476
21	.1638	.0572	.2715	.0476	.1638		.0476
22	.1638		.2743	.0476	.1638		.0476
23	.1638	.0572	.2715	.0476	.1638		.1715
24	.1829	.1638	.0572	.2743		2.13	
Max	3.6885	3.6866	3.4294	3.3913	3.8142	3.6866	2.753
Min	.1638	.0572	.0572	.0476	.0476	2.13	.0476
Avg	1.5047	1.7966	1.5193	1.4564	1.6063	2.9001	1.1144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 204 / 11 KV ADHALA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.0791	.0791	.0743	.0791		.0791
2	.08	.0791	.0791	.8768	.0791	.0791	.0791
3	.08	.0791	.0791	.08	.0795	.0791	.0791
4	.0791	.0791	.0791	.08	.0791	.0791	.0791
5	.08	.0791	.0791	.08	.0791	.0791	.0791
10	.6325	.3953	.3953	.2972	.3163	.3953	.5535
11	.6325	.4744	.7202	.3953	.6325		.5535
12	.6325	.5535	.7116	.6325	.6325		.6325
13	.5535		.6325	.6325	.6325		.6325
14	.5535			.5535	.5535		.6325
15	.5535		.4801	.5535	.5535		.5535
16	.6325	.6325	.5668	.5535	.5535		.6325
17	.6325	.6325	.4801	.6325	.6325		.7116
18	.0791				.0791		
19	.0791	.0791	.081	.0791	.0791		.0791
20	.0791	.0791	.08	.0791	.0791		.0791
21		.0791	.08	.0791	.0791		.0791
22	.0791	.0791	.081	.0791	.0791		.0791
23	.0791	.0791	.081	.0791	.0791		.0791
24	.0791	.0791	.0791	.08	.0791	.0791	
Max	.6325	.6325	.7202	.8768	.6325	.3953	.7116
Min	.0791	.0791	.0791	.0743	.0791	.0791	.0791
Avg	.2998	.2224	.2702	.3114	.2728	.1318	.3163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194024 / 33/11 KV SUB-STATION ITKUR

Feeder No / Name : 205 / 11 KV ITKUR GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7087	.5373	.7392	.7164	.6535	.7316
2	.7392	.6535	.6335	.7468	.7164	.6535	.724
3	.7468	.6535	.724	.7468	.9145	.6535	.8316
4	.9335	.8402	1.1088	.924	1.2136	.8488	1.0164
5	1.2136	1.4146	1.307	1.1888	1.307	1.4146	1.2936
10	1.086	1.0059	1.2136	1.1203		.8954	.7392
11	.905	.724	.823	.823	.905		.7392
12	.724	.6268	.7468	.724	.7087		.7392
13	.6335		.7392	.5373	.7011		.724
14	.543		.7468	.5373			.724
15	.543			.5373	.5316		.724
16	.5258	.6268	.8316	.5373	.6201		.724
17	.5935	.6268		.6268	.6068		.9145
18		.9145	.924	1.1203			.924
19	1.1088	1.2136	1.0974	1.307	.8954		.8859
20	1.4632	1.307	1.2936	1.307	1.386		1.0269
21	1.1765	1.307	1.4003	1.307	1.1765		.9335
22	.9745	1.1888	1.1203	1.1088	.905		.924
23		.905	.8316	.9145	.8145		.8573
24		.7087	.724	.8402	.7164	.7468	.724
Max	1.4632	1.4146	1.4003	1.307	1.386	1.4146	1.2936
Min	.5258	.6268	.5373	.5373	.5316	.6535	.724
Avg	.8622	.9074	.9335	.8847	.8726	.8380	.8450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 201 / 11 KV GOVINDPUR GAOTHAN

GAOTHAN FEEDER

(NEW) Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.173	.181	.1715	.1707	.1715	.1715	.1791
2	.1835	.181	.1715	.1699	.1715	.1882	.1791
3	.1715	.181	.1715	.1699	.1715	.165	.181
4	.2589	.181	.1715	.1699	.1715	.2286	.181
5	.3262	.1791	.1715		.1715	.346	.1791
6	.3414	.2715	.1715	.2549	.1715	.4325	.2715
7	.4287	.2686	.1715	.1711	.2572	.4553	.2686
8	.3429	.2715	.1715	.0854	.2572	.3628	.1791
9	.2572	.1791	.1715	.0857	.1715	.3429	.1715
10	.181	.1715	.1743	.0857	.1715	.1791	.1715
11	.181	.1715	1.5604	.0857	.1903	.181	.0857
12	.181	.0857	.1758	.0857	.1886	.181	.0857
13	.181	.0857	.169	.0857	.1656	.181	.0857
14	.181	.0857		.0857	.1884	.181	.0857
15	.181	.0857	.0854	.0857	.1524	.181	.0857
16	.181		.0853	.0857	.1829	.181	.0857
17	.181	.0857	.0867		.1886	.181	.0857
18	.1829	.0857	.1739	.0857	.1715	.181	.0857
19	.2715	.1715	.2606	.1715	.2572	.2715	.1715
20	.2715	.2572	.2558	.1715	.3639	.2686	.1715
21	.181	.2572	.2561	.2572	.3669	.2715	.1905
22	.1791	.1715	.2552	.1715	.2818	.1791	.1715
23	.181	.1715	.2549	.1715	.1882	.181	.1905
24	.1715	.1715		.1715		.1879	.1715
Max	.4287	.2715	1.5604	.2572	.3669	.4553	.2715
Min	.1715	.0857	.0853	.0854	.1524	.165	.0857
Avg	.2237	.1718	.2426	.1399	.2075	.2366	.1548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 202 / 11 KV DEODHANORA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0941	.0953	.0953	.0868	.0953	1.5242	1.829
2	1.5242	1.2041	1.4289	1.0197	.8573	1.8404	2.2672
3	1.9963	1.829	1.9052	1.6994	1.4289	1.9963	2.2939
4	2.335	2.4291	2.0005	2.0485	1.5242	2.4356	2.753
5	3.0712	2.753	2.0957	2.6459	1.7147	2.5149	2.7206
6	1.9433	2.8807	2.2862	3.0693	1.9052	2.753	2.753
7	2.4387	2.915	.4763	3.0384		2.7435	2.8826
8	2.5781	2.2672		2.3632	3.4294	2.8361	2.8826
9	2.5306	2.2672		2.6673	3.2388	2.5911	2.8578
10	.0953	.0953		.0953	.0857	.0953	.0953
11	.0953	.0953		.0953	.0857	.0953	.0953
12	.0953	.0953	.0341	.0953	.0952	.0953	.0953
13	.0953	.0953		.0953	.0939	.0953	.0953
14	.0953	.0953	.0352	.0953	.0939	.0953	.0953
15	.0953	.0953	.0333	.0953		.0953	.0953
16	.0953	.0953	.034	.0953		.0953	.0953
17	.0953	.0953	.0348	.0953		.0953	.0953
18	.0953	.0953	.0521	.0953		.0953	.0953
19	.0953	.0953	.087	.0953		.0953	.0953
20	.0953	.0953	.0867	.0953	.0952	.0953	.0953
21	.0953	.0953	.0869	.0953	.0953	.0953	.0953
22	.0953		.085	.0953	.0953	.0953	.0953
23	.0953	.0953	.0853	.0953	.0953	.0953	.0953
24	.0922	.0953		.0953		.7621	.0953
Max	3.0712	2.915	2.2862	3.0693	3.4294	2.8361	2.8826
Min	.0922	.0953	.0333	.0868	.0857	.0953	.0953
Avg	.8307	.8685	.6079	.8362	.8841	.9721	1.0279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 203 / 11 KV KHAMASWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0939	.0953	.0953	.0521	.0953	.0953	.0953
2	.0918	.0953	.0953	.0521	.0953	.0953	.0953
3	.0857	.0953	.0953	.0521	.0953	.0952	.0953
4	.0862	.0953	.0953	.0868	.0953	.0953	.0953
5	.0923	.0953	.0953		.0953	.0953	.0953
6	.0952	.0953	.0953	.0695	.0953	.0951	.0953
7	.0953	.0953	.0953	.0703	.0953	.0953	.0953
8	.0953	.0953	.0953	.0512	.0953	.0953	.0953
9	.0953	.0953	.0953	.0572	.0953	.0952	.0953
10	1.0174	1.1431	1.0197	1.2384	1.2193	.6478	1.2384
11	1.5261	1.7147		1.7147	1.4588	1.3717	1.4289
12	1.5432	1.9052	1.5346	1.9052	1.5364	1.7147	1.7147
13	1.5432	1.9052		1.7147	1.5242	1.7147	1.7147
14	1.3717	1.5242	1.2803	1.7147	1.5242	1.7147	1.9052
15	1.3717	1.5242	1.3596	1.5242	1.6184	1.5432	1.9052
16	1.3717		1.3596	1.7147	1.6954	1.5432	2.0005
17	1.7147	1.5242	1.3596	1.7147	1.5337	1.7147	2.0957
18	.0953	.0953	.0522	.0953	.0953		.0953
19	.0953	.0953	.0872	.0953	.0953	.0953	
20	.0953	.0953	.0869	.0953	.0953	.0953	.0953
21	.0953	.0953	.087	.0953	.0953	.0953	.0953
22	.0953	.0953	.0854	.0953	.0857	.0953	.0953
23	.0953	.0953	.0871	.0953	.0952	.0953	.0953
24	.0919	.0953		.0953		.0953	.8573
Max	1.7147	1.9052	1.5346	1.9052	1.6954	1.7147	2.0957
Min	.0857	.0953	.0522	.0512	.0857	.0951	.0953
Avg	.5398	.5550	.4408	.6261	.5883	.5823	.7041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 204 / 11 KV JAWALA AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0919	.081	.0762	.0851		2.0287	2.5865
2	2.3106	2.1796	2.6063	2.3342		2.6699	2.6292
3	2.766	2.6429	2.9767	2.9698		2.8701	3.0064
4	2.7328	2.6978	3.0544	3.3852		2.6722	3.2476
5	3.3219	3.2206	3.344	1.6705		2.9737	3.469
6	3.9522	3.6374	3.9247	4.5557		3.8783	4.167
7	3.9461	3.9731	4.3416	4.3599	1.1812	4.2227	4.2364
8	3.8718	3.9701	3.863	4.0981	4.2486	4.2173	4.2181
9	3.8871	3.9655	3.4263	4.1648	4.2623	4.1442	4.0985
10	1.1129	.8992		.9434	.9313	1.0069	.5776
11	.081	.0762		.0762	.0857	.081	.0762
12	.081	.0762	.168	.0762	.0941	.081	.0762
13	.081	.0762	.0347	.0762	.0941	.0819	.0762
14	.081	.0762	.0348	.0762	.0953	.0819	.0762
15	.081	.0762	.0341	.0762		.0819	.08
16	.081	.0762	.0347	.0846		.0819	.0762
17	.081	.0762	.0347			.0819	.0762
18	.081	.0762	.0521			.0819	.0762
19	.081	.0762	.0872	.0762	.0701	.08	.0762
20	.081	.0998			.186	.081	.0953
21	.081	.0762	.0854		.1852	.081	.0762
22	.081	.0762	.0851		.1661	.081	.0762
23	.081	.0762	.085		.7735	.081	.0762
24	.0922	.0762		.085	1.1264	1.249	.0762
Max	3.9522	3.9731	4.3416	4.5557	4.2623	4.2227	4.2364
Min	.081	.0762	.0341	.0762	.0701	.08	.0762
Avg	1.2141	1.1816	1.4175	1.6219	.9643	1.3746	1.3886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 205 / 11 KV BORGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953		.0953	
2		.0953		.0953	
3		.0953		.0953	
4		.0953		.0953	
5		.0953		.0953	
6		.0953		.0953	
7		.0953		.0953	
8		.0953		.0953	
9		.0953	.0572	.0953	.0953
10	1.1431		1.2384		1.3336
11	2.3815		2.0957		1.6194
12	2.3815		2.0957		1.7147
13	2.2862		2.0957		1.9052
14	2.191		2.0957		1.9052
15	2.191		2.2862		2.0005
16	2.2862		2.2862		2.0005
17	1.6194		2.2862		2.0957
18	.0953		.0953		.0953
19	.0953		.0953		.0953
20	.0953		.0953		.0953
21	.0953		.0953		.0953
22	.0953		.0953		.0953
23	.0953		.0953		.8573
24	.0953		.0953		
Max	2.3815	.0953	2.2862	.0953	2.0957
Min	.0953	.0953	.0572	.0953	.0953
Avg	1.1431	.0953	1.0753	.0953	1.0669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 206 / 11 KV DEODHANORA GAOTHAN

GAOTHAN FEEDER

FEEDE Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1791	.1715	.2549	.1715	.1715	.181
2	.1726	.181	.1715	.2603	.1715	.1726	.181
3	.2761	.1791	.1715	.2638	.1715	.1888	.1791
4	.3757	.1791	.1715	.2638	.1715	.2483	.1791
5	.4696	.2686	.1715		.1715	.3426	.181
6	.5144	.4525	.1715	.3483	.3429	.5144	.4525
7	.4287	.4477	.3429	.3471		.4967	.4477
8	.4396	.362	.3429	.3372	.3429	.4287	.4525
9	.3757	.2715	.3429	.3429	.3429	.3429	.4287
10	.1791	.1715		.1715	.1905	.2686	.1715
11	.1791	.1715	.1758	.1715	.1715	.181	.1715
12	.181	.1715	.1705	.1715	.1715	.181	.1715
13	.1791	.1715	.2529	.1715	.173	.181	.1715
14	.1791	.1715	.3387	.1715	.1715	.1791	.1715
15	.181	.1715	.2606	.1715		.1791	.1715
16	.181	.1715	.2549	.1715		.181	.1715
17	.181	.1715	.2606	.1715		.1791	.1715
18	.181	.1715	.2612	.1715		.2686	.1715
19	.4477		.3467	.3429		.4477	.3429
20	.4477	.3429	.4263		.3429	.4525	.3429
21	.362	.3429	.4263	.3429	.4287	.4525	.3429
22	.2686	.3429	.4249	.3429	.4296	.3582	.381
23	.2715	.1715	.3399	.1715	.1713	.2686	.1905
24	.1713	.1715		.1715		.1835	.1524
Max	.5144	.4525	.4263	.3483	.4296	.5144	.4525
Min	.1713	.1715	.1705	.1715	.1713	.1715	.1524
Avg	.2839	.2363	.2726	.2424	.2433	.2862	.2491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194032 / 33/11 KV SUB-STATION

GOVINDPUR

Feeder No / Name : 207 / 11 KV ADLERS EXPRESS

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.0347	.0953	
2		.0953	.0879	.0953	
3		.0953	.0869	.0953	
4		.0953	.0879	.0953	
5		.0953	.0867	.0953	
6		.0953	.0879	.0953	
7		.0953	.0881	.0953	
8		.0953	.0879	.0953	
9		.0953	.0953	.0953	.0953
10	.0953	.0879	.0953		.0953
11	.0953	.0869	.0953		.0953
12	.0953	.0913	.0953		.0953
13	.0953	.0352	.0953		.0953
14	.0953	.0879	.0953		.0953
15	.0953	.0867	.0953		.0953
16	.0953		.0953		.0953
17	.0953	.0874	.0953		.0953
18	.0953		.0953		.0953
19	.0953	.0872	.0953		.0953
20	.0953	.0869	.0953		.0953
21	.0953	.0348	.0953		.0953
22		.0869	.0953		.0953
23	.0953	.087	.9907		.0953
24	.0953		.0953		
Max	.0953	.0953	.9907	.0953	.0953
Min	.0953	.0348	.0347	.0953	.0953
Avg	.0953	.0859	.1278	.0953	.0953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194054 / 33/11 KV SUB-STATION MASSA

Feeder No / Name : 202 / 11 KV MASSA AG-II FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943		.0943	
2		.0943		.0943	
3		.0943		.0943	
4		.0943		.0943	
5		.0943		.0943	
6		.0943		.0943	
7		.0943		.0943	
8		.0943			
9	.0943		.0943		.0943
10	1.5089		1.6032		1.6032
19			.0943		.0943
20			.0943		.0943
21			.0943		.0943
22			.0943		.0943
23			.0943		.0943
24		.0943		.0943	
Max	1.5089	.0943	1.6032	.0943	1.6032
Min	.0943	.0943	.0943	.0943	.0943
Avg	.8016	.0943	.3099	.0943	.3099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194054 / 33/11 KV SUB-STATION MASSA

Feeder No / Name : 203 / 11 KV MASSA GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048		.2667	
2		.3048		.2286	
3		.3429		.2667	
4		.381		.3429	
5		.4572		.381	
6		.5335		.4191	
7		.4954		.4954	
8		.4954			
9	.4572		.4572		.4954
10	.4191		.381		.4191
11			.3429		.3048
12			.2286		.2286
13			.1905		.1905
14	.2286		.2286		.1905
15	.1905		.2286		
16	.2286		.2667		.2286
17	.2286		.2667		.1905
18	.2667		.3429		.3048
19	.4572		.4191		.3429
20	.4572		.5335		.5335
21	.4954		.4954		.4954
22	.4572		.4572		.4191
23	.381		.381		.381
24		.3429		.3048	
Max	.4954	.5335	.5335	.4954	.5335
Min	.1905	.3048	.1905	.2286	.1905
Avg	.3556	.4064	.3480	.3382	.3375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194057 / 33/11 KV SUB-STATION

RAIGHAVAN

Feeder No / Name : 202 / 11 KV RANJANI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2987	.0829		.081	1.6289	1.8099
2	1.2193	1.251	1.1336	1.2955	1.1336		1.8099
3		1.307	1.2955		1.1336	1.7147	1.8099
4	1.6194	1.307	1.3765	1.4575	1.3765		1.8099
5		1.4937	1.7166		1.5384	1.8861	1.7194
6	1.8004	1.8671	1.7814	1.8004	1.5384	1.9719	1.7375
7	1.8004	1.8861	1.7814	1.8861	1.5384	1.9719	1.7147
8	1.5242	1.7661	1.4575	1.8861	1.6194	1.7147	1.7147
9	1.448	1.8004	1.5384		1.2146	1.4575	1.5775
10	1.5432				1.2146	1.2955	1.3226
11	1.8991	1.4575		1.6194	1.7147	2.0062	1.6194
12	1.8652	1.7147		1.6194	2.0576	1.8861	1.7814
13	1.7295	1.8004		1.6194	2.1434	1.6289	1.7004
14	1.6108	1.8004		1.7814	2.1434	1.5432	1.7814
15	1.4413	1.5384		1.5384	2.0576	1.5432	1.6194
16	1.7465			1.5384	2.0576	1.5432	1.6356
17	1.95			.6478		1.5432	1.6194
18		1.6194		.0838			1.6194
19		.0829		.0838		.4163	.2818
20		.0829		.0838		.4525	.2818
21	.181	.0829		.0829		.4525	.2818
22	.2715	.0829		.0829		.4525	.2818
23	.2987	.0829		.0829		.4525	
24	.0762	.2987	.0829	.0762	.0829	.6097	1.3575
Max	1.95	1.8861	1.7814	1.8861	2.1434	2.0062	1.8099
Min	.0762	.0829	.0829	.0762	.081	.4163	.2818
Avg	1.3347	1.1248	1.2247	1.0140	1.4497	1.3415	1.4299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194057 / 33/11 KV SUB-STATION

RAIGHAVAN

Feeder No / Name : 203 / 11 KV RAIGAVHAN GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3734	.4144		.4534	.2286	.3658
2	.2286	.3734	.4049	.1524	.4858		.3658
3		.3734	.4049		.4858	.2286	.3658
4	.2286	.3734	.4049	.2286	.4858		.3658
5		.4668	.4049		.4858	.2286	.4525
6	.3239	.5068	.4049	.2286	.4858	.2286	.5792
7	.3239	.463	.4049	.2429	.4858	.3048	.6001
8	.3048	.4287	.4049	.3429	.4049	.3048	.583
9	.3048		.4049			.3048	.583
10	.2572	.3429			.3239	.2286	.5087
11	.39	.2286		.2429	.2286	.4287	.2429
12	.3391	.2286		.2429	.2286	.3772	.2429
13	.3391	.2286		.2429	.2286	.2572	.2429
14	.3391	.2286		.2429	.2429	.3429	.2429
15	.3391	.2429		.2429	.2429		.2429
16	.3391			.2429	.2286		.2429
17	.2915			.2429			.2486
18	.362	.2429		.2515			.2486
19		.2486		.2486			.4973
20		.2486		.2486		.6335	.4858
21	.4163	.2486		.2486		.5068	.4858
22	.362	.2486		.4144		.362	.4858
23	.362	.4049		.4858		.362	.4858
24	.2286	.3734	.4144	.2286	.4534	.2286	.3658
Max	.4163	.5068	.4144	.4858	.4858	.6335	.6001
Min	.2286	.2286	.4049	.1524	.2286	.2286	.2429
Avg	.3200	.3274	.4068	.2643	.3719	.3268	.3971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 201 / 11 KV PADOLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3734	.3742			1.3117	1.1284
2		1.1139	1.4165			1.3614	1.3489
3		1.2727	1.4842			1.406	1.4445
4		1.3603	1.6747			1.4932	1.5244
5		1.4781	1.6933			1.6032	1.6747
6		1.8463				1.6712	1.8736
7		2.0187	2.3952			2.2222	2.2421
8		1.7584	2.2325	2.005		2.0755	1.6582
9		1.646	1.9849			1.8907	1.5966
10			.5999		.5664		.5201
11					.4145	.412	
12	.4124				.3757	.3715	.4849
13	.4045				.3361	.3333	
14	.4045				.2957	.3164	.3193
15	.3299				.2942	.3122	.296
16	.2911				.2975		
17	.3723				.4435	.2738	.3734
18	.5004					.5516	.4303
19	.7245					.7514	
20	.7468					1.0929	.9619
21	.7484					1.0374	
22	.5239				.4601	.5601	
23	.4649				.4045	.4137	
24	2.1628	.4091		.2984		1.2239	1.0179
Max	2.1628	2.0187	2.3952	2.005	.5664	2.2222	2.2421
Min	.2911	.3734	.3742	.2984	.2942	.2738	.296
Avg	.6220	1.3277	1.5395	1.1517	.3888	1.0312	1.1115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194058 / 33/11 KV SUB-STATION PADOLI

Feeder No / Name : 203 / 11 KV NAIGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5601	.5658		.5601	.5658
2		.5647	.5653		.5601	.567
3		.6224	.7567		.563	.5658
4		.9054	.944		.8488	.7514
5		1.0405			1.1374	
10	1.6518	1.2774	1.4445	1.9071	1.5638	
11	2.182			2.1172	2.0096	
12	2.3449	2.029		2.2282	1.9867	2.2156
13	2.2981			2.0494	1.323	2.323
14	2.1033	1.8233		2.0287	1.1616	2.0402
15	1.8128	1.6604		1.8233	1.5565	1.7939
16	1.9959			1.8633		
17	2.291			2.06	1.9083	1.6722
18	.6557				.5567	.5041
19	.9326				.7514	1.2235
20	1.2248				1.4075	1.2826
21	1.1225				1.5089	
22	.9008			.9719	.9749	
23	.6528			.8368	.5653	
24		.4108	.5596		.5584	.5664
Max	2.3449	2.029	1.4445	2.2282	2.0096	2.323
Min	.6528	.4108	.5596	.8368	.5567	.5041
Avg	1.5835	1.0894	.8060	1.7886	1.1317	1.2363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194063 / 33/11 KV SUB-STATION

KHAMASWAD

Feeder No / Name : 202 / 11 KV KHAMASWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4252		1.3927	1.2186	1.1443	1.3603	1.3279
2	.4252		1.3927	1.2334	1.1294	1.3603	1.3599
3	.5144		.3391	.503	.3658	.4973	.431
4	.6097		.4382	.503	.4001	.5316	.5258
5	.6668		.4763	.6443	.5316	.5895	.6097
6	.6878		.5335	.7095	.6859	.724	.6859
7	.6878		.6287	.0543	.724	.7811	.724
8	.724	.6097			.6859	.743	.743
9	.5373	.6287		.5552	.6859	.724	.6097
10	.4917	.3544	.5525	.4359	.543	.4024	
11			.362	.3391	.3155	.2947	.3189
12		.3048	.3222	.3052	.3429	.3086	
13			.3353	.3315	.2947	.2846	
14			.3149	.3086	.2572	.2688	.3403
15			.3441	.2947	.3121		.3258
16		.2629	.3506		.3121	.2543	.298
17		.3429		.3155	.2947	.2683	.3067
18		.3239		.3185	.3185		.3067
19		1.9204	1.8564	1.9766	1.7711	.3772	1.503
20		1.7004	1.7394	1.531	1.7966	1.8652	1.457
21		1.5565	1.3889	1.4842	1.6975	1.3279	1.411
22		1.4685	1.3735	1.4373	1.6512	1.4746	1.3803
23		1.4403	1.2793	1.326		1.3765	1.3803
24	.4477		1.2643	.5792	1.1591	1.3757	1.3123
Max	.724	1.9204	1.8564	1.9766	1.7966	1.8652	1.503
Min	.4252	.2629	.3149	.0543	.2572	.2543	.298
Avg	.5652	.9095	.8342	.7457	.7574	.7814	.8265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194063 / 33/11 KV SUB-STATION

KHAMASWAD

Feeder No / Name : 203 / 11 KV BANJARA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857		.104	.0953	.0943	.1149	.0947
2	.0857		.0914	.0857	.0892	.1183	.0974
3	.1326		.1086	.1715	.0926	.1217	.0857
4	.1492		.1143	.1715	.0943	.1372	.1448
5	.1638		.1524	.1844	.1143	.1619	.1715
6	.1802		.1905	.1823	.1865	.1715	.1905
7	.1619	.2286	.1524	1.4582	.2286	.2096	.2096
8	.1966		.1524	.1715	.2096	.2096	.2096
9	.096	.1265		.1524	.1905	.2096	.1524
10	.0572	.1524	.1524	.1149	.1036	.1021	.1715
11			1.2955	1.4575	1.3765	1.5223	1.5074
12		1.5074	1.2963	1.5203	1.4899	1.6518	1.4918
13			1.3123	1.3916	1.3283	1.4074	1.4582
14			1.3283	1.2308	.7145	1.2654	1.4752
15				1.1069	1.0031		1.3426
16		1.4746	1.4723	1.2163	1.2967	1.4575	1.7004
17		1.7404	1.2955	1.5384	1.3441	1.6057	1.5067
18		1.5384	.5639	1.387		1.4918	1.5337
19		.1082	.1082		.1217	.1326	.1534
20		.1715	.1353	.1783	.1353		.1227
21		.1372		.1614	.1488	.1372	.1537
22		.1353	.132	.1467	.1334	.9604	.1534
23		.1067	.1067	.1067		.1353	.1227
24	1.3148		.1067		.1067	.1296	.1067
Max	1.3148	1.7404	1.4723	1.5384	1.4899	1.6518	1.7004
Min	.0572	.1067	.0914	.0857	.0892	.1021	.0857
Avg	.2385	.6189	.4939	.6468	.4819	.6115	.5982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194064 / 33/11 KV SUB-STATION

WAGHOLI(G

Feeder No / Name : 202 / 11 KV HALADGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.4054			.4401		
4	.5213	.5792		.1905	.6859	.6249	.884
6		.7811			1.0562		
8	.9332	.8278		.2477	1.1717	.9488	.9755
10						.1905	.2896
12	.1334					.1524	.0953
13			.0953				
16	.1143		.1524	.8535	.0953		.1524
17						.1524	
18				.1905			
20	.4001			.381		.2667	.381
23						.2096	
24	.1905	.1905		.1905	.2096	.1905	
Max	.9332	.8278	.1524	.8535	1.1717	.9488	.9755
Min	.1143	.1905	.0953	.1905	.0953	.1524	.0953
Avg	.3821	.5568	.1239	.3423	.6098	.3420	.4630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194064 / 33/11 KV SUB-STATION

WAGHOLI(G

Feeder No / Name : 203 / 11 KV WAGHOLI-(G) FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2477			.2858		
4	.2858	.2477		.2858	.2858	.3429	.1905
6		.3048			.4001		
8	.362	.2667		.3048	.2858	.381	.2667
12				1.1574			1.5497
13			1.1888				
16	1.3672		1.0709	1.3717	1.3717		1.3889
17	1.6821					.5281	
18				.1905			
20				.4382		.4572	.381
23	.4382					.381	
24	.2858	.2667		.2667	.2667	.2858	.2667
Max	1.6821	.3048	1.1888	1.3717	1.3717	.5281	1.5497
Min	.2858	.2477	1.0709	.1905	.2667	.2858	.1905
Avg	.7369	.2667	1.1299	.5736	.4827	.396	.6739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194066 / 33/11 KV SUB-STATION BHOGJI

Feeder No / Name : 201 / 11 KV BHOGJI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-MAY-17	19-MAY-17
HR	Load (MW)	Load (MW)
3		.0953
11	1.8591	.08
16	1.692	
18	.1905	
24		.0953
Max	1.8591	.0953
Min	.1905	.08
Avg	1.2472	.0902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194066 / 33/11 KV SUB-STATION BHOGJI

Feeder No / Name : 202 / 11 KV BHOGJI GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	21-MAY-17
HR	Load (MW)
1	.1143
2	.1334
3	.1334
4	.1524
5	.1524
6	.2286
7	.3239
24	.1143
Max	.3239
Min	.1143
Avg	.1691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194066 / 33/11 KV SUB-STATION BHOGJI

Feeder No / Name : 203 / 11 KV PIMPALGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.6964
2			.7716
3		.4858	.7888
4	1.1498		.9156
5			.9774
6		.7811	1.5089
7			1.6766
8	1.2811	.9061	
9	1.3757		
16	.0762		
18	.2667		
24	.1905	.1905	.6274
Max	1.3757	.9061	1.6766
Min	.0762	.1905	.6274
Avg	.7233	.5909	.9953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194083 / 33/11 KV SUB-STATION MANGRUL

Feeder No / Name : 202 / 11 KV BHATSHIRPURA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1905	.1905	.1905	.1905	.1334
2	.1715	.2286	.1524	.1905	.1715	.1905	.1715
3	.1715	.2286	.1524	.1905	.1715	.1905	.1715
4	.1905	.3048	.1524	.1905	.1905	.2667	.2286
5	.2858	.381	.1905	.2286	.1905	.2667	.2096
6	.381	.381	.2667	.3048	.3429	.381	.2477
7	.3429	.4382	.3429	.381	.381	.4382	.2286
8		.4001	.3048	.381	.3239	.362	.1905
9	.2858	.3239	.2667	.3429	.2667	.2858	.1715
10	.4321	.423	.5121	.4588	.4586	.4374	.4428
11	.6081	.3704	.583	.6464	.6554	.506	.6154
12	.6081	.3048	.583	.5801		.5624	.5761
13	.6401	.4111	.4999	.4961	.6554	.4902	.4744
14	.4481	.3841	.4744	.4096	.4481	.4696	.3704
15	.4801	.4744	.502	.3605	.4481	.4938	.3749
16	.5921	.5761	.5506	.4801	.4801	.4938	.4687
17	.6097	.6401	.6718	.6478	.3913	.5376	.6958
18	.1143	.1524	.1067	.1581	.1143	.1715	.1143
19	.2667	.1905		.2858	.3048	.1905	.1905
20	.362	.2667	.4001	.3239	.381	.2286	.2286
21	.3048	.2667	.2667	.2858	.2858	.2477	.2667
22	.2858	.2286	.2286	.2286	.2667	.2286	.2667
23		.1905	.1905	.1905	.2286	.1905	.1905
24	.1905	.2096	.1905	.1905	.1905	.1905	.1143
Max	.6401	.6401	.6718	.6478	.6554	.5624	.6958
Min	.1143	.1524	.1067	.1581	.1143	.1715	.1143
Avg	.3610	.3319	.3382	.3393	.3277	.3338	.2976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

KALAM (R)S/DN[430] BU 2666

Substation No/ Name :- 194083 / 33/11 KV SUB-STATION MANGRUL

Feeder No / Name : 203 / 11 KV PIMPALGAON (D) SINGLE PHASING

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2972	.301	.301	.3467	.7621	.7748
2	.7316	.8383	.6173	.6325	.7116	.8192	.9665
3	.8802	.8383	.7499	.8642	.8288	.9012	.8886
4	1.0402	1.0288	.8745	.9717	.9945	1.1469	1.1174
5	1.2431	1.286	1.3413	1.326	1.3003	1.3927	1.4582
6	1.5261	1.5775	1.5261	1.6766	1.595	1.7204	1.7635
7	1.7101	1.7804	1.989	1.8313	1.7974	1.6575	1.7939
8		1.8652	1.4586		1.7804	1.6766	1.7695
9	1.5364		1.4091	1.4419	1.595	1.6004	1.4723
10	1.1584	.6706	1.012	.8962	1.1469	.9488	.9945
11	1.278	.9717	1.3565	1.3904	1.6108	1.1142	1.4754
12	1.4251	1.1012	1.4419	1.4582		1.1174	1.4754
13	1.4251	1.1142	.9717	1.4255	1.5089	1.2887	1.3108
14	1.2483	1.1142	1.278	1.2431	1.3108	1.2239	1.2163
15	1.2483	1.2308	1.2452	1.2742	1.1469	1.3117	1.1069
16	1.3108	1.3108	1.2929	1.3748	1.3279	1.3763	1.2803
17	1.2803	1.3923	1.4754	1.3923	1.3717	1.2929	1.4251
18	.2953	.2401	.3395	.4321	.3567	.5426	.3467
19	.4915	.4428		.4915	.4664	.6485	.5144
20	.7087	.5898	.7522	.6962	.7522	.7701	.7087
21	.6036	.5121	.6173	.6443	.6104	.7133	.6661
22	.4915	.4481	.4268	.5426	.503	.6878	.6626
23		.3658	.3612	.4748	.362	.6268	.5658
24	.3563	.3269	.301	.2972	.373	.6859	.6796
Max	1.7101	1.8652	1.989	1.8313	1.7974	1.7204	1.7939
Min	.2953	.2401	.301	.2972	.3467	.5426	.3467
Avg	1.0166	.9280	1.0060	1.0034	1.0347	1.0844	1.1014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194019 / 33/11 KV Takali-B

Feeder No / Name : 201 / 11 Takali B.

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1387	.1865		.1772	.5304	.5487
2		.6588	.567		.5316	.6588	.6068
3		.7202	.6733		.5959	.7712	.6962
4		.7545	.7362		.6516	.7716	.8669
5		.8139	.8596		.7712	.6935	.9259
6		.823	1.0029		.8505	.9259	1.0402
7		.8478	1.1218	1.0898	1.0277	1.0517	.4287
8		.7712	1.1443	1.3032	1.1104	.9326	1.1145
9		.823		1.153		.9536	1.0631
10		.1509				.1357	.1357
11		.1029		.1612		.1326	.12
12	.1357	.12		.1147		.1006	.12
13	.12	.1187				.0995	.1017
14	.1029	.1017		.1326		.4218	.0857
15	.104	.1174		.1526		.6554	.0848
16	.1372	.116		.1509		.081	.1029
17	.2058	.1341		.1658		.1006	.0995
18	.2743			.1509		.2204	.1677
19	.3294	.2721		.2401		.2321	.2321
20	.3121	.2713		.2229		.2683	.0972
21	.2804	.2374		.218	.2204	.1943	.2753
22	.208	.2401		.2035	.2254	.1989	.2374
23	.1734	.2035		.1907	.2058	.1658	.1989
24		.1387	.1949		.1949	.4144	.4578
Max	.3294	.8478	1.1443	1.3032	1.1104	1.0517	1.1145
Min	.1029	.1017	.1865	.1147	.1772	.081	.0848
Avg	.1986	.3772	.7207	.3767	.5469	.4463	.4087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194019 / 33/11 KV Takali-B

Feeder No / Name : 203 / 11 KV Borkheda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0693	.0671		.0678	.5144	.463
2		.4854	.5087		.4801	.583	.5079
3		.5144	.583		.5316	.5935	.6241
4		.5548	.5895		.543	.6935	.7202
5		.583	.6762		.6733	.7362	.7716
6		.6173	.788		.7701	.7956	.8322
7		.7461	.9088	.9602	.8682	.8669	.2401
8		.8309	.8328	.8402	.9036	.8573	.7628
9		.8669		.9391		.7956	.7716
10		.0857		.0514		.0663	.0497
11		.0693		.0678		.0509	.0486
12	.0678	.0509		.0509		.0486	.0497
13	.0686	.0514				.0486	.0497
14	.0686	.0526		.0343		.0486	.0497
15	.052			.0339		.0678	.0678
16	.052	.0509		.0514		.0497	.0648
17	.0686	.0686		.0671		.0497	.0663
18	.0857	.0537		.0686		.0819	.0838
19	.12	.116		.12		.0995	.0995
20	.1372	.1187		.1387		.1006	.1147
21	.1029	.12		.12		.0678	.1296
22	.0867	.1017		.1029	.116	.0678	.116
23	.0693	.0857		.0848	.1017	.0838	.0663
24			.0663		.0678	.4508	.4115
Max	.1372	.8669	.9088	.9602	.9036	.8669	.8322
Min	.052	.0509	.0663	.0339	.0678	.0486	.0486
Avg	.0816	.2861	.5578	.2332	.4657	.3258	.2984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 203 / 11 KV RAGHUCHIWADI AG SEPARATED AG FEEDERS HAVING SPECIAL
 FEEDER Feeder KV- 11 / DESIGN TRANSFORMER
 OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.9945	.8697
2	.9919	.9945	1.0279	.6962	.4973	1.1603	.9498
3	.9969	1.2266	1.1822	.9945	1.326	1.326	1.0286
4	1.025	1.2266	1.2944	.9945	1.326	1.3923	1.1003
5	1.0276	1.2266	1.4255	.9945	1.326	1.3923	1.2389
6	1.0455	1.326	1.5003	1.4255	1.326	1.3923	1.3108
7	1.2507	1.3923		1.4586	1.3923	1.3923	1.4752
8	1.2793	1.3923	1.4706	1.326	1.3923	1.4586	1.5617
9	1.2635	1.3923	1.4742	1.326	1.4255	1.4586	1.3201
24						.4973	
Max	1.2793	1.3923	1.5003	1.4586	1.4255	1.4586	1.5617
Min	.9919	.9945	1.0279	.6962	.4973	.4973	.8697
Avg	1.1101	1.2722	1.3393	1.1520	1.2514	1.2465	1.2061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 205 / 11 KV GAOSUD GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1126	.1509	.132	.1097	.1097	.1097	.1128
2	.1123	.1132	.1128	.1097	.1097	.1097	.0943
3	.112	.1132	.1129	.1097	.1097	.1097	.0945
4	.112	.132	.1125	.128	.1097	.1097	.112
5	.1126	.1509	.1311	.128	.1097	.1097	.1316
6	.1507	.1132	.1463	.1097	.1097	.0914	.15
7	.1506	.1132		.1097	.1097	.0914	.1882
8	.1501	.1132	.1318	.1097	.1097	.0914	.1698
9	.1126	.1132	.1132	.1097	.11	.0914	.1506
10	.1126	.0945	.0943	.0921	.0918	.0914	.1097
11	.1126	.0948	.0914	.0733	.0916	.0913	
12		.1134	.0729	.0732	.0914		.0911
13	.1126	.0943	.0724	.0732	.0916	.0732	.0914
14	.1126	.0941	.0732	.073	.0736		.0917
15	.1126	.1132	.073	.0732		.0914	.0922
16	.1126	.0948	.0909	.0913	.0732	.1101	.0931
17	.1126		.1143		.0915	.1095	.0934
18	.1314	.1867		.1097	.1097	.1287	.1303
19	.1501	.1829	.1463	.1463		.1848	.1829
20	.1501		.1463	.1463	.1463	.1863	.1839
21	.1501	.1848	.1463	.1463	.1463	.168	.1667
22	.1501	.168	.1463	.1463	.1463	.1498	.168
23	.1501	.1506	.1463	.1463	.1463	.1506	
24	.132	.1501	.1509	.128	.1463	.1463	
Max	.1507	.1867	.1509	.1463	.1463	.1863	.1882
Min	.112	.0941	.0724	.073	.0732	.0732	.0911
Avg	.1273	.1289	.1162	.1105	.1106	.1180	.1285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 207 / 11 KV WALGUD GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.1143	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0762	.0953	.0953	.0953	.0953
4	.0762	.0953	.0762	.0953	.0953	.0953	.0762
5	.0953	.0953	.0953	.0953	.0953	.0953	.0953
6	.1143	.0953	.1143	.1143	.0953	.0953	.1143
7	.0953	.0953		.1143	.0953	.0953	.1334
8	.0953	.0953	.1143	.1143	.0953	.0953	.1143
9	.0953	.9526	.0953	.1143	.0953	.0953	.1143
10	.0953	.0762	.0953	.0762	.0953	.0953	.0762
11	.0953	.0762	.0762	.0762	.0762	.0762	
12		.0762	.0572	.0762	.0762		.0762
13	.0953	.0762	.0572	.0762	.0762	.0762	.0762
14	.0953	.0572	.0572	.0762	.0762		.0762
15	.0953	.0572	.0572	.0762		.0762	.0762
16	.0953	.0762	.0762	.0762	.0762	.0953	.0762
17	.0953		.0953		.0762	.0953	.0762
18	.1143	.1143		.1143	.0953	.0953	.0953
19	.1143	.1334	.1143	.1143	.1143	.1143	.1334
20	.1143		.1143	.1143	.1143	.1334	.1143
21	.1143	.1143	.1143	.1143	.1143	.1143	.1143
22	.1143	.1143	.1143		.1143	.1143	.0953
23	.0953		.1143	.1143	.0953	.0953	
24	.0953	.0953	.0953	.1143	.1143	.0953	
Max	.1143	.9526	.1143	.1143	.1143	.1334	.1334
Min	.0762	.0572	.0572	.0762	.0762	.0762	.0762
Avg	.0994	.1325	.0909	.0979	.0953	.0970	.0962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194026 / 33/11 KV POHNER SUB-STATION

Feeder No / Name : 208 / 11 KV POHNER GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	.3239	.3429	.3048	.3048	.2858
2	.3048	.3429	.2858	.3429	.3048	.3048	.2858
3	.2286	.3429	.2858	.3429	.3048	.3048	.3048
4	.2286	.3429	.2477	.3429	.3048	.3048	.3239
5	.3048	.3429	.3429	.3048	.3048	.3048	.3429
6	.3429	.3429	.4001	.3048	.3048	.2667	.4382
7	.3429	.3429		.3048	.3048	.2667	.381
8	.3048	.3048	.4572	.3048	.3048	.2667	.3239
9	.2286	.3048	.4382	.3048	.3048	.2667	.3239
10	.1905	.2286	.381	.1524	.1905	.1905	.1905
11	.1905	.1905	.1524	.1524	.0381	.1524	
12		.1905	.1524	.1524	.1524		.1905
13	.2286	.1524	.1524	.1524	.1524	.1524	.1524
14	.2286	.1334	.1524	.1524	.1524		.1524
15	.2286	.1334	.1524	.1524		.1524	.1524
16	.2286	.1524	.1524	.1524	.1524		.1524
17	.2286		.1524		.1524	.1524	.1524
18	.3048	.4001		.1905	.2286	.2286	.2667
19	.381	.4382		.381	.381	.4001	.4382
20	.381		.381	.381		.4382	.4572
21	.381	.4191	.381	.381	.381	.4001	.4572
22	.381	.4382	.381	.3429	.381	.3429	.4763
23		.4191	.381	.3429	.381	.3429	
24	.3429	.3429	.381	.381	.3048	.3048	
Max	.381	.4382	.4572	.381	.381	.4382	.4763
Min	.1905	.1334	.1524	.1524	.0381	.1524	.1524
Avg	.2858	.3022	.2921	.2766	.2632	.2785	.2976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 201 / 11 KV BEMBALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6668	.5426	.5087	.6097	.743	.5716
2	.6859	.6668	.5087	.5426	.5716	.724	.5716
3	.5716	.6668	.5087	.5935	.5525	.743	.5716
4	.5716	.6668	.5426	.5935	.5525	.724	.5716
5	.6097	.5716	.5935	.5935	.5716	.6668	.6097
6	.6668	.5716	.5935	.5426	.6097	.6097	.6478
7	.724	.6097	.5935	.5087	.6097	.6097	.6097
8	.6668	.5716	.5087	.4239	.4763	.5144	.5716
9	.6097	.5716	.5426	.4239	.4763	.5335	.5335
10	.5716	.4763	.5596	.5087	.6668	.6668	.4763
11	.6668	.5087	.6783	.8383	.8002	.7621	.8954
12	.7621	.5935	.763	.7811	.8573	.7621	.8383
13	.8573	.6783	.763	.8573	.8573	.7811	.8573
14	.9145	.6783	.7461	.7621	.9526	.8383	.8954
15	.9526	.7122	.7291	.9145	1.0288	.8573	.8383
16	.8954	.7461	.7291	.9526	1.0669	.8573	.9526
17	.8573	.7461	.7291	1.0479	.9907	.8002	.8954
18	.4763		.5087	.4763	.5716	.4763	.5716
19	.5716		.5765	.7621	.8002	.5716	.6097
20	.6668	.6613	.6443	.8573	.8192	.724	.7621
21	.7621	.6783	.6783	.8383	.8383	.8383	.7811
22	.7621	.6952	.6783	.724	.8192	.8002	.724
23	.724	.6443	.5935	.7049	.743	.7621	.7049
24	.6859	.724	.5935	.5087	.6668	.7049	.7621
Max	.9526	.7461	.763	1.0479	1.0669	.8573	.9526
Min	.4763	.4763	.5087	.4239	.4763	.4763	.4763
Avg	.7049	.6412	.6210	.6777	.7295	.7113	.7010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 205 / 11 KV Ambewadi GaothAn

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0678	.0509	.0762	.0572	.0572
2	.0572	.0572	.0848	.0509	.0762	.0572	.0572
3	.0572	.0572	.1017	.0678	.0762	.0572	.0572
4	.0572	.0572	.1017	.0678	.0762	.0572	.0572
5	.0762	.0762	.1187	.0848	.0953	.0953	.0762
6	.0953	.0953	.1017	.0848	.0953	.0953	.0953
7	.0762	.0953	.0848	.0678	.0953	.0953	.0762
8	.0762	.0572	.0848	.0678	.0762	.0762	.0762
9	.0762	.0381	.0678	.0509	.0762	.0572	.0572
10	.0381	.0191	.0339	.0339	.0572	.0381	.0381
11	.0381	.0164	.0339	.0381	.0381	.0381	.0381
12	.0381	.0339	.0339	.0381		.0381	.0381
13	.0381	.0339	.0339	.0381	.0381	.0381	.0381
14	.0381	.0339	.0339	.0381	.0381	.0381	.0381
15	.0381	.0339	.0339	.0381	.0381	.0381	.0381
16	.0381	.0339	.0339	.0381	.0381	.0381	.0381
17	.0381	.0339	.0509	.0381	.0381	.0381	.0381
18	.0381		.0678	.0381	.0381	.0381	.0381
19	.0572		.0848	.0953	.1143	.0572	.0572
20	.0762	.0848	.0848	.0953	.1143	.0762	.0953
21	.0762	.0848	.0848	.0953	.0953	.0762	.0953
22	.0762	.0848	.0848	.0762	.0953	.0572	.0953
23	.0762	.0678	.0678	.0762	.0572	.0572	.0572
24	.0572	.0572	.0678	.0678	.0762	.0572	.0572
Max	.0953	.0953	.1187	.0953	.1143	.0953	.0953
Min	.0381	.0164	.0339	.0339	.0381	.0381	.0381
Avg	.0580	.0550	.0685	.0599	.0704	.0572	.0588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194027 / 33/11 KV BEMBALI S/SN

Feeder No / Name : 207 / 11 KV Vtthalwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.1017	.1017	.0762	.0953	.0762
2	.0762	.0762	.1017	.0848	.0762	.0953	.0762
3	.0762	.0762	.1017	.0848	.0762	.0953	.0762
4	.0762	.0762	.1187	.1017	.0953	.1143	.0762
5	.0953	.0953	.1187	.1017	.1143	.1334	.0953
6	.1143	.1334	.1357	.1187	.1334	.1334	.0953
7	.1334	.1524	.1357	.1187	.1334	.1334	.1143
8	.1524	.0953	.1526	.1187	.1143	.0953	.1143
9	.1143	.0762	.1357	.1017	.1143	.0953	.0953
10	.2858	.381	.39	.407	.4763	.381	.2858
11	.5335	.4239	.4239	.5335	.4954	.4572	.5716
12	.5716	.4748	.4748	.4954	.4763	.4954	.5144
13	.6097	.4748	.4748	.5144	.4572	.5144	.4763
14	.6478	.5087	.5087	.5335	.4572	.5335	.4954
15	.6097	.5426	.5087	.5335	.4763	.5335	.5144
16	.5716	.5765	.5256	.4763	.4954	.5716	.5335
17	.5716	.6104	.5256	.4763	.5144	.5716	.4763
18			.5256	.0762	.0572	.0572	.0762
19	.1143		.1187	.1524	.1524	.0953	.0953
20	.1334	.1187	.1187	.1524	.1524	.1334	.1334
21	.1334	.1017	.1187	.1334	.1334	.1524	.1143
22	.1143	.0848	.1187	.1334	.1143	.1334	.0953
23	.1143	.0848	.1187	.1143	.1143	.1143	.0953
24	.0762	.0953	.0848	.1017	.0953	.0953	.0953
Max	.6478	.6104	.5256	.5335	.5144	.5716	.5716
Min	.0762	.0762	.0848	.0762	.0572	.0572	.0762
Avg	.2609	.2425	.2558	.2403	.2334	.2429	.2247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194036 / 33/11 KV KESHEGAON S/S

Feeder No / Name : 201 / 11 KV KESHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.8671	1.6632	1.2803	1.9433		
24					1.3717	.6097
Max	1.8671	1.6632	1.2803	1.9433	1.3717	.6097
Min	1.8671	1.6632	1.2803	1.9433	1.3717	.6097
Avg	1.8671	1.6632	1.2803	1.9433	1.3717	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194036 / 33/11 KV KESHEGAON S/S

Feeder No / Name : 202 / 11 KV KESHEGAON GOATHAN
FEEDER Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	16-MAY-17	17-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.4481		
16	.1844			
18			.208	
23	.3749		.3437	
24		.3437		.3437
Max	.3749	.4481	.3437	.3437
Min	.1844	.3437	.208	.3437
Avg	.2797	.3959	.2759	.3437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194036 / 33/11 KV KESHEGAON S/S

Feeder No / Name : 203 / 11 KV BAMNI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10				1.5432			
16	2.0576	1.8122		1.6632	1.7833	1.6309	1.8176
23		.048				.048	
24			.048				.048
Max	2.0576	1.8122	.048	1.6632	1.7833	1.6309	1.8176
Min	2.0576	.048	.048	1.5432	1.7833	.048	.048
Avg	2.0576	.9301	.048	1.6032	1.7833	.8395	.9328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194047 / 33 KV WADGAON (S)

Feeder No / Name : 203 / 11 KV BAVI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4846		.4929	.4934	.4956	.4676	.4686
2	.4311		.4707	.4733	.4635	.4609	.4604
3	.3448		.4812	.4707	.4423	.4578	.4419
4	.4291		.5104	.5173	.4568	.4568	.4887
5	.5432		.5921	.7656	.5186	.5197	.5548
6	.8243		.8215	.8364	.8392	.7862	.8029
7	.7553		.8075	.7385	.8075	.7862	.8093
8	.7452		.7299	.64	.696	.7106	
9	.7283		.6028	.4897	.5098	.5542	
10	1.2657		1.1145	1.0392	1.1145	1.126	
11	1.3539		1.3929	1.2709	1.3525	1.4103	
12	1.5185		1.4291	1.3136		1.4479	
13	.4367		1.4204	1.2761	1.3443	1.2748	
14	.6584		1.2484	1.1611	1.3443	1.2136	
15	1.307		1.3096	1.1799	1.3457	1.4364	
16	1.5232		1.4046	1.2161	1.3484	1.432	
17		1.4032	1.5623	1.4132	1.4233	1.4406	1.4922
18		.4892	.4795	.4907	.3948	.4692	.5057
19		.7793	.8162	.7378	.8579	.7057	.7956
20		.729	.7704	.8368	.8184	.7662	.7888
21		.6121	.7804	.7004	.6148	.7019	.6457
22		.5803	.6155	.6195	.5072	.6372	.4934
23	.502	.5298	.5287	.5316	.4886	.5258	.4411
24	.502		.5004	.4961	.5188	.4707	.4886
Max	1.5232	1.4032	1.5623	1.4132	1.4233	1.4479	1.4922
Min	.3448	.4892	.4707	.4707	.3948	.4568	.4411
Avg	.7974	.7318	.8701	.8212	.8132	.8441	.6452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194052 / 33 KV S/SN ,RUIBHAR

Feeder No / Name : 203 / 11 KV Ruibhar Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.2134	.2241	.2058	.2263	
2		.2058	.2134	.2241	.2058	.2263	
3	.2058	.2058	.2134	.2241	.2058	.2263	
4	.2058	.2401	.2134	.2241	.2058	.2641	
5	.2401	.2743	.2134	.2614	.2401	.2587	
6	.2743	.3086	.2439	.2987	.2743	.2926	.1829
7	.2743	.2743		.2987	.3086	.2957	
8	.2401	.2401		.2987	.2401	.2561	
9	.2401	.2058	.2987	.2241	.1715	.2195	
10	.1543	.1524	.2241	.1372	.1494	.1524	.2241
11	.1715	.1524	.1867	.1372	.1509	.1524	.1867
12	.1372	.1524	.1494	.1372	.1509		.1867
13	.1372	.1524	.1494	.1372	.1509		.1867
14	.1372	.1524	.1494		.1509		.1867
15	.1715	.1524	.1867				.1867
16	.1372	.1524	.1867	.1543	.1509		.1867
17	.1715	.1524	.2241	.1543	.1478		.1867
18	.1715	.1524	.2614	.1543	.2218		.2641
19	.2743	.2134	.2987	.2743	.3018		.2614
20		.2134	.3361	.3086	.3696		.3395
21	.3086	.2743	.3361	.2743	.3018		.2957
22	.2401	.2743	.3361	.2743	.2641		.2587
23	.2058	.2134	.2614	.2401	.2263		.2218
24	.2439	.2058	.2134	.2614	.2058	.2263	
Max	.3086	.3086	.3361	.3086	.3696	.2957	.3395
Min	.1372	.1524	.1494	.1372	.1478	.1524	.1829
Avg	.2068	.2053	.2322	.2238	.2174	.2331	.2237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 201 / 11 KV Ambejawalge Ag SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.0608		.0517	.0762	.0592	
2	.0633	.0614		.0517	.0762	.0598	
3	.0633	.0623	.0658	.0517	.0762	.0612	
10	1.0185	.7433	1.4486	1.5013	1.0255	1.0334	
11	1.2727	1.6907	1.0334	1.3763	1.4284	1.2271	1.3279
12		1.764	1.0334	1.3916	1.4217	1.2271	1.4243
13	1.2833	1.5043	1.0334	1.1574	1.2351	.1163	1.3123
14	1.3491	1.5043	.93	1.1574	1.1646	.9042	1.2803
15	1.2818	1.4998	.9042	1.1574	1.1744	.9042	1.1248
16	1.1974	1.3169	1.0334	1.186	1.1216	1.0334	1.2186
17	1.136		1.098	1.186	1.1016	1.085	.0762
18	.0571	.0659	.0258	.0762	.0604	.0258	.0762
19	.0599		.0517	.0762	.0604	.0517	
20	.0606		.0517	.0381	.0598	.0498	.0762
21	.0601		.0517	.0762	.0604	.0724	.0762
22	.0606		.0517	.0762	.0613		.0762
23	.0614	.0659	.0517	.0762	.061	.0749	.0762
24	.0633	.0626	.0652	.0517	.0762	.0665	.0424
Max	1.3491	1.764	1.4486	1.5013	1.4284	1.2271	1.4243
Min	.0571	.0608	.0258	.0381	.0598	.0258	.0424
Avg	.5383	.8002	.5581	.5966	.5745	.4736	.6298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 202 / 11 KV Ghatangri Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0427			.0635	.0518	1.2087	
2	.9869	1.2337		.0635	1.1888	1.2163	1.9776
3	.9869	1.3138		.0635	1.1888	1.2269	2.2131
4	1.0151	1.3077			1.3094	1.2102	1.9491
5	1.3077	1.5091			1.475	1.3781	2.1094
6	1.3889	1.6944	1.4502		1.6766	1.5546	2.0729
7	1.5074	1.7613	2.3972	1.7457	2.0081	1.9136	2.1283
8	1.4746	1.6309	2.2099	1.9044	1.6461	1.8299	1.54
9	1.1883	1.6404	1.8765	1.9044	1.5813	1.6042	2.1695
17							.0457
18			.0317	.0762	.0585	.0159	.0457
19	.0642		.0635	.0442	.0598	.0635	
20	.0638		.0635	.0442	.0604		.0457
21	.0613		.0635	.0427	.0613	.066	.0457
22	.0626		.0635	.0427	.0638		.0457
23	.063		.0635	.0518	.0635	.0502	.0457
24	.0427			.0635	.0518	1.1706	.0509
Max	1.5074	1.7613	2.3972	1.9044	2.0081	1.9136	2.2131
Min	.0427	1.2337	.0317	.0427	.0518	.0159	.0457
Avg	.6837	1.5114	.8283	.4700	.7841	1.0363	1.099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 203 / 11 KV Sonegaon Ag. SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0319		.0321	.0381	.0313	
2	.0381	.032		.0321	.0381	.0311	
3	.0381	.0321	.0751	.0321	.0381	.0317	
7				.0321			
9							.0363
10	1.2134	1.6481	1.5821	1.2735	1.1523	1.4455	
11	1.5309	1.5802	1.5258	1.3927	1.5127	1.3563	
12		1.8167	1.5258	1.4746	1.4452	1.5258	1.5581
13	1.4201	1.7997	1.3652	1.3763	1.3016	1.5258	1.5249
14	1.4934	1.1712	1.3652	1.3927	1.2423	1.1564	1.4918
15	1.4318	1.6514	1.4455	1.3763	1.2735	1.2046	1.4752
16	1.3555	1.2518	1.6061	1.3763	1.2289	1.2046	1.3916
17	1.4502		1.6061	1.3763	1.3171	1.5258	.0381
18	.0317	.0729	.0321	.0572	.0319	.0321	.0381
19	.0324		.0321	.0381	.032	.0321	
20	.0325		.0321	.0381	.0323		
21	.0372		.0321	.0381	.0325	.0368	.0381
22	.0374		.0321	.0381	.0328		.0381
23	.0325	.005	.0321	.0381	.0325		.0381
24	.0381	.032	.0658	.0321	.0381	.0332	.0735
Max	1.5309	1.8167	1.6061	1.4746	1.5127	1.5258	1.5581
Min	.0317	.005	.0321	.0321	.0319	.0311	.0363
Avg	.6030	.8558	.7722	.6025	.6011	.7449	.6452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 204 / 11 KV Ambejawalga Gaothan

GAOTHAN FEEDER

Fee Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1127	.1498	.1126	.1143	.1134	.1004
2	.1132	.1121	.0793	.1126	.1143	.1129	.0995
3	.1132	.1125	.1846	.1126	.1143	.1121	.1004
4	.1132	.112	.1498	.1501	.1137	.1127	.1
5	.132	.1501	.1827	.1501	.1327	.1504	.0913
6	.1698	.188	.1701	.1689	.1509	.1854	.1256
7	.1698	.151	.1498	.1877	.1509	.1858	.1964
8	.1509	.1497	.1004	.1501	.132	.1475	.0629
9	.128	.1119	.1497	.1126	.132	.1495	.0552
10	.1093	.0642	.1656	.0749	.1126	.1126	.0549
11	.1101	.093	.1314	.0924	.1124	.1126	.0732
12		.0751	.1126	.0924	.1119	.0938	.1097
13	.0741	.0751	.1126	.0934	.0745	.0938	.1097
14	.0744	.0823	.1126	.0934	.0748	.0938	.0914
15	.074	.0936	.1126	.0934	.0726	.0938	.0905
16	.0745	.0988	.1126	.0934	.0722	.1126	.0905
17	.069		.1126	.112	.0711	.1126	.1086
18	.1021	.1501	.1314	.1174	.1057	.1314	.1463
19	.1816	.1877	.2252	.1595	.1762	.1689	.1646
20	.2202		.2064	.181	.2209	.2193	.2561
21	.1859	.1813	.1501	.1991	.1852	.1248	.1829
22	.1494	.1471	.1314	.1867	.1494		.1886
23	.1124	.0099	.1126	.1307	.1126	.1462	.132
24	.1132	.1123	.1471	.1126	.1143	.1132	.1503
Max	.2202	.188	.2252	.1991	.2209	.2193	.2561
Min	.069	.0099	.0793	.0749	.0711	.0938	.0549
Avg	.1241	.1168	.1414	.1287	.1217	.1304	.1200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 205 / 11 KV Ghatangri Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0741	.0781	.0713	.056	.074	.1103
2	.056	.0742	.0989	.0713	.0566	.0745	
3	.056	.0748	.1137	.0713	.0566	.0745	.1014
4	.0747	.0747	.1448	.0713	.0566	.0749	.1471
5	.0754	.1124	.1821	.1069	.0943	.1125	.1471
6	.132	.1509	.0991	.1425	.1132	.1478	.184
7	.1886	.15		.1425	.1494	.1475	.1648
8	.132	.1131	.1498	.1069	.1307	.1468	.1004
9	.0924	.0744	.1498	.0713	.056	.0744	.0977
10	.0554	.0492	.1637	.0562	.0359	.0534	.0549
11	.0369	.0558	.0713	.0686	.0361	.0534	.0549
12		.0658	.0713	.0514	.0363	.0534	.0549
13	.0367		.0534	.052	.0364	.0356	.0549
14	.0363	.0658	.0356	.0514	.036	.0534	.0549
15	.0369	.0375	.0356	.0514	.0367	.0534	.0549
16	.073	.0735	.0534	.052	.0364	.0713	.0549
17	.034		.0713	.052	.0362	.0713	.0914
18	.0306	.0658	.0891	.1061	.073	.0713	.0934
19	.1111	.0989	.1425	.1433	.1095	.1247	.1307
20	.1475		.1425	.1448	.1457	.0867	.1698
21	.1117	.1126	.1069	.1086	.1454	.1154	.0754
22	.0739	.0659	.0713	.0924	.0738		.0754
23	.0748	.0484	.0713	.0739	.0735	.0728	.0754
24	.0732	.0745	.0728	.0713	.056	.0738	.0735
Max	.1886	.1509	.1821	.1448	.1494	.1478	.184
Min	.0306	.0375	.0356	.0514	.0359	.0356	.0549
Avg	.078	.0815	.0986	.0846	.0723	.0833	.0966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194067 / 33/11 KV Ambejawalga

Feeder No / Name : 206 / 11 KV Sonegaon Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0791	.0742	.0636	.0885	.0867	.0727	.1471
2	.0829	.0747	.1103	.0885	.0886	.0722	.1004
3	.0905	.0751	.0987	.0885	.0886	.0715	.1
4	.0905	.0756	.1648	.1062	.0886	.0738	.1296
5	.0934	.1513	.1483	.1416	.1063	.148	.0815
6	.1494	.1896	.1648	.177	.1448	.1861	.1585
7	.2054	.1882	.1821	.177	.1646	.1869	.1507
8	.2033	.1886		.1239	.1646	.1781	.1839
9	.1267	.1873	.0989	.1062	.1307	.1111	.0998
10	.0905	.075	.1978	.0562	.107	.0885	.1417
11	.0726	.0522	.1062	.0526	.0715	.0708	.0532
12		.0644	.0885	.0526	.0358	.0531	.0532
13	.0719	.0795	.0708	.0693	.0359	.0531	.0532
14	.0361	.0937	.0708	.0693	.0719	.0531	.0532
15	.0363	.0937	.0708	.0686	.0729	.0531	.0532
16	.0742	.0988	.0708	.0693	.0726	.0708	.0532
17	.0623		.0885	.0693	.0722	.0708	.0514
18	.094	.0939	.1062	.0655	.0716	.1062	.0857
19	.1449	.0749	.2124	.1387	.1791	.1239	.1509
20	.1831		.177	.1638	.1804	.2206	.1949
21	.146	.0938	.1416	.1475	.1806	.1267	.1772
22	.1099	.0659	.1062	.125	.1465		.1372
23	.1105	.1093	.1062	.1094	.111	.1041	.1029
24	.0791	.0738	.0735	.0885	.0867	.0707	.0887
Max	.2054	.1896	.2124	.177	.1806	.2206	.1949
Min	.0361	.0522	.0636	.0526	.0358	.0531	.0514
Avg	.1058	.1033	.1182	.1018	.1066	.1029	.1084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (R) S/DN[426] BU 2615

Substation No/ Name :- 194088 / 33/11 KV CHILWADI SUB-

STATION

Feeder No / Name : 201 / 11 KV CHILWADI AGRL.

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.2117	1.1016	1.2275	1.2432	1.2747	1.229	1.1975
11	1.2275	1.2904	1.3534	1.3534	1.4478	1.4338	1.2132
12		1.4006	1.196	1.3849	1.2904	1.418	1.229
13	1.4163	1.2904	1.2275	1.3062	1.2747	1.4496	1.2605
14	1.4163	1.2904	1.1645	1.0858	1.2747	1.3708	1.292
15	1.4321	1.2747	1.2117	1.1645	1.3376	1.3865	1.3077
16	1.4478	1.2747	1.3062	1.2432	1.4635		1.3235
17	1.4112		1.3376	1.4321	1.5422	1.2762	1.3235
Max	1.4478	1.4006	1.3534	1.4321	1.5422	1.4496	1.3235
Min	1.2117	1.1016	1.1645	1.0858	1.2747	1.229	1.1975
Avg	1.3661	1.2747	1.2531	1.2767	1.3632	1.3663	1.2684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 202 / 11 KV NEHARU CHOWK FEEDER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.6371	.6539	1.1401	.7712	.7164	.823	.8356
16	.945	.9145	1.0898	.8848	.7316	.9831	.9175
19	1.1126	1.1797	1.3435	1.2742	1.2378	.945	1.1279
24	.8688	.9667	.8383	.8993	.8173	.8684	.8688
Max	1.1126	1.1797	1.3435	1.2742	1.2378	.9831	1.1279
Min	.6371	.6539	.8383	.7712	.7164	.823	.8356
Avg	.8909	.9287	1.1029	.9574	.8758	.9049	.9375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 203 / 11KV DARGA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.0364	1.0212		1.0898	1.1401	1.0814	1.065
16	1.0364	1.0364		1.0486	1.0159	1.1142	1.0322
19	1.4083	1.2944	1.2498	1.2955	1.0974	1.2616	1.3763
24	1.1126	1.1584	1.1904	1.0822	1.2742	1.2717	1.0669
Max	1.4083	1.2944	1.2498	1.2955	1.2742	1.2717	1.3763
Min	1.0364	1.0212	1.1904	1.0486	1.0159	1.0814	1.0322
Avg	1.1484	1.1276	1.2201	1.1290	1.1319	1.1822	1.1351

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 204 / 11KV TER FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.9556	.9724	.7316	.9724	.9297	.9175	.8688
16	.6097	.2606	.9389	.6642	.7373	.7373	.6249
19	.9175	.3963	.9145	.9831	.6859	.9724	.8886
23		.7042					
24	.7545	.6401	.6097	.7164	.8551	.852	.6874
Max	.9556	.9724	.9389	.9831	.9297	.9724	.8886
Min	.6097	.2606	.6097	.6642	.6859	.7373	.6249
Avg	.8093	.5947	.7987	.8340	.802	.8698	.7674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 205 / 11KV UPLA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.1401	1.1401	1.0364	1.0822	1.0364	1.1233	1.0978
16	1.1888	1.1469	1.1126	1.1142	1.1904	1.0669	1.1305
19	1.2346	1.3565	1.3599	1.3077	1.1961	1.2616	1.0978
24	1.1126	1.3927		1.4922	1.3565	1.4746	1.3927
Max	1.2346	1.3927	1.3599	1.4922	1.3565	1.4746	1.3927
Min	1.1126	1.1401	1.0364	1.0822	1.0364	1.0669	1.0978
Avg	1.1690	1.2591	1.1696	1.2491	1.1949	1.2316	1.1797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 206 / 11 KV VIP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3963	.4268	.4588	.4725	.442	.4359	.426
16	.4915	.442	.4268	.4862	.5182	.4572	.4268
19	.6405	.5735	.6036	.5487	.5407	.5407	.5571
24	.362	.4054	.4115	.5487		.5182	.503
Max	.6405	.5735	.6036	.5487	.5407	.5407	.5571
Min	.362	.4054	.4115	.4725	.442	.4359	.426
Avg	.4726	.4619	.4752	.5140	.5003	.488	.4782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 209 / 11 kv New Shivaji Chouk SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.9281	1.8138	1.829	1.8679	2.0287	1.7528	1.933
16	2.4813	2.4926	2.1491	2.4143	2.2611	2.5415	2.0972
19	2.7778	2.5987	2.7566	2.649	2.6873	2.5149	2.6216
24	2.0271	2.1491	2.4981	2.7046	2.3472	2.4905	2.3807
Max	2.7778	2.5987	2.7566	2.7046	2.6873	2.5415	2.6216
Min	1.9281	1.8138	1.829	1.8679	2.0287	1.7528	1.933
Avg	2.3036	2.2636	2.3082	2.4090	2.3311	2.3249	2.2581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194001 / 33KV S/S AAMRAI O'BAD

Feeder No / Name : 211 / New CollecTtor Office

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0423	.0423	.0423	.0282	.0457	.0305	.0457
16	.2294	.1829	.2294	.1981	.2134	.1829	.0572
19	.132	.1143	.0947	.1147	.08	.08	.0705
23						.1829	
24	.0533	.0705	.0564	.0412	.0714	.04	.0406
Max	.2294	.1829	.2294	.1981	.2134	.1829	.0705
Min	.0423	.0423	.0423	.0282	.0457	.0305	.0406
Avg	.1143	.1025	.1057	.0956	.1026	.1033	.0535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 201 / 11 KV MIDC _I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267			.1448			.181
2	.1294			.1448			.181
3	.1294			.1448			.181
4	.1294			.1448			.181
5	.1294			.1448			.2172
6	.1294			.1448			.2172
7	.1294			.181			.2172
8	.1829			.2172			.2172
9		.1086			.2172	.2926	
10		.1448			.2896	.4344	
11		.1448			.2896	.2715	
12		.1448			.2896	.2561	
13		.1448			.2534	.2561	
14		.1448			.2896		.2926
15		.1086			.2896	.2743	.2926
16					.2896	.2926	.2896
17			.2896			.2896	.2378
18			.2896			.2172	.1829
19			.2172			.2172	.1829
20			.1448			.2353	.1663
21			.1448			.2172	.1478
22			.1448			.181	.1109
23			.1448			.181	
24	.1254			.1448			.181
Max	.1829	.1448	.2896	.2172	.2896	.4344	.2926
Min	.1254	.1086	.1448	.1448	.2172	.181	.1109
Avg	.1346	.1345	.1965	.1569	.2760	.2583	.2043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 202 / 11 KV DNYANESHWAR TEMPLE SHEDDABLE URBAN
TOWN Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5384			1.576			1.5043
2	1.5384			1.5043			1.5043
3	1.5384			1.4327			1.4327
4	1.448			1.4327			1.3611
5	1.3756			1.3611			1.3611
6	1.3756			1.3073			1.3611
7	1.3575			1.3611			1.3611
8	1.3213						1.3611
9		1.3253		1.3611	1.3611	1.267	
10		1.3253			1.3611	1.267	
11		1.3611			1.3611	1.3213	
12		1.2346			1.3969	1.3032	
13		1.3611			1.4327	1.3394	
14		1.3611			1.4327		1.3756
15		1.3969			1.4327	1.3575	1.3756
16					1.4685	1.3937	1.3756
17			1.3611			1.3969	1.3213
18			1.4327			1.3969	1.3394
19			1.576			1.5043	1.5203
20			1.7909			1.6834	1.7013
21			1.7193			1.6118	1.7737
22			1.6476			1.6118	1.7737
23			1.6118			1.6118	
24	1.5565			1.6118			1.576
Max	1.5565	1.3969	1.7909	1.6118	1.4685	1.6834	1.7737
Min	1.3213	1.2346	1.3611	1.3073	1.3611	1.267	1.3213
Avg	1.4500	1.3379	1.5913	1.4387	1.4059	1.4333	1.4655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 204 / 11KV MIDC -II FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258			.3224			.3582
2	.3258			.3224			.3582
3	.3258			.2865			.3224
4	.2896			.2865			.3224
5	.2534			.2865			.3224
6	.2534			.2865			.3224
7	.3258			.3224			.3582
8	.3582			.394			.3582
9		.2865			.4298	.3224	.3582
10		.3582			.5731	.4298	
11		.394			.5731	.394	
12		.3582			.5014	.3582	
13		.3582			.3224	.3582	
14		.3224			.394		.3582
15		.3582			.394	.394	.3582
16					.3582	.5014	.3582
17			.3582			.5014	.4656
18			.3582			.4298	.4656
19			.3582			.4298	.4525
20			.394			.3582	.3982
21			.3582			.3582	.3982
22			.3582			.394	.4344
23			.3224			.394	
24	.3582			.3224			.3582
Max	.3582	.394	.394	.394	.5731	.5014	.4656
Min	.2534	.2865	.3224	.2865	.3224	.3224	.3224
Avg	.3129	.3480	.3582	.3144	.4433	.4017	.3752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 205 / 11 KV AMBEJAWALAGA AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.4012		.5864	.5556	
11	.5556		.6636	.679	
12	.7253		.7253	.6173	
13	.6944		.7407	.6173	
14	.6481		.7099		.7407
15	.6481		.7253	.679	.7407
16			.7099	.6944	.7407
17		.6481		.6173	.6944
Max	.7253	.6481	.7407	.6944	.7407
Min	.4012	.6481	.5864	.5556	.6944
Avg	.6121	.6481	.6944	.6371	.7291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 206 / 11 KV CKT HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081			.0829			.0829
2	.081			.0829			.0829
3	.081			.0829			.0829
4	.0486			.0829			.0829
5	.0486			.0829			.0829
6	.0486			.0829			.0663
7	.081			.0829			.0663
8	.081			.0995			.0663
9		.0829			.0663	.081	
10		.0663			.0829	.081	
11		.0829			.0829	.0972	
12		.0829			.0663	.081	
13		.0829			.0829	.0648	
14		.0829			.0829	.0648	.0486
15		.0829			.0995	.0648	.0486
16		.0995			.116	.081	.0486
17			.0829			.0829	.0648
18			.116			.0829	.0972
19			.116			.0829	.1134
20			.1326			.0995	.1134
21			.1326			.0995	.1134
22			.0995			.0995	.1134
23			.0995			.0829	.081
24	.0972			.0829			.0829
Max	.0972	.0995	.1326	.0995	.116	.0995	.1134
Min	.0486	.0663	.0829	.0829	.0663	.0648	.0486
Avg	.072	.0829	.1113	.0847	.0850	.0830	.0810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194033 / 33 KV MIDC S/S O'BAD

Feeder No / Name : 207 / 11KV EXPRESS UPALA WW NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.0446		
6			.0594		
7			.0594		
8			.0594		
9				.0594	
10				.0594	
11				.0446	
12	.0594			.0594	
13	.0594			.0594	
14	.0594			.0594	
15	.0594			.0594	.061
16				.0594	.061
17		.0594			.0594
18		.0594			.0594
19		.0594			.0594
20					.0594
Max	.0594	.0594	.0594	.0594	.061
Min	.0594	.0594	.0446	.0446	.0594
Avg	.0594	.0594	.0557	.0576	.0599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194089 / 33/11 KV BEMBALI CORNER

OSMANA

Feeder No / Name : 201 / 11 KV wadaga Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.016	.0158	.0192	.0192	.0256	.0221	.0192
2	.0224	.0221	.0192	.0192	.032	.0285	.0192
3	.0256	.0316	.0192	.0192	.0224	.0348	.016
4	.0288	.0348	.0224	.0192	.0352	.0506	.0128
5	.0256	.0474	.0256	.0224	.032	.0648	.008
6	.0256	.0474	.0288	.0224	.0291	.0364	.0096
7	.0224	.0364	.0224	.0256	.016	.0316	.0096
8	.0128	.0316	.0096	.0288		.019	.0096
9	.0096	.0285	.0064	.0864	.0064	.0127	.0032
10	.3922	.5345	.6049	.4801	.3874	.3889	.7954
11	.9456	.5793	.7714		.8286	.8226	.8786
12		.733	.7602	.653	.8697	.8898	.8418
13	.8539	.7778	.7538	.677	.8349	.8738	.861
14	.8444	.749	.7746	.6674	.7717	.7714	.7874
15	.8191	.7394	.7682	.6754	.6341	.8066	.8754
16	.8223	.7202	.797	.7106	.6531	.7906	.9154
17	.8966	.6946	.7778	.7794	.661	.8194	.8226
18	.019	.0192	.0064	.0192	.019	.016	.0192
19	.0506	.0224	.0224	.032	.0459	.016	.016
20	.0664	.0256	.0256	.0288	.0664	.0256	.032
21	.0601	.0224	.0256	.0256	.0474	.0256	.0288
22	.0443	.0224	.0224	.0288	.0332	.0256	.0224
23	.0316	.0224	.0224	.0352	.0253	.0224	.0256
24	.0192	.019	.0192	.0192	.032	.019	.0192
Max	.9456	.7778	.797	.7794	.8697	.8898	.9154
Min	.0096	.0158	.0064	.0192	.0064	.0127	.0032
Avg	.2632	.2490	.2635	.2215	.2656	.2756	.2937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 194089 / 33/11 KV BEMBALI CORNER

OSMANA

Feeder No / Name : 202 / 11 KV Express WW

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.0263	.0217	.0251	.0274	.0206	.0046
2	.0034	.0229	.0206	.024	.0286	.0217	.0034
3	.0023	.0183	.0217	.0251	.0034	.0046	.0034
4	.0023	.0011	.0217	.0229	.0023	.0011	.0034
5	.0023	.0011	.0217	.0217	.0046	.0011	.0034
6	.0217	.0034	.0011	.0217	.0046	.0023	.0034
7	.0217	.0206	.0023	.0011	.0023	.0263	.0206
8	.0217	.0206	.0206	.0023	.0011	.0217	.0217
9	.0217	.0217	.0023	.0194		.0023	.0217
10	.0217	.0206	.0034	.0194	.0263	.0229	.0217
11	.0194	.0217	.0023	.0011	.0217	.024	.0023
12		.0217	.0217	.0023	.0217	.0206	.0011
13	.024	.0217	.0023	.0194	.0263	.0217	.0023
14	.0217	.0217	.0023	.0194	.0217	.0217	.0023
15	.0206	.0023	.0023	.0194	.0229	.0023	.0011
16	.0011	.0023	.0023	.0011	.0023	.0023	.0011
17	.0183	.0023	.0023	.0011	.0011	.0034	.0263
18	.0069	.0023	.0034	.0023	.0046	.0103	.0274
19	.0206	.0023	.0046	.0023	.0023	.0206	.0274
20	.0229	.0023	.0046	.0023	.0217	.0217	.0274
21	.0217	.008	.0251	.0286	.0274	.0229	.0286
22	.0011	.0206	.0251	.0286	.0251	.0229	.0274
23	.0034	.0206	.0251	.0286	.0206	.0034	.0274
24	.0251	.0206	.0217	.0251	.0286		
Max	.0251	.0263	.0251	.0286	.0286	.0263	.0286
Min	.0011	.0011	.0011	.0011	.0011	.0011	.0011
Avg	.0143	.0136	.0118	.0152	.0152	.0140	.0135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 198002 / 220 KV OSMANABAD S /

STATION

Feeder No / Name : 401 / 33 KV OSMANABAD

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	5.8528	5.8985	6.1443	6.6392	6.6392	6.6638	6.3409
16	7.444	6.8907	7.0708	7.0416	6.4929	6.9799	5.9442
19	7.7275	6.9959	9.0135	8.582	8.3082	8.3608	8.0121
24	5.9899	6.8587	6.5844	7.0919	7.947	7.668	7.5286
Max	7.7275	6.9959	9.0135	8.582	8.3082	8.3608	8.0121
Min	5.8528	5.8985	6.1443	6.6392	6.4929	6.6638	5.9442
Avg	6.7536	6.6610	7.2033	7.3387	7.3468	7.4181	6.9565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 198002 / 220 KV OSMANABAD S /

STATION

Feeder No / Name : 405 / 33 KV POHNER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0463	.0457	.0457	.0457	.0463	.0457	.0463
2	.0463	.0457	.0457	.0457	.0463	.0457	.0463
3	.0463	.0457	.0457	.0457	.0463	.0457	.0463
4	.0463	.0457	.0457	.0457	.0463	.0457	.0463
5	.0463	.0457	.0457	.0457	.0463	.0457	.0463
6	.0463	.0457	.0457	.0457	.0463	.0457	.0463
7	.0463	.0457	.0457	.0457	.0463	.0457	
8	.0463	.0457	.0457	.0457	.0463	.0514	
9	.0463	.0457	.0463	.0457	.0463	.0457	.0457
10	.0457	.0457	.0463		.0457	.0457	.0457
11	.0457	.0457	.0463	.0457	.0457	.0457	.0457
12	.0457	.0457	.0463	.0457	.0457	.0457	.0457
13	.0457	.0457	.0463	.0457	.0457	.0457	.0457
14	.0457	.0457	.0463	.0457	.0457	.0457	.0457
15	.0457	.0457	.0463	.0457	.0457	.0457	.0457
16	.0457	.0457	.0463	.0463	.0457	.0457	.0457
17	.0457	.0457	.0457	.0463		.0457	.0463
18	.0457	.0457	.0457	.0463	.0457	.0457	.0463
19	.0457	.0457	.0457	.0463	.0457	.0457	.0463
20	.0457	.0457	.0457	.0463	.0457	.0457	.0463
21	.0457	.0457	.0457	.0463	.0457	.0463	.0463
22	.0457	.0457	.0457	.0463	.0457	.0463	.0463
23	.0457	.0457	.0457	.0463	.0457	.0463	.0463
24	.0463	.0457	.0457	.0457	.0463	.0457	.0463
Max	.0463	.0457	.0463	.0463	.0463	.0514	.0463
Min	.0457	.0457	.0457	.0457	.0457	.0457	.0457
Avg	.0460	.0457	.0459	.0459	.0460	.0460	.0461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

OSMANABAD (U) S/DN[741] BU 4741

Substation No/ Name :- 198002 / 220 KV OSMANABAD S /

STATION

Feeder No / Name : 407 / 33 kV MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			3.2933			3.1093
9				3.2442		
11					1.757	
13				2.7206		
18		2.0891				
24	1.989		2.915			2.8664
Max	1.989	2.0891	3.2933	3.2442	1.757	3.1093
Min	1.989	2.0891	2.915	2.7206	1.757	2.8664
Avg	1.989	2.0891	3.1042	2.9824	1.757	2.9879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 201 / PARANDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3696	1.283	1.3696	1.3146	1.4043	1.1431	1.2955
2	1.3003	1.2656	1.2136	1.2795	1.2136	1.1431	1.2955
3	1.2136	1.283	1.2483	1.2795	1.2483	1.1431	1.2193
4	1.2309	1.283	1.2656	1.262	1.283	1.1584	1.1888
5	1.2483	1.3003	1.3003	1.262	1.3003	1.1736	1.1431
6	1.283	1.3176	1.335	1.3146	1.335	1.1584	1.1431
7	1.3176	1.387	1.4043	1.4022	1.335	1.2498	1.1888
8	1.283		1.283	1.3672	1.283	1.2193	1.1736
9	1.3176		1.2483	1.3672	1.4198	1.0974	1.1279
10	1.1431		1.3672	1.4217	1.4723	1.4723	1.3847
11	1.1431		1.4022	1.4563	1.4373	1.4723	1.4723
12	1.2193		1.4022	1.4737	1.4198	1.4723	1.4723
13	1.2193	1.4784	1.4198	1.4737	1.4198	1.5074	1.2971
14	1.2193	1.3413	1.4198	1.3696	1.4198	1.4899	1.4373
15	1.2955	1.326	1.4022	1.4563		1.5249	
16	1.0669	1.3565	1.5249	1.5257		1.595	1.4022
17	1.5249	1.5249	1.2269	1.3523		1.5777	1.4217
18	1.5424	1.5074	1.4899	1.439	1.5089	1.387	1.3003
19	1.7353	1.6651	1.595	1.5777	1.4937	1.595	1.6124
20	1.7177	1.595	1.6651	1.6817	1.5851	1.7337	1.6124
21	1.6126	1.595	1.5775	1.6297	1.448	1.448	1.543
22	1.439	1.5604	1.6126	1.5777	1.4175	1.4632	1.3717
23	1.387	1.5257	1.4548	1.5083	1.3413	1.4022	
24	1.4217	1.3523	1.439	1.3847	1.491	1.2193	1.3565
Max	1.7353	1.6651	1.6651	1.6817	1.5851	1.7337	1.6124
Min	1.0669	1.2656	1.2136	1.262	1.2136	1.0974	1.1279
Avg	1.3438	1.4183	1.4028	1.4240	1.3941	1.3686	1.3391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 202 / LONI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.0943	.1029	.0943	.0857	.0686
2	.0943	.0943	.0943	.1017	.0943	.3944	.0686
3	.1132		.1132	.1029	.0943	.0857	.0857
4	.1132	.1132	.1132	.1174	.1132	.1029	.0857
5	.132	.1132	.132	.12	.0754	.1029	.1029
6	.0754	.132	.1509	.1715	.1698	.12	.1029
7		.3239	.3887	.3144	.3887	.3048	.381
8	.3239		.4372	.2896	.2591	.3658	.2743
9	.3077		.4049	.2572	.2858	.2591	.3048
10	.2896		.3286	.3563	.3144	.2172	.3144
11	.2743			.3077	.2572	.2027	.3001
12	.2896			.2591	.2027	.2858	.2896
13	.3048	.3658	.3001	.2591	.2172	.2858	.2572
14	.2743	.2896	.2858	.2753	.2317	.2896	.2606
20	.1372	.1372	.1372	.132	.1372	.132	.1698
21	.12	.12	.1372	.1509	.12	.12	.1132
22	.1132	.0754	.1372	.1509	.1029	.1029	.1029
23	.0943	.0943	.12	.1132	.1029	.0857	.0686
24	.0943	.0943	.1132	.1017	.1132	.0857	.0857
Max	.3239	.3658	.4372	.3563	.3887	.3944	.381
Min	.0754	.0754	.0943	.1017	.0754	.0857	.0686
Avg	.1803	.1575	.2052	.1939	.1776	.1910	.1809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 203 / WAGEGAVAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.3279	1.2631	1.3765	1.3279	1.1431	1.2193
2	1.3279	1.3927	1.3603	1.3927	1.3927	1.1431	1.2193
3		1.4737	1.4251	1.4251	1.4251	1.2193	1.2651
4	1.4251	1.5708	1.5061	1.4413	1.4737	1.2498	1.2955
5	1.5061	1.749	1.5708	1.4575	1.5384	1.2803	1.2955
6	1.5708	1.8785	1.6032	1.6518	1.6194	1.387	1.5089
7	1.6356	1.8947	1.7004	1.6518	1.5384	1.4022	1.5242
8	1.3441		1.4575	1.9109	1.4899	1.2498	1.3565
9			1.6194	1.9271	.2429	2.0881	1.9662
10				2.0405	2.2024	2.2024	.0191
11			1.7814	2.0081	2.2672		2.2834
12			1.7814	1.9757	2.2672	2.251	2.2348
13		1.6156	1.6194	1.8947	2.1052	2.2024	2.1376
14		1.5546	1.5223	1.8299	2.0567	2.17	1.9919
15	1.6613	1.7071	1.5384	1.8299		2.1862	
16	1.829	1.6766	1.4737	1.8623	2.0081	2.1862	2.0243
17	1.8461						
18	1.6194						
20	.1715	.2229	.2058	.1886	.1715	.2075	.1886
21	.1715	.2229	.1619	.1886	.0857	.1715	.1698
22	.1509	.2075	.1543	.1698	.1029	.1372	.1372
23	.132	.1698	.12	.132	.1029	.12	
24	.1509	.132	.1509	.12	.132	.1029	.12
Max	1.8461	1.8947	1.7814	2.0405	2.2672	2.251	2.2834
Min	.132	.132	.12	.12	.0857	.1029	.0191
Avg	1.1149	1.1748	1.2008	1.3559	1.2775	1.305	1.2609

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 204 / KHASAPURI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.4715	.4904	.4287	.4527	.3944	.4115
2	.5281	.4904	.5093	.4458	.4715	.3944	.4115
3	.5658		.547	.4458	.4904	.4287	.4801
4	.5847	.5281	.5847	.4801	.5281	.5144	.5487
5	.6224	.5658	.6602	.583	.5658	.5658	.6001
6	.6979	.6224	.7922	.703	.6224	.6344	.6516
7		2.7206	2.6882	2.7044	2.753	2.0881	2.8349
8	2.7044		2.7854	2.7206	2.5425	2.4691	2.4387
9	2.5425		2.834	2.7206	3.0769	2.6825	2.6216
10	2.4387		2.753	2.753	2.7206	2.8016	2.8016
11	2.4996		2.672	2.8016	2.5911	2.9635	2.7206
12	2.5758		2.6235	2.8502	2.4615	2.8664	2.6235
13	2.5911	2.2253	2.4291	2.672	2.4777	2.672	2.5587
14	2.4996	2.332	2.2996	2.7044	2.4615	2.5587	2.3805
15	1.6004	1.7985	1.8461	1.7004	1.8623	2.0243	
16	1.9204	1.6766	2.0405	2.0891		2.3482	2.0567
17	2.0405	2.1862	2.0243	2.1376		2.1862	2.0243
18		1.8623		1.9919	1.9052	2.0729	2.1214
19	2.2348	2.0243		1.8461	1.9204	1.8299	2.0567
20	2.1538	1.9919	1.5708	1.9757	1.7985	1.8461	1.7814
21		1.9109	1.8299	1.8947	1.7528	1.6461	1.7976
22	1.668	1.6356	1.749	1.8138	1.6461	1.5851	1.6613
23	.4904	.5093	.4458	.4715	.4287	.4287	.4115
24	1.7004	.4715	.4904	.4115	.4527	.3944	.4115
Max	2.7044	2.7206	2.834	2.8502	3.0769	2.9635	2.8349
Min	.4904	.4715	.4458	.4115	.4287	.3944	.4115
Avg	1.6747	1.4457	1.6666	1.7227	1.6356	1.6832	1.6698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194003 / 33/11 PARANDA SUB-STATION

Feeder No / Name : 205 / DONJA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0567	2.332	1.9757	.4858	3.1579	.3429	1.89
2	2.0729	2.2834	1.9109	.4915	3.1741	.3429	1.89
3	2.0729		1.9271	.4694	2.915	.3772	1.9509
4	2.0891	2.1862	1.9595	.463	2.9959	.3944	1.9052
5	2.1052	2.2024	2.0081	.4694	3.0769	.4115	1.89
6	2.1538	2.17	2.0567	.5506		.4973	1.829
15	.8535	.823	.8583	.8745	1.004	.9231	
16	1.1584	.7316	.9717	.9069	1.0526	.9717	.9231
17	1.1336	1.1336	1.166	1.1336		.9555	1.0202
18	1.2955	.9717		1.1498	.9145	1.0688	1.1012
19	1.6194	1.2308	1.1012	1.2308	1.0364		1.085
20	1.5223	1.2146	1.166	1.3441	.9145	.9555	1.1012
21	1.4575	1.166	1.1498	1.2308	.9145		.9069
22	1.3441	.9231	.9878	1.1336	.8535	1.0974	.8535
23	2.1376	2.3967	2.6882	2.9959		1.9814	1.9052
24	1.0364	2.3967	2.2996	.5668	3.1255	.3429	1.89
Max	2.1538	2.3967	2.6882	2.9959	3.1741	1.9814	1.9509
Min	.8535	.7316	.8583	.463	.8535	.3429	.8535
Avg	1.6318	1.6108	1.6151	.9685	1.9335	.7616	1.4761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194014 / 33/11KV ANALA SUB-STATION

Feeder No / Name : 201 / ANALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2858	.2286	.1286	.3498	.1783	.2652
2	.2286	.2858	.2286	.15	.2047	.1524	.1842
3	.2286	.2858	.2667	.1257	.2047	.1477	.1842
4	.2667	.2858	.2667	.148	.2183	.1334	.1842
5	.2667	.381	.2667	.2858	.2286	.2858	.2667
6	.2667	.381	.2667	.2858	.2667	.381	.2667
7			.2286	.2858	.2667	.381	.2667
8			.2286		.2667	.381	.2286
9			.2858	.2858	.2667	.381	.1905
10			.2858	.2286	.1905	.2667	.1905
11			.2858	.2286	.1905	.2667	.1905
12			.2858	.2286	.1905		
13	.1846	.1235					
14	.1554	.1024					
15	.1595	.1024					
16	.1521	.1783					
17	.1929	.1818					
18	.1477	.2603					
19	.1072	.2616	.381	.2667	.381	.2667	.381
20	.0953	.2183	.381	.2667	.381	.2667	.381
21	.381	.2667	.1795	.2035	.1771	.192	.1986
22	.381	.2667	.1624	.2814	.1858		.2258
23	.2858	.2286	.1635	.2987	.1658		.1814
24	.2286	.2858	.2286	.1381	.3498	.1715	.2641
Max	.381	.381	.381	.2987	.381	.381	.381
Min	.0953	.1024	.1624	.1257	.1658	.1334	.1814
Avg	.2198	.2434	.2567	.2257	.2492	.2568	.2382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194014 / 33/11KV ANALA SUB-STATION

Feeder No / Name : 203 / CHINCHPUR KD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7102	.5324	.6667	.5324	.5335	.5324	.5335
2	.5607	.5329	.668	.4944	.5335	.4758	.5335
3	.7102	.4929	.5601	.4954	.5716	.4753	.5335
4	.7529	.4568	.5601	.4563	.6859	.4739	.6852
5	2.3392	1.4348	.743	.6091	.7938	.5704	.7233
6	2.3872	2.0256	.743	.8349	.7898	.7613	.7537
7		2.4835					
8	2.3138	2.7069					
9	2.5034	2.3339					
10	3.1087	2.5177					
11	3.1193	2.5263					
12	3.1228						
13			2.8729	2.4926	2.5234	2.7593	2.7884
14			2.7852	2.4926	2.4448	1.8212	2.7821
15			2.7069	2.6105	2.4559	2.8551	
16			2.7039	2.7852	2.6135	2.889	.6653
17			3.035	2.7008	2.3739	2.9132	.9169
18			2.8664	1.3872	2.3605	2.887	.8431
19	.6471	.7233	2.8793	2.2848	2.3685	2.5477	2.0256
20	.8349	.7986	2.532	2.1509	2.3632	2.4142	1.9281
21	.6452	.7914	.7621	.7621	.6072	.7606	.7613
22	.5704	.7786	.6471	.8002	.5704		.5693
23	.5687	.7446	.5693	.8002	.5704		.5693
24	.7914	.5704	.7037	.5329	.724	.5313	.724
Max	3.1228	2.7069	3.035	2.7852	2.6135	2.9132	2.7884
Min	.5607	.4568	.5601	.4563	.5335	.4739	.5335
Avg	1.5109	1.3206	1.6114	1.4013	1.4380	1.6042	1.0786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194030 / 33 KV JAWALA SUBSTATION

Feeder No / Name : 203 / 11 KV SHIRSAV SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8233	1.989		2.0481	2.2377
2	1.9062	1.8233		2.13	2.1548
3	1.989	1.8233		2.13	2.1879
4	2.3205	1.6575	2.8178	2.2119	2.1548
5	2.4863	1.8233	2.4863	2.2939	
6	2.4863	1.6575	2.4863	2.0972	.1658
7	2.652	2.9835	2.652	2.4577	2.9007
8	2.652	3.1493	2.9835	2.9165	2.9835
9	2.7349		3.2322	2.8673	2.9835
10	2.652		3.1493	2.7854	2.9007
11	2.4863		2.9835	2.8673	1.5746
12			2.9007	2.6216	1.4918
13			2.4531	2.5396	1.4918
14			2.4863	2.6216	1.4089
15			.16	.1619	.1658
16			.16	.1619	1.989
17			.16	.1619	2.3205
18			.16	.1619	1.989
19			.3201	.3239	1.8233
20			.3201	.3239	1.4918
21			.3201	.3239	1.4918
22			.4001	.3239	1.4918
23	1.6575		1.8233	1.9662	1.6575
24	1.6575	1.8233		1.9662	2.2211
Max	2.7349	3.1493	3.2322	2.9165	2.9835
Min	1.6575	1.6575	.16	.1619	.1658
Avg	2.2695	2.0811	1.7227	1.6860	1.8817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194034 / 33/11KV SUB-STATION SHIRALA

Feeder No / Name : 201 / LOHARA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	20-MAY-17
HR	Load (MW)
16	1.3108
Max	1.3108
Min	1.3108
Avg	1.3108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194034 / 33/11KV SUB-STATION SHIRALA

Feeder No / Name : 203 / 11 SHIRALA GFSS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	20-MAY-17
HR	Load (MW)
16	.3353
Max	.3353
Min	.3353
Avg	.3353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194034 / 33/11KV SUB-STATION SHIRALA

Feeder No / Name : 205 / Wadner Ag FEEDER SEPERATION/PURE AG
Feeder KV- 11 / INCOMING

DATE	20-MAY-17
HR	Load (MW)
16	1.0974
Max	1.0974
Min	1.0974
Avg	1.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194034 / 33/11KV SUB-STATION SHIRALA

Feeder No / Name : 206 / KARKHANA EXPRESS

Feeder KV- 11 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	20-MAY-17
HR	Load (MW)
11	.0213
16	.0213
Max	.0213
Min	.0213
Avg	.0213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194034 / 33/11KV SUB-STATION SHIRALA

Feeder No / Name : 207 / WAGEGAWAN AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	20-MAY-17
HR	Load (MW)
11	2.7587
Max	2.7587
Min	2.7587
Avg	2.7587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 202 / 11 Kv Chinchpur AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0781	.0781					
2	.0781	.0781		.0734	.0734		
3	.0781	.0781					
4	.0781	.0781	.0734	.0734	.0734		
5	.0781	.0781					
6	.0781	.0781	.0734	.0734	.0734	.0734	.0734
13	1.406	1.467		1.3203	1.467		1.406
14	1.8747	1.467					2.0309
15	2.0309	1.6137	1.6137	1.6137			2.0309
16	2.0309	1.6137					2.1872
17	2.3434	1.6137	1.6137	1.6137			2.1872
18	2.3434	1.467					2.3434
19	2.0309	1.467	1.7604	1.7604			2.3434
20	1.8747	1.467		1.7604	1.467		2.0309
21	.0781						.0781
22	.0781						.0781
23	.0781				.0734		.0781
24	.0781	1.467	1.6137	.0734	.0734	.0734	.0734
Max	2.3434	1.6137	1.7604	1.7604	1.467	.0734	2.3434
Min	.0781	.0781	.0734	.0734	.0734	.0734	.0734
Avg	.9287	.9408	1.1247	.9291	.4716	.0734	1.3032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 203 / 11 Kv Tandulwadi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.0686					
2	.823	.0686		.0686	.0686		
3	.9602	.0686					
4	1.0974	.0686	.0686	.0686	.0686		
5	1.2346	.9602					
6	1.2346	1.0974	1.3717	1.166	.9602	1.2346	1.2346
7	1.2346	1.2346	1.3717			1.3717	1.3717
8	1.3717	1.3717	1.3717	1.2346	1.0974	1.3717	1.3717
9	1.3717	1.3717	1.3717	1.3717			1.3717
10	1.3717	1.3717	1.3717		1.3717		1.3717
11	1.5089	1.3717					1.3717
12	1.5089	1.3717	1.3717	1.3717	1.3717		1.3717
20	.0686	.0686	1.7604	.0686	.0686		.0686
21	.0686						.0686
22	.0686						.0686
23	.0686				.0686		.0686
24	1.2346	.0686	.0686	.0686	.0686	.0686	.0686
Max	1.5089	1.3717	1.7604	1.3717	1.3717	1.3717	1.3717
Min	.0686	.0686	.0686	.0686	.0686	.0686	.0686
Avg	.9521	.7545	1.1253	.6773	.5716	1.0117	.8173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 204 / 11 KV SHELGAON GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966	.2204					
2	.1638	.1658		.3814	.4508		
3	.2155	.1658					
4	.3149	.3149	.4854	.4161	.4854		
5	.3944	.4115					
6	.4784	.5138	.4854	.5028	.5028	.4854	.5028
11	.3467	.3814	.2601				.3189
12	.3544	.3294		.2427	.3814		.4075
13	.3366	.2774	1.3203	.2427	.3988		.3641
20	.5068	.4854	.2774	.4681	.4854		.5611
21	.4784						.4887
22	.4031						.4075
23	.2915				.3467		.3506
24	.2204	.2374	.3467	.3467	.4161	.3467	.3467
Max	.5068	.5138	1.3203	.5028	.5028	.4854	.5611
Min	.1638	.1658	.2601	.2427	.3467	.3467	.3189
Avg	.3358	.3185	.5292	.3715	.4334	.4161	.4164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194037 / 33/11 KV SHELGAON SUBSTATION

Feeder No / Name : 205 / 11 KV CHINCHPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1989	.1658					
2	.1989	.2155		.2469	.2469		
3	.213	.2155					
4	.2486	.2543	.1543	.2623	.2778		
5	.2572	.2543					
6	.2835	.2835	.1543	.2778	.2932	.1543	
11	.2543	.1852	.2778				.2572
12	.2572	.1543		.2315	.1543		.2658
13	.2204	.1543	.2315	.2315	.1543		.2601
20	.2658	.2315	.2778	.2778	.1543		.2658
21	.2543						.2835
22	.2572						.2804
23	.2204				.1543		.2254
24	.2204	.2155	.1543	.2315	.1543	.1543	.216
Max	.2835	.2835	.2778	.2778	.2932	.1543	.2835
Min	.1989	.1543	.1543	.2315	.1543	.1543	.216
Avg	.2393	.2118	.2083	.2513	.1987	.1543	.2568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194044 / 33/11 KV SUB-STATION

WARADWADI

Feeder No / Name : 201 / WAKADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	17-MAY-17	20-MAY-17
HR	Load (MW)	Load (MW)
1		.2427
2		.2401
3		.2427
4		.2427
5		.2743
6		.2713
10	1.7204	1.4575
11		2.4615
12		2.7831
13		3.0178
14		2.6825
15		2.4531
16		2.5857
17		2.6216
18		.2683
Max	1.7204	3.0178
Min	1.7204	.2401
Avg	1.7204	1.4563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194044 / 33/11 KV SUB-STATION

WARADWADI

Feeder No / Name : 202 / ASSU

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	20-MAY-17
HR	Load (MW)
1	1.4575
2	1.6194
3	1.9433
4	2.2672
5	2.5911
6	2.753
7	2.8178
8	2.753
9	2.5911
17	.1677
18	.1638
19	.1638
20	.1677
21	.1619
22	.1658
23	.1677
24	1.2955
Max	2.8178
Min	.1619
Avg	1.3675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

PARANDA (R) S/DN[429] BU 2658

Substation No/ Name :- 194044 / 33/11 KV SUB-STATION

WARADWADI

Feeder No / Name : 203 / WAKADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	20-MAY-17
HR	Load (MW)
1	.2267
2	.2267
3	.2241
4	.2294
5	.2622
6	.2622
24	.2267
Max	.2622
Min	.2241
Avg	.2369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194007 / 33/11 KV YEDASHI S/STN.

Feeder No / Name : 201 / 11 kv Ambejawalaga SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	21-MAY-17
HR	Load (MW)
10	.1543
11	.1715
12	.1886
Max	.1886
Min	.1543
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194007 / 33/11 KV YEDASHI S/STN.

Feeder No / Name : 202 / 11kv Yedashi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-MAY-17
HR	Load (MW)
1	.7716
2	.7716
3	.7716
4	.8059
5	.8402
6	.9088
7	.8745
8	.8573
9	.8059
10	.7888
24	1.2431
Max	1.2431
Min	.7716
Avg	.8581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194007 / 33/11 KV YEDASHI S/STN.

Feeder No / Name : 203 / JAWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-MAY-17
HR	Load (MW)
1	.8288
2	.8288
3	.8619
4	.9116
5	.9945
6	1.21
7	1.442
8	1.3094
9	.3429
10	.3429
24	.3258
Max	1.442
Min	.3258
Avg	.8544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194010 / 33/11 KV DHOKI S/STN

Feeder No / Name : 201 / 11 kv Tadwala SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	20-MAY-17
HR	Load (MW)
8	.061
9	.061
10	.7621
11	1.0364
12	.8535
13	.7621
14	.6706
Max	1.0364
Min	.061
Avg	.6010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194010 / 33/11 KV DHOKI S/STN

Feeder No / Name : 202 / 11 kv Khamgao SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	20-MAY-17
HR	Load (MW)
8	.442
9	.3963
11	1.2498
12	1.387
13	1.3413
14	1.3108
Max	1.387
Min	.3963
Avg	1.0212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194010 / 33/11 KV DHOKI S/STN

Feeder No / Name : 203 / 11 kv Govindpur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-MAY-17
HR	Load (MW)
8	1.7071
9	1.6766
10	.0305
11	.061
12	.061
13	.061
14	.061
Max	1.7071
Min	.0305
Avg	.5226

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194010 / 33/11 KV DHOKI S/STN

Feeder No / Name : 204 / 11 kv Kolhegao SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-MAY-17
HR	Load (MW)
8	2.1338
9	2.1338
10	.3048
11	.3353
12	.3658
13	.3658
14	.3658
Max	2.1338
Min	.3048
Avg	.8579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194010 / 33/11 KV DHOKI S/STN

Feeder No / Name : 206 / 11 kv Dhoki SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-MAY-17	20-MAY-17
HR	Load (MW)	Load (MW)
8		.9145
9		.884
11		.6401
12		.7316
13		.6706
14		.6554
17	.8535	
Max	.8535	.9145
Min	.8535	.6401
Avg	.8535	.7494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194011 / 33/11 KV KAMEGAON SUBSTATION

Feeder No / Name : 202 / chikali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.2883	.3086		.3239	.3048
2	.3429	.2915	.3206	.3086		.3239	.3048
3	.3239		.3206	.3258		.3429	.3048
4	.3239		.3206	.3258		.362	.3048
5	.3239		.3206	.3258		.381	.3429
6	.3239	.3429	.3772	.3258		.381	.381
7	.3239		.3961	.3429		.2477	.381
8	.3048	.2572	.2452	.3429		.3239	.3429
9		.1886	.2058			.3239	.2858
10		.6036	1.7833	1.749		1.9814	1.8099
11		2.6406	2.2291		2.1338	2.0957	2.6292
12		2.6029	2.2634	1.9719	2.4768	2.4196	2.6292
13		2.452	2.2291		2.2862	2.4143	2.4768
14		2.3954	2.0576		2.0386	2.2634	2.2862
15		.2075	2.1262		2.2862	2.1338	2.1338
16		2.6972	2.0576		2.3053	1.8671	2.2862
17		2.452	2.1262		2.3815	2.7054	2.3053
18		.2486	.2058		.3239	.2713	.2096
19		.407	.4115		.381	.3391	.3048
20		.407	.4115		.4191	.39	.381
21		.407	.3772		.4572	.3391	.4191
22		.373	.3429		.362	.3052	.381
23		.3391	.3429		.362	.2713	.3429
24	.3429	.3086	.2883	.3086	.3429	.3429	1.2765
Max	.3429	2.6972	2.2634	1.9719	2.4768	2.7054	2.6292
Min	.3048	.1886	.2058	.3086	.3239	.2477	.2096
Avg	.3281	1.0327	.9187	.6032	1.3255	.9646	1.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194011 / 33/11 KV KAMEGAON SUBSTATION

Feeder No / Name : 203 / Kamegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.3391	.3429		.4572	1.8233
2	1.3717	1.2003	1.326	1.3717	1.0974	1.2955	1.8233
3	1.448		1.6575	1.4575		1.3717	1.8233
4	1.5242		1.8233	1.6289		.7621	2.0222
5	1.6004		1.8896	1.8861		.7621	2.0553
6	2.5149	1.989	1.9559	2.0576	2.1948	.8383	2.0553
7	2.6673		2.1879	2.1262			1.1431
8	2.21	1.9719	1.7901	1.989	2.0576		2.5149
9		1.9062	1.7833		2.0576	1.5242	2.0576
10		1.1271	1.5775	1.5775		1.326	
11		1.5912	1.6461				2.1338
12	1.6289	1.6575	1.6461	1.1488	.7621	1.8313	2.0576
13		1.6575	1.6461		1.9052	1.5912	2.1338
14		1.4586	1.5775		1.9052	1.5912	1.9052
15		1.4586	1.5775		1.9814	1.5912	1.9052
16	1.6461	1.5249	1.5775	1.6289	1.9814	1.8564	2.0576
17		1.5249	1.5432		2.0576	1.5249	2.0576
18		.5426	.3429		.4572		.7621
19	.3429	.5426	.5487	.6859	.9145		.6859
20		.407	.5487		.9145	.7461	.7621
21		.407	.4115		1.0669	.4641	.8383
22		.407	.4115		.7621	.4748	.5144
23		.373	.3429	.6001	.6859	.3391	.4572
24	.381	.3429	.3391	.3429	.6097	.6097	1.5242
Max	2.6673	1.989	2.1879	2.1262	2.1948	1.8564	2.5149
Min	.3048	.3429	.3391	.3429	.4572	.3391	.4572
Avg	1.4700	1.1626	1.2704	1.346	1.3771	1.1030	1.6136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194011 / 33/11 KV KAMEGAON SUBSTATION

Feeder No / Name : 204 / Rajuri Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239		.3391			.3429	1.1431
2	.7621	.8573	1.1694		.8059	.6668	1.2193
3	.8002		1.5844	1.0288		1.1241	1.2955
4	.8383		1.8107	.7316		1.3336	1.4098
5	.8764		1.8861	1.2003		1.3527	1.7147
6	1.4289	1.5432	1.9616	1.2346	1.4232	1.4289	1.7718
7	1.5051		2.037	1.7833		1.7147	1.7147
8	1.6004	1.6632	2.037	1.6289	1.6118	1.7909	1.9243
9		1.8296	1.6289		1.6385	1.7718	1.7337
10		.2075	.2229	.1715	.2477	.2096	.2858
11		.132	.1715		.2096	.1905	.2286
12	.2401	.132	.1715	.1886	.1905	.2096	.1905
13		.2075	.1372		.2286	.2286	.2286
14		.2075	.1715		.2286		.2096
15		.2075	.2058		.2286		.2096
16	.2572	.2075	.2058	.2058	.2286	.2641	.2096
17		.2263	.2058		.2286	.2452	.2096
18		.2374	.2401		.2286	.3052	.2286
19	.3086	.3391	.3429		.362	.3391	.3239
20		.415	.3772	.4973	.381	.4578	.4191
21		.415	.3772		.4191	.4409	.4191
22		.373	.3086		.381	.3391	.362
23	.3429	.3391	.3086	.3429	.362	.3052	.362
24	.362	.3258	.3391	.3086	.3429	.3429	.362
Max	1.6004	1.8296	2.037	1.7833	1.6385	1.7909	1.9243
Min	.2401	.132	.1372	.1715	.1905	.1905	.1905
Avg	.7420	.5192	.7600	.7769	.5130	.7002	.7573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194011 / 33/11 KV KAMEGAON SUBSTATION

Feeder No / Name : 205 / Raje borgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334		.1187	.12		.1524	.7621
2	.6668	.8573	.7545	.6859	1.0288	.5716	1.1431
3	.8383		1.1317	.823		1.3336	1.1431
4	.9145		1.2826	.9602		1.5242	1.3717
5	1.0288		1.358			1.5623	1.5623
6	1.1431	1.2003	1.5089	1.1317	1.4746	1.6575	1.6194
7	1.3908		1.6221	1.3717		1.6194	1.2955
8	1.2955	1.3889	1.4712	1.2346	1.406	1.6385	1.6194
9		1.5278	1.286		1.467	1.6004	1.5432
10		.1132	.12	.0514		.0953	
11		.0754			.0572	.0572	.0953
12	.1029		.0857	.0514	.0762	.0572	.0762
13						.0572	.0572
14						.0572	.0572
15						.0754	.0572
16	.1715			.0514	.0572	.0566	.0572
17					.0762	.0572	.0572
18					.0762	.2883	
19		.1187	.1372		.1715	.2713	.1524
20		.1696	.1715		.1715	.2035	.1905
21		.1696	.1715		.1905	.1696	.1905
22		.1696	.1372		.1905	.1357	.1715
23	.1372	.1187	.12	.1372	.1715	.1187	.1715
24	.1524	.1372	.1187	.12	.1524	.1524	.1524
Max	1.3908	1.5278	1.6221	1.3717	1.4746	1.6575	1.6194
Min	.1029	.0754	.0857	.0514	.0572	.0566	.0572
Avg	.6646	.5039	.6821	.5615	.4512	.5630	.6157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 201 / TER Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0095	.0074		.0095		.333	.3125
2	.3506	.3269		.2343		.3429	.3521
3	.3906	.3765		.3005		.3338	.3841
4	.427	.4475		.3563		.4696	.4372
5	.4801	.503		.4001		.4344	.4858
6	.502	.5201	.5487	.4858		.4755	.5121
7	.5281	.5268		.5281	.5898	.4934	.5506
8	.5281	.5201	.5487		.5898	.5502	.5668
9	.5376	.5201	.5535	.4744	.6036	.4049	.5992
10	.0078		.0095	.0686	.0081	.0095	.009
11			.0095			.0095	
12	.0078	.0857	.0095	.0686	.0078	.0095	.009
13			.0095	.0686		.0095	
14	.0078	.1029	.0095	.0514	.0079	.0095	
15			.0095	.0514		.0095	
16	.0077	.0857	.0095	.0543	.0078	.0095	.0857
17			.0095	.0514		.0095	
18	.0079	.0857	.0095	.0686	.0078	.0095	
19			.0095	.0686		.0095	
20	.0065		.0095		.0078	.0095	
21	.0065		.0095	.0514		.0095	.0905
22			.0095		.0078	.0095	
23	.0065		.0095	.0724	.0078	.0095	.0857
24	.0095	.0075	.0857	.0095		.2972	.3125
Max	.5376	.5268	.5535	.5281	.6036	.5502	.5992
Min	.0065	.0074	.0095	.0095	.0078	.0095	.009
Avg	.2123	.2940	.1039	.1737	.1678	.1778	.3195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 202 / 11 Kv Ramwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.2031		.1848	.3086	.2056	.1848
2	.181	.2105		.1848	.3086	.208	.1829
3	.2195	.2105		.2195	.3429	.2105	.2195
4	.2926	.3041		.3361	.4115	.2812	.2957
5	.3696	.4321		.4108	.4115	.3563	.415
6	.4527	.4696	.5144	.5281	.4458	.3521	.5658
7	.4904	.4372		.5658	.4458	.4111	.5658
8	.4527	.421		.5281	.4191	.4481	.5281
9	1.0936	1.085	1.0688	.9998	1.0159	.9488	.9922
10	1.2018		1.0562	1.0814	.9686	1.1336	1.1469
11	1.2018		1.1142	1.0814	.9998	1.1142	1.1305
12	1.186	1.3032	1.1142	1.1305	.9686	1.0814	1.1633
13	1.1336		1.0562	1.1142	.9804	.9717	1.2125
14	1.1336		1.0562	1.1305	1.0242	.8855	1.2289
15	1.0883		1.166	1.1305	1.0437	.9717	1.2289
16	1.0883	1.166	1.278	1.1469	1.1248	1.094	1.278
17	.125		.0762	.3086	.1406	.1791	.3429
18	.1265		.1448	.3086	.2031	.2218	.4115
19			.3361	.3086	.2881	.3395	.4578
20			.4904	.3429	.3437	.4527	.4748
21	.2591		.4527	.3601	.3479	.3772	.4024
22	.253		.3772	.3086	.2629	.3018	.3086
23	.2401		.2957	.3086	.1389	.2241	.3429
24	.1829	.2056	.2401	.2614	.3429	.2056	.2263
Max	1.2018	1.3032	1.278	1.1469	1.1248	1.1336	1.278
Min	.125	.2031	.0762	.1848	.1389	.1791	.1829
Avg	.5888	.5373	.6963	.5950	.5537	.5407	.6378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 203 / 11 Kv Wagholi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.0329	3.2789	1.7368	2.8402	3.8243	3.5315	3.6244
2	3.8264	3.5955	2.194	3.2907	4.309	4.0193	3.786
3	3.634	3.8618	2.2116	3.4065	4.3313	4.1141	3.7258
4	2.8209	4.0344	2.2093	3.7616	4.3621	4.1053	3.8383
5	2.9614	4.0943	2.1628	4.0535	4.4003	4.201	3.9354
6	3.3273	4.458	2.1994	4.1476	4.5313	4.3591	4.2852
7	4.132	4.5344	2.601	4.688	4.9621	4.2333	4.5763
8	4.3805	3.7822	4.9894	4.6659	4.9384	4.5245	4.7287
9	2.1594	1.8781	2.5347	2.3106	2.2383	1.9441	2.3723
10	.2696	.1882	.3513	.3193	.3425	.3277	.3346
11	.141	.1075	.218	.2861	.3021	.231	.2843
12	.2505	.2435	.1585	.2622	.2179	.1813	.3201
13	.2046	.1135	.1906	.277	.2156	.1806	.285
14	.2126	.2317	.179	.298	.2831	.2282	.112
15	.2172	.1311	.1874	.2778	.2846	.2332	.0191
16	.2088	.2053	.1883	.2701	.2164	.1227	
17	.1985	.1113	.1837	.2709	.2061	.1086	.2614
18	.2018	.2114	.2275	.2919	.0983	.224	.3254
19	.2389	.144	.3368	.282	.1966	.2774	.3765
20	.3205	.2629	.5255	.4802	.4375	.5148	.4881
21	.4149	.2782	.506	.4782	.4603	.5067	.4805
22	.5208	.2507	.4846	.421	.4162	.4233	.4634
23	.4094	.2286	.4165	.4359	.3481	.3936	.375
24	2.1513	.2907	.3064	.378	.3925	.3273	.3361
Max	4.3805	4.5344	4.9894	4.688	4.9621	4.5245	4.7287
Min	.141	.1075	.1585	.2622	.0983	.1086	.0191
Avg	1.5515	1.5215	1.1375	1.5914	1.7631	1.6380	1.7102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 204 / 11 Kv Panwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0937		.0709	.2058	.1406	.1052
2	.1086	.0937		.0716	.2058	.1406	.1063
3	.1075	.0937		.1075	.2058	.1875	.1448
4	.1448	.2056		.1448	.3086	.2187	.181
5	.2218	.2372		.2587	.3258	.2778	.2587
6	.3772	.3201	.3429	.3772	.3258	.3163	.415
7	.4527	.3563		.4527	.3086	.3163	.4527
8	.3772	.3479	.3429	.3772	.3086	.3163	.3395
9	.2614	.208	.2587	.2218	.2058	.2241	.1848
10	.0791		.1848	.1715	.1235	.1463	.1543
11	.0762		.1075	.1543		.0724	.1715
12	.0781	.0857	.1052	.1715	.0772	.0716	.1886
13	.0926		.0701	.1543	.0772	.0716	.1715
14	.0791	.0857		.1543	.0772	.0724	.1715
15	.0625		.0686	.1543	.0791	.0724	
16	.0972	.0686	.1075	.1715	.0937	.1097	.2058
17	1.5181		1.7695	1.1961	1.3279	1.5729	1.1469
18	1.5497	1.6461	1.6244	1.2289	1.2967	1.5729	1.1469
19	1.4413		1.4899	1.2616	1.2651	1.5546	1.2289
20	1.278		1.3599	1.278	1.1363	1.4251	1.2616
21	1.1843		1.1561	1.2452	1.0155	1.0936	1.1142
22	1.166		1.1385	1.1633	1.0688	1.0623	1.1142
23	1.166		1.1385	1.1469		1.0883	1.0442
24	.1097	1.1523	1.2689	1.2125	1.1305	1.0155	1.1336
Max	1.5497	1.6461	1.7695	1.278	1.3279	1.5729	1.2616
Min	.0625	.0686	.0686	.0709	.0772	.0716	.1052
Avg	.5057	.3568	.7373	.5394	.5077	.5475	.5409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 205 / 11 kv Mulewadi _Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0082			.009	.0686		.8223
2	.5792	.8592		.5624	1.1142		.8539
3	.6874	.9374		.8539	1.1469		.9282
4	.8223	.9488		.9922	1.1961		1.0364
5	.9282	1.0753		1.0688	1.2125		1.1336
6	1.0688	1.1248		1.1469	1.2944		1.2125
7	1.004	1.142		1.1984	1.3765		1.3108
8	.9172	1.2651			1.4255		1.4586
9	.9602	1.3283		1.2125	1.3108		1.3763
10	.0078			.0857	.0078		.0857
11	.0077		1.2125	.0686			.0905
12	.0078	.0857	.0084	.0857	.0077		.0686
13	.7712			.0686			.0686
14	.0077	.0857	.0083	.0686	.0077	1.1203	.0857
15			.0081	.0857		1.278	.0857
16	.0089	.0857	.0081	.0857	.0077	.0088	.0857
17	.0078		.0083			.009	.0857
18	.0078	.0857	.009		.0077	.0088	
19			.009		.0154	.0086	
20	.0077		.0088			.0088	
21	.0077		.0086	.0686	.0078	.0086	.0857
22			.0089	.0686	.0077	.0086	.0857
23	.0078		.0088	.0857	.0078	.0086	.0857
24	.0081	.0078	.0857	.0088	.0857		.7407
Max	1.0688	1.3283	1.2125	1.2125	1.4255	1.278	1.4586
Min	.0077	.0078	.0081	.0088	.0077	.0086	.0686
Avg	.3730	.6947	.1071	.4118	.5426	.2468	.5613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 206 / MULEWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1086		.0876	.1029	.124	.0857
2	.1029	.0937		.0857	.1029	.1753	.0857
3	.12	.1075		.1063	.12	.1949	.1227
4	.1595	.1595		.1448	.1543	.2328	.1448
5	.2012	.197		.1829	.1543	.2303	.1829
6	.2427	.2481	.2401	.2241	.1543	.2507	.2218
7	.2614	.2454		.2427	.2229	.2534	.2402
8	.2033	.2279	.2401		.2229	.2534	.2195
9	.1267	.1595		.1448	.1543	.2218	.1448
10	.0886			.1372	.1267		.0686
11	.0895		.1052	.12	.1063		.0686
12	.1086	.1029	.0857	.0686	.1086	.0895	.0686
13	.1063			.0686	.1075	.0857	.0686
14	.1086	.1029	.0886	.0857	.1086	.0857	.0857
15	.1017		.1052	.0686	.1086	.0876	.0857
16	.1075	.1029	.1417	.0686	.1063	.1075	.0686
17	.0876		.1433	.1029	.1075	.1267	.1886
18	.1629	.1715	.1629	.1029	.1433	.1448	.1715
19	.197		.2241	.1372	.1612	.1848	.1715
20	.2187		.2427		.1629	.2427	.1886
21	.1791		.2033	.1543	.1629	.2218	.1715
22	.1423		.1646	.1543	.1433	.1646	.1715
23	.1265		.1254	.1372	.1448	.1267	.12
24	.1052	.1075	.1029	.1075	.1029	.1254	.1052
Max	.2614	.2481	.2427	.2427	.2229	.2534	.2402
Min	.0876	.0937	.0857	.0686	.1029	.0857	.0686
Avg	.1439	.1525	.1584	.1242	.1371	.1696	.1355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 207 / TER WATER WORKS

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***		***	***	***	***
2	***	***		***	***	***	***
3	***	***		***	***	***	***
4	***	***		***	***	***	***
5	***	***		***	***	***	***
6	***	***		***	***	***	***
7	***	***		***	***	***	***
8	***	***		***	***	***	***
9	***	***	.0019	***	***	***	***
10	***	***	.0019	***	***	***	***
11	***	***	***	***	***	***	***
12	***	***	***	***	***	***	***
13	***	***	***	***	***	***	***
14	***	***	***	***	***	***	***
15	***	***	***	***	***	***	***
16	***	***	***	***	***	***	***
17	***	***	***	***	***	***	***
18	***	***	***	***	***	***	***
19	***	***	***	***	***	***	***
20	***	***	***	***	***	***	***
21	***	***	***	***	***	***	***
22	***		***	***	***	***	***
23	***		***	***	***	***	***
24	***	.0892	***	***	***	***	***
Max	153.6201	152.5532	152.6065	152.6065	152.5875	152.6065	152.6065
Min	152.5052	.0892	.0019	152.416	152.4903	152.4884	152.5703
Avg	152.6002	142.0849	133.5147	152.5791	152.5345	152.5597	152.5894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 208 / MINOR DRIP IRRIGATION
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.013			.012			.0145
2	.0122	.0128		.0116		.0118	.0141
3	.0116	.0305		.0116			.0137
4	.0116	.0128		.0109	.0181	.012	.0133
5	.0124			.0103	.0183	.0122	.012
6	.0135	.0124	.0171	.0111			.0116
7	.0126			.0122		.0118	.0116
8	.0139	.0124	.0171			.0116	.0109
9	.0122	.0152	.0147	.0126	.0171	.0118	.0116
10	.0128		.0139	.0187		.012	
11			.0124			.0124	
12	.0128		.0118	.0187		.0128	.0187
13			.0116			.013	
14	.013	.0171	.0118			.0133	
15			.0124			.0135	
16	.0131	.0171	.0124	.0187		.0141	.0181
17			.0128	.0187		.0141	
18	.0131	.0171	.0122			.0149	
19			.0128			.0154	.0187
20	.013		.0137			.0162	.0187
21	.0128		.0145	.0187		.016	
22			.0139			.0154	
23	.013		.0147	.0187		.0151	.0187
24	.0135	.013		.013	.0187	.012	.0145
Max	.0139	.0305	.0171	.0187	.0187	.0162	.0187
Min	.0116	.0124	.0116	.0103	.0171	.0116	.0109
Avg	.0128	.0160	.0135	.0145	.0181	.0134	.0147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194020 / 33/11 TER SUBSTATION

Feeder No / Name : 209 / TER GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.4887		.4344	.5087	.4706	.4298
2	.3582	.427		.4344	.503	.4557	.4298
3	.3582	.4887		.4298	.503	.5068	.4706
4	.4344	.5138		.5068	.5636	.5731	.4706
5	.5487	.5552		.5487	.57	.6268	.5121
6	.5914	.591	.5487	.5975	.57	.6401	.5914
7	.6283	.5973		.6722	.5571	.567	.6283
8	.5853	.567	.5144		.5571	.6805	.5853
9	.5853	.543	.5487	.5175	.4588	.499	.5121
10	.5249		.5121	.4917	.4706	.4755	.4578
11	.5194		.4706	.4527	.4835	.4706	.4862
12	.4961		.394	.4527	.4784	.4344	.4287
13	.4908	.4801	.3582	.4527	.4656	.4344	.0181
14	.4607	.3429	.3582	.4527	.4656	.4344	.4115
15	.4557		.3982	.4359	.4656	.3982	.4458
16	.4607	.5144	.4344	.3932	.4525	.3982	.0187
17	.4784		.4344	.4694	.4477	.4755	.5533
18	.5249	.583	.5121	.5533	.5068	.5853	.5868
19	.6447		.6722	.5868	.6335	.7095	.5868
20	.7164		.679	.5868	.6626	.7095	.5967
21	.6697		.5914	.6371		.6653	.503
22	.591		.5487	.5365	.6626	.6348	.4748
23	.4641		.5487	.4862	.5552	.5544	.4862
24	.4755	.5014	.4801	.5175	.4862	.4656	.5121
Max	.7164	.5973	.679	.6722	.6626	.7095	.6283
Min	.3582	.3429	.3582	.3932	.4477	.3982	.0181
Avg	.5192	.5138	.5002	.5064	.5229	.5361	.4665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 201 / JAGJI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.8138	1.8299		1.9109		1.8347	2.0233
10	1.7814	1.6194	1.9547	1.9109		1.9204	2.0405
11	2.0405	1.7814	1.989	1.8623		2.0233	2.0062
12		1.8138	1.989	1.8623		2.1262	1.989
13		1.7814	1.9547	1.7976		2.0233	2.0576
14	.3239	1.749	1.9376			1.9376	2.0233
15	2.1862	1.8947	2.0233			2.0233	2.1948
16	2.1538	1.9109	2.0919		2.6406	2.0576	2.1776
24						2.6406	
Max	2.1862	1.9109	2.0919	1.9109	2.6406	2.6406	2.1948
Min	.3239	1.6194	1.9376	1.7976	2.6406	1.8347	1.989
Avg	1.7166	1.7976	1.9915	1.8688	2.6406	2.0652	2.0640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 202 / Palsap Ag With SDT

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.0324				.1372	
2	.1372	.0324				.1372	
3	.1372	.0324				.1372	
4	.1372	.0324				.12	
5	.1372	.0324				.1372	
6	.1372	.0324				.1372	
7	.1372	.0324				.1372	
8	.1372	.0324			.1372	.1372	
17	2.672	1.7814			2.2634	2.6406	1.9204
18	2.5911	1.7814	2.0576		2.0233	1.8519	2.0576
19	1.6194	1.5089	1.7147	2.4291	1.8176	1.749	1.869
20	1.4575	1.5223	1.6518	2.1052	1.8347	1.6194	2.0233
21	1.3413		1.5089	2.0454	1.749	1.6356	1.989
22	.6478		1.1984	1.6842	1.8004	1.668	1.9204
23	1.2955		1.3032	1.4575	1.749	1.749	1.8347
24	.1372	1.4251		1.3375	1.1984	1.8347	1.7147
Max	2.672	1.7814	2.0576	2.4291	2.2634	2.6406	2.0576
Min	.1372	.0324	1.1984	1.3375	.1372	.12	1.7147
Avg	.8037	.6368	1.5724	1.8432	1.6192	.9893	1.9161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 203 / 11 KV Sumbha Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.749	1.6194	1.4575	1.5432	1.4899	1.8347	1.5775
2	1.6804	1.6194	1.4575	1.5432	1.5223	2.0233	1.7147
3	1.6289	1.6194	1.6194	1.5775	1.5546	1.9547	1.749
4	1.5775	1.6194	1.6032	1.6461	1.6518	1.989	1.8176
5	1.8004	1.7814	1.5384	1.7147	1.6194	1.9204	1.8861
6	1.8861	1.7976	1.8623	1.7318	2.0748	2.0233	1.9547
7	1.9376	1.749	2.0243	2.1605	2.1605	1.9547	2.1262
8	1.8861	1.6356		1.989	.1372	1.989	1.9547
17						1.989	
24	1.8347						
Max	1.9376	1.7976	2.0243	2.1605	2.1605	2.0233	2.1262
Min	1.5775	1.6194	1.4575	1.5432	.1372	1.8347	1.5775
Avg	1.7756	1.6802	1.6518	1.7383	1.5263	1.9642	1.8476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 204 / KOND GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.3258	.2591	.3086	.3239	.3772	.4115
2	.2401	.3258	.2683	.3429	.3887	.3086	.4458
3	.2058	.3258	.2267	.3429	.3239	.2743	.4801
4	.2058	.4525	.3239	.3772	.4534	.4115	.5144
5	.3772	.543	.3887	.4115	.4024	.5487	.583
6	.4458	.6335	.5182	.4287	.6173	.5487	.6859
7	.3772	.6154	.3239	.4115	.583	.583	.6173
8	.3429	.543	.4359	.3086	.5144	.5658	.583
9		.4696		.3239	.5144	.5658	.4801
10	.3353	.2683	.3429	.3239	.4115	.3772	.3086
11	.1296	.2267	.2743	.1943	.3772	.3086	.1886
12		.1943	.2401	.2267	.2915	.2401	.2743
13		.1943	.2058	.2267	.2743	.2401	.2743
14	.1296	.1943	.1715	.2267	.3086	.2401	.3086
15	.2591	.1943	.1715	.2267	.2058	.2401	.2743
16	.2753	.2267	.2058	.2267	.2401	.2401	.3429
17	.2753	.2267	.1715	.2267	.3429	.3086	.3772
18	.1619	.2915	.1715	.3563	.4801	.2743	.4458
19	.4049	.3239	.2743	.5182	.5487	.3772	.3772
20	.4049	.5182	.4372	.4858	.5144	.4534	.3086
21	.4706	.3887	.3563	.5182	.4115	.4858	.3772
22	.4163	.3239	.3239	.4858	.4801	.421	.4801
23	.362		.3429	.3887	.3772	.4115	.3429
24	.2058	.3258	.2267	.3086	.3563	.4115	.3772
Max	.4706	.6335	.5182	.5182	.6173	.583	.6859
Min	.1296	.1943	.1715	.1943	.2058	.2401	.1886
Avg	.2951	.3536	.2896	.3415	.4059	.3839	.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 205 / PALSAP JAGJI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.362	.3563	.4115	.3563	.3772	.3772
2	.3086	.362	.3239	.4458	.3239	.3086	.3772
3	.2743	.362	.3239	.4801	.421	.4115	.4115
4	.3772	.543	.4696	.5144	.5182	.4801	.4458
5	.4801	.724	.6478	.583	.6478	.5487	.5144
6	.6859	.543	.6706	.6859	.6859	.7202	.6173
7	.703	.6516	.6478	.6173	.6859	.6859	.583
8	.5487	.3725	.6706	.3429	.6859	.6173	.6173
9	.5182	.4858		.3239	.5144	.5144	.3429
10		.4858	.4115	.4858	.4801	.2743	.4115
11	.3239	.3887	.3429	.3563	.4115	.2743	.5316
12		.4534	.3086	.3239	.3086	.2401	.2401
13		.3239	.2743	.3239		.2401	.2743
14	.3239	.3239	.2743	.3239		.2743	.2401
15	.2915	.3239	.3086	.3887		.2743	.2743
16	.2591	.4534	.3086	.4694	.3772	.2743	.2743
17	.2429	.4858	.3772		.3772	.3086	.3772
18	.2915	.4858	.4801		.5487	.4115	.4458
19		.6154	.6173	.503	.583	.4458	.6516
20		.5506	.6154	.4858	.4973	.4858	.6001
21	.4858	.0046	.4858		.5144	.421	.4801
22	.543	.5182	.3887	.583	.5487	.3887	.5487
23	.543		.4115	.503	.5144	.3772	.4458
24	.2743	.3982	.4534	.3772	.3887	.4115	.3429
Max	.703	.724	.6706	.6859	.6859	.7202	.6516
Min	.2401	.0046	.2743	.3239	.3086	.2401	.2401
Avg	.4061	.4442	.4421	.4537	.4947	.4069	.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 206 / 11 KV KOND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0062	1.9433	1.6194	1.8861	1.6194	1.8004	1.7147
2		1.9433	1.8442	1.9204	1.7814	2.0233	1.8176
3	1.8861	1.9433	1.6766	1.9547	1.8138	1.989	1.8861
4	1.9204	1.9433	1.7004	1.9547	1.6194	2.1948	1.9204
5	2.0233	2.1862	1.6194	1.989	1.2955	2.1605	1.989
6	2.0919	2.4291	2.0119	2.0576	2.0576	2.1262	2.1262
7	2.1434	2.17	2.2672	2.0576	2.1948	2.0919	2.0233
8	2.1434	2.1862	.9717	1.3717	1.7147	2.1948	1.7833
9	.9878	1.2955		.9717	.8573	1.166	1.2346
10		1.1336	1.0974	.9069	1.0288	.6859	1.2003
11	1.2955	.9717	1.2003	.4858	1.0974	1.2346	1.166
12		.9717	1.2689	.9717	1.2003	1.2689	1.1145
13		.9717	1.3375	.9717	1.166	1.2346	1.2003
14	1.2742	.9717	1.3032	.9717	1.1145	1.166	1.2689
15	1.1336	.9717	1.2003	.9717	1.0974	1.2003	1.3032
16	1.3413	.9717	1.1317	.9717	1.1145		1.2003
24	2.0405						
Max	2.1434	2.4291	2.2672	2.0576	2.1948	2.1948	2.1262
Min	.9878	.9717	.9717	.4858	.8573	.6859	1.1145
Avg	1.7144	1.5628	1.4833	1.4009	1.4233	1.6358	1.5593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194035 / 33/11 kv JAGAJI SUBSTATION

Feeder No / Name : 207 / bhikar sarola ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0324				.0686	
2	.0686	.0324				.0686	
3	.0686	.0324				.0686	
4	.0686					.0686	
5	.0686	.0324				.0686	
6	.0686	.0324					
7	.0686	.0324				.0686	
8	.0686	.0324				.0686	
17	1.3916	1.2955		1.1336	1.0631	1.3546	1.3717
18	1.2955	1.4575	1.3375	1.1336	1.1145	1.3717	1.3032
19	1.2955	1.2146	1.2346	1.1336	1.1145	1.3203	1.0288
20	1.1336	1.0526	1.1336	1.1336	1.166	1.166	1.0631
21	1.1736	1.1012	1.1401	1.004	1.0631	1.1984	.9945
22	1.1336	1.004	1.004	.9717	1.0288	1.085	.9259
23	1.247		1.0631	1.0526	1.1145	1.0288	.9259
24	.0686	1.2146		1.0631	1.004	1.0288	.9945
Max	1.3916	1.4575	1.3375	1.1336	1.166	1.3717	1.3717
Min	.0686	.0324	1.004	.9717	1.004	.0686	.9259
Avg	.5805	.6119	1.1522	1.0782	1.0836	.6689	1.0760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194038 / 33 / 11 KV Wahgoli

Feeder No / Name : 203 / SUT-MILL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0762	.061	.0305	.061	.0457	.0305
2	.0305	.0762	.061	.0305	.061	.0457	.0305
3	.0305	.0762	.061	.0305	.061	.0457	.0305
4	.0305	.0914	.0762	.0305	.0457	.0762	.0305
5	.0305	.1219	.0762	.0305	.0457	.0762	.061
6	.061	.0762	.0914	.0305	.0914	.0914	.061
7	.061	.0762	.0762	.061	.0914	.0914	.061
8	.061	.0762	.061	.061	.0762	.061	.061
9		.0762	.061	.061	.061	.061	.061
10	.884	.5182	.4572	.7468	.6859	.5487	.6401
11		.6859	.6097	.7621	.6401	.6097	.6554
12	.9602	.7621	.6401	.7926	.6401	.6401	.6859
13	.7621	.5335	.6097	.7621	.5335	.6401	.6706
14		.4572	.5792	.7621	.4877	.6097	.6554
15	.6401	.381	.5792	.7316	.4115	.5487	.6097
16	.5792	.6401	.5487	.7468	.6097	.4572	
17	.5487	.6859	.6097	.7621	.7011	.4572	
18	.061	.061	.0305		.0762	.061	
19	.0762	.0762	.0305		.0762	.061	.0762
20	.061	.0914	.061		.0914	.061	.061
21	.0457	.0762	.061	.061	.0762	.061	.061
22	.0457	.0762	.061	.061	.061	.061	.061
23	.0457	.0457	.061	.0457	.061	.061	
24	.9297	.061	.061	.0305	.0457	.0457	.0305
Max	.9602	.7621	.6401	.7926	.7011	.6401	.6859
Min	.0305	.0457	.0305	.0305	.0457	.0457	.0305
Avg	.2845	.2458	.2344	.3157	.2413	.2299	.2317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194038 / 33 / 11 KV Wahgoli

Feeder No / Name : 206 / 11 Kv Wanewadi

SINGLE PHASING

Feeder KV- 11 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1829	.1524	.1981	.9145	1.3108
2	.9145	1.0364	.8688	.6097	1.0669	.9755	1.3108
3	1.2803		.9755	1.2803	1.2193	1.0517	1.3717
4	1.2803		1.1584	1.3108		1.1584	1.4327
5	1.3108		1.326	1.3108	1.3717	1.2955	1.4632
6	1.3108		1.4022	1.3717	1.4632	1.3565	1.5242
7	1.3717		1.4784	1.4632	1.4784	1.4632	1.4937
8	1.3717		1.3565	1.5242	1.448	1.5242	1.4937
9	1.5394	1.2955	1.3717		1.5546	1.4632	1.4632
10	.1372	.1829	.1524	.1372	.1067	.0914	.1372
11	.1677	.1219	.1524	.1524	.1219	.0914	.1219
12	.1524	.0914	.2134	.1219	.1219	.0914	.1372
13		.1219	.1524		.1219	.0914	.1372
14	.1372	.1219	.0914		.1219	.0914	
15		.1219	.0914		.1219	.1219	
16		.1219	.0914	.0914	.1067	.1219	
17	.061	.1372	.1219	.1067		.1219	
18	.1219	.1067	.1219			.1524	.1219
19		.1677	.2134	.1524	.1981	.2439	.1829
20	.2134	.2743	.2134		.2896	.2439	.1981
21	.1829	.2439	.2134	.2591	.2439	.2134	.1829
22		.2286	.2134	.2439	.2134	.1829	.1524
23	.1524	.1981	.1829	.2286	.2134	.1829	
24	.1524	.5182	.1981	1.5546	.1981	.1829	.7621
Max	1.5394	1.2955	1.4784	1.5546	1.5546	1.5242	1.5242
Min	.061	.0914	.0914	.0914	.1067	.0914	.1219
Avg	.6321	.2913	.5227	.6706	.5705	.5595	.7894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194038 / 33 / 11 KV Wahgoli

Feeder No / Name : 207 / 11 Kv Sarola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3201	.3353	.3353	.3353	.3506	.3658
2	.3048	.3048	.3201	.3353	.3048	.381	.3658
3	.3048		.381	.3353	.3048	.4115	.3658
4	.3658		.4877	.3963	.2896	.4877	.4268
5	.6097	.6097	.5792	.5487	.4268	.5487	.5182
6	.6706	.7316	.6249	.6097	.6097	.6097	.6097
7	.6097	.6859	.5944	.6097	.6859	.6249	.6097
8	.5487	.6097	.5792	.6401	.5944	.6097	.5792
9	.4877	.4877	.5487	.5792		.5182	.5639
10	.8535	.8535	.8535	9.1754		.7011	.6859
11	.945	.884	.9145	1.0669	.8993	.7926	.7011
12	.9907	.8993	.9145	.9602	.9907	.7926	.9907
13	.9145	.7621	.8535	.945	.945	.7926	.884
14	.884	.7316	.823		.8535	.823	.8688
15	.8383	.7011	.823		.823	.823	.7621
16	.7926	.9755	.823		.9907	.823	
17		1.0669	.9145	1.0974	1.0669	.7621	
18		.3201	.3658		.3048	.3048	
19	.3353	.4572	.4572	.4877	.503	.6097	.4725
20	.5792	.5182	.5487		.5335	.5182	.5182
21	.6097	.442	.5182	.5182	.4572	.5182	.5792
22	.5335	.4115	.4572	.4877	.4268	.4572	.4877
23	.381	.381	.3963	.4572	.3506	.3963	
24	.3658	.3353	.3658	.3658	.3506	.3353	.3658
Max	.9907	1.0669	.9145	9.1754	1.0669	.823	.9907
Min	.3048	.3048	.3201	.3353	.2896	.3048	.3658
Avg	.6014	.6131	.6033	1.0501	.5930	.5830	.5860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194049 / 33 KV UPLA

Feeder No / Name : 201 / 11 Kv Upla feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0305		
2			.0305		
3			.0305		
4			.0305		
5			.0305		
6			.0305		
7			.0305		
8			.0305		
9		1.9052	1.9052		
10	2.1628	1.9814		2.1376	
11	2.2119	2.0576		2.1376	
12	2.1376	1.9052		2.0805	
13	2.1628	1.8595		2.0481	
14	2.1628	1.829		1.9662	
15	2.13	1.9052		1.9662	
16	2.1862	1.9814		1.9433	
17	.0343	.0305		.0343	.0305
18	.052	.0305		.0347	.0305
19	.0526	.0305		.0351	.0305
20	.0526	.0305		.0351	.0305
21	.0526	.0305		.0351	.0305
22	.0532	.0305		.0354	.0305
23	.0354	.0305		.0354	.0305
24			.0305		
Max	2.2119	2.0576	1.9052	2.1376	.0305
Min	.0343	.0305	.0305	.0343	.0305
Avg	1.1062	1.0425	.2180	1.0375	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194049 / 33 KV UPLA

Feeder No / Name : 202 / 11 Kv Shingoli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.0457		
10	.061	.0457	.0526	
11		.0457	.0526	
12		.0457	.0526	
13		.0457	.0354	
14		.0457	.0351	
15		.0457	.0351	
16		.0457	.0351	
17	1.2193	1.2193	1.3279	
18	1.2498	1.1888	1.2955	1.2498
19	1.1431	1.0669	1.2452	1.2193
20	1.0669	1.0364	1.166	1.0669
21			1.1469	.945
22	.9145		1.1469	.945
23	.884		1.1142	.945
Max	1.2498	1.2193	1.3279	1.2498
Min	.061	.0457	.0351	.945
Avg	.9341	.4064	.6244	1.0618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194049 / 33 KV UPLA

Feeder No / Name : 203 / UPALA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2401		
2			.2401		
3			.2401		
4			.2401		
5			.3086		
6			.3429		
7			.3772		
8			.3429		
9		.2743			
10	.2401	.2058		.2321	
11		.2058		.2035	
12	.2058	.2058		.1886	
13		.2058		.2035	
14	.1524	.2058		.2035	
15		.2058		.2035	
16	.2058	.2058		.2012	
17		.2401		.2012	
18	.3429	.3086		.2984	.2743
19		.3429		.3812	.3772
20	.3772	.3429		.3978	.3772
21		.3429		.3315	.3429
22	.3429	.3086		.3052	.3086
23	.3258	.3086		.2915	.3086
24			.2401		
Max	.3772	.3429	.3772	.3978	.3772
Min	.1524	.2058	.2401	.1886	.2743
Avg	.2741	.2606	.2858	.2602	.3315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194049 / 33 KV UPLA

Feeder No / Name : 204 / 11 KV SHINGOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1886		
2			.2058		
3			.2058		
4			.2229		
5			.2401		
6			.2743		
7			.2743		
8			.2058		
9		.1715			
10	.1715	.1543		.1658	
11	.1524	.1372		.1543	
12		.1372		.1357	
13	.1715	.1372		.1372	
14		.1372		.1372	
15	.1715	.1543		.1372	
16		.1715		.1715	
17	.2058	.1715		.1715	
18		.2058		.1715	.2058
19	.2401	.2439		.0025	.2401
20		.2743		.2374	.2743
21	.2401	.2401		.2374	.2743
22		.2058		.2229	.2572
23	.1886	.2058		.2058	.2401
24			.1715		
Max	.2401	.2743	.2743	.2374	.2743
Min	.1524	.1372	.1715	.0025	.2058
Avg	.1927	.1832	.2210	.1634	.2486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194049 / 33 KV UPLA

Feeder No / Name : 205 / 11 KV WARUDA AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2193		
2			1.3717		
3			1.3717		
4			1.6289		
5			1.448		
6			1.5242		
7			1.5546		
8			1.2803		
9		.061			
10	.061	.061		.0686	
11		.061		.0876	
12		.061		.104	
13		.061		.0867	
14		.061		.0857	
15		.061		.0867	
16		.061		.0867	
17	.0857	.0762		.1052	
18		.0762		.1052	.0914
19		.0914		.1052	
20		.0914		.1227	.0914
21		.0914		.1052	
22		.0914		.1052	.0914
23	.1067	.0914		.1063	.0914
24			.0914		
Max	.1067	.0914	1.6289	.1227	.0914
Min	.061	.061	.0914	.0686	.0914
Avg	.0845	.0732	1.2767	.0972	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194050 / 33/11 KV KHED S/STN

Feeder No / Name : 201 / 11 Kv Khed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2294	.2321	.2401	.2591	.2743	.2347
2		.2321	.2321	.2058	.2429		.2347
3	.2439	.253	.2439		.2591		.2713
4		.2949	.2652	.2743	.2915		.2949
5		.3315	.2818		.3887	.2896	.3277
6	.3353	.3637	.2743	.3429	.4049		.4287
7	.4287	.3963	.3479		.3725	.3506	.4409
8	.39	.427	.3321	.4115	.3887	.2896	.3768
9	.3391	.3277	.3563	.2896	.3812	.407	.3506
10	.3277	.2846		.2439	.3163	.2683	.3048
11	.2458			.1981	.253	.2372	.2439
12	.253	.2204	.2267	.1829		.2294	.2134
13	.2401	.2372	.2105	.2286		.2515	.1981
14		.1966	.2105	.1829	.2294		.2134
15		.2294	.2267	.1829	.2214	.2347	.1524
16	.2486	.2713	.2429		.1966	.2683	.1524
17	2.0153	1.6095		1.8623	1.4864	1.9498	1.8947
18	1.8747	1.8821		1.9271		1.9669	.6478
19	1.9393	1.8176		1.9757		2.0062	1.7166
20	1.7295	1.5581		1.6385		1.6604	1.5384
21	1.3916	1.5238		1.5708		1.5939	1.3748
22	1.5023	1.5089		1.6032		1.5939	1.4413
23	1.448	1.3395		1.6194		1.5769	1.3117
24	.2743	1.4327	1.2597	1.5089	1.587	1.5089	1.5089
Max	2.0153	1.8821	1.2597	1.9757	1.587	2.0062	1.8947
Min	.2401	.1966	.2105	.1829	.1966	.2294	.1524
Avg	.8168	.7377	.3295	.8345	.4549	.8925	.6614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194050 / 33/11 KV KHED S/STN

Feeder No / Name : 202 / ALNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.3904	1.3565	1.3717	1.4922		1.4232
2		1.4022	1.5091	1.5089	1.5592		1.543
3	2.1605	1.7394	1.4548		1.5424	1.8861	1.6126
4		1.9134	1.7859	1.8861	1.6766		1.7177
5		1.9997	2.1628		1.9281		2.1195
6	2.3663	2.1032	2.4531	2.6063	2.3137	2.5549	2.3663
7	2.2558	2.4247	2.3929		2.5987	2.6749	2.4813
8	2.1506	2.2138	2.0424	2.332	2.5316	2.1643	2.4247
9	.4572	.4877	.5365	.5487	.4917	.5658	.5144
10	.3437	.3163	.4024	.4115	.3561	.39	.3429
11	.2846	.3052	.3018	.2915		.2713	
12	.2812	.2543	.3018	.2743	.2743	.2458	
13	.2812	.2543	.2347	.2743		.2372	
14	.2372	.253	.218	.2401	.2622	.2458	.2401
15		.253	.2515	.2572	.2543	.2543	.2401
16	.2688	.253			.2785	.2713	.2572
17	.2896	.3005		.2785		.2683	.213
18	.3637	.373		.3277		.3113	
19		.5935		.4588		.4489	.3932
20	.5944	.6201		.6062		.6443	.6226
21	.4744	.5079		.5079		.5407	.5079
22	.4424	.4359		.4096		.4191	.3932
23	.3437	.3481		.3605		.3048	.3277
24	2.0405	.3086	.2743	.3429	.3521	.2743	.2743
Max	2.3663	2.4247	2.4531	2.6063	2.5987	2.6749	2.4813
Min	.2372	.253	.218	.2401	.2543	.2372	.213
Avg	.9312	.8771	1.1049	.7647	1.1941	.7487	1.0007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194050 / 33/11 KV KHED S/STN

Feeder No / Name : 203 / VIMANTAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2675	.2591	.2915	.2286	.2743	.2317
2		.2526	.2591		.2429		.2317
3	.2743	.1806	.2743	.3086	.2143	.2572	.2606
4		.1806	.2743		.2286		.2606
5		.2408	.2286		.2143		.2172
6	.2572	.2408	.2286		.2429	.2572	.2086
7	.2286	.2258	.1981		.2143		.2258
8	.1372	.2056	.1823	.1677	.2143	.2286	.2258
9	1.7859	1.439	1.4003	1.9433	1.2193	1.5546	1.9243
10	1.5851	1.6604	1.4432	2.0005	1.4784	1.6288	2.0005
11	1.7528	1.6446	1.4861	2.0195	1.5402	1.6309	2.0005
12		1.7869	1.386	1.6956	1.5546	1.6604	1.9624
13	1.5699	1.6604	1.386	1.6385		1.5546	1.6956
14	1.692	1.4937	1.3717	1.6385	1.5242	1.5394	1.5242
15	1.692	1.692	1.4575	1.848	1.6129	1.5546	1.6804
16	1.7071	1.6446	1.286		1.5954	1.7071	1.9052
17	.1265	.1524		.0934	.1372	.1696	.1334
18	.2056	.1829		.1858		.2883	.2534
19		.253		.2286		.2317	.2401
20	.3185	.2751		.2858		.3041	.2401
21	.3418	.2896		.2858		.2709	.2801
22	.3311	.2751		.2572		.3161	.2534
23	.3201	.2606		.2143		.2134	.2134
24	.3258	.3041	.2968	.3086	.2858	.2572	.2258
Max	1.7859	1.7869	1.4861	2.0195	1.6129	1.7071	2.0005
Min	.1265	.1524	.1823	.0934	.1372	.1696	.1334
Avg	.7874	.7004	.7893	.8562	.7499	.7950	.7665

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194050 / 33/11 KV KHED S/STN

Feeder No / Name : 204 / 11 KV KINI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0152	.0152	.0171	.0114		.0151
2		.0152	.0152		.0114		.0152
3	.0152	.0152	.0152	.0171	.0114		.0152
4		.0152	.0152		.0114		.0158
5		.0152	.0152		.0114		.0152
6	.0152	.0152	.0152	.0152	.0114		.0152
7	.0152	.0152	.0164		.0114	.0171	.0158
8	.0152	.0156	.0158	.0171	.0114	.0152	.0164
9	.017	.0152	.0114	.0133	.0158	.0152	.0133
10	.0158	.0152	.0114		.0152	.0152	.0133
11	.0158	.0152	.0114	.0133	.0164	.0152	.0133
12	.0158	.0152	.0114	.0133	.0166	.0158	.0114
13	.0156	.0152	.0114	.0133		.0164	.0114
14	.0156	.0151	.0114	.0133	.0166	.0158	.0114
15	.0156	.0158	.0114	.0152	.0166	.0164	.0114
16	.0158	.0164	.0114		.0158	.0164	.0095
17	.7968	.7529		.7287	.4877	.7116	.6089
18	.8697	.9172		.7868		.9156	.7255
19	.7274	.8065		.6535		.7468	.6219
20	.5921	.5441		.5601		.6554	.5441
21	.5234	.5155		.5735		.7122	.5182
22	.602	.5563		.5601		.68	.4923
23	.6622	.6642		.6001		.6325	.4534
24	.0152	.6554	.6554	.6344	.5258	.6859	.6171
Max	.8697	.9172	.6554	.7868	.5258	.9156	.7255
Min	.0152	.0151	.0114	.0133	.0114	.0152	.0095
Avg	.2377	.2357	.0512	.2914	.0716	.3277	.2000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194062 / 33 kv Padoli-A

Feeder No / Name : 201 / Padoli-A

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743			.3757			1.3321
2	1.0631			.7514			1.576
3	1.1317			1.5608			1.773
4	1.5089			1.8034			1.97
5	1.9204			1.9537			2.3102
6	2.1033			2.0141			2.3998
7	2.3777			2.2144			2.1582
8			2.058		1.6766	1.9387	2.104
9	1.7558	1.6787	2.0455		1.5939	1.8656	1.9161
10		.2543	.3388		.2883	.2926	.263
11			.2993				.2806
12		.2035	.2627		.2374	.2195	.2821
13		.2204			.2204	.2195	.2257
14		.2204	.2252		.2374	.2195	.2257
15		.2204	.2627		.2374	.2561	.1882
16		.2543	.2996		.2374	.2561	.2254
17		.2713	.2996		.2204		.263
18		.3052	.319			.2804	.3012
19		.3561	.3949			.5487	.4692
20			.526			.5853	.5975
21		.39	.5636			.5487	.563
22		.4409	.5244			.5121	.5255
23		.3361	.5082			.439	.5041
24	.2743		.3378	.4508			1.0631
Max	2.3777	1.6787	2.058	2.2144	1.6766	1.9387	2.3998
Min	.2743	.2035	.2252	.3757	.2204	.2195	.1882
Avg	1.3788	.3963	.5791	1.3905	.5499	.5844	.9799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194062 / 33 kv Padoli-A

Feeder No / Name : 202 / Mendha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058			.3381			1.182
2	.9602			.6575			1.1462
3	1.0631			1.3136			1.2894
4	1.166			1.3915			1.576
5	1.2346			1.5059			1.7909
6	1.3169			1.5764			1.7909
7	1.6644			1.8785			1.7558
8	1.5546		2.0643		1.643	1.6461	1.3887
9	1.0974	1.3904	1.9142		1.4922	1.5364	1.315
10		.2035	.2815		.2374	.2195	.2252
11		.1357	.1503		.1357	.1829	
12			.1315		.1526	.1829	.1877
13		.1311	.1126		.1696	.1463	.1501
14		.1017	.1501		.2035	.1463	.1127
15		.1526	.1877		.2204	.1097	.0751
16		.2035	.1501		.1865	.1097	.1126
17		.1696	.2252		.1526	.1097	
18		.1357	.2627		.1882	.1753	.1879
19		.2035	.3006			.5487	.3757
20		.2204	.4884			.5487	.5239
21		.1865	.5239			.5487	.5255
22		.1696	.4894			.5121	.4504
23		.2427	.449			.439	.3765
24	.2401		.2252	.3757			1.0288
Max	1.6644	1.3904	2.0643	1.8785	1.643	1.6461	1.7909
Min	.2058	.1017	.1126	.3381	.1357	.1097	.0751
Avg	1.0503	.2605	.4769	1.1297	.4347	.4476	.7985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194062 / 33 kv Padoli-A

Feeder No / Name : 203 / Ghugi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058					.2149
2	.2058					.2149
3	.2058					.2507
4	.2743					.2507
5	.3086					.3582
6	.3292					.3582
7	.2926					.3292
8	.2561		.1123		.823	.3003
9	.2561		.2252		.1097	.1126
10		.6613	1.4825	1.5261	2.1948	2.058
11		2.9673	2.8812	2.7978	3.0361	3.1903
12		2.9334	3.0026	2.2213	2.9264	3.209
13		2.4413	2.7774	2.2721	2.6337	3.0401
14		2.5265	2.6273	2.3061	2.5972	3.0777
15		2.5434	2.6273	2.34	2.7801	3.0777
16		2.7978	2.5334	2.3739	2.9264	3.1527
17		2.73	2.8366	2.2043	3.0361	2.9935
18			.2259	.1448	.1753	.263
19			.526		.4024	.4504
20			.6011		.4024	.6387
21			.6023		.4024	.5636
22			.5636		.3658	.5265
23			.526		.2561	.5271
24	.2058		.1501			.2058
Max	.3292	2.9673	3.0026	2.7978	3.0361	3.209
Min	.2058	.6613	.1123	.1448	.1097	.1126
Avg	.2540	2.4501	1.4295	2.0207	1.5667	1.2235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427] BU 2623

Substation No/ Name :- 194062 / 33 kv Padoli-A

Feeder No / Name : 204 / Swami Agro Industry
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10				.0188
11		.017	.0183	
12		.017	.0183	
13		.017	.0183	
14		.017	.0183	
15		.017	.0183	
16	.0751	.017	.0183	.0564
17	.0748	.017		
18	.0564	.0145		
19	.0376			
Max	.0751	.017	.0183	.0564
Min	.0376	.0145	.0183	.0188
Avg	.0610	.0167	.0183	.0376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194065 / 33 kv Takli-D

Feeder No / Name : 201 / Yeoti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	2.0957	2.13	2.1434	2.1434	1.9845	2.4768
2	.9431	2.0957	2.1052	2.1434	2.1434	1.9845	2.4768
3	.9602	2.0957	2.1765	2.2291	2.2291	2.0405	2.4768
4	.9602	2.2862	2.2085	2.3148	2.3148	2.0309	2.572
5	1.0288	2.4768	2.3644	2.4006	2.3148	2.1506	2.6482
6	1.286	3.2007	2.5606	2.7778	2.915	2.713	3.3532
7	1.286	3.2388	2.4326	2.7435	2.8292	2.8121	3.1245
8	1.2003	3.0483	2.4615	2.572	2.7435	2.4074	2.8197
9	.0762	.2286	.2286		.3086	.2286	.1524
10	.1524	.1524	.1372	.2572	.1905		.1372
11	.0762	.1143	.1715	.1715	.0762		
12		.0762	.1715	.1372	.0762	.0381	
13		.0762	.1715	.1372	.0762	.0381	.0857
14		.0762	.1715	.1372	.0762	.0762	.0857
15	.9145	.0762	.1715	.1372	.1143	.0762	.0857
16	2.0576	.0762	.1715	.1715	.1143	.0762	.0857
17	.1524	.0762	.1715		.1143	.0762	.1029
18	.1524	.1143	.1715	.1715	.1143		.1715
19	.2286	.1905	.2743	.2572	.1524	.1524	.2401
20	.3048	.3048	.3429	.2915	.3048	.381	.2743
21	.2286	.1905	.1715	.2572	.1524	.2286	.2058
22	.1905	.1524		.2058	.1524	.1524	.2058
23	.1524	.1524		.1715	.1524	.1143	.1715
24	.1524		.1524	.1372	.1715	.0762	
Max	2.0576	3.2388	2.5606	2.7778	2.915	2.8121	3.3532
Min	.0762	.0762	.1372	.1372	.0762	.0381	.0857
Avg	.6403	.9824	.9599	.9984	.9158	.9447	1.1406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194065 / 33 kv Takli-D

Feeder No / Name : 202 / Irla

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2096	.1905	.1715	.1715	.1905	.2096
2	.1715	.2096	.1905	.1715	.1715	.1905	.2096
3	.1715	.2096	.2096	.1715	.1715	.1905	.2096
4	.2058	.2286	.2286	.2058	.2058	.1905	.2286
5	.2058	.2667	.2286	.2058	.2229	.1905	.2667
6	.2401	.3048	.3048	.2572	.2572	.3048	.3048
7	.1715	.3048	.2667	.2915	.2572	.2286	.2858
8	.2572	.2858	.2286	.2572	.2401	.2286	.3048
9	2.21	2.3815	1.9109	2.0576	1.9033	2.2862	2.4196
10	2.2862	2.1125	2.0748	1.9033	1.8679	2.3624	2.1091
11	2.4387	2.0645	2.0748	1.9204	1.989	2.3815	2.1434
12		2.0405	2.1605	2.0233	1.989	2.3815	
13		1.9334	2.1434	1.8347	1.9448	2.3815	2.0919
14		1.8785	2.1434	1.9719	1.9989	2.4006	2.0748
15	2.4958	1.9204	2.1262	2.0062	2.0081	2.4387	2.2291
16	2.3815	1.9524		1.8861	2.0081	2.4958	2.3148
17	.1524	.1143	.1372	.1886	.1143	.1905	.1715
18	.2096	.1143	.1372	.1715	.1334	.2286	.1715
19	.2667	.1905	.2401	.2572	.3048	.2667	.2229
20	.381	.3429	.3086	.2743	.3429	.381	.1886
21	.3239	.3048	.2915	.2058	.3048	.3048	.1715
22	.2667	.2286		.2058	.2286	.2667	.1715
23	.2096	.1905		.1715	.1905	.2286	.1886
24	.2096		.1905	.1886	.1715	.2096	
Max	2.4958	2.3815	2.1605	2.0576	2.0081	2.4958	2.4196
Min	.1524	.1143	.1372	.1715	.1143	.1905	.1715
Avg	.7346	.8604	.847	.7916	.7999	.9550	.8495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

TER (R) S/DN[427]

BU 2623

Substation No/ Name :- 194065 / 33 kv Takli-D

Feeder No / Name : 203 / Takali-D

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514		.0572	.0514	.0514	.0572	.0572
2	.0514	.0762	.0572	.0514	.0514	.0572	.0572
3	.0514	.0762	.0572	.0514	.0514	.0572	.0572
4	.0686	.0762	.0762	.0686	.0686	.0572	.0572
5	.1029	.0953	.0953	.0857	.0857	.0762	.0572
6	.12	.1524	.1143	.1372	.12	.1143	.1143
7	.1029	.1334	.1143	.0171	.0857	.0572	.1334
8	.1029	.1334	.1143	.0686	.1029	.1334	.1334
9	.1143	.1143	.0953	.0686	.1029	.0762	.0953
10	.0762	.0762	.0857	.056		.0762	.0686
11	.0572	.0572	.0686	.0171	.0572	.0572	.0514
12		.0381	.0514	.0343	.0381	.0381	.0514
13		.0381	.0343	.0171	.0381	.0381	.0343
14		.0381	.0343	.0343	.0381	.0381	.0343
15	.0572	.0381	.0343	.0343	.0381	.0381	.0343
16	.0762	.0381	.0343	.0343	.0572		.0514
17	2.3624	1.8442	1.8861	1.8861	1.7147	1.9814	1.9547
18	2.2481	1.8945	1.8519	1.9033	1.7147	2.0767	1.8861
19	2.1338	1.8861	1.749	1.8861	1.7436	1.9433	1.8861
20	2.0195	1.7833	1.6804	1.5432	1.6766	1.6385	1.5432
21	1.9052	1.6461	1.5947	1.4403	1.5893	1.7337	1.4918
22	1.9052	1.6644		1.4403	1.5424		1.4575
23	1.9052	1.6827		1.4403	1.5775	1.6385	1.3717
24	1.9052		1.6827	1.5261	1.4403	1.6385	
Max	2.3624	1.8945	1.8861	1.9033	1.7436	2.0767	1.9547
Min	.0514	.0381	.0343	.0171	.0381	.0381	.0343
Avg	.8294	.6174	.5259	.5789	.6081	.6192	.5513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820] BU 4820

Substation No/ Name :- 194053 / 33/11 KV Terkheda

Feeder No / Name : 202 / 11 KV INDAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1696	.1905	.1905	.1905	.5373
5	.3429	.5544	.543	.5544	
8	.7164	.5258	.7973	.7087	.9526
Max	.7164	.5544	.7973	.7087	.9526
Min	.1696	.1905	.1905	.1905	.5373
Avg	.4096	.4236	.5103	.4845	.7450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194053 / 33/11 KV Terkheda

Feeder No / Name : 204 / 11 KV WADJI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.7164		
10	.6135	.5258		
12		.7011		.6935
13	.7888			
14		.7011		
16	.7011	.6135	.4687	.5468
24		.381		
Max	.7888	.7164	.4687	.6935
Min	.6135	.381	.4687	.5468
Avg	.7011	.6065	.4687	.6202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194055 / 33/11 KV SUBSTATION PARGAON

Feeder No / Name : 201 / 11 kv pargaon gaodan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17
HR	Load (MW)
1	.2458
2	.2401
3	.2372
4	.3315
5	.3277
6	.3163
7	.3239
8	.3277
9	.3277
10	.3201
11	.2818
12	.2486
13	.2035
14	.1658
15	.1658
16	.1619
17	.2486
18	.3239
19	.4001
20	.3239
24	.2458
Max	.4001
Min	.1619
Avg	.2747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194055 / 33/11 KV SUBSTATION PARGAON

Feeder No / Name : 202 / 11 kv loankhas ag
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17
HR	Load (MW)
1	.0633
2	.064
3	.064
10	.16
11	.3163
12	.3239
13	.2401
14	.16
15	.2429
16	.2401
17	.3201
18	.0829
19	.116
20	.1134
24	.08
Max	.3239
Min	.0633
Avg	.1725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194055 / 33/11 KV SUBSTATION PARGAON

Feeder No / Name : 203 / 11 kv rui-pimpalgaon

GAOTHAN FEEDER

gaodan Feeder KV- 11 /
OUTGOING

DATE	15-MAY-17
HR	Load (MW)
1	.0829
2	.0829
3	.1187
4	.1311
5	.128
6	.16
7	.1581
8	.16
9	.16
10	.16
11	.16
12	.0972
13	.0663
14	.0678
15	.0995
16	.0829
17	.0829
18	.1147
19	.16
20	.1581
24	.1187
Max	.16
Min	.0663
Avg	.1214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

OSMANABAD DIVISION[684]

WASHI S/DN.[820]

BU 4820

Substation No/ Name :- 194055 / 33/11 KV SUBSTATION PARGAON

Feeder No / Name : 204 / 11 kv rui

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17
HR	Load (MW)
1	.0663
2	.4858
3	.7907
4	.8697
5	.8097
6	.8802
7	.9831
8	1.0279
9	1.065
16	.0492
17	.0663
18	.0648
19	.081
20	.081
24	.0655
Max	1.065
Min	.0492
Avg	.4924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 201 / 11KV DALIMB AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.5432
2							1.5775
3							1.6804
4							1.7833
5							1.9547
6							2.7435
7							3.1722
8							3.035
9							2.8464
10	2.2805	3.0178	2.1434	2.4177	2.3624	2.2805	
11	3.3265		2.452	2.7778	2.4844	2.7606	
12	3.4294		2.8635	2.6406	2.4539	2.7606	
13	3.2236		2.5549	2.7435	2.4387	2.7606	
14	2.7435		2.572	2.7949	2.4539	2.572	
15	3.0007		2.5034	2.7435	2.4234	2.6406	
16	3.035		2.6749	2.8121	2.5911	2.8807	
17	3.3951		2.6406	2.9492		2.9835	
24							1.3889
Max	3.4294	3.0178	2.8635	2.9492	2.5911	2.9835	3.1722
Min	2.2805	3.0178	2.1434	2.4177	2.3624	2.2805	1.3889
Avg	3.0543	3.0178	2.5506	2.7349	2.4583	2.7049	2.1725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 202 / 11KV SALEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3429	.3429	.3429	.3601	.4458
2	.3772	.3429	.3429	.3429	.3429	.3601	.4458
3	.3772	.3772	.3772	.3772	.4115	.3772	.4801
4							.4801
5							.6173
6							.823
7							.8573
8							.823
9							.7888
13	.7202		.5487	.7202	.7545	.7716	
14	.7716		.583	.6516	.7545	.7545	
15	.7888		.6001	.6859	.7202	.7545	
16	.8573		.703	.703	.7545	.823	.2401
17	.8745		.6859	.8402	.2743	.8402	.3086
18	.8916		.6516	.8745	.7202	.8745	.3429
19	.8745			.8059	.7888	.7888	.4973
20	.8573		.583	.7716	.7888	.8916	
21	.5316		.5316	.583	.583	.5658	
22	.4801		.4801	.5316	.5144	.4973	
23	.3772		.4115	.4287	.3944	.3772	
24	.4115	.3429	.3429	.3601	.3772	.3772	.4287
Max	.8916	.3772	.703	.8745	.7888	.8916	.8573
Min	.3772	.3429	.3429	.3429	.2743	.3601	.2401
Avg	.6379	.3515	.5132	.6013	.5681	.6276	.5413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 203 / 11KV TUGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.2743	.3086	.3086	.8916	.3429
2	.823	.7202	.5487	.7202	.6859	.9088	.3429
3	.9259	.9602	.583	.823	.7202	.9602	.3429
4	1.0288	1.166	.6859	.8916	1.0631	1.0802	
5	1.166	1.406	.7888	1.0631	1.2346	1.1888	
6	1.5261	1.7833	.9431	1.166	1.5261	1.5775	
7	1.9719	1.989	1.1488	1.3546	1.5947	1.6766	
8	1.9204	1.8519	1.2346	1.3717	1.6804	1.5242	
9	1.3717	***	1.4918	1.5432	1.6004	1.4022	
10							1.2003
11							1.406
12							1.6461
13							1.7661
14							1.9547
15							1.7661
16	.2058		.1886	.1715	.1715	.2572	1.989
17	.2058		.2058	.2229	.2058	.2401	1.6975
18	.3086		.2401	.2743	.2401	.2572	.2401
19	.3944		.2401	.3086	.2743	.3086	.2229
20	.4801		.1715	.3601	.3772	.4115	
21	.4458		.1886	.3601	.3429	.4115	
22	.4115		.3944	.3944	.2915	.4115	
23	.4115		.3601	.3601	.2572	.4115	
24	.3429	.3772	.2743	.3258	.3258	.7545	.3601
Max	1.9719	17.1639	1.4918	1.5432	1.6804	1.6766	1.989
Min	.2058	.3429	.1715	.1715	.1715	.2401	.2229
Avg	.7935	2.7761	.5535	.6678	.7167	.8152	1.0913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 204 / 11KV YENEGUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.823	.823	.7888	.7888	.7888	1.0631
2	.8573	.823	.823	.7888	.7888	.7888	1.0631
3	.8573	.8573	.8573	.823	.9602	.823	1.0631
4							1.1317
5							1.2689
6							1.7833
7							1.8861
8	1.7833	1.8519	1.5261	1.8519	1.8861	1.6156	1.9547
9	2.1262		1.8519	1.8519	1.7375	.9145	1.8519
10	1.8176	1.8176	1.8004	1.7147	1.7528	1.6461	
11	1.8519		1.2689	1.8861	1.4632	1.7147	
12	1.8176		1.6461	1.7318	1.5242	1.7147	
13	1.7147		1.5089	1.6804	1.6004	1.6804	
14	1.6461		1.5432	1.6632	1.6461	1.5775	
15	1.7833		1.6461	1.5947	1.6004	1.7147	
16							.7716
17							.823
18	.7888		.7202	.7888		.7888	.823
19	1.0974			1.1831	1.166	1.0974	.9945
20	1.3032		1.3032	1.2689	1.3717	1.3717	
21	1.166		1.166	1.1831	1.2346	1.166	
22	1.0288		1.0288	1.0288	1.0974	1.0288	
23	.9259		.9259	.8916	.8916	.9259	
24	.9259	.823	.823	.823	.823	.823	1.0288
Max	2.1262	1.8519	1.8519	1.8861	1.8861	1.7147	1.9547
Min	.7888	.823	.7202	.7888	.7888	.7888	.7716
Avg	1.3527	1.1660	1.2507	1.3079	1.3137	1.2322	1.2505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 205 / 11 KV Nalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9204	1.869	1.6118	1.6461	1.6804	1.8138	.2229
2	1.9204	1.9033	1.6118	1.6461	1.6804	1.829	.2229
3	1.9033	1.9033	1.6461	1.7318	1.8176	1.8595	.2401
4	1.9033	1.9376	1.6804	1.7318	1.869	1.9052	
5	2.2634	2.1948	1.869	2.0233	2.2634	2.0729	
6	2.5549	2.6235	2.1262	2.452	2.6063	2.1643	
7	2.7949	2.9664	2.2291	2.4348	2.7435	2.4996	
10							1.989
11							2.332
12							2.572
13							2.452
14							2.2291
15							2.0576
16	.2229		.2743	.2743	.2572		2.1262
17	.2401		.3258	.2743			2.3148
18	.3258		.3772	.3429	.3772		.3086
19	.4973			.4458	.4458		.4287
20	.583		.6687	.5658	.6173	.6173	
21	.463		.4973	.5144	.5316	.4973	
22	.4115		.4458	.4287	1.5432	.3772	
23	.3944		.3944	.3772	1.6766	.2229	
24	1.5089	1.7833	1.6461	1.5089	1.4746	1.6004	.2229
Max	2.7949	2.9664	2.2291	2.452	2.7435	2.4996	2.572
Min	.2229	1.7833	.2743	.2743	.2572	.2229	.2229
Avg	1.2442	2.1477	1.1603	1.1499	1.4389	1.4550	1.4085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 206 / 11 KV Dalimb Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4115	.3944	.4115	.3944	.4115	.4115
2	.4115	.3772	.3772	.4115	.3772	.4115	.4115
3	.4115	.4115	.3772	.4458	.3772	.4458	.4115
4	.4801	.4458	.4458	.4801	.4458	.4801	.4115
5	.5487	.5487	.583	.5487	.6173	.5487	.583
6	.6859	.7202	.7202	.6173	.703	.6516	.583
9	.6173	.583	.6001	.5487	.6344	.5487	.5487
10	.5487	.583	.583	.4801	.5487	.5487	.4801
11	.4801		.4801	.463	.4801	.4458	.4115
12	.3772		.3772	.3258	.4458	.3772	.3772
13							.3258
14							.2915
16			.4115	.2743	.3429	.3772	
17	.4801		.4801	.4115	.4801	.4115	
18	.4801		.4458	.3772	.5144	.4458	.463
19	.6173			.5144	.5487	.5487	.5658
20	.6516		.5487	.6173	.6516	.6516	
21	.5487		.5487	.5487	.583	.5487	
22	.4801		.4801	.5144	.5144	.4801	
23	.4458		.4801	.463	.4458	.4458	
24	.4458	.4115	.4115	.4115	.4115	.4115	.4115
Max	.6859	.7202	.7202	.6173	.703	.6516	.583
Min	.3772	.3772	.3772	.2743	.3429	.3772	.2915
Avg	.5068	.4992	.4858	.4666	.5009	.4837	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194008 / YENEGUR

Feeder No / Name : 207 / 11KV ASHTA (KASAR)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3429	.3086	.3086	.3086	.463	.3258
2	.3429	.3429	.2743	.3429	.3429	.4458	.3258
3	.3429	.3772	.2572	.3429	.3772	.4973	.3429
4	.3772	.4115	.2743	.3429	.5144	.4458	
5	.4115	.5487	.2743	.4115	.6173	.4801	
6	.6173	.7545	.3601	.5487	.7716	.7716	
7	.9774	.9088	.4287	.7888	1.046	.9602	
8	.9945		.4287	.7716	.9602	.9145	
9	.823	.7888	.4287	.7545	.8916	.9945	
10							.6859
11							.7888
12							.8916
13							.8573
14							.7716
15							.7545
16	.3601		.2229	.3258	.3429	.3429	.8573
17	.3772		.3429	.3429	.3429	.3944	.8745
18	.4115		.2401	.3429	.3772	.3772	.3258
19	.4801		.2743	.4115	.5144	.4287	.4458
20	.5144		.463	.5144	.5487	.5144	
21	.4801		.4973	.463	.4458	.463	
22	.4287		.3944	.4115	.4115	.4287	
23	.3429		.3772	.3601	.3201	.3429	
24	.3772	.3429	.3429	.3086	.3086	.4801	.3258
Max	.9945	.9088	.4973	.7888	1.046	.9945	.8916
Min	.3429	.3429	.2229	.3086	.3086	.3429	.3258
Avg	.5011	.5354	.3439	.4496	.5246	.5414	.6124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194016 / LOHARA

Feeder No / Name : 201 / 11 KV LOHARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.5182	.6173	.503	.4572	.7316	.6401
2	.6097	.7621	.9945	.7621	.7316	.7621	.6706
3	.6706	.823	1.1145	.8535	.7316	.8383	.7316
4	.7926	.8535	1.2003	.9145	.7621	.884	.7621
5	.8535	.9145	1.2689	.9907	.7926	.9145	.823
6	.9145	.9297	1.3203	1.0212	.8383	.9907	.8688
7	.9602	1.0517	1.3717	1.1126	.884	1.0059	1.0059
8	1.0974	1.0364	1.286	1.1126	.9145	1.0364	.9755
9	.8688	.9755	1.2003	.9145	.9297	1.0212	.8535
10	.442	.3944	.3772	.381	.4801	.3963	.3944
11	.4268	.3944	.4572	.381	.3963	.4572	.3944
12	.4268	.3944	.4268	.381	.381	.3963	.3944
13	.442	.3944	.3963	.3963	.381	.4115	.3772
14	.4268	.4115	.3963	.3963	.3658	.4268	.3772
15		.3772	.381	.4268	.381	.4268	.3944
16	.503	.4458	.381	.4268	.3963	.4115	.3772
17	.4877	.4458	.4268	.4572	.4572	.442	.3944
18	.503	.5487	.4877	.4572	.5487	.442	.3944
19	.6097		.5792	.5487	.6097	.5182	.6173
20	.7011	.7202	.6706	.6097	.6706	.7164	.7202
21	.6401	.7545	.6097	.6706	.6097	.6706	.7202
22	.5944	.7202		.6097	.5792	.6097	.7202
23	.5639	.6859	.5792	.5487	.5487	.5639	.6173
24	.5335	.5335	.6173	.5335	.503	.6859	.6706
Max	1.0974	1.0517	1.3717	1.1126	.9297	1.0364	1.0059
Min	.4268	.3772	.3772	.381	.3658	.3963	.3772
Avg	.6342	.6559	.7461	.6421	.5979	.6567	.6206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194016 / LOHARA

Feeder No / Name : 202 / 11 KV Mogha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4458	.3944	.3506	.3658	.381	.4458
2	.4801	.5144	.3944	.3353	.3658	.381	.5144
3	.5144	.5487	.4458	.4572	.381	.4268	.583
4	.583	.6516	.4458	.503	.4115	.503	.6173
5	.6516	.7545	.6173	.6097	.5335	.5335	.6516
6	.7545	.823	.7202	.6859	.6401	.5792	.6859
7	.823	.7545		.7316	.5335	.6097	.6859
8	.4801	.4115	.6173	.6706	.4268	.6401	.5144
9	.4115	.2439	.5487	.4572	.3658	.6859	.2058
10	1.6804	1.4575	1.7147	2.7435	2.4387	2.0576	2.7435
11	2.7435	1.9719	2.3624	3.4294	2.6216	3.4979	3.1207
12	2.8807	1.9719	2.6673	3.4979	2.7435	3.6351	2.6063
13	2.9492	2.0576	2.774	3.4294	2.8349	3.5322	2.8292
14	2.9492	.7716	2.8654	1.7147	2.8959	3.2922	2.2291
15	2.9492	3.1722	2.8959	1.7147	2.9721	3.2236	2.8121
16	3.4294	3.2579	2.9264	2.6063	3.0483	3.2922	3.0864
17	3.2922	3.3436	2.8654	2.8121	3.0178	3.4294	3.1207
18	.4115	.4458	.4268	.3048	.4572	.3429	.4458
19	.6859		.5335	.3353	.6859	.6516	.6516
20	.7545	.7545	.7316	.4572	.7926	.823	.703
21	.6859	.7202	.6097	.4268	.6706	.7545	.6859
22	.4268	.5487	.5487	.4115	.4877	.6173	.6859
23	.4115	.4458	.4572	.3963	.3963	.4115	.4458
24	.4115	.4115	.4115	.3658	.3658	.3658	.3429
Max	3.4294	3.3436	2.9264	3.4979	3.0483	3.6351	3.1207
Min	.4115	.2439	.3944	.3048	.3658	.3429	.2058
Avg	1.3238	1.1512	1.2598	1.2270	1.2689	1.4445	1.3089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194016 / LOHARA

Feeder No / Name : 203 / 11 KV Hiperga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.1029	.0914	.0914	.0914	.0914
2	.0914	.0914	.1029	.0762	.0914	.0914	.0914
3	.0914	.0914	.0686	.0762	.0914	.0762	.0914
4	.1067	.0914	.0514	.061	.0914	.0762	.0914
5	.1067	.0914	.0686	.061	.0914	.0914	.0914
6	.1219	.0914	.0857	.0762	.1067	.0914	.061
7	.1219	.0914	.1029	.0914	.1219	.1219	.061
8	.0914	.0914	.1029	.1067	.1219	.1067	.0857
9	.0914	.0914	.1029	.1067	.1067	.0914	.0914
10	.0305	.0343	.0514	.0305	.0457	.0152	.0343
11	.061	.0514	.061	.061	.0457	.0305	.0343
12	.061	.0514	.061	.061	.0457	.061	.0343
13	.0305	.0514	.061	.0305	.0457	.061	.0343
14	.0305	.0514	.061	.0305	.0457	.0305	.0343
15	.0305	.0514	.0457	.0305	.0457	.0152	.0343
16	.0305	.0343	.0305	.0305	.0305	.0305	.0343
17	.0305	.0514	.0305	.0305	.0457	.0305	.0514
18	.0914	.1029	.0914	.0914	.0762	.0914	.0857
19	.0914		.1067	.1219	.1067	.0914	.1372
20	.0914	.1715	.1219	.1372	.1372	.0914	.1543
21	.1219	.1715	.1219	.1524	.1219	.0914	.1543
22	.1219	.1543	.1067	.1219	.1067	.0914	.1543
23	.0914	.1372	.1067	.0914	.1067	.0914	.12
24	.0914	.0914	.12	.0914	.0914	.1067	.0914
Max	.1219	.1715	.1219	.1524	.1372	.1219	.1543
Min	.0305	.0343	.0305	.0305	.0305	.0152	.0343
Avg	.08	.0882	.0819	.0775	.0838	.0736	.0810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 201 / 11 KV Jewali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2902	.2422	.2422		.2172	.6041	.6756
2	.7255	.7768	.346	.4644	.543	.6041	
3	.8162	.8285	.346		.5441	.6041	.8642
4	.8706	.7931	.346	.6892	.5792	.6041	
5	.905	.8449	.519		.7171	.725	
6	.905	.9473	.6927		.8059	.8612	
7	.9432	1.0334	.8612	.8282	1.0157	1.0334	1.0774
8	.9412	.8956	.93		1.0184	1.0173	
9	.7981	.8612	.7595		.9645	.9148	.7059
16	.144	.1557	.1858	.1629	.1384	.144	.1385
17	.1818	.1557		.1684	.2076		.1903
18			.2181	.1814	.2401	.2064	.1903
19	.2902	.2941		.2353	.3114		.2595
20		.3287	.4499	.2902	.397		.346
21		.3114		.3265	.346	.3493	.3287
22		.2768	.3093	.3258	.3114		.3114
23		.2595			.2595		.2762
24	.2534	.2422	.2422	.2627		.4498	
Max	.9432	1.0334	.93	.8282	1.0184	1.0334	1.0774
Min	.144	.1557	.1858	.1629	.1384	.144	.1385
Avg	.6203	.5439	.4606	.3577	.5069	.6244	.447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 202 / 11 KV Hipparga (syd) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3265		.3287		.3246	.2941	.3125
2	.3628		.3287	.3003	.3582	.2941	
3	.3628		.3287	.2914	.3765	.2941	.3168
10		.4844	.5944	.7981	.9311		
11		.5882		1.052	1.1392		.4488
12	1.1399	.6574	.9233	.8706	1.3118	1.5631	.8631
13		.6055		.905	1.1712		1.3089
14	1.0814	.725		.9976	1.1023	1.4358	1.3434
15		.8631		1.1789			1.1392
16	1.0883	1.1047	.9722	1.2908	.4833	1.3337	1.2773
17	1.1127	.9666		1.3785	1.2083		1.2745
18			.2574	.2174	.2076	.2206	
19	.362			.399	.4152		.3806
20	.3742	.5536	.547	.4211	.5524		.4844
21	.3948	.4844		.5079	.4844	.5015	.4488
22	.3628	.4152	.4045	.399	.4152		.4143
23	.3265	.346			.346		.3797
24	.2902	.3265	.3287	.3374	.3265	.2941	
Max	1.1399	1.1047	.9722	1.3785	1.3118	1.5631	1.3434
Min	.2902	.3265	.2574	.2174	.2076	.2206	.3125
Avg	.5835	.6247	.5014	.7091	.6561	.6923	.7423

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 194048 / JEWALI

Feeder No / Name : 203 / 11 KV Rudrawadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5441	.519	.4498		.4913	.5178	
2	.6154	.6904	.5524		.4344	.5178	
3	.682	.725	.5542	.8825	.399	.5178	.8545
4	.6478	.8285	.5524		.8869	.5178	
5	.7436	.8458	.6904	1.0509	.8589	.6041	.9902
6	.8076	1.0207	.8659		1.0757	.775	
7	.8688	.9839	.9989	1.0983	.9134	1.0162	1.0409
8	.905	.8631	1.0311		1.0184	1.0162	
9	.7981	.6904	.9108		.9321	.8976	.9815
16	.4711	.4833	.4229	.4353	.5363	.5143	.4661
17	.5436	.519			.4849		.519
18			.5963	.5079	.6401	.6735	.5536
19	.8343	.8131		.6892	.725		.7422
20		.9989	1.0296	.7618	.9494		.8976
21		.8976		.7981	.8631	.8457	.7768
22		.7768	.6598	.6429	.6889		.6927
23		.5006			.4488		.6214
24	.5804	.6228	.4498	.5636	.5441	.3979	.563
Max	.905	1.0207	1.0311	1.0983	1.0757	1.0162	1.0409
Min	.4711	.4833	.4229	.4353	.399	.3979	.4661
Avg	.6955	.7517	.6975	.7431	.7162	.6778	.7461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194079 / 33/11 KV KANEGAON

Feeder No / Name : 201 / 11 KV BHATANGALI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2858	.2858	.2858	.2858	.7621	.8688
2	.7011	.7164	.7164	.7621	.7773	.9145	.9145
3	.7621	.6097	.7316	.9145	.7773	.9145	.9145
4	.7621	.7316	.8535	1.0669	.7621	.9145	.945
5	.7773	.8993	.9145	1.3336	.8383	.9145	.9602
6	.7773	.9602	.9145	1.0669	.9145	1.2193	1.1431
7	.5335	1.1888	1.0822	1.2193	.7773	1.2193	1.1584
8	.6859	.823	1.0669	1.2193	1.0669	1.2193	1.1126
9	.7011	.823	.9145	1.2193	1.0822	1.0822	1.1279
10	.2286	.1524	.1905	.1715	.1905	.2096	.2286
11	.1524	.1334	.1905	.1715	.2286	.1905	.1715
12	.1334	.1715	.1905	.1524	.1905	.1524	.1715
13	.1334	.1524	.1905	.1524	.1905	.1524	.1524
14	.1334	.1524	.1905	.1524	.1905	.1524	.1715
15	.1715	.1524	.1905	.1334	.1905	.1715	.1715
16	.1905	.1715	.1905	.1334	.0191	.1524	.1715
17	.1905	.1905	1.9624	.1524	.1905	.1524	.1524
18	.1905	.1715	.1905	.1524	.1905	.1715	.1715
19	.2667	.2667	.2858	.1905	.2858	.2286	.2286
20	.3239	.362		.362	.381	.3239	.381
21	.3239	.362	.381	.362	.381	.381	.362
22	.3048	.3239	.3429	.3429	.381	.3429	.3429
23	.2858	.3048	.3048	.3239	.2858	.3048	.3048
24	.2858	.2858	.3048	.2858	.3048	.7621	.8078
Max	.7773	1.1888	1.9624	1.3336	1.0822	1.2193	1.1584
Min	.1334	.1334	.1905	.1334	.0191	.1524	.1524
Avg	.3868	.4330	.5472	.5136	.4534	.5420	.5473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194079 / 33/11 KV KANEGAON

Feeder No / Name : 202 / 11 KV NAGUR FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.381	.381	.381	.381	.381	.381
2	.381	.362	.362	.381	.362	.381	.381
3	.381	.381	.381	.381	.362	.381	.381
4	.381	.381	.4572	.381	.362	.381	.381
5	.4572	.4001	.4954	.4763	.381	.4763	.4191
6	.5144	.4191	.5144	.4763	.4001	.381	.4763
7	.4572	.4001	.4763	.381	.4001	.4763	.4382
8	.4382	.381	.4382	.381	.4191	.381	.4382
9	.3429	.3048	.2858	.3048	.362	.4001	.362
10	1.5089	1.6004	1.6766	1.8138	1.5242	1.5546	
11	1.9204	2.0729	1.829	2.2558	1.829	2.0576	2.1033
12	2.0729	2.1795	1.829	2.2862	1.9814	2.0881	2.2558
13	2.1338	2.1033	2.1338	2.0881	1.9814	2.0576	2.1948
14	2.1338	1.9357	1.5242	2.0271	1.9814	2.0729	2.0881
15	2.1795	2.0576	1.829	2.0576	1.9814	1.9357	1.829
16	2.3777	2.1948	2.2862	2.1338	2.1338	1.2384	2.1795
17	2.3472	2.3015	2.1338	2.21	2.1338	1.9814	2.0576
18	.3239	.2286	.2858	.2477	.2858	.3048	.2286
19	.4954	.2858	.4763	.5144	.381	.4382	.381
20	.5716	.5525	.5716	.5906	.6097	.6097	.5906
21	.5525	.5716	.5716	.5906	.5716	.5716	.5716
22	.4572	.5144	.4763	.5335	.4763	.5144	.4763
23	.4001	.4763	.381	.4191	.4763	.4572	.4001
24	.4191	.381	.4382	.381	.4001	.381	.4001
Max	2.3777	2.3015	2.2862	2.2862	2.1338	2.0881	2.2558
Min	.3239	.2286	.2858	.2477	.2858	.3048	.2286
Avg	.9853	.9528	.9264	.9872	.9240	.9126	.9311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 194079 / 33/11 KV KANEGAON

Feeder No / Name : 203 / 11 KV KANEGAON FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.381	.381	.4763	.3429	1.2193	1.1279
2	.7926	1.0822	.8993	.9145	.9755	1.2193	1.1431
3	.8383	1.1431	.9145	1.5242	.9907	1.2193	1.1431
4	.8383	1.2955	1.0364	1.9052	1.0669	1.3717	1.1584
5	.9907	1.3413	1.0974	1.5242	1.1431	1.5242	1.1736
6	1.1126	1.3565	1.1279	1.829	1.3565	1.6766	1.5089
7	1.2803	1.6004	1.5394	1.9814	1.3413	1.9814	1.7375
8	1.2193	1.5851	1.5242	1.9814	1.7071	1.829	1.7375
9	1.2041	1.4175	1.5242	1.829	1.6004	1.5699	1.6766
10	.3048	.3429	.381	.362	.381	.3239	.3239
11	.3429	.3429	.381	.3239	.2858	.362	.381
12		.381	.2858	.362	.2858	.362	.362
13	.3429	.381	.381	.3429	.2858	.362	.381
14	.3429	.381	.2858	.381	.2858	.4001	.381
15	.3429		.2858	.362	.381	.381	.381
16	.3429	.381	.381	.3429	.381	.381	.3429
17	.3239		.381	.3239	.381	.3239	.3239
18	.3239	.4001	.4763	.3239	.381	.3429	.3429
19	.5716	.4191	.5716	.4954	.5716	.4572	.4572
20	.6478	.6668	.6668	.7049	.6859	.724	.6478
21	.6287	.6668	.5716	.6859	.6668	.6668	.6478
22	.5525	.5906	.5716	.6097	.5716	.5906	.5525
23	.4763	.4572	.5716	.5335	.4763	.4763	.4382
24	.4001	.4191	.4572	.4763	.4572	1.2193	1.0822
Max	1.2803	1.6004	1.5394	1.9814	1.7071	1.9814	1.7375
Min	.3048	.3429	.2858	.3239	.2858	.3239	.3239
Avg	.6357	.7742	.6956	.8581	.7084	.8743	.8105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758]

BU 4758

Substation No/ Name :- 195000 / Tawshigad

Feeder No / Name : 201 / 11kv tawshigad

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905		.1905	.1905		
2	.7621	.8383		.5335	.3048		
3	.7621	.9145		.6097	.6097		
4	1.0669	.9907		.6097	.7621		
5	1.2193	1.0669		.9907	.9145		
6	1.2955	1.2193		1.0669	1.3717		
7	1.3717	1.3717		1.2193			1.3717
8	1.2955	1.5242		1.2193			1.2193
9	1.2193			1.1431			1.2193
16	.1905		.1905	.1905		.1905	.1905
17	.1905		.1905	.1905			.1905
18	.1905		.1905	.2858			.1905
19	.2858		.2858	.2858			.1905
20	.381		.381	.2858		.381	.2858
21	.2858		.2858	.381			.381
22	.2858		.2858	.381			.2858
23	.1905		.1905	.1905			.1905
24	.1905	.1905		.1905	.1905		
Max	1.3717	1.5242	.381	1.2193	1.3717	.381	1.3717
Min	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Avg	.6319	.9230	.2501	.5536	.6205	.2858	.5196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 195000 / Tawshigad

Feeder No / Name : 202 / 11kv dhanuri SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716		.5716	.5716		
2	.5716	.5716		.5716	.5716		
3	.5716	.5716		.5716	.5716		
10	1.448		1.5432	1.6004			1.6766
11	1.9052		1.829	1.9052			2.0576
12	2.0576		2.1338	1.9814			2.2862
13	2.1338		2.2862	1.9814			2.3624
14	1.9052		2.2862	1.9052			2.4387
15	2.1338		2.21	1.9814			2.4387
16	2.21		2.0576	2.0576		2.4387	2.21
17	2.2862		.2286	1.9052			1.9814
18	.381		.381				.381
19	.4763		.5716				.4763
20	.5716		.6668	.6668		.7621	.5716
21	.5716		.6668	.6668			.7621
22	.5716		.6668	.6668			.6668
23	.5716		.5716	.5716			.5716
24	.5716	.5716		.5716	.5716		
Max	2.2862	.5716	2.2862	2.0576	.5716	2.4387	2.4387
Min	.381	.5716	.2286	.5716	.5716	.7621	.381
Avg	1.1950	.5716	1.2928	1.2610	.5716	1.6004	1.4915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

LOHARA S/DN[758] BU 4758

Substation No/ Name :- 195000 / Tawshigad

Feeder No / Name : 203 / 11kv harali SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.2858		.381	.381		
2	.6859	.6097		.4572	.4572		
3	.6859	.7621		.5335	.5335		
4	.8383	.9145		.6859	.6859		
5	.9907	1.0669		.8383	.8383		
6	1.0669	1.1431		.9145	.9907		
7	1.2955	1.1431		.9907			1.286
8	1.0669	1.1431		.6859			1.0669
9	1.0669			.6859			.9907
16	.2858		.2858	.2858		.2858	
17	.2858		.381	.381		.381	
18	.381		.381	.4763		.4763	
19	.4763		.5716	.5716		.5716	
20	.5716		.6668	.6668		.6668	.5716
21	.5716		.6668	.5716			.6668
22	.4763		.4763	.5716			.5716
23			.381	.4763			.4763
24	.381	.2858		.381	.381		
Max	1.2955	1.1431	.6668	.9907	.9907	.6668	1.286
Min	.2858	.2858	.2858	.2858	.381	.2858	.4763
Avg	.6769	.8171	.4763	.5864	.6097	.4763	.8043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 201 / 11KV MURUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.0479	.9431	.9526	.9526	.9526	.9431
2	.9526	1.0479	.9431		.9526	1.0479	.9431
3	.9526	1.0479	1.0288	.9526	.9526	1.0479	.9431
4	.9526	1.0479	1.1145	.9526	1.0479	1.0479	1.0288
5	.9526	1.1431	1.1145	1.2384	1.2384	1.0479	1.1145
6	1.0479	1.1431	.9431	1.1431	1.2384	1.1431	1.2003
7	1.1431	1.0479	1.0288	1.1431	1.1431	.8573	1.0288
8	1.1431	.9526	.9431	1.0479	1.1431	.8573	.9431
9	1.0479	.9526	.8573	.9526	1.0479	.8573	.9431
10	1.0479	.8573		.9526		.9431	.8573
11		.9431	.9526	.9526		.9431	.9526
12		1.0288	.9526				.9526
13		.9431	.9526	.9526		1.0288	.9526
14		.9431	.9526	.9526			.9526
15		.8573	1.0479	.9526		1.0288	.9526
16		.8573	1.0479	.9526		.9431	.9526
17			1.0479	.9526		.9431	.9526
18			1.0479	1.1431		.8573	.9526
19			1.2384	1.2384	1.1431	1.0288	.9526
20			1.1431	1.1431	1.1431	1.0288	.9526
21			1.1431	1.0479	1.0479	1.1145	.9526
22		1.1145	1.1431	.9526	1.0479	1.0288	.9526
23		1.1145	1.0479	.9526	.9526	.9431	.9526
24	.9526	1.0479	.9431	.9526	.9526	.9526	.9431
Max	1.1431	1.1431	1.2384	1.2384	1.2384	1.1431	1.2003
Min	.9526	.8573	.8573	.9526	.9526	.8573	.8573
Avg	1.0132	1.0073	1.0251	1.0219	1.0669	.9838	.9697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 202 / 11KV KOTHSALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	1.0479	1.0479	1.0479	.4763	.2858	.381
2	.7621	1.0479	1.0479	1.0479	.4763	.2858	.381
3	.9526	1.0479	1.1431	1.0479	.4763	.2858	.381
4	.9526	1.2384	1.3336	1.2384	.5716	.2858	.381
5	1.0479	1.3336	1.5242	1.3336	.5716	.2858	.4763
6	1.7147	1.5242	1.9052	1.9052	.6668	.2858	.4763
7	1.7147	1.2384	2.0005	1.5242	.5716	.2858	.2858
8	1.7147	2.0005	1.9052	1.9052	.5716	.2858	.2858
9	1.7147	1.9052	1.9052	1.9052	.381	.2858	.1905
10	.2858			.1905			1.0479
11		.1905	.1905	.1905		1.6194	1.0479
12		.1905	.2858			1.8099	1.5242
13		.1905		.1905		1.9052	1.7147
14		.1905	.2858	.1905		1.8099	1.7147
15		.1905	.2858			1.8099	1.7147
16		.1905	.2858	.2858		1.9052	1.7147
17			.381	.2858		1.8099	1.7147
18			.381	.381		.1905	.381
19			.5716	.6668	.381	.2858	.381
20			.6668	.6668	.381	.5716	.381
21			.6668	.6668	.381	.5716	.381
22		.381	.6668	.5716	.2858	.4763	.381
23		.381	.5716	.5716	.2858	.4763	.381
24	.5716	.9526	.9526	.9526	.4763	.2858	.381
Max	1.7147	2.0005	2.0005	1.9052	.6668	1.9052	1.7147
Min	.2858	.1905	.1905	.1905	.2858	.1905	.1905
Avg	1.1085	.8468	.9093	.8530	.4636	.7869	.7541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 203 / 11KV BELUMB (ACHALER) SINGLE PHASING

FEEDER Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.2858	.381	.7621	.9526	.9526
2	.381	.381	.2858		.7621	.9526	.9526
3	.381	.381	.381	.381	.7621	1.0479	.9526
4	.381	.4763	.4763	.381	.8573	1.0479	1.0479
5	.381	.4763	.5716	.5716	.9526	1.0479	1.0479
6	.381	.4763	.5716	.6668	1.0479	1.0479	1.3336
7	.381	.381	.6668	.6668	1.2384	1.0479	1.5242
8	.381	.2858	.381	.6668	1.3336	1.0479	1.5242
9	.381	.1905	.2858	.4763	.5716	.9526	1.4289
10		.9526		.5716		.1905	.1905
11		1.1431	.9526	1.1431		.1905	
12		1.6194	.9526				.1905
13		1.7147	1.2384	1.1431		.2858	.1905
14		1.7147		1.1431		.2858	.1905
15		1.7147	1.3336	1.1431		.2858	.1905
16		1.6194	1.5242	1.1431		.2858	.1905
17			1.5242	1.1431		.2858	.1905
18			1.3336	.381		.2858	.381
19			.5716		.381	.381	.381
20			.6668	.6668	.381	.5716	.381
21			.6668		.381	.4763	.381
22		.4763	.5716	.5716	.381	.4763	.381
23		.4763	.5716	.5716	.381	.381	.381
24	.381	.381	.2858	.381	.6668	.9526	.8573
Max	.381	1.7147	1.5242	1.1431	1.3336	1.0479	1.5242
Min	.381	.1905	.2858	.381	.381	.1905	.1905
Avg	.381	.8022	.7318	.7097	.7240	.6296	.6627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194012 / 33/11KV MURUM S/S

Feeder No / Name : 204 / 11KV ALOOR FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048	.3048	.381	1.3717	1.7147	1.5242
2	.9526	.3048	.3048		1.3717	2.0957	1.5242
3	.9526	.3048	.381	.381	1.448	2.4768	1.6004
4	.9526	.381	.381	.381	1.448	2.4768	1.6766
5	1.0479	.381	.4572	.4572	1.5242	2.6673	1.7528
6	.9526	.381	.4572	.4572	1.6766	2.6673	1.9052
7	.9526	.381	.5335	.5335	1.829	2.1338	2.0576
8	.9526	.381	.6097	.5335	1.9052	2.1338	
9	.9526	.381	.5335	.5335	1.9814	2.1338	
10				.9145			.8383
11		2.1338	.5335	1.9814		.4572	1.7147
12		2.1338	.6097			.6097	.9526
13		2.1338		1.9814		.6097	.9526
14		2.1338		1.829		.6097	.9526
15		2.1338	.7621	1.829		.6097	.9526
16		1.9814	.7621	1.9052		.6097	.9526
17			1.829	1.9052		.6097	.9526
18			1.829				
19			1.6766				
20			1.6766				
21			1.5242				
24	.7621	.3048	.3048	.3048	1.2193	1.1431	1.448
Max	1.0479	2.1338	1.829	1.9814	1.9814	2.6673	2.0576
Min	.7621	.3048	.3048	.3048	1.2193	.4572	.8383
Avg	.9420	1.0097	.8142	1.0193	1.5775	1.5152	1.3599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194028 / 33KV S/S NARANGWADI S/S

Feeder No / Name : 201 / 11KV MADAJ FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1526			.1379
2		.1526			.1543
3		.1677			.1658
7					.1658
10		.7407			
11	.8916			1.0105	
12	1.1145			1.0002	
13	1.1431			1.0574	
14	1.0717			1.0151	
15	1.0715			1.0002	
16	1.0002			1.0574	
17				1.0715	
18	.1543			.1014	
19	.2267			.2591	
20	.253			.2429	
21	.2785			.2785	
22	.1966			.2515	
23	.1715			.1865	
24		.1372	.1288		.1578
Max	1.1431	.7407	.1288	1.0715	.1658
Min	.1543	.1372	.1288	.1014	.1379
Avg	.6311	.2702	.1288	.6563	.1563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194028 / 33KV S/S NARANGWADI S/S

Feeder No / Name : 202 / 11KV MATOLA (BORI) FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2713			1.0345
2		1.0059			1.2003
3		1.1736			1.326
4		1.2431			1.326
5		1.4089			1.4746
6		1.5384			1.6057
7		1.7814			
8		1.4118			
9		1.3575			
16	.2858			.2572	
17				.2932	
18	.3353			.3125	
19	.5992			.6154	
20	.5571			.6554	
21	.426			.5571	
22	.3315			.4854	
23	.3052			.3856	
24		.2915	.2576		1.0517
Max	.5992	1.7814	.2576	.6554	1.6057
Min	.2858	.2713	.2576	.2572	1.0345
Avg	.4057	1.1483	.2576	.4452	1.2884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194028 / 33KV S/S NARANGWADI S/S

Feeder No / Name : 203 / 11 kv naichakur feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5087			.5
2		.4694			.4973
3		.5182			.5243
11	2.3777			2.5263	
12	2.6749			2.572	
13	2.7149			2.6787	
14	2.6082			2.5377	
15	2.5377			2.4291	
16	2.4291			2.6063	
17				2.3167	
18	1.8519			.4321	
19				.8097	
20				.8848	
21	.7362			.8356	
22	.6478			.7545	
23	.5935			.5935	
24		.5144	.4508		.5083
Max	2.7149	.5182	.4508	2.6787	.5243
Min	.5935	.4694	.4508	.4321	.4973
Avg	1.9172	.5027	.4508	1.6905	.5075

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194028 / 33KV S/S NARANGWADI S/S

Feeder No / Name : 204 / 11KV Kawtha Gaonthan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	16-MAY-17	17-MAY-17	18-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2374			.1724
2		.218			.2058
3		.2267			.2321
4		.2591			.2949
5		.3201			.3441
10		.2143			
11	.1783			.2378	
12	.1486			.2	
13	.141			.1692	
14	.1269			.1429	
15	.141			.1448	
16	.1429			.1551	
17				.1286	
21	.2753			.2785	
22	.2683			.2683	
23	.2572			.2543	
24		.2401	.2093		.2103
Max	.2753	.3201	.2093	.2785	.3441
Min	.1269	.2143	.2093	.1286	.1724
Avg	.1866	.2451	.2093	.1980	.2433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194028 / 33KV S/S NARANGWADI S/S

Feeder No / Name : 205 / 11kv narangwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1357			.3448
2		.3561			.3429
3		.3315			
4		.4144			.4096
5		.4534			.4534
6		.4858			.502
7		.5121			
8		.4458			
9		.643			
16	.104			.1429	
17				.1269	
18	.1715				
19	.2267			.2315	
20	.2294			.2591	
21	.2035			.2294	
22	.2058			.1696	
23	.1696				
24		.1372	.1449		.3506
Max	.2294	.643	.1449	.2591	.502
Min	.104	.1357	.1449	.1269	.3429
Avg	.1872	.3915	.1449	.1932	.4006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 202 / 11KV MULAJ FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8							1.7052
10	1.467				.6097	1.6804	
11	2.6406			1.105	2.2634		
12	2.9492		.9526	1.2041	1.8861		
13		1.5718		1.1431	2.332		
14	3.1207		1.1431	1.105	2.2977		
15	2.8807	1.5813		1.105	2.4177		
16	3.5151		1.3336	1.2193	2.6578		
17	3.1379		1.4384	1.2574	2.8121		
22	2.8292						
Max	3.5151	1.5813	1.4384	1.2574	2.8121	1.6804	1.7052
Min	1.467	1.5718	.9526	1.105	.6097	1.6804	1.7052
Avg	2.8176	1.5766	1.2169	1.1627	2.1596	1.6804	1.7052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 203 / 11KV TALMOD FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5239	1.0669	.8002	.7888	
2	.5811	1.0669	.4725	.8745	
3	.9335	1.1431	.4954	.9945	
4	.7621	1.1888	.8269	.9945	
5	1.6137	1.3717	.4725	1.2346	
6	1.6137	1.4937	.503	1.5604	
7	1.8671	1.8938		1.6632	
8	1.9338	1.2936	.9145	2.4348	
9		1.2936	.8383	1.5089	
10		1.3336			
11					2.1948
12					2.4006
13					2.2805
14					2.1948
15					2.2462
16					2.3663
17					2.452
24	.4287	.9907	.8002	.7202	
Max	1.9338	1.8938	.9145	2.4348	2.452
Min	.4287	.9907	.4725	.7202	2.1948
Avg	1.1397	1.2851	.6804	1.2774	2.3050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 204 / 11KV Mulaj Gaothan Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858			.4572	.2439	.4268	
2	.2286			.4268	.2439	.4001	
3	.2362			.4572		.3868	
4	.2439			.5335	.2667	.3868	
5	.381			.6401	.2896	.5868	
6	.5335			.7202	.6001	.8402	
7	.8669			.6268	.381	.9069	
8	.4572			.5335	.9145	.8269	.6763
9	.4572			.6001	.3048		
10	.3048			.4344	.2439	.6001	
11	.4668		.3429	.2743	.3601		.4268
12	.4401		.3772	.2439	.4001		.5068
13	.3201	.3525		.2134	.3467		.5068
14	.3067		.2743	.1981	.3334		.4134
15	.3334	.2953		.2286	.2934		.4534
16	.3734		.2743	.1677	.5068		.4401
17	.4001		.2572	.1677	.5335		.4934
18	.4801		.4401	.16	.5068		.5735
19	.8135		.5068	.2667	.6001		.7335
20	.8535		.6001	.2667	.6935		.8135
21	.7468		.5735	.1829	.7735		.5868
22	.5468		.6401		.6535		.5468
23	.5201		.5335	.4268	.4934		.4668
24	.381			.4877	.4001	.4668	
Max	.8669	.3525	.6401	.7202	.9145	.9069	.8135
Min	.2286	.2953	.2572	.16	.2439	.3868	.4134
Avg	.4574	.3239	.4382	.3789	.4514	.5828	.5456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194041 / 33/11KV S/STN. TURORI

Feeder No / Name : 205 / P.B.A.INFRA EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
KAR Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143			.12	.0381	.0381	
2	.1143			.12	.0381	.0381	
3	.1429			.12	.0381	.0381	
4	.1429			.12	.0381	.0381	
5				.12	.0381	.0381	
6	.061			.12	.0381	.0381	
7	.1715			.1067		.0381	
8	.1715				.061	.0381	.0381
9					.0914	.0381	
10	.0914				.1143	.0381	
11	.1334		.3048		.1429		.1429
12	.1334		.3048		.1429		.1429
13	.1334	.0476	.2667		.1429		.1429
14	.1334		.0914	.1715	.1429		.1429
15	.1334	.0476		.1524	.1429		.1429
16	.1334		.2267	.1524	.1429		.1429
17	.1334		.2134	.1143	.1429		.1429
18	.1334		.2743	.1143	.1429		.1429
19	.1143		.3086	.1143	.1429		.0953
20	.1143		.3086		.1429		.1429
21	.0953		.12	.1524	.1429		.1429
22	.0953		.12	.16	.1143		.0953
23	.0381		.12	.2667	.0381		.0476
24	.1143			.12	.061	.0381	
Max	.1715	.0476	.3086	.2667	.1429	.0381	.1429
Min	.0381	.0476	.0914	.1067	.0381	.0381	.0381
Avg	.1204	.0476	.2216	.1379	.0992	.0381	.1218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194056 / 33KV CHOURASTHA OMERGA S/S

Feeder No / Name : 201 / 11 kv Chourasta gaothan GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3628	.3628	.399	.2477	.2096	.2858
2	.2477	.3628	.3628	.4353	.2477	.2096	.3201
3	.2477	.4716	.399	.4353	.2667	.2096	.2667
4	.2667	.5079	.4353	.4716	.2667	.2286	.2477
5	.2667	.5441	.5079	.5441	.2667	.2382	.2477
10	.5441	.5441	.5441	.5079	.5487	.2667	.2477
11	.4716	.4716	.4716	.4879	.4755	.2286	.2286
12	.4716	.4353	.3628	.4353	.4572	.2477	.2477
13	.4353		.3628	.3628	.4572	.2286	.2286
14	.4353	.3265	.2902	.3265	.4755	.2096	.2286
15	.3261	.2922	.3265	.2902	.4572	.1905	.2096
16	.3628	.3265	.3265	.3265	.4572	.2096	.1905
17	.3265		.2902	.3265	.4572	.1905	.1905
18	.2902		.3265	.2477	.4755	.1905	.2286
19	.4716	.4716	.3628	.2667	.5487	.2667	.2667
20	.5441	.5441	.5079	.2667	.5121	.2858	.2667
21	.6005	.4567	.5441	.2858	.4755	.2667	.2477
22	.4353	.4353	.4716	.2667	.4572	.2477	.2286
23	.3628	.3628	.4353	.2477	.439	.2286	.2286
24	.2286	.3265	.3265	.3628	.2286	.2286	.2286
Max	.6005	.5441	.5441	.5441	.5487	.2858	.3201
Min	.2286	.2922	.2902	.2477	.2286	.1905	.1905
Avg	.3782	.4260	.4009	.3647	.4109	.2291	.2418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194056 / 33KV CHOURASTHA OMERGA S/S

Feeder No / Name : 203 / 11 kv EKURGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429						
2	.4572	.5441					
3	.5487	.7255					
4	.5716	1.0883					
5	.5716	1.451					
6	.6287	1.5961					
7	.6859	1.9951					
8	.6859	1.6324					
9	1.451	1.2696					
10			.7255	.5079	.5487	.3429	.3429
11			1.0883	.8706	1.4632	.6859	.5716
12			1.1245	.8706	1.4632	.7316	.663
13			1.1971	1.0883	1.4632	.8002	.7087
14			.9069	1.0883	1.5729	.6859	.8002
15			.7255	1.126	1.4632	.6859	.8002
16			.8706	1.0883	1.4632	.8002	.9145
17			.7255	1.451	1.4632	.8002	.8002
Max	1.451	1.9951	1.1971	1.451	1.5729	.8002	.9145
Min	.3429	.5441	.7255	.5079	.5487	.3429	.3429
Avg	.6604	1.2878	.9205	1.0114	1.3626	.6916	.7002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194056 / 33KV CHOURASTHA OMERGA S/S

Feeder No / Name : 205 / 11 KV STONE CRUSHER NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS FE Feeder KV- 11 / (CONTINOUS PROCESS)(NO STAGGERING)
 OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.127	.0751	.1088	.0572	.0476	.0476
2		.127	.0907	.0907	.0572	.0381	.0572
3	.0667	.127	.0907	.0907	.0572	.0381	.0572
4	.0667	.127	.0726	.0726	.0476	.0381	.0762
5	.0667	.127	.0726	.0726	.0476	.0381	.0953
6	.0667	.127	.0907	.127	.0476	.0286	.1334
7	.0572		.0907	.127	.0667	.0667	.1048
8	.0572		.1088	.1451	.0667	.0953	.0762
9	.1088		.1995	.1451	.0667	.1619	.0857
10	.127		.1814	.1814	.2561	.1619	.0953
11	.127		.2177	.2539	.1829	.1715	.1143
12	.1451		.2177	.4534	.2561	.1905	.1429
13	.3628		.1877	.3809	.2926	.2191	.1048
14	.399		.2177	.2902	.3658	.2096	.0953
15	.3628		.2539	.1088		.1429	.0953
16	.2902		.3265	.1451	.3292	.1143	.0572
17	.3265		.3083	.1451	.2926	.1715	.0667
18	.3265		.3265	.1143	.2378	.1905	.0667
19	.2177		.2902	.1048	.1829	.0572	.0476
20	.1814		.2177	.0857	.128	.0476	.0476
21	.2177		.1451	.0762	.1097	.0381	.0572
22	.1451		.1451	.0762	.0914	.0381	.0572
23	.1451		.1088	.0667	.0914	.0476	.0572
24	.0572	.1088		.1143	.0667	.0572	.0476
Max	.399	.127	.3265	.4534	.3658	.2191	.1429
Min	.0572	.1088	.0726	.0667	.0476	.0286	.0476
Avg	.1782	.1244	.1755	.1490	.1477	.1004	.0786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194073 / 33/11 KV SUBSTATION BEDGA

Feeder No / Name : 201 / 11 KV BEDGA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2881	.2743	.2881	.3258	.3239	.2915
2	.3258	.3277	.2915	.3239	.3086	.3563	.3086
3	.3772	.3563	.2915	.3277	.5144	.3906	.3429
4	.5144	.4239	.3429	.4534	.5487	.4858	.4801
5	.6516	.6226	.4801	.5535	.6001	.6554	.5487
6	.823	.7969	.5487	.6478	.7716	.7935	.7716
7	.7716	.6802	.5144	.6554	.703	.7202	.703
8	.3772	.5407		.6226	.4115	.6325	.6001
9	.6173	.4752	.4049	.2622		.5992	.4458
10	.4534	.3772		.3772	.4534	.3429	.3429
11	.4096	.3258		.1715	.3239	.1715	.3429
12	.3563	.2743	.2949	.1715	.2949	.1372	.3258
13	.3239	.2572	.2429	.2401	.192	.1372	.2743
14	.2949	.2743	.1966	.2401	.192	.2743	
15	.2458	.2915	.2458	.2743	.2458	.2743	
16	.2458		.2949	.3258	.2591	.3086	
17	.2949		.3277	.3258	.2812	.3258	.3086
18	.3277	.3772	.3605		.3239	.4287	.3944
19	.5935	.5658	.5087	.5144	.4915	.5658	.5487
20	.6443	.5487	.6226	.6859	.6154	.5144	.5144
21	.5182	.4801	.5243	.5144	.5668	.4458	.4801
22	.421		.4588	.3944	.4858	.3601	.3944
23	.3563	.2915	.3391	.3429	.3521	.3429	.3429
24	.3086	.2915	.2743	.2949	.3258	.3086	.2915
Max	.823	.7969	.6226	.6859	.7716	.7935	.7716
Min	.2458	.2572	.1966	.1715	.192	.1372	.2743
Avg	.4400	.4222	.3733	.3916	.4168	.4123	.4311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194073 / 33/11 KV SUBSTATION BEDGA

Feeder No / Name : 202 / 11 KV BEDGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	1.5565	1.2003	1.3108	1.4403	1.1574	
2	1.9719	1.6385	1.2003	1.4746	1.5089	1.2651	
3	1.9719	1.7604	1.2346	1.5565	1.5432	1.5565	
4	2.0062	1.95	1.2689	1.5432	1.6118	1.5813	
5	2.0576	1.8976	1.406	1.6194	1.6804	1.7004	
6	2.3663	2.0645	1.5947	1.2955	1.8861	1.7814	
7	2.4691	2.0805	1.6289	1.668	1.869	1.7747	
8	2.5034	2.0891	1.2689	1.6385	1.749	1.8785	
9	2.3594	2.0243	1.2146	1.5074	1.668	1.9109	
10							1.8861
11							2.0576
12							2.1605
13							2.2634
17							2.1434
24	1.6461	1.2955	1.1145	.9831	1.3717	.9374	
Max	2.5034	2.0891	1.6289	1.668	1.8861	1.9109	2.2634
Min	1.6461	1.2955	1.1145	.9831	1.3717	.9374	1.8861
Avg	2.1238	1.8357	1.3132	1.4597	1.6328	1.5544	2.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194073 / 33/11 KV SUBSTATION BEDGA

Feeder No / Name : 203 / 11 KV CHENDKAL AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.8519
2						1.8861
3						1.8861
4						2.0233
5						2.0576
6						2.1434
7						2.1776
8						2.2291
9						2.1262
10	1.7814	1.3717				
11	1.9662	2.0576				
12	1.7814	2.1091				
13	2.0481	2.1091	.2743	.6325		
14	2.1052	2.1262	.2743	.8097	2.0576	
15	2.1862	2.1605	.2743	.9602	2.332	
16	2.1052		.2743	1.0688	2.1948	
17	2.1214		.2915	1.065	2.0062	
24						1.7661
Max	2.1862	2.1605	.2915	1.0688	2.332	2.2291
Min	1.7814	1.3717	.2743	.6325	2.0062	1.7661
Avg	2.0119	1.9890	.2777	.9072	2.1477	2.0147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194074 / 33/11 KV SUBSTATION BALSOOR

Feeder No / Name : 201 / 11 KV BALSUR GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049	.3988	.3479	.4239	.3437	.3906	.3812
2	.4534	.3521	.3858	.3647		.4001	.3812
3	.4534	.3321	.4428	.3647	.3437	.4428	.3932
4	.4534	.3906	.4744	.3812	.4096	.4374	.4475
5	.5182	.4365	.463	.4424	.4534	.4744	.5735
6	.5182	.5335	.5243	.5921		.4938	.5218
7					.5624		
9				2.3611			2.3329
10	.4424	.4687	.4458	.4475		.3858	.4049
11	.4268	.4687	.3277	.4049	.4374	.3681	.4696
12	.3637	.4374	.2881	.3163	.4687	.3681	.3795
13	.3479	.4687	.2949	.3321	.4687	.3395	.3593
14	.3647	.4999	.3277	.3163	.4687	.3637	.3506
15	.3647	.4999	.3321	.3201	.4374	.4062	.3395
16	.3681	.4687	.3163	.3163	.4687	.4321	.3593
17	.3768	.4374	.3361	.3681	.4687	.3277	.3353
18	.4748	.4374	.3856	.4191	.4687	.2254	.4641
19	.5784		.5434	.5258	.4687	.543	.5548
20	.6626	.4687	.7421	.724	.4999	.7865	.7783
21	.6447	.4687	.6219	.6767	.4687	.7602	.695
22		.5624	.5068	.5853	.4374	.7619	.567
23	.5014	.3906	.4908	.5068	.4062	.543	.5068
24	.4049	.4733	.3479	.4334	.3749		.4024
Max	.6626	.5624	.7421	2.3611	.5624	.7865	2.3329
Min	.3479	.3321	.2881	.3163	.3437	.2254	.3353
Avg	.4562	.4497	.4260	.5283	.4450	.4625	.5454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194074 / 33/11 KV SUBSTATION BALSOOR

Feeder No / Name : 202 / 11 kv BALSOOR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.7966	1.5257					
3	1.8747	1.6129					
4		1.9216					
5	1.8435	1.9566					
6	1.8299	2.3167					
7	2.3434	2.3777					
8	2.4528	2.2733					
9		2.2443					
10			1.6941	1.713		1.4815	1.749
11			2.0645	2.0729	1.3603	2.0645	2.17
12			2.1605	2.0873	2.5587	2.1605	2.2613
13			2.343	.7274	2.5101	2.0988	2.2497
14			2.2611	1.6604	2.5587	2.1348	2.1338
15			2.1664	1.8404	2.3434	2.1247	2.1296
16			2.0557	2.0873	2.3482	2.2245	2.3278
17			2.0005	2.2405	2.2996	2.4577	1.9662
Max	2.4528	2.3777	2.343	2.2405	2.5587	2.4577	2.3278
Min	1.7966	1.5257	1.6941	.7274	1.3603	1.4815	1.749
Avg	2.0235	2.0286	2.0932	1.8037	2.2827	2.0934	2.1234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194074 / 33/11 KV SUBSTATION BALSOOR

Feeder No / Name : 203 / 11KV RAMPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.3441	1.5912
2			1.358	1.2763	1.9052	2.0833	
3			1.5813	1.6078	1.9052	2.1605	1.7695
4			1.7185	1.5746	1.9052	2.2725	1.8679
5			1.929	2.0317	2.1862	2.3122	1.8842
6			2.0934	2.0485	2.2558	.2429	2.2447
7			2.3266	2.5143			2.4684
8			2.4905	2.5724			2.5888
9			2.7854	2.3611		2.6566	2.3329
10	1.6385	1.3575					
11	2.0988	2.7149					
12	2.3878	2.7692					
13	2.4036	2.8959					
14	2.4863	2.8959					
15	2.4646	2.8054					
16	2.4806	2.7149					
17	2.7199	2.7511					
24						1.2186	1.3916
Max	2.7199	2.8959	2.7854	2.5724	2.2558	2.6566	2.5888
Min	1.6385	1.3575	1.358	1.2763	1.9052	.2429	1.3916
Avg	2.3350	2.6131	2.0353	1.9983	2.0315	1.7863	2.0155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194075 / 33/11 KV SUBSTATION GUNJOTI

Feeder No / Name : 202 / 11 KV AURAD FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.7602
2							.8669
3							.9602
4							1.2146
5							1.3575
6							1.6575
7							2.0576
8							1.9528
9							1.8595
10	.9335	1.3003	.3201	1.326	1.1888		
11	1.2269	1.5927	.0229	1.4937	1.4529	1.3717	
12	1.6461	1.8898	.0229	1.6766	1.587	1.7497	
13	1.768	1.9204	.0286	.2858	1.6712	1.8747	
14	1.829	2.0458	.0286	1.5935	1.6842	2.0729	
15	2.0243	2.0919	.0286	1.6842	1.2193	2.1376	
16	2.0081	2.0119	.0286	1.749	1.3717	2.2611	
17	1.9757			1.7814	1.8299	2.3758	
24							.4572
Max	2.0243	2.0919	.3201	1.7814	1.8299	2.3758	2.0576
Min	.9335	1.3003	.0229	.2858	1.1888	1.3717	.4572
Avg	1.6765	1.8361	.0686	1.4488	1.5006	1.9776	1.3144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194075 / 33/11 KV SUBSTATION GUNJOTI

Feeder No / Name : 203 / 11 KV KHASGI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4801	
2	.2667	.4001	.4334	.3096	.5944	
3	.3429	.7202	.5201	.5601	.6001	
4	.5944	.8269	.6241	.7468	.6859	
5	1.0402	1.1431	.7202	1.0288	.7775	
6	1.3575	1.4022	.8669	1.2193	1.0402	
7	1.6766	1.5546	1.4232	1.6004	1.5901	
8	1.9109	1.5851	1.5604	1.2346	1.4327	
9	1.5935	1.448		1.2498	1.2193	
10						1.0056
11						1.5604
12						1.5604
13						1.5257
14						1.5777
15						1.5089
16						1.6817
17						1.8004
24					.4108	
Max	1.9109	1.5851	1.5604	1.6004	1.5901	1.8004
Min	.2667	.4001	.4334	.3096	.4108	1.0056
Avg	1.0978	1.1350	.8783	.9937	.8831	1.5276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194080 / 33/11 KV ALOOR

Feeder No / Name : 201 / 11 KV ALOOR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.9431	1.2193	.0884	.0884	.9431	.8573
2	.9945	.9431	1.0288	.0995	.0884	.8573	.8573
3	.9945	.9431	1.0288	.0854	.0884	.9431	.9431
10	.6859		.061	.0488	.7545	.7373	.7716
11			.061	.0564	.703	.6859	.6859
12		.6859		.0533	.6001		.6001
13		.6001	.0488	.0533	.6001	.6001	.6001
14		.6001	.0564	.0518	.6001	.6001	.6001
15	.6001	.6001	.0564	.0518	.5658	.6001	
16	.6001	.6001	.0564	.0518	.5316		.5144
17	.4287		.1753	.2058	2.2291	2.3148	2.3148
18	.5144		.1886	.2126	2.0576	2.3148	2.2291
19	.5144		.1783	.2126	2.0748	2.2291	1.7147
20	1.3717		.1715	.1612	1.286	2.0576	1.9719
21	1.2955		.1543	.1612	1.4575	1.8004	1.7147
22	1.2955	1.2193	.1509	.1543	1.3717	1.5432	1.6289
23	1.3717	1.1431	.144	.1543	1.286	1.5432	1.5432
24	.9945	1.1431	1.0669	.1389	.1526	1.1145	1.5432
Max	1.3717	1.2193	1.2193	.2126	2.2291	2.3148	2.3148
Min	.4287	.6001	.0488	.0488	.0884	.6001	.5144
Avg	.904	.8565	.3439	.1134	.9187	1.3053	1.2406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

OMERGA (R) S/DN[435] BU 2674

Substation No/ Name :- 194080 / 33/11 KV ALOOR

Feeder No / Name : 203 / 11 KV KESARJAWLGA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.9145	.6859	.1029	.0789	.7716	.8573
2	1.0288	.9145	.7621	.1132	.1029	.9431	.9431
3	1.286	1.0669	.6859	.1132	.1235	1.2003	1.1145
4	1.3717		.6859	.1235	.1372	1.286	1.2003
5	1.3717	1.2193	.6859	1.3717	.144	1.4575	1.4575
6	1.4575	1.2193	.6097	.1578	.1646	1.5432	1.5432
7	1.4575	1.1431	.9145	.1852	.1406	1.6289	1.0288
8	1.3717	1.0669	1.0669	.1612	.1372	1.3717	1.0288
9	.3429	.2572	.2572	.0183	.0274	.3086	.2572
10	.4287	.3429	.0229	.0152	.2743		.1715
11	.2572	.3429		.0152	.2058	.1715	.1715
12	.2572	.3429	.0122	.0152		.1715	.1715
13	.2572		.0122	.0152	.1715	.1715	.1715
14	.2572	.2572	.0122	.0122	.1715	.1715	.1715
15	.2572	.2572	.0152	.0122	.1715	.1715	.1715
16	.2572	.3429	.0152	.0152	.1715	.1715	.1715
17	.2572		.0366	.0213	.1715	.1715	.1715
18	.2572		.0366	.0244	.1715	.1715	.1715
19	.3429		.0366	.0305	.3429	.3429	.2572
20	.5144		.0366	.3353	.3944	.4287	.4287
21	.5144		.0335	.0305	.3429	.4287	.4287
22	.5144	.5144	.0305	.0274	.3429	.3429	.3429
23	.4287	.5144	.0244	.0274	.2572	.2572	.3429
24	1.1145	.3429	.3429	.2439	.0274	.2572	.2572
Max	1.4575	1.2193	1.0669	1.3717	.3944	1.6289	1.5432
Min	.2572	.2572	.0122	.0122	.0274	.1715	.1715
Avg	.6930	.6506	.3053	.1328	.1858	.6061	.5430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 201 / 11 kv URBAN TULJAPUR SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717		1.3717		1.4022	1.3717	1.4022
2	1.3375		1.3375		1.3321	1.3375	1.3321
3	1.3203		1.3375		1.2971	1.3375	1.3321
4	1.3375		1.3717		1.2971	1.3546	1.3496
5	1.3717		1.3717		1.3321	1.3717	1.3672
6	1.3889		1.406		1.4022	1.3889	1.4022
7	1.3546		1.3032		1.3496	1.3889	1.3672
8	1.2346		1.2003	1.3146	1.2971	1.3032	1.262
9	1.2003		1.2003	1.262	1.262	1.1317	1.2269
10	1.267		1.262	1.2269		1.1919	1.2308
11	1.2489		1.3321	1.2445		1.2269	1.267
12	1.3032		1.2445	1.2269		1.2795	1.267
13	1.3032		1.2445	1.2269		1.262	1.267
14	1.267		1.1744	1.2445			1.3032
15	1.3213		1.2094	1.2971			1.3394
16	1.3213		1.1919	1.3146	1.3032	1.2445	1.3575
17	1.3575		1.2971	1.3146		1.3672	1.3575
18	1.3032		1.262	1.3321		1.4373	1.3756
19	1.5203		1.4842	1.4723		1.5074	1.4842
20	1.6289		1.6651	1.6301		1.7002	1.6289
21	1.6289		1.6651	1.4373		1.6651	1.6289
22	1.6108			1.5249		1.6301	1.5927
23	1.5927			1.5424		1.595	1.5927
24	1.406	1.5203	1.406	1.448	1.4548	1.4232	1.4899
Max	1.6289	1.5203	1.6651	1.6301	1.4548	1.7002	1.6289
Min	1.2003	1.5203	1.1744	1.2269	1.262	1.1317	1.2269
Avg	1.3749	1.5203	1.3336	1.3565	1.3390	1.3871	1.3843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 202 / 11 kv APSINGA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524		.1524		.2241	1.0364	1.0562
2	.1372		.8078		.9602	1.2193	1.0883
3	.1219		.9907		1.1203	1.1203	1.0883
4	.1219		1.0974		1.1843	1.2269	1.1203
5	.1219		1.0402		1.3123	1.2803	1.3123
6	.1219		1.1869		1.5684	1.6613	1.6004
7			1.547		2.0485	1.8138	2.0805
8			1.5604	1.8724	1.9022	1.7337	1.7604
9			1.4003	1.7604	1.7444	1.4537	1.6004
10	1.406						
11	1.9033						
12	2.0576						
13	2.0233						
14	1.406						
15	1.6289						
16	1.9909						
17	2.0157						
18			.096	.128		.16	.1886
19	.2229		.2229	.192		.192	.2401
20	.2401		.2401	.2241		.2241	.1029
21	.2572		.2401	.2241		.2241	.2172
22	.2229			.2241		.2241	.2172
23	.2229			.2241		.16	.2172
24	.1677	.2229	.1524	.2229	.2241	.823	.9602
Max	2.0576	.2229	1.5604	1.8724	2.0485	1.8138	2.0805
Min	.1219	.2229	.096	.128	.2241	.16	.1029
Avg	.8271	.2229	.7668	.5636	1.2289	.9096	.9282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 203 / 11 KV KAKRAMBA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2317	.0343		.1456	1.7315	1.6987
2	.2324	.0396	.6379	1.3565	1.7764	1.7162
3	.1524		.6356	1.7078	1.8465	1.7216
4	.1966	.0693	.6112	1.7444	1.9113	1.6994
5	.2339	.0846	.6539	1.8495	1.8351	1.7825
6	.2301	.0884	.8581	2.1476	2.1758	2.1491
7			1.1744	2.796	3.009	3.0513
8			2.7091	2.806	2.9439	2.8075
9			2.4837	2.8921	2.7351	2.6977
10	1.8107	.0389	.7773	1.1553	1.1157	1.0982
11	2.6109					
12	2.6078					
13	2.5217					
14	2.5431	1.0867				
15	2.2214	1.0974				
16	2.7526	1.1332				
17	2.963	1.1919				
18	1.2704	1.1622	.1333	.0091	.1158	.1775
19	.2111	.0815	.2271	.1189	.2195	.298
20	.2728	.0876	.2423	.1273	.218	.3048
21	.2614		.2401	.1189	.2294	.2744
22	.2591		.2256	.1105	.2149	.2926
23	.1837		.192	.1059	.1448	.3148
24	.1684	.1829	.0023	.5236	1.3504	1.464
Max	2.963	1.1919	2.7091	2.8921	3.009	3.0513
Min	.1524	.0343	.0023	.0091	.1158	.1775
Avg	1.1398	.4556	.7377	1.1597	1.3867	1.3852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 204 / HANGARGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0472	.0015	.1234		.0514	.0305	.0343
2	.58	.0008	.1234		.0514	.0305	.0343
3	1.3587	.6722	.0495		.0514	.0305	.0343
4	1.4526	.7072	.0457		.0514	.0305	.0343
5	1.515	.7209	.0457		.0514	.0305	.0343
6	1.6286	.7895	.0457		.0514	.0457	.0343
7	1.1553	1.1218					
8	2.2115	1.275					
9	2.1803	1.1309					.0343
10	1.2582	1.2018	.6859	.7545		.7888	.823
11	.032	.1722	1.7466	2.1933	1.1934	2.0695	2.0507
12			1.869	2.1727	1.2689	2.234	2.2161
13			1.9033	2.1094	1.2742	2.3038	2.0774
14			2.0088	1.9818	1.1667	2.1678	1.9875
15			2.0119	1.9143	1.0181	1.9757	1.8785
16			1.9826	2.0908	1.1035	1.4091	1.8443
17			2.2006	2.226	1.3062	1.9951	2.1567
18	.0457		1.2677	1.1919	1.1683	1.2346	1.3474
19	.0457		.1707	.1265	.2096	.221	.0457
20	.0457	.0808	.0457	.0343	.0008	.0343	.0305
21	.0457	.0861	.0457	.0343		.0343	.0305
22	.0533	.0876		.0514		.0343	.0305
23	.0457	.0838		.0514	.8535	.0343	.0305
24	.0457	.1257	.0457	.0457	.0514	.0305	.0343
Max	2.2115	1.275	2.2006	2.226	1.3062	2.3038	2.2161
Min	.032	.0008	.0457	.0343	.0008	.0305	.0305
Avg	.7637	.5161	.8641	1.1319	.6068	.7983	.7647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 205 / 11 KV VIP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403		1.406		1.6221	1.4575	1.5844
2	1.406		1.3717		1.6032	1.4232	1.5466
3	1.3889		1.3717		1.5466	1.3889	1.5089
4	1.406		1.406		1.5466	1.3717	1.5089
5	1.4575		1.4403		1.5844	1.3375	1.5466
6	1.5089		1.5089		1.6598	1.3032	1.5844
7	1.406		1.4918		1.6221	1.3375	1.5466
8	1.2689		1.3203	1.358	1.3957	1.1831	1.358
9	1.3203		1.3546	1.3203	1.4146	1.1488	1.3769
10	1.358		1.4335	1.2637		1.3014	1.2826
11	1.4712		1.3957	1.3203		1.358	1.3203
12	1.0185		1.3392	1.3769		1.4523	1.3392
13	1.0185		1.2449	1.358		1.5089	1.3957
14	1.5089		1.3203	1.4523		1.5466	1.4335
15	1.5466		1.4146	1.5089		1.5466	1.4712
16	1.5089		1.4335	1.4523	1.406	1.6032	1.4712
17	1.3717		1.4712	1.4901		1.5466	1.4146
18	1.3957		1.4146	1.3957		.0566	1.3203
19	1.6787		1.6598			1.6598	1.5466
20	1.8107		1.773	1.7924		1.8484	1.6975
21	1.8484		1.773	1.773		1.773	1.6651
22	1.7353			1.7164		1.8107	1.6651
23	1.6975			1.7353		1.7918	1.5927
24	1.4575	1.6221	1.4403	1.6032	1.6598	1.4918	1.7164
Max	1.8484	1.6221	1.773	1.7924	1.6598	1.8484	1.7164
Min	1.0185	1.6221	1.2449	1.2637	1.3957	.0566	1.2826
Avg	1.4595	1.6221	1.4448	1.4948	1.5510	1.4270	1.4956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 206 / 11 KV SALAGARA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305				.0469	.0457	.0469
2	1.1065				.0469	.0457	.0469
3	1.9898	.0884			.0469	.0457	.0469
4	1.9639	.2027			.0469	.0457	.0469
5	2.0786	.208			.0469	.0457	.0469
6	2.3765	.2164			.0469	.0305	.0469
7	2.6757	.2736					
8	2.6921	.6158					
9	2.5731	.7125					
10	1.0288	.676	.4732	1.4464	.0427	1.2452	1.6316
11			2.0477	2.5629	1.0181	2.3072	2.6574
12			2.4082	2.4379	1.0479	2.7038	2.8014
13			2.3506	2.3903	.9701	2.4966	2.3968
14			2.3174	2.2714	.8909	2.3309	2.3845
15			2.1799	2.2687	.8215	2.3243	2.4196
16			2.4481	2.0302	2.2135	2.5442	2.8396
17			2.7587	2.4867	1.0227	2.7069	3.0277
18	.0857	.0236	1.1104	1.0498	1.0562	1.0894	1.1252
19	.0857	.2751	.0514	.0469		.0625	.0514
20	.0857	.1555	.0514	.0469		.0625	.0514
21	.0857	.0008	.0514	.0469		.0625	.0514
22	.3669			.0469		.0625	.0514
23	.1387			.0469		.0625	.0514
24	.0305			.0514	.0469	.0457	.0492
Max	2.6921	.7125	2.7587	2.5629	2.2135	2.7069	3.0277
Min	.0305	.0008	.0514	.0469	.0427	.0305	.0469
Avg	1.1408	.2874	1.5207	1.2820	.5882	.9698	1.0415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 207 / 11 KV KAKRAMBA GAOTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315	.3658		.4801	.3658	.3734
2	.3201	.3544		.4801	.3658	.3734
3	.3201	.3429		.4801	.3658	.3734
4	.3429	.3887		.5335	.4115	.4001
5	.4801	.4572		.6401	.4801	.5868
6	.5944	.6401		.8002	.663	.6935
7	.6059	.663		.8002	.663	.7468
8	.6401	.6173	.6935	.6935	.5373	.6935
9	.5601	.6059	.6401	.6401	.583	.5868
10	.5335	.5601	.5335		.5335	.4534
11	.4534	.5335	.4001		.5335	.4534
12	.4268	.4268	.4001		.5068	.4268
13	.4268	.4001	.3734		.3201	.3201
14	.2667	.3467	.2934		.2667	.2667
15	.2667	.2934	.2667		.3201	.2401
16	.3734	.3334	.4268	.3201	.4001	.2667
17	.4268	.3201	.4268		.4001	.3201
18	.4801	.4268	.4268		.4801	.4268
19	.6668	.5868	.5335		.6401	.5868
20	.6135	.5868	.7468		.7468	.7468
21	.5868	.5868	.6401		.6935	.6401
22	.5335		.5335		.5868	.4801
23	.4801		.5335		.4801	.3734
24	.3429	.3772	.4534	.4801	.3772	.4001
Max	.6668	.663	.7468	.8002	.7468	.7468
Min	.2667	.2934	.2667	.3201	.2667	.2401
Avg	.4614	.4643	.4895	.5771	.4884	.4679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 208 / 11 KV APSINGA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258		.3258		.4024	.3944	.3658
2	.3086		.3086		.4024	.3772	.3658
3	.3086		.3086		.4024	.3772	.3658
4	.3258		.3429		.4024	.3944	.4024
5	.3944		.7888		.439	.4287	.439
6	.4458		.4458		.5121	.463	.5121
7	.4287		.4801		.5487	.4287	.5121
8	.3944		.3601	.4024	.5121	.3944	.4755
9	.4287		.3258	.3658	.4755	.4458	.439
10	.362		.3658	.3292		.5121	.362
11	.3258		.3292	.4024		.3658	.3258
12	.3258		.3109	.3109		.2561	.2896
13	.3258		.3109	.3841		.2561	.2896
14			.2926	.3109		.2195	.2896
15	.2896		.3292	.2926		.2561	.2896
16	.2896		.3109	.3292	.2915	.3109	.2896
17	.3258		.3292	.3292		.3658	.2896
18	.362		.3658	.3658		.3658	.3982
19	.5068		.4706	.5853		.4755	.4706
20	.5068		.5068	.6219		.6219	.5792
21	.4706		.5068	.5487		.5853	.543
22	.4344			.5121		.5121	.4706
23	.4344			.439		.4755	.4344
24	.3429	.3258	.3429	.3982	.4024	.3944	.4024
Max	.5068	.3258	.7888	.6219	.5487	.6219	.5792
Min	.2896	.3258	.2926	.2926	.2915	.2195	.2896
Avg	.3767	.3258	.3845	.4075	.4355	.4032	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 209 / TIRTH GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.796	.4062	.7892	.4191	.7674	.6401	.7545
2	.7681	.3887	.7559	.4039	.7598	.6508	.7068
3	.7499	.3765	.7392	.3864	.743	.6523	.706
4	.7488	.3795	.7651	.3833	.8215	.6835	.7423
5	.8014	.4092	.8299	.4077	.9176	.7674	.8436
6	.9808	.5175	1.1279	.5075	1.1452	.9706	1.02
7	1.1093	.6706	1.2437	.6668	1.321	1.1896	1.2578
8	1.1047	.6562	1.1866	1.2435	1.2544	1.1393	1.1892
9	1.0189	.5693	1.0715	1.0879	1.044	1.014	1.0402
10	.917	.4733	.9869	.9248	.4405	.8848	.8943
11	.7485	.3117	.8475	.7004	.4336	.6996	.7415
12	.6074		.6851	.5904	.3437	.6069	.628
13	.5891		.6233	.5475	.2995	.6064	.5769
14	.6059	.0648	.6523	.5355	.2972	.5807	.5845
15	.6466	.3391	.5823	.533	.3285	.599	.5571
16	.6481	.317	.5357	.5807	.5963	.5473	.5731
17	.6376	.3368	.6249	.6336	.3117	.5201	.6323
18	.7396	.3666	.7591	.6988	.33	.6627	.7897
19	1.0003	.4702	.9728	.9603	.3902	.9382	1.0033
20	1.1927	.5738	1.2134	1.2681	.535	1.3717	1.2107
21	1.2392	.6401	1.2862	1.2666	.6562	1.3598	1.1931
22	1.1027	.5769	.6219	1.0985	.6066	1.1234	1.0391
23	.9404	.5289	.5213	.9709	.5312	.9065	.8353
24	.8235	.844	.8417	.8364	.8255	.6942	.7796
Max	1.2392	.844	1.2862	1.2681	1.321	1.3717	1.2578
Min	.5891	.0648	.5213	.3833	.2972	.5201	.5571
Avg	.8549	.4644	.8443	.7355	.6542	.8254	.8458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194009 / 33/11 TULJAPUR S/S

Feeder No / Name : 405 / 33KV YEOTI

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	.6859	1.1431	1.2289	1.2003	3.8866	4.0123
2	2.1948	.9145	2.8806	3.2064	3.2236	4.5724	4.3438
3	3.0636	1.6004	4.1152	4.7839	4.0123	4.6639	4.3438
4	3.4751	1.6004	4.2066	5.5556	4.1152	4.7553	4.4467
5	3.658	1.829	4.6182	6.0014	4.5496	5.1669	4.984
6	4.2981	2.2862	5.7156	6.6758	5.8528	6.0356	6.1842
7	5.2583	2.7435	6.6758	6.6987	7.0531	6.5844	7.3845
8	5.0754	2.2862	5.8528	5.807	5.5441	6.2186	6.6415
9	4.8468	.4572	5.2583	4.7553	5.3155	5.7613	6.5158
10	4.6754		4.5954	4.824	2.7435	4.8468	5.0468
11	6.0128		4.4467	4.3438	2.5149	4.1381	4.6753
12	6.2414		4.4467	4.3438	2.2862	4.2409	4.7954
13	6.2414		4.7783	4.2409	2.2862	4.2409	3.3722
14	6.2414	2.5149	4.1381	3.9095	2.2862	3.8066	4.1209
15	6.0242	2.9721	4.2409	3.8066	2.0576	3.8066	4.3495
16	5.7956	3.2007	4.3438	3.7037	3.6122	3.7037	4.2409
17	5.9042	3.2007	4.0123	3.9095	2.0576	3.9095	3.5551
18	3.4065	2.2862	2.6977	2.4691	2.0576	2.4691	2.6006
19	1.3375	.6859	1.3375	.9716	.6859	1.3032	1.2174
20	1.5661	.9145	1.7947	1.6347	.9145	1.8633	1.6747
21	1.5661	.9145	1.5661	1.5318	.9145	1.5318	1.5661
22	1.4575	.6859	.9145	1.2003	.9145	1.2003	1.2289
23	1.2289	.6859	.6859	1.2003	.6859	1.0974	1.2289
24	1.2346	1.2289	1.1431	1.2289	1.6575	2.4234	2.6635
Max	6.2414	3.2007	6.6758	6.6987	7.0531	6.5844	7.3845
Min	1.2289	.4572	.6859	.9716	.6859	1.0974	1.2174
Avg	3.8349	1.6847	3.5670	3.6680	2.8559	3.8428	3.9664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 201 / 11 KV ITKAL AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.2003	1.0479					
3	1.5242	1.4289					
4	1.8099	1.4289					
5	2.0576	1.7147					
6	2.2291	1.9052					
7	2.4768	2.0957					
8	2.3243	2.0957					
9	2.0957	2.0957					
10				1.4289	1.5242	1.3336	1.7147
11			2.0957	1.829	2.0957	2.0005	2.2862
12			2.2862	2.2862	2.0957	2.0386	2.4006
13			2.2862	2.1338	2.0957	2.0576	2.0195
14			2.191	2.0005	2.0957	2.0005	2.0195
15			2.191	1.9052	2.0005	1.9624	2.0195
16			2.0957	1.8671	1.8099	1.848	2.0195
17			2.0957	1.8099	1.6194	1.8099	2.21
Max	2.4768	2.0957	2.2862	2.2862	2.0957	2.0576	2.4006
Min	1.2003	1.0479	2.0957	1.4289	1.5242	1.3336	1.7147
Avg	1.9647	1.7266	2.1774	1.9076	1.9171	1.8814	2.0862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 202 / 11 KV KESHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1905	.1905	.1524	.1524	1.4289	2.0576
2		.1905	1.0479	1.1431	2.0957	1.9052	2.4006
3	.1524	.1905	1.3336	2.0957	2.4006	1.9052	2.7816
4	.1524	.1905	1.3336	2.2862	2.8197	2.4768	2.8387
5	.1524	.1905	1.9052	2.8578	2.934	2.9531	2.934
6	.1524	.1905	2.4768	3.1436	3.0864	2.3815	2.8959
7			3.1436	3.1436	2.9531	3.5246	3.1436
8			3.2388	3.2388	3.2388	3.5246	3.4294
9			3.0483	3.2388	3.0864	3.3341	3.2388
10	2.191	1.8671					
11	2.8578	2.7625					
12	2.8578	2.7625					
13	3.0483	2.7625					
14	3.0483	2.7625					
15	3.0483	2.8578					
16	3.0483	2.9531					
17	3.0483	2.7625					
18	.1905		.1524	.1143	.1524		.2286
19	.2286	.1905	.1905	.1524	.1905	.1143	.2286
20	.1905	.1905	.1905	.1524	.2858	.1524	
21	.1905	.1905	.1905	.1524	.2858	.1524	.1905
22	.1905	.1905	.1524	.1524	.1905	.1524	.1905
23	.1905	.1905	.1524	.1524	.1905	.1524	.1905
24	.1524	.1905	.1905	.1524	.1524	1.3336	1.8099
Max	3.0483	2.9531	3.2388	3.2388	3.2388	3.5246	3.4294
Min	.1524	.1905	.1524	.1143	.1524	.1143	.1905
Avg	1.2622	1.1888	1.1836	1.3955	1.5134	1.6994	1.9039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 203 / 11 KV ITKAL GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6024	.5121	.6268	.6516	.5792	.6878
2	.5906	.5847	.5335	.6089	.6401	.6154	.7421
3	.6653	.5731	.5121	.6154	.7682	.6401	.724
4	.6878	.5731	.5121	.6335	.8779	.7682	.6805
5	.7602	.8192	.6584	.823	.8954	.8316	.8238
6	.8596	.9328	.8048	.9328	.8954	.8316	.8954
7	.8688	.7316	.7316	.5792			.8059
8	.7499	.6697	.8383				.7522
9	.8413	.6878	.724	.7619	.7964	.7522	.7602
10	.6626	.6878	.6379	.5249	.7362	.8145	.6697
11	.6379	.6516	.6201	.5792	.6733	.724	.6556
12	.6379	.583	.6201	.6335	.6201	.7421	.6379
13	.567	.5335	.6241	.6584	.6135	.7602	.631
14	.567	.5335	.6415	.5853	.6135	.7682	.631
15	.6201	.5335	.6661	.6401	.6001	.7421	.6661
16	.6135	.6668	.6836	.6697	.5895	.7059	.7011
17	.6661	.6661	.7202	.7059	.631	.724	.7712
18	.7108	.7087	.7461	.6516	.6344	.7964	.5087
19	.8954	.7796	.8939	.9313	.9214	.8145	.9214
20	.8596	.8764	.8954	.9313	.9214	.9671	.8859
21	.8238	.695	.8507	.8238	.8859	.8775	.815
22	.7522	.6584	.7602	.7164	.8059	.6805	.7602
23	.6805	.6097	.724	.6878	.7522	.7059	.6878
24	.5611	.567	.5487	.6805	.6878	.6447	.6878
Max	.8954	.9328	.8954	.9328	.9214	.9671	.9214
Min	.5611	.5335	.5121	.5249	.5895	.5792	.5087
Avg	.7078	.6635	.6858	.6957	.7369	.7494	.7293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194023 / 33/11 IEETKAL S/S

Feeder No / Name : 204 / 11 KV VAISHNODEVI FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.3048	.3429	.3239	.2667	.2858	.4191
2	.4382	.4191	.4001	.3429	.4001	.381	.4001
3	.4572	.381	.381	.381	.4382	.381	.4001
4	.4954	.381	.381	.381	.4382	.381	.381
5	.5335	.381	.381	.381	.4001	.381	.381
6	.5335	.3429	.4001	.2858	.4001	.1905	.381
7	.362	.2858	.381	.3048	.3239	.2667	.2667
8	.3048	.1905	.362	.3429	.2096	.4191	.1334
9	.2477	.1905	.362	.2858	.2096	.3429	.2477
10	.2858	.2667	.2286	.2667	.1905	.4191	.3429
11	.2858	.3048	.2286	.2286	.1905	.362	.3429
12	.381	.3048	.4191	.1905	.3048	.381	.381
13	.381	.3048	.381	.2096	.2667	.4382	.3429
14	.4001	.2667	.3239	.0953	.3429	.381	.381
15	.3048	.2286	.2667	.1143	.3429	.362	.3429
16	.3048	.2477	.2667	.1143	.2096	.362	.3048
17	.3048	.2096	.2667	.1143	.2667	.381	.381
18	.3429	.2286	.381	.2286	.3429	.4191	.3429
19	.381	.2286	.3048	.2858	.3239	.4382	.381
20	.3429	.2286	.3048	.2286	.3048	.4001	.381
21	.381	.2858	.3048	.2477	.3429	.4001	.3429
22	.381	.2286	.3048	.2096	.3429	.4001	.3429
23	.381	.2667	.2858	.1905	.3429	.381	.3048
24	.4572	.3429	.3048	.2858	.2286	.2667	.4191
Max	.5335	.4191	.4191	.381	.4382	.4382	.4191
Min	.2477	.1905	.2286	.0953	.1905	.1905	.1334
Avg	.3786	.2842	.3318	.2516	.3096	.3675	.3477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194029 / 33 KV TAMALWADI S/S

Feeder No / Name : 201 / 11 KV TAMALWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0747	.0686	.0724	.5761
2	.7122	.8535	.5441	.4801	.6401
3	.8139	.9259	.6554	.583	.7449
4	.9156	1.0494	.6478	.6935	.8097
5	1.0174	1.1069	.7209	.7461	.9175
6	1.1361	1.2483	.7865	.8048	.8288
7	1.4403	1.2955	.8848	.8951	.5898
8	1.4752	1.4255	1.0277	.9831	.5967
9	1.2483				.6299
10	.5967				
11	.7449				
12	.7449				
13	.7682				
14	.7537				
15	.6882				
16	.7865				
17	.8002	.7682			
18	.0747	.0747			
19	1.8298	.0747			
20	.0747	.0747			
21	.0747	.0747			
22	.0747	.0747			
23	.0747	.0747			
24	.0686	.0747	.0686	.0724	.57
Max	1.8298	1.4255	1.0277	.9831	.9175
Min	.0686	.0747	.0686	.0724	.57
Avg	.7076	.5794	.6005	.5923	.6904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194029 / 33 KV TAMALWADI S/S

Feeder No / Name : 202 / INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-MAY-17	16-MAY-17	17-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187	.1296	.0686	.0983	.0972
2	.1029	.1029	.0686	.0995	.0972
3	.1017	.1296	.0686	.0972	.0972
4	.0848	.1296	.0686	.0972	.0972
5	.0848	.1296	.0686	.0972	.0972
6	.1187	.1296	.0686	.0972	.0972
7	.1017	.1296	.1029	.0972	.1326
8	.1017	.1029	.1029	.0972	.0972
9	.1134			.1372	.0972
10	.1524				
11	.1296				
12	.1524				
13	.1296				
14	.1524				
15	.1524				
16	.1524				
17	.2054	.0686			
18	.1296	.0686			
19	.1524	.0686			
20	.1524	.0747			
21	.1296	.0747			
22	.1296	.0747			
23	.1219	.0686			
24	.1187	.1296	.0686	.0972	.0972
Max	.2054	.1296	.1029	.1372	.1326
Min	.0848	.0686	.0686	.0972	.0972
Avg	.1287	.1007	.0762	.1015	.1007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194029 / 33 KV TAMALWADI S/S

Feeder No / Name : 203 / 11 KV TAMALWADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5529	.5578	.6828	.3193	.3132	.511	.5678
2	.503	.5026	.6024	.3006	.3003	.5034	.5937
3	.4916	.5125	.546	.2751	.2835	.5426	.5525
4	.4634	.5106	.5452	.2736	.2824	.5506	.5578
5	.6108	.6005	.6435	.3147	.3189	.6839	.6036
6	.7575	.7102	.7826	.4729	.4123	.7727	.7902
7	.7609	.7106	.7544	.4694	.4199	.6158	.7644
8	.7411	.6672	.7197	.4043	.3696	.6916	.6554
9	.6717	.3711	.3749	.3593	.3498	.5929	.6115
10	.6744		.3669	.1002	.33	.3323	.3395
11	.663		.3003	.3506	.3193	.3502	.3547
12	.6439		.2987	.4111	.3521	.3849	.3452
13	.5959		.3467	.3746	.3224	.3605	.3338
14	.6176		.3174	.2824	.3125	.362	.349
15	.6089		.322	.3041	.2801	.3456	.3353
16	.6565		.3567	.3452	.3685	.3593	.3509
17	.1837	.8863	.3803	.3711	.3826	.3574	.3921
18	.7872	.8749	.3955	.3799	.4169	.3365	.4332
19	.8437	.8795	.3426	.4496	.4626	.1235	.4085
20	.8562	.8963	.4813	.4889	.4668	.5235	.4649
21	.7971	.8978	.4508	.423	.4675	.4592	.4553
22	.786	.8322	.4424	.3997	.4172	.4336	.418
23	.7373	.8047	.3887	.3685	.3555	.3692	.3612
24	.6157	.6257	.6809	.3277	.3098	.5846	.5921
Max	.8562	.8978	.7826	.4889	.4675	.7727	.7902
Min	.1837	.3711	.2987	.1002	.2801	.1235	.3338
Avg	.6508	.6965	.4801	.3569	.3589	.4645	.4846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 201 / 11 KV SALGARA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.5304	.5068	.5068	.543	.439	.4525
2	.6878	.5304	.4887	.5068	.5249		.3982
3	.724	.6584	.4887	.5068	.5249	.5487	.3801
4	.7964	.7865	.5316		.5249		
5	1.086	.7682					
6	1.267	.9877					
7	1.3213	1.134					
8	1.3937	1.262					
9	1.1946	1.2437					
10			.543	.724	.8507	.6584	.7133
11			.9955	.9709	.7682	1.0317	.823
12			1.0317	.9231	.8413	.9955	.8779
13			.9955	.905	.8413	.9955	.9145
14			.7421		.7682	.9412	.9877
15			.905	.905	.8413	.9231	.9511
16	.4207	.3982	.9412	.8145	.8779	1.0136	1.0608
17		.543	.9774	.8688	.8962	.9955	1.0425
18		.6154	.5611	.4706	.5487	.4706	.6584
19				.6335	.6584	.6516	.631
20	.7682	.7964		.6335	.695	.5973	.6584
21	.6401	.6697		.6516	.6767	.5973	.6401
22	.5487	.6878		.5792	.5853	.543	.5487
23	.5121	.5792		.543	.5487	.5068	
24	.4706	.5487	.5068		.543	.5068	.5068
Max	1.3937	1.262	1.0317	.9709	.8962	1.0317	1.0608
Min	.4207	.3982	.4887	.4706	.5249	.439	.3801
Avg	.8310	.7494	.7297	.6964	.6873	.7303	.7203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 203 / 11 KV DEVSINGA TUL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2195	.3258	.2172	.2172	.823	.8145
2	.3258	.2561	.7059	.543	.9412	.9511	.8688
3	.362	.2561	.724	.8145	.9412	1.134	.905
4			.7011	.9774	.9412	1.2071	.9412
5			1.4118	1.3575	.8688	1.7924	1.086
6			1.086	1.5203	.8688	2.0119	1.448
7			1.448		1.7194	2.1033	1.9728
8			1.3575	1.7194	1.8461	2.0485	1.7375
9			1.2308	1.5023	1.7918	1.6827	1.6651
10	.5068	.695					
11	1.3169	1.6108					
12	1.3717	1.5384					
13	1.4266	1.5384					
14	1.4632	1.5203					
15	1.6461						
16	1.6827	1.086	.1086	.1086	.1097	.2534	.1463
17			.2896	.181	.2743	.2896	.2743
18		.2896	.2172	.2896	.3109	.362	.4024
19				.4344	.3475	.4344	.2279
20	.2561			.3982	.3658	.3982	.3658
21	.3658	.3258		.362	.4024	.3982	.2743
22	.2195	.3258		.3258	.5487	.3982	.2195
23	.2195	.3258		.2172	.5853	.362	
24	.2534	.2378	.2172		.2172	.7964	.7964
Max	1.6827	1.6108	1.448	1.7194	1.8461	2.1033	1.9728
Min	.2195	.2195	.1086	.1086	.1097	.2534	.1463
Avg	.7804	.7304	.7557	.6855	.7388	.9692	.8321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 204 / 11 KV WADGAON DEV SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3109	.2715	.2172	.2896	.2926	.2353
2	.5973	.2926	.2715	.2715	.2896	.2743	.2715
3	.724	.7316	.2896	.3077	.2896	.2561	.2715
4	.8688	.8962	.2896		.2896		
5	1.086	.9877					
6	1.267	1.3717					
7	1.3394	1.4815					
8	1.3937	1.4632				.2743	
9	1.1041	1.4266					
10			.7602	1.2936	.5611	.8779	1.0242
11			1.086	1.267	.567	1.5203	1.0425
12			1.1765	1.2308	1.134	1.448	1.0974
13			1.2127	1.2489	1.2071	1.267	
14			1.2127	1.1584	1.2254	1.2308	1.1888
15			1.1946	1.2308	1.2986	1.1946	1.2437
16		.1267	1.2308	1.2489	1.3535	1.3032	1.2986
17		.181	1.2851	1.267	1.2986	1.3032	1.2803
18			.1991	.3439	.2561	.1629	.2926
19				.2715	.3292	.2715	.2926
20	.3658	.3258		.2896	.2561	.3258	.2926
21	.2926			.2896	.2195	.3258	.2743
22	.2561	.2715		.2896	.2195	.3258	.2743
23	.2743	.2715		.2896	.2561	.2715	
24	.2534	.2926	.2172		.2804	.2353	.2353
Max	1.3937	1.4815	1.2851	1.2936	1.3535	1.5203	1.2986
Min	.2534	.1267	.1991	.2172	.2195	.1629	.2353
Avg	.7275	.6954	.7641	.7362	.6116	.6927	.6635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 205 / 11 KV GANDHORA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.4024	.2353	.2534	.2534	.1829	.2172
2	.6154	.5304	.2353	.2534	.2534	.2195	.2172
3	.6335	.5853	.2353	.2534	.2353	.2378	.2353
4	.724	.695	.2896		.2353		
5	1.086	.8779					
6	1.267	1.0974					
7	1.4118	1.134					
8	1.2851	1.3352					
9	1.1946						
10		1.3169	.6878	.9593	.9955	.823	.6584
11			.905	.9774	1.0242	1.4842	.823
12			1.0498	.9955	1.0059	1.448	.8779
13			.9955		1.0425	1.448	1.0059
14			.9774	1.0317	1.0242	1.3575	1.0608
15			1.0136	1.0679		1.1041	1.0242
16	.1463	.181	1.0317	1.1706	1.0425	1.0679	1.0608
17			1.0498	1.2127	1.0608	1.1765	1.0242
18		.3258	.3077	.181	.2743	.2353	.2743
19				.4163	.3841	.4525	.4024
20	.4572	.4887		.4163	.3658	.3982	.3658
21	.2743			.4163	.3475	.362	.3292
22	.2561	.4163		.362	.2743	.362	.3109
23	.2743	.362		.3077	.2561	.2172	
24	.2715	.3292	.2896		.2454	.2172	.2172
Max	1.4118	1.3352	1.0498	1.2127	1.0608	1.4842	1.0608
Min	.1463	.181	.2353	.181	.2353	.1829	.2172
Avg	.6960	.6718	.6645	.6422	.5734	.7108	.5944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194042 / 33/11 SALAGARA SUBSTAION

Feeder No / Name : 206 / 11 KV KILAJ SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3439	.3292	.3439	.3077	.2896	.7316	.6335
2	.3439	.3475	.4525	.4887	.724	.7682	.6335
3	.3439	.3292	.6154	.8145	.8145	.8413	.724
4			.6335	.8688	.905	.8048	.724
5			1.2308	1.267	1.4661	1.2437	1.086
6			1.267	1.3575	1.4661	1.4632	1.267
7			1.6108	1.647	1.5565	1.5546	1.4661
8			1.4118	1.3575	1.3756	1.4632	1.267
9			1.1765	1.1946	1.3394	1.1888	1.1765
10	.8688	.823			1.3756		
11	.9877						
12	1.0974	1.2851					
13	1.1523						
14	1.134	1.1584					
15	1.1523	1.086					
16	1.1888	1.267	.1991	.1629	.1829	.2715	.2012
17			.2353	.2896	.2743	.2534	.2561
18		.3258	.3258	.2896	.3292	.2715	.3109
19		.3982		.3801	.4207	.4163	.4031
20	.4938			.3982	.3681	.4887	.3841
21		.362		.3982	.3681	.4887	.4024
22		.3439		.362	.3841	.362	.3658
23		.3439		.3258	.4024	.362	
24	.362	.3109	.3258	.3077	.2896	.5792	.5792
Max	1.1888	1.2851	1.6108	1.647	1.5565	1.5546	1.4661
Min	.3439	.3109	.1991	.1629	.1829	.2534	.2012
Avg	.7891	.6222	.7560	.6787	.7543	.7529	.6988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 201 / 11 KV GANJEWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0137	.0953	.0137	.0137	.0953	.9526	.0995
2	.0137	.0953	.1063	.1097	1.1431	1.1431	
3	.0137	.0953	.12	.1097	1.1431	1.4861	.1166
4	.0154	.0953	.1286	.1166	1.3336	1.5242	.12
5	.0171	.0953	.1406	.1286	1.4289	1.6766	.1337
6	.0171	.1905	.1543	.1372	1.4289	1.6766	.144
7	.0154	.1905	.1612	.156	1.7147	1.6766	.1578
8	.0103	.0953	.1509		1.9052	1.5242	.1612
9			.144	.1457	1.9052	1.7147	.1543
10	.0823		.0069	.0086	.0953	.0762	.0086
11			.0069	.0086	.0953	.0762	
12	.144		.0069	.0086	.0953	.0762	.0069
13	1.6194		.0086	.0953	.0953	.0069	.0953
14	1.7147		.0103	.0953	.1143	.0069	.0953
15	1.7147		.0103	.0953	.0953	.0069	.0953
16	1.7147		.0103	.0953	.1143	.0086	.0953
17	1.6194		.0103	.0953	.1143	.0086	.0953
18	.1715		.012	.0953		.012	.0829
19	.1715		.0137	.1905	.1143	.0137	.1905
20	.1905		.0171	.1905	.1524	.0171	.1905
21	.1905		.0154	.1905	.1905	.0171	.1905
22	.1905		.0137	.1905	.1524	.0154	.0953
23	.0953		.0137	.0953	.1905	.0137	.0953
24	.0137	.0953	.0137	.0137	.9145		.096
Max	1.7147	.1905	.1612	.1905	1.9052	1.7147	.1905
Min	.0103	.0953	.0069	.0086	.0953	.0069	.0069
Avg	.4431	.1165	.0537	.1037	.6362	.5970	.1146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 202 / 11 KV SAWARGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.048	.5716		.0412	.4763	.4572	.0377
2	.18	1.8099		.0377	.4763	.4954	.0394
3	.204	1.9052		.0412	.4763	.5335	.0446
4	.2332	2.0957		.0429	.4763	.5716	.048
5	.2435	2.3815		.0446	.5716	.5716	.0514
6	.2658	2.6673		.0514	.5716	.5335	.0514
7	.2726	2.8578		.0429	.4763	.5335	.0514
8	.2675	2.8578		.0463	.4763	.4572	.0412
9	.2486			.0291	.4763	.381	
10	.0343			.2023	2.191	2.1338	.2126
11				.2435	2.4768	2.4768	.2383
12	.0291			.2401	2.6673		.2281
13	.381			2.4768	2.6292	.2229	2.4768
14	.4763			2.4768	2.6673	.2246	2.2862
15	.381			2.6673	2.6292	.2315	2.4768
16	.0953			2.6673	2.6673	.2349	.2858
17	.381			2.4768	2.6292	.2349	.2858
18	.381			.1905			
19	.5716			.7621	.5716	.0497	.6668
20	.8573			.8573	.724	.0549	.8573
21	.7621			.8573	.6859	.0514	.8573
22	.7621			.8573	.5716	.048	.7621
23	.7621			.7621	.5716	.0446	.5716
24	.0497	.6668	.0532	.0446	.5335		.0377
Max	.8573	2.8578	.0532	2.6673	2.6673	2.4768	2.4768
Min	.0291	.5716	.0532	.0291	.4763	.0446	.0377
Avg	.3429	1.9793	.0532	.7566	1.2475	.5020	.5731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 203 / 11 KV WADGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.381		.036	.381	1.7147	.1869
2	.0377	.381		.1818	2.0957	2.0957	.192
3	.0446	.381		.2126	2.2862	3.0483	.2023
4	.048	.381		.2366	2.3815	3.2007	.2126
5	.0514	.381		.2589	2.572	3.1626	.2263
6	.0566	.4763		.2709	2.8578	3.1626	.2469
7	.0463	.4763		.2846	3.2388	3.1626	.3018
8	.0412	.4763		.2606	2.9531	3.2769	.2743
9				.2486	3.0483	3.2769	.2538
10	.2332			.0257	.2858	.3048	
11							.0274
12	.2743			.024	.2858	1.829	.0257
13	3.2388			.2858	.2667	.0274	.2858
14	1.9052			.2858	.3429	.0274	.2858
15	3.0483			.2858		.0257	.2858
16	3.0483					.0257	.2858
17	2.8578			.2858	.3429	.0257	.2858
18				.381	.3429	.0291	
19	.4763			.381	.4572	.0394	.5716
20	.5716			.5716	.4954	.0497	.5716
21	.5716			.5716	.5716	.0463	.4763
22	.5716			.5716	.5716	.0412	.4763
23	.4763			.4763	.5335	.036	.381
24	.0377	.381	.0343	.036	1.6385		.1852
Max	3.2388	.4763	.0343	.5716	3.2388	3.2769	.5716
Min	.0377	.381	.0343	.024	.2667	.0257	.0257
Avg	.8416	.4128	.0343	.2806	1.3309	1.3004	.2837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194043 / 33/11 KV SAWARGAO S/S

Feeder No / Name : 205 / 11 KV KEMWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0206	.2858	.0206	.0343	.1905	.3429	.0206
2	.1372	1.3336	.0206	.0206	.1905	.381	.024
3	.1372	1.5242	.0171	.0412	.1905	.4191	.0257
4	.1629	1.7147	.0171	.0429	.1905	.4572	.0309
5	.1869	2.0957	.0274	.0446	.2858	.4954	.0377
6	.2023	2.191	.0343	.0412	.381	.4572	.0446
7	.2281	2.3815	.0377	.0412	.381	.4954	.0412
8	.2332		.0377	.0377	.2858	.4572	.0412
9	.2229		.0274	.024	.1905	.381	.0309
10	.0103	2.2862	.192	.1732	1.7147	1.6766	.1903
11			.2229	.2058	2.191	2.2862	.2298
12	.0069		.2058	.2023		2.4006	.1955
13	.0953		.1869	1.9814	2.2481	.216	2.0005
14	.0953		.1749	2.0957	2.4768	.2229	1.9052
15	.0953		.1663	2.191	2.4387	.2383	1.9052
16	.0953		.1578	2.2862	2.4768	.2401	1.9052
17	.0953		.144	2.0957	2.4768	.2366	2.2862
18			.024	.2858	.1143	.0257	.2858
19			.0343	.381	.1905	.0343	.381
20	.4763		.0412	.381	.3429	.0412	.1905
21	.381		.0377	.381	.381	.0394	.381
22	.381		.0309	.381	.381	.0309	.381
23	.2858		.0257	.2858	.4191	.0257	.2858
24	.0206	.2858	.024	.0257	.381		.0206
Max	.4763	2.3815	.2229	2.2862	2.4768	2.4006	2.2862
Min	.0069	.2858	.0171	.0206	.1143	.0257	.0206
Avg	.1700	1.5665	.0795	.5700	.8921	.5044	.5350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194045 / 33/11 KV BORAGAO SUB STATION

Feeder No / Name : 201 / 11 KV HANGARGA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.1543	1.3717	1.2498	1.7147	1.8861
2	.4877	.4268	.1543	1.3032	1.2193	1.7147	1.869
3	.5335	.4877	.1715	1.2689	1.1584	1.6975	1.8861
4	.5792	.5182	.1715	1.2689	1.1279	1.6461	1.8004
5	.5944	.5335					
6	.6097	.5792					
8				1.4403			
11			.4287		.4287	.3772	
12			.4287	.381	.3944	.3601	
13	1.6309	1.9719	.3944	.3658	.3944	.3429	.3963
14	1.7071	1.8347	.4115	.3353	.3601	.3601	
15	1.7375	1.9376	.4287	.3353	.3601	.3601	
16	1.8747	1.9719	.4287	.3353	.3772		
17	.5792	2.0405	.4458	.3353	.3772	.5144	
18	1.448		.4458	.3506		.5316	
19	1.4937	1.286	.6687	.5944	.6001	.6001	.6401
20	1.387		.6344	.6859	.7545	.7202	.7316
21	.5487		1.3032	1.448	1.6975	1.7147	1.6766
22	.5487	.1715	1.4918	1.4327	1.9204	1.9719	1.8138
23	.5335	.1715	1.4575	1.3413	1.8861	1.8861	1.4632
24	.5182	.503	.1715		1.2803	1.869	1.9719
Max	1.8747	2.0405	1.4918	1.448	1.9204	1.9719	1.9719
Min	.4572	.1715	.1543	.3353	.3601	.3429	.3963
Avg	.9594	.9927	.5439	.8585	.9168	1.0813	1.4668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194045 / 33/11 KV BORAGAO SUB STATION

Feeder No / Name : 202 / 11 KV SINDGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	1.89	.4801	1.8861	.4572	.4973	.5487
2	.6554	1.8747	.4801	1.8519	.4725	.5144	.583
3	.6401	1.8595	.5487	1.8004	.503	.5487	.5487
4	.6401	1.8442	.583	1.7318	.5182	.5658	.5487
5	.5792	.5335	.6516		.4877	.6687	.6001
6	.5335	.5792	.703		.4572	.6687	.6344
13	.6859	2.4006	.5487	2.0424	2.2291	3.2579	2.7435
14	.7468	2.3491		2.21	2.2805	3.3436	2.8654
15	.5792	2.3148	.5316	1.89	2.3148	3.4294	2.8349
16	.7011	2.3148	.5144	2.271	2.3491	3.3436	2.8959
17	.6706	2.2977	.8059	2.4234	2.452	3.3608	3.0331
18	.7164		.8573	2.4539	2.4348	3.3093	2.8654
19	.7011	1.6804		2.3929	2.572	3.1722	2.8045
20	.7316	.6516	.7888	2.1948	2.3148	3.0864	2.5606
21	1.89	.6516	1.8347	.5944		.6001	.5639
22	2.1186	.5658	1.9719	.5639	.6344	.6516	.5487
23	1.9966	.5487	1.9719	.503	.5487	.6344	.4877
24	.6554	1.9052	.5144	1.9376	.4725	.5144	.6001
Max	2.1186	2.4006	1.9719	2.4539	2.572	3.4294	3.0331
Min	.5335	.5335	.4801	.503	.4572	.4973	.4877
Avg	.8832	1.5448	.8616	1.7967	1.3823	1.7871	1.5704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194051 / 33/11 KV HORTI SUBSTATION

Feeder No / Name : 201 / 11 KV HORTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2591	.3721	.3366	.3277	.3155	.3189
2	.3258	.3052	.3582	.3544	.3052	.2883	.3366
3	.3224	.3391	.3982	.394	.2713	.3086	.3224
4	.3258	.3353	.4163	.4525	.3932	.3506	.3982
5	.3429	.4239	.4382	.4938	.4588	.3814	.4298
6	.3856	.5407	.4887	.5729	.5898	.4115	.543
7	.4115	.4915	.4656	.543	.5079	.426	.4807
8	.4607	.4915	.4344	.4938	.4588	.4578	.4681
9	.3601	.4915	.4024	.5175	.4115	.4239	.4656
10	.3189	.3605	.3467	.2949	.3544	.3601	.4733
11	.213	.3506	.2572	.2458	.3292	.3189	.2294
12	.2294	.3086	.2915	.2515	.3077	.2058	.218
13	.213	.2743	.2629	.2347	.2743	.2126	.213
14	.1966	.1966	.2481	.218	.2481	.2353	.213
15	.2294	.2267	.2279	.213	.2454	.2543	.2543
16	.2458	.2458	.2481	.2204	.2058	.2715	.2622
17	.3605	.2321	.2686	.3052	.1928	.2915	.3222
18	.4096	.2743	.2896	.3688	.3224	.3467	.4191
19	.506		.4607	.4096	.4115	.3856	.4409
20	.5868	.3898	.4477	.5596	.3856	.3944	.4915
21	.503		.439	.3391	.4207	.3506	.373
22	.3353	.3189	.3189	.4239	.3772	.362	.3018
23	.3052	.3544	.298	.3856	.3467	.3086	.3052
24	.3189	.2622	.333	.3155	.3277	.3258	.298
Max	.5868	.5407	.4887	.5729	.5898	.4578	.543
Min	.1966	.1966	.2279	.213	.1928	.2058	.213
Avg	.343	.3397	.3547	.3727	.3531	.3328	.3574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194051 / 33/11 KV HORTI SUBSTATION

Feeder No / Name : 202 / 11 HORTI AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6722	.9962	1.1797	1.3765	1.4255
2			.7125	1.0467	1.1469	1.4746	1.4403
3			.7373	1.0031	1.166	1.4899	1.5074
4			.8775	1.0364	1.3565	1.5074	1.5384
5			.8124	1.0936	1.4091	1.6632	1.6842
6			.8697	1.1111	1.4091	1.5684	1.6385
7	2.1136	1.9433					
8	2.1704	2.251					
9	2.2939	2.3304					
10	1.9334	2.1792					
11	2.1052						
12	2.2119	2.0576					
13	2.2119	2.2245					
14	2.13	2.2939					
15	1.5546	2.1052	1.8299	1.9334	2.4006	2.0119	2.3758
16	1.5927	2.0485	1.9006	1.9662	2.516	2.191	2.4577
17	1.4575	2.0243	1.9334	2.13	2.6755	2.13	2.2939
18	1.4575	1.1683	2.0388	2.1628	2.5423	2.3148	2.2043
19	1.3927		1.8884	2.0481	2.3777	1.9433	2.2634
20	1.3108	1.0235	1.8461	2.13	2.2148	1.8842	2.13
21	1.3413	.9181	1.8023	1.9662	1.9662	1.8244	2.0972
22	1.1469	.7188	1.7814	1.9662	1.917	1.7814	1.9662
23		.7287	1.0202	1.5261	1.278	1.3927	1.4582
24			.6401	1.0242	1.3413	1.3927	1.3927
Max	2.2939	2.3304	2.0388	2.1628	2.6755	2.3148	2.4577
Min	1.1469	.7188	.6401	.9962	1.1469	1.3765	1.3927
Avg	1.7765	1.7344	1.3352	1.5713	1.8060	1.7467	1.8671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194051 / 33/11 KV HORTI SUBSTATION

Feeder No / Name : 203 / 11 KV MURTA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5384	1.6385					
2	1.5912	1.2955					
3	1.5384	1.3108					
4	1.7465	1.5729					
5	1.7804	1.6356					
6	1.7804	1.8023					
7			1.2146	1.7328	1.8351	1.8004	1.7029
8			1.2963	1.7604	1.8023		1.7593
9			1.2967	1.7869	1.9161	2.0481	1.9826
10			1.2651	1.8023	1.8679	1.89	1.9227
11			1.1728	1.8138	1.8023	1.9919	1.7814
12			1.186	1.7814	1.7072	1.8842	1.6766
13			1.1873	1.8842	1.7859	1.7532	1.7814
14			1.1279	1.9334	1.7695	1.7974	1.8023
23	1.6766						
24	1.5746	1.6385					
Max	1.7804	1.8023	1.2967	1.9334	1.9161	2.0481	1.9826
Min	1.5384	1.2955	1.1279	1.7328	1.7072	1.7532	1.6766
Avg	1.6533	1.5563	1.2183	1.8119	1.8108	1.8807	1.8012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 201 / 11 KV NANDURI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1898	.193	.2275	.2401	.227	.472	
2	.1901	.198	1.0805	.5144	.4914	.4769	
3	.2279	.2193	.7147	.6859	.7011	.6475	
4	.2662	.3059		.9945	1.0056	.8962	
5	.2649	.3896	.7935	1.2517	1.2914	1.0423	
6	.3021	.439	.9522	1.5432	1.0395	1.0773	
7	.2829	.5153	1.107	1.6461	1.0151	1.0083	
8		.4716	1.0004	1.0718		1.0394	
9	.2474		1.0254	1.0941	1.6617	1.0151	1.0568
10	.9855		.1503	.1631	.1715	.1892	.2283
11	1.0979		.1507	.2291	.2401	.189	.2283
12	1.0979		.189	.2337		.1509	.2337
13	.9858		.1892	.2302	.2347	.1506	.2283
14	.9825	1.6263	.189	.2283	.2347	.1504	.2609
15	.917	1.4685	.1892	.2283			.2609
16	.9155	1.406	.189	.189	.255		.2649
17	.089		.3018	.189	.2539	.1581	.2646
18		.2083	.3018	.227		.1989	.3018
19		.3006	.3734	.2268		.1989	.3015
20		.2818	.3429	.2649		.1989	.3027
21		.2474	.4115	.2649		.2347	.3006
22		.2442	.3944	.2649		.2347	.263
23		.2442	.3086	.3027		.2683	.2257
24	.2282	.2609	.2115	.2743	.2649	.3767	.2347
Max	1.0979	1.6263	1.107	1.6461	1.6617	1.0773	1.0568
Min	.089	.193	.1503	.1631	.1715	.1504	.2257
Avg	.5453	.5011	.4693	.5233	.6058	.4716	.3098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 202 / 11 KV KATGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1139	.0974					
3	.1753	.1305					
4	.2382	.1604					
5	.3052	.2609					
6	.3004	.2936					
7	.4005	.3262					
8		.36					
9	.3004						
10			.1127		.0857	.1131	.0651
11			.2395	.1305	.3429	.2012	.2936
12			.3018	.3414	.3353	.2692	.2922
13			.3342	.3387	.3353	.3025	.2922
14			.3672	.3262		.3014	.2936
15			.3672	.2946			.2922
16			.3684	.3307	.3262		.3285
17			.415	.298	.3262	.2846	.3277
Max	.4005	.36	.415	.3414	.3429	.3025	.3285
Min	.1139	.0974	.1127	.1305	.0857	.1131	.0651
Avg	.2620	.2327	.3133	.2943	.2919	.2453	.2731

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 203 / 11 KV ARALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8729	.7493	.7862	.7888	.9431	.844	
2	1.0199	.8783	.7278	.7888	.945	.8535	
3	1.0357	1.2323	.7468	.823	.9838	.9581	
4	1.3404	1.6155	.8479	.8573	1.0626	.9459	
5	1.6388	1.6309	1.1835	.9945	1.1317	.9934	
6	1.6598	1.8578	1.1835	.9945	1.2436	.6704	
7	1.7071	1.6635	.9788		1.2774	.884	
8		1.6499	.5687			.9081	
9	1.5101					.8676	.7176
10	.5758		1.3077	.6493	.6859	1.0585	.6168
11	.5596		1.3108	1.6729	1.6804	1.1856	1.4351
12	.5223		1.3916	1.5982	1.643	1.3443	1.6388
13	.5387		1.3014	1.5109	1.5424	1.166	1.5894
14	.5324	.5175	1.2696	1.5205		1.0575	1.6046
15	.482	.4656	1.2727	1.4351			1.5004
16	.4566	.4801	1.2742	1.414	1.6046		1.4781
17	.478		1.5089	1.356	1.533	1.2967	1.4452
18	.5121	.7013	.5658	.7536		.7293	.7842
19		1.2363	.6722	.9838		.8619	1.1225
20		.8831	.6859	1.134		.9945	1.1827
21		.9204	.6859	1.2826		1.1401	1.173
22		.9184	.8916	1.315		1.1736	1.134
23		.8831	.823	1.2386		1.1065	1.052
24	.9127	.7852	.779	.823	1.0552	.848	.9389
Max	1.7071	1.8578	1.5089	1.6729	1.6804	1.3443	1.6388
Min	.4566	.4656	.5658	.6493	.6859	.6704	.6168
Avg	.9086	1.0594	.9897	1.1397	1.2380	.9949	1.2133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194076 / 33/11 KV YEOTI SUB STATION

Feeder No / Name : 204 / 11 KV YEOTI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3262		.3772	.3768	.4893	
2	.4934	.2894	.4711	.4801	.5271	.5261	
3	.5292	.3273	.4711	.5144	.5653	.0376	
4	.5287	.4334	.5653	.6516	.716	.7484	
5	.6036	.4545	.8479	.7545	.8078	.7526	
6	.603	.487	.8102	.7888	.9778	.8535	
7	.6017	.5464	.9986	.9602	1.0154	.9901	
8		.4566	.8856	.685		1.0552	
9	.4145		.7914	.6417	.6859	.9431	.726
10	.5464		.3392		.3429	.3015	.1948
11			.3395	.3258	.3772	.2638	.1948
12				.2186	.2012	.2261	.1964
13			.3012	.1987	.2012	.1882	.1957
14	.7561	.7207	.3009	.1948		.2641	.1957
15	.7415	.6984	.2638	.1888			.1952
16	.6826	.7202	.2638	.2261	.1957		.2638
17	.6645		.2641	.2638	.1957	.2214	.3392
18	.2283	.3392	.3395	.3392		.2984	.3772
19		.5087	.5228	.4522		.2984	.5653
20			.3429	.5276		.3978	.603
21			.4801	.6023		.4694	.603
22		.5276	.4458	.6023		.5365	.5653
23		.3768	.4115	.4899		.4359	.5276
24	.3768	.3588	.358	.4115	.4145	.4566	.3688
Max	.7561	.7207	.9986	.9602	1.0154	1.0552	.726
Min	.2283	.2894	.2638	.1888	.1957	.0376	.1948
Avg	.5407	.4732	.4916	.4737	.5067	.4888	.3820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194081 / 33/11 KV KATI SUBSTATION

Feeder No / Name : 201 / 11 KV DAHIWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.6783					
3	.6783					
4	.8478					
5	1.0174					
6	1.1869					
7	1.1869					
8	1.1022					
9	1.0288					
10		.4915	.7545	.7373	.7373	.6783
11		1.0395	.9774	1.065	1.046	.9326
12		1.0898	.9945	1.0486	1.0631	.9326
13		1.073	1.0288	.9831	1.0631	.8478
14		1.0486	1.0117	.8192	1.0974	.8478
15		1.065	1.0117	.4915	1.0631	.9326
16		1.0898	1.0288	1.0159	.9945	.9326
17		1.0814	1.0974	.9831	.9602	.8478
Max	1.1869	1.0898	1.0974	1.065	1.0974	.9326
Min	.6783	.4915	.7545	.4915	.7373	.6783
Avg	.9658	.9973	.9881	.8930	1.0031	.8690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194081 / 33/11 KV KATI SUBSTATION

Feeder No / Name : 202 / 11 KV WANAWADI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.5716	.3961	.4191	.3961	1.3413	1.0288
2	.3961	.5716	1.3546	1.5089	1.4746	1.3413	1.4403
3	.4527	.5716	1.406	1.6766	1.5939	1.5927	1.4752
4	.4904	.5716	1.4918	1.7604	1.6448	1.5927	1.5261
5	.5847	.6668	1.5939	2.0119	1.8991	1.6766	1.6448
6	.6602	.6668	1.6787	2.0119	2.1125	1.7604	1.8482
7	.5093	.6668	1.9161	2.0957	2.2298	2.1795	2.2298
8	.4338	.5716	2.0622	2.0957	2.1963	2.1795	2.1795
9	.3584	.5658	1.7859	1.8442	2.0008	1.9281	1.9448
10	1.3565	1.5432	.2949	.3395	.285	.2829	.2858
11	1.7804		.2683	.3018	.2683	.2452	.2858
12	1.7804	1.6787		.2641	.2347	.2452	.2858
13	1.6956	1.7465	.2515	.2263	.2012	.2641	.2858
14	1.6956	1.7939	.2515	.2263	.2012	.2829	.2858
15	1.6956	1.8778	.2515	.2263	.218	.3018	.2858
16	1.6956	1.643	.2515	.2829	.2347	.3018	.2858
17		1.6108	.2683		.2347	.3395	.381
18	.381	.3584	.3018	.3584	.3018	.3772	.5716
19	.5716		.4024	.4904	.4694	.5093	.6668
20	.6668		.503	.5847	.503	.547	.6668
21	.6668	.547	.503	.5281	.5365	.5847	.6668
22	.6668	.4715	.4694	.4715	.5365	.5093	.6668
23	.5716	.4527	.4191	.4527	.4694	.415	.5716
24	.4338	.5716	.415	.4191	.415	.6706	.9774
Max	1.7804	1.8778	2.0622	2.0957	2.2298	2.1795	2.2298
Min	.3584	.3584	.2515	.2263	.2012	.2452	.2858
Avg	.8678	.9390	.8059	.8955	.8607	.8945	.9370

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194081 / 33/11 KV KATI SUBSTATION

Feeder No / Name : 203 / 11 KV KHUNTEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.381	.6097	.381	.5716	.5335	.5716
2	1.0117	.8478	.5906	.381	.5716	.4954	.5335
3	1.0974	.8478	.5335	.4763	.6097	.4954	.5335
4	1.1488	.8478	.6097	.5716	.6478	.5335	.6097
5	1.2689	.8478	.6287	.5716	.6668	.5716	.6859
6	1.4752	1.0174	.6859	.6097	.5716	.6287	.724
7	1.6617	1.1022	.743	.5716	.5525	.6097	.5525
8	1.6956	1.1869	.5716	.5335	.4954	.5716	.5335
9	1.5769	1.2717	.5716	.381	.4763	.4763	.4763
10	.1905	.4001	.8383	1.0974	1.2616	1.1317	.8478
11	.1905		1.3413	1.5261	1.3108	1.3226	1.1869
12	.1905	.3429		1.4752	1.3927	1.3565	1.1022
13	.1905	.1905	1.3927	1.4922	1.3435	1.3735	1.1022
14	.1905	.3429	1.4754	1.4752	1.3108	1.3904	1.0174
15	.1905	.362	1.4251	1.4582	1.3108	1.3565	1.0174
16	.1905	.362	1.4251	1.3565	1.3108	1.3565	1.0174
17	.1905	.4001	1.4754		1.3108	1.3226	1.0174
18	.2858	.4382	.381	.381	.381	.4001	.2858
19	.381		.5716	.6097	.5716	.6097	.381
20			.5716	.7621	.6097	.7049	.6668
21	.1905	.7621	.5335	.743	.6668	.7811	.4763
22	.381	.743	.5335	.724	.6097	.6859	.381
23	.381	.6859	.4763	.6478	.5716	.6478	.381
24	.5716	.381	.6287	.4763	.6097	.5335	.5906
Max	1.6956	1.2717	1.4754	1.5261	1.3927	1.3904	1.1869
Min	.1905	.1905	.381	.381	.381	.4001	.2858
Avg	.6602	.6553	.8093	.8131	.8223	.8287	.6955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194082 / 33/11 KV SHAHAPUR SUBSTATION

Feeder No / Name : 201 / 11 KV SHAHAPUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0312	.0312		.0312	1.1012	
2	.0312	.0312		1.1248	1.1822	
3	.0312	.0312		1.1873	1.2146	
4				1.2342	1.2631	
5				1.3435	1.4575	
6				1.7185	1.7185	
7				2.1559	1.9433	1.7497
8				2.0778	2.2348	2.1872
9				1.6872	1.7166	2.2184
10	1.6872	1.781				
11		1.9685				
12	1.4842	2.2028				
13	1.9685	2.1872				
14	2.0622	2.1403				
15	2.1403	1.9372				
16	2.1091	1.9841				
17	2.0778					
18	.0156		.0312	.0324		.0324
19	.0312		.0312	.0324	.0312	.0324
20	.0312		.0312	.0324	.0312	.0324
21	.0312		.0312	.0324	.0312	.0324
22	.0312		.0312	.0324	.0312	.0324
23	.0312		.0312	.0324	.0312	.0324
24	.0312	.0312		.0312	1.0688	
Max	2.1403	2.2028	.0312	2.1559	2.2348	2.2184
Min	.0156	.0312	.0312	.0312	.0312	.0324
Avg	.8133	1.3024	.0312	.7991	1.0038	.7055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194082 / 33/11 KV SHAHAPUR SUBSTATION

Feeder No / Name : 202 / 11 KV SHAHAPUR GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.3658			.4755	.4344	.4024
2	.4572	.3841			.4572	.3982	.3841
3	.4755	.4207			.4755	.3725	.4024
4	.5121	.4572			.5304	.4344	.439
5	.6219	.4938			.5853	.5611	.4755
6	.567	.4938			.6036	.6154	.5487
7	.5624	.5304			.7316	.6335	.6584
8	.7316	.7316			.6767	.6697	.6584
9	.6584	.695			.6036	.2353	
10	.6219	.5304			.5121		.3841
11	.5121	.4755		.1463	.4024	.2012	.1448
12	.4024	.3841	.4938	.1463	.439	.4207	.1448
13	.3658	.3658	.3658	.128	.4163	.4572	.1991
14	.4572		.4024	.128	.3982	.439	.3077
15	.4755	.4024	.439	.128	.4344	.4207	.4163
16	.4938		.4755	.4572	.4706	.4755	.543
17	.4938			.5304	.543	.567	.6154
18	.5853				.543	.6584	.6516
19	.6219			.567	.6697	.6219	.7059
20	.6401			.567	.6878	.6401	.724
21	.5304			.5487	.5792	.6036	.6878
22	.4207			.5487	.543		.6697
23	.3841			.5304	.5068	.4938	.543
24	.439	.3292			.5304	.4525	.439
Max	.7316	.7316	.4938	.567	.7316	.6697	.724
Min	.3658	.3292	.3658	.128	.3982	.2012	.1448
Avg	.5188	.4707	.4353	.3688	.5340	.4912	.4846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194082 / 33/11 KV SHAHAPUR SUBSTATION

Feeder No / Name : 203 / 11 KV DAHITANA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0312	.0312	.0312		.0312	.0324	.0312
2	.6562	.6249			.0312	.0324	.0312
3	.7186	.9061	.0312		.0312	.0324	.0312
4	.7499	1.0311					
5	.7655	1.0936					
6	.9374	1.1717					
7	1.1248	1.3123					
8	1.0936	1.3123					
9	.9842	1.2029					
10					.9686		.9686
11				1.2498	1.1561	1.2654	.9555
12			.9374	1.2811	1.2967	1.3279	1.166
13			1.1873	1.3123	1.3441	1.2967	1.1984
14			1.3123	1.2029	1.2308	1.2654	1.2308
15			1.3435	1.1717	1.1822	1.2811	1.2631
16			1.2342	1.1405	1.247	1.1717	1.2308
17				1.0936	1.3117	1.1873	1.1984
18	.0156			.0312	.0324	.0312	.0324
19				.0312	.0324	.0312	.0324
20	.0312			.0312	.0324	.0312	.0324
21				.0312	.0324	.0312	.0324
22	.0312				.0324	.0312	.0324
23	.0312			.0312	.0324	.0312	.0324
24	.0312	.0312	.0312		.0312	.0324	.0312
Max	1.1248	1.3123	1.3435	1.3123	1.3441	1.3279	1.2631
Min	.0156	.0312	.0312	.0312	.0312	.0312	.0312
Avg	.5144	.8717	.7635	.7173	.5587	.5360	.5295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194086 / 33/11 KV MANGRUL

Feeder No / Name : 201 / 11 KV KUMBHARI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0335	.0343	.0343	.0509	.8145	.8145
2	.0339	.0335		.5144	.503	.905	.8145
3	.0339	.0343	.6001	.6516	.6203	.9955	.905
4	.0339	.0335	.6859	.7202	.7209	1.086	.9955
5			.7373	.9259	.8139	1.1765	1.1222
6			.823	1.1145	.9156	1.2127	1.086
7			.9259	1.2517	1.1065	1.3756	1.1765
8	.0339		1.0974	.9835	1.153		1.1946
9			1.0802	.8987			.9496
10	.8718	.9816					
11	1.0682	1.3032					
12	1.2209	1.3203					
13	1.1869	1.3203					
14	1.17	.9088					
15	1.153	1.166					
16	1.1361	1.1488					
17	1.0852	1.1317					
18	.0509	.0343	.0514	.0339	.1448	.0543	.0339
19	.0339	.0343	.0343	.0339	.0362	.0543	.0339
20	.0339	.0343	.0343	.0339	.0362	.0543	.0339
21	.0339	.0343	.0343	.0339	.0362	.0362	.0335
22	.0339	.0343	.0343	.0503	.0362	.0362	.0339
23	.0339	.0343	.0343	.0503	.0362	.0362	.0339
24	.0339	.0335	.0343	.0343	.0509	.724	.724
Max	1.2209	1.3203	1.0974	1.2517	1.153	1.3756	1.1946
Min	.0335	.0335	.0343	.0339	.0362	.0362	.0335
Avg	.4658	.5081	.4161	.4603	.4174	.6115	.6241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194086 / 33/11 KV MANGRUL

Feeder No / Name : 202 / 11 KV MANGRUL AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.1029	.1029	.0857	.1017	.0362	.0526
2	.5087	.5144		.0857	.1017	.0362	.0724
3	.5935	.5658	.0857	.0686	.0848	.0362	.0724
4	.6783	.6687	.0857	.0686	.0848		.0905
5	.7291	.7202					
6	1.0174	.8745					
7	1.2717	1.1831					
8	1.2378	1.2174			.3561		
9	1.1361	1.1145					
10			.6001	.8478	.8145	.905	.763
11			.9431	1.0174	1.0136	.905	.7969
12			.8916	.9835	.9955	1.0136	.8478
13			.9431	.9665	1.0498	1.0136	.8817
14			.9602	.9496	.9774	.9774	.9156
15			.9945	.8478	1.0317	1.1222	.9835
16			1.046	.78	1.0679	1.267	1.0852
17			1.0288	.9665	1.1403	1.3032	1.153
18	.0848	.0857	.0514	.0678	.1629	.0905	.1017
19	.1017	.1029	.1029	.1017	.0905	.0905	.1017
20	.1017	.0857	.1029	.1006	.0724	.0905	.1017
21	.1006	.1029	.1029	.1017	.0724	.0724	.0838
22	.1006	.1029	.1029	.1006	.0724	.0724	.0678
23	.1029	.1052	.1029	.1006		.0724	.0678
24	.0838	.1029	.1029	.1029	.1006	.0362	.0543
Max	1.2717	1.2174	1.046	1.0174	1.1403	1.3032	1.153
Min	.0838	.0857	.0514	.0678	.0724	.0362	.0526
Avg	.4958	.4781	.4639	.4391	.4943	.5078	.4365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-MAY-17 and 21-MAY-17

LATUR ZONE, LATUR[068]

OSMANBAD CIRCLE[667]

TULJAPUR DIVSION[687]

TULJAPUR (R) S/DN[436] BU 2631

Substation No/ Name :- 194086 / 33/11 KV MANGRUL

Feeder No / Name : 203 / 11 KV MANGRUL GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-MAY-17	16-MAY-17	17-MAY-17	18-MAY-17	19-MAY-17	20-MAY-17	21-MAY-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2713	.2743	.2915	.0343	.2543	.2172	.2353
2	.2883	.2743		.5144	.2543	.2534	.2172
3	.3222	.3086	.3086	.2915	.2883	.362	.2715
4	.373	.3601	.3086	.3429	.3018	.4525	.362
5	.4239	.4115	.3944	.4115	.3391	.5068	.4525
6	.5087	.5658	.4801	.5487	.3222	.5611	.5068
7	.3222	.4115	.4115	.4458	.3052	.4525	.4525
8	.3052	.4287	.4458	.3201		.4525	.4706
9	.39	.3772	.4115	.2713	.2353	.5068	.2543
10	.39	.2915	.3086	.2713	.2353	.3077	.2374
11	.3391	.2743	.3258	.2374	.3077	.2896	.2374
12	.3222	.2401	.2572	.2204		.2896	.2204
13	.2883	.2401	.2058	.218	.2896	.2896	.2204
14	.2543		.2572	.2543	.2534	.2715	.2204
15	.2374	.2058	.2572	.2713	.3258	.2534	.2035
16	.2204	.2229	.2572	.2883	.3439	.2896	.1865
17	.2543	.2572	.2401	.285		.3258	.1696
18	.3353	.2915	.3429	.3353	.3439	.5068	.3391
19	.4527	.4801	.5144	.4694	.5068	.5068	.4359
20	.407	.4801	.4115	.4024	.4525	.4706	.4748
21	.373	.3944	.3944	.3856	.362	.4344	.407
22	.3391	.3258	.3429	.2683	.3258	.3258	.3391
23	.3018		.3086	.2713	.2534	.2715	.2883
24	.2713	.285	.2915	.0343	.2543	.1991	.2534
Max	.5087	.5658	.5144	.5487	.5068	.5611	.5068
Min	.2204	.2058	.2058	.0343	.2353	.1991	.1696
Avg	.3330	.3364	.3377	.3080	.3121	.3665	.3107