

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 201 / BHOKAR TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.4572	.4287	.4287	.4287	.4572
2	.3429	.3429	.4572	.4287	.4287	.4287	.4572
3	.3429	.3429	.4572	.4287	.4287	.4287	.3658
4	.3429	.4287	.4572	.4287	.4287	.5144	.3658
5	.5144	.5144	.4572	.4287	.4287	.5144	.4572
6	.6001	.6001	.5487	.5144	.4287	.5144	.5487
7	.6859	.6001	.6401	.6001	.5144	.6001	.5487
8	.6859	.6001	.823	.6001		.6001	.7316
9	.6001	.6001	.7316	.5144		.5144	.6401
10	.6001	.6001	.6001	.5144	.5487	.5487	.6001
11	.5144	.6001	.5144	.5144	.5487	.5487	.6001
12	.5144	.6001	.5144	.0514	.5487	.5487	.6001
13	.4287	.5144	.5144		.5487	.4572	.5144
14	.4287	.5144	.4287		.5487	.4572	.6001
15	.4287	.4287	.5144		.5144	.5487	.5144
16	.4287	.4287	.6001		.5144	.5487	
17	.4287	.5487	.5144	.5144	.5144	.5487	.6001
18	.4287	.5487	.5144	.6001	.0514	.5487	.6001
19	.5144	.5487	.5144		.5144	.5487	.6001
20	.4287	.5487	.5144	.6001	.5144	.5487	.5144
21	.4287	.5487	.5144	.5144	.5144	.0549	.5144
22	.4287	.5487	.5144	.5144	.5144	.5487	.5144
23	.3429	.4572	.4287		.4287	.4572	.4287
24	.3429	.3429	.5121	.4287	.4287	.4287	.4572
Max	.6859	.6001	.823	.6001	.5487	.6001	.7316
Min	.3429	.3429	.4287	.0514	.0514	.0549	.3658
Avg	.4644	.5063	.5310	.4792	.4700	.4953	.5318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 202 / BHOKAR TOWN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	1.0288	1.0974	.1029	1.0288	1.1145	1.1888
2	.9431	1.0288	1.0974	1.0288	1.0288	1.1145	1.1888
3	.9431	1.0288	1.0974	1.0288	1.0288	1.1145	1.0974
4	.9431	1.1145	1.0974	1.0288	1.0288	1.1145	1.0974
5	1.1145	1.2003	1.0974	1.0288	1.0288	1.2003	1.2803
6	1.2003	1.286	1.2803	1.2003	1.1145	1.0669	1.4632
7	1.3717	1.3717	1.6461	1.3717	1.286	1.286	1.5546
8	1.4575	1.4575	1.6461	1.4575		1.286	1.4632
9	1.3717	1.286	.5487	1.286		1.2003	1.4632
10	1.2003	1.286	1.286	1.2003	1.4632	1.2803	1.286
11	1.1145	1.2003	1.2003	1.2003	1.2803	1.2803	1.286
12	1.1145	1.2003	1.2003	1.2003	1.2803	1.1888	1.286
13	1.0288	1.1145	1.1145		1.2803	1.2803	1.3717
14	1.0288	1.1145	1.0288		1.1888	1.2803	1.3717
15	1.0288	1.0288	1.0288		1.0288	1.2803	1.2003
16	1.0288	1.1145	1.0288		1.0288	1.1888	
17	1.0288	1.2803	1.1145	1.1145	1.0288	1.1888	1.286
18	1.0288	1.2803	1.2003	1.2003	1.0288	1.3717	1.3717
19	1.2003	1.4632	1.4575		1.4575	1.5546	1.3717
20	1.2003	1.3717	1.3717	1.3717	1.3717	1.4632	1.3717
21	1.2003	1.2803	1.286	1.2003	1.286	1.3717	1.3717
22	1.0288	1.2803	1.2003	1.1145	1.2003	1.2803	1.286
23	1.0288	1.0974	1.1145		1.2003	1.1888	1.2003
24	1.0288	1.0288	1.0974	1.0288	1.0288	.1115	1.1888
Max	1.4575	1.4632	1.6461	1.4575	1.4632	1.5546	1.5546
Min	.0943	1.0288	.5487	.1029	1.0288	.1115	1.0974
Avg	1.0720	1.2060	1.1807	1.1203	1.1681	1.2003	1.3064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 203 / BATALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.381	.5121	.4287	.5144	.9145	.9145
2	.4287	.381	.4572	.4287	.5144	.9145	1.2803
3	.4287	.381	.4572	.4287	.5144	1.0669	1.3717
4	.4287	.381	.4572	.4287	.5144	1.2193	1.6461
5					.5144	1.2193	1.829
6					.5144	1.448	2.3777
7						2.1338	2.9264
8						2.2862	2.9264
9						2.4387	2.8349
10						2.652	2.7435
11	2.2862	2.4006	2.0576	1.6766	2.5606		
12	2.4387	2.915	2.7435	2.5911	3.1093		
13	2.2862		2.8292		3.0178		
14	2.21	2.2291	2.8292		2.9264		
15		3.0007	2.915		2.4387		
16		3.0007	3.0864		2.4387		
17		3.2922	3.0007	2.915	2.5149		
18	2.21	3.2007	2.915		2.4387		
19	.4572	.4572	.4287		.4572	.4572	.5144
20	.4572	.4572	.4287	.5144	.4572	.4572	.5144
21	.4572	.4572	.4287	.5144	.4572	.4572	.6001
22	.4572	.4572	.4287	.5144	.4572	.5487	.5144
23	.381	.4572	.4287		.381	.4572	.5144
24	.4287	.381	.5121	.4287	.5144	.9145	.7316
Max	2.4387	3.2922	3.0864	2.915	3.1093	2.652	2.9264
Min	.381	.381	.4287	.4287	.381	.4572	.5144
Avg	1.0523	1.4253	1.4953	.9881	1.3628	1.2241	1.5150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 204 / NARWAT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6097	.7316	.0686	.8573	.4572	.7316
2	1.0288	.6097	.9145	.8573	1.0288	.4572	.7316
3	1.0288	.9145	.9145	.8573	1.0288	.5335	.7316
4	1.0288	1.0669	1.0059	.8573	1.2003	.5335	.7316
5	1.2003	1.0669	1.0974	1.0288	1.3717		
6	1.8861	1.1431	1.1888	1.1145	1.4575	.5335	
7	2.2291	2.2862	2.2862	2.1434	2.4006		
8	2.915	2.5911	3.1093	3.1722			
9	3.0007	2.6673	2.9264	3.0007			
10	2.4863	2.4863	2.572	2.5911	2.7435		
11						2.3777	2.0576
12						2.9264	.2572
13						2.8349	2.4863
14						2.652	2.3148
15	2.2862	.2572				2.7435	2.4863
16	2.2862	.3429				2.8349	
17	2.4387		.2572	.3429	.3048	2.8349	2.4006
18	.6097		.4287	.5144	.381	2.3777	2.4006
19	.6097	.7316	.6859		.6097	.7316	
20	.6097	.7316	.6859	.6859	.6097	.7316	.6859
21	.5335	.7316	.6859	.6859	.6097	.7316	
22	.4572	.7316	.6859	.6859	.5335	.7316	
23	.4572	.6401	.6001		.5335	.7316	
24	.6001	.4572		.6001	.6001	.4572	.7316
Max	3.0007	2.6673	3.1093	3.1722	2.7435	2.9264	2.4863
Min	.4572	.2572	.2572	.0686	.3048	.4572	.2572
Avg	1.4189	1.1148	1.2221	1.2004	1.0169	1.4848	1.4421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 205 / MANJIT COTTON EXP. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.0514	.5487	.6001	.5144	.5144	.5487
2	.5144	.0514	.5487	.6001	.5144	.5144	.5487
3	.5144	.0514	.5487	.6001	.5144	.5144	.5487
4	.5144	.5144	.5487	.6001	.5144	.5144	.5487
5	.5144	.5144	.5487	.6001	.5144	1.2003	.6401
6	.5144	.5144	.5487	.6001	.5144	.5144	.6401
7	.6001	.3429	.6401	.6001	.5144	.5144	.6401
8	.06	.3429	.6401	.6001		.5144	.6401
9	.6001	.3429	.5487	.2572		.5144	.4572
10	.6001	.0171	.6001	.2572	.3658	.6401	.4287
11	.6001	.3429	.6001	.2572	.5487	.6401	.5144
12	.6001	.3429	.6001	.2572	.6401	.6401	.5144
13	.6001	.3429	.6001		.5487	.5487	.5144
14	.6001	.3429	.6001		.5487	.5487	.3429
15	.6001	.1715	.6001		.5144	.5487	.2572
16	.6001	.1715	.5144		.5144	.5487	
17	.3429	.1829	.5144	.5144	.5144	.5487	.5144
18	.3429	.1829	.5144	.6001	.5144	.5487	.5144
19	.3429	.0914	.6001		.5144	.6401	.5144
20	.5144	.2743	.6001		.5144	.5487	.5144
21	.5144	.2743	.6001	.5144	.5144	.5487	.5144
22	.6001	.5487	.6001	.3429	.5144	.6401	.6001
23	.6001	.5487	.6001		.5144	.6401	.4287
24	.5144	.5144	.5487	.6001	.5144	.5144	.5487
Max	.6001	.5487	.6401	.6001	.6401	1.2003	.6401
Min	.06	.0171	.5144	.2572	.3658	.5144	.2572
Avg	.5133	.2948	.5756	.4942	.5180	.5858	.5189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 206 / EXP. FEEDER W/S BKR(SUDHA) NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0914	.0857		.0857	.0914
2	.0857	.0857	.0914	.0857		.0857	.0914
3	.1715	.0857	.1829	.0857		.0857	.0914
4	.1715	.0857	.1829	.0857	.0857	.0857	.0914
5	.1715	.0857	.1829	.0857	.1715	.1715	.0914
6	.1715	.1715	.1829	.0857	.1715	.1715	.1829
7	.1715	.1715	.1829	.1715	.1715	.1715	.1829
8	.1715	.1715	.1829	.1715		.1715	.1829
9	.1715	.1715	.1829	.1715		.1715	.1829
10	.1715	.1715	.1715	.1715	.1829	.1829	.1715
11	.1715	.1715	.1715	.1715	.1829	.1829	.1715
12	.1715	.1715	.1715	.1715	.1829	.1829	.1715
13	.1715		.0857		.0914	.1829	.1715
14	.0857	.1715	.0857		.0914	.0914	.0857
15	.0857	.1715	.0857		.0857	.1829	.0857
16	.0857	.1715	.0857		.0857	.1829	
17	.0857		.0857		.0857	.0914	.0857
18	.0857		.0857		.0857	1.3717	.0857
19	.0857	.0914	.0857		.0857	.0914	.0857
20	.0857	.0914	.0857		.0857	.0914	.0857
21	.0857	.0914	.0857		.0857	.0914	.0857
22	.0857	.0914	.0857		.0857	.0914	.0857
23	.0857	.0914	.0857		.0857	.0914	.0857
24	.0857	.0857	.0857	.0857		.0857	.0914
Max	.1715	.1715	.1829	.1715	.1829	1.3717	.1829
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.1250	.1279	.1253	.1253	.1168	.1831	.1190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 201 / MATUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.5426		.0457	.4915	.8139	.6783
2	.4115	.5087	.0514	.0457		.8573	.6706
3	.4115	.5087	.0457	.0457		1.0288	.6783
4	.4115	.503	.0457	.0457	.4915	1.3032	1.0059
5						1.2887	1.0059
6						1.3413	1.1603
7						1.3565	1.1797
8						1.5089	1.3599
9						1.5089	1.3283
10						1.5424	1.166
11	1.166	.1189	.0884	1.0814	1.3565		
12		.1296	.1128	1.166	1.4754		
13	1.5432	.1311	.1219	1.278	1.5581		
14	1.5775	.1311		1.2452	1.5223		
15		.125	.1158	1.3108	1.4899		
16	1.6118	.1219		1.3927	1.5249		
17	1.5432	.1143		1.4251	1.5939	.57	.0427
18	1.4746	.1067		1.3279	1.3599	.6642	.0488
19	.6859	.0514	.7202	.8619	.8002	.9114	.061
20		.0579	.0579	.7625	.7449	.7712	.0701
21	.7122	.061	.0579	.7042	.6478	.7087	.064
22	.6443	.0549	.0533	.6299	.6783	.6733	.0579
23	.6173		.0488	.5571	.5087	.6447	.0549
24	.5087	.583	.0488	.0457		.503	.5765
Max	1.6118	.583	.7202	1.4251	1.5939	1.5424	1.3599
Min	.4115	.0514	.0457	.0457	.4915	.503	.0427
Avg	.9177	.2265	.1207	.7762	1.0829	.9998	.6227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 202 / BENDRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3353	.0274	.0274	.3315	.3506	.5144
2	.3506	.3391	.0274	.0244		.5258	.5144
3	.3155	.3429		.0274		.5201	.5144
4	.3086	.3353	.0291			.5258	.6104
5						.6173	.6371
6						.6173	.6371
7						.6706	.6478
8						.4801	.7773
9						.6443	.506
10						.6516	.6371
11	.407	.061	.061	.7537	.6516		
12	.8048	.0732	.0655	.8421	.78		
13	.7712	.0892	.0808	.8097	.8383		
14	.5243	.0762	.0762	.7449	.8383		
15	.6882	.0686	.0732	.852	.9054		
16	.7125	.0772		.8848	.9054		
17	.7537	.064		.9175	.8478	.2743	.024
18	.7537		.7888	.7956	.7625	.3277	.0309
19	.426	.0305	.3772	.3647	.3688	.407	.0343
20	.4115	.0381	.0412	.4024	.3688	.407	.0446
21	.4024	.0335	.036	.3978	.3688	.407	.0394
22	.3688	.0305	.0343	.3688	.3429	.407	.0377
23	.3688		.0309		.3429	.3898	.0343
24	.3647	.3647	.0309	.0274		.3506	.3429
Max	.8048	.3647	.7888	.9175	.9054	.6706	.7773
Min	.3086	.0305	.0274	.0244	.3315	.2743	.024
Avg	.5046	.1475	.1187	.5150	.6181	.4763	.3658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 203 / SONARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	2.0995	1.2887	1.0539	2.0485	1.6987	1.8435
2	1.4022	2.5397	1.5196	1.3064	2.3061	1.6545	1.858
3	1.4022	2.8883	1.6239	1.4472	1.2803	1.7376	1.8092
4	1.3717	3.1039	1.7436	1.5501	1.3817	1.7376	1.8922
5	1.4922	3.1586	1.8397	1.5958	1.4548	1.0905	1.1385
6	2.0348	3.6717	2.0988	1.8846	1.6926		
7	2.2131	5.0534	2.8731	2.6582	2.3213		
8	2.6155	5.737	3.267	3.3257	2.7397		
9	2.8837	5.8155	3.546	3.2564	2.7503		
10	2.4813	2.8106	3.341	2.9561	2.7481		
11		2.6894	2.6772	2.505	2.6261	3.2853	1.8823
12						4.9322	3.0872
13						4.9672	2.982
14						5.1616	2.7831
15						2.7968	2.8479
16						5.0205	2.6246
17	.6241	.4809	.3917	1.2834	1.1409	3.5544	2.7503
18	.823	.8314	1.8282	1.6233	1.4746	4.2784	2.5278
19	1.0288	1.1569	2.1651	2.3457	2.0401	3.3341	.8696
20	1.0288	1.2239	1.3107	2.3343	2.1651	2.2345	1.2505
21	.9602	1.1972	1.2125	2.2245	2.1552	2.1643	1.2559
22	.9259	1.1873	1.1766	2.1536	2.0828	2.1941	1.2475
23	.8916	1.0501	1.1363	1.1073	1.8984	2.034	1.1492
24	1.832	1.824	1.0722	1.1104	1.8969	3.4301	1.9068
Max	2.8837	5.8155	3.546	3.3257	2.7503	5.1616	3.0872
Min	.6241	.4809	.3917	1.0539	1.1409	1.0905	.8696
Avg	1.5041	2.5536	1.9006	1.9854	2.0107	3.0161	1.9845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 202 / PALAJ AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.0669	1.4746	1.6385	1.7147		
2	1.0669	1.0669	1.6385	1.9662	1.7147		
3	1.2193	1.2193	1.6385	2.13	2.0576		
4	1.5242	1.2193	1.6385	2.2939	2.0576		
5	1.5242	1.6766	1.8023	2.4577			
6	1.829	1.829	2.2939	2.4577	2.0576		
7	2.2862	1.9814	2.7035	2.6216	2.4006		
8	2.2862	2.1338	2.6543	2.7854	2.2862		
9	2.2862	2.2862		2.7035	2.2862		
10	2.1338	2.2862		2.6543			
11						2.4577	3.4294
12						2.6216	3.4294
13						2.8673	3.2579
14						3.0312	3.2579
15						3.0312	3.2579
16						2.9492	3.2579
17						2.7035	3.1722
18						2.3758	3.1722
Max	2.2862	2.2862	2.7035	2.7854	2.4006	3.0312	3.4294
Min	1.0669	1.0669	1.4746	1.6385	1.7147	2.3758	3.1722
Avg	1.7223	1.6766	1.9805	2.3709	2.0719	2.7547	3.2794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 203 / KINI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1772	.1772	.1772	.2058	.1772	.1772
2	.1772	.1772	.1772	.1772	.2058	.1772	.1772
3	.2126	.2126	.2126	.2126	.2058	.2126	
4	.2126	.2126	.2195	.2126	.2743	.2126	.2481
5	.2481	.2481	.2481	.2481		.2481	.2835
6	.2481	.2481	.2481	.2835	.3086	.2481	.3189
7	.2835	.2835	.2835	.2835	.3086	.2835	.3189
8	.2481	.2835	.2835	.2835	.2481	.2835	.2481
10							.2058
11	.1772	.1772		.1715		.2126	.1715
12	.1417	.1772		.1715	.2126	.2126	.1372
13	.1417	.1417	.1417	.1715	.1772	.1772	.1372
14	.1417	.1417	.1595	.1715	.1417	.1417	.1372
17	.2126	.2126	.2126	.1715	.2126	.2481	.2058
18	.2835	.2481	.2481	.2058	.2481	.2835	.2743
19	.2835	.2835	.2835		.2835	.3189	.3086
20	.2481		.2835	.2743	.2835	.3189	.2743
21	.2126	.2835	.2481	.2743	.2481	.2835	.2401
22	.2126	.2481	.2481	.2401	.2126	.2481	.2401
23	.1772	.2126	.2126	.2058	.1772	.2126	.2401
24	.1772	.1772	.1772		.2058	.1772	.1772
Max	.2835	.2835	.2835	.2835	.3086	.3189	.3189
Min	.1417	.1417	.1417	.1715	.1417	.1417	.1372
Avg	.2109	.2182	.2258	.2187	.2311	.2339	.2261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 204 / PALAJ GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2195	.2195	.2195	.2572	.2195	.2195
2	.2195	.2195	.2195	.2195	.2572	.2195	.2195
3	.2561	.2561	.2561	.2561	.2572	.2561	.2561
4	.2561	.2561	.2561	.2926	.0309	.2561	.2926
5	.2926	.2926	.2561	.3292		.2926	.2926
6	.2926	.2926	.2926	.3292	.3258	.2926	.3292
7	.3292	.3292	.3292	.3292	.3258	.3292	.3292
8	.3292	.3292	.2926	.2926	.2926	.3292	.2561
11	.2561	.2195		.2058		.2561	.2401
12	.2195	.2195		.2058	.2926	.2195	.2229
13	.1829	.1829	.2012	.2058	.2561	.2195	.2058
14	.1829	.1829	.2012	.2058	.2195	.1646	.2401
17	.2561	.2561		.0171	.2561	.2561	.2743
18	.2926	.3292	.3292	.2572	.2926	.2561	.3086
19	.3292	.3658	.3658	.3086	.3292	.3292	.3429
20	.3292		.3292	.3086	.3292	.3292	.3258
21	.2926	.3292	.3292	.3086	.2926	.3189	.3258
22	.2561	.2926	.2926	.2743	.2561	.2926	.0309
23	.2195	.2561	.2561	.2572	.2195	.2561	.3086
24	.2195	.2195	.2195		.0257	.2195	.2195
Max	.3292	.3658	.3658	.3292	.3292	.3292	.3429
Min	.1829	.1829	.2012	.0171	.0257	.1646	.0309
Avg	.2616	.2657	.2733	.2538	.2509	.2656	.2620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174090 / MOGHALI

Feeder No / Name : 201 / MOGHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174090 / MOGHALI

Feeder No / Name : 202 / SHIRUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174090 / MOGHALI

Feeder No / Name : 203 / KAMANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 201 / SINGARWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1989	.2486	.2321	.2486	.2486	.2321	.3315
2	.1989	.2486	.2652	.2486	.2486	.3315	.4144
3	.1989	.2486	.2652	.2486	.2486	.3647	.4144
4	.1989	.2486	.2652	.2486	.2486	.3647	.431
5						.431	.4641
6						.4641	.5304
7						.5304	.5636
8						.6299	.6962
9						.4641	.6962
10						.5304	.663
11	.5967	.5636	.6299	.4807	.4973		
12	.6299	.5967	.6962	.5967	.7293		
13	.663	.6299	.6299	.5304	.6962		
14	.663	.5967	.5304	.5636	.663		
15	.6133	.5636	.5636	.5636	.5967		
16	.6299	.5636	.5636	.5801	.6299		
17	.663	.6299	.5967	.5636	.5967	.1492	.1492
18	.5801	.5636	.5967	.5636	.5636	.1989	.1989
19	.2984	.2984	.2486	.2984	.2321	.3481	.2984
20	.3481	.2984	.2486	.2984	.2652	.2984	.2984
21	.2486	.2984	.2486	.2984	.2652	.2984	.2984
22	.2486	.2652	.2486	.2984	.2652	.2984	.2984
23	.2486	.2652	.2486	.2486	.2652	.2984	.2984
24	.2321	.2486	.2321	.2486		.2652	.2984
Max	.663	.6299	.6962	.5967	.7293	.6299	.6962
Min	.1989	.2486	.2321	.2486	.2321	.1492	.1492
Avg	.4144	.4098	.4061	.3960	.4271	.3610	.4080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 202 / SAWARGAON MAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.9069	.8097	.8907	.8907	.0648	.0648
2	.7459	.9069	.8097	.9393	.9393	.0648	.0648
3	.8097	.9231	.8421	.9393	.9717	.0648	.0648
4	.8421	.9393	.8745	.9393	.9717	.0648	.0648
5	.8745	.9393	.9069	.9717	.9717		
6	1.0526	.9717	1.004	1.004			
7	1.1984	1.166	1.166	1.1984			
8	1.2631	1.1984	1.3279	1.1984	.7773		
9	1.2308	1.2308	1.2308	1.2955	1.2266		
10	1.2308	1.1984	1.1984	1.2308			
11						1.1984	1.166
12						1.1012	1.2308
13						1.2631	1.2308
14						1.1984	1.2146
15						1.166	1.1984
16					.0332	1.166	1.1984
17	.0324	.0324	.0486	.0486	.0324	1.1984	1.1984
18	.0324	.0324	.0486	.0486	.0324	1.1984	1.1984
19	.0648	.0972	.0486	.0486	.0648	.0648	.0648
20	.0648	.0648	.0486	.0486	.0648	.0648	.0648
21	.0648	.0648	.0486	.0486	.0648	.0648	.0486
22	.0648	.0648	.0486	.0486	.0648	.0648	.0648
23	.0648	.0648	.0486	.046	.0648	.0648	.0648
24	.0486	.0486	.0648	.0486		.0648	.0648
Max	1.2631	1.2308	1.3279	1.2955	1.2266	1.2631	1.2308
Min	.0324	.0324	.0486	.046	.0324	.0648	.0486
Avg	.5741	.6028	.5875	.6108	.4781	.5632	.5704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 203 / DEWTHANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.1326	.1326	.1658	.116	.1658	.1492
2	.1658	.1326	.1326	.1989	.1326	.1658	.1492
3	.1658	.1326	.1326	.1989	.1326	.1658	.1492
4	.1658	.1658	.1658	.1989	.1326	.1326	.1492
5	.1658	.1658	.1658	.1989	.1326		
6	.2321	.1658	.2652	.1989			
7	.2984	.2321	.3315	.3315			
8	.3315	.3978	.431	.3978	.2652		
9	.2984	.3315	.3647	.3978	.2984		
10	.2984	.3315	.3315	.431			
11						.2321	.2652
12						.3315	.3315
13						.3315	.2984
14						.2984	.2321
15						.2984	.1989
16						.2984	.2321
17	.0663	.0995	.0497	.0995	.0995	.2652	.2321
18	.0995	.1326	.0497	.0995	.0995	.2652	.2321
19	.1989	.1658	.1492	.1989	.1989	.0995	.1989
20	.1989	.1658	.1492	.1989	.1989	.1989	.1989
21	.1492	.1658	.1492	.1989	.1989	.1989	.1989
22	.1492	.1658	.1492	.1989	.1658	.1492	.1989
23	.1492	.1658	.1492	.1989	.1658	.1492	.1492
24	.1658	.1492	.1658	.1492		.1658	.1492
Max	.3315	.3978	.431	.431	.2984	.3315	.3315
Min	.0663	.0995	.0497	.0995	.0995	.0995	.1492
Avg	.1925	.1888	.1925	.2256	.1670	.2173	.2063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 201 / BHOSI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573			.7811	.6859	.3048	
2					.7716	.3353	
3				1.1812	.8573	.3658	
4	1.1812			1.2955	.6859	.442	
5					1.0288		
6				2.0005	1.286		
7	2.1091	2.0957		2.2862			
8	2.2862		2.17	2.3434			
9				2.2862			
10			1.9685	2.0957			
12						1.9433	2.2862
14					.1734		
15					.1867		
16	.16				.1867	1.5384	2.0957
17			.4191	.3086	.2134		
18	.2401	.2481		.3429		1.7029	
19	.3963			.4458			
20	.4115	.2953	.5335	.4458		.2972	
21	.3963			.4458			
22	.381		.4572	.4115			
23	.3353			.4115			.4954
24	.4001	.3201	.2599	.4191	.3772	.2801	.2858
Max	2.2862	2.0957	2.17	2.3434	1.286	1.9433	2.2862
Min	.16	.2481	.2599	.3086	.1734	.2801	.2858
Avg	.7629	.7398	.9680	1.0938	.5866	.8011	1.2908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 202 / WAKAD FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335			.5144	.4287	.2134	
2					.5144		
3				.6097	.5487	.2	
4	.724			.6859	.6859	.2	
5					.7716		
6				1.086	.8573		
7	1.467			1.5242			
8	1.8099		1.2498				
9				1.7718			
10			1.1405	1.4861			
12							1.7528
16						1.4998	1.6194
17	.0934		.0953	.1715	.1067		
18	.1334	.1143		.2058	.16		1.467
19	.2743			.3258	.2267		
20		.2058	.3239	.3258		.2286	
21	.2134			.2915			
22	.2134		.3429	.2915			
23	.2			.2915			.3429
24	.2667	.2	.1715	.2667	.2743	.2134	
Max	1.8099	.2058	1.2498	1.7718	.8573	1.4998	1.7528
Min	.0934	.1143	.0953	.1715	.1067	.2	.3429
Avg	.539	.1734	.5540	.6565	.4574	.4259	1.2955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 203 / CHITGIRI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954			.4572	.4801	1.6004	
2					.4801	1.7147	
3				.4382	.4801	1.7337	
4	.5335			.4954	.5144	1.7528	
5					.5487	1.7718	
6					.6001	2.6673	
7						2.8959	
8						3.0864	2.7854
9						2.9721	2.4615
10							2.4939
11			3.2769	2.7435	2.553		
12		2.8182	3.2579	3.0007	3.0483		
13				3.0864	3.0864		
14		2.7526		2.915	2.9531		
15			3.0483	2.6578	2.6673		
16	3.1436	2.5911		2.4006	2.6292		
17	3.1055		2.9531	2.6578	2.5149		
18	3.0293	2.4326	2.9721	2.8292	2.3815	.3071	
19	.503			.6173	.5182		
20		.4268	.5716	.6001		.3898	
21				.5658			
22	.442		.5906	.5487			
23	.4268			.5144			
24	.5335	.3963	.3189	.4954	.4801	.4115	.3201
Max	3.1436	2.8182	3.2769	3.0864	3.0864	3.0864	2.7854
Min	.4268	.3963	.3189	.4382	.4801	.3071	.3201
Avg	1.3570	1.9029	2.1237	1.5896	1.6210	1.7753	2.0152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 201 / AMBALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.3944	.4359	.4801	.4458	.8718	.9145
2	.4115	.3772	.4359	.4801	.4458	.9389	.9907
3	.4115	.3772	.4191	.4801	.4287	1.0059	.9755
4	.6001	.4115	.4191	.5144	.4287	1.0898	.9755
5	.6001	.4458	.4359	.5144	.4458	1.0898	.9907
6	.6859	.4801	.503	.5144	.4973	1.1568	1.0669
7	.5144	.5144	.5365	.583	.5144	1.5089	1.6766
8	.463	.4458	.503	.5316	.463	2.1879	1.7528
9	.3601	.3086		.4115		1.8442	1.6766
10	.3601	.3185	.4359	.2743	.4024	1.7604	1.7071
11	1.406	1.5927	1.0822	1.6804	.4024	.2572	.2572
12		1.8442	1.4022	1.749	1.9951	.2229	.2572
13	1.5089	2.0287	1.6156	1.8861	1.9448	.2401	.2572
14	1.1488	1.5927	1.5089	2.0233	1.9616	.2572	.2572
15	1.749	1.8778	1.5546	1.9204	1.9616	.2743	.2743
16	1.8519	1.9281	1.4937	1.6461	2.0454	.2915	.2743
17	1.8519	1.8442	1.5394	1.5089	1.9951	.2743	.3086
18	1.8519	1.7772	1.5242	1.6804	1.8442	.2743	.3258
19	.5144	.4527	.4973	.4973	.503	.3429	.3544
20	.5144	.503	.5144	.463	.503	.4973	.5487
21	.5144	.503	.5316	.4801	.503	.5487	.5658
22	.4801	.503	.5144	.3086	.503	.5144	.5487
23	.4458	.4694	.5144	.4458	.4694	.463	.5144
24	.4115	.4287	.4359	.463	.4458	.4527	.463
Max	1.8519	2.0287	1.6156	2.0233	2.0454	2.1879	1.7528
Min	.3601	.3086	.4191	.2743	.4024	.2229	.2572
Avg	.8290	.8925	.8197	.8973	.9195	.7652	.7472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 202 / HADGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0927	2.1254	2.2512	2.332	2.2504	2.3091	2.4074
2	2.0774	2.0992	2.2421	2.4112	2.2176	2.2863	2.3442
3	2.0728	2.0916	2.2345	2.4737	2.2169	2.2947	2.348
4	2.159	2.2016	2.3493	2.4829	2.3072	2.3958	1.2635
5	2.3895	2.6212	2.6022	2.6852	2.5278	2.6578	2.8113
6	3.4667	3.2525	3.3382	3.2114	3.3623	3.4289	3.5338
7	3.8272	3.6618	3.8475	3.863	3.7815	3.9702	3.4583
8	3.6176	2.2519	2.2662	3.6054	3.5597	3.7763	3.3645
9	3.5018	3.8706	3.6943	3.283	2.8986	3.1947	3.1002
10	2.9568	3.157	3.2112	2.9257	2.8601	2.6427	2.6909
11	2.5477	2.9106	2.9248	2.6886	2.5019	2.5332	2.5637
12	1.9356	2.5597	2.6692	2.3663	2.3663	2.2497	2.5243
13	2.21	2.4614	2.4509	2.348	2.2595	2.2207	2.4211
14	2.1125	2.4484	2.3007	2.2192	2.4052	2.2451	2.4634
15	2.1605	2.3613	2.2679	2.1137	2.316	2.2138	2.3655
16	2.2512	2.4438	2.2275	2.1083	2.1302	2.1559	2.3259
17	2.3824	2.8192	2.4219	2.1437	2.3539	1.0898	2.6208
18	2.7839	3.0137	2.8365	2.678	3.0545	.6889	2.5583
19	3.331	3.5271	3.3852	3.3562	3.3863	3.9034	3.4941
20	3.0391	3.3863	3.1291	3.1973	3.2508	3.5925	3.2827
21	2.8353	3.0529	2.9766	2.9751	3.0023	3.11	3.1374
22	2.6353	2.887	2.8327	2.8974	2.7732	2.8045	2.9382
23	2.4021	2.6906	2.5896	2.6185	2.6612	2.6315	2.7786
24	2.1833	2.3594	2.5071	2.4097	2.439	2.5345	2.5819
Max	3.8272	3.8706	3.8475	3.863	3.7815	3.9702	3.5338
Min	1.9356	2.0916	2.2275	2.1083	2.1302	.6889	1.2635
Avg	2.6238	2.7606	2.7315	2.7247	2.7034	2.6221	2.7241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 203 / BELMANDAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6156	1.8861	1.7394	1.6766	1.8861	.6036	.5487
2	1.6004	1.8861	1.7394	1.6766	1.9204	.6413	.5487
3	1.6004	1.9204	1.7711	1.7071	1.9547	.6224	.5487
4	1.6766	1.989	1.8244	1.6766	2.0233	.6413	.5487
5	1.5242	2.0233	1.9524	1.6461	2.1605	.679	.583
6	1.6461	2.0576	1.9524	1.7071	2.2291	.7922	.6859
7	1.3717	2.1605	2.2405	1.9814	2.4006	.7167	.4801
8		2.3663	2.2405	2.1643	2.332	.6413	.4801
9	2.1033	2.4348	2.2996	2.1338	2.0748	.4904	.4115
10	1.829	2.2186	2.1125	2.0424	2.0243	.3395	.3772
11	.1829	.2829	.2401	.2401	.415	1.89	2.332
12	.2401	.2641	.2058	.2401	.3395	2.0424	2.4348
13	.1886	.3206	.2743	.2743	.3018	2.0729	2.572
14	.2743	.3018	.2743	.2743	.2915	2.1643	2.4177
15	.2743	.2829	.2401	.2915	.3018	2.1643	2.2291
16	.2743	.3018	.2058	.3086	.3206	2.1338	2.1262
17	.2743	.3395	.2401	.3429	.3395	2.1338	2.1262
18	.3086	.3395	.2401	.2915	.5093	2.1338	2.1262
19	.5144		.5487	.5658	.679	.583	.6001
20	.6001	.6413	.583	.6173	.679	.583	.6516
21	.6173	.6602	.6173	.6173	.679	.5487	.6859
22	.583	.6413	.583	.583	.679	.5487	.6516
23	.5487	.6036	.5487	.583	.6413	.5487	.6344
24	.5144	.5316	.6036	.5487	.5487	.6036	.5487
Max	2.1033	2.4348	2.2996	2.1643	2.4006	2.1643	2.572
Min	.1829	.2641	.2058	.2401	.2915	.3395	.3772
Avg	.8853	1.1502	1.0532	1.0079	1.1555	1.0966	1.1395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 204 / WATEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2498	1.3375	.3239	1.2193	1.4575	.3772	.3429
2	1.2955	1.3717	1.3435	1.2498	1.4746	.3584	.3429
3	1.2955	1.3546	1.3279	1.2803	1.5089	.3395	.3429
4	1.2955	1.406	1.3748	1.2803	1.5089	.3772	.3772
5	1.3717	1.4746	1.406	1.2803	1.5432	.4527	.3772
6	1.3717	1.5604	1.4232	1.4327	1.5775	.6224	.4287
7	1.6766	1.7147	1.7711	1.5851	1.8861	.6413	.4115
8	1.7071	1.6461	1.9204	1.6766	1.9204	.5281	.3772
9	1.6156	1.5604	1.8244	1.5851	1.7814	.415	.3086
10	1.5242	1.5364	1.6872	1.6766	1.6872	.2452	.1715
11	.1715	.2452	.2058	.2743	.2641	1.6156	1.8861
12	.1543	.1886	.1372	.2743	.2829	1.7071	1.9204
13	.1134	.2075	.1372	.2401	.2263	1.7071	1.9547
14	.0857	.2075	.1372	.2401	.2263	1.7375	1.9204
15	.1029	.1886	.1715	.1886	.2075	1.6461	1.8861
16	.1886	.2263	.1715	.2058	.1886	1.6461	1.8861
17	.1886	.3206	.2743	.2058	.2452	1.6766	1.8861
18	.2401	.3395	.2743	.2896	.3206	1.5242	1.8861
19	.4115	.4715	.4115	.4287	.4904	.4115	.2743
20	.4115	.4527	.3772	.3772	.4338	.4115	.3772
21	.3772	.415	.3772	.3772	.3772	.3772	.4458
22	.3429	.3772	.3429	.3429	.3961	.3429	.4287
23	.3086	.3584	.3429	.3429	.3772	.3429	.3944
24	.3086	.3086	.3584	.3429	.3258	.3772	.3429
Max	1.7071	1.7147	1.9204	1.6766	1.9204	1.7375	1.9547
Min	.0857	.1886	.1372	.1886	.1886	.2452	.1715
Avg	.7420	.8029	.7551	.7665	.8628	.8284	.8737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 205 / KOTHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.583	.6602	.6173	.6173	2.1628	1.6766
2	.6516	.5487	.6413	.6173	.583	2.1628	1.829
3	.6516	.5487	.6413	.6173	.583	2.1792	1.829
4	.6859	.6173	.6602	.6516	.6001	2.1628	1.829
5	.6859	.6516	.679	.6859	.6173	2.1956	1.768
6	.6859	.6516	.7167	.7202	.6516	2.2119	1.768
7	.6516	.6859	.7922	.6516	.7202	2.4531	2.2862
8	.6173	.5487	.679	.583	.6859	2.7515	2.6825
9	.5792	.463	.547	.5487	.5487	2.7183	2.4387
10	.3772	.3772	.4527	.4115	.4715		2.3472
11	3.0476	3.1161	2.7435	3.1893	3.0664	.2743	.3277
12	3.2579	3.2819	2.5149	3.2236	3.2985		.3429
13	3.5151	3.2985	2.5606	3.3303	2.9504		.3429
14	3.4328	3.1493	2.6825	3.2922	2.9835		.3601
15	3.2922	3.315	2.5911	3.155	3.0167	.3772	.3601
16	3.2579	3.2322	2.7435	3.1722	3.1493	.3772	.2401
17	3.2579	2.9835	2.4082	3.1207	2.8837	.3772	.3772
18	3.2407	2.8509	2.6216	2.915	2.9508	.4801	.4287
19	.6516	.6224	.583	.6687	.7545	.6001	.6859
20	.6344	2.2939	.6516	.6859	.7545	.6097	.7202
21	.5639	.7167	.6859	.6687	.7545	.6516	.7202
22	.6173	.7356	.6516	.6516	.7356	.6516	.6859
23	.6173	.6979	.6173	.6516	.7167	.6516	.6859
24	.5487	.6001	.679	.6173	.6344	.7167	.6516
Max	3.5151	3.315	2.7435	3.3303	3.2985	2.7515	2.6825
Min	.3772	.3772	.4527	.4115	.4715	.2743	.2401
Avg	1.5029	1.5237	1.3002	1.4769	1.4470	1.3383	1.1410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 206 / KOTHALA WW EXP.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0652					
2		.0678			.0652		
3		.0703	.0754		.0686	.072	
4	.0772	.072	.072	.0737	.0686	.0737	.0703
5	.0772	.0754	.072	.0737	.0703	.072	.072
6	.0754	.0754	.0789	.0737	.072	.0737	.0737
7	.0754		.0737	.0686	.0703	.0737	.072
8	.0737	.0703	.0686	.072	.0686	.0754	.0703
9	.0737		.0737		.0655		.0703
10	.0737		.072		.072		.0754
18		.0686					
19		.0789		.0634		.0754	
20		.0772		.0669		.0737	
21				.0686			
Max	.0772	.0789	.0789	.0737	.072	.0754	.0754
Min	.0737	.0652	.0686	.0634	.0652	.072	.0703
Avg	.0752	.0721	.0733	.0701	.0690	.0737	.072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 201 / WAIPANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9768	2.2428	2.2176	2.2428	1.97	1.0817	1.249
2	2.0485	2.3167	2.5792	2.6047	2.2021	1.0486	1.2338
3	2.2809	2.4664	2.6227	2.6619	2.2501	1.0586	.41
4	2.3156	2.6863	2.8014	2.8555	2.5938	1.07	1.1465
5	2.5148	2.9279	2.8887	2.9892	2.5869	1.1942	1.403
6	2.8094	3.1249	2.9881	3.0933	2.292	1.5462	2.4678
7	3.6336	3.6474	3.331	3.6664	3.6366	1.8957	1.925
8	4.2082	4.0783	4.1663	4.0143	3.9289	1.7569	1.5722
9	4.2364	4.0009	4.0695	4.0763	4.0504	1.4479	1.2818
10	3.9498	3.7682	3.9838	3.7777	3.9152	1.2735	1.0639
11	1.5249	3.3993	2.0355	1.2048	1.7677	2.199	2.8174
12	.586	.6675	1.5748	.5815	.7175	3.1268	3.5554
13	.6032	.5494	1.6026	.5578	.7373	3.3631	3.4873
14	.5773	.5407	1.5672	.5312	.6916	1.1805	3.2625
15	.527	.6851	1.5703	.5967	.7407	3.0163	3.3339
16	.6489	.695	1.124	.5927	.6897	3.1108	3.1817
17	.7701	.7872	.6416	.6345	.8086	3.3661	3.429
18	.8696	.9168	1.054	1.0355	.8821	3.3531	3.0902
19	1.4819	1.5721	1.5341	1.3859	1.515	1.9311	1.6149
20	1.4525	1.5958	1.4029	1.3691	1.5169	1.5447	1.2371
21	1.313	1.4845	1.3389	1.3501	1.3656	1.5684	1.2788
22	1.1724	1.3657	1.2715	1.2214	1.2963	1.4769	1.3457
23	1.0883	1.1782	1.2045	1.1126	1.1473	1.3695	1.2217
24	.9596	.9964	1.0966	1.1813	1.1673	1.1077	1.057
Max	4.2364	4.0783	4.1663	4.0763	4.0504	3.3661	3.5554
Min	.527	.5407	.6416	.5312	.6897	1.0486	.41
Avg	1.8145	1.9872	2.1111	1.8891	1.8529	1.8786	1.9861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 202 / DORLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9585	1.4266	2.0904	1.4914	2.0555	1.1027	1.0776
2	2.1239	1.6446	2.7008	1.9303	2.2645	1.0806	1.0578
3	2.2436	1.7033	2.8532	2.1666	2.3141	1.0722	1.0467
4	2.2702	2.1525	3.0667	2.7203	2.3377	1.0692	1.0662
5	2.4097	2.4603	3.1935	3.0018	2.5964	1.1797	1.2293
6	2.7207	3.2556	3.44	3.3303	2.7869	1.4099	1.5067
7	4.0154	4.1792	4.0817	4.3405	4.1579	1.5314	1.5981
8	4.9512	5.1383	4.9741	5.3757	4.9528	1.3016	1.4503
9	5.0099	5.256	5.2271	5.2591	2.8342	1.0387	1.2636
10	3.7342	4.9924	5.2926	4.997	4.3812	.9106	.9135
11	1.1774	1.8716	1.419	1.7452	3.6141	3.5734	3.6965
12		.3932		.6417	.5704	4.4155	4.6272
13		.7163	.5121	.5721	.6081	4.6746	4.5675
14	.6489	.6508	.543	.5409	.5334	4.4154	4.4399
15	.5845	.599	.5053	.5386	.4497	3.0941	4.1876
16	.6119	.6698	.5243	.6402	.5555	3.6359	3.7807
17	.6725	.7887	.4172	.3673	.6817	4.4803	3.8111
18	.8425	.586	.8467	.8362	.8291	4.1922	3.6214
19	1.3504	1.3779	1.3027	1.3276	1.3637	2.0888	2.455
20	1.2875	1.3009	1.2773	1.3085	1.3294	1.403	1.5108
21	1.1756	1.2399	1.2437	1.3299	1.2552	1.4083	1.5212
22	1.1016	.9838	1.2003	1.291	1.2277	1.307	1.4604
23	.9743	1.0822	1.0734	1.1635	1.2224	1.1607	1.3233
24	1.0326	.8875	1.0959	1.0391	1.0779	1.1485	1.2377
Max	5.0099	5.256	5.2926	5.3757	4.9528	4.6746	4.6272
Min	.5845	.3932	.4172	.3673	.4497	.9106	.9135
Avg	1.9499	1.8899	2.1253	1.9981	1.9166	2.1956	2.2688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 203 / TAMSA TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.2743	.4338	.3601	.362	.3772	.5281
2	.362	.2743	.4338	.3601	.362	.3772	.5281
3	.362	.2743	.4294	.3601	.362	.3772	.4904
4	.362	.2743	.0747	.3429	.362	.4115	.4527
5	.4525	.3601	.439	.5144	.543	.4458	.5093
6	.543	.5144	.5228	.5487	.543	.4973	.5281
7	.6335	.5487	.8299	.583	.724	.583	.7545
8	.724	.6001	.6722	.6344	.724	.6001	.7468
9	.724	.6344	.8131	.5316	.6859	.6401	.6722
10	.5144	.5853	.7202	.543	.5144	.5524	.5544
11	.4801	.439	.6344	.543		.4887	.5175
12	.4801	.4755	.5487	.543	.5144	.4938	.462
13	.4287	.5487	.5144	.543	.5144	.5068	.5175
14	.4287	.4706	.4801	.4525	.4801	.4755	.5544
15	.4287	.5373	.463	.362	.463	.591	.5487
16	.463	.5014	.4973	.4525	.4801	.3982	.5601
17	.4973	.5975	.5144	.543	.5487	.6154	.5544
18	.6001	.6024	.5658	.724	.5658	.5373	.5914
19	.6173	.5487	.6001	.724	.6173	.7964	.6602
20	.5487	.5658	.5487	.724	.5487	.5914	.7167
21	.4973	.5658	.5144	.6335	.4973	.5359	.6602
22	.4287	.5544	.4801	.6335	.463	.5914	.6036
23	.3429	.4251	.4287	.4525	.4287	.5658	.5281
24	.362	.2743	.4338	.4287	.362	.3772	.5228
Max	.724	.6344	.8299	.724	.724	.7964	.7545
Min	.3429	.2743	.0747	.3429	.362	.3772	.4527
Avg	.4851	.4769	.5247	.5224	.5072	.5178	.5734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 204 / JAMBHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.3086	.3429	.2915	.2486	.3772	.9145
2	.2429	.3086	.3429	.2915	.2486	.3772	1.0364
3	.2429	.3086	.3429	.2915	.2486	.3772	1.1012
4	.2429	.3086	.3239	.2915	.2486	.6173	1.166
5	.2515	.3258	.3239	.3601	.2486	.7888	1.2803
6	.3239	.3601	.4191	.3772	.3315	1.1488	1.5203
7	.3239	.3601	.4715	.4115	.3315	1.3032	2.4939
8	.3239	.2915	.3961	.3601	.3315	1.7147	2.9473
9	.3239	.2743	.3772	.3086	.3429	2.1434	1.2803
10	.1886	.3048	.3429	.2486	.2401	1.9433	1.8023
11	1.8861	2.0325	2.4006	1.6575	1.6632	.2286	.3772
12	2.7435	2.6216	2.6063	2.4863	2.2462	.1509	.1509
13		2.834	2.6578	2.3205	2.4177	.1698	.1509
14	2.6749	2.5606	2.692	2.4034	2.452	.1307	.1886
15	2.6406	2.4669	2.692	2.4863	2.4863	.1886	.1886
16	2.6578	2.4352	2.5892	2.4863	2.4863	.2075	.1698
17	2.7092	2.4249	2.5034	2.3482	2.5034	.2263	.2263
18	2.1262	2.1759	2.1262	2.1548	2.5034	.2829	.3206
19	.4115	.4668	.4115	.3315	.3944	.4527	.3772
20	.4115	.4572	.3772	.3315	.3944	.415	.4527
21	.3772	.4191	.3429	.3315	.3772	.3921	.4715
22	.3429	.381	.3258	.3315	.3601	.3881	.4527
23	.3258	.3734	.3086	.2486	.3258	.381	.415
24	.2429	.3258	.3429	.2915	.2486	.3258	.3395
Max	2.7435	2.834	2.692	2.4863	2.5034	2.1434	2.9473
Min	.1886	.2743	.3086	.2486	.2401	.1307	.1509
Avg	.9677	1.0469	1.0858	.9767	.9866	.6138	.826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 206 / Natraj Exp

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0857	.0145	.0857	.0838	.0857	.0145
2	.0838	.0857	.0221	.0857	.0838	.0857	.013
3	.0838	.0857	.0168	.0857	.0838	.0857	.0145
4	.0838	.0857	.0145	.0857	.0838	.0857	.016
5	.0838	.0857	.0198	.0857	.0838	.0857	.016
6	.0838	.0857	.0221	.0857	.0838	.0857	.0213
7		.0857	.096	.0857	.0838	.0857	.0926
8	.1677	.2572	.2829	.1715	.2515	.3086	.125
9	.1638	.2743	.2641	.12	.2572	.3086	.1219
10	.1715	.0854	.2401		.2743	.2829	.1372
11	.1715	.2477	.2401	.0838	.2743	.2452	.1311
12	.1715	.2452	.2401	.0838	.2743	.1509	.1147
13	.1715	.2452	.2572	.0838	.2743	2.1125	.1094
14	.2058	.2614	.2915	.0838	.2743	.2477	.112
15	.2572	.2477	.2915	.0838	.2743	.2477	.0983
16	.2058	.2263	.2572	.0838	.2401	.2452	.1017
17	.2058	.2614	.2401	.0838	.2058	.2477	.1052
18	.1715	.3174	.2401	.0838	.2058	.2286	.128
19	.1715	.1143	.2401	.0838	.2401	.125	.1132
20	.1543	.0332	.2401	.0838	.2743	.128	.1132
21	.1372	.0145	.2058	.0838	.2743	.1219	.1132
22	.1372	.0152	.1029	.0838	.2743	.0149	.1132
23	.0857	.0168	.1029	.0838	.1029	.0145	.1132
24	.0838	.0857	.0145	.1029	.0838	.0857	.013
Max	.2572	.3174	.2915	.1715	.2743	2.1125	.1372
Min	.0838	.0145	.0145	.0838	.0838	.0145	.013
Avg	.1450	.1479	.1649	.0906	.1934	.2381	.0855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 201 / KOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3258	.3258	.3086		.3429	.3429
2	.3086	.3258	.3258	.3086		.3086	.3429
3	.3086	.3258	.3258	.3086		.3086	.3429
4	.3772	.362	.3982	.3772		.3772	.4115
5	.4801	.543	.6154	.4801		.5144	.5144
6	.5487	.7602	.7602	.583		.6173	.6516
7	.6516	.7964	.8326	.7202		.823	.7888
8	.6173	.7964	.724	.7202	.724	.7545	
9	.4115	.5731	.543	.5144	.5792	.5487	.5144
10	.3429	.4706	.3982	.4115	.4706	.3429	.4458
11	.3429	.362	.3429	.3582	.362	.2743	.3582
12	.2743	.3258	.3086	.2896	.3086	.3429	.2865
13	.3086	.3258	.3086	.2865	.3086	.2058	.2865
14	.3258	.3224	.2743	.2804	.2743	.2058	.2865
15	.3258	.3224	.2743	.2439	.3086	.2058	.3258
16	.362	.3582	.3429	.2804	.3429	.2401	.362
17	.3982	.4607	.4458	.3856	.3772	.3429	.3982
18	.4706	.5316	.5144	.3963	.4458	.4801	.4344
19	.6516	.6379	.6173	.631	.6516	.6173	.6516
20	.5731	.5731	.6516	.5258	.583	.6859	.6154
21	.5373	.5373	.5144	.4557	.4801	.5144	.543
22	.4656	.4298	.4458		.4458	.4458	.4344
23	.362	.362	.4115		.4115	.4115	.3982
24	.3429	.3224	.3258	.3429		.3772	.3772
Max	.6516	.7964	.8326	.7202	.724	.823	.7888
Min	.2743	.3224	.2743	.2439	.2743	.2058	.2865
Avg	.4207	.4646	.4595	.4186	.4421	.4287	.4397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 202 / DHANORA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.9204	1.9433	1.5089			
2	1.6004	1.9204	1.9433	1.5089			
3	2.7778	1.9204	1.9433	1.6004			
4	1.9204	2.0805	2.1052	1.669			
5	1.9433	2.0805	2.17	1.7604			
6	2.0348	2.2405	2.332	1.8519			
7	2.1491	2.1872	2.915	1.9433			
8	2.1719	2.2405	2.5911	2.9492	2.753		
9						2.7435	2.0576
10						2.8045	2.2862
11						2.774	3.2007
12						2.7435	3.0407
13						2.9569	3.1047
14						2.2862	3.1367
15						2.4006	3.0769
16						1.5089	2.915
Max	2.7778	2.2405	2.915	2.9492	2.753	2.9569	3.2007
Min	1.6004	1.9204	1.9433	1.5089	2.753	1.5089	2.0576
Avg	2.0248	2.0738	2.2429	1.849	2.753	2.5273	2.8523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 203 / VARULA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.829	2.0805	1.7814	1.2574	1.8461		
10	1.89	2.0805	1.7814	1.8861	1.8785		
11	2.0119	2.0805	1.2803	1.6004	1.7814		
12	2.0424	2.1125	1.2803	1.6964	1.7375		
13	1.8595	2.1445	1.3032	1.6644	1.768		
14	2.0805	2.0805	1.3032	1.6766	1.829		
15	2.0805	1.9685	1.2803	1.7375	1.6766		
16	2.1445	1.8747	1.3032	1.829	1.5242		
17						1.3946	2.1052
18						1.3946	2.1052
19						1.2803	1.9433
20						1.2574	1.9433
21						1.7147	1.7814
22						1.5432	1.7814
23						.9374	1.6194
24	2.8292						1.6194
Max	2.8292	2.1445	1.7814	1.8861	1.8785	1.7147	2.1052
Min	1.829	1.8747	1.2803	1.2574	1.5242	.9374	1.6194
Avg	2.0853	2.0528	1.4142	1.6685	1.7552	1.3603	1.8623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 204 / Yelamb

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.1584	.9145
2						1.1584	.9831
3						1.1279	1.0288
4						1.1584	1.0288
5						1.2193	1.0974
6						1.2193	1.1431
7						1.2498	1.1431
8						1.2803	1.1431
17	1.9845	1.5623	1.3717	1.7375	1.6766		
18	1.9845	1.5623	1.3946	1.829	1.6461		
19	1.5043	1.5623	1.3717	1.5242	1.5546		
20	1.406	1.406	1.2574	1.3717	1.5242		
21	1.406	1.406	1.2574	1.406	1.4022		
22	1.2498	1.3123	1.2574		1.3717		
23	1.2803	1.2955	1.1431		1.3108		
24	1.1203	1.2803	1.2955	1.0288		1.1888	
Max	1.9845	1.5623	1.3946	1.829	1.6766	1.2803	1.1431
Min	1.1203	1.2803	1.1431	1.0288	1.3108	1.1279	.9145
Avg	1.4920	1.4234	1.2936	1.4829	1.4980	1.1956	1.0602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 205 / NIWGHA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2534	.2534	.2401		.2401	.2401
2	.2401	.2534	.2534	.2401	.2534	.2401	.2401
3	.2401	.2534	.2534	.2401		.2401	.2401
4	.2743	.2896	.2896	.2743	.3258	.3429	.2743
5	.3429	.362	.362	.3429		.4115	.3429
6	.4115	.4344	.4706	.4115		.4458	.4115
7	.4801	.5068	.543	.4801		.4801	.4801
8	.4115	.5068	.4344	.4458	.4706	.4458	.4801
9	.3086	.3582	.362	.3429	.3982	.3772	.3772
10	.2743	.2896	.3258	.3086	.362	.2743	.3086
11	.2743	.2896	.2743	.2865	.3258	.3429	.2865
12	.2743	.2534	.2401	.2507	.3086	.2743	.2865
13	.2401	.2172	.2401	.2507	.2743	.2743	.2865
14	.2534	.2149	.2058	.2454	.2743	.2743	.2865
15	.2534	.2149	.0171	.2454	.2743	.2743	.2896
16	.2534	.2507	.2743	.2804	.2743	.2743	.2896
17	.2896	.2835	.3086	.3155	.3086	.3086	.3258
18	.3258	.3189	.3772	.3506	.3086		.3258
19	.4344	.4252		.4557	.4458	.4115	.4344
20	.3582	.3582	.4115	.3506	.4115	.4458	.4344
21	.3224	.3224	.3429	.3155	.3429	.3772	.362
22	.2896	.2865	.3086		.3086	.2743	.2896
23	.2534	.2534	.2743		.3086	.2401	.2896
24	.2401	.2507	.2534	.2401		.2743	.2401
Max	.4801	.5068	.543	.4801	.4706	.4801	.4801
Min	.2401	.2149	.0171	.2401	.2534	.2401	.2401
Avg	.3036	.3103	.3076	.3143	.3320	.3280	.3259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 206 / KOLI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3258	.3258	.3086		.3772	.3429
2	.3086	.3258	.3258	.3086		.3429	.3429
3	.3086	.3258	.3258	.3086		.3086	.3429
4	.3429	.362	.362	.3429		.4115	.4458
5	.4801	.543	.5068	.4458		.5144	.4801
6	.583	.6878	.6878	.5144		.583	.5144
7	.6859	.543	.724	.6516		.6173	.583
8	.5487	.5068	.6154	.583	.6154	.583	.583
9	.3086	.4298	.543	.4115	.4706	.4801	.5487
10	.3086	.3982	.362	.3086	.362	.2743	.3772
11	.3086	.362	.2743	.2865	.362	.2743	.3582
12	.2401	.2896	.2401	.2507	.3086	.2401	.2507
13	.2401	.2534	.2401	.2507	.3086	.2401	.2507
14	.2534	.2507	.2058	.2454	.2743	.2401	.2507
15	.2534	.2507	.2058	.2804	.3086	.2401	.2534
16	.2534	.3224	.2401	.3155		.2743	.2896
17	.3258	.3544	.2743	.3155	.3429	.3086	.362
18	.3982	.4252	.3429	.3856	.3772	.3429	.4344
19	.5792	.567	.5144	.5258	.6859	.583	.6154
20	.5014	.5014	.583	.4908	.6173	.5487	.5792
21	.4298	.4298	.5144	.4557	.4801	.4801	.5068
22	.3982	.394	.4458		.4458	.4115	.4344
23	.362	.362	.3429		.4458	.3772	.3982
24	.3086	.3224	.3258	.3086		.4115	.3429
Max	.6859	.6878	.724	.6516	.6859	.6173	.6154
Min	.2401	.2507	.2058	.2454	.2743	.2401	.2507
Avg	.3765	.3972	.3970	.3770	.4270	.3944	.4120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 201 / LINGAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8006	.9465	1.1136	1.1003	1.1003	.114	.1277
2	.8973	.9351	1.1349	1.0696	.6006	.1297	.1366
3	1.0088	.9721	1.1149	1.1531	1.0768	.1402	.1275
4	1.0576	1.034	1.1388	1.2544	.374	.1598	.1425
5	1.1389	1.1589	1.0774	1.2529	.8812	.1791	.1519
6	1.2031	1.3132	1.1295	1.3295	1.0382	.1636	.1844
7	1.2513	1.4769	1.1965	1.3053	1.4899	.1947	.1905
8	1.2544	1.5185	1.2155	1.4935	1.8099	.1853	.1766
9	1.4122	1.53	1.3846	1.3198	1.5449	.1386	.1698
10	1.1003	1.4654	1.1575	1.2955	1.2683	.124	.1166
11	.0861	.0455	.0608	.1137	.1012	1.467	1.177
12	.0535	.0482	.0691	.2477	.0914	1.2	1.2041
13	.0557	.0684	.0818	.0428	.0861	1.3983	1.2826
14	.0806		.0632	.0547	.0526	1.0445	1.1417
15			.0645	.0658	.0615	1.3396	1.2727
16	.0722	.0607	.0864	.0713	.0837	1.3796	1.0159
17	.0796	.0813	.0968	.0746	.0846	1.2899	1.0217
18	.1226	.1174	.1058	.1246	.0934	1.4905	1.0774
19	.1261	.1304	.1396	.2084	.1143	.145	.1407
20	.096	.1024	.0969	.1692	.1341	.1263	.127
21	.096	.1162	.1132	.1756	.1204	.1169	
22	.1089	.1021	.1073	.0921	.1114	.1202	
23	.1104	.108	.1012	.0674	.1113	.118	.0798
24	.1067	.1115	.0955	.095	.1099	.1059	1.2041
Max	1.4122	1.53	1.3846	1.4935	1.8099	1.4905	1.2826
Min	.0535	.0455	.0608	.0428	.0526	.1059	.0798
Avg	.5356	.6110	.5394	.5907	.5225	.5363	.5577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 202 / ASHTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8281	2.8579	2.8091	2.4078	2.7373	1.6057	1.6731
2	3.2891	3.4776	3.12	3.0026	3.0392	1.5592	1.6003
3	3.3617	3.5437	3.2331	3.1046	3.2177	1.6261	1.6365
4	3.3703	3.7136	3.3238	3.2286	3.3545	1.7531	1.7849
5	3.5027	3.9678	3.4097	3.2003	3.4919	1.9027	2.0079
6	3.6127	4.2837	3.6913	3.4476	3.8512	2.3393	2.4466
7	4.6384	4.9905	4.6316	4.2652	4.8043	2.797	2.6055
8	2.7077	5.1501	5.3867	4.227	5.5508	2.638	2.5233
9	4.9391	5.33	5.5017	4.4084	5.5393	2.2521	2.2541
10	5.0961	4.7314	5.3226	4.514	5.027	1.7989	2.003
11	3.1588	2.5557	3.0988	2.8538	2.9101	3.3971	3.789
12	.9535	.9682	.7633	.9509	.6165	4.8694	5.1224
13	.8592	.9733	.8517	.7971	1.0444	5.199	4.7054
14	.2423	.8416	.918	.8444	1.0691	5.1496	4.6837
15	.7049	.1638	1.0967	.7998	1.2493	5.0142	4.5594
16	1.1507	.77	1.1821	.9776	1.1704	4.9926	4.9715
17	1.2879	1.3999	1.3069	1.2208	1.1947	5.1	4.9733
18	1.4685	1.663	1.3542	1.3422	1.5446	5.0293	4.5373
19	2.1657	2.1894	2.2059	1.9988	2.1221	3.9076	3.5679
20	2.1955	2.2184	2.1922	2.2626	2.0985	2.2596	2.2186
21	1.7847	1.9994	1.9898	2.0775	1.988	2.1117	2.1424
22	1.7729	1.8682	1.88	1.863	1.8864	1.9558	2.0108
23	1.6722	1.6889	1.7887	1.7001	1.7209	1.7941	1.9036
24	1.5844	1.5882	1.6156	1.6798	1.6341	1.6973	1.7628
Max	5.0961	5.33	5.5017	4.514	5.5508	5.199	5.1224
Min	.2423	.1638	.7633	.7971	.6165	1.5592	1.6003
Avg	2.4311	2.6223	2.6114	2.3823	2.6193	3.0312	2.9785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 204 / YEOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3904	1.4264	1.5242	1.5762	1.4403	2.9332	3.1038
2	1.3476	1.3351	1.5443	1.6249	1.4525	3.1571	3.373
3	1.4138	1.3124	1.5473	1.6877	1.5275	3.3052	3.5323
4	1.4799	1.405	1.5969	1.7484	1.5336	3.5242	3.8886
5	1.6195	1.4884	1.6413	1.7686	1.5785	3.7221	4.0874
6	1.8755	1.6409	1.8979	1.8842	1.7294	3.9888	4.8326
7	2.0419	1.961	2.1591	2.0823	1.7218	5.4126	5.7428
8	1.0258	1.9082	1.914	1.0341	1.5913	6.006	6.3297
9	.0099	1.6331	1.657		1.4654	6.1138	6.2029
10	.9928	1.2993	1.4138		1.3161	5.1384	5.4586
11	4.9027	4.2833	***		4.162	3.0886	3.1709
12	6.5426	5.9878	6.057	1.1361	3.3291	.9711	.1989
13	6.6758	6.5404	5.9265	3.0889	6.3276	.8496	1.0149
14	6.5447	6.4396	5.8534	3.1383	6.2856	.77	.9678
15	5.6068	6.2895	5.9072	2.297	5.9728	.8338	.503
16	5.8132	6.134	5.5389	3.3021	5.825	.0701	1.1008
17	4.4304	3.6416	5.9921	5.748	5.07	.8039	1.1854
18	6.0532	6.1715	5.9482	6.2424	4.7771	2.8902	1.3108
19	4.077	4.2333	4.0583	4.5678	3.5214	1.6227	1.8376
20	1.6852	1.6844	1.8921	4.1625	1.8339	1.776	1.7908
21	1.6814	1.5997	1.7542	2.2666	1.6395	1.7644	1.8066
22	1.6736	1.6679	1.7225	1.6922	1.6517	1.7361	1.7617
23	1.5272	1.6118	1.6337	1.5605	1.5919	1.7282	1.7404
24	1.4981	1.4508	1.5607	1.5295	1.4928	1.5859	1.592
Max	6.6758	6.5404	16.0097	6.2424	6.3276	6.1138	6.3297
Min	.0099	1.2993	1.4138	1.0341	1.3161	.0701	.1989
Avg	2.9962	3.0477	3.6146	2.5780	2.8682	2.658	2.7722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 201 / BARADSHEWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.8459	.8741	.8916	.9164	1.3032	.5639
2	.7956	.8509	.8741	.8916	.9164	1.3717	1.6918
3	.823	.8459	.8741	.8916	.9728	1.3717	1.6918
4	1.0974	.7754	1.0715	1.0974	1.0715	1.3717	1.9033
5	1.3032	1.1279	1.1561	1.3032	1.1843	1.4403	2.1289
6	1.3717	1.4098	1.3957	1.3717	1.4662	1.5775	2.2135
7	1.4129	1.3394	1.2407	1.3032	1.4098	1.7147	2.3122
8	1.166	1.1279	1.0574	1.166	1.3253	1.8519	2.4249
9	1.0974	1.1561	.9305	1.0974	1.1984	1.8519	2.4672
10	.9602	.7754		.823	.9305	1.7147	2.1571
11		2.6364	2.2634	2.5095	2.1948	.5498	.5639
12		2.9748	2.6749	2.6928	2.332	.4934	.5639
13		2.8197	2.6749	2.6928	2.332	.5639	.5639
14		2.6787	2.4006	2.6928	2.332	.5639	.5921
15	2.6646	2.5659	1.9204	2.6928	2.3594		.5921
16	2.6223	2.5236	2.4006	2.6928		.7049	.5921
17	2.6364	2.6364	2.4006	2.7351	2.2634	.719	.6767
18	2.5941	2.4672	2.332	2.5659	1.989	.7895	
19	1.4098	1.3112	1.166	1.2971	1.2071	1.2689	1.2266
20	1.2266	1.1561	1.0974	1.1561	1.0974	1.1279	1.2125
21	1.0856	1.0856	1.0288	1.0997	1.0974		1.1279
22	1.0856	1.0574	.9877	1.0292	.9877	1.0151	1.0715
23	.9164	.9728		.9869		.5639	.9869
24	3.6008	.9164	.9023	.9328	.9587	.8916	.8459
Max	3.6008	2.9748	2.6749	2.7351	2.3594	1.8519	2.4672
Min	.7956	.7754	.8741	.823	.9164	.4934	.5639
Avg	1.5333	1.5857	1.5329	1.6089	1.4792	1.1282	1.3118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 202 / PALSA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	3.0007
Max	3.0007
Min	3.0007
Avg	3.0007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 203 / SIBDARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.7011	.7011	.8764	.7712	.7011	.3506
2	.7011	.7011	.7011	.8764	.7712	.7011	.3506
3	.7011	.8764	.7011	.8764	.7712	.7011	.3506
4	.7011	.8764	.7712	.8764	.8413	.7011	.3506
5	.7011	1.4022	.9114	.8764	.9114	.964	1.1393
6	1.0517	1.5775	1.0517	.8764	.9816	1.0517	.8764
7	1.5775	1.6651	1.6126	1.5775	1.6126	1.0517	1.0517
8	1.6651	1.5775	1.7528	1.5775	1.8229	1.0517	1.0517
9	1.5775	1.4022	1.6126	1.4022	1.7528	.8764	.8764
10	1.4022	1.4022	1.3321	1.3146	1.4022	.7011	.7011
11	.7011	.3506	.0876	.5258	.5258	1.4022	1.0517
12		.3506	.0876	.4207	.5258	1.4022	1.1218
13		.3506	.2629	.4207	.3506	1.4022	1.3321
14		.3506	.2629	.4207	.1753	1.3146	1.1218
15	.3506	.3506	.3506	.4207	.0876	1.3847	1.1218
16	.3506	.3506	.5258	.4207	.0876	1.4022	1.1919
17		.4908	.6135	.5609	.4382	1.4022	1.4022
18	.964	.7011	.7011	.631	.6135	1.4022	1.0517
19	.964	.9114	.964	.9816	.964	1.0517	.9816
20	.8764	.9816	.964	.9465	.964	.964	.9816
21	.7011	.9114	.964	.8413	.8764		.9816
22	.6135	.8413	.8764		.8764	.3506	.9114
23	.6135	.7712		.8413		.3506	.9114
24	.7011	.6135	.7011	.7888	.7011	.8764	.3506
Max	1.6651	1.6651	1.7528	1.5775	1.8229	1.4022	1.4022
Min	.3506	.3506	.0876	.4207	.0876	.3506	.3506
Avg	.8808	.8545	.8047	.8413	.8185	1.0090	.9005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 201 / TALNI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6165	1.1522	1.2092	.5418	.6773		
2	.6249	1.1941	1.3536	.5914	.7225		
3	.6287	1.2946	1.435	.5792	.7225		
4	1.2807	1.2809	1.467	.5647	.7225		
5	.6295	1.347	1.4329	.5335	.6773		
6	.6417	1.4529	1.3958	.5716	.6321		
7	.7865	1.612	1.4842	.6691	.6321		
8	1.9075	1.7692	1.6366	.8558	.6321		
9	.5472	.407	.0206	.4161			.743
10						.7876	.7727
11						.8173	.7876
12							1.0082
13						.8916	.743
14						.8916	.8322
15						.8916	.8173
16						.8916	.7579
20	.0301	.0301	.0023	.0008			
21		.0301					
22		.0301					
23	.0301	.0301				.0297	.0297
24	.0301	.0301		.0151		.0151	
Max	1.9075	1.7692	1.6366	.8558	.7225	.8916	1.0082
Min	.0301	.0301	.0023	.0008	.6321	.0151	.0297
Avg	.6461	.8329	1.1437	.4854	.6773	.6520	.7213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 202 / SHIVOOR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.037					
2			.037				
5			.037				.0373
8	.037						
9	1.9404	1.7556	1.9404		1.6632		
10		1.7556			1.7741		
11		2.0144	1.9404		1.7741		
12	2.0698	1.7556	1.848	1.6632	1.8296		
13		1.848	1.6632	1.6632			
14	2.1807	1.6632					
15		1.9404			1.7741		
16	2.1807	1.6632		1.6078	1.6078		
17						1.8858	1.6804
18						1.7737	
19						1.6804	1.4937
20						1.3443	1.1145
21						1.251	1.4563
22							1.4003
23	.037					1.307	1.4377
24	.037	.037	.037	.037		.037	1.307
Max	2.1807	2.0144	1.9404	1.6632	1.8296	1.8858	1.6804
Min	.037	.037	.037	.037	1.6078	.037	.0373
Avg	1.2118	1.447	1.0719	1.2428	1.7372	1.3256	1.2409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 203 / TALNI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6535	.7468		.8962	.7282	.6535
2		.7095	.8402		.8962	.7282	.7095
3		.7095	1.0269			.6722	1.1203
4	.7468	.7655	1.2136				
5		1.1203	1.307		1.1763	1.0082	1.2136
6		1.307	1.4003		1.4003	1.1203	1.307
7		1.2696	1.4003		1.286	1.4003	1.307
8	1.1203	1.2136	1.4003		1.4003	1.4003	1.2323
9		.9149	1.0269		1.1203	1.251	.8402
10		.6535		.9335	.8962	1.1576	.7842
11			.6535		.7282	.8029	.6535
12	.3734	.4668	.6535	.7842	.6161	.5788	.5601
13		.4668	.5601			.3734	.4668
14	.3734	.5601		.7282		.3734	.4668
15		.5601			.5601	.3734	.3734
16		.5601		.6161	.5601	.4854	
17		.6535	.8402			.5228	.5601
18	.6535	.8402		.8962		.6908	.6535
19		1.2136				1.2136	1.2136
20	.9709	.037					1.0269
21		.037				.9335	.8775
22		.7468				.8402	.8589
23	.6535	.7468				.7095	.7468
24	.6535	.7468		.7842		.7282	.6535
Max	1.1203	1.307	1.4003	.9335	1.4003	1.4003	1.307
Min	.3734	.037	.5601	.6161	.5601	.3734	.3734
Avg	.6932	.7371	1.0054	.7904	.9614	.8224	.8309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 204 / MATALA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-17
HR	Load (MW)
24	2.4863
Max	2.4863
Min	2.4863
Avg	2.4863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 201 / Lyhari

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3547	.3206		.3772	1.2163	1.2631
2	.3395	.3734	.3206	.0339	.3772	1.2803	1.4089
3	.3584	.3734	.3395	.3083	.3772	1.3443	1.4575
4	.3772	.3921	.3772	.381	.3772	1.4575	1.5223
5	.415	.4108	.4715	.4503	.4108	1.5402	1.5708
6	.4904	.4668	.5093	.4503	.4904	1.6907	1.6842
7	.5847	.5975	.547	.5195	.5658	2.0885	1.8785
8	.5281	.5415	.5281	.4849	.5658	2.1376	2.0729
9	.4527	.4854	.4338	.4156	.4527	2.1052	2.0081
10	.3395	.3395	.4715		.3772	1.9845	1.8461
11	1.7976	1.8461	1.597	2.1376	1.906	.2614	.2425
12	2.0081	2.1052	1.7199	2.17	1.9845	.2054	.2263
13	1.9433	1.9433	1.8427	1.9433	2.0241		.0226
14	1.9433	1.8138	1.812	1.9608	1.9608	.2614	.2928
15	1.9109	1.9433	1.7813	2.1376	1.9372	.2801	.2425
16	1.9109	1.8138	1.812	2.2024	1.9608	.2987	.2078
17	1.8623	1.8138	1.7813	2.1125	2.0165	.3361	.2641
18	1.8138	1.7078	1.7659	2.0557	1.8343	.3734	.2425
19	.4854	.4527	.3685	.4715	.4904	.4481	.4156
20	.4481	.4715	.3699	.4715	.4805	.4668	.4503
21	.4294	.415	1.3667	.4481	.462	.4481	.4904
22	.4481	.4108	.0373	.4481	.4527	.4481	.049
23	.4108	.3734	.3391	.4294	.4108	.3547	.4156
24	.3881	.3921	.3206	.3064	.3479	.4024	.4108
Max	2.0081	2.1052	1.8427	2.2024	2.0241	2.1376	2.0729
Min	.3395	.3395	.0373	.0339	.3479	.2054	.0226
Avg	.9177	.9099	.8847	1.0154	.9433	.9317	.8619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 202 / HARDAP

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3603	1.2793	1.1984	1.0722	1.1203	.3584	.3547
2	1.6032	1.3279	1.2146	1.2022	1.1203	.3584	.3547
3	1.4251	1.3603	1.2146	1.3255	1.1523	.3584	.3547
4	1.4575	1.3927	1.2308	1.3513	1.1385	.3584	.3547
5	1.5223	1.4089	1.247	1.382	1.1843	.415	.3734
6	1.587	1.4899	1.2631	1.4281	1.2483	.4904	.4481
7	1.6194	1.9595	1.5546	1.4742	1.5684	.4904	.4481
8	1.8785	1.8461	1.4251	1.6277	1.7924	.415	.3734
9	1.8785	1.8138	1.7814	1.7199	1.7604	.3395	.2987
10	1.7814	1.6518	1.7166		1.5684		.2054
11	.2054	.1698	.1541	.1509	.1132	1.4575	1.6584
12	.168	.1886	.1233	.1886	.1494	1.5384	1.7506
13	.1494	.1886	.1233	.2075	.1886	1.5708	1.5663
14	.168	.1698		.2075	.1886	1.6032	1.382
15	.168		.1233	.1886	.1886	1.4575	
16	.168			.1886	.1886	1.6032	1.2285
17		.1886		.1698	.1886	1.5708	1.6584
18	.2241	.1698		.2075	.2263	1.5708	1.5049
19	.3361	.3206	.2466	.3206	.3772	.3361	.2918
20	.3361	.3395	.2774	.3961	.3772	.3547	.3071
21	.3547	.3584	.2774	.3961	.3772	.3547	.3378
22	.3361	.3584	.2774	.3772	.3772	.3734	.3071
23	.3361	.3395	.3083	.3772	.3772	.3734	
24	.3206	.3361	.3206	.2774	.3584	.3772	.3734
Max	1.8785	1.9595	1.7814	1.7199	1.7924	1.6032	1.7506
Min	.1494	.1698	.1233	.1509	.1132	.3361	.2054
Avg	.8428	.8481	.8039	.7059	.7221	.7881	.7242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 203 / PINGALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5693	.6958	.6958	.7353	.6722	.3953	.3953
2	.6167	.7748	.7274	.7812	.7274	.3795	.3795
3	.7116	.8697	.759	.8272	.7907	.3795	.3953
4	.759	.933	.7907	.9944	.8539	.3795	.3953
5	.7907	1.0279	.8697	1.1321	.9488	.3795	.427
6	.8697	1.5497	1.0753	1.1933	1.0437	.3953	.4586
7	.9962	1.5497	1.4864	1.2561	1.1702	.3841	.427
8	1.3757	1.6129	1.2018	1.5011		.3361	.3321
9	1.3441	1.5181	1.5971	1.5318	1.5497	.3163	.3163
10	1.0911	1.5813	1.4864	1.6288	1.3916	.2372	.1739
11	.2214	.1898	.1836	.1265	.1898	1.2651	1.1168
12	.1898	.2056	.1838	.1581	.1898	1.5023	1.1627
13	.2056	.2056	.0192	.1739	.2056	1.2967	1.3616
14	.2056	.2214	.1843	.1898	.2056	1.3757	1.4075
15	.2056	.2214	.1843	.1898	.2056	1.5971	
16	.2056	.2056	.1843	.1898	.2214	1.4232	1.1321
17	.2372	.1898	.215	.1423	.2214	1.3283	1.3157
18	.253	.2372	.2451	.2214	.2688	1.3916	1.3004
19	.4111	.3953	.3993	.3953	.4111	.427	.3978
20	.427	.427	.3993	.427	.4428	.427	.459
21	.4428	.427	.3983	.4111	.4428	.4428	.4131
22	.4111	.3953	***	.4111	.4111	.4428	.4284
23	.3795	.3795	.0384	.3795	.4111	.4111	.4284
24	.3479	.3795	.3795	.3676	.3795	.3953	.4111
Max	1.3757	1.6129	29.7688	1.6288	1.5497	1.5971	1.4075
Min	.1898	.1898	.0192	.1265	.1898	.2372	.1739
Avg	.5528	.6747	1.8114	.6402	.5806	.7212	.6537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 201 / JAWALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	2.915
Max	2.915
Min	2.915
Avg	2.915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 202 / VIRSANI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3223	.3419	.3613		.3361	.7095	
2	.3036	.3419	.3803	.3412	.3361	.8589	.7526
3	.2846	.3609	.4183	.3791	.3734	.8962	.7407
4	.3412	.3985	.4554	.436	.4294	.8215	.8021
5	.3602	.4364	.4939	.4929	.4668	.8215	.8026
6	.436	.4939	.5319	.5308	.5975	.8402	.7868
7	.4929	.5308	.5313	.5497	.5975	1.0509	.9094
8	.4438	.4559	.4744	.9858		1.0829	1.0248
9	.3795	.4166	.436	.3981		1.0829	.8613
10	.3423	.3036	.2469		.2614	1.0082	.831
11	.9459	.958	.9101		1.1576	.2079	.2464
12	1.0348	1.0206	.96		1.1389	.2087	.2085
13	.9911	1.017	.9948		1.1389	.2275	.2464
14	1.0288	.9911	.9785		1.1576	.2085	.2282
15	.824	.9492	.9622		1.1576	.2087	.2282
16	.9603	.9751	.9622		1.0829	.2277	.2659
17	1.0601	.9415	.9094	1.0829	1.0456	.3039	.3412
18	1.0147	.9346	.9459	1.1203	1.1203	.3226	.3226
19	.4369	.4559	.455		.4854	.4739	.4364
20	.4369	.4373	.4369		.4481	.455	.4364
21	.3993	.4179	.4369	.4108	.4108	.436	.4369
22	.3993	.4179	.417	.3734	.3734	.3981	.436
23	.3803	.3993	.3795	.3361	.3361	.3795	
24	.3605	.3613	.3985	.2987	.2987	.3412	.3799
Max	1.0601	1.0206	.9948	1.1203	1.1576	1.0829	1.0248
Min	.2846	.3036	.2469	.2987	.2614	.2079	.2085
Avg	.5825	.5982	.6032	.5526	.6705	.5655	.5329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 203 / KAMARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.4287	1.4637	1.3123	1.7924	.5975	.6066
2	1.2558	1.4569	1.4763	1.3763	2.0538	.5975	.6648
3	1.259	1.4935	1.4729	1.4335	2.1472	.5975	.7211
4	1.3171	1.5249	1.5366	1.495	2.3339	.6348	.7583
5	1.4163	1.5197	1.5857	1.568	2.3525	.7842	.8349
6	1.6189	1.8394	1.6169	1.734	2.3899	.8215	.9099
7	1.6892	1.9356	2.1552	2.096	2.1472	.8402	.8539
8	1.6636	2.193	2.1726	2.1164		.7842	.7408
9	2.0301	2.1102	2.3293	1.857		.6161	.5319
10	2.0165	2.1226	2.1879	1.8412	2.1658	.4294	.5313
11	.3981	.4369	.417		.4294	1.8345	1.8675
12	.3803	.4369	.4175		.4108	.5697	2.7298
13	.3419	.3419			.4108	2.0645	2.2138
14	.3605	.3795	.3788		.4294	1.8547	2.0873
15	.3419	.3419	.3605		.4481	1.8747	2.0656
16	.3973	.3602	.3412		.4481	2.0314	2.0854
17		.4162	.3575	.4668	.4481	1.8426	2.1245
18	.6419	.5664	.4092	.5975	.5788	1.9708	1.857
19	.8729	.759	.7962		.7842	.7978	.677
20	.7393	.7598	.7204		.7468	.7218	.7393
21	.6831	.6831	.6831	.7095	.7095	.7225	.6655
22	.6452	.6642	.7196	.6722	.6173	.6838	.6831
23	.6084	.6458	.6452	.6348	.6348	.6655	.6452
24	.5687	.5882	.6066	.5975	.6348	.6458	.5698
Max	2.0301	2.193	2.3293	2.1164	2.3899	2.0645	2.7298
Min	.3419	.3419	.3412	.4668	.4108	.4294	.5313
Avg	.9794	1.0419	1.0804	1.2818	1.1415	1.0410	1.1735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 201 / MANATHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	3.0007
Max	3.0007
Min	3.0007
Avg	3.0007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 202 / KEDARGUDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3052	.3467	.3841	.3391	.4382	.4572
2	.3801	.3391	.4024	.4163	.39	.4191	.4382
3	.4344	.373	.4409	.4887	.4578	.4191	.4382
4	.4733	.4239	.4694	.5249	.4578	.4191	.4191
5	.5609	.4694	.5087	.5434	.503	.4191	.4191
6	.8745	.5365	.5765	.6001	.5197	.4763	.4191
7	1.0562	1.0395	1.0682	1.0974	1.073	.4191	.4382
8	1.1401	1.1736	1.2742	1.1401		.3239	.3239
9	1.0395	.9221	1.1934	1.1142	1.1233	.2667	.2667
10	.9054	1.0059	.7127	.9221	.9221	.2096	.1905
11	.1715	.1509	.1715	.1524	.0152	.7293	.8718
12	.1715	.1509	.1524	.1524	.1524	.9503	1.105
13	.1524	.1524	.1524	.1715	.1715	1.0322	.9556
14	.1524	.1509	.1524	.1524	.1715	.9231	.8886
15	.1524	.1715	.1509	.1715	.1698	.8907	.8048
16	.1524	.1715	.1524	.1715	.1509	.8745	.7545
17	.1905	.1715	.1905	.1905	.1698	.9175	.7712
18	.1905	.1715	.2096	.1905	.1886	.8684	.8048
19	.4382	.4572	.4572	.4572	.4763	.4572	.4572
20	.4763	.4572	.4954	.4763	.4954	.4572	.5335
21	.4763	.4763	.4715	.4763	.4763	.4954	.5335
22	.4572	.4572	.4572	.4572	.4763	.4954	.4954
23	.4382	.4572	.4763	.4572	.4763	.4763	.4763
24	.4191	.4382	.4382	.4572	.4382	.4572	.4763
Max	1.1401	1.1736	1.2742	1.1401	1.1233	1.0322	1.105
Min	.1524	.1509	.1509	.1524	.0152	.2096	.1905
Avg	.4695	.4426	.4634	.4736	.4267	.5765	.5724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 203 / MALZARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.373	.3391	.362	.3391	.2452	.2667
2	.4525	.407	.4144	.4163	.373	.2263	.2477
3	.4784	.4527	.4191	.4525	.4191	.2263	.2477
4	.5258	.503	.431	.4733	.4527	.2263	.2667
5	.6001	.5365	.4694	.4733	.503	.2641	.2858
6	.7042	.6203	.5087	.5087	.547	.3206	.3429
7	.8453	.8718	.779	.7209	.8192	.415	.4191
8	.9945	1.0395	.9724	.9069	1.1105	.3584	.4001
9	.9945	.8718	.9175	.7449	.788	.3018	.2667
10		.8848	.5243	.7042	.8718	.2075	.1886
11	.1715	.1143	.1524	.1509	.1334	.7625	.788
12	.1334	.1143	.1334	.1334	.1524	.7343	.8718
13	.1334	.1143	.1143	.1143	.1334	.7343	.8383
14	.1334	.1334	.1334	.132	.1334	.6944	.7712
15	.1143	.1143	.1334	.132	.1132	.68	.7209
16	.1334	.1334	.132	.1143	.1143	.6249	.6706
17	.1715	.1334	.1698	.1698	.1132	.7907	.7042
18	.2096	.1886	.2096	.1886	.1509	.7655	.5868
19	.3584	.3584	.362	.3772	.3772	.362	.3584
20	.3206	.3395	.3239	.3239	.3206	.362	.3584
21	.2829	.3018	.2858	.2858	.3018	.3239	.2858
22	.2641	.2829	.2858	.2858	.2829	.3048	.2858
23	.2641	.2641	.2858	.2667	.2641	.3048	.2667
24	.2477	.2452	.2452	.2641	.2477	.2452	.2858
Max	.9945	1.0395	.9724	.9069	1.1105	.7907	.8718
Min	.1143	.1143	.1143	.1143	.1132	.2075	.1886
Avg	.3899	.3916	.3642	.3626	.3776	.4367	.4469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 201 / LOHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1802	.3772	.1886	.1886	.1901	.1886
2		.1825	.3734	.1886	.1886	.1825	.1886
3		.1877	.3772	.1886	.1886	.1825	.1886
4	.1867	.1821	.3772	.1867	.1886	.1901	.1867
5		.1865	.1886	.1867	.1886	.2732	.1867
6	.2801	.2849	.2829	.2801	.1886	.2738	.1867
7	.2801	.2846	.3734	.2801	.2829	.2738	.2801
8	.2801	.365	.2829	.2801	.2829	.2652	.2801
9	.2809	.1852	.2801	.3696	.2829	.2815	.1848
10	.1825	.1877	.2772	.1886	.2829	.1867	
11	.884	.5935	.5335	.4744	.9269	.5535	.4515
12	.9126	.5601	.7621	.6097	.9355	1.0536	.6097
13	.9126	.5601		.7526	.9288	.6097	
14		.6401	.7621	.7621	.9316	.6097	
15	.9126	.6097	.6944	.7621	.8535	.6097	
16	.8213	.6097	.6944	.7526	.9126	.6097	.6773
17	.8213	.6173	.6859	.7526	.8983	.6773	
18	.8213	.7716		.602	.7072	.6097	.7621
19	.2738	.2801	.2801	.2829	.2715	.1829	.2829
20	.2652	.2829	.2829	.2829	.2752	.2829	
21	.2652	.2829	.2829	.2829	.2643	.2829	.2829
22	.2638	.2829	.2829	.2829	.2778	.2829	
23	.1768	.2829	.1886	.2829	.2738	.2829	.2829
24	.1867	.1724	.7621	.1886	.2715	.1825	.2829
Max	.9126	.7716	.7621	.7621	.9355	1.0536	.7621
Min	.1768	.1724	.1886	.1867	.1886	.1825	.1848
Avg	.4597	.3655	.4274	.3920	.4580	.3804	.3237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 202 / CHIKALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4251	1.677	1.6632	1.6632	1.387	1.677	1.6632
2	1.8233	1.768	1.829	1.7718	1.5261	1.8633	1.848
3	2.2405	2.1902	1.829	1.6956	1.9662	1.8252	2.2177
4	2.2634	2.6486	2.1262	1.6956	1.9662	2.3182	2.3529
5	2.5149	2.9813	2.713	2.0119	2.4291	2.7864	2.3282
6	2.6825	3.1824	2.4387	2.5149	3.0769	3.1028	2.3739
7	2.9835	3.155	2.9835	3.0178	3.2769	3.1741	2.6825
8	3.315	3.4225	3.3532	3.0178	3.4008	3.4678	3.0178
9	3.2603	3.3779	3.0178	2.652	2.915	3.3471	3.0178
10		2.7149	2.713	2.3205	2.915	2.4863	
11	.3734	.3734	.3734	.2829	.3536	.3734	.3734
12	.365	.3772	.1867	.2829	.365	.3734	.3734
13	.3765	.3734	.1867	.2829	.3536	.3734	
14	.3525	.3772	.2801	.2829	.3578	.3772	
15	.3574	.3696	.2801	.2829	.365	.3772	.3734
16	.365	.3734	.3734	.2829	.3715	.3772	
17	.365	.3696	.4715	.3772	.365	.3772	
18	.5304	.5544	.5544	.5658	.5304	.3772	.5601
19	.7301	.8316		.7545	.7301	.5658	.7468
20	.7956	.8402	.8488	.8488	.8213	.8402	
21	.8213	.924	.8488	.8488	.8145	.9145	.8402
22		.9431	.8488	.8488	.8102	.9431	
23	.7301	.7545	.7545	.8488	.7301	.8488	.7468
24	.7468	.7438	.7545	.7545	.8488	.7049	.8488
Max	3.315	3.4225	3.3532	3.0178	3.4008	3.4678	3.0178
Min	.3525	.3696	.1867	.2829	.3536	.3734	.3734
Avg	1.3372	1.4718	1.3664	1.2461	1.3615	1.4113	1.5509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 203 / WANWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4725	.3772	.4715	.4715	.4563	.4715
2	.4668	.442	.3772	.4715	.4715	.4563	.4668
3		.4406	.3772	.4715	.4715	.362	.4668
4	.4668	.442	.3734	.4715	.4715	.354	.5601
5		.442	.3734	.4715	.4715	.4563	.5544
6	.5658	.5407	.3734	.4715	.4715	.4563	.4668
7	.5716	.442	.3734	.4668	.5658	.4744	.3696
8	.2738	.3753	.3734	.3772	.5658	.3799	.3734
9	.2738	.3757	.2743	.2829	.4715	.2795	.2801
10	2.3727	.365	.2801	.2829	.3772	.2801	
11	2.3727	1.6766		1.4575	1.8785		1.3413
12	2.2984	1.8233	2.0348	2.13	2.0873	2.0348	2.0119
13	2.2588	1.9662	1.9662	1.9433	2.2359	1.9662	
14	2.2588	1.9662	1.8976	1.6385	2.2291	1.8976	
15	2.1902	1.989	1.989	1.6194	2.037	2.0119	1.9062
16	1.9532	1.9662	1.989	1.6194	1.8252	1.9662	1.7404
17	1.9805	2.0481	1.8023	1.6385	1.8252	1.989	
18	2.058	1.8023	1.8023	1.7814	1.6427	.1966	1.5089
19	.5275	.4715	.5601	.4715	.4563	.5658	.4715
20	.4668	.4668	.5658	.4715	.4692		
21	.4692	.5658	.5658	.4715	.4501	.5658	.5658
22	.4525	.5658	.5658	.4715	.4658	.5658	
23	.442	.4715	.5658	.4715	.4563	.5601	.503
24	.4715	.4406	.4715	.4715	.4715	.4525	.4715
Max	2.3727	2.0481	2.0348	2.13	2.2359	2.0348	2.0119
Min	.2738	.365	.2743	.2829	.3772	.1966	.2801
Avg	1.1665	.9399	.8839	.8707	.9725	.8512	.8072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 201 / HIMAYATNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.02	.0225	.0224	.9412		.8596	.8688
2	.0207	.0225	.0224	.9412		.8596	.8596
3	.0207	.0219	.0224	.9313		.8779	.8688
4	.0207	.0224	.0224	.9412		.8688	.8688
5	.0206	.0243	.0224	1.086		.9412	.9412
6	.024	.0261	.0243	1.2071		.9412	.9511
7	.0295	.0299	1.1827	1.182		1.1462	1.086
8	.0294	.028	1.2071	1.086		1.0745	.0299
9	.0294	.0237	1.1584	1.086	1.1104	1.0974	.0299
10	.0258	.0261	1.0974	1.0136	1.2308	.0271	.028
11	.024	.0243	1.2437	1.0136	1.134	.0235	.028
12	.0276	.0243	1.1462	1.0136	1.134		.028
13		.0243	1.2308	1.0242	1.0387	.0238	.0299
14	.0258	.0243	1.0029	1.0242	1.0498	.0233	.0299
15	.0244	.0243	.9412	.0238	1.0136	.0251	.0299
16	.0244	.0224	.9412	.0235	1.0242		.0299
17	.0225		1.0029	.0329	1.0498	.905	.0207
18	.0282	.0299	1.0136	.0326	1.2048	1.0136	.0299
19	.0332		1.3169	.0329	1.267		.0373
20	.0319	.0299	1.2437	.0308	1.1584	1.1584	.0336
21	.0281	.0299	1.2308	.0296		1.086	.0317
22	.0281	.028	1.1584	.0277	1.086	1.0242	.0299
23	.0262	.0261	1.086		1.086		.028
24	.0221	.0239	.0243	1.0974		1.0974	.8596
Max	.0332	.0299	1.3169	1.2071	1.267	1.1584	1.086
Min	.02	.0219	.0224	.0235	1.0136	.0233	.0207
Avg	.0255	.0254	.8069	.6879	1.1134	.7537	.3241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 202 / SAWANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 203 / MANGROOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	1.2003
Max	1.2003
Min	1.2003
Avg	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 204 / KHADKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0082	.0102	.0102	.1791		.1677	.1791
2	.0085	.0098	.0102	.1715		.1677	.1715
3	.0084	.0098	.0102	.1677		.1715	.1715
4	.0085	.0099	.0102	.1677		.1715	.1677
5	.0082	.0098	.0102	.1966		.2439	.2195
6	.0102	.0119	.192	.2347		.2515	.2263
7	.4636	.0119	.213	.2401		.208	.317
8	.0098	.0102	.1783	.2012		.3414	.022
9	.0085	.0085	.2012	.16	.1844	.3414	.0254
10	.0085	.0068		.1006	.128	.0003	.0254
11	.0068	.0051	.0983	.08	.1311	.0034	.022
12	.0051	.0051	.1029	.08	.0983		.022
13		.0288	.0732	.0686	.2515	.0018	.0068
14	.029	.0288	.0686	.0747	.2629	.0018	.0068
15	.0257	.0271	.0693	.008	.2743	.0018	.0068
16	.0239	.0254	.0854	.0079	.221		.0068
17	.0212		.08	.0087	.1132	.0983	.0068
18	.0273	.0271	.064	.0079	.317	.1372	.0068
19	.0245		.0747	.0096	.317		.0119
20	.0255		.0427	.0089	.3071	.2279	.0119
21	.0117	.0119	.16	.0037		.2279	.0119
22	.0115	.0119	.2012	.0034	.218	.2279	.0119
23	.01	.0119	.1966		.1966		.0119
24	.0099	.0098	.0102	.192		.2058	.2149
Max	.4636	.0288	.213	.2401	.317	.3414	.317
Min	.0051	.0051	.0102	.0034	.0983	.0003	.0068
Avg	.0337	.0139	.0940	.1032	.2157	.1599	.0785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 205 / SIRANGINI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	1.1145
Max	1.1145
Min	1.1145
Avg	1.1145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174027 / ISLAPUR

Feeder No / Name : 201 / KOSMETH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.3108	1.5214	1.7147		1.7147		
8						1.9845	
9						1.9183	
10	1.9183						
11	1.9183						
12		1.8861	1.8023		1.6194		
14						1.9117	1.7204
15		1.8861				1.8522	
17	1.7199						
18	1.9845	2.0576		1.8861			
19	1.9183				1.7204	1.7737	
20	1.7199		1.4746			1.7119	
21		1.7147		1.7147			
22	1.5214				1.3927	1.4883	
23			1.3108				1.3108
24							1.323
Max	1.9845	2.0576	1.8023	1.8861	1.7204	1.9845	1.7204
Min	1.3108	1.5214	1.3108	1.7147	1.3927	1.4883	1.3108
Avg	1.7514	1.8132	1.5756	1.8004	1.6118	1.8058	1.4514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174027 / ISLAPUR

Feeder No / Name : 202 / SAHARTRAKUND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.8316	.9869	1.0517		1.0517		
9	1.0574	1.0867		1.0517			
11						1.0221	
12			.905				
13	1.0574						
14						.8812	.8316
15		1.2269					
16						.8812	
18						.8812	
19	1.1279				1.0974	1.0574	
20	1.1279		1.0059			1.0574	
21		1.2269		1.2269			
22	.9869				1.0059	.9516	
23			.9145				.924
24						1.0585	.8812
Max	1.1279	1.2269	1.0517	1.2269	1.0974	1.0585	.924
Min	.8316	.9869	.905	1.0517	1.0059	.8812	.8316
Avg	1.0315	1.1319	.9693	1.1393	1.0517	.9738	.8789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174044 / JALDHARA

Feeder No / Name : 201 / JALDHARA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566		.0305			.0145	
2	.0566		.0297			.0149	
3	.0566		.0305			.0149	
4	.0754		.0305			.0145	
5	.0754		.0305			.0141	
6	.0754		.0305			.0145	
7	.6979						
8	1.094	.6859					
9	1.0288	.6859					
10	1.0631	.7811					
11	1.1145	.8642					
12	1.1145	.8642					
13	1.0288	.7099	1.226		1.0364	1.0288	.9667
14	1.0288	.8642	1.1317		1.0082	1.0288	.8482
15			1.1317	.6859	.8383	1.0288	.5487
16			1.094	1.0288	.6481	1.0288	
17			1.0185		.8539	1.0288	.5418
18			1.0185	.8573	.7468	.8573	.7011
19			.811	.8573	.7099	.6859	.5418
20			.7545	.823	.6455	.6859	.4988
21		.0221	.0754	.6859	.0217	.0686	.0518
22		.0333	.0754		.02		.0762
23		.0267			.0211		.0518
24	.0566	.0686	.0274			.0145	
Max	1.1145	.8642	1.226	1.0288	1.0364	1.0288	.9667
Min	.0566	.0221	.0274	.6859	.02	.0141	.0518
Avg	.5749	.5096	.5027	.8230	.5954	.4715	.4827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174044 / JALDHARA

Feeder No / Name : 202 / NANDGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4458	.4755		.4435		.4458
2	.4904	.4458	.4755		.4481		.4458
3	.4904	.4458	.4755		.4527		.4458
4	.5093	.4458	.4706		.4527		.4458
5	.547	.4801	.5068		.4801	.4854	.4801
6	.547	.4801	.5487		.5144	.4904	.4801
11	.3258	.3224	.415	.3086	.4115	.3086	.4477
12	.3086	.3189	.3584	.3086	.3601	.3429	.4024
13	.3086	.3506	.3395	.3086	.3601	.3429	.3582
14	.3086	.2743	.3018	.3086	.3772	.3429	.3658
15	.3086	.2743	.3018	.3086	.3391	.3429	.3174
16	.3086	.3294	.3395	.3086	.2629	.3429	
17	.3429	.3467	.3584		.3429	.3429	.3881
18	.4115		.4527	.3429	.463	.4115	.4066
19	.4801	.5847	.5658	.4458	.5853	.4458	.5228
20	.5144	.5731	.5847	.4801	.5729	.4801	
21	.5144	.5487	.5847	.5144	.5544	.5144	.5601
22	.5144	.5487	.547	.5144	.5175	.5144	.5601
23	.4458	.5121		.4458	.499	.4801	.5359
24	.5281	.4458	.5121		.4854		.6173
Max	.547	.5847	.5847	.5144	.5853	.5144	.6173
Min	.3086	.2743	.3018	.3086	.2629	.3086	.3174
Avg	.4347	.4302	.4534	.3829	.4461	.4125	.4570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 201 / SARSAM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7316	.7202		.6859	1.0631	.9214
2		.7316	.6859		.6859	1.1488	1.0631
3		.7316	.6859		.6859	1.2003	1.134
4		.7316	.6859		.7545	1.2346	1.3466
5		.8048	.7373		.7888	1.286	1.5432
6	.7716	.8779	.823		.8573	1.3717	1.5432
7	.7545	.8779	.8573		.7545	2.0233	2.0576
8		.7888		.6516		2.1605	1.8861
9		.5487	.6173	.6173	.583	2.1948	2.1262
10		.4801	.4458		.2229	2.0576	1.989
11		1.989	1.5775		1.9204	.4024	.5121
12		2.4006			2.3491	.0229	.439
13		2.5206			2.3663	.3658	.2195
14	2.2291	2.4691			2.332	.3658	.5121
15	2.1948	2.3148			2.2805		.4755
16	2.4006	2.5892	2.4006		2.332	.439	.4755
17	2.572	2.572	2.2977		2.332	.5121	.5487
18	2.4691	2.4863	2.2291	1.8519	2.2977	.5853	.5853
19	.9145	.7545	.7888	.7545	.8573	.8779	.9145
20	.9145	.6859	.7888	.8916	.8573	.9145	.9877
21	.8962	.7545			.823	.9145	.9145
22	.8413	.8059			.7545	.8596	.9145
23	.8048	.7716			.7202	.823	.8779
24	.6859	.7682	.7545		.6859	.6859	.823
Max	2.572	2.5892	2.4006	1.8519	2.3663	2.1948	2.1262
Min	.6859	.4801	.4458	.6173	.2229	.0229	.2195
Avg	1.4191	1.2995	1.0685	.9534	1.2577	1.0221	1.0338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 202 / TEMBHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2481	.4801		.1372	.0857	.0914
2		.2481	.1715		.1372	.0857	.0914
3		.2835	.2058		.1372	.0857	.0914
4		.2835	.3944		.1715	.0857	.1097
5		.3189	.2401		.1715	.1029	.128
6	.3429	.3544	.2401		.1715	.1029	.1463
7	.4458	.4252	.3772		.2401	.1029	.1463
8		.5316		.463		.1029	.1097
9		.5487	.4458	.4801	.3086	.0732	.0914
10		.5487	.4458		.2401	.0732	.0732
11		.0514	.0514		.0686	.4961	.3658
12		.0686	.0514		.0514	.6733	.567
13		.0686			.0686	.7442	.6024
14	.0549	.0514			.0686	.7087	.3544
15	.0549	.0686			.0686		.3544
16		.0686	.0514		.0514	.7087	.3898
17	.0732	.0686	.0686		.0686	.4252	.4961
18	.0914	.0857	.0857		.1029	.3898	.4961
19	.128	.12	.0857		.12	.1097	.1463
20	.128	.1029	.12	.1372	.1372	.128	.1463
21	.128	.12			.1372	.128	.1463
22	.128	.1029			.12	.128	.1463
23	.1097	.1029			.1029		.1463
24	.0857	.0914	.0857		.0686	.0857	.1097
Max	.4458	.5487	.4801	.4801	.3086	.7442	.6024
Min	.0549	.0514	.0514	.1372	.0514	.0732	.0732
Avg	.1475	.2068	.2118	.3601	.1282	.2557	.2311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 203 / TAKARALA (OLD POTA)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7316	.8059		.7888	1.166	.9922
2			.7716		.7888	1.2003	1.0985
3			.7716		.7888	1.2003	1.2403
4			.823		.7545	1.2517	1.4529
5			.9088		.823	1.3717	1.7147
6	.9945		.9259		.9259	1.4918	1.8176
7	.9259		1.1145		.9602	2.4006	2.4863
8				.703		2.8292	2.3148
9			.6859	.5487	.6859	2.4006	2.1434
10		.4115	.4458		.583	2.0576	2.0576
11	2.4863	2.6578	2.0576		2.4863	.439	.2743
12		2.915	2.6578		2.915	.3841	
13		2.8292			2.572	.4024	
14	2.915	2.8292			2.4006	.4938	
15	2.572	2.6578			2.3148		
16	2.7435	2.0576	2.3148	2.572	2.572	.5304	.4938
17	2.572	2.4863	2.4006		2.4006	.5304	.5487
18	2.4863	2.4006	2.2291	2.4006	2.3148	.695	.5853
19	.9145	.9774	.8402	.823	.8573	.9145	.9328
20	.8596	.9945	.8916	.8916	.9088	.9694	.9145
21	.8596	.9259			.8573	.9145	.9694
22	.8413	.8402			.823	.8596	.8797
23	.7682	.823			.7716	.823	.8413
24	.7202	.7682	.823	.8059	.7202	.7202	.7865
Max	2.915	2.915	2.6578	2.572	2.915	2.8292	2.4863
Min	.7202	.4115	.4458	.5487	.583	.3841	.2743
Avg	1.6185	1.7066	1.2628	1.2493	1.3919	1.1324	1.2272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 204 / POTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	1.6289
Max	1.6289
Min	1.6289
Avg	1.6289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174063 / APPARAOPETH

Feeder No / Name : 201 / APPARAOPETH

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	04-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
6			.5201
18		.8501	
24	.6687		
Max	.6687	.8501	.5201
Min	.6687	.8501	.5201
Avg	.6687	.8501	.5201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174063 / APPARAOPETH

Feeder No / Name : 203 / GODJEWALI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-17	04-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
11			.9095
14			.9023
18		.7754	.6996
24	.823		
Max	.823	.7754	.9095
Min	.823	.7754	.6996
Avg	.823	.7754	.8371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174095 / Shiwani

Feeder No / Name : 201 / KANCHALI

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)
6		.9946
7		1.3796
24	1.286	
Max	1.286	1.3796
Min	1.286	.9946
Avg	1.286	1.1871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174095 / Shiwani

Feeder No / Name : 203 / DAYAL DHANORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0623	1.2186	1.2498	1.3123	1.3796	1.2513	
2	1.0059	1.1584	1.1888	1.2193	1.3475	1.2513	.9389
3	.9998	1.1561	1.1591	1.2803	1.3475		.9389
4	1.0242	1.0997	1.1294	.7011	1.3475	1.1229	.9095
5	.9804	1.1439	1.1888	.7316	1.3475	.5454	.9682
6	.9686	1.1888	1.1888	.7811	1.3796		1.0562
7			1.7185	1.4373	1.925		
8				1.7924	1.9571	1.4083	1.6137
9					1.7646		
10	1.656	1.6248					
11		2.0119					
12		2.0934					
13		1.7665	2.0729				2.0245
14	1.531		1.8747		1.8929	1.6137	1.6137
15	1.7375						
17	1.6872	1.9204					
18	1.7497	1.8122					
19	1.6324	1.531	1.5623	1.6683	1.54	1.2029	1.5257
20	1.4632	1.5043	1.4175	1.6042		1.2323	
21	1.4998	1.4529	1.4723	1.5079	1.4758	.7042	1.3496
22	1.4083	1.3748	1.406	1.4438	1.3475		1.3203
23	1.3123	1.3123	1.3748	1.4117	1.2833	.9976	1.2616
24	1.0364	1.2811	1.2498	1.3435	1.3796	1.2513	.9389
Max	1.7497	2.0934	2.0729	1.7924	1.9571	1.6137	2.0245
Min	.9686	1.0997	1.1294	.7011	1.2833	.5454	.9095
Avg	1.3385	1.4806	1.4169	1.3025	1.5143	1.1437	1.2661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 201 / Andegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4458	.4572	.3605	.5228	.6468	1.4937
2	.462	.4458	.4572	.3605	.4908	.7164	1.4937
3	.462	.4458	.4382	.3605	.4908	.8802	1.4632
4	.4572	.4458	.4382	.3647	.4908	1.0402	1.4632
5	.4382	.4458	.4382	.3978	.4908	1.1469	1.6461
6	.4908	.4458	.4681	.4359	.4908	1.3094	1.5432
7		.4024	.4287	.4239	.3944	1.8023	1.9448
8	.2458	.3018	.2881	.2812	.2883	1.8785	2.0645
9	.2294	.2105	.25	.25	.2214		1.9997
10	.2105	.16	.1852	.2134	.2286	1.8185	.8383
11	1.9433	1.7532	1.6604	1.4685	1.4352	.2056	.1543
12	2.1376	2.1376	2.0891	1.4685	1.8435	.1898	.125
13	2.0405	2.2672	2.2405	1.8747	2.0325	.1898	.1852
14	1.9595	2.1862	2.0965	2.0317	2.0325	.1852	.1981
15	1.9845	2.1445	.112	2.0405	1.9608	.1875	.1981
16	1.9845	1.9044	1.4327	2.0729	1.9925	.1875	.1957
17	2.0485		1.7985	2.0243	2.0081	.2401	.2187
18	2.0645	2.0325	1.8364	1.9757	1.9766	.2561	.2561
19	.4481	.4668	.5041	.4527	.5041	.4854	.5281
20	.5228	.5281	.5228	.547	.5175	.4668	.6036
21	.4904	.5281	.5228	.5281	.5359	.4668	.5658
22	.4904	.4715	.4904	.5281	.5175	.4715	.547
23	.4904	.4715	.4904	.5281	.5175	.4715	.5281
24	1.9433	.4904	.4715		.5175		.4715
Max	2.1376	2.2672	2.2405	2.0729	2.0325	1.8785	2.0645
Min	.2105	.16	.112	.2134	.2214	.1852	.125
Avg	1.0442	.9188	.8382	.9126	.9376	.6929	.8636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 202 / TEMBHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.3772	.2743	.4588	.3734	.0924	.0934
2	.462	.3772	.2743	.4588	.3506	.0857	.0934
3	.462	.3772	.2629	.4915	.3506	.08	.0914
4	.4572	.3772	.2629	.4973	.3506	.08	.0914
5	.4382	.4801	.2629	.4973	.4207	.0819	.0914
6	.5609	.5487	.4681	.5365	.4908	.0829	.0857
7	.6274	.6203	.6001	.6104	.6344	.0819	.0838
8	.6554	.7377	.4001	.6405	.7291	.0648	.0819
9	.6882	.7125	.5155	.5937	.6958	.0648	.0625
10	.6964	.6562	.5401	.5639	.6401	.0633	.0457
11	.0324	.0819	.0474	.0312	.0309	.5535	.6173
12	.0324	.0486	.081	.0312	.048	.6325	.6718
13	.0324	.0486	.048	.0312	.048	.6325	.6481
14	.0324	.0486	.048	.0328	.0625	.6173	.6401
15	.032	.048	.048	.0324	.0633	.5937	.6249
16	.032	.032	.0457	.0324	.0474	.5937	.602
17	.032	.032	.0457	.0486	.0324	.6401	.6093
18	.032	.032	.0772	.0648	.0474	.6401	.6081
19	.0373	.112	.112	.1132	.112	.112	.1132
20	.0373	.0943	.0934	.1509	.1478	.112	.132
21	.1132	.0943	.0934	.1132	.1109	.112	.0754
22	.1132	.0943	.0943	.132	.1294	.0943	.0377
23	.1132	.0943	.0943	.132	.1294	.0943	.0377
24	.1132	.1132	.0943	.0943	.0924		.0943
Max	.6964	.7377	.6001	.6405	.7291	.6401	.6718
Min	.032	.032	.0457	.0312	.0309	.0633	.0377
Avg	.2623	.2599	.2035	.2662	.2557	.2698	.2639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 203 / PARDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.4801	.3658	.4915	.5228	.1848	.1867
2	.5544	.4801	.3658	.5243	.4908	.1372	.1867
3	.5544	.4801	.3506	.5243	.4908	.096	.1829
4	.5487	.4801	.3506		.4908	.128	.1829
5	.5258	.5144	.3506	.547	.5609	.1311	.1829
6	.6135	.583	.5548	.5533	.631	.1492	.1543
7	.763	.7377	.6859	.763	.7716	.0983	.1509
8	.9831	.8551	.6722	.9374	.1696	.0648	.0983
9	.9831	.9717	1.0155	.953	.9488	.0324	.0937
10	.9878	.9602	.9414	.945	.7621	.0791	.1067
11	.0972	.0819	.1107	.1094	.0309	.7116	.7716
12	.0972	.0972	.1296	.1094	.0781	.9172	.9061
13	.0972	.081	.08	.0781	.096	.9488	1.0494
14	.0972	.081	.096	.0655	.096	.9259	.4268
15	.096	.096	.112	.0972	.0791	.8592	.884
16	.096	.08	.1067	.0972	.0949	.8592	.9031
17	.096	.08	.1067	.0972	.0972	.9122	.9686
18	.096	.096	.108	.1134	.1107	.9122	.6562
19	.1867	.2054	.1867	.132	.2054	.2241	.2263
20	.2054	.1886	.1867	.2452	.2033	.2241	.2641
21	.2263	.1886	.2427	.2263	.2218	.2241	.2641
22	.2263	.1886	.2075	.2452	.2402	.1886	.2641
23	.2263	.1886	.1886	.2263	.2241	.1886	.2641
24	.1886	.2263	.1886	.2075	.2033		.1886
Max	.9878	.9717	1.0155	.953	.9488	.9488	1.0494
Min	.096	.08	.08	.0655	.0309	.0324	.0937
Avg	.3792	.3509	.3210	.3604	.3258	.3999	.3985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 201 / 11 KV MANDVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				1.1443		
8			1.3523			.2481
9		1.4413				.2103
10		1.1142	.9362		.2126	
11		.181				
12		.1753			1.0749	
13						1.1271
16			.2126			
18					.9882	
20					.2835	.2715
21						.2715
22					.2774	
24	.5144			.2454		.2774
Max	.5144	1.4413	1.3523	1.1443	1.0749	1.1271
Min	.5144	.1753	.2126	.2454	.2126	.2103
Avg	.5144	.7280	.8337	.6949	.5673	.4010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 202 / 11 KV PALSHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.2481		
8			.2126			2.1845
9		.2195				1.9334
10		.2103	.2126		1.6817	
11		1.4091				
12		2.0081			.2126	
13						.2126
16			1.869			
18					.2126	
20					.3189	.2743
21						.2772
22					.3189	
24	.5144			.2454		.3189
Max	.5144	2.0081	1.869	.2481	1.6817	2.1845
Min	.5144	.2103	.2126	.2454	.2126	.2126
Avg	.5144	.9618	.7647	.2468	.5489	.8668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 203 / 11 KV UMRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.9172		
8			1.2498			.1311
9		.9922				.0848
10		1.1934	.6562		.1311	
11		.0924				
12		.0914			.8848	
16			.1311			
18					1.0159	
20					.1638	.1715
21						.1715
22					.1638	
24	1.2003			.1311		.1638
Max	1.2003	1.1934	1.2498	.9172	1.0159	.1715
Min	1.2003	.0914	.1311	.1311	.1311	.0848
Avg	1.2003	.5924	.6790	.5242	.4719	.1445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 204 / 11KV MANDAVI RH FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 201 / 11KV WAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3018	.3361	.3395		.3361
4	.3326	.2572	.3018	.3292	.3395	.2103	.3361
7		.3506				.5258	
8	.3696		.3658	.3658	.362		.8764
11	.2572					.9465	
12		.2149	.0934	.0905			.6859
13					.3429		
15							.1753
16	1.2003	1.1641	.439	.0905	1.2003	.1867	
18	.8573	.7602		.0905	.8573		
19			.7164				
20						.4481	
22		.5853	.5975	.5175		.3734	
24	.5144				.3395		
Max	1.2003	1.1641	.7164	.5175	1.2003	.9465	.8764
Min	.2572	.2149	.0934	.0905	.3395	.1867	.1753
Avg	.5886	.5554	.4022	.2600	.5401	.4485	.4820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 202 / 11KV SINDAKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5658	.6283	.6036		.6468
4	.5975	.5258	.5658	.6348	.6036	.5258	.6535
7		.8916				.7011	
8	1.0166		1.0059	.9671	.8688		.7095
11	1.0288					.5121	
12		.9313	.9465	.9412			.3506
13					.8573		
16	.3429	.3582	.5228	.3982	.3506	1.1919	
18	.5144	.543		.543	.5258		
19			.6219				
20						.9671	
22		.6584	.7023	.6468		.8238	
24	.5853						
Max	1.0288	.9313	1.0059	.9671	.8688	1.1919	.7095
Min	.3429	.3582	.5228	.3982	.3506	.5121	.3506
Avg	.6809	.6514	.7044	.6799	.6350	.7870	.5901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 203 / 11KV DAHELI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5658	.6348	.6413		.5975
4	.5544	.5609	.5658	.6348	.6413	.6135	.5914
7		.7362				.7537	
8	.9511		1.0059	.9335	.9955		.8764
11	.5144					.9114	
12		.6447	.7023	.543			.9088
13					.7373		
16	.8573	1.1104	1.0059	1.1222	1.0631	.7392	
18	.8573	.9593		.8688	.8916		
19			.8413				
20						.7316	
22		.7316	.7316	.6653		.7762	
24	.5487						
Max	.9511	1.1104	1.0059	1.1222	1.0631	.9114	.9088
Min	.5144	.5609	.5658	.543	.6413	.6135	.5914
Avg	.7139	.7905	.7741	.7718	.8284	.7543	.7435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 201 / 11 KV BODHADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7975	.8322	.8775	.8322		.823	.9522
2	.7802	.8149	.8659	.8322		.823	.9709
3	.7628	.8149	.9326	.7975		.7888	.9335
4	.7975	.8669	.9886	.8669		.9259	.9709
5	.9015	.9536	1.1203	.9882		1.0117	1.0621
6	1.0749	1.1789	1.283	1.1317		1.1831	1.1529
7	1.2174	1.2136	1.2963	1.286		1.2689	1.4259
8	1.286	1.1443	1.3602	1.3032		1.3375	1.4415
9	1.182	1.0974	1.1203	1.2517	1.3256	1.1488	
10		.8059	.8916	1.0974	1.2535	.9774	
11		.7202	.7888	.8916	.8829	.9259	
12	.7701	.5144	.7888	.7716	.9316	.8402	
13		.5487		.7373	.9669	.8059	
14	.7701	.7373		.7545	.9896	.8059	
15	.7716	.8402	.7373	.6001	.9709	.8059	
16	.8573	.8962	.823	.6859	.9896	.8402	
17	.9088	.9709	.9431	.6859	.7438	.9709	
18	1.046	1.118	.9431	1.0288	1.1088	1.118	
19	1.1831	1.2567	.9088	1.2689	1.3591	1.386	
20	1.0288	1.1552	1.1145	1.3032	1.2644	1.2778	
21	.9259	1.0829	1.0056	1.2003	1.1157	1.1901	
22	.9189	.9916	.9362	.9774	1.0456	1.0829	
23	.8842	.8606	.8842	.9088	.9602	.9896	
24	.8322	.8669	.8793	.8669		.9259	.9709
Max	1.286	1.2567	1.3602	1.3032	1.3591	1.386	1.4415
Min	.7628	.5144	.7373	.6001	.7438	.7888	.9335
Avg	.9379	.9284	.9768	.9612	1.0605	1.0106	1.0979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 202 / 11 KV SAWRI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4161	.5201	.5428	.4854		.4801	.6851
2	.3988	.4854	.5603	.4854		.4458	.6851
3	.3814	.4854	.5597	.4508			.7026
4	.3814	.4681	.5597	.4681		.5487	.5953
5	.4161	.4681	.541	.5201		.5487	.6851
6	.4854	.5375	.5566	.5487		.4973	.7186
7	.5144	.6068	.574	.6001		.5658	.7529
8	.5487	.463	.5797	.5487		.6001	.7553
9	.5373	.4801	.4216	.5487	.5797	.583	.5797
10		.3429	.4287	.5144	.5809	.4801	
11	.394	.3258	.3944	.5144	.4769	.4973	
12	.4835	.3601	.1372	.5144	.5293	.5316	
13	.5194	.3429		.4458	.5822	.5658	
14	.5014	.3479	.3258	.4287	.527	.5144	
15	.4801	.3479	.3772	.3772	.527	.0463	
16	.4973	.3475	.3944	.4287	.5445	.4973	
17	.4973	.3649	.4508	.5658	.5615	.5985	
18	.5316	.4339	.7202	.6173	.5959	.7218	
19	.6859	.6095	.6516	.6173	.5078	.8063	
20	.6344	.6457	.6001	.7716	.6478	.7712	
21	.703	.5947	.6068	.9602	.631	.7537	
22	.7282	.7828	.5548	.9602	.6161	.7378	
23	.7108	.8001	.5201	1.0631	.5658	.7202	
24	.4334	.5375	.8001	.5201		.5144	.7026
Max	.7282	.8001	.8001	1.0631	.6478	.8063	.7553
Min	.3814	.3258	.1372	.3772	.4769	.0463	.5797
Avg	.5165	.4874	.5155	.5815	.5649	.5664	.6862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 204 / 11 KV BODHADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1628	2.2211	2.2634	1.8351		
2	2.13	2.1548	2.2805	1.8023		
3	2.13	2.1548	2.2805	1.8023		
4	2.0972	2.1548	2.4006	1.7695		
5	2.0243	2.1216	2.4863	1.7204		
6	2.1052	2.2708	2.5206	1.7204		
7	2.3482	2.5888	2.6063	2.2462		
8	2.4615	2.6397	2.8807	2.4177		
9	2.7349	1.8299	2.572	2.4006	2.4348	
11						2.6749
12						2.915
13						2.8292
14						2.7778
15						2.7778
16						2.7435
17						2.6771
18						2.6063
19						2.332
23	2.2542	2.2291	1.873	2.0919		
24	2.1628	2.2708	2.2462	1.8842		
Max	2.7349	2.6397	2.8807	2.4177	2.4348	2.915
Min	2.0243	1.8299	1.873	1.7204	2.4348	2.332
Avg	2.2374	2.2397	2.4009	1.9719	2.4348	2.7037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 205 / 11 KV SAWRI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.7147	1.7147
2						1.749	1.749
3						1.749	1.8519
4						1.7833	1.8861
5						1.8519	1.9719
6						1.8861	2.1091
7						2.0576	2.3491
8						2.2291	2.2291
10		.0572					
11	2.6686	2.3758	1.8004	2.6749	2.2291		
12	2.7349	2.4741	3.0007	2.915	2.4006		
13	2.4863	2.13		2.9835	2.5892		
14	2.4863	2.2291	2.7949	2.9492	2.5206		
15	2.3537	2.4006		.1524	2.452		
16	2.3205	2.4348		2.6063	1.8861		
17	2.5692	2.4691	1.1233	2.4348	2.3148		
18	2.1879	2.3148	1.4419		2.2634		
19			1.21				
20			1.3413				
23					1.6289	1.4575	
24						1.7147	1.4575
Max	2.7349	2.4741	3.0007	2.9835	2.5892	2.2291	2.3491
Min	2.1879	.0572	1.1233	.1524	1.6289	1.4575	1.4575
Avg	2.4759	2.0984	1.8161	2.3880	2.2539	1.8193	1.9243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / GOKUNDA 33 KV

Feeder No / Name : 202 / Town Feeder II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / GOKUNDA 33 KV

Feeder No / Name : 203 / CHIKHALI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8669					.8764	
9	.8669			.7468			
11		.7011	.6859				.5258
12					.7164	.5201	
13						.7164	
18					.6935		
23					.8669		1.0517
24					1.0402	.5487	
Max	.8669	.7011	.6859	.7468	1.0402	.8764	1.0517
Min	.8669	.7011	.6859	.7468	.6935	.5201	.5258
Avg	.8669	.7011	.6859	.7468	.8293	.6654	.7888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / GOKUNDA 33 KV

Feeder No / Name : 204 / CHIKHLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / GOKUNDA 33 KV

Feeder No / Name : 206 / MANDVA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					1.5432	
9			1.3717			
11		1.5775				
12					1.387	
13					1.5775	
18				1.3717		
23						1.0288
24	.5144					
Max	.5144	1.5775	1.3717	1.3717	1.5775	1.0288
Min	.5144	1.5775	1.3717	1.3717	1.387	1.0288
Avg	.5144	1.5775	1.3717	1.3717	1.5026	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174071 / GOKUNDA 33 KV

Feeder No / Name : 207 / RH-GOKUNDA FEEDER
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-
ST

Feeder No / Name : 201 / 11 KV BELLORI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-ST

Feeder No / Name : 203 / 11 KV GHOTI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.8573	.8573	.9088	.8573	.8745	.8916
2	.8916	.8573	.8573	.9088	.8573	.8745	.8916
3	.8916	.9431	.8573	.9088	.8573	.8745	.8916
4	.8916	.9431	.8573	.9088	.8573	.8745	.8916
5	.8916	.8745	.8573	.9088	.8573	.8745	.9259
6	.9431	.8745	.8916	.9088	.8916	.8745	.9602
7	.9945	.8745	.8916	.9431	.8573	.823	.9259
8	.8573	.7202	.7888	.8573	.8916	.7202	.8573
9	.9602	.7545	.8059	.8745	.8059	.7202	.8573
10	.703	.7716	.8059	.823	.7202	.5487	.8573
11	.703	.8402	.583	.7888	.7373	.6859	.823
12	.7202	.8916	.823	.8059	.7545	.4801	.703
13	.7373	.9431	.9259	.8573	.7716	.6203	.823
14	.7888	.4287	.8745	.7545	.8059	.6516	
15	.8059	.7888	.823	.7716	.823		
16	.7373	.8059	.8745	.7373	.7202		
17	.7545	.8573	.8573	.823	.703		
18	.9088	.9602	.9602	.8745	.8059	1.0631	
19	1.2003	1.0288	1.2003	1.3375	1.1317	1.3032	
20	.8745	1.0631	1.1831	1.1145	1.1145	1.1488	
21	.9774	1.046	1.1145		1.0631	1.1145	
22	.8573	.9945	1.0631		.9774	1.0288	
23	.9431	.9602				.9945	
24	.9259	.9431	.9259	.9431	.8573	.9088	.9496
Max	1.2003	1.0631	1.2003	1.3375	1.1317	1.3032	.9602
Min	.703	.4287	.583	.7373	.703	.4801	.703
Avg	.8688	.8759	.8991	.8933	.8573	.8599	.8749

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-
ST

Feeder No / Name : 205 / 11KV SIRMITI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-ST

Feeder No / Name : 206 / 11KV GHOTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174092 / 33 KV T.V Center kinwat SUB-ST

Feeder No / Name : 207 / 11KV SIRMITI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / Umri Bazar

Feeder No / Name : 201 / 11KV Chinchkhed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753		.1753	.2103	.2103		
4				.2103			
7	.2743	.2804	.2804	.2804		.1753	.3856
9						.3506	
11							.4207
16		.2454	.4207		.4207		.1753
17				.3856		.3856	
18	.028				.2629		.2454
19	.298	.2629	.2804	.2804		.4557	
22		.2454	.2103	.1753	.2454	.2804	.1734
24	.5144						
Max	.5144	.2804	.4207	.3856	.4207	.4557	.4207
Min	.028	.2454	.1753	.1753	.2103	.1753	.1734
Avg	.258	.2585	.2734	.2571	.2848	.3295	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / Umri Bazar

Feeder No / Name : 202 / 11KV Umri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4175		1.5384	1.5565	1.5565		
4				1.4118			
7	1.6297	1.647				.6516	1.9004
8		1.828	2.0814				
9	2.1491			1.9909	1.9185	1.7013	
11							1.9547
12			.8688				
13						.3258	
16		.7522	.8326		.8145		.8059
17				1.9185		1.9909	
18	.2389				2.1719		1.7718
19	2.2624	1.9728	1.9185	1.8823		2.0271	
22		1.9004	1.8823	1.6651	1.9185	1.7194	1.4022
24	.5144						
Max	2.2624	1.9728	2.0814	1.9909	2.1719	2.0271	1.9547
Min	.2389	.7522	.8326	1.4118	.8145	.3258	.8059
Avg	1.3687	1.6201	1.5203	1.7375	1.6760	1.4027	1.567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / Umri Bazar

Feeder No / Name : 203 / 11KV Wazara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1966		.1357	.2035	.2035		
4				.2374			
7	.2294	.2374				.2035	.2035
8		.39	.3052				
9	.4096			.5426	.373		
12			.407				
13						.6443	
16							.2458
17				.4409		.5765	
18	.0593				.5087		.218
19	.4239	.39	.373	.373		.3391	
22		.2543	.2374	.1696	.1696	.1696	.1475
24	.5144						
Max	.5144	.39	.407	.5426	.5087	.6443	.2458
Min	.0593	.2374	.1357	.1696	.1696	.1696	.1475
Avg	.3055	.3179	.2917	.3278	.3137	.3866	.2037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 203 / 11KV HADSANI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4908	.5228	.4733	.5525	.6516	.8413
2	.5525	.4908	.5601	.4733	.5525	.6613	.8764
3	.5525	.4908	.5601	.4733	.5335	.6783	.8764
4	.5525	.4908	.5788	.4733	.5335	.6952	.9114
5						.6443	1.0517
6						.6706	1.1393
7						.7291	1.1393
8						.9878	1.1568
9						.9882	1.1568
10						.8987	.9816
11	1.0341	1.0974	1.1043		.9326		
12	1.3672	1.2346	1.0692	1.1065	1.0562		
13	1.3847	1.3032	1.1568	1.2039	1.0898		
14	1.4373	1.286	1.1568	1.1568	1.073		
15	1.2445	1.166	1.1393	1.073	1.0059		
16	1.3146	1.2174	1.1393	1.0059	.9892		
17	1.3496	1.2289	1.1744	1.0802	1.0395	.3856	.4191
18	1.2094	1.2548	1.2094	1.1145	.9326	.4207	.381
19	.5959	.6161	.5784	.6287	.5788	.6135	.6668
20	.5959	.5975	.5959	.6287	.5788	.5959	.6287
21	.5784	.5975	.5959	.6097	.5975	.5784	.6478
22	.5609	.6161	.5609	.5716	.5975	.5609	.6287
23	.5434	.5788	.5258	.5906	.5788	.5434	.6097
24	.5144	.5083	.5415	.4908	.5716	.5601	.5258
Max	1.4373	1.3032	1.2094	1.2039	1.0898	.9882	1.1568
Min	.5144	.4908	.5228	.4733	.5335	.3856	.381
Avg	.8845	.8481	.8205	.7738	.7663	.6591	.8133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 204 / 11KV ASTHA(SARKHANI) SINGLE PHASING

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5083	.6173	.7888	.6859	.6722	.6661
2	.6001	.5434	.5935	.8764	.7202	.6722	.631
3	.6344	.5434	.6767	.8764	.7202	.6908	.631
4	.6516	.5434	.7282	.9114	.7373	.7655	.631
5	.6859	.5959	.6722	.964	.7716		
6	.703	.7362	.4668	1.0166	.7888		
7	.7373	.8764	.4481	1.0867	.9431		
8	1.1145	1.1218	.4668	1.3672	1.1145		
9	1.3146	1.1317		1.3565	1.1736		
10	1.1919	1.1488	.7537	1.1022	.9892		
11						.7716	.8764
12						.9431	1.1568
13						1.1145	1.1393
14						1.0288	1.1218
15						1.0631	1.1043
16						1.0288	
17	.4733	.5041	.4382	.4382	.5041	1.0341	1.2689
18	.5784	.5975	.4733	.6287	.5975	1.0166	1.166
19	.8589	.9149	.8238	.9335	.9335	.8764	.9335
20	.8413	.9149	.8063	.9145	.9709	.8413	.8192
21	.8238	.8775	.7888	.8954	.9149	.8063	.8002
22	.8063	.8402	.7537	.8573	.8589	.7712	.7621
23	.7362	.7842	.7362	.8192	.8029	.7537	.7621
24	.7049	.7011	.6535	.7011	.7811	.8029	.7362
Max	1.3146	1.1488	.8238	1.3672	1.1736	1.1145	1.2689
Min	.4733	.5041	.4382	.4382	.5041	.6722	.631
Avg	.7809	.7713	.6410	.9186	.8338	.8696	.8945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 205 / 11KV MAHUR FEEDER NEW

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914	.631	.6838	.6661	.6099	.6653	.631
2	.6468	.6135	.6838	.6661	.6468	.6653	.6485
3	.6468	.6135	.6468	.6661	.6468	.6653	.6485
4	.5544	.6135	.6283	.6661	.6468	.6838	.6485
5	.7023	.6661	.6653	.6661	.7023	.7207	.6836
6	.7023	.7011	.6838	.7011	.7392	.7392	.7011
7	.7023	.7186	.6653	.7186	.7392	.7577	.7011
8	.6838	.7186	.6283	.631		.6653	.6836
9	.5434	.6653	.6135	.5359	.6283	.6722	.6661
10	.5434	.5729	.6661	.0185	.6283	.6135	.5609
11	.5609	.6099	.631	.0185	.6653	.5609	.5609
12	.5609	.5914	.6135	.6468	.6283	.5258	.5609
13	.5959	.5544	.5784	.6099	.6283	.5083	.5609
14	.6135	.5359	.6135	.6468	.6653	.591	.5784
15	.6135	.5914	.5609	.6653	.6468	.6447	.5784
16	.5959	.5914	.5784	.5914	.5914	.5373	
17	.5609	.5914	.5959	.6535	.6099	.5609	.7602
18	.6135		.631	.7095	.6099	.5784	.7762
19	.7362	1.0164	.8238	.8402	.7947	.6661	.9055
20	.7362	.8501	.8238	.8501	.8131	.7888	.8316
21	.6836	.7947	.8063	.8775	.8686	.8063	.8029
22	.6661	.7947	.7362	.7282	.8501	.7888	.8029
23	.6485	.7392	.7186	.7095	.8131	.7362	.8029
24	.6722	.6485	.7023	.7011	.7207	.7762	.7011
Max	.7362	1.0164	.8238	.8775	.8686	.8063	.9055
Min	.5434	.5359	.5609	.0185	.5914	.5083	.5609
Avg	.6323	.6706	.6658	.6327	.6910	.6633	.6868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 206 / 11KV RENUKADEVI PHC NON SHEDDABLE WATER SUPPLY AND
EXPRESS FE Feeder KV- 11 / UTILITY
OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0362	.0358	.1052	.1075	.0895	.0351
2	.0175	.0362	.0358	.1052	.1075	.0895	.0351
3	.0175	.0362	.0358	.1052	.0358	.0895	.0351
4	.0175	.0362	.0358	.0876	.0179	.0895	.0351
5	.0175	.0362	.0358	.0701	.0358	.0358	.0351
6	.0175	.0362	.0358	.0351	.0358	.0716	.0351
7	.0351	.0362	.0179	.0175	.0537	.0358	.0701
8	.0701	.0181	.0179	.0175	.0179	.0358	.0876
9	.0175	.0905	.0905	.0716	.037	.0362	.0876
10	.0175	.0905	.0724	.0179	.037	.0362	.0876
11	.0876	.0905	.0905	.0179	.0358	.0362	.0876
12	.1086	.0905	.0905	.0358	.0358	.0362	.0701
13	.1227	.0905	.0905	.0358	.0358	.1267	.0701
14	.1402	.0724	.0905	.0537	.0358	.1267	.0701
15	.1402	.1448	.0724	.0358	.0358	.1267	.0351
16	.0701	.1267	.0351	.0179	.0358	.0905	
17	.0724	.0179	.0351	.0358	.0358	.0701	.0358
18	.0362	.0179	.0351	.0537	.0358	.0351	.0358
19	.0362	.0537	.0526	.0537	.0537	.0351	.0537
20	.0543	.0537	.0876	.0537	.0358	.0351	.0543
21	.0543	.0358	.1052	.0358	.0358	.0351	.0362
22	.0543	.0358	.1052	.0358	.0895	.0351	.0362
23	.0181	.0358	.1052	.1075	.0895	.0351	.1086
24	.0526	.0543	.0358	.1052	.1075	.0895	.0351
Max	.1402	.1448	.1052	.1075	.1075	.1267	.1086
Min	.0175	.0179	.0179	.0175	.0179	.0351	.0351
Avg	.0546	.0572	.0602	.0546	.0493	.0634	.0553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 201 / 11 KV WAI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5093	.5093	.5847
2		.5093	.5093	.5847
3		.5093	.5093	.5847
4		.5093	.5093	.5847
5		.547	.5847	.6224
6		.547	.6224	.6224
11		.6224		.6908
12		.7655		.6602
13		.7655		.6535
14		.7655	.6602	.6535
15		.6979		
16		.4715		
17	2.1026	1.7635	1.8313	
18	1.8313	1.7833	1.8313	
19	1.6118	1.7833	1.6118	
20	1.5775	1.6297	1.491	
21	1.5432	1.5257	1.4217	
22	1.4563	1.4563	1.3672	
23	1.491	1.4217		
24		1.3523	1.387	1.3321
Max	2.1026	1.7833	1.8313	1.3321
Min	1.4563	.4715	.5093	.5847
Avg	1.6591	.9968	1.0604	.6885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 202 / 11 KV HIWALANI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3584	.3961	
2		.3584	.3961	.3961
3		.3584	.3961	.3961
4		.3584	.3961	.3961
5		.4338	.3961	.4338
6		.4715	.4338	.4338
9		1.283	1.1104	1.0745
10		1.1443	1.0387	.5228
11		1.1218		
12		1.0867	1.2178	1.0387
13		1.0867	1.262	1.1218
14		.9816	1.2178	1.283
15		1.1218		1.283
16		1.0867		1.134
19	.4715	.4715	.4715	
20	.4338	.4715	.4715	
21	.4338	.4715	.4715	
22	.4338	.4338	.3961	
23	.4338	.4338		
24	.3961		.3961	.3961
Max	.4715	1.283	1.262	1.283
Min	.3961	.3584	.3961	.3961
Avg	.4338	.7123	.6542	.7623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 203 / 11 KV ANJANKHED FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1919	.4715	.7964
2			1.1218	.4338	.7964
3			1.1218	.4338	.7964
4			1.1218	.4338	.7964
5			1.2483	.4715	.9313
6			1.4403	.4715	.9671
7			2.0687	.4338	1.0867
8			1.933	.3961	1.1568
12			.4715		.4338
13			.4715		.4338
14			.5093		.4338
15			.5093		.5093
16				1.4217	
19		.7356	.7282	.6979	
20		.6979	.6979	.6979	
21		.5847	.6602	.6602	
22		.5847	.6602	.6224	
23		1.283	1.1104		
24	1.1962	1.283		1.1104	.9313
Max	1.1962	1.283	2.0687	1.4217	1.1568
Min	1.1962	.5847	.4715	.3961	.4338
Avg	1.1962	.8615	1.0039	.6255	.7746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 201 / UMRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147			
3	1.7147			
4	1.7147		1.8861	
5	1.7147			
6	1.7147	.3429	1.7147	
7	1.8861	2.2291		
8	1.8861		2.2291	
9	1.7147		2.0576	1.8861
10	1.7147			
11	1.0288	.8573		
12		1.0288		
15		1.7147	1.7147	
17		2.2291		
18		2.2291		
19				1.8861
21		1.7147		
23				1.7147
24	1.7147		2.2291	
Max	1.8861	2.2291	2.2291	1.8861
Min	1.0288	.3429	1.7147	1.7147
Avg	1.6835	1.5432	1.9719	1.8290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 202 / TALEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288			
4	1.0288		1.8861	
5	1.0288			
6		2.2291	2.7435	
7	1.0288	2.4006		
8	1.0288		2.572	
9	.8573		2.572	2.2291
10	.8573			
11	3.2579	3.0864		
12		3.0864		
15		3.0864	.8573	
17		3.0864		
18		3.0864	.6859	
19				1.0288
21		1.5432		
24	1.0288		1.5432	1.2003
Max	3.2579	3.0864	2.7435	2.2291
Min	.8573	1.5432	.6859	1.0288
Avg	1.2384	2.7006	1.8371	1.4861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 203 / BOTHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006			
3	2.4006			
4	2.4006		2.0576	
5	2.4006			
6	2.4006	2.0576	2.2291	
7	.8573	.8573		
8	.8573		.8573	
9	.8573		.5144	.8573
10	.8573			
11	2.0576	2.2291		
12	2.2291	2.2291		
15		.6859	.8573	
17		.6859		
18		.8573		
19				1.0288
21		1.0288		
23				.1715
24	.1886		1.8861	1.0288
Max	2.4006	2.2291	2.2291	1.0288
Min	.1886	.6859	.5144	.1715
Avg	1.6590	1.3289	1.4003	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 204 / JAMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8447	1.5051	1.5242	1.4533	1.6331	.3208	.3323
2	4.0169	1.7741	1.8115	1.768	1.8503	.3079	.3224
3	4.1404	1.858	1.9791	1.8595	1.8816	.3155	.3216
4	4.1412	1.9448	2.0134	1.9456	1.909	.8276	.3216
5	4.1777	2.0294	2.0713	1.9799	1.9243	.3185	.3262
6	2.127	2.0439	2.2771	2.1872	2.7153	.8284	.3856
7	4.7165	2.3579	2.5011	2.5697	3.0552	.4024	.487
8	4.606	2.4303	2.4615	2.6498	2.6795	.8517	.4618
9	3.6839	2.5728	2.5728	2.4996	2.5065	.6942	.1661
10	3.629	2.5248	2.5492	1.9182	2.4829	.3551	
11	1.2224	.964	.961	.724	1.5348	2.1689	2.2497
12	.4252	.0076	.2233	.6516	.5875	2.7427	2.4333
13	.6607	.2256		.0076	.2743	2.7153	2.62
14	.1707	.1951	.7118	.2362	.2042	1.5828	2.6254
15	.1654	.1951	.3795	.2027	.5311	4.933	2.5118
16	.1859	.1837	.3231	.1852	.2362	2.6619	2.3701
17	.1928	.1981	.1898	.1966	.5327	2.6764	2.2794
18	.2515	.2675	.2225	.2309	.7727	2.3167	2.3426
19	.3757	.317	.3925	.5586	.397	.865	1.1941
20	.4329	.3894	.4306	.6234	.4565	.4001	.4908
21	.3948	.3978	.3849	.4138	.9031	.4283	.426
22	.3704	.3803	.3765	.4077	.3932	.413	.4062
23	.3589	.3346	.365	.3673	.3887	.3772	.3711
24	2.5774	.3079	.3452	.3864	.3513	.8688	1.2162
Max	4.7165	2.5728	2.5728	2.6498	3.0552	4.933	2.6254
Min	.1654	.0076	.1898	.0076	.2042	.3079	.1661
Avg	1.9528	1.0585	1.1768	1.0843	1.2584	1.2655	1.1592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 205 / GOLEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859			
3	.6859			
4	.6859		.3429	
5	.6859			
6	.6859		.5144	
7	.6859	2.4006		
8	.6859		.3429	
9	.8573		.3429	.5144
10	.8573			
11	.3429	.1715		
12		.1715		
15		.1715	.8573	
17		.2572		
18		.3429		
19				.3506
21		.4287		
23				.3429
24	.5144		.3429	
Max	.8573	2.4006	.8573	.5144
Min	.3429	.1715	.3429	.3429
Avg	.6703	.5634	.4572	.4026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 206 / CIVIL HOSPITAL EXPRESS NON SHEDDABLE WATER SUPPLY AND
 FEEDER Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0171		
2	.0171		
3	.0171		
4	.0171		.0171
5	.0171		
6		.0171	.0171
7		.0171	
8	.0171		.0171
9	.0171		.0171
10	.0019		
11	.0019	.0171	
12		.0171	
15		.0171	
17		.0171	
18		.0171	
24	.0171		
Max	.0171	.0171	.0171
Min	.0019	.0171	.0171
Avg	.0141	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 201 / SHINDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5209	.5232	.53	.5232	.2728	.1688	.4332
2	.511	.5171	.4352	.5148	.2644	.3323	.5212
3	.5079	.5224	.527	.2561	.2629	.3353	.5151
4	.5239	.5331	.5437	.2827	.2766	.3353	.5243
5	.5514	.5567	.5636	.2957	.3056	.3773	.5555
6	.5956	.5887	.6797	.3109	.3323	.4531	.5891
7	.7171	.6238	.7262	.3445	.3437	.5331	.6287
8	.7018	.5895	.7156	.3361	.6614	.5636	.6523
9	.5826	.5643	.5681	.3246	.3163	.5323	.6249
10	.5216	.5087	.5186	.2759	.5369	.4858	.5845
11	.4329	.3902	.4177	.4683	.479	.4729	.3613
12	.4657	.3925	.4215	.2439	.4154	.4165	.3224
13	.4382	.3887	.394	.2393	.4001	.4058	.3155
14	.4222	.3735	.3742	.2423	.3948	.506	.3201
15	.3917	.3742	.343	.2096	.3704	.4241	.3193
16	.3849	.3506	.3544	.4553	.3696	.415	.3346
17	.3849	.346	.3422	.1852	.378	.3666	.3635
18	.3902	.359	.3453	.4645	.3681	.3795	.3902
19	.5971	.5796	.5582	.3109	.5765	.4786	.5872
20	.594	.607	.6032	.3178	.5948	.6024	.6283
21	.5636	.575	.6024	.3178	.5895	.594	.5986
22	.5605	.5681	.5628	.5628	.5651	.5613	.5872
23	.5384	.5468	.5453	.2942	.2777	.5575	.5674
24	.5361	.543	.5346	.5361	.3814	.543	.2949
Max	.7171	.6238	.7262	.5628	.6614	.6024	.6523
Min	.3849	.346	.3422	.1852	.2629	.1688	.2949
Avg	.5181	.4967	.5086	.3464	.4056	.4517	.4841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 202 / HUNDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291	2.4006	2.0576	2.0576		.7716	.8573
2	2.2291	2.572	2.2291			.7716	.8573
3	2.2291	2.572	2.2291			.6859	.8573
4	2.3148	2.572	2.3148			.6859	.8573
5	2.3148	2.572	2.4006			.6859	.8573
6	2.572	2.7435	2.7435			.6859	1.0288
7	2.915	2.915	2.8292			.8573	1.0288
8	3.0864	2.915	3.0864		2.4863	.7716	1.0288
9	2.915	2.8292	2.8292			.6001	.8573
10	2.7435	2.4863	2.4006		2.4006	.4287	
11	.3429	.5144		.5144	.4287	2.2291	2.0576
12	.3429	.4287			.3429	2.4006	2.572
13	.3429	.3429	.3429		.3429	2.4006	
14	.3429	.3429	.3429		.3429	2.4006	2.572
15	.3429	.3429	.3429			2.2291	2.572
16	.3429	.4287	.3429	.3429		2.2291	2.1434
17	.3429	.5144	.3429			2.4863	2.572
18	.6859	.6001	.3429	.7716	.6001	2.572	2.572
19	1.0288	1.1145	1.1145		1.0288	.8573	1.0288
20	1.2003	1.2003	1.0288		1.2003	.8573	1.0288
21	1.0288	1.0288	1.0288		1.1145	1.0288	1.0288
22	1.0288	1.0288	1.0288	1.1145	.9431	1.0288	1.0288
23	1.0288	1.0288	1.0288		.9431	1.0288	1.0288
24	.9431	1.0288	1.0288	1.0288		.9431	2.572
Max	3.0864	2.915	3.0864	2.0576	2.4863	2.572	2.572
Min	.3429	.3429	.3429	.3429	.3429	.4287	.8573
Avg	1.4539	1.5218	1.5198	.9716	1.0145	1.3182	1.5003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 203 / SHIVANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2782	.2698	.2545	.3026	.0015	.0791	.0857
2	.2782	.2729	.3155	.1364	.0953	.0791	.0857
3	.279	.3685	.3231	.1341	.1029	.0819	.0857
4	.2957	.3845	.336	.1341	.0998	.081	.0857
5	.421	.4134	.3642	.1631	.1433	.081	.0857
6	.4592	.4462	.4288	.1783	.1585	.0791	.0857
7	.5148	.4912	.4944	.2225	.1806	.081	.0857
8	.543	.5194	.4982	.2446	.4416	.081	.0857
9	.5216	.5239	.486	.2576	.1257	.2572	.0857
10	.5018	.4912	.4351	.2583	.434	.081	.0857
11	.1711	.1363	.1924	.1429	.1576	.4538	.509
12	.0857	.0819	.0857		.0857	.655	.3491
13	.0857	.081	.0857		.0791	.6512	.1806
14	.0857	.081	.0857		.081	.6474	.3559
15	.0857	.081	.0857		.081	.5631	.3491
16	.0857	.081	.0857	.0857	.081	.5959	.3696
17	.0857	.081	.0857		.081	.5936	.378
18	.0857	.081	.0857	.0857	.0791	.5685	.3735
19	.0857	.0857	.0857		.0791	.2259	.1291
20	.0857	.0857	.0857		.0819	.0857	.0857
21	.0857	.0857	.0857		.081	.0857	.0857
22	.0857	.0857	.0857	.0857	.081	.0857	.0857
23	.0857	.0819	.0857		.0819	.0857	.0857
24	.0918	.0857	.107	.0857		.0857	.1715
Max	.543	.5239	.4982	.3026	.4416	.655	.509
Min	.0857	.081	.0857	.0857	.0015	.0791	.0857
Avg	.2243	.2248	.2193	.1678	.1267	.2652	.1819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 204 / 11 kv Dairy feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.1715		.0857	.1715
2	.0857	.0857	.0857			.0857	.1715
3	.0857	.0857	.0857			.0857	.1715
4	.0857	.0857	.0857			.0857	.1715
5	.0857	.0857	.0857			.0857	.1715
6	.0857	.0857	.0857			.0857	.1715
7	.0857	.0857	.0857			.0857	.1715
8		.0857	.0857		.0857	.0857	.1715
9	.0857	.0857	.0857			.0857	.1715
10	.1715	.1715	.0857		.1715	.0857	.0857
11	.0857	.0857	.0857	.2572	.0857	.1715	.0857
12	.0857	.0857	.0857		.0857	.0857	.0857
13	.0857	.0819	.0857		.0857	.0857	
14	.0857	.081	.0857		.0857	.0857	.0857
15	.0857	.0857	.0857		.0857	.0857	.0857
16	.0857	.0819	.0857	.0857	.0857	.0857	.0857
17	.0857	.0857	.0857		.0857	.0857	.0857
18	.0857	.0857	.0857		.0857	.0857	.0857
19	.0857	.0857	.0857		.0857	.0857	.0857
20	.0857	.0857	.0857		.0857	.0857	.0857
21	.0857	.0857	.0857		.0857	.1715	.1715
22	.0857	.0857	.1715	.1715	.0857	.1715	.1715
23	.1715	.0857	.2572		.0857	.1715	.1715
24	.1715	.0857	.0857	.1715		.1715	.0857
Max	.1715	.1715	.2572	.2572	.1715	.1715	.1715
Min	.0857	.081	.0857	.0857	.0857	.0857	.0857
Avg	.0969	.0888	.0964	.1715	.0914	.1036	.1305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174018 / 33 KV ARJAPUR(BILOLI)

Feeder No / Name : 203 / BILOLI URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9907	1.0164	.9979	1.0059		1.105	.9335
16	.6173	.6653	.7392	.7316		.7468	.7392
20							.9979
23					.8916		
24	.8745	.7023	.7762	.7762	.9511	.8916	.8402
Max	.9907	1.0164	.9979	1.0059	.9511	1.105	.9979
Min	.6173	.6653	.7392	.7316	.8916	.7468	.7392
Avg	.8275	.7947	.8378	.8379	.9214	.9145	.8777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174018 / 33 KV ARJAPUR(BILOLI)

Feeder No / Name : 204 / Govt. Hospital Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.0179		
8	.0171	.0183	.0179	.0181		.0191	.0187
16	.0183	.0181	.0179	.0181		.0187	.0189
20							.0187
23					.0171		
24	.0171	.0183	.0179	.0181	.0179	.0171	.0187
Max	.0183	.0183	.0179	.0181	.0179	.0191	.0189
Min	.0171	.0181	.0179	.0181	.0171	.0171	.0187
Avg	.0175	.0182	.0179	.0181	.0176	.0183	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 201 / 11 KV LOHGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	1.6004				1.0749		
7	1.7353						
8	1.7353	1.7147	1.6244	1.6766		1.6118	1.6975
10					1.4083		
16	1.2407	1.2071	.7545	.8383	.8764	.8676	.6097
24	1.2071		1.1317	1.1694		1.2071	1.226
Max	1.7353	1.7147	1.6244	1.6766	1.4083	1.6118	1.6975
Min	1.2071	1.2071	.7545	.8383	.8764	.8676	.6097
Avg	1.5038	1.4609	1.1702	1.2281	1.1199	1.2288	1.1777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 202 / 11 KV RAHER FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3887				.3018		
7	.4694						
8	.5304	.3018	.3018	.2829		.2641	.3018
10					.3018		
16	.2286	.1886	.4096	.5304	.547	.5636	.4973
24	.2641		.2263	.3018		.2263	.2641
Max	.5304	.3018	.4096	.5304	.547	.5636	.4973
Min	.2286	.1886	.2263	.2829	.3018	.2263	.2641
Avg	.3762	.2452	.3126	.3717	.3835	.3513	.3544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 203 / 11 KV HARNAL FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4755				.8299		
7	.6154						
8	.5014	.631	.7922	.9808		.9619	1.0374
10					.7922		
16	.5658	.547	.6203	.6443	.4801	.5533	.5967
24	.6722		.7356	.6348		.7167	.7167
Max	.6722	.631	.7922	.9808	.8299	.9619	1.0374
Min	.4755	.547	.6203	.6348	.4801	.5533	.5967
Avg	.5661	.589	.7160	.7533	.7007	.7440	.7836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 201 / 11 KV BELKONI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.314			
2				.2983			
3				.2983			
4				.314			
5				.3768			
6				.4087			.4401
7		.7064		.4715			.4558
8	.7683	.8163		.4558		.0472	.3462
9	.6899			.3929			
10					.3458		
11	.2038		.723				
12			.7702		.6916		
13			.8467				
14	.2038		.8467		.6602		
15			.7997				
16			.831		.6602	.6602	.6767
17	.2666		.832			.6287	
18	.2512						
19	.3454		.3925			.3301	
20	.3768						
21	.3454					.3772	
22	.3454		.3768				
23	.314						
24	.2983		.3297	.3454	.3772	.3615	.3772
Max	.7683	.8163	.8467	.4715	.6916	.6602	.6767
Min	.2038	.7064	.3297	.2983	.3458	.0472	.3462
Avg	.3674	.7614	.6748	.3676	.547	.4008	.4592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 202 / 11 KV CHINCHALA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							1.3089
7		.8561					1.3961
8	.8735	.8386	1.5724			1.3438	1.4485
9	.6988		1.485	1.4136			
10			1.4675		1.3961		
11	1.4501		.4892				
12			.4542		.4188		
13			.4193				
14	1.4326		.4193		.4188		
15			.4193				
16	1.485	1.5025	.4368		.4014	.4712	.4363
17	1.5374		.4892			.5061	
18	1.5374						
19	.9085		.6988			.8028	
20	.8386						
21	.8037					.8377	
22	.7687		.6988				
24	.6988	1.5025	.7163	.6814	.7155	.7155	.7679
Max	1.5374	1.5025	1.5724	1.4136	1.3961	1.3438	1.4485
Min	.6988	.8386	.4193	.6814	.4014	.4712	.4363
Avg	1.0861	1.1749	.7512	1.0475	.6701	.7795	1.0715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 203 / 11 KV SAVALI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6							.1164
7		.3659					.1497
8	.3825	.3659	.1331			.1331	.1331
9	.4158		.0998	.0998			
10			.0832				
11	.0832		.3659				
12			.3992		.3992		
13			.4491				
14	.0333		.4324		.4158		
15			.4158				
16	.0665	.0499	.4158		.3992	.3825	.3493
17	.0665		.4158			.3659	
18	.0665						
19			.1164			.1331	
20	.1164						
21						.1331	
22			.1164				
24	.0832	.0499	.0832	.0998	.0832	.0832	.1164
Max	.4158	.3659	.4491	.0998	.4158	.3825	.3493
Min	.0333	.0499	.0832	.0998	.0832	.0832	.1164
Avg	.1460	.2079	.2712	.0998	.3244	.2052	.1730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 204 / 11 KV TALNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.429			.3489			
2				.3489			
3				.3987			
4				.4319			
5				.4652			
6				.4818			.4646
7		.693		.5316			.4646
8	.671	.8075	.484	.4818		.5144	.4818
9	.6546		.3342	.383			
10			.3008		.383		
11	.2776		.6683				
12			.7835		.5988		
13	.1962		.7485				
14	.1964		.6859		.6638		
15			.7625				
16	.2128	.2305	.7293		.7111	.6615	.5629
17	.213		.7433			.7607	
18	.3281						
19	.4927		.5109			.5121	
20	.411						
21						.4796	
22			.3964				
24	.3473		.3481	.3642	.3647	.3969	.4139
Max	.671	.8075	.7835	.5316	.7111	.7607	.5629
Min	.1962	.2305	.3008	.3489	.3647	.3969	.4139
Avg	.3691	.577	.5766	.4236	.5443	.5542	.4776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 205 / 11 KV KASRALI FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1118			.0932			
2				.0932			
3				.1118			
4				.0932			
5				.1118			
6				.1118			.1491
7		.1118		.1304			.1491
8	.1304	.1304	.1491	.1118		.1491	.1491
9	.1118		.1118	.1118			
10			.1118		.1118		
11	.1118		.1118				
12			.1118		.1118		
13			.1118				
14	.0932		.1118		.1304		
15			.1118				
16	.0932	.1118	.0932		.1118	.1118	.1118
17	.1304		.1304			.0932	
18	.1491						
19	.1677		.1491			.1118	
20	.1491						
21						.1491	
22			.1491				
24	.1118		.1118	.1118	.1304	.1304	.1304
Max	.1677	.1304	.1491	.1304	.1304	.1491	.1491
Min	.0932	.1118	.0932	.0932	.1118	.0932	.1118
Avg	.1237	.118	.1204	.1081	.1192	.1242	.1379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 206 / 11 KV RUDRAPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1827			
2				.274			
3				.2892			
4				.3197			
5				.3501			
6				.3501			.3332
7		.0925		.3653			.3938
8	.0933	.0926	.3506	.3806		.3943	.409
9	.0466		.3353	.3806			
10			.3349		.3801		
11	.3269		.0304				
12			.0304		.0304		
13			.0457				
14	.3713		.0305		.0304		
15			.0305				
16	.3849	.3667	.0305		.0911	.0303	.0454
17	.3217		.0457			.0303	
18	.3052						
19	.061		.0916			.091	
20	.061						
21						.0759	
22			.0764				
24	.0613		.0613	.0612	.061	.0609	.076
Max	.3849	.3667	.3506	.3806	.3801	.3943	.409
Min	.0466	.0925	.0304	.0612	.0304	.0303	.0454
Avg	.2033	.1839	.1149	.2954	.1186	.1138	.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 201 / 11 KV DAULATAPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9145		1.0631	.9774	1.0288	.2572	.3429
10				.9774			
16	.1372	.1372	.1372	.1372	.1715	1.0802	.9686
24	.1829	.2743	.2915	.3086	.2915	.3086	.3086
Max	.9145	.2743	1.0631	.9774	1.0288	1.0802	.9686
Min	.1372	.1372	.1372	.1372	.1715	.2572	.3086
Avg	.4115	.2058	.4973	.6002	.4973	.5487	.5400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 202 / 11 KV SAGROLI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10				.4115			
16	.3048	.3601	.3086	.3258	.4115	.3429	.3841
24	.3201	.3048	.3258	.3429	.3601	.3601	.3772
Max	.3201	.3601	.3258	.4115	.4115	.3601	.3841
Min	.3048	.3048	.3086	.3258	.3601	.3429	.3772
Avg	.3125	.3325	.3172	.3601	.3858	.3515	.3807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 203 / 11 KV BOLEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3681	.3696	.3833	.3826	.3711	1.249	1.1553
2	.3574	.362	.3757	.3719	.362	1.2437	1.1462
3	.3544	.3551	.3788	.3688	.3605	1.2475	1.1446
4	.3551	.3536	.3894	.365	.3612	1.2849	1.1439
5	.378	.3749	.4085	.3749	.3818	1.3032	1.1683
6	.4969	.5083	.4321	.4809	.4169	1.3405	1.2254
7	.5578	.5838	.6927	.6302	.5136	1.4586	1.4236
8	1.1469	1.166	1.3344	1.1607	.82	3.0914	2.9081
9	.567	.5495	.5754	.455	.4984	1.6088	1.5447
10	.4527	.5098	.5014	.3429	.1113	1.6263	1.5203
11	1.6133	1.6309	1.1469	1.5859	1.3946	.8314	.823
12	1.7093	1.5478	1.169	1.7177	1.5219	.2515	.2652
13	1.6461	1.5668	1.4449	1.6827	1.6347		.2576
14	1.6773	1.5828	1.5531	1.6217	1.6667		.2667
15	1.6217	1.5287	1.528	1.6461	1.6362	.1981	.2667
16	2.9477	2.8788	2.9119	3.1105	3.0986	.482	.4643
17	1.6872	1.5859	1.5234	1.6179	1.6552	.2987	.2888
18	1.6796	1.5729	1.531	1.5638	1.6423	.3528	.3353
19	1.0258	.9656	1.3001	.8634	1.1058	.4839	.4374
20	.519	.5014	.4748	.4778	.4595	.4687	.4611
21	.4626	.4641	.4512	.4443	.4466	.455	.4572
22	.4268	.4473	.4412	.4176	.4359	.4367	.4504
23	.3993	.4146	.4298	.4031	.4153	.4237	.4382
24	.6783	.6889	.7438	.7338	.735	.7514	.7666
Max	2.9477	2.8788	2.9119	3.1105	3.0986	3.0914	2.9081
Min	.3544	.3536	.3757	.3429	.1113	.1981	.2576
Avg	.9637	.9379	.9217	.9508	.9185	.9494	.8483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 201 / 11 KV TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.8383
2						.7621
3						.7621
4						.7621
5						.7621
8	.905				.8402	.823
9			.961			
10				.6089		
12	.6878					.5853
15			.8871			
17				.5731		
19		1.0164	.905			
22		.9335	.7316	.7392	.724	
24		.7095	.8316		.6468	
Max	.905	1.0164	.961	.7392	.8402	.8383
Min	.6878	.7095	.7316	.5731	.6468	.5853
Avg	.7964	.8865	.8633	.6404	.737	.7564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 202 / 11 KV TOWN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.5472	.5807	.5838	.6165	.6074	.6386
2	.5121	.5243	.5655	.5571	.5891	.5784	.612
3	.5014	.5121	.5594	.5495	.5799	.5746	.6005
4	.4954	.5083	.5434	.5403	.5716	.567	.5975
5	.4961	.5083	.5456	.5403	.5784	.5769	.6051
6	.5708	.5342	.6333	.5662	.6234	.6226	.6645
7	.6478	.6112	.7369	.663	.6737	.6851	.7545
8	1.4434	.7171	.8505	1.3558	.7369	1.5028	1.5543
9	.7575	.6706	1.6034	.6897	.8002	.7232	.8223
10	.6912	.6554	.823	.6981	1.4045	.7095	.7888
11	.5769	.6249	.7217	.5601	.6882	.6066	.6127
12	.9686	.5152	.6683	.5357	.631	.5594	1.1599
13	.4748	.4915	.6051	.5083	.6104	.5632	.5738
14	.474	.5205	.5418	.5175	.551	.5434	.5906
15	.4565	.5114	1.1732	.503	.5479	.5609	.5632
16	.4382	.4816	.4893	.4854	.5274	.5418	.5502
17	.4672	.4649	.4565	.4839	1.2902	.5472	.538
18	.4862	.4291	.4733	.5007	.5213	.5129	.5205
19	.6493	1.3112	1.3489	.7034	.7118	.7072	.7255
20	.7423	.7316	.7628	.772	.7636	.791	.7788
21	.7064	.7004	.7293	.743	.7438	.7644	.759
22	.6516	1.3466	1.251	.7468	1.4373	1.3634	.7423
23	.6257	.6683	.6645	.7148	.7011	.727	.7263
24	.5838	1.2102	1.2171	.6722	.6424	1.142	.6866
Max	1.4434	1.3466	1.6034	1.3558	1.4373	1.5028	1.5543
Min	.4382	.4291	.4565	.4839	.5213	.5129	.5205
Avg	.6231	.6582	.7727	.6329	.7309	.7116	.7152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 203 / 11 KV TOWN 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6097
2							.5716
3							.5716
4							.5716
5							.5716
8	1.0974			1.1888		.7392	1.1765
9			.5914				
10					.6805		
12	.724			.905			.6447
15			.6838				
19		.7392	.9955				
22			.823		.7468	.905	
24		.7023	.7207			.5359	
Max	1.0974	.7392	.9955	1.1888	.7468	.905	1.1765
Min	.724	.7023	.5914	.905	.6805	.5359	.5716
Avg	.9107	.7208	.7629	1.0469	.7137	.7267	.6739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 204 / 11 KV INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0895				.0943	.181
9			.1494			
10				.2149		
12	.1829				.1886	.2172
15			.2263			
17				.2149		.181
19		.0943	.1829			
22		.0943	.1433	.0943	.1829	
24		.0943	.0943		.2263	
Max	.1829	.0943	.2263	.2149	.2263	.2172
Min	.0895	.0943	.0943	.0943	.0943	.181
Avg	.1362	.0943	.1592	.1747	.1730	.1931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 205 / 11 KV TOWN 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5586		
2				.5235		
3				.5045		
4				.4992		
5				.506		
6				.519		
7				.5746		
8	.6584			.7026	.0702	.5792
9			.6468	.676		
10				1.0905		
11				.6135		
12	.5121			.5327	.5041	.4344
13				.506		
14				.5312		
15			.4805	.5296		
16				.5053		
17				.929		
18				.5182		
19		.6468	.6584	.5296		
20				.6554		
21				.6348		
22		.6468	.4755	1.3081	.5487	
23				.6394		
24		.4854	.5544	.6028	.5544	
Max	.6584	.6468	.6584	1.3081	.5544	.5792
Min	.5121	.4854	.4755	.4992	.0702	.4344
Avg	.5853	.593	.5631	.6329	.4194	.5068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 206 / 11 KV BHAKTAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.8059		1.0059		1.0164	.7762
10				.7164		
15			1.0059			
17				.6805		
19		1.0164	.9145			
22		.9145	.695	.7316	.7392	
24		.6283	.823		.6401	
Max	.8059	1.0164	1.0059	.7316	1.0164	.7762
Min	.8059	.6283	.695	.6805	.6401	.7762
Avg	.8059	.8531	.8889	.7095	.7986	.7762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 207 / GOVT. HOSPITAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0181				.0189	.0183
9			.0189			
10				.0181		
12	.0181					.0183
15			.0189			
17				.0181		
19		.0189	.0183			
22		.0189	.0181	.0189	.0183	
24		.0189	.0189		.0189	
Max	.0181	.0189	.0189	.0189	.0189	.0183
Min	.0181	.0189	.0181	.0181	.0183	.0183
Avg	.0181	.0189	.0186	.0184	.0187	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 201 / 11 KV MUKRAMABAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3018	.2926	.2743	.3772	.3361	.2401
2	.2641	.3018	.2957	.2743	.3395	.2987	.2743
3	.3018	.3018	.2957	.3086	.3395	.2987	.3086
4	.3018	.3361	.9145	.3429		.3772	.3429
5	.3772	.3361	.4066	.3772	.4527	.3772	.3772
6	.3429	.4108	.439	.4115	.4904	.415	.4115
7	.3772	.5975	.5228	.5228	.5601	.5281	.5144
8	.4115	.5228	.5487	.5601	.6348	.5228	.5144
9	.4458	.4854	.5601	.5487	.5487	.5601	1.5043
10	.4801	.4481	.5228	.5373	.5144	.4755	.4298
11	.3429	.4024			.2401	.4024	.3696
12	.3086	.3658			.3429	.439	.3658
13	.2743	.3292		.4344	.3086	.3696	.3506
14	.2743	.3658		.3155	.2743	.3982	.3772
15	.3086	.3326			.2743	.362	.3086
16	.3429			.3582	.3224	.3086	.3506
17	.3734	.3292		.3982	.3658	.2743	.3789
18	.3658	.394		.4066	.3658	.3086	.4656
19	.4854	.439	.4801	.4435	.4805	.3429	.5014
20	.4481	.439	.4458	.4805	.4108	.4115	.4805
21	.3734	.4066	.4115	.4066	.3582	.3772	.4435
22	.3734	.3696	.3772	.4108	.3696	.3429	.4108
23	.3361	.3292	.3429	.4108	.3361	.3086	.3696
24	.3018	.3395	.3258	.3086	.3772	.3326	.2743
Max	.4854	.5975	.9145	.5601	.6348	.5601	1.5043
Min	.2641	.3018	.2926	.2743	.2401	.2743	.2401
Avg	.3531	.3863	.4489	.4063	.3950	.3820	.4319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 202 / 11 KV GOJEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9054	.8048	.6859	1.0562	.8238	.8573
2	.9431	.8676	.7762		.9431	.8596	.6859
3	1.0185	.9431	.7964	.9602	.9054	.8573	.8573
4	1.0562	1.0082	.8413	.9259	.8676	.8573	1.0288
5	1.1694	1.0456	.8596	1.0288	.9054		
6	1.0802	1.094	.8573	1.1317	.9431		
7	1.2003	1.3817	1.0288	1.3717	1.5684		
8	1.3717	1.3443	1.3375	1.6118			
9	1.4403	1.2696	1.4937	1.2003	1.4746		
10		1.2323	1.419	1.2346	1.4403		
11						1.2803	1.2346
12						1.3535	1.4403
13						1.4415	1.3717
14						1.4842	1.3375
15						1.448	1.2689
16						1.3375	1.3321
17	1.0829	1.0288	1.3717	1.1946	1.1317	1.2003	1.3672
18	1.2437	1.0974	1.3032	1.4415	1.2689	1.2346	1.3253
19	1.307	1.0288	1.2003	1.3676	1.166	1.2003	1.2894
20	1.1576	1.0288	1.0288	1.2936	1.2003	1.166	1.2936
21	1.1203	.9602		1.1827	1.1317	1.1317	1.2197
22	1.0456	.7164	.9259	1.1203	1.0288	1.0974	1.1458
23	.9709	.7164	.6859	1.0829	.9602	1.0631	1.1203
24	.9808	.9054	.7602	.6516	1.094	.7522	1.0288
Max	1.4403	1.3817	1.4937	1.6118	1.5684	1.4842	1.4403
Min	.9431	.7164	.6859	.6516	.8676	.7522	.6859
Avg	1.1254	1.0319	1.0289	1.1462	1.1227	1.1438	1.1780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 203 / 11 KV RAVANKOLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5658	.6219	.5487	.7167	.5975	.6516
2	.4904	.5281	.5914	.6173	.679	.5601	
3	.5281	.5281	.5914	.6516	.6413	.5601	.6173
4	.5281	.5601	.6584	.6859	.6413	.5658	.6173
5						.6036	.6516
6						.6584	.3772
7						1.0288	1.0288
8						1.3032	1.2689
9						1.4937	1.4403
10						1.0608	1.0288
11	1.1317	1.2936	1.2071		1.2003		
12	1.1317	1.39	1.3336		1.3717		
13	1.0974	1.2803	1.448		1.3032		
14	1.0631	1.134	1.3717		1.2003		
15	1.0288	1.2936	1.2071		1.166		
16	1.0288	1.2567	1.3336	1.182	1.2003		
17	1.2323	1.2689	1.2689	1.1584	1.2689	1.3032	.9465
18	1.2437	1.0631	1.166	1.2567	1.3032	1.2689	1.0387
19	1.1203	.9945	1.0974	1.1827	1.0288	1.2346	1.0745
20	.8962	.823	1.0288	.9979	.823	1.2003	1.0349
21	.8215	.7202	.9602	.7762	.7164	.8573	.961
22	.7468	.7164	.6859	.7842	.6661	.7888	.9335
23	.6722	.6805	.6516	.7468	.6516	.7202	.7842
24	.5281	.6036	.6516	.5144	.7545	.6283	.6859
Max	1.2437	1.39	1.448	1.2567	1.3717	1.4937	1.4403
Min	.4904	.5281	.5914	.5144	.6413	.5601	.3772
Avg	.8766	.9278	.9930	.8541	.9629	.9130	.8906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 204 / 11 KV SAWARMAL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2641	.3292	.3086	.4527	.3734	.3429
2	.3018	.3018	.2987	.2743	.415	.3361	.2743
3	.3395	.3395	.2987	.3086	.3772	.3361	.3086
4	.3395	.3734	.3734	.3429	.415	.415	.3429
5						.415	.3772
6						.4904	.4801
7						.5487	.583
8						.5601	.583
9						.7468	.8238
10						.5121	.7164
11	.6516	.6653	.5281		.6516		
12		.695	.6478		.6173		
13	.6173	.7682	.7621		.583		
14	.6516	.695	.8002		.5144	.362	
15	.6859	.7392	.679			.3982	
16	.6516	.6653	.4191	.6805	.5731	.4115	.4557
17	.7468	.6516	.6173	.543	.6173	.4458	.5014
18	.7682	.6805	.583	.7392	.5487	.4801	.4822
19	.7468	.5373	.5487	.7023	.5175	.5144	.5731
20	.5601	.4801	.5144	.4435	.5601	.5487	.5544
21	.4854	.4755	.4801		.4066	.4801	.5175
22	.4481	.4298	.4458	.4481	.4435	.4115	.4805
23	.3734	.3658	.4115	.4854	.4481	.3772	.4481
24	.6173	.3395	.362	.3772	.4527	.4066	
Max	.7682	.7682	.8002	.7392	.6516	.7468	.8238
Min	.3018	.2641	.2987	.2743	.3772	.3361	.2743
Avg	.5463	.5259	.5055	.4711	.5055	.4557	.4914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 201 / 11 KV TAMLOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.9149	.9149	.9335	.8215	.9896	.9149	.9709
4						.9335	
6	1.1389	1.1389	1.0456				1.1763
7		1.1949					
8		1.251	1.1949				
9	1.0456		1.1203				
10	1.0082	1.0269	.9877				
11						.8589	.9149
12				.8775	1.0642	.8775	.9149
13					1.1016		.8962
14							1.1203
15						1.0456	1.0456
16					.8029		1.0269
17		.9149	.8501				.6908
18	1.0829	.8402			.9149		.8215
19						1.2883	.8962
20			.9145				.8775
21							.8215
22	.8775	.8589					.7468
23	.8402	.8402			.9335	.9335	.6908
24	.8775	.8402	.8402	.8501	1.0829	.8962	.8962
Max	1.1389	1.251	1.1949	.8775	1.1016	1.2883	1.1763
Min	.8402	.8402	.8402	.8215	.8029	.8589	.6908
Avg	.9732	.9821	.9859	.8497	.9842	.9686	.9067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 202 / 11KV NARANGAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2241	.2241	.2054	.4481	.4668	.4854	.5415
4						.5415	
6	.2987	.2987	.3174	.5228	.5788	.6908	.6535
8			.2614			.6908	
9	.2241			.5041	.5975		.5601
10	.1867	.2054					.5415
11	.2614	.4108	.4207			.1509	.1307
12		.4854		.1132		.1307	.1307
13		.4481					.1494
14	.3174	.3734	.4251		.1494		.1494
15		.3547				.112	
16		.3361			.112		.1307
17		.3547	.4024				.1867
18	.5228	.4668			.1494		.2054
19						.2987	.2241
20			.2614				.3734
21							.3361
22	.2054	.2427					.3174
23	.1867	.2241			.2241	.2241	.2801
24	.1867	.1867	.1867	.2012	.2054	.2054	.2241
Max	.5228	.4854	.4251	.5228	.5975	.6908	.6535
Min	.1867	.1867	.1867	.1132	.112	.112	.1307
Avg	.2614	.3294	.3101	.3579	.3104	.3530	.3020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 203 / 11 KV SANGVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0934	.112	.0934	.695	.7282	.8215	.7842
4						.9149	
6	.1494	.168	.168	1.134	1.0974	1.1576	.9335
7		.168					
8		.168	.1867			1.363	
9	.112			1.307	1.4937		1.307
10		.112					1.363
11	1.307	1.4003	1.1763			.0934	.0934
12		1.531		.0732	.1307	.0934	
13		1.4563			.112		
14	1.4937	1.4003	1.3676		.0934		
15		1.307				.0934	
16	1.3256	1.2696			.0934		.056
17		1.1576	1.2803				.112
18	1.4003	1.2883			.1307		.2054
19						.112	.2054
20			.1097				.1867
21							.1494
22	.0934	.1307					.1307
23	.0934	.112			.0934	.0934	.112
24	.0934	.0934	.0934	.0934	.0934	.0934	.0934
Max	1.4937	1.531	1.3676	1.307	1.4937	1.363	1.363
Min	.0934	.0934	.0934	.0732	.0934	.0934	.056
Avg	.6162	.7422	.5594	.6605	.4066	.4836	.4094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174049 / 33 KV KHATGAON

Feeder No / Name : 202 / 11 KV ALANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)
5		.9054
13	.3353	
17	.503	
20	.8383	1.1869
24		.7545
Max	.8383	1.1869
Min	.3353	.7545
Avg	.5589	.9489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174049 / 33 KV KHATGAON

Feeder No / Name : 203 / 11 KV MINKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)
5		.4191
8		.5087
13	.7545	.4191
20	.4191	.4239
24		.4191
Max	.7545	.5087
Min	.4191	.4191
Avg	.5868	.4380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 201 / 11 KV KARADKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.4575	1.2955	.8145	.8145	.8145	.8573
2	1.4575	1.3927	1.3765	.724	.724		.8573
3	1.6289	1.5384	1.5384	.724	.724		.8573
4	1.8004	1.7004	1.7814	.8145	.8145	.8145	.8573
5	1.9719	1.8623	2.1862				
6	2.2634	2.1862	2.3482				
7	2.431	2.3482	2.3482				
8	2.6216	2.3482	2.4291				
9	2.4291	2.5101	2.4291				
10	2.4905	2.4291	2.4291				
11				1.9433	1.9433	2.1052	2.1879
12				2.2672	2.2939	2.2672	2.5692
13				2.4291	2.4291	2.5149	2.5692
14				2.4291	2.4291	2.4863	2.4863
15				2.3482	2.3482	2.4006	2.4034
16				2.3482	2.3482	2.4813	2.3205
17	.6516	.583	.6516	2.4291	2.4291	2.4478	2.2291
18	.724	.6859	.7468	2.4291	2.4291	2.3807	2.0919
19	1.086	1.0288	1.086	.905	.905	1.2536	1.2003
20	1.086	.9431	.9955	1.086	.9955	1.1145	1.1145
21	.9955	.8573	.905	.9955	1.086	1.0288	1.0288
22	.905	.905	.8145	.905	.9955		.9602
23	.8145	.8145	.8145	.8145	.905	.9465	.8916
24	.7716	.7716	.8145	.8145	.8145	.8145	.8573
Max	2.6216	2.5101	2.4291	2.4291	2.4291	2.5149	2.5692
Min	.6516	.583	.6516	.724	.724	.8145	.8573
Avg	1.5326	1.4646	1.4995	1.5123	1.5238	1.7247	1.5744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 202 / 11 KV MARKHEL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.1576	1.0631	.2987	.2987	.3361	.2915
2		1.1576	1.0631	.2801	.2801	.2987	.2915
3	1.2003	1.307	1.2003	.2801	.2801	.2987	.2915
4	1.3375	1.4563	1.3375	.2987	.2987	.3361	.3086
5	1.7833	1.5775	1.6289				
6	1.7833	1.8004	1.8861				
7	1.989	2.0576	2.0576				
8	2.2801	2.332	2.332				
9	2.4478	2.5034	2.5034				
10	1.749	1.8861	2.0576				
11				2.0576	2.0576	2.0576	2.2291
12				2.4006	2.2291	2.4006	2.4531
13				2.4863	2.2634	2.3807	2.4577
14				2.4863	2.3148	2.4478	2.4863
15				2.4863	2.2291	2.4478	2.4531
16				2.4006	2.2291	2.4143	2.4034
17	.2054	.2054	.2054	2.4863	2.2291	2.4348	2.3868
18	.2427	.2427	.2427	2.2291	2.2291	2.4006	2.3537
19	.3921	.4108	.4108	.4108	.4108	.3841	
20	.4294	.4294	.4294	.4294	.4108	.3944	.3772
21	.3734	.3734	.3734	.4108	.4108	.3772	.3601
22	.3361	.3361	.3361	.3734	.3734	.3658	.3601
23	.2987	.2987	.2987	.2987	.3361	.3292	.3086
24	.2743	.2987	.2987	.2987	.2987	.3361	.2915
Max	2.4478	2.5034	2.5034	2.4863	2.3148	2.4478	2.4863
Min	.2054	.2054	.2054	.2801	.2801	.2987	.2915
Avg	1.0697	1.1017	1.0958	1.2451	1.1766	1.2467	1.3002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 204 / 11 KV DEGLOOR WATER SUPPLY NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1029		.0972		.0972		
4	.1029		.0972	.0914	.0972	.0972	.1206
5	.1029	.0972	.0972	.0914	.1134	.0972	.12
6	.1029	.0972	.1134	.1134	.0972	.1134	.1029
7	.1029	.0972	.1134	.1134	.1134	.1134	.1029
8	.12	.0972	.1134	.1134	.0972	.1134	.1029
9	.12	.1307	.0972	.0972	.0972	.0972	.1029
10	.12	.1029	.0972	.0972	.0972	.0972	.1029
11		.0972		.0972		.0972	
12		.0972		.0914	.0914		
13		.0972		.0914	.0914	.1029	
14		.0972		.0914	.0914	.1029	
15		.0972		.0914		.1029	
16		.0972		.0914		.1029	.128
17	.0972	.0972		.0972	.0972	.12	.12
18	.0972	.1134	.0914	.0972	.0972	.12	.12
19	.1006	.1134	.0914	.0972	.0972	.12	.12
20	.0983	.0972	.0914		.0972	.1307	.12
21	.1147		.0914			.1097	.1029
22	.1134		.0914				
23	.0972		.0914				
24					.0914		
Max	.12	.1307	.1134	.1134	.1134	.1307	.128
Min	.0972	.0972	.0914	.0914	.0914	.0972	.1029
Avg	.1062	.1017	.0982	.0977	.0978	.1081	.1128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 205 / 11 KV CHAKUR EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

FEEDER Feeder KV- 11 /

(CONTINOUS PROCESS)(NO STAGGERING)

OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.112	.1478	.1478	.1478	.1294	.112
2	.1307	.1109	.1294	.1494	.1478	.112	.1127
3		.1109	.1294	.1478	.1478		.1116
4		.1109	.112	.1478	.1478	.112	.1115
5		.1109	.112	.1478	.1307		.112
6		.112	.112	.1294	.1307		.112
7		.0924	.0934	.1294	.1307	.112	.112
8	.1307	.0924	.0934	.1307	.1307	.0934	.112
9	.1307	.0924	.0934	.1494	.1294	.0934	.112
10	.1494	.0924	.1134	.1494	.1478	.112	.0934
11	.1494	.1109	.1307	.1494	.1478	.112	.0934
12	.2195	.1478	.0165	.1848	.1629	.1646	.1867
13	.1848	.1478	.181	.2012	.181	.1867	.2614
14	.181	.1646	.2012	.1991	.181	.1867	.2614
15	.1829	.181	.181	.2012	.181	.1859	.2614
16	.1829	.181	.1991	.1829	.181	.1848	.2427
17	.2033	.1848	.1991	.1848	.181	.1672	.2241
18	.2012	.1663	.181	.1848	.181	.1674	.2054
19	.1829	.1478	.1829	.1848	.1663	.1488	.1867
20	.2012	.1478	.1663	.1848	.1663	.1478	.1867
21	.1829	.1494	.1663	.1848	.1663	.1478	.1867
22	.1478	.1494	.1663	.1848	.1663	.128	.1691
23	.1478	.1494	.1494	.1663	.1663	.128	.168
24	.1494	.1478	.1478	.1494	.1478	.1663	.13
Max	.2195	.1848	.2012	.2012	.181	.1867	.2614
Min	.1307	.0924	.0165	.1294	.1294	.0934	.0934
Avg	.1679	.1339	.1419	.1655	.1570	.1422	.1610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174103 / 33 KV S/S KHANAPUR MIDC

Feeder No / Name : 201 / 11 KV MIDC-I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1387	.208	.1715	.3429		.2743	.2572
2	.1387	.1734	.1715	.3429		.2401	.2572
3	.1387	.1734	.1715	.3086		.3086	.2572
4	.1734	.1734	.1715	.3086		.3086	.2572
5	.208	.1734	.2058	.3429		.3086	.2572
6	.208	.208	.2058	.3429		.2743	.2572
7		.208	.2058	.3086	.2401	.2743	.2572
8	.208	.208	.2401	.3772	.3086	.3429	.2572
9	.1907		.2401	.2401	.3429	.4115	.3429
10	.3121		.3086	.3429	.3772	.3429	.4115
11	.3467	.3086	.3772	.4115	.4115	.4115	.4287
12	.3988		.4115	.3772	.4115	.4115	.4458
13	.4161	.3429	.4115	.3429	.4458	.4287	.4458
14	.3814	.3086	.3429	.3429	.4115	.4115	.4287
15	.4681	.2743	.3772	.3086	.3429	.3772	.4115
16	.4681	.2743		.3429	.3429	.3772	.4115
17	.4681	.3429	.4801		.4115	.3772	.5144
18	.3814	.3429	.4458		.4115	.3772	.4458
19	.3294	.2743	.4458	.2743	.4458	.3772	.3772
20	.2254	.2401	.3772	.2743	.3772	.3772	.3429
21	.208	.2058	.3772	.2743	.3772	.3944	.3429
22	.2774	.2058	.3772		.3429	.3944	.2743
23	.2427					.3944	.2401
24	.1734	.2427	.1715	.3429		.2743	.3944
Max	.4681	.3429	.4801	.4115	.4458	.4287	.5144
Min	.1387	.1734	.1715	.2401	.2401	.2401	.2401
Avg	.2827	.2444	.3040	.3275	.3751	.3529	.3465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174103 / 33 KV S/S KHANAPUR MIDC

Feeder No / Name : 202 / 11 KV TADKHEL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8322	.7802	.8573	.8573		.9259	.9259
2	.8322	.8669	.8573	.8573		1.0288	.9259
3	.8322	.8669	.8573	.8916		1.0288	.9945
4	.8322	.8842	.8573	.9259		1.166	1.0631
5				1.0288		1.2346	1.1145
6				1.0631		1.3032	1.286
7				1.166	1.2003	1.3717	1.3375
8				1.3717	1.2346	1.406	1.406
9				1.3375	1.2689	1.3717	1.2346
10				1.1317	1.2003	1.3032	
11	1.0229	1.0974	1.0631				.823
12	.9882		1.0631	.9259			
13	.9536	.9259	1.1317	.8573			
14		1.0288	1.0288				
15		1.166	1.0974				
16	1.1096	1.0288					
17	1.3176	1.166	1.1317	.5487	.583	.6516	.6001
18	1.2309	1.0631	1.1317	.8573	.6859	.7202	.7545
19	1.3003	1.1317	.9945	1.0288	.6516	.3772	.7545
20	1.0576	1.1317	.8916	1.0288	.9945	.7202	.7545
21	1.0056	.9945	.9259	.9602	1.0288	.6859	.7202
22	.8149	.9602	.8573		1.0631	.6859	.7202
23	.7802					.6859	.7202
24	.8322	.7802	.8916	.8573	.9259	1.0288	.6859
Max	1.3176	1.166	1.1317	1.3717	1.2689	1.406	1.406
Min	.7802	.7802	.8573	.5487	.583	.3772	.6001
Avg	.9839	.9920	.9774	.9831	.9852	.9831	.9345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174110 / 33 KV S/S DAPKA

Feeder No / Name : 201 / 11 KV DAPKA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1543		.1677	.1677	.2058	.1715
2	.1886	.1372		.1989	.1677	.1509	.1865
3	.2058	.1372		.2321	.1989	.1677	.1886
4	.2229	.1372		.2458	.2458	.1989	.2058
11	.2743	.2915		.2486	.2622	.2401	.3086
12	.3086	.3429	.3429	.3113	.2785	.2401	.2949
13	.2743			.3605	.2622	.1886	.3277
14	.2743			.3277	.2321	.2058	.3563
15	.2401			.2949	.1989	.2229	.3239
16	.2743			.2785	.2321	.2058	.2949
17				.2486	.2949	.2229	.2622
18	.1029			.2652	.2622	.2401	.2622
19	.2401			.2622	.2785	.2572	.2622
20	.2572			.2458	.2622	.2229	.2294
21	.2229			.2155	.2294	.1886	.2458
22	.1715			.2294	.2012	.2058	.2294
23	.1715			.2155	.1989	.189	.1989
24	.1715	.1715		.1677	.1844	.1357	.1715
Max	.3086	.3429	.3429	.3605	.2949	.2572	.3563
Min	.1029	.1372	.3429	.1677	.1677	.1357	.1715
Avg	.2229	.1960	.3429	.2509	.2310	.2049	.2511

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174110 / 33 KV S/S DAPKA

Feeder No / Name : 202 / 11 KV BAMNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.5487	.4641	.5243	.5636	.6001
2	.583	.4801	.4973	.4973	.5801	.5487
3	.6173	.3944	.5243	.5243	.5898	.5487
4	.6173	.3944	.5735	.5898	.6226	.583
11		.6001	.6226	.6882	.7545	.583
12	.7373	.9945	.8421	.8097		.8097
13	.9259		.8745	.8802		.8962
14	.9945		.8322	.8097		.9282
15	.9774		.8745	.8421		.8802
16	.9774		.8907	.8642	.8059	.8962
17			.9282	.8802	.9945	.8802
18	.8916		.7773	.6062	.8573	.8097
19	.7545		.6226	.6554	.703	.6882
20	.7545		.6554	.6882	.6516	.6554
21	.703		.6226	.6226	.6516	.6554
22	.6516		.5735	.5898	.6173	.5898
23	.6344		.5571	.5735	.5862	.5735
24	.6173	.6173	.4973	.5571	.5571	.583
Max	.9945	.9945	.9282	.8802	.9945	.9282
Min	.583	.3944	.4641	.4973	.5571	.5487
Avg	.7534	.5756	.6794	.6779	.6811	.7061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174110 / 33 KV S/S DAPKA

Feeder No / Name : 203 / 11 KV HATRAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1715	.1677	.1989	.1989	.2058
2	.2058	.1715	.1989	.1989	.1989	.1715
3	.2229	.1543	.2321	.1989	.2155	.1715
4	.2401	.1372	.2486	.2294	.2294	.2058
11	.2229	.2229	.2486	.2458	.2572	.2401
12	.3258	.3772	.3605	.3277	.4115	.3277
13	.3429		.421	.3605	.4115	.3605
14	.3601		.421	.3441	.4115	.421
15	.3601		.3887	.3113	.4115	.3887
16	.3429		.3605	.3277	.3429	.3563
17			.3605	.3441	.3601	.3277
18	.3772		.2949	.2949	.3086	.3277
19	.2915		.3113	.2949	.2572	.2949
20	.2743		.2622	.2785	.2401	.2622
21	.2401		.2321	.2458	.2401	.2458
22	.2401		.2294	.2294	.2572	.2321
23	.2229		.2155	.2294	.2401	.2321
24	.2058	.2058	.1677	.1989	.2155	.2058
Max	.3772	.3772	.421	.3605	.4115	.421
Min	.2058	.1372	.1677	.1989	.1989	.1715
Avg	.2754	.2058	.2845	.2700	.2893	.2765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174117 / 33 KV DEGLOOR-II

Feeder No / Name : 201 / 11 KV SAI MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.7421	.724	.724	.905	.724	.7602
Max	.7421	.724	.724	.905	.724	.7602
Min	.7421	.724	.724	.905	.724	.7602
Avg	.7421	.724	.724	.905	.724	.7602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174117 / 33 KV DEGLOOR-II

Feeder No / Name : 203 / 11 KV HOTTAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.086	.905	.724	1.086	1.086	.724	1.1041
Max	1.086	.905	.724	1.086	1.086	.724	1.1041
Min	1.086	.905	.724	1.086	1.086	.724	1.1041
Avg	1.086	.905	.724	1.086	1.086	.724	1.1041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 201 / 11 KV DHARMABAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0374			
2		1.0269		1.1203		
3						1.1203
4		1.0269				
5	1.0269	1.0269		.9335		1.1203
7	1.0751	1.1203				
8			1.2136	.9335		1.2136
10		1.1203				
11	1.1203		1.3443			1.3817
12				1.4003	1.4563	
14	1.2136		1.4003		1.587	1.531
16	1.2136			1.3443	1.2936	
17		1.4003				
18	1.4003				1.4937	
19						1.4937
20	1.587	1.587			1.4937	
21						1.4003
22	1.307	1.307				
24	1.1317	1.1203	1.2136			1.226
Max	1.587	1.587	1.4003	1.4003	1.587	1.531
Min	1.0269	1.0269	1.0374	.9335	1.2936	1.1203
Avg	1.2306	1.1929	1.2418	1.1464	1.4649	1.3109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 202 / 11 KV DIGRAS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2075			
2		.1494		.112		
3						.2241
4		.1494				
5	.112	.1494	.2075	.112		.2241
7	.132	.1307				
8				.112		.2987
9	.1109					
10		.1307				
11	.1494		.2614			.1867
12				.2614	.112	
14	.4108	.2587	.2801		.112	.2987
16	.4108			.2987	.1294	
18	.4108		.2801		.168	
19						.1867
20	.1494	.3361			.2614	
21						.2614
22	.1494	.2427				
24	.1698	.1494	.2614			.2641
Max	.4108	.3361	.2801	.2987	.2614	.2987
Min	.1109	.1307	.2075	.112	.112	.1867
Avg	.2205	.1885	.2497	.1792	.1566	.2431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 203 / 11 KV BABHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4527			
2		.2801		.1494		
3						1.1203
4		.2801				
5	.4294	.2801		.1494		1.1203
7	.4338	.2241				
8			.3361	.1494		1.307
10		.2241				
11	1.307		.8962			.3174
12				.8402		
14	1.4937	1.5154	1.4003		.2987	.2987
16	1.4003			1.4937	.3142	
17		1.4003				
18	1.4937				.3734	
19						.3734
20	.3361	.5228			.5228	
21						.4481
22	.2801	.5041				
24	.4715	.2801	.8962		.2987	.4904
Max	1.4937	1.5154	1.4003	1.4937	.5228	1.307
Min	.2801	.2241	.3361	.1494	.2987	.2987
Avg	.8495	.5511	.7963	.5564	.3616	.6845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 205 / 11 KV RATNALI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1317			
2		.9335		.7095		
3						1.0829
4		.9335				
5	1.0829	.9335		.6535		1.0456
7	.679	.7392				
8			.9335	.6535		.7468
10		.3734				
11	.4668		.7095			.3734
12				.6535	.3734	
14	.4668	.4435	.6535		.3734	.2987
16	.4668			.5975	.4251	
18	.4668				.4108	
19						.5228
20	.9335	.8402			.7468	
21						.7468
22	.9335	.9335				
24	.9335	.9335	.7095			1.1317
Max	1.0829	.9335	1.1317	.7095	.7468	1.1317
Min	.4668	.3734	.6535	.5975	.3734	.2987
Avg	.7144	.7849	.8275	.6535	.4659	.7436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 206 / 11 KV PIONEER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1886			
2		.6535		.1867		
3						.5228
4		.6535				
5	.6722	.6535		.1867		.5228
7	.679	.5601				
8			.1494	.1494		.5601
10		.462				
11	.6535		.0373			.4108
12				.2801	.4108	
14	.6535	.4066	.0934		.5601	
16	.7468			.2241	.4435	
18	.7468				.3921	
20	.7468	.3734			.4854	
21						.4854
22	.6535	.1494				
24	.4527	.6535	.1132			.6036
Max	.7468	.6535	.1886	.2801	.5601	.6036
Min	.4527	.1494	.0373	.1494	.3921	.4108
Avg	.6672	.5073	.1164	.2054	.4584	.5176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 209 / 33 KV PIONEER

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	07-MAR-17
HR	Load (MW)
14	.5144
19	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 210 / 11 KV WATER SUPPLY EXP
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.12			
2				.112		
5	.1311			.1494		
7	.1311					
8				.1494		
11						.2801
12				.112		
14	.1494		.1494			
16					.1147	
19						.2801
21						.1494
22		.1326				
24	.1494					
Max	.1494	.1326	.1494	.1494	.1147	.2801
Min	.1311	.1326	.12	.112	.1147	.1494
Avg	.1403	.1326	.1347	.1307	.1147	.2365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 211 / RURAL HOSPITAL EXP
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3086			
2				.2652		
3						.2486
4		.3149				
5	.2458			.2321		.2486
7	.2458	.3149				
8			.3052	.2984		.2622
10		.2486				
11			.3734			.2801
12	.2486			.1658	.2458	
14	.2486	.1357	.168		.2458	.2801
16	.2486			.2984	.2458	
18	.2486				.2458	
19						.2801
20	.2486	.2785			.2818	
21						.2987
22	.3149	.2984				
24	.2486	.2785	.2743			.2572
Max	.3149	.3149	.3734	.2984	.2818	.2987
Min	.2458	.1357	.168	.1658	.2458	.2486
Avg	.2553	.2671	.2859	.2520	.253	.2695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 201 / 11 KV KUNDALWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.5853						
7			.6584	.5975	.5914	.6653	.6653
9		.6722	.543				
10	.4481				.5316	4.4815	.4805
11						.4481	
12						.3696	
14						.3856	
15						.4298	
16				.4481		.4298	
18		.5014			.4557		
21	.4854		.5975	.5853			.6468
24	.4908						
Max	.5853	.6722	.6584	.5975	.5914	4.4815	.6653
Min	.4481	.5014	.543	.4481	.4557	.3696	.4805
Avg	.5024	.5868	.5996	.5436	.5262	1.0300	.5975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 203 / 11 KV GUJARI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.415						
7			.3544	.3734	.3547	.3326	
9		.4024	.2743				
10	.1753				.2279		.2054
11						.1831	
12						.112	
13						.1109	
14						.1109	
15						.1086	
16				.1307		.1075	
18		.2149			.1886		
21	.2896		.3361	.3174			.2957
24	.2572						.3582
Max	.415	.4024	.3544	.3734	.3547	.3326	.3582
Min	.1753	.2149	.2743	.1307	.1886	.1075	.2054
Avg	.2843	.3087	.3216	.2738	.2571	.1522	.2864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 204 / 11 KV KONDALWADI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4908					
7			.5487	.5975	.5658	
9		.6878	.6104			
10	.6283				.6371	
11						.724
12						.7964
13						.8048
14						.7578
15						.724
16						.7011
Max	.6283	.6878	.6104	.5975	.6371	.8048
Min	.4908	.6878	.5487	.5975	.5658	.7011
Avg	.5596	.6878	.5796	.5975	.6015	.7514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 205 / 11 KV GUJARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	02-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				1.1603	1.1888
10					1.3817
16		1.7177			
18	1.5432		1.4083		
Max	1.5432	1.7177	1.4083	1.1603	1.3817
Min	1.5432	1.7177	1.4083	1.1603	1.1888
Avg	1.5432	1.7177	1.4083	1.1603	1.2853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 206 / 11 KV SHELGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.2378						
7			.3109	.3361	.3174	.3109	
9		.2715	.2454				
10	.2987				.1949		.1867
11						.2218	
12						.2427	
13						.2402	
14						.2353	
15						.1791	
16				.2054		.181	
18		.1928			.2427		
21	.3361		.2801	.2263			.2641
24	.2427						.3439
Max	.3361	.2715	.3109	.3361	.3174	.3109	.3439
Min	.2378	.1928	.2454	.2054	.1949	.1791	.1867
Avg	.2788	.2322	.2788	.2559	.2517	.2301	.2649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 208 / 11 KV MACHNOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4435						
7			.5847	.5415	.5041	.5895	
9		.439	.4656				
10	.3696				.3439	.4435	.2987
11						.3734	
12						.3696	
13						.3326	
14						.3045	
15						.3109	
16				.3174		.3109	
18		.362			.3721		
21	.5544		.5041	.5093			.547
24	.3898						.5175
Max	.5544	.439	.5847	.5415	.5041	.5895	.547
Min	.3696	.362	.4656	.3174	.3439	.3045	.2987
Avg	.4393	.4005	.5181	.4561	.4067	.3794	.4544

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 201 / 11 KV KARKHELI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.8299		.7167	.8488	.6135	.6335
2	.679	.811	.7583	.679	.8488	.6859	.7011
3	.7167	.8299		.7545	.8676		.6783
4	.7545	.8488		.7545	.8676	.6859	.6783
5	.7545	.8488		.7545	.8865	.8478	.8478
6	.8488	.9431		.8488	.9054	.8478	.8817
7	.8488	.9431	1.1374	.9808	.9808	.8619	1.1022
8	.9431	1.0374			.9431	1.0174	1.0774
9	.7545	.9431	.9478	.8299	.8488	.9945	.7459
10	.6413	.8488	.8505	.7545	.7545	.9116	.7956
11	.763		.9602	.8478	.8573		.5281
12	1.0059	.9622	1.0059	.8383	.8817	.6653	.6036
13	.9724		1.0059	.9221		.6584	.6413
14	.9221	.813	.9835	.8987	.9116	.5544	.6413
15	.8478		.9326	.8478	.9116	.5914	.6036
16	.8478	1.0082	.9724	.8478	.9116	.5853	.6036
17	.8383	1.0285	.9326	.8478	.9116	.6653	.679
18	.8383		.8478	.8478	.8288	.7762	.679
19	.763	.9639	.9054	.8488	.9774	1.1203	1.0374
20	.9431		.9054	1.094	.961	1.1203	1.0374
21	.9431	.891	.9054	1.0374	.961		.9808
22	.9431		.8488	.9431	.9335	1.0082	.9431
23	.9431	.8505	.7545	.9431	.8871	.9709	.9431
24	.679	.8488	.7962	.7545	.8488	.6653	.8962
Max	1.0059	1.0374	1.1374	1.094	.9808	1.1203	1.1022
Min	.6413	.811	.7545	.679	.7545	.5544	.5281
Avg	.8279	.9028	.9139	.8518	.8928	.8023	.7900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 202 / 11 KV YETALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.326	1.0898		1.2431	1.0898	.8402	.8402
2	1.326	1.1736	1.4566	1.3108	1.1401	.7682	.8402
3	1.4575	1.2574		1.3108	1.2574		.7842
4	1.4575	1.326		1.3927	1.3413	.7842	.7842
5	1.4575	1.6385		1.4419	1.4089	.7842	.8316
6	1.5546	1.7204		1.6194	1.6032	.8402	.8871
7	1.7814	1.8023	1.9986	1.9204	1.7814	.8779	.8871
8		2.1605		1.5729	1.9281	.9709	.8402
9		2.1052	2.1413	2.0729	1.9662	.7602	.7842
10		1.9433	2.1751	2.0081	1.9433	.6653	.7468
11			.5658	.5658	.4481		1.6194
12	.5658	.4739	.5281	.5658	.5601	2.0348	1.6194
13	.6036		.4527	.6602		1.9433	1.7814
14	.6036	.567	.4527	.5658	.4481	2.0243	1.9204
15	.5658		.4527	.5281	.4481	1.9433	1.9433
16	.6036	.6426	.4527	.5658	.5601	1.9433	1.9109
17	.6036	.6426	.5281	.5658	.6722	1.9433	1.8785
18	.6036		.6036	.6036	.6722	1.9433	1.8842
19	.6602	.8505	.9431	.6602	.9979	.8871	.9054
20	.7545		.9431	.7545	.9979	.961	.9808
21	.8488	.945	.9431	.7545	.7842		.9054
22	.7545		.8488	.7545	.9335	.9335	.9054
23	1.0898	.8505	.8488	1.0174	.924	.8962	.9054
24	.9054	1.0059	.8316	.8488	1.1022	1.7804	.8402
Max	1.7814	2.1605	2.1751	2.0729	1.9662	2.0348	1.9433
Min	.5658	.4739	.4527	.5281	.4481	.6653	.7468
Avg	.9762	1.2331	.9537	1.0543	1.0873	1.2631	1.1761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 203 / 11 KV ELEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.6036		.5658	.5658	.7888	.8145
2	.4904	.6413	.5481	.5281	.6036	.9326	.9431
3	.4904	.6413		.5281	.6036		.9326
4	.5281	.6602		.5281	.6224	1.0174	.9326
5	.6036	.6602		.5281	.6602	1.0288	1.0174
6	.679	.679		.6413	.679	1.1869	1.1022
7	.7545	.7356	.8505	.7545	.7545	1.2717	1.3565
8	.7545	.8488		.679	.7545	1.4089	1.4089
9	.6036	.7545	.8505	.679	.7167	1.4089	1.4089
10	.5658	.6602	.7583	.679	.6413	1.4089	1.4089
11	1.1401		1.2631	1.3413	1.3565		.4904
12	1.5746	1.5366	1.3916	1.4918	1.4413	.4481	.3772
13	1.6385		1.3283	1.3413		.4435	.3772
14	1.6194	1.609	1.3599	1.4251	1.4918	.4435	.3772
15	1.587		1.3916	1.5089	1.4575	.4108	.3772
16	1.6575	1.6018	1.4232	1.4918	1.4575	.3982	.3772
17	1.6194	1.5366	1.4403	1.4089	1.4575	.5544	.4527
18	1.5565		1.4232	1.5089	1.4575	.6283	.4904
19	.5281	.7583	.8299	.5658	.8316	.8871	.8299
20	.5658		.7545	.6602	.7392	.8962	.8676
21	.7167	.756	.679	.7545	.7468		.679
22	.6602		.6036	.7545	.6722	.7468	.679
23	.679	.6048	.5658	.6602	.5544	.7392	.679
24	.5281	.6036	.567	.5658	.5658	.4481	.6722
Max	1.6575	1.609	1.4403	1.5089	1.4918	1.4089	1.4089
Min	.4904	.6036	.5481	.5281	.5544	.3982	.3772
Avg	.9180	.8829	1.0016	.8996	.9057	.8332	.7938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174109 / 33 KV JARIKOT

Feeder No / Name : 203 / 11 KV JARIKOT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6859
2	.5144	.5144	.5144	.5316	.5658		.6859
3						.6859	.6859
4	.5144	.5144	.6859	.5316	.5658	.6859	.6859
5							.6859
6	.6001	.6001	.6859	.5487	.5487	.6859	.6859
7							.6859
8	.5144	.6001	.5144	.583	.6001	.8573	
9							.8573
10		.5144	.4287	.4115	.5144	.7888	
12		.7716	.8573	.9602	.8573	.3601	
13							.4287
14		.7716	.8573	.9602	.8573	.3601	.3429
15							.3429
16		.8573	.8745	.9259	.8573	.3944	.3429
17					.8573		.3429
18		.8573	.8573	.8916	.8573	.4287	.4287
19							.6516
20		.6859	.6344	.6516	.5144	.6001	.6687
21							.6516
22		.5144	.583	.6001	.5144		.6344
23							.6001
24	.5144	.5144	.5144	.5487	.6001	.5144	.5144
Max	.6001	.8573	.8745	.9602	.8573	.8573	.8573
Min	.5144	.5144	.4287	.4115	.5144	.3601	.3429
Avg	.5315	.6430	.6673	.6787	.6700	.5783	.5804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 201 / 11 KV MUKHED TOWN I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.5487		
6			.6173		
8		.06			
9		.0583	.6173		
10				.0532	.0617
11				.06	
12			.6173		
13		.5487			
14		.583	.5144		
16			.5144		
17					.06
18	.06				
20	.0652	.6516	.6859		
21					.06
22	.0549				
24	.5144		.5487		
Max	.5144	.6516	.6859	.06	.0617
Min	.0549	.0583	.5144	.0532	.06
Avg	.1736	.3803	.583	.0566	.0606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 202 / 11 KV CHANDOLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 203 / 11 KV PFC

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 205 / 11 KV BELI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 206 / 11 MUKHED TOWN II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.7202		
7			.823		
8		.0892			
9		.0874	.7888		
10				.0943	.1029
12		.7888	.7888		.0874
14		.7545	.823		
16			.823		
17					.0995
18	.0892				
20	.0995	.9945	1.0631		
21					.0995
22	.0892				
24	.5144		.7202		
Max	.5144	.9945	1.0631	.0943	.1029
Min	.0892	.0874	.7202	.0943	.0874
Avg	.1981	.5429	.8188	.0943	.0973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 207 / Govt.Hospital Express

Feeder Feeder KV- 11 /

INCOMING

DATE	01-MAR-17
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174038 / 33 KV AMBULGA

Feeder No / Name : 201 / 11 KV RAJURA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174038 / 33 KV AMBULGA

Feeder No / Name : 202 / 11 KV AMBULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2743	.2515		.2926	.2622
4		.415	.2572		.3113	.2785
6					.3725	.4096
8					.5434	.5967
10					.4578	.5087
14	.5335	.4534		.5256		
16	.4973	.4534		.5144		
18	.4115	.4917		.4752		
20	.4382	.4527		.3856	.4656	
22	.2968	.2883		.3113	.3437	
24		.298	.2883		.2743	.2656
Max	.5335	.4917	.2883	.5256	.5434	.5967
Min	.2968	.2743	.2515	.3113	.2743	.2622
Avg	.4355	.3909	.2657	.4424	.3827	.3869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174038 / 33 KV AMBULGA

Feeder No / Name : 203 / 11 KV JAHOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0351	.0572		.1334	.1334
4		.0549	.0572		.1905	.2286
6					.2263	.2667
8					.2858	.3429
10					.2858	.2858
14	.3239	.2667		.2477		
16	.3155	.3048		.2286		
18	.2667	.3048		.2096		
20	.2452	.2286		.1715	.0762	
22	.0509	.0572		.0572	.0762	
24		.0572	.0381		.0572	.0572
Max	.3239	.3048	.0572	.2477	.2858	.3429
Min	.0509	.0351	.0381	.0572	.0572	.0572
Avg	.2404	.1637	.0508	.1829	.1664	.2191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 201 / 11 KV BARHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 202 / 11 KV DORNALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 203 / 11 KV PAISMAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.6516
Max	.6516
Min	.6516
Avg	.6516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174055 / 33 KV BARHALI

Feeder No / Name : 204 / Public Water Work Sugaon NON SHEDDABLE EXPRESS HV FEEDERS
Camp Feeder KV- 11 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.6001
Max	.6001
Min	.6001
Avg	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174067 / 33 KV YEOTI

Feeder No / Name : 201 / 11 KV YEOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6783	.6588	.6443	.6173		
2	.6661	.6783	.6173	.6104	.583		.7059
3			.6001	.5868	.5487		
4	.6135		.6443	.6104	.5765		.724
5			.7545	.6859	.6783		
6	1.0402		.8573	.9945	.823	.8573	
7			.9496	1.1317	.8383		
8	1.0974		.5258	1.2689	1.0174		
9		.9326	.9945	1.1869	1.3032		
10	1.1789	.8478	1.0867	1.1317	.6859	.9431	
11	1.0288						
12	.8478					.9362	1.1218
14							1.0288
16						.9991	.8322
17	.6478	1.0174	.6859	.7202			
18	.7802		1.166	1.2003		1.1043	1.2136
19	.7716	1.0174	1.0288	1.0174	.964		
20	.7621	.8619	.8478	.9259		.9492	.8954
21	.8764	.7712	.8478	.8916			
22	.8764	.7122	.78	.8139		.8417	.7602
23	.7802	.6935	.7122	.7377			
24	.7202	.763	.6859	.6783	.6783	.6935	.788
Max	1.1789	1.0174	1.166	1.2689	1.3032	1.1043	1.2136
Min	.6135	.6783	.5258	.5868	.5487	.6935	.7059
Avg	.8458	.8158	.8024	.8798	.7762	.9156	.8967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174067 / 33 KV YEOTI

Feeder No / Name : 202 / 11 KV HONWADAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7042	.7122	.7461		
2	1.0402		.7545	.7461	.78	.5201	.7059
3			.763	.78	.7712		
4	1.2445		.78	.9496	.8059	.5258	.8507
5			1.1869	1.1869	1.2548		
6	1.5257		1.643	1.6956	1.6766		
7			1.8778	2.0119	2.0553		
8	2.3232		1.1736	1.326	.6859		
9		2.2377	1.8991	2.146	.5487		
10	1.9376	2.2043	2.0119	2.1376			
11		1.9662			1.8861		
12		1.8107			1.9281	2.1845	2.4539
13		1.6278					
14		1.326				2.226	2.1605
16		1.6766				2.2085	2.2885
17	.503	.4534	.503	.5487			
18	.7459	.8413	.503	.8139		2.2786	2.3232
19	.7545	.9835	.6226	.8383	.2629		
20	.763	.8817	.823	.8383		1.0208	1.0387
21	.763	.8048	.8718	.8817			
22	.7716	.7377	.78	.823		.7522	.9231
23	.5087	.6783	.7122	.7042			
24	.6588		.6783	.6706	.6783	.2601	.7164
Max	2.3232	2.2377	2.0119	2.146	2.0553	2.2786	2.4539
Min	.503	.4534	.503	.5487	.2629	.2601	.7059
Avg	1.0415	1.3021	1.0160	1.1006	1.0831	1.3307	1.4957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174067 / 33 KV YEOTI

Feeder No / Name : 203 / 11 KV METHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0339	.0354	.0343	.0343		
2	.0701	.0339	.0351	.0343	.0351		.0362
3		.0308	.0351	.0343			
4	.0867	.0343	.0876	.0343	.0532		.0362
5		.0343	.1052	.0686	.1063		
6	.1402	.0537	.1372	.1017	.1772		
7		.0537	.1715	.1543	.2103		
8	.2254	.1698	.1052	.1715	.2229		
9		.1402	.208	.1715	.2401		
10	.2058	.1387	.2401	.1543	.2401		
11	.0358						
12						.1734	.2103
14						.2454	.1886
16							.1734
17	.0358	.0351	.0347	.0339			
18	.0362	.0701	.0343	.0343		.1928	.1907
19	.0543	.0886	.0347	.0339	.0526		
20	.0526	.0686	.0351	.0514		.0716	.0895
21	.0532	.0686	.0351	.0686			
22	.0543	.0526	.0343	.052		.0537	.0543
23	.0509	.0351	.0351	.0343			
24	.0347	.0514	.0351		.0343	.0173	.0358
Max	.2254	.1698	.2401	.1715	.2401	.2454	.2103
Min	.0347	.0308	.0343	.0339	.0343	.0173	.0358
Avg	.0811	.0663	.0799	.0746	.1279	.1257	.1128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174076 / 33 KV SAWARGAON

Feeder No / Name : 201 / 11 KV JAMB

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.4458
Max	.4458
Min	.4458
Avg	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174076 / 33 KV SAWARGAON

Feeder No / Name : 202 / 11 KV SAWARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174076 / 33 KV SAWARGAON

Feeder No / Name : 203 / 11 KV KAMJALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174078 / 33 KV SUB-STATION BETMOGRA

Feeder No / Name : 201 / 11kv BETMOGRA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
1	.3206
2	.3395
3	.3206
4	.3206
12	.3395
13	.3584
15	.3584
16	.3584
24	.3395
Max	.3584
Min	.3206
Avg	.3395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174078 / 33 KV SUB-STATION BETMOGRA

Feeder No / Name : 202 / 11KV KHATGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
1	.3206
2	.3206
3	.3206
4	.3395
10	.7545
12	.9619
13	1.6032
15	2.037
16	1.9239
24	.3395
Max	2.037
Min	.3206
Avg	.8921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174078 / 33 KV SUB-STATION BETMOGRA

Feeder No / Name : 203 / 11KV EKLARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
1	1.226
2	1.2826
3	1.3014
4	1.3392
5	1.3203
6	1.5089
7	1.5655
8	.1603
9	1.4335
10	1.4146
24	.9054
Max	1.5655
Min	.1603
Avg	1.2234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174113 / 33 KV VASANT NAGAR

Feeder No / Name : 201 / 11 KV BOMNALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.4801
Max	.4801
Min	.4801
Avg	.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174113 / 33 KV VASANT NAGAR

Feeder No / Name : 202 / 11 KV SHIRUR D

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174113 / 33 KV VASANT NAGAR

Feeder No / Name : 203 / 11 KV JUNNA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 201 / 11 KV NARSI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1134	1.0477	1.0822	1.18	1.0966	1.1522	1.2293
2	1.0829	1.0154	1.0524	1.1518	1.0498	1.1355	1.1728
3	1.073	1.0053	1.0342	1.1423	1.0331	1.1127	1.1656
4	1.0593	.9852	1.0387	1.1813	.9947	1.1305	1.1614
5	1.0924	1.0914	1.0836	1.1962	1.0295	1.2147	1.2155
6	1.1721	1.1725	1.1645	1.3005	1.1232	1.3634	1.3344
7	1.5814	1.4219	1.6057	1.4921	1.3672	1.6558	1.6263
8	1.6873	1.6272	1.8137	1.6476	1.6676	1.6568	1.6911
9	1.6434	1.6166	1.7604	1.5905	1.5707	1.4708	1.5009
10	1.5203	1.4616	1.6503	.7369	1.4693	1.4243	1.5291
11	1.2275	1.1915	1.4281	.6722	1.3859	1.412	1.4746
12	1.0312	.9807	1.4106	.6889	1.3268	1.2308	1.1675
13	1.0283	.9537	1.3032	.6241	1.3378	1.3417	.977
14	1.0193	.9444	1.2826	.5167	1.3308	1.3778	.9575
15	.9616	.4763	1.1751	.5525	1.2178	1.2754	.9617
16	.9404	1.0059	1.1645	.6386	.5845	1.1816	.8602
17	1.0362	1.0532	1.1332	.6203	1.4388	1.2745	1.0041
18	1.1434	.5388	1.1812	1.2115	1.1846	1.3778	.6097
19	1.4845	1.544	1.4301	1.3899	1.4281	1.4354	1.4644
20	1.4861	1.4678	1.4685	1.5578	1.6196	1.4822	1.6425
21	1.4288	1.3832	1.4464	1.37	1.557	1.4297	1.6196
22	1.3677	1.3367	1.3748	1.2448	1.448	1.4409	1.431
23	1.2966	1.2506	1.3024	1.1468	1.358	1.3603	1.3649
24	1.1673	1.0388	1.2235	1.2021	1.141	1.1995	1.2765
Max	1.6873	1.6272	1.8137	1.6476	1.6676	1.6568	1.6911
Min	.9404	.4763	1.0342	.5167	.5845	1.1127	.6097
Avg	1.2352	1.1504	1.3171	1.0856	1.2817	1.3390	1.2682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 202 / 11 KV NAIGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576		1.1203	1.1949	1.1852	1.1888	1.307
2	1.1576	.9688	1.1203	1.1949	1.1375	1.1765	1.2323
3	1.1458	1.037	1.1317	1.2071	1.2059	1.1888	1.2449
4	1.2696	1.0274	1.1827	1.3203	1.1754	1.2936	1.3443
5	1.39	1.2878	1.419	1.4563	1.3831	1.4937	1.6804
6	1.6632	1.3809	1.6827	1.6632	1.7142	1.773	1.8656
7	2.1807	2	2.2032	1.9022	1.9973	2.0748	2.1068
8	2.0851	1.9918	2.0119	1.9753	1.9239	2.2634	2.0328
9	1.8656	1.609	1.885	1.8671	1.9083	1.9605	1.922
10	1.6827	1.4693	1.7741		1.8671	1.7741	1.6632
11	1.4712	1.419	1.6632		1.7353	1.6804	1.5778
12	1.2476	1.307	1.6244		1.4335	1.5524	1.4815
13	1.147	1.3676	1.5893		1.3014	1.531	1.3944
14	1.0905	1.1949	1.3756		1.4523	1.3817	1.3732
15	1.0883	1.1523	1.3169		1.4003	1.4563	1.3484
16	1.291	1.3121	1.4266		1.587	1.5154	.9174
17	1.4074	1.386	1.531		1.587	1.5893	1.57
18	1.5428	1.531	1.5729	1.6464	1.6787	1.5893	
19	1.8519	1.7372	1.9022	1.8728	1.9052	1.9022	2.0226
20	1.8576	1.6827	1.7193	1.6261	1.7541	1.7741	2.0727
21	1.6897	1.4784	1.531	1.432	1.5684	1.5893	1.7942
22	1.5074	1.4415	1.4784	1.3943	1.4784	1.5497	1.4185
23	1.311	1.3443	1.3817	1.319	1.3817	1.4335	1.3224
24	1.2071	1.0928	1.1949	1.2197	1.2159	1.2803	1.3443
Max	2.1807	2	2.2032	1.9753	1.9973	2.2634	2.1068
Min	1.0883	.9688	1.1203	1.1949	1.1375	1.1765	.9174
Avg	1.4712	1.4008	1.5349	1.5182	1.5407	1.5838	1.5668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 203 / 11 KV CANAL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.1037	.1029	.1029	.1036	.2709	.1715
2	.0686	.1101	.1017	.1029	.1033	.3048	.3052
3	.0693	.1121	.1029	.1029	.1031	.3239	.3353
4	.0678	.1037	.104	.1029	.1036	.3887	.3429
5	.1006	.1038	.12	.12	.1038	.4588	.4694
6	.1187	.1031	.1372	.1187	.1379	.4915	.5304
7	.1677	.1036	.1677	.1372	.1381	.5801	.7291
8	.1715	.1381	.1677	.1677	.1376	.639	.7461
9	.208	.1376	.1677	.1989	.1373	.6554	.78
10	.2035	.1381	.1677		.1957	.6371	.8059
11	.6187	.5487	.6859		.6874	.1147	.1384
12	.7346	.7202	.8478		.8048	.0995	.1384
13	.6889	.7282	.8619		.8817	.1017	.1375
14	.7698	.7202	.8192		.8951	.1638	.1375
15	.8148	.6859	.7956		.852	.125	
16	.7339	.703	.7293		.7293	.1147	.1038
17	.6889	.7716	.7287		.8192	.1357	.1232
18	.6882	.6516	.6706	.794	.5898	.1341	
19	.1376	.1696	.1357	.123	.132	.1677	.1375
20	.1504	.1696	.12	.0922	.1143	.1562	.0924
21	.1381	.1341	.12	.1037	.1158	.1265	.0921
22	.1381	.1174	.1029	.1384	.1	.1524	.1233
23	.103	.1017	.1029	.1381	.1	.12	.1384
24	.0686	.1032	.1029	.1372	.1028	.1014	.1029
Max	.8148	.7716	.8619	.794	.8951	.6554	.8059
Min	.0678	.1017	.1017	.0922	.1	.0995	.0921
Avg	.3216	.3116	.3401	.1675	.3412	.2735	.3037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 201 / 11 KV RUI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9667	.5114	.4713	.522	.5121	.8192	.8166
2	.9541	.5007	.4584	.5102	.4912	.8802	.9225
3	.9858	.4931	.4649	.5022	.4969	.9275	1.0014
4	1.0254	.5178	.4801	.5266	.4923	.9675	1.0494
5	1.1549	.5758	.5422	.5883	.5407	1.0551	1.1206
6	1.5058	.7632	.7148	.7305	.7164	1.1957	1.2883
7	1.5543	.8417	.812	.8112	.8326	1.4704	1.4803
8	1.5676	.799	.7312	.7537	.8211	1.4731	1.5756
9	1.5017	.7045	.6672	.7133	.7346	1.3908	1.5253
10	.8447	.6264	.6737	.6737	.6699	1.334	1.3797
11	2.9961	1.1065	1.1683	1.241	1.3131	.5098	.4226
12	3.4111	1.3451	1.4441	1.4609	1.475	.4127	.04
13	3.8763	1.3714	1.4739	1.5074	1.5108	.3509	.4119
14	1.4445	1.3485	1.4304	1.5245	1.454	.3433	.4089
15	1.4156	1.0585	1.4041	1.4251	1.4125	.3269	.3567
16	1.3535	1.2635	1.4792	1.3805	1.4853	.2683	.3399
17	1.3596	1.3813	.3757	1.3874	1.4678	.4279	.2477
18	1.4232	1.4083	.7453	.1981	1.3889	.5106	
19	.9777	.8356	.844	.7712	1.2315	.8238	.8147
20	.8657	.764	.8417	.8391	.8787	.8196	.8166
21	.7171	.711	.7396	.796	.7602	.732	.7716
22	.7004	.6863	.6843	.7194	.7404	.6619	.6885
23	.5853	.5491	.6348	.6169	.6314	.6013	.6108
24	1.2113	.5064	.5662	.5559	.5796	.5841	.5693
Max	3.8763	1.4083	1.4792	1.5245	1.5108	1.4731	1.5756
Min	.5853	.4931	.3757	.1981	.4912	.2683	.04
Avg	1.4333	.8612	.8270	.8648	.9432	.7869	.8113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 202 / 11 KV DEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.5658	.2801		.3772	.4668	.6602
2	.2772	.5601	.2801		.4668	.3772	.6602
3	.2715	.6535	.2801		.5601	.3772	.6602
4	.2686	.6335	.2601		.6859	.5658	.6602
5	.3467	.724	.2629		.7011	.7545	.7545
6	.6001	.905	.3582		.8059	.9431	.9431
7	.7468	.8954	.543		.8954	.8488	.9431
8	.6859	.8859	.6001		.8859	.7545	.9335
9	.6859	.6268			.7973	.7545	
10	.6001	.7087		.5201	.5258	.8488	
11		.5658		.4715	.4715	.5316	
12	.3772	.4715		.3772	.3772	.5373	
13	.4715	.4715		.3772	.3772	.5144	
14	.4715	.4287		.3772	.2801	.6001	
15	.4715	.4715		.3772	.2801	.6001	
16	.4715	.3772		.3772		.5144	
17	.4715	.5658			.2801	.5144	
18	.4715	.6602			.3734		
19	.9335	.9431		.9431	.9431	.7545	
20	.7468	.7545		1.1317	.9431	.9431	
21	.7468	.7545		.8402	.9431	.8488	
22	.7468	.6602		.7468	.5658	.7545	
23	.6602	.5658		.6535	.5658	.6602	
24	.5658	.6602	.5658		.5658	.5601	.6535
Max	.9335	.9431	.6001	1.1317	.9431	.9431	.9431
Min	.2686	.3772	.2601	.3772	.2801	.3772	.6535
Avg	.5378	.6462	.3812	.5994	.5942	.6532	.7632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 203 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.663	.7316
2						.6596	.7579
3						.6744	.751
4						.7693	.9214
5						1.1157	1.2734
6						1.398	1.5043
7						1.3009	1.198
8						1.198	1.3889
9						1.262	1.1991
10						1.3032	1.2734
11	1.2357	1.2517	.9671	1.2311	.9877	.2481	.1578
12	1.0197	1.2826	.9351	1.2872	.9785		
13	.8871	.807	.8025	.6516	.7499		
14	.5373	.5624	.8688	.815	.7659		
15	.6333	.5784	.5761	.6036	.5521		
16	.5876	.583	.5476	.631	.5167		
17	.6619	.6847	.7225	.639	.6619		
18	.7533	.8116	.8528	.7842	.8093		
19	.0606	.208	.1932	.2138	.1692		
Max	1.2357	1.2826	.9671	1.2872	.9877	1.398	1.5043
Min	.0606	.208	.1932	.2138	.1692	.2481	.1578
Avg	.7085	.7522	.7184	.7618	.6879	.9629	1.0143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 204 / 11 KV KAHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.5658	.4668		.5658	.4668	.6602
2	.724	.7545	.4668		.5658	.4715	.6602
3	.7316	.8488	.4668		.6001	.4715	.6602
4	.8288	.9431	.4668		.6859	.6602	.7545
5	.9326	.8573	.9335		.8764	.8488	.8488
6	1.1869	1.0288	.8859		.8764	.9431	1.1317
7	1.3717	1.3003	1.3146		1.0517	1.226	.9431
8	1.2717	1.3003	1.3717		1.2136		1.226
9	1.3717	1.3003			1.3003	.7545	
10	1.2717	1.286		1.2003	1.5432	.9431	
11	.4715	.6602		.6602	.7545	1.0402	
12	.4715	.5658		.5658	.5658	1.0402	
13	.4715	.4715		.4715	.4715	1.0059	
14		.5658		.4715	.4715	1.1517	
15	.4715	.5658		.4715	.3772	1.0174	
16	.6602	.5658		.4715		1.1022	
17	.7545	.5658			.4715	1.1145	
18	.9431	.7545		.4715	.7545	1.1022	
19	.9335	1.0374		.5658	1.0374	1.2136	
20	.9335	1.0374		.5658	1.1317	1.0269	
21	.7545	.8488		.7545	.9431	1.0374	
22	.7545	.7545		.8488	.7545		
23	.6602	.7545		.7545	.7545	.7545	
24	.6602	.6602	.6602			.5601	.7545
Max	1.3717	1.3003	1.3717	1.2003	1.5432	1.226	1.226
Min	.4715	.4715	.4668	.4715	.3772	.4668	.6602
Avg	.8415	.8331	.7815	.6364	.8076	.9069	.8488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 205 / TATA Chemicals

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0189		.0152	.0175	.0189
2	.0189		.0189		.0137	.0179	.0189
3	.0189		.0189		.0145	.0179	.0189
4	.0189		.0189		.0147	.0183	.0189
5	.0189		.0189		.0147	.0183	.0185
6	.0171		.0189		.0147	.0183	.0175
7	.0171	.0124	.0179		.0147	.0181	.0173
8	.0173		.0179		.0147	.0152	.0158
9		.0133			.0133	.012	
10	.0133	.0135			.0105	.0177	
11		.0189			.0091	.0149	
12		.0189			.0095	.0141	
13		.4715			.0162	.0173	
14		.0189			.0124	.0177	
15		.0189			.0173	.0189	
16	.0133			.0147	.0171	.0189	
17		.0175			.0173	.0189	
18		.0118			.0171	.0181	
19		.0137			.0168	.0173	
20		.0171			.016	.0141	
21		.0171			.0152	.0189	
22		.0189		.0149	.0179	.0189	
23	.0171	.0189		.0152	.0179	.0189	
24	.0189	.0171	.0189			.0141	.0189
Max	.0189	.4715	.0189	.0152	.0179	.0189	.0189
Min	.0133	.0118	.0179	.0147	.0091	.012	.0158
Avg	.0172	.0449	.0187	.0149	.0148	.0172	.0182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 201 / 11 KV GADGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3772	.4668	.3429	.3429	.4668	.3734
2	.3361	.3772	.6535	.3429	.3429	.4668	.3734
3	.3547	.3772	.7468	.3429	.3429	.4668	.4668
4	.3734	.3772	.9335	.4287	.6859	.6535	.6535
5	.4668	.4715	1.1203	.8573	.6859	.8402	.9335
6	.5601	.4715	1.307	1.2003	.9431	1.307	1.4003
7	.6535	.5281	1.587	1.3717	1.5432	1.4937	1.4937
8		.4527	1.6289	1.5432	1.587	1.587	1.587
9	.5601	.5281	1.531	1.5432	1.4937	1.4937	1.6804
10	.3734	.4715	1.4003	1.3717	1.4003	1.4937	1.587
11	1.1576	1.1203	.3429	.4287	.4668	.3734	.4108
12	1.2136	1.2136	.3429	.4287	.3772	.3361	.3772
13	1.2696	1.2696	.2572	.3429	.2772	.2772	.3395
14	1.2696	1.2696	.2743	.3429	.2801	.2772	.2641
15	1.2696	1.1203	.2743	.2572	.2801	.2772	.2452
16	1.2696		.2743	.2572	.2987	.2987	.2452
17	.8962		.2743	.2572	.3174	.2987	.2452
18	1.1763		.3429	.3429	.3734	.3361	.2452
19	.5093	1.2136	.5144	.4287	.5601	.4108	.5281
20	.4715	1.1576	.4287	.4287	.5975	.4668	.5658
21	.4338	1.1203	.4287	.4287	.5175	.4108	.4715
22	.415	.415	.3772	.3429	.4668	.3734	.415
23	.3772	.415	.3429	.3429	.4108	.3734	.3772
24	.3361	.3772	.415	.3429	.3429	.3734	.3361
Max	1.2696	1.2696	1.6289	1.5432	1.587	1.587	1.6804
Min	.3361	.3772	.2572	.2572	.2772	.2772	.2452
Avg	.6991	.7202	.6777	.5966	.6223	.6314	.6506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 202 / 11 KV KOLAMBI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4668	.1132	.1543	.1372	.1307	.1307
2	.4668	.5601	.1132	.1543	.1372	.1307	.1307
3	.5601	.6535	.1132	.1372	.1372	.1494	.1494
4	.9335	.7468	.1132	.1372	.1543	.1494	.1494
5	1.4937	.9335	.1509	.1543	.1715	.168	.168
6	1.6804	1.307	.1886	.1715	.1886	.1867	.168
7	2.0538	1.8671	.2263	.1886	.1886	.2241	.1867
8	2.1472	2.3525	.0943	.1372			
9	2.2405	2.3339		.1372			.1307
10	2.1472	2.1472	.1698	.12	.1867	.1307	.1494
11	.1132	.1132	1.7147	1.7147	1.6804	1.6804	1.4003
12	.0943	.1132	2.0576	2.0919	2.0538	1.848	1.587
13	.0754	.0943	2.0919	2.0576	2.1472	1.6804	1.7737
14	.0754	.0754	2.0919	1.8861	2.2405	2.0328	1.7737
15	.0754	.0754	2.0576	1.8004	2.2405	1.848	1.7737
16	.0754		1.9547	1.7147	2.1472	2.0538	1.7737
17	.0943		1.8519	1.3717	2.0538	2.0538	1.7737
18	.1698		1.7147	1.286	2.1472	1.6804	1.6804
19	.1698	.2263	.1715	.1715	.1867	.1867	.1509
20	.1698	.1886	.1715	.1715	.168	.1867	.1886
21	.1509	.1509	.1715	.1715	.168	.168	.1886
22	.1132	.1132	.1543	.1543	.1494	.1663	.1698
23	.1132	.1132	.1543	.1372	.1494	.1478	.1509
24	.1307	.1132	.1132	.1543	.1372	.1307	.1307
Max	2.2405	2.3525	2.0919	2.0919	2.2405	2.0538	1.7737
Min	.0754	.0754	.0943	.12	.1372	.1307	.1307
Avg	.6588	.7022	.7719	.6823	.8623	.7788	.6904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 203 / 11 KV MANJRAM

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4715	.5601	.4287	.4287	.5601	.4668
2	.3734	.4715	.6535	.4287	.5144	.5601	.4668
3	.4668	.4715	.8402	.5144	.6859	1.0269	.5601
4	.5601	.4715	1.0269	.8573	.8573	1.0269	.8402
5	.6535	.5658	1.307	1.2003	1.2003	1.307	1.307
6	.6535	.6602	1.8671	1.5432	1.5432	1.8671	1.6804
7	.7468	.7545	2.4272	1.8861	2.1434	2.4272	2.4272
8	.7468	.7545	2.5206	2.0576	2.4272	2.4272	2.3339
9	.2801	.6602	2.4272	2.2291	2.3339	2.2405	2.4272
10	.5601	.5658	2.2405	2.0576	2.0538	2.2405	2.3339
11	1.587	2.0538	.5144	.5144	.3734	.3696	.3772
12	1.7737	2.2405	.4287	.4287	.3734	.3361	.3395
13	1.9605	2.2405	.4287	.4287	.3361	.3174	.3018
14	2.0538	2.0538	.4287	.4287	.3361	.3174	.2641
15	2.0538	1.8671	.4287	.4287	.3361	.3142	.2641
16	2.0538		.4287	.4287	.4668	.3361	.2641
17	2.2405		.4287	.4287	.4854	.3734	.2829
18	2.2405		.4287	.5144	.5601	.4668	.3395
19	.6602	2.0538	.5144	.5144	.7468	.6535	.6602
20	.5658	1.9605	.6001	.5144	.6535	.5601	.6602
21	.5281	1.8671	.5144	.5144	.5601	.4668	.5658
22	.4904	.4715	.5144	.4287	.5601	.462	.4715
23	.4715	.4715	.5144	.4287	.4668	.4108	.4715
24	.3734	.4715	.4715	.4287	.4287	.4108	.3734
Max	2.2405	2.2405	2.5206	2.2291	2.4272	2.4272	2.4272
Min	.2801	.4715	.4287	.4287	.3361	.3142	.2641
Avg	1.0195	1.1237	.9381	.8181	.8696	.8949	.8533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 201 / 11 KV KUNTOOR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.6468		.7392	.6653		.8029
2	.7282	.6283		.7392	.6468		.8029
3	.7207	.6468		.7762	.6653		.7468
4	.8131	.6653		.7762	.6838		.7655
5	.8871	.7207		.8871	.7682		.7842
6	1.1643	1.0059		1.0719	.9877		
7	1.1643	1.1706		1.0903	1.1706	.8993	1.1949
8	1.1643	1.0242		1.1273	1.1523		1.1317
9	1.1157	.8383	.924				.924
10	.9877	.4877	.7207				.8215
11	.8596		.7023			.6535	.7207
12	.7682		.7207		.6097		.7392
13	.7316		.5729		.5182	.0045	.7282
14	.7133		.6283			.6348	.7282
15	.7023		.6468			.6908	.7468
16	.6653		.7207			.7655	.7392
17	.7316		.8501			.8029	.7577
18	.7133		.924			.8962	
19	.9877	.7621	1.0349			1.0082	
20	.9694		1.0164			.8589	
21	.8413		.961			.8402	.8871
22			.8131			.8402	.8501
23	.695		.7577			.8402	.8131
24	.7023	.6838		.7207	.7133		.8215
Max	1.1643	1.1706	1.0349	1.1273	1.1706	1.0082	1.1949
Min	.6653	.4877	.5729	.7207	.5182	.0045	.7207
Avg	.8494	.7734	.7996	.8809	.7801	.7489	.8253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 202 / 11 KV KUNTUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	.8871		1.2752	1.0164		
2	1.1949	.9795		1.386	1.1827		
3	1.2197	1.0349		1.4784	1.2437		
4	1.2197	1.0534		1.4784	.9511		
5	1.2567	1.1088		1.5154	1.0608		
6	1.2936	.7762		1.5154	1.0974		
7	.924	1.0608		1.5339	1.5364		
8	1.848	1.3535		1.5339	1.6832		
9	1.9547	1.4022	1.5708				
10	1.9909	1.3413	1.2936				
11						1.1203	1.7741
12						1.4937	2.2361
13						1.307	2.2177
14						1.6804	2.2177
15						2.0538	2.2361
16						2.1845	2.2361
17						2.1472	2.2546
18						2.2032	
Max	1.9909	1.4022	1.5708	1.5339	1.6832	2.2032	2.2546
Min	.924	.7762	1.2936	1.2752	.9511	1.1203	1.7741
Avg	1.4060	1.0998	1.4322	1.4646	1.2215	1.7738	2.1675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 203 / Koklegaon Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4668
2						.6535
3					.9145	.6535
4						.7468
7					1.5242	
9					1.2193	
10						1.4415
11	1.386	1.1431				
12	1.6644		.5415	1.5242		
13	1.5729		1.2197	1.829		
14	1.2012		1.2936			
15	1.7741		1.2936			
16	1.8107		1.386			
17	1.6448		1.4045			
18	1.4998		1.4045			
Max	1.8107	1.1431	1.4045	1.829	1.5242	1.4415
Min	1.2012	1.1431	.5415	1.5242	.9145	.4668
Avg	1.5692	1.1431	1.2205	1.6766	1.2193	.7924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 204 / 11 kv New Ambika EX
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.1867		.2054	.0187		.0187
2	.2614	.168		.2054	.0187		.0187
3	.2801	.168		.2241	.0187		.0187
4	.2218	.1867		.2033	.0187		.0187
5	.1663	.2054		.2218	.0187		.0187
6	.1663	.1848		.2218	.0187		
7	.2033	.2402		.2218	.0187	.0171	.0187
8	.1848	.1663		.2218	.0187		.0189
9	.0189	.0171	.1494				.1886
10	.0189		.0187				.1663
11	.0189		.0189		.2058	.0187	.1867
12	.0189	.0152	.0189		.3086	.0187	.2033
13	.0189		.0189				.1848
14	.0189		.0189			.0187	.1848
15	.0189		.0189				.1848
16	.0189		.0189			.0187	.1848
17	.0189		.0189			.0187	.1848
18	.0187		.0189			.0187	
19	.0187	.0171	.0189			.0187	
20	.0187	.0171	.0189			.0187	
21	.1478		.1867			.0187	.0189
22			.2033			.0187	.0189
23	.2033		.2033			.0189	.0185
24	.2957	.1867		.1867	.0187		.0187
Max	.2957	.2402	.2033	.2241	.3086	.0189	.2033
Min	.0187	.0152	.0187	.1867	.0187	.0171	.0185
Avg	.1147	.1353	.0634	.2125	.0621	.0186	.0938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 205 / 11 KV KOKLEGAON GAOUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2957		.2614	.2587		.3109
2	.2427	.2772		.2801	.2587		.3142
3	.2427	.2957		.2614	.2772	.3086	.3142
4	.2801	.2957		.2987	.2957		.3475
5	.3511	.3142		.3142	.3475		.3475
6	.4435	.4251		.3696	.439		
7	.4805	.4572		.4066	.4706	.4115	.4755
8	.4435	.4572	.4435	.4435	.4572		.4572
9	.3841		.4066			.3048	.3696
10	.3142	.3086	.2772				.3142
11	.2218		.2218			.2561	.2801
12	.1867		.2033		.2439	.2195	.2402
13	.1494		.1867			.2195	.2427
14	.168		.1867			.1829	.2241
15	.2054		.2054			.1829	.2241
16	.2054		.2218	.2218		.1829	.2241
17	.2218		.2801			.1829	.2402
18	.2561		.3326			.2926	
19	.3658	.2743	.3881			.3841	
20	.3475		.3881			.415	
21	.3292		.3511			.3475	.2957
22			.3142			.3475	.2801
23	.3109		.2957			.3292	.2614
24	.4108	.3142		.2801	.2926		.3292
Max	.4805	.4572	.4435	.4435	.4706	.415	.4755
Min	.1494	.2743	.1867	.2218	.2439	.1829	.2241
Avg	.2966	.3377	.2939	.3137	.3341	.2855	.3046

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 201 / 11 KV VAZIRGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3292	.3772	.3734	.3734	1.5089	1.0269
2	.3772	.3292	.4108	.3734	.3734	1.6598	1.2136
3	.3734	.3292	.439	.3734	.3734	1.773	1.4003
4	.3772	.4108	.5121	.3658	.4481	1.8484	1.829
5	.4715	.5975	.543	.4572	.5975	1.8861	1.8099
6	.4715	.7095	.5792	.5601	.6348	1.8861	1.829
7	.5658	.7095	.5014	.5487	.7095	2.037	1.9204
8	.4668	.5975	.5068	.5601	.6584	2.037	1.9909
9	.3772	.4854	.4481	.5144	.5975	1.9616	1.9004
10	.3772	.3734	.4668	.543	.5121	2.0748	1.2003
11		1.5684	1.8004	1.749	1.829	.4715	.439
12		1.6804	1.9719	2.0233	2.0485	.3772	.4108
13	1.7147	1.8671	1.8861	2.0919	2.1658	.3772	.3734
14		1.9022	1.8861	2.0919	2.0851	.3772	
15	1.8519	1.9418	1.9719	2.1384	1.4632	.3772	.2561
16	1.8519	1.9791	2.0576	1.989	1.8671	.3772	.362
17	1.7833	1.9753	2.1434	1.989	1.8671	.2829	.3982
18	1.749	2.0485	1.2003	1.9204	1.9022	.4715	.4344
19	.6516	.6219	.6001	.4801	.6219	.6602	.6173
20	.4801	.5853	.5144	.5792	.5853	.5658	.583
21	.4706	.5487	.4287	.5121	.5487	.4715	.5487
22	.4108	.4755	.3429	.439	.439	.3772	.4024
23	.3772	.4024	.3658	.4024	.4108	.3772	.3734
24	.3772	.4108	.3772	.3734	.4024	.415	.3772
Max	1.8519	2.0485	2.1434	2.1384	2.1658	2.0748	1.9909
Min	.3734	.3292	.3429	.3658	.3734	.2829	.2561
Avg	.7595	.9533	.9305	.9770	.9798	1.0271	.9433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 202 / 11 KV ANTERGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	.8779	1.1203	1.3717	1.3169	.9054	1.0269
2	1.8099	.8962	2.0576	1.7375	1.5364	.9431	1.0164
3	2.2786	.9709	2.4691	2.1434	1.9022	.9431	.9955
4	2.4863	1.4563	2.7435	2.3148	2.2314	.9808	1.0974
5	2.6578	1.7558	2.8121	2.4863	2.9264	.9808	
6	2.7435	1.9418	3.0178	2.4863	3.1459	1.0562	1.2803
7	2.7435	2.1658	2.8837	3.2579	3.2861	1.0562	1.3575
8	3.0864	2.2325	2.9492	3.1722	3.5475	1.2826	1.3717
9	3.0864	2.6223	3.0007	3.0864	3.5117	1.3203	1.2136
10	2.8121	2.7801	3.0007	3.062	2.9874	1.1317	1.0829
11	.8916	.8779	.8573	1.0456	1.0242	1.7918	2.4691
12	.823	.7468	.7316	.7316	.8413	3.1121	2.7435
13		.6722	.543	.7095	.7316	3.1121	2.915
14		.5121	.6401	.6722	.7316	3.1121	
15	.6173	.6722	.7316	.6722	.8048	3.1121	2.5377
16	.5068	.7842	.823	.7468	.8048	3.1121	2.0576
17	.5487	.8215	.9145	.8962		3.3008	2.4006
18	.9412	.8413	1.0059	1.0456	.9511	3.1121	2.4691
19	1.39	1.3817	1.1888	1.419	1.307	1.3203	1.3375
20	1.4118	1.3443	1.3575	1.4563	1.134	1.4146	1.3032
21	1.2437	1.2437	1.1888	1.2696	1.134	1.226	1.0288
22	.9709	1.0974	1.1203	1.134	.9511	1.1317	.9774
23	.9054	.9145	1.0269	.8779	.9335	1.0374	.8962
24	1.0374	.8299	.9054	.8215	.8779	.9054	1.0269
Max	3.0864	2.7801	3.0178	3.2579	3.5475	3.3008	2.915
Min	.5068	.5121	.543	.6722	.7316	.9054	.8962
Avg	1.6585	1.2683	1.6287	1.6090	1.6791	1.7250	1.5729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 203 / 11 KV BARBADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	.7095	.8299	1.0269	.695		.543
2	1.0374	.695	.9054	1.0059	.695	.6413	.724
3	1.1203	.7095	1.0456	1.0059	.8215	.7167	.8145
4	1.307	.9709	1.1949	1.1517	.9511	.7545	.8145
5	1.4937	1.5364	1.4632	1.4937	1.3169	.8299	.8145
6	1.587	1.8671	1.7924	1.4632	1.4632	.8299	.905
7	1.7375	1.9418	1.7147	1.7194	1.4937	.9054	.9955
8	1.7194	1.8671	1.6118	1.5432	1.4998	.9431	.9955
9	1.587	1.6804	1.5089	1.5546		.9431	1.0269
10	1.4937	1.2437	1.1145	1.3032	1.3169	.8488	.8962
11	.7468	.3734	.6001	.5853	.7095	.7545	.9511
12	.8215	.4252	.724	.6348	.7316	.6602	.8215
13	.6878	.6219	.5487	.6584	.695	.6602	.7468
14		.6584	.5487	.6584	.695	.7545	
15	.6722	.695	.5487	.695	.7316	.7545	.6348
16	.7468	.7468	.6535		.7316	.8488	.6859
17	.6516	.7842	.724	.8048	.8048	1.1317	.9511
18	.6516	.8589	.7316	.8779	.8413	1.226	1.2178
19	1.5089	1.4632	1.5546	1.531	1.4632	1.6032	1.6461
20	1.406	1.3169	1.3575	1.6804	1.3169	1.226	1.2346
21	.9602	1.2437	1.0974	.9511	1.0974	1.0374	1.0288
22	.7964	.8779	1.0974	.8962	.8048	.9431	.8688
23	.7468	.8215	1.0269	.7468	.7682	.9431	.8215
24	1.1317	.7682	.7922	.7316	.7682	.7922	.543
Max	1.7375	1.9418	1.7924	1.7194	1.4998	1.6032	1.6461
Min	.6516	.3734	.5487	.5853	.695	.6413	.543
Avg	1.1152	1.0365	1.0494	1.0748	.9744	.9021	.8992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 201 / 11 kv kirti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	.7621	.724	.9526	.924	.9425	1.3575
2	1.1643	.7621	.724			.924	1.4118
3	1.0719	.7621	.6878			.9055	1.4842
4	1.0164	.7621	.6878			.8871	1.5384
5	.7762	.7621	.6878			.8501	1.6289
6	.7392	.7621	.6697			.8686	1.647
7	.7577	.6668	.7059			.8871	1.6108
8	.9979	.5906	.6154	.8002	.7947	.9979	1.3394
9	1.0059	.6097	.6154	.8002	.7947	1.0974	1.4118
10	.9526	.5959	.5792	.8573	.8686	.9492	1.4861
11	.9526	.8669	.6838	.8573	.8501	1.3032	1.4861
12	1.2003	.7362	.5914	.9717	.8316	1.5203	1.4289
13	1.2003	.7011	.6283	.9526	.8501	1.5203	1.3336
14		.6485	.6468	.8954	.8686	1.5384	
15	.8383		.6653	.8764	.8871	.9412	1.2955
16	.8573	.6485	.6838	.8573		1.448	1.5623
17	.8954	.6626	.7392	.9526	.9055	1.4661	1.6194
18	.7621	.6984	.8131	.9717	.8871	1.6289	1.6385
19	.7621	.6485	.7762	.9526	.8871	1.1765	1.6194
20	.7621	.6697	.7392	.9526	.8686	1.5384	1.6194
21	.8383	.6697	.7762	.9335	.8871	1.3575	1.6194
22	.8383	.7602	.8316	1.0288	.9055	1.2489	1.6385
23	.7811	.7602	.8501	1.0098	.924	1.267	1.7337
24	1.2012	.7811	.7602	.9145	1.0164	.961	1.3032
Max	1.2012	.8669	.8501	1.0288	1.0164	1.6289	1.7337
Min	.7392	.5906	.5792	.8002	.7947	.8501	1.2955
Avg	.9379	.7081	.7034	.9187	.8795	1.1760	1.5136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 202 / 11 kv flemingo
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.0953	.0724	.1143	.1307	.1867	.181
2	.112	.0953	.0724			.1494	.181
3	.0934	.0953	.0724			.1307	.1448
4	.0934	.0953	.0724			.0934	.1448
5	.0762	.0953	.0724			.0762	.1448
6	.0572	.0953	.0724			.0762	.1448
7	.0572	.0953	.0543			.0762	.0724
8	.112	.0762	.1086	.0762	.112	.0934	.0905
9	.168	.0762	.0905	.0762	.168	.168	.2172
10	.1715	.3681	.4887	.2858	.3361	.2865	.381
11	.3429	.3506	.5175	.3429	.462	.6335	.5335
12	.3429	.3506	.499	.3048	.5914	.5973	.5525
13	.3239	.3681	.462	.1905	.5544	.181	.4954
14	.381	.333	.4108	.1524	.4805	.1267	
15	.2096		.3734	.1905	.4435	.3258	.4191
16	.381	.0701	.3361	.3239	.3734	.2172	.1905
17	.362	.1433	.3174	.2858	.3361	.2353	.1905
18	.2667	.1433	.3361	.2477	.2801	.181	.2477
19	.2096	.1227	.2801	.1905	.2241	.2353	.1905
20	.2096	.181	.2241	.1905	.181	.181	.1905
21	.0953	.1267	.1867	.1143	.1867	.181	.1905
22	.0953	.0724	.1307	.1143	.2054	.181	.1715
23	.0953	.0724	.1307	.1334	.2241	.181	.1715
24	.1307	.0953	.0724	.1143	.1307	.2241	.181
Max	.381	.3681	.5175	.3429	.5914	.6335	.5525
Min	.0572	.0701	.0543	.0762	.112	.0762	.0724
Avg	.1882	.1573	.2272	.1916	.3011	.2091	.2360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 203 / 11 kv advance steel
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1334	.0905	.1143	.112	.1307	.1086
2	.0934	.1334	.0905			.1307	.1086
3	.0934	.1334	.0905			.112	.1086
4	.0762	.1334	.0905			.112	.1086
5	.0762		.0905			.112	.1086
6	.0934	.1334	.0905			.112	.1086
7	.0934	.1334	.0905			.112	.1086
8	.112	.1334	.1086	.0762	.112	.1307	.1086
9	.112	.1143	.1086	.1143	.1307	.1494	.1267
10	.1143	.1052	.1086	.1143	.112	.1075	.1334
11	.1143	.1227	.1307	.0953	.112	.1267	.1334
12	.1143	.1227	.112	.1143	.1307	.1086	.1334
13	.1143	.1402	.112	.1334	.1307	.1086	.1524
14		.1052	.112	.1524	.1307	.1267	
15	.1143		.1307	.1334	.1448	.1448	.1143
16	.1143	.1052	.1307	.1334	.1494	.1267	.1334
17	.1143	.0895	.112	.1334	.1494	.1267	.1334
18		.0716	.0934	.1334	.1494	.1086	.0953
19	.1143	.0876	.0934	.1334	.1307	.1267	.0953
20	.1143	.0905	.0934	.1334	.1307	.1267	.0953
21	.1334	.0905	.112	.1334	.1307	.1267	.0953
22	.1334	.0905	.112	.1334	.1307	.1267	.0953
23	.1334	.0905	.112	.1334	.1307	.1086	.0953
24	.112	.1334	.0905	.1143	.112	.1307	.1086
Max	.1334	.1402	.1307	.1524	.1494	.1494	.1524
Min	.0762	.0716	.0905	.0762	.112	.1075	.0953
Avg	.1092	.1133	.1044	.1239	.1294	.1222	.1135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 204 / 33kv flemingo

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	05-MAR-17
HR	Load (MW)
16	.4481
Max	.4481
Min	.4481
Avg	.4481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 205 / 33 KV Venkys Express

Feeder Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9404	2.3285	3.6923
2			2.4949	3.8009
3			2.7721	3.8009
4			3.1047	3.9095
5			3.2922	3.9095
6			3.4019	3.9638
7			3.2922	4.0181
8		3.6591	3.1824	3.5837
9		3.7146	3.0493	3.7466
10		3.77	2.7938	4.0009
11		3.8409	2.8778	4.1152
12		3.8958	2.6063	2.1719
13		3.9506	3.2579	3.658
14	2.1719	3.8409	3.4751	
15	4.0009	3.7311	3.2036	3.8866
16	4.0009	3.6591	3.638	3.8866
17	4.0009	3.5482	3.7466	4.0009
18	1.7147	3.3819	3.4208	4.1152
19	1.7147	3.3265	3.6923	4.0009
20	1.7147	3.3819	3.5294	3.7723
21	2.0005	2.7721	3.5294	3.7151
22		2.4394	3.4751	3.7151
23	1.8861	2.3285	3.2579	3.7151
24		1.8296	2.2177	3.5294
Max	4.0009	3.9506	3.7466	4.1152
Min	1.7147	1.8296	2.2177	2.1719
Avg	2.5784	3.2784	3.1517	3.7699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 206 / 33 KV Citrus Exp Feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9522	.8573		.9717	.8402	1.3306	1.1946
2	1.0082	.8573				1.2197	1.1946
3	1.0642	.5716				1.5524	1.3032
4	1.1203	.5716				1.0082	1.3032
5	1.1643	.5716				.8962	1.3575
6	1.2197	.5716				.8402	1.3575
7	1.2197					.8402	1.3575
8	1.0082			1.086	.5041	.6161	.9774
9	1.0642				.8962	.4481	1.0317
10	.8573			1.1431	.8402		1.1431
11	.8573			.8573	.8962		1.0288
12	.8573		.5041	.9145	.9522	.4887	1.0288
13	.8573		.5041	.9145	1.0082	.4887	1.1431
14			.5601	.9145	1.0082	.4344	
15	.8573		.5601	.8573	1.0642	.7059	1.2003
16	.8573		.6161	1.1431	1.0642	.7602	1.1431
17	1.2574		.8962	1.6004	1.1203	.8688	1.1431
18	1.2574		1.1763		1.1203	.8688	1.1431
19	1.1431		1.2323		1.1643	.8688	1.2574
20	1.1431		1.2323		1.1643	.7602	1.3717
21	1.1431		1.1763	1.1431	1.2197	.8688	1.3717
22	1.0288		1.1203	1.2574	1.3306	.9774	1.2574
23	1.0288		1.1203		1.386	1.0317	1.2574
24	1.0082	1.0288		1.0288	.8402	1.386	1.086
Max	1.2574	1.0288	1.2323	1.6004	1.386	1.5524	1.3717
Min	.8573	.5716	.5041	.8573	.5041	.4344	.9774
Avg	1.0424	.7185	.8915	1.0640	1.0233	.8755	1.2023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174111 / 33 KV NAIGAON

Feeder No / Name : 101 / Lalwandi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.9054	.7922	.5658	.7922	.5658	.5658
2	.9431	.9808	.8488	.7922	.8488	.547	.6413
3	1.1317	1.094	.9054	.9431	.9054	.6224	.679
4	1.3203	1.1694	.9808	1.1883	1.0374	.6979	.7167
5	1.3203	1.226	1.094	1.2826	1.3014	.7922	.7545
6	1.4146	1.2826	1.1694	1.3203	1.3957	.8865	.8488
7	1.5089	1.358	1.5844	1.358	1.5844	.9431	.9431
8	1.6032	1.5278	1.6598	1.4146	1.7164	.8299	.9054
9	1.5466	1.4712	1.3203	.9431	1.5844	.7545	.8676
10	1.358	1.4146	1.226	.3961	1.4335	.6602	.7922
11	.547	.1509	.1132	.4527	.4527	1.1317	1.1128
12	.3961	.1132	.1509	.3395	.4715	1.4146	1.2826
13	.3584	.2263	.1509	.3206	.4904	.9431	.7733
14	.3584	.2829	.1886		.4715	.6602	1.226
15	.3772	.3018	.2263		.4338	.8488	1.1694
16	.3772	.3206	.2641	.1132	.4527	1.1317	1.0374
17	.4904	.4338	.3395	.4715	.4904	1.3203	.9054
18	.5281	.4904	.4527	.7167	.3584	1.1317	
19	.6602	.6224	.5658	.7733	.5281	.3395	.9431
20	.7733	.6979	.6602	.7922	.679	.3772	.9054
21	.6413	.6413	.5658	.7545	.6979	.3772	.7545
22	.5847	.5847	.4527	.7167	.6413	.4904	.679
23	.5658	.5281	.3772	.5658	.6036	.4904	.6413
24	.6413	.5658	.4715	.3395	.547	.5658	.5281
Max	1.6032	1.5278	1.6598	1.4146	1.7164	1.4146	1.2826
Min	.3584	.1132	.1132	.1132	.3584	.3395	.5281
Avg	.8417	.7662	.6900	.7527	.8299	.7718	.8553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 201 / 11 KV SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	07-MAR-17
HR	Load (MW)
1	.4075
2	.4207
3	.4207
4	.4908
5	.7442
6	.8596
7	.985
8	1.0166
9	1.0749
10	.9945
11	.9326
12	.9448
13	.9012
14	.8421
15	.9339
17	.9831
18	.7701
19	.823
20	.823
21	.7209
22	.6464
23	.6133
24	.3841
Max	1.0749
Min	.3841
Avg	.771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 203 / 11 KV JAWAHAR NAVODAY
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	07-MAR-17
HR	Load (MW)
1	.0417
2	.0278
3	.0278
4	.0312
5	.0377
6	.0343
7	.0537
8	.0572
9	.0572
10	.0381
11	.0381
12	.0191
13	.0191
14	.0381
15	.0381
16	.0381
17	.0572
18	.0381
19	.0417
20	.0394
21	.0309
22	.0492
23	.0469
24	.0412
Max	.0572
Min	.0191
Avg	.0392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 177004 / 132 KV NARSI DHUPPA

Feeder No / Name : 204 / 11 KV SHANKARNAGAR SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	07-MAR-17
HR	Load (MW)
1	1.3904
2	1.3735
3	1.3565
4	1.3904
5	1.4403
6	1.595
7	1.9281
8	2.2977
9	2.1195
10	2.079
11	2.0719
12	1.9662
13	2.4777
14	1.9685
15	1.8785
16	1.8404
17	1.9204
18	1.9204
19	1.9839
20	1.7295
21	1.5912
22	1.4419
23	1.326
24	1.2146
Max	2.4777
Min	1.2146
Avg	1.7626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 201 / 11 KV WATER WORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.543		.5601	.9955		.3734
2	.9335	.543		.5601	.9955		.3734
3	.9335	.543		.5601	.9955		.3734
4	.9335	.543		.5601	.9955		.3734
5	.9335	.5487		.5601	1.0059		.3734
6	.9335	.7392		.5601	1.1088		.5601
7	.9335	.7392		.5601	1.1203		.5601
8	.7468	.7468		.5601			.3734
9		.7468	1.1765		1.0269	.5601	.3734
10		.5601	.9335		.9335	.3734	.3734
11		.5601	1.2136		.7468	.3734	.1867
12			1.2136		.5601	.5601	.6535
13			1.2136		.7468	.5601	.7468
14		.9335	.8402		.7468	.5601	.9335
15		.9335	1.1203		.9335	.9335	.9335
16		.9335	1.1203		.9335	.9335	.6535
17	1.2136	.9335	1.0269	1.226		.8402	.9335
18	.6535	.9335	.9335	1.1203		.7468	.9335
19	.7468	.9335	.7468	1.1203		.8402	.9335
20	.7468	.9335	.7468	1.0269		.8402	.9335
21	.6535	.5601	.5601	.6535		.7468	.9335
22	.5601		.5601	.8316		.503	.9335
23	.5544		.5601	1.0059		.5601	.9335
24	.9335	.9335		.5658	.9955		.5601
Max	1.2136	.9335	1.2136	1.226	1.1203	.9335	.9335
Min	.5544	.543	.5601	.5601	.5601	.3734	.1867
Avg	.8340	.7421	.9311	.7519	.9275	.6621	.6379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 202 / 11 KV GURUDWARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.362		.3582	.4525		.3582
2	.3582	.362		.3582	.3696		.3582
3	.3582	.362		.3582	.362		.3582
4	.3582	.362		.3582	.362		.3582
5	.5373	.3658		.3582	.3658		.3582
6	.5373	.462		.5373	.5544		.5373
7	.7164	.6468		.7164	.6535		.5373
8	.7164	.7468		.7164			.8059
9		.7164	.7468		.7164	.7164	.7468
10		.7164	.7468		.7164	.7164	.6535
11		.7164	.6535		.7164	.7164	.6535
12			.6535		.7164	.5373	.6535
13			.6535		.5373	.5373	.6535
14		.5373	.4668		.3582	.5373	.5601
15		.5373	.4668		.5373	.5373	.5601
16		.5373	.4668		.5373	.5373	.6535
17	.5601	.6268	.5373	.6535		.5373	.5373
18	.6535	.6268	.7164	.8402		.7164	.7164
19	.7468	.8059	.8954	.9335		.8954	.8954
20	.7468	.8954	.7164	.9335		.8954	.7164
21	.6535	.8059	.7164	.8402		.8059	.7164
22	.5544		1.3432	.6468		.7164	.7164
23	.462		.5373	.5487		.5373	.5373
24	.3582	.5373		.3582	.4525		.5373
Max	.7468	.8954	1.3432	.9335	.7164	.8954	.8954
Min	.3582	.362	.4668	.3582	.3582	.5373	.3582
Avg	.5534	.5864	.6878	.5947	.5255	.6627	.5908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 203 / 11 KV SOMESH COLONEY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5223	1.086		1.0745	1.1765		1.0814
2	1.0745	1.086		1.0745	1.2012		1.0745
3	1.0745	1.086		1.0745	1.1765		1.0745
4	1.0745	1.086		1.0745	1.1765		1.0745
5	1.0745	1.1888		1.0745	1.2803		1.1641
6	1.5223	1.2936		1.2536	1.5708		1.2536
7	1.3432	1.5708		1.3432	1.587		1.3432
8	1.4327	1.6804		1.5223			1.5223
9		1.6118	2.0538		1.5223	1.5223	1.9605
10		1.5223	1.8671		1.4327	1.6118	1.8671
11		1.6118	2.0538		1.4327	1.6118	1.9605
12			2.0538		1.3432	1.6118	2.0538
13			2.0538		1.3432	1.7013	1.8671
14		1.7909	1.8671		1.2536	1.6118	1.8671
15		1.7013	1.6804		1.2536	1.6118	1.7737
16		1.5223	1.7737		.3582	1.6118	1.6804
17	1.7737	1.7013	1.7909	1.8671		1.1641	1.7013
18	1.8671	1.7909	1.7909	2.0538		1.7013	2.0595
19	2.1472	2.0595	2.0595	2.2405		2.1491	2.3282
20	2.0538	1.8804	1.7909	2.1472		1.8804	2.0595
21	1.7737	1.5223	1.6118	1.8671		1.6118	1.7013
22	1.587		1.3432	1.5708		1.3432	1.3432
23	1.2936		1.1641	1.2803		1.1641	1.2536
24	1.0745	1.8804		1.0745	1.1765		1.1641
Max	2.1472	2.0595	2.0595	2.2405	1.587	2.1491	2.3282
Min	1.0745	1.086	1.1641	1.0745	.3582	1.1641	1.0745
Avg	1.4806	1.5336	1.7970	1.4746	1.2678	1.5939	1.5929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 204 / 11 KV VAZIRABAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0745	.724		.7164	.8145		.7973
2	.7164	.724		.7164	.8145		.7973
3	.7164	.724		.7164	.8145		.7087
4	.7164	.724		.7164	.8145		.7087
5	.7164	.823		.7164	.9145		.7087
6	1.0745	1.0164		.8954	1.1088		.8859
7	1.1641	1.2136		.985	1.1203		.9745
8	1.1641	1.307		1.0745			1.0631
9		1.0745	1.307		1.0631	1.0745	1.307
10		1.0745	1.307		1.0631	1.0745	1.307
11		1.3432	1.4937		1.0631	1.2536	1.587
12			1.4937		1.0631	1.3432	1.6804
13			1.4003		1.0631	1.3432	1.587
14		1.3432	1.307		.8697	1.2536	1.4003
15		1.2536	1.4003		.9745	1.2536	1.4003
16		1.1641	1.4003		1.0631	1.2536	1.4937
17	1.4937	1.3289	1.3432	1.4937		1.3289	1.3432
18	1.6804	1.4175	1.4327	1.6804		1.2651	1.5223
19	1.8671	1.6832	1.7909	2.0538		1.8604	1.7909
20	1.6804	1.5947	1.5223	1.8671		1.6832	1.7909
21	1.4937	1.2403	1.3432	1.4937		1.4175	1.4327
22	1.0269		.985	1.1203		.9745	1.0745
23	.924		.8954	.9145		.8859	.8954
24	.7164	1.6832		.7164	.8145		.7973
Max	1.8671	1.6832	1.7909	2.0538	1.1203	1.8604	1.7909
Min	.7164	.724	.8954	.7164	.8145	.8859	.7087
Avg	1.1391	1.1728	1.3615	1.1173	.9649	1.2844	1.2106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 205 / 11 KV Khadakpura

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.587	.905		.9335	.905		.9335
2	1.1203	.905		.9335	.924		.9335
3	1.1203	.905		.9335	.905		.9335
4	1.1203	.905		1.1203	.905		.9335
5	1.1203	1.0974		1.307	1.0974		1.1203
6	1.587	1.4003		1.587	1.386		1.3817
7	1.9605	1.848		1.7737	1.8861		1.9044
8	2.1472	1.9605		1.9605			2.0911
9		1.9605	2.4272		2.0538	1.9605	2.0538
10		1.7737	2.2405		1.9791	1.6804	1.4003
11		1.4937	2.1472		1.6804	1.4003	1.2136
12			1.9605		1.6804	1.307	1.307
13			1.8671		1.4563	1.2136	1.0269
14		1.307	1.2136		1.251	1.1203	1.0269
15		1.2136	1.1203		1.1576	1.0269	1.1203
16		1.2136	1.1203			1.1203	1.2136
17	1.2136	1.363	1.307	1.307		1.307	1.4003
18	1.6804	1.8671	1.9605	1.9805		1.8671	2.0538
19	2.2405	2.0538	2.1472	2.0538		2.1472	2.3339
20	1.587	1.643	1.587	1.6804		1.6804	1.7737
21	1.307	1.3443	1.4003	1.4937		1.3443	1.4003
22	1.1203		1.307	1.307			1.307
23	1.0164		1.2136	1.0974		1.2323	1.307
24	1.1203	1.4937		1.1203	1.2136		1.1203
Max	2.2405	2.0538	2.4272	2.0538	2.0538	2.1472	2.3339
Min	1.0164	.905	1.1203	.9335	.905	1.0269	.9335
Avg	1.4405	1.4327	1.6680	1.4118	1.3654	1.4577	1.3871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 201 / 11 KV COLLECTOR OFFICE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391		.3292				.3361
2	.3235	.2614	.3292				.3258
3	.3144		.3258				.2835
4	.3151		.3258				
5	.3288		.3258				.3292
6	.3544		.3224				
7	.3589	.3018	.3189				.362
8	.3593		.2896				.3086
9	.6398	.2915	.2926	.3292	.3292	.3353	
10	.3296	.3258			.3361	.3429	
11	.7975	.373			.3189	.4409	
12	.8356	.3932	.4904			.4359	
13	.4851	.4096			.3292	.4801	
14	.4534		.415			.4801	
15	.4374				.3224	.4801	
16	.4553				.3429	.4752	
17	.4618						.4694
18	.8051		.439			.439	.0335
19	.3902		.3429		.3658	.3856	
20	.6367		.3189		.3326	.3544	.3761
21	.3163	.3292				.3734	.3582
22	.3262		.3224		.3658	.3361	.3403
23	.3509					.3086	.3475
24	.6531		.3292	.3361	.3658	.3429	.3258
Max	.8356	.4096	.4904	.3361	.3658	.4801	.4694
Min	.3144	.2614	.2896	.3292	.3189	.3086	.0335
Avg	.4611	.3357	.3448	.3327	.3409	.4007	.3228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 202 / 11 KV CHIKHALWADI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8078	.8017	.695				.7842
2	.7705	1.3649	.6584				.724
3	.7392	.7491	.6516				.7087
4	.7385	.7598	.6878				
5	.7354	.7476	.6878				.7682
6	.8528	.7987	.788				
7	1.0067	1.7154	.8505				.905
8	1.0059	.9427	.8688				.7888
9	1.757	1.6316	.8048	.8779	.8048	.7377	
10	.9031	1.723			.7842	.6859	
11	1.8283	.7933			.815	.8139	
12	.993	1.4407	.9808			.8048	
13	1.0159	.7872			.8413	.9602	
14	1.0181	.8063	.9054			.9259	
15	1.041	.8581			.788	.8916	
16	1.0761	1.0898			.7545	.8848	
17	1.0593	1.0822				1.0498	1.0395
18	2.1163	1.0844	1.2071			1.0974	1.0395
19	1.2308	1.2963	1.286		1.0242	1.4022	
20	2.575	1.5592	1.3112		1.0349	1.3112	1.3969
21	1.3253	1.4952				1.2136	1.2894
22	1.1622	1.2658	.9313		.9145	1.1203	1.1462
23	.98	1.0433				.8573	.9877
24	1.6225		.7316	.8215		.6859	.7964
Max	2.575	1.723	1.3112	.8779	1.0349	1.4022	1.3969
Min	.7354	.7476	.6516	.8215	.7545	.6859	.7087
Avg	1.1817	1.1233	.8779	.8497	.8624	.9652	.9519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 203 / 11 KV GRANTH BHAVAN

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655		.0549				.0747
2	.0629	.0566	.0549				.0724
3	.0556		.0543				.0532
4	.0581		.0543				
5	.0653		.0724				.0732
6	.0737		.0716				
7	.0716	.0377	.0354				.0362
8	.0436		.0362				.0343
9	.0661	.0343	.0366	.0366		.0335	
10	.0339	.0171			.0373	.0343	
11	.0486	.017			.0354	.0339	
12	.0297	.0328	.0377			.0335	
13	.0349				.0366	.0343	
14	.0288		.0189			.0171	
15	.0312				.0358	.0171	
16	.029				.0343	.0328	
17	.0259					.0362	.0335
18	.0842		.0366				.0335
19	.048		.0514		.0549	.0526	
20	.1364		.0532		.0554	.0532	.0716
21	.0707					.0747	.0716
22	.0745		.0537		.0732	.0747	.0716
23	.0777					.0686	.0732
24	.1395		.0549	.056		.0343	.0724
Max	.1395	.0566	.0724	.056	.0732	.0747	.0747
Min	.0259	.017	.0189	.0366	.0343	.0171	.0335
Avg	.0606	.0326	.0486	.0463	.0454	.0421	.0593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 204 / 11 KV BAFNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.422	1.4358	1.3169				1.3817
2	1.3047	2.5537	1.2437				1.3032
3	1.2475	1.2841	1.2308				1.2403
4	1.2231	1.2521	1.1946				
5	1.2445	1.2544	1.3032				1.3169
6	1.3778	1.3519	1.4327				
7	1.5668	3.043	1.4883				1.6289
8	1.6324	1.6141	1.5927				1.4746
9	3.1866	3.1862	1.7558	1.7193		1.5089	
10	1.6941	3.6351			1.6804	1.5432	
11	1.7238	3.836			1.701	1.5261	
12	1.7208	3.4705	1.7353			1.4754	
13	1.6888	1.7429			1.6461	1.5432	
14	1.7177	1.733	1.4335			1.6289	
15	1.6133	1.6941			1.5043	1.6118	
16	1.5516	1.6789			1.3717	1.4746	
17	1.5531	1.6354					1.5089
18	3.315	1.7269	1.6095			1.829	1.6095
19	1.8412	2.1056	2.0576		1.9022	2.1735	
20	3.7083	2.2276	1.9136		1.848	1.949	1.9342
21	1.8397	2.1087				1.9418	1.8625
22	1.6766	1.8145	1.6118		1.6095	1.6804	1.6476
23	1.5821	1.7032				1.3717	1.5729
24	2.8898	3.107	1.4266	1.419			1.448
Max	3.7083	3.836	2.0576	1.7193	1.9022	2.1735	1.9342
Min	1.2231	1.2521	1.1946	1.419	1.3717	1.3717	1.2403
Avg	1.8467	2.1331	1.5217	1.5692	1.6579	1.6613	1.5330

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 205 / 11 KV OLD MONDHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2231	1.1949	1.1706				1.1576
2	1.1187	2.0744	1.0974				1.086
3	1.0982	1.0601	1.086				1.0631
4	1.0913	1.0479	1.0498				
5	1.1065	1.0433	1.1222				1.134
6	1.2003	.9252	1.2536				
7	1.4091	1.0082	1.382				1.3756
8	1.5059	1.3649	1.3756				1.2003
9	2.601	2.5126	1.2071	1.0608	1.1706	1.1736	
10	1.2917	2.319			1.1203	1.0288	
11	1.1934	1.1393			.9922	.9326	
12	.7484		.9808			.8718	
13	.3399				.8779	.8573	
14	1.15	.2134	.9808			.9088	
15	1.0783	1.3542			.8954	.9709	
16	1.0197	1.3115			.8916	.9175	
17	1.0456	1.2894				1.086	.9724
18	2.1185	1.1957	1.0974			1.134	1.073
19	1.166	1.3763	1.3717		1.2437	1.4022	
20	2.7183	1.6392	1.4175		1.3306	1.3112	1.5043
21	1.4304	1.6705				1.3443	1.4685
22	1.2925	1.4792	1.2536		1.2071	1.2696	1.4327
23	1.3146	1.448				1.0288	1.39
24	2.3724		1.1706	1.2136			1.1946
Max	2.7183	2.5126	1.4175	1.2136	1.3306	1.4022	1.5043
Min	.3399	.2134	.9808	1.0608	.8779	.8573	.9724
Avg	1.3597	1.3651	1.1885	1.1372	1.0810	1.0825	1.2348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 206 / 11 KV SACHKHAND

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4119	.4885	.3292				.3361
2	.3818	.894	.3292				.2896
3	.3589	.455	.3258				.2835
4	.3677	.4938	.2715				
5	.3818	.5068	.2896				.3292
6	.3841	.5735	.2507				
7	.3372	.9873	.1772				.2172
8	.242	.4062	.181				.2058
9	.431	.5621	.1463	.1829	.2195	.2012	
10	.2058	.5152			.1867	.2614	
11	.1936	.1985			.2481	.2204	
12	.3334		.1698			.2012	
13	.3929				.2195	.2572	
14	.2629	.0888	.1867			.1372	
15	.2812	.2252			.2507	.1372	
16	.3448	.2511			.2572	.1966	
17	.3555	.2526				.2534	.2347
18	.671	.2446	.2561			.2926	.2515
19	.3921	.3037	.3772		.439	.3506	
20	.9435	.4146	.3544		.4435	.3544	
21	.5655	.4005				.3361	.4298
22	.5418	.3765	.3224		.3658	.3361	.394
23	.5274	.4039				.3086	.4024
24	.913		.3292	.3361			.4119
Max	.9435	.9873	.3772	.3361	.4435	.3544	.4298
Min	.1936	.0888	.1463	.1829	.1867	.1372	.2058
Avg	.4259	.4306	.2685	.2595	.2922	.2563	.3155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 207 / 11 KV RAILWAY HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1097				.112
2		.1132	.1097				.1086
3			.1086				.1063
4			.1086				
5			.1086				.1097
6			.1254				
7			.124				.1267
8			.1267				.1029
9	.1086	.1029	.1097	.1097	.1097	.1006	
10		.1543			.112	.1372	
11	.1063	.1017			.1063	.1187	
12		.1147	.1307			.1174	
13					.1097	.1543	
14			.1132			.12	
15					.1075	.12	
16					.0857	.0819	
17							.1006
18	.0934		.1097				.1006
19			.1029		.1097	.1227	
20	.1132		.124		.1109	.124	.1254
21						.1307	.1433
22			.1254		.1097	.112	.1433
23						.1029	.1097
24	.0943	.168	.1097	.112			.1086
Max	.1132	.168	.1307	.112	.112	.1543	.1433
Min	.0934	.1017	.1029	.1097	.0857	.0819	.1006
Avg	.1032	.1258	.1154	.1109	.1068	.1186	.1152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 201 / 11 KV BILAL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.383	2.2032	1.1088			2.2786	2.2565
2	2.226	2.1887	1.1088			2.2336	2.2215
3	2.2032	1.9959	1.1088			2.2313	2.2161
4	2.2024	2.0043	1.1088			2.2428	2.2238
5	2.258	2.2268	1.1088			2.2847	2.3763
6	2.466	2.5956	1.4784			2.8197	2.612
7	2.7489	2.8722	1.6632			3.2125	3.0845
8	2.8921	3.0842	1.6632			3.1153	3.2693
9	2.9549	2.8281	1.587	1.2136	1.4937	3.0453	2.8182
10	2.7504	2.5655	1.4784	1.0059	1.386	2.6753	2.5133
11	2.9003	2.7557	1.7556	1.2803	1.4784	2.3906	2.7417
12	2.7652	2.6757	1.7556	1.0974	1.386	2.5019	2.621
13	2.5539	2.5644	1.6632	1.0974	1.2803	2.4569	2.351
14	2.5112	2.4965	1.2803	1.0974	1.2803	2.3381	2.3159
15	2.2916	2.3114	1.1888	1.0974	1.1765	2.4051	2.2937
16	2.2443	2.0629	1.1765	1.1888	1.1765	1.1759	2.3205
17	2.4135	2.191	1.2803	1.2803	1.2936	2.5633	2.4695
18	3.123	2.8166	1.4632	1.4632	1.4784	2.9393	2.6836
19	3.219	3.291	1.5708	1.5546	1.4784	3.5465	3.1393
20	2.963	2.9717	1.4784	1.386	1.4784	3.1047	3.2598
21	2.5148	2.6996	1.2803	1.2803	1.4784	2.7214	2.737
22	2.348	2.4653	1.1888		1.2936	2.6017	2.6078
23	2.3022	2.4051	1.0974		1.1088	2.4523	2.399
24	2.2359	2.3053	1.1088	1.0974		2.3182	2.3487
Max	3.219	3.291	1.7556	1.5546	1.4937	3.5465	3.2693
Min	2.2024	1.9959	1.0974	1.0059	1.1088	1.1759	2.2161
Avg	2.5613	2.5240	1.3626	1.2243	1.3512	2.5690	2.5783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 202 / 11 KV RLY TRACK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7725	1.2803	1.2936			1.2936	1.3717
2	2.6581	1.2803	1.2936			1.2936	1.3717
3	2.6033	1.2803	1.2936			1.2936	1.3717
4	2.5827	1.2803	1.2936			1.2936	1.3717
5	2.6234	1.2803	1.2936			1.2936	1.4784
6	2.9035	1.3717	1.4784			1.4784	1.4784
7	3.0933	1.5708	1.848			1.6632	1.6804
8	3.2118	1.6804	1.9404			1.848	1.6804
9	3.5102	1.7737	2.2405	1.8671	1.7737	1.7737	1.8671
10	3.6576	1.9605	2.2177	1.6461	1.848	1.8671	1.848
11	3.3546	1.9605	2.2177	1.6461	1.7556	1.7556	1.848
12	3.206	1.8671		1.4632	1.6632	1.6461	1.848
13	3.1656	1.6461	2.2177	1.2803	1.5546	1.5546	1.848
14	2.9046	1.4632	2.0119	1.2803	1.4632	1.4632	1.4784
15	2.6787	1.4632	1.4632	1.2803	1.267	1.3717	1.448
16	2.5202	1.3717	1.267	1.2803	1.267		1.4632
17	2.6048	1.4632	1.2803	1.2803	1.2936	1.3575	1.4784
18	2.7976	1.6632	1.6461	1.6461	1.6632	1.6461	1.6632
19	3.4644	2.0328	2.0328	2.1033	1.848	2.0328	2.2177
20	3.5909	1.848	1.848	1.9404	1.848	1.829	2.0328
21	3.4484	1.6632	1.6461	1.829	1.6632	1.9204	1.848
22	3.3105	1.6632	1.6461		1.6632	1.6461	1.6461
23	3.0453	1.2936	1.6461		1.4784	1.5546	1.6461
24	2.806	1.2803	1.2936	1.4632		1.4784	1.4632
Max	3.6576	2.0328	2.2405	2.1033	1.848	2.0328	2.2177
Min	2.5202	1.2803	1.267	1.2803	1.267	1.2936	1.3717
Avg	3.0214	1.5599	1.6700	1.5719	1.6033	1.5806	1.6437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 203 / 11 KV DEGLOOR NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7671	1.829	1.848	1.829		3.0006	2.841
2	2.6078	1.829	1.848			2.9503	2.7526
3	2.5903	1.6461	1.848			2.9206	2.7374
4	2.5826	1.6461	1.848			2.9221	2.7267
5	2.6213	1.6461	1.848			2.9496	2.7869
6	2.8647	1.829	2.0328			3.073	3.018
7	2.9939	2.0119	2.4025			3.3319	3.1885
8	2.0538	2.2405	2.5873			3.618	3.2503
9	2.0538	2.2405	2.8006	2.2405	2.0538	3.6115	3.4865
10	2.2405	2.0538	2.9569	2.1948	2.2177	3.8972	3.8379
11	2.0328	2.0538	2.9874	2.1948	2.1253	3.5683	3.6805
12	2.2177	2.2405	2.9569	2.0119	2.1253	3.3646	3.4286
13	1.9404	2.1948	2.9569	1.829	1.9204	3.3234	3.3715
14	1.848	2.0119	2.0119	1.829	1.1888	2.9134	3.1553
15	1.7375	1.829	1.829	1.829	1.8099	2.8616	2.8501
16	1.7375	1.829	1.8099	1.829	1.8099	.9412	2.806
17	1.7375	1.829	1.829	1.829	1.848	2.7793	2.8014
18	2.0119	2.2177	2.0119	2.1948	2.2177	3.1527	3.3883
19	2.2862	2.4025	2.2177	2.652	2.9569	3.726	4.475
20	2.1948	2.2177	2.2177	2.5606	2.4025	3.5665	4.0208
21	2.1948	2.2177	2.0119	2.1948	2.2177	3.2564	3.6092
22	1.829	2.2177	2.0119		2.2177	3.1954	3.2152
23	1.829	2.0328	1.829		2.2177	3.0826	3.1779
24	1.829	1.829	1.848	1.9204		3.3098	2.9987
Max	2.9939	2.4025	2.9874	2.652	2.9569	3.8972	4.475
Min	1.7375	1.6461	1.8099	1.829	1.1888	.9412	2.7267
Avg	2.2001	2.0040	2.1896	2.0759	2.0886	3.1382	3.2335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 204 / 11 KV KHUDWAI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5804	2.5339	1.2936	1.2803		1.2936	1.2803
2	2.3556	2.521	1.2936			1.2936	1.2803
3	2.335	2.332	1.2936			1.2936	1.2803
4	2.3297	2.3297	1.2936			1.2936	1.2803
5	2.5066	1.0974	1.2936			1.2936	1.2936
6	3.0453	1.2803	1.4784			1.4784	1.4784
7	3.2941	1.5708	1.848			1.6632	1.7737
8	3.7475	1.7737	1.848			1.848	1.587
9	3.5993	1.587	1.9605	1.4937	1.7737	1.6804	1.6804
10	3.2854	1.4937	1.9404	1.4784	1.6632	1.4937	1.4784
11	2.9818	1.4003	1.9404	1.2803	1.386	1.2936	1.2936
12	2.737	1.307	1.8671	1.2803	1.386	1.2803	1.2936
13	2.6227	1.2803	1.848	1.0974	1.2803	1.2803	1.2936
14	2.3899	1.0974	1.829	1.0974	1.1888	1.0974	1.2936
15	2.1353	1.0974	1.0974	1.0974	1.086	1.0974	1.086
16	2.0987	1.0974	.905	1.0974	1.086		1.0974
17	2.1704	1.1888		1.2803	1.2936	1.267	1.2936
18	3.0666	1.6632	1.4632	1.5546	1.4784	1.4632	1.6632
19	3.5094	1.848	1.848	1.829	1.848	1.848	1.848
20	3.1825	1.6632	1.6632	1.6632	1.6632	1.6461	2.0328
21	3.0178	1.4784	1.3717	1.4632	1.4784	1.4632	1.4784
22	2.9317	1.4784	1.3717	1.4632	1.4784	1.4632	1.4632
23	2.6391	1.2936	1.2803		1.2936	1.3717	1.4632
24	2.5705	1.2803	1.2936	1.2803		1.2936	1.2803
Max	3.7475	2.5339	1.9605	1.829	1.848	1.848	2.0328
Min	2.0987	1.0974	.905	1.0974	1.086	1.0974	1.086
Avg	2.7972	1.5706	1.5357	1.3585	1.4256	1.4129	1.4289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 206 / 11 KV TOWER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5013	1.5546	1.5851	1.5775	1.5851	1.6004
2	1.4251	1.4098	1.4632	1.4784	1.4784	1.4708	1.5013
3	1.3794	1.3794	1.4175	1.4251	1.4251	1.4403	1.4632
4	1.3565	1.3717	1.4022	1.3946	1.4022	1.4251	1.4556
5	1.4098	1.4098	1.4708	1.4327	1.4403	1.4708	1.5013
6	1.6232	1.5775	1.7071	1.5699	1.608	1.6309	1.6994
7	1.7909	1.7604	1.9204	1.7452	1.8061	1.8595	1.9128
8	2.1338	2.0652	2.2634	2.0424	2.0271	2.1338	2.1491
9	2.271	2.2329	2.5377	2.1719	2.2558	2.2329	2.2634
10	2.2481	2.3091	2.4996	2.1872	2.3167	2.2253	2.2862
11	2.1795	2.0805	2.431	1.989	2.1262	2.0271	1.9966
12	2.0348	2.0119	2.3624	1.768	2.0195	1.9814	1.9966
13	1.9052	1.9585	2.3091	1.6766	1.9509	1.9585	2.0652
14	1.8595	1.89	2.1491	1.6156	1.8671	1.9281	1.989
15	1.7452	1.7375	1.7985	1.547	1.8747	1.8061	1.8366
16	1.6994	1.669	1.7528	1.7299	1.7985	1.7071	1.7985
17	1.669	1.7452	1.8061	1.8214	1.8519	1.8138	1.8214
18	1.8823	1.9738	1.9738	2.0119	2.0576	2.0652	1.9814
19	2.4387	2.5149	2.5072	2.5758	2.4691	2.6597	2.4539
20	2.5377	2.7359	2.6597	2.8502	2.553	2.8273	2.553
21	2.271	2.4234	2.4158	2.6216	2.3853	2.5758	2.3472
22	2.0043	2.0576	2.0805	2.1414	2.1033	2.1719	2.0348
23	1.7909	1.8595	1.8595	1.9204	1.89	1.9357	1.9281
24	1.6461	1.7071	1.6918	1.7375	1.7147	1.7375	1.7452
Max	2.5377	2.7359	2.6597	2.8502	2.553	2.8273	2.553
Min	1.3565	1.3717	1.4022	1.3946	1.4022	1.4251	1.4556
Avg	1.8677	1.8909	2.0014	1.8766	1.9166	1.9446	1.9325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 201 / 11 KV VISHNUPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.7468				.9145		.7545
6		1.1203	1.1317		1.0269		
7			1.1317			1.2071	
8	.8962	1.1576	1.0562	.8962		1.1317	.8215
10		.8299		.7682	1.0082	1.0456	
12				.7316	.7922		.7602
14				.6516		.8299	.7164
15		.8299					
16	.3582			.724	.679	.7762	.8505
17							.9391
18	.823						
19					1.1317		
20	1.0745						1.2178
22	.8238						1.0745
23		.8299		.8326	.8299		1.0745
24	.8299	.8954	.8299		.8326	.8299	.8299
Max	1.0745	1.1576	1.1317	.8962	1.1317	1.2071	1.2178
Min	.3582	.8299	.8299	.6516	.679	.7762	.7164
Avg	.7932	.9438	1.0374	.7674	.9019	.9701	.9039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 202 / 11 KV WAJEGAON (OLD
TUPPA) Feeder KV- 11 /
OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						***	***
2						***	***
3		.0046					
4	.1132	.0892			.128	***	***
5		.1212				***	***
6		.3533	.1886		.1307	.0354	.0114
7		.1635	.1886			***	***
8	.168	.4116	.1886	.1478		***	***
9		.1772				.1303	.1429
10		.3075			.112	***	***
11		.1623				***	***
12		.1623		.1463	.1509	.1543	.1553
13		.1509				***	***
14				.1267		***	***
15		.1623				.0332	
16	.1791	.0697		.1448	.1509	***	***
17		.1292				***	***
18	.1829	.1406				.0789	.0937
19		.1566		.1848	.1886	***	***
20	.197	.1589				***	***
21		.1383				.1235	.1303
22	.2149	.1337				***	***
23		.2915		.1267	.1509	***	***
24	.1132	.2637	.1509		.1267	.1635	.1315
Max	.2149	.4116	.1886	.1848	.1886	75.0653	75.0935
Min	.1132	.0046	.1509	.1267	.112	.0332	.0114
Avg	.1669	.1785	.1792	.1462	.1423	52.1759	54.5626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 203 / 11 KV BHAGYLAXMI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.0373				.0366		.0373
6		.0358	.0566		.0373		
7			.0377			.0377	
8	.0377	.0373	.0377	.0554		.0566	.056
10		.0377			.0373	.0373	
12				.0366	.0754		.0543
14				.0362		.0377	.0537
15		.0377					
16	.0537			.0362	.0377	.056	.0532
17							.0532
18	.0366						
19				.037	.0377		
20	.0358						.0537
22	.0358						.0537
23		.0566		.0543	.0377		.0537
24	.0373	.0358	.0566		.0543	.0377	.0377
Max	.0537	.0566	.0566	.0554	.0754	.0566	.056
Min	.0358	.0358	.0377	.0362	.0366	.0373	.0373
Avg	.0392	.0402	.0472	.0426	.0443	.0438	.0507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 204 / 11 KV CHOUPHALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974					1.1492	1.1888
2	1.0761					1.1172	1.1385
3	1.0715					1.1279	1.1629
4	2.3121				1.6095	1.1919	2.4005
5	1.3032					1.3489	1.4678
6	1.8458	1.8671	1.9993		1.7924	1.8549	1.9829
7	2.2192		2.2634			4.651	2.3213
8	1.7924	2.1472	2.3388	2.0698		4.686	4.1396
9						2.2923	2.242
10		1.6975			2.0165	3.8516	1.9113
11						1.6476	1.6613
12				1.4632	2.1125	1.358	2.6281
13						1.2254	1.2833
14				1.267		2.5072	2.3106
15		1.2449				1.1538	1.1645
16	.9671			1.086	1.2071	2.8883	2.1582
17						1.1965	2.4897
18	1.5546					1.5135	1.4464
19				1.6632	2.0748	2.0683	2.0088
20	1.7909					2.0027	3.7833
21						1.6613	1.6918
22	1.182					1.4617	2.9642
23		1.2449		1.267	1.2449	1.3321	2.7359
24	1.358	1.0745	1.1317		1.1765	2.4886	2.4325
Max	2.3121	2.1472	2.3388	2.0698	2.1125	4.686	4.1396
Min	.9671	1.0745	1.1317	1.086	1.1765	1.1172	1.1385
Avg	1.5054	1.5460	1.9333	1.4694	1.6543	1.9907	2.1131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 206 / 11 KV SHRINIWASA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4863	.4542					.4594
2	.4812	.458					.4715
3	.4719	.4774					.4634
4	.8566	.4647			.1829		.9073
5	.4808						.4682
6	.4869	.4668	.4527		.1867		.4785
7	.4971		.4527			.4904	.496
8	.8771	.4668	.4338	.4481		.4715	.9022
9	.4254						.4919
10	.4796	.4715		.439	.1494	.4481	.4789
11	.4842						.4858
12	.5234			.4344	.1509		.9086
13	.5081						.4915
14	.5087			.362		.4481	.8706
15	.5024	.3395					.4733
16	.8072			.1086	.1509	.4854	.9081
17	.4551						.9043
18	.9346						.4679
19	.4594			.1848	.1509		.4536
20	.9234						.8246
21	.4606						.4415
22	.8816						.8174
23	.4534	.4338		.181	.2263		.819
24	.8275	.4338	.4338		.2263	.3395	.9087
Max	.9346	.4774	.4527	.4481	.2263	.4904	.9087
Min	.4254	.3395	.4338	.1086	.1494	.3395	.4415
Avg	.5947	.4467	.4433	.3083	.1780	.4472	.6413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 207 / 11 Kv Water works
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4108				.439		.4481
6		.4108	.4527		.4854		
7			.4527			.4904	
8	.4481	.4481	.4527	.5281		.4904	.5281
10		.4527			.7095	.5228	
12				.5487	.7545		.7602
14				.5792		.5281	.788
15	.6089	.3772					
16				.9412	.8299	.5975	.8505
17							.8859
18	.5487						
19				.8501	.8299		
20	.5373						.5373
22	.394						.5014
23		.3772		.4344	.415		.4298
24	.4435	.394	.3734		.4344	.415	.4527
Max	.6089	.4527	.4527	.9412	.8299	.5975	.8859
Min	.394	.3772	.3734	.4344	.415	.415	.4298
Avg	.4845	.41	.4329	.6470	.6122	.5074	.6182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 201 / 11 KV NANAKSAR GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.3403	
9		.2402			
10				.2686	
12			.1612	.1791	
14	.1791				
18			.2058	.2987	
19				.3361	
21				.2614	
22			.168		
24	.2572		.1791	.1791	.1774
Max	.2572	.2402	.2058	.3403	.1774
Min	.1791	.2402	.1612	.1791	.1774
Avg	.2182	.2402	.1785	.2662	.1774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 202 / 11 KV VIDYAPEETH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.5014	
9		.4668			
10				.5731	
12			.5194	.591	
14	.5014				
18			.4108	.4152	
19				.5601	
21				.4108	
22			.3696		
24	.1029		.3224	.3045	.3944
Max	.5014	.4668	.5194	.591	.3944
Min	.1029	.4668	.3224	.3045	.3944
Avg	.3022	.4668	.4056	.4794	.3944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 203 / 11 KV GANGABET

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.6161			
10				.5731	
12			.4656	.4607	
14	.3224				
18				.4481	
19				.5975	
21				.4108	
22			.4066		
24	.1532		.5914	.2686	.3673
Max	.3224	.6161	.5914	.5975	.3673
Min	.1532	.6161	.4066	.2686	.3673
Avg	.2378	.6161	.4879	.4598	.3673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 204 / 11 KV PIMPALGAON

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-17	03-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
8			1.2715
10			1.3073
12		1.0387	
14	1.3073		
24	.0914	1.363	
Max	1.3073	1.363	1.3073
Min	.0914	1.0387	1.2715
Avg	.6994	1.2009	1.2894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 205 / 11 KV KALESHWAR AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-17	03-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
8			.5373
10			.5373
12		.4656	
14	.591		
24	.1067	.5041	
Max	.591	.5041	.5373
Min	.1067	.4656	.5373
Avg	.3489	.4849	.5373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 206 / 11 KV PANGRA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-17	06-MAR-17
HR	Load (MW)	Load (MW)
18		1.4045
24	.2915	
Max	.2915	1.4045
Min	.2915	1.4045
Avg	.2915	1.4045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 208 / 11 KV GODAWARI AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-17	03-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.5552	
12		.6268		
14	.7164			
24	.08			.607
Max	.7164	.6268	.5552	.607
Min	.08	.6268	.5552	.607
Avg	.3982	.6268	.5552	.607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 209 / 11 KV VISHNUPURI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.8596	
9		.7468			
10				.6447	
12			.4477	.4477	
14	.394				
18			.6161	.6348	
19				.8215	
21				.7468	
22			.5658		
24	.4687		.4656	.4835	.5676
Max	.4687	.7468	.6161	.8596	.5676
Min	.394	.7468	.4477	.4477	.5676
Avg	.4314	.7468	.5238	.6627	.5676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 201 / 11 kV NAGAPUR G

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.5902	.7095	.5601		.5228	.5601
2	.5601	.5613	.7468			.4481	.5601
3	.6722	.6361	.7484	.5601		.4854	.5975
4	.7545	.6361	.7842	.543		.5658	.7109
5	.9431	.7354	.8962	.9054		.7922	.7882
6	.7545	.7354		.9431		.9054	.898
7	.8676	.6735		.7545			1.0509
8	.8676	.5521	.8589	.7545	.9808	.7545	.9335
9	.5601		.8676	.8676		.6722	.7826
10		.6722	.8215	.865		.6722	.8935
11	.5239	.7858	.7762	.6653	.5601	.5975	.5926
12	.6722	.8257	.5975	.8834	.3734	.5647	.4755
13	.5601	.8215	.4458	.8291	.7468	.5647	.3578
14	.3734	.7468	.3734	.7133	.559	.5975	.3608
15	.5601	.5975		.753	.5217	.6722	.365
16	.8215	.5975	.6348	.8733	.7842	.7468	.6667
17		.7468	.7468	.9135	.8299	.9335	.7008
18	.9231	.8962	.9335	1.0542		1.0851	.5533
19	.9288	.9355	.8299	.8198	.9431	1.0456	.8207
20	.8089	.9008	.7095	.8198	.7922	.8962	.6674
21	.7339	.7882	.7545	.6225	.6413	.7906	.7015
22	.6986	.6735	.679		.6413	.6687	.551
23	.4399	.7109				.5944	.7015
24	.539	.6994	.7095	.5601	.4854	.5601	.5647
Max	.9431	.9355	.9335	1.0542	.9808	1.0851	1.0509
Min	.3734	.5521	.3734	.543	.3734	.4481	.3578
Avg	.6908	.7182	.7312	.7743	.6815	.7016	.6606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 202 / 11 kV PUNEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.4575	1.4758
2						1.6194	1.6557
3						1.6385	1.6615
4						1.6385	1.7856
5						1.6575	1.8394
6						1.8778	1.894
7						2.146	2.2335
8					2.4143	2.3472	.9625
9			3.2861		2.2779	2.3923	1.0241
10					2.1021	2.0933	1.6499
11	2.2805	1.7918	2.4143	2.487			
12	2.4306	2.3649	2.5484	2.2156			
13	2.3594	2.3977	2.4691	2.4701			
14	2.4306	2.476	2.3137	2.3896			
15	1.9707	2.6277		2.3923			
16	2.4419	2.5573	2.8045	2.4644			
17	2.7161	1.9707	2.5149	2.6825			
18	2.8166	1.9547	2.3472	2.1021			
Max	2.8166	2.6277	3.2861	2.6825	2.4143	2.3923	2.2335
Min	1.9707	1.7918	2.3137	2.1021	2.1021	1.4575	.9625
Avg	2.4308	2.2676	2.5873	2.4005	2.2648	1.8868	1.6182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 203 / 11 kV TUPPA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4478	2.9845	1.5721	2.1795			
2	2.4813	2.8778	1.7876	2.4006			
3	2.5774	3.2534	2.0129	2.4006			
4	2.6749	2.5767	2.193	2.4006			
5	2.7435	2.939	2.4588	2.572			
6	.6173	3.4606	3.2786	2.6406			
7	.25	3.4606	3.379	3.2602			
8	.2187	3.2731	3.2579	3.155			
9		2.8995					
10		2.8155	3.2579				
11					3.0552	3.2648	3.0624
12					3.3439	3.2312	3.2579
13					3.2579	3.3114	3.1965
14					2.3491	3.2579	2.9355
15					3.066	3.1927	2.9647
16					3.2846	3.2065	2.0525
17						3.4648	3.0008
18					3.2861	3.0218	3.066
22	2.3727						
23	2.8602						
24	2.2131	2.8277		2.1795			
Max	2.8602	3.4606	3.379	3.2602	3.3439	3.4648	3.2579
Min	.2187	2.5767	1.5721	2.1795	2.3491	3.0218	2.0525
Avg	1.9506	3.0335	2.5775	2.5765	3.0918	3.2439	2.9420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 204 / 11 kv New Wajegaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7514	.7438	.7545		.6036	.7468
2		.7529	.7468	.7545		.6036	.7468
3	.7545	.7906	.7826	.7545		.6036	.7842
4	.8299	.9778	.8232	.8676		.7545	.8215
5	.8676	1.2035	.9008	.9431		.8676	.9017
6	1.1317	1.3553	1.126	1.1317		1.1317	1.0134
7	1.358	1.4697	1.3845	1.4335		1.5466	1.2423
8	1.4712	1.4306	1.4306	1.3203	1.358	1.5466	1.2423
9	1.3567	1.3443	1.4712	1.358	1.531	1.2323	1.2787
10	1.1974	1.1974	1.4632	1.3553	1.126	1.1949	1.0552
11	1.1225	1.0829	1.3203	1.0154	1.1225	.9788	1.0541
12	1.0851	1.0918	1.2449	1.2398	.9335	.8962	1.0154
13	.9709	.9383	1.1317	1.2813	.7842	.898	.9412
14	.9335	.8215	.8299	1.2047	.6722	.8632	.9026
15	.8606	.7484		1.28	.8589	.9008	.7906
16	.8606	.7468	.8299	1.2023	.7468	.9758	1.0165
17	1.0541	.9729	1.1317	1.3176	.9431	1.0509	1.1283
18	1.3553	1.201	1.2071	1.5812	1.0562	1.1647	1.167
19	1.0918	1.3096	1.358	1.2411	1.358	1.3176	1.3176
20	.9788	1.16	1.1317	1.0918	1.0185	1.1647	1.28
21	.8659	1.0851	1.0185	.9798		.9355	.9136
22	.7906	.9355			.9054	.7842	.9412
23	.7537	.8232				.7842	.7906
24	.8299	.7499	.7468	.7922	.7922	.7922	.7858
Max	1.4712	1.4697	1.4712	1.5812	1.531	1.5466	1.3176
Min	.7537	.7468	.7438	.7545	.6722	.6036	.7468
Avg	1.0119	1.0392	1.0868	1.1318	1.0138	.9830	.9949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 205 / 11 kv Injegaon AG
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.9808	1.0165
2						1.094	1.0918
3						1.1317	1.0884
4						1.1317	1.1294
5						1.1317	1.358
6						1.1694	1.5089
7						1.5089	1.5844
8					1.8861	1.773	1.6975
9					1.92	1.8823	1.8052
10					1.807	1.807	1.7318
11	2.2212	1.8823	1.9993	2.1791			
12	2.2212	2.0329	2.5274	2.0664			
13	1.807	2.0329	2.3011	2.2189			
14	2.0706	2.0706		2.1082			
15	2.2257	2.0706		2.1393			
16	2.2257	2.1082	1.829	2.1791			
17	2.0685	2.0329	2.037	2.1082			
18	1.9912	1.9576	1.9993	1.8842			
24		1.9912					
Max	2.2257	2.1082	2.5274	2.2189	1.92	1.8823	1.8052
Min	1.807	1.8823	1.829	1.8842	1.807	.9808	1.0165
Avg	2.1039	2.0199	2.1155	2.1104	1.8710	1.3611	1.4012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 206 / 11Kv MARATHWADA EXPRESS SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0897	.055	.0754		.0754	.0821
2	.0754	.0897	.0547	.0754		.0777	.0821
3	.0754	.0896	.055	.0754		.0777	.0825
4	.0754	.0896	.055	.0754		.0518	.0825
5	.0754	.0896	.0553			.08	.0825
6	.1006	.0896	.055				.0821
7	.0777	.0896	.055	.0754		.0777	.0825
8	.1036	.1195	.0825	.1006	.088	.1097	.0825
9	.0825	.1438	.088	.1257	.085	.1134	.0898
10	.1692	.1742	.1467	.1792	.1703	.1425	.1797
11	.1719	.1651	.2054	.1496	.1719	.1651	.2396
12	.1926	.1942	.2378	.1494	.2006	.1942	.2396
13	.11	.1926	.2378	.1795	.2022	.1664	.239
14	.11	.1381	.1486	.1496	.1701	.1692	.1799
15	.1376	.1387		.1196	.171	.1926	.1799
16	.1387	.1084	.2378	.2393	.1438	.1669	.1797
17	.1795	.0817	.2054	.2393	.1486	.1926	.1799
18	.1195	.0547	.2054	.2685		.1674	.1496
19	.1792	.0543	.1692	.1795		.1642	.1797
20	.1195	.0546	.1372	.1788	.1334	.1376	.1497
21	.1196	.055	.08	.1196	.1036	.1376	.0898
22	.0896	.055	.08		.0777	.11	.1198
23	.0898	.055				.1105	.0898
24	.1006	.0897	.0547	.1006	.0754	.0754	.0825
Max	.1926	.1942	.2378	.2685	.2022	.1942	.2396
Min	.0754	.0543	.0547	.0754	.0754	.0518	.0821
Avg	.1154	.1043	.1228	.1428	.1387	.1285	.1345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 201 / 11 KV R.T.O.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6859	.5434	.8488	.6478	.6135	.7468
2	.6478	.6859	.5434	.8488	.6478	.6135	.724
3	.6478		.5434	.8488	.5716	.6135	.6859
4	.6478	.6478	.5434	.7762	.5716	.6135	.6859
5	.5487	.6478	.5434	.7762	.5525	.6135	.724
6	.5487	.6478	.5434	.6516	.5525	.6135	.8002
7	.5487	.7049	.5316	.583	.6097	.5487	.8002
8	.5487	.5716	.502	.5506	.6097	.9878	.811
9	1.1128	.5487	.9907	1.1506	.8962	.7621	1.0562
10	1.4335	.5487	1.5466	1.4146	1.1883	1.1431	1.3443
11	1.4523	.8299	1.6787	1.6244	1.5466	1.2003	1.5844
12	1.1317	.5731	1.4901	1.6448	1.7177	1.4523	1.5844
13	1.0903		1.7164	.9979	1.1203	.9526	1.358
14	1.1694		1.2003	1.0562	1.5497	1.2765	1.6244
15	1.7364	.6722	1.7541	1.3957	1.3443	1.7551	1.7541
16	1.829	.7468	1.773	1.1694	1.3443	1.6244	1.7353
17	1.6244	.7167	1.7372	1.2003	1.3256	1.6598	1.6787
18	1.6278	.6224	1.531	1.0098	1.2637	1.5844	1.5466
19	1.4712	.6535	1.4712	1.1506	1.1694	1.5684	1.4523
20	.8488	.5788	.9808	.724	1.094	1.0185	1.1694
21	.7167	.5788	.9431	.6859	.7468	.9054	1.0751
22	.6478	.567	.8488	.8573	.7316	.8488	.9808
23	.6668	.567	.8488	.724	.7316	.8676	1.0185
24	.7964		.567	.8488	.724	.7316	.7468
Max	1.829	.8299	1.773	1.6448	1.7177	1.7551	1.7541
Min	.5487	.5487	.502	.5506	.5525	.5487	.6859
Avg	1.0059	.6398	1.0572	.9808	.9691	1.0237	1.1536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 202 / 11 KV NANDED FLOOR MILL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.6668	.4858	.5668	.6859	.7095	.6478
2	.823	.6668	.4858	.5668	.6859	.7095	.6097
3	.823		.4858	.5668	.6859	.7095	.6668
4	.823	.6668	.4858	.5668	.6859	.7095	.7049
5	.823	.6859	.4858	.5668	.6668	.7095	.743
6	1.0631	.743	.7716	.8402	.8383	.7392	.8002
7	1.7177	1.4861	.7716	1.134	1.5242	.8299	1.448
8	1.8107	1.2193	1.1883	1.1088	1.4861	.9619	1.4523
9	1.9616	1.0349	1.3908	1.2637	1.5278	1.0098	1.5655
10	2.1879	1.1088	1.6975	1.5089	1.6598	1.2384	1.7353
11	2.0748	1.1203	1.6032	1.5089	1.7353	1.6221	1.7918
12	.9145	.7545	1.8861	1.5655	1.8484	1.7528	1.7737
13	1.8484		1.8107	1.6975	1.8861	1.5432	1.6632
14	1.5655		1.7528	1.4523	1.6598	1.5813	1.7353
15	1.9427	.2858	1.8673	1.7918	1.8484	1.5813	1.7353
16	1.6975	.3658	1.358	1.8296	1.6975	1.467	1.358
17	.8676	.4049	1.4523	1.3908	1.3203	1.1458	1.226
18	.7167	.4049	.8916	1.086	.961	.7049	.823
19	.7922	.4372	.5668	.7621	.5992	.6859	.5668
20	.6979	.4534	.5668	.6859	.5992	.6859	.5668
21	.679	.4372	.5668	.724	.5992	.724	.5992
22	.724	.4858	.5668	.743	.6154	.6478	.5668
23	.6668	.4858	.5668	.724	.5668	.6859	.6859
24	.823	.6668	.4858	.5668	.724	.7316	.6478
Max	2.1879	1.4861	1.8861	1.8296	1.8861	1.7528	1.7918
Min	.6668	.2858	.4858	.5668	.5668	.6478	.5668
Avg	1.2028	.6943	1.0079	1.0507	1.1295	.9953	1.0880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 203 / 11 KV GODAWARI DRUG

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.7095	.6722	.7545	.7282	.7095	.415
2	.5975	.7095	.6722	.7545	.7095	.7095	.6722
3	.5975	.7095	.6722	.7545	.7392	.7095	.6908
4	.5975	.7095	.7095	.7545	.7023	.7095	.6722
5	.5975	.7207	.6722	.7545	.7316	.7095	.6908
6	.6653	.7207	.6722	.695	.6722	.7392	.7095
7	.6036	.679	.6036	.6173	.6908	.7468	.7095
8	.6653	.6722	.6908	.6203	.7282	.7577	.6535
9	.6535	.5175	.6979	.6154	.6602	.7392	.695
10	.7316	.6036	.6413	.7164	.6722	.7095	.5601
11	.6413	.5175	.6224	.7701	.679	.7316	.415
12	.4904	.2241	.7282	.8048	.6602	.7468	.4435
13	.7095		.7468	.7468	.6722	.7392	.5121
14	.6535		.7095	.7095	.6161	.7392	.8029
15	.6036	.0533	.6602	.7468	.6224	.7207	.7392
16	.7762	.3018	.679	.7733	.7167	.7468	.7762
17	.7468	.6722	.7468	.7316	.7468	.7762	.7947
18	.7023	.6722	.7167	.695	.8299	.7577	.7842
19	.6535	.6348	.6722	.7316	.8131	.7316	.7499
20	.6348	.6348	.7167	.6535	.7316	.7468	.7316
21	.6653	.6535	.6859	.6722	.7133	.7207	.695
22	.6838	.6722	.7449	.6535	.7133	.6584	.7164
23	.6722	.6722	.6802	.6348	.7316	.5544	.6468
24	.6584	.6908	.6722	.6859	.7282	.7316	.3961
Max	.7762	.7207	.7468	.8048	.8299	.7762	.8029
Min	.4904	.0533	.6036	.6154	.6161	.5544	.3961
Avg	.6499	.5978	.6869	.7103	.7087	.7226	.6530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 201 / 11 kv ASARJAN GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696						
2	.1715						.1829
3	.2035						
4	.2058			.2103			.2172
5	.2743				.2241		
6	.2743						.3012
7	.3258					.3292	
8	.3086	.3224	.3224		.2896	.3109	.2658
9	.2926	.3258	.2743		.3109	.2658	.2507
10		.2743	.2743			.197	
11	.2058	.2378	.1886			.1646	
12	.1372	.2012	.1715			.1829	
13	.1696	.1829	.1526				
14	.1696	.1829	.1715				
15	.1696	.2012					
16	.1715	.2172				.2172	
17	.2543			.208			
18	.2543			.2481	.2715	.2561	
19	.2572			.3258			
20	.2713			.2926		.2926	
22						.2561	
24	.2035		.2012	.2402		.2195	
Max	.3258	.3258	.3224	.3258	.3109	.3292	.3012
Min	.1372	.1829	.1526	.208	.2241	.1646	.1829
Avg	.2245	.2384	.2196	.2542	.2740	.2447	.2436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 202 / 11 KV KOUTH GAUTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8478						
2	.8139						.7682
3	.823						
4	.9431			.8328			.8048
5	.9326				.8779		
6	1.0174						1.2178
7	1.166					1.3253	
8	1.1317	1.182	1.2178	1.2048	1.3169	1.2071	1.382
9		1.086	1.0974		1.2071	1.1104	1.182
10		1.0974	1.0288			1.0242	
11	.8817	.8779	.8573				
12	.7461	.7682	.8573				
13	.7202	.7316	.7545				
14	.6859	.6584	.6783				
15	.6783	.6219					
16	.6783						
17	.8478			.8505			
18	.9156			.9568	.9313	1.0136	
19	.8573			1.2048			
20	1.0288			1.2696		1.2437	
22						1.0608	
24	.8478		.8413	.9335		.8779	
Max	1.166	1.182	1.2178	1.2696	1.3169	1.3253	1.382
Min	.6783	.6219	.6783	.8328	.8779	.8779	.7682
Avg	.8718	.8779	.9166	1.0361	1.0833	1.1079	1.0710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 203 / 11 KV AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0339						
2	.0339						.2561
3	.0339						
4	.0343			.0886	.0549		.3224
6							.3544
7						.394	
8				.2743		.439	.4607
9						.439	.4477
10						.443	
11	.4409	.3841	.3601				
12	.5087	.4755	.4287				
13	.5256	.5121	.4239				
14	.5087	.4755	.2743				
15	.4239	.4755					
16	.4287	.4755					
17	.3944			.4075			
18	.3944		.4163	.3856	.4572	.0724	
19	.0514			.0532			
20	.0509			.0739		.0914	
22						.0732	
24	.0339		.0732	.0732		.0732	
Max	.5256	.5121	.4287	.4075	.4572	.443	.4607
Min	.0339	.3841	.0732	.0532	.0549	.0724	.2561
Avg	.2598	.4664	.3294	.1938	.2561	.2532	.3683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 177013 / 132 kV ELICHPUR

Feeder No / Name : 402 / 33 KV MAATASAB FEEDER
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	1.0974
Max	1.0974
Min	1.0974
Avg	1.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 177013 / 132 kV ELICHPUR

Feeder No / Name : 404 / 33 KV AMDURA FEEDER
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.5716
Max	.5716
Min	.5716
Avg	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 202 / 11 KV HUDCO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0364	.9069	1.0059	.9526	1.0593	.9526	1.0974
2	.9831	.8688	.9678	.9069	1.0212	.8993	1.0364
3	.9755	.8993	.9755	.9297	1.0136	.9297	1.0288
4	1.0059	.9831	1.0974	1.0136	1.1431	1.0136	1.1584
5	1.166	1.1888	1.2193	1.1279	1.2651	1.2193	1.2803
6	1.4327	1.5089	1.4708	1.5165	1.4784	1.6156	1.5318
7	1.7299	1.9128	1.8747	1.9509	1.6918	1.9128	1.7528
8	1.7756	1.8976	1.8214	1.9433	1.7909	1.8595	1.8214
9	1.6766	1.7071	1.8823	1.7299	1.8976	1.7528	1.6994
10	1.547	1.5775	1.6385	1.6232	1.7756	1.6309	1.5013
11	1.3032	1.2955	1.387	1.3641	1.4861	1.4251	1.326
12	1.1203	1.1355	1.166	1.1812	1.2727	1.2498	1.2117
13	1.0059	1.0669	1.0745	1.1126	1.166	1.1279	1.0669
14	.9678	1.0364	1.044	1.0364	1.1888	1.1126	1.1203
15	.9755	.945	.9983	1.0288	1.1126	1.0745	1.0898
16	.9755	.9145	.9602	.8459	1.0898	.9907	1.0593
17	1.044	.945	1.0517	.8688	1.1812	1.0364	1.1584
18	1.2346	1.1126	1.326	1.1965	1.3108	1.2193	1.2346
19	1.6461	1.5242	1.6309	1.4556	1.6309	1.4937	1.5851
20	1.6842	1.5775	1.6309	1.608	1.6385	1.5851	1.6918
21	1.3946	1.4556	1.4861	1.4327	1.4937	1.448	1.5546
22	1.2651	1.3108	1.2803	1.3184	1.3489	1.3413	1.3489
23	1.0898	1.2041	1.2269	1.2269	1.2803	1.2498	1.1431
24	.9831	1.0669	1.1203	1.1431	1.044	1.166	1.044
Max	1.7756	1.9128	1.8823	1.9509	1.8976	1.9128	1.8214
Min	.9678	.8688	.9602	.8459	1.0136	.8993	1.0288
Avg	1.2508	1.2517	1.3057	1.2714	1.3492	1.3044	1.3143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 204 / 11 KV OSMANNAGAR(Kiwala)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.1562
Max	.1562
Min	.1562
Avg	.1562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 205 / 11 KV KOHINOOR Exp
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.0934
Max	.0934
Min	.0934
Avg	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 207 / 11 KV GOPALCHAWDI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.1334
Max	.1334
Min	.1334
Avg	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 208 / 11 KV SHIVA PARVATI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17
HR	Load (MW)
24	.2401
Max	.2401
Min	.2401
Avg	.2401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 209 / 11 KV CIDCO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.3489	1.3565
2	1.2269	1.2879	1.2955
3	1.2041	1.2727	1.2803
4	1.1965	1.2879	1.2803
5	1.3032	1.3946	1.3717
6		1.6309	1.608
7		2.0195	2.0195
8		2.0348	2.0576
9		1.8976	1.9052
10		1.6613	1.7452
11		1.448	1.5394
12		1.387	1.4861
13		1.2574	1.4098
14		1.2346	1.3717
15		1.2346	1.3108
16		1.2498	1.3184
17		1.2803	1.3565
18		1.4251	1.4175
19		1.8366	1.9052
20		1.9662	2.0271
21		1.8671	1.9585
22		1.7985	1.829
23		1.6309	1.6613
24		1.4632	1.4861
Max	1.3108	2.0348	2.0576
Min	1.1965	1.2346	1.2803
Avg	1.2483	1.5381	1.5832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 405 / 33 KV CRC (220 KV
WAGHALA Feeder KV- 33 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.1143
Max	.1143
Min	.1143
Avg	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 407 / 33 KV MEDICAL COLLEGE
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	.2286
Max	.2286
Min	.2286
Avg	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 178003 / 220 kV WAGHALA

Feeder No / Name : 702 / 132KV VISHNUPURI 2 FEEDER NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 132 / OUTGOING (NON CONTINOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17
HR	Load (MW)
24	3.658
Max	3.658
Min	3.658
Avg	3.658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 201 / 11 KV REST HOUSE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.2136	1.4146	1.4146	1.4003	1.4937	
2	1.2012	1.2136	1.3203	1.3203	1.307	1.4003	
3	1.2012	1.2136	1.3203	1.3203	1.307	1.4003	
4	1.2012	1.226	1.4146	1.4146	1.4003	1.4937	
5	1.2012	1.307	1.5089	1.5089	.0163	1.587	
6	1.4784	1.4937	1.6032	1.6032	1.4937	1.6804	
7	1.6632	1.6804	1.6975	1.6975	1.4937	1.6804	
8	1.587	1.587	1.6975	1.587	1.587	1.6804	
9	1.6804	1.4937	1.6032	1.587	1.587	1.6804	
10	1.4937	1.4146	1.4937	1.5089	1.9605	1.6804	
11	1.4937	1.226		1.5089	1.587	1.4146	1.6804
12	1.4003	1.1317	1.4003	1.3203	1.307	1.3203	1.587
13	1.307	1.226	1.307	1.3203	1.307	1.3203	1.4003
14	1.2936	1.1317	1.2136	1.3203	1.307	1.3203	1.4937
15	1.2936	1.1317	1.2136	1.3203	1.2136	1.3203	1.1203
16	1.307	1.226	1.307	1.5089	1.2136	1.3203	1.0269
17	1.386	1.226	1.307	1.6975	1.307	1.3203	1.1203
18	1.4937	1.3203	1.4003	1.6975	1.307	1.3203	1.4937
19	1.7737	1.6032	1.6804	1.6975	1.4937	1.6975	1.8671
20	1.7737	1.5089	1.6804	1.6975	1.4937	1.6975	1.7737
21	1.587	1.5089	1.587	1.6975	1.4937		1.6804
22	1.4937	1.5089	1.4937	1.6975	1.4937		1.587
23	1.4003	1.6032	1.4003		1.4937		1.4937
24	1.4937	1.307	1.5089	1.4146	1.4937	1.587	
Max	1.7737	1.6804	1.6975	1.6975	1.9605	1.6975	1.8671
Min	1.2012	1.1317	1.2136	1.3203	.0163	1.3203	1.0269
Avg	1.4374	1.3543	1.4597	1.5157	1.3777	1.4960	1.4865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 202 / 11 KV STADIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.7468	.7545	.7545	.7468	.8402	
2	.7392	.7468	.7545	.7545	.6535	.7468	
3	.7392	.7545	.7545	.7545	.6535	.7468	
4	.7392	.8402	.8488	.8488	.7468	.7468	
5	.7392	.9335	.9431	.9431	.8402	.9335	
6	.8316	1.0269	.9431	.9431	.8402	1.0269	
7	.924	1.0269	.9431	.9431	.8402	1.1203	
8	1.1203	1.0269	1.226	.9431	1.1203	1.1203	
9	1.2136	.9335	1.0374	.9431	1.1203	1.1203	
10	1.0269	.9431	1.0269	.9431	1.2136	.9335	1.0269
11	.9335	.9431		.9431	.9335	.8488	.9335
12	.8402	.8488	.9335	.9431	.8402	.7545	.9335
13	.7468	.8488	.8488	.8488	.8402	.7545	.9335
14	.7468	.8488	.8488	.8488	.7468	.7545	.9335
15	.7468	.8488	.7468	.8488	.7468	.7545	.8402
16	.7468	.8488	.7468	.9431	.7468	.8488	.7468
17	.7468	.9431	.8402	.9431	.8402	.8488	.8402
18	.7468	.9431	.9335	1.3203	.9335	.9431	.9335
19	1.1203	1.226	1.2136	1.3203	1.1203	1.1317	1.1203
20	1.2136	1.1317	1.2136	1.226	1.1203	1.1317	1.1203
21	1.1203	1.0374	1.1203	1.0374	1.1203		1.0269
22	1.0269	.9431	1.1203	.9431	1.1203	.9335	1.0269
23	.9335	.9431	.9335		.9335	.9335	.9335
24		.8488	.8488	.8488	.8402	.9335	
Max	1.2136	1.226	1.226	1.3203	1.2136	1.1317	1.1203
Min	.7392	.7468	.7468	.7545	.6535	.7468	.7468
Avg	.8905	.9243	.9383	.9472	.9024	.9090	.9535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 203 / 11 KV NAGARJUNA HOTEL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.431	1.307	1.226	1.226	1.2136	1.307	1.39
2	2.4005	1.2136	1.226	1.226	1.2136	1.2136	1.3481
3	1.1088	1.226	1.226	1.226	1.2136	1.2136	1.3481
4	1.1088	1.4003	1.3203	1.4146	1.307	1.4003	1.3496
5		1.587	1.4146	1.6032	1.4003	1.587	1.464
6		1.8671	1.5089	1.7918	1.587	1.7737	1.7718
7	1.6632	1.9605	1.7918	1.9805	1.7737	1.8671	2.0302
8	1.6632	1.8671	1.8861	1.9805	1.8671	2.0538	2.0599
9	1.587	1.6804	1.7918	1.9805	1.8671	1.9605	1.9662
10	1.307	1.5089	1.587	1.7918	1.9605	1.4937	3.3344
11	1.2136	1.226		1.2136	1.6804	1.3203	2.7088
12	1.1088	1.1317	1.307	1.2136	1.2136	1.226	2.54
13	.9335	.9431	1.1203	1.226	1.1203	1.0374	2.1799
14	.924	.8488	.9335	1.1317	1.0269	1.0374	2.2688
15	.9335	.8488	.9335	1.1317	1.1203	.9431	2.2051
16	.9335		.9335	1.226	1.2136	.9431	2.1807
17	1.0269	.9431	1.1203	1.5089	1.307	.9431	2.297
18	1.1088	1.226	1.4003	1.6975	1.587	1.3203	2.945
19	1.8671	1.6032	1.6804	1.6032	2.0538	1.6975	3.829
20	1.7737	1.5089	1.8671	1.4146	1.8671	1.6032	3.5768
21	1.6804	1.4146	1.6804	1.3203	1.6804		3.2991
22	1.587	1.3203	1.587	1.3203	1.4937		3.1688
23	1.4003	1.3203	1.307		1.4937		2.8982
24	1.1203	1.3203	1.226	1.3203	1.2136	1.307	1.4868
Max	2.431	1.9605	1.8861	1.9805	2.0538	2.0538	3.829
Min	.924	.8488	.9335	1.1317	1.0269	.9431	1.3481
Avg	1.4037	1.3597	1.3946	1.4586	1.4781	1.3928	2.3186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 204 / 11 KV DATTA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7918	1.7918	1.6975	1.7737	1.8671	1.8671
2	1.6632	1.6804	1.6975	1.6975	1.6804	1.6804	
3	1.6632	1.6975	1.6975	1.6975	1.6804	1.6804	
4	1.6632	1.7918	1.7918	1.8861		1.8671	
5	1.6632	1.9605	1.8861	2.0748		2.0538	
6	2.1253	2.1691	1.9805	2.2634	1.7737	2.2405	
7	2.3101	2.3339	2.1691	2.452	2.1472	2.4272	
8	2.2405	2.3577	2.5463	2.452	2.4272	2.5206	
9	2.3339	2.2405	2.3577	2.452	2.4272	2.3339	
10	1.9605	1.9805	2.1472	2.0748	2.0538	1.9605	2.0538
11	2.0538	1.7918		1.9805	1.8671	1.8861	1.9605
12	1.8671	1.6975	1.8671	1.8861	1.8671	1.7918	1.9605
13	1.6804	1.6975	1.7737	1.7918	1.7737	1.7918	1.9605
14	1.7556	1.6975	1.7737	1.7918	1.6804	1.7918	1.8671
15	1.6804	1.6975	1.7737	1.7918	1.6804	1.7918	1.8671
16	1.6804	1.6975	1.7737	1.7918	1.6804	1.8861	1.8671
17	1.8671	1.7918	1.8671	2.0748	1.6804	1.8861	2.0538
18	1.9605	1.8861	1.9605	2.452	1.8671	1.8861	2.1472
19	2.7349	2.5463	2.7073	2.452	2.7073	2.3577	2.894
20	2.5206	2.452	2.6139	2.452	2.5206	2.5463	2.6139
21	2.3339	2.452	2.4272	2.3577	2.3577	2.452	2.4272
22	2.2634	2.2634	2.2405	2.2634	2.2405	2.2405	2.3339
23	2.0538	2.0748	2.1472		2.0538	2.1472	2.1472
24	1.8671	1.8861	1.9805	1.8861	1.8671	1.9605	1.9605
Max	2.7349	2.5463	2.7073	2.452	2.7073	2.5463	2.894
Min	1.6632	1.6804	1.6975	1.6975	1.6804	1.6804	1.8671
Avg	1.9975	1.9848	2.0422	2.0748	1.9912	2.0436	2.1238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 201 / 11 KV RLY DIVISION

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0754	.0934	.0943	.0754	.0732
2	.0754	.0754	.0754	.0914	.0943	.0754	.0732
3	.0754	.0655	.0754	.0886	.0943		.0732
4	.0943	.0754	.0754	.0886	.0943	.0754	.0732
5	.0943	.0943	.0754	.0914	.0943	.0943	.0732
6	.1132	.0943	.0943		.1132	.1132	.1097
7	.132	.0943	.0943	.0914	.1132	.1132	.1097
8	.132	.132	.1132	.0863	.132	.132	.1097
9	.1132	.132	.132	.0943	.132	.132	.128
10	.132	.1463	.132		.1132	.1509	.1698
11	.132	.1463	.132		.132	.1698	.1509
12	.132	.1463	.1509		.132	.1698	.1509
13	.132	.1463	.1509		.132	.1698	.1509
14	.132	.1463	.1509		.1132	.1698	.132
15	.132	.1463	.132		.1132	.1698	.132
16	.1132	.1463	.132		.132	.1698	.1509
17	.1132	.1509	.1208	.1132	.1132	.128	.132
18	.132	.1132	.1208	.1132	.1132	.128	.132
19	.1509	.1132	.1208	.12	.1132	.128	.132
20	.132	.1132	.1208	.132	.1132	.128	.132
21	.132	.1132	.1036	.132	.1132	.128	.132
22	.132	.1132	.0914	.132	.0943	.1097	.132
23	.1132	.0943	.0914	.1132	.0943		.0914
24	.0943	.0943	.0754	.0914	.1132	.0754	.1509
Max	.1509	.1509	.1509	.132	.132	.1698	.1698
Min	.0754	.0655	.0754	.0863	.0943	.0754	.0732
Avg	.1171	.1153	.1099	.1045	.1124	.1275	.1206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 202 / 11 KV CHAITNYA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1984	1.2289	1.1797	1.4003	1.1984	1.2574	1.3717
2	1.1984	1.2289	1.1797	1.4003	1.1336	1.2574	1.3717
3	1.2631	1.2289	1.2125	1.3575	1.1336	1.2574	1.3717
4	1.2955	1.3108	1.2125	1.3717	1.1336	1.3413	1.3717
5	1.5546	1.4746	1.1469	1.3575	1.1336	1.5089	1.3717
6	1.6842	1.5565	1.4746	1.6804	1.3279	1.5927	2.0119
7	1.9109	1.6385	1.6385	2.1948	1.5546	1.6766	2.3777
8	1.9757	1.8023	1.7204	2.0713	1.9109	1.7004	2.3777
9	1.749	1.6385	1.8107		1.8138	1.6385	1.9204
10	1.4403	1.6461	1.6518		1.6842	1.4575	1.5424
11	1.3603	1.5061	1.4251		1.4899	1.2955	1.3748
12	1.2003	1.2803	1.3603		1.4575	1.2631	1.2574
13	1.1203	1.1888	1.2955		1.2955	1.2631	1.2574
14	1.0402	1.1888	1.2308		1.2308	1.1984	1.2574
15	1.0898	1.1888	1.1174		1.1984	1.166	1.1736
16	1.0898	1.1888	1.1012		1.2308	1.166	1.0898
17	1.1142	1.1142	1.2083	1.166	1.1797	1.3717	1.2071
18	1.1797	1.3435	1.4672	1.2955	1.2452	1.6461	1.6598
19	1.6385	1.5565	1.6398	1.7166	1.7204	1.7375	1.7604
20	1.6385	1.6385	1.6398	1.6518	1.6385	1.7375	1.6766
21	1.5565	1.4746	1.6398	1.5708	1.5565	1.7375	1.643
22	1.4746	1.3927	1.7375	1.5061	1.4746	1.7375	1.5089
23	1.2289	1.3108	1.3717	1.4251	1.3108		1.5546
24	1.247	1.2289	1.2289	1.3717	1.3441	1.2289	1.4632
Max	1.9757	1.8023	1.8107	2.1948	1.9109	1.7375	2.3777
Min	1.0402	1.1142	1.1012	1.166	1.1336	1.166	1.0898
Avg	1.3854	1.3898	1.4038	1.5336	1.3915	1.4451	1.5405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 203 / 11 KV MAHALAJ - SANGVI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5752	.7682	.7316	.823	.7682	.7316	1.627
2	1.5585	.7682	.7316	.8265	.7682	.7316	1.5966
3	1.5981	.823	.7682	.8402	.7682	.7682	1.5996
4	1.7429	1.0059	.7682	.823	.7682	.7682	2.3579
5	2.0004	1.0059	.9511	.823	.9145	1.0059	1.7817
6	2.3823	1.1888	1.0974	1.3717	1.134	1.2803	2.5717
7	3.0628	1.3717	1.3717	1.5546	1.4632	1.5546	3.2449
8	3.293	1.4266	1.4632	2.6663	1.4632	1.4998	3.2579
9	3.0079	1.3169	1.2803		1.3535	1.5546	3.0399
10	2.6627	1.1203	1.134		1.2803	1.0974	2.508
11	2.0691	.7316	.7316			1.0608	2.0881
12	2.047	.7316	.9145		1.0974	.8048	2.0714
13	1.7573	.6401	.8413		.9511	.7682	1.8251
14	1.5684	.6535	.8048		.7682	.7316	1.5577
15	1.6979	.6401	.7316		.7682	.7316	1.701
16	1.5562	.503	.7316		.9511	.7316	1.7405
17	1.7299	.823	.7316	.9145	.823	.7316	1.8961
18	1.0059	1.0059	.9145	1.0974	.8779	1.1888	2.1795
19	1.2803	1.3717	.8631	1.2803	1.3717	1.1888	3.0003
20	1.2071	1.1888	.8631	1.1706	1.2803	1.0974	2.6802
21	1.0974	1.0974	.9145	1.0974	1.1888	1.0974	2.3068
22	1.0608	.9145	.9145	.9328	1.0974	1.0059	2.3213
23	.9145	.823	.823	.8413	.9145		1.8434
24	1.4907	.823	.7682	.823	.8048	.823	1.7367
Max	3.293	1.4266	1.4632	2.6663	1.4632	1.5546	3.2579
Min	.9145	.503	.7316	.823	.7682	.7316	1.5577
Avg	1.8069	.9476	.9102	1.1179	1.0250	.9980	2.1889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 205 / 11 KV AIRPORT

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0076	.0095	.0141	.0343	.0107	.0264
2	.0343	.0076	.0095	.0141	.0343	.0114	.0264
3	.0343	.0076	.0095	.0141	.0343	.0114	.0266
4	.0343	.0076	.0095	.0141	.0343	.0114	.0366
5	.0343	.0076	.0095	.0141	.0343	.0114	.0266
6	.0343	.0076	.0095	.0141	.0343	.0114	.0266
7	.0343	.0095	.0095	.0141	.0343	.0114	.0266
8	.0343	.0095	.0095		.0343	.0095	.0366
9	.0343	.0095	.0076		.0343	.0095	.0266
10	.0095	.0141	.0343		.0343	.0343	.0107
11	.0095	.0141	.0343		.0343	.0343	.0095
12	.0095	.0141	.0343		.0343	.0343	.0362
13	.0095	.0141	.0343		.0343	.0343	.0362
14	.0095	.0141	.0343		.0343	.0343	.0362
15	.0095	.0141	.0343		.0343	.0343	.0095
16	.0095	.0141	.0343		.0343	.0343	.0095
17	.0095	.0095	.0141	.0343	.0095	.0141	.0095
18	.0095	.0095	.0141	.0343	.0095	.0141	.0095
19	.0095	.0095	.0141	.0343	.0095	.0141	.0095
20	.0095	.0143	.0141	.0343	.0095	.0141	.0095
21	.0095	.0143	.0141	.0343	.0095	.0141	.0095
22	.0095	.0095	.0141	.0343	.0095	.0141	.0095
23	.0076	.0095	.0141	.0343	.0095		.0266
24	.0343	.0076	.0095	.0141	.0343	.0076	.0141
Max	.0343	.0143	.0343	.0343	.0343	.0343	.0366
Min	.0076	.0076	.0076	.0141	.0095	.0076	.0095
Avg	.0198	.0107	.0180	.0235	.0271	.0187	.0210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 206 / 11KV GADEGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1406	.2152
2						.1482	.2354
3						.1783	.2297
4						.1928	.2495
5						.2229	.3201
6						.2267	.3338
7						.2439	.4013
8	.1494					.3052	.4413
9						.3105	.5643
10						.3917	.3814
11	.1524	.2561	.2054		.2427	.1673	.1699
12	.2286	.2561	.2987		.2801		
13	.2286	.2926	.2987		.2801		
14	.1372	.2926	.3174		.2614		
15	.2286	.2987	.2801		.2614		
16	.2286	.2926	.2801		.2614		
17	.2286	.2591	.2743	.2054	.1677		
18	.2286	.2286	.1829	.2054	.1677		
22		1.2193					
Max	.2286	1.2193	.3174	.2054	.2801	.3917	.5643
Min	.1372	.2286	.1829	.2054	.1677	.1406	.1699
Avg	.2012	.3773	.2672	.2054	.2403	.2298	.3220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 207 / 11Kv Asana River Express NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0362	.0362	.0366	.0362	.0362	.0366
2	.0362	.0362	.0362	.0373	.0362	.0362	.0366
3	.0362	.0362	.0362	.0366	.0362	.0362	.0366
4	.0362	.0362	.0362	.0366	.0362	.0362	.0366
5	.0362	.0362	.0362	.0366	.0362	.0362	.0366
6	.0362	.0362	.0362	.0366	.0362	.0362	.0366
7	.0362	.0362	.0362	.0366	.0362	.0362	.0366
8	.0362	.0362	.0362	.0345	.0362	.0362	.0366
9	.0362	.0362	.0362		.0362	.0362	.0366
10	.0362	.0366	.0362		.0362	.0362	.0362
11	.0362		.0362		.0362	.0362	.0362
12	.0362	.0366	.0362		.0362	.0362	.0362
13	.0362	.0366	.0362		.0362	.0362	.0362
14	.0362	.0366	.0362		.0362	.0362	.0362
15	.0362	.0366	.0362		.0362	.0362	.0362
16	.0362	.0366	.0362		.0362	.0362	.0362
17	.0362	.0362	.0366	.0362	.0362	.0366	.0362
18	.0362	.0362	.0366	.0362	.0362	.0366	.0362
19	.0362	.0362	.0345	.0362	.0362	.0366	.0362
20	.0362	.0362	.0345	.0362	.0362	.0366	.0362
21	.0362	.0362	.0345	.0362	.0362	.0366	.0362
22	.0362		.0366	.0362	.0362	.0366	.0362
23	.0362		.0366	.0362	.0362		.0366
24	.0362	.0362	.0362	.0366	.0362	.0362	.0366
Max	.0362	.0366	.0366	.0373	.0362	.0366	.0366
Min	.0362	.0362	.0345	.0345	.0362	.0362	.0362
Avg	.0362	.0363	.0361	.0363	.0362	.0363	.0364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 201 / 11 KV MAHAVEER SOCIETY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.181	.1829	.2743	.181	.1867
2	.1848	.1848	.181	.1829	.2743	.181	.1867
3	.1848	.1848	.181	.1829	.2743	.181	.1848
4	.1848	.1848	.181	.1829	.2743	.181	.1848
5	.1848	.1848	.1848	.1848	.2743	.2772	.1848
6	.2801	.3734	.3734	.1867	.2772	.4668	.2801
7	.4668	.5601	.4715	.5601	.3734	.5601	.3734
8	.5601	.4668	.5658	.5601	.4668	.5658	.4668
9	.5601	.5601	.6602	.5601	.5601	.5658	.5601
10	.3734	.4668	.6602	.5601	.5601	.4668	.5601
11	.5601	.3734	.6535		.5487	.3734	.4668
12		.3734	.5601	.3734	.5601	.3734	.3734
13	.3734		.4668		.5601	.3734	.3734
14	.2801	.2801	.3734	.3048	.3734	.3734	.3734
15	.2801	.2801	.3734		.3734	.3734	.3734
16	.2801	.2801	.3734	.3734	.3734	.7468	.3734
17	.3734	.4668	.3734	.4715	.3734	.3734	.3734
18	.4668	.5601	.5601	.5658	.5544	.462	.5601
19	.5601	.5601	.462	.5658	.5544	.5544	.5601
20	.4668	.5601	.5544	.4668	.5544	.4668	.4668
21	.3734	.3696	.3696	.3734	.3696	.2801	.3734
22	.3696	.3734	.3734	.3696	.2743	.2801	.3734
23	.2772	.2715	.3658	.2772	.2715	.2801	.2772
24	.2801	.2772	.181	.2743	.2772	.181	.1867
Max	.5601	.5601	.6602	.5658	.5601	.7468	.5601
Min	.1848	.1848	.181	.1829	.2715	.181	.1848
Avg	.3524	.3642	.4033	.3695	.4011	.3799	.3614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 202 / 11 KV SHIVAJI NAGAR ROAD SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6468	.724	.7316	.6401	.724	.724
2	.6401	.6468	.724	.7316	.6401	.724	.724
3	.6401	.6468	.724	.7316	.6401	.724	.724
4	.6401	.6468	.724	.7316	.6401	.7392	.7316
5	.6401	.6468	.7468	.7316	.6401	.8402	.7468
6	.6468	.7468	.9431	.7392	.7392	.9335	.7468
7	.9335	1.1203	.9431	1.0164	.7468	1.3203	.8488
8	.9335	1.1203	1.1317	1.0269	.9335	1.226	.9335
9	.9335	.9335	1.1317	1.0269	.9335	.9431	.9335
10	.8402	.9335	.9335	.8402	.9335	.8402	.9335
11	1.0374		.8402	1.0269	.9335	.9335	.9335
12		.9335	.9431	.9335	.8402	.9335	1.0269
13	.8402		.9335	.9335	.8402	.9335	1.0269
14	.8402	.8402	.9335	.8402	.8402	.8402	
15	.8402	.8402	.8402	.8316	.7468	.9335	.9335
16	.8402	.8402	.8402	.9335	.7468	.9335	.9335
17	1.8298	.9335	.8402	1.0269	.7392	.924	1.0269
18	.9335	1.1088	1.0164	1.1203	.924	1.1088	1.1203
19	1.1203	1.307	1.2012	1.3203	1.1203	1.226	1.307
20	1.1203	1.307	1.1088	1.1203	1.1203	1.1088	1.1203
21	1.0269	1.1203	1.0059	1.0269	.924	1.0164	1.0269
22	.924	.924	.9145	.924	.924	.9145	.9335
23	.7392	.924	.823	.8316	.8316	.823	.8402
24	.7316	.7392	.8145	.8402	.7392	.724	.8145
Max	1.8298	1.307	1.2012	1.3203	1.1203	1.3203	1.307
Min	.6401	.6468	.724	.7316	.6401	.724	.724
Avg	.8831	.9048	.9075	.9174	.8232	.9320	.9170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 203 / 11 KV INDUSTRIAL AREA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.7438	.3239	.381	.3048	.3353	.4001
2	.3048	.7316	.3239	.381	.3048	.3353	.4001
3	.3048	.7026	.3239	.381	.3048	.3353	.4001
4	.3048	.727	.3239	.381	.3048	.3239	.4001
5	.3048	.7186	.3315	.381	.3048	.3239	.4001
6	.3953	.7384	.4144	.3858	.3953	.4049	.3906
7	.4001	.7972	.4858	.3953	.3906	.4973	.4049
8	.4144	.9251	.4973	.4049	.4049	.5201	.5087
9	.503	.9776	.4191	.4572	.4287	.4477	.5487
10	.5601	1.0722	.4572	.5601	.4572	.5487	.5487
11	.7468	.6272	.6535	.5601	.5544	.7468	.5544
12		1.3866	.7468	.6535	.5601	.8488	.8402
13		.7773	.7468	.7468	.5601	.8488	.8402
14	.7468	1.4822	.8402	.7468	.5601	.7468	.7468
15	.7468	1.4891	.5601	.7468	.6535	.8402	.8402
16	.7468	1.4392	.5601	.7468	.7468	.8402	.8402
17	.7468	1.5288	.7468	.7545	.5658	.7545	.7468
18	.7468	1.3933	.7545	.7545	.5601	.7545	.7468
19	.7468	1.3356	.7545	.6602	.5544	.7545	.7468
20	.6535	1.3041	.6535	.6468	.5544	.066	.6535
21	.5487	1.1217	.5201	.543	.5487	.5544	.5544
22	.4572	.9755	.4334	.4334	.5487	.5316	.4572
23	.3353	.8816	.3953	.4191	.4334	.4287	.4382
24	.3163	.7895	.3239	.3858	.3048	.3429	.4191
Max	.7468	1.5288	.8402	.7545	.7468	.8488	.8402
Min	.3048	.6272	.3239	.381	.3048	.066	.3906
Avg	.5153	1.0277	.5246	.5378	.4711	.5471	.5761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 204 / I.T.M. Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3696	.362	.4572	.4572	.4525	.4525
2	.3658	.3696	.362	.4572		.4525	.4572
3	.3658	.3696	.362	.4572	.4572	.462	.4572
4	.3658	.3696	.362	.4572	.4572	.462	.4572
5	.3658	.3696	.3696	.4572	.4572	.4668	.4572
6	.4668	.3696	.4668	.4668	.462	.4715	.4668
7	.4668	.6535	.5544	.5601	.5601	.6535	.5658
8	.5544	.5601	.5601	.5601	.5601	.5601	.5601
9	.5544	.5601	.5601	.5601	.5601	.5601	.6535
10	.5601	.5601	.5601	.6535	.5601	.6602	.6535
11	.7468	.5601	.7468	.6535	.5601	.6535	.5601
12	.7468	.5601	.7468		.5601	.6535	.7468
13	.6535		.7468		.5601	.6535	.7468
14	.6535	.6535	.7468	.7468	.6535	.7468	.3734
15	.6535	.5601	.7468		.5601	.7468	.7468
16	.6535	.5601	.7468	.8402	.5601	.7468	.7468
17	.6535	.6535	.7468	.6535	.6535	.6468	.7468
18	.6535	.6535	.6335	.6535	.6268	.6468	.6535
19	.7468	.7392	.7392	.7468	.7316	.7392	.7468
20	.7468	.7392	.6535	.7468	.6401	.6468	.7468
21	.6535	.6468	.6468	.6535	.5487	.6468	.6535
22	.5544	.6468	.5544	.6468	.5487	.6401	.5601
23	.462	.543	.4572	.462	.4572		.5601
24	.4572	.3696	.362	.4572	.462	.4525	.4525
Max	.7468	.7392	.7468	.8402	.7316	.7468	.7468
Min	.3658	.3696	.362	.4572	.4572	.4525	.3734
Avg	.5611	.5407	.5747	.5880	.5502	.6009	.5926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 202 / 11 KV NASARADPURA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3018	.3292		.2614	.2987	.3292
2		.2987	.3292		.2427	.2987	.3292
3		.2987	.3292		.2427	.2987	.3292
4		.3395	.3658		.2614	.3734	.3658
5		.3772	.439		.3361	.4108	.439
6		.4108	.4207		.3734	.4108	.4755
7		.4527	.4755		.4294	.4481	.3658
8		.4854	.5487		.4481	.4481	.4755
9		.4481	.5487		.4481	.4294	.5487
10		.4481	.4572	.4755	.4108	.4024	
11	.4481	.4108			.3734	.4024	
12	.4481	.439			.3361	.3658	
13	.4108	.439		.4024	.3734	.3658	
14	.4108	.439		.3658	.4108	.3292	
15	.3734	.4024		.3658	.4108	.3841	
16	.3772	.4024		.4024	.4108	.4024	.4572
17	.4481	.4024		.4755	.4854	.439	.5121
18	.4854	.439		.5121	.5228	.4755	.5121
19	.5281	.4755		.567	.6161	.5487	.5121
20	.4481	.439		1.0909	.5975	.6219	.4961
21	.3921	.4024		.9983	.5228	.5487	.4755
22	.3734	.439		.415	.4481	.439	.4024
23	.2987	.4024		.3734	.3734	.3658	.3658
24	.3429	.2987	.3658		.2987	.3361	.3658
Max	.5281	.4854	.5487	1.0909	.6161	.6219	.5487
Min	.2987	.2987	.3292	.3658	.2427	.2987	.3292
Avg	.4132	.4038	.419	.5370	.4014	.4101	.4309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 203 / 11 KV Dnyaneshwar Wadi
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2079	1.1317	1.134		1.1949	2.2554	2.3769
2	1.1485	1.1203	1.134		1.1949	2.1929	2.2758
3	1.1492	1.1317	1.134		1.2071	2.1761	2.2953
4	1.1835	1.358	1.2803		1.2323	2.2931	2.3952
5	1.3481	1.4335	1.5546	1.3169	1.4563	2.5187	2.716
6	1.6644	1.643	1.6827	1.6461	1.7924	2.9538	3.1444
7	2.0348	1.9605	1.8656		1.9044	3.4888	4.0657
8	2.2885	2.1658	2.3411		2.037	3.6099	4.3995
9	2.2817	2.0538	1.7924	1.8671	1.7924	3.3349	4.132
10	1.9898	1.9605	1.6095		1.7177	2.8052	1.8648
11	3.3448	1.7924			1.643	2.1552	1.6636
12	2.8586	1.7193			1.5684	2.6749	1.5143
13	2.8304	1.7193		1.3443	1.419	2.7061	1.4304
14	2.8517	1.7193		1.2696	1.3443	1.7582	1.4419
15	2.7351	1.6461		1.419	1.2696	1.3237	1.4106
16	2.6993	1.6095		1.4937	.5228	2.5331	2.6406
17	2.8997	1.5238		1.5684	.6722	2.9088	2.9828
18	2.9317	1.6461		1.7177	.8589	3.0506	3.3577
19	3.4295	1.7375			1.0456	3.4344	3.8653
20	3.3028	1.6095		1.8298	1.6057	3.3897	3.6557
21	2.9912	1.4998		1.7177	1.3443	3.2175	3.3973
22	2.7511	1.3717		1.4937	1.307	2.9157	3.1345
23	2.5712	1.2803		1.3443	1.2696	2.5765	2.8327
24	1.9349	1.1576	1.1888		1.2696	2.4974	2.5544
Max	3.4295	2.1658	2.3411	1.8671	2.037	3.6099	4.3995
Min	1.1485	1.1203	1.134	1.2696	.5228	1.3237	1.4106
Avg	2.3512	1.5830	1.5197	1.5406	1.3612	2.6988	2.7311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 204 / 11 KV FARANDE NAGAR - II SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.415	.4755		.4108	.4108	.439
2		.4108	.4755		.4108	.4108	.439
3		.4108	.4755		.4108	.4108	.439
4		.4481	.5487		.4108	.5228	.5487
5		.5658	.5853		.4854	.6722	.6584
6		.6413	.695		.7095	.7468	.695
7		.6722	.7316		.7499	.8589	.9145
8		.7468	.9511		.7167	.8962	1.0242
9		.7095	.8779		.6722	.8589	.8413
10		.6535	.695	.7095	.6348	.7316	
11	.5975	.5601			.5281	.7316	
12	.5658	.5487			.4894	.6584	
13	.5228	.5487		.4481	.4854	.5853	
14	.4854	.5487		.4854	.4481	.439	
15	.4481	.5487		.4854	.4481	.439	
16	.4904	.5487		.5228	.4481	.439	.5487
17	.5228	.5487		.5975	.5121	.4755	.5487
18	.6722	.6401		.6348	.5975	.5121	.5487
19	.7095	.695		.6722	.6535	.6401	.7087
20	.6722	.7316		.6348	.5975	.7682	.695
21	.5975	.6767		.5975	.5601	.7316	.695
22	.5601	.5853		.5281	.4854	.6401	.6401
23	.4854	.5487		.4854	.4481	.5121	.5853
24		.4527	.5121		.4481	.4108	.5121
Max	.7095	.7468	.9511	.7095	.7499	.8962	1.0242
Min	.4481	.4108	.4755	.4481	.4108	.4108	.439
Avg	.5638	.5773	.6385	.5668	.5317	.6043	.6379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 205 / 11 KV Vijay Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8962	.9145		.8962	.8962	.8779
2		.8676	.9145		.8589	.8962	.8779
3		.8589	.9145		.8676	.8962	.8779
4		.9808	1.0059		.8589	.9335	1.0059
5		1.1203	1.0974		.9335	1.2136	1.1888
6		1.2696	1.2803		1.1203	1.307	1.2803
7		1.419	1.39		1.4003	1.4003	1.4632
8		1.4937	1.5729		1.2696	1.4563	1.6095
9		1.4563	1.4998		1.1203	1.4003	1.4998
10		1.3443	1.2803	1.3169	1.0456	1.2437	
11	1.2696	1.1949			.8402	1.1888	
12	1.1576	1.134			.7842	1.134	
13	1.0829	1.0974			.7842	1.0974	
14	.9709	1.0631		.9335	.8589	.8413	
15	.8962	1.0974			.8402	.8413	
16	.8589	1.0059			.8402	.9145	.9511
17	.9335	.9145			1.0082	.9511	1.0059
18	1.1203	1.0059			1.1203	1.1888	1.0059
19	1.2826	1.1888		1.531	1.307	1.2803	1.3169
20	1.1949	1.2803		1.419	1.2696	1.3169	1.3112
21	1.1203	1.2437		1.2696	1.2136	1.2803	1.3169
22	1.0456	1.0974		1.1203	1.0829	1.0974	1.134
23	1.0082	1.0059		1.0456	1.0082	1.0059	.9877
24		.9335	.9145		.0934	.9335	.9145
Max	1.2826	1.4937	1.5729	1.531	1.4003	1.4563	1.6095
Min	.8589	.8589	.9145	.9335	.0934	.8413	.8779
Avg	1.0724	1.1237	1.1622	1.2337	.9759	1.1131	1.1459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 202 / 11 KV ANAND NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0288	1.0288	1.0288	1.2003	2.3577	1.8858	1.8484
14			1.0288		2.3011		
16	1.0288	1.0288		1.0288	2.2257	1.9044	1.8296
24	1.0288	1.0288	1.0288	1.0288	2.2634	1.8298	1.8671
Max	1.0288	1.0288	1.0288	1.2003	2.3577	1.9044	1.8671
Min	1.0288	1.0288	1.0288	1.0288	2.2257	1.8298	1.8296
Avg	1.0288	1.0288	1.0288	1.0860	2.2870	1.8733	1.8484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 203 / 11 KV GAJANAN MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0288	1.2003	1.2003	1.0288	1.5249	1.5249	1.543
14			1.0288				
16	1.0288	1.2003		1.2003	1.7918	1.6124	1.9845
24	1.7147	1.0288	1.0288	1.0288	1.7924	1.9231	1.5424
Max	1.7147	1.2003	1.2003	1.2003	1.7924	1.9231	1.9845
Min	1.0288	1.0288	1.0288	1.0288	1.5249	1.5249	1.5424
Avg	1.2574	1.1431	1.0860	1.0860	1.7030	1.6868	1.6900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 204 / 11 KV WAMAN NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0288	1.0288	1.0288	1.0288	.8764	.905	.9621
14			1.0288				
16	1.0288	1.0288		1.0288	.8669	.8954	.924
24	1.7147	1.0288	1.0288	1.2003	.8192	.8859	.9717
Max	1.7147	1.0288	1.0288	1.2003	.8764	.905	.9717
Min	1.0288	1.0288	1.0288	1.0288	.8192	.8859	.924
Avg	1.2574	1.0288	1.0288	1.0860	.8542	.8954	.9526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 205 / 11 KV GANESH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0288	1.0288	1.0288	1.2003	1.0903	1.1949	1.2136
14			1.0288				
16	1.0288	1.0288		1.0288	1.1523	1.2382	1.1706
24	1.0288	1.0288	1.0288	1.0288	.8686	1.134	1.1706
Max	1.0288	1.0288	1.0288	1.2003	1.1523	1.2382	1.2136
Min	1.0288	1.0288	1.0288	1.0288	.8686	1.134	1.1706
Avg	1.0288	1.0288	1.0288	1.0860	1.0371	1.1890	1.1849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 206 / 11 KV PAWDEWADI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715				
14		.1715			
16			1.0288	1.2498	1.2809
Max	.1715	.1715	1.0288	1.2498	1.2809
Min	.1715	.1715	1.0288	1.2498	1.2809
Avg	.1715	.1715	1.0288	1.2498	1.2809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 207 / 11 KV VIVEK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288						
8	1.0288	1.0288	1.0288	1.0288	1.8111	2.0538	2.6595
14			1.0288				
16	1.0288	1.0288		1.0288	1.8111	1.9753	2.6972
24		1.2003	1.2003	1.0288	1.6448	2.5953	1.8296
Max	1.0288	1.2003	1.2003	1.0288	1.8111	2.5953	2.6972
Min	1.0288	1.0288	1.0288	1.0288	1.6448	1.9753	1.8296
Avg	1.0288	1.0860	1.0860	1.0288	1.7557	2.2081	2.3954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 208 / 11 KV POLICE COLONY`

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288						
8	1.0288	1.0288	1.0288	1.0288	.9134	.8745	1.0719
14			1.2003				
16	1.0288	.8573		1.0288	.9774	1.0317	1.0791
24		1.0288	1.0288	1.0288	.9795	.8682	1.0136
Max	1.0288	1.0288	1.2003	1.0288	.9795	1.0317	1.0791
Min	1.0288	.8573	1.0288	1.0288	.9134	.8682	1.0136
Avg	1.0288	.9716	1.0860	1.0288	.9568	.9248	1.0549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 209 / 11 KV SAHAYOG NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288						
8	1.0288	1.0288	1.0288	1.0288	1.6278	1.7375	1.8107
14			1.0288				
16	1.0288	1.2003		1.2003	2.0144	1.7918	1.7924
24		1.2003	1.0288	1.0288	1.5181	1.5912	1.7741
Max	1.0288	1.2003	1.0288	1.2003	2.0144	1.7918	1.8107
Min	1.0288	1.0288	1.0288	1.0288	1.5181	1.5912	1.7741
Avg	1.0288	1.1431	1.0288	1.0860	1.7201	1.7068	1.7924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 400 / Auxiliary Supply

Feeder KV- 33 / INCOMING

DATE	01-MAR-17
HR	Load (MW)
24	.463
Max	.463
Min	.463
Avg	.463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 201 / 11 KV LIMBGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0561			.0374	.2843	.21
2		.0564		.0452	.0375	.3553	.2789
3		.0564		.0455	.0375	.3487	.2801
4		.0564		.0455		.3553	.2804
5						.3553	.2816
6						.4264	
7						.7468	
8						.8882	.8278
9						.8037	.7468
10							.7154
11	.8435	.5415	.7773		.7459		
12	.9944	.7726	.9214		.8205		
13	.9957	.5268	.9179	1.0179	.8205		
14	.8425	.7573	.7649	.9271	.8215		
15	.763	.7516	.612	.9351	.8215		
16	.7659	.8404	.6764		.6722		
17	.7668	.8372	.7583	.7516	.599		
18	.4607	.7373	.8341	.7202	.599		
19	.0752		.0753	.5041	.0752	.0566	
20	.0524		.0753	.4167	.0752	.0564	
21	.0752		.0607		.0752	.0562	
22	.0752		.0614	.0563	.0752	.0554	
23	.0564				.0564	.037	
24	.056	.0564		.0455		.0564	.0372
Max	.9957	.8404	.9214	1.0179	.8215	.8882	.8278
Min	.0524	.0561	.0607	.0452	.0374	.037	.0372
Avg	.4874	.4651	.5446	.4592	.3981	.3255	.4065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 202 / 11 KV CHUDAWA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0562			.0561	.3482	.331
2		.0562		.0451	.0562	.3487	.3984
3		.0562		.0451	.0563	.4184	.3984
4		.0565		.0408	.0561	.4184	.4001
5						.4184	.4681
6						.4881	
7						.6973	
8						.8653	.9845
9						.8653	.8121
10							.7116
11	.743		.8194		.8733	.6104	
12	.8916	.9833			1.0149		
13	.743	.961		1.0093	1.0229		
14	.743	.8905		1.0006	.9498		
15	.743	.5952		.9259	.9498		
16	.8916	.9008	1.0576	.7325	.8768		
17	.8916	.9647	1.0522	.9635	.9498		
18	.8184	.9387	1.0029	.8516	.5845		
19	.075	.6944	.6925	.8208	.0747	.0716	
20	.075		.6925	.6783	.0747	.0562	
21	.075		.0601		.056	.0561	
22	.075		.0601	.0564	.0747	.0557	
23	.0564			.0562	.056	.0556	
24		.0562		.0451		.056	.0556
Max	.8916	.9833	1.0576	1.0093	1.0229	.8653	.9845
Min	.0564	.0562	.0601	.0408	.056	.0556	.0556
Avg	.5247	.5546	.6797	.5194	.4578	.3644	.5066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 203 / 11 KV NALESHWAR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.0312				
5			.0301			
7		.0312				
8	.0305	.0308				
9	.0304	.0312	.031			
10	.0447		.0458	.0299		
12						.0308
13					.0288	.032
14					.0288	.0312
15						.0312
16						.0306
17					.0303	.0314
18					.0287	.0305
23	.1515					
Max	.1515	.0312	.0458	.0299	.0303	.032
Min	.0304	.0308	.0301	.0299	.0287	.0305
Avg	.0643	.0311	.0356	.0299	.0292	.0311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 204 / 11 KV TALNI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.0782				
4			.0685				
5	.0805	.07	.0709		.0297		
6	.076	.0756	.0718		.0714		
7	.1568	.0757			.0764		
8	.1541	.1501	.1528				
9	.1528	.1501	.1547	.1524	.1484		
10	.1437	.1469	.1501	.1406	.1482		
11						.1505	.0727
12						.1507	.1467
13						.1457	.1513
14						.1465	.1446
15						.1395	.0285
16						.1406	.1347
17						.1456	.0703
18						.1377	.0694
Max	.1568	.1501	.1547	.1524	.1484	.1507	.1513
Min	.076	.07	.0685	.1406	.0297	.1377	.0285
Avg	.1273	.1114	.1067	.1465	.0948	.1446	.1023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 205 / 11 KV LIMBGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3871	.645	.6579	.6912	.6765	.6753	.7088
2	.6546	.6325	.6358	.4543	.6572	1.1432	.6928
3	.6587	.6386	.7304	.7777	.6604	.7479	.9781
4	.7713	.7498	.8546	.8825	.4123	.8163	1.01
5	.9691	1.025	1.032	1.0658	.4915	1.0096	1.2098
6	1.3781	1.4533	1.4716	.7545	1.2967	1.4487	.8063
7	1.8737	1.8	.9457	.9724	.9816	1.6735	.9915
8	1.7467	1.8831	1.7185	.9435	.9907	1.7086	1.7314
9	1.5817	1.5013	1.6743	1.5745	1.6705	1.4912	1.4782
10	1.2468	1.1992	.8177	1.0243	1.2982	.6996	1.1739
11	.8319	.9255	.5049	.3483	.9964	1.0008	.805
12	.6689	.6325	.4542		.6928	.6076	.5885
13	.5881	.5106	.0381	.5395	.6357	.6364	.4999
14	.5614	.4091		.648	.6288	.7267	.4537
15	.7	.3693		.5959	.6296	.7446	.6642
16	.7342	.6126	.7689	.6252	.7418	.7667	.5893
17	.7815	.3765	.9237	.6837	.8112	.935	.804
18	.939	1.0903	1.1345	.9849	1.0911	1.1387	1.0449
19	1.3168	1.2892	1.3461	1.2405	1.3471	1.5196	1.2653
20	1.3121	1.2636	1.4757	1.3185	1.4461	1.5844	1.2783
21	1.1902	.9713	1.1456	.6508	1.2192	1.1522	1.0467
22	.8432	.7544	.8039	.4946	.8904	1.1066	.8224
23	1.0859	.689	.733	4.311	.8074	.8436	.7709
24	.3742	.6737	.6978	.6927	.6871	.8226	.7326
Max	1.8737	1.8831	1.7185	4.311	1.6705	1.7086	1.7314
Min	.3742	.3693	.0381	.3483	.4123	.6076	.4537
Avg	.9665	.9206	.9348	.9684	.9067	1.0416	.9228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174048 / 33 KV DEGAON

Feeder No / Name : 202 / 11 KV SUGAR FACTORY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3086	.3048		.3429	.3048	.3429
2	.3258	.3086	.3048		.3429	.3048	.3429
3	.3258	.3086	.3048		.3429	.3048	.3429
4	.3258	.3086	.3048		.3429	.3048	.3429
5	.3258	.3086	.3048		.3258	.3048	.3429
6	.3086	.3086	.3048		.3086	.3048	.3429
7	.3086	.2915	.3048		.2743	.3048	.3086
8	.2915	.3601	.3048		.3048	.3048	.3086
9	.3258	.3048		.3429	.3048	.3429	.2743
10	.2915	.3048		.3086	.2439	.2743	.2743
11	.3429	.3048		.3086	.2439	.3086	.3048
12	.3429	.3048		.3429	.2439	.3429	.3048
13	.3258	.3048		.3258	.2743	.3258	.3048
14	.2915	.3048		.3086	.2743	.2915	.3048
15	.3086	.3048		.3086	.2439	.3429	.3048
16	.3086	.3048		.3258	.0305	.3429	.3048
17	.3086	.3048		.3086	.3048	.3429	.3048
18	.3086	.3048		.2915	.2439	.2743	.3048
19	.3086	.3048		.3258	.3048	.3086	.3048
20	.3086	.3048		.3258	.3048	.2915	.3048
21	.3086	.3048		.3086	.3048	.2915	.3048
22	.3086	.3048		.3429	.3048	.2915	.3048
23	.3258	.3048		.3429	.3048	.3429	.3048
24	.3258	.3086	.3048		.3429	.3048	.3429
Max	.3429	.3601	.3048	.3429	.3429	.3429	.3429
Min	.2915	.2915	.3048	.2915	.0305	.2743	.2743
Avg	.3158	.3077	.3048	.3212	.2858	.3108	.3137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174048 / 33 KV DEGAON

Feeder No / Name : 203 / 11 KV SHELGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	04-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)
7		1.7147	
8		2.0576	
9	2.6578		
10	2.572		
11	2.4863		
12	2.4006		
13	2.4006		
14	2.4006		
15	2.2291		
16	2.4863		
17	2.4006		
18	2.0576		
19	1.8861		
20	1.7147		1.8861
21	1.7147		
22	1.7147		
Max	2.6578	2.0576	1.8861
Min	1.7147	1.7147	1.8861
Avg	2.2230	1.8862	1.8861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174048 / 33 KV DEGAON

Feeder No / Name : 205 / 11KV PIMPALGAON GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6001	.6859		.6344	.6173	.6859
2	.6001	.6001	.6859		.6344	.6173	.6859
3	.7716	.6001	.7888		.6859	.6173	.7716
4	.9431	.7716	.823		.8573	.6859	.9431
5	1.0974	1.0288	1.2003		1.1145	1.0288	1.1317
6	1.2517	1.2517	1.2346		1.3717	1.2689	1.4232
10	.8573	.6859		.9602	.8573	.8059	.8573
11	.7373	.6859		.7888	.8573	.6173	.7202
12	.6001	.6859		.6344	.6859	.5658	.6859
13	.5144	.6859		.5487	.5144	.6859	.6173
14	.4801	.6859		.5487	.5144		.0229
15	.6001	.6173		.583	.5144	.6001	.5144
16	.6516	.6173		.6516	.5144	.6687	.5144
17	.7202	.6859		.7716	.6859	.7716	.6859
18	.8573	.8573		.8573	.9145	.8573	.7716
19	1.0288	.8573		1.0288	1.0631	1.0802	.7716
20	.9088	.6859		.9431	1.0288	.9431	.8573
21	.7716	.6859		.8059	.823	.7888	.8573
22	.7202	.6859		.7373	.6859	.7545	.7716
23	.6516	.6859		.6859	.6859	.6859	.6859
24	.943	.6001	.6859		.6344	.6859	.6859
Max	1.2517	1.2517	1.2346	1.0288	1.3717	1.2689	1.4232
Min	.4801	.6001	.6859	.5487	.5144	.5658	.0229
Avg	.7765	.7267	.8721	.7532	.7751	.7673	.7458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 202 / 11 KV JAITAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2076	.381	.346		.0381	.0346
2	.4763	.3464	.381	.4325	.4763	.0381	.0346
3		.3806	.381	.4325		.0381	.0346
4	.5716	.4325	.381	.5536	.5144	.0381	.0346
5		.4325	.4763	.6574			
6	.7049	.519	.5716	.7785	.6668		
7		.6574	.7621	.865			
8	.8573	.865	.7621		.7621		
9	.8573	.865	.7621		.8573		
10	.7266	.6574	.7621		.7621		
11						.381	.6668
12						.7621	.7621
13				.7621		.7621	.8573
14				.8573		.6535	.8573
15							.7621
16						.5716	.7621
17	.0346	.0381	.0346	.0381			.7621
18	.0346	.0381	.0346		.0381	.519	.6668
19	.0346	.0381	.0346	.0381	.0381	.0346	.0572
20	.0346	.0381	.0346		.0381	.0346	
21	.0346	.0381	.0346		.0381	.0346	.0381
22	.0343	.0381	.0346		.0381	.0346	
23	.0346	.0381	.0346		.0381	.0346	.0381
24	.0381	.0346	.0381	.0346	.0381	.0381	.0346
Max	.8573	.865	.7621	.865	.8573	.7621	.8573
Min	.0343	.0346	.0346	.0346	.0381	.0346	.0346
Avg	.3196	.3147	.3278	.4830	.3312	.2508	.4002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 203 / 11 KV PIMPALGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6055	.9907	.692		.0381	.0346
2	1.3717	1.1244	1.1431	1.1244	1.0479	.0381	.0346
3		1.2974	1.3336	1.2109		.0381	.0346
4	1.4289	1.3493	1.3717	1.2974	1.3717	.0381	.0346
5		1.3839	1.5623	1.4704			
6	1.8099	1.3839	1.6194	1.8164	1.7147		
7		1.7299	1.8099	1.9894			
8	2.0957	2.0759	2.2862		2.2862		
9	2.2862	2.1624	2.0957		2.191		
10	1.9894	2.1624	2.191		2.0957		
11						1.8099	1.7147
12						2.2405	2.0957
13				1.1431		2.3243	2.0957
14				1.7147		2.3815	2.191
15						2.2862	2.0957
16						1.8671	2.0957
17	.0346	.0381	.0346	.0381	.0381	1.8164	2.0957
18	.0346	.0381	.0346		.0381		2.0005
19	.0346	.0381	.0343	.0572	.0381		.0953
20	.0346	.0381	.0346		.0381	.1158	
21	.0346	.0381	.0343		.0381	.0346	.0953
22	.0346	.0381	.0346		.0381	.0346	
23	.0346	.0381	.0346		.0381	.0346	.0762
24	.0381	.0346	.0381	.0346	.0381	.0381	.0346
Max	2.2862	2.1624	2.2862	1.9894	2.2862	2.3815	2.191
Min	.0346	.0346	.0343	.0346	.0381	.0346	.0346
Avg	.8044	.8654	.9269	1.0491	.7866	.946	1.0515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 204 / 11 KV SUGAON AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0346	.0381	.0346		1.1431	1.0391
2	.0381	.0343	.0381	.0346	.0381	1.3717	1.3493
3		.0346	.0381	.0346		1.3717	1.5569
4	.0381	.0346	.0381	.0346	.0381	1.4289	1.6434
5						1.5813	1.8164
6						1.7147	1.9375
7						1.9052	1.9894
8						2.2862	2.0759
9						2.2862	1.9894
10						2.2862	1.7645
11	1.9029		2.0759				
12	2.6673	1.9052	2.5084				
13	2.5603	2.7625		2.0957			
14	2.5084	2.572		2.0957	2.8578		
15	2.2835	2.572			2.8578		
16	2.2489	1.9052	2.3354		2.8578		
17	2.3354	1.9052	2.3354	2.2862	2.6673	.0346	.0381
18	2.1624	2.2862	.0346		2.7625	.0346	.0381
19	.0346	2.2862	.0346	1.9052	2.572	.0346	.0381
20	.0346	.0381	.0346		2.2862	.0346	
21	.0346	.0381	.0346		2.0957	.0346	.0381
22	.0343	.0381	.0346		.0381	.0346	
23	.0346	.0381	.0346		.0381	.0346	.0381
24	.0381	.0346	.0381	.0346	.0381	.0381	.0381
Max	2.6673	2.7625	2.5084	2.2862	2.8578	2.2862	2.0759
Min	.0343	.0343	.0346	.0346	.0381	.0346	.0381
Avg	1.1848	1.0894	.6435	.9506	1.6267	.9809	1.0869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 205 / 11 KV NALESHWAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5536	.6097	.6061		.6097	.6061
2	.6097	.519	.6097	.6235		.6097	.6581
3		.7274	.6097	.6574		.6097	.7785
4	.8383	.8304	.7621	.692	.8954	.6287	.9342
5		.9515	1.2384	1.1244		.7621	1.038
6	1.1431	1.038	1.3336	1.2455	1.3336	1.467	1.1763
7		1.1763	1.4098	1.3839		1.5432	1.2974
8	1.3336	1.1244	1.4861	1.4289	1.4289	1.5623	
9	1.3336	.9515	1.2574		1.3336	1.2193	1.0726
10	.9515	.692	1.0669	.8954	.9526	1.105	.865
11	.6516	.5525	.7274		.8764	.7621	.7621
12	.5542	.5335	.0653		.724	.4763	.5716
13	.433	.4572	.0373	.5716	.6478	.3806	.4572
14	.346	.381	.5195	.5144	.5525		.4572
15	.1732	.381	.5195		.5716	.381	.5716
16	.1732	.4763	.6574		.5716	.6668	.7621
17	7.3695	.5144	.6574	.8573	.5906	.8304	.8954
18	.9005	.9526	.9525		.8764	.9515	1.0479
19	1.0045	1.2955	1.0737	1.2384	1.2193	1.1244	1.1431
20	.9352	1.0479	.9525		1.1622	1.038	
21	.7785	.8383	.8996		.9526	.9515	.8954
22	.6927	.7621	.692		.743	.6927	
23	.6061	.724	.6581		.724	.6581	.6097
24	.6097	.5542	.6668	.6061	.6668	.6097	.6061
Max	7.3695	1.2955	1.4861	1.4289	1.4289	1.5623	1.2974
Min	.1732	.381	.0373	.5144	.5525	.3806	.4572
Avg	1.0719	.7514	.8109	.8889	.8854	.8539	.8193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 201 / 11KV MUGAT GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.6001	.5175	.6859		.6859	.6283
2	.6335	.6859	.5544	.6859		.6859	.6283
3	.6516	.6859	.5914	.6859		.6859	.695
4	.7602	1.0288	.6653	.8573		.8573	.7602
5	.961	1.2003	.7762	1.2003		1.0288	.9816
6	1.3817	1.286	1.1088	1.4575	1.307	1.2003	1.2536
7	1.5893	1.5432	1.2567	1.4575	1.643	1.5432	1.4563
8	1.5154	1.3717	1.134	1.4575	1.5154	1.3717	1.2136
9	1.386	1.1458	1.0608	1.4784	1.4415	.7716	1.387
10	1.2197	1.2071	.9709		1.1458	1.1191	.8383
11	.6554	.6241	.924		.7545	.8686	1.0498
12	.8192	.3953	.192		.663	.5611	
13	.7045	.1739	.16		.5668	.5121	
14	.4915	.1739	.2214	.5735	.4641	.4207	
15	.3277	.1898	.5571		.5281	.4207	.6001
16	.663		.6962		.639	.7499	.8573
17	1.3717	.9054	.8383	.8648	.6882		1.0288
18	1.0288	.9945	1.0059	.9389	.8288	1.2071	1.2003
19	1.2003	1.2936	1.386	1.386	1.2936	1.2197	1.3717
20	1.1145	.8131	1.1088		.8573	1.0349	1.1145
21	1.0288	.6283	.8573		.8573	.8871	.8573
22	.6001		.6859		.6859	.7316	.6859
23	.6001	.5121	.6859		.6859	.6653	.6859
24	.6468	.6001	.5121	.6859		.6859	.6283
Max	1.5893	1.5432	1.386	1.4784	1.643	1.5432	1.4563
Min	.3277	.1739	.16	.5735	.4641	.4207	.6001
Avg	.9160	.8209	.7695	1.0297	.9203	.8658	.9487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 202 / 11 KV MATASAB AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.394	.6859	.3696	.4801			
2	.3982	.7545	.4066	.6859			
3	.4525	.7545	.5175	.823			
4	.543	.823	.5544	.8916			
5	.5914	.9602	.6653	.9602			
6	.8215	.9602	.8871	.9602	.7468		
7	1.0349	1.0288	1.1088	1.0974	.8962		
8	1.0349	1.166	1.0974	1.0974	.961		
9	1.0349	1.0903	1.0974	1.0974	.961		
10	1.0349	1.2437	.7468		1.0903		
11						1.1088	.9945
12						1.2308	1.1317
13			.6722			1.1706	1.3032
14						1.3575	
15						.8779	1.3032
16						1.3575	1.2346
17						1.3575	1.3032
18						1.0974	1.3032
Max	1.0349	1.2437	1.1088	1.0974	1.0903	1.3575	1.3032
Min	.394	.6859	.3696	.4801	.7468	.8779	.9945
Avg	.7340	.9467	.7385	.8992	.9311	1.1948	1.2248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 203 / 11 KV AMDURA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1372	.1715	.1372		.4801	.3856
2	.1715	.1372	.1715	.1372		.5487	.5609
3	.181	.1372	.1715	.1372		.5487	.7282
4	.2172	.2058	.1715	.1372		.6859	.9431
5	.2058	.2058	.2058	.1715		1.166	1.0288
6	.2058	.2058	.2058	.2058	.1715	1.2346	1.2894
7						1.5775	1.6644
8						1.5775	1.7337
9						1.6617	1.7337
10						1.6617	1.6598
11	1.6956	1.4723	1.6632	1.7703	1.5089		
12	1.7204	1.8976	1.6644		1.7736		
13	1.8515	2.0241	1.8724	1.6741	1.7976		
14	1.8679	1.7711	1.8343	1.8187	1.7924		
15	1.8023	1.7078	1.9006	1.7072	1.6804		
16	1.8233	1.8023	1.7404		1.6712		
17	1.6289	1.8275	1.8107	1.5939	1.6712		
18	1.7833	1.7238	1.8107	.1848	1.6575		
19	.2058	.2058	.1715	.1848	.1848	.1543	.1372
20	.2058	.1715	.1848	.1848	.1715	.1715	.1372
21	.1715	.1715	.1715		.1715	.1715	.1372
22	.1715	.1715	.1372		.1715	.1715	.1372
23	.1372	.1646			.1715	.1715	.1372
24	.1715	.1372	.1715	.1372		.1715	.1715
Max	1.8679	2.0241	1.9006	1.8187	1.7976	1.6617	1.7337
Min	.1372	.1372	.1372	.1372	.1715	.1543	.1372
Avg	.8195	.8139	.8543	.6788	1.0425	.7596	.7866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 201 / 11 KV TRIKUT AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6097	.7468
2						.7716	.7468
3						.7716	.7842
4						.8916	.8402
5						.9259	.9709
6						.9602	1.0082
7						1.1145	1.1203
8						1.2003	1.2136
9						1.2174	1.307
10						1.286	1.3443
11		1.4003	1.3169	1.3203	1.3203		
12	1.4632	1.4003	1.5364	1.5565	1.4575		
13	1.587	1.3575	1.5154	1.4403	1.5912		
14	1.4632	1.4784	1.643	1.5364	1.5364		
15	1.5927	1.4784	1.5684	1.5364	1.4403		
16	1.6461	1.4784	1.4998	1.406	1.4403		
17	1.6461		1.4632	1.5364	1.406		
18	1.6289		1.4266	1.406	1.4632		
19	1.4998						
Max	1.6461	1.4784	1.643	1.5565	1.5912	1.286	1.3443
Min	1.4632	1.3575	1.3169	1.3203	1.3203	.6097	.7468
Avg	1.5659	1.4322	1.4962	1.4673	1.4569	.9749	1.0082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 202 / 11 KV MATASAB GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2241	.2241	.2241	.2195	.2378	.2241
2	.2058	.2241	.2801	.2241	.2241	.2427	.2241
3	.2241	.2614	.3734	.2614	.2241	.2427	.3174
4	.3361	.3361	.5601	.3361	.3292	.3174	.3734
5	.4115	.4481	.7316	.4481	.4435	.4287	.6535
6	.6722	.7468	.8402	.6722	.6535	.7316	.7468
7	.7842	.8962	.9335	.8589	.8048	.7316	.7468
8	.6535	.7468	.7468	.7468	.7468	.6401	.6535
9		.6722	.5975	.5601		.5487	.5975
10		.4108	.4572			.4572	
11			.2614	.2743	.3734	.3696	.2614
12	.2987		.2241	.2195	.2561	.181	.1867
13	.1867		.1494	.1829	.2241	.1402	.1867
14	.2054		.1867	.1829	.2058	.1791	.2241
15	.2241		.1867	.2195	.2058	.2715	.2241
16	.2614		.2987	.2743	.2926	.3292	
17	.3734		.3361	.3658	.3658	.462	.3734
18	.4668		.4481	.4207	.4572	.5175	.5068
19	.6348		.6348	.5853	.5853	.7095	.6348
20	.4668		.4854	.5121	.4287	.6535	.4668
21	.2987		.3361	.2926	.2915	.3734	.3361
22	.2801	.4108	.2987	.2378	.2378	.3361	.2987
23	.2614	.2772	.2614	.2353	.2427	.2801	.2614
24	.2241	.2241	.2218	.2241	.2427	.2427	.2241
Max	.7842	.8962	.9335	.8589	.8048	.7316	.7468
Min	.1867	.2241	.1494	.1829	.2058	.1402	.1867
Avg	.3655	.4522	.4197	.3721	.3661	.4010	.3965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 203 / 11 KV MUGHAT RLY STN
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.9412	.9145	.8688	.7716	.0857	.0934
2	.7716	1.0608	.9145	1.0082	.8573	.0857	.0934
3	.7716	1.1949		1.1827	.8383	.0857	.0934
4	.8573	1.307	1.3169	1.3306	1.1145	.0762	.0934
5	.9774	1.3169	1.6461	1.4266	1.2536	.0857	.0934
6	1.1317	1.4937	1.829	1.531	1.4575	.0857	.0934
7	1.8347	1.7558	2.0119	1.9022	1.9022		
8	1.2346	2.1033	1.9204	2.0271	1.869		
9	1.8656	1.9418	2.0119	2.0165	1.749		
10	1.6651	1.7551	2.0119		1.749		
11						1.8111	2.1033
12		.2241				2.1357	2.1948
13		.1867				2.0157	2.2862
14		.1848				1.97	1.7558
15		.2772				1.9004	
16		.3326				1.9204	
17						2.0328	1.829
18						1.9404	1.9204
19	.0857	.7392	.0857	.0857	.0762	.0934	1.6095
20	.0857	.0924	.0876	.0857	.0857	.0934	1.4998
21	.0857	.0924	.0857	.0857	.0857	.0934	.0876
22	.0914	.0924	.0857	.0857	.0762	.0934	.0876
23	.0857	.0924	.0914	.0762	.0857	.0934	.0914
24	.0762	.0876	.0924	.0914	.0857	.0857	.0934
Max	1.8656	2.1033	2.0119	2.0271	1.9022	2.1357	2.2862
Min	.0762	.0876	.0857	.0762	.0762	.0762	.0876
Avg	.7691	.8225	1.0070	.9203	.8786	.8392	.8955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174083 / 33 kV NEELA

Feeder No / Name : 201 / 11 KV NEELA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9979	1.0082	1.0456			1.0082	1.1576
2	.961	1.0082	1.0082			1.0082	1.1576
3	1.0349	1.1203	1.0456			1.0829	1.1949
4	1.3306	1.307	1.2696			1.3443	1.2696
5	1.848	1.8671	1.8298	1.8298		1.8484	1.8298
6				1.8671	1.848	1.8671	1.8671
10	1.7556		1.643	1.5708	1.531	1.4784	1.4937
11	1.1458	1.1203	1.1949		1.1576		1.1576
12	.961	.9709	1.0082		.9709		1.0269
13		.8962			.8589		.9335
14	.8131	.7842			.8589		
15	.8402	.8589	.9335	.924	.8962	.9335	.8589
16	.9335	1.0082	.9335	1.1088	.8962	1.1088	.9335
17	1.2696	1.2696			1.1949	1.2323	1.1203
18	1.3817	1.4563			1.307	1.3817	1.4563
19	1.7737	1.8671	1.8671	1.7741	1.8298		1.587
20	1.4937	1.531			1.4563	1.4937	1.4937
21	1.307	1.2696			1.2323	1.2696	1.307
22	1.1949	1.1576			1.0829		1.1949
23	1.0456	1.0829	1.1203		1.0082	1.1203	1.0829
24	.9979	1.0082	1.0456	1.0719		1.0082	1.1203
Max	1.848	1.8671	1.8671	1.8671	1.848	1.8671	1.8671
Min	.8131	.7842	.9335	.924	.8589	.9335	.8589
Avg	1.2150	1.1890	1.2265	1.4495	1.2086	1.2790	1.2622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174083 / 33 kV NEELA

Feeder No / Name : 202 / 11 KV CHIKHALI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0747	.056			1.2452	1.4685
2	.0566	.0747	.056			1.2163	1.4998
3	.0566	.0924	.056			1.2323	1.6248
4	.0566	.0924	.056			1.3077	1.656
5	.056	.0924	.0554			1.3546	1.7185
6				.0747	.0747	1.4632	1.7185
7						1.5895	1.7966
16	1.9814	2.4905	2.3434	2.1872	2.2996		
17	2.0576	2.5069			2.2085		
18	1.9814	2.2085			2.2138		
19	1.6766	1.906	1.7654	1.9372	1.906		
20	1.5699	1.6766			1.768	.0747	.0934
21	1.5352	1.6766			1.5752		.0934
22	1.5202	1.6347			1.4045		.0934
23	1.5051	1.5844	1.656		1.3146	.0747	.0747
24	.0566	.112	.056	.0747		1.2431	1.406
Max	2.0576	2.5069	2.3434	2.1872	2.2996	1.5895	1.7966
Min	.056	.0747	.0554	.0747	.0747	.0747	.0747
Avg	1.0119	1.1588	.6778	1.0685	1.6405	1.0801	1.1036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174083 / 33 kV NEELA

Feeder No / Name : 203 / 11 KV NEELA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8623	1.0269	.8741				
2	.8623	1.0551	.9023				
3	.9023	1.0848	.9023				
4	.9431	1.1145	.9846				
5	.9574	1.2041		1.1873			
6	1.1004	1.2793	1.1443	1.2498	1.1561		
7	1.2483	1.3094	1.3123	1.2498	1.1873		
8	1.6091	1.3413	1.3279			1.2944	1.406
9	1.1717	1.3565	1.2492			.8916	
10	1.1111			1.2811		1.2955	1.3123
11	1.034	1.2654			1.2193	1.3123	1.3435
12	1.0974	1.2193			1.2492		1.3123
13	1.1736	1.2346			1.2342		1.2498
14	1.0974	1.1888			1.278		1.2029
15	1.1279	1.1138	1.1717	1.1873	1.1873		1.1405
16						1.4529	1.2346
17						1.4373	1.3889
18						1.4373	1.4661
19							1.1126
20						1.0936	1.0212
21						1.0623	.9482
22							.9332
23						1.0623	.9362
24	.8345	1.0269	.7956	.8749			
Max	1.6091	1.3565	1.3279	1.2811	1.278	1.4529	1.4661
Min	.8345	1.0269	.7956	.8749	1.1561	.8916	.9332
Avg	1.0708	1.1880	1.0664	1.1717	1.2159	1.2340	1.2006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 201 / 11 KV KANDHAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.3336	1.0974
2	1.2955						1.1088
3							1.2012
4	1.2955						1.2936
5							1.2936
6	1.4098		1.6766			1.6766	1.386
7						1.9052	1.4784
8	1.7528						1.5708
9		1.7528	1.829		2.191	1.5546	1.4632
10		1.5242				1.4784	1.3717
11					1.5242	1.2803	1.2003
12			1.0288			1.0974	1.2003
13						1.3717	1.286
14		1.3336				1.2803	1.3717
15						1.1888	1.3717
16		1.7147			1.3336		1.286
17	1.829		1.286	2.2862			1.3717
18							1.3717
19				2.191			1.4575
20							1.4575
21	1.7909			1.9814			1.3717
22		1.5242					1.286
23	1.448			1.5242			1.2003
24	1.2003	1.5242	1.1431			1.3717	
Max	1.829	1.7528	1.829	2.2862	2.191	1.9052	1.5708
Min	1.2003	1.3336	1.0288	1.5242	1.3336	1.0974	1.0974
Avg	1.5027	1.5623	1.3927	1.9957	1.6829	1.4126	1.3260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 202 / 11 KV AMBULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0014	.807	.6744	.8474	.7118	.5861	.7819
2	2.347	.7903	.6501	.8009	.6836	.3948	.7697
3	.9717	.772	.6447	.7758	.6973	.3963	.7735
4	2.2896	.7872	.6409	.7827	.708	.4077	.7766
5	1.0494	.8154	.7156	.823	.7491	.4534	.9063
6	2.6681	.9191	1.6887	.9442	.9054	.7751	.5609
7	1.6316	1.1759	1.1264	1.4053	1.1378	3.3425	3.0624
8	3.0083	1.4685	1.3847	1.5607	1.4068	1.6712	4.2006
9	.9145	2.9135	3.1009	1.073	3.3524	3.6793	4.1022
10	1.6133	3.0575	1.6507	1.5417	1.7726	3.8305	4.4416
11	1.48	1.563	1.5402	1.4091	.8859	4.0005	4.1289
12	1.6217	1.5364	3.139	1.5996		3.9834	3.9171
13	1.6324	1.5554	1.2932	1.7139		3.3836	3.4145
14	1.6072	3.0476	1.4342	1.4998		3.8614	3.2419
15	1.3466	1.3656	1.201	1.3603		1.5872	.8592
16	1.7543	2.5705		1.5417	.5358	.2713	.4988
17	3.4496	1.7116	.4287	3.0316	.4252	.3109	.5628
18	1.9067	1.7246		1.6164	.4931	.3269	.6919
19	3.6333	1.3771	.4146	2.7921	.6135	.5197	.8725
20	1.7543	1.3146	1.496	1.5493	.8177	.6836	1.089
21	1.0852	.9656	1.3763	2.6814	.7453	.6318	.9815
22	1.1111	2.2885	1.2262	1.1591	.5586	.5022	.8664
23	2.173	.6981	.8391	1.9592	.4717	.4329	.7598
24	1.9764	.7034	1.3966	.7567	.4275	.604	.397
Max	3.6333	3.0575	3.139	3.0316	3.3524	4.0005	4.4416
Min	.9145	.6981	.4146	.7567	.4252	.2713	.397
Avg	1.8344	1.4970	1.2756	1.4677	.9050	1.5265	1.7774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 203 / 11 KV PANBHOSI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1772	.2772
2	.2743						.2772
3							.2772
4	.2572						.3326
5							.3326
6	.3086		.3506			.1734	.3696
7						.3506	.3696
8	1.8111						.3658
9		2.0805	1.848		1.4175	.1829	.3658
10		1.9342				.2743	.2572
11					2.0328	.2743	.2572
12			.1886			.2743	.2572
13						.1829	.2572
14		1.6461				.1829	.1715
15						1.4632	1.5432
16		.1772			.1772		1.7147
17	.3898		.2572	.1753			1.8861
18							2.0576
19				.1753			2.0576
20							1.8861
21	.3506			.2629			1.8861
22		.2835					1.7147
23	.2481			.1753			.2572
24	.2572		.1715			.1734	
Max	1.8111	2.0805	1.848	.2629	2.0328	1.4632	2.0576
Min	.2481	.1772	.1715	.1753	.1772	.1734	.1715
Avg	.4871	1.2243	.5632	.1972	1.2092	.3372	.8335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 204 / 11 KV KURULA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.9281	1.4632
2	.2401						1.4784
3							1.2936
4	.3086						1.6632
6	.3429		.3429			2.9569	1.4784
7						.1772	.3696
8	.4801						.3696
9		.1772	.1829		.2658	.181	.2715
10		.1753				.181	.2572
11					.2629	.181	.1715
12			.5144			.1829	.1715
13						.2743	.1715
14		.1753				.2715	.1715
15						.1829	.1715
16		2.7435			2.1262		.1715
17	2.3891		2.2291	2.1253			.1715
18							.2572
19				2.0328			.2572
20							.2572
21	2.3655			1.848			.3429
22		2.3777					.2572
23	.2658			.2103			1.2003
24	.2572	2.3777	.1772			1.7909	
Max	2.3891	2.7435	2.2291	2.1253	2.1262	2.9569	1.6632
Min	.2401	.1753	.1772	.2103	.2629	.1772	.1715
Avg	.8312	1.3378	.6893	1.5541	.8850	.7552	.5644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174033 / 33 KV BARUL

Feeder No / Name : 202 / 11 KV PETHWADAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953			.9526	.1132
2		.0762			.9907	1.1576
3		.0572			1.0479	1.2136
4		.0572			1.105	1.1317
5		.1143			1.1431	1.2071
6		.1524			1.1812	.9431
7		.1715			1.6004	1.4335
8		.1698			1.587	1.6409
9			.1494			1.6598
10			.112			1.6598
11			1.531			.0747
12			1.6804			.0934
13			.9709			
14			1.643			.056
15			1.7353			
16			1.7177			
17	1.531		1.6617	1.2323		
18	1.4937		1.7177	1.531		.0934
19	.1494		.1509	.168	.1886	
20	.1698		.1867	.168		
21	.1698		.1698	.112		
22	.1509		.132	.112	.132	
23	.1132		.1132	.112	.112	
24	.9145	.1143		.1132	.112	.112
Max	1.531	.1715	1.7353	1.531	1.6004	1.6598
Min	.1132	.0572	.112	.112	.112	.056
Avg	.5865	.1120	.9114	.4436	.8460	.8393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174033 / 33 KV BARUL

Feeder No / Name : 203 / 11 KV KAWTHA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 201 / 11 KV KURULA AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6371		.0095	.6325	.57		
2	.6371		.0095	.7287	.57		
3	.6036		.0095	.7537	.6036		
4	.6371		.0095	.7865	.7712		
5	.7042		.0095		.7712		
6	.9054		.0191		.8383		
7	1.0395		.5571		1.0059		
8	1.1065		1.1768	1.0774	1.016		
9	1.1065			1.0486	1.1401		
10	1.1065	.8288	.6882	1.0202	1.2071		
11						1.0442	2.1198
12						1.2574	2.196
13						1.291	2.8014
14						1.291	2.6924
15						1.3413	2.5655
16						1.1736	2.5737
17						1.291	2.532
18						1.291	2.4711
19							1.2193
22	.7392						
Max	1.1065	.8288	1.1768	1.0774	1.2071	1.3413	2.8014
Min	.6036	.8288	.0095	.6325	.57	1.0442	1.2193
Avg	.8384	.8288	.2765	.8639	.8493	1.2476	2.3524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 202 / 11 KV KURULA GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.6722	.5415	.5601	.6348	.6161	.6908
2	.6348	.6722	.5415	.5601	.6348	.6161	.6908
3	.6348	.6722	.5975	.6535	.6722	.6161	.6908
4	.6722	.7468	.8215	.7468	.7468	.6722	.7468
5	.7842	.9335	.9896	.8962	.8589	.8589	.9335
6	1.0456	1.1389	1.0269	1.0269	1.0456	1.0829	1.1203
7	1.3443	1.363	1.1576	1.1203	1.3443	1.1763	1.3817
8	1.307	1.363	1.0829	1.1763	1.1417	.9149	1.2323
9	1.1576	1.1389		1.0903	1.1576	1.0269	1.0456
10	.9709	.7468	1.0642	.9979	1.0456	.8962	.8215
11	.8059	.7682	.9145		.8962	.7133	.905
12	.6335		.7392		.7095	.6036	
13			.6584		.4481	.6268	.6036
14	.5611		.5853	.5601	.3077	.5847	.6154
15	.6626		.724	.5228		.5611	.5914
16	.5373	.4409	.5544	.5228	.362	.5973	.5487
17	.7087		.5487	.6348	.3982	.5533	.7164
18	.8417		.724	.8962	.5228	.7316	.6805
19	1.2696	1.1203	1.1203	1.2696	1.1317	.9795	1.0903
20	1.1273	1.0082	1.0642	1.1949		.9795	1.0642
21	.8316	.7842	.7842	.8962		.8775	.8402
22	.7392			.7842		.8215	.7468
23	.7023	.6161		.7468		.7468	.6535
24	.6722	.6722	.5601	.5601	.6348	.6161	.6908
Max	1.3443	1.363	1.1576	1.2696	1.3443	1.1763	1.3817
Min	.5373	.4409	.5415	.5228	.3077	.5533	.5487
Avg	.8382	.8740	.8000	.8294	.7733	.7696	.8305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 203 / 11 KV DIGRAS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.8383	.8421
2							1.0526
3							1.1336
4							1.2146
5						.6401	1.2955
6						.8535	1.4746
7						1.1797	1.6221
8						1.326	1.8896
9						1.3125	1.8233
10						1.2483	1.6575
11	1.4255	.9448	1.8233		1.6277		
12	1.2929		2.0809		2.0645		
13				2.2131	2.0645		
14	1.5912			2.079	2.1548		
15	2.304		2.1628	1.6766			
16	2.3371	2.1795	1.989	1.6766	1.9826		
17	2.2874		1.989	1.576	1.6057		
18	2.2542		1.704	1.2742	1.5565		
Max	2.3371	2.1795	2.1628	2.2131	2.1548	1.326	1.8896
Min	1.2929	.9448	1.704	1.2742	1.5565	.6401	.8421
Avg	1.9275	1.5622	1.9582	1.7493	1.8652	1.0569	1.4006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 201 / 11 KV JANGAMWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0517	1.1145	1.2548	1.0174	.1867	.1357
2		1.0517	1.2269	1.3226	1.0774	.1829	.1357
3			1.2403	1.3717	1.1603	.1448	.1214
4			1.7013	1.4403	1.3077	.1433	.1417
5			1.97	1.5257	1.6804	.1791	.1433
6			2.3388	1.7147	1.9071	.2328	.2534
7	2.2291	2.191	2.4272	2.2539	2.5139	.2658	.208
8	2.6353	2.4272	2.6006	2.5377	2.5139	.2835	.2279
9	2.5941	2.1643	2.7263	2.5095	2.572	.2629	
10	2.572	2.3472	2.2382	2.3304	2.4006	.1734	
11	.2743	.2804	.0848	.1907	.1989	1.6766	1.8778
12		.104	.0678	.1715	.2058	2.1216	2.431
13		.1214	.0686	.1387	.1715	2.3205	2.4034
14		.1017	.0678	.104	.1696	2.1628	2.0405
15		.1017	.0678	.1174	.1357	2.2634	2.1714
16		.1187	.0678	.1017	.1017	2.1879	2.13
17		.1187	.0678	.1017	.1029	2.1879	2.1628
18	.1341	.12	.1543	.1372	.1526	2.2885	2.1628
19	.2658	.1907	.3206	.2263	.3018	.2658	.2987
20		.2279	.3361	.2772	.3206	.2658	.2772
21		.2507	.2987	.2772	.3018	.2507	.2987
22		.2452	.2641	.2427	.2641	.2534	.2614
23	.2629	.218	.2427	.2263	.2427	.2378	.2452
24	.181	.208	.2035	.2263	.1886	.2452	.2402
Max	2.6353	2.4272	2.7263	2.5377	2.572	2.3205	2.431
Min	.1341	.1017	.0678	.1017	.1017	.1433	.1214
Avg	1.2387	.6820	.9124	.8667	.8754	.8660	.9258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 202 / 11 KV HARBAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1753	.2229	.2374	.2543	1.1203	.9259
2		.1753	.1928	.2374	.2486	1.2803	1.0174
3			.2126	.2401	.2486	1.448	1.3003
4			.197	.2572	.2683	1.4327	1.3289
5			.2865	.2774	.2915	1.4327	1.5223
6			.3189	.2743	.3121	1.5223	1.7194
7	.3429	.3681	.3814	.3294	.3467	2.0376	1.9071
8	.3467	.3467	.3121	.3258	.3467	2.1616	2.3663
9	.3856	.3048	.2401	.3222	.3429	2.191	2.332
10	.3429	.3018	.1526	.2515	.3086	1.9938	2.3388
11	.6859	1.6651	1.56	1.6297		.1844	.1341
12		.9536	1.9161	1.8861	1.6289	.1492	.1677
13		1.8031	2.0062	1.9938	2.1434	.1326	.1326
14		2.2382	2.0687	2.0458	1.95	.1475	.1296
15		2.2721	2.2382	1.9951	2.1195	.1509	.116
16		1.933	2.1534	1.9839	2.1195	.1492	.1147
17		2.3739	2.1026	2.1195	2.1948	.1658	.1311
18	.5868	2.1434	1.8347	1.0288	1.4413	.156	.1638
19	1.6832	.3467	.415	.3961	.3772	.3189	.3921
20		.3856	.3734	.3881	.3961	.3189	.3696
21		.3224	.2427	.3696	.3772	.3582	.3547
22		.3206	.3018	.3361	.3395	.3982	.3174
23	1.5775	.2683	.2801	.3206	.2801	.3292	.2829
24	.2353	1.5604	.2543	.2829	.3018	.2829	.3326
Max	1.6832	2.3739	2.2382	2.1195	2.1948	2.191	2.3663
Min	.2353	.1753	.1526	.2374	.2486	.1326	.1147
Avg	.6874	1.0129	.8443	.8137	.8103	.8276	.8291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 203 / 11 KV PANSHEWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1052	.1029	.1017	.1017	.1867	.2315
2		.1052	.1052	.1017	.0995	.3658	.4239
3			.1063	.1029	.0995	.4525	.4334
4			.1075	.12	.1174	.4477	.5316
5			.1254	.1387	.1543	.5373	.5731
6			.124	.1543	.1734	.6268	.8383
7	.1543	.1402	.1387	.1734	.1753	.7973	.8669
8	.156	.1214	.156	.1543	.156	.8505	.8573
9	.1578		.1543	.1187	.1372	.7888	.8573
10	.1543		.1187	.1006	.12	.7802	.6201
11	.7202	.1214	.7969	.6241	.7127	.0671	.0503
12			.78	.703	.7716	.0663	.0671
13			.8059	.6935	.823	.0829	.0497
14		.5935	.6783	.6935	.763	.0328	.0486
15		.763	.7122	.6371	.763	.0503	.0497
16		.7969	.6613	.6274	.78		.0655
17		.5935	.6783	.6613	.7716	.0663	.0655
18	.6706	.7373	.703	.583	.5935	.0867	.0819
19	.124	.3467	.1509	.132	.1509	.124	.1494
20		.1254	.1307	.1294	.132	.124	.1478
21		.1254	.1307	.1294	.132	.1254	.1307
22		.1132	.132	.112	.1132	.1448	.1307
23	.1227	.1006	.112	.1132	.112	.128	.132
24	.1086	.1214	.1017	.1132	.1132	.1132	.1294
Max	.7202	.7969	.8059	.703	.823	.8505	.8669
Min	.1086	.1006	.1017	.1006	.0995	.0328	.0486
Avg	.2632	.3131	.3255	.3008	.3361	.3063	.3138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174085 / 33 KV PETHWADAJ

Feeder No / Name : 201 / 11 KV PETHWADAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9431	1.0269	.9335	.8402	1.1317	.7468
2	1.0374	1.1317	1.0269	.9335	.924	1.1317	.7468
3	1.226	1.226	1.2136	.7468	.9145	1.1317	.6468
4	1.226	1.2936	1.587	1.4937	1.0059	1.1317	.6401
5	1.307	1.5708	1.829	1.6804	1.1088	1.1088	.7316
6	1.587	1.6632	1.9204	1.7375	1.1888	1.1888	.8145
7	1.6632	1.6632	2.0119	1.7375		1.1888	.9955
8	1.6632	1.9404	2.1033	1.9204	1.9605	1.1888	.9145
9	1.848	1.9404	2.0119	1.9204	1.8671	1.1888	.9335
10	1.848	1.9204	1.829	1.829	1.6804	.823	.8402
11	.5544	.6401	.6401	.6468	.5658	1.2803	1.2936
12	.5544	.5487	.5487	.5544	.5658	1.6632	1.6632
13	.5544	.5487	.5487	.5601	.4715	1.6804	1.7737
14	.5544	.5487	.5487	.5487	.4715	1.5708	1.6804
15	.5544	.5487	.5487	.3696	.4715	1.7737	1.6632
16	.5544	.5487	.5487	.3734	.4715	1.6804	1.6632
17	.5544	.6401	.5487	.462	.5658	1.6632	1.7375
18	.7392	.823	.7316	.7468	.8488	1.587	1.829
19	1.1317	1.1203	1.0974	1.0269	1.1088	1.1203	1.1317
20	1.1317	1.1317	1.1317	1.1203	1.2083	1.1317	1.1317
21	1.0374	.9431	1.0374	1.0269	1.1888	1.0374	1.1317
22	1.0374	.9431	.9431	.9431	1.1317	.9431	.9431
23	.9431	.8488	.8488	.8488	1.1317	.9431	.9431
24	.8488	.8488	.8488	.8488	.7468	1.1317	.8488
Max	1.848	1.9404	2.1033	1.9204	1.9605	1.7737	1.829
Min	.5544	.5487	.5487	.3696	.4715	.823	.6401
Avg	1.0458	1.0823	1.1305	1.0421	.9756	1.2675	1.1435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174085 / 33 KV PETHWADAJ

Feeder No / Name : 202 / 11 KV WARWANT

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6602	.7468	.7468	.6535	.8488	1.1203
2	.6602	.6468	.7468	.7468	.6468	.9431	1.307
3	.6602	.6468	.7468	.7468	.6401		1.386
4	.7468	.8316	.7468	.8402	.7316	1.1317	1.4632
5	.8402	.924	.823	.8402	.7392	1.2936	1.6461
6	1.0269	1.1088	.9145	.9145	.823	1.4632	1.6289
7	1.1088	1.1088	1.0059	1.0059		1.829	1.9909
8	1.1088	1.1088	1.0059	1.0059	1.0269	2.0119	2.1033
9	1.1088	1.0164	1.0059	.9145	1.0269	2.1948	2.3339
10	1.0164	.9145	.9145	.823	.8962	2.1033	2.1472
11	1.6632	1.829	1.829	1.848	1.3203	.5544	.6468
12	1.848	2.0119	2.1948	2.0328	1.6975	.462	.5544
13	2.1253	2.1948	2.1948	2.1472	***	.4668	.4668
14	1.848	2.1948	2.1948	2.1033	2.3577	.462	.4668
15	2.1253	2.1948	2.1948	2.2177	2.3577	.4668	.462
16	2.1253	2.1948	2.1948	2.3339	2.2634	.4668	.462
17		2.1948	2.1948		2.2634	.462	.5487
18	2.1253	2.0119	2.0119	.5601	2.1691	.6535	.6401
19	1.0374	1.1203	1.1317	1.0269	1.0164	1.1203	1.1317
20	.9431	1.1317	1.0374	1.2136	1.0974	1.0374	1.1317
21	.8488	.9431	1.0374	1.2136	.9145	.9431	.9431
22	.7545	.8488	.9431	.9431	.9431	.9431	.9431
23	.7545	.7316	.8488	.7545	.7545	.8488	.8488
24	.7545	.7545	.7545	.7545	.7468	.7545	.7545
Max	2.1253	2.1948	2.1948	2.3339	19.8989	2.1948	2.3339
Min	.6602	.6468	.7468	.5601	.6401	.462	.462
Avg	1.2126	1.3051	1.3091	1.2058	2.0428	1.0200	1.1303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 201 / 11 KV BACHOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.7966	.7975	.7455	.9709	.7522	.695
2	1.0402	.9352	.9816	1.1096	1.0402	.7164	.695
3	1.1919	1.1789	1.1919	1.2136	1.1269	.9492	.6255
4	1.3523	1.3191	1.3672	1.439	1.2656	1.0745	.834
5	1.5424	1.529	1.5775	1.5083	1.491	1.1641	1.0402
6	1.7528	1.7878	1.7878	1.5604	1.647	1.2894	1.3003
7	1.9281	1.9982	1.8229	1.7337	1.7337	1.4327	1.4217
8	2.191	2.1033	1.858	1.9071	1.9938		1.1815
9	1.949	2.0332	1.893	1.9765	1.9765		
10	1.949	1.7215	1.9281	1.8378	1.8724		
11	.8545	.6447	.8954	.9134	.8954	1.5604	1.4579
12	.7594	.6447	.8238	.8954	.788	1.5604	1.7009
13	.7202	.6379	.788	.8596	.7522	1.595	1.7356
14	.7103	.6733	.788	.788	.7164	1.6644	1.7703
15	.6668	.7087	.8059	.7522	.7343	1.4563	1.807
16	.6255	.8859	.8238		.7522	1.6315	1.807
17	.6943	.9015	.8596	.8954	.8954		1.8418
18	.8621	.8764	1.0387	1.0029	1.0387	1.4926	1.8418
19	1.1367	1.1568	1.2536	1.2894	1.2536	1.1108	1.0773
20	1.0011	1.0166	1.1641	1.1462	1.1462	1.0773	1.1108
21	.8285	.8413	1.0745	1.0387	1.0745	.9383	1.0414
22	.7595	.8063	1.0029	.9313	.9671		.9025
23	.692	.7712	.8954	.8954	.8954		.8331
24	1	.6927	.8238	.788	.788	.7298	
Max	2.191	2.1033	1.9281	1.9765	1.9938	1.6644	1.8418
Min	.6255	.6379	.788	.7455	.7164	.7164	.6255
Avg	1.1285	1.1109	1.1768	1.1838	1.1590	1.2331	1.2724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 202 / 11 KV CHINCHOLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.5369	.5258	.5373	.5731	.6241	.6603
2	.567	.5369	.5258	.591	.591	.6935	.7819
3	.6379	.5548	.5609	.6268	.6268	.7282	.834
4	.6379	.6248	.631	.6805	.6805	.7802	.8688
5	.6733	.7298	.7362	.7164	.7164	.8669	.9536
6	.7011	.8413	.8413	.8059	.8059	.9536	1.0749
7	.8505	.9816	.9816	.9134	.8954	1.0923	1.0576
8	.8859	1.0867	1.0517	1.1104	1.0566	1.0749	1.0425
9	.7087	.9465	.8413	1.0566	.8954	1.1269	1.3364
10	.7087	.808	.8413		.7701	.9882	1.3017
11	1.0217	1.0631	1.1269	.9709	1.0749	.5201	
12	1.0848	1.1517	1.1096	1.1789	1.2656	.3988	
13	1.1883	1.1517	1.1789	1.2483		.3467	.3124
14	1.243	1.2048	1.2136	1.3003	1.3003	.2774	.3471
15	1.2074	1.2403	1.3176		1.2656	.3294	.3823
16	1.1642	1.2403	1.387		1.2483	.3645	.3996
17	1.1455	1.3146	1.4043	1.2483	1.2656	.4686	.4865
18	1.1207	1.1393	1.335	1.3523	1.2483	.5554	.556
19	.9128	.9391	1.4685	.9313	.985	.8331	.7298
20	.7595	.7712	.8238	.8238	.8954	.7298	.781
21	.6559	.6661	.7164	.7164	.8059	.6603	.5901
22	.6041	.631	.6089	.6805	.7164		.5207
23	.5536	.5847	.5731	.6268	.6268		.486
24	.4557	.5369	.5373	.5552	.5373	.556	
Max	1.243	1.3146	1.4685	1.3523	1.3003	1.1269	1.3364
Min	.4557	.5369	.5258	.5373	.5373	.2774	.3124
Avg	.8356	.8868	.9307	.8891	.9064	.6804	.7382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 203 / 11 KV BAMNI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.5542	.5609	.5731	.5731	.7802	.7819
2	.567	.5542	.5609	.6268	.591	.9709	.973
3	.6379	.6241	.631	.6447	.6089	1.1096	1.1294
4	.6733	.6943	.7011	.6089	.6268	1.2136	1.2163
5	.7087	.7645	.7712	.6268	.6805	1.2656	1.3003
6	.7975	.8413	.8413	.6626	.7164	1.387	1.387
7	.8669	.8764	.8764	.6805	.7522	1.5604	1.0056
8	.9362	.8764	.964	.7164	.8417	1.4563	1.3032
9	.8779	.8413	.964	.6984	.8238	1.491	1.5621
10	.8326	.7553	.964	.6089	.7164	1.387	1.3538
11	1.4675	1.5061		1.0576	1.3523	.4508	
12	1.6634	1.6124	1.2483	1.2656	1.6124	.3814	
13	1.7104	1.5074	1.6644	1.439	1.491	.3814	
14	1.5981	1.5074	1.8031	1.387	1.4043	.3294	
15	1.5441	1.4548	1.8204		1.387	.2774	.3475
16	1.4943	1.4899	1.647		1.387	.4513	.417
17	1.4926	1.5775	1.5777	1.5604	1.439	.4686	.5213
18	1.4483	1.4899	1.439	.9882	1.335	.5554	.5908
19	.8612	.8764	.8954	.9313	.9671	.8678	.834
20	.794	.8063	.788	.8238	.8596	.7819	.781
21	.725	.7282	.7164	.7522	.7701	.6603	.7463
22	.6559	.6661	.6626	.7164	.7164		.6943
23	.5882	.631	.6447	.6805	.6805		.6248
24	.6154	.5715	.6447	.6268	.6268	.6255	
Max	1.7104	1.6124	1.8204	1.5604	1.6124	1.5604	1.5621
Min	.567	.5542	.5609	.5731	.5731	.2774	.3475
Avg	1.0051	.9920	1.0168	.8489	.9566	.8569	.9247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174101 / 33 KV DIGRAS

Feeder No / Name : 201 / 11 KV DIGRAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2263	.3018	.2641	.2641	.2641	.2987
2	.2641	.2075	.2829	.2614	.2641	.2263	.2614
3	.2263	.2075	.2829	.2614	.2614	.2641	.2614
4	.2614	.2263	.3018	.3018	.3018	.2641	.3018
5	.3018	.3395	.3772	.3395	.3361	.3018	.3395
6	.3772	.3961	.415	.415	.415	.415	.4904
7	.5281	.5788	.5228	.6722	.5281	.6036	.6036
8	.5975	.6161	.5415	.6348	.6036	.5975	.5975
9	.4527	.4481	.5415	.4854	.5658	.5281	.5228
10	.4527	.4294	.4108	.3734	.4527	.4527	.4527
11	.3206		.2987	.3395	.3018	.3018	.3361
12	.2452	.3174	.2641		.2641	.2614	.2641
13	.2427	.2614	.2263		.2614	.2241	.2218
14	.2054	.2241	.2241	.2641	.2241		.2195
15	.2241	.2241	.1867		.2241		.2241
16	.2241	.2241	.2241		.2241	.2241	.1867
17	.2427	.2427	.2241	.2241	.2614	.2218	.2218
18	.2801	.2987	.2926	.2926	.2587	.2587	.2561
19	.5228	.5228	.4854	.5601	.5175	.5175	.4854
20	.4854	.5228	.5175	.5601	.5175	.5544	.4854
21	.3734	.4108	.4108	.4481	.4066	.4435	.4481
22	.3361	.3734	.3734	.3734	.3361	.3734	.3734
23	.2987	.3395	.3361	.3361	.2987	.3361	.3361
24	.2641	.2614	.2987	.3018	.3018	.3018	.2987
Max	.5975	.6161	.5415	.6722	.6036	.6036	.6036
Min	.2054	.2075	.1867	.2241	.2241	.2218	.1867
Avg	.3329	.3434	.3475	.3854	.3496	.3607	.3536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174101 / 33 KV DIGRAS

Feeder No / Name : 202 / 11 KV DIGRAS AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.1012	1.278
2						1.1797	1.278
3						1.2452	1.3108
4						1.3108	1.4419
5						1.4091	1.5074
6						1.5402	1.5729
7						1.8233	1.6842
8						1.9006	2.0645
9						1.9662	1.9989
10						1.6842	1.7924
11	1.8399	1.6221	1.6057	1.8564	1.7695		
12	1.989	2.1879	1.9334		1.989		
13	2.1548	1.8896	2.0222		2.0553		
14	2.1216	1.6575	1.7368		2.0317		
15	2.1879	1.8564	1.7695		2.13		
16	1.989	2.0222	1.8564		2.13		
17	2.1548	1.7901	2.0553	2.0317	1.9989		
18	1.9334	1.757	1.9109	1.9662	2.1502		
Max	2.1879	2.1879	2.0553	2.0317	2.1502	1.9662	2.0645
Min	1.8399	1.6221	1.6057	1.8564	1.7695	1.1012	1.278
Avg	2.0463	1.8479	1.8613	1.9514	2.0318	1.5161	1.5929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 201 / SAWARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288	1.2003	1.307			.2915
2		1.0288	1.2003				.2915
3		1.286	1.3717	1.3203			.2915
4		1.286	1.5432				.3429
5		1.5432	1.5432	1.4937			.3429
6		1.5432	1.5432				.3429
7		1.8861	1.7147	1.5089		.9145	.3429
8	2.2634	2.0576	1.8861	1.4937	1.5242	.9145	.3429
9		.2915	.2572				1.5432
10		1.3717	.2572				1.7147
11	.2572		.2572			1.8861	1.8671
12	.2572		.2572	.3174		1.8861	
13	.2915		.2572			1.8004	1.6975
14	.2915		.2572	.3206		1.8861	
15	.2915		.2572			1.8861	1.307
16	.2915		.2572	.3772	.7621	1.8861	
17	.2915		.2572			.2915	.5093
18	.2915	.2915	.2572			.2915	
19	.3429	.2915				.3429	.3734
20	.3429	.2915			.9145	.3429	.3734
21	.3429	.2915				.3429	.3734
22	.3429	.2915				.3429	.3772
23	.3429	.2915				.2915	
24	.3772	.3429	.2572	.2829	.9145	1.8861	.2915
Max	2.2634	2.0576	1.8861	1.5089	1.5242	1.8861	1.8671
Min	.2572	.2915	.2572	.2829	.7621	.2915	.2915
Avg	.4412	.9068	.7806	.9357	1.0288	1.0745	.6851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 202 / SUNEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.463	.2572	.2829			.3429
2		.463	.2915				.3429
3		.5144	.3429	.3174			.4287
4		.5144	.3429				.4287
5		.463	.3429	.3734			.3772
6		.4115	.3772				.3772
7		.3429	.3429			.6097	.3429
8	.3734	.3429	.2572		.9145	.6097	.3086
9		1.5432	1.6289				.2572
10			1.406	1.6032			.2058
11	1.5432		1.3717			.1715	.1867
12	1.4575		1.3717			.1715	
13	1.3717		1.286			.1715	.1494
14	1.3717		1.286	1.0269		.1715	
15	1.3717		1.286			.1715	.1307
16	1.2003		1.286	1.4146	1.2193	.1715	
17	.1715		.1715			1.2003	1.5089
18	.2401	.2058	.2058			1.286	
19	.3772	.2572				1.7147	1.6032
20	.3429	.2572			.6097	1.7147	1.307
21	.3429	.3429				1.5432	1.226
22	.2572	.2572				1.5432	1.307
23	.2572	.2572				1.3717	
24	.3206	.2572	.2572	.2829	.6859	.6097	1.2003
Max	1.5432	1.5432	1.6289	1.6032	1.2193	1.7147	1.6032
Min	.1715	.2058	.1715	.2829	.6097	.1715	.1307
Avg	.7333	.4308	.7427	.7573	.8574	.8270	.6332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 203 / KAREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.2915	.3206			1.0288
2		.2572	.2915				1.2003
3		.2572	.2915	.3206			1.3717
4		.2572	.3429				1.3717
5		.3429	.2915	.3174			1.2003
6		.2915	.2915				1.2003
7		.2915	.2572	.2801		1.448	1.5432
8	.3174	.2915	.2572	.2801	.9145	1.5242	1.5432
9		.2915	.1715				.1715
10			.2572	.3206			.1715
11	.2572		.2572			.2915	.3206
12	.2572		.2572	1.587		.2915	
13	.2572		.2572			.2915	.3174
14	.1715		.2572	.3772		.2915	
15	.1715		.2572			.2915	.3174
16	.1715		.2572	.3174	.7621	.2915	
17	1.7147		1.5432			.2915	.3174
18	1.8861	1.8861	1.7147			.2915	
19	1.7147	1.8861				.3429	.3206
20	1.8861	1.7147			1.5242	.3429	.3734
21	1.7147	1.7147				.3429	.3734
22	1.5432	1.5432				.2915	.3734
23	1.3717	1.3717				.2915	
24	1.1317	1.2003	.2572	1.5089	1.3717	1.5242	.2915
Max	1.8861	1.8861	1.7147	1.587	1.5242	1.5242	1.5432
Min	.1715	.2572	.1715	.2801	.7621	.2915	.1715
Avg	.9711	.8659	.4106	.5630	1.1431	.5275	.7267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 204 / LOHA URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3717	1.5432	1.8861			1.3717
2		1.3717	1.5432				1.3717
3		1.5432	1.7147				1.5432
4		1.7147	1.8861				1.7147
5		1.8861	2.0576				1.8861
6		2.0576	2.0576				1.9719
7		2.4006	2.572			2.1338	2.4006
8	3.1741	2.6578	2.915		2.6673	2.2862	2.6578
9		2.4863	2.6578				2.6578
10			2.572	2.8292			2.3148
11	2.572		2.572			2.4006	2.4272
12	2.4863		2.572	2.5206		2.4863	
13	2.4006		2.4863			2.2291	2.4272
14	2.4006		2.4006	2.5463		2.3148	
15	2.2291		2.4863			2.4006	2.1472
16	2.4863		2.4863	2.4272	2.1338	2.4006	
17	2.4863		2.4006			2.4863	2.6139
18	2.4863	2.3148	2.4006			2.4863	
19	2.4006	2.2291				2.572	3.0178
20	2.2291	2.1434			2.2862	2.4006	2.8292
21	2.0576	2.0576				2.2291	2.2634
22	1.8861	1.8861				2.0576	2.1691
23	1.6289	1.8004				1.8861	
24	2.4006	1.5432	1.7147	1.8861	1.5242	2.2862	1.6289
Max	3.1741	2.6578	2.915	2.8292	2.6673	2.572	3.0178
Min	1.6289	1.3717	1.5432	1.8861	1.5242	1.8861	1.3717
Avg	2.3550	1.9665	2.2652	2.3493	2.1529	2.3160	2.1797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 201 / KALAMBAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381						.6097
2	.4763	.9526					.6097
3	.5716	.9526					.6668
4	.724	1.2384					.7621
5	.7621						.8573
6		1.6194	.9526				.9145
7	1.363		1.4003			.9808	.9526
8	1.4003	1.6194				.9522	.9526
9	1.5242	1.6194	1.0059	1.5242		.8402	.7621
10	1.5242		.3109	1.5242	1.1203	.7621	.6668
11	.4763	.5228	.3658		.5601	.9526	.9526
12	.4763		.3658	.381		1.1431	.9526
13	.5335		.362	.381		1.1431	1.2384
14	.5335			.381	.3429		1.2384
15	.4763	.4668			.4001	1.0479	1.0288
16	.4763				.4481	1.0479	1.0288
17	.5716				.4854	1.0479	.8573
18	.6668	.6668				1.0479	.5716
19	.7621					.7621	.7621
20	.7621	.8002			.724	.9526	.9907
21	.5716	.5716			.5906	.9526	.9526
22	.5716					.8573	.9145
23	.5335					.8192	.8573
24	.4382	.4763	.4572			.4572	.7621
Max	1.5242	1.6194	1.4003	1.5242	1.1203	1.1431	1.2384
Min	.381	.4668	.3109	.381	.3429	.4572	.5716
Avg	.7207	.9589	.6526	.8383	.5839	.9275	.8693

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 202 / PANGRA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.381
2	.724						.381
3	.8573						.3429
4	.9145						.3429
5	1.0479						.3429
6			1.2955				.381
7	1.6804		1.6804			.6161	.381
8	1.643					.5601	.3429
9	1.587		1.1222	1.9052		.4854	.2858
10	1.5242		1.3336	2.0005	1.6975	.381	.2858
11	.1905	.1494	.2286		.1867	1.5242	1.6194
12	.1905		.2477	.4382		1.6194	1.6194
13	.1905		.2858			1.7147	1.6766
14	.1905				.1715	1.7147	1.7147
15	.1905				.1524	1.7147	1.6194
16	.2286				.1867	1.7147	1.5242
17	.2858	.2241			.2054	1.6194	1.4861
18	.3429	.3048			.2427	1.6194	1.3336
19	.381					.2858	.381
20	.381	.5144				.381	.381
21	.381	.4382			.4763	.4763	.3429
22	.3429					.4763	.3429
23	.2858					.4572	.2858
24	.2858	.2858	.381		.2054	.4191	.381
Max	1.6804	.5144	1.6804	2.0005	1.6975	1.7147	1.7147
Min	.1905	.1494	.2286	.4382	.1524	.2858	.2858
Avg	.6293	.3195	.8219	1.4480	.3916	.9878	.7573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 203 / TELKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.025	1.1416	.5624	.5883	.5967	.5845	1.9928
2	1.0006	1.1515	.5525	.5563	.5548	.7628	2.4265
3	1.0555	1.1691	.5601	.5784	.5754	.8863	2.6224
4	1.118	1.233	.5822	.6028	.6142	1.0402	2.9287
5	1.3192	1.4464	.7194	.6935	.743	1.0707	3.2899
6	.8863	1.8602	1.9639	.8794	.8375	1.278	3.4896
7	2.2039	2.1719	2.1833	.9465	.9724	3.9613	4.2249
8	2.2237	2.2489	1.1187	1.0029	1.1035	4.5207	4.8056
9	2.063	2.0492	1.3557	1.3694	1.1119	4.2376	4.8018
10	1.8099	.9374	1.2843	1.3709	.9335	3.9979	4.5824
11	2.95	2.7282	2.7438	.8238	.5632	1.9502	2.7451
12	4.3118	2.1247	4.1977	4.212	2.3701	.423	.9366
13	4.4437	2.287	4.382	4.3492	2.4448		.4466
14	4.5724		2.4768	4.3743	2.3678		.3826
15	4.5656	3.8009	2.3122	2.1536	4.286	1.1272	.8421
16	4.558	2.5629	2.2619	2.1887	4.2935	1.1447	1.1066
17	4.7142	5.2233	2.3541	2.2634	4.4818	.5449	1.3809
18	4.523	5.1616	2.3868	2.4181	2.2192	1.5844	1.6149
19	3.3661	2.5347	2.1994	2.0348	2.2093	1.8069	1.925
20	2.159	1.957	1.0067	1.0029	1.0029	1.9905	1.9974
21	1.7246	1.4792	.8246	.9214	.7872	1.749	1.8
22	1.3778	.7827	.7628	.7285	.6889	1.5447	1.6628
23	1.3069	.6417	.6501	.6668	.6729	1.4853	1.3946
24	1.0844	1.1287	1.1568	.6264	.6302	1.1797	1.3695
Max	4.7142	5.2233	4.382	4.3743	4.4818	4.5207	4.8056
Min	.8863	.6417	.5525	.5563	.5548	.423	.3826
Avg	2.5151	2.0792	1.6916	1.5563	1.5442	1.7668	2.2821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 204 / ALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5434	1.7124	.6523	.6462	.8749	.458	1.0761
2	1.6476	1.0387	.9183	1.0166	1.1683	.439	1.0723
3	1.8663	1.1629	1.1698	1.1134	1.2536	.4588	1.073
4	2.0919	1.2734	1.2155	1.0463	1.2932	.4923	1.1743
5	2.3899	1.3778	1.2902	1.1782	1.4289	.5738	1.2399
6	1.454	1.5585	3.1604	1.3481	1.6088	.7072	1.4899
7	3.9655	2.0409	4.138	1.9806	2.1536	1.8378	1.704
8	4.1472	2.3807	2.1818	1.8877	1.7231	1.7966	1.739
9	4.2902	4.6677	2.2253	4.3797	2.3777	1.525	1.4693
10	4.2318	1.7528	3.8881	4.4345	3.8763	1.2506	1.2331
11	2.242	1.9863	1.5966	2.0279	2.2397	3.5376	3.0857
12	.7887	.3384	.6242		.3399	4.5328	3.8965
13	.6736		.5655	.5746	.3041	4.6921	3.847
14	.5525		.2545	.6965	.631	3.4408	3.7814
15	.5411	.5601	.2888	.3155	.5876	4.1358	1.9006
16	.5975	.3246	.3117	.3353	.1623	4.0284	1.7871
17	.7262	.3437	.4458	.3803		4.1137	3.6252
18	.8657	.9995	.4481	.4778		4.161	3.5795
19	1.259	.7293	.679	.7758	.7423	2.3327	2.3609
20	1.5013	1.3954	.8657	.8672	1.5539	1.6065	1.7337
21	1.3268	1.2132	.663	.6142	1.2986	1.4647	1.5775
22	1.1035	.551	.5601	.5617	.5517	1.3077	1.3702
23	1.0311	.4969	.5289	.5396	.5075	1.1934	1.2406
24	.9228	1.0441	.9861	.5014	.4847	.9632	1.1378
Max	4.2902	4.6677	4.138	4.4345	3.8763	4.6921	3.8965
Min	.5411	.3246	.2545	.3155	.1623	.439	1.0723
Avg	1.6983	1.3158	1.2357	1.2043	1.2346	2.1271	2.0081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 201 / KAPSI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6325	.6325	.6325	.759	.759	.7907	.759
2		.6325		.759	.759		.759
3		.6325		.759	.759		.759
4		.759		.759	.759		1.2651
5		1.012	.7116	.8855	.8539	.9488	1.2651
6	.7907	1.2651	.9488	1.1069	1.012		1.2651
7	.9488	1.4864	.9488	1.1069	1.2651	.9488	1.1385
8	.9488	1.2651	.7907		.9488	.9488	1.1385
9		1.012	.7907			1.012	.8855
10		.8855					
11		1.3916	1.2651			1.5181	1.4074
12	1.3916	1.8976	2.0557		1.8976	1.8976	1.9292
13	2.0241	2.0241	1.9134	2.0557		2.0241	1.6446
14		1.7711	2.0399	2.1664		1.6446	
15	1.5181	1.8976	1.9134	2.0241	2.0557	1.7711	1.4232
16	1.6446	1.8976	2.0399	2.1506	1.7394	1.6446	1.5339
17	1.8976	1.7711	2.0241	2.3087	1.7394	1.6446	
18	1.8976	1.7394		1.9292		1.6446	1.4232
19	1.0911	.9488	.9488	.9488		1.1385	1.2651
20	1.012	.9488	.8855	.9488	1.2651	1.012	1.2651
21	.8855	.9488	.8855	.8855		.8855	1.1069
22	.759	.7907	.759	.759	1.1069	.759	.9488
23	.6325		.759	.759		.759	.9488
24	.7116	.6325	.7116	.759	.759	.9488	.759
Max	2.0241	2.0241	2.0557	2.3087	2.0557	2.0241	1.9292
Min	.6325	.6325	.6325	.759	.759	.759	.759
Avg	1.1741	1.2279	1.2118	1.2542	1.1786	1.2601	1.1852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 202 / MARTALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3991	2.8822	2.4014	2.9043	2.5279	2.7942	2.5812
2	1.2544	2.8807	1.2864	2.9211	2.5484	1.4937	2.5538
3	1.2803	2.8944	1.3115	2.9485	2.5736	1.4861	2.7062
4	1.3664	3.0491	1.3801	2.867	2.7039	1.5653	2.9508
5	1.7939	5.0168	5.0716	5.6371	5.5056	5.2484	5.4108
6	4.5932	6.0982	6.1465	6.9151	6.6816	3.3242	6.2491
7	5.0417	6.842	6.6067	7.1704	6.8176	7.5278	6.9673
8	5.2465	7.0399	7.0592	7.2504	7.46	7.2825	7.1963
9	4.9897	7.5084	6.2232	6.3733	3.8355	7.284	7.2162
10	4.4978	7.4783	7.5507	6.3268	7.5271	7.2543	6.8
11	2.255	3.1791	1.9532	3.3479	2.1574	3.2015	1.9601
12	1.3741	1.9487		1.9586	2.3553	1.7894	
13	1.4038	1.7239		1.6979	.8185	1.9174	
14	.7209	1.6614		1.5669	.7948	1.7421	
15	1.3862	1.5417		1.6835	2.2947		
16	1.5211	1.528	2.2969	1.97	.4047		
17	1.6406	.9602	2.5383	2.1598	2.7013	.0114	.2904
18		.1677	2.5751	.7987	1.2551	2.8312	2.7306
19	5.1143	4.7656	7.3663	6.1104	3.4248	5.5091	6.3449
20	6.4495	6.8494	7.2375	6.9448	6.8688	6.3786	6.6312
21	6.4226	7.3964	7.1003	6.9151	3.6176	6.9593	6.1363
22	6.4327	7.2836	6.8984	6.8092	6.1976	6.5257	5.8189
23	3.7449	2.9691	3.7989	3.8028	2.3	3.4164	3.6014
24	2.6292	2.7847	2.8575	2.8213	2.8525	2.6448	2.7306
Max	6.4495	7.5084	7.5507	7.2504	7.5271	7.5278	7.2162
Min	.7209	.1677	1.2864	.7987	.4047	.0114	.2904
Avg	3.1982	4.0187	4.4830	4.1625	3.5927	4.0085	4.5724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 203 / Sai Stone Crusher (Express SHEDDABLE FEEDER HAVING WEEKLY
 Fee Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.128	.1829	.1463	.1097	.1829	.0732
2		.128		.1463	.1097		.0732
3		.128		.1463	.1097		.0732
4		.128		.1463	.1097		.0732
5		.1097	.1829	.1463	.1097	.1829	.0732
6	.1829	.1097	.1829	.1463	.1097		.0732
7	.1829	.1097	.1829	.1463	.1097	.1829	.1646
8	.1829	.128	.1829	.1463	.1097	.1829	.1646
9	.1829	.1097	.1829	.128		.1463	.1646
10	.2012	.1463	.1829	.3658	.128	.2561	.1646
11	.2926	.128	.2012	.128		.2012	.0914
12	.2195	.2378	.2378	.3658	.1829	.2561	.0914
13	.4938	.2012	.0914	.3292		.128	.0914
14		.128	.1097	.2378		.1097	
15	.4024	.0914	.3292	.0914	.1829	.1097	.0914
16		.1463	.2561	.2378	.1829	.1097	.0914
17	.1097	.128	.2195	.1829	.1829	.128	
18	.2926	.1829	.1463	.3292		.1646	.1829
19	.2743	.1829	.1463	.1463		.128	.1829
20	.128	.1829	.1646	.1463	.1829	.0914	.1829
21	.128	.1829	.1463	.1097		.0732	.1829
22	.1097	.1829	.128	.1097	.1829	.1646	.1829
23	.128		.1463	.1097		.1646	.0914
24	.1829	.1097	.1829	.128	.1097	.128	.1646
Max	.4938	.2378	.3292	.3658	.1829	.2561	.1829
Min	.1097	.0914	.0914	.0914	.1097	.0732	.0732
Avg	.2154	.1439	.1803	.1798	.1383	.1545	.1239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 204 / Golegaon New

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431		1.1317	1.1317	1.0185	1.226	.9054
2		1.0185		1.1317	1.1317		.9054
3		1.0185		1.2449	1.1317		1.358
4		1.0185		1.2449	1.2449		1.358
5		1.1317	1.6975	1.4712	1.6975	1.6975	1.5844
6	1.1317	1.4712	2.2634	2.1502	1.8861		1.5844
7	1.4146	2.1502	2.2634	2.1502	1.9239	2.3577	2.2634
8	1.5089	2.1502	2.6406	2.3765	2.7161	2.6406	2.2634
9	1.1317	2.2634	2.7349	2.6029		2.3765	2.1502
10	1.0185	1.9993	2.6406	2.037	2.3765	2.1502	1.9239
11	1.6975	.679	.7922	.679		.7922	.7922
12	2.1502			.5658	1.0288	.5658	
13	2.2634	.5658		.5658		.4527	
14		.4527	.5658	.4527		.5658	
15	.3395	.4527	.5658	.4527		.5658	.5658
16	2.1502		.679	.679	1.1317	.679	.679
17	2.2822	.7922	.7922	.9054	1.1317		
18	2.2822	.8488	1.1317	.9054		1.0185	.9431
19	1.4712	1.226	1.358	1.4712		1.4712	1.5089
20	1.358	1.3203	1.358	1.358	1.5089	1.358	1.6032
21	1.2449	1.3203	1.2449	1.2449		1.2449	1.5089
22	1.0185	1.1317	1.1317	1.0185	1.3203	1.1317	1.3203
23	1.0185		1.0185	.9054		1.1317	1.1317
24	1.1317	.9054	.9431	1.0185	.9054	1.1317	1.0185
Max	2.2822	2.2634	2.7349	2.6029	2.7161	2.6406	2.2634
Min	.3395	.4527	.5658	.4527	.9054	.4527	.5658
Avg	1.4503	1.1958	1.4186	1.2401	1.4769	1.2925	1.3684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 201 / GOLEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.1307
2				.8573			.1307
3							.1307
4		.8059	.5144	.9259	.4656	.1307	.1254
5							.1433
6	.6473					.1867	.1791
7						.1848	.1791
8		1.1488	1.3032	1.2346	1.1488	.1848	.1791
9						.1478	.1791
10	.9755	.0747	1.0974	.9556	1.1191	.1307	.1079
11					.112	.8916	.6165
12	.1543	.0747	.1029	.0617	.0914	.9774	.8323
13					.0747	.9431	
14				.0617	.0747	.9088	
15					.0747	.9054	
16	.1372	.0747	.1029	.0771	.0747	.9602	
17					.0934	.9221	
18		.112	.1543	.0914	.112	.9326	
19			.1715			.1494	.1387
20		.1307		.1233	.1307	.1494	.1233
21			.1543			.1307	
22		.1307			.1307	.1307	.1079
23			.12		.1307	.1307	
24	.0925	.1509	.132	.12	.1132	.1307	.1079
Max	.9755	1.1488	1.3032	1.2346	1.1488	.9774	.8323
Min	.0925	.0747	.1029	.0617	.0747	.1307	.1079
Avg	.4014	.3003	.3853	.4509	.2631	.4614	.2132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 202 / SHIRADHON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.4973
2				.5144			.4973
3							.5087
4		.5487		.6173	.5731	.6859	.5487
5							.583
6	.6757					.763	.6173
7						.7969	.7716
8		1.0974	1.0974	1.0288	1.0059	.8718	.7461
9						.9259	.823
10	.1021	.9945	1.2003	1.0173	1.0174	.9774	.709
11					.0934	1.0208	
12	.2058	.2987	.12	.2004	.0934		
13					.0747		
14				.185	.0747		
15					.0857	.6447	
16	.1715		.1029	.0771	.0857	.6687	
17					.5601	.823	
18		.1307	.1543	.0925	.6584	.8648	
19			.1715			.8145	.7707
20		.823		.6936	.6584	.7783	.7398
21			.6859			.8145	
22		.6859			.6653	.9745	.6011
23			.6173		.695	1.0269	
24	.5549	.5228	.6344	1.0173	.5086	.695	.6011
Max	.6757	1.0974	1.2003	1.0288	1.0174	1.0269	.823
Min	.1021	.1307	.1029	.0771	.0747	.6447	.4973
Avg	.342	.6377	.5316	.5444	.4567	.8322	.6439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 203 / JOSHI SANGVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6626
2				.1715			.6344
3							.6443
4		.1372	.1509	.1886	.1509	.9816	.6443
5							.763
6	.2004					1.4918	1.5939
7						1.7238	1.9951
8		.1886		.2572	.2427	1.9393	2.1874
9						1.8896	2.4034
10	.1886	.1886	.1543	.1387	.2054	1.8564	.5857
11					1.5581	.1867	.0925
12	1.8861	2.0622	1.8004	1.7879	2.1051	.1867	.0617
13					2.079	.1494	
14				1.7417	2.0119		
15					2.0056	.1307	
16	2.2291	2.079	2.1776		2.0056	.1307	
17					1.9062	.1307	
18		2.0287	1.9719	1.6338	1.9281	.1307	
19			.1886			.1509	.2004
20		.168		.1541	.1509	.1494	.1541
21			.2058			.1494	
22		.168			.1494	.168	.1541
23			.2058		.1698	.168	
24	.1233	.1494	.1509	1.8804	.1233	.1698	.168
Max	2.2291	2.079	2.1776	1.8804	2.1051	1.9393	2.4034
Min	.1233	.1372	.1509	.1387	.1233	.1307	.0617
Avg	.9255	.7966	.7785	.8838	1.1195	.6255	.8091

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 205 / Osmannagar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6344
2				.3086			.6516
3							.6516
4		.8573	.3018	.3429	.2614	1.2209	.6443
5							.763
6	.894					1.5089	1.1869
7						1.5592	1.5939
8		.2229		.3944	.4294	1.9616	1.6766
9						1.9113	1.95
10	.2229	.2614	.3429	.1079	.3734	1.861	1.6954
11					1.6095	.197	.2004
12	1.1831	1.7833	1.1831			.2012	.2004
13					1.7833	.2241	
14				1.418	2.1874	.2241	
15					2.1605	.2241	
16	2.1434		2.1262		2.1125	.2241	
17					2.0576	.2801	
18		.6173	1.8861	1.9266	1.989	.2801	
19			.3772			.3018	.3391
20		.2401		.2774	.2075	.3547	.3391
21			.4115			.2987	
22		.2987			.2614	.2987	.2774
23			.3772		.2829	.2801	
24	1.0327	.9259	.4527	1.8496	.2312	.2801	.2801
Max	2.1434	1.7833	2.1262	1.9266	2.1874	1.9616	1.95
Min	.2229	.2229	.3018	.1079	.2075	.197	.2004
Avg	1.0952	.6509	.8287	.8282	1.1391	.6846	.8178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 201 / SONKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7666	.7636	.7026	.7087	.7255	.8291	.8695
2	.695	.8001	.6965	.6996	.7171	.756	.8634
3	.8296	.8009	.7217	.7125	.7476	.7544	.9571
4	.9724	.9129	.8596	.8436	.8207	.8123	1.2407
5	1.2288	1.238	1.0867	1.1431	1.0479	1.156	1.504
6	1.4205	1.3695	1.3245	1.4221	1.3367	1.4777	1.603
7					.0549		
8	.3147					.2736	
9	1.4838	1.6	.7727	1.5105	1.4686	1.4655	1.5044
10	1.4701	1.4701	1.3299	1.4617	1.4838	1.3599	1.3162
11	1.3027	.3597	1.1866	1.1744	1.1195	1.1393	1.0265
12	1.1203	.2157	1.0654	1.0829	.9807	.9576	1.0646
13	1.0585		.9561	1.0433	.8878	.9225	.9561
14	.8939		.9614	.8939	.8223	.9164	.9187
15	.8725	1.0509	.934	.0686	.8489	.8334	.9035
16	.9473	1.1493	.2477	1.0303	.7415	1.0844	.9035
17	1.0844	1.2102	.1067	1.1302	.8817	1.089	.471
18	1.2189	1.0318	1.2631	1.2944	1.0661	1.2768	1.0578
19	1.5703	1.3733	1.4442	1.3134	1.3611	1.4373	1.2684
20	1.3599	1.1583	1.3401	1.198	1.2384	1.1972	1.0273
21	.9785	1.041	1.0593	1.07	.948	1.0882	.9431
22	.8893	.9129	.9332	.8764	.9045	1.0783	.9301
23	.8413	.6752	.8055	.8558	.8725	.9068	.8433
24	.8284	.7476	.7331	.7872	.7986	.884	.8093
Max	1.5703	1.6	1.4442	1.5105	1.4838	1.4777	1.603
Min	.3147	.2157	.1067	.0686	.0549	.2736	.471
Avg	1.0499	.9941	.9332	1.0146	.9511	1.0302	1.0446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 203 / Dagadgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3048	.3048	.2286		.3048	.381
2	.2572	.3048	.3048	.2286		.3048	.381
3	.3429	.3048	.3048	.3048		.3048	.381
4	.3429	.3353	.3048	.3048		.3048	.4572
5	.3429	.381	.3048	.3353		.3048	.5144
6	.3429	.381	.381	.3353		.381	.5144
9						1.2003	1.5432
10					.2286	1.0669	1.4003
11	.5144	.381	.5144	.4572	.5144	1.5242	1.467
12	.5144	.4572	.4572	.5144	.4572	1.467	1.467
13	.4572		.5335	.5144	.5335	1.6004	1.6766
14	.381		.6001	.5144	.5335	1.5242	1.6766
15	.5144	.4572	.6001		.5335	1.6004	1.6766
16	.5144	.5335	.6001	.381	.5335	1.3336	1.6289
17	2.4006	2.0576	1.5432	2.3148	1.9814	.3048	
18	2.4006	2.1338	2.0576	2.3148	1.9052	.381	.4287
19	2.0576	1.448	1.8004	1.8861	1.2955	.5487	.5144
20	1.7147	.9145	1.3717	1.6289	1.2955	.5487	.5144
21	1.7147	1.0669	1.2003	.3048	1.2193	.5144	.5144
22	1.6289	1.2193	1.4022	.3048	1.2193	.4268	.5144
23	1.5432	1.0669	1.3717		1.2193	.4268	.4801
24	1.3717	1.4575	1.0669	1.2955		1.1431	.381
Max	2.4006	2.1338	2.0576	2.3148	1.9814	1.6004	1.6766
Min	.2572	.3048	.3048	.2286	.2286	.3048	.381
Avg	.9807	.8447	.8512	.7871	.9621	.7962	.8816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 204 / Dapshed Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048	.3048	.3048	.3048	.3048	.3353
2	.3429	.3353	.3048	.3048	.3048	.3048	.381
3	.4287	.3353	.3048	.3048	.3048	.3048	.381
4	.4287	.381	.381	.3048		.3048	.4268
5	.4287	.5144	.381	.381	.4801	.381	.5144
6	.5144	.5144	.4572	.4572	.5487	.4572	.5144
9	1.2003	1.1317		1.0288	1.286		
10	1.1145	1.1145	.9907	1.1145	1.2003		
11	1.0288	.9145	1.1145	1.1145	1.0288	.4287	.4287
12	.9431	.9145	1.1145	1.1145	.7621	.4287	.3429
13	.8916		1.0288	.8573	.7621	1.8004	.2572
14	.6859	.9145	1.0288	1.0288	.7621	.2572	.1715
15	.9259	1.0669	1.1145	1.0288	.7621	.2572	.1715
16	1.0288	1.0669	1.2003	1.0288	.8383	.3429	.3429
17	.2743		.3429	.3353	.2286	1.2346	
18	.3353		.3429	.3048	.3048	1.2346	1.2003
19	.5144	.4572	.5144	.4801	.4572	1.1145	1.1145
20	.5144	.4572	.4287	.381	.4572	.9431	1.0288
21	.381	.381	.4287	.3658	.381	.8916	.0857
22	.3353	.381	.3772	.3353	.3048	.9259	.8573
23	.3048	.3048	.3772	.3353	.381	.8916	.8573
24	.4287	.3048	.381	.3772	.3353	.381	.7716
Max	1.2003	1.1317	1.2003	1.1145	1.286	1.8004	1.2003
Min	.2743	.3048	.3048	.3048	.2286	.2572	.0857
Avg	.6088	.6208	.6152	.6040	.5807	.6595	.5360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 201 / MALAKOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1077	1.3251		.6355	1.1963	.3385	
2	1.2074	1.4385		.7278		.3021	
3	1.3016	1.3889		.7278		.3018	
4	1.4876	1.4377		.9212		.3018	
5	1.5806	1.5418		1.0164		.3381	
6	1.665	1.5887		1.2963		.5584	
7	2.2314	2.2546		.9326		.5584	
8	2.641	2.6548	2.4717	1.2012		.5453	1.0871
9	2.3289		2.3752	1.11	2.5419	.4923	.8179
10	2.3289		1.829	1.7231	2.3727	.4091	1.1876
11	1.0997		1.1913	1.1008	.3669	1.4046	2.0077
12	1.0219		.8945	.8085	.3077	2.272	2.2434
13	.9124		.6255	.8085	.2706	2.3529	2.3997
14	.7514		.4449	.8642	.2341		2.1193
15			.0894	.9211	.2341		2.2243
16		.8093	.0893	1.0409	.2156	2.1719	1.6101
17		.8633	.0893	.9134	.2338	1.9951	2.3232
18		.8983	.8954	1.1139	.3064	2.1788	2.3207
19		1.3589	1.4464	1.356	1.4132	1.2309	1.448
20		1.3717		1.3073	.5118	1.6097	
21		1.287	.6965	1.3503			.8145
22		1.1754	1.2376	1.2867		1.327	1.3289
23		.9949	1.1393	1.1581			1.1393
24	1.0494	1.1595	.8273	1.0448	1.1356	.3738	
Max	2.641	2.6548	2.4717	1.7231	2.5419	2.3529	2.3997
Min	.7514	.8093	.0893	.6355	.2156	.3018	.8145
Avg	1.5143	1.3852	1.0214	1.0569	.8101	1.0531	1.6714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 202 / MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1108	.1104		.1089		.1128	
2	.1115	.1107		.1092		.1133	
3	.1116	.1296		.1092	.1295	.1132	
4	.1302	.1494		.129		.1509	
5	.1488	.1672		.1294	.1658	.1691	
6	.148	.1869		.1852		.2056	
7	.2395	.2587		.2425	.2772	.2234	
8	.255	.2929	.2563	.2402	.255	.2553	.2718
9	.2183		.2193	.2405	.0908	.2188	.2726
10	.1638		.1463	.1451	.073	.2045	.1827
11	.165		.1193	.1651	.1651	.0375	.1095
12	.1793		.161	.1639	.1991	.0364	.1077
13	.1789		.1251	.1437	.2165	.0362	.1067
14	.1605		.1424	.144	.18		.0706
15			.1251	.1445	.162		.1068
16		.1439	.1071	.1436	.1437	.0905	.1073
17		.1619	.125	.2149	.1439	.0726	.1072
18		.1797	.1791	.1797	.1442	.1634	.143
19		.1449	.217	.1808	.0754	.1894	.181
20		.1829	.1959	.1634	.0758	.2083	.1987
21		.1839	.1741	.18	.0755	.1894	.181
22		.1653	.1591	.143	.0563	.1517	.124
23		.1658	.1227	.1228	.0563		.1227
24	.1049	.1104	.1287	.3048	.1048	.0374	
Max	.255	.2929	.2563	.3048	.2772	.2553	.2726
Min	.1049	.1104	.1071	.1089	.0563	.0362	.0706
Avg	.1617	.1673	.1590	.1681	.1395	.1419	.1496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 203 / ASHTUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6646	.7546		.6718	.6626	.7146	
2	.7059	.7746		.6732		.8307	
3	.8368	.7407		.7278	.666	.9054	
4	.8368	.8402		.8659		1.0562	
5	.9297	1.0588		.924		1.315	
6	1.11	1.1214		1.0741	1.1088	1.4018	
7	1.3265	1.4415		1.2497	.0554	1.5263	
8	1.3478	1.3732	1.3549	1.2012	1.2203	1.9084	2.0474
9	1.0553		1.2607	.9805	.3631	1.878	2.0175
10	.7642		.823	.8343	.3468	1.8967	1.6261
11	1.4479		1.3013	1.1559	1.0641	.3371	.6206
12	2.0617		1.8248	1.7303	1.5565	.2908	.3769
13	1.9679		1.7692	1.8325	1.5877	.2715	.5155
14	1.8784		1.7617	1.6204	1.5844		.4062
15			1.5369	1.5894	1.5123		.5338
16		1.7985	1.6424	1.705	1.4912	.8326	.5546
17		1.8345	1.7316	1.7551	1.3951	.7255	.6433
18		1.8685	1.7551	1.7068	1.3157	1.1075	.6784
19		.9603	.9583	.9763	.4522	1.4014	.9412
20		.9511	.8372	.926	.5118	1.3635	1.0476
21		.9193	.7836	.8102	.472	1.3256	.8326
22		.8816	.7249	.7327	.4504	1.2132	.7973
23		.8106	.6661	.6492	.3941		.7011
24	.6121	.7178	.6986	.6269	.6289	.3551	
Max	2.0617	1.8685	1.8248	1.8325	1.5877	1.9084	2.0474
Min	.6121	.7178	.6661	.6269	.0554	.2715	.3769
Avg	1.1697	1.1087	1.2606	1.1258	.8971	1.0789	.8963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 204 / Limboti Dam (Old Express) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0186	.0184		.0182	.0184	.0188	
2	.0186	.0173	.1462	.0182		.0189	
3	.0186	.0185		.0182	.0185	.0189	
4	.0186	.0187		.0184		.0189	
5	.0186	.0186		.0185	.0185	.0188	
6	.0185	.0187		.0185	.0185	.0187	
7	.0921	.0554		.0746		.0186	
8	.1821	.1465	.1465	.1848	.0182	.1818	.1631
9	.1819		.1462	.185	.0182	.1459	.1636
10	.0182		.0549	.0726	.0183	.1116	.0183
11	.0183		.0183	.0183	.0183	.0187	.0183
12	.0179		.0179	.0182	.0181	.0182	.0179
13	.0179		.0179	.018	.018	.0181	.0178
14	.0179		.0178	.018	.018		.0177
15			.0179	.0181	.018		.0178
16		.018	.0179	.0179	.018	.0181	.0179
17		.018	.0179	.0179	.018	.0181	.0179
18		.018	.0179	.018	.018	.0182	.0179
19		.0181	.0181	.0181	.0188	.0189	.0181
20		.0183	.0178	.0182	.019	.0189	.0181
21		.0184	.0174	.018	.0189	.0189	.0181
22		.0184	.0177	.0179	.0188	.019	.0177
23		.0184	.0175	.0175	.0188		.0175
24	.0175	.0184	.0184	.0174	.0175	.0187	
Max	.1821	.1465	.1465	.185	.019	.1818	.1636
Min	.0175	.0173	.0174	.0174	.0175	.0181	.0175
Avg	.0450	.0280	.0413	.0366	.0183	.0369	.0361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 201 / PENUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.6859	.6859		.5335	
2	.6859		.7316			.5335	.6859
3	.6859		.7621			.4572	
4	.6859		.7621	.7716		.4572	.6859
5	.6859		.7926		.7621	.4268	
6	.6859		.7926	.7716		.7011	.6859
7	1.3717		.7926		.9145	.6401	
8	1.3717	.6097	.8535	1.0288		.6249	.823
9	1.1279	.5335	.8573	.5182	.6097		.6097
10					.6097	.6859	.5487
11		.4572			.7621		.6706
12		.7926		.8383	.9145	1.0288	.8383
13		.9145	1.0288	.8383	.9145		
14		.8688	.9431	.8383		1.0288	
15		.6859		.8383			
16		.8383	1.0288	.884		1.2003	.7011
17	.4115	.8383		.6401	.6097		
18	.4572	.9145	1.0288	.7468	.6097	1.0288	.9145
19		.7621			.6859		
20		.6859	.7716	.7011	.6401	.6859	
21		.6859		.6554	.6097		
22		.6859			.6097	.0686	
23			.6859		.6097	.7716	
24	1.0212	.6097		.6859	.6097	.6859	.6859
Max	1.3717	.9145	1.0288	1.0288	.9145	1.2003	.9145
Min	.4115	.4572	.6859	.5182	.6097	.0686	.5487
Avg	.8231	.7255	.8345	.7628	.6981	.6799	.7136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 202 / ANTESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		.1524			.2286	
2	.5335		.1524	.1715		.2286	.3429
3	.5335		.1524			.2286	
4	.5335		.1524	.1715		.3048	.3429
5	.5335		.1524		.3048	.3048	
6	.5335		.1524			.381	.3429
7	.4572		.1524		.4572	.3048	
8	.4572	.1524	.1524	.1715		.3048	.3429
9	.4572	.1524	.1524	.1524	.3048		.3048
10				.1524	.2286	.2572	.3048
11		.6097	.6859		.5792		.381
12	.1524	.6401		.4572	.7316	.7716	.4572
13		.6401	.6859	.6097	.7316		
14		.6859	.7716	.6859		.7716	
15		.6859		.6859			
16		.6097	.7716	.6859		.7716	.5335
17	.1524	.6097	.6859	.7621	.4572		
18	.1524	.6554	.7716	.6859	.5335	.5144	.6097
19		.1524			.7011		
20		.1524	.2058	.2286	.8383	.3429	
21		.1524		.1524	.5335		
22		.1524	.2058		.4572	.3429	
23			.1715		.2286	.2572	
24	.4572	.1524		.1829	.1524	.2286	.3429
Max	.5335	.6859	.7716	.7621	.8383	.7716	.6097
Min	.1524	.1524	.1524	.1524	.1524	.2286	.3048
Avg	.4162	.4136	.3515	.3971	.4826	.3849	.3914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 203 / Godawari Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669						
2	1.0669						
3	1.0669						
4	1.0669						
5	.1189						
6	1.0669						
7	1.5242						
8	1.6766						
9	1.6004						
11		1.4632	1.7147		1.7375	1.8861	1.7375
12		1.6156		1.7528	1.8747	2.0576	1.768
13		1.6766	2.0576	1.829	1.89		
14		1.7375	1.8861	1.9052		2.0576	
15		1.7071		1.9814			
16		1.6461	1.8861	1.89		2.0576	1.768
17		1.7375		1.8595	1.7985		
18		1.7528	1.8861	1.8747	1.829	2.0576	1.8442
19					1.829		
20					1.7985		
21					1.829		
22					1.89		
24	1.6156						
Max	1.6766	1.7528	2.0576	1.9814	1.89	2.0576	1.8442
Min	.1189	1.4632	1.7147	1.7528	1.7375	1.8861	1.7375
Avg	1.1870	1.6671	1.8861	1.8704	1.8307	2.0233	1.7794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 201 / Mohanpura Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3086	.3361		.3547	.3772
2			.3086	.3361		.3547	.3734
3			.3086	.3361		.3547	.3734
4	.4066	.3772	.4801	.4481	.4115	.3547	.3734
5			.6173	.5601		.3734	.4481
6			.7202	.6722		.4805	.5544
7			.8402	.8029		.6653	.8316
8	.7762	.7202	.7545	.6722	.6687	.5544	.6653
9				.7468		.5544	.5121
10			.4287	.5601	.3429	.5487	.463
11			.3086		.3734	.3292	.2743
12	.2241	.2401	.2058	.2058			.2058
13			.1715		.2772	.2195	.2058
14			.1715		.2033	.2241	.1715
15			.1886		.2033	.2241	.2229
16	.2241	.2743	.2229	.2401	.2218	.2614	.2401
17			.2743		.2587	.2801	.2743
18			.3429		.3326	.3547	.3944
19			.583	.5316	.3696	.5415	.5144
20	.5228	.4801	.5487		.4066	.4668	.4801
21			.4801		.3734	.4481	.4115
22		.3772	.4115		.3511	.4294	.3772
23			.3429		.3547	.3921	.3429
24	.3547	.3429	.3258	.3086	.3086	.3547	.3734
Max	.7762	.7202	.8402	.8029	.6687	.6653	.8316
Min	.2241	.2401	.1715	.2058	.2033	.2195	.1715
Avg	.4181	.4017	.4063	.4826	.3411	.3966	.3942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 203 / Betsangavi Agri

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.4937	1.531		.6653	1.4045
2			1.587	1.6057		.6653	1.4784
3			1.6804	1.6804		.6653	1.4784
4	1.1458	1.7551	1.7737	1.7924		.7392	1.4632
5			1.7924	1.8671		.7392	1.6827
6			2.0538	1.9605		.7682	1.8107
7			2.2592	.9335		.9877	2.1719
8	1.4632	2.4272	2.4272		1.829	2.0119	2.2862
9				2.2405		2.1033	2.2805
10			1.9605	2.3152	1.8595	2.0271	1.89
11			.1132			.0943	.0343
12	.0754	.0457	.1132	.0305	.1307		.0686
13			.0943				.0686
14			.0943				.0514
15			.0754				.0514
16		.0457	.0754				.0754
17			.0754				.0686
18			.1132		.0934	.1132	.1029
19			.1509	.0457	.1494		.1715
20	.1509	.061	.1509		.1494	.1886	.1543
21			.1509		.1494		.1372
22		.061	.132		.1307	.1698	.1029
23			.132		.1132	.132	.0857
24	.112	1.8671	.0514	.1109	.0457	.1132	.132
Max	1.4632	2.4272	2.4272	2.3152	1.8595	2.1033	2.2862
Min	.0754	.0457	.0514	.0305	.0457	.0943	.0343
Avg	.5895	.8947	.8065	1.3428	.4650	.7615	.8021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 204 / Jawala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1886	.1886		.2241	.2263
2			.1886	.1886		.2241	.2263
3			.1886	.1886		.2241	.2263
4	.1848	.2263	.2263	.2075	.2058	.2241	.2263
5			.2263	.2075		.2801	.2452
6			.2641	.2263		.3511	.2614
7			.1886	.2263		.4805	.3174
8	.3696	.2829	.3395		.3601	.4024	.2241
9				.1509		.3696	.2801
10			.2641	.2075	.3086	.3142	.1372
11			.6161			.6767	.6001
12	.8402	.6516	.7468		.7762	.7023	.6859
13			.7842		.7682	.7392	.6859
14			.7842		.7392	.7316	.6516
15			.7468			.7316	.6516
16	.7655	.7716	.7468	.7202	.7207	.7316	.6859
17			.7655		.6767	.7392	.703
18			.7282		.6838	.7207	.5335
19			.415	.3772	.3142	.2801	.2401
20	.3018	.5658	.3395		.3734	.3734	.2572
21			.3018		.3174	.3734	.2743
22		.2572	.2641		.2587	.2801	.2743
23			.2452		.2241	.2263	.2743
24	.1494	.1886	.2058	.2263	.2058	.2218	.2263
Max	.8402	.7716	.7842	.7202	.7762	.7392	.703
Min	.1494	.1886	.1886	.1509	.2058	.2218	.1372
Avg	.4352	.4206	.4246	.2596	.4622	.4426	.3798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 201 / Janapuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3563	.4096		.3353	.4475		.1886
2	.4858	.4588		.3605	.4641		.1886
3	.5182	.4915		.4096	.4973		.1905
4	.5668	.5735		.5182	.5735		.2286
5	.6554	.663		.6226	.6299		.2477
6	.7377	.8288		.7042	.7459		.3018
7	1.0774	1.1603		.9831	1.1271		.3961
8	.8192	1.3592		1.1336	1.3108		.3772
9	1.326			1.2597			.3395
10	1.2631			1.166			
11	.2263		.1132	.1886		1.0774	
12	.1698		.132	.1886		1.3923	
13	.1494		.1509	.1886		1.3763	
14	.168		.1698	.1698		1.4746	
15	.168		.1294	.1886		1.3603	
16	.168		.1509	.1886		1.2803	
17	.168		.2263	.2263		1.3435	
18	.1886		.2641	.2829		1.2803	
19	.3772		.3206	.3395		.3395	
20	.3395		.2829	.2829		.2614	
21	.2801		.2452	.2614		.2427	
22	.2452		.2263	.2402		.2241	
23	.2263		.2075	.2241		.2054	
24	.1509	.2263		.2075	.2241		.1867
Max	1.326	1.3592	.3206	1.2597	1.3108	1.4746	.3961
Min	.1494	.2263	.1132	.1698	.2241	.2054	.1867
Avg	.4513	.6857	.2015	.4446	.6689	.9122	.2645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 202 / Wadepuri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3772		.3772	.3772		.39
2	.3584	.3772		.3772	.3961		.4578
3	.3584	.3772		.3772	.3961		.503
4	.3772	.415		.3961	.3961		.5365
5	.4572	.4904		.4763	.4904		.5801
6	.6413	.679		.6224	.6036		.7716
7	.7922	.7468		.7545	.7545		.9389
8	.811	.679		.5281	.7922		1.0898
9	.7167			.7167			1.1271
10	.6413			.6036			
11	.9717		.8848	.7202		.3772	
12	1.1203		1.0486	.9831		.3429	
13	.9922		1.0688	.9717		.2858	
14	1.0753		1.0562	.9282		.1905	
15	.9804		.9172	.8855		.1905	
16	1.0402		.9717	.9602		.3048	
17	1.0402		.9995	.9602		.4001	
18	1.0402		.9602	1.0402		.4572	
19	.6722		.6602	.679		.679	
20	.679		.6602	.6602		.5658	
21	.5093		.4715	.5281		.4904	
22	.415		.4527	.4338		.4527	
23	.3772		.415	.4108		.415	
24	.3772	.3772		.3772	.3961		.3772
Max	1.1203	.7468	1.0688	1.0402	.7922	.679	1.1271
Min	.3584	.3772	.415	.3772	.3772	.1905	.3772
Avg	.7001	.5021	.8128	.6570	.5114	.3963	.6772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 203 / Ratneshwari Gaothan
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3395		.3772	.415		.3734
2	.3772	.3395		.3772	.415		.3772
3	.3772	.3395		.3772	.4715		.4527
4	.3772	.3772		.415	.4715		.5281
5	.5281	.4668		.5281	.6602		.5658
6	.679	.6602		.679	.7842		.6722
7	.8215	.8402		.8589	.8589		.8962
8	.8215	.8402		.8589	.924		.7762
9	.6908			.7655			.5601
10	.6535			.7095			
11	.4715		.5228	.1509		.4481	
12	.4066		.4108	.1463		.3961	
13	.3292		.3734	.1214		.3361	
14	.3544			.104		.3292	
15	.3658			.104		.3292	
16	.4066		.1187	.112		.362	
17	.499		.5544	.5281		.4435	
18	.5544		.6219	.5975		.5175	
19	.6653		.6908	.7095		.6722	
20	.5601		.5975	.6602		.5544	
21	.4668		.4481	.5281		.4854	
22	.4108		.3961	.462		.4481	
23	.3734		.3961	.4481		.4108	
24	.3772	.3734		.3772	.4108		.3734
Max	.8215	.8402	.6908	.8589	.924	.6722	.8962
Min	.3292	.3395	.1187	.104	.4108	.3292	.3734
Avg	.4977	.5085	.4664	.4582	.6012	.4410	.5575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 201 / 11KV MUDKHED (U)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	07-MAR-17
HR	Load (MW)
15	.8764
16	.964
Max	.964
Min	.8764
Avg	.9202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 202 / 11KV MENDAKA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	07-MAR-17
HR	Load (MW)
15	.2343
16	.2343
Max	.2343
Min	.2343
Avg	.2343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 203 / 11KV IZALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	07-MAR-17
HR	Load (MW)
14	1.6004
15	1.6404
16	1.6404
20	.6936
Max	1.6404
Min	.6936
Avg	1.3937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 204 / 11KV DONGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	07-MAR-17
HR	Load (MW)
15	.2343
16	.2372
Max	.2372
Min	.2343
Avg	.2358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 205 / 11KV CRPF EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	07-MAR-17
HR	Load (MW)
14	.0905
16	.0905
20	.0905
21	.0905
Max	.0905
Min	.0905
Avg	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 201 / CHAINAPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	.6859	1.7147	1.3717	1.7147	.3772	.3506
2	2.0576	.6859	1.7147	1.5242	1.7147	.3772	.3506
3	2.0576	.6859	2.1434	1.5242	1.7147	.3772	.3658
4	2.2291	.6859	2.2291	1.6004	1.7147	.3944	.3658
5	2.4006	.6859	2.572	1.6004	1.7147	.4801	.3963
6	2.4006	.7716	2.6578	1.6766	1.8861	.4801	.4268
7	2.4863	.8573	2.692	1.6766	1.8861	.3944	.4572
8	2.4348		2.6578	1.5242	1.7909	.3429	.3048
9	2.4006		2.572	1.5242	1.7147	.3429	.2743
10	2.1338		2.2862	1.448	1.7147	.3048	.2743
11		.1715	.1524	.1829	.1715	1.9814	1.9814
12		.1715	.1524	.1524	.1715	1.9814	1.9814
13		.2058	.1524	.1524	.1715	1.9814	1.9052
14		.1715	.1524	.1524	.1715	1.829	1.6766
15		.1715	.1524	.1524	.1715	1.829	1.5242
16		.1715	.1524	.1524	.1886	1.6766	1.3717
17		.2572	.1524	.1524	.2229	1.6766	1.3717
18	.3048	.3429	.1524	.1524		1.6766	1.5242
19	.3506	.4801	.381	.381		.3658	.4115
20	.3658	.4801	.381			.381	
21	.381	.463	.381			.381	.3963
22		.4287	.381			.3658	.381
23		.4287	.3658			.3658	.381
24	.4287	.4115	.4287	.3658	.3944	.4801	.3658
Max	2.4863	.8573	2.692	1.6766	1.8861	1.9814	1.9814
Min	.3048	.1715	.1524	.1524	.1715	.3048	.2743
Avg	1.6098	.4483	1.1157	.8734	1.0683	.8684	.8191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 202 / 11KV BARASGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.583	.5144	.4877	.5144	2.7435	1.9814
2	.5144	.583	.5658	.4877	.5144	3.0864	2.2862
3	.5144	.583	.5658	.5182	.5144	3.0864	2.2862
4	.5144	.6173	.6001	.5487	.5144	3.2579	2.5911
5	.6001	.6859	.6859	.6097	.6001	3.4294	2.5911
6	.6859	.8573	.7716	.7621	.7716	3.5151	2.8959
7		.7888	.823	.7926	.8573	3.6008	3.0483
8		3.4294	.6859	.7621	.7716	4.0809	3.0483
9						4.0809	3.0483
10			.4572			3.5056	3.0483
11	3.658	3.4294	1.0669	2.8959	3.7723		.3048
12	3.658	4.2524		3.2007	3.7723		.3048
13	3.5056	4.1152	3.3532	3.3532	3.7723	.3048	.3048
14	3.5056	3.7723	3.5056	3.3532	4.1152	.3048	.3048
15	3.5056	3.6008	3.5056	3.3532	4.1152	.3048	.3048
16	3.5056	3.6008	3.3532	3.3532	4.1152		
17		3.4294	3.3532	3.2007	4.1152		
18	3.3532	3.4294	3.0483	3.0483		.4572	.4572
19	.7926	.7545	.7621	.7621		.7621	.7621
20	.6097	.7202	.6859			.7316	
21	.5182	.6173	.6097			.6706	.6401
22		.5658	.5792			.6097	.6097
23		.5658	.5487			.5792	.5792
24	.6001	.583	.5487	.5182	.5144	.5144	.5182
Max	3.658	4.2524	3.5056	3.3532	4.1152	4.0809	3.0483
Min	.5144	.5658	.4572	.4877	.5144	.3048	.3048
Avg	1.7974	1.8893	1.3905	1.7782	2.0844	1.9813	1.5198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 203 / BARAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.394	.4119	.4287	.4115	.4119	.394	.4287
2	.394	.394	.4287	.4115	.394	.394	.4287
3	.4119	.394	.4287	.4115	.394	.394	.4287
4	.4656	.394	.4287	.4287	.4119	.5014	.463
5	.5014	.4656	.4801	.463	.4477	.5373	.4973
6	.5731	.5552	.5144	.5144	.5014	.5373	.5487
7	.6089	.6268	.6173	.5658	.591	.6089	.6173
8			.5373	.4973	.591	.5373	.5487
9			.4973	.4973	.5552	.5014	.4801
10	.4115		.4287	.4477	.4477	.4115	.4458
11	.3601	.3582	.3429	.3772	.394	.3772	.4115
12	.3772	.4477	.3429	.394	.394	.3772	.4115
13	.3944	.394	.2915	.394	.394	.3601	.3944
14	.3772	.3582	.2915	.394	.394	.3772	.3944
15	.3772	.3403	.3086	.3772	.394	.3772	.4115
16	.3601		.3429	.3772	.3772	.3772	.4115
17	.3772		.3772	.3944	.3601	.3944	
18	.3944	.4656	.4287	.4115		.4115	
19	.5487	.591	.5316	.5658		.4115	
20	.5144	.5487	.5144			.4287	
21	.4458	.5144	.4801			.4287	.5487
22		.463	.463			.4287	.5144
23		.4477	.4287			.4287	.4801
24	.4656	.4298	.4287	.4287	.4298	.4477	.4287
Max	.6089	.6268	.6173	.5658	.591	.6089	.6173
Min	.3601	.3403	.2915	.3772	.3601	.3601	.3944
Avg	.4376	.4526	.4318	.4381	.4379	.4351	.4647

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 204 / SHEMBOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.7147	1.7147	1.6766	2.2291	.5144	.4572
2	2.0576	1.7147	1.7147	1.9814	2.2291	.5144	.4572
3	2.0576	2.0576	2.0576	2.2862	2.572	.5144	.4268
4	2.2291	2.0576	2.0576	2.2862	2.572	.5144	.4268
5	2.2291	2.2291	2.4006	2.5911	2.915	.5487	.4877
6	2.4006	2.2291	2.4006	2.5911	3.0864	.6001	.5792
7	2.4006	2.572	2.572	2.7435	3.0864	.5144	.6097
8	2.4006		2.572	2.8959	3.2579		.5335
9	2.4006		2.4863	2.8959	3.2579		.4572
10	2.1338		2.1338	2.8959	3.2579		.4572
11			.3048	.3048		2.5911	2.1338
12				.2743		2.5911	2.4387
13			.3048	.2743		2.7435	2.5911
14		.3429	.3048	.3048		2.7435	2.5911
15			.2286	.3048			2.4387
16		.3429		.3048		2.5911	2.2862
17		.4287		.3048		2.2862	2.4387
18	.4572	.4287	.381	.381		2.1338	2.4387
19	.5335	.583	.5792	.4877		.4877	.5487
20	.5182	.583	.5487			.5182	
21	.4572	.5487	.5182			.5182	.4877
22		.5144	.4877			.4877	.4572
23		.5144	.4877			.4877	.4268
24	.5144	.5487	.5144	.4572	.5144	.5144	.4877
Max	2.4006	2.572	2.572	2.8959	3.2579	2.7435	2.5911
Min	.4572	.3429	.2286	.2743	.5144	.4877	.4268
Avg	1.6565	1.1418	1.2748	1.4121	2.6344	1.2208	1.1590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 205 / Barad AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.8573	1.2193
2						1.0288	1.2193
3						1.0631	1.2193
4						1.2003	1.2193
5						1.2003	1.2955
6						1.286	1.2955
7						1.286	1.2955
8						1.4575	1.2193
9						1.5432	1.0669
10						1.448	1.0669
11	1.448	1.5432	1.5242	1.5432	1.5432		
12	1.448	1.5432	1.6004	1.5432	1.5432		
13	1.448	1.6461	1.6004	1.6289	1.6289		
14	1.448	1.7147	1.6004	1.6289	1.6289		
15	1.5242	1.8004	1.6004	1.5242			
16	1.5242	1.7147	1.5242	1.5242	1.5432		
17	1.5242	1.7147	1.5242	1.5242	1.4232		
18	1.448	1.6289	1.3717	1.448			
Max	1.5242	1.8004	1.6004	1.6289	1.6289	1.5432	1.2955
Min	1.448	1.5432	1.3717	1.448	1.4232	.8573	1.0669
Avg	1.4766	1.6632	1.5432	1.5456	1.5518	1.2371	1.2117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 201 / 11 Kv Niwgha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3239	.2915	.3077	.3239	1.3279	1.3927
2	.3239	.3239	.2915	.3077	.3239	1.3279	1.4899
3	.3563	.3401	.2915	.3239	.3239	1.3279	1.6194
4	.3887	.4049	.3239	.3401	.3239	1.3603	1.4575
5		.4049	.3563	.3563	.3239	1.3927	1.5546
6		.4049	.3887	.3887	.3887	1.4575	1.7166
7		.4049	.2915	.3887	.3887	1.587	1.9595
8		.4049	.3563	.3725	.3563	1.7814	1.8138
9	.3239	.3239	.3221	.3239	.3563	.3563	.3401
10	.3077	.2753	.2105	.2915	.3077	.3077	.2915
11	.2105		.1619	.2105	.1943	.1943	.1943
12	.1619	.1296	.1619	.2105	.1781	.1619	.1943
13	.1457	.1457	.1296	.1619	.1619	.1296	.1943
14	.1457	.1457	.1134	.1943	.1457	.1296	.1619
15		.1619	.1134	.1619	.1619	.1457	.1619
16	.1943	.1781	.1619	.1943	.1619	.1781	.2267
17	1.8623	2.0405	2.0729	2.0081	2.1376	.2105	.2591
18	2.0243	2.1052	1.9433	2.0081	2.0729	.2753	
19	1.7004	1.9433	1.8947	.081	1.7814	.3887	.3239
20	1.4575	1.6194	1.6518	1.6194	1.7166	.3401	.3239
21	1.3117	1.587	1.5223	1.6194	1.6194	.3077	.3239
22	1.3117	1.5223	1.4575	1.4575	1.3927	.3077	.3239
23	1.2955	1.2955	1.3927	1.4575	1.3279	.3077	.3239
24	1.2955	1.2955	1.166	1.2955	1.2955	1.2955	.3077
Max	2.0243	2.1052	2.0729	2.0081	2.1376	1.7814	1.9595
Min	.1457	.1296	.1134	.081	.1457	.1296	.1619
Avg	.7969	.7731	.7111	.6700	.7402	.6916	.7372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 202 / 11 kv Pardi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.6194	1.6194	1.7166	1.7004	.081	.0972
2	1.6194	1.6194	1.749	1.7814	1.7814	.0972	.0972
3	1.6194	1.7004	1.7814	1.7814	1.8623	.0972	.0972
4	1.7814	1.7814	1.7814	1.8461	1.8623	.0972	.0972
5	1.7814	1.8623	1.8138	1.9109	1.8623	.1134	.1134
6	1.9433	1.9433	1.9109	1.9433	2.0081	.1296	.1296
7	2.2672	2.2186	2.2996	2.1538	2.1052	.1296	.1296
8	2.1052	2.2996	2.1052	2.1376	2.1862	.1134	.1296
9	.0972	.1296	.1296	.0972	.0972	2.5587	2.5425
10	.0972	.0972	.0972	.1296	.0972	2.3482	2.4291
11	.0648		.081	.081	.0648	2.2996	2.2672
12	.0486	.0486	.0648	.081	.0486	2.0729	2.2672
13	.0486	.0486	.0486	.081	.0486	2.1862	2.1376
14	.0648	.0648	.0486	.0648	.0486	2.2024	2.1052
15	.0486	.0648	.0486	.0648	.0486	2.2348	2.1052
16	.0486	.0648	.0648	.081	.0486	2.251	2.0081
17	.081	.0648	.0648	.081	.081	.081	.0972
18	.081	.081	.0648	.081	.081	.081	.0972
19	.0972	.081	.1134	.081	.0972	.0972	.1296
20	.0972	.081	.0972	.081	.0972	.0972	.1296
21	.081	.081	.0972	.0972	.0972	.1134	.1296
22	.0972	.081	.0972	.0972	.0972	.1134	.0972
23	.081	.081	.0972	.0972	.0972	.0972	.0972
24	.0972	.081	.081	.081	.0972	.081	.0972
Max	2.2672	2.2996	2.2996	2.1538	2.1862	2.5587	2.5425
Min	.0486	.0486	.0486	.0648	.0486	.081	.0972
Avg	.6653	.7041	.6815	.6937	.6923	.8239	.8178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 203 / 11 KV Khambal feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0162	.0162	.0324	.0324	.0324	.0324
2	.0324	.0162	.0162	.0324	.0324	.0324	.0324
3	.0324	.0324	.0162	.0324	.0324	.0324	.0324
4	.0324	.0162	.0324	.0324	.0324	.0324	.0324
5		.0324	.0324	.0324	.0324	.0324	.0324
6		.0324	.0324	.0324	.0324	.0324	.0324
7		.0324	.0324	.0324	.0324	.0324	.0324
8			.0324	.0324	.0324	.0324	.0324
9	2.4291		3.3036	3.1741	2.5911	.0324	.0324
10	3.3198	2.915	2.7206	3.2388	2.834	.0324	.0324
11	3.3198			3.1741		.0324	.0324
12	3.0769			2.915	.1619	.0324	.0324
13	3.0769	3.2388	3.0121	3.0445	2.6235	.0324	.0324
14	2.915	2.915	2.9959	2.915	2.753	.0324	.0324
15	2.8178	3.2065	2.9473	2.753	2.753	.0324	.0324
16	2.753	3.2065	2.7206	2.753	2.753	.0324	.0324
17	.0162	.0324	.0324	.0324	.0162	3.3036	2.5911
18	.0324	.0324	.0324	.0324	.0324	3.3036	3.3036
19	.0324	.0324	.0324	.0324	.0324	2.8826	2.753
20	.0324	.0324	.0324	.0324	.0324	2.5911	2.5911
21	.0324	.0324	.0324	.0324	.0324	2.4291	2.4291
22	.0324	.0324	.0324	.0324	.0324	2.2996	2.2672
23	.0324	.0162	.0324	.0324	.0324	2.2024	2.2672
24	.0324	.0324	.0162	.0324	.0324	.0324	2.1376
Max	3.3198	3.2388	3.3036	3.2388	2.834	3.3036	3.3036
Min	.0162	.0162	.0162	.0324	.0162	.0324	.0324
Avg	1.2040	.7952	.8252	1.0202	.7379	.8151	.8691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 201 / 11 KV Mahati

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.251	1.2044			1.0502		
2	1.2496						
3	1.1797						
4	1.1742						
5	1.096						
6	1.1149						
7	1.3251			1.5217			
8	1.3459						
9	1.4536						
10			1.551			.3542	.4662
11			.2858			1.4678	1.7206
12							1.8917
13							1.6848
14	.195						1.6423
15							1.7469
16							1.6802
17							1.6363
18							1.757
19						.5951	.595
20							.5665
21							.5418
22							.5104
23							.4787
24	.3708						
Max	1.4536	1.2044	1.551	1.5217	1.0502	1.4678	1.8917
Min	.195	1.2044	.2858	1.5217	1.0502	.3542	.4662
Avg	1.0687	1.2044	.9184	1.5217	1.0502	.8057	1.2085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 202 / 11 KV Malkautha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4019	.4771			.5433		2.439
2	.4019			.5451			
3	.4012						
4	.4458						
5	.5359						
6	.6711						
7	.4496						
10						2.9973	2.759
11			2.5758				.3372
13							.2913
14							.2644
15							.2829
16							.3419
17							.3398
18							.4411
19							.6914
20							.7762
21							.7899
22							.726
23							.7298
24	.4748						
Max	.6711	.4771	2.5758	.5451	.5433	2.9973	2.759
Min	.4012	.4771	2.5758	.5451	.5433	2.9973	.2644
Avg	.4728	.4771	2.5758	.5451	.5433	2.9973	.8007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 203 / 11 KV Rohipimpalgaon
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6556	1.5021		1.5389	1.2364		
2	1.6575						
3	1.6556						
4	1.6861						
5	1.5927						.3116
6	1.6946						
7	2.2058						
8	2.0222						
9	2.1241						
10			1.8292			.2094	.228
11			.1111			1.9382	1.9536
12							1.6132
13							1.8884
14							1.8861
15							1.8799
16							1.8694
17							1.8631
18							1.9155
19						.2896	.3144
20							.3307
21							.3037
22							.2911
23							.2698
24	.1997						
Max	2.2058	1.5021	1.8292	1.5389	1.2364	1.9382	1.9536
Min	.1997	1.5021	.1111	1.5389	1.2364	.2094	.228
Avg	1.6494	1.5021	.9702	1.5389	1.2364	.8124	1.1279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 201 / ARDHAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2003	1.0288	1.1641	1.0631	1.2003
2	.8573	1.0288			1.1517	1.0631	1.2003
3			1.3717		1.1694	.9745	1.2003
4	1.0288	1.1145	1.4575	1.0288	1.1694	.9745	1.2003
5			1.5432		1.2178	1.0631	1.2003
6	1.2003	1.2003	1.6289	1.7147	1.4175	1.4175	1.3717
7	1.3717	1.2193	1.6289	1.7147	1.5061	1.7364	1.7147
8	1.3717		1.7147	1.5432	1.6118	1.6832	1.3717
9	1.2193			1.3717	1.5947	1.5769	1.4575
10	1.286		1.7718	1.286	1.3717	1.4883	1.2003
11	1.2003	1.5242	1.5947	1.1145	1.286	1.2403	.9907
12	1.2003	1.2193	1.5947	1.1145	1.2003	1.0745	.9145
13	1.0288		1.0631	1.1145		1.0631	1.0288
14	1.0288	.9907	1.0631	1.0288	1.1145	1.0288	
15	1.0288	.9145	1.0631	1.0288	1.1145	1.0288	1.0288
16	1.0288		1.1517	1.0288	1.0288	1.0288	.9431
17		1.2003	1.2003	1.1145	1.3289		1.1145
18		1.3839	1.286	1.3717	1.5238		1.4575
19		1.4575	1.5432	1.4575	1.6301	1.3717	1.5432
20		1.3717	1.5432	1.4575	1.4175	1.5432	1.3717
21		1.3717	1.3717	1.3717	1.3432	1.3717	1.3717
22		1.2003	1.2003	1.286	1.3146	1.3717	1.286
23		1.2003		1.3289	1.2403	1.2003	1.1145
24	1.0288	1.0288	1.2003	1.2003	1.2403	1.2403	1.0288
Max	1.3717	1.5242	1.7718	1.7147	1.6301	1.7364	1.7147
Min	.8573	.9145	1.0631	1.0288	1.0288	.9745	.9145
Avg	1.1343	1.2141	1.3901	1.2717	1.3112	1.2547	1.2309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 202 / DABHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4287	.3658	.462	1.8861
2	.3429	.4287			.3658	.4572	2.0576
3			.4287		.3658	.5487	2.2291
4	.4287	.5144	.4287	.4287	.3582	.5544	2.4006
5							2.4006
6							2.572
7							2.572
8							2.7435
9							2.915
10							2.4387
11	3.0864	1.829	2.13	2.915	2.572	2.5911	
12	3.4294	2.7435	2.4577	3.0864	3.0864	2.915	
13	3.3436		2.5301	3.0864	3.0864	3.0407	
14	3.0864	2.5911	2.5301	3.0864	2.8292	2.915	
15	3.0864	2.5911	2.5301	2.915	2.8292	2.915	
16	3.0864		2.5301	2.7435	2.7435	2.7435	
17		2.8292	2.572	2.7435	1.7814	2.8292	.3429
18		2.6578	2.572	2.7435	2.4006	2.7435	.5144
19		.4287	.5144	.5144	.5304	.4287	.5144
20		.4287	.5144	.5144	.5544	.4287	.5144
21		.4287	.4287	.5144	.4938	.4287	.5144
22		.4287	.4287	.4287	.4755	.4287	.5144
23		.4287		.4572	.462	.4287	.4287
24	.4287		.4287	.4287	.3696	.4572	.4287
Max	3.4294	2.8292	2.572	3.0864	3.0864	3.0407	2.915
Min	.3429	.4287	.4287	.4287	.3582	.4287	.3429
Avg	2.2577	1.4099	1.5350	1.6897	1.4261	1.5176	1.5549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 203 / Dabhad-II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6859	.8145	.8316	2.0576
2	.6859	.7716			.724	.8316	2.4006
3			.6859		.7316	.924	2.4006
4	.9431	1.0288	.8573	.6859	.823	1.0534	2.4006
5							2.7435
6							3.2579
7							3.3436
8							3.2579
9							3.0007
10							2.4387
11	3.4294	2.8959	2.6882		3.0864	2.5911	
12	3.3436	3.2007	2.9492	3.4294	3.5151	2.8807	
13	3.7723		3.0045	3.6866	3.4294	3.0407	
14	3.5151	3.2769	3.0045	3.2579	3.0864	3.0864	
15	3.3436	2.7435	2.8464	3.2579	3.0864	2.915	
16	3.2579		2.372	3.1722	3.1722	3.0864	
17		2.8292	2.915	3.3436	2.915	2.7435	.5144
18		2.7435	2.915	2.7435	2.915	2.6578	.6859
19		.6859	.8573	.8573	.9328	.8573	.7716
20		.6859	.6859	.8573	.9145	.8573	.7716
21		.6859	.6859	.6859	.924	.8573	.7716
22		.6001	.6859	.8573	.8413	.7716	.7716
23		.6001		.9145	.7316	.7716	.6859
24	.6859		.6001	.6859	.8316	.7392	.6859
Max	3.7723	3.2769	3.0045	3.6866	3.5151	3.0864	3.3436
Min	.6859	.6001	.6001	.6859	.724	.7392	.5144
Avg	2.5530	1.7498	1.8502	1.9414	1.8597	1.7498	1.8311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 204 / MENDHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.0576	2.0576	1.3717	1.5432	.5144
2	1.3717	1.5432			1.5432	1.5432	.5144
3			2.3148		1.7147	1.7147	.6859
4	1.8861	1.7147	2.4006	2.0576	1.8023	1.8233	.7716
5			2.4006		1.8023	1.8233	
6	1.9814	2.0576	2.572	2.4006	1.9662	1.9662	
7	2.2862	1.9814	2.6578	2.4006	2.0805	2.2939	
8	2.4387		2.572	2.572	2.2405	2.4577	
9	2.3624			2.572	2.2929	2.2939	
10	2.4863		2.372	2.4863	2.3148	2.0576	
11							2.21
12							2.2862
13							2.572
15							2.4863
16							2.4006
17		.6859	.5144	.6859	.6859	.7716	2.4006
18		.6859	.7716	.8573	.8507	.8573	1.8861
19		.6859	.8573	.8573	.9774	.8573	.7716
20		.6859	.6859	.7716	.9145	.6859	.7716
21		.6001	.6859	.6859	.7392	.6859	.5144
22		.6001	.5144	.4287	.4572	.5144	.5144
23		.4287		.4572	.4572	.5144	.5144
24	.5144		.4287	.5144	.462	.4668	2.4863
Max	2.4863	2.0576	2.6578	2.572	2.3148	2.4577	2.572
Min	.5144	.4287	.4287	.4287	.4572	.4668	.5144
Avg	1.9159	1.0609	1.5870	1.4537	1.3707	1.3817	1.4295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 205 / NIRML COTTON & GINNING
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0343	.0171	.0171	.0171
2	.0343	.0343			.0171	.0171	.0171
3			.0171		.0171	.0173	.0171
4	.0343	.0343	.0171	.0343	.0171	.0175	.0171
5			.0171		.0171	.0175	.0171
6	.0171	.0171	.0171	.0171	.0171	.0179	.0171
7		.0171	.0171		.0171	.0181	.0171
8	.0152		.0171	.0171	.0171	.0183	.0171
9				.0171	.0171	.0189	.0171
10	.0171		.0171	.0171	.0171	.0171	.0152
11	.0171	.0152	.0171	.0171	.0171	.0171	
12	.0171		.0171	.0171	.0171	.0171	.0171
13	.0171		.0171	.0171	.0171	.0171	.0171
14	.0171	.0152	.0171	.0171	.0171		.0171
15	.0171	.0152	.0171	.0171	.0171		.0171
16	.0171		.0156	.0171	.0171		.0171
17		.0171	.0171	.0171	.0179	.0171	.0171
18		.0171	.0171	.0171	.0179	.0171	.0171
19		.0171	.0171	.0171	.0181	.0171	.0171
20		.0171	.0171	.0171	.0171	.0171	.0171
21		.0171	.0171	.0171	.0171	.0171	.0343
22		.0171	.0171	.0171	.0171	.0171	.0343
23		.0171		.0171	.0175	.0171	.0343
24	.0343		.0171	.0171	.0171	.0171	.0171
Max	.0343	.0343	.0171	.0343	.0181	.0189	.0343
Min	.0152	.0152	.0156	.0171	.0171	.0171	.0152
Avg	.0212	.0192	.0170	.0188	.0172	.0174	.0193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 201 / MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.5801	.7773	.7042	.9602	1.2136	1.2136
2	.8383	.6706	.9221	.7125	.8383	1.2136	1.2136
3	.8383	.7127	1.0395	.7537	.9724	1.2136	1.2136
4	1.1401	.7545	1.2689	.8048	1.1065	1.307	1.307
5	1.3717	.8478	1.3032	.8817	1.3717	1.4937	1.4937
6	1.5775	.9221	1.5089	1.1096	1.4575	1.7177	1.6991
7	1.7147	1.3927	1.7318	1.7147	1.7147	1.9605	1.8671
8	1.8519		1.8313	2.0119	1.8991	1.9605	1.8671
9	1.4083	1.2193	1.5424	1.8564	1.6575	1.0829	1.8671
10	1.3927	1.6194	1.4083	1.6004	1.7204	1.5089	1.2696
11	1.3491	1.0562	1.0082	1.0562	1.307	1.5061	1.4575
12	1.2197	.9709	.961	.9145	1.267	1.7004	1.6004
13	1.1641	.8779	.905	.7316	1.1336	1.7004	1.4083
14	1.0402		.8131	.7842	1.2136	1.7004	1.4632
15	.8954	1.0242	.924	.8215	1.1203	1.8671	1.4403
16	1.1999	1.1203	.9979	.8322	1.0269	1.5927	1.5043
17	1.2752	1.2323	1.2323	1.1203	1.0456	1.6766	1.4723
18	1.307	1.2696	1.307	1.2437	1.4003	1.7604	1.4232
19	1.6804	1.2071	1.6263	1.2696	1.4003	1.848	1.7002
20	1.587	1.1706	1.5893	1.3169	1.4003	1.6804	1.5524
21	1.4937	1.1706	1.2936	1.2071	1.4003	1.4937	1.39
22	1.4003	1.0974	1.1584	1.0974	1.3769	1.4146	1.267
23	1.3203	1.0242	1.086	1.0242	1.3203	1.3769	1.086
24	.9511	1.226	.9511	.9979	1.0136	1.2826	1.3203
Max	1.8519	1.6194	1.8313	2.0119	1.8991	1.9605	1.8671
Min	.6554	.5801	.7773	.7042	.8383	1.0829	1.086
Avg	1.2780	1.0530	1.2161	1.1070	1.2968	1.5530	1.4624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 202 / UMRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.5868	.7373	.8002	.8573	.3734	.3772
2	.7377	.6783	1.0059	.8097	.8383	.3734	.3772
3	.9221	.8029	1.073	.852	.9724	.4108	.3772
4	1.073	.8048	1.3717	.9054	1.1736	.4715	.415
5	1.2003	.9709	1.3717	.9496	1.406	.5601	.5281
6	1.2689	1.0174	1.5775		1.5432	.7922	.6602
7	1.3717	1.3413	1.7147	1.3375	1.6289	.9242	.9054
8	1.3717		1.6956	1.3413	1.8111	.6722	.679
9	1.3413	1.448	1.6766	1.4586	1.2431	.4904	
10	1.4415	1.4089	1.4403	1.2003	1.2452		
11	.2241	.3018	.2263	.2829	.1867	1.278	
12		.1509	.1886	.1886	.1509	1.5708	1.1523
13	.2149	.1509	.1509	.1509	.1886	1.4575	1.4403
14	.2587	.2987	.1886	.1886	.1867	1.3927	1.4632
15	.2241	.2801	.1886	.3018	.2054	1.4091	1.4083
16	.3658	.3361	.1886	.3547	.2241	1.4419	1.2483
17	.3734	.3734	.3018	.3921	.2241	1.4754	1.2803
18	.3734	.4668	.3395		.4668	1.4754	1.2334
19	.5359	.4715	.6413	.4108	.4668	.5175	.679
20	.4668	.4527	.5658	.462	.4481	.4938	.6413
21	.4108	.4251	.415	.3772	.4294	.4668	.415
22	.3734	.415	.3772	.3772	.4108	.3734	.415
23	.3734	.415	.3772	.3772	.3961	.3734	.415
24	.3772	.3772	.3734	.3772	.3772	.3961	.3772
Max	1.4415	1.448	1.7147	1.4586	1.8111	1.5708	1.4632
Min	.2149	.1509	.1509	.1509	.1509	.3734	.3772
Avg	.6909	.6076	.7578	.6316	.7117	.8343	.7851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 203 / DEGAON (KD.)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	1.0642	.7545	.4527	.6413	.6962	.7045
2	.679	1.0269	.7545	.5281	.6413	.7127	.7625
3	.5658	1.0269	.6371	.6413	.5658	.7545	.8383
4	.5658	1.0269	.7167	.679	.679	.7956	.9282
5	.679	1.0456	.7922	.8299	.7167	.9221	.9945
6	.7545	.9339	.8676	.7545	.7545	1.1065	1.1469
7	.9054	.8048	.9054	.7167	.7545	1.1797	1.3108
8	.9054		.7545	.7922	.7545	1.3108	1.4918
9	.7545	.6036	.811	.7545	.7468	1.4575	1.3413
10	.4481	.6036	.5281	.6036	.5975	.7133	1.2967
11	1.2803	1.1523	1.1203	1.1523	1.2955	.3018	.4527
12	1.2967	1.2651	1.3763	1.1385	1.3765	.1509	.3772
13	1.3763	1.2346	1.3763	1.1248	1.3441	.1867	
14	1.3763	1.2498	1.2811	1.0936	1.3117	.2987	
15	1.3763	1.2498	1.2498	1.1385	1.3108	.3277	.5281
16	1.3763	1.2346	1.1873	.7545	1.3108	.4668	.6036
17	1.3765	1.2498	.8642	1.4083	1.326	.5228	.679
18	1.3927	1.2498	1.1385	1.2651	.6535	.5365	.7545
19	.7842	.8299	.9054	.6348	.6722	.6653	.9054
20	.8962	.7545	.7922	.811	.5601	.7316	.6413
21	.6535	.7545	.6413	.7922	.4668	.7468	.7167
22	.5975	.7545	.5658	.7545		.7545	.5658
23	.6036	.7545	.4904	.6602	.6224	.7545	.4904
24	.4481	.6036	.6036	.4904	.7545	.6036	.7545
Max	1.3927	1.2651	1.3763	1.4083	1.3765	1.4575	1.4918
Min	.4481	.6036	.4904	.4527	.4668	.1509	.3772
Avg	.9103	.9771	.8798	.8321	.8633	.6957	.8311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 204 / KASARKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4294	.415	.415	.4527	.4973	.4588
2	.3772	.4294	.415	.4527	.4904	.6706	.5801
3	.3395	.4668	.3772	.4904	.5658	.8048	.6706
4	.4527	.5601	.4715	.5281	.679	.9945	.8288
5	.6036	.5658	.5601	.6036	.7545	1.2239	1.0774
6	.7167	.7733	.679	.7922	.8215	1.4251	1.278
7	.8488	.6602	.8488	.8299	.8488	1.4746	1.491
8	.811		.8299		.6722	1.6842	.5967
9			.6602		.5788	1.6004	.5533
10			.5281		.4481	1.1003	.4744
11	1.6484	1.4083	1.5043	1.6164	1.4083	.6036	
12	1.8027	1.866	1.6964	1.6446	1.668	.3174	
13	1.8724	1.7284	1.7284	1.6604	1.6194	.2987	
14	1.8244	1.656	1.5935	1.5623	1.6385	.2987	
15	1.7764	1.4842	1.5623	1.6288	1.6385	.2785	.415
16	1.7284	1.5432	1.531	1.7604	1.5238	.2427	.3395
17	1.7859	1.5623	1.6324	1.7284	1.5249	.3772	.3772
18	1.7859	1.5623	1.6762	1.7078	.4854	.4854	.4527
19	.6722	.6036	.679	.4715	.4854	.499	.6036
20	.5788	.5281	.6036	.5975	.5041	.5121	.5658
21	.5228	.4904	.4904	.4527	.5041	.4904	.5281
22	.4668	.4527	.4527	.4338	.4527	.4715	.4527
23	.4481	.4338	.4527	.4338	.415	.6036	.4527
24	.415	.4338	.415	.415	.415	.415	.3734
Max	1.8724	1.866	1.7284	1.7604	1.668	1.6842	1.491
Min	.3395	.4294	.3772	.415	.415	.2427	.3395
Avg	.9934	.9351	.9084	.9631	.8581	.7237	.6285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 201 / LAHAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602		.8764		1.086	1.0669	.3429
2	1.1145		.8764		1.4289	1.0669	.3429
3	1.2174		.9526		1.5432	1.6004	.3772
4	1.3546		1.1431		1.6956	1.7147	.3772
5	1.5432		1.4098		1.7337	1.7909	.4115
6	1.6289		2.1338		1.9052	1.9052	.4115
7	1.7004		2.21	1.6461	1.9624	1.9052	.4115
8	1.9919		2.2862	1.7833	2.1719	1.9814	.4801
9	2.0719	1.989	2.2862	1.7833	1.9814	1.9814	.4115
10	1.9204		1.7833	1.5415	1.7528	1.5775	.4115
11	.2058	.381		.2915	.3048	.2058	1.3717
12	.1372		.1372	.2321	.3048	.2058	1.989
13				.1715	.2286	.2058	1.0288
14				.1715	.2286	.2058	1.989
15	.2058	.3048	.2058	.2058	.2286	.2058	1.768
16		.2286		.1658		.2058	1.5851
17	.2058	.3048	.2743	.2321		.2743	
18	.2743	.381	.2743	.3086	.2286	.2058	
19	.4115	.5335	.4115	.4287	.3048	.4115	
20		.5335		.4973	.381	.4115	
21		.4572			.381	.4115	
22	.4115	.381	.4115		.4572	.4115	
23		.381			.381	.4115	
24	.3086	.3429	.381	.4115	.381	.381	.4115
Max	2.0719	1.989	2.2862	1.7833	2.1719	1.9814	1.989
Min	.1372	.2286	.1372	.1658	.2286	.2058	.3429
Avg	.9813	.5182	1.0620	.6580	.9578	.8643	.8306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 202 / CHABHARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.4572		.381	.381	1.1145
2	.3086		.4572		.381	.381	1.1145
3	.3429		.381		.381	.4191	1.2003
4	.3772		.4191		.4191	.4191	1.2003
5	.4801		.4191		.9145	.4954	1.286
6	.5144		.4954		.5716	.4954	1.4575
7	.6001		.4954	.5487	.6668	.5716	2.0576
8	.3944		.4572	.4287	.5716	.4954	2.332
9	.3772	.3772	.4191	.3429	.4001	.4191	2.572
10	.2401		.2572	.2572	.381	.1715	2.3148
11	2.4006	2.4768	1.8861	2.3148	3.315	1.8861	.2058
12	3.1722	3.8104	2.915	2.8664	3.2388	2.915	.1715
13		3.7342		2.652	3.0483	2.1434	.1715
14		3.1245		2.2672	3.1245	2.0576	.1372
15	2.7435	2.7816	2.2291	1.6194	2.5149	1.9719	.1619
16		2.6673		1.8947	2.553	2.0576	
17	2.3148	2.7435	2.4006		2.553	1.9719	
18	2.572	2.8197	2.3148		2.4387	.3772	
19	.4115	.5335	.4458	.3944	.381	.3772	
20		.4191		.4287	.4191	.4115	
21		.4191		.4287	.381	.4115	
22	.3772	.4572	.4115		.4954	.4115	
23		.4572			.4572	.4115	
24	.3429	.4115	.4572	.4115	.4191	.381	.4115
Max	3.1722	3.8104	2.915	2.8664	3.315	2.915	2.572
Min	.2401	.3772	.2572	.2572	.381	.1715	.1372
Avg	1.0174	1.8155	.9621	1.2040	1.2669	.9181	1.1193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 203 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.6859	.6859	.7621	.6859	.9145	.8573
Max	.6859	.6859	.7621	.6859	.9145	.8573
Min	.6859	.6859	.7621	.6859	.9145	.8573
Avg	.6859	.6859	.7621	.6859	.9145	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 204 / 11KV SONALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801		.5716		.5335	.5716	.6859
2	.4801		.5716		.5716	.5716	.6859
3	.5144		.4572		.5716	.6478	.6859
4	.6001		.4572		.6668	.6859	.7716
5	.6516		.6859		.5716	.6859	.7716
6	.6859		.7621		.8764	.7621	.8573
7	.7716		.8002	.8573	.9526	.7621	1.4575
8	.6859		.8002	.7716	.7621	.8002	1.7147
9	.6859	.6859	.724	.583	.724	.7621	1.5432
10	.5144		.5144	.463	.6287	.3772	1.3717
11	1.4575	1.829	1.286	1.6289	1.9814	1.286	.3429
12	2.0576	2.21	1.9719	1.9271	1.829	1.6289	.2743
13		2.0957		1.7814	1.7528	1.4575	.2743
14		1.8671		1.4575	1.7528	1.286	.3086
15		1.6385	1.286	1.3279	1.3717	1.2003	.2652
16		1.5623		1.4575	1.3717	1.1145	.3772
17	1.3717	1.5242	1.3717	1.3279	1.3336	1.1145	
18	1.4575	1.6385	1.3717	1.406	1.3717	1.2003	
19	.6173	.724	.6859	.6859	.6859	1.1145	
20		.724		.6687	.6478	.6173	
21		.6478			.6478	.583	
22	.583	.6097	.6001		.6097	.583	
23		.6097			.5716	.5487	
24	.5144	.5144	.5716	.5144	.6668	.5716	.5487
Max	2.0576	2.21	1.9719	1.9271	1.9814	1.6289	1.7147
Min	.4801	.5144	.4572	.463	.5335	.3772	.2652
Avg	.8311	1.2587	.8605	1.1239	.9772	.8722	.7610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 201 / PARDI (M) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2922	1.1843	1.4413	1.4601	1.2334	1.2483	1.1317
2	1.4311	1.2803	1.6108	1.6461	1.3283	1.3763	1.1317
3	1.5236	1.3916	1.8652	1.7705	1.406	1.4548	1.226
4	1.6324	1.4548	1.95	1.848	1.4998	1.5497	1.3203
5	1.85	1.6446	2.2891	2.037	1.6049	1.7394	
6	2.3216	1.8976	2.4587	1.9815	1.8964	2.0241	
7	3.0471	2.6871	2.7978	3.0058		2.7831	
8	3.3759		3.0521	3.299		2.8121	
9	2.7496		2.9752	3.2291	1.4373	1.0883	
10	2.7183		2.891	2.8295	2.2558	1.9433	
11							2.3122
12							2.5621
13							2.4985
14							2.4646
15							2.4059
16							2.3472
17	1.0562	.8139	.964	.963	.9808	.9431	2.4966
18	1.094	1.0174	1.0752	1.1077	1.1317	1.1317	2.3777
19	1.5089	1.0174	1.4712	1.5074	1.2826	1.3203	1.358
20	1.1694	.9326	1.2787	1.2035	1.1317	.1226	1.2826
21	1.0562	.9326	1.1271	1.1271	1.1317	1.226	1.2071
22	1.0562	.9326	1.126	1.1271	1.1317	1.1317	1.2071
23	1.0562	.9326	1.0552	1.0907	1.1317	1.1317	1.2071
24	1.052	1.0562	.9326	1.0562	1.0562	1.1317	
Max	3.3759	2.6871	3.0521	3.299	2.2558	2.8121	2.5621
Min	1.052	.8139	.9326	.963	.9808	.1226	1.1317
Avg	1.7217	1.2784	1.7978	1.7939	1.3525	1.4532	1.7963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 202 / CHORAMBA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2569	.2614	.2294	.2555	.2641	.3018	.7907
2	.2202	.2614	.2294	.2561	.2641	.2641	.8002
3	.2627	.2614	.2622	.2951	.3018	.2614	.7907
4	.263	.2987	.2622	.3326	.2987	.2987	.8802
5							.8802
6							.9602
7							.9602
8							.9602
9							.7621
10							.7526
11	.9686	.8192	.9297	.9432	.8124	.8002	
12	1.0311	1.0159	1.2122	1.1742	.9374	1.0402	
13	.9998	.9831	1.1742	1.1971	.9808	1.0402	
14	.8535	1.1142	1.1493	1.2109	.9214	.9717	
15	.8128	.9012	1.11	1.2109	.9031	.9717	
16	.8025	.8192	1.0719	1.1375	.8509	.8802	
17	.8429	.7373	1.1123	1.0641	.873	.7716	.1848
18	.7225	.8192	1.001	1.0328	.7526	.7716	.2241
19	.3206	.2622	.3018	.2627	.3018	.3018	.2829
20	.3018	.2622	.3385	.3006	.3018	.2641	.2987
21	.3018	.2622	.3381	.3006	.3018	.2641	.2987
22	.3018	.2622	.3003	.263	.3018	.2641	.2987
23	.2641	.2294	.3015	.263	.3018	.2641	.2614
24	.2627	.2641	.2294	.2641	.263	.3018	.2641
Max	1.0311	1.1142	1.2122	1.2109	.9808	1.0402	.9602
Min	.2202	.2294	.2294	.2555	.263	.2614	.1848
Avg	.5439	.5464	.6419	.6536	.5518	.5574	.5917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 203 / Delub Bk SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5255	.5658	.4915	.6206	.6036	.6036	1.7814
2	.5137	.5658	.4915	.6219	.6036	.5975	1.7814
3	.5871	.6413	.5898	.7008	.6413	.6348	1.8623
4	.6965	.7167	.6226	.8131	.7095	.7167	1.9204
5							2.0243
6							2.0557
7							2.0309
8							2.0557
9							1.9528
10							1.929
11	2.1376	2.13	2.2314	2.2491		1.9204	
12	2.4291	2.2283	2.5345	2.5659		2.1052	
13	2.2497	2.1628	2.3851	2.5686	2.0988	2.0805	
14	2.0988	2.1628	1.965	2.4667	2.1491	2.0005	
15	1.9814	2.13	1.9979	2.4926	1.9052	1.9433	
16	1.5954	2.0481	2.1807	2.3851	1.8663	1.9433	
17	1.9966	2.0481	2.1874	2.2727	1.8814	1.7604	.4854
18	1.829	1.9662	2.2987	2.2131	1.6857	1.7604	.5228
19	.6036	.7209	.8299	.677	.8299	.7922	.7545
20	.6413	.6554	.7522	.677	.679	.7545	.6413
21	.6036	.5898	.6387	.6011	.6036	.6036	.6413
22	.6036	.5243	.6005	.6017	.6036	.6036	.6413
23	.5601	.4915	.603	.6017	.6036	.6036	.6036
24	.5636	.5658	.5243	.6036	.6036	.6036	.6036
Max	2.4291	2.2283	2.5345	2.5686	2.1491	2.1052	2.0557
Min	.5137	.4915	.4915	.6011	.6036	.5975	.4854
Avg	1.2342	1.2730	1.3292	1.4296	1.1292	1.2238	1.3493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 201 / KAMTHA (BK.)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.679	.5658	.5658	.5658	.128	.132
2	.6535	.7922	.679	.5658	.5658	.128	.1509
3	.7468	.8488	.679	.6602	.6602	.1448	.1698
4	.7468	.9054	.8488	.7545	.7545	.1829	.1886
5	.8402	.9808	.8488	.7922	.7545	.2378	.2263
6	.823	1.0751	.9054	.8488	.8488	.2743	.2829
7	.8779	1.0751	1.0185	.8865	.9242	.2926	.2829
8	1.0269		1.0185	1.0374	1.0751	.2587	.2641
9	.9619	1.1317	.9054	1.0374	.9997	.2378	.2075
10	.9431	1.0185	.9054	.9431	.9619	.2195	.1509
11	.1132	.1132	.132		.1086	.8676	.8488
12	.1132	.0943	.1132	.1132	.1267	.9619	.9054
13	.1132	.0943	.0943	.1132	.1267	.9242	.9054
14	.0943	.0943	.0943	.1132	.1086	.9619	.9054
15	.1132	.1132	.1132	.1132	.1086	.9054	.9054
16	.1509	.1132	.1132	.1132	.1267	1.0185	.8488
17	.1886	.1698	.132	.132	.1267	.9431	.9054
18	.2075	.2263	.1509	.1886	.1629	1.0562	.9054
19	.2075	.1886	.2263	.2452	.2172	.2263	.2263
20	.1886	.1886	.2075	.2075	.1991	.2075	.2263
21	.1698	.1698	.1698	.1698	.181	.1886	.2075
22	.1698	.1698	.1509	.1509	.1448	.1698	.1886
23	.1509	.1698	.1509	.132	.128	.1509	.1886
24	.1086	.1509	.1509	.132	.1132	.1097	.132
Max	1.0269	1.1317	1.0185	1.0374	1.0751	1.0562	.9054
Min	.0943	.0943	.0943	.1132	.1086	.1097	.132
Avg	.4279	.4592	.4323	.4355	.4204	.4498	.4315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 202 / GANPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.132	.132	.132	.132	1.4003	1.0374
2	.0905	.132	.132	.1509	.132	1.4563	1.0374
3	.0914	.132	.1509	.1698	.1509	1.4937	1.1317
4	.1448	.1509	.1509	.1886	.1698	1.5466	1.226
5	.2172	.1509	.1698	.1886	.2263	1.6032	1.3203
6	.2353	.1886	.2075	.2263	.2452	1.6975	1.4146
7	.3077	.2263	.2263	.2829	.3395	1.6804	1.905
8	.2743		.2263	.2263	.2829	1.8298	2.0559
9	.1886	.2263	.2263	.2263	.2263	1.8298	1.9805
10	.132	.1886	.1509	.1886	.1698	1.8861	1.8107
11	1.6975	1.6975	1.773	1.6409	1.3717	.0943	.0943
12	1.8861	1.9805	1.8107	1.8861	1.9231		.0943
13	1.8861	1.8861	1.773	1.9805	1.8671		.0943
14	1.8861	1.9239	1.6975	1.8484	1.7737		.0943
15	1.8673	1.9239	1.7353	1.8484	1.6975		.0943
16	1.8673	1.8861	1.7918	1.8484	1.587		.1132
17	1.9239	1.9239	1.8484	1.7918	1.6032		.1132
18	1.8861	1.9805	1.773	1.9239	1.6804	.1886	.1132
19	.2641	.1886	.3018	.2641	.1307	.2829	.132
20	.2263	.1886	.2263	.2075	.181	.2075	.1886
21	.2263	.132	.1886	.1886	.1646	.1698	.1886
22	.1698	.132	.1509	.1509	.1463	.1509	.1698
23	.1509	.132	.132	.132	.1097	.132	.1509
24	.1097	.1132	.132	.132	.132	.0914	.132
Max	1.9239	1.9805	1.8484	1.9805	1.9231	1.8861	2.0559
Min	.0724	.1132	.132	.132	.1097	.0914	.0943
Avg	.7417	.7659	.7128	.7427	.6851	.9856	.6955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-MAR-17 and 07-MAR-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 203 / NANDUSA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-MAR-17	02-MAR-17	03-MAR-17	04-MAR-17	05-MAR-17	06-MAR-17	07-MAR-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.9054	.9054	.7545	.7545	.0732	.0943
2	.9335	1.1317	1.1317	.8488	.7545	.0724	.0943
3	.9335	1.2449	1.1317	.9431	.9054	.0905	.0943
4		1.4146	1.4712	1.0374	1.0374	.0914	.1132
5	1.307	1.5844	1.5844	1.1317	1.1317	.1097	.1132
6	1.4003	1.6975	1.6975	1.226	1.226	.128	.132
7	1.4003	1.6975	1.6975	1.3203	1.4712	.128	.1132
8	1.8484		1.5844	1.7353	1.7541	.1097	.2829
9	1.6975	1.6975	1.4712	1.5655	1.6032	.0914	.0943
10	1.6409	1.5844	1.5089	1.5089	1.6032		
11		.0566	.0566	.0566	.0905	1.3769	1.6975
12		.0566	.0566	.0566	.0543	1.8107	1.7353
13	.0754	.0566	.0377	.0566	.0543	1.8296	1.6975
14	.0566	.0566	.0377	.0566	.0543	1.8296	1.5844
15	.0566	.0566	.0377	.0566	.0549	1.7353	1.4712
16	.0566	.0754	.0566	.0566	.0543	1.7918	1.358
17	.0566	.0943	.0566	.0754	.0724	1.6221	1.4146
18	.0943	.0943	.0754	.0754	.0724	1.4146	1.4146
19	.1132	.1132	.1132	.1132	.0905	.1132	.132
20	.132	.1132	.1132	.1132	.1267	.1132	.132
21	.132	.1132	.1132	.1132	.1086	.1132	.1132
22	.1132	.1132	.0943	.0943	.0905	.1132	.1132
23	.1132	.1132	.0943	.0943	.0914	.1132	.1132
24	.0914	.0943	.1132	.0943	.0754	.0732	.0943
Max	1.8484	1.6975	1.6975	1.7353	1.7541	1.8296	1.7353
Min	.0566	.0566	.0377	.0566	.0543	.0724	.0943
Avg	.6176	.6159	.6350	.5494	.5555	.6497	.6175