

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 201 / 11 KV AJARA

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4163	.439	.439	.3898		.4024	
2	.3982	.439	.4344	.3982		.4024	
3	.3982	.4298	.4024	.3982		.3658	
4	.4119	.4344	.3982	.4344		.362	
5	.4477	.4706	.4557	.543		.4557	
6	.5552	.5121	.5068	.5731		.4961	
7	.6733	.5792	.5853	.631		.5144	
8	.6556	.6584	.6379	.7133		.5847	
9	.695	.6173	.6024	.7265		.6173	
10		.7343	.583	.7265		.6001	
11		.691		.7499	.7373		
12	.7133	.691		.6687	.7373		
13	.631	.7133	.4961	.6485	.583		
14	.6024	.5493	.4961	.6001	.6001		
15		.5609	.4733	.6173	.5144		
16	.6154	.6379	.2126	.583	.583		
17	.6584	.6661	.2149	.6173	.7888		
18	.7865	.7421	.6173	.6173	.703		
19	.8682	.7865	.7545	.8059	.7888		
20	.9328	.8859	.8859	.8402			.0347
21	.8326	.8596	.8413	.7964			
22	.695	.7316	.7133	.695			
23	.5068	.5121	.4887	.5249	.5121		
24	.4525	.439	.439	.3982			
Max	.9328	.8859	.8859	.8402	.7888	.6173	.0347
Min	.3982	.4298	.2126	.3898	.5121	.362	.0347
Avg	.6165	.6159	.5308	.6124	.6548	.4801	.0347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 203 / POLGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0914	.1448	.0732	.0732	.0543	
2	.0724	.0724	.1086	.0905		.0543	
3	.0724	.0724	.1063	.0905		.0362	
4	.0549	.0724	.1086	.1086		.0362	
5	.0724	.0724	.1629	.1227		.0351	
6	.0724	.0724	.2012	.1629		.0351	
7	.0543	.0724	.2353	.0724		.0543	
8	.0549	.0905	.0655	.0724		.0362	
9	.4163	.3077	.0724	.0543		.0181	
10	.4525	.2896	.0655	.0701		.0181	
11	.3982	.2896		.0724		.0181	.0171
12	.4525	.3077		.0543		.0181	.0171
13	.3982	.3439		.0543			.0343
14	.362	.3258		.0543			.0343
15	.3982	.3439		.0724	.0181	.0362	.0171
16	.3801	.362		.0724	.0362		
17	.0543	.0724		.0724	.0343	.0362	
18	.1267	.0492	.0532	.0905	.0362	.0724	.0171
19	.1448	.0655	.0532	.0905	.0686	.0724	.0514
20	.1463	.0633	.0716	.0905	.0724	.0724	.0857
21	.1629	.0724	.0732	.0914	.0549		.0857
22	.1267	.1595	.1097	.0914	.0549		.0709
23	.1086	.1463	.0905	.0914	.0543		.0701
24	.0724	.1267	.1448	.0905	.0732		
Max	.4525	.362	.2353	.1629	.0732	.0724	.0857
Min	.0543	.0492	.0532	.0543	.0181	.0181	.0171
Avg	.1970	.1642	.1098	.0836	.0524	.0414	.0455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 204 / 11 KV Watangi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0724	.1646	.1646	.0724	.0732	.0724
2	.0886	.0732	.1578	.1629	.0747	.0724	.0724
3	.0886	.0732	.1595	.1629	.0724	.0724	.0724
4	.0886		.1595	.1646			.0724
5	.0886		.1829	.181			.0732
6	.0886	.0914	.2195	.1949			.0724
7	.1063	.0732	.2378	.2353			.0724
8	.0895	.0914	.0791	.1063		.0492	.0905
9	.4207	.3429	.081			.0343	.0857
10		.3772		.0655		.0328	
11				.0655	.0343		.1017
12	.3841	.3429		.0857	.0514		.1802
13	.3681	.3544		.0857	.0514		.0983
14	.0492	.4733		.0686	.0514		.0514
15		.4578		.0686	.0514		.0514
16	.2543	.3429		.0686	.0514		.2229
17	.0819	.0633	.0514	.0686	.0686	.0358	.0686
18	.0819	.0819	.1029	.0686		.0537	.0537
19	.0819	.0819	.1029	.0171	.0686	.0686	.0716
20	.0914	.0819	.1075	.0514			.0886
21	.0914	.0914	.1097	.0366			.0819
22	.0914	.1829	.1829	.1097			
23	.0732	.1629	.1448	.1097	.0905	.0543	.0655
24	.0857	.0732	.1646	.1629	.0905		.0724
Max	.4207	.4733	.2378	.2353	.0905	.0732	.2229
Min	.0492	.0633	.0514	.0171	.0343	.0328	.0514
Avg	.1373	.1898	.1417	.1089	.0638	.0547	.086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 205 / 11 KV WATANGI VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2172	.1772	.2126			.0181
2	.1991	.2195	.1829	.2172	.181		.0181
3	.181	.2172	.1772	.2126	.181		.0183
4	.1991	.2172	.1772	.2172			.0181
5	.2715	.2715	.2481	.2454			.0181
6	.3224	.3077	.3189	.3077			.0181
7	.4298	.3982	.394	.4344			.0181
8	.4298	.4572	.4207	.5121		.2743	.0181
9	.4207	.4908	.3898			.3258	.0164
10		.4835		.4252		.2401	
11		.4656		.3641	.2743		.2401
12	.3475	.3721		.2915	.3601		.2629
13	.3189	.3898		.3258	.2149	.2058	.2454
14	.2835	.3155		.2865	.1715	.2149	.2279
15		.2947		.2743			.2454
16	.3012	.3294		.2835	.2058	.2149	.2658
17	.3898	.4031	.3224	.3772	.3772	.2865	.2401
18	.5138	.3856	.463	.5144	.4115	.1791	.4382
19	.6584	.6767	.583	.583	.6344	.463	.4115
20	.7499	.823	.7202	.6001			.7716
21	.5853	.6767	.6036	.5853			.6661
22	.3841	.4938	.4252	.3475			
23	.2378	.2241	.2561	.2195	.2896	.0179	.2743
24	.2353	.2195	.181	.2172			.0183
Max	.7499	.823	.7202	.6001	.6344	.463	.7716
Min	.181	.2172	.1772	.2126	.1715	.0179	.0164
Avg	.3655	.3896	.3553	.3502	.3001	.2422	.2031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 206 / 11 KV MIDC feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0543	.0532	.1097	.0183	.0183	.4344
2		.0549	.0526	.0724	.0183	.0362	.4344
3	.0549	.0549	.0532	.0732	.0181	.0366	.4344
4	.0549	.0549	.0532	.0732		.0366	.439
5	.0549	.0549	.0354	.0724		.0549	.5121
6	.0549	.0543	.0354	.0724		.0549	.5611
7	.0549	.0549	.0532	.0543		.0492	.6516
8	.0549	.0732	.0492	.0549		.0514	.6878
9	.0724	.0716	.0339			.0514	.7421
10	.0914	.0895		.0857		.0819	
11	.0914	.0895		.0492	.0343		.6859
12	.0914	.0886		.0514	.0514		.7316
13	.0532	.0678		.0686	.0514	.0857	.639
14	.0848	.0474		.1075	.0514	.6173	.6733
15		.0655		.0857	.0514		.6516
16	.0709	.0678		.0857	.1029	.6173	.6687
17	.0633	.0678	.0895	.0716	.0686	.6556	.6173
18	.0724	.0655	.0537	.0709	.0514	.7522	.6859
19	.0914	.0819	.0532	.0686	.0686	.8573	.8573
20	.0732	.0819	.0537	.0343		.9145	.8573
21	.0549	.0543	.0549	.0183		.8048	.8507
22	.0549	.0366	.0362	.0183	.0183	.7133	
23	.0543	.0543	.0724	.0362	.0366	.4938	.5487
24		.0549	.0543	.1086	.0181		.439
Max	.0914	.0895	.0895	.1097	.1029	.9145	.8573
Min	.0532	.0366	.0339	.0183	.0181	.0183	.4344
Avg	.0675	.0642	.0522	.0671	.0439	.3492	.6274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 207 / 11 KV Bhadvan Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433			.1791	.1791	.1791	.181
2	.1254			.1791	.1791	.1791	.181
3	.1254			.1772	.1791		.181
4	.1433			.1791			.0953
5	.1612			.2149			.2507
6	.197			.3045			.2686
7	.2507			.3761			.3224
8	.2835			.4298			.3761
9	.3189			.4252		.3045	.4252
10	.4784		.3189	.394		.3582	.3403
11	.4075		.3012	.4075	.3582	.3012	.3224
12	.4031		.2126	.3544	.3224	.2303	.2686
13	.3189		.1949	.3189	.2865	.2835	.2507
14	.3544		.2149	.3403	.4298	.3012	.1791
15	.3012		.1433	.3224	.4298	.3366	.197
16	.3189		.2303	.2915	.4119	.3189	.2328
17	.3544	.3077	.2865	.3224	.3898	.2865	.0991
18	.4075	.3258	.3544	.3721	.5316	.3898	
19	.5847	.5249	.4961	.5138	.691	.5373	.5658
20	.6516	.7421	.6344	.6379	.6859	.5731	.6516
21	.5784	.5973	.5487	.4115	.5493	.5144	
22	.3544	.4525	.3898	.3898	.3761	.3224	.3086
23	.2303	.2353	.2149	.2328	.2507	.1991	.2572
24	.1417			.1791	.197		.181
Max	.6516	.7421	.6344	.6379	.691	.5731	.6516
Min	.1254	.2353	.1433	.1772	.1791	.1791	.0953
Avg	.3181	.4551	.3244	.3314	.3793	.3303	.2789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 405 / 33 KV Amboli

HV Non-Express Feeder

Feeder KV- 33 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224	.2715	.3189	.2172		.0549	.0543
2	.3224	.2715	.2658	.2195		.0543	.0549
3	.3224	.2715	.2629	.2126		.0543	.0549
4	.3224	.2715	.2658	.2103		.0543	.0549
5	.3224	.2743	.2658	.2126		.0543	.0543
6	.3224	.3258	.3121	.3155		.0543	.0549
7	.3721	.4344	.4252	.4252		.0514	.2149
8	.4115	.439	.463	.4938		.0514	.2195
9	.4938	.6687	.5144			.0514	.2058
10		.463		.3601		.0514	
11		.5144		.4115			.2058
12	.3258	.5373		.4252			.2058
13	.5847	.463	.3086	.3086			.2058
14	.463	.5144	.3086				
15		.4733	.4115	.3086	.7202		.3086
16	.4115	.463	.3086	.3086	.5144		.3086
17	.3601	.4115	.2058	.3086	.2058		.3086
18	.463	.4115	.4115	.3086	.9259	.2058	.3601
19	.7682	.5658	.6687	.9774	1.1317	.2058	.5144
20	.8779	.823	.7716		1.262		.6687
21	.7133	.7682	.7682		1.1403		.4115
22	.4938	.543	.3801	.1629			
23		.3258	.3258	.2195		.1097	.0514
24	.3224	.2715	.3292	.3258			.0549
Max	.8779	.823	.7716	.9774	1.262	.2058	.6687
Min	.3224	.2715	.2058	.1629	.2058	.0514	.0514
Avg	.4498	.4490	.3949	.3366	.8429	.0810	.2177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 201 / 11KV UtturVg.

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.4298	.4066	.5228	.3361	.3582	.3326
2	.3361	.3582	.4066	.5228	.3361	.3224	.3326
3	.3361	.3582	.3696	.4854	.2987	.3224	.3326
4	.3547	.3403	.4066	.4854	.2987	.3224	.3326
5	.4108	.4298	.4435		.2829	.3582	.2957
6	.5415	.5014	.5175	.2614	.5041	.4656	.4435
7	.7655	.6805	.6653	.2987	.7282	.5373	.5914
8	.7842	.7164	.7392	.3361	.7468	.7522	.6653
9	.8402	.7522	.7762	.3734	.7468	.7164	.7392
10		.788	.6722	.6722	.6908	.7164	
11	.631	.5175		.5975	.5258		.6653
12	.5731	.5175			.4298	.4805	.4108
13	.591	.5914	.2987		.4298	.3696	.4481
14	.6283	.4805	.4854	.0747	.4656	.4066	.5415
15	.6089	.5914	.4481	.056	.4656	.5544	.5041
16	.6447	.5175		.6722	.4298	.4435	.5228
17	.7164	.5544	.4854		.6447	.5914	.4854
18	.7773	.5914	.6722	.6908	.7164	.6099	.7095
19	.905	.8131	.9335	.7655	.8238		1.0082
20	1.0029	1.1458	1.2323	1.1576	.8954		1.1576
21	.9671	1.0349	.9709	.9522	.9671		1.0642
22	.8238	.8131		.7282	.7164		.8402
23	.6089	.5175	.5975	.4481	.5373		.5914
24	.3547	.4298	.4435	.5601	.4108	.4477	.3511
Max	1.0029	1.1458	1.2323	1.1576	.9671	.7522	1.1576
Min	.3361	.3403	.2987	.056	.2829	.3224	.2957
Avg	.6321	.6029	.5985	.5331	.5595	.4875	.5811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 202 / 11KV Bahirewadi Ag.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0486	.081	.112	.0972	.0648	.0324
2	.0324	.0486	.081	.112	.0972	.0648	.0324
3	.0324	.0486	.0648	.0934	.0972	.0486	.0324
4	.0324	.0486	.081	.0934	.0972	.0486	.0324
5	.0324	.0486	.081	.112	.096	.0648	.0324
6	.0497	.0486	.1134	.1307	.081	.0648	.0324
7	.0486	.0486	.1943	.2054	.1781	.081	.0324
8	.0486	.0486	.0486	.0486	.048	.0324	.0486
9	.2267	.1943	.0324	.0469	.0486	.0324	.1134
10		.2105	.0324	.0343	.0486	.0324	
11	.2591	.2105		.0486	.0486		.1187
12	.3077	.3077			.0324	.0324	.1307
13	.3077	.3077	.0324		.0486	.0324	.112
14	.2753	.3077	.0335	.0324	.0486	.0324	.112
15	.2915	.3077	.0335	.0486	.0486	.0324	.112
16	.3077	.3239		.032	.0486	.0324	.1307
17	.0486	.0486	.0514		.0486	.0324	.0324
18	.0486	.0324	.0486	.0486	.0324	.0648	.0324
19	.0486	.0324	.0486	.0486	.0486		.0324
20	.0486	.0486	.0486	.0474	.0486		.0324
21	.0486	.0486	.0486	.0486	.0486		.0324
22		.1134		.128	.1134		.0324
23	.0324	.1134	.112	.1267	.1296		.0373
24	.032	.0358	.0972	.112	.0972	.0972	.0324
Max	.3077	.3239	.1943	.2054	.1781	.0972	.1307
Min	.032	.0324	.0324	.032	.0324	.0324	.0324
Avg	.1178	.1263	.0682	.0814	.0721	.0495	.0595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 203 / MAHAGOND AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0181	.0177	.0177	.0181	.0324	.0177
2	.0181	.0181	.0177	.0177	.0181	.0324	.0177
3	.0181	.0181	.0177	.0177	.0181	.0324	.0177
4	.0181	.0181	.0177	.0177	.0181	.0324	.0177
5	.0181	.0181	.0177	.0177	.0181	.0324	.0177
6	.0181	.0181	.0177	.0187	.0181	.0362	.0177
7	.0181		.0177	.0177	.0181	.0362	.0177
8	.0181	.0183	.0177	.0177	.0181	.0181	.0177
9	.0181	.0181	.2658	.2987	.1417	.0181	.0177
10		.0181	.2987	.3734	.1595	.0181	
11	.0183	.0177		.3403	.1086		.0177
12	.0183	.0177			.0905	.0177	.0177
13	.0183	.0177	.112		.0732	.0177	.0177
14	.0181	.0177	.0339	.3224	.0549	.0354	.0177
15	.0181	.0177	.0377	.2629	.0543	.0709	.0177
16	.0181	.0177		.2126	.0724	.0709	.0177
17	.0183	.0177	.0187		.0549	.0177	.0175
18	.0183	.0177	.0373	.0177	.0366	.0354	.0177
19	.0183	.0177	.0354	.0362	.0366		.0177
20	.0183	.0177	.0354	.0181	.0543		.0177
21	.0183	.0177	.0354	.0181	.0543		.0177
22	.0183	.0177		.0181	.0362		.0373
23	.0183	.0177	.0177	.0362	.0362		.0373
24	.0181	.0183	.0177	.0187	.0181	.0362	.0177
Max	.0183	.0183	.2987	.3734	.1595	.0709	.0373
Min	.0181	.0177	.0177	.0177	.0181	.0177	.0175
Avg	.0182	.0179	.0544	.1008	.0511	.0328	.0194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 201 / 11 KV Kanoli Vg.

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.2743	.2401		.2572	.2401	
2	.2534	.2401	.2401		.2572		
3	.2561	.2743	.2743		.2572		
4	.2534	.2915	.2915				
5	.2896	.3258	.3086				
6	.3292	.3772	.3429	.4481			
7	.4207	.4115	.4115	.4668		.4115	
8	.439	.463	.4973	.5601		.4287	
9	.4706	.5144	.5144	.5788	.5487		
10		.4458	.4458	.5601	.5144		
11		.3772		.4108	.4287		.3429
12	.3361	.3429	.3006	.2896	.3772		.208
13		.2572	.2241	.2896	.3429		
14	.3361	.2572		.2896	.2572		.3467
15		.2572		.2896	.2572		.3814
16	.3757	.2572		.3077	.2572		
17		.2401	.2374	.3439	.4287		.3988
18	.5228	.3429		.4344	.4973		.4458
19	.6722	.5658			.6516		.6241
20	.6687	.6687		.6335	.6173		.6588
21	.5658	.583	.6722		.5487		.583
22	.4458	.4287					
23	.3258	.2743	.3734		.2743		.0686
24	.2896	.2743	.2401		.2743		
Max	.6722	.6687	.6722	.6335	.6516	.4287	.6588
Min	.2534	.2401	.2241	.2896	.2572	.2401	.0686
Avg	.3949	.3644	.3509	.4216	.3915	.3601	.4058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 202 / 11KV Sarambalwadi Ag.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0686	.0171		.0343	.0343	
2	.096	.0686	.0171		.0343	.0343	
3	.096	.0686	.0171		.0343	.0343	
4	.1097	.1029	.0171			.0343	
5	.1094	.1372	.0171			.0343	
6	.125	.1372	.0171			.0343	
7	.125	.2058	.0171			.0514	
8	.0543	.0343	.0171			.0343	
9	.0362	.0171	.1715	.112	.0686		
10		.0171	.1372	.112	.0857		
11		.0171		.1357	.0686		.0347
12	.038	.0171		.144	.0686		.0347
13		.0171	.112	.096	.0686		.0351
14	.0377	.0171		.096	.0343		.0173
15		.0171		.08	.0343		.0175
16	.0373	.0171		.064	.0343		
17		.0171	.0373	.0362	.0343		.0171
18	.038	.0343		.0362	.0343		.0175
19	.038	.0343		.0543	.0343		.0171
20	.0343	.0171			.0343		.0171
21	.0343	.0171	.0187		.0343		.0173
22	.0686	.0171					
23	.0686	.0171	.0187		.0343		.0693
24	.0937	.0686	.0171		.0343		
Max	.125	.2058	.1715	.144	.0857	.0514	.0693
Min	.0343	.0171	.0171	.0362	.0343	.0343	.0171
Avg	.0710	.0493	.0433	.0879	.0448	.0364	.0268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 203 / 11 kv Kolindre Ag.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0343	.1543	.3361	.0686	.0686	
2	.0362	.0343	.1543		.0686	.0686	
3	.0362	.0343	.1543		.0686	.0686	
4	.0366	.0343	.1543			.0686	
5	.0366	.0343	.1543			.0686	
6	.0358	.0514	.1543			.1029	
7	.0362	.0514	.1715			.1029	
8	.0526	.0514	.0171			.0343	
9	.25	.0514	.0171	.0381	.0343		
10		.2572	.0171	.0373	.0343		
11		.2229		.056	.0343		.0693
12	.2374	.2229		.0537	.0343		.0693
13		.2229	.0373	.0537	.0343		.0693
14	.2713	.2401		.0537	.0343		.0701
15		.2401		.0537	.0343		.0701
16	.2035	.2572		.0358	.0343		
17		.0343	.038	.0362	.0343		.0175
18	.0381	.0343		.0362	.0343		.0347
19	.038	.0343		.0362	.0343		.0347
20	.0514	.0343			.0343		.0347
21	.0514	.2401	.0571		.0343		.0347
22	.0343	.1543					
23	.0343	.1543	.1494		.0686		.0351
24	.0362	.0343	.1543	.1494	.0686		
Max	.2713	.2572	.1715	.3361	.0686	.1029	.0701
Min	.0343	.0343	.0171	.0358	.0343	.0343	.0175
Avg	.0817	.1150	.1056	.0751	.0438	.0729	.0490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 201 / 11 KV Devarde Vg.

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0781	.0886	.0895	.0747		.0732	.0754
2	.0819	.0914	.0924	.0754		.0732	.0762
3	.081	.0934	.0943	.0739	.0187	.0747	
4	.0838	.0934	.0094	.0701		.0747	
5	.0857	.1097	.1097	.0716			
6	.1494	.1097	.1267	.1097			.0924
7	.1848	.1629	.1848	.1463			.1097
8	.1829	.2126	.2218	.1772			.1867
9	.1829	.2926	.2172	.2195			.2195
10		.2033	.1791	.1478			.181
11		.2218		.1494	.1109		.1848
12	.1696	.2241		.1494	.0914	.0185	.1848
13	.2058	.1772		.1433	.128	.0185	
14	.1907	.2195		.1509	.1267	.0183	
15	.1791	.2172		.1494	.1267	.0187	.0377
16	.2149	.2218		.1387	.1294	.1109	.0732
17	.1991	.1772		.1715	.1494	.128	.1109
18	.2218	.2218	.1753	.1791	.2614	.2172	.1867
19	.2987	.2987	.3258	.2926	.3206	.2561	.2641
20	.3206	.3361	.3326		.3395	.2987	.2614
21	.2801	.3018	.3361		.3018	.2263	.2263
22	.2054	.1867	.1848				
23	.1448	.1448	.0914	.1357	.0914		.0943
24	.0926	.0867	.0876				.0724
Max	.3206	.3361	.3361	.2926	.3395	.2987	.2641
Min	.0781	.0867	.0094	.0701	.0187	.0183	.0377
Avg	.1743	.1872	.1681	.1413	.1689	.1148	.1465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 202 / 11 KV Velvatti Ag.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0312	.0362	.029	.029		.0171	.0183
2	.0328	.0354	.0297	.0274		.0171	.0185
3	.0343	.0351	.0305	.0259		.0175	.0185
4	.0347	.0351	.0312	.0251		.0179	.0185
5	.0351	.0343	.0312	.029		.0183	.0181
6	.0347	.0343	.0305	.0412			.0183
7	.0366	.0347	.048	.0389			.0179
8	.0343	.0347	.0362	.0343			.0181
9	.061	.096	.0351	.0366			.0151
10		.096	.0171	.056			.0152
11		.1014		.037	.0164	.0183	.0183
12	.088	.1		.0358	.0152	.0185	.0181
13	.1	.1054		.0354		.0185	.0185
14	.0705	.108		.0343		.0181	.029
15	.0714	.0914		.016		.0179	.0332
16	.0857	.0753		.0293		.0183	.0297
17	.0554	.0347		.0309	.037	.0181	.0354
18	.037	.0366	.0316	.0339	.037	.0183	.0354
19	.0566	.0373	.0366	.037		.0183	.0373
20	.0566	.0554	.0543		.0373	.0373	.037
21	.056	.0549	.037		.0373	.037	.0377
22	.0373	.0328				.0343	
23	.0366	.0297	.0198	.0251	.0181	.0366	.0362
24	.0324	.0362	.029	.0236	.0236		.0183
Max	.1	.108	.0543	.056	.0373	.0373	.0377
Min	.0312	.0297	.0171	.016	.0152	.0171	.0151
Avg	.0508	.0571	.0329	.0325	.0277	.0221	.0244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 203 / 11 KV Kittawade Ag.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0232	.0693	.0724		.0162	.0152
2		.0244	.0686	.0716		.0171	.0151
3		.0248	.0701	.0732	.0686	.0171	.0149
4		.0248	.0716	.0739		.0175	.0151
5		.0255	.0732	.0724		.0175	.0152
6		.0255	.0709	.0724			.0154
7		.0263	.0724	.0693			.0156
8	.0671	.0173	.0732	.0663			.0177
9	.0732	.0286	.0676				.0181
10			.0572				.0179
11		.0324		.0133	.0886		.0135
12	.0423	.0335		.013	.0924		.0185
13	.0446	.0343		.0282	.0412	.0171	.016
14	.0349	.0362		.0638	.0267	.0164	.0185
15	.0572	.0181		.0511	.0255	.0166	.0189
16	.0572	.0354		.0638	.0267	.0162	.0189
17	.0532	.0351		.0678	.0543	.0537	.0185
18	.0867	.061	.0503	.0663	.0543		.0173
19	.0739	.0926	.0532	.0648	.056	.0179	.017
20	.0934	.1075	.0895		.0747	.0183	.037
21	.0732	.0724	.0724		.0747	.0181	.0373
22	.0229	.0732				.0154	.017
23	.0232	.0693	.0671	.0617		.0149	.0166
24		.0232	.0701	.0701	.0648		.0162
Max	.0934	.1075	.0895	.0739	.0924	.0537	.0373
Min	.0229	.0173	.0503	.013	.0255	.0149	.0135
Avg	.0574	.0411	.0685	.0598	.0576	.0193	.0184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 201 / 11 KV KOWAD VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.2743			.2743	
2	.2481	.2743			.2347	
3	.2481	.2374			.2347	
4	.2481	.2374			.2743	
5	.3544	.2835			.2743	
6	.4298	.3391			.3086	
7	.5373	.5087	.4801		.4748	.5144
8	.5144		.4801		.5487	
9	.5487	.5228	.5144	.5144		
10		.5975	.5144	.5144		
11		.5601	.3688			
12		.4108		.5731		
13		.3361		.4252		
14		.2987				
15		.3361	.4409			
16			.3429			
23		.4115			.4801	
24	.2507	.3052	.3429		.3052	.4115
Max	.5487	.5975	.5144	.5731	.5487	.5144
Min	.2481	.2374	.3429	.4252	.2347	.4115
Avg	.3630	.3708	.4356	.5068	.3410	.4630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 202 / 11 KV Kagani Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354			.1006	
2	.0354			.1006	
3	.0351			.1017	
4	.0358			.1017	
5	.0354			.1029	
6	.0358			.1006	
7	.0358		.6706	.1029	.0671
9	.6036	1.0059			
10		1.1736			
11		1.3077			
12		1.4754			
13		1.4083			
14		1.4083			
15		1.2071			
23		.503		.0671	
24	.0358		.503	.1017	.0671
Max	.6036	1.4754	.6706	.1029	.0671
Min	.0351	.503	.503	.0671	.0671
Avg	.0987	1.1862	.5868	.0978	.0671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 203 / 11 KV Kudnoor Vg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3898	.2713			.2713	
2	.3898	.2374			.2713	
3	.394	.2374			.2347	
4	.4298	.2035			.2012	
5	.4607	.2058			.2347	
6	.4961	.2713			.3052	
7	.4961	.4409	.3429		.4748	.5487
8	.4801		.4115		.373	
9	.048	.4854	.3772	.4801		
10		.5975	.373	.4801		
11		.5601	.3391	.5014		
12		.5228		.5014		
13				.4252		
14		.4108				
15		.4108	.3052			
16			.3052			
23		.3429			.4115	
24		.3353	.3429		.3052	.3429
Max	.4961	.5975	.4115	.5014	.4748	.5487
Min	.048	.2035	.3052	.4252	.2012	.3429
Avg	.3983	.3689	.3496	.4776	.3083	.4458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 204 / 11 KV KUDNOOR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1696		
2	.1791	.1715		
3	.1791	.1715		
4	.2149	.1734		
5	.2481	.1696		
6	.2865	.1696		
7	.2149	.1696		
9		.0381	.3189	
10		.0381	.3086	.0671
11		.0381	.2713	.0671
12		.0381		.1966
13		.0381		.2591
14		.0381		
15		.0381		
16			.3506	
24	.1772	.2035		
Max	.2865	.2035	.3506	.2591
Min	.1772	.0381	.2713	.0671
Avg	.2096	.111	.3124	.1475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 205 / 11 KV KAGANI VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716	.0335			.0335	
2	.0716	.0335			.0335	
3	.0716	.0335				
4	.0709	.0351			.0339	
5	.0716	.0335			.0686	
6	.0716	.1017			.1029	
7	.1417	.1017	.1029		.1372	.1372
8	.1372		.1372		.1357	
9	.1715	.1867	.1357	.1372		
10		.112	.1017	.1372		
11		.1494	.0655	.1109		
12		.1494		.0747		
13		.112		.0747		
14		.0747				
15	.0747	.0747				
16			.0678			
23		.1029			.1029	
24	.0716	.0678	.0686		.0686	.0686
Max	.1715	.1867	.1372	.1372	.1372	.1372
Min	.0709	.0335	.0655	.0747	.0335	.0686
Avg	.0932	.0876	.0971	.1069	.0796	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 206 / 11 KV Hemrus

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343					
2	.0343				.0339	
3	.0343					
4	.0343				.0335	
5	.0343					
6	.0343				.0335	
7	.0343		.0343		.0339	.0343
8	.0343		.0343		.0335	
9	.0686		.0335	.0343		
10				.0343		
11				.0358		
12		.0381		.0373		
13		.0381		.0373		
14		.0381				
15	.0362	.0381	.0335			
16			.0335			
23		.0343			.0343	
24	.0343		.0343		.0335	.0343
Max	.0686	.0381	.0343	.0373	.0343	.0343
Min	.0343	.0343	.0335	.0343	.0335	.0343
Avg	.0376	.0373	.0339	.0358	.0337	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 207 / Nrusinhwadi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358				
2	.0358			.1017	
3	.0354				
4	.0358			.1006	
5	.0358			.1017	
6	.0358			.1006	
7	.0358		.1677	.1017	.0671
9	.2347	.2683			
10		.2683			
11		.3018			
12		.3353			
13		.3688			
14		.3353			
15	.3932	.2347			
23		.1006		.0335	
24	.0358		.1006	.1006	.0335
Max	.3932	.3688	.1677	.1017	.0671
Min	.0354	.1006	.1006	.0335	.0335
Avg	.0914	.2766	.1342	.0915	.0503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 208 / RAJGOLI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149			
2	.2126			
3	.2149			
4	.2149			
5	.2347			
6	.2683			
7	.3353			
9			.3429	
10			.4854	
11			.4252	.1341
12				.3277
13		.0381		.3932
14		.0381		
15			.4207	
16			.4115	
24	.2507			
Max	.3353	.0381	.4854	.3932
Min	.2126	.0381	.3429	.1341
Avg	.2433	.0381	.4171	.285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 202 / 11 KV Shinoli Ex.

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1463	.0655	.1132	.0655	.1132	.1132
2	.0377	.0362	.0328	.0377	.0328		.0377
3	.0377	.0362	.0328	.0377	.0328	.0189	.0377
4	.0377	.0362	.0328	.0377	.0328	.0189	.0377
5	.0377	.0362	.0328	.0377	.0328	.0189	.0377
6	.0377	.0362	.0339	.0377	.0328	.0189	.0377
7	.0377	.0362	.0347	.0377	.0328	.0189	.0377
8	.1132	.1463	.12		.1147	.1132	.1132
9	.1509	.1463	.1357		.1311	.1886	.1509
10		.1663	.1357		.1311	.1509	.1509
11	.1448	.1311			.1311	.1698	.1311
12	.1463	.1147			.1147	.1132	.1311
13	.128	.0339	.1132		.1311	.1132	
14		.0158	.1132		.0328	.1132	
15		.1147	.0377		.0983	.0377	.0164
16	.0362	.0328			.0983	.0377	
17	.0366	.0164	.0377		.0328	.0377	.0328
18	.0362	.0328	.0377	.0328	.0328	.0377	.1147
19	.0366	.0328	.0377	.0328	.0328	.0377	.1147
20	.128	.0328	.0377	.0328	.1311	.1509	.1147
21	.1478	.1311	.1509	.1311	.1147	.1509	.1311
22	.1463	.1311			.1311		
23	.1494	.1311	.1509	.1147	.1311		.1311
24	.1132	.1463	.1187	.1132	.1147		.1132
Max	.1509	.1663	.1509	.1311	.1311	.1886	.1509
Min	.0362	.0158	.0328	.0328	.0328	.0189	.0164
Avg	.0882	.0800	.0746	.0613	.0819	.0830	.0893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 203 / 11 KV Gaulwadi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0171	.1696	.2134	.0492	.0457	.0152
2	.0152	.0171	.1475	.1829			.0152
3	.0152	.0171	.1475	.1829		.0457	.0152
4	.0152	.0171	.1802	.1829		.0457	.0152
5	.0152	.0171	.2294	.2134		.0457	.0152
6	.0152	.0171	.2622	.2439		.0457	.0152
7	.0152	.0171	.3277	.3658		.0457	.0152
8	.0152	.0171	.017	.0152		.0152	.0152
9	.6097	.6859	.017	.0152		.0152	.1219
10		.7373	.0328			.0152	
11	.7545	.6325				.0152	
12	.7969	.763	.0152		.0164	.0152	.0819
13	.7545	.7122	.0152		.0164	.0152	.1311
14		.5898	.0152		.0164	.0152	
15		.5898	.0152		.0164		
16	.7545				.0164	.0152	.0983
17	.0168	.2785	.0152		.0164	.0152	
18	.017	.0164	.0152	.0164	.0164	.0152	.0164
19	.0339	.0164	.0152	.0164	.0164	.0152	.0164
20	.0339	.0164	.0152	.0164	.0164	.0152	.0164
21	.017	.0164		.0164	.0164	.0152	.0164
22	.017	.1966		.0492	.0492		
23	.017	.1475	.2439		.0492		.0164
24	.0152	.017	.1638	.2439	.0492	.0457	.0152
Max	.7969	.763	.3277	.3658	.0492	.0457	.1311
Min	.0152	.0164	.0152	.0152	.0164	.0152	.0152
Avg	.1885	.2414	.1030	.1316	.0258	.0259	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 205 / 11 KV BELEBHAT Mix

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.1463	.1311	.1227	.1578	.1227
2	.1227	.1463	.1147	.1227		.1227
3	.1227	.1463	.1187	.1227	.1227	.1227
4	.1402	.1646	.1526	.1402	.1227	.1402
5	.2103	.1829	.1865	.1578	.1402	.1753
6	.2804	.2715	.2458	.1928	.1753	.2134
7	.4557	.4572	.3932	.333	.3506	.3856
8	.4557	.499	.4239	.3856		.4207
9	.4557	.4572	.3988	.4207		.3681
10		.4755	.2949			
11	.3982	.4239	.3506			
12	.362	.39	.3155		.1753	.3441
13	.362	.2458	.3155			
14		.3222	.2804		.2629	
15		.3113	.2804			.2949
16	.2561	.2785			.3856	.3768
17	.3475	.2785	.2629		.4382	.3441
18	.4024	.3768	.3681	.4096	.3963	.407
19	.4805	.407	.4733	.4588	.6135	.5121
20	.6283	.6274	.631	.5243	.5959	.5243
21	.5729	.5243	.5258		.5258	.4424
22	.4024	.3441				
23	.1867	.213	.1928			.1802
24	.1578	.1646	.1357	.1402	.1402	.1402
Max	.6283	.6274	.631	.5243	.6135	.5243
Min	.1227	.1463	.1147	.1227	.1227	.1227
Avg	.3305	.3273	.2996	.2716	.3069	.2967

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 206 / 11 KV Gaulwadi Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.128	.1017	.0876	.0983	.1227	.1052
2	.1052	.1097	.104	.0876	.0983		.1052
3	.1052	.1097	.1017	.0876	.0983	.1052	.1052
4	.1227	.128	.1187	.0876	.1311	.1052	.1067
5	.1578	.1646	.1492	.1227	.1475	.1402	.1402
6	.2103	.1829	.1865	.1753	.1802	.2103	.1928
7	.2454	.2561	.2713	.2804	.2785	.3155	.298
8	.2629	.3109	.2543	.3155	.2785		.3155
9	.2454	.3292	.2572	.2804	.3113		.298
10		.2587	.2374				
11	.2195	.2883					
12	.2172	.2214			.2622	.2454	
13	.2353	.1475	.2103		.2458		.2458
14		.1475	.2279		.1966	.1928	
15		.1475	.1052		.213		.2294
16	.2195	.1638			.2294	.2454	.213
17	.2561	.1966	.1753		.2458	.2454	.3277
18	.2587	.2785	.2279	.2785	.2622	.2804	.2458
19	.3326	.2374	.298	.3441	.3277	.2896	.3441
20	.3511	.2949	.333	.3113	.3113	.333	.3441
21	.3142	.2713	.2804	.3113	.2785	.2804	.2785
22	.2378	.1966		.1966	.213		
23	.1867	.1107	.1402		.1475		.1475
24	.1227	.1494	.0983	.1052	.1147	.1402	.1227
Max	.3511	.3292	.333	.3441	.3277	.333	.3441
Min	.1052	.1097	.0983	.0876	.0983	.1052	.1052
Avg	.2148	.2012	.1939	.2048	.2123	.2168	.2192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 207 / 11 KV Turkewadi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0686	.2204		.0819	.0762	.0152
2	.061	.0514	.2204				.0152
3	.061	.0514	.1966				.0152
4	.061	.0514	.2458				.0152
5	.061	.0686	.2713				.0152
6	.061	.0857	.2785				.0152
7	.061	.0857	.4096				
8	.0762	.0857	.0655			.0305	.0152
9	.4877	.583	.0678			.0152	
10		.6173	.0492			.0152	
11	.5087	.6952	.061		.1475		.0492
12	.6613	.6226	.061		.0492	.0305	.0983
13	.6443	.6443	.061		.0655	.0305	
14		.6554	.061		.0655	.0152	
15		.5243	.0457		.0492		.0819
16	.5765				.0492	.0305	.0819
17		.0492	.061		.1311	.0457	.0492
18	.0509	.0492	.0457	.0655	.0655	.0457	.0328
19	.0678	.0492	.0457	.0655	.0492	.0457	.0328
20	.0848	.0164	.0457	.0655	.0492	.0457	.0328
21	.0678	.0492	.0152	.0492	.0655	.0152	.0328
22	.0678	.2374		.0819	.0983		
23	.0678	.2543			.1147		.0328
24	.061	.0678	.2374		.0819	.1067	.0152
Max	.6613	.6952	.4096	.0819	.1475	.1067	.0983
Min	.0509	.0164	.0152	.0492	.0492	.0152	.0152
Avg	.1925	.2462	.1317	.0655	.0776	.0392	.0359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 208 / 11 KV Shivanage Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0686	.017	.0152	.0152	.0305
2	.0762	.0686	.017	.0152		.0305
3	.0762	.0857	.017	.0152	.0152	.0305
4	.0914	.1029	.0509	.0152	.0152	.0305
5	.1067	.12	.017	.0152	.0152	.0305
6	.1219	.1543	.017	.0152		.0305
7	.1677	.2401	.0164	.0152	.0152	.061
8	.0152	.0171	.017	.0152		.0152
9	.0152	.0171	.5426	.381		.0152
10		.0171	.5935	.4096		
11		.017		.3932		.0164
12	.0168	.0164			.0457	.0164
13	.0168	.0158	.4877			
14		.0164	.4877		.0457	
15		.0164	.4572			.0164
16	.0168	.0164			.0457	
17	.0168	.0164	.0152		.0152	.0164
18	.017	.0164	.0152		.0152	.0164
19	.0168	.017	.0152	.0164	.0152	.0164
20	.017	.0164	.0152	.0164	.0152	.0164
21	.017	.0158	.0152		.0152	.0164
22	.1017	.0164				
23	.0848	.017	.0152			.0492
24	.0762	.0857	.017	.0152	.0152	.0305
Max	.1677	.2401	.5935	.4096	.0457	.061
Min	.0152	.0158	.0152	.0152	.0152	.0152
Avg	.0572	.0496	.1423	.0967	.0217	.0255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 209 / 11 KV BELEBHAT Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)
1		.0457
2		.0457
3		.0457
4		.0457
5		.0457
6		.0457
7		.0762
8		.0457
15		.0492
16	.061	.0492
17	.0305	
18	.0457	.0655
19	.0457	.0655
20	.061	.0328
21	.061	.0328
23		.0492
24		.061
Max	.061	.0762
Min	.0305	.0328
Avg	.0508	.0501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 210 / Gad AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0171	.0164	.0152	.0164	.0152	.0305
2	.0305	.0171	.0164	.0152	.0328		.0305
3	.0305	.0171	.0164	.0152	.0328	.0152	.0305
4	.0305	.0171	.0164	.0152	.0328	.0152	.0305
5	.0305	.0171	.0164	.0152	.0164	.0152	.0305
6	.0457	.0343	.0164	.0152	.0328	.0152	.0305
7	.061	.0514	.0164	.0152	.0164	.0152	.0305
8	.0152	.0171	.017	.0152	.0164	.0152	.0152
9	.0152	.0171	.1696	.1524	.0164	.0152	.0152
10		.0171	.1638		.0328	.0152	.0152
11	.0168	.017	.1829		.0328	.0305	.0164
12	.0168	.0152	.1372		.0328	.0305	.0164
13	.0168		.1219		.0328		.0164
14		.017	.1219		.0328	.0305	
15		.0164	.1067		.0328		.0164
16	.0168	.0164			.0328	.0305	
17	.017	.0164			.0164	.0152	.0164
18	.017	.0164	.0152		.0164		.0164
19	.017	.0164	.0152	.017	.0164	.0152	.0164
20	.017	.0158	.0152	.0164	.0164	.0152	.1147
21	.017	.0164	.0152	.0164	.0164	.0152	.0164
22	.0339	.0164		.0164	.0164		
23	.017	.0164	.0152	.0164	.0164		.0328
24	.0305	.017	.0164	.0152	.0164	.0152	.0305
Max	.061	.0514	.1829	.1524	.0328	.0305	.1147
Min	.0152	.0152	.0152	.0152	.0164	.0152	.0152
Avg	.0249	.0189	.0585	.0248	.0239	.0186	.0271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 201 / 11 KV Adkur Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0191	.0381	.0185	.0373	.0189	.0191
2	.0185	.0191	.0381	.0187	.037	.0189	.0189
3	.0187	.0191	.0373	.0187	.0362	.0191	.0189
4	.0187	.0191	.0362	.0189	.0381	.0191	.0191
5	.0543	.0377	.0373	.0189	.0566	.0191	.0187
6	.0554	.0377	.0373	.0377	.056	.0191	.0373
7	.0554	.0566	.0754	.0537	.0554		.0549
8	.0532	.0554		.0554	.056		.0543
9	.0189	.0554		.056	.0549		
10		.0381			.0566		
11	.0373	.0373	.0377	.0191	.056		
12	.0377	.0373	.0377		.0377		.0716
13	.0377	.037	.0373		.0377	.0187	.0351
14			.0373	.0187	.0377	.0191	.0373
15		.0377	.0373		.0187	.0189	
16	.0366	.0377	.037		.0187	.0189	.0366
17	.0554	.037	.0895		.0377		.0537
18	.0716	.037	.0914	.0709	.0943	.0732	.0183
19	.0716	.0754	.0934	.0709	.0934	.0747	.0183
20	.0943	.0754	.1132	.0724	.112	.0953	.0747
21	.0754	.0943	.0943	.0732	.0943	.0754	.0747
22	.0572	.0566	.0566	.0549	.0377	.0566	
23	.0381	.0377	.0373	.0373	.0377	.0377	.0189
24	.0185	.0191	.0377	.0181	.0373	.0189	.0191
Max	.0943	.0943	.1132	.0732	.112	.0953	.0747
Min	.0185	.0191	.0362	.0181	.0187	.0187	.0183
Avg	.0449	.0425	.0542	.0407	.0515	.0366	.0368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 202 / 11 KV Kurtanwadi Vg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0377	.0343	.0549	.0263	.0377	.0566
2	.0362	.0351	.0347	.0373	.0549	.0373	.0381
3	.037	.0377	.0373	.0377	.0554	.0366	.0381
4	.0373	.0377	.0373	.0377	.0554	.0377	.0377
5	.0514	.0732	.056	.0373	.0554	.0377	.0566
6	.104	.1097	.112	.0934	.0747	.0377	.0934
7	.1052	.1629	.1294	.1463	.0747		.1478
8	.1417	.1448		.1478	.0747		.1433
9	.1086	.1463		.1132	.1402	.132	.132
10		.1307		.112	.1402	.1307	.1109
11	.1075	.096	.0905	.112	.0724	.0754	.0905
12	.124	.0945	.0554	.0111	.1017	.0747	.0905
13	.1132	.1063	.0724	.1109	.1017	.0732	.0739
14		.1052	.0572	.104	.0934	.1132	.0747
15		.1227	.0566		.0934	.1109	
16	.1402	.0983			.1109	.1109	
17	.1052	.1265			.1646		.0701
18	.1928	.1448		.0732	.1829	.2058	.1677
19	.1867	.1629	.2378	.0724	.2033	.2614	.2241
20	.2378	.2481	.2614	.0732	.2218	.2641	.2263
21	.1829	.2054	.2427	.0724	.1886	.2241	.2263
22	.128	.132	.168	.1086	.132	.1509	
23	.0754	.0754	.0754	.0543	.0549	.0747	.112
24	.052	.0566	.0566	.0543	.0543	.0377	.0566
Max	.2378	.2481	.2614	.1478	.2218	.2641	.2263
Min	.0362	.0351	.0343	.0111	.0263	.0366	.0377
Avg	.1105	.1121	.1008	.0792	.1053	.1078	.1080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 204 / 11 KV Hambire Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0135		.0686	.0187	.017		
2	.0133		.0686	.0189	.017		
3	.0137	.0572	.0754	.0187	.0183		
4	.0135	.0686	.0747	.0187	.017		
5	.0857	.1029	.0747	.0189	.017		
6	.08	.1372	.0754	.0189	.017		
7	.088	.1372	.0754	.0189	.0187		
8	.0189	.0152		.0189	.0187		
9	.0187	.0678		.1311	.0747		
10		.0678		.1296	.0747		.0189
11	.017	.0754	.1296	.1296	.0747		.0187
12	.0189		.1265	.1296	.0533		.0187
13	.0189		.1094	.1387	.0533		.0189
14		.0187	.1204	.0139	.0705		.0187
15		.0189	.1189		.0857	.0145	
16	.0171	.0189	.132		.0667		
17	.0171	.0187	.0189		.0171		.0187
18	.017	.0189	.0189	.0187	.0171	.0189	.0189
19	.0686	.0189	.0189	.0187	.0686	.0754	.0181
20	.0686	.0189	.0189	.0189	.0686	.0943	.0187
21	.0678	.0351	.0189	.0189	.0686	.0754	.0187
22	.0533	.0754	.0189	.0189	.0686		
23	.0686	.0754	.0189	.0189	.0686		.0187
24	.0181	.0686	.0754	.0189	.0171	.0686	
Max	.088	.1372	.132	.1387	.0857	.0943	.0189
Min	.0133	.0152	.0189	.0139	.017	.0145	.0181
Avg	.0379	.0558	.0694	.0455	.0454	.0579	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 205 / 11 KV Kuratnwadi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0171	.0175	.0263	.0381	.0152	.0133
2	.0152	.0175	.0175	.0219	.0067		.0135
3	.0152	.0171	.0274	.021	.0067		.0135
4	.0152	.0187	.0274	.021	.0067		.0133
5	.0162	.0171	.032	.0191	.0067		.0124
6	.016	.0187	.0366	.0198	.0067		.0124
7	.016	.0187	.0335	.0198	.0067		.0103
8	.016	.0171		.1478	.0168		.0103
9	.0114	.0617		.0173	.0171	.0171	.0088
10		.0991			.0171	.012	.0048
11	.0381		.0128	.0175	.0171	.0116	.0048
12	.0476	.0814	.0154	.0177	.0171	.0118	.0048
13	.0572	.0823	.0111	.0181	.0171	.012	.004
14		.0854	.0082	.0181	.0171	.0107	.0046
15		.096	.009		.0187	.0156	
16	.0572	.0629			.0171	.0114	
17	.0158	.0168			.0171		.0097
18	.016			.012	.0171	.0124	.0097
19	.0156	.0156	.0166	.0164	.0171	.012	.0099
20	.016	.0156	.0166	.0191	.0171	.0114	.0095
21	.0171	.0263	.0162	.0191	.0171	.0131	.0111
22	.0156	.0198	.016	.0189	.0091	.012	
23	.017	.0198	.0175	.056	.0305	.0124	.0111
24	.0152	.0171	.0168	.0251	.0747	.0152	.0135
Max	.0572	.0991	.0366	.1478	.0747	.0171	.0135
Min	.0114	.0156	.0082	.012	.0067	.0107	.004
Avg	.0221	.0383	.0193	.0276	.0181	.0129	.0098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 206 / 11 KV Adkur Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0617	.1128	.0754	.0754	.0187	.0189	
2	.0617	.1189	.0747	.0754	.0187	.0189	
3	.0693	.1189	.0747	.0747	.0187	.0189	
4	.0686	.1067	.0747	.0754	.0189	.0189	
5	.0724	.1524	.0747	.0754	.0189	.0189	
6	.2149	.2134	.0747	.0754	.0191	.0189	
7	.2126	.2439	.1143	.0754	.0191		
8	.1132	.1132		.0943	.0191		
9	.112	.1509		.2824	.0164		
10		.1509		.286	.0149		
11	.1509	.112	.2439	.2469	.0152		
12	.1698	.1132	.2934		.0648		.0151
13	.1509	.112	.362	.2774	.1219	.0724	.0189
14		.1132	.2858	.2743	.1372	.104	.0171
15		.1132	.2503		.0686	.1372	
16		.0943	.2235		.0678	.1	
17	.0686	.0754	.1132		.017		.0189
18	.0943	.0943	.1132	.0732	.0754	.0762	
19	.1017	.0943	.1132	.0724	.0754	.0754	.0191
20	.1017	.0943	.1132	.0732	.0686		.0191
21	.08	.0754	.0953	.0183	.0686		.0189
22	.1128	.0754	.0754	.0183	.0754		
23	.1128	.0754	.0754	.0183	.0754		.0648
24	.061	.1128	.0754	.0747	.0183	.0686	
Max	.2149	.2439	.362	.286	.1372	.1372	.0648
Min	.061	.0754	.0747	.0183	.0149	.0189	.0151
Avg	.1095	.1182	.1427	.1168	.0472	.0575	.0240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 208 / 11 KV Chandgad

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218		.2241	.2195	.439	.2012	.2452
2	.2241		.2241	.2241	.4527	.1886	.2263
3	.3395	.2195	.2195	.1886	.3292		.2241
4	.3258	.2195	.2195	.1867	.3292		.2241
5	.3155	.2926	.2614	.2241	.3292		.2241
6	.4115	.3292	.3584	.3174	.439		
7	.4161	.3921	.5601	.3801	.4481		.5121
8	.4207	.4481		.4435	.439		.5544
9	.5373	.6219		.4572	.5487	.4435	.5601
10		.6283			.5487	.5544	.567
11	.6516	.788	.6805	.6516	.5487	.5228	.5788
12	.6697	.7442	.7059	.6584	.6379	.5228	
13	.5544	.543	.5194	.6722	.5784	.5601	.5788
14		.5487	.5973	.6516	.543	.5544	.3258
15		.5611	.5792		.5973	.4527	
16	.5373	.5552	.4755		.5487	.4481	
17	.543	.439	.4706		.543	.499	.3258
18	.4435	.4656	.4481	.6722	.543	.499	.543
19	.499	.5487	.6224	.6722	.5601	.6722	.5601
20	.6722	.5658	.5975	.6584	.5601	.6653	.6722
21	.5487	.5658	.5658	.679	.5658	.6099	.6722
22	.5041	.4481	.4715	.543	.4435	.4854	.6722
23	.3292	.3361	.3395	.4344	.2772	.2801	.5601
24	.2263	.2926	.1867	.2195	.439	.2172	.2427
Max	.6722	.788	.7059	.679	.6379	.6722	.6722
Min	.2218	.2195	.1867	.1867	.2772	.1886	.2241
Avg	.4472	.4797	.4441	.4577	.4870	.4654	.4535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 201 / 11 KV VAIJANATH

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0857		.0857	.0857
2	.0857	.0857	.0857	.0857		.0857	.0914
3	.0857	.0857	.0857	.0857		.0857	.0914
4	.0857	.0857	.0857	.0857		.0857	.0914
5	.0857	.0857	.0857	.0857		.0857	.0914
6	.0857	.0857	.0857	.0857		.0857	.0914
7	.1715	.0857	.1715	.0857		.0857	.0914
8	.4287	.1715	.5144	.0857	.1715	.0857	.0914
9	.6001	.3429	.5144	.2572	.0857	.0857	
10		.6001	.4287	.4572	.0857	.0914	.0857
11		.5144	.2572		.0857		.0857
12		.6001	.4287		.0857		.0857
13		.6001	.4287	.2743	.0857	.1829	.0857
14	.6859	.6001	.3429	.3658	.0857	.1829	.0857
15	.6001	.5144	.3429	.3658	.0857	.0914	.0857
16	.6001	.5144	.3429	.0914	.0857	.0914	.0857
17	.5144	.4287	.3429	.1829	.0857		.0857
18	.4287	.3429	.3429	.1829	.0857		.0857
19	.3429	.3429	.2572	.1829	.0857	.1829	.0857
20	.3429	.3429	.2572		.0857	.1829	.0857
21	.3429	.3429	.1715		.0857	.0914	.0857
22	.1715	.1715	.0857		.0857	.0914	.0857
23	.1715	.0857	.0857		.0857	.0914	.0857
24	.0857	.1715	.0857	.0857		.0857	.0914
Max	.6859	.6001	.5144	.4572	.1715	.1829	.0914
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.3001	.3036	.2465	.1740	.0911	.1069	.0877

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 202 / 11 KV HITECH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.5144	.5144	.6859	.6859	.5144
2	.5144	.6001	.6001	.5144	.6001	.6001	.5144
3	.6001	.5144	.6001	.5144	.6001	.5144	.5144
4	.6001	.6859	.5144	.5144	.5144	.6001	.5144
5	.5144	.6001	.6001	.5144	.5144	.5144	.5144
6	.5144	.5144	.5144	.5144	.6859	.5144	.5144
7	.6001	.5144	.6001	.5144	.6859	.6001	.5144
8	.9431	.7716	.5144	.5144	.5144	.5144	.5144
9	.6859	.6859	.5144	.4287	.5144	.6001	.6001
10		.8573	.5144	1.2003	.7716	.6859	1.3717
11		1.7147	.2572		1.0288		1.3717
12	.8573	1.7147	.5144		1.1145	.6859	1.0288
13	1.0288	1.7147	.5144	1.5432	1.3717	.8573	.7716
14	1.6289	1.8004		1.2003	1.8861	.9431	1.1145
15	1.0288	1.7147		1.2003	1.7147	1.0288	1.8861
16	1.3717	1.5432	.3429	1.2003	1.5432	1.1145	1.2003
17	1.2003	1.1145	.4287	1.086	1.3717	.8573	1.3717
18	.6001	.6859	.0343	.9955	1.0288	.6001	1.1145
19	.5144	.5144	.4287		.8573	.6001	1.0288
20	.5144	.6001	.4287		.7716	.6001	1.0288
21	.6001	.5144	.4287		.8573	.6001	.8573
22	.6859	.6001	.6001		.8573	.6335	.7716
23	.8573	.6859	.6001		.7716	.5144	.6001
24	.6859	.6859	.6001	.5144	.6859	.6859	.5144
Max	1.6289	1.8004	.6001	1.5432	1.8861	1.1145	1.8861
Min	.5144	.5144	.0343	.4287	.5144	.5144	.5144
Avg	.7833	.9181	.4848	.7932	.9145	.6761	.8645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 203 / 11 KV Angolkar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.2572	.2572	.2572	.2572	.1715
2	.2572	.2572	.2572	.2572	.2572	.2572	.1715
3	.2572	.2572	.2572	.2572	.2572	.2572	.1715
4	.2572	.2572	.2572	.2572	.2572	.2572	.0857
5	.2572	.2572	.2572	.2572	.2572	.2572	.0857
6	.2572	.2572	.2572	.2572	.2572	.2572	.0857
7	.2572	.2572	.2572	.2572	.2572	.2572	.0857
8	.2572	.2572	.2572	.2572	.2572	.2572	.0857
9	.2572	.2572	.2572	.3429	.2572	.2572	
10		.3429	.2572	.3429	.3429	.3429	.0857
11		.3429	.2572		.3429	.3429	.0857
12	.3429	.3429			.3429	.2572	.2572
13	.3429	.3429		.3429	.3429	.2572	.2572
14	.4287	.4287		.3429	.4287	.2572	.3429
15	.3429	.4287		.3429	.3429	.3429	.3429
16	.4287	.3429	.2572	.3429	.3429	.3429	.3429
17	.3429	.3429	.2572	.3429	.3429	.2572	.3429
18	.3429	.2572	.2572		.3429	.2572	.3429
19	.3429	.2572	.2572		.3429	.2572	.3429
20	.2572	.2572	.2572		.3429	.2572	.2572
21	.2572	.2572	.2572		.2572		.2572
22	.2572	.2572	.2572		.2572	.1715	.2572
23	.2572	.2572	.2572		.2572	.1715	.2572
24	.2572	.2572	.2572	.2572	.2572	.2572	.1715
Max	.4287	.4287	.2572	.3429	.4287	.3429	.3429
Min	.2572	.2572	.2572	.2572	.2572	.1715	.0857
Avg	.2962	.2929	.2572	.2947	.3001	.2647	.2125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 204 / 11 KV Aqua

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6859	.6001	.5144	.6859	.6859	.6859
2	.6001	.7716	.5144	.5144	.6859	.7716	.6859
3	.6001	.6859	.6001	.5144	.6859	.6859	.724
4	.6859	.6001	.6859	.4287	.6859	.6001	.6859
5	.6859	.5144	.6001	.4287	.6859	.6859	.6859
6	.6001	.5144	.6859	.4287	.6859	.6001	.6859
7	.6001	.6001	.6001	.5144	.6859	.6859	.6859
8	.6859	.6859	.6001	.5144	.3429	.6859	.6859
9	.7716	.6859	.6001	.8573	.6859	.7716	.8573
10		.6859	.6001	.905	.8573	.905	.6859
11		.7716	.6859		.8573		.7716
12	.6859	.8573	.6001		.7716		.6859
13	.6859	.8573	.0514	.724	.6859	.905	.7716
14	.7716	.7716	.6859	.905	.7716	.905	.7716
15	.6859	.6859	.5144	.905	.8573	.8145	.6859
16	.5144	.7716	.5144	.8145	.6859	.8145	.7716
17	.6859	.8573	.5144	.724	.7716		.6859
18	.8573	.8573	.5144	.724	.8573	.8145	.8573
19	.9431	.7716	.4287		.8573	.8145	.7716
20	.6859	.6859	.4287		.7716	.8145	.8573
21	.7716	.7716	.4287		.8573	.905	.7716
22	.6859	.8573	.5144		.6859	.905	.8573
23	.6859	.6859	.5144		.6859		.6859
24	.6001	.7716	.6001	.5144	.6859	.7716	.6859
Max	.9431	.8573	.6859	.905	.8573	.905	.8573
Min	.5144	.5144	.0514	.4287	.3429	.6001	.6859
Avg	.6859	.7252	.5451	.6430	.7287	.7771	.7375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 201 / 11 KV AMROLI

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.1086	.0716	.1267	.1063		.0895
2	.1075	.0914	.0701	.1075	.0876		.0895
3	.1267	.0914	.0701	.1075	.0701		.0724
4	.1267	.0905	.0701	.0895	.0701		.0724
5	.1448	.0905	.124	.0905	.0886		.1075
6	.1629	.128	.1772	.1086	.1227		.1629
7	.2353	.2172	.2103	.2353	.2303	.0716	.197
8	.2534	.2534	.2454	.2353	.2454	.0724	.2149
9	.3258	.2896		.2686	.2279	.0716	.1991
10		.2896			.2279	.1254	.1991
11		.2454	.1991	.2149		.1791	.1448
12	.2172		.2172		.1595	.1791	.1463
13	.1829	.1578	.181		.1402	.181	.1463
14	.1646	.1772	.1267	.181	.1227		.1448
15		.1772		.1578	.1402		.128
16	.1829	.1949		.1646	.1595	.1433	.1448
17	.181	.2126	.1791		.1772	.1433	.1646
18	.2534	.2835	.2715	.2172	.2279	.1433	.2172
19	.362	.3856	.3403	.3258	.3506	.2328	.4344
20	.4525	.4161	.3982	.3982	.3856	.3582	.4572
21	.3801	.3856	.362	.3544	.3439		.3292
22	.2534	.2103	.1448	.2629	.1402		.2172
23	.181	.1227	.1448	.1734	.1052		.1448
24	.1267	.1267	.0886	.1448	.1227	.0895	.0895
Max	.4525	.4161	.3982	.3982	.3856	.3582	.4572
Min	.1075	.0905	.0701	.0895	.0701	.0716	.0724
Avg	.2157	.2063	.1846	.1982	.1762	.1531	.1797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 202 / 11 KV BONJURDI

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0895	.0358	
2				.1267		
3				.1267	.0358	
4				.1086	.0358	
5				.1267	.0358	
6		.0366		.1448	.0362	
7		.0366		.1267	.0358	
8		.0366				
9	.3582	.2715				.0934
10		.3077				.0914
11		.3366		.0362		.1097
12	.362	.3189				.1097
13	.362	.3898				.0905
14	.362	.3506		.0362		.0905
15		.3856				.0914
16	.3258	.4031				.0724
17	.0549	.0526	.0543			
18	.0543	.0526				
19	.0724	.0526		.0366		.0366
20	.0724	.0526		.0362		.0366
21	.0543	.0526		.0351		.0366
22	.0543	.2454	.1086	.0526		.0362
23	.0362		.1086	.0354		
24				.1448	.0362	
Max	.362	.4031	.1086	.1448	.0362	.1097
Min	.0362	.0366	.0543	.0351	.0358	.0362
Avg	.1807	.1989	.0905	.0842	.0359	.0746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 204 / Adkur Village

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895	.0724	.0532	.0895	.0709	.0537	.0537
2	.0905	.0537	.0526	.0895	.0526		.0537
3	.0905	.0549	.0526	.0724	.0526	.0537	.0537
4	.0716	.0543	.0526	.0716	.0549	.0537	.0716
5	.0905	.0724	.0876	.0895	.0701	.0724	.0905
6	.1075	.0914	.1402	.1075	.1063	.1267	.1075
7	.181	.181	.1595	.1629	.1753	.1612	.1433
8	.197	.197	.1753	.1791	.1772		.197
9	.1629	.181	.1629	.1629	.1772	.1267	.1433
10		.1629	.1267	.1448	.1417	.0895	.1448
11		.1595	.1267	.1254		.0895	.1448
12	.1254	.1417	.1267		.124	.0895	.1267
13	.1267	.0876	.1086		.124	.0537	.1086
14	.1267	.1227	.0905	.1086	.1052		.1267
15		.1417		.1052	.1052		.0905
16	.1448	.1578		.1267	.1052	.1086	.0549
17	.1448	.1772	.1086		.124	.1629	.0905
18	.1629	.1753	.1448	.1629	.1753	.1791	.1448
19	.2534	.2481	.2534	.2534	.2454	.1791	.2534
20	.2715	.2629	.2534	.2534	.2658	.2534	.2743
21	.2172	.2103	.2172	.2103	.2103	.1791	.2534
22	.1612	.1417	.0895	.1578	.0886		.1629
23	.1267	.0701	.0905	.1063	.0701		.1086
24	.1267	.0905	.0532	.0905	.0905	.0537	.0537
Max	.2715	.2629	.2534	.2534	.2658	.2534	.2743
Min	.0716	.0537	.0526	.0716	.0526	.0537	.0537
Avg	.1461	.1378	.1239	.1367	.1266	.1159	.1272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 205 / Satavane Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.181					.0537
2	.3077	.1829					.0543
3	.2896	.181					.0537
4	.2896	.181					.0543
5	.3077	.1991					.0537
6	.3077	.2172					.0543
7	.4525	.394					.0716
9			.724	.4706	.0709	.1791	
10			.7964	.4477	.0701	.1254	
11			.7164	.4656		.1254	
12			.7421		.2103	.1086	
13			.724		.2103	.1075	
14			.6697	.4656	.2103		
15				.3856	.1949		
16				.3582	.2103	.1075	
22	.181						.0362
23	.181					.0543	.0362
24	.2353	.181					.0537
Max	.4525	.394	.7964	.4706	.2103	.1791	.0716
Min	.181	.181	.6697	.3582	.0701	.0543	.0362
Avg	.2824	.2147	.7288	.4322	.1682	.1154	.0522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 201 / 11 KV Kurani Village

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0919	.1454	.1091	.0938		.0749	
2	.0919	.1091	.0909	.0938		.0749	
3	.0919	.0909	.0909			.0749	
4	.0919	.1272	.1091			.0749	
5		.1272	.0909			.0749	
6		.1636	.1272				
7		.1728	.1818				
8		.1999	.2181				
9		.239				.0749	
10		.2206	.1454	.2181		.0749	
11		.2022		.2181	.0562		
12	.1308	.1655		.1818			.0545
13	.1682	.1287	.1272			.1126	.0727
14		.1471	.1094	.1636		.1501	.0364
15		.1655		.1454			.0545
16	.1311	.1471		.1818		.1314	
17	.1873	.1091	.1873		.206	.2064	.0909
18	.2181	.1818	.239	.1311	.1124	.2064	.2181
19	.3272	.2545	.3677	.2622	.2622	.3003	.2545
20	.3999	.3999	.4316		.3184	.3753	.3817
21	.3272	.3453	.3941		.2996	.3003	.3817
22	.2181	.2545			.1873		.2363
23	.1818	.1091	.1501		.0936		.1454
24	.0919	.1636	.1091	.0938		.0749	
Max	.3999	.3999	.4316	.2622	.3184	.3753	.3817
Min	.0919	.0909	.0909	.0938	.0562	.0749	.0364
Avg	.1833	.1821	.1822	.1621	.1920	.1489	.1752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 202 / Bijur AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0691	.0346	.0346	.0346	.0173
2		.0864	.0346	.0346	.0173	.0173
3		.0864	.0346	.0346	.0173	.0173
4		.0691	.0346	.0346	.0173	.0173
5		.0691	.0346	.0346	.0173	.0173
6		.0864	.0346	.0346	.0173	.0173
7		.0864	.0346	.0346	.0173	
8		.0173	.0346	.0346	.0173	.0173
9		.0173		.0864	.0346	.0864
10		.0346	.0518	.0864	.0346	
11		.0346		.0864	.0173	
12	.0171	.0173		.0691	.0346	
13	.0346	.0173	.1037			
14		.0173	.1037	.0864		
15		.0173		.0518		
16	.0346	.0173		.0518		
17	.0346	.0173	.0173		.0173	
18	.0346	.0346	.0346	.0346	.0173	
19	.0346	.0346	.0518	.0346	.0173	
20	.0346	.0346	.0346	.0346	.0173	
21	.0346	.0346	.0346	.0346	.0173	
22	.0518	.0346		.0346	.0173	
23	.0518	.0346	.0346	.0346	.0173	
24	.0691	.0691	.0346	.0346	.0346	.0173
Max	.0691	.0864	.1037	.0864	.0346	.0864
Min	.0171	.0173	.0173	.0346	.0173	.0173
Avg	.0393	.0432	.0432	.0472	.0216	.0250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 203 / Pundra AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0339	.0339	.0339	.0339
2		.0339	.0339	.0339	.0339
3		.0339	.0339	.0339	.0339
4		.0339	.0339	.0339	.0339
5		.0339	.0339	.0339	.0339
6		.0339	.0509	.0339	.0339
7		.0339	.0339	.0339	.0339
8		.0339	.0339	.017	.0339
9		.0678		.017	.017
10		.0339	.017	.017	.017
11		.0339		.017	.017
12	.0509	.0339		.017	.017
13	.0509	.0339	.017		
14		.0339	.017	.017	
15		.0339		.017	
16	.0848	.0339		.017	
17	.0509	.017	.017		.017
18	.0339	.017	.017	.017	.017
19	.017	.017	.017	.017	.017
20	.017	.017	.017	.017	.017
21	.017	.017	.017	.017	.017
22	.0339	.0339		.0339	
23	.0339	.0339	.0339	.0339	
24	.017	.0339	.0339	.0339	.0339
Max	.0848	.0678	.0509	.0339	.0339
Min	.017	.017	.017	.017	.017
Avg	.0370	.0318	.0273	.0247	.0255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 201 / RAVIKIRAN PAPERMILL EXP

HV Non-Express Feeder

Feeder Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	1.0185	.0343	.0189		.037	1.1203
2	.8779	.7545	.0373			.0373	1.0829
3	.8029	.9054	.0187			.0185	1.0456
4	.9145	.8676	.037			.0185	1.1016
5	.8316	.9054	.0187			.0187	1.0269
6	.7282	.9054	.0185	.0187		.0187	.056
7	.9694	.9431	.0187	.0187			1.0642
8	.7023	.7167			.0187		.9896
9	.8871	.8488		.0373	.0185		1.0082
10		.7167			.0187		
11		.9431					1.0719
12	.9619	.7023			.0185	.7282	.7577
13	.7356	.924			.0185	.8402	.9328
14	.9619	.6908			.0187	.8215	.9795
15	.7356	.8779			.0554	.9149	.9055
16	.9431	.7842	.0187			.6908	.9795
17	.9242	.6653	.0187	.0183		.8775	.0187
18	.679	.5304	.0187	.0187	.0185	.6535	
19	.9431	.9522	.0187	.0185	.0187	1.1203	
20	.8488	.0185	.0181	.0187	.0185	.8589	
21	.8488	.0185	.0187	.0185	.0373	1.1203	
22	.9242	.0366	.0187	.0183	.037		
23	.7167	.037	.0187	.0187	.037	1.1389	
24	1.0164	.9242	.0373	.0373		.037	1.1576
Max	1.0164	1.0185	.0373	.0373	.0554	1.1389	1.1576
Min	.679	.0185	.0181	.0183	.0185	.0185	.0187
Avg	.8568	.6953	.0231	.0217	.0257	.5528	.8999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 202 / 11 KV Turkewadi Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0739	.0701	.056			.056
2	.0739	.0739	.0693	.056			.056
3	.0747	.0739	.0701				.056
4	.0732	.0739	.1052				.056
5	.0739	.0739	.1063				.056
6	.0914	.0924	.1227				.0747
7	.1307	.1478	.1227	.112			.0943
8	.1294	.1478	.1753	.168	.112		.1307
9	.2427	.1478	.208	.2054	.168		.2054
10		.1663	.2279	.2054	.2054		
11		.1478	.2241	.2054	.1629		.2241
12	.2587	.2126	.2614	.2241	.2054	.2054	.1848
13	.2033	.1753	.1494	.1867	.2012	.1867	.1867
14	.1848	.1753			.1867	.1867	.1867
15	.1848	.1734		.1848	.1928	.1867	.2012
16	.2033	.1227	.1867	.168	.208	.1867	.2054
17	.2033	.1387	.1494	.1715	.1753	.1867	
18	.1294	.1595	.112		.2103	.1494	.1494
19	.1663	.1578	.1867	.1867	.1753	.1867	.1478
20	.2033	.1753	.2054	.1867	.1402	.168	
21	.1663	.1734	.1494	.1829	.1578	.1307	
22	.1294	.124	.112	.112			.112
23	.0943	.0867	.0747	.0739	.0693	.0747	.0924
24	.0747	.0739	.0876	.056		.1109	.056
Max	.2587	.2126	.2614	.2241	.2103	.2054	.2241
Min	.0732	.0739	.0693	.056	.0693	.0747	.056
Avg	.1439	.132	.1444	.1523	.1714	.1633	.1266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 203 / Megha Express

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2263	.0747			.2241	.2054
2	.2054	.1886	.0554			.1848	.168
3	.2402	.2263	.0554			.1494	.1494
4	.1867	.2641	.0366			.1294	.1867
5	.2218	.1886	.0187			.168	.2054
6	.2033	.1886	.0187			.1294	.168
7	.1494	.132	.0185			.1463	.2054
8	.0914	.0754		.2801	.2427		.2241
9	.3547	.2075		.168	.2427		.1307
10		.3961		.3734	.5175		
11		.3772		.3696	.4066		.3547
12	.3018	.3547		.462	.4207	.2614	.3511
13	.3772	.0924		.4481	.2033	.2054	.2987
14	.3395	.4481			.2987	.3361	.2987
15	.4527	.439		.3696	.4108	.2987	.2801
16	.3772	.3734		.3734	.4066	.2801	.2614
17	.2452	.3734		.3326	.3696	.2801	.3326
18	.2075	.2012		.1663	.1663	.2614	.1646
19	.132	.1848		.2402	.1307	.2054	.1867
20	.2452	.2427			.2218	.112	.1478
21	.132	.2587			.168	.2241	.0934
22	.1698	.2587			.1663		.0747
23	.2075	.2241			.1867	.112	.0924
24	.2054	.2452	.0934			.2801	.1867
Max	.4527	.4481	.0934	.462	.5175	.3361	.3547
Min	.0914	.0754	.0185	.1663	.1307	.112	.0747
Avg	.2394	.2570	.0464	.3258	.2849	.2099	.2072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 201 / Parle Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1837	.1387	.1509	.1959		.108	
2	.1434	.1372	.1234	.1658			
3	.1392	.1387	.1315	.1675			
4	.1468	.1214	.166	.1357			
5	.2154	.1402	.2211	.137			
6	.2929	.2621	.2856	.2126			
7	.3567	.297	.3582	.2595			
8	.4111	.3494	.4477	.3326			
9	.4175	.3641	.4431	.3272			
10	.4033	.4334		.3555		.1856	
11	.2683		.3433	.3097		.1485	
12			.2997			.1858	.3121
13		.2435	.2564		.0375	.185	
14		.2406			.092	.185	.1387
15		.2374	.0755		.15	.1869	.104
16		.282			.3372	.2177	
17	.4537	.3536	.2521		.2411		.104
18	.4542	.6141	.3509		.2523	.2939	.1048
19	.4892	.6251	.4622		.4534	.4141	.4334
20	.5241	.753	.5573		.4103		.5028
21	.4892	.5853	.4825		.3761		.4161
22	.3145	.4661	.3738		.3381		.3467
23	.1734	.3658	.2241		.2433		.1907
24	.2215	.1214	.189	.2606		.1477	
Max	.5241	.753	.5573	.3555	.4534	.4141	.5028
Min	.1392	.1214	.0755	.1357	.0375	.108	.104
Avg	.3210	.3305	.2950	.2383	.2665	.2053	.2653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 202 / Here Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0301	.0152	.0152		.0152	
2	.0302	.0297	.0151	.0152		.0153	
3	.0151	.0297	.0151	.0152			
4	.0152	.0301	.0151	.0152			
5	.0151	.0297	.0149	.0152			
6	.0304	.0303	.0151	.0152			
7	.0302	.0303	.0152	.0152			
8	.0151	.0151	.0152	.0152			
9	.0151	.0151	.0605	.0152		.0152	
10	.0151	.0151		.0457		.0305	
11	.0151		.0456	.0457		.0153	
12			.0456				.0164
13		.0151	.0759				.0164
14		.0151	.0456				.0164
15		.0151	.0152				.0164
16		.0151			.0152		
17	.0151	.0151	.0151		.0153		.0164
18	.0151	.0151	.0151		.0152	.0153	.0164
19	.0151	.0151	.0152	.0151	.0152	.0153	.0328
20	.0303	.0151	.0152		.0152	.0154	.0328
21	.0303	.0151	.0152		.0153		.0328
22	.0454	.0151	.0152		.0152		.0164
23	.0602	.0151	.0152		.0153		.0164
24	.0304	.0452	.0151	.0152		.0152	
Max	.0602	.0452	.0759	.0457	.0153	.0305	.0328
Min	.0151	.0151	.0149	.0151	.0152	.0152	.0164
Avg	.0239	.0212	.0241	.0199	.0152	.0170	.0209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 201 / 11 KV Mangao VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0566	.0724	.0754	.0924	.0739	.056
2	.0747	.0566	.0724	.056	.056	.0566	.056
3	.0554	.0566	.0716	.056	.0566	.0848	.0554
4	.0732	.056	.0724	.0554	.0566	.0686	.0554
5	.056	.0754	.0724	.0747	.056	.0693	.0554
6	.0943	.0943	.1097	.0754	.0754	.0914	.0747
7	.1478	.132	.1463	.1294	.1307	.1052	.1109
8	.1433	.1463	.1829	.1791	.1463	.181	.1448
9	.156	.1463	.1612	.1612	.1267	.1928	.1463
10		.1417	.156	.1433	.1433	.1417	
11		.1433		.1254	.0914		.128
12	.128	.1227			.0739		.1052
13	.1063	.104	.0914	.0187	.0701	.0886	.1214
14	.1052	.1214	.0905	.1433	.0739	.1063	.104
15		.12		.1254	.0905	.0924	.0171
16	.1227	.1017		.1086		.124	.1086
17	.1772	.104	.1063		.1075	.124	.1187
18	.1791	.1417	.1294	.1448	.1086		.1696
19	.2149	.1629	.181	.181	.2012		.1991
20	.2402	.2534	.2534	.2427	.2353	.2218	
21	.2241	.2172	.2218	.2033	.1848	.2218	.2195
22	.168	.1848		.1494	.1463		.1829
23	.0754	.1254	.0943	.112	.1629		.1294
24	.0739	.0754	.1075	.0943	.112	.128	.0934
Max	.2402	.2534	.2534	.2427	.2353	.2218	.2195
Min	.0554	.056	.0716	.0187	.056	.0566	.0171
Avg	.1289	.1225	.1259	.1207	.1130	.1207	.1114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 202 / 11 KV Vargao AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0617	.048	.0312	.0187	.0187
2	.0191	.0189	.0625	.0474	.0309	.0377	.0187
3	.017	.0189	.0625	.0625	.0316	.0185	.0187
4	.0181	.0189	.0625	.0474	.032	.0185	.0187
5	.0183	.0189	.0617	.048	.0312	.0175	.0187
6	.0187	.0189	.0926	.0617	.0309	.0171	.0187
7	.0187	.0189	.2469	.1174	.0772	.0175	.0187
8	.0187	.0189	.0189	.0187	.0189	.0158	.0187
9	.3749	.2267	.0189	.0162	.0116	.0175	.0663
10		.4049	.0189	.0173	.0124	.0173	
11		.3563		.0189	.0189		.0648
12	.3479	.3521			.0183		.0926
13	.3593	.3395	.0181	.0162	.0179	.0171	.0926
14	.3637	.2721	.0185	.0179	.0179	.0185	.0914
15		.2623		.0187	.0149	.0173	.08
16	.3479	.2743		.0187		.0189	.0892
17	.0373	.0189	.017		.0168	.0156	.0183
18	.0377	.0187	.017	.0183	.017		.0171
19	.0377	.0187	.0177	.0187	.0177		.0185
20	.0377	.0187	.0185	.0189	.0185	.0187	
21	.0189	.0187	.0185	.0187	.0187	.0187	.0189
22	.0189	.081		.0351	.0362		.0187
23	.0189	.0781	.0474	.0343	.0187		.0189
24	.0185	.0189	.0781	.048	.0316	.0183	.0187
Max	.3749	.4049	.2469	.1174	.0772	.0377	.0926
Min	.017	.0187	.017	.0162	.0116	.0156	.0171
Avg	.1032	.1213	.0504	.0349	.0248	.0188	.0389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 203 / 11 KV Lakkikate AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0734	.0189	.0189	.0189	.0191	.0189
2	.0572	.0705	.0189	.0189	.0189	.0187	.0189
3	.0867	.0705	.0189	.0189	.0189	.0191	.0189
4	.0762	.0705	.0191	.0189	.0189	.0381	.0189
5	.0747	.0686	.0189	.0189	.0189	.0189	.0189
6	.0983	.0667	.0189	.0377	.0189	.0191	.0189
7	.1286	.1406	.0189	.0189	.0189	.0181	.0457
8	.0189	.0189	.0189	.0189	.0189	.0164	.0189
9	.0189	.0189	.208	.2241	.08	.044	.0189
10		.0189	.3239	.2458	.0406	.0282	
11		.0191		.2818	.0434		.0189
12	.0189	.0189			.0417		.0189
13	.0187	.0189	.2429	.1638	.0389	.044	.0189
14	.0189	.0189	.2056	.2429	.0267	.0518	.0189
15		.0189		.1619	.04	.0297	.0189
16	.0189	.0189		.1134		.0423	.0187
17	.0189	.0189	.0189		.0191	.0189	.0377
18	.0189	.0189	.0189	.0191	.0189		.0189
19	.0189	.0189	.0189	.0189	.0381		.0377
20	.0377	.0189	.0189	.0189	.0191	.0377	
21	.0189	.0377	.0189	.0377	.0191	.0377	.0189
22	.0762	.0381		.0373	.0191		.0486
23	.0724	.0189	.0377	.0187	.0189		.0486
24	.1187	.0734	.0189	.0377	.0189	.0189	.0377
Max	.1286	.1406	.3239	.2818	.08	.0518	.0486
Min	.0187	.0189	.0189	.0187	.0189	.0164	.0187
Avg	.0517	.0406	.0675	.0815	.0276	.0289	.0254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144120 / 33/11 KV Tudiye

Feeder No / Name : 201 / 11 KV Tudiye VG

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.2263	.2058	.1867		
2	.2149	.1593	.1867	.1753	.1886		
3	.2427	.1572	.2054	.1715	.1663		
4	.2263	.1614	.2263	.1772	.168		
5	.1753	.1715	.2263	.2058	.1402		
6	.2103	.2315	.2801	.2126	.0974		
7	.2058	.4024	.4294	.3258	.112		
8	.415	.5144		.4338	.1357		
9		.5658	.6283	.4527	.2033		.132
10		.5973	.5228	.4784	.1698		
11	.7164	.691				.1109	.2263
12		.6415		.5175		.1509	
13	.6836	.5487	.2012	.4481	.2829	.2561	.168
14	.6836	.6068	.2957	.4108	.3258	.2926	.3018
15	.6135	.7059	.381	.415	.2172	.2614	.381
16	.6626	.6516	.3395	.3772	.415		.3921
17	.6516	.5552	.4904	.3206	.2772	.1886	.415
18	.3395	.4508	.5093	.4338	.415	.3982	.4338
19	.4001	.4481	.4527	.4481	.3921		.4854
20	.5359	.5601	.5093	.5041	.3547	.3429	.5175
21	.4525	.4904	.4338	.462	.3109	.3018	.5121
22	.3561	.3841	.3189	.362		.2263	.4066
23	.2343	.2195	.2429	.2987			.2614
24	.2058	.2107	.2378	.2031	.2218		.1109
Max	.7164	.7059	.6283	.5175	.415	.3982	.5175
Min	.1753	.1572	.1867	.1715	.0974	.1109	.1109
Avg	.4007	.4290	.3497	.3496	.2390	.2530	.3389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 201 / 11 KV GADHINGLAJ

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.6219	.7316	.695	.7316	.6584	.6219
2	.695	.5853	.695	.5853	.7316	.6584	.6219
3	.695	.5853	.695	.5853	.7316	.6584	.6219
4	.695	.6219	.7316	.5853	.7682	.6584	.7316
5	.7316	.7316	.8779	.5853	.8779	.7316	.823
6	.9145	.9145	.9145	.8779	1.1706	1.134	.9511
7	1.1706	1.0974	1.0974	1.0974	1.2071	1.2803	1.134
8	1.1706	1.3169	1.1888	1.3169		1.5364	1.3169
9	1.1706	1.2071	1.3169	.9145	1.2803	1.2803	1.1888
10		1.1888	1.0974	1.2071	1.1888	1.1888	
11		1.1888		1.2071	1.0974		1.134
12	1.2437	1.134			1.0059		1.0608
13	1.1706	.9877	.9877		.9511	1.0059	1.0059
14	1.0974	1.0608	1.0242	1.0242	.9511	.9145	
15		1.0059	.9877	1.0608	.9511	.9145	.9511
16	1.1706	1.0608		1.0242	.9145		.9511
17	1.0974	1.1706	.9877		1.2071	1.1706	1.0974
18	1.2071	1.0608	1.0974	1.0608	1.3169	1.3169	1.1946
19	1.2803	1.2437	1.2803	1.1888	1.4266		1.3169
20	1.5546	1.6461	1.39	1.3169	1.39	1.5546	1.4632
21	1.4266	1.3535	1.3169	1.2803	1.3169	1.2803	1.3717
22	1.2803	1.2437		1.0974	1.0974		1.0974
23	.8779	.8779	.8413	.7316	.8413		.9145
24	.7316	.6219	.7316	.7316	.6219		.6401
Max	1.5546	1.6461	1.39	1.3169	1.4266	1.5546	1.4632
Min	.695	.5853	.695	.5853	.6219	.6584	.6219
Avg	1.0530	1.0220	.9995	.9607	1.0338	1.0554	1.0095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 204 / 11 KV Uttur Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1494	.1448	.4694	.2622	.301	.112
2	.2241	.1494	.1254	.4877	.2622	.3048	.112
3	.2241	.1494	.1075	.4694	.2622	.3048	.112
4	.2195	.1494	.1086	.4694	.2743	.3048	.112
5	.2241	.1494	.1448	.4694	.2743	.3048	.128
6	.2195	.1494	.1433	.5792	.2915	.3048	.16
7	.2195	.1463	.181	.9389	.6478	.3048	.208
8	.2195	.1463	.181	.2241		.1867	.2263
9	.6081	.6478	.2075	.2075	.2172	.181	.2561
10		.8322	.1886	.1886	.1448	.0183	
11		.4144		.1886	.1267		.2561
12	.6882	.5344			.1086		.2561
13	.6722	.7682	.0566		.1086	.1448	
14	.7522	.7682	.056	.1132	.1086	.1267	.0366
15		.7682	.0754	.1132	.1086	.1086	.0339
16	.5761	.8962		.1132	.1267		.5761
17	.1448	.132	.132		.1509	.1698	.1698
18	.2172	.132	.2263	.2172	.2263	.1867	.1698
19	.2172	.1886	.2829	.2172	.2263		.3018
20	.2896	.3206	.3018	.2896	.2829	.3018	.3018
21	.2865	.3206	.3018	.1783	.2641	.2829	.2641
22	.2172	.2715		.4108	.3239		.2263
23	.2987	.1448	.4877	.3521	.301		.1698
24	.2241	.1463	.1448	.4268	.2561		.112
Max	.7522	.8962	.4877	.9389	.6478	.3048	.5761
Min	.1448	.132	.056	.1132	.1086	.0183	.0339
Avg	.3315	.3531	.1799	.3392	.2329	.2257	.1955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 205 / 11 KV Nool Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0366	.0171	.1806	.1311	.0587	.032
2	.0373	.0366	.0177	.1829	.1311	.0533	.032
3	.0373	.0373	.0187	.1829	.1372	.0533	.032
4	.0366	.0373	.0171	.1829	.1372	.0533	.032
5	.0366	.0373	.0354	.1829	.1341	.0533	.048
6	.0366	.0373	.0358	.176	.1296	.0533	.048
7	.0366	.0373	.0358	.2347	.128	.0533	.064
8	.0366	.0373	.0181	.0373		.0187	.0185
9	.2241	.192	.0185	.0185	.0181	.0181	.064
10		.1875	.0185	.0185	.0181	.0183	
11		.2241		.0185	.0179		.064
12	.3041	.2561			.0181		.064
13	.3041	.2561			.0181	.0181	.048
14	.2561	.253		.017	.0181	.0181	.056
15		.3201		.037	.0181	.0181	.0509
16	.2772	.3201		.0185	.0181		.0324
17	.0181	.0185			.0189	.0189	.0189
18	.0362	.037		.0362	.0189	.0189	.0189
19	.0166	.037	.0377	.0358	.0189		.0189
20	.0171	.037	.0377	.0362	.0189	.0377	.0377
21	.0173	.037	.0377	.0293	.0377	.0377	.0189
22	.0343	.0354		.088	.0633		.0189
23	.0373	.0177	.1829	.1467	.0343		.0185
24	.0187	.0366	.0181	.1692	.1311		.032
Max	.3041	.3201	.1829	.2347	.1372	.0587	.064
Min	.0166	.0177	.0171	.017	.0179	.0181	.0185
Avg	.0884	.1068	.0365	.0966	.0615	.0354	.0378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 207 / 11 KV WATERWORKS

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1829	.2987	.1867	.1867	.1867	.2614
2	.1867	.1829	.2614	.1494	.1867	.1867	.1867
3	.1829	.1829	.2241	.1494	.1867	.1867	.1867
4	.1829	.1829	.1848	.1494	.1867	.1867	.2054
5	.1829	.1829	.2241	.1494	.1867	.1867	.2054
6	.1829	.2195	.2241	.1494	.1867	.1867	.2054
7	.2195	.2195	.2241	.2241	.2241	.1867	.2427
8	.2241	.2195	.2987	.2241		.2987	.2427
9	.4108	.415	.4481	.3734	.4108	.4108	.4108
10		.3395	.3734	.3921	.4108	.3734	
11		.2829		.3174	.3734		.3361
12	.2987	.3018			.2987		.2987
13	.2987	.3018	.2427		.2614	.2926	.2987
14	.2614	.3018	.2241	.2987	.2241	.2987	.2926
15		.2263	.2241	.2054	.2987	.2241	.2241
16	.2427	.2427		.2241	.2987		.2241
17	.2241	.2241	.2829		.2263	.2263	.2263
18	.2241	.2054	.2263	.2241	.2263	.2263	.2263
19	.2241	.1867	.2829	.2241	.2263		.197
20	.1867	.1867	.1886	.1867	.1886	.1578	.2075
21	.2241	.2241	.2075	.2241	.2263	.2263	.2263
22	.2614	.3547		.2987	.2641		.2829
23	.2926	.3734	.2241	.2614	.2614		.3547
24	.2987	.2987	.3361	.2241	.2614		.2987
Max	.4108	.415	.4481	.3921	.4108	.4108	.4108
Min	.1829	.1829	.1848	.1494	.1867	.1578	.1867
Avg	.2395	.2516	.2600	.2303	.2522	.2378	.2540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 210 / 11 KV Uttur VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.0732	.1829	.1829	.1463	.1463	.2195
2	.2926	.0732	.1463	.1829	.1463	.1463	.1829
3	.2926	.0732	.1463	.1829	.1463	.1463	.1829
4	.2926	.0732	.1829	.1829	.1463	.1463	.2195
5	.3292	.1097	.2195	.2195	.1463	.1463	.2561
6	.4024	.1463	.2926	.2195	.2195	.2561	.2926
7	.439	.1829	.3658	.3658	.3658	.3658	.4024
8	.3658	.1829	.3292	.3658		.3658	.439
9	.3658	.362	.3658	.4024	.3658	.3658	.439
10		.4207	.4024	.3841	.3658	.3658	
11		.3258		.3475	.3658		.2926
12	.3292	.3982			.2561		.2926
13	.2743	.2896	.2195		.2926	.2926	
14	.2561	.3439	.1829	.3109	.2561	.2926	.2926
15		.3258	.1829	.2926	.2926		.2926
16	.2743	.2926		.3109	.2195		.3658
17	.2926	.3475	.2715		.3077	.362	.362
18	.3658	.3475	.3982	.439	.3982	.3258	.4344
19	.439	.4572	.5068	.5121	.3982		.5068
20	.5121	.5487	.543	.5121	.543	.543	.543
21	.439	.5121	.4706	.439	.5068	.4887	.5068
22	.3658	.2195		.3658	.3801		.3982
23	.1097	.2195	.2195	.2195	.2195		.2378
24	.2926	.0732	.1829	.2195	.1829		.2378
Max	.5121	.5487	.543	.5121	.543	.543	.543
Min	.1097	.0732	.1463	.1829	.1463	.1463	.1829
Avg	.3344	.2666	.2906	.3170	.2899	.2972	.3362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 211 / 11KV Belbag

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.4755	.5487	.5121	.5121	.7682	.4755
2	.5853	.4755	.439	.5121	.5487	.8048	.439
3	.5853	.4755	.439	.5121	.6219	.8048	.439
4	.5853	.4755	.439	.5121	.6219	.8048	.4755
5	.5853	.5121	.5487	.5121	.7316	.8048	.5487
6	.695	.5853	.6584	.5487	.8413	.8048	.6219
7	.7316	.6584	.8048	.7682	.7316	.8048	.7316
8	.7682	.8048	.8048	.8779		.8779	.823
9	.8413	.8048	.823	.8413	.8048	.8779	.7316
10		.7392	.7316	.8048	.7316	.8048	
11		.7316		.823	.7316		.8048
12	.8596	.7316			.7316		.7316
13	.7682	.7316			.7316	.7316	.7316
14	.7682	.7316		.6584	.7316	.6584	.6584
15		.695		.5853	.6584		.6584
16	.7865	.7316		.695	.7316		.8048
17	.8048	.7682			.9511	.8048	.8048
18	.8779	.8048	1.1706	.8779	.9511	.9511	.8779
19	.9511	.9877	1.0974	.9511	1.0974		1.0242
20	1.0974	1.1706	1.2437	1.0242	1.0974	1.0974	1.1706
21	.9511	1.0242	1.0974	.8779	.9511	.9511	.9511
22	.8048	.8779		.8048	.7964		.8048
23	.5853	.7133	.6584	.5853	.5853		.6219
24	.5853	.4755	.5487	.5487	.439		.4755
Max	1.0974	1.1706	1.2437	1.0242	1.0974	1.0974	1.1706
Min	.5853	.4755	.439	.5121	.439	.6584	.439
Avg	.7525	.7159	.7533	.7063	.7535	.8345	.7133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 201 / 11 Kv Karambali Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1296	.1134	.4191	.3246		.4191
2	.1334	.1296	.1134	.4191	.2591		.4001
3	.1143	.1296	.1134	.4191	.1943		.381
4	.1143	.1296	.1134	.4191	.1943		.0191
5	.1524	.1296	.1296	.4382	.2591		.0762
6	.1905	.1296	.1296	.4382	.1619		.0762
7	.1905	.1781	.1619	.5335	.0648		
8	.1905	.1781	.1619	.1524	.0648		.0191
9	.5144	.4858	.1619	.1715	.0648		.0191
10		.4372	.1296	.1296	.0625		
11		.5668		.1134	.0648	.1905	
12	.2915	.5182		.0972	.0648	.1143	
13	.4534	.5182	.1143		.0648	.1143	.3887
14	.3887	.5344	.1905	.1134	.0648	.1143	.3725
15		.583	.1334	.081	.0625	.1143	.3563
16	.4696	.583		.0972	.0648	.0953	
17	.1134	.0972	.1524		.0648	.1143	.0972
18	.1134	.1619	.2286	.1134	.0648	.1143	.1296
19	.1943	.1781	.2477	.1619	.0648		.1781
20	.1943	.2105	.2667	.1943		.2096	.1943
21	.1943	.1943	.2477			.2286	.1781
22	.1619	.1943	.4763		.3887	.4763	.1619
23	.1457	.1619	.4382			.4572	.0972
24	.1334	.1457	.1296	.0156	.3563		.4382
Max	.5144	.583	.4763	.5335	.3887	.4763	.4382
Min	.1134	.0972	.1134	.0156	.0625	.0953	.0191
Avg	.2185	.2793	.1883	.2383	.1417	.1953	.2106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 202 / 11 KV Kaulage Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0156	.0171		.0156
2				.0156	.0171		.0156
3				.0156	.0171		.0156
4				.0156	.0171		.0156
5				.0156	.0171		.0156
6				.0156	.0171		.0156
7				.0156	.0171		.0156
8					.0171		
9	.0781	.0914			.0171		.0156
10		.0633			.0171		
11		.0949			.0171		
12	.0762	.0949		.0316	.0171		
13	.081	.1107			.0171		.0158
14	.0914	.1107			.0171		.0147
15		.0949			.0171		.0149
16	.061	.0949			.0171		
17					.0171		
18					.0171		
19					.0171		
20					.0171		
21					.0171		
22			.0191		.0171		
23			.0156			.0156	
24					.0171		.0158
Max	.0914	.1107	.0191	.0316	.0171	.0156	.0158
Min	.061	.0633	.0156	.0156	.0171	.0156	.0147
Avg	.0775	.0945	.0174	.0176	.0171	.0156	.0155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 203 / 11 KV Ainapur Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2031	.1781	.1715				
2	.2031	.1781	.1715				
3	.1875	.1781	.1715				
4	.1875	.1781	.1715				
5	.2031	.1781	.1715				
6	.2031	.1943	.1715				
7	.3281	.3725	.2429				
9			.3286	.2812			
10			.3572	.2675		.1562	
11				.2858		.1718	
12				.2641		.1718	
13			.3593		.0152	.1718	
14			.3906	.2641	.1372	.1406	
15			.3749	.2494	.1543	.1406	
16				.2787	.1372	.1718	
17					.0171		
18					.0171		
19					.0171		
20					.0171		
21					.0171		
22	.1943	.1858			.0171		
23	.1943	.1715					.1014
24	.2031	.1781	.1715				
Max	.3281	.3725	.3906	.2858	.1543	.1718	.1014
Min	.1875	.1715	.1715	.2494	.0152	.1406	.1014
Avg	.2107	.1993	.2503	.2701	.0547	.1607	.1014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 204 / 11 KV Hiralge(karmbali) Vg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.1781	.1781	.2286	.2058		.2096
2	.2286	.1781	.1781	.1905	.2058		.1905
3	.2286	.1781	.1781	.1905	.2058		.1905
4	.2286	.1943	.1943	.2096	.2058		.1905
5	.3048	.2267	.2915	.3429	.2229		.2286
6	.4191	.2915	.3239	.4001	.3429		.3239
7	.4763	.421	.3725	.4763	.3944		.4001
8	.4954	.4049	.421	.4954	.4287		.4954
9	.4954	.3887	.3563	.4763	.4287		.4954
10		.3725	.3887	.3887	.4287	.4001	
11		.2915		.3563	.4287	.4001	
12	.2915	.2753		.3401	.4287	.3429	.3401
13	.1943	.2915	.2667		.2743	.362	.2753
14	.2105		.2667	.3077	.2743	.3048	.2591
15		.3239	.2858	.3239	.2743	.2858	.2675
16	.3401	.3077		.3725	.2743	.3048	.2753
17	.2915	.3239	.3429		.3429	.4001	.3725
18	.3401	.3887	.3429	.4534	.3772	.4763	.4049
19	.502	.5344	.5335	.5182	.4973		.4534
20	.6154	.664	.5906	.5182	.5487	.6859	.5668
21	.4858	.4858	.5335		.5144	.5716	.4858
22	.3239	.4372	.4763		.3429	.4382	.4049
23	.2267	.2591	.2858			.2858	.2429
24	.2667	.1943	.2105	.2477	.2058		.2477
Max	.6154	.664	.5906	.5182	.5487	.6859	.5668
Min	.1943	.1781	.1781	.1905	.2058	.2858	.1905
Avg	.3435	.3309	.3342	.3598	.3414	.4045	.3328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 205 / KCL

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0189	.0191	.0187		.0191
2	.0191	.0191	.0189	.0191	.0181		.0191
3	.0191	.0191	.0189	.0191	.0187		.0191
4	.0191	.0191	.0189	.0191	.0187		.0191
5	.0191	.0191	.0189	.0191	.0187		.0191
6	.0191	.0191	.0189	.0191	.0181		.0191
7	.0191	.0191	.0189	.0191	.0181		.0191
8	.0191	.0191	.0189	.0191	.0187		.0191
9	.0191	.0191	.0189	.0191	.0187		.0191
10		.0189	.0189	.0189	.0187	.0191	
11		.0189		.0189	.0181	.0191	.0191
12	.0191	.0189		.0189	.0187	.0191	.0189
13	.0191	.0189	.0191		.0187	.0191	.0189
14	.0191	.0189	.0191	.0189	.0187	.0191	.0189
15		.0189	.0191	.0189	.0187	.0191	.0189
16	.0191	.0189		.0189	.0187	.0191	.0189
17	.0191	.0189	.0191		.0187	.0191	.0189
18	.0191	.0189	.0191	.0189	.0187	.0191	.0189
19	.0191	.0189	.0191	.0189	.0187		.0189
20	.0191	.0189	.0191	.0189	.0187	.0191	.0189
21	.0191	.0189	.0191		.0187	.0191	.0189
22	.0191	.0189	.0191		.0171	.0191	.0189
23	.0191	.0189	.0191			.0191	.0189
24	.0191	.0191	.0189	.0191	.0187		.0191
Max	.0191	.0191	.0191	.0191	.0187	.0191	.0191
Min	.0191	.0189	.0189	.0189	.0171	.0191	.0189
Avg	.0191	.0190	.0190	.0190	.0185	.0191	.0190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station

Feeder No / Name : 201 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.056	.0343	.0934	.0514	.0343	.056
2	.0554	.056	.0343	.0747	.0343	.0343	.0373
3	.0554	.056	.0343	.056	.0343	.0343	.0373
4	.0554	.0362	.0343	.056	.0343	.0343	.0373
5	.0554	.0373	.0343	.056	.0343	.0343	.0373
6	.0554	.0373	.0343	.056	.0514	.0343	.0373
7	.0739	.056	.0343	.0373	.0514	.0343	.056
8	.0739	.056	.0343	.0373	.0514	.0343	.056
9	.1109	.112	.0343	.0747	.0857		.112
10		.1307	.12	.1307	.0857	.112	.1494
11	.3734	.1029			.1372	.1494	.1867
12	.4294	.1029			.1715	.168	.1494
13	.3921	.1029			.1543	.168	.0934
14	.4163	.0686		.1294	.1372	.1494	.056
15	.3982	.0686		.1663	.0514		.0739
16	.2614	.0686		.1478	.0514	.056	
17	.1267	.0686		.1294	.0343	.056	.0934
18	.0747	.0171		.1109	.0343		.0554
19	.0747	.0171		.0554	.0343		.0554
20	.0373	.0343		.0554	.0343		.0554
21	.0373	.0343		.037	.0514		.0739
22	.056	.0686		.0739	.0514		.0739
23	.056		.0934	.0739	.0514		.0739
24	.0924	.056	.0343	.0934	.0924		.056
Max	.4294	.1307	.12	.1663	.1715	.168	.1867
Min	.0373	.0171	.0343	.037	.0343	.0343	.0373
Avg	.1494	.0628	.0464	.0831	.0667	.0755	.0745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station

Feeder No / Name : 202 / Shendri AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.1187	.2058	.0328	.0343	.0343	.0328
2	.1629	.12	.2058	.0328	.0343	.0343	.0328
3	.1629	.1029	.2229	.0328	.0343	.0343	.0328
4	.1629	.1029	.2229	.0328	.0343	.0514	.0328
5	.181	.1372	.2229	.0328	.0343	.0686	.0328
6	.1991	.2058	.2401	.0328	.0686	.0686	.0492
7	.362	.3086	.2743	.0819	.0514	.0857	.0655
8	.0686	.0509	.0686	.0819	.0686	.0857	.0819
9	.0686	.0339	.5316	.4588			.0492
10		.0339	.4973	.4424			.0655
11	.0339	.0514			.12		.0339
12	.034	.0686			.1715	.1638	.0339
13	.1696	.0686			.2058	.2035	.0339
14	.0339	.0686		.4525	.1715	.2622	.0343
15	.1017	.0514		.4163	.9259		.0343
16	.0509	.0514		.3801	.1715	.1865	
17	.0328	.0514		.0514	.0514	.0509	.0335
18	.0373	.0514		.0686	.0343		.0514
19	.0373	.0514		.0686	.0343		.0514
20		.0514		.0857	.0343		.0514
21		.0686		.0857	.0686		.0514
22	.181	.2229		.0686	.0686		.1029
23	.1475		.0328	.0514	.0686		.0857
24	.2353	.1543	.2229	.0328	.0514		.0328
Max	.362	.3086	.5316	.4588	.9259	.2622	.1029
Min	.0328	.0339	.0328	.0328	.0343	.0343	.0328
Avg	.1276	.0968	.2457	.1440	.1154	.1023	.0481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 201 / Nool Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1829	.181	.1612		.1646	.1629
2		.1646	.1646	.1629		.1646	.1612
3		.1829	.1646	.181		.1646	.1417
4		.1829	.1829	.2149		.2012	.1448
5		.2012	.2172	.2481		.2195	.1417
6		.2743	.2865	.3155		.2743	
7		.3292	.3544	.3429		.3475	
8		.4572	.3681	.3944		.3292	.1097
9		.5121	.3841	.4024		.3658	.2614
10		.3475	.3475	.4024		.3109	
11		.3292		.3109			.2402
12	.4572	.3292				.2926	
13	.439	.3475	.2427			.3292	
14	.4207	.2926	.2353			.3292	7.9157
15		.2561	.1848	.1646		.2561	.298
16	.3658	.2658		.2743		.2926	
17	.3467	.3086	.2378	.4024		.2926	.4024
18		.3258	.3292	.4681			.4607
19	.6089	.3982	.4938	.567		.1463	.5144
20	.6401	.5609	.567	.6154		.5487	.4961
21	.5068	.5258	.4835			.463	.4119
22	.3658	.4144	.3258		.3475	.2561	.2241
23	.2561	.2715	.3258			.2534	.1629
24		.1829	.181	.181			
Max	.6401	.5609	.567	.6154	.3475	.5487	7.9157
Min	.2561	.1646	.1646	.1612	.3475	.1463	.1097
Avg	.4407	.3185	.2980	.3227	.3475	.2858	.7206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 202 / Bhadgaon Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.1772	.2328	.0716		.0343	.0543
2	.2056	.1595	.2126	.0526		.0343	.0362
3	.2056	.1772	.2149	.0537		.0343	.0358
4		.1772	.2172	.0537		.0514	.0362
5		.1949	.2172	.0709		.0514	.0362
6		.3189	.2507	.0716		.0514	
7		.6024	.3856	.0686		.0514	
8		.0709	.0354	.0857		.0514	
9		.0532	.567	.3366			.0358
10		.0732	.583	.3601		.1715	
11		.0532					.0328
12		.0532				.12	.0335
13		.0532	.5117			.1029	.037
14		.0532		.2658		.1063	.0332
15		.0532	.4167	.2572		.1063	.0347
16	.3012	.0351		.1886		.1029	
17	.0566	.0343	.0532	.056		.0354	.0354
18		.0532	.0709	.0762		.0532	.0532
19	.0943	.0537	.0886	.0739		.0709	.0709
20	.0943	.104	.0886	.0943		.0709	.0709
21	.0724	.0857	.1063			.0686	.0716
22	.2481	.2486	.0724		.0532	.0543	.1219
23	.2126	.2454	.0724			.0549	.0772
24	.2429	.1949	.2353	.0716			.032
Max	.3012	.6024	.583	.3601	.0532	.1715	.1219
Min	.0566	.0343	.0354	.0526	.0532	.0343	.032
Avg	.1797	.1386	.2316	.1283	.0532	.0704	.0494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 203 / Chennikuppi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0709	.0724	.3898		.1715	.1063
2	.0747	.0709	.0724	.3898		.1715	.0716
3	.0747	.0709	.0716	.4252		.2058	.0739
4	.0686	.0886	.0716	.4607		.2058	.0724
5	.0762	.0886	.0905	.5014		.2915	.0732
6	.1227	.1063	.0895	.5316		.3429	
7	.1463	.1063	.1063	.6516		.3258	
8	.1463	.1063	.1075	.1372		.1063	.0754
9	.5138	.6556	.1063	.0886		.1063	.2408
10		.7087	.0886	.0886			
11		.7973		.0886			.208
12	.6733	.8505					.2675
13	.6733	.815	.0754				.2526
14	.6733	.703	.0943	.0514		.0886	.2378
15		.7545	.0953	.0686		.1417	.2408
16	.5493	.4031		.0709		.0709	.1783
17	.1143	.0686	.0886	.0924		.0354	.0709
18		.1063	.124	.0895		.0354	.0914
19	.132	.1448	.1417	.1417		.0354	.1063
20	.1886	.1715	.1772	.1509		.0532	.124
21	.1629	.1715	.1612			.12	.1075
22	.1063	.1357	.4458		.2481	.1629	.112
23	.0886	.1052	.4656			.1086	.0747
24	.0747	.0709	.0724	.4344			.056
Max	.6733	.8505	.4656	.6516	.2481	.3429	.2675
Min	.0686	.0686	.0716	.0514	.2481	.0354	.056
Avg	.2367	.3071	.1342	.2554	.2481	.1463	.1353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 204 / Guddai AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.125	.0983	.1075			
2	.1094	.0983	.1063			
3	.1094	.0983	.0905			
4	.1067	.1147	.0905			
5	.1067	.1147	.0895			
6	.1067	.1147	.0895			
7	.1698	.213	.124			
9			.2294	.2294		
10			.2294	.2294		
11				.213		
12					.1311	
13			.2172		.0492	
14			.2462	.1966	.0655	
15			.2054	.1802		
16				.1638	.0492	
22	.1147	.116				.048
23	.1147	.1267				
24	.128	.1147	.1086			
Max	.1698	.213	.2462	.2294	.1311	.048
Min	.1067	.0983	.0895	.1638	.0492	.048
Avg	.1191	.1209	.1488	.2021	.0738	.048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 205 / 11 KV JARALI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2896		.0716
2				.2865		.0724
3				.2715		.0543
4				.2715		.0537
5				.2865		.0724
6				.3189		
7				.5068		
9	.6718	.7373				.2107
10		.7865				
11		.7865				.2378
12	.6718	.6554				.2675
13	.6554	.7537				.1486
14	.639	.8029				.1204
15		.8029				
16	.6718	.78				.1189
22			.3086		.0747	
23			.3258		.0724	
24				.3258		
Max	.6718	.8029	.3258	.5068	.0747	.2675
Min	.639	.6554	.3086	.2715	.0724	.0537
Avg	.6620	.7632	.3172	.3196	.0736	.1298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 206 / 11 KV SAMARTHANAGAR VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1494	.2328	.1463		.128
2	.2075	.1494	.2149	.128		.128
3	.1991	.168	.1267	.128		.1097
4	.2149	.168	.1448	.1463		.1086
5	.2279	.1867	.1417	.1629		.1097
6	.2896	.2241	.1595	.181		
7	.3292	.2241	.197			
8	.3109	.2054	.2012	.2103		.2378
9	.3109	.2012	.2195	.2378		.2353
10		.2012	.1595	.2378		.2058
11		.1829		.2012		.208
12	.3475	.1829			.2195	.2126
13	.2378	.1829	.1629		.2378	.2195
14		.2195		.1829	.2195	.1991
15		.2378	.197	.1829	.2743	.2353
16	.1463	.2103		.1646	.2561	
17	.1387	.2172	.2012		.2195	.2378
18		.2103	.2378	.2075	.2378	.1829
19	.2829	.2303	.2743	.2452	.2926	.2743
20	.3429	.2743	.3292	.3018	.3292	.2743
21	.2896	.2743	.2947		.2629	.2328
22	.2427	.2321	.2229		.2195	.1698
23	.1867	.1612	.181		.1448	
24	.2096	.1646	.1448	.1448		.132
Max	.3475	.2743	.3292	.3018	.3292	.2743
Min	.1387	.1494	.1267	.128	.1448	.1086
Avg	.2495	.2024	.2022	.1888	.2428	.1921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 201 / 11 KV Nilaji Gaothan

Gaothan Feeder

Feeder Feeder KV- 11 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048	.3429			.4755	.3292
2	.3429	.3048	.3048			.4755	.3292
3	.3429	.3048	.3048			.4755	.3292
4	.4191	.3429	.3048			.439	.3292
5	.4954	.381	.3395			.4024	.3658
6	.6859	.5716	.4954				.4938
7	.7468	.7167	.724				.6584
8	.6653	.679	.679				
9		.5487	.6283	.6348			
10	.6584	.5121		.6283			
11	.6584	.5121		.5487			.5601
12	.5487	.5121		.5601			.4854
13	.5487	.439		.4435			.4854
14	.4805	.3658		.4435	.4435		.4854
15	.4755	.4108		.4108	.4435		.4481
16	.4755	.4435		.4108	.4481		.4481
17	.4805	.439		.4481	.4755	.4481	.4854
18	.5914	.4066		.5975	.6219	.6283	.7095
19	.7468	.5544		.7922	.7682	.8048	.7922
20	.9709	1.0082			.7682	.8779	.8779
21	.8676	.9709			.7682	.7682	.9145
22	.6859	.8002			.6219	.6401	.695
23	.4572	.5335			.5487	.5121	.5853
24	.381	.3429	.4191				.3292
Max	.9709	1.0082	.724	.7922	.7682	.8779	.9145
Min	.3429	.3048	.3048	.4108	.4435	.4024	.3292
Avg	.5682	.5169	.4543	.5380	.5908	.5790	.5303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 202 / HITANI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0732	.112				.2195
2	.0895	.0739	.112				.2012
3	.0934	.0739	.112				.2012
4	.112	.0739	.1307				.2012
5	.1478	.0876	.1433				.2195
6	.1848	.1294	.2033				.2012
7	.2715	.1867	.2987				.2012
8	.2454	.2054	.2743				
9		1.0059	.3077	.2481			
10	1.1888	1.0059		.2534			
11	1.262	1.0059		.2195			.3201
12	1.2254	1.0242		.181			.3077
13	1.0437	.8413		.1772			.2561
14	1.0311	1.0974		.1612	.128		.2241
15	1.1069	.2229		.1417	.1109		.2056
16	.7186	.2846		.156	.124		.2134
17	.1267	.0354		.1595	.128	.1478	.1294
18	.1646	.1949		.1402	.1463	.1829	.1867
19	.1663	.2328		.1848	.1463	.2012	.2075
20	.1494	.2195			.1463	.1829	.1829
21	.1294	.2033			.128	.1646	.1829
22	.1086	.1646			.2195	.2012	.1829
23	.0693	.1267			.2195	.2012	.1829
24	.0924	.0701	.1307				.2012
Max	1.262	1.0974	.3077	.2534	.2195	.2012	.3201
Min	.0693	.0354	.112	.1402	.1109	.1478	.1294
Avg	.4270	.3600	.1825	.1839	.1497	.1831	.2109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 203 / HASURCHAMPU AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1829	.192			.1132	.0914
2		.1829	.192			.1097	.0914
3		.1829	.192			.1097	.0914
4		.1829	.192			.1097	.0914
5		.2134	.1981			.1097	.1097
6		.2968	.2656			.1097	.128
7		.4268	.3521			.1646	.1646
8		.1334	.1905			.1463	
9		.1097	.5312	.5864		.2378	
10	.3658	.1097		.5864		.2378	
11	.3658	.1097		.4999		.2378	.1307
12	.0914	.1097	.6335	.463		.2195	.1109
13	.0934	.0732		.4843		.2195	.0924
14	.0934	.0732	.6268	.463	.1204	.2378	.0934
15	.0924	.056	.6335	.4115	.1054		.0943
16	.0732	.0762	.6089	.3864	.0892	.1635	.0924
17	.0934	.0953	.1294	.112	.0914		.0943
18	.1132	.0953	.1254	.132	.1097	.1886	.1524
19	.132	.1334	.1417	.1509	.128	.1829	.1905
20	.1509	.1524	.1772		.128	.1463	.1463
21	.1509	.1524	.1267		.128	.1463	.128
22	.1829	.2372	.1254		.1097	.1097	.2195
23	.1429	.1981	.0886		.1097	.1097	.2378
24		.208	.2214				.0914
Max	.3658	.4268	.6335	.5864	.128	.2378	.2378
Min	.0732	.056	.0886	.112	.0892	.1097	.0914
Avg	.1530	.1580	.2830	.3887	.1120	.1624	.1258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025] BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 204 / 11KV Hirnyakeshi SHEDDABLE FEEDER MIDC EQUIVALENT
Industrial Ex Feeder KV- 11 / HAVING WEEKLY STAGGERING
OUTGOING

DATE	18-JUL-17
HR	Load (MW)
12	.0747
13	.0914
14	.0739
Max	.0914
Min	.0739
Avg	.08

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 201 / 11 KV Halkarni Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1328	.1143	.4348	.2896		.284	.0949
2	.1331	.114	.3915	.2754		.2853	.1141
3	.1142	.094	.4077	.2714		.2623	.1141
4	.1143	.1143	.4614	.2515		.2737	
5	.1524	.132	.4597	.2726		.3006	
6	.1517	.1521	.4725	.3475		.3763	.1327
7	.1701	.1704	.4115	.3677		.4454	.1282
8	.15	.1326	.1515	.0939		.0944	.1331
9	.5421	.6351	.1704	.1133		.0748	.3144
10		.5381	.1513	.1503		.0756	.3493
11		.5576		.1246		.1328	.3177
12	.2715	.6104				.0758	.3025
13	.5185	.5494				.0762	.3412
14	.599	.4567	.1136	.1123		.0761	.3042
15		.5348	.1139	.1296		.0762	.3223
16	.5414	.481	.1328	.1304		.0953	.2267
17	.1699	.1315	.1327		.0751	.0932	.0757
18	.1867	.1888	.2066	.1322		.1139	.0692
19	.2266	.1894	.2268	.132			.0762
20	.2275	.2092	.1905	.1503		.1143	.0953
21	.2089	.2092	.1901	.1506		.1141	.0953
22	.15	.3958		.2666		.0953	.0953
23	.1331	.4281	.2126	.2986		.0756	.0762
24	.1323	.1327	.4332	.3006		.3056	.0756
Max	.599	.6351	.4725	.3677	.0751	.4454	.3493
Min	.1142	.094	.1136	.0939	.0751	.0748	.0692
Avg	.2393	.3030	.2733	.2077	.0751	.1703	.1752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 202 / 11 KV Hiduggi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5937	.3735	.142	.1134		.4134
2	.5951	.353	.1305	.0944		.447
3	.5658	.3397	.1309	.0914		
4		.3978	.1159	.1117		
5		.422	.1159	.1322		
6		.5729	.1739	.1552		
7	.5582	.7401	.1922	.1658		
8	.0729	.165	.1863	.1722		
9	.0912	.1501	.9828	.6226		
10		.1308	1.0736	.8699		.0726
11		.1136		.8688		.0717
12		.1125				
13		.1061	1.3685			
14	.3824	.1127	1.0149	.8542	.0731	
15		.1315	.9989	.8619		
16	.1783	.1121	1.004	.5853		
17	.2241	.1193	.1245		.0167	.0553
18	.2259	.1796	.148	.1827		.1196
19		.2156	.184	.1449	.1457	.1831
20	.1741	.1991	.1823	.1793	.1651	.1667
21	.1694	.1951	.1928	.1694	.159	.1755
22	.5898	.1791	.1641	.1507		.4012
23	.3761	.1743	.1218	.1507	.3667	.3847
24	.6188	.3745	.1517	.0926		.3296
Max	.6188	.7401	1.3685	.8699	.3667	.447
Min	.0729	.1061	.1159	.0914	.0167	.0553
Avg	.3611	.2488	.4045	.3223	.1544	.2350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 203 / 11 KV nagnoor Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3458	.3182	.3669	.3353	
2			.3193	.2515		.3023	
3			.3155	.2737		.3041	
4			.3977	.2365		.2754	
5			.446	.3048		.2727	
6			.4932	.4437		.2932	
7			.5731	.5149		.3174	
9	.535	.5313					.2609
10		.5789					.3166
11		.4893					.3221
12	.6257	.681					.3161
13	.6335	.6108					.3493
14	.6048	.6204					.3033
15		.6182					.2574
16	.5466	.6016					
22		.3567	.4332	.2166			
23		.3658	.3815	.2171			
24			.3416	.3378	.3853	.3071	
Max	.6335	.681	.5731	.5149	.3853	.3353	.3493
Min	.535	.3567	.3155	.2166	.3669	.2727	.2574
Avg	.5891	.5454	.4047	.3115	.3761	.3009	.3037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 204 / 11 KV HALKARNI VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1331	.1684	.1706	.1123		.1296	.1518
2	.1331	.1477	.1711	.1143		.131	.1711
3	.1143	.1307	.1521	.0921		.143	.1518
4	.1524	.1239	.1521	.0953		.2804	
5	.1524	.1489	.1715	.1117		.2915	
6	.1905		.2085	.1143		.3038	.1839
7	.2452		.2447	.2435		.3181	.2442
8	.2606	.222	.2415	.2425		.2227	.3015
9	.2405	.2385	.2037	.2231		.2215	.3015
10		.2181	.1449	.2211		.1837	.1978
11		.2158		.2016		.2234	.2261
12	.1922	.1626				.1863	.1928
13	.1497	.2119	.1048				.1839
14	.1955	.1643	.1278	.1488			.1886
15		.1658	.1262	.1806		.2738	.1638
16	.216	.1629	.1349	.1766		.2321	
17	.2071	.2005	.1517		.1884	.2222	.2622
18	.285	.312	.2281	.2507		.282	.2918
19	.3366	.2652	.3067	.3122			.3278
20	.3544	.3881	.1865	.3054		.3337	.3681
21	.3562	.3704	.2442	.263		.2821	.3006
22	.2641	.2838	.1715	.2263			.2263
23	.1706	.1896	.1334	.189		.166	.1888
24	.1328	.1509	.1888	.1323		.1287	.1515
Max	.3562	.3881	.3067	.3122	.1884	.3337	.3681
Min	.1143	.1239	.1048	.0921	.1884	.1287	.1515
Avg	.2134	.211	.1802	.1884	.1884	.2278	.2274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 205 / 11 KV Hidduggi Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5313	.4116	.6256	.4904	.5067		.1706
2	.4744	.4066	.6237	.444	.4582		.2263
3	.4744	.3746	.5882	.3692	.4399		
4	.4744	.3692	.5894	.3024	.4796		
5	.5113	.4904	.5693	.2993	.4303		
6	.567	.6818	.5716	.321	.3302		.263
7	.8597	.5143	.7545	.8106	.5132		.5308
8	.8173	.7178	.771	.8224			.4522
9	.6735	.7059	.6481	.5944			.4504
10		.5431	.3453	.5281	.3275	.2323	.3936
11		.4536		.3344	.3677		.3439
12	.4175	.2227			.2631	.4426	.2966
13	.2089	.2236			.3742	.4513	
14	.2651	.2277	.2667	.3515		.3893	.308
15		.2277	.2477	.3361	.2218	.3877	
16	.2654	.2085		.2572	.2569	.362	
17	.225	.2365	.1521		.32	.335	
18		.2698	.334	.365	.4557		.2667
19		.7702	.9008	.444	.5258	.4864	.3738
20	.5812	.9214	.9026	.9749	.5865	.5975	.7363
21	.8048	.8999	.6458	.7537	.564	.5239	.6458
22	.4373	.7757	.449		.3254		.3953
23	.4954	.6818	.5882	.2268		.2266	.2096
24	.5687	.4531	.6615	.5239	.5415		.1896
Max	.8597	.9214	.9026	.9749	.5865	.5975	.7363
Min	.2089	.2085	.1521	.2268	.2218	.2266	.1706
Avg	.5080	.4911	.5618	.4775	.4144	.4031	.3678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 206 / 11 KV Nagnoor Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0761	.0732	.0949	.0715		.1133	.1518
2	.0761	.0739	.0758	.0918		.1468	.1331
3	.0762	.0893	.0761	.074		.1262	
4	.0953	.0706	.0761	.0751		.1825	
5	.1331	.1072	.1143	.1095		.2236	
6	.1888	.1509	.1701	.151		.1959	.1691
7	.2415	.2218	.2405	.1884	.1898	.2197	.1711
8	.201	.1827	.1856	.2043	.2079	.2284	.2261
9	.1658	.1797	.1684	.1687	.1884	.2151	
10		.1288	.167	.1674	.1694	.1793	.1863
11		.1116		.1387	.1879	.1372	.1306
12	.1109	.1095			.1457	.1643	.1443
13	.0912	.0741	.1283		.141	.1494	.1275
14	.074	.0757	.019	.1104	.1234	.1231	.1287
15		.0755	.1489	.1306	.1216	.1251	.1087
16		.1283	.1918	.1311		.1471	
17	.1543	.1266	.1949		.1216	.1471	.1405
18		.1772	.1802	.1463	.2318		.1797
19	.2951	.2197	.2929	.2619	.2672	.2963	.2957
20	.2865	.3479	.3161	.2625	.2853	.263	.3012
21	.225	.3522	.2769	.2263	.2318	.2452	.2277
22	.1703	.1796	.1507	.1512	.1457		.1521
23	.094	.1137	.0946	.0947	.1323	.1421	.114
24	.0947	.0935	.1137	.0927		.1127	.1521
Max	.2951	.3522	.3161	.2625	.2853	.2963	.3012
Min	.074	.0706	.019	.0715	.1216	.1127	.1087
Avg	.1500	.1443	.1580	.1451	.1807	.1765	.1705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 201 / 11 KV Kowad Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0686	.0381	.032	.0343		.0762
2	.0762	.0686	.0381	.032	.0343		.0762
3	.0762	.0686	.0381	.032	.0343		.0762
4	.0762	.0686	.0381	.0328	.0343		.0762
5	.0762	.0686	.0381	.0328	.0343		.0762
6	.0762	.0686	.0381	.032	.0343		.0762
7	.7621	.0686	.0381	.0332	.0343		.0762
8	.0381	.0343	.0381	.032	.0343		.0381
9	.0381	.0343	.1143	.0655	.0343		.0381
10			.1143		.0343		
11		.0343		.0655	.0343		.0381
12	.0381	.0343			.0343	.0655	.0381
13	.0381	.0343				.0328	.0381
14	.0381	.0343		.0655		.0328	.0381
15	.0381	.0343		.0655		.0328	.0381
16	.0381	.0343		.0655		.0328	.0381
17	.0381	.0343				.032	.0381
18	.0381	.0343		.0328	.0343	.032	.0381
19	.0381	.0343		.0343	.0343		.0381
20	.0381	.0343	.0381	.0343	.0381	.032	.0381
21	.0381	.0343	.0381	.0343	.0381	.0381	.0381
22	.0762	.0343		.0343	.0381	.0762	.0762
23	.0762	.0343	.0381	.0343	.0381		.0762
24	.0762	.0762	.0343	.032	.0343	.0328	.0762
Max	.7621	.0762	.1143	.0655	.0381	.0762	.0762
Min	.0381	.0343	.0343	.032	.0343	.032	.0381
Avg	.0866	.0466	.0487	.0411	.0351	.0400	.0547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 202 / 11 KV Talewadi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.2401	.0381	.032	.0343	.032	.0381
2	.381	.2401	.0381	.032	.0343	.032	.0381
3	.381	.2401	.0381	.032	.0343	.0328	.0381
4	.381	.2401	.0381	.032	.0343	.032	.0381
5	.381	.2401	.0381	.032	.0343	.032	.0381
6	.381	.2401	.0381	.032	.0343		.0381
7	.381	.2401	.0381	.032	.0343	.032	.0381
8	.0381		.0381	.032	.0343	.032	.0381
9	.0381		.381	.3277	.1715	.1966	.0381
10			.4572	.3277	.0343		
11		.0343		.3277	.1715		.0381
12	.0381	.0343			.1372	.1966	.0381
13	.0381	.0343				.0655	.0381
14	.0381	.0343		.2622		.0655	
15	.0381	.0343		.2622		.1311	
16	.0381	.0343		.2622		.1311	.0381
17	.0381	.0343				.0316	.0381
18	.0381	.0343		.0328	.0343	.0328	.0381
19	.0381	.0343		.0343	.0343		.0381
20	.0381	.0343	.0381	.0343	.0381	.032	.0381
21	.0381	.0343	.0381	.0343	.0381	.0381	.0381
22	.3048	.0343		.0343	.0381	.0381	.381
23	.2667	.0343	.0381	.0343	.0381		.2286
24	.381	.2667	.0343	.032	.0343	.032	.0381
Max	.381	.2667	.4572	.3277	.1715	.1966	.381
Min	.0381	.0343	.0343	.032	.0343	.0316	.0381
Avg	.1853	.1140	.0923	.1077	.0550	.0640	.0635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 203 / 11 KV Batakanangle Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1372	.724	.4915	.5144	.3277	.0381
2	.1524	.1372	.6859	.4915	.5144	.3277	.0381
3	.1524	.1372	.6859	.4915	.5144	.3277	.0381
4	.1524	.1372		.4915	.5144	.3391	.0381
5	.1524	.1372		.4915	.5144	.3277	.0381
6	.1524	.1372		.4915	.5144	.3277	.0381
7	.2286	.1372		.4915	.5144	.3277	.0381
8	.2286	.2058		.16	.2058		.0381
9	.8383	.7202		.1638	.1029		.6097
10				.1638	.1029		
11		.7545		.1638	.1029		.4572
12	.5335	.9602			.1029	.064	.2286
13	.6478	1.0288				.096	.6097
14	.8002	.9602		.1311		.064	.4572
15	.8764	.9602		.1311		.032	.4572
16	.8764	.9602		.1311		.032	.4572
17	.1524	.1372				.032	.1524
18	.1524	.1372		.1311	.0343	.0332	.0762
19	.1524	.1372		.1715	.0343		.0762
20	.1524	.1372	.1524	.2058	.0381	.0328	.0381
21	.1524	.1372	.1524	.2058	.0381	.0381	.0381
22	.1524	.7202		.5487	.4572	.0381	.0381
23	.1524	.7202	.5716	.5487	.4572		.0381
24	.1524	.1524	.6859	.4915	.5144	.3277	.0381
Max	.8764	1.0288	.724	.5487	.5144	.3391	.6097
Min	.1524	.1372	.1524	.1311	.0343	.032	.0381
Avg	.3256	.4256	.5226	.3233	.3048	.1720	.1773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 204 / 11 KV Talewadi Vg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1372	.1524	.1696	.1372		.1524
2	.1524	.1372	.1524	.1696	.1372		.1524
3	.1524	.1372	.1524	.1696	.1372		.1524
4	.1524	.1372	.1524	.1696	.1372		.1524
5	.1524	.1372	.1524	.1638	.1372		.1524
6	.1524	.1372	.1905	.1638	.1372		.1524
7	.2286	.1372	.2667	.1638	.1372		.1524
8	.2667		.2667	.2374	.2058		.2667
9	.2286		.2667	.2713	.2058	.1966	.3048
10			.2286	.2713	.2058		
11		.2401		.2374	.2058		.2286
12	.2286	.2401			.1715	.2035	.0381
13	.2286	.2058				.1638	.1905
14	.2286	.2058		.1638			.1905
15	.2286	.2058		.1638		.1311	
16	.2286	.1372		.1966		.1638	.2286
17	.1905	.2743				.1658	.2286
18	.2667	.3086		.2294	.3086	.2294	.3048
19	.3429	.3429		.3086	.3429		.3429
20	.3048	.4115	.4954	.4115	.4572	.373	.4572
21	.2667	.4115	.4572	.3086		.3429	.381
22	.2286	.2743		.2058		.2667	.2667
23	.1524	.1715	.1905	.1715	.1905		.1905
24	.1524	.1524	.1372	.1696	.1372	.1311	.1524
Max	.3429	.4115	.4954	.4115	.4572	.373	.4572
Min	.1524	.1372	.1372	.1638	.1372	.1311	.0381
Avg	.2130	.2163	.2330	.2151	.1995	.2152	.2199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 205 / 11 KV Kowad Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3772	.381	.426	.4458	.3605	.4954
2	.4191	.3772	.381	.426	.4458	.3605	.4954
3	.4191	.3772	.381	.426	.4458	.3605	.4954
4	.4191	.3772	.381	.426	.4458	.3605	.4954
5	.4191	.3772	.4191	.426	.4458	.3605	.4954
6	.4191	.3772	.4954	.426	.4458	.3605	.4954
7	.6478	.3772	.6478	.426	.4458	.3605	.6478
8	.6859	.6173	.724	.3277	.583	.5243	.724
9	.6859	.6516	.6859	.3605	.6173	.6882	.8002
10			.5716	.426	.6173		
11		.583		.3932	.5487		.6097
12	.4954	.583			.5144	.5243	.5335
13	.4954	.5144				.4915	.4954
14	.4191	.5144		.4915		.426	.4954
15	.4572	.5144		.5243		.426	.3429
16	.4572	.4458		.5243		.426	.4954
17	.5716	.4801				.5243	.6478
18	.6478	.583		.6554	.7545	.5898	.7621
19	.8383	.823		.8573	.8916		.9145
20	.9907	.9602	1.0669	.8916	.9907	.8192	1.0669
21	.8002	.8573	.9526	.6859		.8383	.9145
22	.6478	.6516		.583		.724	.7621
23	.4572	.4115	.4954	.4801	.4191		.4954
24	.4191	.4191	.3429	.426	.4458	.3605	.4954
Max	.9907	.9602	1.0669	.8916	.9907	.8383	1.0669
Min	.4191	.3772	.3429	.3277	.4191	.3605	.3429
Avg	.5560	.5326	.5661	.5052	.559	.4943	.6163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 201 / 11 KV MAHAGAON VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.439	.3361	.3361	.2987	.4024	.3696
2	.4887	.4251	.2987	.2987	.2987	.3841	.3475
3	.4887	.4024	.3174	.3174	.2987	.3696	.3292
4	.4887	.3841	.3547	.3547	.2987	.3658	.3292
5	.5068	.3841	.4108	.4108	.2987	.4251	.3658
6	.5281	.4024	.4854	.4854	.4481	.4572	.4024
7	.6036	.4572	.6161	.5975	.5788	.5853	.567
8	.6036	.4755	.5601	.6348	.5975	.695	.567
9	.6224	.4755	.5228	.5068	.5788		.6219
10			.5041	.4706	.5975		.5487
11		.4207		.4344	.5975		.4435
12	.4904	.3982			.5601	.4668	.4854
13	.4854	.4207	.4668		.4854	.415	.4481
14	.4481	.4163	.4294	.4481	.4668	.415	
15	.4108	.4344	.4294	.4854	.4481	.3772	
16	.4294	.4344	.4108	.4481	.4854	.4572	
17	.3921	.4572	.4481		.5041	.5093	.4481
18	.4755	.5068	.5228	.5415	.5788	.6036	.5788
19	.6283	.5792	.6348	.7095	.6908		.7282
20	.7421	.7602	.7468	.8215	.8413	.7545	.8029
21	.6878	.6722	.7095	.6722	.6468	.6219	.7059
22	.6335	.5788	.5415	.5601	.439	.5544	.5853
23	.5121	.4108	.4108	.5041	.4251	.4024	.5249
24	.5249	.4755	.3734	.3734	.3174		.3841
Max	.7421	.7602	.7468	.8215	.8413	.7545	.8029
Min	.3921	.3841	.2987	.2987	.2987	.3658	.3292
Avg	.5317	.4700	.4787	.4958	.4909	.4875	.5040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 203 / 11 KV Mahagaon Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3439	.3544	.3658	.4024	.3658	.3366	.0354
2	.3439	.3506	.3475	.4024	.3292	.3189	.3681
3	.3439	.3366	.3658	.3841	.3292	.3189	.3544
4	.362	.3544	.3841	.4024	.3292	.3366	.3544
5	.3801	.4252	.3841	.4024	.3292	.3544	.3721
6	.4163	.4252	.4207	.4024	.3292	.3721	.3898
7	.4115	.4075	.5487	.4755	.5121	.4252	.3898
8	.3944	.4075	.4024	.3841	.4024	.3898	
9	.4287	.4784	.4024	.3982	.4207		.4075
10			.4024	.3801	.4207		.3898
11		.5316		.362	.3841		.3898
12	.426	.5792			.4024	.3772	.3658
13	.4755	.567	.3841		.3841	.373	.3658
14	.4572	.5853	.3841	.3841	.4024	.373	
15	.5487	.5611	.4024	.4024	.4024	.373	
16	.5487	.5792	.4024	.4024		.373	
17	.4024	.4344	.4024		.4024	.373	.4024
18	.3898	.4344	.4024	.4024	.4207	.373	.4024
19	.4031	.4163	.4207	.4207			.4024
20	.4344	.4344	.4024	.4024	.4075	.373	.4024
21	.4163	.4207	.3841	.4108	.3898	.3898	.3982
22	.3982	.3841	.4024	.3658	.3544	.3856	.3801
23	.3544	.4207	.4024	.3841	.3544	.3681	.362
24	.3658	.3544	.3658	.4024	.3841		.3721
Max	.5487	.5853	.5487	.4755	.5121	.4252	.4075
Min	.3439	.3366	.3475	.362	.3292	.3189	.0354
Avg	.4111	.4453	.3991	.3987	.3844	.3676	.3652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 205 / 11 KV Nadighat Ag Feeder

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0339	.032	.032	.032	.0335	.0335
2	.0343	.0335	.032	.032	.032	.0335	.0328
3	.0343	.0335	.032	.032	.032	.0328	.0328
4	.0343	.0335	.032	.032	.032	.0335	.0328
5	.0339	.0335	.032	.032	.032	.0328	.0328
6	.0343	.0335	.032	.032	.032	.0328	.0335
7	.0328	.0335	.032	.032	.032	.0328	.0328
8	.0328	.0335	.032	.032	.032	.0328	.0328
9	.0655	.0503	.032	.0339	.032		.0328
10			.032	.0339	.032		.0305
11		.0503		.0343	.032		.0335
12	.0492	.0343			.032	.0328	.032
13	.048	.0543	.032		.032	.0377	.032
14	.048	.0543	.032	.032	.032	.0328	
15	.048	.0526	.032	.032	.032	.0328	
16	.048	.0543	.032	.032		.0328	
17	.032	.0339	.032		.032	.0328	.032
18	.0335	.0343	.032	.032	.032	.0328	.032
19	.0335	.0343	.032	.032	.032		.032
20	.0362	.0339	.032	.032	.0335	.0328	.032
21	.0362	.032	.032	.032	.0335	.0335	.0343
22	.0339	.048	.032	.032	.0335	.0335	.0343
23	.0335	.032	.032	.032	.0335	.0335	.0343
24	.0339	.0335	.032	.032	.032		.0328
Max	.0655	.0543	.032	.0343	.0335	.0377	.0343
Min	.032	.032	.032	.032	.032	.0328	.0305
Avg	.0387	.0392	.032	.0323	.0323	.0333	.0328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144112 / 33/11 Kv Nangnur

Feeder No / Name : 201 / 11 KV Aralgundi AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0469	.061	1.0526	.8802	.427	.1781	.0274
2	.0474	.0625	1.0526	.8802	.4111	.176	.0267
3	.0469	.0474	1.0688	.8907			.0267
4	.0469	.0486	1.1012	.8907			.0267
5	.0457	.0648	1.1336	.9012			.0255
6	.0474	.0655	1.1822	.9717			.0248
7	.0648	.0663	1.247	1.085			.0248
8	.0655	.0791	.0648	.0686		.0671	.0232
9	1.6409	1.5402	.0724	.0509			.0503
10		1.5746	.0526	.0503			
11		1.7101		.0543			.0987
12	1.6876	1.6385	.048				.2709
13	1.7736	1.6409	.048	.0503	.3048	.0429	.3201
14	1.6907	1.6766	.0452	.0497	.2824		.3086
15	1.6741	1.668	.0469	.0514	.2896	.0335	.3353
16	1.6078	1.4563		.0492	.2591	.1932	.3201
17	.0633	.0594	.0474		.0514	.0486	.0156
18		.061	.0671	.0716	.0716		.0335
19	.0886	.1097	.0724	.0924	.0709		.0678
20	.0905	.0914	.112	.0914	.0732		.0754
21	.0886	.0914	.0914	.0724	.0724		.0747
22	.0686	1.1336		.4961	.176		.0724
23	.064	1.0562	.9069	.4744	.1783		.0497
24	.0463	.0602	1.0526	.9069	.4428		.029
Max	1.7736	1.7101	1.247	1.085	.4428	.1932	.3353
Min	.0457	.0474	.0452	.0492	.0514	.0335	.0156
Avg	.5236	.6693	.5031	.4150	.2222	.1056	.1012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144112 / 33/11 Kv Nangnur

Feeder No / Name : 203 / Khandal Ag.

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0145	.2172	.1269	.0303	.0326	.0286
2	.0301	.0143	.2317	.1286	.0309	.0332	.029
3	.0305	.0145	.2317	.1286	.0314	.0354	.029
4	.0297	.0147	.2675	.1269	.032	.0309	.0301
5	.0297	.0149	.2972	.1429	.0332	.0303	.029
6	.0305	.0149	.3269	.2606	.0337	.032	.029
7	.0297	.0156	.3715	.333	.1932	.0389	.029
8	.029	.0328	.029	.032	.0152	.0309	.0305
9	.5639	.5312	.0152	.016	.0158	.0297	.0648
10		.5937	.0156	.016	.0152	.0301	
11		.7116		.0168	.0152		.0812
12	.7011	.703	.0145	.016	.0156		.0812
13	.6687	.6718	.024	.0145	.0286	.0278	.0511
14	.6249	.571	.0236	.0145	.0297	.0282	.0657
15	.5792	.5335	.0236	.0164	.0297	.0305	.0667
16	.5216	.5201				.0286	.08
17	.0147	.0135	.0225			.0293	.0137
18		.0297	.036	.0162	.0312		.0286
19	.0173	.0312	.0463	.0354	.0328		.0343
20	.0343	.0351	.0469	.0351	.0328		.0343
21	.0354	.0343	.0463	.0351	.0332		.0343
22	.0166	.2027		.0349	.0332		.0305
23	.0151	.1947	.1252	.0303	.032		.0286
24	.0305	.0141	.2172	.1269	.0303		.0286
Max	.7011	.7116	.3715	.333	.1932	.0389	.0812
Min	.0147	.0135	.0145	.0145	.0152	.0278	.0137
Avg	.1935	.2303	.1252	.0774	.0352	.0312	.0416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 201 / YADRAV

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4897	2.8292	3.2065	2.6406	3.2065	3.0933	3.1595
2	2.452	2.7915	3.131	2.6029	3.1687	3.0178	3.0556
3	2.3388	2.7161	3.0178	2.5652	3.0178	2.9801	3.0178
4	2.3765	2.7538	3.0178	2.5652	3.131	2.9801	2.9424
5	2.3765	2.6513	3.0933	2.6406	3.2065	2.9801	2.8669
6	2.452	2.6139	3.1687	2.8669	3.2065	3.0178	3.0933
7	2.6406	2.6513	3.3196	3.0178	3.4705	3.2819	3.1975
8	2.7915	2.6406	2.6406	3.2065	3.3951	3.0933	
9	3.3951	3.3951	2.452		4.1495		
10	3.5837	3.6969	2.2634	3.5848	3.7342		2.9874
11	3.4705	3.7723	2.3011	3.3951	3.6222		2.838
12	3.131	3.2065	2.2634	2.9874	3.0178		2.5972
13		2.6406	1.9239	2.6886	2.6406	3.0933	
14		3.0178	2.0748	3.3608	3.0178	3.0556	
15		3.4705	1.8861	3.6222	3.3951	3.4705	
16	3.4705	3.3951	1.9616	3.6591	3.4328	3.546	
17	3.3951	3.6214	1.9239	3.3951	3.6969	3.6214	2.6406
18	3.3951	3.546	1.8861	3.5837	3.5837	3.6591	2.6406
19	3.3608	3.4705	1.8861	3.546	3.5837	3.4259	2.6406
20	3.1741	3.2065	2.5652	3.2065	3.4328	3.2356	2.5652
21	3.3981	3.3196	2.6783	3.3951	3.3196	3.2356	2.5652
22	3.1741	3.3951	2.8292	3.4705	3.3196	3.3196	2.5274
23	2.9874	3.3196	3.0178	3.3951	3.3196	3.2737	2.5652
24	2.5274	2.838	3.2442	2.7161	3.3196	3.2065	3.2065
Max	3.5837	3.7723	3.3196	3.6591	4.1495	3.6591	3.2065
Min	2.3388	2.6139	1.8861	2.5652	2.6406	2.9801	2.5274
Avg	2.9705	3.1233	2.5730	3.1353	3.3495	3.2294	2.8393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 203 / ARUNDATHI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	1.0456	.9808	.6036	1.0185	1.1694	1.094
2	1.1317	1.0082	.9431	.6036	.9431	1.094	1.0562
3	1.094	.9709	.9431	.5658	.8676	.9808	1.0658
4	1.0185	.9335	.9054	.5658	.8299	.9054	.9897
5	.9431	.9054	.8299	.6413	.8676	.9054	.9431
6	.9431	.7842	.7545	.6413	.8676	.9054	.9136
7	.9054	.8215	.8299	.7167	.9054	.9054	1.0278
8	1.0562	.8299	.6036	.7545	.9431	.9431	
9	1.1317	.9431	.6036		1.1694		
10	1.1694	1.2071	.5658	1.1203	1.1317		1.1317
11	1.1317	1.2449	.5658		1.1203		1.1949
12	1.1694	1.1317	.6036		1.1694		1.1694
13		.9054	.5658		.9808	1.142	
14		1.0185	.5658		1.0185	1.18	
15		1.1694	.6036	1.0082		1.2181	
16	1.094	1.1694	.5281	.9709		1.18	
17	1.1317	1.2449	.5658	1.358		1.3323	1.1317
18	1.1694	1.2071	.5281	1.2449		1.4084	1.1694
19	1.1576	1.1317	.6036	1.1317		1.3704	1.3203
20	1.1203	1.1317	.5658	1.0562		1.3323	1.1317
21	1.1203	1.1694	.6036	.9431		1.2562	1.1694
22	1.1203	1.094	.6413	1.1317	1.1694	1.2181	1.2071
23	1.1203	1.1317	.6413	1.094	1.1694	1.1317	1.2449
24	1.2071	1.0829	1.094	.6413	1.094	1.1694	1.142
Max	1.2071	1.2449	1.094	1.358	1.1694	1.4084	1.3203
Min	.9054	.7842	.5281	.5658	.8299	.9054	.9136
Avg	1.1002	1.0534	.6932	.8838	1.0156	1.1374	1.1168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 204 / SPM

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712	1.3817	1.3957	1.2071		1.3203	1.4846
2	1.3957	1.307	1.3203	1.1694		1.3203	1.4335
3	1.3203	1.2696	1.2826	1.1694		1.3203	1.3957
4	1.3203	1.2449	1.3203	1.1694		1.3203	1.4465
5	1.2826	1.1949	1.358	1.2071		1.3203	1.4335
6	1.3203	1.3203	1.358	1.1694		1.358	1.5089
7	1.358	1.1949	1.4335	1.1694		1.2071	1.5089
8	1.4335	1.2071	.6036	1.3203		1.2449	
9	1.4335	1.3203	.6036				
10	1.4146	1.5466	.5658	1.3443			1.5089
11	1.4712	1.5466	.5658				1.531
12	1.3957	1.4712	.5658				1.4937
13		1.358	.5658			1.4846	
14		1.3957	.5658			1.5226	
15		1.4712	.6036	1.3817		1.5226	
16	1.5089	1.3957	.679	1.307		1.3704	
17	1.1203	1.5466	.5658	1.5466		1.4084	1.5089
18	1.0082	1.5089	.6036	1.5844		1.5607	1.5089
19	1.307	1.4712	.6036	1.6221		1.5089	1.5466
20	1.2696	1.3203	.8299			1.3957	1.5089
21	1.2323	1.4712	1.0185			1.4335	1.4335
22	1.307	1.5844	1.2449		1.358	1.4846	1.5089
23	1.4937	1.4712	1.3203		1.3957	1.5226	1.4335
24	1.5466	1.4563	1.4335	1.2449		1.3203	1.5226
Max	1.5466	1.5844	1.4335	1.6221	1.3957	1.5607	1.5466
Min	1.0082	1.1949	.5658	1.1694	1.358	1.2071	1.3957
Avg	1.3529	1.3940	.9336	1.3075	1.3769	1.3973	1.4843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 205 / PADMAJA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6221	1.5684	1.5844	1.1694		1.5089	1.5988
2		1.531	1.5466	1.1694		1.5089	1.5466
3		1.531	1.5089	1.1694		1.4712	1.5226
4	1.358	1.531	1.4712	1.2071		1.4712	1.5226
5	1.4335	1.5684	1.5466	1.2826		1.4712	1.5089
6	1.5089	1.643	1.6221	1.3203		1.5089	1.5466
7	1.5844	1.643	1.3203	1.4712		1.5089	1.6221
8	1.8107	1.6598	.7545	1.6057	1.6975	1.5089	
9	1.6598	1.8861	.7545		1.9616		
10	1.5466	1.9805		1.8671	1.8861		1.8861
11		1.9239			1.9993		1.9239
12	1.6975	1.8484			1.9239		1.8671
13		1.6975			1.8861	2.0175	
14		1.8107			1.8861	1.9414	
15		1.9239	.7545	1.6804	1.8861	1.6749	
16	1.9993	1.8861		1.6804	1.9239	1.9794	
17	1.8671	1.9993	.7545	1.5089	2.0748	1.9033	1.6598
18	1.8671	1.8861	.7545	1.8107	2.037	1.6975	1.5089
19	1.8671	1.8107	.7545	1.773	1.9239	1.4712	1.8861
20	1.6804	1.6221	.7545		1.8107	1.3704	1.5844
21	1.4937	1.5089	.9431		1.6975	1.5226	1.5089
22	1.5684	1.4712	1.1694		1.5089	1.5844	1.3203
23	1.643	1.5466	1.1694		1.3203	1.6221	1.3203
24	1.6975	1.6221	1.5466	1.1694		1.5089	1.5844
Max	1.9993	1.9993	1.6221	1.8671	2.0748	2.0175	1.9239
Min	1.358	1.4712	.7545	1.1694	1.3203	1.3704	1.3203
Avg	1.6614	1.7125	1.1506	1.459	1.8390	1.6126	1.6066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 206 / 11 kV YADRAV AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3113	.2591	.426				.1475
2	.2785	.2515	.3932				.1475
3	.2622	.2515	.3605				.1475
4	.2429	.2915	.4096				.1475
5	.2915	.3887	.4534				.1475
6	.3725	.5365	.583				.1966
7	.583	.7125	.7287				.3441
9					.4696		
10				.6722	.421		
11					.3887		
12					.3887		
13					.2591	.1966	
14					.2622	.1966	
15				.5975	.2458	.1638	
16				1.6804	.2622	.1966	
21							.0566
22	.3239		.0566			.1638	.1492
23	.3239	.4915				.1475	.1326
24	.3277	.2915	.4752				.1475
Max	.583	.7125	.7287	1.6804	.4696	.1966	.3441
Min	.2429	.2515	.0566	.5975	.2458	.1475	.0566
Avg	.3317	.3860	.4318	.9834	.3372	.1775	.1604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 207 / TARDAL AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2429	.3605				.1638
2		.2515	.3277				.1638
3		.2347	.3277				.1475
4		.2591	.3605				.1475
5		.4694	.3887				.1638
6		.5182	.4534				.2458
7		1.073	.7935				.4588
8						.1886	
9					.5344		
10				.7468	.4534		
11					.3887		
12					.3887		
13					.3887	.3277	
14					.2622	.3277	
15				.5228	.2458	.3277	
16				.5228	.3277	.3277	
18				.1509			
22	.3239						.1658
23	.2915	.3932					.1326
24		.2591	.3932				.1638
Max	.3239	1.073	.7935	.7468	.5344	.3277	.4588
Min	.2915	.2347	.3277	.1509	.2458	.1886	.1326
Avg	.3077	.4112	.4257	.4858	.3737	.2999	.1953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 402 / SUNIL INDUSTRIES

HV Non-Express Feeder

Feeder KV- 33 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5041	.4527	.4527	.5093	.5093	.5144
2		.4481	.4527	.3961	.5093	.4527	.5144
3		.4481	.5093	.3961	.4527	.4527	.4572
4		.5041	.5093	.3961	.5093	.5093	.4572
5		.5041	.5093	.4527	.5093	.5093	.5144
6		.5601	.5093	.5093	.5658	.5093	.5144
7		.5041	.5093	.4527	.5093	.5658	.5716
8		.4527	.5093	.5093	.5093	.5658	
9		.5093	.3961		.5658		
10		.5658	.3961	.4527	.5093		.5041
11		.5658	.3961		.5093		.5601
12		.5658	.3961		.3961	.3921	.5601
13		.5093	.3961		.5093		
14		.5093	.3961		.4527		
15		.5658	.4527	.3961	.5093		
16	.5093	.5093		.5093	.4527		
17	.4481	.5144	.2829	.5716	.5093		.5093
18	.3921	.5144	.2829	.5658	.5658		.5658
19	.3921	.5716	.2829	.5658	.5658		.5093
20	.4481	.5716	.2829	.4527	.5093		.5093
21	.5041	.5716	.3395	.5093	.5093		.5658
22	.6161	.5716	.4527	.5658	.5093		.5658
23	.5601	.5144	.5093	.5658	.5093	.5139	.5658
24		.4481	.5093	.4527	.5658	.5093	.4568
Max	.6161	.5716	.5093	.5716	.5658	.5658	.5716
Min	.3921	.4481	.2829	.3961	.3961	.3921	.4568
Avg	.4838	.5210	.4232	.4828	.5093	.4990	.5231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 703 / 33 KV Main VCB
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.5766	2.9424	1.7541	2.3765	2.1502	2.4897
2		2.6886	2.8292	1.6975	2.3765	2.0936	2.4897
3		2.5206	2.8292	1.6975	2.2634	2.037	2.3982
4		2.5766	2.9424	1.6975	2.3765	2.0936	2.3982
5		2.8006	3.0556	1.8673	2.3765	2.1502	2.3982
6		3.3608	3.3951	1.9805	2.4897	2.2068	2.6029
7		3.6969	3.6214	2.0936	2.7161	2.32	3.1687
8		2.3765	2.037	2.32	2.4897	2.32	
9		2.4143	1.8107		3.7346		
10		2.6595	1.6975	3.8089	3.5082	3.0727	2.4646
11		2.6595	.4527		3.6214	3.3608	2.4646
12		2.4331	.5093		3.3951	3.1367	2.3525
13		2.32	.5093		3.1687		
14		2.4331	.3395		3.7346		
15		2.6029	1.0185	3.2487	3.2819		
16	2.6595	2.5463		2.9127	3.2819		
17	2.5206	2.7161	.8488	2.2634	2.7161		2.3765
18	2.5766	2.6029	.9054	2.6029	2.7161		2.2068
19	2.4646	2.6029	1.0185	2.6029	2.6595		2.6029
20	2.1285	2.4897	1.2449	2.3765	2.4897		2.32
21	2.1285	2.3765	1.5278	2.6029	2.4331		2.32
22	2.8006	3.1687	1.8673	2.6029	2.2068		2.2634
23	2.6886	3.1687	1.8673	2.4897	1.9805	2.6265	2.2068
24		2.6886	3.0556	1.7541	2.4897	2.1502	2.4897
Max	2.8006	3.6969	3.6214	3.8089	3.7346	3.3608	3.1687
Min	2.1285	2.32	.3395	1.6975	1.9805	2.037	2.2068
Avg	2.4959	2.6867	1.8402	2.3355	2.7868	2.4399	2.4452

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 201 / LAXMI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9719	1.9433	2.0957	1.5242	2.2291	2.0957	2.0576
2	1.8519	1.9433	2.0957	1.4861	1.9719	2.0957	1.9052
3	1.749	2.0576	1.9052	1.4861	1.8004	1.9052	1.8671
4	1.6289	2.0195	1.9052	1.448	1.7147	1.9052	1.8671
5	1.5432	1.9814	1.829	1.448	1.6289	1.9052	1.9052
6	1.7147	2.0576	1.7909	1.4098	1.7147	2.0957	1.9433
7	1.9719	2.2862	1.7147	1.5242	1.8861	2.0957	1.9433
8	1.7147	2.2481	1.1431	1.6766	1.7147	2.2862	1.9814
9	1.9719	2.3148	1.1431	1.8861	1.8861	2.6673	2.0576
10	3.0483	2.572		2.3663	2.2291		2.3148
11	3.1626	2.6578		2.4006	2.4006		2.4006
12	2.934	2.7435		2.332	2.2291		
13	2.6673	2.8292	.8573	2.2291	2.4006		
14	2.6673	2.6578	.9431	2.3148	2.5911		
15		2.915	1.1145		2.3624		
16	2.8959	3.3532	1.2003		2.4768	2.2291	
17	2.9721	3.0483	1.3336	2.3148	2.4768	2.5149	
18	2.8197	2.6673	1.3717	2.2291	2.6673	2.3624	
19	2.5149	2.2862	1.4098	2.2291	2.4768		
20	2.2862	2.2862	1.3717	2.1434	2.4768	2.0957	
21	2.3624	2.2862	1.5242	2.1434	2.2862	2.3624	
22	2.0576	2.2862		2.3148	2.2862	2.3624	
23	1.9814	2.2862	1.6004	2.572	2.21	2.1338	
24	1.8861	1.9433	2.0957	1.5623	2.2291	2.0957	2.0957
Max	3.1626	3.3532	2.0957	2.572	2.6673	2.6673	2.4006
Min	1.5432	1.9433	.8573	1.4098	1.6289	1.9052	1.8671
Avg	2.2771	2.4029	1.5222	1.9564	2.1811	2.1887	2.0282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 202 / MANIK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0233	1.9052	2.0957	1.2955	1.4403	1.5242	1.8671
2	1.869	1.8671	2.0957	1.2955	1.4746	1.4861	1.829
3	1.7318	1.829	1.829	1.2955	1.406	1.4861	1.7147
4	1.5775	1.7909	1.7528	1.2193	1.3203	1.448	1.7147
5	1.5089	1.8671	1.7147	1.2193	1.2003	1.3717	1.7528
6	1.5604	1.8671	1.6766	1.2574	1.1831	1.3717	1.9052
7	1.6461	1.6766	1.6385	1.2955	1.1317	1.4098	1.9052
8	1.8176	1.7147	1.5242	1.4098	1.1831	1.5623	1.9052
9	1.5261	1.9204	.9145	1.3717	1.3375	1.9052	1.9547
10	2.2862	2.2805		1.8861	1.4403		2.0919
11	2.4768	2.4006		1.3717	1.6461		2.6063
12		2.2977	.8573	1.3717	1.6804		
13		2.1091	.8059	1.4746	1.7147		
14		2.2462	.8402	1.406	1.9814		
15		2.452	.823		2.0576		
16	2.9721	2.4768	.823		2.0576	2.1605	
17	2.934	2.4768	1.1431	1.4403	1.829	2.3624	
18	2.6673	2.4006	1.4098	1.3717	1.6766	2.2862	
19	2.4387	2.4006	1.4098	1.2346	1.6385		
20	2.2862	2.21	1.3717	1.0288	1.5623	2.0957	
21	2.1719	2.21	1.448	.8059	1.5623	2.0576	
22	2.0957	2.0957		1.0117	1.5242	2.0576	
23	1.9433	2.0957	1.3717	1.1831	1.5242	1.9814	
24	1.9547	2.0005	2.0957	1.4098	1.3717	1.5242	1.9433
Max	2.9721	2.4768	2.0957	1.8861	2.0576	2.3624	2.6063
Min	1.5089	1.6766	.8059	.8059	1.1317	1.3717	1.7147
Avg	2.0744	2.1080	1.4115	1.3025	1.5393	1.7700	1.9325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 204 / 11 KV AUTOLINE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7833	2.21	2.4768	.9907	2.4177	2.2862	2.0957
2	1.7147	2.2862	2.2862	1.0288	2.2805	2.2862	2.0576
3	1.8176	2.3624	2.0957		2.0233	2.0957	2.21
4	1.9204	2.3624	2.0957	1.105	1.7147	2.0957	2.2862
5	2.1262	2.3624	1.829	1.1431	1.6118	2.0957	2.2862
6	2.2119	2.3624	1.7528	1.1241	1.6975	2.2862	
7	2.3663		1.5242	1.2574	1.7318	2.2862	2.2862
8	.7888	2.3624	1.5242	1.2574	1.6804	1.9052	1.6766
9	2.7263	2.332	.9907	1.3717	1.749	1.4861	1.8861
10		2.5206		1.6461	1.8519		2.2977
11		2.5892		1.6461	2.4006		2.692
12		2.4348	.8573	1.6118	2.2634		2.2462
13	2.7816	2.2805	.8745	1.9204	2.1948		1.8861
14		2.4006	.8573	2.0576	2.5911		1.8176
15		2.5206	.823		2.3624		1.6118
16	2.2862	2.2862	.823		1.6766	2.4006	
17	2.0957	2.0957	.9145	1.9033	1.9052	2.5911	
18	2.2862	2.0957	.9145	1.749	2.2481		
19	2.3624	2.4387	.9526	1.869	2.21		
20	2.2862	2.5149	.9907	1.9547	2.21	2.3624	
21	2.3624	2.0576	.8383	2.0576	2.1338	2.3624	
22	2.2862	1.6766		2.2805	2.21	2.2862	
23	2.2481	2.8578	.9145	2.4006	2.2862	2.0576	
24	1.9547	2.2481	2.4768	.9526	2.4691	2.2862	2.0957
Max	2.7816	2.8578	2.4768	2.4006	2.5911	2.5911	2.692
Min	.7888	1.6766	.823	.9526	1.6118	1.4861	1.6118
Avg	2.1266	2.3329	1.3720	1.5870	2.0800	2.1981	2.0954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 206 / 11 KV MARUTI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	2.2481	2.0957	1.6004	1.5775	2.21	2.3624
2	1.4403	2.21	1.9052	1.5242	1.6461	2.1338	2.2862
3	1.5261	2.1338	1.9052	1.5242	1.5604	2.0957	2.2862
4	1.6975	2.0957	1.9052	1.5623	1.6975	2.0957	2.21
5	1.9376	2.0576	1.9052	1.5623	1.8861	2.2862	1.9052
6	2.1434	2.0576	2.0957	1.6004	1.9547	2.3624	1.6766
7	2.2634	2.2862	2.0957	1.6766	2.1776	2.4768	1.9814
8	1.6289	2.5149	1.9052	1.9052	1.5947	2.4768	2.0957
9	2.4177	2.4006	1.5242		1.9204	2.4768	2.0405
10		2.452			2.2291		2.1605
11		2.6406			2.4006		2.2977
12		2.692		2.332	2.3663		2.3663
13		2.452		2.3663	2.1262		2.2805
14		2.5377		2.2634	2.6673		2.4006
15		2.4177			2.6673		2.2977
16	2.934	2.4768			2.3624	2.332	2.3491
17	2.4768	2.553	.9526	2.3663	2.5149	2.5149	
18	2.8197	2.4768	.9907	2.4006	2.7054	2.5911	
19	2.5149	2.7435		2.4691	2.5911		
20	2.4387	2.7054		2.332	2.4768	2.3624	
21	2.5911	2.4768	.8383	2.2291	2.4768	2.4387	
22		1.7147		1.9547	2.2862	2.5149	
23	2.3624	2.0957	1.5242	1.5775	2.21	2.4387	
24	1.6118	2.2862	2.0957	1.6004	1.6975	2.21	2.4387
Max	2.934	2.7435	2.0957	2.4691	2.7054	2.5911	2.4387
Min	1.4403	1.7147	.8383	1.5242	1.5604	2.0957	1.6766
Avg	2.1381	2.3636	1.6956	1.9393	2.1580	2.3539	2.2021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 401 / 33 KV LIE Industrial No 1 SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8519	2.2862	2.1719	2.4006	2.2291	2.0576	2.5149
2	1.9033	2.2862	2.1719	2.5149	2.2862	2.0576	2.4006
3	2.0576	2.1719	2.2862	2.5149	2.1719	1.9433	2.4006
4	1.9547	2.1719	2.2862	2.5149	2.1148	1.829	2.5149
5	1.8519	2.1719	2.4006	2.5149	2.1719	1.9433	2.4006
6	1.9033		2.2862	2.5149	2.2291	2.1719	2.2862
7	2.0062	2.2862	2.4006	2.5149	2.2291	2.5149	2.6292
8	2.1091	2.4006	2.4006	2.5149	2.4006	2.5149	2.5149
9	2.3663	2.2119	2.6292		2.572	2.6292	2.3663
10	2.6292	2.1605			2.6863		2.3148
11	2.6292	2.1091			2.572		2.3663
12	2.7435	2.1605	2.1091	2.2119	2.5149		2.3148
13	2.6292	2.0576	2.0576	2.2634	2.4006		2.4177
14	2.6292	2.0576	2.1091	2.2119	2.5149		2.3663
15		2.1091	2.0576		2.5149		2.3148
16	2.4006	2.1719	2.0576		2.4006	2.2119	2.1605
17	2.5149	2.1719	2.1719	2.1605	2.4006	2.5149	
18	2.5149	2.2862	2.1719	2.0576	2.5149	2.4006	
19	2.6292	2.1719	2.2862	2.0576	2.4006		
20	2.5149	2.4006	2.2862	1.9547	2.4006	2.5149	
21	2.5149	2.2862	2.4006	1.9033	2.2862	2.5149	
22	2.4006	2.1719		2.0576	2.2862	2.4006	
23	2.4006	2.1719	2.4006	2.1091	2.1719	2.5149	
24	1.8519	2.4006	2.0576	2.4006	2.2291	2.0576	2.4006
Max	2.7435	2.4006	2.6292	2.5149	2.6863	2.6292	2.6292
Min	1.8519	2.0576	2.0576	1.9033	2.1148	1.829	2.1605
Avg	2.3047	2.2119	2.2476	2.2838	2.3625	2.2819	2.3932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 402 / 33 KV LIE Industrial No 2 SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.7147	1.7147	1.1431	1.9433	1.829	1.7147
2	1.8519	1.7147	1.829	1.1431	1.7147	1.7147	1.6004
3	1.4403	1.6004	1.829	1.1431	1.6004	1.6004	1.829
4	1.2346	1.6004	1.6004	1.1431	1.4861	1.6004	1.7147
5	1.3375	1.829	1.6004	1.1431	1.4861	1.7147	1.7147
6	1.4403	1.829	1.7147	1.1431	1.6004	1.7147	1.829
7	1.6461	1.7147	1.829	1.1431	1.7147	1.829	1.829
8	1.3375	1.829	1.3717	1.2574	1.4861	1.4861	1.7147
9	1.8519	1.8519	1.2574		1.7147	1.3717	1.6461
10	2.0576	2.0576		1.749	2.0005		1.749
11	2.0576	1.8519		1.8519	2.0005		1.8519
12	1.9433	1.5432	1.0802	1.8004	2.0005		1.749
13	2.0576	1.2346	1.0288	1.749	2.0576		1.8519
14	1.9433	1.5432	1.0802	1.5947	2.1719		1.9547
15		1.8519	1.0288		2.0576		1.8519
16	1.9433	1.4861	1.0288		1.9433	1.5947	1.8519
17	1.9433	1.9433	1.1431	1.9547	1.9433	1.829	
18	1.9433	1.9433	1.1431	1.749	2.0576	1.9433	
19	1.9433	1.9433	1.0288	1.8519	1.9433		
20	1.829	1.829	1.0288	1.6461	1.829	1.829	
21	1.9433	1.6004	1.1431	1.5432	1.7147	1.9433	
22	1.7147	1.9433		1.4403	1.829	1.7147	
23	1.829	1.6004	1.2574	1.3375	1.829	1.6004	
24	1.5432	1.829	1.6004	1.1431	1.829	1.829	1.7147
Max	2.0576	2.0576	1.829	1.9547	2.1719	1.9433	1.9547
Min	1.2346	1.2346	1.0288	1.1431	1.4861	1.3717	1.6004
Avg	1.7599	1.7452	1.3494	1.4605	1.8314	1.7144	1.7745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 201 / SAJANI FEEDER

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3772	.4108	.2054	.2614	.2987	.3361
2	.3174	.3174	.3734	.2054	.2241	.2987	.3174
3	.3174	.3174	.3734	.2054	.2241	.2987	.3174
4	.3174	.3547	.3734	.2241	.2241	.2987	.3361
5	.3547	.4108	.4108	.2241	.2801	.3361	.3734
6	.4668	.4854	.4481	.2614	.3734	.3547	.4108
7	.4294	.5228	.4481	.3361	.4481	.4108	.4668
8	.4294	.5228	.3734	.2987	.4294	.4854	.4481
9	.4854	.5415	.2614	.4108	.4668	.4854	.5415
10		.5975	.2054	.4854	.4481	.5228	.5228
11	.3921	.5601		.4481	.4481		.4668
12	.3921	.4294		.4108	.4294	.4481	.3361
13	.3734	.3547		.3734	.3361	.3734	.5041
14					.3547		.4481
15	.4294	.4668			.3734		.5415
16	.4294	.4854			.3734	.3734	
17	.5041	.4854	.2054		.4108		.3734
18	.4668	.4854	.2241	.5228	.5228		.5415
19	.5415	.5228	.2801	.5041	.4854		.5601
20	.6161	.5415	.2987		.4854	.5041	.5601
21	.5601	.5788	.3361		.4854		.5415
22	.4668	.5601			.4108		.4854
23	.4108	.5228	.2241		.3734		.4294
24	.3361	.3734	.4481	.2241	.2801	.3361	.3361
Max	.6161	.5975	.4481	.5228	.5228	.5228	.5601
Min	.3174	.3174	.2054	.2054	.2241	.2987	.3174
Avg	.4262	.4702	.3350	.3338	.3812	.3883	.4432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 202 / SOOT GIRNI FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	17-JUL-17
HR	Load (MW)
10	.2427
Max	.2427
Min	.2427
Avg	.2427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 203 / PANCHAGANGA

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.3921	.5228	.3547	.3734	.2987	.3361
2	.4066	.3361	.5228	.3361	.3547	.2987	.3361
3	.4066	.3547	.5228	.3361	.3547	.2987	.3361
4	.4108	.3547	.5228	.3734	.3921	.3734	.3734
5	.4805	.4108	.5601	.4854	.4481	.5228	.3734
6	.8501	.6161	.5975	.5975	.6722	.6348	.4108
7	.8316	.7282	.7842	.8402	.6161	.7468	.4854
8	.8589	.7095	.6348	.8775	.6161	.8589	.6161
9	.8402	.6908	.5228	.9335	.7095	.8962	.6535
10		.7733	.4481	.6535	.7468	.6722	.6722
11	.8029	.7468		.7468	.5041		
12	.7842	.5601		.8215	.5228	.7095	
13	.7468	.6348		.8962	.5041	.7282	.4668
14	1.2323	.5975			.4854		.5975
15		.6722			.4854		.5601
16		.6722			.5228	.7095	
17		.6535			.4668		.4854
18		.6348	.4481	.9709	.6722		.6348
19	.8775	.5975	.6161	.9709	.6722		.6908
20	.8775	.6348	.5975		.6908	.7655	.6722
21	.6908	.6722	.5975		.6348		.6348
22	.6161	.6535	.6161		.4854		.5228
23	.4668	.5975	.3921		.3734		.3734
24	.4481	.4481	.5228	.3547		.3361	.3734
Max	1.2323	.7733	.7842	.9709	.7468	.8962	.6908
Min	.4066	.3361	.3921	.3361	.3547	.2987	.3361
Avg	.6880	.5892	.5546	.6593	.5350	.59	.5050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 204 / RUI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0671	.2652	.2012	.1509	.0995	.0503
2		.0671	.2652	.1844	.1509	.0829	.0503
3		.0671	.2652	.1844	.1509	.0829	.0503
4		.0671	.2652		.1509	.0829	.0503
5		.0671	.2652		.1509	.0829	.0671
6		.0671	.2984		.2012		.0671
7		.0838	.3812		.2347	.1326	.0671
8		.0838	.0663		.0671	.0663	.0671
9	.1006	.5365	.0663		.0503	.0663	.1174
10		.6414	.0671		.0503	.0503	.1147
11		.6203			.0671		.1475
12		.5868			.0671	.0497	.1475
13		.503		.2486	.0503	.0503	.1147
14		.4694			.0503		.1147
15		.4694			.0503		.1475
16		.4359	.0625		.0503	.0503	
17		.0671	.0671		.0503		.0655
18		.0671	.0671	.1006	.0503		.0492
19	.0655	.0663	.0671	.0838	.0663		.0671
20	.0819	.0663	.0671		.0663	.0838	.0671
21	.0819	.0663	.0838		.0663		.0671
22	.0655	.2652	.2515		.0829		.0503
23	.0655	.2652	.1844		.0995		.0503
24		.0671	.2652	.2012	.1509	.0995	.0503
Max	.1006	.6414	.3812	.2486	.2347	.1326	.1475
Min	.0655	.0663	.0625	.0838	.0503	.0497	.0492
Avg	.0768	.2401	.1748	.1720	.0969	.0772	.0800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 205 / MANGAON

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1307	.1494	.1494	.1494	.1494	.1494
2	.1307	.1307	.1494	.1307	.1307	.1494	.1494
3	.1294	.112	.1494	.1307	.1307	.1307	.1494
4	.1307	.112	.1494	.1494	.1307	.1494	.168
5	.1494	.112	.1494	.1494	.1494	.1867	.168
6	.1494	.1307	.1494	.168	.1494	.2054	.1867
7	.1494	.1494	.168	.168	.168	.2241	.1867
8	.1494	.168	.1494	.1867	.168	.2241	.1867
9	.1494	.1494	.1494	.1494	.1494	.2241	.1867
10		.1307	.1307	.1307	.1494	.168	.2054
11	.1307	.1307		.1307	.1307		.1307
12	.112	.1307		.1307	.1307	.1494	.1494
13	.112	.1494		.1307	.112	.1494	.168
14	.112	.1307			.112		.168
15		.1307			.112		.1494
16		.1307			.1307	.1307	
17		.1307			.112		.1494
18		.168	.1307	.2241	.1867		.2054
19	.2241	.2054	.1715	.2427	.2241		.2427
20	.2614	.2241	.1867		.2614	.2801	.2427
21	.2427	.2241	.2054		.2614		.2427
22	.2054	.2054	.1867		.2241		.1867
23	.168	.1867	.1494		.168		.1494
24	.1307	.1494	.168	.1494	.1494	.1494	.1494
Max	.2614	.2241	.2054	.2427	.2614	.2801	.2427
Min	.112	.112	.1307	.1307	.112	.1307	.1307
Avg	.1561	.1509	.1584	.1575	.1579	.1780	.1770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 206 / 11 KV MANGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.8573	.5487	.0857		
2	.0343	.0343	.823	.5144			
3	.0343	.0343	.823	.5144			
4	.0343	.0343	.823				
5	.0343	.0343	.823				
6	.0343	.0343	.823				
7	.0343	.0343	.823			.0343	
8	.0339	.0343	.0343				
9	1.0117	1.2003	.0343		.0343		.0171
10		1.2517	.0343		.0343		.0171
11	.9945	1.2517					.0343
12		1.166					.0171
13		1.1488					
14		1.1488					
15		1.0802					.0171
16		1.0631					
17		.0343					
18		.0343	.0343	.0343			
19	.0343	.0343	.0343	.0343			
20	.0343	.0343	.0343				
21	.0343	.0343	.0343				.0171
22	.0343	.8573	.6173				.0171
23	.0343	.8573	.583				.0171
24	.0343	.0343	.8573	.5658	.12		
Max	1.0117	1.2517	.8573	.5658	.12	.0343	.0343
Min	.0339	.0343	.0343	.0343	.0343	.0343	.0171
Avg	.1554	.4794	.4761	.3687	.0686	.0343	.0193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 207 / 11 KV Laxmi AG. (Sajani)

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0625	.0625	.5312	.4062	.3281	.2656	.0469
2	.0625	.0625	.5312	.3906	.3281	.25	.0469
3	.0625	.0625	.5312	.3906	.3125	.25	.0625
4	.0625	.0625	.5312	.4062	.2968	.25	.0781
5	.0781	.0625	.5624	.4062	.3749	.2656	.0781
6	.0937	.0937	.6249		.5468	.2812	.0937
7	.0937	.1094	.9374	.7343	.6249	.3281	.0937
8	.0937	.0781	.0625	.0781	.0625	.0781	.0781
9	1.1405	1.1873	.0625	.0781	.0781	.0781	.3593
10		1.1561	.0625	.0625	.0781	.0781	.3749
11	1.1717	1.1561		.0625	.0625		.4218
12	1.0936	1.1092		.0625	.0625	.0937	.4062
13	1.0623	.9842		.0625	.0625	.0937	.4218
14	1.0311	1.0155			.0469		.4218
15		.9998			.0469		.3906
16		1.0155	.0625		.0469	.0625	
17		.0625			.0469		.0625
18		.0625	.0781	.0781	.0625		.0469
19	.0937	.0781	.0937	.0625	.0625		.0625
20	.0781	.0781	.0937		.0625	.0625	.0625
21	.0781	.0781	.0781		.0625		.0625
22	.0625	.5624	.4999		.2812		.0625
23	.0625	.5624	.4374		.2812		.0469
24	.0625	.0625	.6348	.4062	.3281	.2812	.0469
Max	1.1717	1.1873	.9374	.7343	.6249	.3281	.4218
Min	.0625	.0625	.0625	.0625	.0469	.0625	.0469
Avg	.3445	.4485	.3564	.2458	.1894	.1812	.1664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 208 / 11 KV Gomtesh Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2096	.1867	.1867	.1867	.1494	.1494
2	.168	.1905	.1867	.168	.168	.1494	.1494
3	.168	.1715	.1867	.168	.1494	.1494	.1494
4	.1663	.1715	.1867	.1867	.1494	.1494	.168
5	.2033	.1715	.2054	.1867	.1867	.168	.168
6	.2241	.2096	.2241	.2054	.2241	.1867	.1867
7	.2033	.2477	.2241	.2241	.2241	.2054	.2054
8	.2054	.2286	.2054	.2054	.2241	.2054	.2054
9	.2427	.2286	.2054	.1867	.1867	.2054	.2427
10		.2858	.2427	.2614	.1867	.2614	.2452
11	.2801	.2614		.2241	.2427		.3395
12	.3361	.2241		.2054	.2054	.2614	.2641
13	.3547	.1867		.1867	.2801	.2987	.2263
14	.3361	.2054			.2427		.2263
15	.3361	.2054			.2241		.3018
16		.2054	.2427		.2427	.2987	
17		.2054	.2054		.2801		.2614
18		.2054	.2054	.2263	.2241		.2452
19	.2241	.1867	.2054	.2427	.2241		.2987
20	.2427	.2054	.2054		.2241	.2054	.2614
21	.2427	.2054	.2241		.2054		.2054
22	.2241	.2054	.2241		.1867		.1867
23	.2054	.2054	.2054		.1867		.1867
24	.1848	.1905	.2054	.2054	.2054	.168	.168
Max	.3547	.2858	.2427	.2614	.2801	.2987	.3395
Min	.1663	.1715	.1867	.168	.1494	.1494	.1494
Avg	.2367	.2089	.2093	.2044	.2108	.2041	.2192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 401 / 33 KV Mangaon Industrial
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5268	4.1152	3.658	4.0741	4.2438	4.5725	4.7531
2	4.5833	4.0009	3.7151	4.0741	4.0741	4.4582	4.6399
3	4.5833	4.1307	3.7151	3.9609	4.1307	4.3439	4.5268
4	4.6399	4.1152	3.7723	3.9609	4.2438	4.2867	4.5268
5	4.5268	4.1724	3.7151	3.9609	4.4136	4.4582	4.6399
6	4.4136	4.2867	3.7723	4.0175	4.8097	3.8866	4.6965
7	4.357	4.2295	4.1152	4.2438	4.9228	4.6868	4.6399
8	4.357	4.1152	4.0009	4.0741	4.7531	4.8583	4.1307
9	4.2438	4.7439	3.8866	3.8866	4.8663	4.6296	4.6399
10		4.7963	3.5082	4.4582	4.2438	4.5833	4.8663
11	5.144	4.4136		4.3439	4.1307		4.6965
12	4.0009	5.4321		4.2867	5.2058	4.8171	4.8663
13	4.4582	4.7531		4.2295	4.4702	4.8663	4.6399
14	4.7439	4.7531			4.4136		4.8097
15		4.7531			5.3755		4.7531
16		4.6965			5.2058	4.7531	
17		4.9794			4.9228		5.2058
18		4.8097	3.6214	4.4136	5.0926		5.036
19	4.2438	4.0009	3.7912	4.7531	4.6868		5.1492
20	4.5833	4.4582	3.7346		4.8011	4.4136	4.8663
21	4.4702	4.4582	3.9609				4.3004
22	4.5268	3.658	4.0741		4.9154		4.7531
23	4.6399		4.1307		4.9154		4.8663
24	4.6399	4.2867	3.7151	4.1307	4.6399	4.6868	4.8663
Max	5.144	5.4321	4.1307	4.7531	5.3755	4.8663	5.2058
Min	4.0009	3.658	3.5082	3.8866	4.0741	3.8866	4.1307
Avg	4.5096	4.4417	3.8169	4.1793	4.6729	4.5534	4.7334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 201 / PUJARI MALA AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0667	1.2003	1.1488	.8436	.0686	.061	.0446
2	.0676	1.166	1.1488	.8642	.0686		.0457
3	.0648	1.166	1.1488	.8421	.0686	.061	.044
4	.0667	1.0974	1.1488	.8421	.0686	.061	.044
5	.0648	1.0974	1.1488	.823	.0686	.061	.044
6	.0667	1.0974	1.166	.9282	.0686	.061	.0452
7	.0762	1.2003		1.046	.0686	.061	.0457
8	.081	.0686		.061	.0686		.0457
9	1.6842	.0514		.0412	.8573		.2812
10		.0514					
11		.0514					.3048
12	1.8004	.0457					.3601
13	1.7147	.0457	.0686			.2155	.3086
14	1.5775	.0469	.0686			.2035	.3429
15	1.4232	.0305	.0686		.5087	.1989	.3429
16	1.4232	.0312			.503	.2134	.3429
17	.0514				.4268	.0446	.0514
18	.0514	.0457	.0686		.4801	.0301	.0514
19	.0686	.0446	.0686		.0457		.0514
20	.0686	.0457	.0594	.0686		.0389	.0457
21	.0686	.061	.061	.0686		.04	.0514
22	1.2517	1.1488		.0686	.061		.0514
23	1.2003	1.1488	1.0288	.0686	.061		.0514
24	.0667	1.2003	1.1488	.9061	.0686	.061	.0446
Max	1.8004	1.2003	1.166	1.046	.8573	.2155	.3601
Min	.0514	.0305	.0594	.0412	.0457	.0301	.044
Avg	.5911	.5279	.6367	.5337	.2095	.0941	.1322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 202 / 11Kv Ganpati Mandir AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097					.061
2	.6173					.061
3	.6401					.061
4	.6478					.061
5	.6554					.061
6	.7209					.061
7	.7125					.061
9		.8916		.8619	.6173	
10		.8059				
11		.8916				
12		.9389		.9602		
13		.8962	1.1145	1.0669		
14		.9389	1.0974		.1715	
15		.8421	1.0631		.1715	
16		.8718			.1357	
17					.1296	
18					.1372	
22					.061	
23					.061	
24	.7125					.061
Max	.7209	.9389	1.1145	1.0669	.6173	.061
Min	.6097	.8059	1.0631	.8619	.061	.061
Avg	.6645	.8846	1.0917	.963	.1856	.061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 203 / SHIRADWAD FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1875	.5487	.5487	.4748	.4801	.4268	.4062
2	.1543	.5487	.5487	.4641	.4801	.4268	.3563
3	.1619	.5144	.5487	.4748	.4801	.4268	.3688
4	.16	.5144	.5487	.4641	.4801	.4268	.373
5	.1989	.4801	.5487	.4694	.4801	.4268	.3688
6	.2267	.4801	.4801	.4973	.4801	.4268	.407
7	.2374	.4973		.5959	.4801	.4268	.4409
8	.2743	.5658		.583	.5487	.4877	.3963
9	.5506	.6859		.5868	.6859		.1943
10		.6859		.6859			
11		.7202		.6859			.3658
12	.5487	.5426		.3429			.2229
13	.5144	.3563	.3944	.3429		.5258	.2058
14	.4801	.421	.5487		.5087	.6173	.1715
15	.6173	.5182	.6516		.5959	.6173	.2229
16	.6173	.583			.6154	.663	.2915
17	.6173	.6299			.5426	.6661	.2229
18	.6516	.5426	.6173		.6783	.6154	.2229
19	.6173	.583	.6859		.7011		.2058
20	.5487	.6173	.6249	.6173		.5636	.2401
21	.6173	.4877	.583			.5182	.2743
22	.5487	.5487			.5487		.2058
23	.5487	.5487	.5344	.4801	.5316		.1543
24	.1852	.5487	.5487	.4744	.4801	.4725	.503
Max	.6516	.7202	.6859	.6859	.7011	.6661	.503
Min	.1543	.3563	.3944	.3429	.4801	.4268	.1543
Avg	.4211	.5487	.5608	.5150	.5443	.5138	.2966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 204 / ABDUL LAT AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	.1543	.2229	.1492	.1543	.5316	.421
2	1.7368	.1543	.2229	.1492	.1543	.5316	.4062
3	1.7368	.1543	.2229	.1509	.1543	.5316	.421
4	1.7772	.1543	.2229	.1509	.1543	.6516	.4062
5	1.8442	.1715	.2229	.1696	.1715	.823	.4572
6	1.9669	.1715	.2401	.1865	.1886	.8916	
7	2.2611	.1886		.2105	.2229	.9945	1.078
8	.1524	.1886		.2012	.2058		.1524
9	.1943	2.8292		2.2965	1.7147		.1524
10		3.275		2.572			
11		3.3608		2.692			.1219
12		3.3234		2.5377			.1372
13		3.0407	3.2579	2.4177		.0762	.12
14		2.3482	3.0693		.6783	.1067	.12
15		2.8121	3.155	2.572	.9503	.0949	.12
16		2.967			.8573	.1094	.1029
17		.1656	.1543	.1715	.3239	.1219	
18			.1715		.3239	.1372	.1886
19	.2058	.2031	.2229		.0972		.1715
20	.2572	.1886	.2105	.2572		.1635	.1677
21	.2401	.2572	.1981	.2229		.1943	.1829
22	.1886	.2401		.1886	.5487		.442
23	.1543	.2401	.1524	.1715	.5316		.381
24	1.749	.1543	.2401	.1337	.1543	.5316	.4374
Max	2.2611	3.3608	3.2579	2.692	1.7147	.9945	1.078
Min	.1524	.1543	.1524	.1337	.0972	.0762	.1029
Avg	1.0850	1.1627	.7617	.8801	.4215	.4057	.2946

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 205 / 11 KV LATWAD GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0149	.0171	.0171	.0149	.0171	.0171	.0156
2	.0152	.0171	.0171	.0152	.0171	.0171	.0156
3	.0152	.0171	.0171	.0152	.0171		.0168
4	.0152	.0171	.0171	.0152	.0171	.0171	.0162
5	.0158	.0171	.0171	.0156	.0171		.0162
6	.0305	.0171	.0171	.0152	.0171		.0152
7	.0305	.0171		.0305	.0171		.0152
8	.0335	.0171		.0324	.0171	.0171	.0156
9	.0152	.0171		.0185	.0171		.0152
10		.0171		.0171			
11	.0343	.0171		.0343			.0324
12	.0171	.0149		.0171			.0171
13	.0171	.0168	.0171	.0171		.0332	.0171
14	.0171	.0168	.0171		.0187		.0171
15		.0156	.0171		.017		.0171
16		.0168			.0343	.0149	.0171
17		.0164	.0171		.0305	.0166	.0171
18	.0173	.0152	.0171		.0332	.016	.0171
19	.0171	.0324	.0171		.0305		.0343
20	.0171	.0343	.0152	.0171		.0305	.0305
21	.0171	.0171	.0156	.0171		.0305	.0171
22	.0171	.0171		.0171	.0171		.0152
23	.0171	.0171	.0152	.0171	.0171		.0171
24	.0149	.0171	.0171	.0152	.0171	.0171	.0152
Max	.0343	.0343	.0171	.0343	.0343	.0332	.0343
Min	.0149	.0149	.0152	.0149	.017	.0149	.0152
Avg	.0195	.0182	.0168	.0190	.0205	.0207	.0184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 206 / 11 Kv Society Feeder

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1526	.1886	.1886	.1658	.2058	.2058	.1696
2	.1509	.1886	.1886	.1526	.2058	.2058	.1492
3	.1526	.1886	.1886	.1526	.1886	.2058	.1526
4	.1543	.1886	.1886	.1543	.1886	.2058	.1526
5	.1734	.1886	.1886	.1715	.1886	.2058	.1658
6	.1928	.1886	.1886	.1907	.1886	.2058	
7	.1865	.1886		.2075	.2058	.2058	.1802
8	.1677	.1886		.2452	.2401	.2058	.1696
9	.2439	.2229		.2561	.2401		.1357
10	.2743	.2572		.2229			
11	.2915	.2743		.3086			.1715
12	.3086	.2401		.2229			.12
13	.2058	.1943	.2572	.2229			.12
14	.2058	.1658	.1543	.1886	.1677		.1715
15	.2743	.218	.2743	.1886	.2229		.1715
16	.2743	.2204		.1715	.2204	.2454	
17	.2401	.2035		.2572	.2155	.2279	.1372
18	.2058	.218	.2058		.2374	.2572	
19	.2229	.2439	.2058		.2204		.1543
20	.2229	.2401	.2155	.2572		.2204	.1543
21	.1886	.2229	.1823	.2572		.2543	.1219
22	.2058	.2058		.2401			.1372
23	.1886	.2058	.1781	.2401	.2229		.1372
24	.1581	.1886	.2058	.1781	.2058	.2229	.1865
Max	.3086	.2743	.2743	.3086	.2401	.2572	.1865
Min	.1509	.1658	.1543	.1526	.1677	.2058	.12
Avg	.2101	.2096	.2007	.2115	.2097	.2196	.1529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 402 / I-CO SPIN FEEDER

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4294	3.3436	1.6004	1.4861	1.3889	1.7147	1.6004
2	3.315	3.2922	1.6004	1.4861	1.286	1.7147	1.6004
3	3.2007	3.4465	1.6004	1.3717	1.286	1.7147	1.4861
4	3.315	3.0864	1.6575	1.3717	1.4403	1.7147	1.4861
5	3.4294	3.1379	1.7147	1.3146	1.4403	1.7147	1.4289
6	3.4294	3.035	1.8861	1.2003	1.5432	1.7147	1.4289
7	3.7151	3.2922		.9717	1.5432	1.7147	1.8861
8	3.4865	1.8004		.5144	1.4918	1.4861	1.7718
9	3.6008	2.1091		.6287	1.8004		1.7718
10	3.4294	2.1719					
11	2.8807	1.9547		.6859			1.7147
12	3.3436	2.0576		.6859			1.5947
13	3.7723	2.1719	1.6461	.7202		1.7718	1.6461
14	3.8866	1.8861	1.3375				1.4918
15	3.7723	2.0576	1.8519				1.6975
16	3.6008	1.7718			1.3717	1.4861	
17	3.3722	1.6004			1.4289	1.6575	1.6461
18	3.2922	1.9433	1.4403		1.7718	1.6004	1.5432
19	3.2922	1.5432			1.6575		1.1831
20	3.1379	1.4918	1.4861	1.3375		1.3717	1.4289
21	3.2407	1.6975	1.6575	1.5947		1.6004	1.6004
22	3.035	1.4918		1.286	1.7147		1.5432
23	3.3436	1.6575	1.4861	1.5947	1.7718		1.7147
24	3.4294	3.3951	1.6575	1.6004	1.3889	1.7718	1.6575
Max	3.8866	3.4465	1.8861	1.6004	1.8004	1.7718	1.8861
Min	2.8807	1.4918	1.3375	.5144	1.286	1.3717	1.1831
Avg	3.4063	2.3098	1.6159	1.1677	1.5203	1.6499	1.5874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 201 / 11 KV SAHARANAGAR

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1928	.4755	.5121	.5571		.4572	.5765
2	.1928	.4458	.4801	.5304		.4268	.5426
3	.1928	.4161	.4801	.4915		.3963	.5087
4	.1753	.3864	.4801	.4973		.3963	.4748
5	.1753	.3668	.4481	.4588		.3963	.4748
6	.2103	.3715	.4481	.4588		.4268	.407
7	.2126	.4161	.4801	.5571		.442	.4748
8	.2865	.4755	.5441	.6554		.4877	.4748
9		.5796	.5761	.7045		.5335	.4409
10		.5944	.6401	.7209		.6097	.4409
11		.5868	.6554			.5792	.4409
12	.6335	.4401	.5407			.4877	.373
13	.4119	.3814	.4096		.3963	.4572	.2035
14	.4938	.3521	.5243	.6173	.535	.4877	.373
15	.5487	.4401	.5898	.6401	.5647	.5487	.4748
16	.5841	.5868	.6226	.6401	.5944	.6401	
17	.5563	.5868	.6226	.6249	.5647	.6097	
18	.543	.5868	.6554	.6097	.535	.5792	.1357
19	.5144	.5575	.6226	.5792	.5201	.5487	.1696
20	.5281	.4988	.5898		.5182	.5182	.1696
21	.5281	.4988	.6554		.503		
22	.535	.4988	.6226		.4904		
23	.5201	.4694	.6554		.4755	.5182	.2035
24	.1715	.5201	.5121	.6299		.4755	.5765
Max	.6335	.5944	.6554	.7209	.5944	.6401	.5765
Min	.1715	.3521	.4096	.4588	.3963	.3963	.1357
Avg	.3908	.4805	.5570	.5866	.5179	.5010	.3968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 202 / 11 KV BIRDEV

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6556	.964	1.0159	1.0059		1.2003	1.1984
2	.6135	.8764	.9831	.9503		1.166	1.166
3	.6201	.8413	.9831	.9503		1.1317	1.166
4	.6335	.8413	.9831	.9831		1.1317	1.1336
5	.6201	.8764	.9831	1.0288		1.2003	1.1336
6	.6556	.9114	.9831	1.0395		1.2346	1.1336
7	.7011	1.0166	1.065	1.1401		1.3032	1.1174
8	.7888	1.1218	1.1469	1.2407		1.3717	1.1984
9		1.3496	1.1797	1.3763		1.4918	1.247
10		1.3847	1.2125	1.3279		1.5432	1.2308
11		1.3672	1.1797			1.5089	1.2308
12	1.267	1.0867	.8192			1.0802	.9717
13	.8764	1.0517	.7537		.8402	1.0288	.583
14	.9816	1.3321	1.0364	1.0802	1.0631	1.4232	
15	1.1218	1.4373	1.004	1.2498	1.2689	1.4575	1.004
16	1.1568	1.5074	1.0364	1.2498	1.2517	1.4575	
17	1.1919	1.4723	1.0814	1.2651	1.286	1.406	
18	1.2269	1.2971	1.0688	1.2498	1.3375	1.3717	.421
19	1.2445	1.262	1.0159	1.2186	1.3375	1.3717	.4858
20	1.2094	1.262	1.0159			1.3375	.5344
21	1.1744	1.1919	1.0898				
22	1.1393	1.1568	1.0814				
23	1.1584	1.1393	1.004		1.2003	1.2689	.6478
24	.7011	1.0166	1.0159	1.0562		1.2346	1.1984
Max	1.267	1.5074	1.2125	1.3763	1.3375	1.5432	1.247
Min	.6135	.8413	.7537	.9503	.8402	1.0288	.421
Avg	.9399	1.1568	1.0308	1.1419	1.1982	1.3055	.9896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 203 / 11 KV Industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0458	2.4863	2.4619	1.5947		2.6642	2.6113
2	2.0285	2.4006	2.4272	1.5238		2.524	2.5774
3	2.0508	2.3148	2.4272	1.4883		2.4539	2.5774
4	2.0508	2.3148	2.3926	1.5238		2.3838	2.5434
5	2.0285	2.3148	2.2885	1.5238		2.4539	2.5434
6	2.1033	2.3148	2.3405	1.6278		2.4539	2.5434
7	2.0805	2.4006	2.3232	1.5947		2.524	2.5434
8	2.3148	2.4863	1.2136	2.4806		2.8045	2.7469
9		2.7435	1.1789	2.8349		2.9797	2.9165
10		2.7435	1.0749	3.0121		2.9797	2.9165
11		2.7092	1.1584			2.9447	2.8826
12	2.6749	2.3663	.7964			2.6292	2.6452
13	2.1262	2.3148	.7964		2.2539	2.5941	2.34
14	2.6063	2.6063	.815	2.7664	2.8045		2.6791
15	2.7778	2.7092	.815	2.6558	3.0849	3.0148	2.9334
16	2.7435	2.8121	.7796	2.8502	3.0849	3.0323	
17	2.7435	2.7778	.815	2.8502	3.0498	3.0148	
18	2.7435	2.8292	.7712	2.8502	3.0148	3.0674	2.6452
19	2.7435	2.7949	.815	2.8502	2.9797	3.0148	2.4587
20	2.7168	2.5377	.7973			2.4714	2.3061
21	2.5377	2.4863	1.701				
22	2.5377	2.4691	1.5947				
23	2.5377	2.4348	1.5947		2.7343	2.6993	2.5434
24	2.1033	2.572	2.4619	1.6301		2.7343	2.6113
Max	2.7778	2.8292	2.4619	3.0121	3.0849	3.0674	2.9334
Min	2.0285	2.3148	.7712	1.4883	2.2539	2.3838	2.3061
Avg	2.3950	2.5392	1.4933	2.2152	2.8759	2.7352	2.6282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 205 / Chandur Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049		.4321	.3277			
2	.4049		.4321	.3441			
3	.4049		.4321	.3277			
4	.4049		.4012	.3277			
5	.4049		.4012	.3277			
6	.4049		.3704	.3441			
7	.4359		.3704	.3605			
8			.3858				
9			.3858			.0724	
10						.0701	
11						.0701	
12							.0701
13					.1107		.0701
14					.1107		
15					.0949		
16		.362			.0791		
17		.362					
18		.3982					
22		.4706	.3277				
23		.5068	.3277				
24	.4534		.4321	.3441			
Max	.4534	.5068	.4321	.3605	.1107	.0724	.0701
Min	.4049	.362	.3277	.3277	.0791	.0701	.0701
Avg	.4148	.4199	.3916	.3380	.0989	.0709	.0701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 206 / 11 Kv Abhar Phata
Industrial Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7349	2.9424	2.8669	2.8669		2.8292	2.8292
2	2.7349	2.8669	2.8669	2.8292		2.8292	2.8292
3	2.6972	2.8292	2.8669	2.8669		2.7915	2.8292
4	2.6972	2.8292	2.8669	2.7915		2.7915	2.8292
5	2.7349	2.8669	2.8669	2.8669		2.7915	2.8669
6	2.8669	2.9424	2.8669	2.8292		2.8669	3.0178
7	2.8292	3.0178	2.8292	2.7538		3.0178	2.9801
8	2.8292	3.2065	2.1502	2.8292		3.0178	2.9047
9		3.0556	2.2257	2.9801		3.0178	2.9047
10		2.9424	2.3011	3.0178		2.9424	2.9047
11		2.9801	2.2634			2.9235	2.9047
12	2.9047	2.9047	2.1125			2.8292	2.8669
13	2.8292	2.8292	2.0748		2.7538	2.7161	2.8669
14	2.8669	2.9801	2.1125	2.8292	2.8292	2.9047	2.9047
15	2.9047	2.9235	2.1502	2.9235	2.9235	2.9801	2.9801
16	2.9424	2.9801	2.0748	2.9235	2.9235	3.0556	
17	2.9047	2.9047	2.1125	2.8292	2.9235	3.0178	
18	2.8669	2.9424	2.0748	2.8292	2.9235	2.9424	2.9047
19	2.8292	2.9047	2.1125	2.7349	2.9424	2.9047	2.8669
20	2.8292	2.8292	2.1125		2.9047	2.8669	2.8669
21	2.7915	2.8292	2.9424		2.9424		
22	2.8292	2.8292	2.8669		2.9424		
23	2.8669	2.8669	2.8292		2.9047	2.8669	2.8292
24	.8488	3.0178	2.8669	2.9047		2.8292	2.8292
Max	2.9424	3.2065	2.9424	3.0178	2.9424	3.0556	3.0178
Min	.8488	2.8292	2.0748	2.7349	2.7538	2.7161	2.8292
Avg	2.7304	2.9259	2.4756	2.8592	2.9012	2.8969	2.8858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 207 / 11 KV Sonar Mali AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5243	.3647		
2			.5243	.3441		
3			.4915	.3401		
4			.4915	.3605		
5			.4588	.3605		
6			.426	.3605	.1006	
7			.5243	.3605	.1341	
9		.8848				.132
10		.9667				.1132
11		.9503				.1132
12	.9012	.8684				.0943
13	.9012	.8848				.0754
14	.9012	.852				.0754
15	.8684	.8192				.0754
16	.8192	.7373				
22	.0655	.5571	.426			
23	.0655	.5571	.3768			
24			.5735	.3647		
Max	.9012	.9667	.5735	.3647	.1341	.132
Min	.0655	.5571	.3768	.3401	.1006	.0754
Avg	.6460	.8078	.4817	.3570	.1174	.0970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 208 / 11 KV MAULI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	.8907	.8478	.7042		1.166	1.2209
2	1.4575	.8421	.8478	.7042		1.1336	1.1869
3	.7773	.8259	.8478	.7293		1.1174	1.1869
4	.7773	.8097	.8478	.6962		1.1174	1.153
5	.8097	.8421	.8478	.7537		1.1336	1.153
6	.8745	.8745	.8478	.8029		1.166	1.153
7	.8907	.9393	.763	.8848		1.1822	1.1869
8	.8421	1.004	.6443	1.073			1.2717
9		1.1012	.5765	1.2266		1.3441	1.3904
10		1.1012	.5087	1.2452		1.3279	1.3565
11		1.1012	.5087			1.2955	1.3226
12	.9717	.9717	.3353			1.2308	1.0852
13	.7935	.8097	.2481		1.0526	1.1012	.8817
14	.8907	.8745	.2481	1.1069	1.2308	1.1336	1.0513
15	1.004	.9393	.2835	1.186	1.2955	1.2631	1.1869
16	1.0364	1.004	.2454	1.1717	1.3117	1.2955	
17	1.0526	1.004	.2835	1.1717	1.2955	1.2955	
18	1.0688	.9831	.2835	1.1717	1.2955	1.2631	1.0513
19	1.085	1.004	.3467	1.1717	1.2955	1.2631	1.0174
20	1.0526	.8745	.4115			1.2308	.9835
21	1.0202	.8421	.78				
22	.9717	.8421	.763				
23	.9393	.8745	.7712		1.2146	1.166	1.1191
24	.8097	.9231	.8817	.7377		1.2146	1.2209
Max	1.4575	1.1012	.8817	1.2452	1.3117	1.3441	1.3904
Min	.7773	.8097	.2454	.6962	1.0526	1.1012	.8817
Avg	.9493	.9283	.5821	.9728	1.2490	1.2115	1.1590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 209 / 11 KV Jaihind Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.6859	.679	.679		.679	.679
2	.5658	.6859	.679	.6979		.679	.679
3	.5658	.6859	.679	.7167		.679	.679
4	.5658	.6859	.679	.679		.679	.7356
5	.5847	.6859	.679	.7167		.679	.679
6	.6036	.724	.7167	.7545		.7167	.679
7	.6036	.724	.679	.7545		.7545	.7167
8	.679	.724	.6036	.7545		.7167	.679
9		.7167	.6036	.7545		.7167	.6413
10		.7621	.5658	.7545		.7922	.679
11		.7621	.6036			.7545	.679
12	.7621	.6859	.6036			.6413	.6413
13	.6478	.6097	.5658		.724	.6036	.6413
14	.679	.6859	.5658	.7167	.724	.7545	.6036
15	.7545	.6859	.6036	.7545	.7621	.7922	.6413
16	.7545	.724	.6036	.7545	.7621	.7545	
17	.7621	.7545	.6224	.7545	.7545	.7545	
18	.724	.7167	.6036	.7545	.7545	.7922	.679
19	.6859	.679	.6413	.7545	.7545	.724	.6413
20	.6859	.679	.679			.6516	.6413
21	.724	.679	.7545				
22	.724	.679	.7545		.724		
23	.7545	.7167	.7545		.724	.679	.6413
24	.6036	.6859	.679	.7167		.6859	.679
Max	.7621	.7621	.7545	.7545	.7621	.7922	.7356
Min	.5601	.6097	.5658	.679	.724	.6036	.6036
Avg	.6662	.7010	.6499	.7334	.7426	.7127	.6668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 201 / 11KV TELEPHONE EXCHANGE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0195	2.1338		2.0165	1.7909
2	2.0576	2.0957		1.9044	1.7528
3	2.0957	2.0576		1.8279	1.7147
4	2.1338	2.0195		1.7924	1.6766
5	2.1529	2.0957		1.8484	1.7909
6	2.0767	2.1338		1.8671	1.8671
7	2.1529	2.191		1.9231	1.9052
8	2.0957	2.0957			1.829
9	2.21	2.2481			
10	2.191	2.3815			
11	2.3815	2.4196		2.3624	2.4006
12	2.3243	2.3624		2.4006	2.2862
13	2.0576	2.0576		2.0957	2.2862
14	2.21	2.3243			2.2862
15	2.3434	2.4006			2.4387
16	2.3053			2.4768	2.5149
17	2.2481				2.4387
18	2.191				2.2862
19	2.1529				2.2481
20	2.21		1.8858	2.0576	2.21
21	2.1338		1.9418		2.0957
22	2.2481		1.9959		2.0576
23			2.0559	1.8671	2.0576
24	2.0576	2.1719		1.9791	
Max	2.3815	2.4196	2.0559	2.4768	2.5149
Min	2.0195	2.0195	1.8858	1.7924	1.6766
Avg	2.1761	2.1993	1.9699	2.0299	2.0921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 202 / 11 KV KHOTWADI

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.8962	.8962	.9145	.8215
2	.8676	.8589	.8326	.8589	.7842
3	.7468	.8215	.7634	.7602	.7468
4	.7922	.7842	.7964	.7316	.7842
5	.7468	.7468	.724	.7964	.8215
6	.7842	.8589	.8326	.8779	.8962
7	.8299	.8962	.905	.9193	.8589
8	.7545	.9335	.8688		.7842
9	.9335	1.0082	1.0136		
10	1.0082	.9335	1.0498		
11	1.0456	.9709	1.1041	1.1576	.8962
12	.9335	.8962	.905	.9709	.8589
13	.6722	.7655	.8361	.8589	.9145
14	.6348	.8402	.8688		.8764
15	.8962	.9335	.9412		.8962
16	.8215		1.0059	1.0456	.9335
17			.9511		.8962
18	.9335		.8688		.9149
19	.9709		.7964		.924
20	.8962		.7682	1.0456	.9145
21	.9709		.8688		.8764
22	1.0082		.8688		.8962
23			.8238	.8962	.8589
24	.8299	.9335	.8326	.8688	
Max	1.0456	1.0082	1.1041	1.1576	.9335
Min	.6348	.7468	.724	.7316	.7468
Avg	.8628	.8799	.8801	.9073	.8645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 203 / 11 KV SARITA POLYMER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9235	2.8959	2.6981	2.8753	2.6673
2	2.8578	2.8578	2.7351	2.894	2.7054
3	2.8197	2.8197	2.6797	2.809	2.7435
4	2.7816	2.7816	2.726	2.8006	2.7816
5	2.6673	2.7435	2.6242	2.8753	2.8578
6	2.6783	2.8197	2.7633	2.9156	2.9721
7	2.5911	2.8769	2.6612	2.95	3.0102
8	2.934	3.0102	2.8006		2.7625
9	2.7625	2.8197	2.782		
10	2.9531	2.7816	2.726		
11		2.8197	2.838	3.1626	2.934
12	2.915	2.6292	2.8006	3.0293	2.8578
13	2.7816	2.7054	2.6886	2.8197	2.8578
14	2.6482	2.8578	2.7351		2.7816
15	3.0102	2.934	2.9156		2.934
16	2.8959		2.838	3.0864	2.8197
17	2.8197		2.9313		2.8578
18	2.8578		2.9127		2.8959
19	2.915		2.894		2.8578
20	2.6673		2.7633	2.8197	2.8197
21	2.8197		2.809		2.8578
22	3.0102		2.894		2.9721
23			2.838	2.6673	2.8578
24	2.934	2.934	2.726	2.7351	2.6292
Max	3.0102	3.0102	2.9313	3.1626	3.0102
Min	2.5911	2.6292	2.6242	2.6673	2.6292
Avg	2.8293	2.8304	2.7825	2.8886	2.8379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 204 / RENUKANAGAR

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6108	1.8099	1.9547	2.0995	1.9909
2	1.6289	1.7737	2.0271	1.9342	2.0271
3	1.5203	1.7375	2.0416	1.9044	2.0995
4	1.5384	1.8099	2.0416	1.8099	1.9547
5	1.5565	1.8823	1.8642	1.9185	2.1357
6	1.5746	1.9909	1.97	2.0506	2.0271
7	1.5927	2.0995	2.0416	2.1357	2.0271
8	1.6289	1.9004	2.0995		1.8823
9	2.2443	2.2443	2.1719		
10	2.2443	2.2805	2.3891		
11		2.3167	2.3461	2.2443	2.0485
12	2.0995	2.2081	2.4764	2.2443	2.0538
13	1.8099	1.8099	2.1742	2.0814	2.0195
14	1.8823	2.1719	2.0293		2.0165
15	2.1357	2.2443	2.1357		2.0748
16	2.1719		2.2081	2.2443	1.8861
17	2.0633		2.371		1.8089
18	2.1719		2.2805		1.6732
19	2.3167		2.2231		1.6804
20	1.9909		2.0995	1.9909	1.6188
21	1.8823		2.2314		1.829
22	1.9547		2.1491		1.7551
23			2.0995	2.0814	1.6804
24	1.5203	1.8461	1.949	2.0271	
Max	2.3167	2.3167	2.4764	2.2443	2.1357
Min	1.5203	1.7375	1.8642	1.8099	1.6188
Avg	1.8700	2.0079	2.1406	2.0548	1.9185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 205 / 11 KV Sanmati Vg Feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6221	1.829	1.5927	1.7918	1.7193
2	1.5684	1.7924	.1662	1.7193	1.6827
3	1.5089	1.7558	1.6289	1.647	1.6461
4	1.5844	1.7193	1.5565	1.643	1.6095
5	1.531	1.6827	1.448	1.4632	1.6461
6	1.6221	1.6461	1.5565	1.7737	1.7193
7	1.5497	1.7193	1.6651	1.828	1.7375
8	1.643	1.7924	1.8267		1.5729
9	1.9239	2.0485	1.97		
10	1.9753	2.0851	1.9568		
11	2.0485	2.1216	2.0271	2.0119	1.8858
12	1.9387	1.9753	2.0372	1.9387	1.8671
13	1.4266	1.4815		1.7558	
14	1.7193	1.829			1.6804
15	2.0119	1.957			1.6057
16	2.0485			2.2314	1.6172
17	1.9753				1.6787
18	1.9204				1.7737
19	1.957				1.8484
20	1.7924		1.7174	1.7924	1.8107
21	1.8656		1.7918		1.7924
22	1.9387		1.5927		1.7558
23			1.6651	1.7924	1.6804
24	1.643	1.8656	1.5402	1.7174	
Max	2.0485	2.1216	2.0372	2.2314	1.8858
Min	1.4266	1.4815	.1662	1.4632	1.5729
Avg	1.7746	1.8313	1.6317	1.7933	1.7165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 206 / 11 KV SARADA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	2.2862	2.3285		2.3243
2	2.4006	2.2481	2.2405		2.2862
3	2.4387	2.21	2.2546		2.3243
4	2.3624	2.1719	2.1807		2.3624
5	2.4768	2.2481	2.2405		2.4006
6	2.4006	2.2862	2.2405		2.4387
7	2.3434	2.4006	2.3152		2.4958
8	2.3624	2.3815	2.3306		2.5149
9	2.4577	2.4387	2.4459		
10	2.6673	2.4006	2.4394		
11	2.6101	2.4768		2.6673	2.4768
12	2.572	2.4196	2.4646	2.4768	2.6292
13	2.4387	2.3053	2.4272	2.3815	2.6673
14	2.4196	2.4768			2.6673
15	2.6101	2.6482	2.4646		2.7054
16	2.6292		2.4025	2.8387	2.6482
17	2.553		2.5019		2.6673
18	2.4768		2.3899		2.6673
19	2.5149		2.3494		2.5911
20	2.3434		2.2779	2.5339	2.553
21	2.3815		2.3655		2.553
22	2.4006		2.4272		2.4768
23			2.4394	2.3434	2.5149
24	2.5149	2.3243	2.4646		2.3624
Max	2.6673	2.6482	2.5019	2.8387	2.7054
Min	2.3434	2.1719	2.1807	2.3434	2.2862
Avg	2.4718	2.3577	2.3632	2.5403	2.5149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING

STATI

Feeder No / Name : 402 / 33 KV KABNOOR

Feeder KV- 33 / INCOMING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3086	.3086	.3086	
2	.3086		.3086	.3086	.3086	
3	.3086		.3086	.3086	.3086	
4	.3086		.3086	.3086	.3086	
5	.3086		.3086	.3086	.3086	
6	.3086		.3086	.3086	.3086	
7	.3086		.3086	.3086	.3086	.3086
8	.3086		.3086	.3086	.3086	.3086
9	.3086		.3086	.3086	.3086	.3086
10				.3086		.3086
11	.3086			.3086		.3086
12	.3086			.3086		.3086
13	.3086			.3086	.3086	.3086
14	.3086			.3086	.3086	.3086
15				.3086		.3086
16	.3086	.3086				.3086
17	.3086	.3086		.3086	.3086	.3086
18	.3086	.3086	.3086	.3086	.3086	.3086
19	.3086	.3086	.3086	.3086	.3086	.3086
20	.3086	.3086	.3086	.3086	.3086	.3086
21	.3086	.3086	.3086	.3086	.3086	.3086
22	.3086		.3086	.3086		.3086
23	.3086	.3086	.3086	.3086		.3086
24	.3086		.3086	.3086	.3086	.3086
Max	.3086	.3086	.3086	.3086	.3086	.3086
Min	.3086	.3086	.3086	.3086	.3086	.3086
Avg	.3086	.3086	.3086	.3086	.3086	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING

STATI

Feeder No / Name : 403 / 33 KV RUI-CHANDUR

Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	11.5741	11.9342	13.0659	11.214	13.2716	12.9115	
2	11.5741	11.8313	13.0144	11.1111	13.0144	12.8087	
3	11.6255	11.5741	12.8601	11.0082	12.8601	12.8601	
4	11.677	11.3169	12.6543	11.0082	12.5515	12.7572	
5	11.7284	11.7284	12.3971	11.0597	12.4486	12.5	
6	11.7799	12.1399	12.3457	10.9568	12.1914	12.0371	
7	11.214	12.8601	11.9342	12.0885	13.0659	12.6543	13.0659
8	11.7284	12.2943	11.3169	11.5226	13.3745	13.0144	12.963
9	14.1976	14.1461	10.2366	13.9403	13.9918	13.2202	13.5803
10		14.6091	9.5679		13.4774		13.3745
11	13.4774	15.535	9.5679		14.3004		13.6317
12	13.5288	14.249	9.2593		13.2716		13.0144
13	12.7572	12.1399	8.2305		12.2428	11.7799	11.5741
14	14.0947	13.1687	7.9733		13.9918	13.786	11.4198
15		14.1976	8.2305		14.5062	14.0947	13.5803
16	14.8663	14.3519	8.4362			14.1976	
17	12.8601	13.8375	8.4877		14.1461	13.9918	4.3724
18	12.7058	13.9918	7.9733	14.4548	13.9403	13.7346	10.9054
19	13.6831	13.5803	7.8189	14.3519	13.8375	13.8889	11.3169
20	12.8601	12.5515	8.9506	13.786	13.4259	13.5803	10.9054
21	13.1173	13.786	10.8539	13.3745	13.5288	13.786	11.4198
22	12.8087	13.8889		13.786	12.963		11.2654
23	13.1173	13.1173	11.214	13.8889	12.8601		11.3169
24	11.6255	12.1914	13.1173	11.1626	13.4774	12.9115	13.7346
Max	14.8663	15.535	13.1173	14.4548	14.5062	14.1976	13.7346
Min	11.214	11.3169	7.8189	10.9568	12.1914	11.7799	4.3724
Avg	12.6637	13.1259	10.4133	12.4196	13.3365	13.1850	11.8495

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING

STATI

Feeder No / Name : 404 / 33 KV KOROCHI

Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.9321	3.0864	2.9321	2.9835	2.9321	
2	2.572	2.9321	3.035	2.9835	2.9321	2.9321	
3	2.5206	2.8807	2.9835	2.7778	2.9321	2.8807	
4	2.6749	2.8807	3.035	2.7778	2.8807	2.8292	
5	2.6749	2.8807	2.9835	2.8292	2.8807	2.8292	
6	2.7263	2.8807	2.9835	2.8807	2.9835	2.7778	
7	2.8292	3.0864	3.1379	3.0864	3.1379	3.0864	3.2922
8	2.9321	3.0864	3.1893	3.1893	3.2922	3.1893	3.035
9	3.2407	3.5494	2.8807	3.4465	3.4979	3.2922	3.1379
10		3.6008	2.572		3.3951		3.0864
11	3.2407	3.7037	2.4691		3.0864		3.1893
12	3.1893	3.5494	2.3663		3.4979		3.0864
13	2.8292	2.9835	2.2634		2.9835	2.9835	2.7263
14	3.1893	3.2407	2.9835		3.1893	3.1893	2.8807
15		3.4465	2.6235		.9259	3.3951	2.8292
16	3.3951	3.6008				3.3436	2.8807
17	3.3951	3.4465			3.3951		2.7778
18	3.4465	3.4979	2.5206	3.2922	3.2922		2.6235
19	3.2922	3.2922	4.5782	3.3951	3.2922		2.6235
20	3.1893	3.1893	2.6235	3.1893	3.1379		2.7263
21	3.2922	3.2407	3.1379	3.1379	3.1379	3.1379	2.6749
22	3.1379	3.1893		3.1893	3.1893		2.572
23	3.1893	3.0864	3.0864	3.1379	2.9835		2.6235
24	2.572	2.9835	3.0864	2.9835	2.9835	2.9835	3.035
Max	3.4465	3.7037	4.5782	3.4465	3.4979	3.3951	3.2922
Min	2.5206	2.8807	2.2634	2.7778	.9259	2.7778	2.572
Avg	3.0046	3.2150	2.9346	3.0768	3.0439	3.0521	2.8778

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING

STATI

Feeder No / Name : 405 / 33 KV SAJANI-MANGAON

Urban/Sheddable Urban Feeder

Feeder KV- 33 / INCOMING

DATE	17-JUL-17
HR	Load (MW)
15	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 202 / 11 KV ABDUL LAT GOVTHAN

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.0934	.0934	.0895	.0895	.112	.0781
2	.08	.0924	.0934	.0914	.0914	.0857	.0625
3	.081	.0838	.0943	.0686	.0686	.0857	.0594
4	.0781	.0848	.0943	.0671	.0671	.0857	.0686
5	.0791	.0838	.0914	.0753	.0753	.1029	.08
6	.0937	.0972	.1132	.0829	.1063	.1086	.0791
7	.096	.0762	.1132	.0743	.0671	.1132	.0714
8	.1017	.1063	.1132	.0747	.0937	.0671	.048
9	.1494	.1698	.1132	.1509	.1265	.1006	
10		.2218		.1227	.1509	.1372	
11		.2149		.1132	.1886		.0943
12	.1886	.112			.1478	.1132	.0943
13	.1867	.1132			.1509	.1132	.0781
14		.1614		.1494	.1494	.1509	.0772
15		.1848	.0743	.1478	.112	.1132	.0671
16	.2263	.1581				.1132	.0648
17	.1509	.1494	.0663		.1509	.1132	.0648
18	.1075	.132	.0753	.1132	.1132	.132	.0829
19	.0686	.1132	.081	.0905	.1132		.0972
20	.0583	.0914	.0648	.0903		.0834	.0972
21	.1097	.1132	.0838	.0914		.1017	.0995
22	.1086	.1132	.0886	.0876			
23	.1063	.112	.0876	.0876	.1132	.0789	.0972
24	.0972	.1086	.0924	.0876	.0876	.1132	.0914
Max	.2263	.2218	.1132	.1509	.1886	.1509	.0995
Min	.0583	.0762	.0648	.0671	.0671	.0671	.048
Avg	.1124	.1245	.0908	.0978	.1132	.1059	.0787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 204 / 11 KV GANGOBA MANDIR

Gaathan Feeder

GOVTHAN Feeder KV- 11 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.5258	.4694	.5487	.5487	.5144	.4298
2	.2427	.631	.4694	.5434	.5434	.4801	.4252
3	.2241	.57	.426	.5544	.5544	.426	.362
4	.2402	.5487	.426	.4694	.4694	.4161	.4163
5	.2801	.4973	.4694	.5426	.5426	.4687	.4298
6	.3734	.4508	.503	.5258	.5365	.5365	.4477
7	.4024	.5256	.5487	.5487	.6036	.57	.5434
8	.4607	.5365	.5144	.5658	.5571	.5967	.5201
9	.5898	.6226	.5304	.6133	.5506	.6443	
10		.6154		.6226	.5761	.6859	
11		.6401		.6154	.6081		.373
12		.5571			.5441		.3429
13		.4409			.4588	.4024	.2263
14		.503		.4588	.5243	.4359	.3045
15		.5601	.3856	.5365	.5243	.5121	.3121
16	.5601	.5506				.5441	.3772
17	.6009	.5921	.5441		.6081	.5182	.407
18	.5506	.6167	.5243	.6081	.5312	.4424	.3856
19	.6299	.6554	.583	.6299	.5761		.4344
20	.6024	.5959	.631	.5895		.567	.4527
21	.6859	.6516	.6836	.6104		.5847	.4527
22	.583	.6241	.6241	.57			
23	.5087	.5487	.5765	.5765	.5548	.4557	.3326
24	.2641	.583	.503	.5596	.5596	.5144	.4477
Max	.6859	.6554	.6836	.6299	.6081	.6859	.5434
Min	.2241	.4409	.3856	.4588	.4588	.4024	.2263
Avg	.4469	.5685	.5229	.5645	.5486	.5158	.4011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 205 / 11 KV INDIRA NAGAR GOVTHAN

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.4588	.3963	.3978	.3978	.3395	.4111
2	.1886	.4854	.3963	.3841	.3841	.3437	.3906
3	.168	.3567	.4012	.3688	.3688	.3201	.3593
4	.1867	.4108	.4062	.3772	.3772	.3048	.2984
5	.2263	.4268	.4687	.3887	.3887	.3437	.3149
6	.2641	.4374	.5121	.4161	.3978	.3521	.3163
7	.2587	.426	.5182	.4586	.4801	.4359	.373
8	.2614	.4744	.5636	.4877	.4938	.4973	.3391
9	.5761	.5556	.5761	.571	.5376	.5365	
10		.5556			.5441	.5053	
11		.5556		.4877	.5441		.2454
12		.4687			.3563		.2865
13		.3795			.3353	.4024	.2172
14		.4938		.4801	.426	.4801	.2195
15		.5569	.3277	.4572	.4801	.4801	.2454
16	.5487	.4784				.5182	.2835
17	.535	.5796			.5312	.5304	.2507
18	.5487	.535	.1848		.4938	.506	.2402
19	.5937	.5182	.3391	.4744	.5441		.2614
20	.4973	.5312	.3521	.5182		.4915	.2263
21	.5304	.6081	.5312	.5624		.5636	.2452
22	.4938	.5601	.4372	.4801			
23	.4572	.4572	.4372	.4801	.426	.4374	.1886
24	.1886	.4938	.4268	.421	.421	.3932	.4321
Max	.5937	.6081	.5761	.571	.5441	.5636	.4321
Min	.168	.3567	.1848	.3688	.3353	.3048	.1886
Avg	.3729	.4918	.4279	.4562	.4464	.4391	.2926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 201 / 11KV TAKWADE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.3812	.4588	.421	.5407	.5506	.5506
2	.2105	.431	.426	.3887	.5407	.5468	.5182
3	.2105	.431	.3932	.3887	.5407	.5344	.5182
4	.2267	.3978	.3932	.3725	.5407	.502	.4858
5	.2267	.3647	.3932	.3887	.5243	.502	.4858
6	.2267	.3481	.3932	.4049	.4588	.4999	.4372
7	.2591	.4807	.4588	.4534	.4915	.5344	.4696
8	.2915	.5138	.5571		.5407	.6154	.3725
9	.4973	.6133	.5898	.3887	.6226	.664	.3725
10	.5668	.7127		.7773		.7287	.4534
11	.6154	.6796		.7293	.6554	.7611	.4534
12	.5992	.6962		.7293	.7935	.7287	.421
13	.4858	.502	.5182	.547	.4999	.5668	.3725
14	.502	.5668	.5138	.5967	.6802	.5668	.3887
15	.639	.6401	.5138	.7459	.7287	.6802	.3725
16	.6154	.7042		.8122	.7611	.7449	.3077
17	.5919	.6316	.7045	.779	.7611	.664	.2915
18	.5243	.6401	.639	.6299	.6478	.5506	.2915
19	.5898	.5761	.6226	.7127	.6874	.6154	.3239
20	.583	.5898	.6316	.7127	.6964	.6478	.3563
21	.5967	.6248	.4858	.6882	.7287	.6964	.3239
22	.5636	.5898	.5344	.6226	.664	.6478	.2915
23	.5304	.5243	.4696	.6062	.664	.6154	.2753
24	.2429	.4807	.4973	.4534	.5992	.5992	.583
Max	.639	.7127	.7045	.8122	.7935	.7611	.583
Min	.2105	.3481	.3932	.3725	.4588	.4999	.2753
Avg	.4433	.5467	.5097	.5804	.6247	.6151	.4049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 202 / 11 KV PATIL MALA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3978	.7209	.8097	.8951	.8619	.7956	.8951
2	.3647	.8356	.7773	.8619	.8619	.8619	.8619
3	.3647	.8356	.7449	.8288	.8619	.8619	.8288
4	.3978	.7209	.7125	.7625	.8619	.8453	.7459
5	.3978	.6882	.7125	.7956	.8453	.8288	.7625
6	.431	.7373	.7773	.7956	.7956	.8288	.7293
7	.4641	.852	.8745	.8951	.8453	.9448	.8288
8	.5636	.8684	.9717	.8951	.9448	1.0111	.6796
9	1.0608	1.0814	1.085	1.2929	1.1603	1.1437	.6464
10	1.012	1.065		1.2266	1.1768	1.1271	.5304
11	1.0753	1.1305		1.278	1.1934	1.1437	.5967
12	.9804	1.1469		1.1469	1.0277	1.094	.4641
13	.6958	.9282	.7209	.8684		.663	.3812
14	.8855	.9282	.7865	.9831	1.0774		.3978
15	1.012	1.0277		1.1961	1.1105	1.0608	.3887
16	1.0437	1.0608		1.1469	1.1603	1.1271	.3978
17	1.0279	1.0608	.9831	1.1305	1.1603	1.1271	.3978
18	.9922	1.0277	.9831	1.1797	1.1934	1.094	.3481
19	1.1069	1.0608	1.0486	1.1797	1.2266	.9922	.4807
20	.9488	.9717	.9779	1.1305	1.0277		.5304
21	1.0486	1.0202	1.0277	1.1142	1.094		.5801
22	.9339	.9878	.9945	1.1305	1.0608		.5304
23	.8848	.9393	.9614	1.0159	.9448		.4641
24	.3978	.8684	.8907	.9282	.8848	.9116	.9282
Max	1.1069	1.1469	1.085	1.2929	1.2266	1.1437	.9282
Min	.3647	.6882	.7125	.7625	.7956	.663	.3481
Avg	.7703	.9402	.8863	1.0282	1.0164	.9717	.5998

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 203 / 11 KV PARIJAAT FEEDER
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.4641	.5144	.4801	.5365	.4801	.4801
2	.208	.4807	.4801	.4481	.5365	.4961	.4481
3	.208	.4807	.4801	.4161	.5365	.4801	.4481
4	.2241	.4641	.4748	.4161	.5365	.4641	.4801
5	.2401	.4475	.4801	.4481	.503	.4481	.4481
6	.2561	.4641	.5144	.4641	.4694	.5121	.4801
7	.3201	.5138	.583	.5121	.503	.5281	.5121
8	.3201	.547	.5487	.5281	.57	.5281	.4001
9	.6241	.7625	.6859	.7202	.7377	.6882	.4161
10	.6796	.6882		.7682		.7682	.4161
11	.7209	.7127		.8785	.8048	.7682	.3841
12	.663	.7459		.7459	.6401	.7202	.3841
13	.4973	.4801	.6371	.5636	.5601	.5281	.3201
14	.7459	.5921	.6706	.6796	.6081	.6562	.2881
15	.663	.6964		.7127	.6401	.6401	.3041
16	.6962	.6478		.7459	.6722	.6722	.3201
17	.6962	.6464	.8048	.7956	.7682	.6722	.2721
18	.6962	.7287	.8048	.7956	.7202	.6401	.2561
19	.663	.6802	.7209	.7127	.6401	.6718	.2721
20	.5801	.6344	.663	.6299	.5601		.3041
21	.6299	.6443	.6154	.6371	.6241		.3521
22	.5636	.6001	.5344	.6371	.5601		.3361
23	.547	.5487	.4858	.6203	.5441		.2881
24	.2267	.4973	.5087	.4801	.5533	.5121	.4801
Max	.7459	.7625	.8048	.8785	.8048	.7682	.5121
Min	.208	.4475	.4748	.4161	.4694	.4481	.2561
Avg	.4956	.5903	.5898	.6182	.6011	.5937	.3788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 204 / 11 KV DRAINAJE FEEDER
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.6805	.7716	.7449	.6952	.7537	
2	.3506	.6805	.7545	.7125	.6783	.7186	
3	.3856	.6626	.7202	.6478	.6783	.7186	
4	.3856	.6626	.7373	.583	.6783	.6836	
5	.4207	.6447	.7202	.6154	.6836	.6485	
6	.4207	.6805	.7202	.6154	.6661	.7011	
7	.4908	.8059	.823	.8097	.6836	.8939	
8	.5609	.8954	.905	.7773	.5784	.9465	
9	1.0867	1.0924	1.0974	1.166	1.1919	1.0166	
10	.9602	1.1999		1.0688	1.1393	1.0867	
11	1.0974	1.2536		1.2403	1.0517	1.1744	
12	.9945	1.1999		1.1694	.9991	1.0692	
13	.7042	.7712	.3391	.6556	.7186	.7011	.4031
14	.7969	.8413		.7973	.9114	.7712	.4207
15	.9496	1.0517		1.1517	.964	.9114	.4382
16	1.0513	1.1568		1.1694	1.1218	1.0867	
17	1.0852	1.1568	.78	1.134	1.1919	.9816	.4382
18	1.1191	1.1218	.9156	1.1694	1.1218	.9816	.4207
19	1.0682	1.0517	.9259	1.1163	1.0517	1.0166	.5434
20	.9431	.9602	.9465	1.0099	.9816		.5959
21	1.0924	1.1568	1.0166	.9835	1.0517		.5609
22	.985	.9431	.9114	.9665	.964		.5258
23	.9134	.8916	.8764	.8478	.9114		.4207
24	.362	.8238	.8402	.7773	.7202	.8413	
Max	1.1191	1.2536	1.0974	1.2403	1.1919	1.1744	.5959
Min	.3506	.6447	.3391	.583	.5784	.6485	.4031
Avg	.7739	.9327	.8223	.9137	.8931	.8851	.4768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 205 / BALIRAJA

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3563	.2818	.3978	.3887			
2	.3239	.2818	.3812	.3563			
3	.3239	.2652	.3647	.3887			
4	.3401	.2818	.3647	.3563			
5	.3401	.2818	.3856	.3239			
6	.3401	.2984	.4153	.3563			
7	.3563	.3315	.4153	.3563			
8	.1296						
9				.4049	.3401	.1619	.1296
10				.421			
11				.4475	.2915		
12				.4641	.2753		
13				.4641	.2429		
14				.4475	.2267		
15				.4475	.1943		
16				.4144	.1781		
22	.3315	.431	.3725				
23	.3315	.431	.3725				
24	.3563	.2984	.4527	.3887			
Max	.3563	.431	.4527	.4641	.3401	.1619	.1296
Min	.1296	.2652	.3647	.3239	.1781	.1619	.1296
Avg	.3209	.3183	.3922	.4016	.2498	.1619	.1296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 201 / TAMBE MAL Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.8848			.9945		.9602
2	.4801	.852		1.0364	.9602		.9602
3	.4801	.852		.9831	.9602		.9602
4	.4801	.8848		.9717			.9602
5	.4801	.8848		.9717			.9602
6	.4801	.8848		.9717			1.0288
7	.4801	.9175		1.0486			1.0288
8	.4801	.9175		1.1012			1.0288
9	1.2346	1.3108	1.291		1.4403	1.2193	.7545
10	1.2346	1.3108	1.1736		1.3889	1.2193	.7545
11	1.2003	1.278	1.1149		1.3717	1.2193	.7545
12	1.2003	1.2452	1.1149		1.0288	.9145	.6173
13	1.166	.9831	1.0269		.9602	.9145	.6173
14	1.2003	1.0486	1.0562		1.1317	1.0974	.6173
15	1.2003	1.1797	1.1736		1.2003	1.0974	.583
16	1.2346	1.1797	1.1736		1.2003	1.0974	
17		1.2125	1.1736	1.0688	1.2003	1.0974	
18		1.2407	1.1736	1.153	1.3717		
19		1.1797	1.1736	1.1012	1.3717		
20		1.1142	.9976	1.1488	1.2003	.9145	
21		1.0814	.9976	1.085	1.166	1.0364	
22		1.0486		1.0364	1.0288	.9755	
23		.9922		1.0631	1.0288	.9755	.4458
24	.4801	.8848		1.0364	1.0288		1.0288
Max	1.2346	1.3108	1.291	1.153	1.4403	1.2193	1.0288
Min	.4801	.852	.9976	.9717	.9602	.9145	.4458
Avg	.8231	1.0570	1.1262	1.0518	1.1597	1.0599	.8271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 202 / UTTAM

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	1.0288		.9412	.8916		1.166
2	.8916	1.0288			.8573		1.166
3	.8916	1.0288		.9412	.823		1.166
4	.8916	.9945		.9412	.7545		1.166
5	.8916	.9945		.9412	.8573		1.166
6	.8916	.9945		.9412	.9259		1.166
7	.8916	1.0288		1.0136	1.0288		1.166
8	.8916	1.0974		1.0136	1.1317		1.166
9	1.3032	1.3032	1.262		1.2689	1.4022	1.0288
10	1.3375	1.3375	1.262		1.2346	1.4022	1.0288
11	1.3717	1.2346	1.1218		1.2003	1.3321	1.0288
12	1.2689	1.166	1.0517		1.0288	1.1218	.823
13	1.3032	.9602	1.0517		.7545	1.0517	.7888
14	1.3032	1.0288	.9816		1.0631	1.1919	.7888
15	1.2689	1.0974	1.0517		1.0974	1.1919	.7888
16	1.2689	1.0974	1.0517		1.0974	2.2436	
17	1.2346	1.1317	1.1919	.9717	1.3032	2.4539	
18	1.2346	1.1317	1.1919	1.0288	1.2689	2.5941	
19	1.2346	1.166	1.1919	1.0631	1.2346	2.8746	
20	1.2346	1.166	1.1218	1.0631	1.2346	1.4022	
21	1.2346	1.166	1.0517	1.0974	1.2003	1.4022	
22	1.2346	1.2346		1.0288	1.2003	1.3672	
23	1.2003	1.166		.9602	1.0288	1.3321	.7545
24	.8916	1.0288		.9412	.9259		1.2346
Max	1.3717	1.3375	1.262	1.0974	1.3032	2.8746	1.2346
Min	.8916	.9602	.9816	.9412	.7545	1.0517	.7545
Avg	1.1274	1.1088	1.1218	.9925	1.0588	1.6242	1.0349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 203 / 11 KV CHANDUR ROAD FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	1.7147		1.9204	1.749		2.0576
2	.1715	1.7147		1.9204	1.7147		2.0576
3	.1715	1.6461		1.9204	1.7147		2.0576
4	.1715	1.6461		1.9204	1.7833		2.0576
5	.1715	1.6461		1.9204	1.9204	1.4575	2.0576
6	.1715	1.6461		1.9204	2.0576	1.4899	2.0576
7	.1715	1.5432		1.9204	2.1262	1.6194	1.8861
8	.1715	1.7147		2.0805	2.1948	1.6194	2.0576
9	2.2291	2.4691	.7682		2.2291	2.1052	.3429
10	2.2291	2.4691	.8322		2.2634	1.6575	
11	2.2291	2.4006	2.0805		2.2291	1.326	
12	2.2291	2.3663	1.9204		1.8861	1.9433	.6859
13	2.1605	2.0576	1.6004		1.5432	1.6194	.6859
14	2.1605	2.1948	1.9204		1.6461	1.9433	.7202
15	2.1605	2.0576	1.9204		1.7147	1.9433	.7202
16	2.1605	1.989	1.9204		1.989	1.9433	
17	2.1262	1.8519	1.9204	1.9204	1.989	1.9433	
18	2.1605	1.5775	1.9204	2.1262	2.0233	1.9433	
19	2.1605	1.3717	2.0805	2.0405	2.0233	2.1052	
20	2.1262	1.2346	2.0805	2.1262	2.0233	2.1052	
21	2.1262	1.0974	2.0805	2.0576	1.989	2.1052	
22	1.8176	1.0288		1.9547	1.989	1.9433	
23	1.8176	1.0174		1.8519	1.8861	1.9433	.6859
24	.1715	1.7147		1.9204	1.7833		2.0576
Max	2.2291	2.4691	2.0805	2.1262	2.2634	2.1052	2.0576
Min	.1715	1.0174	.7682	1.8519	1.5432	1.326	.3429
Avg	1.3932	1.7571	1.7727	1.9701	1.9362	1.8293	1.4792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 204 / WATER WORKS

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	1.5432		1.7147	1.6118	1.7238	1.5775
2	.6859	1.5432		1.6461	1.5432	1.6907	1.5089
3	.6859	1.5432		1.6461	1.5089	1.6907	1.5089
4	.6859	1.5775		1.5729	1.4746	1.4918	1.5089
5	.6859	1.5432		1.5729	1.5775	.9945	1.5089
6	.6859	1.5432		1.5729	1.6461	1.4918	1.5089
7	.6859	1.5775		1.5729	1.7147	1.5912	1.5261
8	.6859	1.9547		1.6385	2.1262	1.5912	1.5775
9	1.989	2.1033	1.8351	1.9669	2.1262	1.989	.823
10	1.989	2.1384	1.8679	2.0748	2.1262	1.989	.823
11	2.0233	2.1033	1.9006		2.0576	1.989	.7888
12	1.9547	2.0233	1.8351	1.5089	1.2193	1.4586	.6173
13	1.9204	1.7833	1.6385	1.4403	1.5432	1.326	.6173
14	1.9204	1.989	1.7695	1.6598	1.6118	1.989	.6516
15	1.9547	2.0576	1.7695	1.6975	2.0576	1.989	.6516
16	1.9547	2.0919	1.7695	1.773	2.0576	1.989	
17	1.9547	2.0919	1.7695	1.6385	2.0748	1.9227	
18	1.9547	2.0576	1.7695	1.704	2.0576	1.9227	
19	1.989	1.989	1.7695	1.6712	2.0576	1.8564	
20	1.9547	1.9204	1.704	1.6956	2.0576	1.7901	
21	1.9204	1.8519	1.704	1.6057	1.8861	1.7901	
22	1.7147	1.7833		1.6057	1.8861	1.6575	
23	1.7147	1.7147		1.5729	1.8176	1.5249	.5144
24	.6859	1.5775		1.7147	1.6461	1.757	1.5775
Max	2.0233	2.1384	1.9006	2.0748	2.1262	1.989	1.5775
Min	.6859	1.5432	1.6385	1.4403	1.2193	.9945	.5144
Avg	1.4618	1.8376	1.7771	1.6638	1.8119	1.7169	1.1347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 205 / DKTE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.8954		.823	.8916	.6516	2.6063
2	.8916	.8764		.823	.823	.631	.9602
3	.8916	.823		.823	.7888	.6661	.9602
4	.8916	.823		.823	.7545	.6661	.9602
5	.8916	.823		.823	.7888	.7011	.9602
6	.8916	.823		.823	.8916	.7712	.9602
7	.8916	.8573		.823	.9945	1.0517	1.0288
8	.8916	1.0974		.823	.9602	1.0517	1.0288
9	1.0974	1.0974	1.2696		1.166	1.2269	.9602
10	1.1317	1.0974	1.307		1.2003	1.2269	.8916
11	1.1317	1.0288	.2987		1.2003	1.262	.8916
12	1.0631	1.0288	.9709		1.0974	1.1218	.8916
13	1.0288	.823	1.0456		1.0288	1.0517	.8916
14	1.0631	.8573	1.0456		1.0631	1.0517	.8916
15	1.1317	.9259	.8215		.9602	1.1218	.8916
16	1.1317	.9602	.8215		1.0288	1.1218	
17	1.0974	.9945	1.2696	1.0288	1.0288	1.1218	
18	1.0974	1.0288	1.2696	1.0974	1.0974	1.1584	
19	1.0974	1.0631	1.419	1.0631	1.0974	1.262	
20	1.0974	1.0974	1.2696	1.0974	1.2346	1.1919	
21	1.0974	1.1317	1.1949	1.0974	1.1317	1.1919	.9945
22	1.0974	1.0288		.9831	1.0631	1.1218	1.0288
23	1.0631	1.0288		.9175	1.0288	1.0517	1.0288
24	.8916	.9313		.8916	.8916	.5959	1.0288
Max	1.1317	1.1317	1.419	1.0974	1.2346	1.262	2.6063
Min	.8916	.823	.2987	.823	.7545	.5959	.8916
Avg	1.0188	.9642	1.0772	.9225	1.0088	1.0029	1.0450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 206 / GAON BHAG Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.6554		.7125		.6173	.823
2	.4801	.6859		.6478		.6173	.7545
3	.4801	.6859		.6478		.6173	.7545
4	.4801	.6516		.6478		.6562	.7545
5	.4801	.6226	.6539	.6859		.6481	.7545
6	.4801	.6554	.6836	.724		.7099	.7545
7	.4801	.7209	.7133	.7545		.7716	.7545
8	.4801	.7209	.7727	.7545		.7716	.7545
9	.823	.7209	.9511		1.0288	.9259	.6859
10	.7888	1.0159	.8173		1.0631	.9259	.6859
11	.7888	1.0288	.7727		.9602	.8642	.6859
12	.7545	.9503	.743		.9602	.8025	.6173
13	.7888	.7209	.5944		.9259	.6173	.6173
14	.7888	.7865	.5944		.8916	.6173	.6173
15	.7888	.8192	.6539		.9259	.7407	.6173
16	.7011	.852	.6539		.9259	.7407	
17	.7545	.8916	.7727	.8421	.9259	.8025	
18	.7888	.852	.7727	.9175	.9602	.8025	
19	.823	.8848	.8322	.9393	.9602	.9259	.5144
20	.823	.9175	.8322	.9831	.9602	.9602	.4801
21	.7888	.9831	.8322	.9717	1.0288	.9259	.4801
22	.6859	.852		.9496	.8916	.8642	.4801
23	.6859	.7865		.8478	.7545	.8025	.4458
24	.4801	.6554		.7449		.6481	.8916
Max	.823	1.0288	.9511	.9831	1.0631	.9602	.8916
Min	.4801	.6226	.5944	.6478	.7545	.6173	.4458
Avg	.6622	.7965	.7439	.7982	.9442	.7657	.6630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 207 / 11 KV Ramnagar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7833	2.2291	2.3411	1.9616	1.7833	2.8829	2.6063
2	1.7833	2.2291	2.268	1.7833	1.749	2.809	2.6063
3	1.7833	2.1948	2.2314	1.7833	1.7147	2.809	2.6063
4	1.7833	2.1948	2.1216	1.7833	1.8176	2.809	2.6063
5	1.7833	2.1948	2.1948	1.7833	1.9547	2.5133	2.6063
6	1.7833	2.1948	2.268	1.7833	2.1948	2.7721	2.6063
7	1.9204	2.1948	2.3411	1.9204	2.332	2.9569	2.6749
8	1.9204	2.2634	1.829	2.1125	2.332	2.9569	2.6749
9	2.7435	2.8464	2.0485		3.0178	3.4004	2.7435
10	2.8121	2.8464	1.8656		3.0521	3.4004	2.6063
11	2.8121	2.8121	1.6095		3.155	3.4004	2.2291
12	2.8464	2.7435	1.6095		2.1605	2.5133	2.0576
13	2.6749	2.2291			1.8861		2.0576
14	2.6749		1.3169		1.9547		2.0919
15	2.9321	2.7435	1.4632		3.0864	3.2526	2.0576
16	2.915	2.6749	1.4632		3.0864	3.2526	
17	2.8464	2.6406	1.1706	2.6406		3.2526	
18	2.8464	2.6063	1.1706	2.7161	3.0521	3.2526	
19	2.7435	2.572	1.0242	2.7915	2.7435	3.1047	
20	2.7778	2.572	2.0485	2.5034	2.7435	2.9569	
21	2.7435	2.5377	2.0485	2.6783	2.7435	2.9569	
22	2.4691	2.5377		2.452	2.7435	2.809	
23	2.4691	2.3663		2.2634	2.7435	2.809	1.7833
24	1.7833	2.2291	1.0242	1.9616	1.8519	2.9569	2.6063
Max	2.9321	2.8464	2.3411	2.7915	3.155	3.4004	2.7435
Min	1.7833	2.1948	1.0242	1.7833	1.7147	2.5133	1.7833
Avg	2.4013	2.4632	1.7837	2.1824	2.4304	2.9922	2.4248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 208 / 11 KV KRISHI GANGA

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1619	.192	.1134			
2	.2058	.1619	.218	.12			
3	.2058	.1619	.218	.12			
4	.2058	.1619	.2241	.12			
5	.2058	.1619	.2241	.12			
6	.2058	.1619	.2241	.12			
7	.2058	.1619	.2241	.12			
9					.1715		
10					.1715		
11					.2058		
12					.2058		
13					.1029		
14					.1029		
15					.1029	.032	
16					.1029	.032	
17				.2294			
22	.1715	.1619					.0343
23	.1715	.1943	.112				.0343
24	.2058	.1619	.192	.1147			
Max	.2058	.1943	.2241	.2294	.2058	.032	.0343
Min	.1715	.1619	.112	.1134	.1029	.032	.0343
Avg	.1989	.1651	.2032	.1308	.1458	.032	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 209 / JACKWELL

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0739	.0857	.0857	.0739	.0857
2	.0686	.0686	.0739		.0857	.0739	.0857
3	.0686	.0686	.0739	.0857	.0857	.0739	.0857
4	.0686	.0686	.0739	.0857	.0857	.0739	.0857
5	.0686	.0686	.0739	.0857	.0857	.0739	.0857
6	.0686	.0686	.0739	.1715	.1715	.0739	.0857
7	.0686	.0686	.0739	.1715	.1715	.1848	.1715
8	.0686	.0686	.0739	.1715	.1715	.1848	.1715
9	.0686	.0686	.0739		.1715		.1715
10	.0686	.0686	.1848		.1715		.1715
11	.0686	.0686	.1848		.1715		.1715
12	.0686	.0686	.1848		.1715		.1715
13	.0686	.0686	.1848		.1715		.1715
14	.0686	.0686	.1848		.1715		.1715
15	.0686	.0686	.0739		.1715	.1848	.1715
16	.0686	.0686	.0739		.1715	.1848	
17	.0686	.0686	.0739	.1696	.1715	.1848	
18	.0686	.0686	.0739	.1638	.1715	.1848	
19	.0686	.0686	.0739	.1638	.1715	.1848	
20	.0686	.0686	.0739	.1696	.1715	.1848	
21	.0686	.0686	.1848	.1638	.1715	.1848	
22	.0686	.0686	.1848	.1638	.0686		
23	.0686	.0678	.1848	.1638	.0686		.0686
24	.0686	.0686	.0739	.1619	.1715	.0739	.0857
Max	.0686	.0686	.1848	.1715	.1715	.1848	.1715
Min	.0686	.0678	.0739	.0857	.0686	.0739	.0686
Avg	.0686	.0686	.1109	.1452	.1451	.1363	.1301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 210 / AVENUE SUPER MARKET

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0747	.0373	.0648	.0514	.056	.0514
2	.0343	.0747	.0373	.0328	.0514	.056	.0343
3	.0343	.0373	.0373	.0328	.0514	.056	.0343
4	.0343	.0373	.0373	.0324	.0514	.056	.0343
5	.0343	.0373	.0373	.0324	.0514	.0373	.0343
6	.0343	.0373	.0373	.0343	.0514	.0934	.0343
7	.0343	.0373	.0503	.0514	.0514	.0373	.0343
8	.0343	.0373	.4287	.0686	.0686	.0373	.0343
9	.0686	.056	.0747	.1187	.0686		.0686
10	.0857	.0747	.0747	.1147	.0686		.0686
11	.0857	.0747	.0747	.1147	.0686		.1029
12	.1029	.0934	.112	.1134	.0686		.12
13	.1029	.112	.112	.1147	.0857		.12
14	.1029	.112	.1307	.0983	.0857	.1307	.12
15	.1029	.1307	.1494	.1017	.0857	.112	.12
16	.12	.1494	.1494	.1147	.1543	.112	.12
17		.1494	.168	.1341	.12	.1494	.1372
18		.168	.168	.1311	.12	.1494	
19		.1867	.168	.1311	.1372		.1372
20		.1867	.168	.1311	.1543	.168	.1372
21		.1867	.168	.0983	.1543	.168	.1372
22		.112	.1494	.0819	.0686		.1029
23		.0747	.112	.0678	.0686		.0857
24	.0514	.0747	.056	.0983	.0686	.056	.1029
Max	.12	.1867	.4287	.1341	.1543	.168	.1372
Min	.0343	.0373	.0373	.0324	.0514	.0373	.0343
Avg	.0656	.0965	.1141	.0881	.0836	.0922	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 211 / naikmala

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602		1.643	1.749		1.8442	1.8519
2	.9602		1.643			1.8442	1.8519
3	.9602		1.6095	1.749		1.6766	1.749
4	.9602		1.576	1.749		1.6766	1.749
5	1.0288		1.6095	1.749		1.5089	1.7147
6	1.0288		1.643	1.749	1.8519	1.6766	1.7147
7	1.1317		1.6766	1.7661	1.9547	1.8778	1.7147
8	***		1.6766	1.7833	2.0062	1.9113	1.6975
9	2.1605		1.7436	1.7532	2.0576		1.2003
10	2.2977		1.8442	2.1792	2.1262		1.2003
11	2.2291		1.8945	2.1956	2.0576		1.2003
12	2.2291		1.8442	2.13	1.7147		1.2003
13	2.332		1.5089	2.0317	1.6804		1.0288
14	2.332		1.7101	1.8679	1.6975		1.0288
15	2.3663		1.8442	1.9662	1.9547	2.3807	1.0974
16	2.332		1.9281	2.0317	2.0233	2.3807	
17	2.2977		1.8442	2.1628	1.9204	2.3472	1.1317
18	2.2977		1.7772	2.0972	1.9547		1.166
19	2.2977		1.7772	2.1026	1.989	2.3472	1.166
20	2.3834		1.7436	1.9662	2.0748	2.0119	1.0288
21	3.2579		1.7436	1.8461	2.0576	1.9113	1.0288
22	2.1605		1.7101	1.8023	1.8861		1.0288
23	2.0576	1.8679	1.7101	1.7368	1.8861		1.0288
24	.9602		1.643	1.749		1.8442	1.8861
Max	13.9061	1.8679	1.9281	2.1956	2.1262	2.3807	1.8861
Min	.9602	1.8679	1.5089	1.7368	1.6804	1.5089	1.0288
Avg	2.3720	1.8679	1.7227	1.9093	1.9385	1.9493	1.3680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 212 / MAHADEV NAGAR Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857		.3018	.3761		.2683	.3086
2	.0857		.2683	.3761		.2683	.3086
3	.0857		.2683	.3761		.2683	.3086
4	.1029		.2683	.3521		.2683	.2915
5	.1029		.3018	.394		.2683	.2915
6	.1029		.3353	.394		.2683	.2915
7	.1372		.3688	.394		.3688	.2915
8	.1372		.4024	.4119		.4191	.2743
9	.3944		.4024	.407		.4024	.2743
10	.4115		.4359	.407	.3772	.4024	.2743
11	.3772		.3018	.3277	.3772	.4024	.2401
12	.3772		.3018	.3277	.3429	.2683	.1715
13	.3429		.3018	.3113	.3429	.2515	.1715
14	.3429		.3018	.3277	.3086	.2515	.1715
15	.3429		.3353	.3605	.3086	.3353	.1715
16	.3429		.3353	.3932	.3429	.3353	.1715
17	.3086		.3353	.3932	.0343	.3521	.1715
18	.3258		.3185	.3932	.3429	.3521	.1715
19	.3429		.3185	.3768	.3429	9.9086	.1372
20	.3429		.3185	.39	.3601	.3353	.1372
21	.3086		.3185	.373	.3429	.3506	.1372
22	.3086		.3521	.3605	.3429	.3353	.1372
23	.3086	.2949	.3521	.3277	.3086		.1372
24	.0857		.3018	.3601		.3018	.3086
Max	.4115	.2949	.4359	.4119	.3772	9.9086	.3086
Min	.0857	.2949	.2683	.3113	.0343	.2515	.1372
Avg	.2543	.2949	.3269	.3713	.3196	.7384	.2229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 704 / 33 KV Main VCB TILAWANI SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.0988		10.6745	11.8199	10.5453	11.5684	12.8601
2	7.2017		10.359	11.8199	10.1338	11.5684	12.7572
3	7.2017		10.0435	11.8199	9.8766	11.0425	12.5515
4	7.2017		9.6754	11.214	9.8251	11.0425	12.5515
5	7.2017		10.096	11.7124	10.5453	9.465	12.4486
6	7.2017		10.5167	12.3571	11.5741	9.9909	12.4486
7	7.2017		11.6735	12.4109	12.0885	13.1459	12.4486
8	7.2017		12.3045	12.8944	12.963	14.2501	12.5515
9	13.2716		13.251	14.9177	15.072	16.3009	9.6708
10	13.3745		13.1459	14.9177	15.1749	14.7234	9.5679
11	13.786		11.7787	14.0947	14.9692	15.6173	8.7449
12	12.3457		11.0425	13.0144	12.0371	11.5684	8.2305
13	8.7449		9.2021	10.4938	10.8025	10.5167	7.3045
14	12.6543		11.2003	10.4938	12.3457	14.6182	7.8189
15	13.6831		11.5684	11.9856	13.9918	14.7234	7.9733
16	13.8889		11.6735	12.6029	14.0947	15.8802	
17	13.6317		11.7787	12.8087	14.3004	15.7751	
18	14.1461		11.7787	12.3868	14.6091	16.3981	
19	13.9918		11.7787	12.436	12.8944	14.8811	
20	12.8601		12.0942	12.3377	13.8889		
21	12.8601		12.1994	12.1411	13.1687		
22	12.1399		11.8839	11.6987	11.2483		
23	10.8539	11.621	11.8839	10.8631	10.7911		6.9445
24	7.0988		10.8848	12.6589	10.8539	11.5684	12.8601
Max	14.1461	11.621	13.251	14.9177	15.1749	16.3981	12.8601
Min	7.0988	11.621	9.2021	10.4938	9.8251	9.465	6.9445
Avg	10.7018	11.621	11.3537	12.3292	12.4081	13.2322	10.5725

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 202 / IND EST FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1706	1.2003	1.2071	.7712		1.2003	1.3073
2	1.0974	1.1145	1.2071			1.2003	
3	1.0059	1.1145	1.1706	.7712		1.2003	1.267
4	.9602	1.1145	1.1706	.8063		1.2003	1.2178
5	1.0242	1.1145	1.0974	.815		1.2003	1.2178
6	.9602	1.1145	1.1203	.8505		1.2003	1.2536
7	1.1706	1.1145	1.1203	1.0136		1.2003	1.2757
8	1.4632	1.2003	.8215	1.0867		1.6289	1.3466
9	1.8823	1.7147	.6584	1.8031		1.8004	1.7528
10		1.8004	.6859	1.9281		1.9719	
11		1.9418		1.989	2.0576		1.9418
12	1.6289	1.8671			1.8861		1.7337
13	1.4575	1.4022	.4877		1.4575		1.2689
14		1.7528	.5182	1.6461	1.8004		1.6476
15		1.8229	.6783	2.1125	1.9204	1.989	1.7528
16	1.9719	1.893			1.8004	1.989	1.8229
17	1.8004	1.8229	.631	1.9547	1.8861	1.8861	1.6827
18	1.8004	1.7147	.5258	1.8823	1.8861	1.9204	1.5775
19	1.7147	1.5402	.4999	1.8861	1.7147		1.4022
20	1.3717	1.262	.506	1.4937		1.3523	1.1949
21	1.3717	1.2689	.823			1.3672	1.262
22	1.3032	1.262				1.4175	
23	1.2346	1.262	.7712		1.286		1.2269
24	1.1827	1.2071	1.307	.7628		1.2003	1.3432
Max	1.9719	1.9418	1.307	2.1125	2.0576	1.989	1.9418
Min	.9602	1.1145	.4877	.7628	1.286	1.2003	1.1949
Avg	1.3786	1.4426	.8504	1.3866	1.7695	1.4958	1.4522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 204 / YASHWANT FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6095	1.6289	1.8107	1.0059		1.7194	1.701
2	1.5089	1.5384	1.773	1.0174		1.7194	1.6651
3	1.4403	1.5384	1.6975			1.7194	
4	1.5203	1.5384	1.6975	.9835		1.7194	1.7013
5	1.5364	1.5384	1.5844	1.0174		1.8099	1.7193
6	1.5089	1.4899	1.5844	1.0631		1.8099	1.7193
7	1.6651	1.4899	1.5844	1.0631		1.8099	1.7551
8	1.5089	1.448	1.1203	1.1218		1.9004	1.7193
9	1.8861	1.9004	1.0456	1.5775		1.9004	1.8625
10		1.9909	1.0082	1.7718		2.1719	
11		2.1658		1.848	2.0814		2.3152
12	2.0328	2.1658			2.0814		2.3152
13	1.848	1.8671	.7926		1.8099	2.1357	2.0911
14		2.0911	.8002	1.7924	1.9909	2.1719	2.1285
15		2.1658	.8002	1.9022	2.0814	2.1491	2.2405
16	1.9909	2.1125		1.8823	2.0814	2.2314	2.2405
17	1.9909	2.2634	.9175	1.9616	2.1719	2.1491	2.0538
18	1.9909	2.1658	.8436	1.7833		2.1357	1.8671
19	1.9909	2.0911	.8749	1.9022		1.9547	2.1658
20	1.8099	1.7177	.8749	1.8107		1.9342	2.037
21	1.8099	1.8671	1.0288			1.8267	1.6804
22	1.8099	1.9418					
23	1.7194	1.8671	1.0288		1.9004		1.7551
24	1.5927	1.6289	1.8861	1.0059		1.7194	1.7013
Max	2.0328	2.2634	1.8861	1.9616	2.1719	2.2314	2.3152
Min	1.4403	1.448	.7926	.9835	1.8099	1.7194	1.6651
Avg	1.7385	1.8422	1.2377	1.4728	2.0248	1.9344	1.9254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 205 / IGM FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2698	.9061	1.0288	.9393		.9488	1.153
2	.2652	.8592	.9945	.9069		.9488	1.1145
3	.2561	.8592	.9724			.9488	1.0631
4	.439	.8592	.9389	.8745		.9488	1.0174
5	.4024	.8592	.9602	.8848		.9804	1.0059
6	.2561	.8592	.9602	.8962		.9804	.9945
7	.4207	.8592	1.0974	1.0883		1.0279	1.0277
8	.823	1.0155	1.166	1.1523		1.2334	.9945
9	1.3565	1.406	1.5089	1.4083		1.5181	.9175
10		1.4232	1.4723	1.4083		1.5181	
11		1.4723		1.3748	1.4232		.8048
12	.9259	1.0562			1.4232		.6219
13	.7716	.7042	.7865		.7907	1.004	.5121
14		1.2803	1.1523	1.4937	1.0753	1.2631	.5121
15		1.2803	1.2955	1.6095	1.3441	1.3927	.5853
16	1.1574	1.3443		1.4754	1.4232	1.3927	.6516
17	1.0802	1.2803	1.2803	1.6278	1.4548	1.3279	.5975
18	1.0802	1.2803	1.2803	1.6461	1.4232	1.5043	.4854
19	1.2346	1.2803	1.2334	1.7372	1.4232	1.5546	.5228
20	1.0155	1.0562	1.1702	.7316		1.278	.3963
21	1.1145	1.0364	1.1523				.5853
22	1.0279	1.0364					
23	.9374	.9602	.9717		1.1069		.4854
24	.2058	.9374	1.0288	.9393		.9488	1.1869
Max	1.3565	1.4723	1.5089	1.7372	1.4548	1.5546	1.1869
Min	.2058	.7042	.7865	.7316	.7907	.9488	.3963
Avg	.7520	1.0796	1.1225	1.2330	1.2888	1.1958	.7834

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 206 / 11 K.V BHAJI MARKET
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2774	.8507	.9709	.8688		.815	.8507
2	.2835	.7783	.9709	.8507		.7973	.7964
3	.2469	.7783	.9335			.7973	.7522
4	.2972	.7783	.9335	.7964		.7973	.7522
5	.2715	.7421	.8589	.7964		.8505	.7701
6	.2972	.8145	.8589	.8059		.9391	.8059
7	.4588	.8145	.9335	.8326		.9745	.8059
8	.8139	.9593	1.0456	.9745		1.0985	.8328
9	.9602	1.0498	1.134	1.1517		1.2048	.6024
10		1.086	1.1157	1.2048		1.258	
11		1.0974		1.2308	1.2127		.679
12	.9412	.8779			1.1403		.6348
13	.8326	.8048	.9955		.9922	.9134	.5228
14		.9511	1.0679	.9665	.4784	1.1584	.5228
15		1.0242	1.0566	.9945	.5493	1.0341	.5975
16	.9412	1.0242		1.2127	.6733	1.1041	.6348
17	.9955	1.0608	1.0631	1.2254	1.2048	1.0745	.6348
18	.9955	1.0242	1.0566		1.2403	1.0454	.5975
19	1.0317	1.0608	1.0454	1.307	1.2226	1.1218	.5975
20	.9593	.9877	1.0099	1.073		1.0341	.5868
21	.9774	.9877	1.0136				.7842
22	.9774	.9877					
23	.905	.9877	.9412		1.0454		.7842
24	.2774	.8869	.9877	.905		.8505	.905
Max	1.0317	1.0974	1.134	1.307	1.2403	1.258	.905
Min	.2469	.7421	.8589	.7964	.4784	.7973	.5228
Avg	.6870	.9340	.9996	1.0116	.9759	.9931	.7023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 207 / 11 KV BALAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0892	.506	.583	.4694		.4687	.5365
2	.0762	.4744	.5506	.4578		.4687	
3	.0838	.4744	.5506	.4359		.4687	.4748
4	.1029	.4744	.5506	.4409		.4999	.4748
5	.2801	.4902	.5182	.4578		.4843	.4748
6	.3628	.4843	.5243	.4578		.4999	.4862
7	.221	.4784	.5182	.4578		.4999	.4527
8	.4338	.6173	.5506	.5243		.5937	.503
9	.695	.6173	.583	.6722		.6405	.2883
10		.6249	.5992	.7287		.6401	
11		.6401		.7293	.6562		.2957
12	.4999	.5182			1.0936		.2218
13	.4218	.4999	.4752		.5312	.5256	.1867
14		.6401	.5533	.6203	.5624	.5765	.1867
15	.6249	.6722	.6062	.4973	.6249	.7045	.2614
16	.6718	.6401		.4287	.6249	.6952	.2241
17	.6249	.6722	.6226	.7316	.6562	.5935	.2241
18	.6249	.6478	.5921	.7625	.6405	.6952	.1867
19	.6249	.6722	.5992	.8962	.6874	.703	.1867
20	.5864	.6249	.5506	.5796		.6344	.1844
21	.5401	.6478	.5506				.2241
22	.5401	.6154					
23	.5401	.583	.4696		.5624		.1867
24	.0914	.5218	.5898	.4694		.4843	.5596
Max	.695	.6722	.6226	.8962	1.0936	.7045	.5596
Min	.0762	.4744	.4696	.4287	.5312	.4687	.1844
Avg	.416	.5766	.5569	.5693	.6640	.5725	.3248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 208 / 11 KV JIVESHWAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.208	.7545	.8413	.6733		1.1317	1.1765
2	.2454	.6859	.8326	.6089		1.166	1.1584
3	.5144	.7545	.8413	.6089		1.0631	1.134
4	.4458	.6859	.8413			.9602	1.1222
5	.4755	.6516	.8048	.6447		.9602	1.1462
6	.5792	.6516	.8048	.7011		.8573	1.1694
7	.6219	.7545	.8048	.7011		.8573	.8954
8	1.1222	.9945	.6584	.7282		1.0631	.9922
9	.9717	1.3032	.8413	1.0631		1.0974	.929
10		1.3717	.8063	1.166		1.2003	
11		1.4723		1.4937	1.3717		1.2971
12	.9259	1.2803			1.3032		1.1218
13	1.0288	1.2269	.3944		1.0631		.7796
14		1.3466	.5609	1.2536	1.0288		1.182
15		1.3466	.4908	1.307	1.0288	1.4217	.8764
16	1.2209	1.4022		1.3032	.9602	1.406	.9671
17	1.2209	1.4327	.9465	1.307	1.0288	1.1191	.8954
18	1.0631	1.1104	.8669	.9496	1.0631	1.0867	.7522
19	.8573	.9465	.9465	1.2696	1.0631		.7362
20	1.0631	.9465	.9922	.7827		.9145	.7042
21	1.166	.9465	.964				.7087
22	1.0288	.8764					
23	.8573	.9114	.7011		.9259		.9511
24	.4146	.8573	.9145	.7011		1.2003	1.2308
Max	1.2209	1.4723	.9922	1.4937	1.3717	1.4217	1.2971
Min	.208	.6516	.3944	.6089	.9259	.8573	.7042
Avg	.8015	1.0296	.7927	.9590	1.0837	1.0941	.9966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 201 / 11 KV JANTA TEX.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.3265	3.0178	2.8959	2.9235	3.2065
2		3.3265	3.0178	2.8959	2.894	3.2065
3		3.2341	2.8292	2.8959	2.8292	3.2065
4		3.1417	2.8006	2.8959	2.8292	3.2065
5		3.0493	3.0178	2.8959	3.0178	3.2065
6		3.2341	3.0178	2.8045	3.2065	3.2674
7		3.4189	2.8292	2.8959	3.2674	3.1741
8		3.4189	2.6406	2.9864		2.9235
9		3.4189		3.0769	3.3008	3.3608
10		3.3634		3.0769		3.4541
11		3.3265	1.9909	3.1093		3.3008
12	3.1417	3.3951		3.1093		3.3008
13	2.9938	3.2065		2.9264		3.4517
14	3.2341	3.2065	1.448	3.1093		3.4541
15	3.4541	3.2065	1.8099	3.2922	3.1674	3.4541
16	3.4541	3.1741	1.8099	3.2007	3.1674	3.3608
17	3.3608	3.1741	1.8099	3.1459	3.1674	3.3951
18	3.2674	3.1741	1.8099		3.2579	3.3951
19	3.1741		1.7194		3.1674	3.3951
20	3.2007	3.2065				3.3951
21	3.2922					3.3951
22		3.3008	2.8959			3.2065
23		3.2065	2.8959			
24		3.2922	3.0178	2.8959	2.9235	3.2065
Max	3.4541	3.4189	3.0178	3.2922	3.3008	3.4541
Min	2.9938	3.0493	1.448	2.8045	2.8292	2.9235
Avg	3.2573	3.2637	2.4655	3.0061	3.0800	3.3010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 202 / 11 KV DECCAN PROCESS
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.7435	2.8006	2.5339	2.9235	2.894
2		2.7435	2.8292	2.3529	2.7435	2.8006
3		2.652	2.7349		2.8292	2.8006
4		2.5606	2.7349		2.8292	2.894
5		2.5606	2.8292		2.8292	2.8006
6		2.652	2.8292		2.8292	2.8006
7		2.7435	2.6406		2.8006	2.8006
8		2.8349	2.3577			2.894
9		2.9264			2.9874	2.9874
10		2.963				2.9874
11		2.963	1.6289		3.0769	3.1741
12	2.9235	3.0178		2.652	2.899	2.894
13	2.7349	2.8292		2.5606	2.7149	2.7073
14	2.8006	2.8292	1.448	2.7435	2.7149	2.894
15	2.894	2.9235	1.448	2.8349	2.9864	2.9874
16	2.9874	3.0178	1.448	2.8349	2.9864	2.9874
17	3.0807	3.0178	1.448	2.8349	2.9864	3.0483
18	2.9864	3.0178	1.448		2.9864	2.9531
19	2.8959		1.448		3.0769	2.9531
20	2.9264	2.8292				2.9531
21	2.7435					2.9531
22		2.8292	2.5339			2.9531
23		2.8292	2.5339			
24		2.7435	2.8292	2.5339	2.9235	2.894
Max	3.0807	3.0178	2.8292	2.8349	3.0769	3.1741
Min	2.7349	2.5606	1.448	2.3529	2.7149	2.7073
Avg	2.8973	2.8285	2.2206	2.6535	2.8958	2.9136

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 203 / 11 KV ICH METALLOY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6804	1.6975		1.7918	1.7737
2		1.6804	1.6975		1.6975	1.7737
3		1.6804	1.6975		1.6975	1.7737
4		1.587	1.5089		1.6032	1.7737
5		1.587	1.5089		1.6975	1.7737
6		1.6804	1.5089		1.7918	1.7737
7		1.6804	1.5089		1.8861	1.7737
8		1.6804	1.5089			1.7737
9		1.7737			1.9805	1.7737
10		1.8671		1.9004		1.9605
11		1.8671	1.086	1.9605	1.9909	1.9605
12	1.7918	1.8861	1.086	1.9605	1.9004	1.9605
13	1.7918	1.6975	1.086	1.8671	1.9004	1.7737
14	1.7194	1.6975	.9955	1.9605	1.9004	1.7737
15	1.7194	1.6975	.9955	2.0538	1.9004	1.8671
16	1.7194	1.7918	.905	2.0538	1.9004	1.8671
17	1.8099	1.8861	.905	1.9605	1.9004	1.8861
18	1.8671	1.8861	.905		1.9004	1.7918
19	1.7737		.9955		1.9004	1.7918
20	1.7737	1.6975				1.7918
21	1.6804					1.8861
22		1.5089	1.5384			1.8861
23		1.6975	1.5384			
24		1.6804	1.6975		1.7918	1.7737
Max	1.8671	1.8861	1.6975	2.0538	1.9909	1.9605
Min	1.6804	1.5089	.905	1.8671	1.6032	1.7737
Avg	1.7647	1.7223	1.3185	1.9646	1.8407	1.8232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 204 / 11 SHAHPUR IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0328	1.9805	1.9805	2.0538
2		2.0328	1.8861	1.8861	1.9605
3		2.0328	1.8861	1.8861	2.0538
4		1.9404	1.8861	1.8861	2.0538
5		1.848	1.8861	1.8861	1.9605
6		1.9404	1.8861	1.9805	1.9605
7		2.1253	1.8861	2.0748	2.0538
8		2.1253	1.5089		2.0538
9		2.1253		2.0748	2.0538
10		2.1253			2.2405
11		2.2177	1.1765	2.0814	2.2405
12	2.0328	2.2634	1.267	9.5203	2.2779
13	2.0328	2.0748	1.267	1.9909	2.0538
14	2.1253	2.0748	1.267	1.9909	2.1472
15	2.1253	2.0748	1.267	2.0814	2.2405
16	2.1253	2.0748	1.267	2.0814	2.2405
17	2.0698	2.0748	1.267	2.0814	2.2634
18	2.1253	2.0748	1.267	2.0814	2.2634
19	2.1253		1.267	2.0814	2.2634
20	2.1253	2.0748			2.2634
21	2.0328				2.1691
22		2.0748	1.8099		2.1691
23		2.0748	1.7194		
24		2.0328	1.9805	1.9805	2.0538
Max	2.1253	2.2634	1.9805	9.5203	2.2779
Min	2.0328	1.848	1.1765	1.8861	1.9605
Avg	2.092	2.0689	1.5814	2.4237	2.1344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 207 / 11 K.V AMIT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1691	2.0748		1.8861	2.0748
2		2.1691	2.0748		1.7918	2.0748
3		2.1691	1.8861		1.6975	1.9805
4		1.9805	1.8861	1.448	1.6975	1.9805
5		1.9805	1.9805		1.6975	1.9805
6		2.0748	1.9605		1.6975	1.9805
7		2.1691	1.9605		1.6975	1.9805
8		2.1691	1.6975			1.9805
9		2.2634			1.9805	2.0748
10		2.2634				2.0748
11		2.3577	1.086		1.9909	2.1691
12	2.2405	2.3577	.9955		2.0814	2.2634
13	2.1472	2.2634			2.0814	2.1125
14	2.2634	2.2634	.724			2.1691
15	2.3577	2.1948	.905		2.1719	2.2634
16	2.2634	2.2634	.905		2.0814	2.2634
17	2.2634	2.2634	.905		2.1719	2.2634
18	2.2634	2.1691	.9955		2.0814	2.1691
19	2.2634		.9955		1.9909	2.1691
20	2.2634	2.0748				2.1691
21	2.1691					2.1691
22		2.1691	1.6289			2.1691
23		2.1691	1.5384			
24		2.1691	2.1691		1.8861	2.0748
Max	2.3577	2.3577	2.1691	1.448	2.1719	2.2634
Min	2.1472	1.9805	.724	1.448	1.6975	1.9805
Avg	2.2495	2.1874	1.4931	1.448	1.9225	2.1133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 208 / 11 K.V. TULJABHAVANI
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.9264	3.0178	2.5339	3.3951	3.2674
2		2.9264	3.0178	2.6244	3.2065	3.2674
3		2.7435	2.8292	3.0769	3.2065	3.1741
4		2.652	2.8292	2.5339	3.1741	3.2674
5		2.652	2.6406	2.6244	3.1741	3.2674
6		2.8349	2.6406	2.5339	3.3951	3.1741
7		3.1093	2.452	2.6244	3.3951	3.2674
8		3.2922	2.2634	2.7149		3.2674
9		3.658		3.2579	3.7723	3.3608
10	3.3484	3.658		3.2579		3.5475
11	3.3484	3.7494	1.6289			3.5475
12	3.4541	3.5475	1.3575	3.2236		3.6408
13	3.3608	3.3951	1.3575	3.0445		3.3608
14	3.4751	3.3608	1.267	3.2236		3.4541
15	3.658	3.3608	1.086	3.4027	3.5294	3.4541
16	3.4751	3.5475	1.1765	3.4027	3.5294	3.4541
17	3.658	3.5475	1.1946	3.3131	3.5294	3.4541
18	3.6961	3.5475	1.1946		3.4389	3.4541
19	3.6408		1.1765		3.4389	3.4168
20	3.5475	3.3951				3.4541
21	3.4541					3.3608
22		3.3951	2.6244			3.3608
23		3.3951	2.5339			
24		2.9569	3.2065	2.5339	3.3951	3.2674
Max	3.6961	3.7494	3.2065	3.4027	3.7723	3.6408
Min	3.3484	2.652	1.086	2.5339	3.1741	3.1741
Avg	3.5097	3.2569	2.0747	2.9369	3.3986	3.3713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 209 / 11 K.V YOGASHRAM

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9335	.905	1.086	.905	1.1088
2		.9335	.9145	1.086	.905	1.1088
3		.9335	.9431	1.086	.905	1.1088
4		.7468	.9431	1.086	.905	1.1088
5		.7468	1.086	1.086	1.086	1.1088
6		.7468	1.086	1.086	1.086	1.1088
7		.9335	1.086	1.086	1.086	1.1088
8		1.307	1.0974	1.1765		.7392
9		1.4937		1.448	1.448	.7392
10	1.307	1.4937		1.448		.7392
11	1.307	1.2803	1.448	1.5089		.7392
12	1.0974	1.3203	1.086	1.3203		.7392
13	.7316	1.1203	1.086	.9431		.5544
14	1.1203	1.086	1.086	1.3203		.5544
15	1.307	1.0974	1.267	1.3203	1.448	.5544
16	1.307	1.2936	1.267	1.3203	1.448	.5544
17	1.307	1.4632	1.267	1.3203	1.448	.5658
18	1.2936	1.4632	1.267		1.3575	.5658
19	1.2936		1.267		1.267	.5658
20	1.2936	1.3203				.5658
21	1.1088					.5601
22		1.086	1.086			.5658
23		1.0974	1.086			
24		.9335	.905	1.086	.9431	1.1088
Max	1.307	1.4937	1.448	1.5089	1.448	1.1088
Min	.7316	.7468	.905	.9431	.905	.5544
Avg	1.2062	1.1287	1.1090	1.2119	1.1598	.7901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 210 / 11 KV New Supereme Feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.4272	1.9805	1.7013	2.5463	2.5652
2		2.4272	1.9805	1.7194	2.5463	2.5463
3		2.3339	1.8861	1.7194	2.7349	2.584
4		2.2405	1.7918	1.7375	2.7349	2.5463
5		2.2405	1.7918	1.7737	2.8006	2.5652
6		2.3339	1.7918	1.7556	2.894	2.7726
7		2.4272	1.6975	1.8461	2.9874	2.0748
8		2.7073	1.6975	1.9004		1.9239
9		2.9874		2.4072	2.5206	2.1125
10		3.0807		2.4253		3.1687
11		2.5206	1.448	2.5393		2.5274
12	2.5606	2.5463		2.3339		3.1121
13	1.7375	2.452		2.2405		2.3577
14	2.1033	3.0178	1.1946	2.3339		2.4272
15	2.3777	2.7349	1.1946	2.4272	1.8642	2.452
16	2.3777	2.5463	1.267	2.7073	1.9004	2.4272
17	2.5606	2.452	1.2851	2.8006	1.8823	2.452
18	2.3777	2.452	1.267		1.9004	2.452
19	2.2862		1.2489		2.4615	2.452
20	2.3777	2.3577				2.452
21	2.3777					2.452
22		2.5463	1.6832			2.452
23		2.5463	1.7013			
24		2.4272	2.0538	1.7194	2.3577	2.5463
Max	2.5606	3.0807	2.0538	2.8006	2.9874	3.1687
Min	1.7375	2.2405	1.1946	1.7013	1.8642	1.9239
Avg	2.3137	2.5366	1.6089	2.116	2.4380	2.4966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 211 / 11 KV Mhashoba Mandir Urban/Sheddable Urban Feeder
 Feeder Feeder KV- 11 /
 OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6289	1.7604	1.5746	1.6766	1.7177
2		1.6289	1.6766	1.4842	1.6766	1.6991
3		1.6289	1.7528	1.448	1.5384	1.7177
4		1.5384	1.6651	1.4299	1.6651	1.6991
5		1.5384	1.7194	1.448	1.8099	1.6804
6		1.6289	1.7194	1.448	1.9004	1.6804
7		1.6289	1.7194	1.5746	1.8404	1.6991
8		1.9004	1.8099	1.6651		.7468
9		2.1719		2.4253	2.2634	1.643
10		2.2624		2.4434		1.6244
11		2.3529	1.8099	2.5463		1.587
12	1.8671	2.3577		2.2634		1.4003
13	1.4937	2.0119		2.1691		1.0269
14	1.9805	1.8623	.9774	2.2634		1.2136
15	2.1691	1.9433	1.8642	2.3577	2.3529	1.2136
16	2.1691	2.0957	1.8099	2.452	2.3891	1.2136
17	2.1691	2.0957	1.9004	2.452	2.4434	1.1203
18	2.1472	2.0957	1.8099		2.3167	.9335
19	2.0538		1.7556		2.2805	.9335
20	2.0748	1.9433				.9335
21	1.9605					1.1203
22		1.8442	1.5746			1.1203
23		1.8442	1.5565			
24		1.6289	1.7604	1.5565	1.6766	1.7737
Max	2.1691	2.3577	1.9004	2.5463	2.4434	1.7737
Min	1.4937	1.5384	.9774	1.4299	1.5384	.7468
Avg	2.0085	1.8924	1.7023	1.9445	1.9879	1.3695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 201 / 11 KV KABNOOR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	1.5546	1.7372	1.5708	1.5592	1.7372	1.5546
2	.823	1.5546	1.7372	1.4937	1.5592	1.7372	1.5546
3	.823	1.5708	1.7372	1.4937	1.5592	1.7372	1.5546
4	.823	1.5708	1.7372	1.4937	1.5592	1.7372	1.5708
5	.823	1.5708	1.7372	1.4937	1.5592	1.7741	1.5708
6	.823	1.6632	1.7372	1.4937	1.5592	1.7741	1.5708
7	1.0974	1.6632	1.7372		1.7718	1.848	1.5708
8	1.2003	1.6632	1.7741		1.7718	1.97	1.4146
9	1.7147	1.8804	2.0698		1.9845	2.0058	
10	1.8229	1.8804	1.9631	2.1491	2.1262	2.0416	
11	1.9281	1.8804	1.9982		2.0908		1.0719
12	1.7718	1.8625	1.8604		2.0553		.8871
13	1.3575	1.3432	1.5223		1.4706		.8488
14	1.6461	1.8088	1.6289	1.7147	1.949		.8488
15	1.97	2.0058	1.8604		1.949		.8488
16	1.949	2.0058	1.8204		1.949	1.9281	.8488
17	1.9004	2.0058	1.8404		2.0908	1.949	.8488
18	1.8099	1.9879	1.9004	1.9204	2.1262	1.8804	.8488
19	1.829	2.0199	1.9004	2.0576	2.1262	2.0119	1.0374
20	1.829	2.073	1.9204	1.8861	2.0553	2.0119	1.1317
21	1.848	1.97	1.7375	1.7147	1.9136	1.9204	1.5089
22	1.848	1.7551	1.6804	1.7147	1.7718		1.4712
23	1.6461	1.7193	1.6804	1.7147	1.6655		1.4712
24	.823	1.5546	1.7741	1.5708	1.5592	1.7372	1.6461
Max	1.97	2.073	2.0698	2.1491	2.1262	2.0416	1.6461
Min	.823	1.3432	1.5223	1.4937	1.4706	1.7372	.8488
Avg	1.4554	1.7735	1.7955	1.6988	1.8242	1.8707	1.2582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 202 / CHANDUR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7833	2.6863	3.0803	2.8349	2.774	2.9729	2.8654
2	1.7833	2.6863	3.0445	2.8654	2.774	2.9371	2.8654
3	1.7833	2.6863	3.0445	2.8654	2.774	2.9371	2.8654
4	1.7833	2.6863	3.0445	2.8654	2.774	2.9371	2.8959
5	1.7833	2.6863	3.0445	2.8654	2.774	2.9371	2.8959
6	1.7833	2.6863	3.0445	2.8654	2.774	2.9371	2.8959
7	1.9204	2.6863	3.0445		3.0514	2.9729	2.7149
8	1.9204	2.8654	2.8654		3.0514	3.0864	2.4272
9	3.155	3.4294	3.5818		3.4675	3.3951	
10	3.1901	3.5818	3.4355	3.6008	3.6408	3.4294	
11	3.4675	3.5818	3.493		3.6062		1.7718
12	2.8654	2.9191	3.4294		3.4675		1.4175
13	2.4539	2.5072	3.0121		2.3579		1.358
14	3.155	3.4027	3.155	3.155	3.4675	2.1262	1.4937
15	3.4294	3.6892	3.4675		3.5368		1.4937
16	3.4294	3.6892	3.4294		3.5368	3.4294	1.4937
17	3.2941	3.6534	3.2579		3.5715	3.4675	1.4937
18	3.2941	3.6176	3.155	3.6008	3.5888	3.4675	1.5089
19	3.1207	3.4027	3.1893	3.4294	3.4675	3.5818	1.358
20	3.155	3.1161	3.0445	3.0864	3.086	3.0445	1.4784
21	3.0121	3.152	3.0121	3.4294	3.2247	3.155	2.0328
22	3.0121	3.152	3.0121	3.155	3.1207		2.1253
23	2.8349	3.152	3.0445	2.915	3.0514		2.2177
24	1.7833	2.8654	3.1161	3.0121	2.774	3.0445	2.955
Max	3.4675	3.6892	3.5818	3.6008	3.6408	3.5818	2.955
Min	1.7833	2.5072	2.8654	2.8349	2.3579	2.1262	1.358
Avg	2.6330	3.1075	3.1687	3.1031	3.1547	3.1033	2.1193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 203 / 11 KV COLLAGE FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.7164	.7865	.7087	.5895	.7316	.7164
2	.4115	.7164	.7682	.6268	.5895	.7316	.724
3	.4115	.7164	.7682	.6268	.5636	.7316	.724
4	.4115	.7164	.7682	.6268	.5636	.7316	.724
5	.4115	.7164	.7682	.6268	.5636	.7316	.724
6	.4115	.7164	.7682	.6268	.5636	.7316	.724
7	.4801	.7164	.7682		.7293	.7682	.724
8	.5487	.7087	.8596			.8063	.6468
9	.8097	.9221	1.0387		1.0608	.9816	
10	.8421	.9431	1.0985	.9221	1.0608	.9389	
11	.8907	.9431	.9614		.9945	1.0774	.5281
12	.7545	.8745	.8383		.8951	.763	.4527
13	.6783	.7202	.7545		.663	.6783	.3772
14	.763	.8059	.8383	.7449	.8619	.8288	.3584
15	.8097	.9602	.8907		.8951	.9012	.3584
16	.8192	.9602	.8907		.8951	.9012	.3584
17	.8192	.9259	.8907		.9282	.9012	.3584
18	.9012	.9088	.9116		.9779	.9012	.3772
19	.9221	.8916	.9221	.8288	.9116	.964	.4527
20	.9221	.8916	.9431	.8288	.8619	.8764	.4904
21	.8764	.8573	.8669	.8288	.8288	.8669	.5658
22	.8764	.7888	.8859	.7956	.7625		.5281
23	.7087	.7716	.7973	.7956	.6962		.4904
24	.4115	.7164	.7865	.7164	.5636	.7316	.7087
Max	.9221	.9602	1.0985	.9221	1.0608	1.0774	.724
Min	.4115	.7087	.7545	.6268	.5636	.6783	.3584
Avg	.6793	.8169	.8571	.7360	.7835	.8307	.5506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 205 / DATTA NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	1.0059	1.0923	1.0059	1.0364	1.1191	1.0059
2	.5487	1.0059	1.0749	1.0059	1.0364	1.0852	.9221
3	.5487	1.0059	1.0749	1.0059	1.0364	1.0852	.9221
4	.5487	1.0059	1.0749	1.0059	1.0364	1.0852	.9326
5	.5487	1.0059	1.0749	1.0059	1.0364	1.0852	.9326
6	.5487	1.0059	1.0749	1.0059	1.0364	1.0852	1.0174
7	.6173	1.0059	1.0749		1.1336	1.1361	1.0174
8	.6859	.9945	1.1443		1.1336	1.1736	.9431
9	1.2308	1.2803	1.406		1.2498	1.358	
10	1.2308	1.326	1.4232	1.3603	1.2955	1.358	
11	1.2955	1.326	1.2955		1.4089	1.3765	.7545
12	1.0898	1.094	1.2955		1.2955	1.1336	.6413
13	.8288	.8288	1.0059		.9069	.9012	.5658
14	1.0774	1.1271	1.0774	1.0688	1.2955	1.1336	.6036
15	1.2431	1.2266	1.2003		1.3279	1.2003	.6224
16	1.2146	1.2597	1.2003		1.3279	1.2803	.6036
17	1.2431	1.2597	1.186		1.3279	1.2955	.5658
18	1.2289	1.2929	1.2003			1.2955	.6036
19	1.2431	1.2266	1.2146	1.2955		1.326	.6602
20	1.1603	1.1768	1.2289	1.2955	1.2308	1.2431	.7545
21	1.0898	1.1603	1.1469	1.2742	1.2146	1.2289	.8488
22	1.0898	1.0774	1.1736	1.2071	1.1822		.7922
23	.9945	1.0442	1.1736	1.1401	1.166		.7545
24	.5487	1.0059	1.0923	1.0898	1.0364	1.1869	1.0898
Max	1.2955	1.326	1.4232	1.3603	1.4089	1.3765	1.0898
Min	.5487	.8288	1.0059	1.0059	.9069	.9012	.5658
Avg	.9335	1.1145	1.1669	1.1262	1.1705	1.1896	.7979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 207 / Chandur Kabnur Ag Feeder

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.3193	.0152	.0149	.0152	.0149	.1235	.1562
2	.3963	.0152	.0149	.0152	.0149	.1235	.1524
3	.4458	.0152	.0149	.0152	.0149	.1235	.1524
4	.4458	.0152	.0149	.0152	.0149	.1543	.1524
5	.4458	.0152	.0149	.0152	.0149	.1852	.1829
6	.4458	.0152	.0149	.0152	.0149	.1852	.2134
7	.6173	.0153	.0149		.0149	.216	.2378
8	.0152	.0152	.0149		.0149	.0149	.0149
9	.0152	.6401	.7099		.3704	.0149	
10	.0151	.6173	.7407		.3704	.0149	
11	.0151	.6173	.7202				.0152
12	.0151	.5864	.7202				.0152
13	.0151	.5556	.6325		.2623		.0152
14	.0151	.5247	.6401		.2315		.0152
15	.0149	.5556	.6325		.2315		.0152
16	.0151	.5556	.6401		.1852	.0151	.0152
17	.0149	.0149	.0151		.0149	.0151	.0152
18	.0151	.0149	.0151		.0149	.0152	.0152
19	.0151	.0149	.0149		.0149	.0151	.0152
20	.0151	.0149	.0151		.0149	.0152	.0152
21	.0152	.0149	.0151	.2469	.0149	.0152	.0152
22	.0152	.0149		.216	.1235		.1235
23	.0152	.0149		.0149	.1235		.1235
24	.3963	.0152	.0149	.0151	.0149	.1235	.1562
Max	5.3193	.6401	.7407	.2469	.3704	.216	.2378
Min	.0149	.0149	.0149	.0149	.0149	.0149	.0149
Avg	.3648	.2039	.2566	.0584	.0958	.0806	.0833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 208 / 11 KV Dhuleshwar Nagar
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.5373	.5792	.543	.4694	.5731	.5258
2	.2572	.5373	.543	.4572	.4694	.5731	.5258
3	.2572	.5373	.543	.462	.4694	.5731	.5316
4	.2572	.5373	.543	.462	.4694	.5731	.5316
5	.2572	.5373	.543	.462	.4694	.5731	.5316
6	.2572	.5373	.543	.5487	.4694	.5731	.6201
7	.2743	.5373	.543		.5365	.5731	.6201
8	.3429	.5258	.5792		.5365	.5959	.543
9	.6478	.6859	.6379		.6706	.7011	
10	.7377	.7087	.6447	.6478	.6706	.7011	
11	.6706	.7087	.6024		.6706		.3734
12	.5316	.567	.5373		.6036		.2987
13	.5087	.6201	.5258		.4862		.2829
14	.5935	.6556	.5201	.5506	.5365		.3395
15	.5935	.7087	.5201		.6371		.3772
16	.5935	.7087	.5144		.6539	.6001	
17	.5935	.7087	.5201		.6371	.6001	.3734
18	.6935	.7087	.5316		.6371	.6001	.3395
19	.6935	.6733	.6268	.6478	.6371	.6201	.3018
20	.6068	.6733	.6335	.6478	.6371	.6201	.3395
21	.6135	.6201	.6335	.6036	.6371	.6935	.415
22	.6135	.6024	.6335	.6036	.6036		.415
23	.5316	.5847	.6335	.5365	.583		.415
24	.2572	.5373	.5792	.543	.4694	.5731	.5258
Max	.7377	.7087	.6447	.6478	.6706	.7011	.6201
Min	.2572	.5258	.5144	.4572	.4694	.5731	.2829
Avg	.4850	.6150	.5713	.5511	.5692	.6069	.4393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 201 / 11 KV HANUMANNAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.7621	.8817	.8539	.8383	.8383	.9488
2	.3584	.7621	.8309	.8539	.7926	.8383	.9488
3	.3395	.7621	.7969	.8381	.7468	.8383	.9488
4	.3395	.7621	.8139	.8381	.7773		.9172
5	.3395	.7621	.8817	.8697	.823	.8383	.9014
6	.4338	.7621	.9326	.9172	.884	.8383	.9014
7	.4904	.8535	1.0174	.9962	.9297	.9145	.9962
8	.679	.945	1.1022	1.1227	1.0059	1.1126	.9488
9	1.3392	1.1736	1.2209	1.2809	1.3108	1.2498	.6325
10	1.1431	1.2193	1.2717	1.3283	1.3413	1.2803	
11	1.1431	1.3395		1.4074	1.2955		.5335
12	.9907	1.1361		1.2548	1.1431		.381
13	.7926	1.2378	.8381	1.1361	.945	.933	
14	1.0364	1.2717	1.0279	1.2039	1.1431	1.1069	
15	1.1888	1.3226			1.2955	1.2018	
16	1.1888	1.3565			1.3108		
17	1.1584	1.3565	1.2176		1.3108	1.2967	.4115
18	1.1584	1.3226	1.186	1.3565	1.2498	1.3125	.3353
19	1.1279	1.2717	1.1385	1.3056	1.2193	1.2334	.2896
20	1.0669	1.2209	1.012	1.2039		1.1702	
21	.9907	1.17		1.0364		1.1702	
22	.945	1.0852		1.0212		1.1069	
23	.8383	1.0513	.9172	.945	.9907		.381
24	.3772	.7621	.9326	.8855	.8993	.9145	.9646
Max	1.3392	1.3565	1.2717	1.4074	1.3413	1.3125	.9962
Min	.3395	.7621	.7969	.8381	.7468	.8383	.2896
Avg	.8268	1.0695	1.0011	1.0788	1.0596	1.0629	.7150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 203 / 11 KV SWAMI APPARTMENT

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.381	.373	.39	.4725	.5335	.4748
2	.3018	.381	.3391	.39	.442	.5335	.4748
3	.3018	.381	.3391	.373	.4115	.5335	.4748
4	.2829	.381	.3561	.373	.4115	.5335	.4578
5	.2829	.381	.39	.373	.4268	.5335	.4409
6	.2829	.381	.4239	.407	.4268	.5335	.4578
7	.3395	.4115	.4578	.5087	.4877	.5639	.5426
8	.4527	.5335	.6104	.8987	.6249	.6401	.5256
9	.6602	.7164	.8139		.823	.8383	.4917
10	.6401	.6859	.8139	.9326	.823	.8383	
11	.6401	.7291		.9496	.823		.4268
12	.5487	.5935		.7122	.6859		.3506
13	.3658	.6443	.3052	.5426	.4725	.5087	
14	.4877	.7122	.6274	.6783	.7164	.6443	
15	.5792	.6952		.7969	.7926	.78	
16	.5792	.7461		.8987	.7926		
17	.6097	.7291	.7969	.8817	.8383	.8139	.3353
18	.6097	.7122	.78	.9156	.8383	.8139	.3353
19	.6097	.6613	.7461	.8817	.8383	.8817	.3353
20	.6097	.6274	.6783	.6783		.78	
21	.5335	.6104		.5639		.78	
22	.4877	.5596		.5335		.6783	
23	.4572	.4917	.4917	.5182	.6097		.3048
24	.3206	.381	.407	.4578	.503	.5335	.5087
Max	.6602	.7461	.8139	.9496	.8383	.8817	.5426
Min	.2829	.381	.3052	.373	.4115	.5087	.3048
Avg	.4702	.5636	.5417	.6372	.6314	.6648	.4336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochoi Sub Station

Feeder No / Name : 201 / 11 KV Dhangarmal

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.3841	.4001	.3841	.4801	.3353	.3353
2	.2427	.3841	.3841	.3521	.4961	.3277	.3018
3	.2427	.3521	.3841	.3201	.4961	.2949	.3018
4	.2427	.3521	.3841	.3201	.4481	.2949	.2984
5	.2427	.3637	.3841	.3521	.4481	.2949	.2984
6	.2427	.3637	.4481	.3841	.4481	.3605	.3149
7	.2926	.4111	.5121	.4481	.4481	.426	.3978
8	.3658	.4586	.5121	.5441	.4481	.4588	.4534
9	.5487	.6325	.3841	.6722	.5121	.5243	.4801
10		.6325	.3841	.6081	.5121	.4915	.4801
11		.6009	.5121	.6081	.5441		.4801
12	.4755	.5376	.4161	.5441	.4801		.4424
13	.3292	.3479	.2561		.3429	.2949	.3277
14	.4024	.4428	.4481	.4161	.4115	.3932	.3277
15		.5693	.5441	.4161	.4801	.4915	.3277
16	.5853	.6009	.5121		.5487	.4915	.3277
17	.5853	.5693	.5441		.5487		.3605
18	.567	.5441	.4801	.6413	.5144		.2622
19	.5487	.4801	.4481	.5658			.2949
20	.5121	.4801	.4801	.4961		.3688	.2949
21	.5014	.5121	.4801	.4801		.4694	.3277
22	.5014	.5121	.4801	.5281		.4024	
23	.4161	.4001	.4481	.5281	.4024	.3688	.2622
24	.2427	.4001	.4001	.3841	.5281	.3688	.3353
Max	.5853	.6325	.5441	.6722	.5487	.5243	.4801
Min	.2427	.3479	.2561	.3201	.3429	.2949	.2622
Avg	.3967	.4722	.4428	.4759	.4769	.3925	.3493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station

Feeder No / Name : 203 / 11 KV Ghorpade

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.8676	.9431	.8676	.7922	.8676	.811
2	.9054	.8676	.9431	.8299	.7922	.8299	.7922
3	.8676	.8299	.8299	.8299	.7922	.7922	.7922
4	.8676	.8299	.8299	.7922	.8299	.7922	.7922
5	.8676	.8676	.8676	.7922	.8299	.8299	.7922
6	.9808	.9054	.9054	.8299	.8299	.8299	.8488
7	.9145	.9054	.9054	.9054	.8299	.9054	.9054
8	.9431	.7922	.8676	.9054	.8299	.9054	.9054
9	.9054	.9431	.679	.9808	.8676	.9054	.9054
10		.9054	.679	.9431	.8676	.9808	.9431
11		.9808	.415	.9431	.8299		.9808
12	.9054	.9808	.7167	.8676	.9431		.8299
13	.9054	.8676	.8299		.8676	.9431	.9054
14	.9808	.9808	.8299	.8299	.8676	.8676	.9431
15		.9808	.7922	.9054	.7167	.8676	.9431
16	.9054	.9808	.7167	.8299	.7167	.8299	.9054
17	.9431	.9808	.8676	.9054	.7922		.9054
18	.9808	1.0185	.8299	.9054	.8676		.9054
19	1.0185	1.0185	.7922	.8676			.8676
20	.9054	1.0185	.8676	.8299		.7922	.9054
21	.9431	.9808	.9054	.8488		.8299	
22	.9431	.9431	.9431	.7545		.8299	
23	.9054	.9431	.9054	.7545	.8676	.8299	.8676
24	.9431	.8676	.9431	.8676	.7545	.8676	.8676
Max	1.0185	1.0185	.9431	.9808	.9431	.9808	.9808
Min	.8676	.7922	.415	.7545	.7167	.7922	.7922
Avg	.9256	.9274	.8252	.8603	.8242	.8577	.8779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochoi Sub Station

Feeder No / Name : 204 / 11 KV Chavan

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	2.1125	2.0748	2.037	2.2634	2.037	2.1502
2	1.773	2.0748	2.0748	1.9616	2.2634	2.037	2.1502
3	1.6975	1.9993	2.0748	1.9616	2.2634	1.9616	2.1502
4	1.6975	1.9993	2.0748	1.8861	2.1502	1.8861	2.1502
5	1.6975	1.9993	2.1879	1.8861	2.1502	1.8861	2.1502
6	1.8107	2.037	2.1879	1.9616	2.037	2.037	2.1502
7	1.9616	2.1879	2.2634	2.037	2.1502	2.1125	2.1502
8	1.9993	2.1879	2.2634	2.1125	2.1502	2.1879	2.0748
9	2.2634	2.4897	1.8861	2.3388	2.2634	2.3388	2.0748
10		2.4143	1.8107	2.3388	2.3765	2.4143	2.0748
11		2.5652	1.8861	2.3388	2.4331		2.1125
12	2.1125	2.4143	1.6598		2.4143		2.0182
13	1.8107	2.1125	1.2071		2.1125	2.037	1.8107
14	2.1879	2.3388	1.4335	1.6598	2.2634	2.2634	1.9616
15		2.4143	1.5089	2.3388		2.4897	2.037
16	2.3388	2.3388	1.5089		2.3388	2.3765	1.9616
17	2.4143	2.3388	1.4335		2.2634		1.8107
18	2.3388	2.3011	1.4335	2.2634	2.3388		1.8107
19	2.2634	2.2634	1.4335	2.2634			1.8484
20	2.2634	2.2634	1.9616	2.1502		2.1125	1.8861
21	2.2257	2.2634	2.1125	2.1502		2.1502	
22	2.1879	2.1879	2.037	2.2634		2.1125	
23	2.1502	2.1125	2.1125	2.2634	2.1879	2.1502	1.8107
24	1.8484	2.1125	2.1125	2.037	2.2634	2.1125	2.1502
Max	2.4143	2.5652	2.2634	2.3388	2.4331	2.4897	2.1502
Min	1.6975	1.9993	1.2071	1.6598	2.037	1.8861	1.8107
Avg	2.0406	2.2304	1.8641	2.1125	2.2465	2.1423	2.0225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 201 / 11 kv Chokak Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0663	.0983	.1147	.0829	
2	.0655		.0995	.0983	.0983	.0829	
3	.0655		.1029	.0983	.0983	.0663	
4	.0655		.0995	.0983	.0983	.0663	
5	.0655		.0995	.0983	.0983	.0663	
6			.1326	.1311	.0983	.0663	
7	.0655		.2321	.2622	.2294	.2321	
8	.0819					.0663	
9	.4489					.0829	.2058
10			.0164	.0335			.1658
11							.1658
12	.6718						.1658
13	.7865		.0328				
14							.1658
16	.4096						
17			.0328				
18			.0819				
19			.0819	.0663	.0829		
20		.0829	.0819	.0663	.0829		
21		.0829	.0819	.0663			
22		.1326		.0934		.0076	
23		.1326	.1147	.116	.0829		.0655
24			.1326	.1147	.1147	.0829	
Max	.7865	.1326	.2321	.2622	.2294	.2321	.2058
Min	.0655	.0829	.0164	.0335	.0829	.0076	.0655
Avg	.2726	.1078	.0931	.1030	.109	.0821	.1558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 202 / 11KV Mudshingi Vg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0185	1.0185	1.0456	1.094	1.2696
2	1.0374		1.0185	1.0185	1.0082	1.094	1.1576
3	1.0374		1.0185	1.0185		1.0562	1.1203
4	1.0374		1.0185	1.0185		1.0562	1.1203
5	1.1317		1.094	1.094		1.094	1.3817
6	1.4146		1.358	1.2826	.2614	1.3203	1.531
7	1.5466		1.5466	1.5089	.2614	1.6975	1.6057
8	1.4146		1.3203	1.358	.2241	1.5844	1.7177
9	1.0898		1.3957		.1867	1.6975	1.7924
10			1.2071	1.2289		1.531	1.8107
11				1.358		1.4937	1.773
12	1.1317			1.531	1.7737	1.4563	1.5089
13	1.1317		1.094	.9667	1.5466	1.3817	
14				1.3435	1.5684		1.5089
15				1.358	1.5089	1.2323	
16	1.0829			1.358	1.358	1.307	
17	1.0269		1.2826		1.7353		1.7353
18	1.2323	1.2071	1.5844	1.8484			1.6975
19	1.3817	1.4712	1.5844	1.8861	1.8861		1.6975
20		1.8861	1.7918	1.9616	1.9239	1.7924	2.0748
21		1.8484	1.7918	1.6975		1.8484	1.6787
22		1.6975		1.6032		1.6804	1.6975
23		1.4712	1.1317	1.3203	1.4712	1.531	1.3014
24	1.2826	1.1949	1.1317	1.0616	1.0456	1.3203	1.307
Max	1.5466	1.8861	1.7918	1.9616	1.9239	1.8484	2.0748
Min	1.0269	1.1949	1.0185	.9667	.1867	1.0562	1.1203
Avg	1.1986	1.5395	1.2993	1.3564	1.1753	1.4134	1.5470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 203 / 11 KV HERLE VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3361	.3361	.3772	.3361	.2241
2	.3361		.3361	.3361	.3772	.3361	.1867
3	.3361		.3361	.3361	.3772	.3361	.1867
4	.3361		.3361	.3361	.3395	.3361	.1867
5	.3734		.3734	.3734	.3395	.3734	.2614
6	.5601		.5228	.5601	.3772	.5228	.3361
7	.5975		.5601	.5601	.5658	.5228	.3734
8	.5601		.5601	.5975	.6036	.5601	.4854
9	.503		.4854	.5228	.5281	.4481	.4108
10			.4668	.5228	.4715	.3734	.5228
11				.5601	.4715	.3734	
12	.3361			.5228	.4668	.3734	.3734
13	.3174		.2987		.4294	.3734	
14					.3734	.3734	.3734
15				.4668	.3734	.4481	
16	.4108					.4481	
17	.3734		.4108		.4108		.4108
18	.4481	.4854	.5228	.6722	.5601		.5228
19		.4854	.5975	.6722	.6348		.6722
20		.6722	.6722	.7095	.7095	.6348	.7095
21		.6722	.6348	.6348		.6348	.6348
22		.5601		.5601		.5601	.5601
23		.4481	.4108	.4108	.4108	.3734	.4108
24	.3734	.4108	.3734	.3734	.3772	.3361	.2241
Max	.5975	.6722	.6722	.7095	.7095	.6348	.7095
Min	.3174	.4108	.2987	.3361	.3395	.3361	.1867
Avg	.4187	.5335	.4574	.5032	.4559	.4321	.4033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 204 / 11Kv Halondi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1372	.1341	.1341	.1372	
2	.2683		.1372	.1341		.1372	.1372
3	.2683		.1372	.1341		.1372	
4	.2683		.1372	.1341		.1372	
5	.2683		.1372	.1341	.1341	.1372	
6	.3353		.1372	.1509	.1341	.1372	
7	.503		.1372	.1341	.1341	.1543	
8	.1174		.1372	.1341	.1341	.1543	
9	.132		.6859	.7545	.2683	.1886	
10			.6706	.8048	.1174	.1715	.1029
11				.8215	.2012	.1715	.1029
12	.1174			.4191	.1844	.1715	.1029
13	.1174		1.1065	.3353	.2012	.1715	
14				.3521	.1844	.1372	.0857
15				.285	.1844	.1372	
16	.1006				.1844	.1543	
17	.0133		.1174		.0671		.0671
18	.0133	.1372	.1341	.1372	.1372		.0671
19		.1372	.1341	.1543	.1372		.0838
20		.1543	.1509	.1543	.1543	.0152	.0671
21		.1543	.1509	.1372		.0152	.0671
22		.1543		.1372		.0171	.0838
23		.1543	.1509	.1372	.1372	.1372	.0838
24	.3353	.1715	.1372	.1341	.1341	.1372	.0152
Max	.503	.1715	1.1065	.8215	.2683	.1886	.1372
Min	.0133	.1372	.1174	.1341	.0671	.0152	.0152
Avg	.2042	.1519	.2520	.2661	.1560	.1313	.0820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 205 / 11Kv Rukadi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4115	.2743	.1307	.0857	.0038
2	.0343		.4115	.2743	.12	.0857	.0038
3	.0343		.4115	.2743	.1029	.0857	.0038
4	.0343		.4115	.2743	.1029	.0857	.0038
5	.0343		.4115	.2683	.1715	.0857	.0038
6	.0343		.4458	.3086		.0857	.0038
7	.0343		.5144	.3772	.1715	.1372	.0038
8	.0514		.0514	.0343	.0171	.0343	.0038
9	1.1065		.0514	.0514	.0343	.0343	.1372
10			.0514	.0514	.0343	.0038	.1372
11				.0343	.0343		.1372
12	1.0288			.0343	.0343		.1372
13	.9945		.0343	.0343	.0343	.0038	
14				.0343	.0343	.0038	.1372
15				.0343	.0343	.0038	
16	.8573				.0343	.0038	
17	.0377		.0514		.0343		.0187
18	.0377	.0343	.0343	.0343	.0343		.0171
19		.0343	.0343	.0514	.0343		.0343
20		.0514	.0514	.0514		.0038	.0343
21		.0514	.0514	.0343		.0038	.0343
22		.4458	.3429	.12		.0038	.0343
23		.4115	.3086	.12	.0857	.0038	.0343
24	.0343		.4115	.3086	.12	.0857	.0004
Max	1.1065	.4458	.5144	.3772	.1715	.1372	.1372
Min	.0343	.0343	.0343	.0343	.0171	.0038	.0004
Avg	.311	.1715	.2364	.1400	.0700	.0442	.0440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 201 / 11 KV Nimshirgaon AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0305	.0819	.1219	.0914	.061	.0492
2	.0305	.0305	.0655	.1219	.0914	.061	.0492
3	.0305	.0305	.0655	.1219	.0914	.061	.0492
4	.0305	.0305	.0819	.1219	.0914	.061	.0492
5	.0305	.0305	.1147	.1372	.0914	.061	.0492
6	.0305	.0457	.1475	.1677	.1219	.0762	.0492
7	.0457	.0457	.2458	.2591	.2134	.1829	.0655
8	.0305	.0457	.0328	.0457	.0305	.0457	.0492
9	.3658	.2949		.0457	.0305		.1311
10	.3658	.3277		.0305	.0305	.061	.1524
11	.4115	.3277		.0305	.0457		.1677
12	.3658	.2949	.0457		.0566		.1677
13	.3506	.3605	.0457		.0305		.1524
14	.3201	.3277			.0305		.1219
15		.426			.0305		.0914
16	.2591	.3277			.0305	.0305	.0914
17	.0305	.0328	.0457	.0686	.0305	.0457	.0305
18	.0457	.0328	.0305	.061		.0328	
19	.0305	.0492	.0457	.061			
20	.0305	.0492	.0457	.061		.0492	
21	.0305	.0492	.0457	.061		.0492	
22	.0305	.1311	.1219	.061			
23	.0305	.0983	.1219	.0914	.061		
24	.0305	.0305	.0819	.1219	.0914	.061	.0492
Max	.4115	.426	.2458	.2591	.2134	.1829	.1677
Min	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Avg	.1286	.1437	.0814	.0943	.0679	.0626	.0870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 202 / 11 KV Alate AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1406	.1562	.218	.2187	.1562	.1562	.1174
2	.125	.1562	.2012	.1875	.1562	.1562	.1174
3	.125	.1562	.2012	.1875	.1562	.1562	.1174
4	.125	.125	.2012	.1875	.1562		.1341
5	.1406	.1562	.3018	.2187	.1562		.1677
6	.1562	.1718	.3856	.3437	.1875		.1677
7	.2031	.1875	.57	.7499	.6249		.2012
8	.1718	.1875	.218	.1562	.1875		.2012
9	.8436	.8886		.1372	.1875		
10	.9374	.9724		.1219	.1562		
11	.9374	.8886		.1219	.1562		
12	.8124	.9221	.0625		.125		
13	.8124	.9221	.0312		.125		.5937
14	.7499	1.0059			.125		.4687
15	.8124	.6203			.1094		.4687
16	.7499	.7377			.1448	.125	.5487
17	.1094	.1174		.1219	.1448	.125	.4062
18	.1875	.1006		.1219		.1509	.3437
19	.1875	.1509	.2343	.1524			.1562
20	.2187	.218	.2343	.1829		.218	.2187
21	.2187	.218	.2187	.1875		.218	.2187
22	.1875	.285	.2656	.1875			.1875
23	.1875	.2347	.2343	.1562	.1562		.1875
24	.1406	.1562	.218	.2187	.1562	.1875	.1509
Max	.9374	1.0059	.57	.7499	.6249	.218	.5937
Min	.1094	.1006	.0312	.1219	.1094	.125	.1174
Avg	.3867	.4056	.2372	.2084	.1772	.1659	.2587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 203 / 11 Kv Atigre Vg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.2829	.3206	.2829	.2641	.2829	.3206
2	.3018	.2829	.3018	.2641	.2641	.2829	.3018
3	.3018	.2263	.3018	.2641	.2641	.2829	.3018
4	.3018	.2829	.3018	.2641	.3018	.3395	.3018
5	.3395	.2829	.3206	.2829	.3395	.3395	.3584
6	.3961	.2829	.3584	.3584	.3772	.3772	.415
7	.3961	.3772	.415	.3961	.4527	.415	.4527
8	.3772	.3772	.3206	.3772	.3772	.4338	.4338
9		.3772		.3258	.3772	.3961	.415
10		.3584			.3395	.3772	.3772
11		.3584			.3584	.3584	.3395
12		.3584	.2452		.3395	.3584	.3584
13	.3018		.2075		.3206	.3584	.2641
14	.3206				.3018		.2829
15	.3206				.2829		.3206
16	.3206				.3018	.3018	.3018
17	.3395	.3772	.2263	.3086	.3155	.3395	.2829
18	.3961	.4338	.2829	.3429	.415	.415	.415
19	.415	.4715	.3584	.4801	.4904		.4409
20	.415	.5335	.4527	.4458	.4904	.5093	.4904
21	.415	.4904	.4338	.4527	.4715	.4904	***
22	.3961	.4338		.3772	.415		.4338
23	.3395	.3772	.3395	.3395	.3206		.3584
24	.3206	.3206	.3395	.3018	.3018	.3018	.3206
Max	.415	.5335	.4527	.4801	.4904	.5093	10.1681
Min	.3018	.2263	.2075	.2641	.2641	.2829	.2641
Avg	.3518	.3643	.3251	.3450	.3534	.3663	.7690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029] BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 205 / 11KV Nimshirgaon VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	21-JUL-17
HR	Load (MW)
8	.0492
9	.1311
Max	.1311
Min	.0492
Avg	.0902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 206 / Jathar Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.5242	1.5623	1.5623	1.6766	1.5242	1.6004
2	1.5623	1.5623	1.5242	1.5623	1.7147	1.5242	1.6004
3	1.5623	1.5623	1.5242	1.5242	1.6766	1.6194	1.6004
4	1.5623	1.5242	1.5242	1.6004	1.6385	1.6194	1.6194
5	1.6385	1.5242	1.5623	1.6004	1.6385	1.6766	1.6194
6	1.6766	1.6194	1.5623	1.6385	1.6766	1.7147	1.6385
7	1.6385	1.7147	1.6004	1.7147	1.7147	1.7147	1.6194
8	1.6385	1.6194	1.4861	1.6385	1.6385	1.5242	1.5623
9	1.5623	1.6004		1.2498	1.6766	1.5242	1.6766
10	1.2955	1.6385		1.2955	1.6194	1.5242	1.6004
11	1.6194	1.6194		1.4737	1.6194		1.5242
12	1.6194	1.5623	1.1431		1.5242		1.6194
13	1.5242	1.6194	1.1431		1.5242		1.6194
14	1.5623	1.6004			1.5623		1.6194
15	1.6194	1.5242			1.6766		1.6194
16	1.6194	1.6004			1.6194	1.5813	1.6194
17	1.5242	1.5242	1.2384	1.2803	1.6766	1.6194	1.5242
18	1.6194	1.5623	1.2384	1.2498		1.6194	
19	1.7147	1.6385	1.2384	1.2803			
20	1.7147	1.5242	1.2955	1.2498	1.6766	1.5623	
21	1.6194	1.5623	1.5242	1.6004	1.7147	1.6194	
22	1.7147	1.6004	1.5242	1.6766	1.7147		
23	1.7147	1.6004	1.6004	1.6766	1.5242		
24	1.6004	1.5242	1.5623	1.5242	1.6385	1.6194	1.6194
Max	1.7147	1.7147	1.6004	1.7147	1.7147	1.7147	1.6766
Min	1.2955	1.5242	1.1431	1.2498	1.5242	1.5242	1.5242
Avg	1.6051	1.5813	1.4363	1.4946	1.6428	1.5992	1.6057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 207 / 11KV ALATE VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.2829	.4527	.415	.4904	.3772	.4527
2	.4338	.2829	.4338	.3961	.4904	.3772	.4527
3	.4338	.2829	.4338	.3961	.4904	.3772	.4527
4	.4527	.2829	.4715	.3961	.5281	.4715	.4715
5	.4715	.3772	.5093	.415	.5281	.5658	.5093
6	.5093	.4527	.5281	.4715	.5658	.5658	.547
7	.5281	.4715	.5847	.5093	.5658	.6224	.5658
8	.547	.4715	.4904	.4904	.5281	.5658	.5658
9	.679	.6036		.6173	.679	.6602	.679
10	.6979	.6413			.7733	.7733	.7733
11	.6979	.6224	.0566		.7922	.8488	.8299
12	.679	.6413	.0566		.7545	.7545	.811
13	.547	.4527	.0566		.6979	.6979	.5658
14	.6036	.547			.6602	.6602	
15	.6413	.5281			.7545	.6224	
16	.679				.6224	.679	
17	.6036		.2641	.6516	.6979	.7545	.6036
18	.5093	.5658	.3395	.6859	.7167	.6602	.7167
19	.5093	.5847	.4527	.7202	.6224	.6602	.7167
20	.5281	.6224	.5847	.6173	.6224	.679	
21	.4715	.5847	.5658	.679	.6036	.679	
22	.4527	.547	.5093	.6036	.5658	.5658	
23	.3395	.5093	.4527	.5658	.4715	.4904	
24	.4715	.3395	.4527	.415	.5281	.4338	.4715
Max	.6979	.6413	.5847	.7202	.7922	.8488	.8299
Min	.3395	.2829	.0566	.3961	.4715	.3772	.4527
Avg	.5391	.4861	.4050	.5321	.6146	.6059	.5991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 208 / Laxminagar Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0905	.0754	.0543	.0362	.0724	.0754
2	.0543	.0543	.0754	.0543	.0362	.0724	.0754
3	.0543	.0362	.0754	.0543	.0362	.0724	.0754
4	.0543	.0362	.0754	.0543	.0362	.0724	.0754
5	.0543	.0724	.0754	.0543	.0724	.0724	.0754
6	.0543	.1086	.0754	.0543	.0724	.1086	.0754
7	.0724	.1086	.0943	.0724	.0724	.1086	.0754
8	.0724	.1086	.0943	.0724	.0724	.1086	.0943
9	.0905	.0754		.0686	.0724	.1086	.0754
10	.1086	.0754		.0686	.1086	.1086	.0724
11	.1086	.0754		.0686	.1086		.0724
12	.1086	.0754	.0543		.0724		.0724
13	.1086	.0754	.0724		.0724		.1086
14	.1086	.0754			.0724		.1086
15	.0724	.0754			.0724		.1086
16	.0724				.0724	.0724	.1086
17	.0724		.0724	.0686	.1132	.0905	.0972
18	.1086	.0754	.0724	.0686		.0754	
19	.1086	.0754	.0953	.0686			
20	.1086	.0754	.0905	.0686		.0943	
21	.1086	.0754	.0905	.0724		.0943	
22	.1086	.0754	.0724	.0724			
23	.1086	.0754	.0724	.0362	.0905		
24	.0543	.0905	.0754	.0543	.0362	.0905	.0754
Max	.1086	.1086	.0953	.0724	.1132	.1086	.1086
Min	.0543	.0362	.0543	.0362	.0362	.0724	.0724
Avg	.0845	.0766	.0783	.0624	.0698	.0889	.0845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 201 / 11 KV Hingangaon Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.6371	.0332	.0381	.0335	.0332	.1187
2	.7956	.6371	.0332	.0381	.0335	.0332	.1187
3	.7956	.6371	.0332	.0381	.0335		.1187
4	.7956	.6371	.0332	.0381	.0335	.0332	.1187
5	.7956	.6371	.0332	.0381	.0335	.0332	.1357
6	.7956	.6706	.0332	.0381	.0335	.0332	.1696
7	.8951	.8048	.0332	.0381	.0335	.0332	.1696
8	.0332	.0335	.0332	.0381	.0335	.0332	.0381
9	.0332	.0381	1.2407	1.1603	.8817	.4973	.0381
10		.0381	1.3748	1.1603	.7712	.3978	.0335
11		.0381	1.4754	1.3923	.7042	.3315	.0335
12	.0332	.0381	1.5089	1.3923	.6706		.0335
13	.0332	.0381	1.5424	1.1271	.6371	.2652	.0335
14	.0332	.0381	1.4754	1.094	.6443	.2984	.0335
15		.0381	1.5424	1.094	.5765		.0335
16	.0335	.0381		.9282	.5087	.2984	
17	.0335	.0332	.0381	.0335	.0381	.0381	.0335
18	.0335	.0332	.0381	.0335	.0381	.0381	.0332
19	.0335	.0332	.0381	.0335	.0381	.0381	.0332
20	.0335	.0332	.0381	.0335	.0381	.0381	.0332
21	.0335	.0332	.0381	.0335	.0381	.0381	.0332
22	.7042			.0335	.0381	.1341	.1989
23	.7042		.0381	.0335	.0381	.1174	.1658
24	.8288	.6706	.0332	.0381	.0335	.0332	.1187
Max	.8951	.8048	1.5424	1.3923	.8817	.4973	.1989
Min	.0332	.0332	.0332	.0335	.0335	.0332	.0332
Avg	.3939	.2653	.4858	.4136	.2484	.1332	.0816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 202 / 11 KV Warana Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.0838	.5935	.6104	.2012	.1187	.0503
2	.0848	.0838	.5935	.6104	.1844	.1187	.0503
3	.0848	.0838	.5935	.5765	.1844		.0503
4	.0848	.0838	.5935	.6104	.1844	.0848	.0503
5	.0848	.0838	.5935	.6274	.218	.0848	.0503
6	.0848	.0838	.6443	.6613	.2347	.0848	.0503
7	.0848	.0838	.6443	.78	.3353	.1865	.0503
8	.0848	.0838	.0829	.0838	.0838	.1017	.0503
9	1.1869	1.1191	.0838	.0848	.0838	.1017	.1017
10		1.1869	.0838	.0848	.0838		.1341
11		1.2548	.0838	.0678	.0838		.1677
12	1.17	1.1869	.0838		.0838		.2347
13	.8139	.9326	.0838		.0838	.0339	.1174
14	.9496	.9835	.0838	.0848	.0671	.0339	.1174
15		1.0395	.0829	.0848	.0671	.0339	.1341
16	.8718	.9221		.0848	.0671	.0509	
17	.0838	.0848	.0838	.0838	.0848		.0335
18	.0838	.0848	.0838	.0838	.0848		.0509
19	.0838	.0848	.0838	.0838	.0848		.0509
20	.1006	.1017	.1006	.0838	.0848	.0671	.0509
21	.1006	.1017	.1006	.0838	.0848	.0671	.0509
22	.0838			.2347	.1187	.0671	.0509
23	.0838		.6443	.218	.1187	.0503	.0509
24	.0848	.0838	.6443	.6104	.218	.1187	.0503
Max	1.1869	1.2548	.6443	.78	.3353	.1865	.2347
Min	.0838	.0838	.0829	.0678	.0671	.0339	.0335
Avg	.3036	.4472	.3030	.2970	.1302	.0826	.0782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 203 / 11KV Kumbhoj Gaothan
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4066	.5281	.3696	.3696	.3734	.3696
2	.4108	.3696	.5281	.3292	.3326	.3734	.3326
3	.4108	.3696	.5281	.3292	.3326		.3696
4	.4481	.4066	.5281	.3292	.3696	.3734	.3696
5	.5975	.4435	.5281	.4435	.4435	.4481	.4435
6	.6653	.5914	.6036	.6099	.5544	.5601	.5914
7	.5487	.6283	.6036	.5544	.6283	.6653	.7023
8	.5121	.5175	.6036	.5914	.5914	.5544	.5914
9	.4527	.4024	.5175	.5658	.5487	.4755	.5544
10		.4435	.5175	.5658	.4755	.4024	.4805
11		.4805	.4435	.4527	.4435	.362	.4435
12	.415	.4805	.4066		.4435		.5175
13	.415	.4755	.4066	.4298	.4435	.4298	.4435
14	.415	.439	.3696	.4298	.4435		.4066
15		.4066	.4066	.4298	.4435		.4066
16	.4066	.4024		.4298	.4435	.4298	
17	.5175	.415	.439	.5175	.4435	.4066	.4435
18	.5544	.415	.4805	.5175	.5544	.5544	.4755
19	.6653	.415	.5544	.6653	.6283	.7392	.7316
20	.7392	.7167	.7392	.7392	.6283	.7392	.7023
21	.7023	.7167	.5914	.6283	.6283	.7392	.6348
22	.6283			.5544	.4805		.4481
23	.5544		.4435	.5175	.4066	.4435	.3361
24	.4481	.4805	.7545	.3696	.3696	.4108	.3696
Max	.7392	.7167	.7545	.7392	.6283	.7392	.7316
Min	.4066	.3696	.3696	.3292	.3326	.362	.3326
Avg	.5199	.4737	.5237	.4943	.4769	.4990	.4854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 204 / 11 KV Bahubali Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0497	.0335	.373	.4359	.2347	.1492	.0503
2	.0497	.0335	.373	.4191	.2347	.1326	.0503
3	.0497	.0503	.373	.4191	.2347		.0503
4	.0497	.0503	.373	.4024	.285	.0995	.0503
5	.0497	.0503	.373	.4409	.2347	.0995	.0503
6	.0663	.0503	.39	.4694	.2515	.0995	.0671
7	.0497	.0503	.39	.5197	.3353	.116	.0671
8	.0497	.0503	.0339	.0671	.0671	.0829	.0671
9	.5765	.6783	.0335	.0509	.0671	.0663	.2035
10		.7291	.0335	.0509	.0503		.2347
11		.763	.0335	.0509	.0503		.2683
12	.6952	.7291	.0335		.0503		.2347
13	.6274	.6706	.0335	.0497	.0503	.0497	.1844
14	.6274	.6613	.0335	.0497	.0671	.0497	.218
15		.6371	.0335	.0497	.0503	.0497	.2012
16	.5533	.5365		.0497	.0503	.0497	
17	.0335	.0509	.0335	.0671	.0497	.0503	.0335
18	.0335	.0509	.0503	.0838	.0663	.0503	.0497
19	.0503	.0848	.0671	.0838	.0663	.0503	.0663
20	.0503	.0848	.1006	.0838	.0663	.0671	.0663
21	.0503	.0848	.0838	.0838	.0829	.0671	.0663
22	.0503			.3018	.1658	.0503	.0663
23	.0503		.4578	.2683	.1658	.0503	.0663
24	.0497	.0503	.39	.4578	.2683	.1658	.0503
Max	.6952	.763	.4578	.5197	.3353	.1658	.2683
Min	.0335	.0335	.0335	.0497	.0497	.0497	.0335
Avg	.1839	.2809	.1862	.2154	.1352	.0798	.1071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 205 / 11 KV Narande Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1844	.9945	1.0288	.3353	.3429	.0857
2	.1886	.1844	.9945	.9945	.3353	.3429	.0857
3	.1886	.1844	.9945	.9945	.3353		.0857
4	.1886	.1844	.9945	.9945	.3185	.3429	.0857
5	.1886	.1844	.9945	1.046	.1844	.3429	.0857
6	.1886	.1844	1.046	1.0974	.3185	.3429	.1029
7	.1886	.1677	1.046	1.1317	.5197	.463	.1029
8	.1886	.1677	.1886	.1886	.1677	.1715	.1029
9	***	1.3889	.1677	.1886	.1715	.1715	.2058
10		1.4575	.1677	.1886	.1715		.2347
11		1.4918	.1677	.1715	.1715		.2347
12	1.406	1.4403	.1677		.1715		.218
13	1.3546	1.3717	.1677		.1715	.1029	.1781
14	1.3375	1.3904	.1677	.1715	.1715	.1029	.1844
15		1.3717	.1677	.1715	.1715	.1029	.2012
16	1.0395	1.3375		.1715	.1715	.0857	
17	.1677	.1715	.1715	.1677	.1715	.0857	.0838
18	.1677	.1715	.1886	.1677	.1715	.1029	.0857
19	.1844	.0514	.1886	.1844	.1715	.1029	.1029
20	.1844	.1886	.1844	.1844	.1886	.1029	.1029
21	.1844	.1886	.1886	.1844	.1886	.1029	.1029
22	.1844			.3018	.2743	.0857	.1029
23	.1677		.9665	.3688	.3601	.0857	.0857
24	.1886	.1844	.9774	1.0288	.3688	.3429	.0857
Max	14.9692	1.4918	1.046	1.1317	.5197	.463	.2347
Min	.1677	.0514	.1677	.1677	.1677	.0857	.0838
Avg	1.0974	.6203	.5133	.5058	.2409	.1963	.1281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 206 / 11 KV Kumbhoj AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5967	.5365	.0332	.0381	.0335	.0332	.0339
2	.5967	.5365	.0332	.0381	.0335	.0332	.0339
3	.5967	.5365	.0332	.0381	.0335		.0339
4	.5967	.5365	.0332	.0381	.0335	.0332	.0339
5	.5967	.5365	.0332	.0381	.0335	.0332	.0339
6	.5967	.57	.0332	.0381	.0335	.0332	.0339
7	.663	.6036	.0332	.0381	.0335	.0332	.0339
8	.0332	.0335	.0332	.0381	.0335	.0332	.0381
9	.0332	.0381	.9724	.8288	.57	.3315	.0381
10		.0381	1.0395	.8619	.5765	.3315	.0335
11		.0381	1.073	.9945	.5365		.0335
12	.0332	.0381	1.1065		.5365		.0335
13	.0332	.0381	1.1401	.8951	.4694	.0332	.0335
14	.0332	.0381	1.073	.7956	.503		.0335
15		.0381	1.073	.7625	.5087		.0335
16	.0335	.0381		.663	.5087	.0332	
17	.0335	.0332	.0381	.0335	.0381	.0381	.0335
18	.0335	.0332	.0381	.0335	.0381	.0381	.0332
19	.0335	.0332	.0381	.0335	.0381	.0381	.0332
20	.0335	.0332	.0381	.0335	.0381	.0381	.0332
21	.0335	.0332	.0381	.0335	.0381	.0381	.0332
22	.5365			.0335	.0381		.0332
23	.5365		.0381	.0335	.0381	.0335	.0332
24	.6299	.5365	.0332	.0381	.0335	.0332	.0339
Max	.663	.6036	1.1401	.9945	.5765	.3315	.0381
Min	.0332	.0332	.0332	.0335	.0335	.0332	.0332
Avg	.3006	.2226	.3639	.2773	.1991	.0677	.0340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 207 / 11KV Bahubali-Nej Vg
Feeder KV- 11 / OUTGOING

Gaathan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1294	.1294	.1294	.1294	.1294	.1109
2	.1478	.1294	.1294	.1294	.1294	.1294	.1109
3	.1478	.1294	.1294	.1294	.1174		.1109
4	.1478	.1294	.1294	.1294	.1294	.1294	.1307
5	.1478	.1294	.1294	.1478	.1294	.1478	.1478
6	.1663	.1663	.1663	.1663	.1848	.1848	.1663
7	.1848	.1663	.1663	.1478	.1848	.1848	.2033
8	.1478	.1663	.1663	.1478	.1478	.1478	.1848
9	.1848	.2402	.1478	.1294	.1478	.1109	.1478
10		.1848	.1294	.2218	.1294		.1294
11		.1109	.1294	.2218	.1109		.1294
12	.2033	.1294	.1294		.1294		.2218
13	.1848	.1294	.1109	.1109	.1294	.1109	.1478
14	.1663	.1294	.1294	.1109	.1294	.1848	.1478
15	.2218	.2402	.1294	.1109		.2033	.1478
16	.2033	.2218		.1109		.1478	
17	.2587	.2033	.1109	.1294	.1478		.1663
18	.2587	.2033	.1478	.1478	.1478		.1294
19	.2218		.1663	.1848	.1663		.1848
20	.1848	.1848	.1663	.1848	.1478	.1848	.1848
21	.1663	.1848	.1478	.1663	.1478	.1848	.1848
22	.1478			.1478	.1294	.1663	.1663
23	.1478		.1478	.1478	.1294	.1478	.1478
24	.1478	.1294	.1478	.1478	.1294	.1294	.1294
Max	.2587	.2402	.1663	.2218	.1848	.2033	.2218
Min	.1478	.1109	.1109	.1109	.1109	.1109	.1109
Avg	.1789	.1637	.1403	.1478	.1397	.1544	.1535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 208 / Parshwanath LIS

HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2103	.0175	.1417	.0175		.0177
4	.3506	.2804	.3544	.0701	.0351	.0177
5	.3506	.2804	.3544	.0175	.0351	.0354
6	.4207	.3155	.443	.0175	.0351	.0532
7	.5258	.6661	.6201	.3155	.0876	.0177
8	.7108	.7537	.6024	.3506	.1052	.0177
9	.7186	.7796	.6135	.3544	.0876	.0177
10		.7087	.6135	.1772		.0175
11		.6556	.5784	.0354		.0175
12	.7186	.691		.0354		.0175
13	.7186	.7265	.5258	.0354	.0175	.0175
14	.7011	.7265	.3856	.0354		.0175
15		.691	.3856	.0354		.0175
16	.6661	.7087	.4382	.0354	.0175	
17	.6485	.6661	.4382	.0351	.0177	.0175
18	.6485	.6661	.4733	.0351	.0177	.0175
19		.0526				
Max	.7186	.7796	.6201	.3544	.1052	.0532
Min	.2103	.0175	.1417	.0175	.0175	.0175
Avg	.5684	.5521	.4645	.1002	.0456	.0211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 201 / Tamadalage VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1509	.2058	.1509	.1494	.1715	.1509
2	.1886	.1509	.2058	.1509	.1494	.1543	.1509
3	.1886	.1509	.2058	.1509	.1494	.1543	.1509
4	.1886	.1509	.2058	.1509	.1494	.1543	.1509
5	.2241	.1886	.2058	.1886	.1867	.1715	.1509
6	.2614	.2263	.2229	.2641	.2614	.2229	.2641
7	.2987	.2641	.2229	.3018	.2987	.2401	.3018
8	.2614	.2241	.2229	.2641	.2987	.2743	.3018
9	.2614	.2241	.2058	.2987	.2987	.2401	.2614
10		.2801	.2614	.2987	.2614	.2987	
11		.2801		.2801	.2241		.2241
12	.2241	.2241			.2054		.2614
13	.2054	.1494	.1867		.1867	.1494	.2241
14	.2054	.168		.1867	.168	.1494	.1867
15		.1494		.2241	.1494	.1867	
16	.1867	.168		.2054		.1867	
17	.2614	.132	.168		.1867	.1867	.1867
18	.2241	.2058	.1867	.2241	.2401	.1867	.2713
19	.2987	.3086	.3734	.3734	.3429		.3601
20	.4294	.4287	.4481	.4294	.3601	.4481	.3772
21	.3921	.4115	.4294	.4294	.3429	.4481	
22	.3361	.3429		.3734		.2801	
23	.1886	.2743	.2987	.2987	.2229		.2058
24	.2641	.1509	.2058	.1886	.1867	.1886	.1509
Max	.4294	.4287	.4481	.4294	.3601	.4481	.3772
Min	.1867	.132	.168	.1509	.1494	.1494	.1509
Avg	.2513	.2252	.2479	.2587	.2281	.2246	.2280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 202 / Nimshirgaon Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.0152	.0914	.108	.0949	.0914	.0152
2	.0164	.0152	.0914	.108	.0949	.0914	.0152
3	.0164	.0152	.0914	.108	.0949	.0914	.0152
4	.0164	.0152	.1219	.108	.0949	.0914	.0152
5	.0164	.0152	.1829	.1235	.1265	.0914	.0152
6	.0164	.0152	.2286	.1852	.1581	.1219	.0152
7	.0162	.0152	.2439	.2932	.2372	.1981	.0152
8	.0156	.0152	.0152	.0154	.0158	.0152	.0152
9	.3048	.2896	.0152	.0158	.0158	.0152	.1524
10		.3906	.0158	.0158	.0158	.0158	
11		.2812		.0158	.0158		.1898
12	.3321	.2816			.0158		.1739
13	.3163	.25	.0158		.0158	.0158	.1898
14	.3163	.2187		.0158	.0158	.0158	.1581
15		.2187		.0158	.0158		
16	.2056	.2439		.0158		.0158	
17	.0158	.0162	.0152		.0158	.0158	.0158
18	.0152	.0152	.0154	.0162	.0152	.0152	.0152
19	.0152	.0152	.0154	.0164	.0152		.0152
20		.0152	.0309	.0158	.0152	.0152	.0305
21	.0152	.0305	.0154	.0158	.0152	.0152	
22	.0152	.1219		.1107			
23	.0152	.1067	.1235	.0949	.0914		.0152
24	.0164	.0152	.0914	.108	.0949	.0914	.0152
Max	.3321	.3906	.2439	.2932	.2372	.1981	.1898
Min	.0152	.0152	.0152	.0154	.0152	.0152	.0152
Avg	.0857	.1097	.0789	.0725	.0587	.0569	.0575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 203 / 11 KV Hatkanangale Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.0149	.061	.0446	.0301	.0305	.0149
2	.0164	.0149	.061	.0446	.0301	.0305	.0149
3	.0164	.0149	.061	.0446	.0301	.0305	.0149
4	.0164	.0149	.061	.0446	.0301	.0305	.0149
5	.0162	.0149	.0762	.0446	.0301	.0305	.0149
6	.0156	.0149	.0762	.0594	.0301	.0457	.0149
7	.0156	.0149	.0914	.0743	.0452	.0457	.0149
8	.0156	.0149	.0152	.0149	.0151	.0152	.0149
9	.1067	.104	.0152	.0151		.0152	.0446
10		.1094	.0151	.0151	.0151	.0151	
11		.1094		.0151	.0151		.0602
12	.1054	.1067			.0151		.0452
13		.0926	.0151		.0151	.0151	.0753
14		.0937		.0151	.0151	.0151	.0602
15		.1067		.0151	.0151	.0151	
16	.0903	.1067		.0151		.0151	
17	.0151	.0164	.0149			.0151	.0151
18	.0149	.0152	.0149	.0162	.0152	.0149	.0152
19	.0149	.0152	.0149	.0164	.0152		.0152
20		.0152	.0149		.0305	.0149	.0152
21	.0147	.0152	.0149	.0151	.0305	.0149	
22	.0149	.061		.0301			
23	.0149	.061	.0446	.0301	.0305		.0152
24	.0164	.0149	.061	.0446	.0301	.0305	.0149
Max	.1067	.1094	.0914	.0743	.0452	.0457	.0753
Min	.0147	.0149	.0149	.0149	.0151	.0149	.0149
Avg	.0298	.0484	.0405	.0307	.0242	.0232	.0261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 204 / 11 KV Ganeshnagar

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0514	.0566	.0566	.0857	.0566
2	.0566	.0566	.0514	.0566	.0566	.0686	.0566
3	.0566	.0566	.0514	.0566	.0566	.0686	.0566
4	.0566	.0566	.0514	.0566	.0566	.0686	.0566
5	.056	.0566	.0514	.0566	.0566	.0686	.0566
6	.0747	.0566	.0514	.0566	.0566	.0686	.0566
7	.0747	.0566	.0514	.0566	.0566	.0514	.0566
8	.056	.0566	.0514	.0566	.0754	.0514	.0566
9	.112	.0754	.0857	.0754	.0943	.0514	.0943
10		.0934	.0754	.1509	.1132	.0943	
11				.132	.1132		.1132
12	.1132			.1132	.1132		.1132
13	.0943		.0754		.0943	.1132	.0943
14	.132	.1494		.1132	.1132	.1132	.132
15		.1307		.132	.1132		
16	.1132	.112		.132		.132	
17	.1132	.0754	.0566		.1132	.1132	.1132
18	.0943	.0686	.0566	.0934	.0857	.1886	.1029
19	.0943	.0686	.0754	.0747	.0857		.1029
20		.0686	.0754	.0943	.0857	.1132	.0857
21	.0754	.0686	.0754	.0943	.0857	.0943	
22	.0754	.0686		.0943		.0754	
23	.0754	.0514	.0566	.0754	.0857		.0686
24	.0566	.0566	.0514	.0566	.0566	.0857	.0754
Max	.132	.1494	.0857	.1509	.1132	.1886	.132
Min	.056	.0514	.0514	.0566	.0566	.0514	.0566
Avg	.0819	.0733	.0608	.0857	.0829	.0898	.0815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 201 / 11KV Udagaon

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	1.2384	.788	.5335	.3429	.0162
2	.0762	.0762	1.2574	.7042	.5335	.3429	.016
3	.0762	.0762	1.2574	.6783	.5335	.3239	.0162
4	.0762	.0762	1.2384	.6874	.5335	.3239	.0164
5	.0762	.0762	1.3336	.6874	.5335	.3239	.0175
6	.0762	.0762	1.3717		.6097	.3239	.0177
7	.0762	.0762	1.5242		.6859	.4763	.0187
8	.0762	.0762	.0762		.0762	.0762	.0187
9	2.3624	1.8945		.0762	.0152	.0762	
10		1.989	.0762	.0762	.0162	.0762	
11		1.9547	.0762		.0179		.6097
12	2.4958	1.9033			.0151		.6859
13	2.3243	1.9161			.0152	.0762	.6097
14	2.2862	1.9376		.0762	.0141	.0762	.6859
15		1.6956		.0762	.0154	.0762	.6859
16	1.9814	1.56		.0762			
17	.0762	.0762	.0191	.0762	.0762	.0162	.0762
18	.0762	.0762	.0171	.0762	.0762	.0168	.0762
19	.0762	.0762	.017	.0762	.0762		.0762
20	.0762	.0762	.0175		.0762	.0179	.0762
21	.0762	.0762	.017	.0762	.0762	.0185	.0762
22	.0762	1.2765		.6097	.4001	.017	.0762
23	.0762	1.2765	.8048	.6097	.4191		.0762
24	.0762	.0762	1.2955	.8048	.5335	.4001	.0177
Max	2.4958	1.989	1.5242	.8048	.6859	.4763	.6859
Min	.0762	.0762	.017	.0762	.0141	.0162	.016
Avg	.6033	.7696	.6846	.3680	.2557	.1790	.1888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 202 / 11KV Estate

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.7528	1.7147	.8383	1.6766	1.7147	1.7353
2	1.6004	1.5242	1.6956	.7287	1.6766	1.7147	1.6598
3	1.5623	1.5242	1.6956	.7819	1.5242	1.6956	1.6632
4	1.5242	1.5242	1.7147	.6001	1.4098	1.6956	1.6644
5	1.4861	1.5242	1.6575	.6584	1.3336	1.6766	1.5524
6	1.4861	1.5242	1.0288		1.2193	1.3908	1.4266
7	1.5242	1.1431	1.0288		1.448	1.6956	1.6991
8	1.7147	1.3717	1.2384		1.2955	1.7718	1.5497
9	2.0957	1.7909	1.2193	1.5242	1.848	2.1338	1.9814
10		1.8099	1.2193	1.829	1.8099	2.3815	2.21
11		2.0936	.8383		1.9814		2.0576
12	2.0576	1.9805	.9145		1.8671		2.1338
13	2.4577	1.9239			2.0195	2.1338	2.0576
14	1.9433	1.905	.9145	1.9624	1.905	2.3815	2.2862
15		1.905	.9145	1.9624	1.9814	2.2862	2.2862
16	2.21	2.1313	.9335	2.1148			
17	2.2862	1.9433	.8288	2.0576	2.1338	2.4143	2.21
18	2.0576	2.0195	1.0174	1.6766	1.9433	2.2634	2.1338
19	2.0576	1.2574	.9389	1.7528	1.9052		2.191
20	1.9814	1.9433	.9389	1.9814	1.8861	2.2634	2.0576
21	1.9814	1.829	.8916	1.9052	1.9052	2.0182	2.2481
22	1.9814	1.6956		1.9052	2.0957	2.1719	2.21
23	2.0576	1.848	.8579	1.6766	1.829		2.191
24	2.0005	1.9814	1.8099	.8535	1.6766	1.7528	1.9616
Max	2.4577	2.1313	1.8099	2.1148	2.1338	2.4143	2.2862
Min	1.4861	1.1431	.8288	.6001	1.2193	1.3908	1.4266
Avg	1.8943	1.7478	1.1823	1.4894	1.7553	1.9766	1.9638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 204 / 11KV Mayur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4861	1.3717	1.5432	.7621			1.1888
2	1.4861	1.3717	1.5623	.6481			1.0997
3	1.4861	1.3717	1.5432	.7343			1.0269
4	1.448	1.3717	1.5242	.4999			.9846
5	1.448	1.3717	1.5242	.8025			.9288
6	1.467	1.5242	1.4861				.8833
7	1.5813	1.448	1.6385				1.1248
8	1.5813	1.9052	1.6956				1.587
9	2.2862	1.9959	1.5242		2.7244	2.4387	2.3624
10		2.0911	1.3717	.1143	2.0936	2.2862	2.4387
11	2.21	2.6292			2.7435		3.0483
12	2.4768	2.3577			2.3577		2.5149
13	2.0576	1.905			1.8839		2.1338
14	2.0957	2.7161			2.6863	2.6673	2.7435
15	2.0957	2.5463		2.8959	2.5463	2.3434	2.8578
16	2.6101	2.4897					
17	2.3624	2.4006	1.0117	2.4387	2.5911	2.1765	
18	2.2862	2.2481	.8436	2.4387		2.4897	2.0957
19	2.2862	1.829	.9922	2.21			2.2481
20	1.9052	2.0767	.8951			2.0119	2.4006
21	1.9814	1.5623	.7926	1.6004		1.6478	1.6385
22	1.6004	1.7718				1.4563	
23	1.5242	1.6194	.8488	1.6766			1.6004
24	1.5242	1.5242	1.5623	.703			1.3927
Max	2.6101	2.7161	1.6956	2.8959	2.7435	2.6673	3.0483
Min	1.448	1.3717	.7926	.1143	1.8839	1.4563	.8833
Avg	1.8820	1.8958	1.3153	1.3480	2.4534	2.1686	1.8238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 205 / 11 KV Buvaphan AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	1.3336	1.0364			.0191
2	.0191	.0191	1.4861	.8288			.0191
3	.0191	.0191	1.3146	.8173			.0191
4	.0191	.0191	1.3146	.8025			.0191
5	.0191	.0191	1.4289	.8383			.0191
6	.0191	.0191	1.5813				.0191
7	.0191	.0191	1.829				.0191
8	.0191	.0191	.0191				.0191
9	2.2862	1.9109	.0191	.0191	.0191		.4572
10		2.1956	.0191	.0191	.0191		.381
11	2.4768	2.2447	.0191		.0191		
12	2.1338	2.1956	.0191		.0191		
13		2.1052	.0191		.0191	.0191	
14	1.9052	1.7976	.0191	.0191	.0191	.0191	
15	2.1719	1.6288	.0191	.0191	.0191	.0191	
16	2.1338	1.6484	.0191		.0191		
17	.0191	.0191	.0191		.0191	.0191	
18	.0191	.0191				.0191	.0191
19	.0191	.0191	.0191				.0191
20	.0191	.0191	.0191			.0191	.0191
21	.0191		.0191			.0191	.0191
22	.0191						
23	.0191		1.1873				.0191
24	.0191	.0191	1.3717	1.0974			.0191
Max	2.4768	2.2447	1.829	1.0974	.0191	.0191	.4572
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.6097	.7607	.5952	.5497	.0191	.0191	.0691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 206 / Jogeswari gaonthan

Gaonthan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4572	.4191	.547			.415
2	.4191	.381	.381	.5228			.3772
3	.4191	.381	.381	.3961			.3772
4	.4191	.381	.362	.4338			.415
5	.4572	.381	.381	.4527			.4527
6	.5525	.5335	.5335				.547
7	.5335	.5335	.5716				.6413
8	.5144	.7621	.5525				.6161
9	.6668	.7655	.5335	.9145	.6348	.7811	.7621
10		.7207	.6097	.7049	.6838	.724	.6859
11	.7621	.6468	.6097		.6283		.6859
12	.5906	.5853	.5335		.6283		.4572
13	.4763	.439	.5335		.4481	.4572	.4572
14	.4382	.439	.381	.4572	.4435	.4763	.4572
15	.4382	.3881	.362	.4382	.4251	.4572	.381
16	.4191	.4805			.3881		
17	.4572	.4763	.4251	.4572	.4382	.4251	
18	.4572	.6097	.4755	.5335		.4572	.5335
19	.7621	.6859	.8413	.6097			.8192
20	.9907	.9717	.9795			.9896	1.0669
21	.9526	1.0098	.9522	.9145		.8775	.9717
22	.7621	.7811		.8383		.7733	
23	.6097	.6287	.6602	.4572			.6478
24	.4572	.6097	.5716	.5658			.4715
Max	.9907	1.0098	.9795	.9145	.6838	.9896	1.0669
Min	.4191	.381	.362	.3961	.3881	.4251	.3772
Avg	.5641	.5853	.5477	.5777	.5242	.6419	.5828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 208 / 11 KV Krushna LIS

HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0953	.0762	.1143			.0572
4	.0953	.0762	.0953			.0572
5	.0953	.0953	.0953			.0572
6	.0953	.0953				.0572
7	.0953	.0953				.0572
8	.0953	.0953				.0572
9	.0953	.0995	.1334	.0724	.0572	.0572
10		.1006	.1334	.0734	.0572	.0572
11		.1294		.0724		.0572
12	.1143	.128		.0724		.0572
13	.1143	.128		.0724	.0572	.0572
14	.1143	.1294	.1524	.0724	.0572	.0572
15	.1143	.1294	.1524	.0377	.0572	.0572
16	.1143	.1006	.1524			
17	.1143	.1143	.1334	.0572	.0389	
18	.0953	.0953	.0953		.0372	.0572
Max	.1143	.1294	.1524	.0734	.0572	.0572
Min	.0953	.0762	.0953	.0377	.0372	.0572
Avg	.1034	.1055	.1258	.0663	.0517	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 209 / KULKARNI POWER TOOLS
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	1.105	1.1431	.3658			.9231
2	1.0098	1.105	1.1431	.3334			.8642
3	1.0098	1.0288	1.105	.2286			.7335
4	.9907	.9526	1.105	.1905			.6967
5	.9907	.9526	1.086	.4287			.7775
6	.9907	.9907	.9907				.7716
7	.9907	1.0669	.8954				.8488
8	1.0479	1.0098	.8954				.8619
9	1.3717	1.5123	.9145	1.3336	1.531	1.5813	
10		1.587	.9145	1.5432	1.6598	1.4861	1.5623
11		1.7528	.6859		1.829		1.6766
12	1.848	1.6956	.7621		1.8107		1.848
13	1.2193	1.262			1.3352	1.4289	1.5242
14	1.3336	1.6221		1.7718	1.4901	1.8671	1.9052
15		1.5655		1.6575	1.7164	1.7528	1.7147
16	1.5813	1.773		1.7718		1.7528	
17	1.5242	1.4289	.2427	1.5242	1.4861	1.475	
18	1.3336	1.1812	.2763	1.4861		1.4632	1.6004
19	1.3717	1.2003	.2614	1.5242	1.4098		1.4289
20	1.2384	1.2384	.3292			1.2226	1.2765
21	1.4098	1.1431	.3384	1.2574		1.2012	1.2384
22	1.3336			1.2193		1.4148	
23	1.1812		.381	1.2574			1.467
24	1.1812	1.105	1.2193	.3921			.9665
Max	1.848	1.773	1.2193	1.7718	1.829	1.8671	1.9052
Min	.9907	.9526	.2427	.1905	1.3352	1.2012	.6967
Avg	1.2384	1.2854	.7731	1.0756	1.5853	1.5133	1.2343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 201 / 11KV LIS

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	2.2481	2.2481		.0762	
2		.0953	.3048	2.1719		.0762	
3		.0953	2.2481	2.1338	.0953	.0762	
4		.0953	2.2862	2.0957	.1143	.5716	
5		.1143	2.6101	2.0957	.1715	.0953	
6		.1334	2.6101	2.1719	.2096	.1143	
7		.1334	1.6956	1.6385	.2667	.1143	
8		.1143	.0953	.0953	.0191	.1143	.1143
9	2.5339	3.0864	.0762	.0953	.0191		1.0669
10	2.6673	3.4865	.0572	.0953	.0191		.9145
11	2.6101	3.4675			.8954		
12	2.6292	3.4294		.0762	.0953	.0381	
13	2.5149	2.4768		.0762	.0953	.0762	
14	2.553	2.4768		.0762	.0953		.4763
15		2.2481		.0762	.0953		.5525
16	2.1719	2.1338		.0953	.0953		.6287
17	.0762	.0762	.0953	.0762	.0953	.0762	
18	.0953	.0762	.0953	.0953	.0953	.0572	
19	.1143	.0953	.1334	.1143	.0953	.0953	
20	.1334	***	.1334	.1334	.0953	.1143	
21	.1524	.1334	.1334	.1143	.1334	.1143	
22	.1334	1.5813		.8954	.724	.1143	
23	.1334	1.9052	2.3053	.8573	.724	.0953	
24		.1143	2.2481	2.3053	.8383	.0762	
Max	2.6673	15.3559	2.6101	2.3053	.8954	.5716	1.0669
Min	.0762	.0762	.0572	.0762	.0191	.0381	.1143
Avg	1.3228	1.7925	1.1398	.8623	.2313	.1164	.6255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 202 / 11KV Kothali Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478	.0572	.0572	.0572	.2096	
2		.6478	.0572	.0572	.0572	.2286	
3		.6478	.0572	.0572	.0572	.1905	
4		.6478	.0572	.0762	.0572	.1905	
5		.7049	.0762	.0762	.0572	.2286	
6		.7621	.0762	.0762	.0572	.2286	
7		.7811	.0762	.0762	.0762	.2858	
8		.0572	.0762	.0762	.0572	.0762	.0572
9	.0572	.0572	1.5432	1.5432	.8002		.0572
10	.0572	.0572	1.6385	1.6385	.7621		
11	.0572	.0572		1.6385	.743		
12	.0572	.0381	1.9243		.7621		
13		.0381	1.8671	.743	.6859		
14		.0381		1.105	.6287		.0381
15		.0381		1.1431	.6097		.0381
16	.0381	.0381		1.3336	.5525		.0572
17	.0572	.0381	.0572	.0762	.0762	.0572	
18	.0572	.0381	.0762	.0572	.0762	.0572	
19	.0572	.0381	.0762	.0572	.0762	.0572	
20	.0762		.0762	.0572	.0762	.0572	
21	.0762	.0762	.0762	.0762	.0762	.0762	
22	.7049	.0572		.0572	.0572	.4763	
23	.6668	.0572	.0572	.0572	.0572	.2858	
24		.6668	.0572	.0572	.0572	.2286	
Max	.7049	.7811	1.9243	1.6385	.8002	.4763	.0572
Min	.0381	.0381	.0572	.0572	.0572	.0572	.0381
Avg	.1636	.2709	.4202	.4432	.2739	.1834	.0496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 203 / 11KV Umalwad Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.9145	.7621	.3429	.0191	
2		.0191	.8764	.7621	.3429	.0191	
3		.0191	.8764	.724	.3429	.0191	
4		.0191	.9145	.724	.3429	.0191	
5		.0191	.9145	.724	.362	.0191	
6		.0191	.9526	.7621	.381	.0191	
7		.0191	.9907	.8954	.4954	.0191	
8		.0191	.0191	.0191	.0191	.0191	.0191
9		1.5051	.0191	.0191	.0191		.3239
10		1.5051	.0191	.0191	.0191		.3239
11		1.5432		.0191	.0191		
12		1.4861	.0191	.0191	.0191		
13		1.2955	.0191	.0191	.0191		
14		1.2574		.0191	.0191		.3239
15		1.2574		.0191	.0191		.3048
16	1.448	1.2193		.0191	.0191		.2667
17	.0191	.0191	.0191	.0191	.0191	.0191	
18	.0191	.0191	.0191	.0191	.0191	.0191	
19	.0191	.0191	.0191	.0191	.0191	.0191	
20	.0191	.0191	.0191	.0191	.0191	.0191	
21	.0191	.0191	.0191	.0191	.0191	.0191	
22	.0191	.9907		.381	.2667	.0191	
23	.0191	.9526	.8192	.362	.2667	.0191	
24		.0191	.9145	.8192	.362	.0191	
Max	1.448	1.5432	.9907	.8954	.4954	.0191	.3239
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.1977	.5533	.4402	.2993	.1572	.0191	.2604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 204 / 11KV Danoli Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5623	.1524	.1334	.1143	.7621	
2		1.5623	.1334	.1334	.1143	.7621	
3		1.5623	.1334	.1334	.1143	.724	
4		1.5623	.1524	.1334	.1334	.724	
5		1.5813	.1715	.1524	.1524	.7621	
6		1.9243	.1715	.1905	.1715	.8573	
7		2.5339	.2096	.2286	.1715	1.5051	
8		.1524	.1715	.1905	.1715	.1905	.1715
9	.1334	.1334	3.1055	2.572	2.0576		.1334
10	.1334	.1143	3.3722	2.8769	1.848		
11	.0953	.0191		2.915	1.7909		
12	.1143	.0191	3.1817	2.7435	1.7147		
13		.0191	3.0864	2.6673	1.5623		
14		.1143		2.6673	1.4861		.1143
15		.1143		2.6292	1.467		.0953
16	.0953	.1334		2.1529	1.4098		.0762
17	.1334	.1334	.1143	.1143	.1715	.1143	
18	.1334	.1524	.1334	.1334	.1715	.1524	
19	.1715	.1715	.1905	.1715	.1524	.1334	
20	.1905	.2096	.2096	.1905	.1905	.1524	
21	.1905	.2096	.2096	.1905	.2286	.1905	
22	1.829	.1905		.1334	.1715	.6668	
23	1.7528	.1905	.1524	.1334	.1524	.7621	
24		1.6004	.1524	.1524	.1143	.8002	
Max	1.829	2.5339	3.3722	2.915	2.0576	1.5051	.1715
Min	.0953	.0191	.1143	.1143	.1143	.1143	.0762
Avg	.4144	.6653	.8002	.9891	.6597	.5787	.1181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 205 / 11KV Waranamai

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2384	.4382	.0381	.0381	.1905	
2		1.2193	.0381	.0381	.0381	.1715	
3		1.2193	.0381	.0381	.0381	.1715	
4		1.2193	.0381	.0381	.0381	.1524	
5		1.2384	.0381	.0381	.0381	.1715	
6		1.2955	.0381	.0381	.0381	.1715	
7		1.5051	.0381	.0381	.0381	.3239	
8		.0381	.0381	.0381	.0381	.0381	.0381
9	.0381	.0381	2.1719	2.0767	1.4861		.0572
10	.0381	.0381	2.3053	2.2862	1.3717		.0572
11	.0381	.0381		2.4006	1.3146		
12	.0381	.0381	2.3053	2.0957	1.2955	.4572	
13	.0381	.0381	2.3434	2.2481	1.2003	.4191	
14	.0381	.0381		2.21	.9717		.0381
15		.0381		2.0957	.8954		.0381
16	.0381	.0381		1.9814	.7621		.0381
17	.0381	.0381	.0381	.0381	.0381	.0191	
18	.0381	.0381	.0381	.0381	.0381	.0381	
19	.0381	.0381	.0381	.0381	.0381	.0381	
20	.0381	.0381	.0381	.0381	.0381	.0381	
21	.0572		.0381	.0381	.0381	.0572	
22	1.3717	.0381		.0381	.0381	.2286	
23	1.3336	.0381	.0381	.0381	.0381	.1715	
24		1.2574	.0381	.0381	.0381	.1905	
Max	1.3717	1.5051	2.3434	2.4006	1.4861	.4572	.0572
Min	.0381	.0381	.0381	.0381	.0381	.0191	.0381
Avg	.2273	.4680	.5314	.7502	.4128	.1694	.0445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 206 / 11KV Danoli Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4001	.381	.4191	.3239	.3429	
2		.4001	.3429	.4001	.3239	.3429	
3		.4001	.381	.4001	.3239	.381	
4		.4191	.4191	.4001	.3429	.381	
5		.5335	.4954	.4572	.4191	.4191	
6		.5906	.5335	.5906	.5335	.4572	
7		.5716	.4954	.5906	.5906	.5716	
8		.5144	.4954	.5716	.4382	.5525	.4572
9	.4954	.5335	.362	.4572	.5525		.5144
10	.4572	.5335	.3239	.5335	.5144		.4572
11	.3429	.5525		.4572	.4954		
12	.3429	.5144		.4954	.4954		
13	.4572	.5335	.1905	.4382	.4954		
14		.4763		.4382	.4763		.2667
15		.4763		.4191	.4763		.4001
16	.4572	.4954		.381	.4382		.4191
17	.4954	.4191	.2477	.4954	.5144	.4572	
18	.5144	.4954	.3429	.5335	.6287	.4572	
19	.6287	.5335	.4954	.6097	.6668	.6097	
20	.6478	.6097	.6097	.6478	.6668	.6478	
21	.6287	.4191	.5716	.5906	.5906	.5716	
22	.4954	.3429		.4191	.4763	.5335	
23	.4572	.381	.4572	.381	.4191	.4954	
24		.4191	.4191	.4191	.3048	.3429	
Max	.6478	.6097	.6097	.6478	.6668	.6478	.5144
Min	.3429	.3429	.1905	.381	.3048	.3429	.2667
Avg	.4939	.4819	.4202	.4811	.4795	.4727	.4191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 207 / 11KV Umalwad Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.4191	.4954	.3239	.4191	
2		.4382	.381	.4572	.3239	.381	
3		.4382	.4191	.4572	.3429	3.4865	
4		.4572	.4572	.4572	.3429	.381	
5		.5335	.4954	.5144	.4572	.4954	
6		.6097	.5716	.6287	.5716	.5716	
7		.5716	.5335	.5716	.5906	.5716	
8		.4954	.4954	.5335	.5144	.4572	.4954
9		.4763	.4382	.4572	.4572		.4191
10		.4382	.381	.4191	.4191		.4001
11		.4382		.4191	.4001		
12		.4001		.4572	.381		
13		.4001		.381	.381		
14		.362		.4191	.4191		.3239
15		.362		.381	.4191		.3048
16	.381	.4191		.381	.4001		.3429
17	.4191	.4191	.4954	.4382	.4191	.4572	
18	.4572	.4954	.5144	.5335	.4572	.5335	
19	.5335	.5335	.5716	.6478	.5525	.5716	
20	.6859	.6859	.6668	.6859	.6478	.6097	
21	.6478	.6668	.6478	.5906	.6287	.6097	
22	.5906	.5335		.4572	.5144	.5716	
23	.5144	.4954	.5335	.4001	.4572	.4954	
24		.4572	.4191	.4954	.3429	.4191	
Max	.6859	.6859	.6668	.6859	.6478	3.4865	.4954
Min	.381	.362	.381	.381	.3239	.381	.3048
Avg	.5287	.4827	.4965	.4866	.4485	.6895	.3810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 201 / 11KV RAILWAY

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5041	.5544	.5281	.4805	.462	.5093
2	.4904	.4854	.5359	.6413	.462	.462	.4904
3	.4904	.4854	.5175	.6036	.462	.4435	.4715
4	.4904	.4668	.499	.5658	.462	.4251	.4527
5	.5281	.5041	.5175	.5658	.4805	.462	.4481
6	.6224	.5601	.6099		.5914	.6099	.6348
7	.7207	.6535	.7023		.7207	.7207	.7095
8	.7133	.6468	.7392		.6838	.7392	.7655
9	.7762	.7207	.695	1.2308	.7023	.7023	.7421
10		.7762	.7762		.7762	.8131	.7682
11		.8131		.8507	.8316		.823
12	.8596	.7947		.8688	.8131		.7602
13	.8688	.7207	.7207		.8131	.7783	.823
14	.8145	.6838	.7133	.7682	.7207	.7316	.7316
15	.8145	.6653	.6838	.7682	.6653	.6219	.6878
16	.7602	.6838		.7421	.7023	.6401	.7682
17	.7964	.7023	.7947		.8131	.7964	.724
18		.7207	.8131	.7964	.8501	.7964	.7783
19	.9412	.8316	.8131	.9593	.9795		.9328
20	1.0608	.9795	.961	.9593	.9795	1.0425	1.0242
21	.9412	.961	.924	.8686	.9055	.9145	.9412
22	.8962	.8131		.7392	.7762		.7392
23	.6653	.6838		.6468	.6283		.6283
24	.547	.5281	.5544	.547	.499	.4805	.5228
Max	1.0608	.9795	.961	1.2308	.9795	1.0425	1.0242
Min	.4904	.4668	.499	.5281	.462	.4251	.4481
Avg	.7289	.6827	.6908	.7583	.6999	.6654	.7032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 202 / 11KV PINGARA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4854	.4854	.5093	.3734	.3734	.415
2	.4338	.4481	.4668	.547	.3361	.3734	.3772
3	.4338	.4481	.4481	.5093	.3361	.3361	.3772
4	.4338	.4668	.4854	.5093	.3921	.3361	.3772
5	.4715	.5041	.5041	.547	.5175	.4294	.4108
6	.6036	.4668	.5601		.5601	.5415	.5975
7	.7167	.6161	.7842		.7095	.7282	.5601
8	.6401	.6838	.7842		.7095	.7468	.7468
9	.6722	.7282	.6653	1.5384	.5788	.7392	.5792
10		.6535	.6468		.5601	.7023	.5973
11		.5788		.6697	.5788		.6335
12	.5853	.3734			.5914		.6516
13	.6154	.5228	.5359		.5975	.5359	.5068
14	.6154	.5041	.4755	.543	.4854	.4805	.4163
15	.4887	.5041	.4887	.5068	.5415	.4887	.4887
16	.4706	.4668		.5068	.5228	.4572	.5068
17	.4344	.5041	.2957		.4854	.4525	.4706
18		.5228	.6099	.543	.5415	.5068	.5068
19	.5792	.6348	.6099	.695	.6535		.6401
20	.724	.8402	.7762	.7059	.8029	.7865	.7421
21	.7421	.8215	.7762	.6722	.7655	.7316	.7316
22	.6348	.7655		.6348	.7282		.6838
23	.5601	.6348		.5601	.5415		.4938
24	.4715	.4294	.5041	.4715	.4108	.4108	.4294
Max	.7421	.8402	.7842	1.5384	.8029	.7865	.7468
Min	.4338	.3734	.2957	.4715	.3361	.3361	.3772
Avg	.5609	.5668	.5738	.6276	.5550	.5346	.5392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 203 / 11KV SHAHUNAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4108	.4066	.4527	.3511	.3511	.3772
2	.3772	.3734	.3881	.4904	.3326	.3326	.3584
3	.3772	.3734	.3696	.4527	.3326	.3326	.3395
4	.3961	.3734	.3696	.4527	.3326	.3142	.3395
5	.4338	.4481	.4435	.4251	.4066	.3696	.3734
6	.4904	.4854	.5359		.499	.499	.4854
7	.5729	.5228	.5729		.5544	.5175	.5788
8	.3921	.5729	.5729		.5914	.6099	.5601
9	.4251	.5544	.5729	1.0317	.4805	.5175	.5304
10		.5175	.4435		.4251	.5359	.4706
11		.4805		.4344	.3881		.4024
12	.4706	.4251			.4066		.3841
13	.4525	.4066	.3326		.4066	.3696	.3801
14	.3801	.4066	.3326	.3658	.3511		.3475
15	.3982	.4251	.3258	.362	.3326	.3258	.2926
16	.362	.3696		.3439	.3696	.3292	.3109
17	.4344	.4435	.3511		.4066	.3696	.2896
18		.5359	.4435	.543	.5359	.4344	.3292
19	.5973	.6468	.6099	.6516	.6838		.6584
20	.7682	.7577	.7392	.6516	.7762	.7316	.7499
21	.7133	.7207	.7023	.6468	.7207	.7316	.6878
22	.5914	.6838		.6283	.6283		.5487
23	.5228	.5544		.5544	.4805		.4706
24	.4338	.4481	.4435	.4338	.3696	.3696	.3921
Max	.7682	.7577	.7392	1.0317	.7762	.7316	.7499
Min	.362	.3696	.3258	.3439	.3326	.3142	.2896
Avg	.4755	.4974	.4714	.5248	.4651	.4467	.4441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 201 / 11KV Takawade Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	1.073	.0335	.0335	.0335	.0335	.1829
2	.9297	1.0395	.0335	.0335	.0335	.0335	.1829
3	.9297	1.0395	.0335	.0335	.0335	.0335	.1829
4	.9214	1.0395	.0335	.0335	.0335	.0335	.1524
5	.9783	1.073	.0335	.0335	.0335	.0335	.1829
6	1.0551	1.073	.0335	.0335	.0335	.0335	.1829
7	1.2193	1.1736	.0335	.0335	.0335	.0335	.3201
8	.0213	.0335	.0335	.0267	.0335	.0335	.0305
9	.0213	.0335	1.6766	1.5089	1.073	.3688	.0305
10		.0213	1.6613	1.4754		.4024	
11		.0213		1.4754	.4694		.0198
12	.0335	.0198		1.4083	.4359		.0198
13	.0335	.0198	1.6613	1.4083	.4024	.3353	.0198
14	.0335	.0198	1.5394	1.2071	.4024	.3353	.0198
15	.0335	.0198	1.6309	1.2071		.3353	.0213
16	.0335	.0198		1.1401		.3018	.0198
17	.0335	.0335	.0366		.0335	.032	.0335
18	.0335	.0335	.0335	.0213	.0335	.0335	.0335
19	.0335	.0335	.0335	.0213	.0335	.0229	.0335
20	.0335	.0335		.0213	.0335	.0229	.0335
21	.0335	.0335		.0198	.0335	.0229	.0335
22	1.1401			.0213	.0335	.1555	
23	1.1065		.0335	.0213	.0335	.1829	
24	.9907	1.073	.0335	.0335	.0335	.0335	.2012
Max	1.2193	1.1736	1.6766	1.5089	1.073	.4024	.3201
Min	.0213	.0198	.0335	.0198	.0335	.0229	.0198
Avg	.4822	.4073	.4782	.4892	.1581	.1297	.0922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 202 / Shirdhon, Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0198	.0671	.7377	.7712	.3353	.1006	.0335
2	.0198	.0671	.7377	.8048	.3353	.1006	.0335
3	.0198	.0335	.7377	.8048	.3353	.1006	.0335
4	.0202	.0335	.7377	.7712	.3185	.1006	.0335
5	.0213	.0335	.7377	.7712	.3185	.1006	.0335
6	.0206	.0335	.8048	.7042	.3018	.1006	.0335
7	.0206	.0335	.8048	.7377	.3018	.1006	.0335
8	.0198	.0671	.0335	.0335	.0335	.0335	.0305
9	1.1736	1.0395	.0335	.0343	.0168	.0335	.0335
10		1.1126	.032	.0335		.0335	
11		1.1736		.0335	.0335		.0372
12	1.4083	1.2041		.0335	.0335		.0372
13	1.3413	1.2346	.0297	.0335	.0335		.0251
14	1.3413	1.1888	.0297	.0335	.0335		.0251
15	1.3413	1.1279	.0297	.0335			.0248
16	1.3413	.945		.0335	.0335		.0251
17	.0305	.0335	.0503			.0335	.0335
18		.0335	.0503	.021	.0335	.0335	.0335
19	.0335	.0335	.0671	.0198	.0335	.0335	.0335
20	.064	.0335		.0198	.0335	.0335	.0335
21	.0671	.0335		.0213	.0335	.0335	.0335
22	.0671			.3201	.1341	.0305	
23	.0671		.7042	.3201	.1006	.0335	
24	.0198	.0671	.7712	.7042	.3521	.1006	.0335
Max	1.4083	1.2346	.8048	.8048	.3521	.1006	.0372
Min	.0198	.0335	.0297	.0198	.0168	.0305	.0248
Avg	.4028	.4377	.3961	.3084	.1517	.0632	.0321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 204 / 11KV Shiradhon Takawade
Vlg Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887	.4755	.503	.5121	.503	.4694	.6219
2	.5014	.4755	.503	.5121	.4694	.4694	.5487
3	.4733	.4755	.503	.5121	.4694	.4694	.5487
4	.4508	.5121	.503	.5487	.503	.4694	.5487
5	.4784	.5121	.503	.5487	.5365	.4694	.5853
6	.4961	.5487	.5365	.5487	.57	.5365	.6219
7	.5258	.5487	.5365	.5853	.5533	.5365	.6584
8	.5068	.5121	.503	.5487	.5365	.5365	.6219
9	.5792	.5121	.5365	.5853	.57	.5365	.6219
10		.5083	.543	.57		.5365	
11		.567		.6036			.6154
12	.4694	.4908		.4694	.4694		.5784
13	.4694	.4733	.3258	.4694	.503	.6219	.4908
14	.5121	.4344	.362	.5365	.503	.6219	.443
15	.5121	.5434	.631	.5365	.5365	.6219	.567
16	.5487	.5609		.503	.57	.6584	.4908
17	.5487	.503	.5853		.6036	.695	.4694
18	.5487	.4694	.6584	.6836	.6706	.695	.4694
19	.6584	.5365	.7682	.8326	.7316	.8413	.6706
20	.8048	.6706		.7888	.7316	.8413	.6706
21	.7682	.6706		.7888	.7316	.8413	.6706
22	.7316			.6697	.6584	.6584	
23	.6219		.6219	.6516	.5487	.6219	
24	.4908	.5487	.5365	.5487	.57	.4694	.6219
Max	.8048	.6706	.7682	.8326	.7316	.8413	.6706
Min	.4508	.4344	.3258	.4694	.4694	.4694	.443
Avg	.5539	.5250	.5366	.5893	.5700	.6008	.5779

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 205 / JAMBHALI-TAKWADE LIS

HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3658	.3582	.4024	.0335
4	.3658	.3582	.439	.0335
5	.3658	.3582	.439	.0335
6	.3658	.3582	.439	.0335
7	.3963	.3582	.439	.2683
8	.381	.3224	.439	.3018
9	.3658	.3658	.439	.3018
10		.3269	.4024	
11		.3353	.4024	.0335
12	.4024	.3353	.4024	.0335
13	.4024	.3353	.4024	.2012
14	.439	.3353	.3353	.2012
15	.439	.3353	.3353	.2683
16	.439	.3353	.2683	.3018
17	.4024	.3353		.1006
18	.0732	.1006	.021	.1006
Max	.439	.3658	.439	.3018
Min	.0732	.1006	.021	.0335
Avg	.3717	.3284	.3737	.1498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 206 / JAYHIND-JAWAHAR LIS

HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0572	.08	.08	.0671
4	.1429	.08	.08	.0671
5	.1486	.08	.08	.0838
6	.1677	.08	.08	.0838
7	.1677	.08	.08	.0838
8	.1677	.08	.08	.0838
9	.1372	.1067	.08	.0838
10		.1337	.1006	
11		.1372	.1006	.0335
12	.1341	.1372	.1006	.0335
13	.1341	.1372	.1006	.0503
14	.1219	.1372	.1006	.0503
15	.1219	.1372	.1006	.0503
16	.1524	.1372	.0671	.0671
17	.1524	.1341		.0671
18	.1524	.1341	.1219	.0671
Max	.1677	.1372	.1219	.0838
Min	.0572	.08	.0671	.0335
Avg	.1399	.1132	.0902	.0648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 201 / 11 Kv Shridatt Feeder AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0312	1.2308	1.0056	.3163	.0173	.0156
2	.0332	.0312	1.1523	1.0166		.0175	.0156
3	.0332	.0312	1.1142	.9568	.3163	.0177	.0156
4	.0335	.0312	1.1012	.9671	.3163	.0179	.0156
5	.0332	.0312	1.1437	.9774	.3163	.0181	.0156
6	.0328	.0312	1.1142	1.0242	.3163	.0183	.0156
7	.0335	.0312	1.1142	1.1088	.3479	.0185	.0156
8	.0332	.0312	.0339	.056	.0316		.0156
9	2.1376	1.6248	.032	.0377	.0316	.0189	.0156
10	2.1247	1.9608			.0316	.0171	
11	2.1247	2.0241		.0324	.0316		.0166
12	2.1247	2.0622			.0351		
13	2.2024	1.9433	.0312	.0316		.0158	.0324
14	2.0873	1.8747	.0358	.0316			.0332
15		1.8747	.0362	.0312			.0332
16	1.8976	1.9989		.0316			.032
17	.0309	.0663	.037				.0164
18	.0309	.0335	.0373	.0312			.0166
19	.0312	.0332	.0566	.0312		.0156	.0335
20	.0312	.0332	.0514	.0312	.0171	.0156	.0332
21	.0312	.0335	.052	.0316	.0173	.0156	
22	.0312	1.3592	1.0692	.3163		.0156	.0332
23	.0312	1.326	1.0631	.3277	.0177	.0156	.0335
24	.0332	.0312	1.326	.9945	.3163	.0171	.0156
Max	2.2024	2.0622	1.326	1.1088	.3479	.0189	.0335
Min	.0309	.0312	.0312	.0312	.0171	.0156	.0156
Avg	.6616	.7721	.5916	.4320	.1640	.0170	.0224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 202 / 11 kv Bastwad feeder AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0497	1.8679	1.3696	.4858	.1214	.0497
2	.0332	.0497	1.8461	1.3847	.4801	.1227	.0497
3	.0324	.0497	1.8138	1.3466	.4801	.1417	.0497
4	.0332	.0497	1.8842	1.3611	.4801	.1791	.0497
5	.0335	.0497	1.9227	1.4118	.4858	.1991	.0497
6	.0328	.0497	1.9498	1.4998	.5506	.2195	.0497
7	.0328	.0497	2.0325	1.5708	.5921	.3142	.0497
8	.032	.0497	.0497		.048	.0373	.0497
9	2.4966	2.5888	.048		.0486	.0377	.2321
10		2.7035			.048		
11		2.6566		.0492	.0486		.1658
12	2.7328	2.7041			.032		.1823
13	2.6825	2.5459			.0486	.0492	.1677
14	2.7664	2.4827	.0537	.0492	.0486		.1638
15		2.4827	.0543		.0492		.1677
16	2.5101	2.4777			.0469	.0492	.1823
17		.048	.0554		.0492	.0486	.0328
18	.0497	.0497	.056	.0497	.056	.0497	.0328
19	.0497	.0486	.0566	.0497	.0377	.0497	.0328
20	.0497	.0497	.0514	.0497	.0343	.0497	.0332
21	.0497	.0497	.052	.0486	.0347	.0497	.0324
22	.0497	1.8884	1.4723	.4902		.0497	.0328
23	.0497	1.8564	1.4529	.4687	.1595	.0497	.0335
24	.0335	.0497	1.8564	1.3717	.4744	.1372	.0497
Max	2.7664	2.7041	2.0325	1.5708	.5921	.3142	.2321
Min	.032	.048	.048	.0486	.032	.0373	.0324
Avg	.6892	1.0450	.9777	.7857	.2095	.1029	.0843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 203 / HERWAD VILLEGE

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2801	.2035		.2241	.156	.2241
2	.2103	.2614	.2058		.2054	.1578	.2241
3	.2195	.2614	.2103		.1991	.1772	.2241
4	.2561	.2614	.2303		.2195	.2328	.2614
5	.2865	.2801	.2543		.2378	.2534	.2987
6	.3366	.3361	.2804	.3292	.3109	.2926	.3361
7	.3155	.3734	.3258	.4066	.3658	.3696	.3547
8	.3012	.3547	.3721	.3547	.3292	.4294	.3361
9	.3012	.3547	.3045	.3395	.3292	.3395	.3174
10		.3292			.2926	.2915	
11		.3258		.2926	.2743		.2481
12	.2801	.2957					.2601
13	.2241	.2054		.2658	.1829	.3361	.2835
14	.2012	.2987	.2149	.2427	.2195		.2507
15		.2926	.2172		.2534		.2507
16	.2772	.3326			.2743	.2614	.2629
17	.3326	.3189	.2772		.3258	.2561	.2454
18	.3696	.3544	.3361	.3696	.4481	.3142	.2926
19	.4435	.3681	.3772	.4066	.4527	.3921	.3761
20	.4854	.394	.3772	.4108	.3944	.3734	.4207
21	.4481	.3681	.3641	.3681	.3641	.4108	.3841
22	.3921	.3222	.3155	.3012		.3361	.3475
23	.3174	.2374	.2835	.2303	.2126	.2801	
24	.2279	.2801	.2321		.2427	.1715	.2427
Max	.4854	.394	.3772	.4108	.4527	.4294	.4207
Min	.2012	.2054	.2035	.2303	.1829	.156	.2241
Avg	.3069	.3119	.2833	.3321	.2890	.2916	.2928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 204 / 11 kv water works feeder Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.0857	.0857	.104	.0857	.0693	.0686
2	.0678	.0857	.0876	.1052	.0857	.0701	.0686
3	.0716	.0686	.0886	.1063	.0857	.0709	.0686
4	.0732	.0857	.0895	.1075	.0857	.0716	.0857
5	.0876	.0686	.0867	.1086	.0857	.0724	.0857
6	.0895	.1029	.0678	.1097	.1029	.0732	.0857
7	.0701	.1029	.0876	.0924	.1029	.0739	.0857
8	.0526	.1017	.1029	.0747	.0686	.0747	.0848
9	.0671	.0633	.1052	.1132	.0686	.0754	.1017
10		.0648			.0686	.1029	
11		.0633		.0732	.0686		.0876
12	.0633	.0625					.0876
13	.0655	.0625	.0709	.0724	.0857	.0848	.1029
14	.0625	.0678	.0716	.0709	.0686		.0678
15		.0686	.0724		.0701		.0678
16	.0316	.0686			.0709	.1029	.0686
17	.0848	.0876	.0924		.0686	.1017	.0678
18	.0848	.0686	.0934	.0848	.0747	.1017	.0701
19	.0857	.0678	.0943	.0848	.0754	.0678	.0905
20	.0686	.0848	.0857	.0848	.0686	.0678	.0895
21	.0686	.0886	.104	.0848	.0867	.0686	.0857
22	.0857	.0857	.1052	.0655		.0686	.0895
23	.0857	.0848	.1063	.0678	.0709	.0686	.0914
24	.0686	.0686	.0848	.1029	.0857	.0686	.0686
Max	.0895	.1029	.1063	.1132	.1029	.1029	.1029
Min	.0316	.0625	.0678	.0655	.0686	.0678	.0678
Avg	.0717	.0775	.0891	.0902	.0788	.0778	.0813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 205 / 11 Kv Herwad Fdr

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.032	1.6804	1.387		.5548	.032
2	.0328	.032	1.6484	1.4022		.5258	.032
3	.0332	.032	1.6876	1.4175		.5316	.032
4	.0328	.032	1.7404	1.4685		.6089	.032
5	.0324	.032	1.7204	1.5384		.6154	.032
6	.032	.032	1.7368	1.6278		.7133	.032
7	.032		1.8896	1.7372		.9795	.064
8	.0328		.032	.056		.0373	.032
9	2.2775	2.0454	.0332	.0377		.0377	.7362
10		2.1026				.0343	.7682
11		1.9608					.6401
12	2.3594	1.9136					.5921
13	2.3205	1.8976		.0328		.0324	.5506
14	2.5034	1.8747	.0537	.0316			.5571
15		1.9989	.0543		.0324		.5801
16	2.3594	1.8138			.0328	.0316	.5668
17		.0492	.0554			.0335	.0332
18		.0497	.056	.032	.0373	.032	.032
19	.0316	.0328	.0377	.032	.0566	.032	.0335
20	.0316	.032	.0514	.032	.0514	.032	.0332
21	.032	.032	.052	.0328	.0347	.032	.0332
22	.032	1.6385	1.5424	1.0814		.032	.032
23	.032	1.6804	1.5061	1.0814	.691	.032	.0328
24	.0328	.032	1.7204	1.406		.6001	.032
Max	2.5034	2.1026	1.8896	1.7372	.691	.9795	.7682
Min	.0316	.032	.032	.0316	.0324	.0316	.032
Avg	.6460	.8794	.9104	.8019	.1337	.2764	.2309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 206 / 11KV Kurundwad Urban
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5935	.6802	.7712		.7125	.6588	.4534
2	.5731	.6478	.663		.6478	.631	.421
3	.5373	.6478	.6706			.6379	.421
4	.5959	.6478	.7461		.5693	.6984	.4858
5	.6859	.6802	.779		.506	.724	.5506
6	.823	.7773	.8648		.6325	.8596	.6154
7	.8817	1.004	1.0174		.7274	1.0903	.8421
8	.9945	1.0364	1.1568		.7907	1.1203	1.004
9	1.1142	1.1012	1.1871		.759	1.1694	1.0688
10		1.0936			.759	1.1317	
11		1.0936	.9172	1.166	.759		1.1736
12	1.1336	1.0802					1.0395
13	.9488		.8223	1.0936	1.0277	.8421	.8309
14	.9069	.9488	.591	.1619	1.1385		.823
15		.9488	.8326		.7907		.9326
16	.9488	1.1142			.9393	.8192	1.1488
17	1.1336	1.2269	1.2567		1.2452	.7125	1.17
18	1.1984	1.1934	1.4377	1.2631	1.5497	.7773	1.262
19	1.3279	1.2407	1.4901	1.3603	1.5655	.9069	1.3717
20	1.3279	1.2597	1.4232	1.2955	1.2689	1.004	1.39
21	1.1336	1.17	1.2309	1.1385	1.2136	.9069	1.2536
22	1.0202	1.0111	1.0692	.9804	1.0517	.7773	1.134
23	.8421	.9326	.9214	.8539	.8859	.6154	.9511
24	.6687	.7449	.8139		.7773	.7202	.4858
Max	1.3279	1.2597	1.4901	1.3603	1.5655	1.1694	1.39
Min	.5373	.6478	.591	.1619	.506	.6154	.421
Avg	.9233	.9687	.9839	1.0348	.9235	.8402	.9056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 207 / BASTWAD VILLEGE

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1526	.2263	.2126	.1867		.156	.1886
2	.1595	.1886	.1829	.1848		.1578	.1886
3	.1612	.1886	.1791	.1829		.1772	.1886
4	.2126	.2641	.2149	.2241		.3045	.2263
5	.3109	.3206	.2926	.2614		.3258	.3018
6	.3898	.3772	.3506	.3696	.3174	.3658	.3772
7	.3506	.3547	.3856	.4024	.3734	.4066	.3961
8	.3045	.2772	.3366	.3174	.2987	.3361	.3547
9	.2328	.2561	.2686	.2926	.2614	.3206	.2772
10		.2957		.2801	.2427	.2401	.2743
11		.2987		.2402	.2241		.2507
12	.2629	.3292			.2054		.2229
13	.218	.2427	.2012	.2534	.2054	.3109	.2279
14	.2241	.2195	.197	.1991	.2054		.2507
15		.1991	.181		.1646		.2195
16	.2033	.2353			.1494	.2241	.181
17		.2561			.168	.1663	.1829
18		.2303	.2241	.3109	.2241	.2353	.2743
19	.2926	.2195	.3206	.3696	.2829	.3292	.3439
20	.3841	.3601	.3086	.3696	.3086	.3475	.3881
21	.3361	.3475	.3294	.3292	.2947	.3326	.3658
22	.3206	.2883	.298	.3109		.2801	.3326
23	.2829	.2543	.2658	.2195	.1949	.2427	.2587
24	.1886	.2263	.2058	.2195		.1543	.1886
Max	.3898	.3772	.3856	.4024	.3734	.4066	.3961
Min	.1526	.1886	.1791	.1829	.1494	.1543	.181
Avg	.2625	.269	.2608	.2762	.2424	.2707	.2692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 208 / KURUNDWAD AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0312	.1966	.1214	.0474	.0347	.0312
2	.0335	.0312	.1823	.1052	.0474	.0351	.0312
3	.0332	.0312	.1619	.1063	.0474	.0354	.0312
4	.0328	.0312	.1638	.1075	.0474	.0358	.0312
5	.032	.0312	.1619	.1267	.0474	.0362	.0312
6	.0324	.0312	.1696	.1463	.0791	.0366	.0312
7	.032	.0312	.213	.2033	.1107	.0554	.0312
8	.0328	.0312	.032	.0373	.0316	.0373	.0312
9	.2818	.2968	.0324	.0377	.0316	.0377	.0625
10		.3077				.0343	
11		.253		.0316			.0492
12	.25	.25					.0486
13	.2401	.2846	.0324	.0324		.0312	.0335
14	.2622	.253	.0358	.0312	.0328		.032
15		.0158	.0362		.0324		.0328
16	.2591	.2105			.0316	.0312	.032
17	.0309	.032	.037		.0324	.0316	.0166
18	.0309	.0339	.0373	.0312	.0373	.0312	.0162
19	.0309	.0335	.0377	.0312	.0377	.0312	.0328
20	.0309	.0324	.0343	.0312	.0343	.0324	.0328
21	.0312	.0324	.0347	.0316	.0347	.0312	.0332
22	.0312	.1802	.1578	.0474		.0312	.032
23	.0309	.1966	.1595	.0474	.0354	.0312	.032
24	.0335	.0312	.1966	.1372	.0474	.0343	.0312
Max	.2818	.3077	.213	.2033	.1107	.0554	.0625
Min	.0309	.0158	.032	.0312	.0316	.0312	.0162
Avg	.0860	.1122	.1056	.0760	.0445	.0348	.0333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 209 / 11KV Nrisinghwadi Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.2195	.2195		.1734	.1734	.2012
2	.1772	.2195	.1753		.1734	.1753	.1829
3	.1791	.2195	.1791		.1734	.1772	.1829
4	.2103	.2195	.1949		.1753	.1791	.1829
5	.2481	.2378	.2401		.2126	.2172	.2195
6	.2629	.2534	.2543		.2835	.2561	.2561
7	.298	.3982	.3429		.3721	.3881	.3658
8		.3258	.3041		.3045	.3361	.362
9	.3189	.2561	.3012		.2835	.3395	.2896
10		.2561			.2481	.2743	
11		.2195		.2987	.2126		.2401
12	.2267	.2241			.2481		.2058
13	.1875	.2195	.2561	.2835	.2507	.1772	.1886
14	.1638	.2534	.2507	.1829	.2149		.2103
15		.2587	.2534		.181		.2481
16	.2926	.2561			.2804	.298	.2865
17	.2534	.2401			.2804	.2481	.2353
18	.2715	.2804	.3734	.2896	.2987	.2561	.2743
19	.3077	.3012	.415	.362	.3395	.1829	.3109
20	.3982	.333	.3429	.362	.3086	.3841	.3292
21	.362	.3544	.3467	.3109	.2947	.3292	.2865
22	.3077	.3052	.2804	.2926		.2926	.2743
23	.2715	.2429	.2126	.2172	.2126	.2195	.2195
24	.2103	.2378	.2254		.1734	.1715	.2012
Max	.3982	.3982	.415	.362	.3721	.3881	.3658
Min	.1638	.2195	.1753	.1829	.1734	.1715	.1829
Avg	.2563	.2638	.272	.2888	.2476	.2538	.2502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 201 / 11KV Takali Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.1143	.0953	.0953
2	.0953	.0953	.1143	.0953	.1143	.0762	.0953
3	.0953	.0953	.1143	.0953	.1143	.0762	.0953
4	.0953	.0953	.0953	.0953	.1143	.0762	.0953
5	.0953	.0953	.0953	.0953	.1143	.0953	.0953
6	.0953	.1334	.1143	.1334	.1334	.1143	.1334
7	.1334	.1524	.1524	.1524	.1524	.1715	.1143
8	.1334	.1334	.1143	.1143	.1334	.1334	.1143
9	.1143	.1334		.1143	.1143	.1143	.0953
10		.1143			.0762	.0953	.0953
11		.1143			.0953		.0953
12	.0762	.0953			.0953		.0762
13	.0762	.0953			.1143	.0953	.0762
14	.0762	.0762		.1143	.0953	.0953	.0762
15		.0953	.1143	.0953	.0762	.0953	.0762
16	.1143	.0762	.1143	.0762	.0762	.0953	.0762
17	.1143	.0953	.1143	.0762	.0762	.0953	.0953
18	.0953	.0953	.1143	.0953	.1524		.1143
19	.1524	.1334	.1524	.1524	.1715		.1334
20	.1715	.1334	.1524	.1715		.1524	.1715
21	.1524	.1524	.1524	.1524		.1524	.1524
22	.1143	.1334	.1524	.1334			.1524
23	.0953	.0762	.0953	.1143	.0762		.1143
24	.0953	.0953	.0953	.0953	.1143	.0953	.0953
Max	.1715	.1524	.1524	.1715	.1715	.1715	.1715
Min	.0762	.0762	.0953	.0762	.0762	.0762	.0762
Avg	.1089	.1088	.1196	.1134	.1107	.1069	.1056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 202 / 11KV Takaliwadi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	1.2003	.0381	.0381	.0381	.0381	.5335
2	1.0402	1.1622	.0381	.0381	.0381	.0381	.5335
3	1.0402	1.1431	.0381	.0381	.0381	.0381	.5335
4	1.0402	1.1431	.0381	.0381	.0381	.0381	.5335
5	1.07	1.1431	.0381	.0381	.0381	.0381	.5335
6	1.0997	1.1622	.0381	.0381	.0381	.0381	.5716
7	1.1443	1.3336	.0381	.0572	.0381	.0381	.7621
8	.0297	.0381	.0572	.0572	.0381	.0381	.0572
9	.0297	.0381		1.6004	1.4098	1.0288	.0381
10		.0381		1.2334	1.2193	.8764	.0297
11		.0572		1.2037	1.1812		.0297
12	.0381	.0381		1.2334	1.1431		.0297
13	.0381	.0381		1.2631	1.1622	.7621	.0297
14	.0381	.0381		1.2334	1.105	.724	.0297
15		.0381		1.2334	1.0669		.0297
16	.0381	.0381	1.7147	1.2334	1.0288	.6478	.0297
17	.0381	.0381	.0381	.0297	.0381	.0381	.0297
18	.0381	.0381	.0572	.0297	.0381		.0297
19	.0381	.0381	.0381	.0297	.0381		
20	.0381	.0381	.0381	.0381	.0381	.0381	
21	.0381	.0572	.0381	.0381	.0381	.0381	
22	1.2384	.0572	.0381	.0381	.0381		
23	1.2003	.0381	.0381	.0381	.0381		
24	1.0402	1.2003	.0381	.0381	.0381	.0381	.5335
Max	1.2384	1.3336	1.7147	1.6004	1.4098	1.0288	.7621
Min	.0297	.0381	.0381	.0297	.0381	.0381	.0297
Avg	.5408	.4231	.1390	.4524	.4136	.2645	.2578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 203 / 11KV Danwad AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0381	1.1431	.9526	.5906	.2286	.0381
2	.0332	.0381	1.1431	.9526	.5906	.2477	.0381
3	.0332	.0381	1.1622	.9526	.5906	.2477	.0381
4	.0332	.0381	1.1622	.9526	.5906	.2286	.0381
5	.0332	.0381	1.1812	.9526	.6097	.2286	.0381
6	.0332	.0381	1.2193	.8954	.6287	.2667	.0381
7	.0332	.0381	1.2955	1.0288	.6478	.381	.0381
8	.0332	.0381	.0381	.0381	.0381	.0381	.0381
9	1.4089	1.6194		.0381	.0381	.0381	.3429
10		1.6956		.0332	.0381	.0381	.3149
11		1.7147		.0332	.0381		.3149
12	1.6575	1.6575		.0332	.0381		.2486
13	1.5623	1.5623		.0332	.0381	.0381	.2321
14	1.5242	1.6194		.0332	.0381	.0381	.2321
15		1.6004	.0381	.0332	.0381	.0381	.1989
16	1.4098	1.5813	.0381	.0332	.0381	.0381	.1989
17	.0381	.0381	.0381	.0332	.0381	.0381	.0332
18	.0381	.0381	.0381	.0332	.0381		.0332
19		.0381	.0381	.0332	.0381		
20		.0381	.0381	.0332	.0381	.0381	
21		.0381	.0381		.0381	.0381	
22		1.2384	1.0288	.4191	.2286		
23		1.2193	1.0098	.5906	.2286		
24	.0332	.0381	1.1812	1.0098	.5906	.2286	.0381
Max	1.6575	1.7147	1.2955	1.0288	.6478	.381	.3429
Min	.0332	.0381	.0381	.0332	.0381	.0381	.0332
Avg	.4961	.6684	.6573	.3977	.2429	.1355	.1312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 204 / 11KV Rajapur AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0774	.7621	.0572	.0381	.0381	.0381	.1524
2	1.0774	.7621	.0572	.0381	.0381	.0381	.1524
3	1.0774	.743	.0572	.0381	.0381	.0572	.1524
4	1.0774	.7621	.0572	.0381	.0381	.0572	.1524
5	1.094	.8002	.0572	.0381	.0381	.0572	.1524
6	1.1437	.8573	.0572	.0381	.0381	.0572	.1905
7	1.2431	.9526	.0572	.0381	.0381	.0572	.1905
8	.0332	.0381	.0381	.0381	.0381	.0572	.0572
9	.0332	.0381		.9907	1.0669	.2858	.0381
10		.0572		.8951	.9907	.2667	.0332
11		.0381		1.6409	.9145		.0332
12	.0381	.0572		1.6409	.8002		.0332
13	.0381	.0572		1.6409	.7621	.1715	.0332
14	.0381	.0381		1.6244	.724	.1715	.0332
15		.0572		1.5746	.6097		.0332
16	.0381	.0572	1.8671	1.326	.5525	.0381	.0332
17	.0381	.0572	.0381	.0332	.0381	.0572	.0332
18	.0381	.0572		.0332	.0381		.0332
19	.0381	.0572	.0381	.0332	.0381		
20	.0381	.0572	.0381	.0381	.0381	.0381	
21	.0381	.0381	.0381	.0381	.0381	.0381	
22	.7811	.0381	.0381	.0381	.0191		
23	.7811	.0381	.0381	.0381	.0191		
24	1.094	.7811	.0381	.0381	.0381	.0381	.1524
Max	1.2431	.9526	1.8671	1.6409	1.0669	.2858	.1905
Min	.0332	.0381	.0381	.0332	.0191	.0381	.0332
Avg	.5169	.3001	.1608	.4970	.2913	.0897	.0889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 205 / Rajapur Vlg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.2096	.1905	.1715	.1715	.1524
2	.1524	.1524	.1905	.1905	.1715	.1905	.1524
3	.1524	.1334	.1905	.1905	.1715	.1905	.1524
4	.1524	.1334	.2286	.1905	.1715	.2096	.1524
5	.1524	.1715	.2286	.1905	.1905	.2096	.2286
6	.1905	.2286	.2477	.2286	.2286	.2477	.2667
7	.2096	.2477	.2477	.2667	.2477	.2667	.2286
8	.1905	.2096	.2096	.2286	.2286	.2667	.2286
9	.1334	.1905		.1905	.1905	.1524	.1905
10		.1334		.1905	.1524	.1143	.0953
11		.1715		.1524	.1143		.0953
12	.1334	.1715		.1524			.1334
13	.1334	.1715		.1715		.1334	.0133
14	.1715	.1524		.1715		.1524	.1334
15		.1334		.1524		.1524	.1334
16	.1524	.1334	.1524	.1334		.1524	.1524
17	.1524	.1524	.1715	.1334		.1524	.1524
18	.1524	.1715	.2286	.1715			.1715
19	.2096	.2477	.3048	.2667	.362		
20	.3048	.2286	.3048	.3048	.362	.3048	
21	.2667	.2667	.2667	.2667	.2858	.3048	
22	.2096	.2477	.2477	.2286	.2286		
23	.1715	.1905	.1905	.1905	.1524		
24	.1905	.1715	.2096	.1905	.1715	.1715	.1524
Max	.3048	.2667	.3048	.3048	.362	.3048	.2667
Min	.1334	.1334	.1524	.1334	.1143	.1143	.0133
Avg	.1778	.1818	.2253	.1977	.2118	.1969	.1571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 206 / Takaliwadi Vlg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0381	.0572	.0572	.0572
2	.0572	.0381	.0572	.0381	.0572	.0572	.0572
3	.0572	.0381	.0572	.0381	.0572	.0572	.0572
4	.0572	.0381	.0572	.0381	.0572	.0572	.0572
5	.0572	.0572	.0572	.0381	.0572	.0572	.0572
6	.0762	.0572	.0572	.0572	.0572	.0572	.0572
7	.0762	.0762	.0762	.0572	.0572	.0762	.0762
8	.0762	.0572	.0762	.0572	.0572	.0572	.0762
9	.0572	.0762		.0953	.0762	.0953	.0762
10		.0762			.0953	.0762	.0762
11		.0762			.0953		.0762
12	.0572				.0762		.0762
13	.0762				.0762	.0572	.0762
14	.0572	.0953		.0762	.0572	.0572	.0762
15		.0762	.0762	.0572	.0572		.0572
16	.0572	.0762	.0762	.0572	.0953	.0572	.0572
17	.0953	.0572	.0762	.0572	.0572	.0953	.0572
18	.0572	.0762	.0762	.0572	.0572		.0762
19	.0953	.0762	.0762	.0953			.0762
20	.1143	.0762	.0953	.1143		.0953	.1143
21	.1143	.1143	.0953	.1143	.0953	.0953	.1143
22	.0953	.0953	.0953	.0762	.0762		.1143
23	.0572	.0572	.0381	.0762	.0381		.0762
24	.0572	.0572	.0572	.0381	.0572	.0381	.0572
Max	.1143	.1143	.0953	.1143	.0953	.0953	.1143
Min	.0572	.0381	.0381	.0381	.0381	.0381	.0572
Avg	.0717	.0684	.0699	.0638	.0667	.0673	.0730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 207 / 11 KV TAKALI (AG)

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2765	.9907	.6097	.1143	
2			1.2765	.9907	.6097	.1143	
3			1.2574	.9907	.6097	.1143	
4			1.2574	.9907	.6097	.1143	
5			1.2955	.9526	.6097	.0953	
6			1.2955	.8764	.6287	.1143	
7			1.3717	.8764	.6287	.1334	
9	1.4754	1.7909					
10		1.8099					
11		1.8671					.1341
12	1.9624	1.4289					.1174
13	1.8861	1.6575					.1006
14	1.9624	1.7337					.0838
15		1.7718			.1524		.0671
16	1.8671	1.6766					.0503
22		1.3527	1.0669	.6097	.1334		
23		1.3336	1.105	.6287	.1334		
24			1.2955	1.105	.6097	.1143	
Max	1.9624	1.8671	1.3717	1.105	.6287	.1334	.1341
Min	1.4754	1.3336	1.0669	.6097	.1334	.0953	.0503
Avg	1.8307	1.6423	1.2498	.9012	.4850	.1143	.0922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 208 / 11 KV SANGAM AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0381	1.0098	.8383	.381	.0381	.0381
2	.0332	.0381	1.0098	.8383	.381	.0381	.0381
3	.0332	.0381	.9907	.8383	.381	.0381	.0381
4	.0332	.0381	.9907	.8383	.381	.0381	.0381
5	.0332	.0381	.9526	.8383	.381	.0381	.0381
6	.0332	.0381	.9717	.8002	.381	.0381	.0381
7	.0332	.0381	.9717	.8383	.381	.0381	.0381
8	.0332	.0381	.0381	.0381	.0381	.0381	.0381
9	1.1603	1.5242		.0381	.0381	.0381	.0572
10		1.5623			.0381	.0381	.0332
11		1.5623			.0381		.0332
12	1.467	1.5813	.0381		.0381		.0332
13	1.4289	1.5051			.0381		.0332
14	1.448	1.5432		.0332	.0381	.0381	.0332
15		1.5051	.0381	.0332	.0381	.0381	.0332
16	1.4098	1.5623	.0381			.0381	.0332
17	.0381	.0381	.0381	.0332		.0381	.0332
18	.0381	.0381	.0381	.0332	.0381		.0332
19		.0381	.0381	.0332	.0381		.0332
20		.0381	.0381	.0332		.0381	.0332
21		.0381	.0381	.0381	.0381	.0381	.0332
22		1.086	.8954	.381	.0381		.0381
23		1.0098	.8764	.381	.0381	.0381	.0332
24	.0332	.0381	.9907	.8764	.381	.0381	.0381
Max	1.467	1.5813	1.0098	.8764	.381	.0381	.0572
Min	.0332	.0381	.0381	.0332	.0381	.0381	.0332
Avg	.4556	.6240	.5264	.4096	.1687	.0381	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 209 / 11 KV Danwad Gaothan
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.1143	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0762	.0953
4	.0953	.0953	.1143	.0953	.0953	.0762	.0953
5	.0953	.0953	.1143	.1524	.1143	.1143	.0953
6	.1334	.1334	.1524	.1715	.1143	.1334	.1524
7	.0152	.1334	.1334	.1524	.1524	.1905	.1524
8	.1143	.1334	.1143	.1334	.1143	.1524	.1334
9	.0953	.1143		.1334	.1143	.1143	.1143
10		.0953			.1143	.0953	.0953
11		.1334		.1143	.1143		.0953
12	.0953	.1143		.1143	.0762		.0953
13	.0762	.1143		.0953	.0953	.0953	.0953
14	.0762	.0762		.0953	.0762	.0762	.0953
15		.0762	.0381	.0953	.0762	.0572	.0762
16	.0572	.0762	.0381	.0953	.0953	.0762	.0762
17	.0762	.0953	.0953	.0953	.1143	.0953	.0953
18	.1143	.0953	.1143	.0953	.1143		.1143
19	.1334	.1143	.1524	.1524	.1143		.1334
20	.1715	.1334	.1715	.1715	.1715	.1524	.1715
21	.1524	.1524	.1715	.1524	.1524	.1524	.1715
22	.1143	8.5162	.1334	.1334	.1143		.1524
23	.0953	.1143	.0953	.1143	.0762		.1143
24	.0953	.0953	.1143	.0953	.0953	.0762	.0953
Max	.1715	8.5162	.1715	.1715	.1715	.1905	.1715
Min	.0152	.0762	.0381	.0953	.0762	.0572	.0762
Avg	.0996	.4581	.1143	.1193	.1080	.1069	.1127

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 201 / 11 KV Santubai AG Feeder

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0324	1.4685	1.3927	.9555		.0486
2	.0324	.0324	1.4685	1.4091	.9231		.0486
3	.0324	.0324	1.5384	1.4419	.9231		.0486
4	.0328	.0324	1.5546	1.4251	.9393		.0486
5	.0492	.0486	1.531	1.5729	.9555		.064
6	.0486	.0486	1.5813	1.6032	.9717		.064
7	.0492	.0486	1.5779	1.6518	1.1174		.08
8		.0324	.0469	.0648	.0648		.048
9		2.0567	.0469	.0492	.048		
10		2.1538		.0486	.0486		
11		2.1247		.0486	.0486		.6081
12	2.2024	2.0934			.0324	.0486	.6316
13	2.1052	1.9372			.0328	.0486	.6154
14	2.1214	1.9757		.0648	.0324	.0324	.5992
15		1.906		.0648	.0324	.0324	
16	2.0891	1.9216		.081	.032	.0324	
17	.0486	.0312	.0492	.081	.0328	.0324	.0486
18	.0486	.048	.0486	.081	.0324	.048	.0324
19	.0648	.0492	.0486	.0648	.048	.0486	.0486
20	.0486	.064	.0655	.0648	.0486	.064	.0486
21	.0486	.0648	.0648	.081	.0486		.0486
22	.0486	1.4842	1.3443	1.004	.5312		
23	.0324	1.5043	1.3927	.9878	.5441		.0324
24	.0324	.0324	1.4685	1.3927	.9717	.5441	.0486
Max	2.2024	2.1538	1.5813	1.6518	1.1174	.5441	.6316
Min	.0324	.0312	.0469	.0486	.032	.0324	.0324
Avg	.4825	.8231	.8998	.6671	.3923	.0932	.1691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 202 / 11 kv Ghosarawad AG Feeder

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.085	.9282		.0162	.016		.16
2	1.085	.9122		.0164	.016		.16
3	1.0722	.9122		.0164	.016		.1543
4	1.0688	.8962		.0162	.016		.1739
5	1.0688	.8962		.0162	.016		.1943
6	1.065	.8962		.0162	.016		.1943
7	1.0526	1.0242		.0162	.016		.2241
8		.016		.016	.016		.016
9		.016		1.247	.8962		
10		.016		1.2793	.8322		
11		.0162		1.2631	.7432		.0162
12	.016	.0164			.7116	.1943	.016
13	.016	.016				.1802	.016
14	.016	.0164		1.2483	.2881	.1619	.016
15		.0164		1.2163	.2881	.1475	
16	.016	.0164		1.2003	.3201	.1619	
17	.016	.0162	.0162	.016	.0324	.0158	.016
18	.016	.0162	.0164			.0158	.016
19	.016	.016	.0162	.016	.016	.0162	.016
20	.016	.016	.0328	.016	.0164	.016	.016
21	.016	.0162	.0328	.016	.0164		.016
22	.9922	.0324	.0324	.016			
23	.9762	.0328	.0162	.016	.0162		.144
24	1.085	.9282		.0162	.016	.0162	.1619
Max	1.085	1.0242	.0328	1.2793	.8962	.1943	.2241
Min	.016	.016	.0162	.016	.016	.0158	.016
Avg	.5629	.3202	.0233	.3665	.2058	.0926	.0909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 203 / 11 KV Ghosarawad VG

Gaothan Feeder

Feeder Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1109		.112	.1109		.112
2	.112	.0924		.1132	.0924		.1132
3	.112	.1109		.1132	.0924		.1132
4	.1698	.1294		.1494	.1294		.1698
5	.2075	.1663		.1867	.1848		.2054
6	.2427	.2033		.2614	.2402		.2587
7	.2772	.1848		.2427	.2402		.2402
8		.2218		.2587	.2033		.1848
9		.2957		.2218	.1629		
10		.2772		.2033	.1448		
11		.2896		.1848	.128		.1109
12	.2772	.1991			.1267	.1478	.1294
13		.181				.1294	.1109
14	.1848	.181		.1848	.2172	.0924	.1478
15		.1463		.1663	.2172	.0924	
16	.1109	.1829		.1478	.2195	.0924	
17	.1663	.1267		.1478	.181	.1109	.1663
18	.1848	.1086	.2587	.1478	.181	.1109	.1848
19	.2033	.1267	.2772	.1663	.2353	.1663	.2402
20	.2772	.2353	.3142	.2218		.2587	.2587
21	.2587	.2534	.3361	.1848			.2402
22	.1848	.181	.2218	.1478			
23	.1294	.1448	.1867	.1109	.1086		.1109
24	.1307	.1109		.1109	.1109	.1086	.112
Max	.2772	.2957	.3361	.2614	.2402	.2587	.2587
Min	.1109	.0924	.1867	.1109	.0924	.0924	.1109
Avg	.1867	.1775	.2658	.1720	.1663	.1310	.1689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 204 / 11 kv Balumama AG Feeder

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0316	.0469		1.1092		.6401	.0312
2	.032	.0469		1.1227		.6722	.0312
3	.032	.0469		1.1227		.6882	.0316
4	.032	.0469		1.1544		.7209	.0312
5	.032	.0469		1.1544		.7042	.0316
6	.0316	.0469		1.1717		.7537	.0316
7	.0312	.0312		1.2186		.7362	.0316
8		.0469		.0474		.032	.0316
9		1.7029		.0158	.0324	.0328	
10		1.8435		.0162	.0328		
11		1.9044		.0156	.0324		.6562
12	1.7497	1.8591			.0324	.0301	
13	1.7029	1.8747			.0324	.0312	
14	1.6872	1.8747		.0312	.0328	.0316	.6093
15		1.8278		.0312	.0328	.0316	
16	1.5779	1.7497		.0312	.0328	.0312	
17	.0469	.0324	.0316	.0312	.0324	.0312	.0469
18	.0625	.032	.0316	.0312	.032	.0312	.0469
19	.0469	.032	.0316	.0312	.032	.0316	.0625
20	.0469	.048	.0474	.0312		.0312	.0625
21	.0469	.048	.0469	.0312			.0469
22	.0469	1.4217	1.1544	1.0623			
23	.0469	1.406	1.1248	1.0623	.6478		.0469
24	.0316	.0469		1.1092		.6401	.0312
Max	1.7497	1.9044	1.1544	1.2186	.6478	.7537	.6562
Min	.0312	.0312	.0316	.0156	.032	.0301	.0312
Avg	.3850	.7526	.3526	.5287	.0838	.3106	.1095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 205 / 11 KV Dattawad AG Feeder

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9069	.639		.0328	.0328	.032	.0972
2	.9175	.6226		.0324	.0328	.032	.0972
3	.9069	.6226		.0324	.0328	.032	.0972
4	.9069	.6062		.0324	.0328	.0328	.1134
5	.8907	.6062		.0324	.0328	.0324	.1134
6	.9012	.6062		.0328	.0328	.032	.128
7	.8907	.6062		.0324	.0328	.032	.1457
8		.0328		.0324	.0328	.032	.016
9		.0328		1.3279	.9061	.213	
10		.0328		1.3603	.7362	.1781	
11		.0328		1.3603	.6718		.016
12	.0328	.0324				.1619	.0164
13	.0328	.0328			.1966	.1457	.0164
14	.0328	.0324		1.3108	.176	.1265	.0164
15		.0328		1.2452	.1943	.1265	
16	.0328	.0328		1.1961	.1781	.1094	
17	.0328	.0328	.0332	.0328	.0328	.0158	.0164
18	.0328	.0324	.0324	.0328	.032	.016	.0164
19	.0328	.0324	.0324	.0328	.0324	.016	.0164
20	.0328	.032	.0324	.0328		.016	.0164
21	.0328	.0324	.0328	.0328			.0164
22	.6718	.0324	.0328	.0328			
23	.6554	.0324	.0324	.0328	.0324		.0983
24	.9069	.6554		.0328	.0328	.0324	.096
Max	.9175	.6554	.0332	1.3603	.9061	.213	.1457
Min	.0328	.032	.0324	.0324	.032	.0158	.016
Avg	.4658	.2286	.0326	.3783	.1742	.0707	.0605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 206 / 11 KV Dattawad VG

Gaathan Feeder

Feeder Feeder KV- 11 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.181		.1867	.1448	.1448	.168
2	.1698	.1629		.1698	.1267	.1448	.1494
3	.1698	.1629		.1509	.1267	.1463	.1509
4	.2054	.1991		.1478	.1629	.1448	.1886
5	.2452	.2353		.1848	.2172	.1829	.2241
6	.2987	.2715		.2587	.2715	.2534	.2614
7	.3326	.2534		.3142	.2896	.362	.2772
8		.2534		.2614	.2715	.3077	.2587
9		.2534		.2402	.2715	.2534	
10		.2353		.2218	.2534	.2534	
11		.2353		.2218	.2534		.2402
12	.2534	.2561			.2195	.2218	.181
13	.181	.2195			.2195	.2033	.1448
14	.181	.2012		.1448	.1991	.2033	.181
15		.2195		.1629	.2195	.2033	
16	.2172	.2195		.181	.2195	.2033	
17	.3077	.2561	.2772	.1991	.2561	.2218	.2353
18	.2715	.2561	.3142	.2172	.2534	.2957	.2896
19	.2534	.2926	.3326	.3258	.3258	.3326	.3258
20	.362	.362	.3881	.3258		.3881	.3801
21	.3258	.3258	.3361	.2896			.362
22	.2715	.2715	.2987	.2353			
23	.2172	.2172	.2241	.181	.2172		.181
24	.1848	.181		.1867	.1448	.1829	.1663
Max	.362	.362	.3881	.3258	.3258	.3881	.3801
Min	.1698	.1629	.2241	.1448	.1267	.1448	.1448
Avg	.2439	.2384	.3101	.2185	.2221	.2325	.2298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 207 / 11 KV Hanuman AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8579	.8535		.0152	.0152	.0149	
2	.8688	.8535		.0151	.0152	.0147	
3	.8688	.8383		.0152	.0152	.0149	
4	.8688	.8383		.0151	.0152	.0149	
5	.8951	.8383		.0152	.0152	.0149	
6	.884	.8535		.0151	.0152	.0149	
7	.873	.8688		.0152	.0152	.0149	
8		.0152		.0152	.0152	.0149	
9		.0152		1.0669	.8619		
10		.0152		1.0987	.8215		
11		.0149		1.0837	.8173		.0152
12	.0152	.0149			.8025		.0152
13	.0152	.0149			.7579	.4515	.0152
14	.0152	.0149		1.0364	.743	.4755	.0152
15		.0149		1.0059	.7133	.4755	.0152
16	.0152	.0149		.9907	.639	.4607	.0152
17		.0149	.0151	.0152	.0152	.0151	.0152
18	.0152	.0149	.0151	.0152	.0149	.0152	.0152
19	.0152	.0149	.0151	.0152	.0149	.0151	.0152
20	.0152	.0145	.0152	.0152		.0152	.0152
21	.0152	.0149	.0152	.0152			.0152
22	.884	.0149	.0152	.0152			
23	.8535	.0149	.0152	.0152	.0149		.3201
24	.8579	.8535		.0152	.0152	.0149	
Max	.8951	.8688	.0152	1.0987	.8619	.4755	.3201
Min	.0152	.0145	.0151	.0151	.0149	.0147	.0152
Avg	.4907	.2932	.0152	.2966	.3025	.1210	.0406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 201 / 11KV Shirati Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1326	.1307	.1307		.1143	.0953
2	.1307	.1658	.12	.1307		.1143	.0953
3	.1307	.1658	.1307	.1307		.1143	.0953
4	.1494	.1524	.1307	.1494		.1143	.0953
5	.168	.1658	.168	.1867		.1143	.1524
6	.1867	.1823	.2054	.2614		.2286	.2477
7	.2241	.1658	.1494	.2241		.2477	.2286
8	.2054	.1823	.1494	.2286	.2054	.2477	.2477
9	.2054	.2241	.1905	.1715	.2054		.1823
10	.1867	.2054	.1524	.1524	.1867		.1823
11	.1494	.2054		.1905	.1867	.1715	.1658
12	.1494	.2054		.1524	.1867	.1715	.1658
13	.116	.1867	.1905	.1715	.1307	.1715	.116
14	.1326	.1494	.1524	.1334	.1307	.112	.116
15	.116	.168	.1334	.1524	.1334	.112	.0995
16	.0829	.0934	.1143	.1715	.1524	.12	.0995
17	.116	.0934	.1307		.1334	.1334	.1326
18	.0995	.1307	.1494		.1715	.1524	.168
19	.1326	.168	.1867		.2096	.2096	.1867
20	.1989	.2241	.2241		.2096	.2286	.2427
21	.1989	.2054	.2054		.2096	.2096	.2241
22	.1326	.1867	.1867		.1715	.1715	.1867
23	.116	.1494	.1494		.1143	.1143	.1307
24	.1307	.116	.1372	.1307		.1143	.0953
Max	.2241	.2241	.2241	.2614	.2096	.2477	.2477
Min	.0829	.0934	.1143	.1307	.1143	.112	.0953
Avg	.1496	.1677	.1585	.1687	.1711	.1585	.1563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 202 / KUTWAD AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0332	1.2136			.1334	.0191
2	.0373	.0332	1.2136			.1334	.0191
3	.0373	.0332	1.2136			.1334	.0191
4	.0373	.0332	1.2136			.1334	.0191
5	.0373	.0332	1.2136			.1334	.0191
6	.0373	.0332	1.2308			.1334	.0191
7	.0373	.0332	1.3256			.1715	.0191
8	.0373	.0332	.0373		.0373	.0191	.0191
9	1.9044	1.6991	.0191		.0373		.2486
10	1.8858	1.8298	.0191	.9907	.0373		.2486
11	1.9605	1.9978		1.0669	.0373	.0171	.2321
12	1.9044	2.0725		1.105	.0373	.0171	.1823
13	1.8399	1.9605	.0191	1.0288	.0373	.0171	.1823
14	1.8896	1.9978	.0191	.0191	.0373	.0171	.1658
15	1.873	1.9231		.0191	.0373	.0171	.1326
16	1.6575	1.8484	.0381	.0191	.0373	.0343	
17	.0332	.0171	.0373		.0191	.0191	.0332
18	.0332	.0171	.0373		.0191	.0191	.0373
19	.0332	.0171	.0373		.0191	.0191	.0373
20	.0332	.0171	.0373		.0191	.0191	.0373
21	.0332	.0171	.0373		.0191	.0191	.0373
22	.0332	1.1831	1.0751		.1524	.0381	.0373
23	.0332	1.2323	1.0082		.1524	.0191	.0373
24	.0373	.0332	1.1888	1.0082		.1334	.0191
Max	1.9605	2.0725	1.3256	1.105	.1524	.1715	.2486
Min	.0332	.0171	.0191	.0191	.0191	.0171	.0191
Avg	.6451	.7554	.5826	.6571	.046	.0635	.0792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 203 / SHIROL AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0497	1.0642	.0187		.3239	.0191
2	.0373	.0497	1.0642	.0187		.3239	.0191
3	.0373	.0497	1.0456	.0187		.3239	.0191
4	.0373	.0497	1.0456	.0187		.3239	.0191
5	.0373	.0497	1.0456	.0187	.6344	.3239	.0381
6	.0373	.116	1.0829	.0187	.6516	.1143	.0191
7	.0373	.0332	1.2883	.0187	.7373	.1524	.0381
8	.0373	.0332	1.046	.0191	.0373	.0191	.0381
9	1.7364	1.8484	.0191	.0191	.0373		.2486
10	1.8484	1.9418	.0191	.0191	.0373		
11	2.1098	1.8671			.0373	.0171	
12	2.0725	2.0351		.7049	.0373	.0171	
13	1.7072	1.9791	.0191	.7811	.0373	.0171	.1823
14	1.6741	1.9231	.0191	.743	.0373	.0171	.2984
15	1.6575	1.8111	.0191	.724	.0373	.0171	.3647
16	1.4255	1.6991	.0191	.6668	.0373	.0171	
17	.0995		.0373		.0191	.0191	.3481
18	.0995		.0373		.0191	.0191	.3547
19	.116	.0343	.0373		.0381		.0373
20	.0995	.0343	.0373		.0191	.0381	.0373
21	.116	.0343	.0373		.0191	.0381	.0373
22	.116		.3174		.4001	.0381	.0373
23	.0332	.9774	.3361		.3429	.0191	.0377
24	.0373	.0332	1.0829	.3361		.3239	.0191
Max	2.1098	2.0351	1.2883	.7811	.7373	.3239	.3647
Min	.0332	.0332	.0191	.0187	.0191	.0171	.0191
Avg	.6353	.7928	.4873	.2590	.1693	.1192	.1106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 204 / GHALWAD AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.5304	.0514	.0747	.0747	.0762	.0762
2	.7655	.5636	.0514	.0747	.0686	.0762	.0762
3	.7468	.5636	.0514	.0747	.0934	.0762	.0762
4	.7655	.5636	.0514	.0747	.0686	.0762	.0762
5	.7655	.5636	.0514	.0747	.0747	.0762	.0953
6	.8029	.5304	.0514	.0747	.12	.0762	.1143
7	.8029	.663	.0686	.0747	.0686	.0762	.1334
8	.0747	.0497	.0686	.0762	.0747	.0762	.0572
9	.056	.0754	1.9624	1.9433	1.6057		.0497
10	.056	.0747	2.191	2.0005	1.5684		.0497
11	.0514	.0747		2.0195	1.2696	.3772	.0497
12		.0747		2.21	1.307	.3944	.0497
13		.0747	1.6766	1.9814	1.1949	.3772	.0497
14		.0373	2.0576	2.0957	1.1576	.3601	.0497
15		.0747	2.0957	1.4861	1.0456	.3429	.0497
16		.0747	.0381	1.3336	1.0456	.3429	
17		.0514	.0747		.0572	.0572	.0497
18	.0497	.0514	.0747		.0572	.0572	.0747
19	.0497	.0514	.0747		.0762	.0572	.0747
20	.0497	.0514	.0747		.0762	.0572	.0747
21	.0497	.056	.0373		.0762	.0572	.0747
22	.5138	.0514	.0747		.0762	.0762	.0747
23	.4973	.0514	.0747		.0762	.0762	.0168
24	.7468	.4973	.0514	.0747	.0747	.0762	.0762
Max	.8029	.663	2.191	2.21	1.6057	.3944	.1334
Min	.0497	.0373	.0373	.0747	.0572	.0572	.0168
Avg	.4217	.2271	.5002	.9261	.4753	.1509	.0682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 205 / 11KV Shirti Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.4641	.0343	.0373		.0191	.0572
2	.6722	.4641	.0343	.0373		.0191	.0572
3	.6908	.431	.0343	.0373		.0191	.0572
4	.7095	.431	.0343	.0373		.0191	.0572
5	.7095	.431	.0343	.0373		.0191	.0572
6	.7468	.3978	.0343	.0373		.0191	.0572
7	.7095	.3812	.0343	.0373		.0191	.0572
8	.0187	.0332	.0343	.0191	.0187	.0191	.0381
9	.0343	.0373	1.5242	1.5242	.112		.0332
10	.0373	.0373	1.7718	1.6766	1.1203		.0332
11	.0343	.0373		1.6385	.7095	.0514	.0332
12	.0373	.0373		1.6004	.6722	.0686	.0332
13	.0332	.0373	1.9052	1.467	.5601	.0686	.0332
14	.0332	.0373	1.9624	1.3527	.4854	.0514	.0332
15	.0332	.0373	1.9052	1.3908	.3361	.0686	.0332
16	.0332	.0373	1.9052	1.2955	.2801	.0686	
17	.0332	.0343	.0373		.0191	.0191	.0332
18	.0332	.0343	.0373		.0191	.0191	.0373
19	.0332	.0343	.0373		.0191	.0191	.0373
20	.0332	.0343	.0373		.0191	.0381	.0373
21	.0332	.0373	.0373		.0191	.0191	.0373
22	.4641	.0343	.0373		.0191	.0572	.056
23	.4641	.0373	.0373		.0191	.0572	.056
24	.6908	.4641	.0343	.0373		.0191	.0572
Max	.7468	.4641	1.9624	1.6766	1.1203	.0686	.0572
Min	.0187	.0332	.0343	.0191	.0187	.0191	.0332
Avg	.2913	.1684	.5247	.7214	.2768	.0354	.0445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 206 / Kutwad Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1658	.112	.0934		.0953	.0953
2	.0934	.1658	.112	.0934		.0953	.0953
3	.0934	.1658	.112	.0934		.0953	.0953
4	.112	.1492	.1307	.112		.0953	.0953
5	.1307	.1492	.1307	.1494		.1143	.1143
6	.168	.1326	.1494	.1867		.1524	.1524
7	.1867	.1492	.1307	.1867		.1715	.1715
8	.1307	.116	.12	.1715	.1494	.1524	.1524
9	.112	.112	.0953	.1334	.112		.1326
10	.112	.112	.0953	.1143	.1307		.0995
11	.112	.112		.0953	.112	.0857	.0995
12	.112	.112		.0953	.0934	.1029	.0995
13	.0829	.1307	.0953	.0762	.112	.0686	.0663
14	.0829	.112	.0762	.0762	.112	.0686	
15	.0829	.112	.0762	.0762	.0747	.0686	.0497
16	.0497	.0934	.0953	.0953	.0934		
17	.0663	.0934	.0747		.0762	.1143	.0995
18	.0663	.112	.1307		.1143	.1334	.0934
19	.116	.168	.1867		.1524	.1905	.1494
20	.1492	.168	.2241		.1905	.1905	.2241
21	.1326	.168	.1867		.1524	.1524	.1867
22	.2818	.1494	.1494		.1143	.1334	.1307
23	.1989	.112	.112		.0953	.0953	.0934
24	.112	.1658	.112	.0934		.0953	.0953
Max	.2818	.168	.2241	.1867	.1905	.1905	.2241
Min	.0497	.0934	.0747	.0762	.0747	.0686	.0497
Avg	.1199	.1344	.1231	.1142	.1178	.1177	.1178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 207 / Ghalwad Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1326	.1543	.2054	.1715	.1524	.1715
2	.1494	.1326	.168	.2075	.168	.1524	.1715
3	.1494	.1326	.168	.2054	.168	.1524	.1715
4	.168	.1989	.1543	.2241	.1715	.1524	.1715
5	.2241	.2486	.2427	.2614	.2229	.2286	.2286
6	.3361	.2984	.2743	.3361	.3361	.3429	.3429
7	.2987	.2652	.2614	.2614	.3361	.3429	.3429
8	.2054	.2486	.2229	.2477	.2801	.2858	.2667
9	.2054	.2427	.2477	.2096	.2614		.2321
10	.2054	.2427	.2096	.2477	.2427		.1989
11	.2241	.2427		.2477	.2614	.2054	.1658
12	.1867	.168		.1905	.2427	.1886	.1492
13	.1326	.1494	.0381	.1334	.1867	.1715	.2155
14	.116	.168	.0381	.1143	.1867	.1029	.1989
15	.116	.168	.1143	.1334	.1494	.0857	.1326
16	.0995	.1494	.1715	.1524	.112	.12	.1326
17	.116	.1543	.1494		.1715	.1715	.1326
18	.116	.1715	.1867		.2096	.1905	.1867
19	.2486	.2401	.2614		.2667	.2667	.2427
20	.2652	.2743	.2987		.2858	.3048	.3361
21	.2486	.2572	.2801		.2858	.2858	.0168
22	.2155	.2401	.0187		.2477	.2096	.2427
23	.1989	.168	.1907		.1905	.1905	.168
24	.168	.1658	.1715	.2054	.1867	.1715	.1905
Max	.3361	.2984	.2987	.3361	.3361	.3429	.3429
Min	.0995	.1326	.0187	.1143	.112	.0857	.0168
Avg	.1893	.2025	.1828	.2108	.2226	.2034	.2004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 201 / 11KV K'Guland

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0166	1.0395	.6962	.2321	.0819	.0152
2	.0152	.0166	1.0395	.6962	.2321	.0819	.0152
3	.0152	.0164	1.0395	.6962	.2321	.081	.0152
4	.0152	.0164	1.0395	.6796	.2294	.081	.0152
5	.0152	.0164	1.0395	.6962	.2294	.0819	.0152
6	.0152	.0164	1.1401	.7459	.2949	.0819	.0152
7	.0152	.0166	1.2239	.8619	.3605	.0983	.0152
8	.0152	.0164	.0152	.0152	.0164	.0164	.0152
9		1.5746	.0152	.0152	.0164	.0164	.1475
10		1.576	.0152	.0152	.0164	.0152	
11		1.5927		.0152	.0164	.0152	
12	1.6575	1.6263			.0164	.0152	.2035
13	1.6244	1.576	.0152		.0164	.0152	.1658
14		1.5089	.0152	.0152	.0164	.0152	.1658
15		1.4754	.0152	.0152	.0164	.0152	.1326
16	1.4918	1.4754		.0152	.0164	.0152	.1326
17	.0166	.0152	.0152		.016	.0152	.0166
18	.0164	.0152	.0152	.0152	.0162	.0152	.0166
19	.0166	.0152	.0152	.0152	.0164	.0152	.0164
20	.0166	.0152	.0152	.0152	.0164	.0152	.0164
21	.0166	.0152	.0152	.0166	.0164	.0152	.0164
22	.0166	1.073		.2622	.0983	.0152	
23	.0166	1.073		.2294	.0983	.0152	.0164
24	.0152	.0166	1.073	.7045	.2294	.0983	.0152
Max	1.6575	1.6263	1.2239	.8619	.3605	.0983	.2035
Min	.0152	.0152	.0152	.0152	.016	.0152	.0152
Avg	.2646	.6157	.4632	.3065	.1027	.0388	.0564

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 202 / 11KV Ganeshwadi

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4352	1.2431	.0162	.0158	.0162	.0164	.1417
2	1.4352	1.2431	.0162	.0158	.0164	.0164	.1417
3	1.4175	1.2431	.0162	.0158	.0164	.0164	.1417
4	1.4175	1.2289	.0162	.0158	.0164	.0164	.1417
5	1.4175	1.3108	.0162	.0158	.0164	.0164	.1417
6	1.6301	1.3927	.0162	.0158	.0164	.0164	.2126
7	1.8959	1.5746	.0162	.0158	.0164	.0164	.4607
8	.0162	.0164	.0162	.0158	.0164	.0164	.0162
9		.0166	2.3034	1.8842	1.4413	.4588	.0166
10		.0162	2.3594	1.9826	1.2955	.4252	
11		.0162		2.0972	1.2289	.3898	
12	.0166	.0162			1.2289	.3544	.0166
13	.0166	.0162	2.1628		1.0526	.3189	.0166
14		.0162	2.2119	1.8679	.9831	.3189	.0166
15		.0162	1.9334	1.8023	.9012	.2835	.0164
16	.0166	.0162	1.9334	1.6712	.9012	.2126	.0166
17	.0164	.0162	.0158		.0162	.0162	.0164
18	.0164	.0162	.0158	.0158	.0164	.0162	.0164
19	.0166	.0162	.0158	.0158	.0164	.0162	.0166
20	.0166	.0162	.0158	.0158	.0162	.0162	.0164
21	.0166	.0162	.0158	.0164	.0162	.0162	.0166
22	1.326	.0162	.0158	.0164	.0164	.1417	
23	1.326	.0162	.0158	.0164	.0164	.1417	.0983
24	1.4352	1.326	.0162	.0158	.0164	.0164	.1417
Max	1.8959	1.5746	2.3594	2.0972	1.4413	.4588	.4607
Min	.0162	.0162	.0158	.0158	.0162	.0162	.0162
Avg	.7834	.4509	.5982	.5497	.3873	.1364	.0867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 203 / 11KV Alas Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.5304	.0143	.0152	.0162	.0164	
2	.6706	.5304	.0143	.0152	.0164	.0164	
3	.6371	.4973	.0143	.0152	.0164	.0164	
4	.6371	.4973	.0143	.0152	.0164	.0164	
5	.6371	.4973	.0143	.0152	.0164	.0164	
6	.6371	.5304	.0143	.0152	.0164	.0164	
7	.6874	.5571	.0143	.0152	.0164	.0162	
8	.0143	.0166	.0143	.0152	.0164	.0162	
9		.0166	.8718	.7956	.3441	.1943	
10		.0143	1.0608	.9054	.3521		
11		.0143		.9389	.3563		
12	.0166	.0143			.3563		.0166
13	.0166	.0143	1.1105		.2915		.0829
14		.0143	1.0608	.9389	.2915		.0829
15		.0143	.9945	.9054	.2753	.1006	.0164
16	.0166	.0143	.9779	.8192	.2561	.1006	.0166
17	.0166	.0143	.0152		.0164	.0143	.0166
18	.0166	.0143	.0152	.0152	.0164	.0143	.0164
19	.0164	.0143	.0152	.0152	.0164	.0143	
20	.0166	.0143	.0152	.0152	.0164	.0143	.0164
21	.0166	.0143	.0152	.0164	.0164	.0143	.0164
22	.5967	.0143	.0152	.0164	.0164	.0838	.0819
23	.5801	.0143	.0152	.0164	.0164	.0838	.0655
24	.6706	.5636	.0143	.0152	.0162	.0164	.0838
Max	.6874	.5636	1.1105	.9389	.3563	.1943	.0838
Min	.0143	.0143	.0143	.0152	.0162	.0143	.0164
Avg	.3459	.1849	.2869	.2636	.1161	.0411	.0427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 204 / 11KV Alas Village

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3366	.2454	.3366	.3155	.2835	.2804	.3189
2	.3366	.2454	.3366	.3155	.2835	.2804	.2835
3	.3366	.2454	.3366	.3155	.2835	.2804	.2835
4	.3366	.2454	.3366	.3155	.2835	.2835	.2835
5	.3544	.3155	.3721	.3506	.3506	.3155	.3544
6	.4252	.3681	.4075	.3856	.4207	.3856	.4252
7	.4961	.4031	.4075	.4557	.4557	.4382	.4784
8	.4252	.3681	.3898	.4557	.4557	.4557	.4607
9		.3544	.3366	.4207	.4382	.4207	.4755
10		.3721	.3155	.3506	.3856		.4344
11		.3189		.3506	.3856		.4344
12	.3898	.3898			.3506		.3982
13	.3856		.333		.3155		.4066
14		.3898	.3155	.3681	.3155		.3189
15		.3189	.3155	.3155	.298	.3012	.3189
16	.3189	.3544	.2454	.3506	.2454	.3012	.3721
17	.3506	.3189	.298		.3155	.3361	.3544
18	.3856	.3721	.3506	.4031	.4207	.3721	.3506
19	.5609	.443	.4557	.4908	.4961	.4961	.4908
20	.0175	.5847	.5609	.5609	.5609	.567	.4908
21	.4382	.5316	.5258	.5258	.5258	.5316	.4557
22	.3856	.4784	.4733	.4207	.4382	.4607	.4207
23	.3155	.4252	.3856	.333	.333	.3721	.3506
24	.3544	.2804	.3544	.333	.298	.298	.3189
Max	.5609	.5847	.5609	.5609	.5609	.567	.4908
Min	.0175	.2454	.2454	.3155	.2454	.2804	.2835
Avg	.3658	.3639	.3722	.3873	.3725	.3777	.3867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 205 / 11KV Ganeshwadi Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2481	.2378	.2835	.2561	.2378	.2534	.2658
2	.2481	.2378	.2481	.2378	.2378	.2267	.2658
3	.2481	.2353	.2481	.2378	.2378	.2561	.2658
4	.2481	.2353	.2481	.2378	.2378	.2561	.2658
5	.3012	.2715	.3012	.2743	.2926	.2926	.2835
6	.3898	.3292	.3898	.3658	.4207	.439	.4252
7	.3544	.3658	.3544	.3841	.3658	.4572	.4252
8	.2658	.2926		.2926	.362	.3841	.3544
9		.2561	.2835	.2561	.3258	.3292	.3292
10		.2835	.2743	.2378	.2926	.2835	
11		.2481		.2378	.2561	.2126	
12	.2378	.2303			.2378	.2126	.2926
13	.2378	.2126	.2195		.2561	.2126	.2378
14		.2481	.2378	.2012	.2743	.1772	.1829
15		.2126	.2378	.2012	.2743	.1772	.2012
16	.2561	.2481	.2378	.1829	.2172	.2126	.2195
17	.2926	.2835	.2926		.3109	.2835	.2378
18	.3109	.3012	.3475	.3292	.3841	.3012	.2378
19	.4755	.3366	.3841	.3841	.4024	.3544	.4344
20	.439	.4784	.4207	.4755	.4706	.4784	.5121
21	.4024	.4252	.4207	.439	.439	.4252	.4755
22	.3475	.3898	.3658	.3475	.3658	.3544	
23	.2743	.3012	.2926	.2896	.2896	.3366	.3109
24	.2481	.2561	.3012	.2743	.2534	.2715	
Max	.4755	.4784	.4207	.4755	.4706	.4784	.5121
Min	.2378	.2126	.2195	.1829	.2172	.1772	.1829
Avg	.3066	.2882	.3042	.2925	.3101	.2995	.3112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 206 / 11KV Krishna Feeder

HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3361	.3772	.3772	.1698	.0754	.0934
4	.3734	.3772	.3772	.1698	.0732	.0934
5	.3734	.3961	.3772	.1698	.0732	.0934
6	.3734	.3961	.3772	.1886	.0724	.0934
7	.3734	.3772	.3961	.3961	.0732	.1307
8	.3734	.3772	.3734	.3961	.0732	.1494
9		.3772	.3734	.3772	.0716	.0754
10		.3734	.3734	.3772		.0943
11		.3734	.3734	.3395		.1132
12	.3772	.3734		.3395		.0943
13	.3395	.3734		.3395		
14		.3734	.3772	.2829		.0754
15		.3734	.3772	.1509	.0934	.0754
16	.3772	.3734	.3772	.1509	.0934	.0754
17	.3772	.3547		.1509	.0934	.0754
18	.3395	.3547	.3734	.132	.0934	.0754
Max	.3772	.3961	.3961	.3961	.0934	.1494
Min	.3361	.3547	.3734	.132	.0716	.0754
Avg	.3649	.3751	.3772	.2582	.0805	.0939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 207 / 11KV Vijay-Ganesh

HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2303	.2957	.1829	.0181	.0181	.0177
4	.2481	.3326	.1829	.0181	.0181	
5	.2835	.3658	.2012	.0183	.0181	
6	.3544	.3801	.2012	.0183	.0181	
7	.3366	.3658	.2218	.1086	.0181	
8	.3721	.362	.2033	.1991	.0181	
9		.3982	.3142	.2172	.0179	
10		.3721	.3142	.1086	.0177	
11		.3721	.3142	.1097	.0177	
12	.3881	.3721		.1097	.0177	.0181
13	.362	.3721		.1086	.0177	.0183
14		.3721	.3326	.1109	.0177	.0181
15		.2481	.3326	.1097	.0177	.0181
16	1.6289	.3544	.2587	.1097	.0177	.0181
17	.3696	.3898		.1097	.0177	.0181
18	.3696	.3898	.2561	.1097	.0177	.0181
Max	1.6289	.3982	.3326	.2172	.0181	.0183
Min	.2303	.2481	.1829	.0181	.0177	.0177
Avg	.4494	.3589	.2551	.099	.0179	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 208 / 11 KV Bubnal Express

HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.1448	.1086	.1086	.1086	.124
4		.1829	.1109	.1097	.1075	.124
5		.181	.1294	.1097	.1075	.124
6		.1829	.2402	.128	.1254	.124
7		.1829	.2402	.1829	.0895	.124
8		.1829	.2378	.2012	.0905	.124
9		.2353	.2926	.2033	.0895	.0905
10		.2378	.2926	.2033		.0905
11		.2926	.2926	.1829		.0914
12	.2957	.2926	.2926	.1829		.0914
13	.2896	.2715	.2926	.128	.124	.0905
14	.2896	.2896	.2926	.128		.0905
15	.2743	.2957	.2987	.1463	.1063	.0905
16	.2926	.2957	.2987	.128	.1063	.0914
17	.2926	.2378	.2402	.1463	.1063	.0914
18	.2587	.2378	.1848	.1463	.1063	.0905
Max	.2957	.2957	.2987	.2033	.1254	.124
Min	.2587	.1448	.1086	.1086	.0895	.0905
Avg	.2847	.2340	.2403	.1522	.1056	.1033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 201 / 11 KV Nandani Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.7362	.0173	.0175	.0171	.0171	.2835
2	.7922	.7011	.0171	.0175	.0171	.0173	.2835
3	.7922	.7011	.0173	.0175	.0173	.0171	.2835
4	.7842	.7362	.0171	.0175	.0171	.0171	.2835
5	.7842	.8063	.0171	.0175	.0171	.0171	.3045
6	.7202	.8413	.0171	.0175	.0173	.0171	.3224
7	.9808	.8764	.0171	.0175	.0171	.0173	.4252
8	.0177	.0175	.0171	.0175	.0171	.0173	.0175
9	.0175	.0171			.6241	.5228	.0175
10	.0175	.0171			.583	.4805	.0175
11	.0175	.0171			.583	.4435	.0175
12	.0175	.0171			.5487	.4024	.0175
13	.0175	.0171	1.1218		.5548	.439	.0175
14	.0175	.0171	1.134	.7712	.5201	.4024	.0175
15		.0173	1.1458	.7362	.4973	.4024	.0175
16		.0171	1.1576	.7011	.5144	.4024	.0175
17		.0171	.0177	.0175	.0171	.0168	.0175
18		.0173	.0175	.0175	.0173	.017	.0175
19	.0175	.0171	.0175	.0175	.0171	.017	.0175
20	.0175	.0171	.0175	.0175	.0171	.0168	.0175
21	.0175	.0171	.0177	.0171			.0175
22	.7362	.0173	.0177	.0171			.2103
23	.7362	.0171	.0175	.0171	.0171	.2804	.2103
24	.7842	.7362	.0173	.0175	.0171	.0171	.2804
Max	.9808	.8764	1.1576	.7712	.6241	.5228	.4252
Min	.0175	.0171	.0171	.0171	.0171	.0168	.0175
Avg	.4039	.2671	.2418	.1309	.2121	.1817	.1305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 202 / 11 KV Nandani Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2103	.2401	.2454	.2601	.2572	.2804
2	.2641	.2103	.2427	.2454	.2401	.2401	.2481
3	.2641	.2103	.2401	.2454	.2427	.2401	.2481
4	.2987	.2454	.2572	.2804	.2401	.2401	.2835
5	.3734	.298	.3086	.3155	.2743	.2601	.3224
6	.4108	.3681	.3601	.3681	.3429	.3429	.3582
7	.415	.3856	.3601	.3856	.3772	.3944	.4075
8	.3721	.3856	.3772	.3856	.3772	.3814	.3506
9	.3506	.3601	.3395		.3429	.3361	.3155
10	.3155	.3258	.3206		.3294	.3511	.3155
11	.3155	.2743	.3361		.2915	.3326	.3506
12	.3506	.3429			.0343	.3292	.3155
13	.2454	.3294			.0347	.3109	
14		.2229		.3506	.2743	.1829	
15		.2947		.298	.2915		
16		.3294	.4108	.333		.2195	
17		.2915	.3366	.3681		.3018	.298
18		.2774	.4031	.3506		.39	.3155
19	.3681	.2743	.4908	.964		.3391	.3155
20	.4031	.4458	.4908	.4031		.4024	.4031
21	.3856	.3641	.3898	.3467			.3681
22	.3506	.3258	.3189	.2947			.3439
23	.3155	.2601	.2804	.2572	.2774	.2804	.298
24	.2614	.2454	.2401	.2804	.2572	.2572	.2804
Max	.415	.4458	.4908	.964	.3772	.4024	.4075
Min	.2454	.2103	.2401	.2454	.0343	.1829	.2481
Avg	.3329	.3032	.3372	.3536	.2640	.3043	.3209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 203 / Ganesh Bakery

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1227	.12	.1052	.1029	.1387	.1063
2	.1132	.1227	.12	.1052	.1029	.1029	.1063
3	.1132	.1227	.12	.1052	.1029	.1029	.1063
4	.1307	.1227	.1214	.1227	.1029	.104	.124
5	.1494	.1578	.1372	.1402	.1387	.12	.1791
6	.168	.1928	.1715	.1753	.1886	.1543	.197
7	.2452	.2279	.1715	.1928	.2058	.2058	.2126
8	.2658	.2454	.2427	.2454	.2774	.208	.2454
9	.2629	.2572	.2641		.2804	.2427	.2896
10	.2804	.2774	.2452		.2601	.2218	.2896
11	.3155	.2572	.2801		.2601	.2218	.3155
12	.3506	.2743	.2743		.2572	.2195	.3155
13		.2601	.2103		.2572	.2378	.298
14		.2229	.1829	.2629	.2601		
15		.2401	.2402	.2454	.2401		
16		.2229	.2241	.2454	.2601	.2743	
17		.2229	.2126	.2454	.2572	.2012	.2454
18		.2058	.1928	.2279	.2601	.2204	.2103
19	.2103	.2058	.1928	.2103	.2229	.2035	.2103
20	.2103	.2229	.1753	.1928	.2103	.2012	.2103
21	.2103	.2058	.1595	.1715			.2103
22	.1753	.0347	.1417	.1715			.1928
23	.1402	.104	.1227	.1715	.1543	.1402	.1753
24	.1307	.1227	.12	.1227	.1372	.1387	.1227
Max	.3506	.2774	.2801	.2629	.2804	.2743	.3155
Min	.1132	.0347	.12	.1052	.1029	.1029	.1063
Avg	.2002	.1938	.1851	.1821	.2063	.1830	.2077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 204 / 11 KV Agar Village

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2103	.208	.2103	.208	.2058	.1928
2	.2263	.2103	.2058	.1928	.2058	.208	.1772
3	.2263	.2103	.2058	.1928	.2058	.2058	.1772
4	.2427	.2103	.2254	.1928	.2058	.2058	.1772
5	.2614	.2279	.2229	.1928	.2058	.2058	.2149
6	.2801	.2279	.2427	.2103	.2058	.2058	.2328
7	.2829	.2454	.2743	.2279	.2401	.2427	.2481
8	.3012	.2629	.3121	.2279	.2601	.2601	.3155
9	.2804	.2572	.2829		.2572	.2801	.298
10	.3155	.2572	.2641		.2427	.2218	.298
11	.298	.2427	.2987		.2427	.2587	.298
12	.2629	.0514	.2378		.2427	.2743	.298
13	.2629	.0514	.2454		.2774	.2378	.2804
14	.2454	.0514	.2012	.2103	.2401		.2804
15		.1886	.2402	.1753	.2254		.2629
16		.1886	.2614	.1753	.2743	.2012	.2454
17		.2058	.2126	.2103	.2572	.218	.2454
18		.2254	.2454	.2804	.2427	.2543	.2279
19	.2279	.2572	.2804	.333	.3121	.3052	.2279
20	.2454	.3681	.3155	.3681	.3429	.285	.3155
21	.2804	.3641	.2835	.3258			.298
22	.2454	.2947	.2481	.2743			.2454
23	.2103	.2401	.2454	.2229	.2058	.2103	.2103
24	.2241	.2103	.2254	.2103	.2058	.2058	.2103
Max	.3155	.3681	.3155	.3681	.3429	.3052	.3155
Min	.2103	.0514	.2012	.1753	.2058	.2012	.1772
Avg	.2573	.2191	.2494	.2333	.2412	.2346	.2491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 205 / 11KV Dharangutti Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.4899	.0343	.0351	.0347	.0347	.2835
2	1.6975	1.4899	.0343	.0351	.0347	.0347	.2835
3	1.6975	1.4899	.0343	.0351	.0343	.0514	.2835
4	1.643	1.5074	.0347	.0351	.0347	.052	.2835
5	1.643	1.5074	.0343	.0351	.0343	.0514	.3045
6	1.643	1.5424	.0347	.0351	.0343	.052	.3045
7	1.8861	1.5424	.0514	.0351	.0343	.0343	.4607
8	.0354	.0351	.0514	.0351	.0347		.0351
9	.0351	.0343	2.1691		1.3375	.5601	.0351
10	.0351	.0347	2.2634		1.286	.5175	.0362
11	.0351	.0351	2.4272	2.191	1.3203	.499	.0351
12	.0351	.0351		2.1209	1.2346	.4755	.0351
13		.0514		2.0683	1.1789	.4207	
14		.0514		.0351	.8916	.4207	
15		.0514		1.9105	.8764		
16		.052	2.4646	1.9105		.4024	
17		.0514	.0354	.0351		.0335	.0351
18		.0347	.0351	.0351		.0339	.0351
19	.0351	.052	.0351	.0351		.0339	.0351
20	.0351	.0514	.0351	.0351		.0335	.0351
21	.0351	.0514	.0354	.0343		.0335	.0351
22	1.4548	.0514	.0354	.0343			.2279
23	1.4899	.0514	.0351	.0343	.0343	.2804	.2279
24	1.6804	1.4899	.0343	.0351	.0343	.0343	.2804
Max	1.8861	1.5424	2.4646	2.191	1.3375	.5601	.4607
Min	.0351	.0343	.0343	.0343	.0343	.0335	.0351
Avg	.9341	.5326	.4957	.4907	.4982	.1947	.1646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 201 / MINCHE AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3239	.1943			.1966	.2058
2	.3696	.3239	.1966			.1966	.2058
3	.3734	.3239	.1966				.2058
4	.3734	.3239	.1966			.1966	.2058
5	.3887	.3239	.1966			.1966	.2743
6	.583	.6802	.2294			.2622	.3772
7	.7773	.7773	.2622			.2622	.4801
8	.2591	.1943	.1966			.2622	.2401
9	.2267	.1619	.9069			.3277	.1943
10		.1619	1.0486	.7449	.4915	.2949	.1943
11	.1966	.1715	.9717	.7449	.4588	.3563	.1943
12	.1966	.1715	.9069	.6554	.4588	.3887	.1943
13	.1966	.1372	.5182	.6154	.426	.4534	.1943
14	.1966	.1372	.583	.5761	.426		.1619
15		.1372	.6478		.3932		.1619
16	.1966	.1715	.6478		.3605	.421	.1619
17	.2294		.0648	.1638	.2058	.2267	.1619
18	.2294	.1372	.2915	.1966	.1715	.2058	.1943
19	.2915	.1943	.3086	.2915		.2401	.2591
20	.3239	.2622	.3086	.2915		.2743	.2591
21	.3239	.2591	.3086	.2622		.2743	.2591
22	.3887	.2622	.2743	.2622	.2622	.2374	.2915
23	.3887	.2622	.2401	.2294	.2294	.2058	.1619
24	.3696	.3239	.2267			.1943	.2058
Max	.7773	.7773	1.0486	.7449	.4915	.4534	.4801
Min	.1966	.1372	.0648	.1638	.1715	.1943	.1619
Avg	.3295	.2705	.4135	.4195	.3531	.2702	.2269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 202 / NARANDE Ag FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.0648	.5761		.3239	.2241	.0686
2	.0972	.0648	.5121		.3239	.2241	.0686
3	.0972	.0648	.5761		.3239		.0686
4	.0972	.0648	.5761		.3239	.192	.0686
5	.0972	.0648	.5761		.3239	.192	.0686
6	.0972	.0648	.7042		.4534	.192	.0686
7	.0972	.0648	.8002		.6478	.4801	
8	.0648	.0648	.064		.0648	.096	
9	1.166	1.4251	.064		.0648	.096	
10		1.4251	.064	.0648	.0686	.096	.1296
11	1.2803	1.0364	.0648	.0655	.0686	.0972	.1296
12	1.2803	1.3108	.0648	.0648	.0686	.0648	
13	1.2163	.7209	.0972	.064	.0686	.0648	.0972
14	1.2163	1.166	.0648	.0655	.0686		.1296
15		1.166	.0972	.0648	.0686		.3239
16	1.0883	1.166	.0648	.0648	.0686	.0648	.3239
17	.064		.0648	.064	.0686	.0648	.1638
18	.064	.0686	.0972	.064	.0686	.1029	.1619
19	.0648	.128	.1372	.0648		.1029	.0648
20	.0648	.128	.1372	.0655		.1029	.0972
21	.0648	.128	.1372	.0655		.0686	.0983
22	.0648	.6401	.583	.3239	.2561	.0686	.0648
23	.0648	.6081	.583	.3239	.2561	.0686	.0648
24	.0972	.0648	.5761		.3239	.2241	.0686
Max	1.2803	1.4251	.8002	.3239	.6478	.4801	.3239
Min	.064	.0648	.064	.064	.0648	.0648	.0648
Avg	.3883	.5087	.3034	.1018	.2049	.1375	.1165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 203 / KHOCHI AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0648	.7209	.5243	.3239	.1966	.0686
2	.0648	.0648	.7209	.5243	.3239	.1966	.0686
3	.0648	.0648	.7209	.5243	.3239		.0686
4	.0648	.0648	.7209	.5243	.3239	.1966	.0686
5	.0648	.0648	.7209	.5243	.3239	.1966	.0686
6	.0648	.0648	.7209	.5898	.3239	.2294	.0686
7	.0648	.0648	.852	.7537	.5182	.3605	.0686
8	.0648	.0648	.0655	.0686	.0648	.0655	.0686
9	1.5223	1.749	.0655	.0686	.0648	.0655	.3239
10		1.7814	.0648	.0648	.0686	.0655	.3887
11	1.5729	1.7814	.0648	.0328	.0686	.0648	.3887
12	1.5729	1.6518	3.4332	.0324	.0686	.0655	.3887
13	1.5074	1.5546	.0972	.0324	.0686	.0648	.3887
14	1.5074	1.587	.0648	.0328	.0686		.2915
15		1.587	.0648	.0324	.0686		.3239
16	1.4419	1.5546	.0648	.0324	.0686	.0648	.3239
17	.0655	.0686	.0648	.0655	.0686	.0648	.0648
18	.0655	.0686	.0648	.0655	.0686	.0686	
19	.0648	.0655	.0686	.0648		.0686	
20	.0648	.0655	.0686	.0655		.0686	
21		.0655	.0686	.064		.0686	
22		.7865	.5182	.3277	.1966	.0686	
23		.7537	.5182	.3239	.1966	.0686	.0648
24	.0648	.0648	.7209	.5243	.3239	.1966	.0686
Max	1.5729	1.7814	3.4332	.7537	.5182	.3605	.3887
Min	.0648	.0648	.0648	.0324	.0648	.0648	.0648
Avg	.5247	.6543	.4690	.2443	.1869	.1193	.1876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 204 / BENDAVADE AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4588	.4858	.0648	.0686		.0655	.0686
2	.4641	.4858	.0648	.0686		.0671	.0686
3	.4641	.4858	.0648	.0686			.0686
4	.4641	.4858	.0648	.0686		.0648	.0686
5	.4641	.4858	.0648	.0686		.0648	.1372
6	.5304	.7449	.0648	.0686		.0648	.2401
7	.7956	.8097	.0648	.0686		.0655	.3429
8	.0648	.0648	.0648	.0686		.0655	.0686
9	.0648	.0648	1.4754	1.2308		.1638	.0648
10		.0648	1.5546	1.2803	.4858	.2949	.0648
11	.0671	.0686	1.5912	1.3603	.1966	.2984	.0648
12	.0671	.0686	1.6095	1.3108	.2622	.2652	.0648
13	.0671	.0686	1.5912	1.1336	.2622	.1989	.0648
14	.0671	.0686	1.5912	1.1336	.2622		.0648
15		.0343	1.6095	1.0364	.2622		.0648
16	.0671	.0686	1.5912	1.0364	.2622	.2294	.0648
17	.0648	.0686	.0663	.0648	.0686	.0663	.0648
18	.0648	.0686	.0648	.0648	.0686	.0686	
19	.0648	.0648	.0686	.0648	.0648	.0686	
20	.0648	.0648	.0686	.0655	.0648	.0686	
21	.0648	.0648	.0686	.0648	.0648	.0686	
22	.583	.0655	.0686	.0655	.0655	.0686	
23	.583	.0655	.0686	.0648	.0648	.0686	.0663
24	.4534	.4858	.0655	.0686		.0671	.0686
Max	.7956	.8097	1.6095	1.3603	.4858	.2984	.3429
Min	.0648	.0343	.0648	.0648	.0648	.0648	.0648
Avg	.2750	.2293	.5697	.4414	.1754	.1168	.0938

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 205 / BENDAVADE GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.112	.1086	.112		.1097	.112
2	.1086	.112	.1086	.112		.1097	.112
3	.1097	.112	.1086	.112			.112
4	.1086	.112	.1086	.112		.1097	.112
5	.1086	.112	.1086	.112		.1097	.112
6	.1448	.1494	.1448	.1494		.1829	.1494
7	.181	.1494	.1448	.1494		.1448	.1867
8	.1463	.1494	.1448	.1494		.1448	.1867
9	.1448	.1494	.1448	.1494		.1097	.1448
10		.1494	.1448	.1448	.1494	.1448	.1448
11	.1086	.112	.112	.1433	.1494	.1097	.1448
12	.1086	.112	.0732	.1448	.112	.1097	.1448
13	.1086	.112	.1086	.1448	.112	.1097	.1448
14	.1086	.112	.0724	.1433	.112		.1086
15		.112	.1086	.1448	.112		.1086
16	.1086	.112	.1086	.1448	.112	.1086	.1086
17	.1448	.112	.1086	.1448	.112	.1494	.1448
18	.1448	.1867	.1448	.181	.1494	.112	
19	.181	.2172	.1867	.2241	.181	.1867	
20	.2172	.2172	.2241	.2172	.2195	.1867	
21	.2172	.2172	.1867	.1829	.1829	.1867	
22	.1448	.181	.1494	.181	.1463	.1494	
23	.1086	.1448	.112	.1433	.1463	.112	.1086
24	.1086	.1086	.1086	.112		.1097	.112
Max	.2172	.2172	.2241	.2241	.2195	.1867	.1867
Min	.1086	.1086	.0724	.112	.112	.1086	.1086
Avg	.1350	.1402	.1280	.1481	.1426	.1331	.1315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 206 / Khochi Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2172	.1829	.1494	.1494	.1867	.1867
2	.1867	.2172	.1867	.1494	.1494	.1867	.1867
3	.1867	.2172	.1867	.1494	.1494		.1867
4	.1867	.2172	.1867	.1494	.1494	.1867	.1867
5	.2241	.2896	.2241		.2241	.2614	.1867
6	.2241	.2896	.2241		.2987		.2241
7	.2241	.2896	.2241		.2614	.2987	.2614
8	.2241	.2534	.2241		.2241	.2987	.2614
9	.2241	.2172	.2241		.2241	.2241	.2534
10		.2172	.1867	.181	.1867	.2241	.181
11	.1867	.2241		.1463	.1867	.1829	.181
12	.1494	.1867	.1494	.1448	.1867	.2172	.181
13	.1494	.1867	.1867	.1463	.2241	.2218	.181
14	.1494	.1867	.1867	.1433	.1867		.181
15		.1867	.1494	.1448	.1867		.1619
16	.1867	.1867	.1494	.1448	.1867	.1867	.1619
17	.1494		.1448	.1494	.2241	.1867	.3258
18	.1867	.2241	.1867	.2241	.2241	.2241	
19	.3258	.2614	.2614	.3258	.2987	.2987	
20	.3258	.2987	.2987	.3658	.2987	.2987	
21	.3258	.2987	.2987	.2865	.2987	.2987	
22	.2896	.2241	.2241	.2172	.2614	.2241	
23	.2172	.2241	.1867	.2241	.2241	.1867	.2241
24	.1867	.2172	.1867	.1494	.1867	.1867	.1867
Max	.3258	.2987	.2987	.3658	.2987	.2987	.3258
Min	.1494	.1867	.1448	.1433	.1494	.1829	.1619
Avg	.2135	.2318	.2026	.1890	.2163	.2290	.2052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 207 / Narand Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0724	.0747		.0732	.0747	.0747
2	.0732	.0724	.0747		.0732	.0747	.0747
3	.0732	.0724	.0747		.0732		.0747
4	.0732	.0724	.0747		.0732	.0747	.0747
5	.1097	.0724	.0747		.0732	.0747	.0747
6	.1097	.1448	.1494		.1097	.1494	.112
7	.1463	.1448	.1494		.1097	.1494	.1494
8	.1097	.1448	.112		.1097	.1494	.112
9	.1097	.1448	.112		.1097	.112	.1086
10		.1448	.112	.1086	.112	.112	.1086
11	.112	.112	.0747	.1086	.1494	.1463	.1086
12	.112	.112	.0732	.1086	.1494	.1109	.1086
13	.112	.112	.0732	.1097	.112	.1109	.1086
14	.0747	.112	.0747	.1075	.112		.1086
15		.112	.0747	.1086	.0747		.1086
16	.112	.0747	.0747	.1086	.0747	.1463	.1086
17	.112		.0732	.112	.112	.1463	.1463
18	.112	.112	.1109	.1494	.112	.1494	.1463
19	.1086	.1494	.1494	.181		.1867	.1478
20	.181	.1867	.1867	.1829		.1867	.1478
21	.181	.1494	.1494	.1463		.1494	.1494
22	.1448	.112	.112	.1086	.112	.112	.1097
23	.0724	.112	.0747	.1075	.0747	.0747	.0739
24	.0732	.0724	.0747		.0732	.0747	.0747
Max	.181	.1867	.1867	.1829	.1494	.1867	.1494
Min	.0724	.0724	.0732	.1075	.0732	.0747	.0739
Avg	.1084	.1137	.0994	.1249	.0987	.1222	.1088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 208 / Minche Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2534	.2561			.2195	.2241
2	.2587	.2534	.2561			.2195	.2241
3	.2587	.2534	.2561				.2241
4	.2587	.2534	.2561			.2195	.2241
5	.3326	.2534	.2561			.2561	.2614
6	.3696	.362	.3658			.3292	.3734
7	.4066	.4344	.3658			.439	.4108
8	.3696	.362	.3658			.439	.4108
9	.2957	.3258	.2926			.3658	.3258
10		.3258	.2195	.2896	.3734	.3292	.3258
11	.2926	.3361	.2218	.2896	.3361	.1848	.3258
12	.2926	.3361	.2218	.2561	.2987	.1867	.3258
13	.2561	.2241	.1463	.2507	.2241	.2241	.2896
14	.2561	.2241	.1296	.2534	.2241		.2241
15		.2614	.1296		.2241		.2241
16	.2926	.2987	.1296		.2614	.2614	.2241
17	.1097		.1848	.2896	.2614	.2987	.2241
18	.2926	.2987	.2987	.3292	.3361	.3361	.2614
19	.3982	.4024	.3734	.4344		.4108	.4108
20	.4344	.4755	.4481	.4344		.4481	.4108
21	.4344	.439	.4481	.3658		.4481	.3734
22	.3258	.4024	.2987	.3292	.3292	.3361	.3361
23	.2534	.3292	.2241	.2561	.2926	.2614	.2241
24	.2587	.2534	.2926			.2561	.2241
Max	.4344	.4755	.4481	.4344	.3734	.4481	.4108
Min	.1097	.2241	.1296	.2507	.2241	.1848	.2241
Avg	.3048	.3199	.2682	.3148	.2874	.3081	.2951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 209 / 11KV Buwache Wathar AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0297	.0312	1.0059	.9389	.2347	.1311	.0343
2	.0305	.0312	.9054	.9389	.2347	.1311	.0343
3	.0305	.0312	.9054	.9389	.2347		
4	.0316	.0312	.9054	.9389	.2347	.1311	
5	.0324	.0312	.9389	.9389	.2347	.1311	
6	.032	.0312	1.0059	.9724	.2683	.1638	
7	.0324	.0312	1.073	1.0059	.4024	.3018	.0343
8	.0324	.0312	.0328	.032	.032	.032	.0343
9	1.5223	1.7101	.032	.032	.032	.032	.1943
10		1.7101	.032	.032	.032	.032	.1943
11	1.6095	1.5089	.032	.032	.032	.0339	
12	1.6095	1.643	.032	.032	.032	.0328	
13	1.576	1.643	.032	.032	.032	.0335	.1619
14	1.576	1.643	.032	.032	.032	.0332	.1296
15		1.643	.032	.032	.032		.1296
16	1.5424	1.6095	.032	.032	.032		.1296
17	.032	.032	.032	.032	.032	.0305	.1296
18	.032	.032	.032	.032	.0328	.0686	.0324
19	.0324	.032	.032	.032	.032	.0686	.0324
20	.0324	.032	.032	.0321	.032	.0686	.0324
21	.0324	.032	.032	.032	.032	.0686	.0324
22	.0324	1.1065	.9389	.2347	.1677	.0343	.0324
23	.0324	1.0395	.9389	.2347	.1677	.0343	
24	.0324	.0312	1.0059	.9389	.2347	.1311	.0343
Max	1.6095	1.7101	1.073	1.0059	.4024	.3018	.1943
Min	.0297	.0312	.032	.032	.032	.0305	.0324
Avg	.4521	.6541	.4197	.3554	.1193	.0821	.0825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 210 / Khandoba AG (Bhendwade)

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3239	.032	.0343		.032	.1372
2	.2915	.3239	.032	.0343		.032	.1372
3	.2915	.3239	.032	.0343			.1372
4	.2915	.3239	.032	.0343		.032	.1372
5	.3239	.3239	.032	.0343		.032	.1372
6	.3239	.421	.032	.0343		.032	.1715
7	.4534	.421	.032	.0343		.032	.2058
8	.0324	.0324	.0312	.0343		.032	.0324
9	.0324	.0324	.8579	.8192		.1966	.0324
10		.0324	.9393	.852	.3277	.1966	.0324
11	.032	.0343	.9717	.8421	.3277	.2267	.0324
12	.032	.0343	.9717	.8192	.3277	.2241	.0324
13	.032	.0343	.9393	.8097	.3361	.1943	.0324
14	.032	.0343	.9717	.8002	.2622		.2214
15	.032	.0343	.9717		.2622		.0324
16	.032	.0343	.8745		.2622	.2267	.0324
17	.0312	.0343	.0324	.0328	.0343	.0324	.0324
18	.0312	.0343	.0324	.0328	.0343	.0343	.0324
19	.0324	.0312	.0343	.0328		.0343	.0316
20	.0324	.0312	.0343	.0328		.0343	.0316
21	.0324	.0312	.0343	.0324		.0343	1.6604
22	.3239	.032	.0343	.0324	.032	.1372	.0972
23	.3239	.032	.0343	.0324	.032	.1372	
24	.2915	.3239	.032	.0343		.032	.1372
Max	.4534	.421	.9717	.852	.3361	.2267	1.6604
Min	.0312	.0312	.0312	.0324	.032	.032	.0316
Avg	.1575	.1381	.3342	.2491	.2035	.0936	.1551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 401 / 33 kv Sharad Co-gen

Co-Generation Feeder

Feeder KV- 33 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1109	.1097	.1086		.1097	
2	.1086	.1109	.1097	.1029		.1097	
3	.112	.1109	.1097	.1086		.1097	
4	.112	.1109	.1097	.1086		.1097	
5	.1086	.1109	.1097	.1086		.1097	
6	.1086	.1109	.1097	.1086		.1097	
7	.1097	.1109	.1097	.1086		.1097	
8	.112	.1109	.1097	.1086		.1097	
9		.1109	.1097	.1086		.1097	
10		.1109	.1097	.1109	.1086	.1097	.1075
11	.1097	.1086	.1086	.1109	.1086	.0972	.1109
12	.1097	.1029	.0983	.1109	.1052	.0112	.1109
13	.1097	.1052	.0972		.1086	.1097	.1109
14	.1097	.1029	.1086		.1086		.1109
15		.1029	.1086		.1086		.1109
16	.1097	.1029	.1086		.1029	.1017	.1109
17	.1097	.1029	.1086	.1097	.1029	.112	.1086
18	.1097	.1029	.112	.1097	.1086	.1029	.1086
19	.1109	.1097	.1086	.1086		.1086	.1109
20	.1109	.1097	.1086	.1086		.1086	.1097
21	.1109	.1097	.1086	.1086		.1086	.1017
22	.1109	.1097	.1029	.1086	.1097		.1097
23	.1109	.1097	.1029	.1052	.1097		.1086
24	.112	.1109	.1097	.1086		.1097	
Max	.112	.1109	.112	.1109	.1097	.112	.1109
Min	.1086	.1029	.0972	.1029	.1029	.0112	.1017
Avg	.1103	.1083	.1079	.1086	.1075	.1034	.1093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 201 / 11KV Bhokari (Bhadole) AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.8192	.6241	.0469	.0324	.0305
2	.0191		.7865	.6081	.0625	.0324	.0305
3	.0191		.7865	.5921	.0625		.0305
4	.0191		.7865	.5921	.0625	.0324	.0305
5	.0191		.8192	.6081	.0781	.0324	.0305
6	.0191		.8192	.6009	.1094	.0324	.0305
7	.0191		.8356	.68	.1406	.0324	.0305
8	.0191		.0324	.0305		.0324	.0305
9	1.3443	1.2186	.0324	.0305		.0324	.0305
10		1.3279	.0324	.0305	.0305	.0324	
11	1.3927	1.3441			.0305		.0469
12	1.3763	1.3603			.0305		.0781
13	1.3763	1.2963			.0191	.0191	.0625
14	1.3272	1.3279			.0191	.0191	
15	1.3435	1.2643			.0305	.0191	
16	1.2944	1.2003				.0191	
17	1.2452	.0305			.0324	.0191	
18	1.1469	.0305		.0324	.0324	.0191	
19		.0324	.0305		.0324	.0305	
20		.0324	.0305		.0324	.0305	
21		.0324	.0305		.0324	.0305	
22		.852		.0492	.0324	.0305	
23			.6401	.0469	.0324	.0305	.0191
24	.0191		.8192	.6241	.0469	.0324	.0305
Max	1.3927	1.3603	.8356	.68	.1406	.0324	.0781
Min	.0191	.0305	.0305	.0305	.0191	.0191	.0191
Avg	.6677	.8107	.4867	.3678	.0474	.0281	.0365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 202 / 11KV Latwade AG Fdr

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.6226	.0324	.061		.0492	.112
2	.6554	.6226	.0328	.061		.0492	.112
3	.6554	.6226	.0328	.061			.0949
4	.6554	.5898	.0328	.061		.0655	.0949
5	.6554	.6062	.0328	.061		.0655	.112
6	.7045	.5898	.0328	.061		.0819	.112
7	.7701	.639	.0328	.061		.0819	.176
8	.0286		.0328	.061		.0819	.0305
9	.0286		1.2266	1.1012	.4424	.1823	.0305
10			1.2308	1.0364	.4001	.1638	
11	.0486	.0305			.3841		
12	.0324	.0305			.144		
13	.0324	.0305	1.4419		.1475	.1629	
14	.0324	.0305	1.3763		.1475	.1475	
15	.0324	.0305	1.3435		.144	.1638	
16	.0324	.0305				.1802	
17	.0324	.0305			.0486	.0191	
18	.0324	.0305		.0492	.0492	.0191	
19		.0328	.0457		.0486	.0305	
20		.0328	.0457		.0486	.0457	
21		.0324	.0457		.0486	.0457	
22	.6554	.0324			.0486	.112	
23	.639	.0324	.061		.0492	.112	.0983
24	.6554	.639	.0324	.061		.0492	.112
Max	.7701	.639	1.4419	1.1012	.4424	.1823	.176
Min	.0286	.0305	.0324	.0492	.0486	.0191	.0305
Avg	.3517	.2542	.3951	.2280	.1536	.0909	.0986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 203 / 11KV Latwade Village

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0732	.0905	.0867	.0914	.1097	.0857
2	.1086	.0732	.0724	.0686	.0732	.1097	.0686
3	.1086	.0914	.0724	.0686	.0732		.0686
4	.1086	.1097	.0905	.0686	.0732	.0914	.0686
5	.1448	.1097	.0905	.0857	.0914	.1097	.0857
6	.181	.1463	.1267	.12	.1463	.1463	.12
7	.1629	.1829	.1463	.1372	.1829	.1646	.1372
8	.1267	.1646	.1097	.12	.1829	.1463	.12
9	.0905	.1463	.1267	.12	.1829	.1097	.12
10		.128	.1267	.12	.1372	.1097	
11	.0914	.12			.12		.0914
12	.0914	.12			.1029		.0914
13	.0914	.1029	.0732		.0905	.1086	
14	.0549	.1029	.0732		.1086	.0724	
15	.0732	.1029	.0914		.0857	.0724	
16	.0549	.1029				.0724	
17	.0914	.1029	.0914		.1086	.0905	.0709
18	.1097	.0857	.1097	.1267	.1448	.1267	.128
19	.1463	.1463	.1402	.128	.181	.1543	
20	.1829	.1829	.1402	.1646	.2172	.1543	
21	.1646	.1646	.1402	.1463	.181	.1372	
22	.1463	.1463		.1097	.1629	.12	
23	.0914	.1097	.1029	.0914	.1086	.12	.1086
24	.1086	.0914	.0905	.0867	.0914	.1097	.1029
Max	.1829	.1829	.1463	.1646	.2172	.1646	.1372
Min	.0549	.0732	.0724	.0686	.0732	.0724	.0686
Avg	.1147	.1211	.1053	.1088	.1277	.1160	.0978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 204 / Laxmi AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.4214	.381	.1829	.1486	.0305
2	.0191		.4064	.3658	.1829	.1337	.0305
3	.0191		.4012	.3506	.2134		.0305
4	.0191		.4161	.3506	.2286	.1337	.0305
5	.0191		.4161	.3858	.2286	.1486	.0305
6	.0191		.4458	.4012	.2439	.1486	.0305
7	.0191		.4755	.4475	.2743	.1783	.0305
8	.0191		.0297	.0305		.0297	.0305
9	.8619	.823	.0297	.0305	.0305	.0297	.2134
10		.823	.0297	.0305	.0305	.0297	
11	.9633	.9374			.0305		.1829
12	.873	.9414			.0305		.1829
13	.9332	.884			.0191	.0191	
14	.8128	.8383			.0191	.0191	
15	.7827	.823			.0305	.0191	
16	.7526	.8078				.0191	
17	.7526	.0305			.0297	.0191	
18	.6622	.0305		.0297	.0297	.0191	
19		.0301	.0305		.0297	.0305	
20		.0301	.0305		.0297	.0305	
21		.0301	.0305		.0297	.0305	
22		.4515		.2134	.1635	.0305	
23		.4515	.3963	.2134	.1486	.0305	.0191
24	.0191		.4214	.381	.1981	.1486	.0305
Max	.9633	.9414	.4755	.4475	.2743	.1783	.2134
Min	.0191	.0301	.0297	.0297	.0191	.0191	.0191
Avg	.4203	.5288	.2654	.2580	.1093	.0665	.0671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 205 / Tasgaon LIS

HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
7	.1341	.3429	.3429
8	.3521	.3429	.3429
9	.3521	.3429	.3429
10		.3429	.3467
11	.3561	.3429	
12	.3681	.3429	
13	.3641	.3429	
14	.3681	.3429	
15	.3641	.3429	
16	.3721	.3429	
17	.3681	.3429	
18	.3467	.3429	
Max	.3721	.3429	.3467
Min	.1341	.3429	.3429
Avg	.3405	.3429	.3439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 401 / 33 KV GAGANBAWADA

LT Small Hydro Feeder

GENERATION F Feeder KV- 33 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.1285	1.701	1.9404	1.5123	1.2357	
2			1.6632	1.7558	1.4415	1.3169	1.3443
3		1.7741	1.6244	1.7741			1.3306
4			1.6244	1.6461			1.4003
5		1.5684	1.6461	1.6461			1.3306
6		1.5684	1.701	1.5524			1.4003
7		1.4969	1.773	1.5364			
8		1.6632	1.9879	2.0851			
9		2.1285	2.1399	2.1948	2.2177	2.1719	
10		2.2965		2.1622	2.2497	2.3525	
11		2.1948		2.3525	2.3045		
12		2.2028		2.2731	2.2731		
13		2.2028		2.2405	2.3045		
14	2.2731	2.2325		2.2405	2.3045		
15	2.3525	2.2325			2.3285		
16	2.3285	2.2565		2.2405	2.2965	1.9404	1.6804
17	2.2405	2.2028		2.2405	2.2497	2.0165	1.6244
18	2.2405	2.1948		2.1622	2.2731		1.7187
19	2.1845	2.1948	2.1285	2.1845	2.1948	1.9605	
20	2.1622	2.1491	2.0165	2.1285			
21	2.1622	2.0953	1.9605				
22	2.1068	2.0851			1.3969		
23	2.1845	1.8107	1.7741		1.386	1.6804	1.6409
24		2.1285	1.6632	1.9404	1.5844	1.3169	1.4003
Max	2.3525	2.2965	2.1399	2.3525	2.3285	2.3525	1.7187
Min	2.1068	1.4969	1.6244	1.5364	1.386	1.2357	1.3306
Avg	2.2235	2.0367	1.8146	2.0148	2.0199	1.7769	1.4871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 207 / 11 KV KARVIIR EXPRESS

HV Express Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0131	.0171	.0133			
2	.0171	.0131	.0171	.0137			
3	.0171	.0133	.0171	.0135			
4	.0171	.0133	.0171	.0139			
5	.0171	.0133	.0171	.0137			
6	.0171	.0128	.0171	.0133			
7	.0171	.0124	.0171	.0133			
8	.0171	.0124	.0171	.0066			
9		.0126	.0171	.012			
10				.0137	.0135		
11				.0137	.0135		
12		.0171		.0171	.0271		
13		.0171		.0171	.0135		
14		.0171		.0171	.0137	.0135	
15		.0171			.0092		
16	.0135	.0171			.0131		
17	.0135	.0171					
18	.0135		.0133	.0171			
19	.0135	.0171	.0135	.0171			
20		.0171	.0137	.0171			
21	.0137	.0171	.0133				.0171
22	.0133	.0171					
23	.0133	.0171	.0133				
24	.0171	.0133	.0171	.0133			
Max	.0171	.0171	.0171	.0171	.0271	.0135	.0171
Min	.0133	.0124	.0133	.0066	.0092	.0135	.0171
Avg	.0155	.0151	.0159	.0143	.0148	.0135	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 201 / 11 KV Shiye Ag Feeder

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	.0492	.2294	.3277	.1966	.0492	.0492
2	.0492	.0492	.2294	.3277	.1966	.0492	.0492
3	.0492	.0492	.2294	.3277	.1638	.0492	.0492
4	.0492	.0492	.2294	.3277	.1638	.0492	.0492
5	.0492	.0492	.3391	.6554	.2622	.0492	.0492
6	.0492	.0492	.6706	.3277	.2949	.0492	.0492
7	.0492	.0492	.6882	.7209	.3391	.0492	.0655
8	.0492	.0492	.0503	.0492	.0492	.1677	.0492
9	.6554	.663	.0503	.0328	.0492		.2949
10	.6882	.663		.0351			.2949
11	.2561	.663		.0526			.2949
12	.1829	.6299		.0537			.1966
13	.6882	.5967		.052		.1638	.1966
14	.6914	.5967		.0537		.1638	.2294
15	.7209	.5967	.0492	.104		.1966	.213
16	.7712	.663	.0492	.104		.1966	.2294
17	.0492	.0497	.0492	.1063		.0492	
18	.0492	.0492	.0492	.0819	.0492	.0671	.0819
19	.0492	.0492	.0492	.1052	.0492		.0819
20	.0492	.0492	.0492	.1063	.0492	.0492	.0819
21	.0492	.0492	.0492	.104	.0492	.0655	
22	.0492	.3113	.2458	.2601	.0492	.0655	
23		.2294	.3277	.2601	.0492	.0492	.0492
24	.0492	.0492	.2622	.3277	.2801	.0492	.0492
Max	.7712	.663	.6882	.7209	.3391	.1966	.2949
Min	.0492	.0492	.0492	.0328	.0492	.0492	.0492
Avg	.2344	.2626	.2051	.2043	.1432	.0857	.1287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 202 / 11KV Water Supply -Shiye
Feeder KV- 11 / OUTGOING

Gaathan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5937	.3953	.7023	.6325	.703	.7922	.6249
2	.5937	.3953	.7095	.6325	.6718	.7468	.5937
3	.5937	.3953	.7095	.6325	.6718	.7468	.5937
4	.6249	.3953	.7095	.6325	.6718	.7468	.578
5	.6562	.3953	.7023	.6325	.703	.7842	.5937
6	.703	.3953	.7095	.6325	.703	.8215	.6249
7	.7811	.4687	.7282	.6325	.703	.8962	.7499
8	.8592	1.1203	.7023	.7116	.828	.9149	.6562
9	1.2498	1.587	.6653	1.3441	.9842		.7186
10	1.5655	1.6975		1.7909			.703
11		1.587		1.9791			.5468
12		1.587	.5937	1.1385			.8592
13		.3125	.5624	.9962		.9488	.9374
14		1.2136	.5312	.9804		.9488	
15		1.4003		.759		.8697	
16		1.3203		1.0753		.9488	
17		1.587		1.0911		.8697	.9374
18		1.2986	.5535	.9061	.9242		.8697
19		.8779	.5535	.7907	.8865		.8697
20		.7316	.6325	.759	.9054	.68	.7907
21		.7947	.6325	.7432	.8299	.7116	
22		.7762	.6325	.7701	.7545	.6958	
23		.7577	.6325	.7116	.8676	.68	.7116
24	.6249	.3953	.7356	.6325	.703	.7922	.6483
Max	1.5655	1.6975	.7356	1.9791	.9842	.9488	.9374
Min	.5937	.3125	.5312	.6325	.6718	.68	.5468
Avg	.8042	.9119	.6525	.9003	.7819	.8108	.7162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 203 / 11KV TOP II AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.2883	.3018	.3391		.285	.2012
2	.2515	.2883	.1677	.3391		.285	.1844
3	.2515	.2883	.3018	.3391		.285	.1677
4	.2683	.2883	.3018	.3391		.285	.1677
5	.2683	.2883	.4359	.3391		.285	.1677
6	.285	.2883	.4694	.3391		.285	.2012
7	.285	.2883	.5197	.5087		.285	.2012
8	.285	.2883	.2683	.2713		.2683	.2012
9	1.5089	1.4251	.2683	.2883	.285		.218
10		1.6766		.2683			.218
11	1.7772	1.8442		.2347			.218
12		1.7604	.2683	.1017			.2012
13		1.7604	.2683	.1017		.2883	.2012
14		1.8442	.2683	.1017		.3174	
15		1.8442	.2683	.1017		.2883	
16		1.7604	.2683	.1017		.2883	
17		.3185	.218	.1017		.2713	.218
18		.3185	.2883	.1174	.285		.2035
19		.3185	.2883	.2204	.285		.2035
20		.3185	.2883	.2713	.285	.2035	.2035
21		.3185	.2883	.2883	.2591	.2035	
22		.3185	.3391	.3052	.285	.2035	
23		.3185	.3391	.2543	.285	.2035	.2035
24	.2515	.2883	.3018	.3391		.285	.2012
Max	1.7772	1.8442	.5197	.5087	.285	.3174	.218
Min	.2515	.2883	.1677	.1017	.2591	.2035	.1677
Avg	.5167	.7808	.3058	.2505	.2813	.2676	.1990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 204 / HANUMAN GAOTHAN FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1494	.1478	.1509		.1509	.1307
2	.1307	.1494	.1494	.1509		.1509	.1307
3	.1307	.1494	.1494	.1509		.1509	.1307
4	.1494	.1494	.1509	.1509			.1494
5	.1867	.1867	.1886	.1867		.1509	.1867
6	.2614	.2427	.2218	.2241		.1886	.2427
7	.2427	.2241	.2614	.2614		.2641	.2614
8	.2241	.2241	.1848	.2241		.2641	.2614
9	.2241	.2241	.1848	.2054			.2614
10		.2241		.1829			.2054
11		.2241		.1646			.1867
12		.2241	.1494	.1494			.168
13		.1867	.112	.1307		.1494	.0934
14		.1494	.0934	.1307		.1307	
15		.0934	.1494	.1307		.1494	
16		.1867	.1307	.1307		.1494	
17		.1494	.1307	.1307		.1867	
18		.2054	.1867	.2241	.2263		.2241
19		.2614	.2614	.2987	.3018		.2801
20		.2957	.2801	.2987	.3018	.3174	.3174
21		.2587	.2801	.2614	.2829	.2987	
22		.2263	.1867	.2241	.1886	.2427	
23		.1848	.1867	.1867	.1509	.168	.1867
24	.168	.1494	.1494	.1494		.1478	.1307
Max	.2614	.2957	.2801	.2987	.3018	.3174	.3174
Min	.1307	.0934	.0934	.1307	.1509	.1307	.0934
Avg	.1849	.1966	.1789	.1875	.2421	.1918	.1971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 202 / 11 KV NIGAWA GAVTHAN
Feeder KV- 11 / OUTGOING

Gaathan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.0953	.112	.1524	.0953	.112
2	.0953	.0953	.0953	.112	.1334	.0953	.1143
3	.0953	.0953	.0953	.1509	.1143	.0953	.1143
4	.0953	.0953	.0953	.1509	.1143	.0953	.1524
5	.1143	.1143	.1143	.1867	.1143	.1143	.1524
6	.2286	.1715	.1698	.1867	.1905	.1524	.1524
7	.2286	.2096	.2054	.1867	.2286	.1715	.1524
8	.2241	.1905	.2054	.1867	.1905	.2096	.1867
9	.168	.1905	.1848	.2012	.1524		.1886
10		.1905	.1294	.1848	.1524	.1867	.1886
11		.1715			.1524	.1867	.1509
12	.1478	.1494			.1524	.1829	.1867
13	.2218	.1494			.1143		
14	.1132	.1509			.0934		.112
15	.1132	.1494			.112	.1478	.1307
16	.1867	.1698			.1132	.1478	
17	.1494	.1867	.1867	.1867	.1509	.1867	.1867
18	.1867	.1867	.1867	.1867	.1886	.1867	.2614
19	.2241	.2987	.2241	.2241	.2401	.2241	.2987
20	.2241	.2987	.2987	.2263	.2033	.2561	.3018
21	.2054	.2241	.2241	.2241	.2054	.2195	.2263
22	.1886	.2075	.1494	.1524	.1494	.1905	
23	.1143	.132	.112	.1524	.0953	.1524	.1132
24	.1143	.0953	.1143	.112	.1524	.0953	.1143
Max	.2286	.2987	.2987	.2263	.2401	.2561	.3018
Min	.0953	.0953	.0953	.112	.0934	.0953	.112
Avg	.1615	.1674	.1604	.1735	.1528	.1615	.1713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 204 / 11KV AMBEWADI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0619	.0667	.0503	.0171	.0191	.0191	
2	.0619	.0705	.0503	.0171	.0191	.0191	
3	.0629	.0705	.0511	.0171	.0191	.0191	
4	.0648	.0705	.0511	.0171	.0191	.0191	
5	.0648	.0695	.0518	.0343		.0191	
6	.0812	.0834	.0511	.0343		.0191	
7	.108	.0987	.0518	.0343		.0381	
8	.0191	.0312	.0324	.0343		.0381	
9	.032	.0343	.1027	.0995		.0457	
10		.0343	.088	.0857		.0495	
11		.0343				.0293	
12	.0332	.0343			.0381	.0457	
13	.0328	.0343	.045		.0381		
14	.0324	.0343			.0381		.0191
15	.0168	.0343			.0343	.0152	.0191
16	.0164	.0343			.0343	.0152	
17	.0164	.0343	.0343	.0191	.0162	.0171	.0191
18	.0324	.0343	.0343	.0191	.0164	.0171	.0191
19	.016	.0343	.0343	.0191	.0164	.0171	.0191
20	.017	.0343	.0343	.0191	.0191	.0171	.0191
21	.0339	.0343	.0343	.0191	.0191	.0171	.0191
22	.0823	.0518	.0343	.0191	.0191	.0171	
23	.08	.0518	.0343	.0191	.0191	.0171	.0191
24	.0619	.0667	.0488	.0343	.0191	.0191	
Max	.108	.0987	.1027	.0995	.0381	.0495	.0191
Min	.016	.0312	.0324	.0171	.0162	.0152	.0191
Avg	.0467	.0491	.0481	.0310	.0238	.0241	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 205 / 11 KV Kerli Ag.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524			.1372	.1467		.1372
2	.1524			.1715	.1524		.1372
3	.1524			.1715	.1524		.1372
4	.1524			.1715	.1524		.1372
5	.1524			.2058	.1524		.1372
6	.1524			.2058	.1966		.1372
7	.1524			.3429	.2743	.1402	.1543
8	.1524			.1372	.1524		.1372
9	.2439	.3429	.1524		.1524		.2103
10		.4115	.1524		.1524	.1524	.2103
11		.4115			.1524	.1524	.1715
12	.1875	.3429			.1143	.1524	.1734
13	.282	.3429	.1524		.1143	.1524	
14	.2347	.3429	.1524		.1143	.1524	.1433
15		.4115			.1029	.1524	.1387
16	.1974	.4115			.1029	.1524	
17		.1372		.1524		.1372	.1524
18		.1372		.1524		.1372	.1524
19		.1372	.1372	.1524		.1372	.1524
20		.1372	.1372	.1524		.1372	.1524
21		.1372	.1029	.1524		.1372	.1524
22			.1543	.1677		.1372	
23			.1372	.1581		.1372	.1143
24	.1524			.1372	.141		.1372
Max	.282	.4115	.1543	.3429	.2743	.1524	.2103
Min	.1524	.1372	.1029	.1372	.1029	.1372	.1143
Avg	.1798	.2849	.1420	.1730	.1486	.1445	.1512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 206 / 11 KV VILLAGE

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4191	.4572	.4481	.3772	.381	.3734
2	.381	.4191	.4191	.4481	.3772	.381	.3734
3	.381	.4191	.4191	.5601	.381	.381	.3734
4	.381	.4572	.4191	.7095	.381	.381	.6722
5	.4572	.5281	.5335	.7468	.3772		.6722
6	.7621	.7468	.8962	.8215	.7468	.6722	.7545
7	.8131	.7392	.5975	.8215	.8215	.8871	.8215
8	.8048	.8413	.6584	.8962	.8779		.8215
9	.724	.8048	.6584	.8048	.7842		.7392
10		.8215	.5792	.8131	.7468	.4961	.7964
11		.7468		.6878	.6722		.6447
12	.7164	.7095			.5975	.5487	.5373
13	.4066	.6036			.5975	.7087	
14	.543	.5975			.5228		.567
15		.4481			.5228	.6447	.5792
16	.6379	.4481			.5975	.6447	
17	.4748	.7095	.6089	.5068	.7164	.8779	.6447
18	.6935	.7468	.7095	.7392	.7964	.9511	.6516
19	.8048	.7468	.7164	.8215	.8871	1.0456	.8131
20	.8962	.8962	.8215	.8299	.8215	.8215	.8962
21	.8299	.8299	.7468	.7545	.8215	.7842	.8215
22	.6859	.7545	.5975	.6413	.6036	.7167	
23	.5335	.5335	.5228	.4572	.4572	.4527	.5281
24	.4191	.4024	.4572	.4527	.3772	.4191	.415
Max	.8962	.8962	.8962	.8962	.8871	1.0456	.8962
Min	.381	.4024	.4191	.4481	.3772	.381	.3734
Avg	.6079	.6404	.6010	.6821	.6193	.6418	.6427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 207 / 11 KV Nigave Ag.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.1562	.1562	.1372	.0762	.0924	.1029
2	.208	.1543	.1562	.1372	.0762	.0924	.1029
3	.2614	.1543	.1581	.1372	.0762	.0914	.1029
4	.2439	.1562	.1562	.1372	.0762	.0914	.1029
5	.2778	.1875	.1852	.1372	.0762	.0914	.1029
6	.4321	.3163	.2469	.1372	.0953	.1097	.1029
7	.8535	.7042	.4999	.1372	.1524	.1478	.1372
8	.1334	.0983	.0972	.1372	.1143	.1478	.1372
9	.0914	.1372	.5247	.4938	.3429	.2641	.1143
10		.1372	.5556	.4961	.3429	.0886	.1143
11		.1372			.3429	.2214	.0953
12	.1097	.1029			.3429	.192	.0762
13	.0724	.1029	.4108		.3086		
14	.0724	.1029			.2743		.0762
15	.1086	.1029			.2743	.2214	.0953
16	.1086	.1029			.2058	.3163	
17	.112	.1372	.1029	.1143	.0876	.1029	.0762
18	.1326	.1372	.1372	.1143	.0876	.1372	.0762
19	.1227	.1372	.1372	.1143	.124	.1372	.1143
20	.1063	.1372	.1372	.1143	.1086	.1372	.1334
21	.1063	.1372	.1372	.1143	.1097	.1372	.1524
22	.1875	.1943	.1029	.1143	.1097	.1372	
23	.1562	.192	.1029	.1143	.0934	.1029	.192
24	.2134	.1562	.192	.1029	.1143	.0924	.1029
Max	.8535	.7042	.5556	.4961	.3429	.3163	.192
Min	.0724	.0983	.0972	.1029	.0762	.0886	.0762
Avg	.1965	.1701	.2209	.1661	.1672	.1433	.1100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 208 / 11 KV Panhala Feeder
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2667	.3048	.3734	.3018	.3048	.3361
2	.3018	.2667	.3048	.3734	.3048	.3048	.3361
3	.3048	.2667	.3048	.3734	.3048	.3048	.3361
4	.3048	.2667	.3048	.4108	.3048	.3048	.3734
5	.381	.3429	.3429	.4108	.3395		.4481
6	.4904	.4527	.4904	.4854	.4904	.415	.4481
7	.5281	.5228	.4854	.5601	.5658	.5228	.4854
8	.5228	.5281	.5601	.5228	.5228	.4805	.4854
9	.5281	.5228	.5601	.5228	.5228	.5175	.5175
10	.4854	.4481	.5175	.4527	.5228	.4108	.4805
11	.5175	.4481			.4854	.0754	.4066
12	.4435	.3734			.3734	.4024	.4108
13	.4066	.3734	.3734		.3734	.4108	
14	.3734	.3772	.3361		.3734	.3326	.3734
15	.3361	.3734			.4108	.3326	.3326
16	.3696	.4481			.4527	.362	.3982
17	.4706	.5228		.4435	.4435	.4108	.439
18	.4755	.5601		.5228	.5228	.5228	.5544
19	.6722	.5601	.7095	.6413	.6722	.5601	.6036
20	.7468	.5975	.7095	.679	.7167	.5601	.679
21	.6413	.6348	.7468	.679	.7167	.5228	.6413
22	.5335	.5658	.4854	.5281	.5335	.5228	
23	.3429	.381	.4854	.3772	.3292	.4481	.3429
24	.3018	.2667	.3048	.4854	.3018	.3048	.3361
Max	.7468	.6348	.7468	.679	.7167	.5601	.679
Min	.3018	.2667	.3048	.3734	.3018	.0754	.3326
Avg	.4492	.4319	.4626	.4912	.4536	.4058	.4438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 201 / 11 kv Yavaluj Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0343		.0177		.0152
2	.0362	.0343	.0167	.0175		.0152
3	.0373	.0343		.0175		.0305
4	.0366	.0343		.0177		.0305
5	.0366	.0343		.0177		.0305
6	.0366	.0339		.0175		.0305
7	.0549	.0678		.0175		.0305
8	.0175	.0187	.0188	.0175	.0167	.0152
9	.0175	.0187	.0761	.0362	.0305	.0152
10		.015	.0732	.0305	.0152	.0175
11	.0189		.0732	.0305	.0305	.0175
12	.0189	.019			.0305	.0175
13	.0187	.015			.0305	.0175
14	.0187	.015		.0305	.0305	.0175
15	.0187			.0305	.0305	
16	.0187	.0163	.0532	.0305	.0305	.0177
17	.0187		.0177		.0152	.0175
18	.0187		.0177	.0152	.0152	.0177
19	.0187	.0148	.0175		.0152	.0175
20	.0189		.0177		.0152	.0175
21	.0189	.0188			.0152	.0175
22	.0175				.0305	.0175
23	.0171		.0175		.0305	.0175
24	.0351	.0343	.019	.0175	.0188	.0152
Max	.0549	.0678	.0761	.0362	.0305	.0305
Min	.0171	.0148	.0167	.0152	.0152	.0152
Avg	.0255	.0270	.0349	.0226	.0236	.0198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 202 / 11 KV YEVALUJ VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0754	.0761	.0747	.0761	.061
2	.0747	.0754	.0761	.0747	.0761	.061
3	.0747	.0754	.0761	.0747	.0761	.061
4	.0934	.0754	.0761	.0747	.0761	.0762
5	.112	.1132	.0952	.0934	.1142	.0762
6	.1494	.1509	.1142	.112	.1332	.0914
7	.168	.1509	.1506	.1494	.1523	.1067
8	.1646	.168	.1696	.2054	.1332	.1067
9	.1307	.1494	.1713	.2054	.1067	.0914
10		.1523	.1867	.0122	.0914	.112
11	.1478		.1848	.0457	.061	.112
12	.1478	.1713	.0747		.0762	.1307
13	.1294	.1509	.0924	.0762	.1067	.1307
14	.1294	.1332	.0724	.0762	.1067	.1494
15	.1307		.0739	.0762	.1067	.112
16	.1494	.1523	.112	.0762	.1219	.1307
17	.1509		.1109		.1067	.168
18	.1494		.1097	.1372		.1867
19	.1886	.1903	.1494		.1524	.1867
20	.2263		.1867		.1677	.2054
21	.1886	.1903			.1524	
22	.1509				.0914	
23	.112		.1267		.0762	.1307
24	.0747	.0754	.1142	.0934	.0952	.0762
Max	.2263	.1903	.1867	.2054	.1677	.2054
Min	.0747	.0754	.0724	.0122	.061	.061
Avg	.1356	.1324	.1182	.0975	.1068	.1165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 203 / 11Kv Satarde sheti

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0175	.0189	.1129	.0747		.0152
2	.0177	.0189	.1128	.0747		.0152
3	.0177	.0189	.1016	.0724		.0152
4	.0177	.0189	.1199	.0732		.0152
5	.0177	.0189	.1334	.0914		.0152
6	.0177	.0189	.1369	.0914		.0152
7	.0177	.0189	.1711			.0152
8	.0177	.0187	.0171		.0188	.0152
9	.2801	.2058	.0169		.0152	.061
10		.1705	.0177	.0152		.0701
11	.1029		.0177	.0152		.0747
12	.1372	.1903	.0177	.0152		.0732
13	.12	.1631	.0183	.0152		.0543
14	.1029	.1648	.0175	.0152	.061	
15	.1029		.0177	.0152	.061	.0373
16	.12	.1711	.0175	.0152	.061	.0373
17	.0187		.0175		.0152	.0175
18	.0187		.0171	.0152	.0152	.0175
19	.0189	.0188	.0175		.0152	
20	.0189		.0175		.0152	
21	.0189	.015			.0152	
22	.0189				.0152	
23	.0189		.0724		.0152	.0177
24	.0175	.0189	.0934	.0732	.015	.0152
Max	.2801	.2058	.1711	.0914	.061	.0747
Min	.0175	.015	.0169	.0152	.015	.0152
Avg	.0546	.0747	.0583	.0448	.0260	.0314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 204 / Majgaon Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0177	.0189	.1703	.0532	.0646	.0304
2	.0177	.0189	.1597	.0549	.0638	.0304
3	.0175	.0189	.1914	.0543	.0635	.0304
4	.0175	.0189	.1907	.0724	.0794	.0304
5	.0177	.0189	.2574	.0747	.0457	.0304
6	.0177	.0189	.2912	.0747	.061	.0304
7	.0177	.0189	.3406	.0724	.1937	
8	.0177	.0189	.034	.0175	.0315	
9	.0532	.156	.0321	.0175	.0304	
10		.2193	.0177	.0152	.0304	
11	.0514	.1067	.0177	.0152	.0304	
12	.0514	.2207		.0152	.0304	.0354
13	.0514	.2201		.0152	.0304	.0358
14	.0514	.2055		.0152	.0304	.0354
15	.052	.0914		.0152	.0304	.0351
16	.052	.1587	.0175	.0152	.0304	.0354
17	.0189	.0152	.0177		.0304	
18	.0187	.0152	.0175	.0152	.0304	.0175
19	.0189	.0315	.0177		.0304	
20	.0189	.0152	.0175		.0304	
21	.0189	.0316			.0304	.0175
22	.0189	.0914			.0304	
23	.0189	.0914	.0549		.0304	.0177
24	.0177	.0189	.1617	.0175	.0946	.0304
Max	.0532	.2207	.3406	.0747	.1937	.0358
Min	.0175	.0152	.0175	.0152	.0304	.0175
Avg	.0284	.0767	.1115	.0350	.0481	.0295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 205 / Majgaon Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.132	.0952	.112	.1523	.1067
2	.1307	.132	.0952	.0934	.1332	.1067
3	.1307	.132	.0951	.0934	.1142	.1219
4	.1307	.132	.1142	.0934	.0952	.1219
5	.1494	.1509	.1331	.1494		.1372
6	.1867	.1867	.1694	.1867	.1713	.1677
7	.1867	.2241	.1903	.1867		.1981
8	.2054	.2241	.2284		.2284	.2134
9	.2241	.2402	.2284		.1829	.1981
10		.2474	.2241	.1829	.1981	.2195
11	.2218		.2241	.1829	.1829	.2054
12	.0554	.2284	.0175	.1829	.1524	.2054
13	.2218	.2284	.2427	.1677	.1677	.1867
14	.2033	.2277	.2427	.1524	.1829	.1867
15	.2218		.2614	.1524	.1981	.2054
16	.2218	.2284	.2614	.1677	.1981	.1867
17	.2241		.2801		.2134	
18	.2427		.2801	.2743	.2439	.2241
19	.2829	.3392	.2987		.2743	
20	.3395		.3361		.2896	
21	.2452	.3426	.2987		.2743	
22					.2286	
23	.1886		.1867		.1372	.1867
24	.1307	.1509	.1132	.1307	.1523	.1067
Max	.3395	.3426	.3361	.2743	.2896	.2241
Min	.0554	.132	.0175	.0934	.0952	.1067
Avg	.1943	.2086	.2007	.1568	.1896	.1729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 206 / 11 KV Satarde Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1509	.1523	.1307	.1903	.1219
2	.1494	.132	.1142	.1307	.1523	.1219
3	.1494	.132	.1142	.1307	.1142	.1219
4	.1494	.132	.1142	.1494	.1142	.1524
5	.1867	.1509	.1713	.1867	.1713	.1677
6	.2614	.2801	.2474	.2614	.2665	.1829
7	.3174	.2987	.3045		.3045	.2439
8	.2614	.2772	.3236		.3045	.2286
9	.2801	.2957	.3236		.2286	.2439
10		.2474	.2801	.2286	.1829	.2801
11	.2561		.2427	.2286	.1829	.2614
12	.2378	.2665		.1524	.1829	.2614
13	.2033	.2665		.1677		.2427
14	.2218	.2665		.1677	.2286	
15	.2587			.1829	.2743	.2427
16	.3326	.3045	.2427	.2134	.2896	.2987
17	.3361		.2614		.2439	.3361
18	.3361		.2987	.2896	.2743	.3921
19	.3734	.3997	.3547		.2896	
20	.415		.4108		.3048	
21	.3772	.3807			.2896	
22	.2801				.1981	
23	.1886		.1867		.1524	.1307
24	.1494	.1509	.1523	.1494	.2284	.1219
Max	.415	.3997	.4108	.2896	.3048	.3921
Min	.1494	.132	.1142	.1307	.1142	.1219
Avg	.2553	.2431	.2386	.1847	.2247	.2186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 201 / 11KV BORGOAN VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.016	.0187	.0351			
2	.0152	.0162	.0187	.0351		.0162	
3	.0152	.016	.0187	.0351		.0151	
4	.0152	.016	.0187	.0351		.016	
5	.0152	.032	.0373	.0351		.0164	
6	.0316	.0486	.0373	.0526		.0324	
7	.0486	.0486	.0709	.0509		.0503	
8	.0486	.0509	.0709	.0526		.048	
9	.0486	.048	.056			.048	.056
10	.0509	.0532	.0526	.0526	.0509	.048	
11	.0509	.0532	.0526	.0486	.048		.0526
12	.0497	.0532		.0486	.0486	.0373	.0526
13	.0452	.0532	.0509	.0486	.048	.0373	.0526
14	.0497	.0532	.0509	.0486		.0373	.0526
15	.0486	.0532	.0509	.0486		.0373	.0526
16	.0486	.0532	.0526	.0486		.0373	.0526
17	.0486	.0532	.0526	.0486	.0463	.056	.0526
18	.0503	.0532	.0526	.0486	.048		
19	.0509	.0532	.0532	.0663	.064		.0532
20	.0671	.0747	.0532		.0671		.0701
21	.0497	.056	.0701		.048		.0526
22	.0339	.0373			.032		.0351
23	.0156	.0373			.0168	.0187	
24	.0152	.016	.0373	.0351		.0168	.0187
Max	.0671	.0747	.0709	.0663	.0671	.056	.0701
Min	.0152	.016	.0187	.0351	.0168	.0151	.0187
Avg	.0387	.0436	.0465	.0460	.0471	.0334	.0503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 203 / 11KV PADASALI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.0328	.056	.0351		.0162	.0373
2	.0486		.056	.0351		.016	.0373
3	.0486	.0328	.056	.0351		.0164	.0373
4	.0486	.0347	.0532	.0351		.0162	.0373
5	.0486	.0328	.056	.0351		.032	.0373
6	.0648	.0335	.056	.0354		.0335	.0373
7	.0648	.032	.0747	.0351		.0324	.0373
8	.0305	.0312	.0373	.0351		.0324	.0373
9	.0305	.0324	.056				
10	.0339	.0354	.0526	.0526	.0486	.032	
11	.0328	.0354	.0526	.0486	.0328		
12	.0328	.0354		.0486	.048	.0373	
13	.0324	.0354		.0486	.0497	.0373	
14	.0332	.0354	.0526	.0486		.0373	
15	.0339	.0354	.0543	.0486	.0328	.0373	
16	.0335	.0354	.0526	.0486	.0324	.0373	
17	.0328	.0354	.0351	.0305	.032	.0373	
18	.0339	.0354	.0339	.0305	.0328		
19	.0503	.0354	.0351	.0305	.0324		
20	.0509	.0373	.0351		.048		
21	.0463	.0373	.0351				
22	.032						
23	.0316	.056			.032	.0373	
24	.0486	.0335	.056	.0351		.032	.0373
Max	.0648	.056	.0747	.0526	.0497	.0373	.0373
Min	.0305	.0312	.0339	.0305	.032	.016	.0373
Avg	.0414	.0355	.0498	.0396	.0383	.0306	.0373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 204 / 11 Kv Boragaon Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.032	.056			
2	.0486	.032	.056			
3	.0486	.0328	.056			
4	.0486	.0335	.056			
5	.0486	.0324	.056			
6	.0486	.048	.056			
7	.0648	.08	.0747			
9						.0162
10			.0351	.0526	.0168	.016
11			.0351	.0324	.016	
12				.0162	.017	.056
13			.0351	.0162	.0162	.056
14			.0351	.0162		.056
15			.0351	.0162		.0373
16			.0351	.0162		.0373
22	.048	.056				
23	.0328	.056				
24	.0486	.032	.056			
Max	.0648	.08	.0747	.0526	.017	.056
Min	.0328	.032	.0351	.0162	.016	.016
Avg	.0486	.0435	.0484	.0237	.0165	.0393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 205 / 11 KV PADASALI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0474		.0747	.0701		.0492	
2	.0474		.0747	.0701		.048	
3	.0474		.0747	.0701		.048	
4	.0474		.0709	.0701		.048	
5	.0648		.0934	.0876		.048	
6	.0995		.112	.1052		.048	
7	.116		.112	.1052		.048	
8	.116	.0838	.1307	.1227		.048	
9	.0995	.0819	.1307				
10	.1147	.0886	.1227	.1063	.1107	.081	.1052
11	.112	.0886	.1052	.0995	.0848		
12	.0819	.1063		.0995	.0926	.0934	.1052
13	.08			.116	.096	.112	.0876
14	.081		.1052	.116		.112	.0848
15	.064		.1052	.116		.1307	.0876
16	.0848	.1417	.1227	.116		.1494	.1052
17	.1017	.1772	.1227	.116	.0819	.112	.1052
18	.1357	.2126	.1402	.1492	.1147		
19	.1357	.2126	.1753	.1886	.1296		.1052
20	.1943	.2427	.2279		.112		
21	.1326	.1867	.1753				
22	.0625	.112					
23	.0633	.0747			.0463	.0747	
24	.0474	.048	.0747	.0701		.048	.056
Max	.1943	.2427	.2279	.1886	.1296	.1494	.1052
Min	.0474	.048	.0709	.0701	.0463	.048	.056
Avg	.0907	.1327	.1175	.1050	.0965	.0764	.0936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 206 / 11 KV KARANJFEN GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.081	.0934	.0876		.064	.0747
2	.081	.0848	.0934	.0876		.0655	.0747
3	.081	.0838	.0934	.0876		.0678	.0747
4	.081	.0972	.0934	.0876		.0678	.0747
5	.0972	.1134	.1307				.1307
6	.1492	.1844	.168				.1867
7	.1886	.2294	.2241	.1928			.2427
8	.2058	.2187	.2427	.2279			.2427
9	.2229	.2214	.2427	.0876		.16	.2427
10	.2105	.2658	.2103	.2374	.1543		.2279
11	.208	.2303	.2103	.2229	.16		
12	.2267	.2303		.2229	.192	.2054	.2279
13	.2241	.2303	.2103	.2058	.2204	.2241	.2279
14		.2303	.2103	.2058		.2241	.2279
15		.2303	.2103	.2058			.2279
16		.2303	.2279	.2058		.2614	.2454
17		.2658	.2454		.2187	.2614	.2454
18	.2591		.2629	.2572	.2429	.2801	
19	.3561	.3366	.3155	.333	.3563		.2629
20	.3052	.3734	.3681		.3841		
21	.3052	.3012	.3506				
22	.1696	.1949					.2454
23	.0926	.1307			.08	.112	
24	.0972	.0838	.112	.1227		.0655	.0934
Max	.3561	.3734	.3681	.333	.3841	.2801	.2629
Min	.081	.081	.0934	.0876	.08	.064	.0747
Avg	.1821	.2021	.2055	.1811	.2232	.1584	.1882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 201 / 11 KV KAKHE AG.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0762	.061	.2343	.0937	.1219	.0514
2	.0857	.0762	.061	.2343	.0937	.0914	.0514
3	.0857	.0762	.061	.2343	.0937	.0914	.0514
4	.0857	.0762	.061	.2343	.0937	.061	.0514
5	.0857	.0762	.061	.2343	.1562	.1524	.0514
6	.1029	.0762	.0762	.2812	.2656	.1524	.0686
7	.12	.1067	.0914	.5624	.4843	.1524	.0857
8	.0857	.061	.1067	.1029	.0686	.061	.0857
9	.6401	.5792	.1029	.0686	.0857	.1219	.2187
10		.6874	.0857	.0762	.0686	.1715	.1524
11	.6401	.7343		.0762	.0686		.1219
12	.6097	.7499			.0686		.1372
13	.6097	.7186	.0857	.061	.0514	.1219	.1219
14		.7811	.0857	.061	.0514	.0914	.1219
15		.7811	.0686	.061	.0686	.1219	
16	.6097	.8749	.0686	.061	.0686	.1524	
17	.0762	.061	.1029		.0686	.0686	.061
18	.061	.0762	.1029	.061	.0762	.1029	.0857
19	.061	.0762	.1029	.0762	.0914	.1029	.0857
20	.0914	.1067	.1029	.0762	.0762		.0857
21	.0914	.0914	.1029		.0762		
22	.0914	.0914	.2656		.1067		
23	.061	.0914	.2572		.0762		.0686
24	.1029	.0914	.061	.1875	.0937	.1524	.0514
Max	.6401	.8749	.2656	.5624	.4843	.1715	.2187
Min	.061	.061	.061	.061	.0514	.061	.0514
Avg	.2135	.3007	.0989	.1570	.1061	.1162	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 202 / 11KV KODOLI URBAN VILLAGE Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4801	.4268	.463	.4801	.3658	.4458
2	.4458	.463	.3963	.4458	.4801	.3353	.4287
3	.4458	.463	.3658	.4458	.4801	.3048	.4115
4	.5144	.463	.3963	.4458	.4801	.3658	.4115
5	.583	.5144	.5792	.5144	.5144	.4572	.4458
6	.6859	.6859	.6706	.6687	.703	.6097	.7202
7	.8059	.8059	.7316	.9431	.9088	.7621	.9259
8	.8916	.823	.7926	.8916	.8916	.8535	.9945
9	.7888	.8059	.8573	.7888	.9088	.7621	.8573
10		.823	.7545	.6706	.823	.7716	.7888
11	.6554	.7888		.6097	.6859		.7373
12	.6401	.7373			.6516		.7202
13	.6097	.6859	.6001	.5487	.583	.6516	.6173
14		.6516	.6001	.5182	.583	.7202	.583
15		.6516	.5487	.5182	.5487	.6859	
16	.5182	.583	.583	.5487	.5658	.583	
17	.6706	.6859	.6516		.6859	.7545	.7202
18	.8916	.7316	.7888	.8916	.884	.8916	.823
19	.9602	.823	.8745	1.0631	1.3717	1.1317	.9602
20	1.1317	1.0059	1.0802	1.166	1.0059		1.1145
21	.9945	.884	1.0117		.9145		
22	.8916	.7621	.8573		.6859		
23	.6173	.5487	.583		.5182		.6516
24	.4801	.4973	.4572	.4801	.4801	.3963	.4801
Max	1.1317	1.0059	1.0802	1.166	1.3717	1.1317	1.1145
Min	.4458	.463	.3658	.4458	.4801	.3048	.4115
Avg	.6985	.6818	.6640	.6643	.7014	.6335	.6919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 203 / 11 KV FACTORY VILLAGE

Gaathan Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4287	.3658	.4835		.381	.5373
2	.4801	.4287	.3658	.4477		.3658	.4656
3	.4801	.4287	.3353	.4477		.3353	.4477
4	.5144	.4287	.3658	.5014		.3658	.4656
5	.7888	.4801	.5182	.5552		.4572	.6268
6	.9259	.7545	.6706	.788		.6097	1.0029
7	1.166	.9774	.823	1.0745		.7926	1.2536
8	1.0288	.9774	.8535	1.1104	1.2536		1.182
9	.8402	.9774	.9259	.9492	1.1641	.8535	1.182
10		1.1104	.8573	.7011		.4801	1.0631
11	.6401	.8596	.823	.4877	.788		.9945
12	.4877	.6268	.2401		.7701		.8059
13	.6097	.591	.2743	.6706	.591	.7545	.8573
14		.5014	.2743	.6859	.6626	.6516	.8573
15		.6447	.2401	.6097	.788	.7545	
16	.7011	.6805	.2572	.5792	.8059	.8573	
17	.7011	.5487	.2743		.7522	.6859	.9088
18	.6859	.5792	.985	.9602	.945	1.182	.8916
19	.823	.7011	.9492	1.0974	.8535	1.2715	1.1145
20	1.0117	.8535	1.0208	1.1317	.945		1.0802
21	.8573	.7926	1.0924		.823		
22	.7373	.6401	.9313		.6401		
23	.5487	.5792	.6805		.4572		.7202
24	.5316	.4458	.381	.5014		.3963	.5552
Max	1.166	1.1104	1.0924	1.1317	1.2536	1.2715	1.2536
Min	.4801	.4287	.2401	.4477	.4572	.3353	.4477
Avg	.7162	.6682	.6044	.7254	.8160	.6585	.8506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 204 / 11 KV POKHALE Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.1829	.1524	.2656	.2187	.1219	.1372
2	.2229	.1829	.1524	.2915	.2187	.1524	.12
3	.2229	.1829	.1524	.2656	.2187	.1829	.12
4	.2229	.1829	.1524	.2656	.2187	.2134	.12
5	.2401	.1829	.1829	.3125	.2812	.3048	.1372
6	.2743	.2439	.2439	.5155	.3593	.3353	.1715
7	.3086	.2896	.2743	.8124	.6249	.3506	.2058
8	.2915	.2591	.2439	.25	.2058	.1829	.1886
9	.6706	.6859	.2401	.2229	.2572	.3353	.3125
10		.8436	.3086	.1829	.2058	.3086	.3048
11	.5487	.8749		.1829	.1715		.2743
12	.823	.9061			.1715		.2286
13	.9145	.6874	.2401	.1219	.1715	.4115	.2591
14		.8749	.2401	.1219	.1715	.4287	.1524
15		.9686	.2058	.1219	.1715	.3353	
16	.7926	.9374	.2058	.1219	.1715	.2743	
17	.1829	.2134	.2058		.2058	.1372	.1219
18	.2439	.2134	.2743	.1219	.2286	.2058	.2058
19	.2286	.2439	.2743	.1829	.1829	.2229	.2229
20	.2591	.2439	.2743	.2286	.2134		.2229
21	.2439	.2439	.2743		.2134		
22	.2286	.2134	.3437		.2439		
23	.1829	.1829	.3125		.1524		.1715
24	.2229	.1829	.1524	.2812	.2134	.1524	.1372
Max	.9145	.9686	.3437	.8124	.6249	.4287	.3125
Min	.1829	.1829	.1524	.1219	.1524	.1219	.12
Avg	.3594	.4260	.2321	.2563	.2288	.2587	.1907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 205 / 11 KV AMRUT AG.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1219	.0914	.2812		.1524	.0686
2	.1029	.1067	.0762	.2812		.1524	.0686
3	.1029	.1067	.0762	.2812		.1524	.0686
4	.1029	.1067	.0914	.2812		.1829	.0686
5	.1029	.1067	.1067	.3281		.2439	.0686
6	.12	.1219	.1067	.3906		.2743	.0857
7	.1543	.1372	.1219	.6093		.3048	.1029
8	.1715	.1372	.1219	.1543	.1372	.1219	.12
9	.9259	.9145	.1372	.1543	.12	.3048	.3281
10		.9998	.12	.1219	.0857	.2401	.3048
11	.8078	1.0311	.12	.1219	.1029		.2743
12	.7468	.6874	.12		.1029		.2286
13	.8535	.8436	.12	.1067	.1029	.2401	.2591
14		.9061	.12	.1067	.0857	.2401	.2134
15		.9686	.1029	.0914	.0857	.2572	
16	.8535	1.0155	.1543	.061	.0686	.2743	
17	.1067	.1219	.1029		.12	.0857	.0762
18	.0914	.1067	.1372	.0762	.1219	.1029	.1029
19	.1067	.1067	.1543	.0762	.1067	.1029	.12
20	.1219	.1219	.1372	.0914	.0914		.12
21	.1067	.1219	.1372		.1067		
22	.1067	.1219	.3593		.1829		
23	.1067	.1067	.3353		.1524		.0857
24	.12	.0914	.0914	.3125		.1829	.0686
Max	.9259	1.0311	.3593	.6093	.1829	.3048	.3281
Min	.0914	.0914	.0762	.061	.0686	.0857	.0686
Avg	.2864	.3838	.1351	.2067	.1109	.2009	.1417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 206 / 11 KV KAKHE VILLAGE FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4458	.4268	.5258		.3048	.4908
2	.5144	.4973	.3963	.5258		.3506	.4207
3	.463	.4801	.3963	.5258		.3658	.3506
4	.463	.4458	.3963	.4382		.3658	.3155
5	.463	.4458	.3658	.3681		.381	.2804
6	.463	.4458	.3658	.4382		.3506	.2629
7	.4801	.4458	.3963	.1753		.3353	.3155
8	.4801	.463	.4115	.1227	.5258	.3201	.3506
9	.4973	.4801	.4287	.12	.4207	.3048	.3506
10		.4557	.5316	.0914		.3429	.3086
11	.4877	.4557	.4801	.0762	.2629		.3086
12	.5182	.4382	.4458				.3601
13	.4725	.4207	.2915	.1829	.1402	.5316	.4115
14		.4207		.2439		.5487	
15		.4382	.3772	.2591	.2804	.5144	
16	.4725	.3856	.4287	.2743	.3681	.4973	
17	.3506	.3963	.583		.2629	.6001	.5658
18	.4801	.503	.6485	.3429	.3506	.631	.5487
19	.6173	.4725	.6661	.5144	.5792	.7362	.6859
20	.6859	.5944	.631	.583	.5792		.6687
21	.5487	.5792	.6661		.4877		
22	.463	.5487	.6135		.381		
23	.3601	.5182	.5083		.3506		.5487
24	.6001	.3429	.4572	.5083		.3048	.5258
Max	.6859	.5944	.6661	.583	.5792	.7362	.6859
Min	.3506	.3429	.2915	.0762	.1402	.3048	.2629
Avg	.4966	.4633	.4745	.3324	.3838	.4325	.4247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 207 / 11 KV Jakhoba LIS

LT LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.0514			.0305	.0343
4		.0514			.0305	.0343
5		.0514			.0305	.0343
6		.0514			.0305	.0343
7		.0514	.0305		.0305	.0343
8		.0514	.0305		.0305	.0343
9		.0686	.061	.0343	.0305	.0343
10		.0343	.061	.0343	.0343	.0343
11		.0686	.0457	.0343		.0343
12		.0686		.0343		.0343
13		.0686		.0343	.0343	.0343
14		.0686	.0305	.0343	.0343	.0343
15		.0686	.0305	.0343	.0343	
16	.061	.0686	.0305	.0343	.0343	
17	.061	.061		.0343	.0343	.0343
18	.0171	.061	.0343	.0305	.0343	.0343
Max	.061	.0686	.061	.0343	.0343	.0343
Min	.0171	.0343	.0305	.0305	.0305	.0343
Avg	.0464	.0591	.0394	.0339	.0324	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 401 / 33 KV Biltube Express

HV Express Feeder

Feeder Feeder KV- 33 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9547	2.2119	2.0119	.5144	2.4691	.503	2.3148
2	1.8004	2.1605	1.9204	.5658	2.3663	.5487	2.1605
3	1.8519	2.2634	1.829	.6173	2.4691	.503	2.0576
4	1.9547	2.2119	1.9204	.9259	2.3663	.4572	2.2634
5	1.749	2.3663	1.7375	1.4403	2.3148	.4572	2.3148
6	1.6461	2.4691	1.829	1.4918	2.2634	.5487	2.2119
7	2.1605	2.4177	.503	1.4403	2.6749	.5944	2.4177
8	2.1605	2.1605	.5944	2.1605	2.572	.5944	2.3148
9	2.0576	2.1091	.5487	2.7263	2.4177	.5944	2.1605
10		2.2634	.6173	2.3777	2.2634	.7202	2.2634
11	2.4691	2.4177		2.4691	2.5206		2.7263
12	2.0119	1.9547			2.4177		2.4177
13	2.0576	2.2634	.6173	2.2862	2.2119	.6173	2.6749
14		2.5206	.6173	1.9204	2.4691	.5658	2.6749
15		2.1605	.5658	1.9662	1.0288	2.0576	
16	1.6461	2.4691	.5144	2.1033	.7202	2.7778	
17	2.1491	2.2862	.5144		.7202	2.7778	2.4691
18	2.1091	1.9662	.6687	2.4691	.7202	2.5206	2.572
19	2.572	1.829	.6173	2.3663	.5487	2.5206	2.4691
20	2.3148	1.9204	.5658	2.3148	.5944		2.4691
21	2.6749	1.9204	.6173		.6401		
22	2.7778	2.0119	.5658		.6401		
23	2.0576	2.1033	.7202		.5944		2.6749
24	2.0062	2.2634	2.0576	.5658	2.5206	.5487	2.4177
Max	2.7778	2.5206	2.0576	2.7263	2.6749	2.7778	2.7263
Min	1.6461	1.829	.503	.5144	.5487	.4572	2.0576
Avg	2.1039	2.1967	1.0070	1.7222	1.7718	1.1060	2.4023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 201 / Single Phasing Stave-
Sawarde Feeder KV- 11 /
OUTGOING

Single Phasing Feeders

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.181	.181	.0724	.0724	.0566	.0914
2	.1478	.181	.181	.0724	.0724	.0566	.0914
3	.1478	.181	.1791	.0724	.0716	.0566	.0914
4	.1478	.181	.1772	.0716	.0716	.0566	.0924
5	.1848	.2126	.1772	.0716	.0716	.0754	.1109
6	.2195	.2629	.2103	.0895	.0886	.0943	.1478
7	.2804	.3086	.2401	.0876	.0876	.0943	.1991
8	.0934	.0716	.0905	.0934	.0934	.0934	.0934
9		.0678	.2035	.1772	.1417	.0739	.0934
10		.0678	.1989	.1526	.1387	.0747	.0754
11		.0678		.1677	.1677		.0754
12	.0655	.0678			.1802	.0914	.0566
13	.0648	.0663	.2187		.1677	.0724	
14	.0671	.0503	.1981	.1509	.1509		.0381
15	.0686	.0503	.1981	.1526	.1823		.0381
16	.0701	.0486		.1357	.1696	.0543	.0566
17	.0724	.0724	.0934	.0732	.0739	.0739	.0747
18	.0747	.0934	.0934	.0934	.0739	.0934	.0924
19		.112	.1132	.1132	.0943	.1132	.1132
20	.132	.132	.1509	.132	.1132	.1509	.1132
21	.132	.1494	.1509	.1509	.1132	.132	.1132
22	.1848	.1867		.1307	.0934		.1109
23	.1463	.1848	.0924	.1109	.0754		.0924
24	.1848	.1848	.1829	.0905	.0914	.0566	.0914
Max	.2804	.3086	.2401	.1772	.1823	.1509	.1991
Min	.0648	.0486	.0905	.0716	.0716	.0543	.0381
Avg	.1316	.1326	.1665	.1119	.1107	.0827	.0936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 202 / Single Phasing Stave-
Mohare Feeder KV- 11 /
OUTGOING

Ag dominated/Pure Ag

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0905	.0543	.0566	
2				.0905	.0543	.0566	
3				.0905	.0537	.0566	
4				.0895	.0895	.0566	
5				.1254	.1075	.0566	
6				.1612	.1417		
7				.2629	.1753		
9		.2035					.0747
10		.2035					.0566
11		.2204					.0566
12	.1781	.2204					.0377
13	.1781	.2155				.0362	.0381
14	.2012	.218					.0381
15	.2229	.218					.0381
16	.2279	.2267				.0543	.0566
22				.0934	.0747		
23			.0924	.0924	.0566		
24				.0905	.0914	.0566	
Max	.2279	.2267	.0924	.2629	.1753	.0566	.0747
Min	.1781	.2035	.0924	.0895	.0537	.0362	.0377
Avg	.2016	.2158	.0924	.1187	.0899	.0538	.0496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 203 / Single Phasing Stave-
Satave Feeder KV- 11 /
OUTGOING

Single Phasing Feeders

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1448	.1448	.0724	.0724	.0754	.0914
2	.1109	.1448	.1448	.0724	.0724	.0754	.0914
3	.1109	.1448	.1417	.0724	.0716	.0754	.0914
4	.1109	.1448	.1417	.0716	.0716	.0754	.0924
5	.1109	.1772	.1417	.0895	.0895	.0943	.1294
6	.1463	.2103	.1753	.1075	.0886	.1132	.1663
7	.2103	.2401	.2058	.1052	.1052	.132	.1991
8	.0934	.0895	.0905	.0934	.0934	.0934	.112
9		.0848	.1696	.1595	.1772	.0924	.0934
10		.0848	.1658	.1865	.1734	.0934	.0754
11		.0678		.1341	.1844		.0754
12	.0655	.0678			.1638	.0732	.0754
13	.0648	.0663	.2031		.1341	.0724	.0762
14	.0671	.0503	.1981	.1509	.1509		.0572
15	.0686	.0503	.1829	.1526	.1658		.0572
16	.0701	.0648		.1357	.1357	.0543	.0566
17	.0724	.0905	.0747	.0732	.0739	.0739	.0934
18	.0747	.112	.0934	.0934	.0924	.0934	.1109
19	.112	.1307	.132	.1132	.132	.1132	.132
20	.1509	.1509	.1509	.132	.132	.1509	.1509
21		.1494	.1509	.1509	.132	.132	.1509
22	.1848	.1494		.1307	.112		.1848
23	.1463	.1478	.1109	.1109	.0754		.1294
24	.1294	.1478	.1463	.0905	.0914	.0754	.0914
Max	.2103	.2401	.2058	.1865	.1844	.1509	.1991
Min	.0648	.0503	.0747	.0716	.0716	.0543	.0566
Avg	.1106	.1213	.1482	.1136	.1163	.0926	.1077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 201 / Shahuwadi-Maan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566	.0566	.0566	.0566	.0566	.0566
2		.0566	.0566	.0566	.0566	.0566	.0566
3		.0566	.0566	.0566	.0566	.0566	.0566
4		.0566	.0566	.0754	.0566	.0566	.0566
5		.0747	.0943	.0943	.0754	.0943	.0747
6		.0914	.132	.1307	.0905	.132	.112
7		.1294	.168	.1663	.1294	.132	.1307
8		.1294	.1494	.1663	.1294	.1307	.1097
9		.1478	.112	.1663	.1109	.1075	
10		.1109	.1097	.1612	.1086	.1052	.0914
11	.1097	.112		.1494	.1052	.0543	
12	.0914	.1097		.1254	.0716	.0716	
13	.0914	.0716	.0693	.128	.0732	.0716	
14	.0914	.0732	.0724	.1075	.0724	.0701	.0716
15	.1097	.0895		.1097	.0732	.0747	.0716
16	.1097	.0716	.0739		.0739	.0724	.1086
17	.1097	.0914	.0924	.1097	.0934	.0732	.1227
18	.1478	.1097	.1294	.1294	.112		.128
19	.1478	.1463	.1867	.1494	.1494	.1494	.1463
20	.2033	.2012	.2075	.1867	.1867	.1867	.1829
21	.1663	.1646	.1509	.1867	.1867	.1867	.1772
22	.1307	.1307		.1494	.132	.132	.1494
23	.0747	.0747	.0754	.0754	.0754	.0747	.0747
24		.0754	.0566	.0566	.0566	.0566	.0566
Max	.2033	.2012	.2075	.1867	.1867	.1867	.1829
Min	.0747	.0566	.0566	.0566	.0566	.0543	.0566
Avg	.1218	.1013	.1053	.1215	.0972	.0957	.1017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 202 / Shahuwadi- Amba Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754	.0754	.0754	.0754	.0754	.0754
2		.0754	.0754	.0754	.0754	.0754	.0732
3		.0754	.0754	.0754	.0754	.0754	.0754
4		.0754	.0754	.0943	.0754	.0754	.0754
5		.0934	.0943	.1132	.0943	.0943	.112
6		.112	.112	.1307	.1307	.1307	.1494
7		.1307	.1494	.168	.168	.168	.1867
8		.3174	.168	.168	.168	.1867	.1867
9		.1494	.168	.168	.168	.1848	.1646
10		.168	.1663	.1478	.168		.1646
11	.1829	.1629		.1463	.1433		.1646
12	.2012	.1612		.1294	.1463		.181
13	.1829	.1646	.128	.1254		.1829	.1612
14	.1829	.1433	.1463	.1086		.1494	.1448
15	.1663	.1829		.1254	.1494	.1478	.1463
16	.1494	.1463	.1307		.1478	.1646	.1433
17	.1494	.1463	.1509	.1509	.1478	.1646	.1463
18	.168	.1463	.1698	.1886	.1867	.1829	.1829
19	.1867	.1829	.1886	.1886	.1867	.2012	.2054
20	.2241	.2195	.1886	.1886	.2054	.2012	.2054
21	.1867	.1867	.1698	.1886	.1867	.1867	.1867
22	.168	.168	.168	.1509	.1494	.168	.1494
23	.112	.1307	.132	.132	.1132	.1307	.1307
24		.0943	.1132	.1132	.1132	.0943	.0754
Max	.2241	.3174	.1886	.1886	.2054	.2012	.2054
Min	.112	.0754	.0754	.0754	.0754	.0754	.0732
Avg	.1739	.1462	.1355	.1371	.1398	.1448	.1453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 203 / Shahuwadi-sawe

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.1509	.1698	.1698	.1509	.1509
2		.1509	.1509	.1698	.1509	.1509	.1509
3		.1509	.1509	.1698	.1509	.1509	.1132
4		.1509	.1509	.1886	.1509	.1509	.132
5		.1867	.1886	.1886	.1867	.1886	.1886
6		.2195	.2263	.2241	.2218	.2263	.2263
7		.2641	.2641	.3018	.2402	.2641	.2641
8		.3395	.2641	.3395	.2829		.3018
9		.3772	.2829	.3961	.3584	.2614	.3206
10		.3584	.2452	.3696	.3361	.2957	.3018
11	.3206	.2987		.2987	.2957	.2987	
12	.3018	.2641		.2829	.2641		
13	.2614	.2075	.1886		.2614	.2641	
14	.2241	.2075	.1646	.1848	.2263	.2075	.1848
15	.1886	.2075		.2075	.2241	.1829	.1829
16	.2075	.2641	.2263		.2263	.2075	.1867
17	.2641	.2641	.2829	.2263	.2263	.2263	.2641
18	.3395	.3395	.3772	.2641	.2641	.2641	.2829
19	.3772	.3772	.4527	.3395	.3395	.3395	.3395
20	.4904	.4904	.5658	.4527	.4527	.4527	.4715
21	.4715	.4715	.4904	.415	.415	.415	.415
22	.3361	.3395	.3395	.3361	.3395	.3395	.3395
23	.2241	.2263	.2452	.2452	.2263	.2263	.2452
24		.1886	.1886	.1886	.2075	.1886	.1886
Max	.4904	.4904	.5658	.4527	.4527	.4527	.4715
Min	.1886	.1509	.1509	.1698	.1509	.1509	.1132
Avg	.3082	.2706	.2665	.2709	.2591	.2478	.2500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 204 / Shahuwadi-Kotoli Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.016	.0305			
2		.0156	.0305			
3		.0156	.0305			
4		.0156	.0305			
5		.0156	.0309			
6		.0149	.0305			
7		.0297	.0309			
9			.0305	.029	.0072	
10			.0156	.0282	.0091	
11				.0297	.0069	
12				.0305		
13			.0326	.0149	.0074	
14			.0213	.0137	.0091	
15				.013	.0149	
16			.0111		.0152	
22	.0335	.0305				.0286
23	.0335	.0309				.0286
24		.016	.0305			
Max	.0335	.0309	.0326	.0305	.0152	.0286
Min	.0335	.0149	.0111	.013	.0069	.0286
Avg	.0335	.0200	.0274	.0227	.01	.0286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 205 / Shahuwadi - Malkapur
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2263	.2263	.2263	.2263	.2263	.2263
2		.2263	.2263	.2263	.1886	.1886	.2263
3		.2263	.2263	.2263	.1886	.1886	.2263
4		.2263	.2263	.2641	.1886	.1886	.2263
5		.2614	.2641	.3395	.2263	.2263	.2641
6		.2987	.3395	.3772	.3018	.3018	.3547
7		.3547	.3921	.3734	.3734	.3772	.415
8		.3734	.3921	.4108	.4108	.4108	.4108
9		.3921	.3921	.4481	.3734	.3696	.4108
10		.4251	.4435	.4066	.4066		.4108
11	.462	.4481		.4481	.4024	.4066	
12	.4572	.4435		.4251	.4066		
13	.439	.4024	.3439	.4024	.3658	.4938	
14	.3982	.3841	.3511	.4066	.3511	.3696	.112
15	.3982	.3658		.4108	.3475	.3658	.1086
16	.3801	.4024	.3696		.3439	.394	.0924
17	.4024	.4024	.4066	.4435	.3658	.4024	.4938
18	.4435	.439	.4481	.5228	.4024	.4207	.5228
19	.4668	.4572	.4854	.5601	.5487	.5487	.5601
20	.5658	.5544	.5975	.6036	.5853	.5975	.5975
21	.4904	.4854	.5281	.5281	.5228	.5228	.5228
22	.415	.415	.415	.415	.415	.415	.415
23	.2987	.2614	.3206	.3206	.2829	.3018	.3018
24		.2641	.2641	.2641	.2641	.2641	.2641
Max	.5658	.5544	.5975	.6036	.5853	.5975	.5975
Min	.2987	.2263	.2263	.2263	.1886	.1886	.0924
Avg	.4321	.3640	.3647	.3935	.3537	.3628	.3411

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 206 / Shahuwadi-Parale Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0076	.0328	.0328	.0354	.0366
2		.0171	.008	.0328	.0328	.0358	.0373
3		.0171	.016	.0328	.0324	.0358	.0373
4		.0168	.016	.0328	.0328	.0358	.0373
5		.0168	.0076	.0492	.0328	.0362	.0366
6		.0164	.0069	.0486	.0328	.0362	.0366
7		.0164	.0069	.0486	.0324	.0362	.0358
8		.0164	.0069	.0168	.016	.0076	.0076
9		.0492	.0061	.0168	.016	.0072	.0324
10		.0492	.0175	.0183	.0171		.0324
11	.0686	.061		.0175	.0179		
12	.0857	.08		.0175	.0185		
13	.0876	.0335	.0181	.0175	.0187		
14	.0857	.0514	.0181	.0179	.0189		.0351
15	.1017	.0429		.0183	.0175		
16	.0995	.0434	.0189		.0171		.0171
17	.0164	.008	.0189	.0177	.0076		.0187
18	.0164	.008	.0189	.0179	.0076		.0076
19	.0164	.0076	.0189	.0181	.0076	.008	.0076
20	.0164	.0069	.0189	.0181	.0076	.008	.0076
21	.0164	.0069	.0189	.0183	.0076	.0076	.0076
22	.0168	.0076	.0229	.0351	.0351	.0343	.0076
23	.0171	.0076	.0328	.0335	.0354	.0343	.0086
24		.0171	.0076	.0328	.0335	.0354	.0366
Max	.1017	.08	.0328	.0492	.0354	.0362	.0373
Min	.0164	.0069	.0061	.0168	.0076	.0072	.0076
Avg	.0496	.0256	.0149	.0265	.0220	.0263	.0242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 207 / Shahuwadi-Bajagewadi Ag Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.0286				
2		.0343	.0286				
3		.0343	.0286				
4		.0335	.0297				
5		.0328	.0297				
6		.0469	.0286				
7		.0549	.0267				
9			.0549	.0088	.0213	.0072	
10			.0492	.0111	.0091	.0076	
11					.0076	.0061	
12					.0057		
13			.0324	.0091	.0072	.0101	
14			.0244	.0061	.0088	.0183	
15				.0057	.0057	.0164	
16			.0175		.005	.0112	
22	.037	.029					.0343
23	.056	.029					.0343
24		.0526	.0286				
Max	.056	.0549	.0549	.0111	.0213	.0183	.0343
Min	.037	.029	.0175	.0057	.005	.0061	.0343
Avg	.0465	.0382	.0313	.0082	.0088	.0110	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 208 / Shahuwadi-Perid Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0282	
2				.0282	
3				.0282	
4				.0297	
5				.0446	
6				.04	
7				.0354	
9		.04			.0111
10		.0168			.0198
11	.04	.0221			.0179
12		.0297			
13	.0244	.032			.0229
14	.0229	.0246			.0183
15	.0343	.0263			.0145
16	.0457	.0257			.0152
22			.0198		
23			.0259		
24				.0267	
Max	.0457	.04	.0259	.0446	.0229
Min	.0229	.0168	.0198	.0267	.0111
Avg	.0335	.0272	.0229	.0326	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 209 / Shahuwadi-Ameni vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187	.0191	.0187	.0187	.0191	.0191
2		.0187	.0191	.0187	.0187	.0191	.0191
3		.0187	.0191	.0187	.0187	.0191	.0191
4		.0187	.0191	.0187	.0187	.0191	.0191
5		.0187	.0191	.0187	.0187	.0191	.0187
6		.0185	.0373	.0187	.0189	.0362	.0362
7		.0183	.0362	.0366	.0177	.0362	.0362
8		.0362	.0362	.0362	.0343	.0362	
9		.0354	.0362	.0354	.0173	.0183	.0362
10		.0347	.0351	.0175	.0175	.0179	.0362
11	.0362	.0343		.0181	.0171	.0175	.0171
12	.0362	.0343		.0171	.0171		.0171
13	.0358	.0343	.0351	.0171	.0175	.0171	.0171
14	.0351	.0343	.0171	.0171	.0179	.0171	.0175
15	.0343	.0343		.0175	.0175	.0171	.0171
16	.0343	.0343	.0175		.0171	.0171	.0181
17	.0343	.0351	.0377	.0175	.0175	.0177	.0175
18	.0343	.0358	.0343	.0343	.0358	.0362	.0362
19	.0343	.0362	.0343	.0347	.0362	.0362	.0362
20	.0351	.0362	.0351	.0351	.0362	.0362	.0362
21	.0351	.0366	.0354	.0358	.0362	.0362	.0362
22	.0179	.0191	.0358	.0181	.0362	.0362	.0362
23	.0185	.0191	.0185	.0185	.0191	.0191	.0191
24		.0187	.0191	.0187	.0187	.0191	.0191
Max	.0362	.0366	.0377	.0366	.0362	.0362	.0362
Min	.0179	.0183	.0171	.0171	.0171	.0171	.0171
Avg	.0324	.0283	.0284	.0234	.0225	.0245	.0252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 201 / Sarud-Bambawade Village

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.5601	.5601	.4715		.5601	.4481
2	.4527	.4481	.5601	.4715			.4294
3	.4527	.4481	.5601	.415			.4294
4	.4668	.5228	.5601	.4715			.4481
5	.6535	.5601	.5658	.6036		.4108	.5975
6	.7842	.7468	.7468	.7922		.5601	.8029
7	.6722	.7468	.8402	.9619		.8962	.9522
8	.8215	.8962	.9335	1.0082		.9335	.9709
9	.5601	.9709		.9431		.8402	.9522
10	.8402	.8775	.8215	.8402			.7468
11		.8402		.7468	.8589		.7095
12		.7842		.7468	.8962		.6348
13	.9896	.7095	.6161	.6535	.8029		
14		.7468	.4854	.6161	.6908	.9335	.7095
15		.7468	.5415	.6161	.6348	.9335	.7468
16	.7468	.7842		.6348	.6908	.9335	
17	.7468	.8775	.6722		.7468	.9709	.8215
18	.9709	.9335	.9431	1.1203	.8402		.8215
19	1.1949	1.2696	1.1694	1.1203	1.2136		.9335
20	1.3443	1.307	1.4003	1.1203	1.307	1.3256	1.2136
21	1.1949	1.1949	1.1763		.9896	1.1203	1.1203
22	.8962	.9149	1.0082		.7468		
23	.6722	.056	.5601		.5601		.6722
24	.6722	.6722	.5975	.4715		.5601	.4854
Max	1.3443	1.307	1.4003	1.1203	1.307	1.3256	1.2136
Min	.4481	.056	.4854	.415	.5601	.4108	.4294
Avg	.7790	.7756	.7659	.7413	.8445	.8445	.7451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 202 / Sarud-Bhedasgaon

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2241	.2614	.2075		.1867	.1867
2	.1886	.2263	.2614	.1886		.1867	.1867
3	.1867	.2263	.2614	.1886		.1867	.1867
4	.1867	.2614	.2614	.1886			.1867
5	.2801	.2987	.2614	.2452		.2427	.2427
6	.3734	.3361	.3174	.3361		.2987	.3921
7	.4108	.3734	.3174	.415		.3734	
8	.3734	.3734	.3734	.4108		.3734	.3921
9	.3361	.4108		.4338		.4108	.3547
10	.3734	.3361	.3361	.3734	.3361		
11	.4108	.3361		.3174	.2614		.2987
12	.2614	.3174		.3174	.2614		.2614
13	.2427	.3395	.2241	.2801	.2829		.2614
14		.3174	.2241	.2614	.2641		.2241
15		.2829	.2241	.2614	.2829		.2614
16	.2614	.2987		.2241	.3361	.3174	
17	.2801	.3361	.2614		.3734	.3734	.3361
18	.2987	.3361	.4108	.4108	.3734		.3734
19	.4481	.5228	.4854	.4481	.4668		.5228
20	.5601	.5601	.5415	.4854	.5601	.5228	.5228
21	.4854	.5228	.4854		.5041	.4854	.4854
22	.3734	.4481	.3734		.3361		
23	.2614	.2614	.2801		.2427		.2801
24	.2241	.2614	.2614	.2263		.2241	.2054
Max	.5601	.5601	.5415	.4854	.5601	.5228	.5228
Min	.1867	.2241	.2241	.1886	.2427	.1867	.1867
Avg	.3183	.3420	.3212	.311	.3487	.3217	.3081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 203 / Sarud-Sarud Village
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1494	.1494	.1307		.1307	.1307
2	.0943	.1494	.1494	.1307		.1307	.1307
3	.0943	.1307	.1494	.1307		.1307	.1307
4	.112	.1494	.1494	.1307			.1307
5	.1494	.1494	.1494	.1494			.1494
6	.2241	.1867	.2241	.2054		.1867	.1867
7	.2241	.2241	.2614	.2614		.1867	.2241
8	.1867	.2241	.2427	.2641		.1494	.2427
9	.2241	.2614		.2427		.1494	.2054
10	.1867	.2054	.1867	.1867	.2427		
11	.1867	.2427		.1867	.1307		.1867
12	.2054	.2054		.1867	.1867		.1494
13	.1494	.2054	.1307	.168	.1307		.1494
14		.2054	.112	.1494	.168		.0191
15		.2075	.1307	.1494	.2427		.1867
16	.1867	.2054			.2054	.1867	
17	.1867	.2241	.112	.1494	.2614	.2427	.1494
18	.2241	.2241	.112	.2241	.2427		.2614
19	.2614	.2987	.3361	.2614	.3174		.2987
20	.3361	.3174	.3547	.3361	.3361	.3547	.2987
21	.2987	.3174	.3395		.2801	.2614	.2987
22	.2614	.2427	.2614		.2241		
23	.1867	.1867	.1867		.1494		.168
24	.112	.1494	.1494	.132		.1494	.1307
Max	.3361	.3174	.3547	.3361	.3361	.3547	.2987
Min	.0934	.1307	.112	.1307	.1307	.1307	.0191
Avg	.1902	.2109	.1944	.1888	.2227	.1883	.1823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 204 / Sarud-Gogawe Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.0187	.0189		.0191	.0189
2	.0377	.0377	.0187	.0187		.0191	.0189
3	.0377	.0377	.0187	.0189		.0191	.0189
4	.0373	.0377	.0187	.0187			.0189
5	.0373	.0377	.0187	.0187		.0191	.0189
6	.0373	.0373	.0187	.0187		.0191	.0189
7	.0747	.0747	.0187	.0187		.0191	.0189
8	.0187	.0191	.0187	.0189		.0191	.0189
9	.0191	.0191		.056		.0381	.0187
10	.0191	.0187	.056	.0373	.056		
11	.0191	.0189		.0373	.056		.0191
12	.0191	.0187		.0373	.056		.0191
13	.0187	.0187	.0373	.0373	.0566		.0191
14		.0189	.0373	.0373	.056		
15		.0187	.056	.0373	.056		.0191
16	.0187	.0189			.056	.0373	
17	.0187	.0187	.0191		.0187	.0187	.0191
18	.0191	.0191	.0187	.0191	.0187		.0187
19	.0191	.0191	.0189	.0191	.0191		.0187
20	.0191	.0191	.0187	.0191	.0191	.0187	.0187
21	.0191	.0187	.0187		.0191	.0187	.0187
22	.0373	.0191	.0189		.0191		
23	.0373	.0191	.0189		.0191		.0187
24	.0373	.0373	.0187	.0187		.0191	.0189
Max	.0747	.0747	.056	.056	.0566	.0381	.0191
Min	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.0290	.0267	.0243	.0266	.0375	.0219	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 205 / Sarud-Shirgaon Village
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.0934	.0934		.112	.0943
2	.0754	.0747	.0187	.0934		.112	.0934
3	.0754	.0747	.0934	.0934		.112	.0943
4	.0747	.0934	.0934	.0934			.0934
5	.0934	.0934	.112	.112		.112	.0934
6	.112	.112		.1307		.112	.0934
7	.112	.1307		.1509		.1307	.1307
8	.112	.1494		.1509		.1307	.1509
9	.112	.168		.1494		.1307	.1494
10	.1307	.1494	.1494	.1307	.1307		
11	.1307	.0934		.1494	.1307		.0934
12		.1307		.1494	.1307		.0747
13	.1307	.132	.0747	.1307	.1307		.0747
14		.1132	.0747	.1307	.1494		.0934
15		.132	.056	.112	.112		.112
16	.112	.132				.112	
17	.1307	.1494	.1307		.1307	.112	.1307
18	.1307	.1494	.1307	.1494	.1307		.1307
19	.2054	.2241	.1867	.1867	.168		.1494
20	.2241	.2427	.2614	.2054	.2427	.2427	.1867
21	.2054	.1867	.2075		.2054	.1867	.1867
22	.1494	.1494	.1509		.1494		
23		.112	.1132		.1307		.112
24	.0747	.0943	.0934	.112		.1307	.0934
Max	.2241	.2427	.2614	.2054	.2427	.2427	.1867
Min	.0747	.0747	.0187	.0934	.112	.112	.0747
Avg	.1233	.1317	.1200	.1328	.1494	.1336	.1158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 206 / Sarud-Salashi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867		.112		.0747	.112
2	.1886	.1867		.112		.0747	.112
3	.1886	.1867		.112		.0747	.112
4	.2054	.2241		.112			.112
5	.2801	.2614		.1307		.0747	.112
6	.3734	.3547		.168		.0934	.1307
7	.5228	.112		.2241		.112	.1867
8	.168	.1307		.1867		.1307	.0943
9	.168	.1307		.4481		.1867	.0943
10	.168	.1509	.1494	.4108	.4294		
11	.168	.1494		.4294			.1494
12		.132		.4108	.2987		.1307
13	.1494	.132	.4668	.3734	.2452		.1494
14		.132	.4668	.3174	.2427		.1494
15		.132	.4668	.3174	.2427		.1494
16	.112	.132				.2614	
17	.1307	.112	.1494			.0934	.1494
18	.1867	.1307	.132	.1307	.1524		.112
19	.168	.1494	.1886	.1307			.1307
20	.1867	.1494	.1867	.1307	.0762	.112	.112
21	.1494	.1524	.168		.112	.0934	.0934
22	.2054	.1524	.1307		.1143		
23	.1867	.1334	.1132		.0191		
24	.1867	.1867		.112		.0747	.1494
Max	.5228	.3547	.4668	.4481	.4294	.2614	.1867
Min	.112	.112	.1132	.112	.0191	.0747	.0934
Avg	.2038	.1625	.2380	.2299	.1933	.1120	.1271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 207 / Sarud-Thergaon Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0191		.0747		.0381	.0189
2	.0189	.0191		.0747		.0373	.0189
3	.0189	.0191		.0747		.0373	.0189
4	.0187	.0191		.0747			.0189
5	.0187	.0191		.0747		.0373	.0189
6	.0187	.0191		.0943		.0373	.0187
7	.0187	.0191				.0373	.0189
8	.0187	.0191				.0189	.0189
9	.0747	.0747				.0187	
10		.0934	.0191	.0191	.0189		
11		.112		.0191	.0189		.0373
12		.0934		.0191	.0189		.0373
13	.0747	.0943		.0191	.0189		.0373
14		.0754		.0191	.0189		.0373
15		.0943	.0191	.0191			.0191
16	.0934	.0943				.0187	
17	.0187	.0187	.0191		.0189	.0187	.0191
18	.0191	.0187	.0187	.0191	.0191		.0187
19	.0191	.0187	.0189	.0191	.0191		.0187
20	.0191	.0187	.0187	.0191	.0191	.0187	.0187
21	.0191	.0191	.0189		.0191	.0189	.0187
22	.0191	.0373	.0747		.0381		.0187
23	.0191	.0373	.0747		.0381		
24	.0187	.0191		.0747		.0381	.0187
Max	.0934	.112	.0747	.0943	.0381	.0381	.0373
Min	.0187	.0187	.0187	.0191	.0189	.0187	.0187
Avg	.0287	.0447	.0313	.0447	.0222	.0289	.0225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 209 / Sarud-Nerle Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0191		.0377	.0373	.0373	.0189
2	.0189	.0191		.0377	.0373	.0373	.0189
3	.0189	.0191		.0377	.0373	.0373	.0183
4	.0187	.0191		.0373	.0373		.0189
5	.0187	.0191		.0373	.0373	.0373	.0189
6	.0187	.0191		.0373	.0373	.0747	.0189
7	.0187	.0191		.0934	.0747	.0747	.0189
8	.0187	.0191		.0187	.0191	.0187	.0189
9	.0747	.0747		.0187	.0191	.0187	.056
10	.0747	.0747	.0191	.0191	.0191		
11	.0747	.0747		.0191	.0191		.056
12	.0373	.056		.0191	.0191		.0373
13	.0373	.056		.0191	.0191		.0373
14		.0566		.0191	.0191		.0373
15		.056	.0191	.0191	.0191		.0373
16	.0373	.0754			.0191	.0187	
17	.0187	.0187			.0191	.0187	.0191
18	.0191	.0187	.0187	.0191	.0191		.0187
19	.0191	.0187	.0189	.0191	.0191		.0187
20	.0191	.0191	.0189	.0191	.0191	.0189	.0187
21	.0191	.0373	.0189	.0373	.0191	.0187	.0187
22	.0191	.0373	.0377	.0373	.0373		
23	.0191	.0373	.0373	.0373	.0373		.0187
24	.0187	.0191		.0377	.0373	.0373	.0189
Max	.0747	.0754	.0377	.0934	.0747	.0747	.056
Min	.0187	.0187	.0187	.0187	.0191	.0187	.0183
Avg	.029	.0368	.0236	.0308	.0282	.0345	.0259

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 201 / 11 Kv Warul-Amba

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.2743	.2241	.3429		.2772
2	.3395	.2743	.2218	.3429		.2218
3	.3395	.2743	.2195	.3429		.2241
4	.3395	.2743	.2241	.3048		
5		.2835	.2772	.3429		
6	.2054	.3475	.3174	.4191		
7	.2427		.3734	.4954		
8	.3439		.499	.5658	.5316	
9	.439				.6135	
10	.4207				.567	
11	.4207				.5258	
12	.5068					.2218
13	.5121			.4835		.4527
14	.5121			.3658		
15				.462		
16	.4066			.4207	.3155	.3734
17	.4207	.4435	.4854		.3696	
18	.5487	.4938	.6036		.4207	
19	.7265	.4938	.679		.4938	
20	.5853	.6401	.7356		.6653	
21	.7087	.6036	.743		.6161	
22	.5316		.6036		.5487	
23	.4755	.3292	.415		.4251	
24	.3361	.2926	.2587	.3772		.3142
Max	.7265	.6401	.743	.5658	.6653	.4527
Min	.2054	.2743	.2195	.3048	.3155	.2218
Avg	.4408	.3865	.4300	.4051	.5077	.2979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 202 / 11 Kv Warul -Yelur

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.0181		
7	.0305	.0183		
14			.0187	
15			.037	
16			.0181	.0177
23	.0183			
24		.0183		
Max	.0305	.0183	.037	.0177
Min	.0183	.0181	.0181	.0177
Avg	.0244	.0182	.0246	.0177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 203 / 11Kv Warul- Bhendavade
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	15-JUL-17	16-JUL-17	17-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.0187	
7			.0187	
12	.0366			
16	.0185			
23		.037		.0187
24			.037	
Max	.0366	.037	.037	.0187
Min	.0185	.037	.0187	.0187
Avg	.0276	.037	.0248	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 201 / Turukwadi Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0154	.0179	.0171				
2	.0154	.0177	.0171				
3	.0154	.0177	.0171				
4	.0154	.0179	.0171				
5	.0154	.0177	.0171				
6	.0154	.0179	.0171				
7	.0154	.0177	.0179				
9			.0175		.0181	.0168	
10			.0171	.0177	.0179	.0171	
11			.0171	.0175	.0175	.0171	
12			.0171	.0171	.0171		
13			.0171	.0181	.0173		
14			.0171		.0173		
15			.0171	.0175	.0173		
16			.0171	.0173		.0171	
22	.0183	.0181					
23	.0175	.0175					.0183
24	.0154	.0171	.0171				
Max	.0183	.0181	.0179	.0181	.0181	.0171	.0183
Min	.0154	.0171	.0171	.0171	.0171	.0168	.0183
Avg	.0159	.0177	.0172	.0175	.0175	.0170	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 202 / 11 KV Thawade - Udagiri Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0716	.0686	.0686	.0716	.0686	.0514
2	.0754	.0709	.0686	.0686	.0724	.0686	.0514
3	.0754	.0709	.0686	.0686	.0709	.0686	.0514
4	.0754	.0716	.0686	.0686	.0724	.0686	.0514
5	.0747	.0709	.0686	.0686	.0716	.0686	.0686
6	.0934	.0895	.0876	.0895	.0905		.0876
7	.1494	.1417	.1075	.128	.128		.1254
8		.124	.1433		.1267		.1417
9		.1417	.1227		.1267		.1227
10		.1417		.124	.1075		
11	.104	.1402	.0686	.1227	.0876		.1052
12	.0716	.1029	.0686	.1029	.0857		.0905
13	.0857	.1029	.0686	.0905	.0693		.0732
14	.0895	.0857	.0686	.0716	.0693		.0549
15	.0671	.0857	.0686	.1052	.052		.0924
16	.0838	.1372	.0686	.1214		.1029	.0914
17	.1006	.1734	.12	.1734	.12	.1543	.0724
18	.1417	.1928	.197	.1772	.1753	.1595	.181
19	.1949	.2126	.2172	.1991	.2149	.2012	.1791
20	.2587	.2896	.2896	.2402	.2378	.2054	.2378
21	.2402	.2195	.1829	.2218	.2012	.1848	
22	.1829	.1629	.128	.1478		.1463	
23	.1227	.1052	.1052	.0886	.0857	.0895	.1097
24	.0754	.0686	.0857	.0857	.0716	.0686	
Max	.2587	.2896	.2896	.2402	.2378	.2054	.2378
Min	.0671	.0686	.0686	.0686	.052	.0686	.0514
Avg	.1161	.1281	.1105	.1197	.1095	.1183	.1020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 203 / 11 KV Kandavan Village

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1433	.12	.12	.1433	.1372	.1029
2	.1478	.1417	.12	.12	.1448	.1372	.1029
3	.1478	.124	.12	.12	.1417	.1372	.1029
4	.1463	.1254	.12	.12	.1448	.12	.1029
5	.1829	.1417	.12	.12	.1433	.1029	.1372
6	.2378	.2149	.1753	.1791	.2353		.1578
7	.3292	.2658	.2686	.2743	.2926		.2686
8		.3012	.2686		.362		.2303
9		.2835	.2804		.3439		
10		.2658	.2229	.1949	.2686	.1715	
11	.2254	.2279	.2229	.1928	.1928	.1715	.1753
12	.2507	.1886	.1715		.1715	.1715	.181
13	.2572		.2058		.1387		.2012
14			.1886	.1612	.1387		.1829
15	.2012	.1715	.1886	.1753	.156	.2058	
16	.2347	.2401	.1886	.2254		.2229	
17	.3185	.2947	.2229	.2601	.2401	.3086	
18	.3012	.3155	.3224	.2481	.298	.3189	
19	.3721	.3544	.3801	.4525	.3582	.4207	.4298
20	.462	.3982	.3982	.4805	.4024	.4294	.439
21	.3881	.3658	.3292	.4066	.362	.3511	
22	.2926	.2715	.2743	.3142		.2743	
23	.1578	.1578	.1578	.2126	.1543	.2149	.1829
24	.1463	.1543	.12	.12	.1612	.1372	.12
Max	.462	.3982	.3982	.4805	.4024	.4294	.439
Min	.1463	.124	.12	.12	.1387	.1029	.1029
Avg	.2473	.2340	.2161	.2249	.2270	.2240	.1949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 201 / Sh-R- Panhala Hill Station Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1143	.1143	.0953	.1143	.0572
2	.1334	.1334	.1143	.1143	.0953	.1143	.0572
3	.1334	.1334	.1143	.1143	.0953	.1143	.0572
4	.1334	.1334	.1143	.1143	.0953	.1143	.0572
5	.1524	.1334	.1143	.1143	.0953	.1334	.0572
6	.2096	.1524	.1143	.1334	.1715	.1524	.0762
7	.1905	.1905	.2096	.1905	.1715	.1905	.1143
8	.2286	.2477	.1905	.2096	.1905	.2286	.1334
9	.2096	.2477		.1905	.1905		.1143
10		.1905		.1715	.2096		
11		.1715		.1715	.1715		
12	.1905	.1524			.1524		
13	.1715	.1524	.1524		.1715		
14	.1715	.1524	.1524	.1715	.1715		.3086
15		.1524	.1524	.1524	.1715		.1886
16	.1334	.1524	.1524	.1524	.1524	.1543	
17	.1524	.1715	.1524		.1524	.1334	.1905
18	.1715	.1715	.1715	.1905	.1905		.1524
19	.2096	.2477	.2096	.2477	.2096		.2286
20	.2477	.2477	.2477	.2667	.2667		.2286
21	.2286	.2286	.2286	.2477	.2477		.2286
22	.2096	.2096		.2096	.2286		.2096
23	.1715	.1715	.1715	.1524	.1524	.1143	.1524
24	.1334	.1524	.1524	.1334	.1334	.1143	.0572
Max	.2477	.2477	.2477	.2667	.2667	.2286	.3086
Min	.1334	.1334	.1143	.1143	.0953	.1143	.0572
Avg	.1769	.1762	.1594	.1697	.1659	.1399	.1405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 202 / SH-R- 11 KV WAGHAWE
GAVTHAN Feeder KV- 11 /
OUTGOING

Gaothan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0381	.0762	.0953
2	.0953	.0953	.0953	.0953	.0381	.0762	.0953
3	.0953	.0953	.0953	.0953	.0381	.0762	.0953
4	.0953	.0953	.0953	.0953	.0381	.0762	.0953
5	.1143	.0953	.1143	.1143	.0953	.1143	.0953
6	.1715	.1334	.1524	.1905	.1143	.1334	.1143
7	.1905	.1715	.2096	.1905	.1143	.1524	.1334
8	.2286	.1905	.2286	.2096	.0953	.1524	.1334
9	.2477	.2477		.1905			.1524
10		.2858		.1905	.0191		
11		.2858		.1905	.0191		.1524
12	.2286	.2477			.0191		.1372
13	.2286	.2477	.2286		.0762		.1334
14	.2286	.2477	.2096	.1143	.0762		.1372
15		.1905	.1715	.1334	.0762		.1715
16	.2667	.1524	.1905	.1334	.1524	.1372	
17	.2858	.2286	.2286		.2667	.1543	.2477
18	.2286	.2667	.3048	.2096	.2667		.2286
19	.2477	.2477	.2477	.2477	.3048	.2667	.2286
20	.2858	.2667	.2667	.2667	.3048	.2096	.2858
21	.2477	.2667	.2667	.2477	.2667	.1905	.3048
22	.1715	.1905		.1905	.2286	.1524	.2477
23	.0953	.1143	.1143	.1334	.1143	.1143	.1524
24	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Max	.2858	.2858	.3048	.2667	.3048	.2667	.3048
Min	.0953	.0953	.0953	.0953	.0191	.0762	.0953
Avg	.1878	.1897	.1795	.1633	.1243	.1361	.1606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 203 / 11 KV NAVALI VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2667	.2667	.2286	.2667	
2	.2667	.2667	.2667	.2667	.2286	.2667	
3	.2667	.2667	.2667	.2667	.2286	.2667	
4	.2667	.2667	.2667	.2667	.2286	.2667	
5	.3429	.2667	.3048	.3048	.2286	.3429	
6	.4954	.4191	.4191	.4572	.4572	.4191	
7	.6097	.4763	.5335	.5335	.6287	.5716	
8	.6097	.5906	.5716	.5335	.6287	.5716	
9	.6097	.6097		.6478	.5144		
10		.5335		.6859	.4458		
11		.5335		.5906	.4572		
12	.4954	.5335			.4572		
13	.4572	.5335	.381		.381		
14	.3353	.5335	.2858	.4191	.381		.3086
15		.5716	.381	.381	.381		.5144
16	.6287	.5716	.4191	.4572	.4954	.4458	
17	.5716	.6097	.4572		.5335	.4801	.8002
18	.6287	.6097	.5335	.6859	.6478		.8573
19	.7049	.6859	.724	.724	.7621	.8002	.8383
20	.9526	.9145	.8002	.8954	.8383		1.0288
21	.7621	.8002	.724	.7621	.724		.9526
22	.6668	.6478		.5906	.5335		.5525
23	.381	.4191	.3429	.381	.3048		.381
24	.3429	.3429	.3429	.3048	.2667	.2667	
Max	.9526	.9145	.8002	.8954	.8383	.8002	1.0288
Min	.2667	.2667	.2667	.2667	.2286	.2667	.3086
Avg	.5077	.5112	.4362	.4962	.4576	.4137	.6926

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 204 / 11 KV MITHARWADI GAVTHAN

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.1143	.0953	.1143	.0762	.0953
2	.0953	.0953	.1143	.0953	.1143	.0762	.0953
3	.0953	.0953	.1143	.0953	.1143	.0762	.0953
4	.0953	.0953	.1143	.0953	.1143	.0762	.0953
5	.1143	.0953	.1143	.1143	.1143	.1143	.1143
6	.1524	.1524	.1524	.1715	.1715	.1524	.1715
7	.1905	.1905	.1524	.2096	.2096	.1905	.1905
8	.2096	.2096	.2286	.2286	.2096	.1905	.2096
9	.2096	.2286		.2096	.1715		.2477
10		.1905		.1905	.1543		
11		.1524		.1715	.1524		
12	.1143	.1524			.1524		
13	.1715	.1524	.1334		.1334		
14	.1524	.1524	.1334	.1334	.1524		.1886
15		.1524	.1143	.1715	.1524		.2058
16	.1524	.1334	.1143	.1524	.1715	.0857	
17	.1715	.1524	.1334		.1905		.1524
18	.2096	.1524	.1715	.2667	.2286		.2667
19	.2477	.2667	.2096	.3048	.2477	.3429	.2286
20	.2858	.2667	.2286	.2667	.2667		.2858
21	.2286	.2477	.2477	.2477	.2477		.2667
22	.2096	.1905		.1905	.1905		.1715
23	.1334	.1524	.1143	.1524	.1143	.1905	.1334
24	.1143	.1143	.1143	.0953	.1143	.1143	.1143
Max	.2858	.2667	.2477	.3048	.2667	.3429	.2858
Min	.0953	.0953	.1143	.0953	.1143	.0762	.0953
Avg	.1642	.1619	.1484	.1742	.1668	.1405	.1752

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 205 / 11 KV INJOLE VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1143	.0953	.0953	.2286
2	.1143	.1143	.1143	.1143	.0953	.0953	.2286
3	.1143	.1143	.1143	.1143	.0953	.0953	.2286
4	.1143	.1143	.1143	.1143	.0953	.0953	.2286
5	.1334	.1143	.1524	.1334	.0953	.1143	.2286
6	.2096	.1715	.1905	.2096	.1905	.1524	.3048
7	.2667	.2477	.2667	.2667	.2477	.2286	.3429
8	.2667	.2858	.3048	.2858	.2096	.2286	.381
9	.2858	.2858		.2667	.1543		.381
10		.2858		.3048	.1543		
11		.2858		.2667	.2096		.3429
12	.2286	.1905			.1905		
13	.2286	.1524	.1905		.1905		
14	.2096	.1524	.1715	.1905	.1905		.2058
15		.1905	.1524	.2096	.1905		.1715
16	.2096	.1905	.1524	.1905	.1905	.2229	
17	.2286	.2286	.1715		.2667	.1715	.2667
18	.2477	.2286	.2286	.2477	.2477		.3048
19	.2667	.2667	.3048	.2858		.3048	.2096
20	.3048	.3239	.3239	.2858	.3239	.3429	.2858
21	.2858	.2858	.3048	.3048	.2667		.2858
22	.2096	.2286		.2096	.2286		.1905
23	.1715	.1524	.1524	.1524	.1334	.2286	.1524
24	.1334	.1334	.1334	.1143	.1143	.1143	.2286
Max	.3048	.3239	.3239	.3048	.3239	.3429	.381
Min	.1143	.1143	.1143	.1143	.0953	.0953	.1524
Avg	.2069	.2024	.1925	.2087	.1816	.1779	.2599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 206 / 11kv Broadcast Express HV Non-Express Feeder
feeder Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0381	.0381	.0381	.0381	.0572
2	.0572	.0572	.0381	.0381	.0381	.0381	.0572
3	.0572	.0572	.0381	.0381	.0381	.0381	.0572
4	.0572	.0572	.0381	.0381	.0381	.0381	.0572
5	.0572	.0572	.0381	.0572	.0572	.0381	.0572
6	.0572	.0572	.0381	.0572	.0381	.0381	.0572
7	.0572	.0572	.0572	.0572	.0572	.0572	.0572
8	.0572	.0572	.0572	.0572	.0572	.0572	.0572
9	.0572	.0572		.0572	.0514		.0572
10		.0572		.0572	.0343		
11		.0572		.0572	.0572		
12	.0572	.0572			.0572		
13	.0572	.0572	.0572		.0572		
14	.0572	.0572	.0572	.0572	.0572		.0514
15		.0572	.0572	.0572	.0572		.0514
16	.0572	.0572	.0572	.0572	.0572	.0514	
17	.0572	.0572	.0572		.0572	.0514	.0572
18	.0572	.0572	.0572	.0572	.0572		.0572
19	.0572	.0572	.0572	.0572	.0572	.0572	.0572
20	.0191	.0191	.0572	.0191	.0381		.0572
21	.0572	.0191	.0572	.0572	.0572		.0572
22	.0572	.0572		.0572	.0572		.0572
23	.0572	.0572	.0572	.0572	.0572	.0572	.0572
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0191	.0191	.0381	.0191	.0343	.0381	.0514
Avg	.0554	.0540	.0512	.0517	.0512	.0475	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 207 / 11Kv Mitharwadi Ag.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1143	.1067	.1143	.1524
2	.1524	.1524	.1524	.1143	.1067	.1143	.1524
3	.1524	.1524	.1524	.1143	.1067	.1143	.1524
4	.1524	.1524	.1524	.1143	.1334	.1143	.1524
5	.1524	.1524	.1524	.1143	.1334	.1143	.1524
6	.1524	.1524	.1524	.1524	.1372	.1143	.1905
7	.1905	.1905	.1905	.3429	.2439		.2096
8	.2096	.1905	.2286	.1905	.2667	.1143	.2096
9	.4115	.4191		.1905	.2229		.1829
10		.4572		.2286	.2058		
11		.4572		.2286	.1905		
12	.3353	.4572			.1905		
13	.2439	.4572	.1905		.1715		
14	.2439	.381	.1905	.1715	.1715		.1372
15		.381	.1905	.1524	.1905		.1886
16	.2743	.3048	.1715	.1524	.1524	.1715	
17	.1715	.1905	.1715		.1524	.1715	.1905
18	.1524	.1524	.1715	.1905	.1905		.2286
19	.1905	.2286	.1905	.1905	.2286	.2096	.2286
20	.1905	.2286	.1905	.1905	.2286		.2286
21	.1905	.1905	.1524	.1905	.2286		.1905
22	.1715	.1905		.1524	.1905		.1715
23	.1524	.1524	.1524	.1524	.1524	.1524	.1524
24	.1524	.1524	.1524	.1143	.1524	.1524	.1524
Max	.4115	.4572	.2286	.3429	.2667	.2096	.2286
Min	.1524	.1524	.1524	.1143	.1067	.1143	.1372
Avg	.1998	.254	.1715	.1696	.1773	.1381	.1802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 208 / Waghawe Ag.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191		.0191	.0191
9	.0191	.0191		.0191	.0191		.0152
10		.0191		.0191	.0191		
11		.0191		.0191	.0191		.0152
12	.0914	.1143			.0191		.0514
13	.1067	.1143	.0191		.0191		.0457
14	.0914	.1143	.0191	.0191	.0191		.0514
15		.1143	.0191	.0191	.0191		.0514
16	.1372	.1143	.0191	.0191	.0191	.0171	
17	.0191	.0191	.0191		.0191		.0191
18	.0191	.0191	.0191	.0191	.0191		.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191		.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.1372	.1143	.0191	.0191	.0191	.0191	.0514
Min	.0191	.0191	.0191	.0191	.0191	.0171	.0152
Avg	.0358	.0389	.0191	.0191	.0191	.0190	.0244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 209 / 11KV INJOLE AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0762	.0762				
2	.1143	.0762	.0762				
3	.1143	.0762	.0762				
4	.1143	.0762	.0762				
5	.1143	.0762	.0762				
6	.1715	.0914	.0762				
7	.1905	.1219	.0953				
9				.1524	.12		
10				.1219	.12		
11				.1219	.1372		
12					.1524		
13			.1143		.1524		
14			.1143	.1067	.1334		
15			.1524	.0762	.0191		
16			.1524	.0914	.0191	.0171	
17					.0762		
22	.0914	.0762					.0152
23	.0914	.0762					.0152
24	.1143	.0914	.0762				
Max	.1905	.1219	.1524	.1524	.1524	.0171	.0152
Min	.0914	.0762	.0762	.0762	.0191	.0171	.0152
Avg	.1231	.0838	.0968	.1118	.1033	.0171	.0152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 201 / 11 KV DIGAWADE VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0686	.0686	.0566	.0514	.0514	.0566
2	.0566	.0514	.0514	.0566	.0514	.0514	.0377
3	.0566	.0514	.0514	.0566	.0514	.0514	.0377
4	.0754	.0686	.0686	.0566	.0686	.0686	.0377
5	.0747	.1029	.0857	.0747	.0686	.0857	.0566
6	.1478	.12	.12	.1463	.12	.1029	.0943
7	.1629	.12	.1372	.1448	.1372	.12	.1494
8	.1612	.12	.12	.1448	.1372	.1372	.1294
9	.1433	.12	.12	.1448	.1372	.1372	.1294
10		.1448	.12	.1372	.1372	.1433	.124
11		.1448			.12		
12	.12	.1433			.12	.1254	
13	.12	.1433	.0686		.12	.1075	.12
14	.12	.1075	.0686		.12	.0895	
15	.1029	.1075			.1372	.0895	
16	.0857	.0895	.1715		.1543	.1052	
17	.0857	.12	.1612		.1372	.0171	.0343
18	.1372	.1372	.1791	.1029	.1543	.0171	.1372
19	.1372	.1715	.1829	.1372	.1543		.1372
20	.1715	.1715	.1848	.1372	.1372		.1372
21	.1543	.1372	.1494	.1372	.12		.1372
22	.12	.12		.0857	.12		.1029
23	.0686	.0857	.0754	.0686	.0686	.0566	.0686
24	.0754	.0686	.0686	.0566	.0514	.0514	.0566
Max	.1715	.1715	.1848	.1463	.1543	.1433	.1494
Min	.0566	.0514	.0514	.0566	.0514	.0171	.0343
Avg	.1115	.1131	.1127	.1026	.1114	.0847	.0939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 202 / 11 KV ALAWE-KOTOLI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0343	.0343	.0171	.061	.0457
2	.0171	.0343	.0343	.0171	.061	.0457
3	.0171	.0343	.0343	.0171	.061	.0457
4	.0171	.0343	.0343	.0171	.061	.061
5	.0171	.0343	.0343	.0343	.061	.0762
6	.0343	.0343	.0343	.0343	.061	.0762
7	.0305	.0343	.0343	.0343	.061	
8	.0305	.0343	.0343	.0152	.061	
9	.125	.0343	.0343	.0152	.0305	
10		.1658	.0914	.0171	.0305	
11		.1823			.0305	
12	.1886	.1989			.0305	.0152
13	.2572	.1989	.1372		.0305	
14		.0983	.1219		.0305	
15		.096			.0305	
16	.1543	.1423	.1147		.0305	
17	.0343	.0343	.0305		.0305	.0152
18	.0343	.0343	.0305	.0343	.0305	.0305
19	.0343	.0343	.0305	.0343	.0305	
20	.0343	.0343	.0305	.0305	.0305	
21	.0343	.0343	.0305	.0305	.0305	
22	.0343	.0343		.061	.0762	
23	.0343	.0343	.0305	.061	.0762	
24	.0152	.0343	.0343	.0152	.061	.0457
Max	.2572	.1989	.1372	.061	.0762	.0762
Min	.0152	.0343	.0305	.0152	.0305	.0152
Avg	.0581	.0694	.0496	.0286	.0457	.0457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 203 / 11 KV GHOTWADE VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0686	.0686	.0566	.1029	.0514	.0566
2	.0566	.0686	.0514	.0566	.1029	.0514	.0572
3	.0566	.0686	.0514	.0566	.12	.0514	.0381
4	.0754	.0857	.0686	.0754	.12	.0686	.0381
5	.0943	.1029	.0857	.1132	.1372	.0857	.0572
6	.1698	.1372	.12	.1509	.1372		.0762
7	.1867	.1543	.1543	.1886	.1372	.0686	.132
8	.2402	.2058	.1715	.2241	.12	.12	.132
9	.2218	.2058	.1543	.2614	.1886	.1372	.168
10		.2012	.1543	.1886	.1543	.1663	.12
11		.168			.1029		.1372
12	.1372	.1494			.12		.12
13	.12	.1109	.1029		.12	.128	
14	.1029	.1109	.1029		.12	.0514	
15	.1029	.1294			.12	.1463	
16	.1372	.1494	.1372		.12	.0914	
17	.1886	.1372	.168		.2058	.2402	.0857
18	.2743	.2058	.2614	.2401	.2229	.2801	.3086
19	.3086	.2572	.3174	.2572	.2915		.3429
20	.2915	.3086	.2829	.2743	.2229		.3429
21	.2572	.2572	.2075	.2401	.2229		.0343
22	.1372	.1715		.1715	.1886		.2572
23	.0857	.0857	.0754	.1372	.12	.0566	.1715
24	.0754	.0686	.0686	.0566		.0514	.0566
Max	.3086	.3086	.3174	.2743	.2915	.2801	.3429
Min	.0566	.0686	.0514	.0566	.1029	.0514	.0343
Avg	.1543	.1504	.1402	.1617	.1521	.1086	.1366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 204 / 11 kv Digavade Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0343	.0343	.0152	.0762	.1067
2	.0152	.0343	.0343	.0152	.061	.1067
3	.0152	.0343	.0343	.0152	.061	.0914
4	.0152	.0343	.0343	.0152	.061	.1029
5	.0152	.0343	.0343	.0152	.1067	.0914
6	.0152	.0343	.0343	.0152	.1067	.1067
7	.0305	.0343		.0305	.12	
8	.0305	.0343	.0154	.0152	.1067	
9	.0762	.0343	.0343		.0305	
10		.1067	.1067	.0171		.0305
11		.0914			.0152	
12	.12	.0914			.0152	.0305
13	.1715	.0914	.0914		.0152	
14	.12	.061	.0914		.0152	
15	.12	.0762			.0152	
16	.12	.0762			.0152	
17	.0343	.0343	.0305		.0152	.0305
18	.0343	.0343	.0305	.0343		
19	.0343	.0343	.0305	.0343	.0305	
20	.0343	.0343	.0305	.0305	.0152	
21	.0343	.0343	.0305	.0305	.0152	
22	.0343	.0343		.0914	.1372	
23	.0343	.0343	.0305	.0914	.1219	
24	.0152	.0343	.0343	.0152		.1219
Max	.1715	.1067	.1067	.0914	.1372	.1219
Min	.0152	.0343	.0154	.0152	.0152	.0305
Avg	.0516	.0491	.0424	.0301	.0551	.0819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 205 / 11 KV ALAVE-KOTOLI VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1543	.1698	.132	.1543	.12	.1132
2	.1509	.1372	.1372	.132	.1543	.12	.1132
3	.1509	.1372	.1372	.132	.1372	.12	.1132
4	.1509	.1543	.1543	.132	.1372	.1372	.1132
5	.1698	.2058	.2058	.1698	.1715	.2058	.132
6	.2427	.2572	.2401	.2452	.2058	.2401	.2801
7	.2987	.3086	.2572	.2987	.2229	.2915	.2987
8	.2926	.3086	.2915	.3361	.2915	.3086	.3174
9	.3109	.3429	.2743		.2743	.3258	.2987
10		.3109	.2572	.3086		.3475	.2743
11		.3142			.2915		.2743
12	.2058	.2926			.2915	.2926	.2743
13	.2572	.2957	.2401		.2743	.2561	
14		.2195	.2561		.2058	.2195	
15	.2572	.2561			.2229	.2195	
16	.2915	.3109			.2572	.2561	
17	.2572	.3258	.3696		.3772	.3292	.1372
18	.3601	.3601	.4294	.2743	.3944	.3696	.3601
19	.4458	.3772	.5041	.3086	.4458		.4458
20	.4115	.4115	.4668	.3429	.4287		.4801
21	.3772	.3772	.3961	.3258	.3601		.0343
22	.2915	.3086		.2401	.2915		.2572
23	.2572	.2401	.1698	.1715	.1543	.132	.1715
24	.1698	.1715	.1715	.1509		.12	.1132
Max	.4458	.4115	.5041	.3429	.4458	.3696	.4801
Min	.1509	.1372	.1372	.132	.1372	.12	.0343
Avg	.2619	.2741	.2699	.2313	.2611	.2322	.2301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 206 / 11 KV GHOTWADE AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.2572	.1543	.0732		
2	.0152	.2058	.1372	.0732		
3	.0152	.1543	.1029	.0732		
4	.0152	.1543	.1029	.0732		
5	.0152	.1543	.1029	.0732		
6		.1372	.12	.0914		
7		.1715	.1372	.1463		
8	.3189					
9					.1219	.0914
10				.1543		.0914
11					.1372	
12					.1219	
13					.1219	.0732
14					.0914	
15					.0914	.1097
16					.0762	.0716
22	.3429	.2601				
23	.3086	.2401	.0914			
24	.0133	.3086	.1886	.0732		
Max	.3429	.3086	.1886	.1543	.1372	.1097
Min	.0133	.1372	.0914	.0732	.0762	.0716
Avg	.1177	.2043	.1264	.0924	.1088	.0875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 201 / 11 kv M.Shiroli sheti fdr AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0953	.0381	.0572	.0381		
2	.0572	.0953	.0381	.0572	.0381		
3	.0572	.0953	.0381	.0572	.0381		
4	.0572	.0953	.0381	.0572	.0381		
5	.0572	.0953	.0381	.0572	.0381		
6	.0762	.0953	.0572	.0572	.0381		
7	.1905	.1334	.0381	.0572	.0381		
8	.0572	.0572	.0572	.0572	.0381		
9	.0572	.0572	.2096	.1334	.0572		
10	.0572	.0572	.2096	.1334	.0762		
11	.0572	.0381			.0762		
12		.0381			.0572		
13	.0381	.0381	.1334		.0572		
14	.0381	.0381	.1334	.0762	.0572		
15	.0381	.0572	.1524	.0762	.0572		
16	.0381	.0381	.1524	.0762	.0572	.0762	
17	.0381	.0572			.0572	.0762	.0381
18	.0381	.0572	.0572	.0572	.0572	.0572	.0381
19	.0572	.0572	.0572	.0572	.0572		.0381
20	.0572	.0572	.0572	.0572	.0572	.0572	.0381
21	.0572	.0572	.0572	.0381	.0572	.0381	.0381
22	.0953	.0381		.0381	.0381	.0762	
23	.0953	.0381	.0572	.0381	.0381		
24	.0572	.0953	.0381	.0572	.0381	.0381	
Max	.1905	.1334	.2096	.1334	.0762	.0762	.0381
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0622	.0659	.0829	.0648	.0500	.0599	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 202 / 11 kv Chande Sheti Feeder

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381		.0381	.0381	.0381	.0381
3	.0381	.0381		.0381	.0381	.0381	
4	.0381	.0381		.0762	.0381	.0381	
5	.0381	.0381		.0762	.0381		
6	.0381	.0381		.0762	.0381		
7	.0381	.0381		.1905	.0381		
8	.0381	.0381		.1905	.0381		
9	.4382	.4763		.0381	.0381		
10	.4763	.5144		.0381	.0381		
11	.5144	.5144					.0381
12		.5335			.0381		.0381
13	.5906	.4572			.0381	.0381	
14	.4763	.4763	.0381	.0381	.0381	.0381	.0381
15	.381	.4572	.0381	.0381	.0381	.0381	.0381
16		.4572	.0381	.0381	.0381	.0381	.0381
17		.0381	.0381		.0381	.0381	.0381
18		.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381		
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381		.0381	.0381	.0381	.0381
22	.0381	.0381		.0381	.0381	.0381	
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	.5906	.5335	.0381	.1905	.0381	.0381	.0381
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.1705	.1873	.0381	.0591	.0381	.0381	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 203 / 11 Kv Kanchanwadi Sheti AG Feeder with SDT

Feeder Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2		.0381	.0381	.0381	.0381	.0381	.0381
3		.0381	.0381	.0381	.0381	.0381	.0381
4		.0762	.0381	.0381	.0381	.0381	.0381
5		.1143	.0381	.0381	.0381		.0381
6		.1524	.0381	.0381	.0381		.0762
7	.0381	.1715	.0381	.0381			
8		.0381	.0381	.0381			
9		.0381	.1905	.1905	.0381		.0381
10		.0381	.1905	.1334	.0381		
11		.0381			.0381		.0381
12		.0381			.0381		.0381
13	.0381	.0381	.1905		.0381	.0572	
14	.0381	.0381	.1905	.0572	.0381	.0381	.0381
15	.0381	.0381	.1905	.0572	.0381		.0381
16	.0381	.0381		.0572	.0381	.0953	.0381
17	.0381	.0381	.0381		.0381	.0381	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381		.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381		.0381	.0381	.0381	
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	.0381	.1715	.1905	.1905	.0381	.0953	.0762
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0381	.0532	.0762	.0534	.0381	.0436	.0401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 204 / 11 KV Arale AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0572		.0381	.0381	
2			.0572		.0381	.0381	
3			.0572		.0381	.0381	
4			.0572		.0381	.0762	
5			.0572		.0381		
6			.0572		.0381		
7			.0953		.0381		
9	.2096	.2477					.0381
10	.1905	.2667					.0381
11	.1715	.2096					.0381
12		.381					.0381
13	.2858	.381					
14	.2286	.381					.0381
15	.1715	.2477					.0381
16	.1524	.1715					.0381
22		.0381		.0381	.0381		
23		.0572		.0381	.0381		
24			.0572		.0381	.0381	
Max	.2858	.381	.0953	.0381	.0381	.0762	.0381
Min	.1524	.0381	.0572	.0381	.0381	.0381	.0381
Avg	.2014	.2382	.0620	.0381	.0381	.0457	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 205 / 11 kv M. Shirolgi Gaothan Gaothan Feeder
fdr Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.1524	.1524	.1905	.1905	.1524
2	.1905	.1715	.1524	.1524	.1905	.1905	.1524
3	.1905	.1715	.1524	.1524		.1905	.2286
4	.2286	.1905	.1905	.1524		.1905	.2286
5	.3048	.2667	.2667	.2286			.3048
6	.4191	.381	.3048	.3048			.362
7	.381	.381	.3239	.381	.3429		
8	.3429	.3429	.2858	.381	.3429		
9	.3048	.3239	.2858	.381	.2667		.3239
10	.2858	.3239	.2858	.2667	.2667		.2286
11	.2477	.2667			.2667		.2286
12		.2286			.2667		.2286
13	.2477	.1905	.2858		.2667	.381	
14	.2286	.1905	.2858	.1905	.3048	.3429	.1905
15	.2286	.1905	.2858	.2286	.3048	.381	.1905
16	.2286	.2667	.2858	.2667	.3048	.381	
17	.2286	.3239	.2858		.381		.2286
18	.3048	.381	.381	.3048	.4191	.3429	.2477
19	.4572	.3239	.0381	.381	.4572		
20	.4572	.4572	.381	.4191	.4572	.4572	.4191
21	.381	.381	.381	.3429	.4572	.4191	.3048
22	.3048	.2858		.2667	.381	.2667	
23	.1905	.2286	.1905	.1905	.3048	.1524	.1905
24	.1905	.1715	.1905	.1524	.2286	.2286	.1524
Max	.4572	.4572	.381	.4191	.4572	.4572	.4191
Min	.1905	.1715	.0381	.1524	.1905	.1524	.1524
Avg	.2841	.2755	.2567	.2648	.3200	.2939	.2424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 206 / 11 Kv Chande Gavthan

Gaathan Feeder

Feeder Feeder KV- 11 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0762	.0953	
2	.0953	.0953	.0953	.0953	.0762	.0953	
3	.0953	.0953	.0953	.0953	.0762	.0953	
4	.1143	.1143	.1143	.0953	.0953	.0953	
5	.1524	.1524	.1334	.0953	.1334		
6	.1905	.1905	.1715	.1334	.1715		
7	.2096	.2096	.2096	.2286	.1905		
8	.1715	.1715	.1715	.2286	.1905		
9	.1715	.1334	.1524	.2286	.1524		.0953
10	.1524	.1524	.1524	.1524	.1524		.0762
11	.1524	.1524					.0762
12		.1143			.1334		.0762
13	.1143	.0953	.0762		.1334	.1143	
14	.1143	.0953	.0762	.0953	.1334	.0953	.0762
15	.1143	.0953	.0762	.0953	.1334	.0953	.0762
16		.0953	.1334	.1143	.1524	.1524	.0762
17		.1334	.1524		.1905	.1715	.0953
18		.1715	.1715	.1524	.2286	.2477	.1334
19	.2477	.1905	.2286	.2096	.2286		.2286
20	.2477	.2667		.2286	.2286	.2667	.1905
21	.1905	.2096	.2286	.2096	.2286	.2286	.1524
22	.1334	.1715		.1524	.1905		
23	.1143	.1334	.0953	.0953	.1524		.0762
24	.0953	.0953	.0953	.0953	.0762	.0953	
Max	.2477	.2667	.2286	.2286	.2286	.2667	.2286
Min	.0953	.0953	.0762	.0953	.0762	.0953	.0762
Avg	.1486	.1429	.1362	.1448	.1532	.1422	.1099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 207 / 11 Kv Kanchanwadi Gavthan

Gaathan Feeder

Feed Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905		.1905	.1905
2	.1905	.1905	.1905	.1905		.1905	.1905
3	.1905	.1905	.1905	.1905		.1905	.1905
4	.2286	.2286	.2667	.1905		.1905	.2667
5	.3429	.3048	.3429	.2667			.381
6	.4572	.4191	.4191	.4191			.4572
7	.4191	.381	.4001	.4191			
8	.381	.4001	.4191	.4191			
9	.3429	.381	.3429	.381	.2667		.4572
10	.3429	.3429	.3429	.3048	.2667		.3429
11	.3429	.3429			.2667		.2667
12		.3239			.2667		.2286
13	.3429	.3048	.2667		.2667	.2858	
14	.3429	.3048	.2667	.2096	.2667	.2858	.1905
15	.3429	.3048	.2667	.2667	.2667		.1905
16	.3429	.3048	.3048	.2858	.3429	.3429	.1905
17		.2858	.3048		.381	.362	.2286
18	.381	.3239	.4191	.3429	.4763	.3239	.2667
19	.4572	.362	.4763	.4191	.4763		.381
20	.4191	.362	.4763	.4572	.4763	.4763	.381
21	.381	.362	.2286	.381	.4763	.4001	.3429
22	.3048	.2858		.2667	.381	.3048	
23	.1905	.2286	.1905	.1905	.2286	.2286	
24	.1905	.1905	.1905	.1905	.0381	.1905	.1905
Max	.4572	.4191	.4763	.4572	.4763	.4763	.4572
Min	.1905	.1905	.1905	.1905	.0381	.1905	.1905
Avg	.3239	.3048	.3093	.2991	.3215	.2831	.2807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 208 / 11 kv ARALE GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0572	.0572
4	.0572	.0572	.0572	.0572	.0572	.0572	.0572
5	.0762	.0572	.0762	.0762	.0762		.0572
6	.0953	.0762	.1143	.0953	.1143		.0572
7	.1143	.1334	.1143	.1143	.1143		
8	.1143	.1524	.1143	.1143	.0953		
9	.0953	.1143	.0953	.1143	.0762		.0762
10	.0762	.1143	.0953	.1143	.0953		.0572
11	.0762	.1143			.0953		.0572
12		.0953			.0953		.0572
13	.0762	.0953			.0953	.0572	
14	.0953	.0953	.0953	.0762	.0762	.0572	.0572
15	.0953	.0572	.0953	.0762	.0762	.0572	.0572
16	.0762	.0762	.0953	.0953	.0953	.0953	.0572
17	.0953	.0762	.0953		.1143	.1143	.0572
18	.1143	.1143	.1143	.1143	.1524	.1334	.0762
19	.1524	.1334	.1524	.1334	.1524		
20	.1715	.1524	.1524	.1334	.1524	.1524	.1334
21	.1524	.1334	.1143	.1143	.1524	.1143	.1143
22	.0953	.0762		.0762	.0953	.0762	
23	.0572	.0572	.0572	.0572	.0572	.0572	.0572
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	.1715	.1524	.1524	.1334	.1524	.1524	.1334
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0920	.0921	.0934	.0896	.0945	.0800	.0662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 201 / 11 Kv Bachani Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0566	.0343	.0343	.0168	.0343	.0381
2	.0686	.0566	.0514	.0343	.017	.0343	.0381
3	.0686	.0566	.0509	.0343	.0168	.0351	.0381
4	.0686	.0566	.0514	.0343	.0173	.0339	.0572
5	.0857	.0566	.0503	.0343	.0171	.0354	.0572
6	.1029	.0754	.0514	.0343	.0171	.0351	.0762
7	.1886	.1509	.0503	.0343	.0171	.0343	.0572
8	.0343	.0377	.0509	.0343	.0175	.0339	.0381
9		.0381	.2075	.0762	.0171	.0686	.0377
10		.0381	.2263	.0953	.0171	.0686	.0377
11		.0381			.0526		.0377
12	.0335	.0381		.0762	.0173		
13	.0343	.0381	.2263	.0762	.0339	.0686	.0373
14		.0381	.2263	.0953	.0339	.0686	.0377
15		.0381		.0953	.0509	.0686	.0377
16	.0335	.0191		.0762	.0339	.0762	.0189
17	.0377	.0335	.0343	.037	.0335	.0381	.0377
18	.0377	.0335	.0343	.0377	.0339	.0381	.0377
19	.0373	.0335	.0343	.0377	.0339	.0381	.0373
20	.0377	.0339	.0343		.0339	.0381	.0377
21	.0377	.0335	.0343		.0339		.0377
22	.0566	.0335			.0343		.0366
23	.0377	.0335	.0343		.0335		.0566
24	.0686	.0566	.0343	.0343	.0166	.0339	.0381
Max	.1886	.1509	.2263	.0953	.0526	.0762	.0762
Min	.0335	.0191	.0343	.0343	.0166	.0339	.0189
Avg	.0599	.0468	.0799	.0533	.0270	.0464	.0419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 202 / 11 Kv Nandgaon Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0377	.0655	.1715	.0972	.1802	.0381
2	.0343	.0373	.0663	.1715	.1006	.1638	.0381
3	.0343	.0362	.0671	.1715	.0829	.1619	.0381
4	.0343	.0377	.0819	.1715	.0819	.1802	.0381
5	.0343	.0377	.1134	.1715	.0972	.1989	.0381
6	.0343	.0377	.1966	.1715	.1134	.2012	.0381
7	.0343	.0566	.1658	.1715	.1147	.1147	.0572
8	.0343	.0566	.0324	.0343	.0324	.0324	.0381
9		.1905	.0366	.0381	.0332	.0343	.0905
10		.1905	.0377	.0381	.0328	.0343	.112
11		.1905			.032		.1132
12	.1296	.2096		.0381	.0335		.1463
13	.0983	.2858	.0377	.0381	.0324	.0343	.1886
14		.2477	.0377	.0381	.0328	.0343	.1867
15		.2858		.0572	.0328	.0343	
16	.1475	.2667		.0381	.0328	.0381	
17	.0377	.0328	.0343	.0377	.0328	.0381	.0366
18	.0377	.0324	.0343	.0377	.0328	.0381	.0377
19	.0377	.0335	.0343	.0377	.0328	.0381	.0377
20	.0377	.0332	.0343		.0328	.0381	.0377
21	.0377	.0328	.0343		.0328		.0378
22	.0377	.0819			.0343		.0377
23	.0377	.0819	.1029		.1966		.0373
24	.0343	.0377	.0829	.1029	.116	.1989	.0381
Max	.1475	.2858	.1966	.1715	.1966	.2012	.1886
Min	.0343	.0324	.0324	.0343	.032	.0324	.0366
Avg	.0499	.1071	.0682	.0914	.0622	.0944	.0664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 203 / 11 kv Ispurli Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1509	.2785	.1715		.1619	.0762
2	.12	.132	.2753	.1715		.1781	.0762
3	.1372	.1494	.3113	.1715		.1781	.0762
4	.1372	.1698	.3201	.2058		.1943	.0953
5	.1543	.1886	.3201	.2401		.2105	.0953
6	.1715	.2263	.3563	.2743		.213	.1143
7	.2058	.1886	.4858	.5487		.3887	.1143
8	.2058	.1886	.1677	.12		.1296	.0762
9		.8002	.6036	.1905		.1372	
10		.8764	.2172			.1372	
11		.9335	.2075	.1715	.1296		
12	.5571	.8573	.1886	.1715	.128		.2452
13	.5304	.8764	.1509	.1334	.1134	.1372	.2263
14		.8192	.1132	.1524	.112	.1372	
15		.8002		.1715	.112		
16	.4534	.8383		.1905	.112		
17	.1698	.1341	.1372	.1886	.128	.1143	.0943
18	.1509	.1296	.1372	.1698	.1296	.0953	.1132
19	.1886	.176	.1715	.1886	.128	.0953	.1132
20	.2075	.208	.1715		.16	.0953	.1109
21	.2241	.1943	.1715		.1619		.1132
22	.1867	.3201			.192		
23	.1829	.2721	.2058		.2881		.1132
24	.1372	.1886	.2915	.1715	.2105	.16	.0762
Max	.5571	.9335	.6036	.5487	.2881	.3887	.2452
Min	.12	.1296	.1132	.12	.112	.0953	.0762
Avg	.2232	.4091	.2515	.2002	.1504	.1625	.1135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 204 / 11 Kv Bachani Vg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2829	.3048	.2743	.3048	.2667	.3048
2	.2572	.2641	.2858	.2572	.2858	.2858	.2858
3	.3086	.2641	.2858	.2915	.2858	.3239	.2858
4	.3601	.4668	.3239	.3429	.362	.362	.362
5	.4115	.4572	.4001	.4115	.4001	.4001	.4382
6	.4801	.547	.4954	.5144	.5525	.4954	.5335
7	.5316	.5847	.5716		.5716	.6097	.6097
8	.4801	.547	.5335	.4801	.5906	.6097	.5906
9		.4191	.4338	.4954	.4954	.5144	.4715
10		.4001	.3772	.4572	.4191	.3601	.415
11		.381			.381		.3772
12	.3429	.4191		.381	.381		.3772
13	.3048	.3429	.3292	.3239	.2286	.2743	.3584
14		.362	.3206	.3048	.2667	.3429	.3584
15		.3429		.3429	.3429	.3944	
16	.381	.4763		.3429	.4191	.4763	.4715
17	.4527	.4572	.3944	.3772	.4572	.5335	.4715
18	.4715	.4191	.463	.4668	.4954	.5525	.4715
19	.6413	.5335	.5658	.6036	.6097	.6097	.5093
20	.679	.6478	.6001		.6478	.6478	.6413
21	.6224	.5716	.5487		.5716		.5847
22	.4527	.4572			.4572		.4715
23	.3734	.4191	.3258		.3048		.3395
24	.3086	.3395	.3429	.3086	.3239	.2667	.3048
Max	.679	.6478	.6001	.6036	.6478	.6478	.6413
Min	.2572	.2641	.2858	.2572	.2286	.2667	.2858
Avg	.4281	.4334	.4159	.3876	.4231	.4382	.4362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 205 / 11 kv ispurli Vg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3109	.3429	.2915	.3239	.2858	.3239
2	.2743	.3018	.3429	.2743	.3048	.2858	.3048
3	.3429	.3018	.362	.3429	.3048	.3239	.3048
4	.4458	.3772	.3239	.4458	.4572	.381	.381
5	.5144	.547	.4191	.6173	.5525	.4191	.5144
6	.583	.7545	.7621	.7202	.7621	.6668	.6859
7	.6859	.8299	.7621	.6859	.7621	.8002	.7621
8	.6001	.7545	.724	.6344	.7621	.6859	.6859
9		.5716		.5716	.5335	.5487	.5292
10		.5716	.4904	.5716	.5525	.4801	.4904
11		.5525			.4572		.4715
12	.4954	.4954		.5144	.381		.4715
13	.381	.4001	.3206	.381	.3239	.2401	.4527
14		.381	.3206		.3429	.2915	
15		.4954		.4001	.381	.3429	
16	.5335	.4954		.4572	.5144	.4382	
17	.6036	.5716	.4458	.5658	.6097	.4763	.5093
18	.679	.5144	.5144	.6161	.6478	.6478	.5658
19	.7545	.5906	.6859	.7545	.724	.7621	.6154
20	.7922	.7811	.7545		.7811	.8002	.8299
21	.7545	.724	.6859		.724		.6979
22	.5093	.6478			.5716		
23	.439	.4572	.3429		.3429		.3475
24	.3429	.3772	.381	.3258	.3429	.3048	.3239
Max	.7922	.8299	.7621	.7545	.7811	.8002	.8299
Min	.2743	.3018	.3206	.2743	.3048	.2401	.3048
Avg	.5275	.5335	.4989	.5095	.5192	.4832	.5134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 206 / 11 KV Renuka & Hanuman

HV LIS Feeder

Express Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0171	.0189	.0171	.0191	.0191	.0191
4	.0171	.0189	.0171	.0191	.0191	.0191
5	.0171	.0189	.0171	.0191	.0191	.0191
6	.0171	.0189	.0171	.0191	.0191	.0191
7			.0171	.0191	.0191	.0191
8	.0171	.0189	.0171	.0191	.0191	.0191
9		.0191	.0191	.0191	.0171	.0189
10		.0191	.0191	.0191	.0171	.0189
11		.0191		.0191		.0183
12	.0191	.0191	.0191	.0191		.0189
13	.0191	.0191	.0191	.0191	.0171	.0171
14		.0191	.0191	.0191	.0171	
15		.0191	.0191	.0191	.0171	
16	.0191	.0191	.0191	.0191	.0191	
17	.0189	.0191	.0187	.0191	.0191	
18	.0189	.0191	.0183	.0191	.0191	
Max	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0171	.0189	.0171	.0191	.0171	.0171
Avg	.0181	.0190	.0182	.0191	.0184	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 207 / 11 KV Kawane Ag Feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0189	.0173	.0171	.017	.0171	.0191
2	.0171	.0189	.0177	.0171	.017	.0171	.0191
3	.0171	.0189	.017	.0171	.017	.0175	.0191
4	.0171	.0189	.017	.0171	.017	.017	.0191
5	.0171	.0183	.0168	.0171	.0171	.017	.0191
6	.0171	.0189	.0173	.0171	.0171	.0171	.0191
7	.0171	.0189	.017	.0171	.0171	.0175	.0191
8	.0171	.0189	.0168	.0171	.0171	.0177	.0191
9		.0191	.0189	.0191	.0168	.0171	.0187
10		.0191	.0189	.0191	.0168	.0171	.0189
11		.0191			.0168		.0189
12		.0191			.017		.0189
13	.0168	.0191		.0191	.017	.0171	.0189
14	.017	.0191		.0191	.017	.0171	.0181
15		.0191		.0191	.017	.0171	
16	.017	.0191		.0191	.0168	.0191	
17	.0189	.0162	.0171		.0168	.0191	.0181
18	.0189	.017	.0171	.0189	.0171	.0191	.0187
19	.0189	.0162	.0171	.0189	.0171	.0191	.0189
20	.0189	.0168	.0171		.017	.0191	.0189
21	.0189	.0166	.0171		.0168		.0189
22	.0189				.0175		.0189
23	.0189	.0171	.0171		.0168		.0189
24	.0171	.0189	.0175	.0171	.0168	.017	.0191
Max	.0189	.0191	.0189	.0191	.0175	.0191	.0191
Min	.0168	.0162	.0168	.0171	.0168	.017	.0181
Avg	.0177	.0184	.0173	.0180	.0170	.0177	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 201 / 11 KV BHOGAWATI GAVTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2075	.2614	.2641	.2452		.2427
2	.2641	.2075	.2614	.2641	.2452		.2402
3	.2641	.2075	.2614	.2641	.2452		.2427
4	.2641	.2075	.2801	.2641	.2452		.2378
5	.3361	.3584	.2957	.3361	.3395		.2926
6	.5041	.4904	.462	.4294	.4755		.439
7	.5041	.4668	.4854	.4854	.4938	.0187	.4572
8	.4251	.4572	.4108	.4668	.439	.4938	.3801
9		.5068	.4066	.4481	.439	.4854	.3841
10		.439	.4024	.2195	.439	.2195	
11	.439	.4024		.2195	.4572		.3734
12	.3841	.4024			.3292		.3547
13	.3292	.3077	.2378		.2865	.1829	.3292
14	.2896	.2686	.128	.128	.2743	.128	.2957
15		.2686	.0914	.128	.2561	.1267	.2957
16	.439	.3506		.1829		.1829	
17	.4938	.362	.1829		.4024	.2012	.4108
18	.4435	.4344	.3658	.2012	.4755	.439	.4207
19	.4715	.4706	.4435	.439	.4706	.5041	.4938
20	.4904	.4755	.5544	.5281	.5121	.5487	.5359
21	.4904	.4755	.499	.5658	.4755		.499
22	.3961	.3841	.3961	.4904	.4108		.4294
23	.2641	.2957	.2829	.3584	.3361		.3206
24	.2641	.2452	.2614	.2641	.2829	.2614	.2801
Max	.5041	.5068	.5544	.5658	.5121	.5487	.5359
Min	.2641	.2075	.0914	.128	.2452	.0187	.2378
Avg	.3819	.3622	.3319	.3308	.3729	.2917	.3616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 202 / 11 KV RASHIWADE

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0213	.0381	.0305	.0305	.0381	.0332
2	.0152	.0191	.0381	.0305	.0305	.0381	.0332
3	.0152	.0191	.0381	.0305	.0305	.0381	.0332
4	.0152	.0183	.0381	.0305	.0305	.0381	.0332
5	.0152	.0168	.0381	.0305	.0305	.0381	.0332
6	.0152	.016	.0381	.0305	.0305	.0381	.0332
7	.0152	.016	.0381	.0305	.0305	.0381	.0332
8	.0189	.0381	.0381	.0305	.0152	.0381	.0332
9		.0191	.0503	.0305	.0076	.0332	.0332
10		.0191	.0497	.0177	.0076	.0183	
11	.0166	.0191		.0183	.0076		
12	.0166	.0191			.0076		
13	.0166	.0191	.0191		.0091	.0354	.0191
14	.0166	.0191	.0166	.0183	.0076	.0366	.0191
15		.0191	.0332	.0183	.0076	.0183	.0191
16	.0166	.0191		.0183		.0181	
17	.0166	.0191	.0183		.0343	.0183	.0191
18	.0191	.0191	.0305	.0166	.0381	.0166	.032
19	.0191	.0191	.0305	.0166	.0381	.0166	.0324
20	.0381	.0191	.0305	.0305	.0381	.0166	.0324
21	.0381	.0191	.0305	.0305	.0381		.0324
22	.0213	.0191	.0305	.0305	.0381		.0286
23	.0213	.0381	.0305	.0305	.0381		.0286
24	.0152	.0213	.0381	.0305	.0305	.0381	.0332
Max	.0381	.0381	.0503	.0305	.0381	.0381	.0332
Min	.0152	.016	.0166	.0166	.0076	.0166	.0191
Avg	.0189	.0205	.0340	.0262	.0251	.0300	.0297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 203 / 11 KV KOULAV AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0191	.0156	.0189	.0189	.0162	.0191
2	.0189	.0191	.0158	.0189	.0189	.0162	.0191
3	.0189	.0191	.0158	.0189	.0189	.0162	.0191
4	.0189	.0191	.0156	.0189	.0189	.0162	.0191
5	.0189	.0191		.0189	.0189	.0162	.0191
6	.0189	.0191		.0189	.0189	.016	.0191
7	.0189	.0191		.0189	.0189	.0162	.0191
8	.0189	.0191		.0189	.0189	.0191	.0191
9		.0587		.0189	.0189	.0191	.0191
10		.064	.0191		.0189	.0183	
11	.0914	.0648			.0189		
12	.0663	.032			.0189		
13		.0469	.0191		.0189	.0183	
14		.0312	.0183		.0189	.0183	
15		.0312	.0158		.0189	.0183	.0168
16	.0791	.0469				.0183	
17	.0158	.0191	.0183		.0189	.0183	.0168
18	.0191	.0191	.0189		.0191		.0189
19	.0191	.0191	.0189	.0152	.0191	.0191	.0189
20		.0191	.0189	.0189	.0191	.0191	.0189
21	.0381	.0191	.0189	.0189	.0191		.0189
22	.0381	.0312		.0189	.0162		.0189
23	.0191	.0162	.0189	.0189	.0168		.0189
24	.0189	.0191	.0156	.0189	.0189	.0162	.0191
Max	.0914	.0648	.0191	.0189	.0191	.0191	.0191
Min	.0158	.0162	.0156	.0152	.0162	.016	.0168
Avg	.0309	.0288	.0176	.0187	.0187	.0175	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 204 / 11 KV NAGESHWAR GAVTHAN

Gaathan Feeder

VG FD Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.1132	.0943	.0943	.0943
2	.1132	.1143	.1132	.1132	.0943	.0943	.0943
3	.1132	.1143	.1132	.1132	.0943	.0943	.0943
4	.0189	.1143	.1132	.1132	.0943	.0943	.0943
5	.132	.1334	.1132	.1509	.0943	.0943	.1132
6	.1698	.1524	.1509	.1698	.1509	.1494	.1509
7	.2054	.1905	.1886	.1886	.168	.1886	.2075
8	.1867	.1886	.1867	.1886	.1663	.2054	.1698
9		.1698	.1494	.1698	.1829	.168	.1698
10		.1629	.1307	.1646	.1663	.1646	
11	.1294	.1478		.1463	.1494		.1307
12	.1494	.1294			.1463		.1494
13		.0886	.1097		.1097	.128	.1097
14		.1086	.1097	.128	.1294	.1463	.1294
15		.0905	.112	.128	.1294	.128	.1307
16	.1227	.1357		.1646		.1829	
17	.1791	.1848	.1463		.128	.2195	.1867
18	.1791	.1949	.168	.2427	.2033		.2033
19	.2641	.2218	.2263	.2427	.2587	.2614	.2772
20	.3018	.2772	.2614	.2801	.2587	.2801	.2987
21	.2452	.2378	.2452	.2427	.2452		.2427
22	.1698	.1829	.1886	.1867	.1886		.2075
23	.132	.132	.132	.132	.1509		.132
24	.1132	.1143	.1132	.1132	.0943	.0943	.0943
Max	.3018	.2772	.2614	.2801	.2587	.2801	.2987
Min	.0189	.0886	.1097	.1132	.0943	.0943	.0943
Avg	.1599	.1542	.1517	.1663	.1521	.1549	.1582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 205 / SHAHU LIS

HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0189	.0191	.0189	.0189	.0191	.0191
4	.0189	.0191	.0189	.0189	.0191	.0191
5	.0189	.0191	.0189	.0189	.0191	.0191
6	.0189	.0191	.0189	.0189	.0191	.0191
7	.0189	.0191	.0189	.0189	.0191	.0191
8	.0189	.0191	.0189	.0189	.0191	.0191
9		.0191	.0189	.0189	.0191	.0191
10		.0191		.0189	.0183	
11	.0191	.0191		.0189		.0191
12	.0191	.0191		.0189		.0191
13		.0191		.0189	.0183	.0191
14		.0191		.0189	.0183	.0191
15		.0191		.0189	.0183	.0191
16	.0191	.0191			.0183	
17	.0191	.0191		.0183	.0183	.0191
18	.0191	.0191	.0191	.0191		.0189
19			.0191			
Max	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0189	.0191	.0189	.0183	.0183	.0189
Avg	.0190	.0191	.0189	.0189	.0187	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 201 / 11 Kv Wakare Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0137	.0168	.0274	.0332	.0343	.0274	.0166
2	.0137	.0168	.0274	.0335	.0351	.0274	.0168
3	.0137	.0168	.0274	.0335	.0347	.0274	.0168
4	.0137	.0168	.0274	.0335	.0351	.0274	.0168
5	.0137	.0168	.0274	.0335		.0274	.0168
6	.0139	.0166	.0274	.0335		.0274	.0166
7	.0139	.0166	.0412	.0335		.0274	.0168
8	.0139	.0335	.0137	.0168		.0137	.0166
9	.0316	.0168	.0177	.0177		.0171	
10		.0335		.0181		.0171	
11		.0335		.0175		.0175	.0274
12	.0278	.0335		.0171		.0171	.0274
13	.0278	.0332		.0175	.0175	.0171	.0274
14	.0278	.0332		.0173	.0173	.0171	
15		.0335		.0175		.0171	
16	.0278	.0335		.0171		.0151	
17	.0177	.0137			.0137		.0137
18	.0171	.0137	.0166	.0135	.0137		.0135
19	.0177	.0137	.0166	.0135	.0137		.0135
20	.0171	.0137	.0168	.0173	.0137		.0137
21	.0111	.0137	.0168	.0177	.0137		.0137
22	.0173	.0274	.0335	.0175			.0135
23	.0147	.0274	.0335	.037	.0274		.0135
24	.0137	.0166	.0274	.0168	.0343	.0274	.0168
Max	.0316	.0335	.0412	.037	.0351	.0274	.0274
Min	.0111	.0137	.0137	.0135	.0137	.0137	.0135
Avg	.0181	.0226	.0249	.0228	.0234	.0217	.0173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 202 / 11 Kv Mahe Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1357	.181	.2713	.1612	.1448	.1372
2	.181	.1357	.181	.2713	.1629	.1448	.1372
3	.181	.1357	.181	.2713	.1629	.1448	.1372
4	.2172	.1357	.181	.2713	.1629	.1448	.1372
5	.2896	.1696	.2172	.3391		.181	.1715
6	.4344	.3647	.362	.4115		.362	.2743
7	.4344	.407	.362	.4115		.4344	.4115
8	.3982	.407	.362	.4115		.4706	.4115
9	.3801	.407		.3544		.439	.4344
10		.407	.3506	.3582		.4481	.4344
11		.407		.3658			.3982
12	.3982	.3391				.3982	.3801
13	.3982	.2713		.362	.4344	.362	.3801
14	.362	.2713		.2534	.4298	.2865	
15		.2896		.2865		.3258	
16	.3258	.2713		.3258		.362	
17	.3155	.3258			.4344		.3982
18	.362	.362	.4748	.3258	.5068		.2896
19	.4481	.362	.5426	.4344	.5068	.407	.4344
20	.4805	.4344	.5365	.4706	.543	.4115	.4344
21	.4854	.4344	.4694	.439	.4706	.4115	.4344
22	.3292	.362	.407	.3077		.2713	.2896
23	.2587	.2172	.3391	.1991	.2172	.1715	.2172
24	.2172	.1696	.181	.2713	.181	.181	.1357
Max	.4854	.4344	.5426	.4706	.543	.4706	.4344
Min	.181	.1357	.181	.1991	.1612	.1448	.1357
Avg	.3370	.3009	.3330	.3369	.3365	.3096	.3085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 203 / 11 Kv Bahireshwar Vg
Feeder KV- 11 / OUTGOING

Gaathan Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1097	.0747	.5121	.0934	.0747	.1097
2	.112	.1097	.0747	.5121	.0739	.2614	.1097
3	.112	.1097	.0747	.5121	.0739	.2614	.1097
4	.112	.1097	.0747	.5853	.0739	.2614	.1097
5	.1478	.1097	.0754	.5853		.2926	.1463
6	.2033	.2195	.1886	.6584		.5281	.1829
7	.1848	.2195	.1463	.7316		.6219	.1829
8	.1612	.2195	.1463	.7316		.6219	.1829
9	.1433	.1829	.1448	.7468		.543	.1463
10		.1829	.1448	.724		.5914	.1829
11		.1829		.5792			.2103
12	.1772	.1829					.1753
13	.1772	.1829			.2241	.4298	.1696
14	.1734	.1829		.4108	.2218	.4435	.156
15		.1829		.5068		.4435	.1772
16	.1772	.1829		.2172		.2218	.1791
17	.181	.1753			.1791		.181
18	.1734	.1433		.1829	.1829		.1478
19	.2218	.1433	.9511	.2195	.2195	.2195	.2054
20	.2587	.2195	.9511	.2054	.2561	.2195	.1867
21	.2614	.1867	.8779	.2054	.2218	.2195	.1867
22	.2241	.1494	.5853	.1848		.1463	.1494
23	.1494	.112	.5121	.112	.112	.1097	.1294
24	.112	.1097	.0747	.5121	.112	.0732	.1097
Max	.2614	.2195	.9511	.7468	.2561	.6219	.2103
Min	.112	.1097	.0747	.112	.0739	.0732	.1097
Avg	.1702	.1629	.3186	.4588	.1573	.3292	.1594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 204 / 11 Kv Sangrul Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0274	.0332	.0135	.0166	.0164	.0135	.0332
2	.0274	.0332	.0135	.0166	.0164	.0135	.0332
3	.0274	.0332	.0135	.0166	.0166	.0135	.0332
4	.0274	.0332	.0135	.0166	.0166	.0135	.0332
5	.0274	.0332	.0135	.0166		.0135	.0332
6	.0274	.0332	.0135	.0166		.0135	.0332
7	.0274	.0332	.0135	.0166		.0135	.0332
8	.0137	.0166	.0135	.0166		.0135	.0166
9	.0137	.0166	.0164	.0328		.0328	
10		.0166		.0332		.0164	
11		.0166		.0328		.0328	.0135
12	.0137	.0166		.0328			.0135
13	.0137	.0166		.0332	.0328	.0328	.0135
14	.0137	.0166		.0332	.0332	.0332	.0135
15		.0166		.0332		.0332	.0137
16	.0137	.0166		.0332		.0332	.0137
17	.0164	.0135			.0135		.0137
18	.0164	.0135	.0166	.0135	.0135		.0135
19	.0164	.0135	.0166	.0135	.0135		.0135
20	.0164	.0135	.0166	.0164	.0135		.0154
21	.0166	.0135	.0166	.0166	.0135	.0166	.0141
22	.0328	.0133	.0166	.0164		.0166	.0274
23	.0328	.0135	.0166	.0166	.0135	.0166	.0274
24	.0274	.0332	.0135	.0166	.0166	.0135	.0332
Max	.0328	.0332	.0166	.0332	.0332	.0332	.0332
Min	.0137	.0133	.0135	.0135	.0135	.0135	.0135
Avg	.0214	.0212	.0148	.0220	.0177	.0203	.0222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 205 / 11 Kv Mahe Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.0168	.0259	.0671	.0829	.0267	.0168
2	.0137	.0168	.0259	.0671	.0819	.0267	.0168
3	.017	.0168	.0259	.0671	.0829	.0267	.017
4	.017	.0168	.0244	.0671	.0829	.0259	.0168
5	.017	.0168	.0244	.0671		.0259	.0168
6	.0162	.0168	.0412	.1006		.0259	.0168
7	.0162	.0168	.1158	.1341		.072	.0168
8	.0162	.0168	.0156	.0168		.0179	.0168
9	.1029	.1341	.0166	.0185		.0126	
10		.1341		.0173		.0185	.0259
11		.1006		.0173		.0175	.0259
12	.0869	.1006				.0171	.0259
13	.0869	.1341			.0128	.0164	.0225
14	.0914	.1296		.0173	.0128	.0128	
15		.1341		.0171		.0164	
16	.0617			.0173		.0173	
17	.0166	.0158			.0154		.0171
18	.0128	.0152	.017	.017	.0164		.0173
19	.0185	.0158	.0168	.017	.0177	.0168	.0175
20	.0185	.0156	.0168	.0126	.0179	.0168	.0177
21	.0166	.0166	.0168	.0173	.0183	.0168	.0177
22	.017	.0333	.0671	.0511		.0168	.0179
23	.0173	.0324	.0671	.0511	.02	.0168	.0179
24	.0149	.0168	.0259	.0671	.0819	.0267	.0168
Max	.1029	.1341	.1158	.1341	.0829	.072	.0259
Min	.0128	.0152	.0156	.0126	.0128	.0126	.0168
Avg	.0330	.0506	.0340	.0440	.0418	.0221	.0187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 206 / 11 Kv bahireshwar Ag
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0137	.0152	.0511	.061	.0524	.0518	.0152
2	.0137	.0152	.0511	.061	.0533	.0518	.0152
3	.0137	.0152	.0511	.061	.0638	.0518	.0152
4	.0137	.0152	.0511	.061	.0572	.0511	.0152
5	.0137	.0152	.0511	.061		.0511	.0168
6	.0137	.0152	.0511	.061		.0518	.0152
7	.0137	.0152	.0754	.0914		.0777	.0152
8	.0152	.0166	.0158	.0152		.0139	.0152
9	.0754	.1067	.0164	.0166		.0109	
10		.1067		.0166		.0128	
11		.0914		.0162		.0126	.0648
12	.0754	.1006		.0166		.0124	.0518
13	.0766	.1219		.0111	.0109	.0126	.0518
14	.0766	.1219		.0105	.0107	.0173	
15		.1372		.0122		.0126	
16	.0503	.1341		.0109		.0126	
17	.0101	.0114			.0152		.013
18	.0105	.0118	.0152	.0139	.0156		.013
19	.0151	.0149	.0152	.0139	.0164	.0152	.0133
20	.0109	.0152	.0152	.0109	.0145	.0152	.0145
21	.0111	.0116	.0152	.0105	.0156	.0152	.0145
22	.0109	.0638	.061	.0543		.0152	.0133
23	.0173	.0638	.061	.0442	.0511	.0152	.0133
24	.0137	.0152	.0511	.061	.0543	.0511	.0152
Max	.0766	.1372	.0754	.0914	.0638	.0777	.0648
Min	.0101	.0114	.0152	.0105	.0107	.0109	.013
Avg	.0269	.0521	.0405	.0344	.0332	.0287	.0211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 203 / 11 kv khupire Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1372	.1524	.2915		.2401	.1715
2	.1829	.1372	.1219	.2058		.2229	.1715
3	.2134	.1543	.1219	.2058		.2058	.1715
4	.2286	.1715	.1981	.1886		.2058	.1715
5	.2286	.2058	.1981	.1886		.2058	.1715
6	.2591	.2572	.2439	.3772		.3086	.2743
7		.2743	.2439	.4458		.3429	.2915
8	.3048	.3086	.2286	.3944		.3601	.3429
9	.2286	.2743		.3772		.3086	.3429
10				.3258		.2743	
11		.3353		.4287		.2572	
12	.3601	.3048				.2743	.2229
13	.3772	.2743		.3944	.2915	.2401	
14	.3944	.2439		.3601	.2915		.3086
15		.2439		.3429	.3258		.3429
16	.3429	.2743				.2401	
17	.3944	.3048		.4287	.3772		.4115
18	.3601	.3048	.4287		.4115	.3772	.4115
19	.3944	.3048	.4287		.4287		.4458
20	.3772	.381	.5316		.463	.4115	.4287
21	.3086	.3048	.5144		.4801	.3772	
22	.2058	.3048				.2915	
23	.1543	.2286	.3258		.3086		.1886
24	.1524	.1543	.1524	.2915		.2743	.1715
Max	.3944	.381	.5316	.4458	.4801	.4115	.4458
Min	.1524	.1372	.1219	.1886	.2915	.2058	.1715
Avg	.2810	.2559	.2779	.3279	.3753	.2852	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 204 / 11 Kv Fulewadi Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6344	.6516	.5316		.583	.4458
2	.6516	.6344	.6516	.5316		.4877	.4458
3	.6516	.6516	.5487	.5316		.5658	.4458
4	.6859	.6516	.5487	.5316		.583	.4801
5	.6859	.6516	.6859	.5658		.6173	.5144
6	.8916	.7202	.8573	.7202		.823	.6687
7	.9602	.9602	1.0288	1.0117		.9259	.9602
8	.9145	1.0288	.9907	1.0117		.823	.9945
9	.7926	.9431		.9259		.823	.9259
10				.7888		.6516	
11		.8573		.7888		.6344	.7202
12	.7373	.8573					.6173
13	.7373	.6859		.5487	.583	.6516	
14	.703	.6097		.583	.6687	.6687	
15		.7202		.6516	.5658		.583
16	.703	.7202				.6173	
17	.7202	.7716		.7202	.6859	.6859	.7202
18	.823	.8573	1.1317	.8573	.9259	.8059	.7716
19	1.0288	.9431	1.1831		1.0631		.9945
20	1.2174	1.2003	1.2346		1.2003	1.0631	1.0631
21	1.166	1.166	1.166		.9145	.9945	
22	.9945	.9907				.9259	
23	.7202	.8573	.8402		.6516		.6859
24	.6859	.6859	.6859	.6001		.5487	.4973
Max	1.2174	1.2003	1.2346	1.0117	1.2003	1.0631	1.0631
Min	.6516	.6097	.5487	.5316	.5658	.4877	.4458
Avg	.8153	.8173	.8718	.7000	.8065	.7240	.6964

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 206 / 11 KV KUDITRE AG FEEDER AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1372	.1372	.0305		.1372	.0305
2		.1372	.1372	.0305		.1372	.0305
3	.2058	.1524	.1715	.0305		.1219	.0305
4	.2401	.1524	.1715	.0305		.1372	.0305
5	.2915	.1829	.2058	.0305		.1677	.0305
6	.2439	.2134	.2743	.0305		.1829	.0305
7	.4287	.2439	.2058	.1372			.1829
8	.0305	.0305	.0343	.0152		.0305	.0152
9	.1715	.2134		.2439			.0305
10				.1981		.0305	
11		.1715				.0343	.0305
12	.1372	.1524				.0343	.0305
13	.1372	.2058		.1524	.1372	.0343	
14	.1372	.1829		.1677	.0305	.0343	.0305
15		.1715		.1524	.1372		.0305
16	.1372	.1372				.0343	
17	.0152	.0343		.0343	.0152		.0343
18	.0305	.0343	.0152	.0343		.0152	.0343
19	.0305	.0343	.0152		.0305		.0343
20	.0305	.0343	.0152		.0305	.0152	.0343
21	.2439	.0343	.0152		.0305	.0152	
22	.1524	.061				.0305	
23	.1677	.1219	.0305		.1524		.0343
24	.1715	.1524	.1372	.0305			.0305
Max	.4287	.2439	.2743	.2439	.1524	.1829	.1829
Min	.0152	.0305	.0152	.0152	.0152	.0152	.0152
Avg	.1587	.1301	.1119	.0843	.0705	.0702	.0387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 207 / 11 KV FULEWADI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0305	.0152		
2			.0305	.0152		
3			.0305	.0152		
4			.0305	.0152		
5			.0305	.0152		
6			.061	.0152		
9	.0762	.061			.0152	
10					.0152	
11		.0762			.0152	
12	.0457	.0762				.0152
13	.0305	.0762			.0152	
14	.0305	.0762				.0152
15		.0762				.0152
16	.0457	.0762			.0152	
22		.0305				
23		.0305	.0152			
24			.0305	.0152		
Max	.0762	.0762	.061	.0152	.0152	.0152
Min	.0305	.0305	.0152	.0152	.0152	.0152
Avg	.0457	.0644	.0324	.0152	.0152	.0152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 208 / 11KV Padali Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4572	.4115		.3201	.3353
2	.6097	.4572	.4572	.3658		.3353	.3353
3	.6097	.4877	.4572	.3658		.3353	.3353
4	.6097	.5487	.5792	.3658		.3506	.381
5	.7621	.5792	.5792	.4115		.3658	.4115
6	.7621	.6706	.6097	.6859		.1524	.6554
7	.8573	.7011	.6097	.7926		.5487	.7468
8	.6859	.6401	.6097	.7316		.6706	.7011
9	.6859	.6706		.7316		.6706	.6706
10				.7468		.6401	
11		.6859		.6401		.6554	
12	.6097	.6097				.5944	.6401
13	.5944	.6097		.5792	.5792	.6097	
14	.5335	.5335		.6097	.5335		.5182
15		.5335		.5487	.5487		.5792
16	.6097	.5792				.5639	
17	.503	.6097		.5792	.6706		.6401
18	.6706	.6859	.823		.7164	.1677	.7316
19	.7316	.7621	.884		.7621		.7926
20	.8535	.9145	.9145		.7926	.442	.2134
21	.7621	.7926	.8535		.7316	.6249	
22	.6516	.6859				.6249	.5944
23	.4877	.6097	.5182		.3658		.442
24	.4572	.4725	.4572	.4115		.3353	.381
Max	.8573	.9145	.9145	.7926	.7926	.6706	.7926
Min	.4572	.4572	.4572	.3658	.3658	.1524	.2134
Avg	.6431	.6216	.6293	.5611	.6334	.4741	.5318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 201 / 11 KV SANGRUL VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2263	.2241				.0566
2	.2641	.2263	.2218				.0566
3	.2452	.2075	.2054				.0469
4	.2641	.2263	.2054				.0452
5	.3395	.3018	.3174				.0602
6	.5041	.547	.4904				.0678
7	.5228	.6161	.5788				.0747
8	.4854	.5914	.5729				.0747
9	.4481		.5041				.056
10			.4481				
11		.5175					.4251
12	.3142	.5068			.3982		.3696
13	.4024	.3511					.4119
14	.3403	.3982			.3658		.3881
15		.4656					.3801
16	.1772	.4525		.4066		.3721	.4706
17	.2328	.5611		.4525	.4572	.4207	.4024
18	.2715	.5973		.6401	.6099		.4938
19	.8596	.6838		.7095	.6348		.6348
20	.8962	.8589		.7655	.679	.7282	.6535
21	.7842	.7842		.6722	.547	.6413	.6224
22	.547	.5228		.4294	.3772		.4715
23	.3018	.3174		.2829	.2829		.2641
24	.2829	.2263	.2427		.2263		.0934
Max	.8962	.8589	.5788	.7655	.679	.7282	.6535
Min	.1772	.2075	.2054	.2829	.2263	.3721	.0452
Avg	.4165	.4630	.3646	.5448	.4578	.5406	.2878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 202 / 11 KV KHATANGLE AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0069				.0191
2	.0191	.0067				
3	.0191	.0067				.0191
4	.0191	.0067				.0191
5	.0191	.0078				
6	.0191	.0082				.0191
7	.0251	.0389				.0191
9			.0714	.0189		
10			.0572	.0189		
11				.0189		
12				.0189		
14				.0189		
16					.0191	
22	.0191				.0191	.0191
23	.0078				.0191	.0191
24	.0141	.0067				.0191
Max	.0381	.0389	.0714	.0189	.0191	.0191
Min	.0078	.0067	.0572	.0189	.0191	.0191
Avg	.0200	.0111	.0643	.0189	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 203 / 11 KV UPWADE AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0191		.0189		
2			.0191		.0189		
3			.0191		.0189		
4			.0191		.0189		
5			.0191		.0189		
6			.0332		.0189		
7			.0503		.0189		
8							.0191
9	.0671	.0347				.1524	.0191
10		.0434					.0191
11		1.1004					.0191
12		.0514					.0191
13		.0663					
14	.1296	.0514					.0191
15		.0347					.0191
16	.0819	.0343					
21				.0189			
22		.0191		.0189	.0149		
23		.0191		.0189			
24		.0191	.0191		.0189		
Max	.1296	1.1004	.0503	.0189	.0189	.1524	.0191
Min	.0671	.0191	.0191	.0189	.0149	.1524	.0191
Avg	.0929	.1340	.0248	.0189	.0185	.1524	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 202 / 11 KV SHENAGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1143	.0191	.0191	.0191	.0183	.0191
2	.0762		.0191	.0191	.0191	.0183	.0191
3	.0762		.0191	.0191	.0191	.0183	.0191
4	.0762		.0191	.0191	.0191	.0183	.0191
5	.0953		.0191	.0191	.0191	.0183	.0191
6	.0953		.0191	.0191	.0191	.0183	.0191
7	.0953		.0191	.0191	.0191	.0183	.0191
8	.0191		.0191	.0191	.0191	.0183	.0191
9	.0191		.1524	.0953	.0953		
10		.0762	.1715	.1143	.0953		
11		.0953		.1334	.0953		.0191
12	.0191	.0953		.1524			.0191
13	.0191	.0953			.0183		.0191
14	.0191	.0953		.0572	.0183		.0191
15		.0191		.1524	.0183		.0191
16	.0191	.0191	.1524	.1143	.0183	.0191	
17	.0191	.0191	.0191	.0191	.0183	.0191	.0191
18	.0191	.0191	.0191	.0191	.0183	.0191	.0191
19	.0191	.0191	.0191	.0191	.0183	.0191	.0191
20	.0191	.0191		.0191		.0191	.0191
21	.0191	.0191		.0191		.0191	.0191
22	.0762	.0191		.0191			.0191
23	.0762	.0191	.0191	.0191	.0183		.0191
24	.0953	.1143	.0191	.0191	.0191	.0183	.0191
Max	.0953	.1143	.1715	.1524	.0953	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0183	.0183	.0191
Avg	.0499	.0536	.0453	.0489	.0302	.0186	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPALGAON VG.

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4382	.4382	.4382	.4382	.4763	.4382
2	.4191	.4382	.4382	.4191	.4382	.4763	.4191
3	.4191	.4382	.4382	.4191	.4382	.4191	.4191
4	.4191	.4382	.4382	.4191	.4382	.4382	.4191
5	.4572	.4572	.4382	.4382	.4382	.4954	.5335
6	.5906	.5335	.5525	.4954	.5716	.5335	.5906
7	.6478	.5906	.6097	.6097	.7049	.6097	.6287
8	.5906	.6097	.6859	.6478	.8002	.6478	.6859
9	.6097	.6287	.7049	.6859	.6859		.6859
10		.7049	.6478	.6478	.6478		
11		.6478		.6097	.6668		.5906
12	.6859	.5716			.6036		.5716
13	.6478	.5906	.5906		.6097		.6097
14	.5906	.5716	.5906	.5906			.6287
15		.4763	.5144	.5525	.5525		.5525
16	.5144	.5525	.4572	.4954	.5335	.6097	
17	.5335	.6287	.4954	.6097	.6097	.5906	.6478
18	.6859	.6478	.5525	.743	.6859	.7049	.6287
19	.9145	.8764	.8002	.724	.8764	.8383	.9145
20	1.0098	1.0288	.9145	.9907		.9145	.9907
21	.9145	.9526	.8383	.9335		.8383	.9145
22	.743	.8002	.724	.7811			.7621
23	.5144	.5525	.5335	.5525	.4763	.4954	.5525
24	.4572	.4382	.4382	.4763	.4763	.4763	.4382
Max	1.0098	1.0288	.9145	.9907	.8764	.9145	.9907
Min	.4191	.4382	.4382	.4191	.4382	.4191	.4191
Avg	.6088	.6089	.5837	.6036	.5846	.5978	.6192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 204 / 11 KV MADILAGE VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.1905	.2286	.2096	.2096	.1715	.1715
2	.2477	.1905	.2286	.2096	.2096	.1715	.1715
3	.2477	.1905	.2286	.2096	.2096	.1524	.1715
4	.2477	.2096	.2286	.2096	.2286	.1905	.1715
5	.2667	.2667	.2667	.2286	.2667	.3048	.2286
6	.362	.3429	.362	.3048	.3429	.362	.3429
7	.4191	.381	.3429	.4001	.4001	.4001	.381
8	.381	.362	.3429	.381	.4001	.4001	.3429
9	.3429	.362	.3429	.381	.381	.381	.362
10		.3239	.3239	.362	.362	.3239	
11		.3239		.3239	.2858	.3048	.3048
12	.3239	.2858			.3109	.2858	.2858
13	.3048	.2477	.2286		.2667	.2858	.2667
14	.2858	.2286	.2286	.2858	.2667	.2477	.2667
15		.2286	.2286	.2667	.2477	.2667	.2477
16	.3048	.3239	.2286	.3048	.2477	.2477	
17	.3239	.3048	.2667	.3429		.381	.2667
18	.4001	.381	.362	.4572		.4191	.4191
19	.4954	.4382	.4572	.5335		.5144	.5335
20	.5716	.5525	.4954	.5335		.5335	.5335
21	.5335	.4763	.4954	.4954		.4763	.4954
22	.381	.4001	.4001	.4572		.362	.4001
23	.2286	.2667	.2667	.2667	.2477	.2286	.2667
24	.2477	.1905	.2286	.2286	.2286	.1905	.1905
Max	.5716	.5525	.4954	.5335	.4001	.5335	.5335
Min	.2286	.1905	.2286	.2096	.2096	.1524	.1715
Avg	.3411	.3112	.3083	.3360	.284	.3167	.3100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044] BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 205 / 11 KV GARGOTI PWW EXPRESS Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0572	.0572
4	.0572	.0572	.0572	.0572	.0572	.0572	.0572
5	.0572	.0572	.0572	.0572	.0572	.0572	.0572
6	.0572	.0572	.0572	.0572	.0572	.0572	.0572
7	.0572	.0572	.0572	.0572	.0572	.0572	.0191
8	.0572	.0572	.0572	.0572	.0572	.0572	.0191
9	.0572	.0191	.0572	.0572	.0572		.0572
10		.0572	.0572	.0572	.0572		
11		.0572		.0572	.0572		.0572
12	.0572	.0572			.0543		.0191
13	.0572	.0572	.0572		.0572		.0572
14	.0572	.0572	.0572	.0572	.0572		.0572
15		.0572	.0572	.0572	.0572		.0572
16	.0572	.0572	.0572	.0572		.0572	
17	.0572	.0572	.0572	.0572	.0572	.0572	.0572
18	.0572	.0191	.0191	.0191			.0572
19	.0572	.0572	.0572	.0572	.0572	.0572	.0572
20	.0572	.0572		.0572		.0572	.0572
21	.0572	.0572	.0572	.0572		.0572	.0572
22	.0572	.0572	.5335	.0572			.0572
23	.0572	.0572	.0572	.0572	.0572		.0572
24	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Max	.0572	.0572	.5335	.0572	.0572	.0572	.0572
Min	.0572	.0191	.0191	.0191	.0543	.0572	.0191
Avg	.0572	.0540	.0781	.0555	.0570	.0572	.0520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 206 / 11 KV PIMPALGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0191	.0381	.0381	.0191		.0191
2	.0381	.0191	.0381	.0381	.0191		.0191
3	.0381	.0191	.0381	.0381	.0191		.0191
4	.0381	.0191	.0381	.0381	.0191		.0191
5	.0381	.0191	.0381	.0381	.0381		.0191
6	.0381	.0381	.0381	.0381	.0381		.0191
7	.0381	.0572	.0381	.0381	.0381		.0191
8	.0191	.0381	.0381	.0381	.0381		.0191
9	.0191	.0381	.0953	.0762	.0381		
10		.0191		.0381	.0381	.0572	
11		.0191		.0381	.0381		.0191
12	.0191	.0191			.0366	.0191	.0191
13	.0381	.0191	.0953		.0366	.0191	.0191
14	.0381	.0191	.0953	.0572	.0366	.0191	.0191
15		.0191	.0953	.0572	.0183	.0191	.0191
16	.0191	.0191		.0572	.0183	.0191	
17	.0191	.0191	.0191	.0381		.0191	.0191
18	.0191	.0381	.0191	.0381		.0191	.0191
19	.0191	.0381	.0381	.0381		.0191	.0191
20	.0191	.0381	.0381	.0381		.0191	.0191
21	.0191	.0381	.0381	.0381		.0191	.0381
22	.0381	.0381	.0381	.0381		.0191	.0381
23	.0191	.0381	.0381	.0191		.0191	.0381
24		.0191	.0381	.0381	.0191		.0191
Max	.0381	.0572	.0953	.0762	.0381	.0572	.0381
Min	.0191	.0191	.0191	.0191	.0183	.0191	.0191
Avg	.0286	.0278	.0476	.0416	.0299	.0220	.0218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 207 / 11 KV GANGAPUR AG.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0366	.0381
2	.0572	.0572	.0572	.0572	.0572	.0366	.0381
3	.0572	.0572	.0572	.0572	.0572	.0366	
4	.0572	.0572	.0572	.0572	.0572	.0366	
5	.0572	.0572	.0762	.0572	.0572	.0366	
6	.0572	.0572	.0953	.0572	.0572	.0366	
7	.0572	.0572	.1143	.0762	.0572	.0366	
8	.0572	.0572	.0572	.0572	.0572	.0366	.0191
9	.1524	.2858	.0572	.0572	.0572	.0381	.0191
10		.3048	.0572	.0572	.0572	.0381	
11		.3429		.0572	.0572	.0381	.0191
12	.2477	.381			.0543	.0381	
13	.2858	.3048	.0572		.0549	.0381	.0191
14	.2667	.3239	.0572	.0572	.0549	.0381	.0191
15		.3429	.0191	.0572	.0549	.0381	.0191
16	.2286	.1524	.0191	.0572	.0366	.0381	
17	.0572	.0572	.0191	.0572		.0381	.0191
18	.0572	.0572	.0572	.0572		.0381	.0191
19	.0572	.0572	.0572	.0572		.0381	.0191
20	.0572	.0572	.0572	.0572		.0381	.0381
21	.0572	.0572	.0572	.0572		.0381	.0381
22	.0572	.0762	.0572	.0572		.0381	.0381
23	.0572	.0572	.0572	.0381	.0366	.0381	.0381
24	.0572	.0572	.0572	.0572	.0572	.0366	.0381
Max	.2858	.381	.1143	.0762	.0572	.0381	.0381
Min	.0572	.0572	.0191	.0381	.0366	.0366	.0191
Avg	.0998	.1405	.0572	.0572	.0544	.0375	.0274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 208 / 11 KV DARWAD AG.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0381	.0191	.0191	.0191	.0191
7	.0191	.0191	.0381	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0381	.0191	.0191	.0191	.0191		.0191
10		.0191		.0191	.0191		.0191
11		.0191		.0191	.0191		.0191
12	.0572	.0191			.0183		.0191
13	.0381	.0191	.0191		.0362	.0191	.0191
14	.0381	.0381	.0191	.0191	.0366	.0191	.0191
15		.0381	.0191	.0191	.0183	.0191	.0191
16	.0191	.0381	.0191	.0191	.0183	.0191	
17	.0191	.0191	.0191	.0191		.0191	.0191
18	.0191	.0191	.0191	.0191		.0191	.0191
19	.0191	.0191	.0191	.0191		.0191	.0191
20	.0191	.0191	.0191	.0191		.0191	.0191
21	.0191	.0191	.0191	.0191		.0191	.0191
22	.0191	.0381	.0191	.0191		.0191	.0762
23	.0191	.0381	.0191	.0191	.0183	.0191	.0191
24		.0191	.0191	.0191	.0191		.0191
Max	.0572	.0381	.0381	.0191	.0366	.0191	.0762
Min	.0191	.0191	.0191	.0191	.0183	.0191	.0191
Avg	.0239	.0231	.0209	.0191	.0208	.0191	.0216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 209 / 11KV MADUR VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1905	.2286	.1715	.1905	.1715	.1524
2	.1524	.1905	.2286	.1715	.1905	.1715	.1524
3	.1524	.1905	.2286	.1715	.1905	.1715	.1524
4	.1715	.1905	.2286	.1715	.2096	.1905	.1524
5	.2286	.2096	.2286	.2096	.2286	.2286	.1905
6	.3429	.2858	.3429	.2667	.3429		.2286
7	.381	.362	.4001	.3429	.4001		.2667
8	.3429	.3239	.4001	.3429	.4382		.2286
9	.3429	.3239	.362	.362	.5525		.3048
10		.381	.3048	.3048	.362		
11		.3048		.3239	.2477		
12	.2858	.2858			.2477		.2858
13	.2667	.3239			.2286		.3048
14	.2858	.3048		.3239	.2286		.1905
15		.2477		.2477	.2286		.2477
16	.3048	.2858	.3239	.2858	.2286	.2477	
17	.381	.3239	.2667	.2667	.2286	.3048	.3048
18	.4001	.4001	.381	.381	.3048	.3429	.4191
19	.4954	.4954	.4191	.5144	.381	.4954	.4572
20	.6097	.5906		.5335	.4572	.5335	.5906
21	.5144	.5335			.4191	.4191	.5335
22	.3048	.4001			.3048		.381
23	.1905	.2286	.2286		.2286		.2477
24	.1524	.1905	.2286	.1715	.2096	.1905	.1524
Max	.6097	.5906	.4191	.5335	.5525	.5335	.5906
Min	.1524	.1905	.2286	.1715	.1905	.1715	.1524
Avg	.3075	.3152	.3001	.2928	.2937	.2890	.2830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 201 / 11 KV MANGNOOR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0019		.1829	.0747	.056	.0373	
2	.0019		.1478	.056	.056		
3	.0019		.128	.056	.056		
4	.0019		.1294		.056		
5	.0019		.128		.056		
6	.0019		.2195		.0934		
7	.0019		.2195		.1307		
8	.0019		.0073				
9	.3174	.4108	.0073				
10		.4668	.0073				
11		.1829					
12	.4668						
13	.3921					.0074	
14	.3547	.1097				.0074	
15	.3547	.2195				.0073	
16	.3547	.3475				.0074	
17		.0073				.0073	
18		.0074	.0019			.0074	.0373
19		.0073	.0019				.0373
20		.0074					.0019
21		.0074					.0019
22		.1646		.0747			.0019
23		.2012	.168	.056	.0373		.0019
24	.0019		.1991	.1307	.056	.0373	
Max	.4668	.4668	.2195	.1307	.1307	.0373	.0373
Min	.0019	.0073	.0019	.056	.0373	.0073	.0019
Avg	.1505	.1646	.1106	.0747	.0664	.0149	.0137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 202 / 11 KV ARALGUNDI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0373	.0074	.0019			.0377
2	.056	.0373	.0074	.0019			.0377
3	.0373	.0373	.0073	.0019			.0377
4	.0373	.0373	.0074	.0019			.0377
5	.0566	.0373	.0074	.0019			.0377
6	.0747	.056	.0073	.0019			.0377
7	.0747	.112	.0073	.0019			.0732
8	.0019		.0073	.0019			.0074
9	.0019		.1646	.1494	.056	.0373	.0074
10			.181	.112		.056	.0074
11		.0073		.1494	.0373		.0073
12		.0073			.0373		.0073
13		.0073	.2614		.0373	.0366	
14		.0074	.2241	.0934	.0373	.0185	.0073
15		.0073	.2427	.0747	.0373	.0366	.0073
16		.0074		.0747	.056	.0366	
17		.0073			.056	.0073	.0019
18		.0074	.0019			.0073	.0019
19		.0073	.0019				.0019
20		.0074					.0019
21		.0074					.0019
22	.056	.0073				.0747	
23	.056	.0073	.0019			.0754	.056
24	.0747	.056	.0073	.0019			.0754
Max	.0747	.112	.2614	.1494	.056	.0754	.0754
Min	.0019	.0073	.0019	.0019	.0373	.0073	.0019
Avg	.0486	.0241	.0674	.0447	.0443	.0386	.0234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 203 / 11 KV ARALGUNDI VG.

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0377	.0377	.0377	.0189
2	.0377	.0377	.0373	.0377	.0377	.0377	.0189
3	.0377	.0377	.0373	.0377	.0377	.0377	.0187
4	.0377	.0377	.0377	.0377	.0377	.0377	.0189
5	.0566	.0377	.0373	.0566	.0377	.0377	.0189
6	.0754	.0754	.0747	.0943	.0754	.0754	.0377
7	.0943	.0754	.1109	.1132	.1132	.1132	.1132
8	.112	.0943	.1109	.1132	.1132	.1132	.1109
9	.0943	.0754	.112	.0943	.1132	.1132	.1109
10		.0754	.0924	.1132	.1132	.1132	.0934
11		.0934		.0943	.1132		.0739
12	.0754	.0747			.0943		.0924
13	.0754	.0373	.0566	.0754	.0754	.0754	.0943
14	.0377	.0739	.0943	.0754	.0943	.0366	.0373
15	.0377	.037	.0754	.0754	.0754	.037	.0943
16	.0377	.0373		.0754	.0754	.0373	
17	.0754	.0373	.0754		.0943	.037	.0019
18		.0747	.1132	.1132	.132	.1109	.1132
19	.1509	.1307	.1698	.1509	.1886	.1463	.1698
20	.1886	.2241		.1886	.1886	.1463	.2075
21	.1509	.168		.1509	.1698	.128	.1698
22	.1132	.1494		.1132			
23	.0754	.0373	.0943	.0943	.0943		.0747
24	.0566	.0377	.0373	.0566	.0377	.0566	.0377
Max	.1886	.2241	.1698	.1886	.1886	.1463	.2075
Min	.0377	.037	.0373	.0377	.0377	.0366	.0019
Avg	.0790	.0749	.0780	.0909	.0935	.0764	.0785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 205 / 11 KV BARVE VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0739	.0566	.0566	.0566	.0754
2	.0566	.0566	.0747	.0566	.0566	.0566	.0754
3	.0566	.0566	.0739	.0566	.0566	.0566	.0754
4	.0566	.0566	.0747	.0566	.0566	.0566	.0754
5	.0943	.0754	.0739	.0754	.0754	.0566	.0943
6	.132	.1132	.1109	.112	.132	.132	.132
7	.1698	.1698	.1109	.1698	.1698	.1509	.1698
8	.1886	.1886	.2218	.1886	.2075	.2075	.1663
9	.168	.2075	.2218	.1886		.1886	.1867
10		.1886	.2033	.1698		.1698	.1663
11		.1848		.1698	.132		.1478
12	.0754	.1478			.132		.1478
13	.0754	.1478	.1132		.1132	.0943	.0943
14	.0754	.1294	.132	.1132	.1132	.0924	.0739
15	.0754	.168	.1132	.0943	.1132	.0934	.1307
16	.1132	.1109		.1132	.1132	.1109	
17	.132	.1478	.1132		.132	.1109	.1132
18		.168	.1698	.1886	.1886	.1478	.1132
19	.2263	.1848	.2452	.2263	.2641	.2926	.2452
20	.3018	.3292		.3206	.2614	.2561	.3174
21	.2452	.2772	.2641	.2641	.2075	.2402	.2452
22	.1509	.1867	.1886	.1886			
23	.0943	.0924	.1132	.0943	.0754		.1132
24	.0754	.0566	.0739	.0754	.0566	.0566	.0754
Max	.3018	.3292	.2641	.3206	.2641	.2926	.3174
Min	.0566	.0566	.0739	.0566	.0566	.0566	.0739
Avg	.1248	.1459	.1383	.1419	.1292	.1314	.1379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 202 / 11 KV MHASARANG AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	16-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362		.0747	
2	.0373		.0724	
3	.0362			
4	.0362			
5	.0364			
6	.0366			
7	.0366			
8	.0373			
9	.5544			
10	.5601			
11	.5914			
12	.6161			
13	.6468	.0183		
14	.5359	.0183		
15	.4854	.0187		
16	.4108	.0189		.0747
17	.0373	.0187		.0747
18	.037	.0181		.0747
19	.0362			.0747
20	.037	.0189		.0747
21	.0373	.0189		.0747
22	.3734	.0914		.056
23	.3547	.0739		.0187
24			.0747	
Max	.6468	.0914	.0747	.0747
Min	.0362	.0181	.0724	.0187
Avg	.2438	.0314	.0739	.0654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 204 / 11 KV DONAWADE AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.0747	.0373	.0181	
2	.1307	.0747	.0373	.0187	
3	.1307	.0724	.0373		
4	.1307	.0747	.0373		
5	.1494	.0732	.0372		
6	.1494	.0744	.0372		
7	.1494	.0744	.0373		
8	.0373	.0181	.0373		
9	.056	.0187	.1867		
10		.0185	.2033		
11		.0185	.2241		
12	.056	.037	.1867		
13	.056	.0747	.2054		
14	.056	.0554	.2054		
15	.056	.0744	.2241		
16	.056	.037	.2054		
17	.056		.0373		
18	.056		.0362		
19	.0747		.0343		.0187
20	.0747		.0373		.0373
21	.0747		.0373		.0373
22	.0747		.0373		.0373
23	.0747		.0373	.0181	.0188
24	.1494		.0373	.0187	.0187
Max	.1494	.0747	.2241	.0187	.0373
Min	.0373	.0181	.0343	.0181	.0187
Avg	.0900	.0544	.0931	.0184	.0280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 205 / 11 KV SHELOLI VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	16-JUL-17	17-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1867	.2614	.1448
2	.1494	.168	.2254	.1494
3	.1448	.168		.1307
4	.1448	.1867		.1307
5	.1494	.2054		.1494
6	.168	.2054		.1867
7	.1691	.2614		.2241
8		.3174	.2614	
9		.3361	.2801	.2254
10		.3174	.2801	.2241
11		.2614	.3077	.2218
12		.2241	.3174	.1879
13		.2241	.1867	.1494
14		.2241	.1867	.1478
15		.2241	.1879	.1867
16	.2402	.1494	.1829	.2241
17		.2241	.168	.2987
18		.3361	.2254	.2987
19		.3734	.3734	.3361
20		.4108		.4108
21		.4481		.3734
22		.2987		.4879
23		.2241	.1488	.2218
24		.2241	.2625	.1494
Max	.2402	.4481	.3734	.4879
Min	.1448	.1494	.1488	.1307
Avg	.1642	.2583	.2410	.2287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 206 / 11 KV KARADWADI VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0934		.0739	
2	.0747	.0934		.0747	
3	.0747	.0934			
4	.0747	.0924			
5	.0934	.0905			
6	.112	.1294			
7	.1494	.1494			
8	.1494	.1267			
9	.112	.112			
10		.0934	.1494	.0905	
11		.0744	.1307	.0934	
12	.0934	.0934	.1307	.112	
13	.0934	.112	.112		
14	.0934	.0934	.112		
15	.0934	.0924	.112		
16	.112	.1109	.1302	.0747	.0751
17	.1307		.1503	.0747	.0938
18	.1494		.1877	.0747	.1501
19	.2614		.2627	.1867	.1879
20	.2614		.2987		.2252
21	.2241		.2241		.2241
22	.112		.1307		.1867
23	.112		.112	.1494	.1127
24	.0934			.0724	.0747
Max	.2614	.1494	.2987	.1867	.2252
Min	.0747	.0744	.112	.0724	.0747
Avg	.1248	.1032	.1602	.0979	.1478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 207 / 11 KV NANDOLI VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0905	.112		.0188
2	.0934	.0905	.0934		.0187
3		.0905	.0934		.0188
4		.0934	.112		.0188
5		.0905	.1307		.0188
6		.1307	.1494		.0375
7		.168	.1867		.0543
8		.168	.1867		
9		.1478	.1867		.056
10		.1494	.168		.056
11		.1478	.1494	.181	
12		.1448		.181	.0373
13		.1494			.056
14		.1478			.0747
15		.1294			.1086
16		.1478		.1629	.1494
17				.1663	.168
18				.181	.1867
19				.2353	.2241
20					.2614
21					.2427
22					.2241
23				.0185	.1867
24	.112		.1494	.2172	.0187
Max	.112	.168	.1867	.2353	.2614
Min	.0934	.0905	.0934	.0185	.0187
Avg	.1058	.1304	.1432	.1679	.1016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 201 / 11 KV MINCHE GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1646	.1524	.1521			.1524
2		.1463	.1334	.1517	.1307		.1334
3		.1463	.1143	.1518	.133		.1143
4		.2926	.1334	.1517	.1711		.1524
5		.3475	.2477	.2087	.2277		.2096
6		.3841	.3239	.3033	.2849		.2858
7		.3841	.381	.3993	.3658		.3429
8		.3801	.381	.3981	.4364		.381
9		.3801	.381	.3795	.3602		.4001
10		.3429	.362	.3605	.3605		.362
11		.362			.3232	.2667	.3048
12		.3429			.2846	.2667	.2667
13		.2858	.2472		.2464		.2096
14		.2477	.2275		.2085	.2286	.2477
15		.2667	.2852		.2657	.2667	.2477
16		.2858	.2846		.3226	.3429	.3239
17		.3429	.2852			.381	.3239
18		.381	.4175			.4382	.381
19	.5487	.5716	.5497			.5525	.381
20	.6154	.6287	.5687			.5906	
21	.5304	.5335	.4929				
22	.3658						
23	.2561	.2286	.2092				.2096
24		.1646	.1905	.1711	.168		.1905
Max	.6154	.6287	.5687	.3993	.4364	.5906	.4001
Min	.2561	.1463	.1143	.1517	.1307	.2286	.1143
Avg	.4633	.3309	.3033	.2571	.2681	.3704	.2676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 202 / 11 KV HEDEWADE AG.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.057	.038
2		.0905		.057	.038
3		.0905		.057	.038
4		.0905		.057	
5		.0905		.0951	
6		.0905		.171	
7		.0905		.2472	
8		.1086		.0761	
9		.3258		.0758	
10				.0761	
12			.0951		
13			.0951		
14			.1141		
15			.0949		
16			.0761		
17			.038		
19	.0905		.0761		
20	.0905		.076		
21	.0905		.0761		
22	.0905				
23	.0905		.057		
24		.0905		.057	.0373
Max	.0905	.3258	.1141	.2472	.038
Min	.0905	.0905	.038	.057	.0373
Avg	.0905	.1187	.0799	.0933	.0378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 203 / 11 KV NILPAN AG.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0543	.0381	.0373		.0191
2		.0543	.0381	.038		.0191
3		.0543	.0381	.038		.0191
4		.0362	.0381	.038		.0191
5		.0543	.0381	.038		.0191
6		.0362	.0381	.038		.0191
7		.0362	.0381	.0038		.0191
8		.0362	.0381			
9		.0362	.0953	.0569		.0191
10		.0381	.0953	.057		
11		.0381			.0191	.0191
12		.0381	.0948		.0191	.0191
13	.0362	.0381	.1518		.0191	.0191
14	.0362	.0381			.0191	.0191
15	.0362	.0381			.0191	.0191
16	.0362	.0381			.0191	.0191
17	.0543	.0381			.0191	.0191
18	.0543				.0191	.0191
19	.0543		.038		.0191	.0191
20	.0543		.038		.0191	.0191
21	.0543		.038			.0191
22	.0543					.0191
23	.0543	.0381	.038			.0191
24		.0543	.0381	.038		.0191
Max	.0543	.0543	.1518	.057	.0191	.0191
Min	.0362	.0362	.038	.0038	.0191	.0191
Avg	.0477	.0419	.0548	.0383	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 402 / 33 KV Shriram LIS

HV LIS Feeder

Feeder KV- 33 / OUTGOING

DATE	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.057	
2			.057	
3			.057	
4			.057	
5			.057	
6			.057	
7			.0569	
8			.057	
10	.0572		.057	
11	.0572			.0572
12	.0572			
13	.0572			
14	.0572			
23		.057		
24			.057	
Max	.0572	.057	.057	.0572
Min	.0572	.057	.0569	.0572
Avg	.0572	.057	.0570	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 201 / 11 KV DASEWADI AG.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0566	.0762		.0339		
2	.0181	.0566	.0762		.0343		
3	.0181	.0566			.0343		
4	.0179	.0554	.0762		.0343		
5	.0179	.0554	.0762		.0328		
6	.0179	.0566	.0762		.0648		
7	.0179	.0566	.0762		.0983		
8	.0181	.0566	.0191		.0183		
9	.2743	.2772	.0191	.0191	.0181		
10		.2987	.0191	.0191			.0566
11		.2667		.0175			.0566
12	.3174	.2858	.0381		.0189		.0566
13	.2957	.3048	.0191		.0181		.0554
14	.1867	.2477	.0191	.0175			.0554
15		.2667		.0173			.0566
16	.2829	.2667					.0566
17	.2241	.0381					.0189
18	.0747	.0381		.0183		.0381	.0187
19	.0739	.0381		.0185			
20	.0747	.0381		.0187			.0373
21	.0754	.0381					.0566
22	.0566						.0189
23	.0566	.0762					.0189
24	.0183	.0566	.0762		.0343		
Max	.3174	.3048	.0762	.0191	.0983	.0381	.0566
Min	.0179	.0381	.0191	.0173	.0181	.0381	.0187
Avg	.1026	.1298	.0513	.0183	.0367	.0381	.0432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 202 / 11 KV PATGAON VG.

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0943	.1143			
2	.0905	.0924	.1143			
3	.0905	.0943	.1143			
4	.1075	.0934	.1334			
5	.1433	.112	.1524			
6	.197	.1509	.1524			
7	.197	.2075	.2096			
8	.1991	.2452	.2667			
9	.2058	.2641	.2667	.2286		.2614
10		.2075	.2858	.2286		.2587
11		.1905		.1578		.2054
12	.1848	.1715	.1905			.1494
13	.2075	.1524	.1524			.1509
14		.1334	.1143	.1227		
15		.1524		.1214		
16	.1867	.1715				.0934
17	.2263	.1524				.132
18	.2241	.2286		.2195	.1524	.132
19	.2987	.3048		.2957		
20	.3361	.362		.3361		
21	.3018	.3429				
22	.2054	.2667				
23	.1132					.1132
24	.128	.1132	.1524			
Max	.3361	.362	.2858	.3361	.1524	.2614
Min	.0905	.0924	.1143	.1214	.1524	.0934
Avg	.1867	.1871	.1728	.2138	.1524	.1663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALÉ SUBSTATION

Feeder No / Name : 203 / 11 KV SHIVDAV AG.

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0189	.0191			
2	.0362	.0185	.0191			
3	.0362	.0189	.0191			
4	.0358	.0189	.0191			
5	.0358	.0185	.0191			
6	.0358	.0377	.0191			
7	.0358	.056	.0191			
8	.0181	.0189	.0191			
9	.0171	.0187	.0191	.0381		.0187
10		.0185	.0191	.0381		.0185
11		.0191		.0175		.0189
12	.0187	.0191	.0191			.0187
13	.0187	.0191	.0191			.0185
14		.0191	.0191	.0351		.0189
15		.0191		.0347		.0189
16	.0373	.0191				.0187
17	.0373	.0191				.0189
18	.0187	.0191		.0183	.0191	.0189
19	.0189	.0191		.0185		.0187
20		.0191		.0187		.0189
21	.0187	.0191				.0189
22	.0185	.0191				.0187
23	.0185	.0191				.0189
24	.0366	.0189	.0191			
Max	.0373	.056	.0191	.0381	.0191	.0189
Min	.0171	.0185	.0191	.0175	.0191	.0185
Avg	.0278	.0213	.0191	.0274	.0191	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 201 / SILVER ZONE

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0362	.0183	.0362	.0358	.0358	
2	.0366	.0362	.0183	.0362	.0358	.0358	.0187
3		.0362	.0183	.0362	.0358	.0358	
4		.0362	.0183	.0358	.0358	.0358	
5		.0358	.0183	.0358	.0358	.0358	
6		.0358	.0366	.0358	.0358	.0358	
7		.0358	.0183	.0358	.0358	.0537	
8		.0358		.0362	.0179	.0362	.0187
9		.0366	.0183	.0358	.0179	.0358	.0187
10		.0366			.0358		
11		.0366			.0358		.0362
12	.0358	.0549					.0358
13	.0179	1.6712			.0358		
14	.0177	.0366		.0162	.0358	.0187	
15	.0179	.0366		.0179			
16	.0179	.0366		.0179		.0187	
17	.0354	.0183	.0358	.0179	.0358		.0358
18	.0358	.0183	.0358	.0179	.0358		.0358
19	.0358	.0366	.0354	.0179	.0358		.0358
20	.0358	.0366	.0358	.0179	.0362		.0358
21	.0358	.0366	.0366	.0179	.0362		.0358
22	.0362	.0366	.0358	.0179	.0358		.0362
23	.0362	.0366	.0358	.0179	.0358		.0362
24	.0366	.0362	.0366	.0362	.0358	.0358	.0187
Max	.0366	1.6712	.0366	.0362	.0362	.0537	.0362
Min	.0177	.0183	.0183	.0162	.0179	.0187	.0187
Avg	.0312	.1037	.0283	.0269	.0341	.0345	.0306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 202 / HUPARI VILLAGE

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8059	.9877	.8059	.6805	.8145	
2		.788	.9877	.7522	.6447	.7421	.6994
3		.7343	.9145	.7522	.6268	.6878	
4		.6805	.9145	.7343	.6447	.6805	.6994
5		.6733	.8192	.7701	.6805	.7164	
6		.691	.9145	.788	.7164	.788	.865
7		.7973	.9328	.8954	.9134	.9492	.9018
8		.9134	1.0425	.9671	.9492	1.0387	.957
9		.9694	1.0974	.9036	.9313	1.0745	.9938
10		1.1706			1.0387		
11		1.1706			1.2536		1.1999
12	.9214	1.1706					1.182
13	.7796	1.1142			1.2403		
14	.7619	.9831		.8834	1.182	1.1411	
15	.7796	.9831					
16	.691	.8848		.8466		1.1411	
17	.7619	1.0974	1.0099				1.2178
18	.7796	1.134	1.1104	.8466			1.2894
19	1.0387	1.134	1.1999	.8238	1.1999		1.3969
20	1.1999	1.2437	1.2715	.8417	1.1641		1.3466
21	1.182	1.262	1.2178	.8417	1.379		1.1999
22	1.0208	1.0974	1.0498	.8059	1.1584		1.0387
23	.9412	1.0242	.8859	.7522	1.0387		.8596
24		.8417	1.0242	.8417	.7602	.8775	.773
Max	1.1999	1.262	1.2715	.9671	1.379	1.1411	1.3969
Min	.691	.6733	.8192	.7343	.6268	.6805	.6994
Avg	.9048	.9735	1.0224	.8251	.9580	.8876	1.0388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 203 / YALGUD AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4458	.0164	.0171	.0171	.0171	
2		.4458	.0164	.0171	.0171	.0171	.1968
3		.463	.0164	.0171	.0171	.0171	
4		.463	.0164	.0171	.0171	.0171	.2132
5		.4801	.0164	.0171	.0171	.0171	
6		.5316		.0343	.0171	.0343	.2132
7		.7888		.0171	.0171	.0343	.3773
8		.0171	.0164	.0343	.0171		.0164
9		.0164	.8356	.7377	.4458	.3258	.0162
10		.0164			.4024		
11		.0164			.4024		.0171
12	.0171	.0164		.7142	.3856		.0171
13	.0171	.0164			.3688		
14	.0171	.0164		.6818	.3185	.1968	
15	.0171	.0164			.285		
16	.0171	.0164		.6655	.2347	.1968	
17	.0171	.0164	.0171		.0171		.0171
18	.0171	.0164	.0171	.0162	.0171		.0171
19	.0171	.0164	.0171	.0171	.0171		.0343
20	.0343	.0164	.0171	.0171	.0171		.0343
21	.0343	.0164	.0171	.0171	.0171		.0343
22	.4801	.0164	.0171	.0171	.0171		.1886
23	.463	.0164	.0171	.0171	.0171		.1715
24		.463	.0164	.0171	.0171	.0171	.1968
Max	.4801	.7888	.8356	.7377	.4458	.3258	.3773
Min	.0171	.0164	.0164	.0162	.0171	.0171	.0162
Avg	.0957	.1810	.0713	.1626	.1299	.0810	.1101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 204 / RENDAL

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.267	1.6461	1.4175	1.4327	1.2536	
2		1.267	1.6461	1.2536	1.267	1.2536	.8116
3		1.0974	1.6461	1.0974	1.0974	1.0974	
4		1.0974	1.6461	1.0974	1.0974	1.0974	1.1363
5		1.0974	1.6461	1.0631	1.267	1.0974	
6		1.267	1.6461	1.2269	1.267	1.0974	1.2986
7		1.5604	1.6461	1.4022	1.4327	1.4327	1.1363
8			1.6461	1.5775	1.6118	1.2536	1.1363
9		2.3777	2.2291	2.1795	1.9071	1.4022	1.8945
10		6.0296			2.1795		
11		2.1033			2.1795		2.0119
12	2.1795	1.8099			2.1795		2.0119
13	1.2269	1.8099			1.7147		
14	1.4022	1.829		1.9685	1.2536	.6562	
15	2.0348	2.5606			2.0119		
16	2.1795	2.5606			2.1548	.6562	
17	2.2043	2.1033	2.1795		2.1795		1.0745
18	2.1795	2.1948	2.0576	2.1325	1.8652		1.0745
19	2.0348	1.829	1.7528	1.7147	1.8861		1.6118
20	1.7147	1.829	1.7337	1.5775	1.6118		1.6118
21	1.7528	1.6461	1.5947	1.4327	1.6118		1.6118
22	1.5775	1.5947	1.5775	1.4327	1.5947		1.4327
23	1.6118	1.5947	1.6118	1.4327	1.4327		1.267
24		1.4327	1.6461	1.4175	1.4327	1.4327	.9842
Max	2.2043	6.0296	2.2291	2.1795	2.1795	1.4327	2.0119
Min	1.2269	1.0974	1.5775	1.0631	1.0974	.6562	.8116
Avg	1.8415	1.9112	1.7383	1.4955	1.6528	1.1442	1.3816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 207 / HUPARI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0347	.9831	.8402	.3086	.0343	
2		.0351	.9831	.823	.3086	.0171	
3		.0347		.8059	.2743	.0343	
4		.0347	.9831	.8059	.3429	.0343	
5		.0347	.9831	.823	.3601	.0343	
6		.0347	.9831	.823	.3601	.0343	
7		.0343	1.0343	.8916	.3601	.0343	
8		.0343	.0328	.0343	.0171	.0343	.0325
9		1.491	.0328	.0343	.0171	.3772	.3571
10		1.6385			.0343		
11		1.6385			.0343		.3772
12	1.5091	1.6712					.3944
13	1.4918	1.6712			.0343		
14	1.4918	2.13		.0164	.0343	.3571	
15	1.4232	1.6385			.0358		
16	1.4403	1.3927		.0164	.0343	.3733	
17	.0343	.0164	.0347		.0343		.0347
18	.0343	.0164	.0347	.0164	.0343		.0347
19	.0347	.0164	.0347	.0173	.0343		.0358
20	.0343	.0164	.0351	.0173	.0343		.0351
21	.0347	.0328	.0347	.0173	.0343		.0351
22	.0351	.9175	.8916	.3086	.0347		.0347
23	.0347	.9175	.8745	.3258	.0347		.0343
24		.0351	.9175	.8402	.3601	.0343	.0162
Max	1.5091	2.13	1.0343	.8916	.3601	.3772	.3944
Min	.0343	.0164	.0328	.0164	.0171	.0171	.0162
Avg	.6332	.6466	.5546	.4143	.1373	.1166	.1185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 208 / BIRDEV AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.6554	.5426	.2401	.0171	
2		.0171	.6554	.5256	.2401	.0171	.0162
3		.0171	.7209	.4917		.0171	
4		.0171	.7537	.4748		.0171	
5		.0171	.7537	.4917		.0171	
6		.0171	.8192	.4917		.0171	
7		.0171	.8192	.6104		.0171	
8		.0171	.0164	.0343		.0171	.0162
9		.0492	.0164	.0343		.0171	.2297
10		.0819					
11		.6554					.2507
12	.8453	.852					.1886
13	.8951	.8848					
14	.9448	.9831		.0187			
15	.9116	.9831					
16	.0514	.9831		.0187			
17	.0171	.0164	.0171		.0171		.0171
18	.0171	.0164	.0343	.0164	.0171		.0171
19	.0171	.0164	.0343	.0171	.0171		.0343
20	.0171	.0164	.0343	.0171	.0171		.0171
21	.0171	.0164	.0343	.0171	.0171		.0343
22	.0171	.6554	.6274	.2401	.0171		.0171
23	.0173	.6554	.5596	.2743	.0171		.0171
24		.0171	.6554	.5426	.2743	.0171	.0162
Max	.9448	.9831	.8192	.6104	.2743	.0171	.2507
Min	.0171	.0164	.0164	.0164	.0171	.0171	.0162
Avg	.3140	.2925	.4239	.2700	.0874	.0171	.0671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 201 / PATTANKODOLI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.5261	1.2136	.6516		.0514
2	.056		1.4746		.6516		
3			.823	1.1203	.6001		.0514
4			1.4746	1.1203	.6001		.0514
5			1.4918	1.1763	.5658		.0514
6			1.5604	1.2696	.5658		.0514
7			1.7147	1.4003	.7716		.0514
8			.0514		.0514		.0514
9			.0514		.0514		.3601
10				.056			
11	2.6749	2.7435		.0343			.4115
12	2.3834	2.7606					.3772
13	2.4006	2.7435					.3772
14		2.572		.0343			.2058
15		2.4863	.0514				.2572
16	2.4177	2.4863	.0514	.0343			.2572
17	.0343			.0343			
18		.0343		.0343		.0343	
19		.0514	.0747	.0686		.0514	
20		.0686	.0747	.0686		.0514	
21		.0686	.0747	.0686		.0514	
22		1.6975	1.4563	.7373		.0514	
23		1.6289	1.307	.6859		.0514	
24			1.5604	1.2696	.6516		.0514
Max	2.6749	2.7606	1.7147	1.4003	.7716	.0514	.4115
Min	.0343	.0343	.0514	.0343	.0514	.0343	.0514
Avg	1.6612	1.6118	.8717	.5793	.5161	.0486	.1772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 202 / 11 kV INGALI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0343	.0373			.0514
2			.0171	.0373			.0514
3			.0171	.0373			.0514
4			.0171	.0373			.0514
5			.0171	.0373			.0857
6			.0343	.0373	.0343		.0857
7			.0343	.0373	.0343		.1543
8			.0343		.0343		.0343
9			1.2346		.1543		.0343
10				.9709	.1543		
11		.823		.8916	.168		.0343
12	.0343	.823			.168		.0343
13	.0343	1.0288	1.3717		.1494		.0343
14		1.2003	1.3375	.7202	.112		.0343
15		1.3717	1.3375	.5144	.112		.0343
16	.0343	1.3203	1.3375	.5144	.1307	.0343	.0343
17	.0343	.0171		.0171			
18				.0171		.0343	
19		.0343	.0373	.0171		.0171	
20		.0343	.0373			.0343	
21		.0343	.0373			.0343	
22		.0343	.0373			.0857	
23		.0343	.0373			.0857	
24			.0343	.0373			.0686
Max	.0343	1.3717	1.3717	.9709	.168	.0857	.1543
Min	.0343	.0171	.0171	.0171	.0343	.0171	.0343
Avg	.0343	.5630	.3708	.2476	.1138	.0465	.0546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 203 / 11 kV SANGWADE AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.12	.112	.0857		.2743
2			.12	.112	.0857		.2743
3			.1029	.112	.0857		.2743
4			.1029	.112	.0857		.2743
5			.1029	.112	.0857		.3258
6			.12	.112	.0857		.4287
7			.1372	.1494	.0857		.6687
8			.1543		.1029		.0686
9			1.9719				.0514
10				1.5684			
11	.1029	.1372		1.4403	.9335		.0514
12	.0857	.1372			.9335		.0343
13	.0857	.1372	2.4863		.9709		.0343
14		.1029	2.4691	1.0631	.5601		
15		.1029	2.2634	.7888	.6348		.0343
16	.0857	.1029	2.2634	.8059	.6161		.0343
17	.0857	.1029					
18				.0686		.0686	
19		.1372	.112	.0857		.0686	
20		.1543	.1307	.1029		.0686	
21		.1543	.112	.1029		.0686	
22		.1372	.112	.1029		.3429	
23		.12	.112	.0686		.3086	
24			.12	.112	.0857		.3086
Max	.1029	.1543	2.4863	1.5684	.9709	.3429	.6687
Min	.0857	.1029	.1029	.0686	.0857	.0686	.0343
Avg	.0891	.1272	.6902	.3753	.3625	.1543	.2092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 204 / 11 KV INGALI VILLAGE

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.12	.1307			.0857
2			.12	.1307			.0857
3			.12	.1307			.0857
4			.12	.1307			.0857
5			.12	.1494			.1029
6			.1543	.1867			.1372
7			.1372	.1867			.1715
8			.12				.12
9			.0857				.12
10				.0934			
11	.1029	.12		.0857	.0747		.1029
12	.1029	.12			.0747		.1372
13	.1029	.12	.1029		.0747		.1372
14		.12	.1029	.0857	.0747		.1029
15		.12	.0686	.0857	.0747		.0857
16	.1029	.12	.0686	.0857	.056	.0686	.0857
17	.1029	.12		.0857			
18				.0857		.0686	
19		.12	.1494	.1543		.1543	
20		.1372	.1494			.1543	
21		.1372	.168			.1372	
22		.1372	.1494			.12	
23		.1372	.1307			.12	
24			.12	.1307			.1029
Max	.1029	.1372	.168	.1867	.0747	.1543	.1715
Min	.1029	.12	.0686	.0857	.056	.0686	.0857
Avg	.1029	.1257	.1214	.1211	.0716	.1176	.1093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 205 / 11 KV SANGAWADE VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3429	.3734	.2572		.2401
2			.3086		.2229		.2401
3			.3086	.3734	.2229		.2401
4			.3086	.3734	.3944		.2401
5			.3258	.4108	.2915		.2915
6			.3772	.4294	.3944		.4115
7			.3772	.4481	.4458		.4287
8			.3601		.4801		.4458
9	.4115		.3601		.4458		.4287
10				.3361	.3086		
11	.3772	.3086		.3086	.3734		.3429
12	.3772	.3429			.3361		.3429
13	.3772				.3361		.3429
14		.3429		.3429	.3361		.2743
15		.3429		.3429	.3361		.2743
16	.3772	.3429		.3429	.3547		.2743
17		.3772		.3429			.2743
18	.4115	.3772		.4973		.3772	
19		.4115	.5228			.4801	
20		.4973	.5228			.4801	
21		.4801	.5041			.463	
22		.4287	.4481			.4287	
23		.3772	.3734			.3601	
24			.3601	.3734	.2572		.3086
Max	.4115	.4973	.5228	.4973	.4801	.4801	.4458
Min	.3772	.3086	.3086	.3086	.2229	.3601	.2401
Avg	.3886	.3858	.3867	.3783	.3408	.4315	.3177

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 206 / 11 KV PATTANKODOLI VLG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6173	.4668	.3772		.3258
2			.6173	.4481	.3601		.3258
3			.6001	.4481	.3429		.3258
4			.6001	.4481	.3429		.3429
5			.6001	.4481	.4287		.3772
6			.6344	.4668	.5316		.6001
7			.7545	.6161	.4458		.6859
8			.7545				.6687
9			.6687				.5316
10				.6348			
11	.583	.6173		.583		.5144	
12	.6173	.6173				.5487	.6516
13	.6173	.6516			.7468	.5487	.6516
14		.6516		.6173	.5041		.6516
15		.6516		.6173	.5228		.6173
16	.6173	.6516		.6173	.5228	.5487	
17	.6516	.6516		.6173			
18				.6516		.5487	
19	.6859	.7202	.9335	.703		.8745	
20		.8402	.9335			.8573	
21		.823	.8589			.8059	
22		.7545	.7842			.703	
23		.7202	.7468			.4344	
24			.6687	.5601	.4287		.5144
Max	.6859	.8402	.9335	.703	.7468	.8745	.6859
Min	.583	.6173	.6001	.4481	.3429	.4344	.3258
Avg	.6287	.6959	.7182	.5590	.4629	.6384	.5193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 201 / 11 KV BRAMHANATH AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	1.166	.156	.1214		.1227	.3772
2	1.3565	1.1488	.1543	.1214		.1254	.4115
3	1.4243	1.1145	.1543	.1214		.1372	.407
4	1.4419	1.1317	.1543	.12		.1578	.4409
5	1.4746	1.1963	.1543	.12		.1578	.4458
6	1.5074	1.3565	.1526	.12		.1612	.4801
7	1.5223	1.5415	.1526	.1214		.1629	.5028
8	.1187	.1387	.1715	.1006		.1075	.1063
9	.1341	.1341	1.5684	1.4403		.502	.1086
10		.1341	1.7814	1.5249			
11	.1296			1.4746			.1086
12	.116					.3688	.1086
13	.116	.116	1.8399			.3353	.0716
14	.1174	.1326	1.7695			.3086	.0895
15	.1187	.1326	1.8442	1.1385		.2915	.0867
16	.1341	.1311	1.704		.6562	.2743	.0709
17	.116	.1341	.1147		.7291	.0876	.0876
18	.116	.1372	.1147		.6274	.0876	.1052
19	.1174	.1578	.1174		.1214	.0895	.1227
20	.1094	.1578	.1341		.124	.1075	.0876
21	.1254	.1595	.1214		.1402	.1097	.0886
22	1.2403	.1612	.1387		.1433	.3224	.2507
23	1.1736	.1595	.1372	.1475	.1387	.3506	.2126
24	1.3032	1.1401	.156	.1387		.12	.3814
Max	1.5223	1.5415	1.8442	1.5249	.7291	.502	.5028
Min	.1094	.116	.1147	.1006	.1214	.0876	.0709
Avg	.6674	.5355	.5814	.4865	.3350	.2040	.2240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 202 / 11 KV PANCHGANGA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8669	.7108	
2			.8573	.6935	
3	.2204		.8745	.6762	
4			.8745	.6687	
5			.8745	.6859	
6			.8648	.6859	
7			.8648	.7108	
9	1.0562	.8718			
10		.9054			
11	1.0526	.9156			
12	1.0442	.8848			
13	1.0111	.8785			
14	1.0059	.8951			
15	1.153	.9116			
16	1.1568	.9012			
22		.8596	.7455		.0179
23		.8859	.7373		.0173
24			.8669	.7282	
Max	1.1568	.9156	.8745	.7282	.0179
Min	.2204	.8596	.7373	.6687	.0173
Avg	.9625	.8910	.8427	.695	.0176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 203 / 11 KV RANGOLI VILLAGE

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1715	.208	.1734	.2172	.1753	.1886
2	.2035	.1715	.2058	.156	.2353	.1791	.1715
3	.2204	.1543	.2229	.156	.1991	.2058	.2035
4	.213	.1886	.2229	.1715	.181	.2454	.2374
5	.2294	.208	.2401	.208	.2149	.2804	.2743
6	.2294	.2374	.2374	.2229	.2658	.3224	.2915
7	.2267	.3366	.2204	.3121	.333	.3258	.3121
8	.2883	.2601	.2229	.3018	.3086	.3045	.2835
9	.3018	.3521	.2561	.2721	.3018	.2915	.2353
10		.3018	.2105	.3149	.2984		
11	.3077	.2883		.2785	.3018		.2353
12	.2818	.2785			.2785	.2515	.2172
13	.2321	.2818	.1658		.2652	.2012	.197
14	.2683	.2155	.1638			.2229	.197
15	.2883	.2984	.218			.2401	.208
16	.3018	.3277	.213		.2881	.2572	.2126
17	.2818	.3185	.2294		.3561	.3155	.2103
18	.2818	.3258	.2267	.3814	.2883	.3506	.2454
19	.285	.3506	.3018	.4382	.3814	.3761	.298
20	.3582	.3506	.2515	.3544	.3544	.3403	
21	.3582	.3721	.2947	.3544	.333	.3109	
22	.2835	.3403	.208	.3403	.2865	.2865	
23	.2103	.2835	.1886	.3045	.2427	.2454	.2303
24	.1886	.1844	.2427	.1734	.2865	.2058	.208
Max	.3582	.3721	.3018	.4382	.3814	.3761	.3121
Min	.1886	.1543	.1638	.156	.181	.1753	.1715
Avg	.2629	.2749	.2250	.2730	.2826	.2697	.2328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042] BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 201 / 11 KV YELGUD VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2328	.1829	.1867	.1867		.1715	.1715
2	.1612	.1663	.1663	.168		.1715	.1715
3	.1612	.1478	.1663	.1494		.1612	.1524
4	.1612	.1478	.1663	.1494		.1772	.1524
5	.197	.1448	.1829	.168		.1753	.1715
6	.2172	.1612	.2012	.2054		.1886	.1905
7	.2353	.1772	.2172	.2241		.2195	.2286
8	.2172	.2477	.2614	.2587		.2667	.2614
9	.2126	.2126	.2172	.2195		.2286	.2543
10		.3429	.2572	.2572	.2058	.3429	.3045
11	.3018	.3258		.285	.2058		.3475
12	.285	.3185		.3018	.2374		.3109
13	.2683	.2374		.3018	.2374	.2987	.2743
14	.218	.2543	.1341	.2347	.1865	.2155	.2858
15	.2229	.2401	.2054	.2058	.1886	.2204	.2667
16	.1372	.1886		.1734		.208	.2667
17	.1905	.2477			.2477		.2286
18	.2477	.2858	.2096	.2858	.2858		.2477
19	.2477	.3239	.2667	.2858	.3048		.3239
20	.3048	.3048	.3048	.3048	.3429	.3429	.1128
21	.2858	.2614	.2667		.2858	.2667	.2667
22	.2195	.2452				.2477	.2263
23	.2195	.2263	.2218		.2075	.2096	.2096
24	.1949	.2012	.2054	.2054	.2075	.1905	.2096
Max	.3048	.3429	.3048	.3048	.3429	.3429	.3475
Min	.1372	.1448	.1341	.1494	.1865	.1612	.1128
Avg	.2234	.2330	.2132	.2285	.2418	.2265	.2348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 202 / LAXMI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179	.0183	.2427	.2241		.0191	.0191
2	.0179	.0185	.2402	.2241		.0191	.0191
3	.0179	.0185	.2402	.2241		.0179	.0191
4	.0179	.0185	.2402	.2241		.0179	.0191
5	.0179	.0362	.2561	.2987		.0175	.0191
6	.0362	.0358	.2926	.3361		.0171	.0191
7	.0362	.0177	.3801	.3921		.0183	.0191
8	.0181	.0191	.0373	.0187		.0191	.0187
9	.4161	.4784	.0362	.0181		.2096	.1357
10		.5144	.0343	.0171	.0171	.1905	.1433
11	.4915	.5144		.0168	.0171		
12	.4752	.5197		.0168	.017		
13	.4862	.5426		.0168	.017	.1307	
14	.4359	.5487	.0168	.0168	.017	.1492	
15	.4287	.5487	.0187	.0171	.0171	.1526	
16	.4287	.5487		.0173		.156	.1524
17	.0191	.0191	.0191		.0191		.1905
18	.0191	.0381	.0381	.0381	.0191		.1715
19	.0381	.0381	.0381	.0381	.0191		.0191
20	.0381	.0381	.0381	.0381	.0191	.0191	.007
21	.0381	.0373	.0381		.0191	.0191	.0191
22	.0366	.2452				.0191	.0189
23	.0366	.2452	.2402		.0189	.0191	.0191
24	.0177	.0183	.2427	.2241	.132	.0191	.0191
Max	.4915	.5487	.3801	.3921	.132	.2096	.1905
Min	.0177	.0177	.0168	.0168	.017	.0171	.007
Avg	.1559	.2116	.1416	.1209	.0268	.0647	.0552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 203 / bajrang ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8238	.567	.0373	.0187		.0191	.1524
2	.6089	.5544	.037	.0187		.0191	.1334
3	.591	.5544	.037	.0187		.0179	.1334
4	.591	.5544	.037	.0187		.0358	.1334
5	.6268	.5973	.0366	.0187		.0351	.1524
6	.7522	.6805	.0366	.0187		.0343	.1905
7	.8326	.7265	.0362	.0187		.0366	.2858
8	.0181	.0191	.0373	.0187		.0381	.0187
9	.0347	.0177	.9412	.7682		.3239	.017
10		.0171	.9945	.7545	.3429	.2858	.0179
11	.0164	.0171		.7712	.3429		.0183
12	.0164	.0168		.7377	.3391		.0183
13	.0168	.017		.6706	.3052	.2614	.0183
14	.0168	.0171	.8886	.4359	.3052	.2155	.0191
15	.0171	.0171		.3944	.2915	.2204	.0191
16	.0171	.0171		.3467		.208	.0191
17	.0191	.0191	.0191		.0191		.0191
18	.0191	.0191	.0191	.0381	.0191		.0381
19	.0191	.0381	.0191	.0381	.0191		.0381
20	.0381	.0381	.0381	.0381	.0191	.0381	.0141
21	.0381	.0373	.0381		.0191	.0381	.0381
22	.567	.0377				.1524	.1509
23	.5853	.0377	.037		.0189	.1524	.1524
24	.6733	.5487	.0373	.0373	.0189	.0191	.1524
Max	.8326	.7265	.9945	.7712	.3429	.3239	.2858
Min	.0164	.0168	.0191	.0187	.0189	.0179	.0141
Avg	.3017	.2153	.1848	.2590	.1585	.1132	.0813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 201 / GADMUDSHINGI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8421		.1143	.0953	.0857	.0953	.2347
2	.8421		.1143	.0953	.0857	.0762	.2374
3	.8421		.1143	.0953	.0857	.0762	.218
4	.9393		.1334	.0953	.0857	.0953	.2347
5	1.0242		.1334	.1143	.0857	.0953	.2347
6	1.1523		.1524	.1334	.0857	.1143	.2515
7	1.1683		.1524	.1905	.0137	.1334	.3521
8	.132		.1715	.1334	.1372	.1334	.1334
9			1.9719	1.3283	.6706		.012
10			2.0919	1.2308	.5533		
11		.0191		1.1336	.5365		.1029
12	.0762	.1524			.5197	.3353	.0686
13	.0953		.0154		.4359	.3018	.0514
14	.0762		1.6632	.8848	.3772		.0686
15				.6882	.3429	.3185	.0686
16	.1143		1.749	.6133	.3772	.285	.0686
17	.1029		.1334	.1029	.0953	.1143	.0857
18	.12		.1334	.0857	.0953	.1143	.0857
19	.12	.1334	.1334	.0857	.1334	.1143	.1029
20	.1029	.1524		.12	.1143	.1334	.1029
21	.12	.1524	.1334		.1143	.1334	.1029
22		.1524	.1143		.0953		.2543
23		.1334	.0953		.0953		.2374
24	.9069	.823	.1334	.0953	.0857	.0953	.2374
Max	1.1683	.823	2.0919	1.3283	.6706	.3353	.3521
Min	.0762	.0191	.0154	.0857	.0137	.0762	.012
Avg	.4876	.2148	.4727	.3853	.2211	.1536	.1542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 202 / KALAMWADI VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0343	.0747	.0934	.0686	.0716	.0747
2	.0943	.0514	.0747	.0934	.0686	.0716	.0747
3	.0943	.0343	.0934	.0934	.0686	.0716	.0747
4	.0943	.0343	.0934	.0934	.0686	.0716	.0934
5	.0943	.0343	.0934	.0934	.0686	.0716	.0934
6	.1132	.0686	.0934	.0934	.0686	.0732	.112
7	.0943	.1029	.112	.1307	.0857	.0924	.0943
8	.0943	.12	.112	.0934	.0857	.0924	.0934
9		.112	.12	.1132	.0914		.1029
10		.168	.1372	.132	.1097		
11		.1494		.1132	.0914		.12
12	.0934	.1494			.0724	.1307	.1029
13	.112	.112	.1029		.0543	.112	
14	.112			.0943	.0549	.112	.1029
15				.132	.0732	.0934	.1029
16	.1307		.12	.1509		.0747	.12
17	.1029		.112	.1372		.0934	.1029
18	.0686		.1307	.1029		.1307	.12
19	.1029	.1307	.1307	.1029		.1307	.12
20	.1029	.168	.1698	.12		.1307	.12
21	.12	.1494	.1509	.12		.132	.1372
22		.1307	.1307	.1029			.132
23		.0943	.0934	.0857	.0716		.0953
24	.0943	.0514	.0934	.0934	.0857	.0716	.056
Max	.1307	.168	.1698	.1509	.1097	.132	.1372
Min	.0686	.0343	.0747	.0857	.0543	.0716	.056
Avg	.1007	.0998	.1119	.1084	.0757	.0962	.1021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 203 / GADMUDSHINGI VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3258	.3734	.2772	.3429	.3696	.3174
2	.4338	.3772	.3734	.2772	.4115	.3696	.3174
3	.4338	.3772	.415	.2772	.4287	.3696	.3361
4	.5415	.3944	.4294	.2772	.4458	.3881	.3734
5	.5601	.4287	.4481	.3361	.4458	.4108	.3921
6	.5975	.463	.4668	.3921	.5144	.4668	.4294
7	.6602	.4801	.5093	.4668	.583	.6722	.5041
8	.5093	.4115	.4854	.4668	.4287	.4854	.4854
9		.4668	.3944	.4527	.4668		.4287
10		.5415	.3429	.3961	.3734		
11		.6036		.3584	.3734		.3258
12	.5228	.3921			.3921	.3734	
13	.4854	.3361	.2743		.3547	.3361	
14	.415		.2915	.3018	.3881	.5041	.3086
15				.3395	.4251	.4668	.2743
16	.3547		.3086	.3395		.3224	.2229
17	.3772		.2801	.3429		.3982	.2229
18	.3601		.2987	.4973		.5788	.2572
19	.463	.6161	.4668	.5487		.5975	.4287
20	.6344	.8215	.5415	.6516		.7282	.6173
21	.6001	.5601	.5041	.4801		.7167	.4801
22		.6535	.4481	.4287			.547
23		.6224	.3361	.3429	.4066		.547
24	.5281	.3429	.3921	.2957	.3086	.3881	.3361
Max	.6602	.8215	.5415	.6516	.583	.7282	.6173
Min	.3547	.3258	.2743	.2772	.3086	.3224	.2229
Avg	.4961	.4850	.3990	.3885	.4170	.4707	.3882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 204 / sarnobatwadi ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0514	.0886	.0953	.0171	.0381	.0381
2	.0762	.0514	.0886	.0953	.0171	.0381	.0381
3	.0572	.0514	.1063	.0953	.0171	.0381	.0381
4	.0762	.0514	.124	.0953	.0171	.0381	.0381
5	.0762	.0514	.124	.1097	.0171	.0381	.0572
6	.0953	.0514	.1417	.1463	.1029	.0381	.0572
7	.0953	.0514	.2303		.1029	.0572	.0572
8	.0953	.0857	.0953		.0514	.0572	.0762
9		.3561	.0686	.0572	.0572		.1029
10		.4527	.0514	.0572	.0381		
11		.4656		.0572	.0381		.0343
12	.443	.4477			.0381	.1063	
13	.4075	.4298	.0686		.0381		.0343
14	.3898		.0686	.0381	.0381		.0514
15				.0381	.0381		.0686
16	.1772		.0514	.0381		.1063	.0857
17	.0514		.0381	.0514		.0572	.0343
18	.0514		.0572	.0343		.0381	.0343
19	.0514	.0381	.0572	.0343		.0572	.0343
20	.0514	.0381	.0572	.0514		.0572	.0343
21	.0686	.0381	.0381	.0343		.0572	.0343
22		.1595	.0791	.0171			.0381
23		.1063	.0953	.0171	.0381		.0381
24	.0762	.0514	.0886	.0953	.0171	.0381	.0381
Max	.443	.4656	.2303	.1463	.1029	.1063	.1029
Min	.0514	.0381	.0381	.0171	.0171	.0381	.0343
Avg	.1342	.1594	.0866	.0629	.0402	.0538	.0483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 201 / EKONDI Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3083	.2865	.0762			.0762
2		.3073	.3045	.0762			.0762
3		.3073	.3045	.0762			.0762
4		.3236	.3224	.0762			.0762
5		.338	.3582	.0762			.0762
6		.3414	.4298	.0762			.0762
7		.4934	.4557				.0762
8		.072		.0762			.0762
9		.0762			.3048		
10		.0762		.4298	.381		
11		.0762		.4298	.362		.0537
12	.1075	.0762			.2858		.018
13	.1075	.0762					.018
14		.0762		.394			.018
15		.0762		.394			.018
16	.1086	.0762			.3239		
17		.1143	.0762			.1143	
18	.0685	.1075	.0953	.0741	.1075	.1143	
19	.0701	.1075	.0953	.0742	.1075	.0762	
20	.0701		.0762		.1086	.0762	
21	.0703		.0762		.1097	.0762	
22	.274		.0762				
23	.2912		.0762				
24		.2912	.2835	.0762			.0762
Max	.2912	.4934	.4557	.4298	.381	.1143	.0762
Min	.0685	.072	.0762	.0741	.1075	.0762	.018
Avg	.1298	.1861	.2211	.1718	.2323	.0914	.0580

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 202 / Siddhanerli- Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2035	.2481	.0762			.0381
2		.1987	.2865	.0762			.0381
3		.1989	.2865	.0762			.0381
4		.2318	.3224	.0762			.0572
5		.2676	.3224	.0762			.0572
6		.3353	.3582	.0762			.0762
7		.5633	.4961	.0762			.0762
8		.0716		.0762			.0762
9		.0762			.2286		
10				.3582	.2477		
11				.3582	.2667		
14				.3582			
15				.362			
17			.0762			.0762	
18			.0762		.0716	.0762	
19	.0732		.0762	.0732	.1097	.0762	
20	.0732		.0762		.0724	.0762	
21	.0732		.0762		.0895	.0762	
22	.2051		.0762				
23	.2048		.0762				
24		.1707	.2507	.0762			.0762
Max	.2051	.5633	.4961	.362	.2667	.0762	.0762
Min	.0732	.0716	.0762	.0732	.0716	.0762	.0381
Avg	.1259	.2318	.2070	.1568	.1552	.0762	.0593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 203 / 11KV Shendur Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	19-JUL-17
HR	Load (MW)
16	.3048
Max	.3048
Min	.3048
Avg	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 204 / Sidhnerli Ekondi Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3309	.2926	.3048			.3048
2		.3309	.2926	.3048			.3048
3		.3482	.2926	.3048			.3048
4		.3299	.3658	.3429			.381
5		.3486	.4066	.4191			.4191
6		.5865	.4344	.5335			.4954
7		.6061	.4755	.6097			.6097
8		.5877		.5906			.5716
9		.6668			.5716		
10		.6478		.5853	.5525		
11		.5716		.5487	.5144		.4755
12	.4938	.5716					.4553
13	.5121	.4572			.4191		.4938
14		.4191		.5175	.4572		.4582
15		.4191		.5068	.4382		.4403
16	.5487	.4572			.4382		
17		.5716	.3048			.5335	
18	.5175	.439	.5525		.5544	.5716	
19	.6908	.5792	.724	.6322	.5853	.7049	
20	.7167		.8573		.724	.5335	
21	.716		.6859		.6516	.4763	
22	.5313		.5906				
23	.3734		.381				
24		.3292	.3292	.3239			.3048
Max	.7167	.6668	.8573	.6322	.724	.7049	.6097
Min	.3734	.3292	.2926	.3048	.4191	.4763	.3048
Avg	.5667	.4799	.4657	.4660	.5370	.5640	.4299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 205 / 11 kv Shendur Gavthan

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2529	.2561	.1905			.2286
2		.2529	.2561	.1905			.2286
3		.2518	.2587	.1905			.2286
4		.2523	.2926	.2477			.2667
5		.2732	.2772	.3048			.2858
6		.3658	.3109	.381			.3239
7		.4032	.3292	.381			.4001
8		.422		.4382			.4001
9		.381			.4191		
10				.362	.362		
11		.362		.3292	.3048		.2333
12	.3109	.381			.3429		.3486
13	.2957	.2667			.3048		.3306
14		.2477		.3292	.3048		.2398
15		.2667		.3658	.3048		.239
16	.3326				.3048		
17		.4191	.3048			.3429	
18	.3721	.3841	.3429	.4649	.4108	.4382	
19	.4861	.439	.4191	.4845	.439	.5335	
20	.5239		.4191		.5121	.5335	
21	.5062		.4382		.4755	.4763	
22	.4513		.4001				
23	.3409		.2667				
24		.2521	.2587	.2096			.2286
Max	.5239	.439	.4382	.4845	.5121	.5335	.4001
Min	.2957	.2477	.2561	.1905	.3048	.3429	.2286
Avg	.4022	.3263	.3220	.3246	.3738	.4649	.2845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 206 / Octega Green

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0352	.0343	.0381			.0381
2		.0351	.0335	.0381			.0381
3		.0352	.0335	.0381			.0381
4		.0352	.0335	.0381			.0381
5		.0352	.0335	.0381			.0381
6		.0352	.0332	.0381			.0381
7		.0348	.0335	.0381			.0381
8		.0351		.0381			.0381
9		.0381			.0381		
10		.0381		.0332	.0381		
11		.0381		.0328	.0381		.0351
12		.0381			.0381		.0352
13	.0335	.0381			.0381		.0352
14		.0381		.0366	.0381		.0352
15		.0381		.0362	.0381		.0352
16	.0324	.0381			.0381		
17		.0381	.0381			.0381	
18	.0351	.0366	.0381	.0352	.0362	.0381	
19	.0351	.0335	.0381	.0352	.0335	.0381	
20	.0352		.0381			.0381	
21	.0352		.0381			.0381	
22	.0352		.0381				
23	.0353		.0381				
24		.0351	.0332	.0381			.0381
Max	.0353	.0381	.0381	.0381	.0381	.0381	.0381
Min	.0324	.0335	.0332	.0328	.0335	.0381	.0351
Avg	.0346	.0365	.0357	.0368	.0375	.0381	.0371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 402 / 33 KV Shahu LIS -SDH-

HV Ag & Cold storage

Feeder KV- 33 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0572			
2			.0572			
3		.054	.0572			.0572
4		.054	.0572			.0572
5		.0539	.0572			.0572
6		.054	.0572			.0572
7		.054	.0572			.0572
8		.0544	.0572			.0572
9		.0572		.0572		
10		.0572	.0537	.0572		
11		.0572	.0537	.0572		.054
12	.0549	.0572		.0572		.054
13	.0549	.0572		.0572		.0544
14		.0572		.0572		.0544
15		.0572		.0572		.0543
16	.0549	.0572		.0572		
17		.0572			.0572	
18	.0544	.0503	.054	.0549	.0572	
Max	.0549	.0572	.0572	.0572	.0572	.0572
Min	.0544	.0503	.0537	.0549	.0572	.054
Avg	.0548	.0556	.0563	.0569	.0572	.0558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 201 / Kagal Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5335	.0953	.0762		.0191	.1524
2		.5335	.0953	.0762		.0191	.1524
3		.5335	.0953	.0953		.0191	.1715
4		.5335	.1143	.0762		.0191	.1715
5		.5144	.1143	.0953		.0191	.1905
6		.6668	.1143	.0953		.0191	.2858
7		.6668	.1143	.1143		.0191	.381
8		.1334	.1143	.1143			.0953
9	.1143	.0762		.6859	.4191		
10	.1143	.0762		.5716	.381		
11	.0953	.0762		.5144	.3239		.1143
12	.0762	.0953			.3239		.0762
13	.0953	.0953			.3429		.0762
14	.0953	.1143		.4191	.3048		.0762
15		.1143		.4382	.3048		.0762
16	.0762	.1143		.4191			.0762
17	.0953	.0953	.0762	.0762		.0762	.0762
18	.1334	.0953	.0953	.0762		.0572	.0953
19	.1334	.0953	.1334	.1143		.0762	.0953
20	.1524	.1143	.1334	.1143		.1524	.0953
21	.1524	.1143	.1143		.0381	.1334	.0953
22	.5525	.1143	.1143		.0191		.1715
23	.5525	.0953	.0762		.0191		.1524
24		.5525	.0953	.0762		.0191	.1715
Max	.5525	.6668	.1334	.6859	.4191	.1524	.381
Min	.0762	.0762	.0762	.0762	.0191	.0191	.0762
Avg	.1742	.2564	.1060	.2236	.2477	.0499	.1386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 202 / Kagal-Sugar Factory Vg

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.2286	.2096		.1905	.1715
2		.1715	.2286	.1905		.1905	.1524
3		.1715	.2286	.1715		.1905	.1715
4		.1715	.2286	.1715		.2096	.1905
5		.2096	.2477	.2096		.2286	.1905
6		.3429	.3429	.3239		.3239	.3239
7		.4191	.381	.4763		.4001	.381
8		.4001	.3239	.4191		.4001	.4191
9	.5144	.4763	.3048	.4001	.2858		
10	.5525	.5335	.2286	.2858	.2667		
11	.4954	.5144	.2286	.4001	.3239		.4191
12	.5716	.743			.5525	.2858	.4382
13	.4001	.4763	.2477		.381	.2858	.381
14	.4572	.4954	.1524	.2477	.1905	.2667	.3048
15		.4572		.2667	.4191	.2667	.4191
16	.2858	.4763		.2858	.2286	.2667	.362
17	.4382	.4572	.2096	.2858	.3429		.362
18	.3239	.3048	.3048	.2667	.3429		.3048
19	.362	.4191	.4001	.381	.4191		.381
20	.4382	.4763	.4572	.4001	.4572		.4382
21	.362	.4763	.4001		.4191		.4191
22	.3239	.4191	.3239		.3048		.3239
23	.2286	.2477	.2286		.2286		.1905
24			.2286	.1905		.1905	.1905
Max	.5716	.743	.4572	.4763	.5525	.4001	.4382
Min	.2286	.1715	.1524	.1715	.1905	.1905	.1524
Avg	.4110	.3935	.2821	.2938	.3442	.264	.3152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 203 / Non Sh MIDC Kagal-Anant SHEDDABLE FEEDER HAVING WEEKLY
 Roto Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2955	1.6766	.9526		1.5623	1.6575
2		1.3336	1.7528	.9717		1.7147	1.6575
3		1.6385	1.7528	.9335		1.4289	1.7337
4		1.6004	1.6385	.8954		1.448	1.7718
5		1.8099	1.5242	.9907		1.3908	1.7909
6		1.8861	1.6956	1.0669		1.6194	1.8099
7		1.848	1.7909	1.1812		1.7528	1.8671
8		1.8671	1.5432	1.2193		1.6956	1.7337
9	1.9243	1.848	.5335	1.3908	1.8099		
10	2.191	2.1529	.5144	1.5242	1.9814		
11	1.7147	2.0576	.5144	1.8671	2.0005		1.9624
12	1.9814	2.0767	.5335		2.21	1.7337	1.9624
13	1.9243	2.0195	.5335		2.0005	1.7528	1.9052
14	1.6385	1.9243	.5335	1.6956	2.0576	1.7909	1.7909
15		1.9624	.5335	1.7337	2.0576	1.9624	2.0576
16	1.7147	2.1529		1.8861	2.0767	2.0005	1.9814
17	2.0386	2.0195	.5335	1.6766	1.9814		2.0386
18	2.0957	2.0957	.5335	1.6194	2.0576		2.0005
19	1.7909	2.1338	.5906	1.5623	2.0957		1.8861
20	1.6385	2.0576	.5906	1.8099	1.5623		1.8099
21	1.6194	1.829	.5144		1.2955		1.6385
22	1.4861	1.6385	.5716		1.4098		.9335
23	1.467	1.5813	.7811		1.5432		1.3527
24		1.4289	1.6385	.9335		1.4289	1.6766
Max	2.191	2.1529	1.7909	1.8861	2.21	2.0005	2.0576
Min	1.467	1.2955	.5144	.8954	1.2955	1.3908	.9335
Avg	1.8018	1.8441	.9924	1.3637	1.8760	1.6630	1.7736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 204 / Laxmi Ind

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.743	.6097	.3429		.6097	.5906
2		.7621	.6097	.3239		.5906	.4572
3		.743	.5906	.3429		.743	.5525
4		.6859	.5716	.362		.724	.5906
5		.5716	.5716	.381		.6859	.6287
6		.6859	.5716	.381		.7049	.6287
7		.724	.4572	.381		.743	.8383
8		.6287	.4572	.5144		.7811	.8002
9	.1905	.8954	.4382	.7621	.9145		
10	.9335	.9526	.4191	.6668	.6859		
11	.8383	.9907	.4191	.9907	.724		1.0669
12	.8954	.6478	.3429		.743		.8002
13	.7811	.8002	.381		.8192	.7621	.6097
14	.9335	.8002	.381	.724	.6478	.743	.7049
15		.8002	.381	.7811	1.0098	.6668	.8192
16	.9526	.5906	.4001	.8573	.724	.9145	.8573
17	1.0288	.8383	.3239	.7811	.9145		.7621
18	.743	.7049	.3429	.6097	.6859		.5144
19	.7811	.5335	.381	.743	.6859		.5906
20	.724	.7049	.4191	.743	.8002		.5335
21	.6859	.8002	.4191		.5716		.8002
22	.6668	1.0288	.381		.8383		.7621
23	.8383	.8764	.3429		.5906	.7049	.7811
24		.9526	.6097	.3429		.6859	.7049
Max	1.0288	1.0288	.6097	.9907	1.0098	.9145	1.0669
Min	.1905	.5335	.3239	.3239	.5716	.5906	.4572
Avg	.7852	.7692	.4509	.5806	.7570	.7185	.6997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 205 / K.Sangaon

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2477	.2667	.2667		.2667	.2477
2		.2286	.2477	.2477		.2286	.2096
3		.2858	.2477	.3048		.2477	.3048
4		.2858	.2477	.3429		.2667	.362
5		.4001	.2667	.4001		.381	.4001
6		.4763	.3048	.4572		.4382	.5144
7		.5335	.3429	.6478		.6478	.5906
8		.5716	.4001	.6668		.5525	.6287
9	.5716	.5906	.4191	.5906	.6478		
10	.4954	.5716	.3048	.5335	.5335		
11	.4763	.5144	.2667	.3239	.4763		.5144
12	.4001	.4191	.2667		.4001		.4382
13	.4001	.3429	.2286		.4382	.4572	.3429
14	.4001	.4191	.2477	.4001	.4191	.4001	.4572
15		.4001	.2286	.4001	.4001	.4001	.4001
16	.4001	.381	.2477	.4001	.4001	.4001	.4382
17	.4382	.4191	.2477	.381	.4572		.4001
18	.362	.4382	.4001	.4954	.4763		.4954
19	.4763	.4954	.4382		.5335		.5525
20	.5716	.5906	.4954	.6478	.5716		.5906
21	.5525	.5716	.4763		.5335		.5716
22	.4191	.5144	.4191		.4572		.4954
23	.3048	.362	.3429		.3429		.3239
24		.2477	.3048	.2858		.3048	.2858
Max	.5716	.5906	.4954	.6668	.6478	.6478	.6287
Min	.3048	.2286	.2286	.2477	.3429	.2286	.2096
Avg	.4477	.4295	.3191	.4329	.4725	.3840	.4347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 206 / Laxmi-Ag Feeder-

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.0381	.0381		.0381	.2286
2		.1905	.0381	.0381		.0381	.1905
3		.1905	.0381	.0381		.0381	.1905
4		.1905	.0381	.0381		.0381	.2096
5		.1905	.0381			.0381	.2286
6		.3048	.0381			.0381	.2286
7		.3239	.0381			.0381	.2096
8		.0381	.0381			.0381	.0381
9	.0381	.0381	.5716	.4572	.3239		.0381
10	.0381	.0381	.6097	.4001	.2667		.0381
11	.0381	.0381	.6097	.2667	.1905		.0381
12	.0381	.0381	.4954		.2286		.0381
13	.0381	.0381	.5716		.2286	.1143	.0381
14	.0381	.0381		.1524	.2286	.1143	.0381
15		.0381	.5525	.1524	.1905	.1143	.0381
16	.0381	.0381	.5716	.1524	.1143	.1143	.0381
17	.0381	.0381	.0381	.0381	.0381	.0381	.0381
18	.0572	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0572	.0381	.0381	.0381	.0381	.0381	.0381
21	.0572	.0381	.0381		.0381	.0381	.0381
22	.2096	.0381	.0381		.0381	.2286	.0762
23	.2096	.0381	.0381		.0381	.2286	.0762
24		.2096	.0381	.0381		.0381	.1905
Max	.2096	.3239	.6097	.4572	.3239	.2286	.2286
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0667	.1008	.1996	.1283	.1359	.0724	.0984

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 207 / S.Kharkhan Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.3429			.1334	.0572
2		.0572	.3429			.1334	.0572
3		.0572	.3429			.1334	.0572
4		.0572	.3429			.1334	.0381
5		.0572	.362			.1334	.0381
6		.0572	.4191			.1334	.0572
7		.0572	.6859			.3048	.0572
8		.0572	.0572			.0762	.0572
9	.6668	.8192	.0572	.0572	.0572		.2667
10	.6097	.9717	.0381	.0572	.0572		.2286
11	.6478	.9907		.0572	.0381		.2477
12	.7049	.9335			.0381		.1524
13	.724	.8954			.0381	.0381	.1143
14	.7621	.8192		.0572	.0381	.0381	.0572
15		.6287	.0572	.0572	.0381	.0381	.0953
16	.724	.6668	.0381	.0572	.0381	.0381	.0953
17	.0381	.0381	.0191	.0572	.0572	.0381	.0381
18	.0381	.0381	.0191	.0572	.0572	.0572	.0381
19	.0572	.0381	.0762	.0762	.0572	.0572	.0572
20	.0572	.0572	.0762	.0762	.0572	.0762	.0572
21	.0762	.0762	.0762		.0572	.0572	.0572
22	.0572	.381	.381		.1334	.0572	.0572
23	.0572	.3429	.362		.1143	.0572	.0381
24		.0572	.3429			.1334	.0572
Max	.7621	.9907	.6859	.0762	.1334	.3048	.2667
Min	.0381	.0381	.0191	.0572	.0381	.0381	.0381
Avg	.3729	.3422	.2220	.061	.0584	.0934	.0866

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 208 / Kagal Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.5906			.4954	.5525
2		.5335	.5716			.4954	.4954
3		.5144	.5525			.4954	.5335
4		.5144	.5525			.5144	.5525
5		.5525	.5906			.5525	.5716
6		.724	.6859			.7621	.743
7		.8002	.8002			.9335	.8764
8		.8383	.8573	.8383		.9335	.9145
9	.7621	.8002		.8383	.8383		.8954
10	.724	.8002		.724	.7621		.724
11	.743	.7049		.7049	.724		.743
12	.6859	.6668			.7621		
13	.6859	.6859			.724		.7049
14	.6287	.6287		.6287	.6478	.6668	.5716
15		.5906		.6287	.6097	.6097	.6287
16	.6287	.5906	.8573	.6287	.6287	.6287	.6287
17	.6287	.6859	.8573	.724	.743	.743	.7621
18	.7621	.7621	.8383	.8192	.8764	.8383	.8192
19	.8954	.8764	1.086	1.105	1.0098	1.0479	1.0479
20	1.1241	1.1241	1.2574	1.1622	1.105	1.1812	1.1241
21	1.0479	1.0669	1.086		1.0098	1.086	1.0288
22	.9145	.9526	.9526		.8764	.8954	.8764
23	.7049	.724	.7621		.6478	.724	.6668
24		.5906	.6097			.5335	.6097
Max	1.1241	1.1241	1.2574	1.1622	1.105	1.1812	1.1241
Min	.6287	.5144	.5525	.6287	.6097	.4954	.4954
Avg	.7811	.7208	.7946	.8002	.7977	.7440	.7422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 402 / 33KV Shahu LIS - KGL-

HV Ag & Cold storage

Feeder KV- 33 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.1715	.1715		.1143	.1143
4		.1715	.1715		.1143	.1143
5		.2286	.1715		.1143	.1143
6		.3429	.1715		.1143	.1143
7		.4572	.1143		.1143	.1143
8		.4572	.1143		.1143	.1143
9	.6859		.1143	.1143		.1143
10	.6287	.743	.1143	.1143		.1143
11	.5144	.743	.1143	.1143		.1143
12	.5144	.6859		.1143		.1143
13	.4572	.6859		.1143	.1143	.1143
14	.5144	.6859	.1143	.1143	.1143	.1143
15		.6859	.1143	.1143	.1143	.1143
16	.5144	.6859	.1143	.1143	.1143	.1143
17	.5144	.6859	.1143	.1143	.1143	.1143
18	.1715	.1715	.1143	.1143	.1143	
19			.1143			
Max	.6859	.743	.1715	.1143	.1143	.1143
Min	.1715	.1715	.1143	.1143	.1143	.1143
Avg	.5017	.5068	.1296	.1143	.1143	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 201 / 11KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	1.7528	1.7147	1.5242	1.5623	1.6385	1.5242
2	1.829	1.7909	1.6194	1.7337	1.5432	1.6766	1.6194
3	1.829	1.7909	1.7147	1.7528	1.5242	1.6004	.5144
4	1.6575	1.829	1.6194	1.7147	1.5623	1.6194	.5144
5	1.6575	1.7909	1.6194	1.7337	1.5432	1.1431	.5144
6	1.6385	1.7909	1.5242	1.7147	1.5242	1.2574	.5144
7	1.6956	1.7909	1.6194	1.6956	1.5623	1.2384	.3429
8	1.5623	1.5432	1.5813	1.6194	1.5242		
9		2.0957	1.6004	1.7528	2.1338		1.5623
10		2.2291	1.6004	1.829	2.4577	2.0576	2.21
11		2.0576		1.829	1.9433		1.9052
12	1.848	1.8671		1.9624	2.2862		.9526
13	1.6766	1.5813		1.8099	1.7528	1.448	
14	2.3243	1.9624		1.9814	2.2481		
15		1.5813		1.9814	2.2862		
16	2.2481	1.7337	.381	1.8671		1.6766	
17	2.1529		.4191		2.1529	1.8861	2.0386
18	1.8099		1.5623	1.8861	1.7528		1.8099
19	1.5813	1.5051	1.6956	1.6575	1.7337	1.6004	1.8099
20	1.9052	1.5242	1.6385	1.829	1.5242	1.5242	1.7718
21	1.5242	1.4289	1.6385	1.5432	1.5051		1.5432
22	1.4861	1.5623		1.467	1.6575		
23	1.7909	1.6766	1.5623	1.6766	1.6766		1.6004
24	1.7909	1.7528	1.7147	1.5432	1.5813	1.7147	1.6194
Max	2.3243	2.2291	1.7147	1.9814	2.4577	2.0576	2.21
Min	1.4861	1.4289	.381	1.467	1.5051	1.1431	.3429
Avg	1.7899	1.7563	1.4903	1.7437	1.7843	1.5772	1.3537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 202 / 11KV West Block

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	2.191	2.2862	1.9052	2.191	2.0957	2.0005
2	2.2862	2.2862	2.2862	1.9052	2.2862	1.9052	2.0957
3	2.2862	2.2862	2.191	1.9052	2.0957	2.0957	1.9052
4	2.2862	2.2862	2.3815	1.9052	2.191	2.2862	2.0005
5	2.2862	2.191	2.191	1.9052	2.2862	2.2862	2.0005
6	2.2862	2.191	2.0957	1.9052	2.2862	2.2862	1.9052
7	2.2862	2.3815	2.0005	1.9052	2.191	2.2862	1.9052
8	2.2862	2.191	2.0005	1.2384	2.2862	2.2862	2.0005
9		3.4294	1.9052	2.4768	2.6673	3.0483	2.6673
10		4.1914	1.9052	3.0483	3.4294	3.2388	
11		4.0009		3.4294	3.3341		
12	3.8104	3.6199		3.4294	3.0483		3.8104
13	3.0483	3.4294		3.4294	3.4294	3.0483	
14	3.4294	3.4294		3.3341	3.3341		1.7147
15		3.4294		3.7151	3.4294		
16	3.8104	3.2388	1.9052	3.8104		3.8104	
17	3.0483	3.2388	1.9052		3.7151	3.0483	2.2862
18	3.2388	2.6673	1.9052	2.6673	3.0483		2.0957
19	2.2862	2.6673	1.9052	2.2862	2.4768	2.2862	2.2862
20	2.2862	2.2862	1.9052	2.4768	2.0957	2.2862	1.9052
21	2.0957	2.2862	1.9052	2.0957	2.2862	2.2862	1.9052
22	2.0386	2.191		2.0957	2.4768		
23	2.191	2.2862	1.9052	2.191	2.6673		1.9052
24	2.4768	2.2862	2.3815	1.9052	2.2862	2.2862	2.191
Max	3.8104	4.1914	2.3815	3.8104	3.7151	3.8104	3.8104
Min	2.0386	2.191	1.9052	1.2384	2.0957	1.9052	1.7147
Avg	2.6120	2.7784	2.0534	2.4768	2.6756	2.5216	2.1434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 203 / KANERI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5335	.5716	.5144	.5144	.4572	.4954
2	.5144	.5144	.5335	.4954	.4763	.4954	.4954
3	.5144	.5144	.5335	.4954	.381	.4954	.4954
4	.5144	.5716	.5716	.5144	.4191	.4954	.4954
5	.5716	.7621	.5716	.5525	.4954	.8764	.6668
6	1.0669	1.0288	.7621	.8573	.7621	.9526	.9335
7	1.1812	1.086	.8383	1.1812	1.2574	1.3717	1.086
8	.9717	1.1431	.8573	1.1241	.9907	1.0479	.8192
9		.9907	.7621	1.1431	1.1812	1.1431	.9717
10		1.2193	.5335	1.1431	.9717	1.5623	1.2574
11		1.3527		1.0098	1.2193		1.6004
12	1.1812	1.3527		1.1241	1.1431		.8573
13	1.6004	1.0479	.381	1.0098	.8192	1.0669	1.3717
14	1.0479	1.4289	.1905	1.0288	.7621		.8192
15		.8192	.2096	.8383	.9145		
16	.8192	.8002	.2096	.7621		1.0098	
17	1.3908	1.1622	.2096		1.086	1.5051	1.0669
18	1.2574	1.3908	.4954	.9145	.8383	1.1431	.8002
19	.9717	1.1622	.724	.9717	.9335	1.2193	1.0288
20	1.1812	1.105	.7621	1.0479	.8573	1.3146	1.0479
21	.9145	1.0288	.8573	.7621	.743	.9335	.9335
22	.7621	.8764		.7811	.7049		.8192
23	.6097	.724	.5525	.5906	.5716		.6287
24	.5335	.5335	.5906	.5144	.5144	.4382	.5525
Max	1.6004	1.4289	.8573	1.1812	1.2574	1.5623	1.6004
Min	.5144	.5144	.1905	.4954	.381	.4382	.4954
Avg	.9069	.9645	.5580	.8424	.8068	.9738	.8747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 204 / 11 KV PANCHAGANGA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	2.0957	2.191	.8573	1.4289	1.9052	2.0957
2	2.2862	2.2862	2.2862	.8573	1.5242	1.5242	2.0005
3	2.2862	2.191	2.0957	.8573	1.8099	1.5242	1.9052
4	2.6673	2.2862	2.2862	.8573	2.0957	1.1431	1.8099
5	2.6673	2.0957	2.3815	.8573	2.191	1.7147	2.0005
6	2.6673	2.0005	2.191	.8573	2.2862	1.5242	1.9052
7	2.6673	2.191	1.8099	.8573	1.8099	1.9052	1.7147
8	2.191	2.191	.8573	.8573	1.1431	2.0957	1.1431
9		2.191	.7621	1.7147	2.2862	1.9052	2.572
10		2.6673	.9526	1.9052	2.2862	2.2862	2.0957
11		3.2388		2.2862	1.9052		2.191
12	2.6673	2.8578		2.2862	2.572		2.0957
13	1.9052	2.6673		2.2862	1.7147	1.9052	1.5242
14	2.2862	2.6673		2.2862	2.191		2.2862
15		3.0483		2.2862	2.2862		
16	2.4768	2.0957	.7621	1.8099		.9526	
17	2.6673	2.2862	.381		2.2862	.9526	1.9052
18	3.0483	2.6673	.7621	2.6673	2.9531		2.2862
19	2.6673	2.572	.7621	2.2862	2.2862	2.4768	2.2862
20	1.9052	2.0957	.5716	2.2862	2.2862	2.0957	2.2862
21	2.0957	1.7147	.5716	1.5242	2.572	2.4768	1.9052
22	2.3815	2.2862		1.9052	2.8578		
23	2.0005	2.191	.6668	1.4289	2.2862		2.6673
24	1.7147	1.9052	2.2862	.8573	1.2384	2.0957	2.2862
Max	3.0483	3.2388	2.3815	2.6673	2.9531	2.4768	2.6673
Min	1.7147	1.7147	.381	.8573	1.1431	.9526	1.1431
Avg	2.3577	2.3537	1.3654	1.5945	2.0998	1.7931	2.0458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 205 / 11KV MainRoad

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.9145	.7621	.8764	.7049	1.1431	1.1431
2	.6478	.7621	.724	.8383	.724	1.1812	1.1812
3	.6478	.8573	.724	.9145	.7049	1.0669	1.2193
4	.6668	.8764	.6859	.9526	.724	.9145	1.3146
5	.6478	.9145	.6859	.9526	.724	.8002	1.1431
6	.6478	.9145	.6859	.9145	.743	.8002	.7621
7	.7049	.6668	.7049	.8383	.724	1.1241	.8192
8	.9335	.7621	.6859	.7621	.743		1.0098
9		1.2003	.7621	1.0288	.8573		.8573
10		1.2003	.7621	1.0098	1.2574	1.3527	1.3527
11		1.7528		1.086	.9335		1.0098
12	1.2193	1.3908		1.2384	1.105		.9907
13	1.1812	1.1241		.8954	.9526	.6097	.8383
14	1.2193	1.3336		1.2765	.9526		.9717
15		1.3717		1.2003	1.105		
16	1.1622	1.4861	.8192	.8573		.8764	
17	1.3908	.9145	.8383		1.086	1.2193	.8764
18	1.0479	.9717	.7811	.9335	.9526	.7811	.8573
19	1.0479	.7811	.724	.743	.7621	.8192	.8002
20	.6478	.6478	.724	.8192	.8764	.7811	.8383
21	.743	.743	.7811	.724	.8192	.743	.8192
22	.8002	.8002	.724	.8573	1.0669		.724
23	1.0669	.6859	.6859	.724	1.2765		1.1622
24	.7049	1.1812	.724	.8764	.724	1.2384	1.2765
Max	1.3908	1.7528	.8383	1.2765	1.2765	1.3527	1.3527
Min	.6478	.6478	.6859	.724	.7049	.6097	.724
Avg	.8907	1.0106	.7360	.9269	.8921	.9657	.9985

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 206 / 11KV Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814	1.9814	2.0195	1.3336	2.191	2.0195	1.5623
2	2.0957	2.0957	1.9052	1.3336	2.0957	1.9433	1.7147
3	2.1719	1.9814	2.0005	1.3717	2.191	2.0957	1.7528
4	1.7909	1.9433	2.0005	1.3336	2.0957	2.1719	1.7909
5	1.9052	1.9433	2.0957	1.3717	2.191	2.1719	1.829
6	1.9433	1.9052	1.9052	1.3336	2.1338	2.1338	1.7528
7	2.2481	1.7147	1.7909	1.3717	1.829	2.2481	1.829
8	1.7909	1.6385		1.5623	1.7528	1.9814	1.7147
9		2.0957	1.3717	1.9052	2.2862	2.0195	2.3243
10		2.1338	1.3717	2.3243	2.1719	2.3624	2.4006
11		2.2862		2.3243	2.7435		2.2481
12	2.4006	1.9433		2.0576	2.2862		2.5149
13	1.9052	2.1338		2.2862	2.21	2.2481	2.1719
14	2.1719	2.3243		2.5149	2.4768		2.3243
15		2.1338		2.7435	2.7435		2.2481
16	2.0195	2.0576	1.3336	2.1719	2.2481	2.4768	
17	2.1338	2.0957	1.2193		2.5911	2.1719	2.4387
18	1.829	1.9814	1.4098	2.2862	2.1338		1.9814
19	1.8671	1.9433	1.3717	1.9052	2.1338	1.6004	2.0957
20	1.448	1.5623	1.3336	1.6385	1.6004	1.6004	1.7528
21	1.7147	1.6766	1.3336	1.9052	1.7528	1.6385	1.6766
22	1.6385	1.7147	1.2955	1.9433	1.6385		
23	1.7528	2.1338	1.3717	2.2862	1.9814		1.9814
24	1.9433	1.9433	2.0195	1.2955	2.2862	2.0957	1.6194
Max	2.4006	2.3243	2.0957	2.7435	2.7435	2.4768	2.5149
Min	1.448	1.5623	1.2193	1.2955	1.6004	1.6004	1.5623
Avg	1.9376	1.9735	1.6194	1.8522	2.1568	2.0576	1.9875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 207 / 11 KV UJALAIWADI VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2477	.2667	.2286	.2286	.3048	.743
2	.2286	.2286	.2477	.2286	.2286	.2858	.743
3	.2286	.2286	.2286	.2096	.2667	.2858	.7621
4	.2477	.2477	.2477	.2096	.3048	.2858	.743
5	.3429	.2858	.2477	.2286	.3429	.3239	.8573
6	.362	.3239	.3429	.381	.381	.4572	1.0288
7	.4954	.4382	.4382	.4572	.4572	.5906	1.3527
8	.4382	.4191	.4382	.4382	.4191	.6097	1.3717
9		.381	.381	.381	.4191	.5335	1.3336
10		.3429	.381	.4382	.4001	.5144	1.3146
11		.381		.4001	.381		1.3527
12	.4572	.362		.4382	.4954		1.2193
13	.4001	.4001	.2286	.4001	.4954	1.105	1.1622
14	.362	.362	.2286	.3239	.4572		1.0288
15		.3239	.2096	.3429	.381		
16	.3429	.3239	.2286	.381	.4382	1.0479	
17	.362	.362	.2477		.5144	1.1622	1.2193
18	.3429	.4191	.3239	.381	.5525	1.2193	1.2955
19	.4191	.381	.381	.4572	.5525	1.4289	1.467
20	.4954	.4763	.4001	.4954	.5906	1.5623	.6478
21	.4572	.4191	.4572	.4191	.5525	1.4289	1.448
22	.4001	.381	.362	.362	.4954		1.2955
23	.3239	.3239	.2858	.2858	.3429		1.0288
24	.2477	.2477	.2858	.2286	.2286	.3239	.8002
Max	.4954	.4763	.4572	.4954	.5906	1.5623	1.467
Min	.2286	.2286	.2096	.2096	.2286	.2858	.6478
Avg	.3601	.3461	.3118	.3529	.4136	.7483	1.1007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 208 / KANERI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.4954	.6478	.0572	.0572	.0762	.0572
2	.6859	.4954	.6287	.0572	.0572	.0762	.0572
3	.6859	.5144	.6287	.0572	.0572	.0762	.0572
4		.5335	.6287	.0572	.0572	.0762	.0762
5	.1334	.5716	.6287	.0572	.0762	.0953	.0762
6	.1334	.5906	.7621	.0572	.0762	.1143	.0762
7	.2667	.8383	.8764	.0953	.0762	.0953	.0762
8	.0191	.0953	.1143	.0762	.0572	.1143	.0762
9		.0953	.9717	.7811	.5335	.5525	.0762
10		.0762	.9907	.7621	.5144	.5525	.0572
11		.0572		.7049	.5525		.0762
12	.0953			.6287	.4954		.0572
13	.1143	.0191	1.1431	.5525	.4763	.4001	.0762
14	.1715	.0191	.9145	.5525	.4382		.0381
15		.0762	.8383	.5525	.4382		
16	.1715	.0762	.8954	.5335	.4572	.4763	
17	.1715	.0191	.0762		.0572	.0762	.0762
18	.1715	.1143	.0953	.0953	.0762	.0953	.0762
19	.1524	.1334	.0953	.0762	.0953	.0762	
20	.1905	.1334	.0762	.0762	.1143	.0762	.0572
21	.2096	.1143	.0572	.0762	.0953	.0762	.0572
22	.7621	.6859	.0953	.0572	.0953		.3429
23	.5335	.6668	.0762	.0572	.0762		.2858
24	.6859	.4954	.6668	.0572	.0572	.0762	.0572
Max	.7621	.8383	1.1431	.7811	.5525	.5525	.3429
Min	.0191	.0191	.0572	.0572	.0572	.0762	.0381
Avg	.3179	.3007	.5413	.2643	.2120	.1768	.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 209 / UJALAIWADI SHETI PUMP

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.0381	.3429	.2286	.1715	.0953
2	.0381	.0381	.0381	.3239	.2286	.1715	.0953
3	.0381	.0381	.0381	.3239	.2286	.1715	.0953
4	.0572	.0381	.0381	.3429	.2096	.1715	.0953
5	.0572	.0381	.0381	.3429	.2286	.1715	.0953
6	.0572	.0381	.0381	.4001	.2286	.1715	.1143
7	.0572	.0572	.0381	.4763	.3239	.2667	.1524
8	.0572	.0381	.0572	.0381	.0572	.0381	.0381
9		.6097	.0381	.0381	.0381	.0381	.0381
10		.6859	.0381	.0381	.0191	.0381	.1715
11		.7811		.0381	.0191		.1715
12	.724	.8192			.0191		.2096
13	.743	.8954	.0381	.0381	.0191	.0381	.1715
14	.7621	.8002	.0381	.0191	.0191		.1715
15		.8192	.0191	.0191	.0191		.2286
16	.5906	.8002	.0381	.0191	.0191	.0191	.2286
17	.0381	.0381	.0381		.0191	.0191	.0191
18	.0381	.0191	.0381	.0381	.0191	.0381	.0191
19	.0381	.0381	.0381	.0381	.0191		.0191
20	.0572	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0572	.0381	.4001	.2477	.1905		.0191
23	.0381	.0381	.362	.2286	.1905		.0191
24	.0572	.0381	.0381	.3429	.2286	.1715	.0953
Max	.7621	.8954	.4001	.4763	.3239	.2667	.2286
Min	.0381	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.1801	.2842	.0693	.1715	.1104	.1042	.1016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 201 / 11KV Randeviwadi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)
1		.0486
2		.0324
3		.0324
4		.0486
5		.0486
6		.0648
7		.0648
8		.0486
9		.4372
11	.0324	
12	.0324	
13	.0324	
14	.0324	
15	.0324	
16	.0324	
17	.0324	
18	.0324	
19	.0486	
20	.0486	
21	.0486	
24		.0486
Max	.0486	.4372
Min	.0324	.0324
Avg	.0368	.0875

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 202 / M Sangaon Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.6516	.4858	.4527	.5068	.4858
2	.4887	.6154	.4372	.4527	.5068	.4534
3	.4887	.6154	.4372	.415	.5068	.4534
4	.543	.6335	.4858	.5093	.5068	.4858
5	.7059	.6516	.583	.6979	.5249	.5344
6	.7602	.6697	.7287	.9808	.7059	.6154
7	.9231	.905	.7287	1.0829	.905	.8097
8	.8145	.8326	.6316	.9425	.724	.7287
9	.6878	.724	.6316	.8501	.724	.583
10	.6516	.6335	.583	.6908	.6878	
11	.6516	.583		.7619	.5506	.7207
12	.5068	.4372		.7619	.5992	.439
13	.5068	.5344		.7164	.5506	.6036
14	.5611	.5344		.6516	.502	.7095
15	.543	.5344		.4938	.502	.4527
16	.5973	.5506		.5121	.502	.6468
17	.6878	.6802		.724	.6478	.7207
18	.7602	.6316		.7442	.6478	.7964
19	.6878	.6316	1.1317	.8059	.6802	.9795
20	.724	.6802	1.1203	.9036	.8259	.9431
21	.7421		.9619		.7773	.8865
22	.724	.6802	.7545			.8865
23	.7059	.583	.7545			.6602
24	.5973	.6697	.5344	.679	.5249	.5344
Max	.9231	.905	1.1317	1.0829	.905	.9795
Min	.4887	.4372	.4372	.415	.502	.439
Avg	.6501	.6375	.6869	.7061	.6186	.6578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 203 / Sulkud AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.6697	.0324	.0492	.0381	.1457
2	.6173	.6516	.0324	.0457	.0381	.1457
3	.6173	.6697	.0324	.0457	.0381	.1457
4	.6687	.6878	.0324	.0457	.0381	.1457
5	.6859	.724	.0486	.0625	.0381	.1781
6	.7716	.7964	.0486	.064	.0381	.1943
7	.8402	1.0317	.081	.0838	.0572	.1943
8	.0762	.0905	.0486	.0452	.0381	.0486
9	.0572	.0724	1.2308	1.2163	.3048	.0162
10			1.4413	.9762	.2896	
11	.0754	.0648		1.0288	.2105	.0183
12	.0754	.0648		1.0682	.1619	.0351
13	.0943	.0486	.0914	1.0802	.1457	.0324
14	.0566	.0486	.0892	1.0288	.1457	.0305
15		.0486	.0892	.8842	.1457	.0312
16	.0754	.0486	.088	.7888	.1457	.029
17	.0754	.0486	.0377	.0566	.0324	.0305
18	.0754	.0486	.0594	.0754	.0486	.0335
19	.0754	.0648	.064	.0754	.0324	.0543
20	.0943	.0648	.064	.0754	.0486	.0351
21	.0943	.0648	.0648		.0324	.104
22	.7059	.0648	.0457			.0914
23	.6878		.0446			.0892
24	.6687	.6878	.0486	.0497	.0362	.1457
Max	.8402	1.0317	1.4413	1.2163	.3048	.1943
Min	.0566	.0486	.0324	.0452	.0324	.0162
Avg	.3572	.3074	.1734	.4212	.0956	.0858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 204 / 11 KV LINGNOOR (VG)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0648	.0514	.0572	.0486
2	.0566	.0377	.0648	.0514	.0572	.0486
3	.0566	.0377	.0648	.0514	.0572	.0486
4	.0566	.0377	.0648	.0514	.0572	.0486
5	.0943	.0566	.0972	.0857	.0762	.0648
6	.1132	.0943	.0972	.0857	.0953	.0972
7	.0943	.132	.1134	.12	.132	.0972
8	.1132	.132	.0972	.112	.1448	.0972
9	.0754	.0905	.081	.0934	.1086	.081
10		.0943	.0648	.0934	.0905	
11	.0754	.081		.0566	.081	.0914
12	.0754	.081		.0566	.081	.0724
13	.0754	.0486	.0549	.0566	.0486	.0732
14	.0754	.0486		.0566	.0486	.0732
15		.0486	.0532	.0566	.0486	.0724
16	.0377	.0486	.0566	.0566	.0486	.0724
17	.0943	.0486	.0754	.0566	.0648	.0739
18	.0943	.0486	.0924	.0943	.0972	.0754
19	.0754	.081	.0943	.1494	.1134	.1307
20	.1509	.1296	.1509	.1494	.1457	.1698
21	.1509	.1296	.1509		.1134	.1698
22	.1132	.1296	.1132			.1132
23	.0943	.0972	.0566			.0566
24	.0566	.0943	.0972	.0514	.0762	.0486
Max	.1509	.132	.1509	.1494	.1457	.1698
Min	.0377	.0377	.0532	.0514	.0486	.0486
Avg	.0857	.0785	.0860	.0779	.0838	.0837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 201 / 11KV Arya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.5242	1.7147	.1231	1.6221	1.094	1.7177
2	1.3336	1.5655	1.7147	.14	1.419	1.0517	1.6991
3	1.448	1.448	1.6575	.1555	1.5242	1.0117	1.7541
4	1.448	1.4712	1.6575	.1684	1.6385	.9882	1.6804
5	1.5051	1.4335	1.6385	.1934	1.5623	.9724	1.6448
6	1.848	1.3717	1.6575	.2115	1.5844	.9555	1.6632
7	1.6004	1.3336	.8002	.2185	1.5813	1.4998	1.166
8	1.0479	1.1431	.7811	.6493	1.2071	.9979	.7926
9	2.3624	1.1431	.6859	1.386	1.6244	.8764	1.307
10		1.7337	.2578	1.5684	2.6139	1.4861	1.2696
11		1.7718		1.1458	2.838		2.1658
12	2.3624	1.829			1.7177		2.2405
13	2.2862	1.6004	.1707		1.7353	2.0767	1.8671
14	1.8861	1.7528	.16	1.448	1.7924		
15		1.848	.1494	1.3817	1.8861		1.2696
16	1.848	2.5149	.1713	.5487	1.1088	2.0005	1.3443
17	2.2862	1.9624	.1989		2.1879	1.9052	1.307
18	1.7528	2.0005	.1943	.9896	1.8861	1.5242	1.8671
19	1.7528	1.8671	.1524	.8223	1.9616	.6859	2.0005
20	2.0957	1.848	.2134	1.3336	1.8484	1.3121	1.3527
21	1.6766	1.4289	.2	.9511	1.7918	1.595	
22	2.0005	1.7718		1.9814	1.7918		
23	1.9814	1.9433	.1814	1.6461	1.4998		1.9433
24	1.3146	1.6385	1.8099	.1768	1.7528	1.0562	1.5023
Max	2.3624	2.5149	1.8099	1.9814	2.838	2.0767	2.2405
Min	1.0479	1.1431	.1494	.1231	1.1088	.6859	.7926
Avg	1.7700	1.6644	.7699	.8209	1.7573	1.2828	1.5978

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 202 / 11 KV Managal Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4424	.3384	.1905	.3467	.5194	.6192
2	.4477	.3765	.3582	.2429	.3467	.4557	.6607
3	.4567	.3239	.2686	.1905	.3498	.5171	.6967
4	.4858	.3475	.2926	.2138	.3048	.5121	.6142
5	.5251	.3467	.2103	.2477	.2972	.5373	.6628
6	.5251	.3048	.3067	.2818	.3048	.5213	.6001
7	.815	.5548	.1867	.4746	.2987	.7255	.4477
8	.9976	.7442	.1943	.6741	.8299	.5415	.4847
9	1.07	1.1174	.1524	1.078	1.419	1.21	1.1822
10		1.828	.181	1.1934	1.4937	1.9936	1.8671
11		1.773		1.3546	1.7924		2.1658
12	2.0144	1.6655			1.643		1.9418
13	1.3426	1.1574			1.6289	1.6787	1.5684
14	1.3523	1.3203		1.4563	1.6095		1.643
15		1.6118		1.6478	1.5565		1.531
16	1.7556	1.2717	.1684	1.773		1.8823	1.4937
17	1.5074	1.6301	.1852				1.3443
18	1.3108	.9181	.1263	1.0059	.9389		1.5684
19	1.186	.7531	.1738	.7659	1.3321	.7573	1.3413
20	1.0936	.9095	.1288	.381	1.0802	.5761	1.0364
21	.8387	.8459	.1652	.4161	.4755	.8768	
22	.9288	.8135		.362	.7756		
23	.4001	.8318	.1429	.2675	.4755		.8833
24	.515	.4755	.439	.1214	.3048	.3772	.743
Max	2.0144	1.828	.439	1.773	1.7924	1.9936	2.1658
Min	.4001	.3048	.1263	.1214	.2972	.3772	.4477
Avg	.9522	.9318	.2233	.6828	.8911	.8551	1.1407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 203 / 11 KV KORGAONKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.6413	.4954	.4681	.5487	.4755	.6535
2	.9526	.6097	.5335	.4508	.543	.4656	.6516
3	.8954	.5601	.5335	.4458	.5121	.4334	.6584
4	.8954	.5601	.5144	.4239	.4854	.4557	.6154
5	.8002	.5281	.5144	.4607	.4572	.4784	.5552
6	.9526	.5544	.5525	.4191	.4715	.4887	.4755
7	1.0098	.5281	.5716	.4805	.5281	.4733	.4706
8	1.2765	.5335	.7049	.543	.7167	.5434	.6268
9		.4854	.6287	.6516	.6908	.6478	.6697
10		.5335	.8326	.7468	.7095	.8573	.7842
11		.5716		.8238	.7095		.8962
12	.8002	.5716	.5609		.7095		.7468
13	.8002	.5525	.691		.7545	.724	.7842
14	.8383	.5335	.7316	.8676	.7095		.8402
15		.4954	.7421	.8299	.7545		.8402
16	.743	.5716	.7011	.7922	.7922	.8764	.7842
17	.7811	.5335	***		.8215	.6097	.7842
18	.6535	.4954	.631	.6615	.6653	.6859	.6722
19	.7049	.5144	.5731	.6154	.6335	.6516	.6287
20	.6668	.7049	.567	.6602	.6219	.6516	.6097
21	.5601	.724	.5138	.5716	.5487	.5973	
22	.7621	.6859		.6154	.5973		
23	.7095	.5335	.4858	.5731	.5138		.6478
24	1.0288	.6413	.5335	.4961	.5716	.4887	.6447
Max	1.2765	.724	10.7019	.8676	.8215	.8764	.8962
Min	.5601	.4854	.4858	.4191	.4572	.4334	.4706
Avg	.8392	.5693	1.0597	.5999	.6278	.5891	.6836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 204 / 11 KV Silver Zone

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.0957	2.2291	1.7318	1.9624	1.7295	1.7857
2	2.1719	1.8861	2.2291	1.7337	1.6221	1.7703	1.7318
3	2.0767	1.9814	2.0957	1.7541	1.8858	1.7896	1.7295
4	2.0005	1.9433	1.9624	1.7684	1.9052	1.668	1.7269
5	1.9433	1.9052	1.8671	1.7896	2.0005	1.5741	1.6575
6	2.0957	1.9052	1.829	1.7164	1.9814	1.6194	1.6876
7	2.0386	1.9243	1.9433	1.5278	1.8298	1.8461	1.8004
8	2.0957	2.0195	2.0005	1.6518	1.9814	1.7974	1.7604
9		2.21	1.9433	2.3529	2.4832	2.4196	2.347
10		2.6292	1.7974	2.7244	3.0807	2.8959	3.1741
11		2.6673		3.5437	3.3951		3.5475
12	3.4294	2.9721			3.1367		3.3608
13	3.2579	2.5149			3.0556	3.0293	3.3608
14	3.2388	2.8387		3.2007	3.0178		3.2861
15		3.0102		3.2769	3.0178		3.3608
16	3.4294	2.6673	1.2631	2.9874		3.4484	3.3234
17	3.1626	2.8578	1.2597				3.3608
18	2.5149	2.553	1.166	2.934	2.1125		2.4646
19	2.4196	2.4958	1.5912	2.5911	2.6513	2.4709	2.6863
20	2.4387	2.3053	1.6221	2.572	2.6217	2.2177	2.4768
21	2.2862	2.6101	1.6842	2.2862	2.1216	2.0953	
22	2.21	2.9912		2.7054			
23	2.2862	2.8769	1.6933	2.0957	2.0271		2.21
24	2.0957	2.1719	2.3815	1.6956	1.9814	1.922	1.8229
Max	3.4294	3.0102	2.3815	3.5437	3.3951	3.4484	3.5475
Min	1.9433	1.8861	1.166	1.5278	1.6221	1.5741	1.6575
Avg	2.4644	2.4180	1.8088	2.3162	2.3748	2.1433	2.4846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 205 / 11 kV VILSON ROOFING
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0483	3.7723	4.0771	2.0178	3.7342	4.1118	3.942
2	3.0483	3.6591	4.0009	2.0687	4.0741	4.1076	4.1495
3	3.1055	3.4294	4.0009	2.0957	3.9628	4.0929	4.2105
4	3.1055	3.5437	4.0771	2.1033	3.9956	4.1684	4.2816
5	3.1245	3.4865	3.9628	2.1085	3.9609	4.0741	4.1684
6	3.9057	3.658	3.5056	2.073	4.0962	4.0175	4.1396
7	4.8964	4.382	3.2388	2.4691	3.8666	3.7912	4.5456
8	4.2486	3.5056	3.2007	2.9264	3.4675	3.8104	3.1855
9	5.4298	4.6677	2.6863	3.006	5.0412	4.5153	3.9986
10		4.9726	2.4188	4.3381	4.0329	4.8202	4.481
11		5.2584		3.2156	4.3317		3.8836
12	4.9154	5.1821	2.5943		5.2279		4.0329
13	3.8676	3.5246	.8322		5.0926	4.5725	3.8836
14	3.9247	4.1152	2.5549	5.2012	5.1821		4.3317
15		4.9345	2.2436	5.1059	5.168		4.2943
16	4.0962	4.6296	2.3137	4.0009	4.2627	3.9628	4.1076
17	3.2388	4.8773	2.332		4.6776	3.5056	4.0329
18	4.0741	5.0297	2.3148	3.8104	3.7723	4.2676	4.1823
19	4.0581	4.3058	2.3838	4.5725	4.3193	.7716	4.02
20	3.1436	3.9628	1.8755	3.5056	3.5271	4.2061	3.8485
21	3.0483	3.7723	2.0748	3.1436	3.0744	3.271	
22	4.0009	4.4391		3.5056	4.0741		
23	4.4201	4.5344	2.1879	3.8104	3.9209		3.8485
24	3.1436	4.0009	4.0581	2.1874	2.8578	3.8855	3.3653
Max	5.4298	5.2584	4.0771	5.2012	5.2279	4.8202	4.5456
Min	3.0483	3.4294	.8322	2.0178	2.8578	.7716	3.1855
Avg	3.8021	4.2352	2.8607	3.2031	4.1550	3.8862	4.0424

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 206 / 11KV Mahalaxmi

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.8107	1.1431	.2835	1.6194	1.1904	1.4998
2	1.6004	1.9243	1.0479	.3267	1.8107	1.1142	1.3969
3	1.6004	1.9814	1.0479	.362	1.9624	1.1934	1.386
4	1.848	2.0351	.9526	.3267	2.0957	1.0648	1.3565
5	1.9624	1.9427	.8954	.3715	2.0005	1.0936	1.3176
6	2.0386	2.0576	1.3146	.3498	2.0576	1.0974	1.2174
7	2.0386	1.4861	1.3908	.5857	1.8671	1.9753	1.166
8	.8573	1.3717	.8573	.5746	1.2384	.4611	1.0059
9	1.9433	2.0576	.9526	1.0923	2.0538	2.8959	2.371
10		3.4103	.2195	2.1285	2.9874	3.0293	1.8671
11		3.4294		1.922	3.0994		3.8836
12	2.553	2.1719			2.838		1.9605
13	2.7625	2.3053			2.8292	2.0386	2.3152
14	2.0957	2.6482		2.5911	2.7538		3.5848
15		3.0864		2.7054	2.7633		2.7633
16	2.934	1.7337	.218	1.9052		1.3146	2.6139
17	2.4768	1.5051	.208				2.2405
18	2.0005	1.086	.2138	1.9433	.2401		2.0911
19	2.0576	1.3527	.1829	2.0576	1.8111	1.2209	2.0767
20	1.2574	2.7244	.2241	2.1338	.6984	1.885	2.2291
21	1.2574	2.5911	.2953	2.191	1.3375	2.6972	
22	1.2765	1.8671		2.2862			
23	1.7147	1.467	.2707	2.0576	.9328		1.3717
24	.8573	1.6004	1.1241	.2686	1.4289	.5658	.7499
Max	2.934	3.4294	1.3908	2.7054	3.0994	3.0293	3.8836
Min	.8573	1.086	.1829	.2686	.2401	.4611	.7499
Avg	1.8372	2.0686	.6977	1.3554	1.9250	1.5523	1.9302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 201 / 11 KV Vardhaman Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.1338	2.0195	1.3717	2.2862	2.2862	2.4768
2	2.0957	1.9052	2.1338	1.4098	2.4768	2.3624	2.2862
3	1.9052	1.7909	1.9814	1.5623	1.7147	2.0957	2.0957
4	2.1338	1.9433	2.0957	1.5242	1.7528	1.9052	1.6194
5		1.9433	1.9433	1.3717	1.8099	1.7147	2.0957
6	1.6004	2.1719	1.9814	1.3717	1.8099	1.6385	2.3815
7	1.6194	2.1529	1.9433	1.6766	2.1338	1.7147	1.6766
8	1.9052	2.1338	1.6004	1.5623	1.6004	1.8671	1.5242
9		2.4768	1.4098	2.1719	1.7147	2.6673	2.2291
10		2.4768	1.3717	2.6292	1.829	2.8006	
11		2.7054		2.7435	2.0957		2.8959
12	2.553	2.3624			2.553		2.8197
13	2.2862	2.553	1.3908		2.6673	2.191	2.5911
14	2.6673	2.6673	1.4098	2.2862	2.8578	2.7244	2.4387
15		2.8578		2.0005	2.5911	2.7244	2.4196
16	2.6863	2.4768		2.4768	2.4768	2.572	1.8671
17	2.3434	2.0957	1.3717		2.4387	2.3815	2.0767
18	2.2481	1.9814	1.3717	2.191	2.3624	2.191	2.0767
19	2.21	2.3243	1.4098	1.9433	2.3243		1.9624
20	2.0386	2.0957	1.3717	1.3336	2.2862	2.0005	1.2955
21	1.9433	1.9052		2.5149	2.0957	2.1338	2.1338
22	1.9052	1.9814		2.2481	1.9052	2.6673	2.6673
23	2.3624	2.0195	1.3527	2.0957			2.6673
24	2.21	2.191	2.0957	1.3717	2.6673	2.4768	2.5339
Max	2.6863	2.8578	2.1338	2.7435	2.8578	2.8006	2.8959
Min	1.6004	1.7909	1.3527	1.3336	1.6004	1.6385	1.2955
Avg	2.1479	2.2227	1.6808	1.8979	2.1935	2.2558	2.2100

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 202 / 11 KV Mather & Platt
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.2574	1.2955	1.2955	1.2193	1.2574	1.2384
2	1.1431	1.2765	1.3336	1.2955	1.2384	1.3336	1.1431
3	1.1812	1.2765	1.2193	1.2955	1.1431	1.2574	1.1812
4	1.2384	1.2955	1.2955	1.3146	1.1431	1.2955	1.1812
5	1.2955	1.2955	1.2955	1.3336	1.1812	1.1812	1.1431
6	1.2384	1.2574	1.3336	1.3717	1.3336	1.2193	1.1812
7	1.2765	1.2765	1.3717	1.5242	1.2003	1.3336	1.2955
8	1.2955	1.2574	1.4098	1.5242	1.2955	1.448	1.3336
9	1.6004	1.3717	1.4098	1.6004	1.3336	1.448	1.9052
10		1.5242	1.3527	1.7528	1.7909	1.7147	
11		1.7147		1.7528	1.7147		2.0386
12	1.8099	1.4098			1.3717		1.0479
13	1.7528	1.448	1.3336		1.6385	1.6194	1.8099
14	1.5432	1.5242		1.6766	1.7147		1.9433
15		1.5623		1.8099	1.8671	1.829	
16	1.7909	1.4861		1.7147	1.7147	1.829	2.0957
17	1.467	1.4861	1.2955		1.6385	1.4861	1.8671
18	1.5051	1.448	1.2955	1.4098	1.4861	1.448	1.5813
19	1.448	1.4861	1.2955	1.4289	1.4098		1.448
20	1.2574	1.4098	1.3146	1.2384	1.3336	1.3717	1.2955
21	1.2574	1.3336		1.2574	1.2955	1.1622	1.2574
22	1.2574	1.2955		1.2955	1.3336	1.2384	1.3336
23	1.3336	1.3336	1.3146	1.2384			1.4289
24	1.2574	1.2384	1.2574	1.3146	1.2193	1.2955	1.2384
Max	1.8099	1.7147	1.4098	1.8099	1.8671	1.829	2.0957
Min	1.1431	1.2384	1.2193	1.2384	1.1431	1.1622	1.0479
Avg	1.3899	1.3860	1.3190	1.4498	1.4181	1.4088	1.4540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 204 / Tamgoan VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8764	1.0288	.9145	.8573	.8764	.2286
2	.8002	.8573	.8764	.8764	.8764	.8383	.2096
3	.8573	.8573	.8383	.8573	.7621	.8383	.2286
4	.8573	.9145	.8383		.9145	.9526	.2286
5	.8573	.9526	.9907	.8573	.9907	.9526	.2477
6	1.1431	1.0288	1.1812	1.105	.9526	.9907	.3429
7	1.3336	1.3717	1.3336	1.2765	1.1812	1.1431	.4763
8	1.3908	1.448	1.3717	1.1812	1.0479	1.4098	.4001
9	1.4098	1.4098	1.4098	1.1622		1.3717	.4001
10		1.3717	1.105	1.1431		1.3717	
11		1.2955		1.1431			.4001
12	1.2384	1.2193			1.4098		.4191
13	1.1431	1.1812	.724		1.1431		.3429
14	1.086	1.1431	.7811	1.1431	1.105	.381	.362
15		1.0669		1.0479	1.0669	.4572	.6478
16	1.1431	.9907		1.0479	1.1431	.4191	.6668
17	1.2574	1.1812	.8954		1.2193	.4382	.6859
18	1.3717	1.105	1.105	1.4289	1.3717	.5716	.7049
19	1.4098	1.448	1.2955	1.5242	1.5623		.743
20	1.6766	1.5623	1.3908	1.6004	1.5242	.5716	.724
21	1.4098	1.4098		1.467	1.4098	.4572	.6668
22	1.3336	1.3717		1.2765	1.0288	.4763	.6097
23	1.0479	1.1431	1.0098	.9907	1.0669		.4954
24	.9145	.8764	1.0669	.9526	.8383	.9526	.2286
Max	1.6766	1.5623	1.4098	1.6004	1.5623	1.4098	.743
Min	.8002	.8573	.724	.8573	.7621	.381	.2096
Avg	1.1685	1.1701	1.0690	1.1498	1.1177	.8142	.4548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 205 / 11 KV Patel Petro feeder SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	1.0288	.9907	.724	.6478	.8764	.9145
2	.6668	.9907	.9145	.743	.6668	.724	.8764
3	.7621	.8002	.8383	.7621	.6668	.6859	.9145
4	.7621	.7621	.8764	.7621	.6478	.6859	.9526
5	.7811	.7621	.7621	.7621	.6668	.9145	.7621
6	.7621	.743	.6478	.7621	.7049	.9526	.724
7	.8383	.9335	.6097	.743	.7049	.8764	1.0479
8	1.4289	.9335	.6478	.7621	.8573	.7621	1.1812
9	2.0957	1.5623	.6478	1.7337		1.6004	1.9433
10		1.3336	.6668	1.7147	1.9814	1.5813	
11		1.2574		2.191	1.9052		2.3815
12	1.848	2.0957			1.7147		1.7909
13	1.4861	1.4861			1.7909	1.9624	1.105
14	2.1529	1.7147	.6668	1.7528	1.829	1.7147	1.3908
15		2.1719		2.2481	1.7147	1.7718	2.1719
16	2.21	2.1338		2.191	1.4098		1.7147
17	1.2193	1.4861	.6668		1.1431	1.5242	1.448
18	1.0669	.9526	.6478	.9907	.9907	.9145	1.0098
19	.9526	.8764	.6478	.9526	.9145		.8954
20	.8573	.724	.6668	.6668		.6668	.7049
21	.7049	.6859		.6668	.6478	.6668	.6287
22	.6859	.6478		.6668	.9526	.6478	.5716
23	.743	.6097	.724	1.0479	1.0669		.9717
24	.6668	1.0098	1.105	.724	.6287	.9145	.9526
Max	2.21	2.1719	1.105	2.2481	1.9814	1.9624	2.3815
Min	.6668	.6097	.6097	.6668	.6287	.6478	.5716
Avg	1.1123	1.1542	.7486	1.1223	1.1024	1.0759	1.1763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 206 / 11KV Devi gas

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.448	.8764	.7811	1.1431	1.105	1.2003
2	1.2384	1.448	.8383	.7811	1.2193	1.0669	1.105
3	1.1431	1.2955	.9145	.9907	1.1431	1.0288	1.0479
4	.9907	1.2955	.8764	.9526	1.105	1.105	.9526
5	1.2003	1.2574	.8383	1.0288	1.0479	1.0669	.9526
6	1.3336	1.2574	.8764	.9907	1.0479	.9907	.8764
7	1.6194	1.1431	.8764	.9717	1.467	1.0288	1.3336
8	1.6194	1.4289	.8002	.9526		1.105	1.4289
9	1.4861	1.6385	.8383	1.0288		1.2955	1.1812
10		1.5623	.8192	1.7909		1.4861	
11		1.5242		1.5242			1.1431
12	1.8099	1.829			1.9052		1.6385
13	1.7909	1.7147	.8002		1.829		1.8671
14	2.0195	1.5623	.7621	1.5623	1.7909	1.6575	1.8671
15		1.448		1.6194	1.7147	1.7909	1.7909
16	1.4098	1.829		1.5623	1.7909		1.4861
17	1.2574	1.6004	.7811		1.829	1.5813	1.448
18	1.5813	1.3717	.7621	1.5242	1.8671	1.4861	1.4861
19	1.1431	1.2574	.8002	1.5242	1.3717		1.5623
20	1.5242	.9907	.7811	1.4289	1.1431	1.4289	1.3336
21	1.3717	.9145		.9526	.8764	1.0098	1.2574
22	1.2955	.9145		1.5242	1.1812	1.086	1.1431
23	1.5242	.9526	.7621	1.4098	1.3336		1.3146
24	1.4098	1.4861	.9145	.7621	1.1431	1.1431	1.2384
Max	2.0195	1.829	.9145	1.7909	1.9052	1.7909	1.8671
Min	.9907	.9145	.7621	.7621	.8764	.9907	.8764
Avg	1.4380	1.3821	.8288	1.2221	1.3975	1.2479	1.3328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 201 / Mhakve AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.117	.12		.0381		
2	.117	.12		.0381	.0381	.0343
3	.116	.12		.0381	.0381	.0343
4	.1492	.12		.0381	.0381	.0343
5	.1492	.1372		.0381	.0381	.0343
6	.1989	.1543		.0381	.0381	.0514
7	.2652	.2401		.0381	.0572	.0343
8	.0497	.0514		.0381	.0572	
9		.0514			.0762	.0497
10		.0343			.0686	.0332
11		.0343	.0499	.1143	.0514	.0332
12	.0381	.0343	.0497			.0332
13	.0572	.0343			.0514	.0497
14		.0343		.1143	.0514	.0332
15		.0343		.1143	.0514	.0332
16		.0343		.0762	.0857	.0497
17	.0572	.0514		.4191	.0343	.0332
18	.0381	.0514		.0572	.0343	.0332
19		.0514			.0343	.0332
20	.0381	.0514		.0572	.0514	.0497
21	.0381	.0514		.0572	.0514	.0497
22	.1524			.0572	.0514	.0332
23	.1524	.0514		.0381	.0514	.0332
24	.116	.1372		.0381	.0381	.0343
Max	.2652	.2401	.0499	.4191	.0857	.0514
Min	.0381	.0343	.0497	.0381	.0343	.0332
Avg	.1088	.0783	.0498	.0762	.0494	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 202 / Mhakve Gavthan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1867	.1867	.2033	.2096	.1905	
2	.1848	.1867	.1867	.1848	.2096		
3	.1848	.1867	.1867	.1848	.2096	.1905	.1867
4	.1848	.1867	.1867	.1848	.2286	.1905	.1867
5	.2402	.2054	.2054	.2218	.3048		.2427
6	.3326	.2987	.2987	.3511	.362	.3429	.2987
7	.3149	.3547		.3511	.381	.362	.1867
8	.3326	.3174	.3361	.3696	.362	.3239	
9		.3174	.3142	.3511	.381	.3048	.2801
10		.3174	.2772	.3326	.3239		.2801
11		.2801		.2957	.2858		.2801
12	.2667	.2614					.2241
13	.2477	.2427			.1905		.1867
14		.2614			.1905		.2241
15					.1905		.2241
16		.2347			.362		.2241
17	.3048	.2987					.2801
18	.381	.3174					.3174
19		.3734			.4001		.4108
20	.4954	.4668	.5544		.4572		.4481
21	.4191	.4294	.499		.4382		.4294
22	.3429	.3921	.3881		.3239		.3361
23	.2614		.2218		.2286		.2054
24	.2033	.2054	.2054	.2218	.2096	.1905	.2054
Max	.4954	.4668	.5544	.3696	.4572	.362	.4481
Min	.1848	.1867	.1867	.1848	.1905	.1905	.1867
Avg	.2872	.2873	.2891	.2710	.2976	.2620	.2694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 203 / Kenavade Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0514	.1715	.0983	.0572	.0572	.0343
2	.0328	.0514	.1715	.0983	.0572	.0572	.0343
3	.0328	.0514	.1715	.0983	.0572	.0572	.0343
4	.0328	.0514	.1715	.0983	.0762	.0572	.0343
5	.0492	.0514	.1715	.1147	.0762	.0762	.0343
6	.0655	.0686	.1715	.1638	.1143	.1143	
7	.0819	.0747	.3086	.2458	.1715	.1334	.0514
8	.0655	.0686	.0686	.0655	.0572		
9		.583	.0655	.0655	.0572	.0572	.0983
10		.583		.0492	.0572	.0343	.1311
11		.6001		.0492	.0572	.0343	.0983
12	.7049	.5487				.0343	.0819
13	.743	.6687			.0381	.0343	.0819
14		.6344			.0381	.0343	.0492
15		.6344			.0381	.0343	.0492
16		.5487			.0572	.0343	.0819
17	.0762	.0514			.0572	.0343	.0492
18	.0762	.0514	.0819		.0381	.0343	.0492
19		.0514	.0819			.0343	.0328
20	.0762	.0514	.0655		.0381	.0343	.0328
21	.0762	.0514	.0492		.0572	.0343	.0328
22	.0572	.2229	.0983		.0572	.0343	.0328
23	.0514	.1886	.0983		.0572	.0343	.0328
24	.0328	.0514	.1886	.0983	.0762	.0572	.0343
Max	.743	.6687	.3086	.2458	.1715	.1334	.1311
Min	.0328	.0514	.0492	.0492	.0381	.0343	.0328
Avg	.1346	.2496	.1335	.1038	.0632	.0499	.0542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 201 / 11KV KAPASHI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2858	.0381	.0572	
2	.2286	.2667	.0381	.0572	
3	.2096		.0381	.0381	
4	.1905	.2477	.0381	.0381	
5	.2096	.2477	.0381	.0381	
6	.2477	.3048	.0381	.0572	
7	.3239	.3429	.0381	.0572	
8	.0381	.0381		.0572	
9	.0381	.0381	.6478	.4001	
10	.0381	.0572	.724	.3429	
11	.0381	.0381	.7621	.3048	
12	.0572	.0381	.6859	.3429	
13	.0572	.0381		.3429	
14	.0572	.0381		.3239	
15	.0572	.0381		.2858	
16	.0572	.0381		.2667	
17	.0572	.0381		.0381	
18	.0572	.0572		.0381	
19	.0572	.0381		.0381	
20	.0572	.0381		.0381	
21			.0572	.0572	
22	.2858	.0381	.0572	.0381	.0381
23	.3048	.0381		.0381	.0381
24	.2477	.2858	.0381	.0572	
Max	.3239	.3429	.7621	.4001	.0381
Min	.0381	.0381	.0381	.0381	.0381
Avg	.1375	.1178	.2314	.1397	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 202 / 11 KV Hasoor Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.5335	.362	.0572	
2	.0572	.0381	.5144	.362	.0572	
3	.0381	.0381	.4954	.3429	.0572	
4	.0381	.0381	.4763	.3429	.0572	.0762
5	.0381	.0381	.4763	.362	.0572	.0762
6	.0572	.0572	.5716	.381	.0572	.0953
7	.0572	.0572	.6097	.381	.0572	.1143
8	.0572	.0762	.0572	.0762	.0572	.0572
9	.8573	.8192	.0572	.0762		.0572
10	.8573	.9145	.0572	.0762		.0381
11	.9145	1.2955	.0572	.0762		.0381
12	.8383	.9145	.0572	.0762	.0381	.0381
13	.8192	.8383	.0762	.0762	.0381	.0381
14	.7621	.9717	.0572	.0762	.0381	.0381
15	.7621	.9526	.0953	.0762	.0381	
16	.7811	.9335	.0953	.0762	.0381	.0381
17	.0762	.0572	.0953	.0762	.0381	.0381
18	.0572	.0572	.0953	.0762	.0381	
19	.0572	.0572	.0572	.0762	.0381	.0381
20	.0572	.0572	.0572		.0572	.0381
21	.0572	.0572	.0572	.0572	.0572	.0572
22		.5716	.4001	.0572	.1905	.0381
23	.0381	.5716		.0572	.0953	.0381
24	.0572	.0381	.5716	.4191	.0572	
Max	.9145	1.2955	.6097	.4191	.1905	.1143
Min	.0381	.0381	.0572	.0572	.0381	.0381
Avg	.3214	.3953	.2444	.1756	.0581	.0529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 203 / 11 KV MUGALI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4382	.0762	.0762	.0762	.0572
2	.381	.4001	.0762	.0762	.0572	.0572
3	.3429	.4001	.0953	.0762	.0572	.0572
4	.3429	.381	.0762	.0762	.0572	.0572
5	.3429	.4001	.0953	.0762	.0762	.0572
6	.381	.4191	.0953	.0953	.0953	.0572
7	.4572	.4572	.0953	.0762	.0953	.0572
8	.0953	.1334	.1143	.1143	.0953	.0572
9	.0762	.0953	.9907	1.105	.381	.2096
10	.0762	.0953	1.1241	.9335	.381	.2096
11	.0572	.0953	1.0669	.8002	.381	.1715
12	.0953	.0953		.7811	.3429	.1524
13	.0953	.0953	1.2003	.7621	.3429	
14	.1334	.1143	1.2765	.724	.3429	
15	.1334	.1143	1.3336	.6478	.3239	
16	.1334	.1143	1.2955	.6097	.3048	
17	.1334	.1143	.0953	.0762	.0572	
18	.1143	.1143	.0953	.0762	.0572	
19	.0953	.1143	.0953	.0762	.0572	.0762
20	.0953	.0762	.0953	.0953	.0762	.0762
21	.0953	.0762	.1143	.0953	.0953	.0572
22	.4572	.0762	.1143	.0762	.0953	.0762
23		.0762		.0762	.0953	.0762
24	.4191	.4763	.0762	.0953	.0762	
Max	.4572	.4763	1.3336	1.105	.381	.2096
Min	.0572	.0762	.0762	.0762	.0572	.0572
Avg	.2162	.2072	.4408	.3207	.1675	.0919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 204 / 11 KV LINGNOOR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.7811	.5144	.2477	.1334
2	.0381	.0381	.743	.4954	.2477	.1143
3	.0381	.0381	.724	.4954	.2096	.1143
4	.0381	.0381	.724	.4763	.2096	.1143
5	.0381	.0381	.743	.4954	.2286	.1143
6	.0381	.0381	.8192	.5144	.381	.1524
7	.0381	.0381	.9526	.6097	.3429	.1715
8	.0381	.0381	.0572	.0572	.0572	.0572
9	.8383	1.0479	.0572	.0572	.0572	.0572
10	.9907	1.3336	.0572	.0572	.0572	.0572
11	.9526	1.3717	.0572	.0572	.0572	.0381
12	.9145	1.1812	.0572	.0572	.0572	.0381
13	.8954	1.3336	.0572	.0572	.0572	.0381
14	.9145	1.4289		.0572	.0572	.0381
15	.8383	1.448	.0381	.0572	.0572	.0381
16	.743	1.3336	.0381	.0572	.0572	.0381
17	.0572	.0572	.0381	.0572	.0572	.0381
18		.0572	.0381	.0572	.0572	
19	.0381	.0572	.0381	.0572	.0572	.0381
20	.0381	.0762	.0381	.0572	.0572	.0381
21	.0381	.0762	.0381	.0572	.0572	.0381
22		.8573	.5716	.3048	.2286	.0572
23	.0381	.0762	.0381	.3048	.2667	.0572
24	.0381	.0381	.8383	.5906	.2858	
Max	.9907	1.448	.9526	.6097	.381	.1715
Min	.0381	.0381	.0381	.0572	.0572	.0381
Avg	.3473	.5033	.3280	.2334	.1437	.0719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 205 / 11 KV Arjunwada Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.0572	.0762	.0381	.0381
2	.2858	.3048	.0572	.0762	.0381	.0381
3	.2667	.2858	.0572	.0762	.0381	.0381
4	.2667	.3048	.0572	.0762	.0381	
5	.2477	.3048	.0572	.0762	.0381	
6	.2858	.3239	.0572	.0953	.0572	
7	.4191	.3429	.0572	.0953	.0572	.0381
8		.0381		.0953	.0572	.0381
9	.0572	.0572	.5525	.4572	.2667	.1524
10	.0762	.0572	.6097	.4191	.1905	.1334
11		.0572	.6097	.381	.1905	.1334
12	.0572	.0572	.724	.2858	.2477	.1334
13	.0572	.0572	.743	.4001	.2286	.1905
14	.0572	.0572	.8002	.381	.1905	.1905
15	.0572	.0762	.8002	.362	.1905	.1905
16	.0762	.0762	.8002	.3429	.1715	.1905
17	.0762	.0762	.0572	.0572	.1715	.0381
18	.0762	.0762	.0572	.0572	.0381	
19	.0762	.0762	.0572	.0572	.0381	.0381
20	.0762	.0572	.0572	.0572	.0381	.0381
21	.0762	.0572		.0572	.0381	.0381
22	.3048	.0572	.1143	.0572	.0762	.1334
23	.3429	.0572		.0381	.0381	.1334
24	.3048	.3429	.0572	.0953	.0381	
Max	.4191	.3429	.8002	.4572	.2667	.1905
Min	.0572	.0381	.0572	.0381	.0381	.0381
Avg	.1749	.1461	.3067	.1739	.1048	.1013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 206 / 11 KV Vadgaon Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2667	.1905	.3048	.1715
2		.2667	.1524	.3048	.1524
3		.2667	.1524	.2858	.1524
4		.2667	.1524	.2858	.1524
5		.3239	.1715	.3048	.1715
6		.3239	.3239	.362	.2858
7		.362	.381	.381	.3429
8		.362	.362	.4001	.362
9	.4191	.381	.381	.4191	.381
10	.3429	.362	.2286	.362	.3239
11	.2477	.2667	.2096	.3048	.2477
12	.2286	.2858	.2096	.2477	.2477
13	.1715	.2477	.1905	.2667	.2286
14	.1524	.2096	.2096	.2477	.2096
15	.1334	.2096		.2286	.1715
16	.1905	.2477	.2096	.2096	.2286
17	.1524	.2667	.2667	.3048	.2667
18	.3429	.3429	.3429	.4001	.381
19	.5335	.4572	.5335	.5716	.4954
20	.6287	.7049	.5906	.6287	.6287
21	.5335	.5906	.5144	.5144	.4001
22	.362	.4001	.4001	.362	.2096
23	.3239	.2477	.362	.2858	
24		.3048	.2096	.3429	.1715
Max	.6287	.7049	.5906	.6287	.6287
Min	.1334	.2096	.1524	.2096	.1524
Avg	.3175	.3318	.2932	.3469	.2775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 207 / 11 KV BALEGHOL GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1143	.1715	.1143	
2		.1715	.1143	.1715	.0953	
3		.1524	.1143	.1524	.0953	
4		.1524	.0953	.1524	.1143	
5		.1715	.1143	.1715	.1143	
6		.1715	.1905	.2096	.0762	
7		.2286	.2286	.2477	.2286	
8		.2286		.3048	.2286	
9	.2477	.2096	.2286	.2667	.2477	
10	.2286	.2286	.2286	.2286	.2286	
11	.1715	.2096	.1715	.1905	.1905	
12	.1334	.1905	.1715	.2096	.1905	
13	.1334	.1715	.1715	.1715	.1905	
14	.1524	.1715	.1524	.1715	.1715	
15	.1524	.1524	.1524	.1715	.1715	
16	.1334	.1715	.1524	.1715	.1905	
17	.1524	.1524	.1715	.2096	.2286	
18	.1905	.1715	.2667	.2667	.3048	
19	.362	.3048	.362	.3429	.3239	
20		.4382	.362	.4191	.4191	
21	.3239	.381	.4001	.3239	.2858	
22	.2477	.2667	.2286	.2286	.2286	
23		.1905	.2096	.1715	.1143	.1905
24		.2096	.1334	.1905	.1143	
Max	.362	.4382	.4001	.4191	.4191	.1905
Min	.1334	.1524	.0953	.1524	.0762	.1905
Avg	.2023	.2112	.1971	.2215	.1945	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 208 / 11 KV JAINAL GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.3048	.4572	.2858	.362
2		.4572	.3048	.4572	.2667	.3429
3		.4001	.2858	.4382	.2667	.3429
4		.4001	.2858	.4382	.2667	.3239
5		.381	.2858	.4572	.2858	.362
6		.4954	.5144	.4954		.5144
7		.5906	.5906	.6287	.1524	.5525
8		.5335	.5716	.6097	.2096	.5525
9	.5716	.5716	.5144	.4763	.2858	.6097
10	.4763	.5144	.4763	.4382	.2667	.5525
11	.5335	.5525	.4572	.4191	.2477	.5335
12	.4763	.4954	.2096	.4382	.2667	.4191
13	.4382	.4954	.2477	.362	.2667	.362
14	.4001	.381	.1905	.2667	.4191	.381
15	.4191	.4191	.3429	.362	.4382	.4001
16	.4382	.4954	.362	.4572	.3429	.5144
17	.5906	.4763		.5335	.5525	.5716
18	.5906	.381	.4954	.6097	.6478	.6478
19	.6859	.6478	.6668	.743	.7811	.7049
20	.8954	.9335	.8192	.8192	.8192	.8383
21	.7621	.8764	.7049	.724		.6859
22	.5716	.5906	.5525	.5525	.5716	
23	.5144	.4001	.5144	.381	.3429	
24		.4954	.3239	.4763	.3239	.362
Max	.8954	.9335	.8192	.8192	.8192	.8383
Min	.4001	.381	.1905	.2667	.1524	.3239
Avg	.5576	.5184	.4357	.5017	.3776	.4971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 209 / 11 KV Madyal Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.5144	.4954	.1905	.0953
2		.0572	.5144	.4572	.1905	.0762
3		.0572	.4572	.4191	.1715	.0762
4		.0572	.4572	.4001	.1715	.0762
5		.0572	.4763	.4001	.1905	.0762
6		.0572	.4954	.4001	.2286	.0953
7		.0762	.5906	.4191	.2477	.1143
8		.0762	.0762	.0762		.0572
9	1.0669	.8954	.0762	.0762		.0572
10	1.0669	1.0098	.0762	.0762		.0572
11	.1143	1.0479	.0762	.0762		.0381
12	1.086	1.105	.0762	.0572		.0381
13	1.0669	1.105	.0762	.0572		.0381
14	.9907	1.0669	.0762	.0572		.0381
15	.9335	1.1241	.0762	.0572		.0381
16	.9145	.9335	.0762	.0572		.0381
17	.0381	.0762	.0762	.0572		.0381
18	.0762	.0762	.0762	.0572		
19	.0762	.0572	.0762	.0572		
20	.0762	.0572	.0762	.0762		.0381
21	.1143	.0572	.0762	.0762		.0381
22	.0572	.6097	.6097	.2667		.0381
23	.0572	.5906	.6478	.2477		.0381
24		.0572	.5716	.6287	.2286	
Max	1.086	1.1241	.6478	.6287	.2477	.1143
Min	.0381	.0572	.0762	.0572	.1715	.0381
Avg	.5157	.4319	.2667	.2104	.2024	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 201 / 11 Kv Sonage Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.016		.0526		.0343	.0171
2	.0171	.016		.0526		.0343	
3	.0171	.0164		.0526		.0343	.0171
4	.0171	.0158		.0526		.0343	.0171
5	.0171	.0162		.052		.0343	.0171
6	.0171	.0162		.052		.0343	.0171
7	.0171	.0164		.052		.0343	.0171
8	.0171	.016	.0171	.0173		.0171	.0175
9	.2058	.1886	.0164	.0171	.0351	.0171	.0362
10		.1886	.016	.0171	.0173	.0171	.0358
11		.2229	.0162	.0171	.0173		.0354
12		.2229			.0173		.0362
13	.2401	.2401	.016			.0162	.0366
14		.2743	.0164	.0171	.0173	.0164	
15		.2743		.0171	.0173	.0164	
16	.2058	.2572		.0171	.0173	.0168	
17	.016		.0171		.0171	.0168	.0171
18	.0162	.0171	.0171		.0171	.0168	.0171
19	.016		.0171		.0171	.0168	.0171
20	.0164		.0171		.0171		.0171
21	.0164		.0171				.0171
22	.016		.052		.0171		
23	.016		.052				
24	.0171	.0162		.0532		.0343	.0171
Max	.2401	.2743	.052	.0532	.0351	.0343	.0366
Min	.016	.0158	.016	.0171	.0171	.0162	.0171
Avg	.0483	.1128	.0221	.0360	.0187	.0246	.0224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 202 / 11 KV HAMIDWADA AG FEEDER

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.181		.0175		.0171	.0175
2	.1715	.181		.0175		.0171	
3	.1715	.181		.0175		.0171	.0175
4	.1715	.1772		.0175		.0171	.0177
5	.1715	.1753		.0175		.0171	.0177
6	.1886	.181		.0175		.0171	.0177
7	.2572	.2587		.0175		.0171	.0177
8	.0171	.0162	.0171	.0173		.0171	.0183
9	.0171	.0175	.4382	.2572	.0526	.0335	.0164
10		.0175	.5847	.1715	.0526	.0335	.0164
11		.0173	.5611	.1715	.0526		.016
12					.0526		.0164
13	.0171	.0173			.0526	.0324	
14		.0173	.5068	.1715	.0526	.0328	
15		.0173		.1372	.0526	.0328	
16	.0171	.0173			.0526	.0335	
17	.0162		.0173		.0171	.0168	.0171
18	.0158	.0171	.0173		.0171	.0171	.0171
19	.016		.0173		.0171	.0171	
20	.016		.0173				.0171
21	.0164		.0173				.0171
22	.1829		.0175				
23	.1791		.0175			.0171	
24	.1715	.1772		.0177		.0171	.0175
Max	.2572	.2587	.5847	.2572	.0526	.0335	.0183
Min	.0158	.0162	.0171	.0173	.0171	.0168	.016
Avg	.1045	.0981	.1858	.0762	.0429	.0221	.0172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 203 / 11 KV ARJUNNAGAR

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1254		.1629		.12	.128
2	.12	.1254		.1448		.12	
3	.12	.128		.1448		.12	.1086
4	.12	.124		.1629		.12	.1267
5	.1715	.1595		.197		.1372	.1612
6	.2401	.2378		.2149		.2058	.2328
7	.2572	.2534		.2328		.2743	.2686
8	.2229	.2195	.2218	.2534		.2572	.2896
9	.2012	.1791	.1612	.1715	.2149	.2481	.2561
10		.1254	.1646	.1543	.197	.2126	.2378
11		.124	.1629	.1372	.197		.2303
12		.1417			.1791		.2012
13	.1829	.1595	.1267		.1791	.1595	.1791
14		.1417	.0886	.1372	.1791	.1402	
15		.1402		.1715	.1612	.1417	
16	.1829	.1612			.1791	.1791	
17	.2195		.1791		.2058	.197	.1715
18	.2534	.1829	.2507		.2229	.2507	.2401
19	.3475		.3403		.3086	.3403	.2915
20	.3801		.3544			.394	.3601
21	.3224		.3544			.3582	.3086
22	.2561		.2865			.2686	
23	.1417		.1791			.1612	
24	.1372	.1448		.1646		.1543	.128
Max	.3801	.2534	.3544	.2534	.3086	.394	.3601
Min	.12	.124	.0886	.1372	.1612	.12	.1086
Avg	.2103	.1596	.2208	.1750	.2022	.2073	.2178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 204 / 11 KV SURUPALI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1791		.1867		.1543	.1848
2	.2058	.1772		.1867		.1543	
3	.2058	.1646		.1867		.1543	.1663
4	.2058	.1595		.2241		.1543	.2033
5	.2572	.2402		.2686		.2058	.2561
6	.4115	.3109		.3224		.3601	.3841
7	.4801	.3761		.4887		.4458	.5121
8	.463	.4251	.4024	.5138		.463	.4706
9	.4287	.3721	.3582	.4801	.4784	.4557	.4805
10		.4784	.362	.4287	.4607	.4207	.4525
11		.4784	.2507	.3944	.4075		.4119
12		.4784			.3761		.3898
13	.3772	.3721	.2534				.394
14		.3721	.2149	.3086	.3403	.2629	
15		.3366		.3429	.3403	.3681	
16	.3403	.4252			.3403	.4477	
17	.3801		.3761		.4458	.4119	.3429
18	.4252	.4024	.4656		.4801	.4656	.4458
19	.5487		.5493		.5316	.5373	.5144
20	.5853		.5138		.4801		.5487
21	.5121		.4961				.4801
22	.3761		.3582		.4801		
23	.2561		.2328				
24	.2058	.1949		.2241		.1886	.2012
Max	.5853	.4784	.5493	.5138	.5316	.5373	.5487
Min	.2058	.1595	.2149	.1867	.3403	.1543	.1663
Avg	.3616	.3302	.3718	.3255	.4301	.3324	.3800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 205 / 11 KV Banage Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.0876		.0671		.0171	.0164
2	.12	.0914		.0543		.0171	
3	.12	.0905		.0503		.0171	.0164
4	.12	.0914		.0492		.0171	.0164
5	.12	.0895		.0492		.0171	.0164
6	.1372	.1097		.0486		.0171	.0164
7	.1372	.1086		.0486		.0171	.0164
8	.0171	.0332	.0171	.0486		.0171	.0168
9	.0343	.0324	.3439	.1372	.0168		.0158
10		.0324	.3506	.1372	.0168		.0156
11		.0324	.3582	.1372	.0168		.016
12		.0324			.0168		.016
13	.0343	.0324	.3982				.0158
14		.021	.4298	.0857			
15		.0324					
16	.0343	.0312				.0162	
17	.0492		.0486		.0171	.0162	.0171
18	.0492	.0343	.0486		.0171	.0162	.0171
19	.0332		.0486		.0171	.0162	.0171
20	.0328		.0486				.0171
21	.0324		.0486		.0171		.0171
22	.1075		.0324				
23	.0914		.0324				
24	.1543	.0886		.0655		.0171	.0162
Max	.1543	.1097	.4298	.1372	.0171	.0171	.0171
Min	.0171	.021	.0171	.0486	.0168	.0162	.0156
Avg	.0813	.0595	.1697	.0753	.0170	.0168	.0165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 206 / CHIKHALI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0316		.4075		.1029	.0358
2	.0343	.032		.3898		.1029	
3	.0343	.0324		.3898		.1029	.0358
4	.0343	.0316		.3898		.1029	.0354
5	.0343	.0328		.4031		.1029	.0354
6	.0343	.0492		.4207		.1029	.0354
7	.0343	.0486		.4207		.1372	.0354
8	.0343	.0497	.0514	.0351		.0343	.0358
9	.4115	.5258	.0819	.0343	.0354	.0171	.1097
10		.6661	.064	.0343	.0354	.0171	.1075
11		7.0736	.0486	.0343	.0354		.1097
12		.7537			.0354		
13	.4801	.7712	.0655		.0354	.0173	
14		.7888	.0655	.0343	.0354	.0173	
15		.8063		.0343	.0351	.0173	
16	.4115	.7888			.0351	.0347	
17	.0469		.0701		.0343	.0351	.0343
18	.0543	.0343	.0701		.0343	.0351	.0343
19	.048		.0701		.0343	.0351	.0343
20	.032		.0701			.0347	.0343
21	.032		.0701			.0347	.0171
22	.0324		.4382			.0351	
23	.0328		.4908			.0351	
24	.0343	.0328		.4119		.1029	.0354
Max	.4801	7.0736	.4908	.4207	.0354	.1372	.1097
Min	.032	.0316	.0486	.0343	.0343	.0171	.0171
Avg	.0995	.6972	.1274	.2457	.0350	.0572	.0479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 201 / 11 KV MURGUD Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0274				
2		.0297	.0343		.0343	.0343
3		.0286				
4		.0286	.0343		.0343	.0343
5		.0286				
6		.0286	.0343		.0343	.0343
7		.0429				
8	.0343		.0343		.0343	.0343
9	.0351		.0343			
10		.0343	.12	.0286		.0343
11				.0429		
12		.0343		.0429		
13			.1543	.0446		.0514
14		.0343	.1543	.0594	.0343	
15				.0594	.0343	
16				.0572	.0343	
18		.0343	.0343	.0514	.0343	
20		.0343	.0343	.0343	.0343	
21					.0171	
22		.0343		.0343	.0343	
23	.0267					
24		.0297	.0343		.0343	.0343
Max	.0351	.0429	.1543	.0594	.0343	.0514
Min	.0267	.0274	.0343	.0286	.0171	.0343
Avg	.0320	.0321	.0639	.0455	.0329	.0367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 208 / 11 KV Murgud VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3361					.415
2		.3174	.3258		.3429	.3601	.3772
3		.3174					.3734
4		.3174	.3086	.3258	.3772	.3429	.3772
5		.3361					.3734
6		.3734	.4458	.4801	.4458	.3601	.4481
7		.415		.5144			.4854
8		.415	.5144		.583	.4801	.5975
9	.5853	.4481		.5144			.6722
10		.12	.4458	.5281	.583	.4458	.5914
11				.5228			.5228
12	.5601	.4801		.5228	.4801		.5601
13	.5228		.463	.4668		.4458	.4904
14	.4854	.4115		.4481	.4115		.4481
15	.5175		.3944	.4481	.4801		.4481
16	.5228			.5658	.4287		.4481
17	.5228			.6722		.4458	
18	.6413	.5658		.6173			
19	.6413			.7545	.6859		
20	.679	.7888	.823	.7202	.703		
21	.6413						
22	.5228	.5658	.5487	.583	.5487		
23	.3772						
24		.3584	.3601		.3772	.3772	.4481
Max	.679	.7888	.823	.7545	.703	.4801	.6722
Min	.3772	.12	.3086	.3258	.3429	.3429	.3734
Avg	.5554	.4104	.4630	.5428	.4959	.4072	.4751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 201 / Bhadgaon AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0509	.0838	.0373	.0686	.056	.056	
2	.0509	.0663	.0373	.0686	.056	.056	
3	.0509	.0663	.0373	.0686		.0377	
4	.0509	.0655	.0373	.0686	.056	.0377	
5	.0848	.0497	.0373	.0857	.0747		
6	.081	.0503	.056	.1029	.0747		
7	.0678	.0838	.1109	.1715	.1109		
8	.0848	.1006	.056	.0503			
9	.1715	.2915	.037	.0497	.0373		.0514
10		.1715	.037	.0503	.0373		.0343
11		.2033		.0343	.0373		.0514
12	.1886	.2218			.0373		.0514
13	.12	.2218	.0514		.0373	.0343	.0686
14	.12	.2218	.0332	.0343	.0373	.0343	.0686
15		.2218		.0343	.0373		.0857
16	.0686	.2033		.0343	.056	.0514	
17	.0838	.0373	.0514		.056		.0335
18	.0838	.0373	.0509	.0514	.056		.0497
19	.0829	.056	.0497	.0509	.056		.0492
20		.0373	.0503		.056		.0497
21	.0671	.0373	.0486		.056		.0335
22	.0983	.056			.056		
23	.0655	.056	.0857		.056		.0335
24	.0509	.0838	.0373	.0686	.0747	.056	
Max	.1886	.2915	.1109	.1715	.1109	.056	.0857
Min	.0509	.0373	.0332	.0343	.0373	.0343	.0335
Avg	.0862	.1135	.0496	.0643	.0551	.0454	.0508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 202 / Sonali AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0509	.1029	.056	.0497	.0373	.056	.0171
2	.0509	.0857	.056	.0503	.0373	.056	.0171
3	.0509	.1029	.056	.0497	.0373	.0566	.0171
4	.0509	.0857	.056	.0503	.0373	.0566	.0171
5	.0509	.0686	.056	.0509	.0373	.0566	.0171
6	.1017	.0686	.056	.0503	.0373	.0566	.0171
7	.1865	.1886	.056	.0503	.0373	.0566	.0343
8	.0509	.0492	.056	.0503	.0373	.0566	.0514
9	.0503	.0503	.3292	.2058	.056	.0377	
10		.0497	.3841	.12	.0373	.0377	.0503
11		.056		.0686	.0373		.0497
12		.056					.0509
13	.0509	.056	.3086		.0373	.0171	.0503
14	.0503	.056	.3258	.0686	.0373	.0171	.0497
15		.056		.0514	.0373	.0171	.0497
16	.0509	.056		.0514	.0373	.0514	
17	.0503	.056	.0686		.056		.0503
18		.056	.0509	.0514	.056		.0497
19	.0497	.056	.0497	.0509	.056		.0492
20	.0503	.056	.0503		.056		.0497
21	.0486	.056	.0486		.056		.0335
22	.1475	.056	.0503		.056		
23	.0983	.056	.0497		.056		.0171
24	.0678	.1134	.056	.0497	.0373	.056	.0171
Max	.1865	.1886	.3841	.2058	.056	.0566	.0514
Min	.0486	.0492	.0486	.0497	.0373	.0171	.0171
Avg	.0689	.0706	.1110	.0659	.0438	.0457	.0360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 203 / Sawarde VG

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2713	.2896	.3239	.3077	.2858	.2667	.3077
2	.2543	.2743	.3048	.2896	.2858	.2667	.2896
3	.2543	.2715	.3048	.3109	.2858	.2477	.2896
4	.2543	.2896	.3048	.3439	.2858	.3048	.2896
5	.3222	.3224	.381	.3982	.362		.3439
6	.4748	.543	.5335	.5068	.5525		.4706
7	.5426	.6335	.6287	.5792	.6287		.5973
8	.5087	.6036	.6097	.6036	.6287		.5792
9	.5068	.6036	.5975	.5792	.5847		.4163
10		.5731	.4854	.5487	.5525		.3982
11		.5281		.3982	.5144		.3475
12	.362	.5658		.3982	.4954		.3258
13	.2561	.4904	.3439		.381	.3801	.4755
14	.3258	.415	.1448	.3439	.3429	.3982	.4706
15		.415		.3801	.381		.4298
16	.3982	.4715		.3439	.4382	.4163	
17	.4344	.4763	.3658		.5335	.3982	.4706
18	.5359	.5525	.5853	.6173	.7049	.7059	.6767
19	.7783	.724	.724	.7291	.8002	.7964	.7522
20	.8596	.9335	.8145		.8002	.9231	.905
21	.7783	.8192	.7522		.724	.7964	.7865
22	.5611	.6668				.543	
23	.3155	.4001	.362		.3429	.362	.3658
24	.2713	.2896	.3239	.3077	.3048	.3048	.3077
Max	.8596	.9335	.8145	.7291	.8002	.9231	.905
Min	.2543	.2715	.1448	.2896	.2858	.2477	.2896
Avg	.4412	.5063	.4679	.4437	.4876	.4740	.4680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 201 / 11KV WALWA VILLAGE

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.2801		.3109		.2743
2	.2926	.2614		.3109		.2561
3	.2743	.2772		.2926		.2561
4	.3292	.2957		.3292		.3109
5	.4938	.3547		.4572		.4024
6	.8596		.8383	.7682		.7865
7	.9511	.9149	.8764	.8413		.7499
8	.8596	.7392	.724	.7682		.6401
9	.695	.7392	.5525	.6767	.6287	.567
10		.6478	.4755	.5975	.5304	.4294
11				.5975		.4805
12	.4801					.4066
13	.4755	.4191	.3292		.5121	.3511
14	.4024		.3292	.5359	.4572	.3881
15		.4954	.3475	.5175	.3841	.3326
16		.5335		.5175		
17	.7947	.5716	.4207	.5544	.5304	.5914
18	.7023	.7049	.567	.6099	.7316	.7577
19	.7947	.8002	.7133	.8501	.8048	.8589
20	.8501	.8954	.8779		.823	
21	.7577		.7316		.7133	
22	.5914	.6668			.5487	
23	.4435		.3658		.3658	.3696
24	.3439	.2957	.4572	.3475		.3292
Max	.9511	.9149	.8779	.8501	.823	.8589
Min	.2743	.2614	.3292	.2926	.3658	.2561
Avg	.5851	.5496	.5737	.5491	.5858	.4769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 203 / 11 KV THIKPURLI VILLAGE

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.2957		.2896		.2743
2	.2743	.2987		.2743		.2561
3	.2561	.3142		.2743		.2378
4	.3109	.3326		.3475		.2743
5	.4207			.4207		.3841
6	.7133		.7621	.7059		.6767
7	.695		.7621	.7316		.7133
8	.7316	.2218	.7621	.6584		.695
9	.5487	.5914	.5335		.6097	.6219
10		.5335	.4572	.4668	.5304	.3881
11				.462		.3881
12	.4066					.3881
13	.3326		.4024		.2926	.3142
14	.2957			.3142	.3109	.3511
15		.4954		.3511	.3109	.3142
16	.4066	.5335		.3881		
17	.4435	.6478	.4024	.4805	.5121	.4435
18	.5914	.6287	.5121	.5914	.6584	.6348
19	.7023	.724	.6584	.7023	.7316	.7023
20	.7392	.8383	.7316		.7316	
21	.7023		.695		.6584	
22	.5544	.7049			.5121	.5544
23	.4251		.3475		.362	.3511
24	.3475	.3142	.4382	.3077		.3109
Max	.7392	.8383	.7621	.7316	.7316	.7133
Min	.2561	.2218	.3475	.2743	.2926	.2378
Avg	.4861	.4983	.5742	.4568	.5184	.4416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 201 / 11 KV DHAMOD AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191			.0572			
2	.0191			.0572			
3	.0191	.0377		.0572			
4	.0191			.0572			
5	.0191	.0191		.0572			
6	.0191		.0716	.0914			
7	.0191	.0191	.0886	.0732			.0173
8	.0191	.0191	.0175	.0191			
9	.4119	.4435	.0175				.0175
10			.0175	.0191			
11		.4938					.0179
12		.4887					.0179
13	.5359	.4706					.0179
14		.3898					.0358
15		.362		.0191			.0537
16	.3696	.362		.0191	.0191	.0175	.0537
17		.0175	.0191				
18	.0191	.0175	.0191	.0191		.0175	
19		.0175	.0191	.0191			
20	.0191	.0175	.0191			.0177	
21	.0191	.0175	.0191			.0177	
22	.0191	.0543					
23			.0537				
24	.0191	.0191	.0532	.0572			.0175
Max	.5359	.4938	.0886	.0914	.0191	.0177	.0537
Min	.0191	.0175	.0175	.0191	.0191	.0175	.0173
Avg	.0979	.1815	.0346	.0445	.0191	.0176	.0277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 202 / 11 KV KELOSHI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358			.0191			
2	.0358			.0191			
3	.0358	.0377		.0191			
4	.0358			.0191			
5	.0358	.0377		.0381			
6	.0537		.0175	.0381			
7	.1433	.056	.0175	.0381			.0175
8	.0191	.0191	.0175	.0381			
9	.0191	.0191	.2303				
10			.2686	.2507			
11		.0177					
12		.0177	.3045				
13	.0191	.0177	.3045				
14		.0175	.298				
15		.0175		.2587			
16	.0191	.0175		.2033	.0537		
17		.0175	.0191				
18	.0191	.0175	.0381	.0191		.0175	
19		.0175	.0381	.0191			
20	.0191	.0175	.0381			.0175	
21	.0191	.0175	.0381			.0177	
22	.0377	.0175					
23			.0191				
24	.0358	.0377	.0173	.0191			.0177
Max	.1433	.056	.3045	.2587	.0537	.0177	.0177
Min	.0191	.0175	.0173	.0191	.0537	.0175	.0175
Avg	.0365	.0232	.1111	.0713	.0537	.0176	.0176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 203 / 11KV DHAMOD-KELOSHI

Gaothan Feeder

VILLAGE Feeder KV- 11 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716			.0914			
2	.0716			.0914			
3	.0716	.0747		.0914			
4	.0895			.0914			
5	.1254	.1132		.1097			
6	.197		.1753	.1829			
7	.2865	.2772	.3012	.2507			.1753
8	.2865	.2829	.2835	.2686		.1612	
9	.2328	.2641	.2279				.1928
10			.2126	.2328			
11		.2126					.1612
12		.1595					.1254
13	.1663	.1928	.1612			.1227	.0716
14		.1612	.1433			.1227	.0716
15		.124		.1294			.1433
16	.1478	.1417		.1663	.1075	.1052	.1433
17		.1949	.2149				
18	.2286	.2481	.2328	.2772		.298	
19		.2835	.2865	.3142			
20	.2772	.333	.2865			.3294	
21	.2957	.2835	.2686			.2481	
22	.2033	.1772					
23			.1075				
24	.0895	.0934	.1052	.0895			.1402
Max	.2957	.333	.3012	.3142	.1075	.3294	.1928
Min	.0716	.0747	.1052	.0895	.1075	.1052	.0716
Avg	.1776	.2010	.2148	.1705	.1075	.1982	.1361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 204 / 11 KV BURAMBALI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0191
2				.0191
3				.0191
4				.0191
5				.0191
6			.1075	.0191
7			.1254	.0191
9	.1791	.2402		
11		.2865		
12		.3582		
13	.3142	.3761		
14		.3224		
15		.2507		
16	.2218	.2353		
18			.0191	
22		.0179	.0191	
23			.0191	
24			.0177	.0191
Max	.3142	.3761	.1254	.0191
Min	.1791	.0179	.0177	.0191
Avg	.2384	.2609	.0513	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144026 / 33/11 KV TARALE SUB STSTION

Feeder No / Name : 202 / 11 KV TARALE Gaothan Feeder
VILLAGE(TARLE) Feeder KV- 11
/ OUTGOING

DATE	19-JUL-17
HR	Load (MW)
11	.2865
Max	.2865
Min	.2865
Avg	.2865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 201 / 11 KV SHIRGAON AG
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	16-JUL-17	17-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0156	.0145			
9		.0151		.0191	
10		.016		.0191	
11			.0191		
12			.0191		
14			.0191		
15			.0191		
16			.0191		
23	.0156				.0143
Max	.0156	.016	.0191	.0191	.0143
Min	.0156	.0145	.0191	.0191	.0143
Avg	.0156	.0152	.0191	.0191	.0143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 202 / 11 KV PARITE AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0191	.0145	.0154			
9			.0152		.0191	
10			.0149		.0191	
11				.0191		
12				.0191		
14				.0191		
15				.0191		
23		.0156				.0149
Max	.0191	.0156	.0154	.0191	.0191	.0149
Min	.0191	.0145	.0149	.0191	.0191	.0149
Avg	.0191	.0151	.0152	.0191	.0191	.0149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 203 / 11 KV AWALI-RADHANAGARI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0162	.0145		
9		.0671		
10		.0472		
11				.0191
12				.0191
14				.0191
15			.0114	.0191
23	.0149			
Max	.0162	.0671	.0114	.0191
Min	.0149	.0145	.0114	.0191
Avg	.0156	.0429	.0114	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 205 / 11 KV Awali Vg

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.2075
2							.1867
3							.1867
4							.3361
5							.4108
6						.4108	.6348
7	.6173	.5853	.6908			.6584	.6219
8		.5975	.6161			.6653	.5316
9	.4801	.5175	.5281				.4252
10			.3841			.4755	
11					.4108		
12	.3582				.2658		.2561
13	.3506						.3045
14					.2658	.3109	.3475
15				.3185	.3506	.3292	.4024
16		.439				.3658	.4887
17		.439				.5121	
18						.6036	
19		.5068	.6516				.6516
20		.7842	.7356			.7087	.6878
21			.6602			.6161	
22							.439
23		.2957	.2829				.2926
24							.2126
Max	.6173	.7842	.7356	.3185	.4108	.7087	.6878
Min	.3506	.2957	.2829	.3185	.2658	.3109	.1867
Avg	.4516	.5206	.5687	.3185	.3233	.5142	.4013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 206 / 11KV Kanthewadi Ag.

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0149	.0145			
9		.0141			
10		.0114			
11				.0111	
12				.0202	
14				.0332	
15			.0101	.032	
23	.0162				.016
Max	.0162	.0145	.0101	.0332	.016
Min	.0149	.0114	.0101	.0111	.016
Avg	.0156	.0133	.0101	.0241	.016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 207 / 11 KV Shirgaon VG

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.5041					
7	.5373	.5304	.5788				
8		.4938					
9	.3841		.3734				.0177
10		.4108	.2926				
11					.3109		
12	.2279				.2204		.2686
13	.2012						
14					.2481	.2103	.0179
15				.2279	.2303	.1753	.3403
16		.2715				.2835	
17						.3012	
18		.2715				.4252	
19			.4161				.5014
20			.4525			.4733	.1433
21			.3641			.4668	
22							.3018
23		.2561	.2172				.2641
Max	.5373	.5304	.5788	.2279	.3109	.4733	.5014
Min	.2012	.2561	.2172	.2279	.2204	.1753	.0177
Avg	.3376	.3912	.3850	.2279	.2524	.3337	.2319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 201 / 11 KV SOLANKUR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0857			
2	.0543				
3	.0905	.0857			
4	.0857				
5	.1097	.0857			
6	.1097				
7		.0857			
9				.12	.0554
10				.1029	.0732
11					.0739
12					.0924
13					.1097
14				.0857	.0924
15			.1372		.0739
16			.1029		.0924
22	.0857				
24	.0724	.0857			
Max	.1097	.0857	.1372	.12	.1097
Min	.0543	.0857	.1029	.0857	.0554
Avg	.0828	.0857	.1201	.1029	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 202 / 11KV KALAMMAWADI

Ag dominated/Pure Ag

AG(SOLANKUR) Feeder KV- 11 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.0183	
5			.0185	
6			.037	
7			.037	.0229
9	.0724	.0857		
10		.0724		
11		.1267		
12	.1029	.1433		
13	.1029			
14	.12			
15		.1433		
16	.0686	.1086		
Max	.12	.1433	.037	.0229
Min	.0686	.0724	.0183	.0229
Avg	.0934	.1133	.0277	.0229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 203 / 11KV SOLANKUR VILLEGGE

Gaothan Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.0686		.1372	.3109	.3258	
2	.3439			.3429	.3326	.3077	
3	.3439	.0514		.3429	.3326		
4	.3439			.3429	.3658		
5	.4572	.0686		.4115	.6283		
6	.724			.6859	.7392		
7		.1372		.7545	.8501		
8		.2743	.1294	.7545	.8131		
9	.2896	.6859		.6516	.7023		
10		.6805	.0686	.5487	.6348		
11		.6805	.0857		.5914		
12	.4801	.5731	.0857		.5914		.6859
13	.4801		.5144		.5544		.6173
14	.4115		.5487	.4458	.499	.543	.4115
15		.5373	.5487		.4805	.6154	
16	.5144	.6401	.5144		.5228	.7682	
17	.6859	.6516	.5144	.6173	.695	.7682	.6859
18		.724	.6859	.7716	.8131	.823	.7888
19	.9259	.9145	.9259	.8745	.961		.9259
20	.9602	1.0136		.9259		.2743	.9945
21	.8573	.924					
22	.6516	.7392					
23		.462	.4115		.3696		.4115
24	.3658				.2957	.362	
Max	.9602	1.0136	.9259	.9259	.961	.823	.9945
Min	.2896	.0514	.0686	.1372	.2957	.2743	.4115
Avg	.5402	.5459	.4194	.5738	.5754	.5320	.6902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 204 / 11KV AAINI VILLAGE

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1372	.1294	.1029	.1478	.1463	
2	.1267		.1294	.1029	.1478	.1463	
3	.128	.1372	.1294	.1029	.1463		
4	.1267		.1294		.1478		
5	.1629	.1372	.1848	.1372	.1848		
6	.2172		.2218	.2058	.2218		
7		.2401	.2587		.2587		
8		.2058	.2587	.2058	.2587		
9	.1463	.2401		.2058	.2402		
10		.1991	.2401	.1715	.2218		
11		.1448	.1372	.1715	.2033		
12	.1372	.1448	.1715		.1663		.1029
13	.12		.1372		.1478		.1029
14			.1372	.1372	.128		.1372
15		.181	.1715		.1294		.1715
16		.1267	.1715		.1848		.1715
17	.2401	.197	.1715	.1715	.1848	.1097	.2743
18		.2012	.2058	.2058	.2614	.1829	.2743
19	.2743	.2534	.2743	.2572	.2772		.3086
20	.2915	.362		.2743	.2957	.2195	.3086
21	.2572	.2587	.2401		.2561		
22	.1886	.2033	.1715		.1829		
23		.1478	.1372		.1478		.1372
24	.128	.1372	.1294	.1372	.1478	.1448	
Max	.2915	.362	.2743	.2743	.2957	.2195	.3086
Min	.12	.1267	.1294	.1029	.128	.1097	.1029
Avg	.1781	.1923	.1790	.1726	.1954	.1583	.1989

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 201 / 11 KV KALAMMAVADI VG
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.2012	
2		.2012	
16	.3109		.4108
17	.3475		.4294
18	.4024		.4294
19			.2054
20	.439		.4854
21	.4024		.4481
22			.4108
23	.2012		.2987
24		.2012	
Max	.439	.2012	.4854
Min	.2012	.2012	.2054
Avg	.3506	.2012	.3898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 202 / 11 KV Kudutri Village
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.0747	
2		.0747	
16	.1494	.168	
17	.1494		
18	.1867		.2241
19	.1867		.2987
20	.2054		.2987
21	.2054		.2801
22			.168
23	.056		.112
24		.0747	
Max	.2054	.168	.2987
Min	.056	.0747	.112
Avg	.1627	.0980	.2303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 201 / 11KV I.T.Park

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0177	.0181	.0185	.0181	.0181	.0185
2	.0185	.0177	.0181	.0185	.0181	.0181	.0185
3	.0185	.0177	.0181	.0185	.0181	.0181	.0185
4	.0185	.0177	.0181	.0185	.0181	.0181	.0185
5	.0185	.0177	.0181	.0185	.0181	.0181	.0185
6	.0183	.0177	.0181	.0185	.0181	.0181	.0185
7	.0183	.0177	.0181	.0185	.0181	.0724	.0185
8	.0185	.0177	.0181	.0185	.0181	.0181	.0185
9	.0183	.0177	.0362		.0181	.0181	.0185
10		.0185	.0354	.0362	.0362	.0366	
11		.0185		.0362	.0362		.0354
12	.0181	.0185			.0362		.0354
13	.0181	.0185	.0373		.0362	.037	.0354
14	.0181	.0185	.0354	.0362	.0362	.037	.0354
15		.0185	.0354	.0362	.0362	.037	.0358
16	.0181	.0185		.0362	.0362		
17	.0177	.0181	.037		.0362	.0554	.037
18	.0177	.0181	.037	.0354	.0362	.037	.0366
19	.0177	.0181	.037	.0354	.0362		.0366
20	.0177	.0181	.037	.0354	.0362	.037	.0366
21	.0177	.0181	.037	.0362	.0362	.037	.0366
22	.0177	.0181	.037	.0181	.0362	.0185	.0366
23	.0177	.0181	.0185	.0181	.0181	.0185	.0366
24	.0185	.0177	.0181	.0185	.0181	.0185	.0185
Max	.0185	.0185	.0373	.0362	.0362	.0724	.037
Min	.0177	.0177	.0181	.0181	.0181	.0181	.0185
Avg	.0181	.0181	.0278	.0263	.0279	.0293	.0281

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 202 / HOCKY STADIUM

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1075	.1109	.0739	.0924	.0739	.1109
2	.112	.1075	.0924	.0739	.0739	.0739	.1109
3	.1109	.0895	.0924	.0739	.0739	.0739	.1109
4	.112	.0895	.0924	.0739	.0739	.0739	.1109
5	.1109	.0716	.0924	.0739	.0924	.0739	.1109
6	.1307	.0895	.1109	.0924	.1109	.0739	.1109
7	.0924	.0895	.0924	.1109	.1109	.0739	.0924
8	.1109	.1075	.1109	.0924	.1294	.1109	.1109
9	.1294	.1075	.1109		.1109	.1109	.1294
10		.1109	.0895	.1109		.1109	
11		.0924		.1109			.1254
12	.1109	.0924					.1254
13	.1109	.0924	.0934			.0924	.0895
14	.0924	.0739	.0716	.0739		.0924	.0895
15		.0739	.0716	.0739		.0924	.0895
16	.0739	.0739		.0739		.0739	
17	.0895	.0739	.0739		.0739	.0554	.0739
18	.0895	.0739	.0739	.0895	.0739	.0739	.0924
19	.1254	.0924	.1109	.1254	.0924		.1097
20	.1433	.1478	.1294	.1254	.1294	.1478	.1478
21	.1433	.1478	.1294	.1294	.1294	.1663	.1478
22	.1433	.1478	.1294	.1294		.1478	.1478
23	.1254	.1294	.0924	.1109	.1109	.1294	.1294
24	.112	.1075	.1109	.0924	.0924	.0924	.1109
Max	.1433	.1478	.1294	.1294	.1294	.1663	.1478
Min	.0739	.0716	.0716	.0739	.0739	.0554	.0739
Avg	.1134	.0996	.0991	.0956	.0982	.0959	.1126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 204 / RENUKA FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7049	.6908	.6838	.6653	.6722	.6653
2	.6908	.6668	.6348	.6468	.6348	.6722	.6653
3	.6838	.6668	.6348	.6468	.6099	.6722	.6653
4	.6838	.6668	.6348	.6468	.6161	.6722	.6653
5	.7392	.743	.6348	.6468	.6535	.6722	.6653
6	.7947	.8002	.7468	.7762	.7282	.7468	.7762
7	.8131	.8383	.8316	.8131	.9335	.8589	.9055
8	.8501	.8573	.8962	.8871	.9335	.8775	.9425
9	1.0164	.9145	.9149		.9522	1.0456	.961
10		.9979	1.3146	.9335	1.0082	.9979	
11		.924		.8962	.8402		.8954
12	.8775	.8686			.8589		.8573
13	.8402	.7577	1.8861		.7655	.8316	.8192
14	.7655	.7392	1.5432	.8029	.7842	.7392	.8002
15		.7207	1.467	.7468	.7282	.6838	.7811
16	.7655	.7207		.7842	.7282	.6838	
17	.8192	.7282	.6468		.7282	.7577	.7947
18	.8002	.5788	1.7741	.8954	.8589	.8316	.8316
19	1.0098	.8962	.9979	1.0288	.9522		.9425
20	1.105	.9896	1.0534	1.086	1.1203	1.1088	1.1273
21	1.0479	1.0642	1.0349	1.0269	1.0642	1.0534	1.0719
22	1.0098	1.0082	.9795	.9709		1.0164	.9979
23	.8764	.8589	.8501	.8402	.8589	.8316	.8501
24	.7392	.7621	.7468	.7392	.7023	.7207	.6838
Max	1.105	1.0642	1.8861	1.086	1.1203	1.1088	1.1273
Min	.6838	.5788	.6348	.6468	.6099	.6722	.6653
Avg	.8399	.8114	.9959	.8249	.8141	.8165	.8348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 205 / SUBHASH NAGAR FEEDER
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5525	.5601	.5175	.5175	.4854	.4805
2	.5175	.5335	.5228	.4805	.5228	.4668	.4805
3	.5175	.5335	.5228	.4805	.499	.4668	.4805
4	.5175	.5335	.5228	.4805	.499	.4668	.4805
5	.5914	.5144	.5228	.499	.5601	.4668	.499
6	.7282	.5716	.6348	.6283	.6283	.5975	.6468
7	.7095	.6097	.7842	.7392	.6908	.7842	.7577
8	.8501	.8764	.8402	.8501	.8402	.9709	.8871
9	.8501	.8764	.9522		.9335	.9522	.961
10		.8686	.8002	.8775	.8029	.8131	
11		.7023		.7842	.7095		.7621
12	.7095	.6283			.7842		.724
13	.6722	.6283	.4668		.6535	.6468	.6478
14	.6535	.5544	.4572	.6161	.6348	.6653	.6097
15		.5359	.4763	.6161	.6535	.5914	.6097
16	.5788	.5359			.5975	.5729	
17	.5335	.5601	.5175		.5788	.4805	.4938
18	.6478	.5975	.5914	.8002	.7468	.7577	.7577
19	.8764	.6722	.8131	1.0479	.9335		.823
20	1.1241	1.0456	.9425	1.1622	1.1389	1.0903	1.1088
21	.9717	.9979	.9425	1.1203	.9896	.961	1.0719
22	.9335	.9709	.924	.9149		.8871	.924
23	.7621	.8402	.7577	.7095	.7655	.7577	.7392
24	.6099	.6097	.6722	.5914	.5601	.5788	.5729
Max	1.1241	1.0456	.9522	1.1622	1.1389	1.0903	1.1088
Min	.5175	.5144	.4572	.4805	.499	.4668	.4805
Avg	.7102	.6812	.6773	.7324	.7061	.6886	.7054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 201 / SAMBHAJI NAGAR CZ

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.583	.6535	.6602	.7282	.4715	.547
2	.5658	.5658	.6224	.6413	.6908	.3961	.5281
3	.5658	.5316	.6036	.6224		.3961	.5093
4	.5658	.5487	.6224	.6036		.5093	.5093
5	.6036	.583	.6602	.6036		.5658	.5847
6	.6979	.6344	.7356	.7167		.6036	.7356
7	.7922	.6687	.8402	.7922	.2054	.6413	.8299
8	.811	.7545	.8865	.8865	.4108	.7167	.9431
9	.8488	.8745		.9431	.9149	.7356	.9808
10		.9808		.8676	.7095	.679	
11		.8676		.7922	.5975		.8402
12	.7545	.8299			.5975		.7545
13	.6413	.7733			.5415	.6979	.6344
14	.6224	.811		.8299	.5228	.6979	.5487
15				.8865	.2263	.679	.6001
16	.679	.6979		.811		.7167	.6001
17	.7167	.7356	.5316		.6224	.7095	.7373
18	.6687	.811	.8676	1.0631	.6602	.8676	.9431
19	1.0117	.9431	1.0562	1.2346	.811	1.094	1.094
20	1.0631	1.1203	1.1506	1.406	.9431	1.2071	1.2071
21	1.046	1.1203	1.1317	1.475	.8299	1.1694	1.1694
22	.9602	1.0269	.9997	1.3256		1.1128	
23	.7888	.8865	.7922	1.0456	.6602		.811
24	.6602	.6173	.7468	.6979	.8029	.5093	.679
Max	1.0631	1.1203	1.1506	1.475	.9431	1.2071	1.2071
Min	.5658	.5316	.5316	.6036	.2054	.3961	.5093
Avg	.7461	.7811	.8063	.9002	.6375	.7227	.7630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 202 / JAIL KOLHAPUR
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2401	.2427	.2614	.2427	.2241	.2241
2	.2614	.2229	.2241	.2241	.2241	.1867	.2054
3	.2427	.2229	.2241	.2241	.2241	.1867	.1867
4	.2427	.2229	.2241	.2241		.2427	.1867
5	.2614	.2401	.2427	.2427		.2801	.2427
6	.2987	.2401	.2614	.2987	.3174	.3174	.2801
7	.3361	.2572	.2987	.3734	.3547	.3361	.3174
8	.3547	.3086	.2987	.3921	.3547	.3547	.3734
9	.4481	.3258		.3547	.4668	.4294	.4481
10		.3174		.3361	.3921	.3921	
11		.3174		.2987	.3547		.2915
12	.2614	.2801			.2987		.2572
13	.2427	.2427			.2614	.2614	.2401
14	.3174	.2241		.1867	.3174	.3174	.2572
15				.1867	.2241	.2054	.2058
16	.2614	.2054		.2241		.2427	.2743
17	.2614	.2054	.3772		.2987	.3174	.2743
18	.2572	.2427	.3921	.2743	.2987	.2801	.3174
19	.3429	.2987	.4668	.3086	.3734		.4108
20	.4801	.4668	.4668	.4287	.4854	.5228	.4854
21	.3944	.4294	.4481	.4481	.3734	.4668	.4294
22	.3429	.4108	.4294	.3921		.4108	
23	.2915	.3361	.3361	.3174	.3174		.3174
24	.2801	.2401	.2614	.2801	.2614	.2427	.2801
Max	.4801	.4668	.4668	.4481	.4854	.5228	.4854
Min	.2427	.2054	.2241	.1867	.2241	.1867	.1867
Avg	.3076	.2825	.3247	.2989	.3221	.3109	.2957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 204 / KALAMBA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	.7545	.8131	.7682	.7392	.695	.695
2	.7392	.7202	.7762	.7316	.7207	.6401	.6767
3	.7023	.6859	.7392	.7316	.7023	.6401	.6401
4	.7392	.6687	.7762	.695	.6838	.7499	.6584
5	.7762	.6859	.8316	.8413	.7207	.9145	.7865
6	1.0349	.8916	.9979	1.0791	1.0164	1.0425	.9877
7	1.3306	1.0974	1.2382	1.2803	1.3306	1.2986	1.2986
8	1.4045	1.286	1.423	1.4266	1.4784	1.4632	1.3717
9	1.2012	1.2689		1.2803	1.3676	1.4083	1.2986
10		1.262		1.1523	1.1643	1.1643	
11		1.1157		.9694	1.0164		.8916
12	.6036	.9877			1.0349		.8745
13	.567	1.0608			.8686	.924	.823
14	.5121	.8871		.5487	.924	.8686	.7716
15				.567	.8501	.8131	.703
16	.9145	1.0059		.8779		.7392	.7373
17	.9328	1.0349	.8916		.8686	.7577	.8916
18	1.0631	1.1643	1.2071	1.1317	1.134	1.0242	1.0974
19	1.3546	1.2567	1.4998	1.3375	1.4266		1.3535
20	1.5947	1.5708	1.6095	1.5089	1.5729	1.4998	1.5546
21	1.4575	1.4969	1.5546	1.5154	1.4449	1.4632	1.4998
22	1.3546	1.3306	1.4083	1.423		1.2986	
23	.9945	1.0719	1.0059	.8131	.9511		1.0059
24	.8316	.7888	.8686	.8413	.8131	.7316	.7682
Max	1.5947	1.5708	1.6095	1.5154	1.5729	1.4998	1.5546
Min	.5121	.6687	.7392	.5487	.6838	.6401	.6401
Avg	.9945	1.0475	1.1026	1.0248	1.0377	1.0068	.9721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 205 / JARAG NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.6344	.7316	.6401	.6401	.6401	.6584
2	.6401	.6173	.6401	.6219	.6219	.567	.6219
3	.6219	.583	.6219	.6219	.6036	.567	.5853
4	.6219	.583	.6219	.6401	.5853	.6219	.5853
5	.6401	.5658	.6401	.6767	.6219	.7133	.6219
6	.6767	.5658	.6401	.7316	.7133	.7682	.6767
7	.9145	.6859	.8596	.9877	.8596	.8413	.9328
8	.9694	.8059	1.0059	.9877	.9877	.9877	.9694
9	.8413	.8916		.9511	.9877	1.0425	.9877
10		.9328		.8779	.8596	.9328	
11		.8413		.7499	.7499		.7373
12	.7682	.7499			.7316		.6516
13	.695	.7865			.695	.7316	.583
14	.6767	.695		.6584	.6584	.6584	.6173
15				.6036	.5853	.5853	.5658
16	.5853	.6401		.6036		.5853	.5487
17	.6584	.6219	1.2517		.6219	.6401	.6516
18	.6516	.7499	1.1888	.8059	.8779	.8048	.8048
19	1.046	.8779	1.4632	1.166	1.0974		1.0425
20	1.3032	1.3169	1.4449	1.3546	1.4266	1.39	1.3535
21	1.2689	1.2803	1.39	1.39	1.3352	1.3717	1.2986
22	1.166	1.1888	1.2986	1.2803		1.2254	
23	.8916	.9877	.9511	.9145	.8962		.8962
24	.7316	.6859	.7682	.7499	.695	.6767	.7316
Max	1.3032	1.3169	1.4632	1.39	1.4266	1.39	1.3535
Min	.5853	.5658	.6219	.6036	.5853	.567	.5487
Avg	.8108	.7951	.9699	.8578	.8114	.8176	.7783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 412 / 33kv Shenda Park out going HV Non-Express Feeder
Feeder KV- 33 / INCOMING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.384	2.3148	2.5503	2.5503	2.4394	2.4394	2.3285
2	2.2177	2.1605	2.4394	2.4949	2.3285	2.2177	2.3285
3	2.2177	2.0576	2.3285	2.3285	2.2731	2.2177	2.2177
4	2.2731	2.1091	2.384	2.3285	2.2177	2.5503	2.2177
5	2.384	2.2634	2.4949	2.4394	2.3285	2.9938	2.384
6	2.8829	2.4177	2.8829	2.7166	3.271	3.3265	2.9384
7	3.3265	2.7778	3.4374	2.9384	3.7146	3.4928	3.5482
8	3.6591	3.1893	3.6591	3.1602	3.77	3.7146	3.77
9	3.7146	3.4979		3.3265	3.9918	3.9363	3.8809
10		3.6037		3.7146	3.6037	3.6037	
11		3.1602		2.4394	3.1602		2.9835
12	2.9938	3.0493			2.9938		2.8292
13	2.7721	2.7166			2.8829	2.9938	2.572
14	2.7166	2.4949		2.8275	2.8829	2.8275	2.4177
15				2.6612	2.7166	2.6057	2.4177
16	2.4949	2.4394		1.9959			2.2119
17	2.5503	2.5503	2.3663		2.6612	2.4394	2.5206
18	2.6749	2.6057	3.9363	3.1379	3.1602	3.2156	2.8275
19	3.4979	3.0493	3.9918	2.7778	4.0472		3.77
20	4.1667	4.2135	4.4353	4.2181	4.5462	4.6016	4.5462
21	3.9609	4.1581	4.269	4.269	4.2135	4.4353	4.3244
22	3.6008	3.8809	3.9918	3.8255		3.9363	
23	2.9835	3.3819	3.1602	3.1602	3.1602		3.1602
24	2.6057	2.4177	2.7721	2.7166	2.6057	2.5503	2.4949
Max	4.1667	4.2135	4.4353	4.269	4.5462	4.6016	4.5462
Min	2.2177	2.0576	2.3285	1.9959	2.2177	2.2177	2.2119
Avg	2.9561	2.8917	3.1937	2.9537	3.1350	3.1631	2.9404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 208 / RAJARAMPURI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4527	.4715	.4527		.4527	.4527
2	.4763	.4338	.4338	.3961		.3961	.3961
3	.4572	.415	.4338	.3961		.3961	.3961
4	.4382	.415	.4338	.3961		.4338	.3961
5	.4954	.415	.4715	.415		.4338	.3961
6	.4954	.4715	.5281	.6036		.6602	.4715
7	.6668	.5658	.6979	.5658		.6602	.6602
8	.7621	.6224	.7356	.7167	.7356	.7545	.6979
9	.6859	.6602	.7545	.7356	.7545	.7922	.7733
10		.6602	.8002	.8676	.7545	.8299	
11		1.0082		1.0751	.9808		1.0374
12	1.1506	1.0456		1.1317	.9997		.9431
13	1.1506	.9896		1.0185	1.0562	1.1506	.9997
14	1.0185	.9149	1.1812	.9242	.8865	.9431	.9808
15	.9242	.7733	1.0098	.9054	.8488	.7922	.8865
16	.8676	.8676		.8676		.7922	
17	.9619		.924		.9054	.811	.9526
18	1.0562	1.0751	1.0349	1.1431	1.0185	.9242	1.1812
19	1.3392	1.1506	1.3256	1.3336	1.226		1.3717
20	1.3392	1.3769	1.3817	1.3336	1.3203	1.3392	1.3717
21	1.1317	1.2826	1.1389		.9808	1.2071	1.1812
22	.7922	.8299			.7733		
23	.6224	.6413	.5975		.6224		.6668
24	.5144	.5093	.5093	.4904		.4904	.4527
Max	1.3392	1.3769	1.3817	1.3336	1.3203	1.3392	1.3717
Min	.4382	.415	.4338	.3961	.6224	.3961	.3961
Avg	.8092	.7642	.7823	.7884	.9242	.7505	.7936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 209 / 11 KV VARDHAMAN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2641	.2263	.2452		.2641	.2263
2	.2286	.2641	.2263	.2263		.2452	.2075
3	.2096	.2263	.2263	.2263		.2452	.2075
4	.2096	.2263	.2263	.2263		.2263	.2263
5	.2477	.2452	.2641	.2263		.2263	.2452
6		.2641	.3018	.3018		.3018	.3018
7	.381	.3206	.3772	.3395		.3772	.3772
8	.381	.3206	.3772	.3961	.3395	.415	.4338
9	.381	.3772	.3772	.3961	.3772	.415	.4338
10		.3772	.3429	.3772	.415	.3961	
11		.3921		.4527	.415		.415
12	.4527	.3921		.4527	.415		.4338
13	.415	.3734		.4527	.415	.415	.3961
14	.3772	.3174	.4572	.4527	.3772	.415	.3772
15	.3772	.3018	.381	.415	.3395	.3395	.3772
16	.3772	.3018		.3772		.3395	
17	.3772	.3395	.3696		.3772	.3584	.381
18	.415	.3772	.4435	.381	.415	.415	.4572
19	.4904	.4527	.4854	.5335	.5281		.4954
20	.5658	.5281	.5281	.5335	.5281	.5093	.5335
21	.4904	.5281	.4668		.4527	.4715	.4572
22	.3772	.415			.3772		
23	.3206	.3772	.2987		.3395		.3048
24	.2667	.2641	.2641	.2452		.2641	.2452
Max	.5658	.5281	.5281	.5335	.5281	.5093	.5335
Min	.2096	.2263	.2263	.2263	.3395	.2263	.2075
Avg	.3605	.3436	.3495	.3629	.4074	.3494	.3587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 210 / 11 KV SHAHUPURI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4904	.5093	.4715		.5093	.4715
2	.4763	.4527	.4715	.4338		.4715	.4715
3	.4382	.4338	.4338	.415		.4715	.4715
4	.4572	.4338	.4338	.415		.4715	.4904
5	.4572	.5093	.4904	.415		.4904	.4904
6	.5144	.5093	.5658	.4338		.5281	.4715
7	.5906	.5281	.6036	.547		.5658	.5847
8	.6478	.5658	.6413	.6036	.5281	.7167	.6602
9	.7811	.6224	.7733	.7167	.6602	.7545	.7545
10		.8488	1.0098	.9997	.7922	.9997	
11		.8029		.0189	.9242		1.1694
12	1.2449	.8029			.9054		1.1883
13	1.2637	.8962		1.3769	.9619	1.1506	1.2826
14	1.1883	.8589	1.5051	1.1506	1.0751	1.1317	1.1694
15	1.094	.7733	1.3146	1.1128	1.0751	1.094	1.1506
16	1.1128	.811		1.1506		1.0562	
17	1.1694		1.1643		1.0374	1.1883	1.1241
18	1.1506	.9242		1.1622	1.094	1.1694	1.2384
19	1.1317	.9997	1.1203	1.3336	1.1694		1.2193
20	1.0562	1.0562	1.251	1.1812		1.1128	1.1812
21	.9808	.8865	.9335			.9054	.9526
22	.7922	.7922				.6979	
23	.679	.6602	.6161		.6224		.6287
24	.5525	.5658	.5658	.5093		.547	.4904
Max	1.2637	1.0562	1.5051	1.3769	1.1694	1.1883	1.2826
Min	.4382	.4338	.4338	.0189	.5281	.4715	.4715
Avg	.8298	.7054	.8002	.7604	.9038	.8016	.8410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 211 / Takala

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.5281	.6036	.5847		.5658	.5281
2	.4763	.5281	.5658	.5093		.5658	.5093
3	.4954	.4904	.5658	.5093		.5281	.4904
4	.4954	.4904	.5847	.5281		.5281	.4904
5	.5716	.5093	.6224	.5281		.5281	.5093
6	.6097	.6413	.679	.6036		.6979	.7167
7	.8573	.6979	.9431	.8299		.9431	.9242
8	.8954	.811	.9242	.9054	.8865	.9619	.9431
9	.9335	.8488	.9619	.8676	.9619	.9431	.9431
10		.9242	.7621	.811	.8865	.9431	
11		.7282		.9808	.7922		.7922
12	.7922	.7095		.7545	.7733		.7545
13	.7356	.7095		.679	.6979	.7167	.7167
14	.679	.6535	.724	.6979	.679	.6602	.6224
15	.6413	.6224	.7049	.6224	.6413	.6224	.6036
16	.6224	.6036		.6413		.6413	
17	.6224	.6602	.6283		.6602	.6979	.5906
18	.6602	.6602	.7207	.743	.7545	.7545	.7621
19	.8299	.7733	.8962	.8573	.8865		.8383
20	.9431	.9431	.9709	.9526	.9619	.9997	.9335
21	.9054	.9431	.9709		.9242	.9808	.8954
22	.7922	.9242			.8865		
23	.7356	.7733	.7282		.7167		.6859
24	.5716	.6224	.6413	.6224		.6224	.5847
Max	.9431	.9431	.9709	.9808	.9619	.9997	.9431
Min	.4763	.4904	.5658	.5093	.6413	.5281	.4904
Avg	.6974	.6998	.7473	.7114	.8073	.7316	.7064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 212 / 11 KV SHAHUMILL KOP.MAULI Urban/Sheddable Urban Feeder
FEED Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.415	.415	.415		.415	.415
2	.4191	.3772	.3961	.3772		.415	.3772
3	.4001	.3772	.3961	.3772		.3772	.3584
4	.4382	.3772	.3772	.3772		.3772	.3584
5	.4572	.3961	.4527	.3772		.3772	.3584
6	.4954	.4527	.547	.4904		.4904	.4527
7	.6668	.5658	.6224	.6224		.5847	.5847
8	.6287	.6036	.5658	.6036	.679	.6602	.6036
9	.5906	.5847	.6413	.6224	.6224	.6602	.6224
10		.5093	.5906	.6036	.5658	.6224	
11		.5788		.6036	.5658		.6413
12	.6036	.5601		.6036	.547		.6036
13	.5847	.5041		.6224	.5281	.5847	.5658
14	.5281	.5228	.6668	.547	.4715	.547	.547
15	.4715	.5093	.5525	.4904	.4715	.4715	.5093
16	.4904	.4715		.5093		.3584	
17	.4527	.5658	.5359		.547	.4715	.5906
18	.6602	.6413	.6099	.6287	.679	.5847	.6859
19	.8299	.6979	.7655	.8764	.8299		.8573
20	.9242	.9997	.8589	.9335	.8865	.9431	.9717
21	.8488	.8676	.8215		.7733	.8488	.8764
22	.7356	.7545			.7167	.7167	
23	.5658	.5847	.5601		.547		.5716
24	.4572	.4527	.4527	.4527		.415	.415
Max	.9242	.9997	.8589	.9335	.8865	.9431	.9717
Min	.4001	.3772	.3772	.3772	.4715	.3584	.3584
Avg	.5758	.5571	.5699	.5567	.6287	.5460	.5698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 213 / Panjarpol

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0754	.0566	.0566		.0754	.0754
2	.0572	.0754	.0566	.0566		.0566	.0754
3	.0572	.0754	.0566	.0566		.0566	.0754
4	.0762	.0754	.0566	.0566		.0566	.0754
5	.0762	.0754	.0566	.0566		.0754	.0754
6	.0762	.0754	.0566	.0566		.0754	.0754
7	.0762	.0754	.0566	.0566		.0754	.0754
8	.0762	.0566	.0566	.0566	.0754	.0566	.0754
9	.0762	.0754	.0754	.0754	.1132	.0943	.0754
10		.1132	.0762	.1698	.132	.132	
11		.1867		.1698	.1886		.0754
12	.1886	.1494		.1698	.1698		.1509
13	.1886	.1494		.132	.132	.1509	.132
14	.0943	.112	.0762	.1132	.132	.0943	.1132
15	.1509	.132	.0572	.1509	.1509	.132	.1886
16	.1698	.1132		.1509		.2263	
17	.1698	.1698	.0739		.1886	.1509	.2286
18	.132	.132	.0739	.1715	.132	.1886	.1524
19	.132	.1132	.0747	.1715	.132		.1334
20	.1132		.056	.0953	.0943	.0943	.1143
21	.0943	.0754	.056		.0754	.0754	.0762
22	.0943	.0754				.0943	
23	.0754	.0566	.056		.0754		.0762
24	.0572	.0754	.0566	.0566		.0566	.0754
Max	.1886	.1867	.0762	.1715	.1886	.2263	.2286
Min	.0572	.0566	.056	.0566	.0754	.0566	.0754
Avg	.1041	.1006	.0624	.1040	.1280	.1009	.1045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 411 / 33 KV Incomer No. I MIDC

HV Non-Express Feeder

FEEDE Feeder KV- 33 / INCOMING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8578	2.9424	2.999	2.8292		2.8858	2.7726
2	2.8578	2.8292	2.8292	2.5463		2.5463	2.5463
3	2.8006	2.6595	2.7726	2.5463		2.6029	2.4897
4	2.8578	2.6595	2.7161	2.5463		2.6029	2.5463
5	3.0293	2.7726	3.0556	2.6029		2.6595	2.6029
6	3.315	3.1687	3.4517	3.0556		3.2819	3.1121
7	4.1724	3.5648	4.1872	3.678		4.0175	4.0175
8	4.4582	3.9609	4.3004	4.1307	4.1307	4.4702	4.2438
9	4.5725	4.2438	4.6399	4.2438	4.357	4.5268	4.357
10		4.4702	4.6868	4.8097	4.4702	4.8663	
11		4.9291		4.357	4.8097		5.2058
12	5.6584	4.8731		5.6019	4.7531		5.036
13	5.6019	4.8171		5.3189	4.8097	4.9228	4.9794
14	5.036	4.425		4.8663	4.5268	4.6965	4.6399
15	4.6399	4.0741		4.5268	4.3004	4.3004	4.5268
16	4.6399	4.0741		4.5268		4.2438	
17	4.7531	4.5833	4.5462		4.4702	4.4702	4.8583
18	5.2624	5.036	2.8829	5.3155	5.2058	5.036	5.6013
19	6.2243	5.5453	5.9374	6.5158	6.1111		6.1728
20	6.5638	6.6204	6.3855	6.4015		4.9794	6.5158
21	5.8848	5.998	5.5453			5.7716	5.7156
22	4.8663	5.0926				4.6399	
23	4.0741	4.1307	3.6408		3.7346		3.7723
24	3.2579	3.3385	3.3385	2.999		3.0556	2.999
Max	6.5638	6.6204	6.3855	6.5158	6.1111	5.7716	6.5158
Min	2.8006	2.6595	2.7161	2.5463	3.7346	2.5463	2.4897
Avg	4.4266	4.2004	3.9950	4.1709	4.6399	4.0288	4.2243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 412 / 33 KV Incomer no .II

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	17-JUL-17
HR	Load (MW)
14	2.6863
15	4.0009
Max	4.0009
Min	2.6863
Avg	3.3436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 201 / 11 KV Udymnagar

KOP.INDUSTRIAL Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.724	.724	.6859	.7621	.6859	.6097
2	.7621	.724	.724	.6478	.724	.6859	.6097
3	.7621	.724	.7621	.6478	.6859	.6859	.6097
4	.7621	.724	.7621	.6478	.6859	.6859	.6478
5	.7621	.724	.7621	.6859	.6859	.6859	.6478
6	.7621	.7621	.7621	.6859	.6859	.724	.6859
7	.7621	.724	.724	.724	.6859	.6859	.6859
8	.724	.6859	.724	.724	.6859	.6478	.6859
9	.6478	.6478	.724	.6478	.6097	.5716	.5716
10		.6478	.6859	.724	.6478	.724	
11		.7621		.7621	.724		.8383
12	.7621	.6859			.6859		.6097
13	.6859	.6859	.1905		.6478	.724	.724
14	.7621	.724	.1905	.724	.6859	.724	.6478
15		.7621	.1905	.6859	.6859		.6859
16	.8383	.6859		.7621	.724		
17	.6097	.6097	.1905		.6859	.6478	.6478
18	.6097	.6478	.1905	.6478	.5716	.6097	.5716
19	.6097	.6478	.1905	.6478	.6097		.5716
20	.6097	.6859	.724	.6097	.5716	.6097	.6097
21	.6859	.724	.724	.6859	.6097	.6478	.6478
22	.724	.6859		.6859	.6478		.6859
23	.6859	.6859	.724	.6859	.6859		.6859
24	.724	.724	.6859	.724	.7621	.6859	.6478
Max	.8383	.7621	.7621	.7621	.7621	.724	.8383
Min	.6097	.6097	.1905	.6097	.5716	.5716	.5716
Avg	.7149	.7002	.5678	.6877	.6732	.6725	.6513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 202 / 11 KV SAMARAT NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4191	.4572	.4435	.4066	.381	.4066
2	.4191	.4191	.4572	.4066	.4108	.3429	.3696
3	.4191	.4191	.4572	.4066	.4066	.5335	.3734
4	.4191	.4191	.4954	.439	.4066	.381	.4108
5	.4572	.4191	.5716	.5121	.4024	.4572	.4481
6	.6097	.5716	.6097	.5853	.5914	.5716	.5175
7	.6478	.6478	.6478	.695	.6584	.724	.695
8	.724	.6478	.7621	.7316	.6219	.7621	.7316
9	.724	.6859	.6859	.7316	.7316	.8383	.7316
10		.5853	.6097	.6859	.6584	.724	
11		.6219		.6859	.5121		.6097
12	.6097	.5121			.5487		.5716
13	.5716	.4755	.5335		.5121	.5335	.5335
14	.5335	.4805	.4191	.5335	.5121	.4954	.4954
15		.4755	.381	.4954	.4755		.4572
16	.4572	.439		.4572			
17	.4572	.4954	.4755		.4572	.439	.4954
18	.4954	.5716	.5914	.6478	.5716	.5487	.5335
19	.6478	.6097	.6584	.7621	.724		.6859
20	.8002	.7621	.7392	.8383	.8002	.7682	.7621
21	.7621	.7621	.7682	.7468	.7621	.7316	.7621
22	.6859	.724		.6722	.724		.6859
23	.5716	.6097	.5853	.5914	.6097		.5335
24	.4572	.4572	.4954	.4755	.4435	.4572	.439
Max	.8002	.7621	.7682	.8383	.8002	.8383	.7621
Min	.4191	.4191	.381	.4066	.4024	.3429	.3696
Avg	.5661	.5513	.5700	.5973	.5629	.5700	.5568

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 203 / 11 KV HUTATMA PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8764	.8764	.8383	.8383	.8764	.7621
2	.8383	.8764	.8764	.8383	.8383	.8383	.724
3	.8002	.8383	.8383	.8002	.8002	.8764	.724
4	.8002	.8383	.8002	.8002	.8002	.8764	.724
5	.8383	.8764	.8002	.8383	.8002	.8764	.8002
6	.8383	.8764	.8383	.8764	.8383	.8383	.8383
7	.8383	.8002	.8764	.8764	.8002	.8383	.8002
8	.8002	.7621	.8383	.8383	.8002	.8383	.8383
9	.8383	.7621	.8383	.8002	.7621	.8002	.8383
10		.8383	.8002	.9907	.9526	.9907	
11		1.0669		1.105	1.1812		1.2193
12	1.1431	.9526			1.1431		.5716
13	1.0288	.9526	.8764		1.0288	.9907	1.0288
14	.9907	.9145	.8383	.9526	.9526	.9526	.9526
15		.9907	.8383	1.0288	1.0669		.6859
16	1.0288	1.0288		1.0669			
17	1.0288	.9145	.8764		1.0288	1.0288	1.1431
18	.9145	.9145	.8764	1.0288	1.0669	1.0288	.9907
19	.9145	.9145	.8764	.9145	1.0288		.8764
20	.8383	.9145	.8764	.8002	.8764	.8764	.8764
21	.8383	.8764	.8764	.8002	.8383	.8383	.8764
22	.8002	.8764		.8383	.8383		.8764
23	.8383	.8383	.8764	.8383	.8383		.0762
24	.8383	.8383	.8764	.8764	.8383	.8764	.8002
Max	1.1431	1.0669	.8764	1.105	1.1812	1.0288	1.2193
Min	.8002	.7621	.8002	.8002	.7621	.8002	.0762
Avg	.8873	.8891	.8535	.8927	.9112	.8966	.8192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 205 / RADHA KRISHNA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.724	.7621	.7602	.7164	.7621	.7682
2	.7621	.6859	.7621	.7164	.6805	.6859	.7316
3	.724	.6859	.724	.7164	.6805	.6478	.695
4	.724	.6859	.724	.7164	.6805	.6859	.695
5	.7621	.724	.7621	.7602	.6805	.724	.7316
6	.8383	.7621	.8002	.7602	.7602	.7621	.7602
7	.9145	.8383	.8764	.8326	.8688	.8764	.8413
8	.9526	.8764	.9145	.5068	.905	.9526	.8688
9	1.1431	.9526	1.0288	.9774	1.0498	1.0669	.9774
10		1.0608	1.1812	1.2574	.905	1.1431	
11		1.5565		1.6004	1.2308		1.5623
12	1.9814	1.4842					1.6004
13	1.7909	1.448	1.7528		1.8461	1.6766	1.8671
14	1.7909	1.39	1.6385	1.7528	.9774	1.6766	1.7147
15		1.0498	1.448	1.448	1.7375		1.7528
16	1.5242	1.3032		1.5623		1.4098	
17	1.829	1.3717	1.5927		1.829	1.8099	1.7528
18	1.6766	1.5242	1.8099	1.9433	1.829	1.7558	1.7528
19	1.8671	1.6385	1.7013	1.9814	1.9433		1.8671
20	1.5242	1.6385	1.3756	1.6004	1.6766	1.6289	1.5242
21	1.2955	1.2574	1.3032	1.267	1.4098	1.448	1.2955
22	.9907	.9907		1.0498	1.1431		1.105
23	.8764	.8764	.905	.905	.9526		.9907
24	.8383	.7621	.8002	.7964	.7762	.8383	.8048
Max	1.9814	1.6385	1.8099	1.9814	1.9433	1.8099	1.8671
Min	.724	.6859	.724	.5068	.6805	.6478	.695
Avg	1.2193	1.0953	1.1431	1.1386	1.1490	1.1417	1.2118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 411 / 33 KV Incomer no I

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2007	3.0864	3.2007	3.1436	3.0864	3.0293	2.9721
2	3.0864	3.0293	3.2007	2.9721	3.0293	2.8578	2.8006
3	3.0293	3.0293	3.0864	2.9721	2.915	3.0864	2.7435
4	3.0293	2.9721	3.0864	3.0293	2.915	2.915	2.8578
5	3.1436	3.0864	3.2579	3.2007	2.915	3.0864	3.0293
6	3.4294	3.315	3.4294	3.3722	3.315	3.2579	3.2579
7	3.5437	3.4294	3.6008	3.658	3.5437	3.658	3.5437
8	3.658	3.4294	3.7151	3.7723	3.5437	3.7723	3.7723
9	3.8866	3.4865		3.7723	3.7723	3.8295	3.658
10		3.658	3.7151	4.1724	3.7723	4.1152	
11		4.5725		4.6296	4.1724		4.7439
12	5.0297	4.1724			2.8578		3.8866
13	4.6296	4.0581	3.658		4.4582	4.3439	4.5725
14	4.4582	3.9438	3.315	5.2584	3.315	4.3439	4.2295
15		3.7151	3.2579	4.0009	4.4582		4.0009
16	4.2867	3.8866		4.1724		3.9438	
17	4.2867	4.1152	3.6008		4.401	4.3439	4.4582
18	4.1152	4.1152	4.0009	4.6868	4.4582	4.5153	4.3439
19	4.5725	4.2867	4.1152	4.9154	4.8583		4.5725
20	4.401	4.6296	4.401	4.4582	4.5725	4.5725	4.401
21	4.1724	4.2867	4.3439	4.1724	4.2295	3.7723	4.1724
22	3.7151	3.8866		3.8866	3.8866		3.8866
23	3.4294	3.4865	3.658	3.5437	3.5437		3.4865
24	3.2007	3.2007	3.2579	3.315	3.2007	3.2007	3.1436
Max	5.0297	4.6296	4.401	5.2584	4.8583	4.5725	4.7439
Min	3.0293	2.9721	3.0864	2.9721	2.8578	2.8578	2.7435
Avg	3.8240	3.7032	3.5737	3.8621	3.7052	3.7025	3.7515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 201 / 11 KV AMBAI DEFENCE Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.2852	.2507	.3206	.3395	.2353	.2241
2	.2641	.2662	.2328	.2641	.2829	.2149	.2241
3	.2263	.2662	.2353	.2452	.2641	.197	.2054
4	.2263	.2472	.2353	.2452	.3018	.2149	.2054
5	.2641	.2852	.2561	.2641	.3018	.2715	.2241
6	.3018	.3042	.2715	.2829	.3206	.3077	.2427
7	.3584	.3232	.3258	.3206	.3584	.3801	.3696
8	.3772	.3613	.3475	.3734	.3772	.3982	.4108
9	.3206	.3613	.3077	.3361	.3961	.3982	.3921
10		.3423	.3292	.3734	.3206	.3801	
11		.3395		.2896	.3206		.2896
12	.2801	.2829			.2829		.2896
13	.2402	.2263	.1901		.2452	.2662	.2534
14		.2452	.2092	.1991	.2452	.2472	.2353
15		.2263	.2282		.2263	.2092	.2172
16	.2218	.2452	.2282			.2472	.2172
17	.2378	.2452	.2282		.2614	.2472	.2172
18	.2472	.2353	.2641	.2282	.2715	.2614	.2801
19	.3042	.2715	.3395	.3232	.3475		.3734
20	.3613	.4344	.415	.4373	.3856	.4435	.4481
21	.3993	.3801			.3681	.4251	.4294
22	.3993	.362			.3544	.3881	
23	.3232	.3077	.3395		.2896		.3361
24	.3206	.2852	.2534	.2829	.3018	.2353	.2427
Max	.3993	.4344	.415	.4373	.3961	.4435	.4481
Min	.2218	.2263	.1901	.1991	.2263	.197	.2054
Avg	.2997	.2970	.2744	.2991	.3114	.2984	.2876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 202 / 11 KV VIDYAPEETH

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2092	.1692		.2263	.1524	.2241
2	.2075	.2092	.1551		.2075	.1486	.2054
3	.2075	.1877	.1593		.2075	.1448	.2054
4	.2075	.1877	.1593		.2452	.1404	.2241
5	.2452	.2064	.1882		.2263	.1833	.2427
6	.2641	.244	.2201		.2829	.208	.2801
7	.2829	.2662	.2652		.3018	.208	.2801
8	.2829	.2852	.2374	.3734	.3206	.208	.2987
9	.3018	.3042	.2374	.3547	.3206	.2623	.3361
10		.2815	.2601	.3361	.3395	.2947	
11		.2641		.3467	.3772		.3366
12	.3361	.2641			.3395		.3641
13	.3142	.2452	.3566		.3772	.3423	.3366
14		.2641	.3378	.2947	.3206	.3423	.3294
15		.2452	.3423		.3395	.3042	.333
16	.2957	.2452	.319			.3566	.3467
17	.2926	.2452	.3378		.3361	.319	.3641
18	.2627	.1659	.2641	.3003	.2658	.2614	.2801
19	.244	.1783	.2641	.2627	.2294		.2614
20	.2252	.192	.2641	.2627	.2294	.2587	.2614
21	.244	.1867			.2294	.2587	.2614
22	.244	.1867			.1875	.2402	
23	.244	.1833	.2641		.1698		.2427
24	.2075	.2252	.1833	.2452	.2263	.1543	.2427
Max	.3361	.3042	.3566	.3734	.3772	.3566	.3641
Min	.2075	.1659	.1551	.2452	.1698	.1404	.2054
Avg	.2558	.2280	.2492	.3085	.2742	.2394	.2844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 203 / Siber

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4373	.3696	.3772	.415	.3326	.3361
2	.3961	.4183	.3658	.3772	.415	.3292	.3361
3	.3772	.4183	.3658	.3584	.4338	.3292	.3361
4	.3772	.4373	.4024	.3584	.4338	.3696	.3734
5	.4527	.4563	.4024	.3584	.4715	.4435	.4294
6	.4904	.4563	.4435	.4904	.5093	.5175	.5041
7	.4801	.4753	.4854	.5658	.547	.5788	.5788
8	.547	.5324	.5041	.5601	.5658	.5788	.5601
9	.5281	.5324	.4481	.5415	.5658	.5228	.5228
10		.5324	.5041	.5415	.4904	.5228	
11		.415		.5359	.5847		.5228
12	.5228	.4338			.5658		.5041
13	.4251	.3584	.4183		.4527	.5324	.4481
14		.3206	.3993	.3921	.4904	.4944	.4108
15		.3206	.4183		.4527	.4944	.3921
16	.4066	.3018	.4183			.4563	.3921
17	.3881	.3206	.3993		.4668	.4563	.4294
18	.3803	.3361	.4338	.4373	.4108	.4108	.4108
19	.4753	.4854	.5658	.6655	.5228		.4854
20	.5324	.6161	.6036	.6655	.567	.6099	.5788
21	.6084	.5788			.5729	.5729	.5788
22	.5704	.5601			.5175	.5359	
23	.4753	.4805	.4338		.4435		.3921
24	.4527	.4373	.3734	.3961	.4338	.3326	.3547
Max	.6084	.6161	.6036	.6655	.5847	.6099	.5788
Min	.3772	.3018	.3658	.3584	.4108	.3292	.3361
Avg	.466	.4442	.4378	.4763	.4926	.4710	.4490

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 411 / 33 KV Incomer no I

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.9127	.8402	.679	.9054	.7842	.7842
2	.8488	.9127	.8402	.6224	.9054	.7282	.7842
3	.7922	.8556	.8402	.6224	.9054	.7207	.7282
4	.7922	.8556	.8402	.6224	.9619	.7762	.7842
5	.9619	.9697	.8962	.6224	1.0185	.9425	.8962
6	1.0751	1.0268	1.0082	.7922	1.1317	1.1203	1.0082
7	1.1883	1.0838	1.1203	.9054	1.1883	1.2323	1.2197
8	1.1883	1.1979	1.1203	1.2883	1.2449	1.2323	1.2883
9	1.1317	1.1979	1.0751	1.8484	1.3014	1.2323	1.2323
10		1.1408	1.1203	1.2449	1.1317	1.2323	
11		1.0185		1.2323	1.3014		1.1763
12	1.1203	.9619			1.1883		1.1763
13	.9979	.8488	.9697		1.0642	1.1408	1.0642
14		.8488	.9697	.8962	1.0751	1.0838	1.0082
15		.7922	.9697		1.0185	1.0268	.9522
16	.9425	.7922	.9697		1.0642	1.0838	1.0082
17	.9425	.7922	.9697		1.0642	1.0268	1.0642
18	.9127	.8402	.9619	.9697	.9522	.9522	.9522
19	1.0268	1.0082	1.1883	1.2549	1.1203		1.1203
20	1.1408	1.3443	1.3014	1.369	1.2883	1.3306	1.2883
21	1.2549	1.2323			1.2323	1.2752	1.2883
22	1.1979	1.1763			1.1203	1.1643	
23	1.0268	1.0642	1.0185		.9522		.9522
24	.9619	.9697	.8962	.9054	.9619	.7842	.8402
Max	1.2549	1.3443	1.3014	1.8484	1.3014	1.3306	1.2883
Min	.7922	.7922	.8402	.6224	.9054	.7207	.7282
Avg	1.0204	.9935	.9958	.9922	1.0874	1.0435	1.0280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 201 / 11KV KASABA BAWADA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.8688	.905	.905		.8326	.905
2	.8688	.7964	.8688	.8688		.8145	.8145
3	.8507	.7964	.8688	.8145		.8145	.7783
4	.8869	.7964	.8688	.8145		.8145	.7964
5		.8326	.9955	.9774		.8688	.8688
6	1.1403	.8869	1.086	1.1222		1.0679	1.086
7	1.267	1.1946	1.2127	1.3575		1.3575	1.3575
8	1.267	1.2308	1.3032	1.4118		1.4661	1.3575
9	1.1403	1.2489	1.2489	1.2308		1.3756	1.3394
10		1.1041	1.0498	1.1222		1.2127	
11		1.086		.9955	1.0136		1.0317
12	.9774	.9955			1.086		.9955
13	.8869	.9231	.8688		.8869	.9774	.905
14	.905	.8688	.8507	.8145	.7602	.8869	.8688
15		.8326	.8145	.7964	.7964	.8326	.7964
16	.8145	.8507	.7964	.7964	.7602		.7964
17	.8688	1.0136	.9231		.8145	1.0317	.8688
18	1.1584	1.1222	1.2308	1.267	1.3032	1.086	1.1765
19	1.3394	1.267		1.6108	1.6832		1.4118
20	1.6832	1.7194	1.6108	1.6832	1.8099	1.5746	1.7013
21	1.6108	1.6108	1.5565		1.6289	1.5746	1.4661
22	1.448	1.5023	1.4299		1.4661		
23	1.1765	1.2489	1.1584		1.1041		1.1403
24	.9412	.9593	.9774	.9412		.9231	.9412
Max	1.6832	1.7194	1.6108	1.6832	1.8099	1.5746	1.7013
Min	.8145	.7964	.7964	.7964	.7602	.8145	.7783
Avg	1.1068	1.0732	1.0774	1.0850	1.1626	1.0840	1.0638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 202 / 11 KV KOLHAPUR SUGAR MILL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3395	.3206	.3361		.2829	.3174
2	.3018	.3206	.3018	.3361		.2829	.3206
3	.3206	.3206	.3018	.3395		.2829	.3174
4	.3395	.3206	.3018	.3174		.2829	.3174
5	.3395	.3584	.3018	.3018		.2829	.3018
6	.3018	.3584	.3018	.2987		.2829	.2801
7	.3206	.3584	.3018	.2829		.2829	.2829
8	.3018	.3961	.3018	.2772		.2829	.3018
9	.3772	.415	.3584	.3772		.3018	.3206
10		.3961	.415	.3734		.3395	
11		.3584		.3961	.4108		.3772
12	.3961	.415			.3734		.4108
13	.3772	.415	.4527		.3361	.3584	.3772
14	.3772	.415	.3961	.3395	.3174	.3206	.3772
15		.3961	.3961	.3961	.2801	.3772	.3395
16	.3772	.3772	.3961	.415	.3547		.3547
17	.3584	.415	.3734		.3018	.2587	.3584
18	.3206	.3395	.3395	.3584	.3584	.3361	.3584
19	.3395	.3772		.3018	.3395		.3018
20	.415	.3395	.3584	.3018	.2829	.3734	.3584
21	.3772	.3395	.3584		.2829	.3734	.3772
22	.3772	.3361	.3018		.2641		
23	.3361	.2987	.2957		.2452		.3206
24	.2829	.3174	.3395	.3511		.2452	.3395
Max	.415	.415	.4527	.415	.4108	.3772	.4108
Min	.2829	.2987	.2957	.2772	.2452	.2452	.2801
Avg	.3447	.3635	.3435	.3389	.3190	.3082	.3369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 203 / 11KV ULAPEMALA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.128	.1097	.128		.0732	.0914
2	.0914	.128	.0914	.128		.0732	.0914
3	.0914	.128	.0914	.128		.0732	.0914
4	.0914	.128	.0914	.128		.0732	.0914
5	.1097	.128	.0914	.128		.0914	.1097
6	.1097	.1463	.1097	.1463		.1097	.1097
7	.0914	.1463	.1097	.128		.1097	.128
8	.0914	.1463	.1097	.1463		.128	.1097
9	.2195	.1463	.0914	.128		.128	.1646
10		.1463	.0914	.128		.1097	
11		.1097		.128	.1097		.1463
12	.1097	.1097			.1097		.0914
13	.1463	.1097	.1646		.1097	.1097	.1097
14	.128	.1097	.2012	.1463	.0914	.1463	.1097
15		.1097	.0914	.1463	.0914	.128	.1463
16		.1097	.128	.1097	.0914	.128	.128
17	.1097	.1097	.1097		.0732	.0914	.0914
18	.128	.1097	.128	.0914	.0914	.1463	.0914
19	.128	.1097		.128	.1097		.128
20	.1463	.1463	.1463	.128	.1097	.128	.1463
21	.1463	.128	.1646		.1097	.128	.1463
22	.1463	.128	.1463		.1097		
23	.1463	.128	.1097		.0914		.1097
24	.0914	.128	.1097	.128		.0732	.0914
Max	.2195	.1463	.2012	.1463	.1097	.1463	.1646
Min	.0914	.1097	.0914	.0914	.0732	.0732	.0914
Avg	.1207	.1257	.1184	.1290	.0999	.1078	.1147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 204 / 11 KV WADANAGE GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3881	.3511	.3696	.3326		.2957	.2957
2	.3696	.3326	.3511	.3326		.2772	.2772
3	.3696	.3326	.3511	.3326		.2772	.2772
4	.3696	.3326	.3511	.3326		.2772	.2772
5	.3881	.4066	.4066	.4066		.3511	.3696
6	.5544	.499	.499	.5359		.462	.462
7	.6283	.6283	.6099	.6468		.6653	.6653
8	.6283	.6468	.6468	.6468		.6283	.6838
9	.5544	.6838	.5914	.5729		.5729	.6468
10		.5914	.5359	.5544		.5359	
11	.499	.5175		.5359	.5729		.5175
12	.499	.499			.4251		.4435
13	.462	.462	.1294		.4435	.3881	.3881
14	.4066	.7392	.1109	.3696	.3881	.3511	.3142
15		.4066	.3326	.3511	.3696	.3696	.3511
16	.4435	.462	.3696	.3511	.4251	.4435	.3696
17	.4805	.5914	.5175		.5359	.499	.4251
18	.5175	.5544	.6099	.5544	.4805	.5544	.499
19	.6838	.6653		.6838	.7207		.7023
20	.7947	.7762	.7392	.7207	.7577	.7762	.7762
21	.7577	.7392	.7023		.7023	.7207	.7207
22	.6838	.6653	.6283		.5729		
23	.462	.499	.462		.4066		.4435
24	.3881	.3696	.3881	.3696		.3142	.3142
Max	.7947	.7762	.7392	.7207	.7577	.7762	.7762
Min	.3696	.3326	.1109	.3326	.3696	.2772	.2772
Avg	.5149	.5313	.4620	.4794	.5231	.4610	.4645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 205 / 11 KV Sarwal AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0347		.0693	
2				.0347		.0693	
3				.0347		.0693	
4				.0347		.0693	
5				.0347		.0867	
6				.0347		.104	
7				.0347		.104	
9	.052	.052				.104	.104
10	.0347	.052				.104	
11	.0347	.052					
12	.0347	.052					.0173
13	.052	.052				.1214	.0173
14		.0347				.1214	.0173
15		.0347				.1214	.0173
16		.052				.1214	.0173
22			.052		.0693		
23			.052		.0693		
24				.052		.0693	
Max	.052	.052	.052	.052	.0693	.1214	.104
Min	.0347	.0347	.052	.0347	.0693	.0693	.0173
Avg	.0416	.0477	.052	.0369	.0693	.0953	.0318

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 202 / 11KV FILTER HOUSE FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9335					
2		.9335					
3		.9431					
4		.8402					
5		.8402					
6		.8402					
7		1.0269					
8		1.1763		1.3443			
9		1.0082	1.4377	1.419			
10		1.0562					
11		1.0562					
12	1.4003	.9242					
13		.8676	1.3203		1.307	1.7187	.9145
14		.9997			1.1949	1.4632	
15		1.0374	1.1883		1.1517	1.307	1.1706
16		.9997	1.1694	1.2449	1.1763		
17	1.2071		1.1949	1.1694	1.1694	1.2136	1.1888
18	1.1888	.695	1.2449	1.2323	1.1317	1.307	1.1576
19			1.3014	1.2449	1.251	1.358	1.2883
20	1.39	1.2803		1.3769	1.4335	1.5089	
21	1.3169	1.2437			1.3769	1.4003	1.3443
22					1.2696		
24		.9896	1.0082	.9896		.9997	
Max	1.4003	1.2803	1.4377	1.419	1.4335	1.7187	1.3443
Min	1.1888	.695	1.0082	.9896	1.1317	.9997	.9145
Avg	1.3006	.9846	1.2331	1.2527	1.2462	1.3640	1.1774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 203 / 11KV AKASHWANI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6036					
2		.6036					
3		.5975					
4		.5601					
5		.5601					
6		.5601					
7		.7095					
8		.8676		.9896			
9		.9149	1.0082	1.1016			
10		1.0269					
11		.9431					
12	.9896	.8488					
13	.8962	.7842	.9242		.9425	.9335	.9511
14		.7356			.9149	.8596	
15		.6979	.8676		.823	.8048	.8048
16		.679	.8215	.8299	.823		
17	.7682			.811	.8299	.8488	
18	.8215	.6535	.7545	.8488	.8775	.8215	1.1576
19			.9335	.9431	.9619	.9335	.9896
20	.9877	.9522		1.0374	1.0642	1.0642	
21	.9328	.9328			.9709	.9522	1.0082
22					.9522		
24		.6535	.679	.6722		1.0829	
Max	.9896	1.0269	1.0082	1.1016	1.0642	1.0829	1.1576
Min	.7682	.5601	.679	.6722	.823	.8048	.8048
Avg	.8993	.7442	.8555	.9042	.916	.9223	.9823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 205 / 11KV LAXMIPURI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7468					
2		.7468					
3		.6535					
4		.6535					
5		.6535					
6		.7095					
7		.7167					
8		.811		.8775			
9		.8775	1.0269	1.0456			
10		.9522					
11		1.0751					
12	1.2936	1.094					
13	1.2382	.9431	1.1827		1.2696	1.1763	1.307
14		.9242			1.1576	.9877	
15		.8589	1.0829		.5487	1.1157	1.1157
16		.8589	1.0534	1.1763	.9335		
17	1.2136			1.1203	1.1506	1.1694	1.0974
18	1.1523	.9694	1.358	1.2696	1.1576	1.1763	1.1949
19	1.3169		1.4712	1.363	1.3817	1.3392	1.307
20	1.3717	1.262		1.4146	1.3443	1.4146	
21	1.1706	1.1157			1.1576	1.1763	1.1949
22					1.0642		
24		.7468	.7655	.7655		.7392	.7842
Max	1.3717	1.262	1.4712	1.4146	1.3817	1.4146	1.307
Min	1.1523	.6535	.7655	.7655	.5487	.7392	.7842
Avg	1.2510	.8685	1.1344	1.1291	1.1165	1.1439	1.1430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 206 / 11KV USHA TALKIES FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7468					
2		.7468					
3		.6535					
4		.6535					
5		.6602					
6		.7468					
7		.8488					
8		.9242		.9709			
9		.9335	.9896	1.0456			
10		.9896					
11		1.0185					
12	1.2136	1.0185					
13		1.0185	.9619		1.1949	.9145	1.1523
14		.9149			1.1389	1.1088	
15		.8962			1.0608	1.1016	1.1389
16		.9054		1.1389	1.0791		
17	1.2986		1.251	1.1576	1.1506	1.1576	1.1706
18	1.1706	.8596	1.2637	1.1949	1.1203	1.1949	1.1389
19			1.3014	1.251	1.226	1.2826	1.2323
20	1.251	.9328		1.226	1.2136	1.2449	
21	1.1157	1.0425			1.0456		1.0829
22					.9709		
24		.7655	.8299	.8029		.7922	
Max	1.2986	1.0425	1.3014	1.251	1.226	1.2826	1.2323
Min	1.1157	.6535	.8299	.8029	.9709	.7922	1.0829
Avg	1.2099	.8638	1.0996	1.0985	1.1201	1.0996	1.1527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 208 / 11KV BLOOD BANK FEEDER Urban/Sheddable Urban Feeder
 Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668					
2		.4668					
3		.4668					
4		.4668					
5		.4854					
6		.4854					
7		.5228					
8		.5415		.5975			
9		.5601	.6722	.6535			
10		.5975					
12	.7922	.6224					
13	.7392	.5788	.8299		.7316	.695	.7682
14		.5415			.6908	.695	
15		.547	1.3014		.7316	.695	.7316
16		.5228		.7282	.7095		
17	.695			.7095	.7167	.6908	.695
18	.6767	.5487		.7167	.7095	.7095	
19				.7842	.7545	.7095	.9335
20	.7316	.695		.7545	.8029	.811	
21	.6584	.6584			.6908	.6908	.6908
22					.6161		
24		.4904	.4668	.5041		.5093	
Max	.7922	.695	1.3014	.7842	.8029	.811	.9335
Min	.6584	.4668	.4668	.5041	.6161	.5093	.6908
Avg	.7155	.5403	.8176	.6810	.7154	.6895	.7638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 411 / 33 KV Nagala Park

HV Non-Express Feeder

Feeder KV- 33 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		4.257					
2		4.257					
3		4.0741					
4		3.8649					
5		3.9043					
6		4.0329					
7		4.537					
8		5.2058		5.9934			
9		5.2092	6.1614	6.6095			
10		5.8282					
11		6.0494					
12	7.2074	5.8814					
13	4.3799	5.6584	7.7063		7.1331	7.3525	6.9685
14		5.3772			6.7776	7.0016	
15		5.3189	7.2074		6.1054	6.6392	6.5844
16		5.156		6.6095	6.2003		
17	6.4312			6.6655	6.6095	7.2257	5.8711
18	6.2552	5.1029		7.1696	6.7776	7.0576	7.5823
19	6.749			7.7858	7.6389	7.7858	7.9538
20	7.4074	7.1331		8.0098	8.0659	8.4311	
21	6.5295	6.4746			7.1136		7.0576
22					6.2734		
24		4.481	4.6399	4.7051		4.6571	
Max	7.4074	7.1331	7.7063	8.0098	8.0659	8.4311	7.9538
Min	4.3799	3.8649	4.6399	4.7051	6.1054	4.6571	5.8711
Avg	6.4228	5.0902	6.4288	6.6935	6.8695	7.0188	7.0030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 201 / 11KV S.T. STAND FEEDER Urban/Sheddable Urban Feeder
 Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7655	.6845	.7468	.7282			.7207
2		.6084	.7282	.7545			.7095
3	.7207	.6078	.7095	.7733			.6722
4		.6268	.6908	.7733			.6908
5	.7282	.6084	.7095	.8029			.7468
6	.8029	.7606	.7468	.8488			.7762
7	.9522	.8937	.9522	.8676			.8775
8		1.0288	.9149	.9907			1.0642
9	.9997	1.0098	1.0185	.9522		1.0642	1.1506
10		1.0288	1.1017	1.1389		1.1622	
11				1.1506	1.2071		1.2071
12	1.2071	1.2637			1.094		1.226
13	1.0751	1.0456	1.1408		1.094	1.2071	1.1694
14	1.0751	.9896	1.2169	1.0829	1.094	1.1506	1.0751
15		.8589	1.1241	1.1203	1.0751	1.0751	.9619
16	1.0374	.9149		1.0642			1.0374
17	1.0447	.9335	1.086		1.0269	1.0349	1.0829
18	1.1017	1.1203	1.0562	1.1763	1.1203	1.1128	1.1389
19	1.2524	1.1203	1.2136	1.3256	1.2323	1.3014	1.307
20	1.4042	1.3256	1.2696	1.2936		1.3443	1.3817
21	1.3392		1.1949	1.2136	1.2637	1.3014	1.307
22	1.1408				1.0456		
23	.9907	.9335	.8215		1.1203		1.0269
24	.7842	.7606	.9522	.7095		.7655	.7545
Max	1.4042	1.3256	1.2696	1.3256	1.2637	1.3443	1.3817
Min	.7207	.6078	.6908	.7095	1.0269	.7655	.6722
Avg	1.0234	.9107	.9697	.9877	1.1248	1.1381	1.0038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 202 / 11 KV LINE BAZAR FEEDER Urban/Sheddable Urban Feeder
 Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2812	.2957	.3077			.2743
2		.263	.2987	.3077			.2534
3	.2561	.2619	.2772	.3224			.2534
4		.263	.2957	.3403			.2987
5	.3511	.2619	.3547	.3841			.3326
6	.4066	.3193	.4251	.3982			.3881
7		.3562	.3881	.4251			.4668
8		.3961	.4435	.4108			.499
9	.4481	.4145	.4435	.4344		.4656	.4481
10		.3734	.3889	.4481		.4251	
11		.3077		.4108	.3801		.3439
12	.3841	.3077			.362		.3109
13	.8402	.2743	.3125		.3258	.3292	.3109
14	.3077	.2865	.3677	.3696	.3258	.2926	.3258
15		.2454	.3497	.3142	.3077	.2926	.2804
16	.2896	.2534		.3142		.2587	.2715
17	.3624	.3292	.2561		.2743	.3109	.3361
18	.3261	.3361	.3439	.3921	.3547	.3801	.3142
19	.4362	.4294	.4207	.499	.5041	.439	.4251
20	.5116	.5601	.4887	.499		.5304	.5121
21	.4964		.4706		.5041	.4938	.5041
22	.4596				.4668		
23	.3897	.4108	.362		.3921		.3881
24	.3142	.3168	.7392	.2926		.3142	.2957
Max	.8402	.5601	.7392	.499	.5041	.5304	.5121
Min	.2561	.2454	.2561	.2926	.2743	.2587	.2534
Avg	.4112	.3295	.3861	.3817	.3816	.3777	.3561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 203 / 11 KV EXCISE FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2136	1.1028	1.1949	1.1694			1.0829
2		1.0648	1.1883	1.1576			1.0374
3	1.1763	1.0637	1.1576	1.1883			.9709
4		1.0648	1.1389	1.2136			.9335
5	1.2136	1.0648	1.2883	1.3203			1.0456
6	1.419	1.1218	1.3769	1.307			1.3256
7		1.2929	1.4377	1.363			1.5123
8		1.3972	1.4937	1.5051			1.6787
9	1.4937	1.5529	1.531	1.6032		1.7737	
10		1.4937	1.6715	1.6804		1.5466	
11		1.6057		1.6617	1.6244		
12	1.6598	1.5123			1.5466		1.6787
13	1.6057	1.4146	1.6162		1.5089	1.4377	1.4523
14	1.475	1.3203	1.426	1.3443	1.4335	1.2826	1.358
15		1.3769	1.512	1.3443	1.3957	1.3392	1.3957
16	1.3443	1.1812				1.2637	1.4523
17	1.3419	1.2136	1.4335		1.307	1.3717	1.419
18	1.3986	1.1949	1.5278	1.4901	1.3443	1.5278	1.4563
19	1.701	1.4377	1.6617	1.8107	1.5684	1.6991	1.587
20	1.8896	1.7177	1.773	1.7541		1.8296	1.8671
21	1.7353		1.6598		1.7924	1.7737	1.7551
22	1.6221				1.6244		
23	1.4407	1.4937	1.3392		1.4377		1.4377
24	1.251	1.1812	1.2323	1.1506		1.1389	1.1317
Max	1.8896	1.7177	1.773	1.8107	1.7924	1.8296	1.8671
Min	1.1763	1.0637	1.1389	1.1506	1.307	1.1389	.9335
Avg	1.4695	1.3122	1.4330	1.4155	1.5076	1.4987	1.3789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 204 / 11KV SHAHU COLLEGE FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6838	.6655	.6722	.7023			.5914
2		.6655	.6535	.7095			.5544
3	.6468	.6275	.6468	.6468			.5304
4		.6084	.6908	.6348			.5487
5	.7207	.6084	.7655	.7207			.6653
6	.924	.6845	.8589	.7947			.7468
7	.9335	.7415	.924	.8962			.9522
8		.9867	.961	1.0562			1.0269
9	.9431	1.0395	.9335	1.0185		1.0082	
10		.9242	.8865	.8871		.9808	
11		.811		.7762	.8402		.9335
12	.7095	.7842			.7842		.8299
13	.8402	.7095	.7371		.7545	.7922	.7545
14	.7842	.7282	.7035	.6722	.6979	.7095	.6908
15		.6722	.6783	.6348	.6535	.6161	.679
16	.6535	.6036		.6535	.6161	.5847	.6535
17	.708	.5975	.6413		.6413	.6535	.5601
18	.7274	.6653	.8029	.8316	.7655	.7545	.6908
19	.8668	.8131	1.0164	.9774	.9335	.9709	.9335
20	1.028	1.0642	1.0642	1.0269		1.0082	1.0082
21	1.0165		1.0751		.9145	1.0269	.9896
22	.9887				.9522		
23	.8711	.8962	.8589		.8215		.8215
24	.7282	.7408	.6908	.6979		.6653	.6722
Max	1.028	1.0642	1.0751	1.0562	.9522	1.0269	1.0269
Min	.6468	.5975	.6413	.6348	.6161	.5847	.5304
Avg	.8208	.7563	.8131	.7965	.7812	.8142	.7540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 205 / RAW WATER WORKS

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0194	.0895	.0747			.0206
2		.0196	.0739	.0739			.0183
3	.0693	.0229	.0693	.0924			.0274
4		.0204	.0663	.0934			.032
5	.0709	.0204	.0819	.0739			.0427
6	.104	.0204	.0876	.056			.0524
7	.0829	.0187	.0829	.056			.0514
8	.0886	.0151	.0829	.0747			.0514
9	.0617	.0166	.0655	.056		.064	
10		.0934	.0381	.0829		.0747	
11		.0934		.0648	.056		.0747
12	.0412	.0934			.0373		.0739
13	.0381	.0934	.0265		.0747	.0747	.0747
14	.0351	.0934	.0428	.0655	.0747	.0747	.0739
15		.0934	.0537	.0655	.056	.0747	.0747
16	.0419	.0934		.0663	.0747	.0934	.0747
17	.0289	.112	.0747		.0934	.0619	.0848
18	.0281	.0867	.0934	.0366	.0995	.0295	.0838
19	.0477	.1052	.056	.0514	.0829	.0314	.0829
20	.0328	.0995	.0747	.0553		.0305	.0663
21	.0391		.0747		.0995	.0663	.0663
22	.0586				.0829		
23	.0259	.0648	.056		.0503		.0995
24	.0709	.0194	.0867	.0747		.0663	.0427
Max	.104	.112	.0934	.0934	.0995	.0934	.0995
Min	.0259	.0151	.0265	.0366	.0373	.0295	.0183
Avg	.0537	.0598	.0689	.0674	.0735	.0618	.0604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 206 / APPLE HOSPITAL.

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0756	.0747	.0895			.0554
2		.0755	.0747	.0724			.0549
3	.0739	.0756	.0747	.0739			.056
4		.0756	.0747	.0724			.0549
5	.0554	.0756	.0747	.0732			.0554
6	.0739	.0754	.0747	.0732			.0732
7	.0924	.0754	.0934	.0739			.112
8		.0752	.0747	.056			.0739
9	.0554	.0936	.0934	.0934		.0747	
10		.0914	.1331	.1109		.1097	
11		.0724		.112	.0905		.1097
12	.112	.0924			.1132		.1109
13	.1307	.0543	.1136		.0943	.0739	.1334
14	.112	.0566	.1141	.168	.0934	.0924	.0934
15		.0566	.1334	.1307	.1109	.1109	.0914
16	.112	.0739		.112	.112	.0924	.1132
17	.1117	.0747	.0747		.0934	.0924	.1109
18	.0743	.0934	.112	.0905	.0914	.0924	.1109
19	.0931	.0739	.0716	.0895	.0934	.0924	.1097
20	.1133	.0934	.0549	.0905		.0914	.1097
21	.0947		.0905		.0747	.0914	.0739
22	.0953				.0747		
23	.0889	.0924	.0905		.0747		.0554
24	.0739	.0758	.0747	.0905		.0724	.0724
Max	.1307	.0936	.1334	.168	.1132	.1109	.1334
Min	.0554	.0543	.0549	.056	.0747	.0724	.0549
Avg	.0910	.0772	.0886	.0929	.0931	.0905	.0872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 207 / 11 KV STP Express

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.2075				
9		.2075				
10		.0572			.2286	
11			.1886			.2286
12				.2477		.2096
13	.2286	.0572		.2286		
14	.1905		.2075			
15		.0572		.2286	.2286	.2096
16				.2286	.2286	.2096
17	.0572			.2477	.4938	
18					.3395	
Max	.2286	.2075	.2075	.2477	.4938	.2286
Min	.0572	.0572	.1886	.2286	.2286	.2096
Avg	.1588	.1173	.1981	.2362	.3038	.2144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 202 / 11KV RANKALA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.8779	.8871	.8871		.8686	.8779
2	.8501	.823	.8589	.8501		.8589	.8779
3	.8501	.823	.8402	.8501		.8589	.8413
4	.8686	.823	.8589	.8501		.8962	.8413
5	.8686	.8596	.8962	.8871		.9335	.9511
6	.8871	.905	1.0269	1.0903		1.0082	1.0425
7	1.2696	1.1222	1.1576	1.2936		1.2883	1.2254
8	1.2696	1.2127	1.2696	1.386		1.46	1.39
9	1.1827	1.2851	1.2883	1.2936		1.386	1.262
10		1.2308		1.134	1.0903	1.0974	
11		1.1222		1.0974	1.1016		.9694
12	1.0059	1.0498			1.0534		.9145
13	1.0608	.9593			.961	.8688	.8779
14	.9231	.8688		.8669	.8686	.7964	.8596
15	.905	.8869		.7455	.8316	.8507	.8596
16	.8417	.8688					
17	.8417	.8507			.8686	.8413	.9055
18	.9774	.9671		.9955	1.1104	1.0974	1.086
19	1.2308	1.258	1.9774	1.448	1.4327		1.448
20	1.5746	1.576	1.9035	1.4118	1.6108	1.6095	1.5927
21	1.448	1.4685	1.8296		1.4842	1.5364	1.5203
22	1.4118	1.4118			1.3575	1.4266	1.4118
23	1.2308	1.134	1.0164		1.1041		1.0791
24	.8779	.9522	.9425	.9425		.8962	.9328
Max	1.5746	1.576	1.9774	1.448	1.6108	1.6095	1.5927
Min	.8413	.823	.8402	.7455	.8316	.7964	.8413
Avg	1.0553	1.0557	1.1967	1.0606	1.1442	1.0831	1.0803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 203 / 11KV MAHALAXMI SANEGURUJI Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.724	.7522	.724		.6447	.543
2	.6653	.6878	.7164	.724		.6089	.543
3	.6653	.6878	.6805	.6878		.6089	.5658
4	.7392	.6878	.7164	.724		.6447	.5792
5	.7762	.724	.7522	.7602		.6805	.6516
6	.8686	.7421	.8596	.788		.788	.7783
7	.9522	.8238	.8775	.9412		.9671	.9593
8	1.0349	.9313	.9492	.9492		1.0208	.9955
9	.9979	.8238	1.0029	.9671		1.0208	1.0136
10		.8954		.8238	.8413	.9055	
11		1.0029		.7343	.7865		.8059
12	.7522	.7343			.7499		.7522
13	.7164	.6984			.7499	.6878	
14	.7343	.591		.6626	.7133	.7059	.6089
15	.7164	.6984		.6268	.6219		.6089
16	.6805	.6268					
17	.6984	.6268			.6516	.6805	.6805
18	.788	.7701		.8596	.8596	.8059	.8505
19	.9671	1.0208	1.4842	1.1462	1.0924		1.1041
20	1.3253	1.3073	1.448	1.3611	1.3432	1.2894	1.3073
21	1.2178	1.2536	1.4377		1.182	1.2489	1.2357
22	1.1641	1.1641			1.0745	1.1462	1.1403
23	.8596	.9671	.905		.8596		.8688
24	.7522	.7522	.7701	.7783		.6447	.543
Max	1.3253	1.3073	1.4842	1.3611	1.3432	1.2894	1.3073
Min	.6653	.591	.6805	.6268	.6219	.6089	.543
Avg	.8547	.8309	.9537	.8387	.8866	.8388	.8160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 205 / PUIKHADI WATER WORKS Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5093	.4527	.1886		.5014	.5281
2	.4904	.5093	.4904	.5658		.4527	.4527
3	.5093	.5093	.4904	.5658		.4527	.4527
4	.5281	.5093	.5281	.5658		.5014	.5281
5	.547	.5281	.5281	.5658		.5658	.5658
6	.5658	.5228	.4527	.5658		.6036	.5658
7	.547	.5228	.4527	.543		.5658	.5658
8	.5093	.2829	.5281	.5658		.5658	.5658
9	.5281	.1886	.4527	.5658		.5281	.5658
10		.2829		.5658	.5658	.5847	
11		.1509		.5658	.5658		.4527
12	.5281	.2829			.5658		.4527
13	.5281	.2829		.5281	.5093	.5281	
14	.5281	.415		.5658	.5658	.5093	.5658
15	.5281	.4338		.5281	.5658		.5658
16	.5281	.4715				.5658	
17	.5658	.3018			.5658	.5093	.5658
18	.5093	.3018		.5373	.5658	.5658	.547
19	.5041	.4527	.0343	.5228	.6036		.5281
20	.4854	.4527	.0377	.5415	.5281	.5658	.5658
21	.4854	.4527	.0905		.5658	.5093	.547
22	.5228	.4527			.5658	.4715	.547
23	.4668	.4527	.1886		.5658		.5281
24	.5281	.4854	.4527	.1886		.5281	.547
Max	.5658	.5281	.5281	.5658	.6036	.6036	.5658
Min	.4668	.1509	.0343	.1886	.5093	.4527	.4527
Avg	.5193	.4065	.3700	.5131	.5615	.5303	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 206 / K N Patil Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2801	.2858	.2829		.2667	.2427
2	.2667	.2614	.2667	.2641		.2477	.2241
3	.2667	.2614	.2667	.2641		.2477	.2241
4	.3429	.2614	.2858	.3018		.2667	.2614
5	.3772	.2614	.3429	.3395		.3048	.2987
6	.4338	.3174	.381	.3584		.3429	.3361
7	.5093	.3734	.5281	.5228		.5716	.5415
8	.5658	.5041	.5093	.5788		.6413	.5601
9	.4854	.5041	.5093	.5601		.6036	.5601
10		.4668		.462	.3921	.4294	
11		.4294		.3881	.3921		.3734
12	.3881	.3734			.3921		.3696
13	.3511	.3475			1.4563	.3326	.3292
14	.3361	.3292		.3224	.2987	.3361	.2926
15	.2987	.2926		.3045	.2987		.2241
16	.2614	.2926				.2987	
17	.2926	.2926			.3361	.3142	.3475
18	.3841	.3658		.4251	.462	.4066	.4024
19	.5304	.4938	.6908	.4805	.5359		.5729
20	.5729	.6283	.6908	.5914	.6348	.6099	.6099
21	.5228	.5729			.5788	.5729	.5914
22	.5228	.547			.5228	.499	.5228
23	.4108	.3961	.3734		.3584		.3772
24	.2858	.2987	.3048	.2987		.2667	.2614
Max	.5729	.6283	.6908	.5914	1.4563	.6413	.6099
Min	.2614	.2614	.2667	.2641	.2987	.2477	.2241
Avg	.3942	.3813	.4181	.3968	.5122	.3978	.3874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 201 / 11 KV MASKUTI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4435	.4805	.4525		.5487	.4887
2	.4435	.4435	.4435	.4344		.5068	.4706
3	.4251	.4066	.4435	.4344		.4706	.4525
4	.4251	.4066	.4435	.4344		.4706	.4525
5	.439	.4805	.4805	.4344		.5487	.4525
6	.5304	.5228	.5228	.4887		.6468	.543
7	.5228	.5228	.5975	.5249		.6224	.5973
8	.5544	.5601	.5914	.6283		.7468	.6878
9	.5914	.6653	.6283	.6154		.7762	.8507
10		.6154		.5611	.7682	.7865	.7421
11	.5611	.5611		.5316	.6516		.6878
12	.5249	.543		.567	.7059		
13	.5028	.5249	.3898	.4607	.5853	.6516	.4252
14	.4435	.439	.3582	.439	.567	.6283	.4656
15		.3982	.3801		.5068		.4024
16	.3801	.4163			.5611		.4298
17	.4887	.5068	.443		.6154	.5792	.4075
18		.5258	.6024	.8417	.7442	.8417	.5493
19	.7087	.7619	.7164	1.0387	1.0631	1.1283	.7343
20	.9465	.8764	.8505	1.1222	1.1104	1.1584	.8417
21	.8505	.815	.8417		1.0208	1.0498	.8328
22	.788	.788	.7964				.788
23	.6516	.6584	.6154		.7421	.7316	.6697
24	.5121	.5175	.5487	.4887		.567	.5611
Max	.9465	.8764	.8505	1.1222	1.1104	1.1584	.8507
Min	.3801	.3982	.3582	.4344	.5068	.4706	.4024
Avg	.5596	.5583	.5587	.5832	.7417	.7084	.5884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 202 / 11KV GANGAVES

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1886	.1886	.1494		.1463	.1663
2	.1509	.1509	.1509	.1509		.132	.1478
3	.132	.132	.1509	.132		.132	.1478
4	.132	.132	.1509	.132		.132	.1478
5	.1509	.1886	.1886	.132		.1509	.1478
6	.1698	.2263	.2263	.1698		.1698	.1478
7	.1886	.1886	.2263	.1715		.1886	.2033
8	.1886	.2263	.2263	.2075		.2075	.2218
9	.2263	.2641	.2641	.2587		.2263	.2402
10		.2427		.3658	.2957	.2926	.3142
11	.3142	.2587		.3658	.3326		.3292
12	.3142	.3142		.362	.3511		.2743
13	.3142	.2772	.2926	.362	.3439	.3258	.2835
14	.2957	.2427	.2772	.362	.2772	.3109	.3292
15		.2241	.3109		.2772		.2926
16	.3109	.2715			.3326		.3109
17	.2926	.2743	.3439		.3475	.3439	.3258
18		.3077	.394	.362	.3258	.3801	.3582
19	.3658	.3761	.4607	.4525	.443	.4344	.4344
20	.4298	.3898	.4252	.4477	.4298	.4298	.4163
21	.362	.3258	.3439		.3045	.3258	.3403
22	.2926	.2534	.2561		.2353		.2378
23	.2218	.2587	.2033		.2033	.2033	.2033
24	.1867	.1867	.2241	.168		.168	.1663
Max	.4298	.3898	.4607	.4525	.443	.4344	.4344
Min	.132	.132	.1509	.132	.2033	.132	.1478
Avg	.2472	.2459	.2652	.2640	.3214	.2474	.2578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 203 / 11KV MAHADWAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.9979	.924	.8779		.9431	.823
2	.8596	.924	.8871	.8413		.8676	.7865
3	.8413	.8871	.8871	.8413		.8676	.7682
4	.8316	.8871	.8871	.8413		.8676	.7682
5	.8501	.8871	.961	.8596		.9808	.7682
6	1.0349	.9054	1.0456	.8962		1.1317	1.0974
7	1.2136	1.0562	1.1203	1.0791		1.2637	1.0974
8	1.3121	1.2071	1.2323	1.1888		1.4523	1.2437
9	1.3575	1.307	1.3443	1.3169		1.6598	1.3352
10		1.2803		1.39	1.6461	.8488	1.3352
11	1.4449	1.2986		1.3169	1.5912		1.3394
12	1.39	1.3169		1.3535	1.5364		1.2127
13	1.39	1.2254	1.2851	1.2894	1.4449	1.3575	1.1641
14	1.2071	1.134	1.2254	1.1946	1.3535	1.1888	1.0974
15		1.0608	1.1403		1.3169		1.086
16	1.1157	1.0974			1.39		
17	1.1523	1.134	1.182		1.5181	1.1403	1.1584
18		1.3032	1.4449	1.4299	1.587	1.5402	1.4299
19	1.7364	1.6655	1.8839	1.9366	2.0698	2.0485	1.7909
20	2.0774	1.9163	1.9387	2.0553	2.2177	2.0668	2.0553
21	1.8625	1.7013	1.5912		1.848	1.7193	1.701
22	1.5565	1.5203	1.4815				1.4327
23	1.2308	1.3032	1.1157		1.2696	1.134	1.1765
24	1.0059	1.0974	.9511	.8962		.9877	.8779
Max	2.0774	1.9163	1.9387	2.0553	2.2177	2.0668	2.0553
Min	.8316	.8871	.8871	.8413	1.2696	.8488	.7682
Avg	1.2555	1.2131	1.2264	1.2003	1.5992	1.2666	1.1976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 204 / MIRABAG

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6805	.7023	.7316	.6878	
2	.6697	.6653	.695	.6516	
3	.6584	.6283	.6584	.6335	
4	.6584	.6283	.6584	.6335	
5	.6838	.6653	.7316	.6516	
6	.8316	.6722	.8779	.724	
7	.8871	.8131	.8962	.905	
8	.9425	.961	.8871	.9774	
9	.8779	.9979	.924	.9593	
10		.9593		.8688	
11	.8145	.905		.6584	
12	.8145	.905		.8596	
13	.724	.8145	.6984		
14	.7602	.7421	.7087		.6733
15		.7059	.6805		.6626
16	.7059	.724			.6805
17	.7964	.8145	.6984		.7362
18		.8507	.8326		.8596
19	1.0387	1.0745	.9231		1.0974
20	1.3969	1.3432	1.2489		1.3394
21	1.3394	1.3253	1.3032		1.267
22	1.1946	1.2127	1.1584		1.1765
23	.9774	.9774	.905		.9134
24	.7421	.7522	.7522	.724	
Max	1.3969	1.3432	1.3032	.9774	1.3394
Min	.6584	.6283	.6584	.6335	.6626
Avg	.8664	.8683	.8485	.7642	.9406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 206 / 11 KV SAKOLI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2587	.2987	.2561		.2353	.2715
2	.2587	.2587	.2614	.2378		.2172	.2353
3	.2402	.2218	.2241	.2195		.2263	.2353
4	.2427	.2218	.2241	.2195		.2263	.2172
5	.2427	.2587	.2987	.2561		.2829	.2172
6	.2987	.3018	.3361	.3109		.3142	.2896
7	.3734	.4108	.4481	.4344		.4066	.4344
8	.4251	.4435	.4854	.4344		.4805	.4525
9	.4572	.4805	.4805	.6154		.4706	.4706
10		.4525		.4163	.4163	.4755	.4656
11	.4706	.4344		.4706	.4572		.3761
12	.4163	.3982		.4252	.4163		.4075
13	.4207	.3982	.394	.4252	.3801	.3582	.3761
14	.362	.362	.3801	.362	.3439	.362	.3761
15		.3258	.3439		.3258		.3439
16	.3439	.3258			.3439		.3544
17	.362	.3439	.3258		.362	.3801	.3721
18		.3801	.4163	.4252	.3814	.4344	.4298
19	.4908	.4706	.5304	.5373	.5014	.5249	.5068
20	.5731	.5194	.5249	.5373	.5373	.543	.5731
21	.543	.4887	.4887		.4835	.5068	.4835
22	.4706	.4525	.4572				.4706
23	.4024	.439	.3475		.3439	.362	.3982
24	.3142	.2957	.3326	.2743		.2561	.2715
Max	.5731	.5194	.5304	.6154	.5373	.543	.5731
Min	.2402	.2218	.2241	.2195	.3258	.2172	.2172
Avg	.3794	.3726	.3799	.3810	.4072	.3717	.3762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 207 / SHUKRAWAR GATE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.5121	.5121	.4835		.443	.4656
2	.4572	.4755	.4755	.4477		.4252	.4298
3	.4435	.439	.439	.4298		.4252	.4298
4	.4435	.439	.439	.4298		.4252	.4298
5	.462	.4755	.5121	.4835		.4656	.4298
6	.567	.5175	.5914	.5552		.5068	.5373
7	.6722	.5914	.6722	.6447		.5914	.6089
8	.6767	.7023	.7316	.7164		.7499	.7164
9	.7421	.7392	.7682	.8059		.7682	.8059
10		.7164		.7343	.7343	.7701	.7602
11	.6805	.6805		.6805			.6733
12	.6984	.6626		.6733	.7164		.6135
13	.5731	.6878	.6089	.6379	.6516	.6556	.5487
14	.6268	.5731	.5847	.6379	.6154	.6089	.567
15		.5552	.5316		.5611		.5373
16	.5731	.5552			.5194		.5493
17	.6447	.5731	.5552		.6089	.5316	.5959
18		.6805	.7701	.7712	.6935	.7186	.6836
19	.8413	.9214	.9492	1.0099	.985	.9568	.8764
20	1.0402	.9709	1.0208	1.0208	1.0208	1.0517	.9922
21	.9816	.9114	.9492		.9313	.964	.9114
22	.8859	.8682	.8775		.8417		.8413
23	.7164	.7602	.6626		.6485	.6516	.7265
24	.5304	.5373	.5487	.5194		.4938	.5014
Max	1.0402	.9709	1.0208	1.0208	1.0208	1.0517	.9922
Min	.4435	.439	.439	.4298	.5194	.4252	.4298
Avg	.6539	.6477	.6600	.6490	.7329	.6423	.6346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 208 / 11 KV LAXTIRTH

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3696	.3696	.3292		.905	.9145
2	.3475	.3326	.3326	.3109		.8688	.8596
3	.3326	.3326	.3326	.2926		.8688	.823
4	.3326	.3326	.3326	.2926		.8688	.823
5	.3511	.3696	.4066	.3109		.9774	.823
6	.4435	.3772	.4481	.3658		1.0974	1.0974
7	.4715	.4527	.4527	.4435		1.3256	1.2254
8	.4294	.4527	.5228	.4755		1.3443	1.3352
9	.4066	.5175	.5228	.439		1.3443	1.3169
10		.439		.4207	1.134	1.134	1.0498
11	.3658	.3841		.439	1.5912		.9955
12	.3658	.3841		.3258	.9671		.985
13	.3841	.3658	.3224	.3544	.8596	.9134	.8682
14	.3475	.3109	.3258	.4252	.823	.8507	.0163
15		.2926	.2865	.4252	.8413		.2534
16	.3109	.3292			.8596	.7973	
17	.3292	.3475	.3155		.8962	.9114	.2743
18		.394	.439	1.1462	1.1568	1.1104	.4252
19	.5258	.567	.567	1.5203	1.5203	1.6461	.543
20	.6805	.6626	.6584	1.7551	1.8099	1.7741	.6626
21	.6878	.6447	.6219		1.6651	1.6832	.6516
22	.6584	.6089	.6036				.5973
23	.5121	.5487	.4572		1.2127	1.1706	.4938
24	.3881	.4024	.439	.3658		.9492	.9511
Max	.6878	.6626	.6584	1.7551	1.8099	1.7741	1.3352
Min	.3109	.2926	.2865	.2926	.823	.7973	.0163
Avg	.4294	.4258	.4378	.5494	1.1798	1.1270	.7820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144030 / 33/11KV GPI S/STN

Feeder No / Name : 201 / 11KV TRYAMBOLI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	.3696	.3734	.2987	.3696	.2987
2	.3734	.3734	.3326	.3734	.2987	.2957	.2987
3	.3772	.3734	.3361	.3734	.2987	.2957	.3018
4	.3734	.3734	.3361	.3734	.2987	.2957	.2987
5	.3734	.3734	.4435	.4481	.3018	.2957	.2987
6	.4481	.5228	.5228	.5228	.2987	.4435	.3734
7	.3734	.4527	.5228	.5228	.4854	.5281	.4527
8	.3734	.4481	.5228	.5228	.4481	.5228	.4481
9	.3734	.5228	.4481	.4481	.3696	.5228	.4481
10		.4481	.3696	.4435	.3696	.3734	
11		.4108		.3696	.2957		.3696
12	.3696	.3696		.3696	.2957	.3658	.2957
13	.3696	.3696	.3658		.2957	.3696	.2957
14	.2957	.2987	.2957	.2926	.2926	.1478	.2957
15		.2987	.2957	.2957		.2241	
16	.2987	.2987		.2926		.2241	
17	.2926	.3658	.2957		.4527	.2957	
18	.3582	.4298	.439	.4298	.4298	.3734	
19	.5731	.5068	.5175	.5792	.5068		.5792
20	.724	.6447	.6584	.5853	.724		.6516
21	.6584	.6516	.7133	.5853	.6584		.6516
22	.6584				.5853	.4435	
23	.5175	.5175	.4481	.4435	.4435		.4435
24		.3696	.3696	.3734		.4435	
Max	.724	.6516	.7133	.5853	.724	.5281	.6516
Min	.2926	.2987	.2957	.2926	.2926	.1478	.2957
Avg	.4277	.4258	.4301	.4294	.4023	.3595	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 201 / 11KV Auxilliary

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	17-JUL-17	19-JUL-17	20-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11			.0191	
12	.0189		.0191	.0191
13	.0189		.0191	.0191
14			.0191	
15		.0191		.0191
16	.0189		.0191	
Max	.0189	.0191	.0191	.0191
Min	.0189	.0191	.0191	.0191
Avg	.0189	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 202 / Shirol

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105		1.0751	1.0479		.9808	1.0098
2	1.105		1.0562	1.0098		.9619	.9907
3	1.0669		1.0562	1.0098		.9431	.9717
4	1.1431		1.0374	.9717		.9431	1.0098
5	1.2193		1.0374			.9619	1.0479
6	1.2955		1.1506			1.1694	1.1812
7	1.5242					1.4146	1.4098
8	1.5623		1.3336		1.6004	1.4712	1.5623
9	1.5655	1.5623			1.6385	1.448	
10		1.6575			1.7337	1.6385	
11		1.6956			1.9052	1.6004	
12	1.7918	1.467			1.5432	1.6004	
13	1.5655	1.448			1.4098	1.467	
14	1.1317	1.4289				1.4098	
15		1.448	.9717		1.5051	1.3717	
16	1.6032	1.4289			1.5051	1.3908	
17		1.358	.9717		1.6598	1.5432	1.5051
18		1.4523	1.3527		1.5655	1.6575	1.6004
19		1.3957	1.4098		1.6598		1.8671
20		1.6409	1.5242		1.6975	1.6575	1.7909
21		1.5844	1.4289		1.5655	1.5432	
22		1.4712	1.2955			1.4289	
23		1.2826	1.1431		1.0751	1.1622	1.2574
24	1.1431	.9393	1.1506	1.086		.9997	1.0479
Max	1.7918	1.6956	1.5242	1.086	1.9052	1.6575	1.8671
Min	1.0669	.9393	.9717	.9717	1.0751	.9431	.9717
Avg	1.3444	1.4538	1.1872	1.0250	1.5760	1.3376	1.3037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 204 / Tarabai Park

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2826		1.1523	1.1643		1.0608	1.1203
2	1.226		1.0425	1.0903		.9694	1.0456
3	1.1883		1.0242	1.0456		.9511	1.0288
4	1.1883		1.0974	1.0903		.9694	1.0456
5	1.2637		1.0974			1.0059	1.1016
6	1.3014		1.2437			1.2986	1.2449
7	1.475		1.4815			1.5181	1.5432
8	1.5089		1.5546		1.6263	1.6095	1.6817
9	1.5912	1.6732			1.6078	1.6409	
10		1.6162			1.5893	1.6598	
11		1.4335			1.5524	1.5497	
12	1.4632	1.5466			1.4784	.8402	
13	1.4998	1.4712			1.423	1.6804	
14	1.39	1.4146				1.307	
15		1.2637			1.2752	1.226	
16	1.2254	1.3203			1.1576	1.2637	
17		1.4632			1.1888	1.1458	1.2883
18		1.4632	1.9035		1.4083	1.386	1.5089
19		1.9387	1.9959		1.6461		
20		2.1216	2.1098		1.9387	1.9959	2.0119
21		2.0302	2.0351		1.9022	1.922	
22		1.9022	1.8111			1.7741	
23		1.5181	1.5123		1.2803	1.3817	1.5497
24	1.3203	1.1488	1.2803	1.307		1.1523	1.2012
Max	1.5912	2.1216	2.1098	1.307	1.9387	1.9959	2.0119
Min	1.1883	1.1488	1.0242	1.0456	1.1576	.8402	1.0288
Avg	1.3517	1.5828	1.4894	1.1395	1.5053	1.3612	1.3363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 206 / Vikramnagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094		1.1016	.7621		.6535	.6668
2	1.0562			.724		.6348	.6478
3	1.0562		.7468	.6859		.6348	.6097
4	1.094		.7655	.724		.6535	.6668
5	1.1694		.9335	.743		.8402	.724
6	1.2071		1.2696	.8383		.7842	.8192
7	1.4146		1.4937	.9145		.9709	.9717
8	1.4335		1.4003	1.0098	1.105	1.0642	1.1431
9	1.4937	1.5278			.9717	1.1203	
10		1.6194			.8775	1.0082	
11		1.5844			.9242	.8962	
12	1.5497	1.5655			.8676	.7842	
13	1.4003	1.4377			.8002	.8029	
14	1.4003	1.3014			.8002	.4108	
15		1.358			.7811	.7621	
16	1.4003	1.3203			.743	.743	
17		1.363	.6979		.8215	.7811	.7282
18		1.4003	1.0562		.9335	.8764	.8954
19		1.4003	1.1576		1.0456		1.086
20		1.643	1.2696		1.251	1.1883	1.2003
21		1.6057	1.2955		1.1763	1.2003	
22		1.5684	1.1431			1.105	
23		1.3817	.9145		.8215	.8002	.9145
24	1.1506	1.1218	1.2136	.8002		.7095	.7049
Max	1.5497	1.643	1.4937	1.0098	1.251	1.2003	1.2003
Min	1.0562	1.1218	.6979	.6859	.743	.4108	.6097
Avg	1.2800	1.4499	1.0973	.8002	.9280	.8445	.8413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 207 / Industrial Bapat Camp MYZ SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381		.4572	.4382
2		.381		.4572	.4191
3		.4001		.4191	.4001
4		.381		.4382	.4001
5		.381		.4382	.381
6		.4001		.415	
7		.4572		.5335	.5716
8		.4382	.5144	.4763	.4763
9			.5716	.4801	
10			.6478	.703	
11			.7049	.703	
12			.6478	.7545	
13			.6287	.6979	
14			.6287	.6036	
15			.6478	.7811	
16			.6478	.6478	
17	.4954		.6287	.6097	.5788
18	.4763		.6287	.5716	.5525
19	.4954				.5716
20	.4763		.5716	.5716	.5525
21	.4572		.5335	.5144	
22	.4382			.4954	
23	.4191		.4954	.4572	.4382
24		.4001		.4763	.4572
Max	.4954	.4572	.7049	.7811	.5788
Min	.4191	.381	.4954	.415	.381
Avg	.4654	.4022	.6070	.5523	.4798

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 201 / Kay Industry

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2614	.2614	.2587		.037	.037
2	.3048	.2614	.2614	.2587		.037	.037
3	.2667	.2614	.2614	.2534		.2587	.037
4	.2667	.2614	.0373	.2587		.2587	.2587
5	.2667	.2614	.0373	.2587		.2587	.2587
6	.2667	.2614	.0373	.2587		.2587	.2587
7	.2858	.2614	.0373	.2614		.2772	.2587
8	.2858	.2801	.0373	.2614		.2957	.2587
9	.2858	.2987	.0373	.2801		.2957	.2587
10		.2858	.0381	.2667	.2667		.2858
11		.2667					.3048
12	.3048	.2667			.2667	.2667	.2667
13	.2858	.2667	.0381		.2667	.2667	.2667
14	.2858	.2667	.0381	.2667	.2858	.2667	.2667
15		.2667		.2667	.3048		.2667
16	.2858	.3048		.2667	.2667		.2667
17		.2667	.0381	.2667	.0381	.3048	.3048
18		.2667	.0381	.2667	.0381	.3048	.0381
19	.0381	.2667	.0381	.0381	.0381	.0381	.0381
20	.0381	.2667	.0381		.0381	.0381	.0381
21	.0381	.2667	.0381		.0381	.0381	.0381
22	.0381	.2667			.0381	.0381	.0381
23	.2614	.2614	.2614	.037	.037	.037	
24	.0381	.2587	.2614	.2587		.037	.037
Max	.3048	.3048	.2614	.2801	.3048	.3048	.3048
Min	.0381	.2587	.0373	.037	.037	.037	.037
Avg	.2163	.2689	.0966	.2380	.1479	.1807	.1791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 202 / Sakal Press DBlock Shirol
 Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
 STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.0082	1.0642	1.0082		.9979	.9979
2		.9709	1.0082	.9795		.9795	.9795
3	1.2765	.9335	.9709	.924		.924	.924
4	.9717	.8962	.9335	.8871		.8871	.8871
5	.8954	.8775	.8215	.8589		.8686	.9055
6	.8383	.8775	.6908	.8316		.7762	.8686
7	.7621	1.7178	.7468	.8589		.8131	.8686
8	.8192	1.643	.7842	.7947		.8501	.8686
9	.8383	1.6804	.8029	.7762		.7762	.8501
10		.8573	.8002	.9145	.8954		.8573
11		.9335			.9717		.8954
12	1.0479	1.0288			.9907	.8764	.8192
13	.8192	.8764	.8192		1.0098	.8764	.8192
14	1.1622	.9526	.8192	.9145		.9526	.8002
15		1.0098		.9526	1.0479		.8764
16	1.105	.7621		.8954	1.0288		.7811
17		1.0288	.8002	.8573	.9526	.8573	.9526
18		.9526	.8002	.8002	.8383	.8573	.8764
19	.9526	.9145	.8954	.7811	.7811	.8573	.8192
20	.9145	.8573	.8573		.7811		.8002
21	.8954	.743	.7049		.743	.7621	.724
22	.8954	.7811			.7621	.8192	.8573
23	.8962	.7282	.7282		.7762	.8686	
24	.9717	1.867	.8775	.8686		.8686	.9979
Max	1.2765	1.867	1.0642	1.0082	1.0479	.9979	.9979
Min	.7621	.7282	.6908	.7762	.743	.7621	.724
Avg	.9516	1.0374	.8382	.8767	.8907	.8668	.8707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 203 / Menon Metallica
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.57	.4854	.3881		.499	.6838
2	.6668	.6161	.4668	.4108		.499	.6653
3	.6287	.6161	.4668	.4066		.4805	.6468
4	.5906	.6588	.4481	.4294		.462	.5914
5	.4954	.6722	.4481	.4066		.5544	.5544
6	.4763	.6908	.4294	.4066		.7392	.5175
7	.4763	.5601	.3734	.4066		.7207	.3696
8	.5144	.6535	.3361	.4066		.6838	.3881
9	.5525	.6722	.3361	.4435		.5359	.4066
10		.7621	.362	.5716	.743		.6287
11		.7811			.7811		.724
12	.7621	.7811			.8383	.8002	.8954
13	.8573	.8002	.3239		.7811	.5906	.8573
14	.7621	.8002	.3239	.8764	.7049	.8192	.8954
15		.8002		.9907	.6287		.6287
16	.5335	.724		.8954	.9145		.5525
17		.6668	.3429	.8573	1.0288	.8192	.8954
18		.6478	.3429	.8383	.8383	.7621	.8383
19	.743	.6287	.381	.8192	.5716	.724	.743
20	.6859	.6287	.381		.5716	.6478	.4572
21	.6668	.6097	.381		.4763	.8192	.4382
22	.6287	.4572			.4763	.724	.743
23	.6348	.4668	.3696		.462	.6838	
24	.5906	.6535	.4668	.3696		.4805	.7023
Max	.8573	.8002	.4854	.9907	1.0288	.8192	.8954
Min	.4763	.4572	.3239	.3696	.462	.462	.3696
Avg	.6260	.6632	.3929	.5837	.7012	.6523	.6445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 204 / Budhale

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.7468	.7842	.6653		.7762	.7762
2	.8002	.7282	.7655	.6653		.7577	.7577
3	.7621	.7095	.7468	.6468		.7468	.7392
4	.7811	.6908	.7282	.6468		.7468	.7392
5	.7811	.7095	.7095	.6838		.7577	.7577
6	.7621	.7282	.6908	.7207		.8131	.7577
7	.7621	.7468	.6653	.7207		.8686	.7392
8	1.2193	1.0829	.6722	.961		.8871	1.0164
9	1.4861	1.7924	.6535	1.5154		1.2752	1.0903
10		1.7909	.724	1.8671	1.3527		1.6956
11		1.9243			1.3146		2.0005
12	1.6194	1.3146			1.2574		1.6956
13	1.9433	1.3336	.1715		1.4098	1.6956	1.6004
14	2.191	1.8671		1.4098	1.5432	1.4098	1.4861
15		1.2765		1.5623	1.5813		1.4098
16	1.6766	1.7337		1.9243	1.5813		1.6766
17		1.3527	.6859	1.9052	1.5242	1.3336	1.3146
18		1.2384	.6668	1.7528	1.086	1.3336	1.2193
19	.8954	1.1431	.6859	.9717	.9526	1.2955	1.105
20	.8573	.6859	.6859		.8573	.8002	.8573
21	.8002	.7811	.7049		.8002	.8383	.7811
22	.7621	.7811			.8002	.8002	.7621
23	.7468	.7655	.6908		.7762	.7947	
24	.7811	.7655	.7842	.6838		.7577	.7947
Max	2.191	1.9243	.7842	1.9243	1.5813	1.6956	2.0005
Min	.7468	.6859	.1715	.6468	.7762	.7468	.7392
Avg	1.0751	1.1120	.6787	1.1355	1.2026	.9836	1.1205

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 205 / Chintamani
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.6161	.5788	.5175		.4805	.5544
2		.5975	.5788	.499		.462	.5788
3	.5525	.5975	.5975	.499		.462	.5729
4	.5906	.6099	.5601	.4854		.4805	.5914
5	.6287	.6161	.5228	.499		.5175	.5914
6	.6668	.6161	.4668	.4805		.6468	.6099
7	.6668	.5975	.4854	.499		.6653	.6468
8	.6859	.6535	.5175	.5544		.7023	.6653
9	.743	.7842	.5228	.7023		.7762	.7207
10		1.3146	.5144	.8764	.9335		.9145
11		.9717			1.0669		1.0479
12	1.4098	1.2955			1.105		1.0098
13	1.1431	.8764	.5144		1.086	.7811	1.1241
14	.8954	1.1812	.5144	.8954	1.1241	1.1241	1.1431
15		1.1431		.9526	1.1431		1.1241
16	1.2765	1.1812		1.2003			1.0479
17		1.1622	.5716	1.1812	1.1431	1.0479	.9335
18	.6478	1.1431	.5335	1.1431	.5525	.9526	1.1241
19	.7049	1.105	.5335	.7049	.5525	.8573	1.086
20	.6097	.5144	.5335		.5525	.5335	.743
21	.5716	.5144	.5144		.4954	.5335	.6097
22	.6097	.5906			.4763	.5335	.6097
23	.5792	.5729	.5175		.462	.5175	
24	.8764	.6161	.5975	.5175		.4805	.5359
Max	1.4098	1.3146	.5975	1.2003	1.1431	1.1241	1.1431
Min	.5525	.5144	.4668	.4805	.462	.462	.5359
Avg	.7685	.8280	.5355	.7181	.8225	.6608	.8080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 206 / Gainmax

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	1.0829	1.0269	.9795		.9709	.961
2	.9335	1.0829	1.0269	.9709		.9795	.961
3	1.0669	1.0269	1.0082	.924		.9795	.9425
4	1.0288	1.0456	1.0082	.8871		.961	.9425
5	1.0288	1.0269	1.0082	.8686		.9979	.924
6	1.0479	1.0082	1.0082	.8131	1.0164	.9979	.961
7	1.0669	1.0269	.924	.8501	1.0164	.9795	1.0164
8	1.1241	1.0269	.7577	.8501	1.0164	.9979	1.2936
9	1.2574	1.0269	.5228	1.0349	1.6632	1.2012	1.7187
10		1.1812	.6097	1.2574	1.6385		1.7337
11		1.6766			1.2955		1.7147
12	1.6766	1.4861			1.1431		1.1431
13	1.4098	1.0669	.6287		1.2003	1.4098	1.4289
14	1.467	.8002	.6287	1.2003	1.2193	1.3908	1.6766
15		1.1622		1.2765	1.2384		1.7528
16	1.1431	1.2955		1.2574			.7811
17	1.2384	1.2955	.9526	1.2384	1.7147	1.1431	1.2003
18	1.1241	1.1431	.9907	1.1431	.9907	1.1431	1.086
19	1.1431	1.105	.9907	.9907	.9907	1.1431	1.0288
20	1.1431	1.0479	.9907	1.2384	.9907	1.0288	.6668
21	1.1241	1.0669	.9907		.9907	1.0288	.724
22	1.105	1.0669			.9907	.9907	1.0288
23	1.0829	1.0349	.961		.961	.961	
24	1.0288	1.0829	.9602	.9795		.9313	.9795
Max	1.6766	1.6766	1.0269	1.2765	1.7147	1.4098	1.7528
Min	.9335	.8002	.5228	.8131	.961	.9313	.6668
Avg	1.1530	1.1194	.8945	1.0422	1.1810	1.0650	1.1594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 411 / 33 KV I/C DBLOCK

HV Non-Express Feeder

Feeder KV- 33 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4582	4.145	4.201	3.77	3.8255	3.7146	3.9918
2	4.2867	4.257	4.0889	3.77	3.7146	3.7146	3.9363
3	4.5725	4.145	3.9918	3.6591	3.8809	3.8649	3.8255
4	4.2295	4.145	3.6969	3.5482	3.8809	3.77	3.9918
5	4.1152	4.145	3.5288	3.5482	3.8255	3.9363	3.9918
6	4.0581	4.145	3.3048	3.4928	3.77	4.2135	3.9363
7	4.0009	4.201	3.2156	3.5482	4.0472	4.3244	3.8809
8	4.6296	4.481	3.0807	3.8009	4.2135	4.3799	4.4907
9	5.144	5.3772	2.8567	4.7125	5.7659	4.8234	5.0452
10		6.1728	3.0293	5.7728	5.8299		6.1157
11		6.5729			5.4298		6.6873
12	6.8016	6.1728			5.6013	6.0585	5.8299
13	6.4586	5.2012	2.5149		5.7728	5.6013	6.1157
14	6.7444	5.8871	2.5149	5.5441	5.8871	5.9442	6.2872
15		5.6584		6.0014	5.9442	5.7728	6.0585
16	6.0014	6.0014		6.4586	6.6873		5.0869
17		5.7728	3.3722	6.2872	6.23	5.487	5.6013
18		5.3727	3.3722	5.9442	4.3439	5.3727	5.2012
19	4.5725	5.144	3.5437	4.2867	3.8866	4.9154	4.8011
20	4.2295	4.0009	3.4865		3.7151	3.8866	3.5437
21	4.1152	4.0009	3.315		3.5437	3.9438	3.315
22	4.0581	3.9438			3.5437	3.8866	4.0581
23	4.201	3.8089	3.4928		3.4374	3.8255	
24	4.2867	4.257	4.0329	3.6591	3.7146	3.5482	3.7146
Max	6.8016	6.5729	4.201	6.4586	6.6873	6.0585	6.6873
Min	4.0009	3.8089	2.5149	3.4928	3.4374	3.5482	3.315
Avg	4.7876	4.8754	3.4021	4.5767	4.6038	4.5231	4.7612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 204 / INDIRA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4481	.4294	.4108		.3921	.3921
2		.4294	.4108	.3921		.3734	.3734
3		.3921	.4108	.3734		.3361	.3361
4		.3921	.3921	.3734		.3361	.3361
5		.3734	.3734	.3921		.3361	.3584
6		.3734	.3734	.3921		.3361	.3584
7		.4481	.5228	.4854		.5228	.4668
8		.4481	.5093	.4668		.4481	.4481
9			.5041	.5228	.4854	.5415	.4854
10		.5415	.5975	.5975	.5415	.5788	.5601
11		.6535	.7095	.7468	.7095		.6535
12		.6722	.7095		.7282		.8402
13		.6535	.6535		.7655	.7655	.9431
14		.6348		.6908	.7468	.6908	
15		.6161		.7095	.7095		
16	.8775	.5415		.6722	.7095	.6722	
17	.7655	.5228	.7095		.6348	.6908	
18	.8402	.5415			.5415		.7095
19	.8686	.5415	.8029		.8215		.7468
20	.9522	.5975	.8215		.8589	.8589	.8215
21	.7762	.5415	.7282		.7282	.7282	.6908
22	.3018	.5041					.5415
23	.2452	.5041	.5228		.5041		.5041
24		.5041	.4481	.4294		.4108	.4294
Max	.9522	.6722	.8215	.7468	.8589	.8589	.9431
Min	.2452	.3734	.3734	.3734	.4854	.3361	.3361
Avg	.7034	.5163	.5594	.5103	.6775	.5305	.5498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 205 / GANESH TAIKIES

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6348	.6468	.6283		.6283	.6283
2		.6161	.6283	.5914		.5914	.5914
3		.5975	.6099	.5914		.5544	.5544
4		.5975	.6099	.5914		.5544	.5544
5		.7095	.6283	.6283		.5729	.5729
6		.7095	.6468	.6838		.6283	.5914
7		.7095	.8131	.7577		.8131	.7207
8		.7655	.8316	.7392		.8501	.7392
9		.9335	.8501	.7762	.8215	.8501	.7762
10		.9335	.9149	.8871	.7392	.924	.924
11		.9896	1.0829	1.0349			1.0719
12		1.0082	1.0829		1.2012		1.1088
13		1.0269	1.0642		1.1088	1.0534	1.1088
14		.9335		1.1088	1.0719	.9795	
15		.9425		1.0164	1.0349		
16	1.386	.8501		.9979		.961	
17	1.3676	.8131	.9896		.0869	.9425	
18	1.3676	.8131			1.0349		1.0719
19	1.4045	.8871	1.251		1.2382		1.2197
20	1.5154	.9795	1.2696		1.2752	1.3306	1.3121
21	1.2936	.8686	1.1389		1.1273	1.1458	1.1273
22	.8686	.8501					.8871
23	.8686		.7947		.7947	.8402	.7947
24		.7468	.7392	.6653		.6838	.6653
Max	1.5154	1.0269	1.2696	1.1088	1.2752	1.3306	1.3121
Min	.8686	.5975	.6099	.5914	.0869	.5544	.5544
Avg	1.2590	.8224	.8733	.7799	.9612	.8280	.8510

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 206 / 11 KV Industrial

GANDHINAGAR Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.1905	.0191		.1524	.1905
2		.1905	.1905	.0191		.1524	.1715
3		.1905	.1715	.0191		.1524	.1715
4		.1905	.1524	.0191		.1524	.1715
5		.2096	.1524	.0191		.1524	.1905
6		.2286	.1524	.0191		.1524	.1524
7		.2096	.1334	.0191		.1524	.1905
8		.2667	.1143			.1715	.2286
9		.1905	.0191		.2096	.2286	.2667
10		.3048	.0191	.2096	.2286	.2858	.3429
11		.362	.0191	.2286	.2667		.4191
12		.3429	.0572		.3239		.4191
13		.3239	.0572		.3239	.4001	.4191
14		.2286		.1905	.3048	.2858	
15		.3239	.0381	.3048	.3429		
16	.362	.2477	.0381	.3048	.362	.3429	
17	.4382	.2477	.0381		.3239	.362	
18	.4191	.2587			.362		.3429
19	.362	.2477	.0381		.3239		.3429
20	.3239	.2477	.0381		.2858	.3429	.3429
21	.2477	.1715	.0191		.1715	.2477	.2477
22	.2402	.1905				.2096	.1905
23	.2286	.1715	.0191		.1715	.1905	.1905
24		.2286	.1905	.0191		.1524	.1905
Max	.4382	.362	.1905	.3048	.362	.4001	.4191
Min	.2286	.1715	.0191	.0191	.1715	.1524	.1524
Avg	.3277	.2410	.0880	.1070	.2858	.2256	.2591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 401 / 33KV Gandhinagar I/C

HV Non-Express Feeder

Feeder KV- 33 / OUTGOING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7741	1.6804	1.4415		1.5123	1.5524
2		1.7187	1.6244	1.3306		1.4563	1.4969
3		1.6632	1.5684	1.3306		1.4003	1.386
4		1.6632	1.5123	1.3306		1.4003	1.386
5		1.7741	1.6244	1.4415		1.4003	1.4969
6		1.8296	1.6804	1.6078		1.5844	1.5524
7		1.9959	1.9605	1.7741		2.037	1.9404
8		1.9959	1.9605			2.037	1.9404
9		2.1068	2.1285		2.1068	2.2634	1.9959
10		2.2177	2.2965	2.32	1.9959	2.2497	2.3765
11	2.1285	2.4394	2.5766	2.5766	1.4415		2.6863
12	1.8484	2.4394	2.5206		2.7166		2.915
13	3.1927	2.384	2.4646		2.5503	2.6337	2.9127
14	1.6804	2.1622		2.5206	2.4949	2.3045	
15	3.5288	2.2731	2.8006	2.4949	2.3285		
16	3.1367	1.9959	2.4086	2.4394	2.384	2.4143	
17	3.0493	2.0513	2.1068		2.2634	2.4143	
18	3.2156	2.1285			2.4897		2.5789
19	3.2487	2.2405	2.5503		2.999		2.7984
20	3.3265	2.4646	2.7166		3.1121	3.1602	3.0178
21	2.9384	2.2177	2.4394		2.6326	2.6612	2.5789
22	2.8567	2.1068				2.2731	2.0851
23	2.1845	1.9605	1.7741		1.8484	1.9404	1.8656
24		1.9959	1.7924	1.4969		1.6244	1.6078
Max	3.5288	2.4646	2.8006	2.5766	3.1121	3.1602	3.0178
Min	1.6804	1.6632	1.5123	1.3306	1.4415	1.4003	1.386
Avg	2.7950	2.0666	2.1041	1.8542	2.3831	2.0404	2.1085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 201 / 11KV SARALASHKAR
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.3336		1.1431		1.1431	1.1431
2	1.2384	1.2384		1.1431		1.2384	1.1431
3	1.2384	1.2384		1.1431		1.1431	1.2384
4	1.3336	1.2384		1.1431		1.1431	1.1431
5	1.3336	1.3336		1.1431		1.1431	1.1431
6	1.3336	.2572		1.1431		1.2384	1.2384
7	1.2384	.2572		1.1431		1.3336	1.2384
8	1.3336	1.4289		1.5242		1.3336	1.2384
9	1.5242	1.7147	1.1431	1.5242		1.4289	1.2384
10		1.6194	1.1431	1.6194		2.0005	1.5242
11		2.0957		1.7147			1.9052
12	1.5242	1.7147			1.6194		1.6194
13	1.9052	1.8099	1.2384			1.8099	1.6194
14	2.0957	1.9052					2.0957
15		1.9052					2.0957
16	1.9052	1.4289				1.9052	1.9052
17	1.7147	1.4289			1.4289	1.7147	1.4289
18	1.7147	1.6194	1.1431		1.6194		1.6194
19	1.3336	1.6194	1.2384		1.1431		1.3336
20	1.5242	1.5242	1.1431		1.2384		1.4289
21	1.5242	1.5242	1.1431		1.1431		1.4289
22	1.5242	1.5242	1.2384		1.3336	1.1431	1.3336
23	1.3336	1.5242	1.1431		1.1431	1.1431	1.3336
24	1.2384	1.3336		1.1431		1.1431	1.2384
Max	2.0957	2.0957	1.2384	1.7147	1.6194	2.0005	2.0957
Min	1.2384	.2572	1.1431	1.1431	1.1431	1.1431	1.1431
Avg	1.4879	1.4424	1.1749	1.2939	1.3336	1.3753	1.4448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 202 / 11 KV MAULI FEEDER MIDC SHEDDABLE FEEDER HAVING WEEKLY
 Shirol Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.7147		1.3336		1.8099	1.5242
2	1.6194	1.8099		1.3336		1.7147	1.5242
3	1.5242	1.8099		1.3336		1.9052	1.6194
4	1.4289	1.7147		1.3336		1.8099	1.6194
5	1.4289	1.7147		1.4289		1.8099	1.6194
6	1.4289	1.6194		1.4289		1.5242	1.6194
7	1.4289	1.7147		1.4289		1.6194	1.7147
8	1.9052	1.6194		1.5242		1.9052	1.8099
9	1.7147	2.8578	1.4289	1.5242		1.9052	
10		3.0483	1.4289	3.0483		2.4768	
11		2.8578		3.0483			
12	2.4768	2.6673			2.6673		
13	2.7625	2.0957	1.3336			2.6673	
14	3.0483	2.0957	1.3336				2.0005
15		2.0957	1.4289				2.0957
16	2.6673	1.9052	.6668			2.191	2.0957
17	2.572	1.9052	.6668			2.8578	1.9052
18	2.3815	1.9052	.5716		1.4289		1.7147
19	2.191	1.7147	1.4289		2.191		1.7147
20	2.191	1.6194	1.1431		1.8099		1.6194
21	1.7147	1.6194	1.1431		1.8099		1.6194
22	2.2862	1.6194	1.1431		1.6194	1.6194	1.6194
23	1.9052	1.5242	1.3336		2.0957	1.6194	1.5051
24	2.0005	1.8099		1.3336		2.0005	1.4289
Max	3.0483	3.0483	1.4289	3.0483	2.6673	2.8578	2.0957
Min	1.4289	1.5242	.5716	1.3336	1.4289	1.5242	1.4289
Avg	2.0186	1.9608	1.1578	1.6750	1.9460	1.9647	1.7036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 203 / G' BLOCK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5242		.9526		1.5242	1.7147
2	1.6194	1.7147		.9526		1.7147	1.6194
3	1.6194	1.6194		.9526		1.7147	1.6194
4	1.5242	1.7147		.9526		1.7147	1.6194
5	1.5242	1.7147		.9526		1.6194	1.7147
6	1.5242	1.5242		.9526		1.7147	1.7147
7	1.5242	1.7147		.9526		1.7147	1.6194
8	1.4289	1.7147		.9526		1.6194	1.7147
9	1.9052	1.9052	.8573	1.1431		1.7147	1.7147
10		1.4289	.8573	1.7147		1.9052	1.5242
11		1.5242		2.0957			1.5242
12	1.9052	1.4289			1.9052		2.0005
13	1.7147	1.1431	.8573			1.3336	1.8099
14	1.9052	1.9052	.8573				1.5242
15		1.9052	.9526				
16	1.4289	1.9052	.8573			1.5242	2.0005
17	1.8099		.9526		1.9052	1.4289	1.9052
18	1.8099		.9526		1.5242		2.0005
19	1.3336		.9526		1.7147		1.9052
20	.9526		.9526		1.7147		1.7147
21	1.3336		.9526		1.6194		1.7147
22	1.7147		.9526		1.7147	1.6194	1.7147
23	1.3336		.9526		1.7147	1.7147	1.7147
24	1.6194			.9526		1.6194	1.7147
Max	1.9052	1.9052	.9526	2.0957	1.9052	1.9052	2.0005
Min	.9526	1.1431	.8573	.9526	1.5242	1.3336	1.5242
Avg	1.5741	1.6492	.9159	1.1272	1.7266	1.6373	1.7313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 204 / 11 KV Maharashtra Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.5716		.4763		.5716	.6668
2		.5716		.4763		.6668	
3	.5716	.5716		.4763		.6668	.5716
4	.6668	.5716		.4763		.5716	.5716
5	.5716	.5716		.4763		.6668	.5716
6	.6668	.5716		.4763		.6668	.5716
7	.6668	.5716		.4763		.6668	.5716
8	.6668	.5716		.4763		.5716	.5716
9	.6668	.6668	.1905	.8573		.5716	.5716
10		.6668	.1905	.5716		.5716	.6668
11		.7621		.6668			.6668
12	.5716	.6668			.6668		.6668
13	.5716	.6668	.1905			.6668	.5716
14	.6668	.7621	.1905				.6668
15		.5716	.1905				.6668
16	.6668	.6668	.1905			.6668	.6668
17	.6668		.1905		.1905	.6668	.6668
18	.6668		.1905		.1905		.6668
19	.5716		.1905		.381		.5716
20	.6668		.1905		.5716		.6668
21	.6668		.381		.5716		.6668
22	.6668		.4763		.5716	.6668	.6668
23	.5716		.4763		.6668	.7621	.6668
24	.6668	.5716		.4763		.5716	.6668
Max	.6668	.7621	.4763	.8573	.6668	.7621	.6668
Min	.5716	.5716	.1905	.4763	.1905	.5716	.5716
Avg	.6382	.6220	.2491	.5319	.4763	.6371	.6295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 206 / DEVAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.2384		1.2384		1.7147	
2	1.4289	1.3336		1.1431		1.7147	.9526
3	1.5242	1.2384		1.3336		1.8099	1.1431
4	1.5242	1.2384		1.3336		1.8099	1.5242
5	1.4289	1.3336		1.3336		1.8099	1.6194
6	1.5242	1.3336		1.3336		2.0957	1.7147
7	1.7147	1.2384		1.4289		2.2862	1.6194
8	1.3336	1.6194		1.3336		1.7147	1.7147
9		2.2862	1.1431	1.4289		1.8099	1.5242
10		3.0483	1.1431	1.9052		1.7147	1.3336
11		2.0957		2.0957			1.1431
12	2.2862	2.0957			2.2862		2.191
13	2.2862	2.2862	1.1431				1.9052
14	2.2862	2.8578	1.0479				2.0957
15		2.4768	1.1431				2.2862
16	2.4768	2.0957	1.2384			2.0005	1.6194
17	1.6194	2.0957	1.1431		1.7147	1.7147	1.7147
18	2.0005		1.1431		1.1431		1.3336
19	1.0479		1.1431		2.0005		.9526
20	.9526				1.6194		1.8099
21	1.2384				1.4289		2.0957
22	1.3336				1.4289	1.2384	2.0957
23	1.3336		1.1431		.6668	1.9052	2.0957
24	1.5242	1.2384		1.2384		1.5242	
Max	2.4768	3.0483	1.2384	2.0957	2.2862	2.2862	2.2862
Min	.9526	1.2384	1.0479	1.1431	.6668	1.2384	.9526
Avg	1.6194	1.8417	1.1431	1.4289	1.5361	1.7909	1.6584

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-JUL-17 and 21-JUL-17

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 401 / 33KV MIDC SHIROLI INCOMER

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	15-JUL-17	16-JUL-17	17-JUL-17	18-JUL-17	19-JUL-17	20-JUL-17	21-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.0302	6.5729		5.144		6.7444	
2	6.7444	6.5729		5.0297		7.0302	
3	6.4586	6.6873		5.2584		7.2588	6.1728
4	6.4586	6.6873		5.2584		7.0302	
5	6.2872	6.4586		5.3155		7.0302	
6	6.4586	6.4015		5.3155		7.2588	
7	6.5729	6.5729		5.4298		7.6017	
8	6.6873	6.973		5.8299		7.1445	
9	8.6877	9.4307	4.7439	6.4586		7.4303	6.7444
10		9.8308	4.7439	8.2876		8.6306	6.973
11		9.3164					7.1445
12	8.7449	8.5734			9.145		8.4591
13	9.2593	8.0018	4.7439			6.4586	7.8304
14	10.0023	9.5451	3.4294				8.4019
15		8.9735	3.7151				9.0306
16	9.145	8.0018				8.2876	
17	8.4019		2.9721		5.2584	8.4019	7.6017
18	8.5734				5.8871		7.3731
19	5.8871		4.9726				6.4586
20	6.2872		4.7439		6.973		7.2588
21	6.4586		4.9726		6.5729		7.1445
22	7.5446		5.144		6.6873	6.2872	7.4303
23	6.4586		5.144		6.973	7.1445	7.316
24	7.0302	6.2872		5.144		6.8587	5.0297
Max	10.0023	9.8308	5.144	8.2876	9.145	8.6306	9.0306
Min	5.8871	6.2872	2.9721	5.0297	5.2584	6.2872	5.0297
Avg	7.3895	7.6992	4.4841	5.6792	6.7852	7.2874	7.2731