

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 201 / KATEWADI (AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402	.1646	.2195	.8848	.8779	.9979	.1646
2	.1578	.1829	.2561	.9175	.9511	1.0719	.1829
3	.1753	.1829	.2561	1.0159	1.1706	1.1458	.1829
4	.1791	.2012	.2743	1.1142	1.39	1.2752	.2195
5	.197	.2195	.2743	1.1469	1.4266	1.3306	.2561
6	.2149	.2561	.2926	1.1633	1.4632	1.46	.2561
7	.2507	.2743	.2926	1.1797	1.5123	1.5339	.2743
8	.2149	.2561	.2481	1.1961	1.5893	1.6448	.2561
9	.9328	1.0425	1.2136	.1578	.2012	.1612	1.7551
10	.9328	.8686	1.2323	.1402	.1646	.1402	2.2965
11	.9328	1.0269	1.307	.1402	.1448	.1254	2.3954
12	.8939		1.2752	.1052	.1097	.1227	2.4272
13			1.2254	.1052	.0905	.1052	2.4646
14		.8413	1.2437		.1075	.1063	2.4646
15	.7712	.8501	1.1763	.1052	.1086	.1063	2.3339
16	.7712	.8775	1.1273	.1052	.1086	.1063	2.3101
17	.1463	.1227		.1578	.1267	.1227	.1097
18	.1829	.1578	.1612	.1578	.1646	.1595	.1629
19	.181	.1928	.2195	.197	.2195	.1949	.2012
20	.1829	.1928	.2195	.2328	.2195	.2149	.2195
21	.2149	.1402	.181	.1753	.181	.197	.181
22	.1829	.1463	.1612	.1402	.1753	.2012	.1629
23	.1646	.1463	.7865	.6219	.8596	.1829	.1646
24	.1402	.1646	.1463	.8192	.7682	.924	.1646
Max	.9328	1.0425	1.307	1.1961	1.5893	1.6448	2.4646
Min	.1402	.1227	.1463	.1052	.0905	.1052	.1097
Avg	.3709	.3867	.5995	.5208	.5888	.5680	.9003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 202 / 11 kKV KATEWADI (GFSS)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.415	.415	.415	.4108	.4294	.4715
2	.4481	.4338	.4527	.4527	.4294	.4294	.4715
3	.4854	.4338	.4904	.4904	.4481	.4481	.4904
4	.5228	.4527	.5281	.5281	.4668	.4668	.4904
5	.5601	.4904	.6036	.6036	.4854	.4854	.6036
6	.6348	.6036	.7167	.6413	.5601	.5601	.6413
7	.7282	.7167	.7356	.679	.6516	.6348	.6979
8	.6535	.6413	.5853	.6979	.5138	.5788	.6602
9	.5041	.4656	.439	.4854	.4755	.4668	.439
10	.3921	.3403	.3403	.3547	.362	.3734	.4251
11	.3174	.3077	.2743	.3142	.3658	.3174	.3439
12	.2743		.2743	.2801	.3258	.2957	.3077
13			.2353	.2614	.3224	.2241	.3109
14		.3475	.2353		.3292	.2926	.2561
15	.2743	.3292	.2507	.3326	.362	.2743	.2715
16	.2743	.2896	.2926	.3696	.3475	.2561	.2743
17	.3258	.3734		.3696	.4207	.4108	.362
18	.4706	.3734	.4298	.3696	.439	.4854	.4024
19	.5041	.4904	.5487	.5415	.5121	.5601	.5249
20	.5359	.5415	.5249	.5228	.5249	.5228	.5552
21	.5175	.5041	.4755	.4668	.5228	.5041	.5304
22	.4904	.5093	.439	.4294	.4854	.4527	.5068
23	.4338	.415	.4024	.4108	.4481	.4527	.4527
24	.4108	.415	.3772	.3961	.4108	.4108	.4527
Max	.7282	.7167	.7356	.6979	.6516	.6348	.6979
Min	.2743	.2896	.2353	.2614	.3224	.2241	.2561
Avg	.4622	.4495	.4377	.4527	.4425	.4305	.4559

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 205 / 11 KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.2743	.2401	.2743	.3109	.3292	.3258
2	.3475	.2915	.2743	.2915	.3109	.3109	.3429
3	.3511	.2915	.2743	.2915	.2926	.3109	.3086
4	.3658	.2915	.2743	.2915	.3475	.3109	
5	.3511	.3086	.3086	.3086	.3475	.2926	.2915
6	.3292	.3086	.3086	.3086	.3658	.2926	.3086
7	.3326	.3086	.3429	.3086	.3734	.2926	.3086
8	.4805	.3086	.394	.3086	.3258	.3292	.4115
9	.5175	.3475	.439	.3292	.3658	.3658	.3801
10	.3881	.2715	.543	.3109	.3403	.3696	.4938
11	.499	.3224	.6219	.5304	.5228	.3696	.6036
12	.4755	.2926	.5304	.3772	.6036	.3511	.5121
13	.394	.4887	.4805	.4108	.5373	.3326	.4805
14	.3403	.3881	.4435	.4066	.5601	.2926	.6535
15	.2865	.5068	.4938	.4715	.6348	.3734	.6219
16	.4024	.5792	.6219	.4207	.5788	.4066	
17	.4382	.3696		.4251	.4481	.3292	.543
18	.3734	.5359	.5487	.4435	.4854	.3734	.5068
19	.3439	.3696	.543	.4024	.4854	.4108	.5014
20	.3658	.3881	.5853	.3841	.2743	.4481	.3801
21	.2378	.2743	.439	.3658	.2926	.3326	.3658
22	.2401		.3658	.2926	.3658		.4298
23	.2743		.3086	.2926	.3292		
24	.3292	.2743	.2401	.2743	.2926	.3292	.3258
Max	.5175	.5792	.6219	.5304	.6348	.4481	.6535
Min	.2378	.2715	.2401	.2743	.2743	.2926	.2915
Avg	.3664	.3542	.4183	.3550	.4080	.3433	.4331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214419 / 33/11 KV KATEWADI

Feeder No / Name : 206 / 11 KV GAWARKHOPAD AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0366	.0366	.6882	.5967	.5304	.0366
2	.0328	.0366	.0549	.7209	.5967	.5636	.0549
3	.0328	.0549	.0549	.7209	.6299	.5967	.0549
4	.0492	.0549	.0549	.7537	.6962	.6962	.0549
5	.0492	.0549	.0549	.7865	.7127	.7956	.0549
6	.0492	.0549	.0549	.8192	.7625	.8288	.0549
7	.0328	.0549	.0549	.8192	.7865	.8619	.0549
8	.0492	.0549	.0486	.852	.8785	.9282	.0549
9	.6962	.7655	.6882	.0332	.0316	.0328	.9614
10	.779	.7842	.7545	.0328	.0328	.0328	1.1305
11	.7956		.779	.0328	.0324	.0164	1.2266
12	.852	.7293	.7865	.0328	.0328	.0164	1.2616
13	.6554	.7127	.7287	.0328	.032	.0328	1.2431
14	.7701	.7209	.7701	.0328	.032	.0328	1.2616
15	.7293	.7865	.852	.0328	.0324	.0328	1.2452
16	.6962	.7625	.9012	.0328	.0486	.0328	
17	.032	.0332		.0328	.032	.0328	.0324
18	.0324	.0332	.0328	.0328	.0324	.0328	.0324
19	.048	.0332	.0324	.0328	.0324	.0328	.032
20	.0316	.0497	.0328	.0328	.0328	.0328	.0324
21	.0324	.0332	.0328	.0328	.0328	.0328	.0328
22	.0366		.032	.0328	.0492		.032
23	.0366		.6554	.4641	.4641		
24	.0328	.0366	.0366	.6882	.5304	.4973	.0366
Max	.852	.7865	.9012	.852	.8785	.9282	1.2616
Min	.0316	.0332	.032	.0328	.0316	.0164	.032
Avg	.2743	.2802	.3274	.3239	.2975	.3042	.4083



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 201 / 11 KV DHUMALWADI SINGLE SINGLE PHASING  
PH. Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.5144	.1886	.1715	.2641	.12	.7202
2	.4268	.5144	.1886	.1715	.2641	.12	.7202
3	.4268	.5144	.2263	.1715	.2641	.12	.7202
4	.4572	.5316	.2263	.2058	.3018	.1715	.823
5	.4877	.4973	.3395	.3429	.3018	.3601	.823
6	.5487	.5487	.4527	.4115	.3772	.463	.9602
7	.5792	.583	.415	.3772	.4527	.4801	.9602
8	.5639	.5658	.2915	.3086	.3395	.3086	.9774
9	.1372	.1372	.6173	.6249	.823	.9602	.2263
10	.1372	.1543	.583	.6859	.8573	1.0288	.0754
11	.1372	.1698	.4268	.7621	.8573	1.0288	.1372
12	.1543	.0754	.4268	.7716		1.0288	.1372
13	.1372	.132		1.2193	.8383	1.0288	
14	.1372	.132	.5487	.7316	.8745	1.0631	.1372
15	.1372	.1886	.4877	.7316	.9259	1.0631	.1372
16	.1372	.1886	.583	.823	.9431	1.0974	.1372
17	.1372	.2075	.1372	.1372	.2058	.1886	.1372
18	.1543	.2641	.1543	.2641	.12	.3018	.2229
19	.1372	.3206	.3601	.3772	.3258	.3961	.3601
20	.1372	.3206	.3429	.3961	.3429	.3772	.3772
21	.1372	.3018	.3086	.3772	.3601	.3772	.3429
22	.1543	.3206	.2915	.3772	.3429	.3395	.3258
23	.4458	.2263	.2058	.3395	.1543	.6859	.7164
24	.5144	.463	.1886	.1715	.3206	.12	.7888
Max	.5792	.583	.6173	1.2193	.9431	1.0974	.9774
Min	.1372	.0754	.1372	.1372	.12	.12	.0754
Avg	.2854	.328	.3474	.4563	.4720	.5512	.4767

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 202 / 11 KV DHAKALE SINGLE PH. SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429	.2743	.3048	.6859	.5144	.3772
2	.3086	.3258	.2743	.2896	.6859	.5144	.3772
3	.3086	.3258	.3086	.2896	.7545	.5144	.3395
4	.3086	.3086	.3086	.3353	.7545	.5144	.3772
5	.4287	.4287	.3429	.5335	.8573	.5144	.4527
6	.6687	.6516	.3772	.5792	.8573	.6687	.6036
7	.7202	.7202	.4801	.7773	1.0974	1.0974	.7545
8	.583	.5144	.5847	.7011	1.1317	1.1317	.6413
9	.3963	.463	.415	.2572	.4338	.3772	1.2003
10	.4268	.4801	.3018	.2572	.2829	.2915	1.406
11	.463	.4458	.2058	.2058	.2401	.3018	1.5947
12	.5487	.583	.1886	.2263		.3018	1.8176
13	.4973	.583	.2058	.2452	.2229	.2829	
14	.4801	.583	.1886	.2641	.2229	.3018	1.6804
15	.463		.1886	.3395	.2229		1.4918
16	.4458	.3429	.1886	.2263	.2229	.2829	1.448
17	.2229		.2572	.2229	.2401	.3206	.2743
18	.3258	.5281	.2915	.3772	.2743	.415	.3429
19	.3772	.5658	.463	.5658	.4287	.5658	.5658
20	.4973	.5658	.4801	.6036	.4973	.6036	.5144
21	.4287	.5281	.463	.5658	.4458	.6036	.4801
22	.4115	.4904	.4115	.4715	.4115	.5281	.463
23	.3601	.2743	.3658	.6173	.5144	.415	.3944
24	.3086	.3258	.2743	.3048	.6516	.5316	.415
Max	.7202	.7202	.5847	.7773	1.1317	1.1317	1.8176
Min	.2229	.2743	.1886	.2058	.2229	.2829	.2743
Avg	.4287	.4717	.3267	.3984	.5277	.5040	.7831

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 203 / 11 KV MIDC FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1543	.0754	.0514	.1132	.1543	.1698
2	.1715	.1543		.0686	.1132	.1543	.1698
3	.1543	.1543		.0686	.0754	.1543	.1698
4	.1715	.1543		.0686	.0754	.1543	.1886
5	.1715	.1715		.0686	.0754	.1543	.1886
6	.1715	.1715		.0686	.1509	.1715	.1886
7	.1886	.1886		.0686	.2075	.1543	.2075
8	.1715	.1715		.0686	.2263	.1715	.2641
9	.2572	.1886	.1886	.1372	.6413	.4973	.4527
10	.463	.4115	.1509	.4115	.6224	.5658	.2829
11	.4115	.2075	.1372	.0686	.5144	.6036	.4458
12	.2743	.1698	.1543	.1886		.4527	.3601
13	.1886	.1886	.0686	.1509	.1715	.2263	
14	.1886	.3772	.0686	.2075	.2058	.3395	.2915
15	.1543		.12	.3395	.3258	.415	.2058
16	.1886	.1886	.1029	.2452	.4115	.3395	.3086
17	.1715	.1509	.12	.2743	.5144	.3018	.3601
18	.2229	.1132	.1372	.2641	.2915	.2263	.3429
19	.1886	.0943	.0686	.1886	.1886	.1886	.1372
20	.1715	.0943	.0686	.1886	.1715	.1886	.1715
21	.1886	.0754	.0686	.1886	.1543	.1886	.1715
22	.1715	.0754	.0686	.1886	.1715	.1698	.1543
23	.1715	.0754	.0686	.1509	.1543	.1698	.1886
24	.1543	.1543	.0754	.0343	.1509	.1543	.1886
Max	.463	.4115	.1886	.4115	.6413	.6036	.4527
Min	.1543	.0754	.0686	.0343	.0754	.1543	.1372
Avg	.2058	.1689	.1025	.1566	.249	.2623	.2439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 204 / 11 KV PANDHRE SINGLE PH. SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6001	.9259	.8383	1.1317	1.3032	.7545
2	.6001	.6001	.9259	.8383	1.2003	1.3203	.7545
3	.583	.583	1.0288	.884	1.2003	1.3032	.7545
4	.6516	.5658	1.0288	.884	1.5432	1.3203	.8299
5	.823	.8573	1.1317	.945	1.6804	1.3203	.9431
6	1.1317	1.0802	1.1317	1.1431	1.7833	1.5432	1.1694
7	1.2003	1.2346	1.406	1.448	1.8861	2.0405	1.3203
8	1.0631	1.0802	1.5432	1.5089	2.0062	2.0405	1.0562
9	1.1888	1.4918	.7167	.7202	.8676	.823	2.2805
10	1.326	1.6632	.6413	.6173	.679	.703	2.572
11		1.5604	.5658	.6859	.583	.7545	2.4082
12	1.5432	1.5775	.5487	.6413		.7545	2.3929
13	1.2689	1.4403	.5487	.6413	.6173	.7545	
14	1.2174	1.4403	.5316	.6036	.583	.7922	2.2558
15	1.2003	1.406		.5658	.6001	.7922	2.1033
16	1.1317	1.406	.5316	.6413	.6173	.6413	2.1033
17	.583	.7545	.583	.583	.6173	.7733	.7202
18	.703	.9808	.6344	.8299	.6859	.9431	.7888
19	.8916	1.094	.9088	1.1317	.9945	1.094	1.2003
20	1.0288	1.1317	1.0288	1.2071	1.0802	1.1317	1.0802
21	.8916	1.0562	1.0117	1.1694	1.0117	1.1317	1.0288
22	.703	.9619	.823	1.0185	.9259	1.094	1.0117
23	.6516	.9945	.8993	1.166	1.3203	.8865	.8402
24	.6001	.583	.9945	.884	1.1317	1.3032	.7922
Max	1.5432	1.6632	1.5432	1.5089	2.0062	2.0405	2.572
Min	.583	.5658	.5316	.5658	.583	.6413	.7202
Avg	.9383	1.0893	.8735	.8998	1.0759	1.1068	1.3548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214420 / 33/11 KV PANDARE S/STN

Feeder No / Name : 208 / 11 KV SHIV PURI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0514	.4458	.5792	.7888	.7202	.0566
2	.0343	.0514	.4458	.5335	.7888	.7373	.0566
3	.0343	.0514	.4458	.5335	.8573	.7373	.0566
4	.0343	.0514	.4801	.5792	.8573	.7545	.0566
5	.0514	.0514	.4801	.6097	.9602	.7373	.0754
6	.0514	.0514	.5144	.6401	.9602	.8059	.0754
7	.0514	.0514	.6516	.823	1.0631	1.0288	.0943
8	.0343	.0514	.6859	.9297	1.1145	1.0802	.0566
9	.7373	.7545	.0566	.0343	.0754	.0377	1.406
10	.7011	.8745	.0566	.0343	.0754	.0566	1.6118
11	.8059	.9259	.0514	.0343	.0514	.0754	1.5089
12	.9088	.9431				.0754	1.5851
13	.9088	1.0288	.0343		.0514	.0943	
14	.823	.9602	.0343		.0514	.0566	1.5394
15	.7716	.8745	.0343	.0686	.0514		1.4327
16	.6859	.8573	.0343	.0566	.0686	.0566	1.2651
17	.0514	.0377	.0343	.0514	.0514	.0566	.0514
18	.0686	.0566	.0343	.0566	.0514	.0754	.0514
19	.0514	.0754	.0343	.0566	.0686	.0754	.0686
20	.0514	.0754	.0514	.0566	.0686	.0754	.0686
21	.0514	.0754	.0514	.0566	.0857	.0754	.0514
22	.0686	.0566	.0343	.0514	.0686	.0566	.0514
23	.0514	.5658	.6097	.9259	.8573	.0754	.0343
24	.0343	.0514	.5144	.6097	.8573	.8745	.0566
Max	.9088	1.0288	.6859	.9297	1.1145	1.0802	1.6118
Min	.0343	.0377	.0343	.0343	.0514	.0377	.0343
Avg	.2957	.3593	.2528	.3486	.4315	.3660	.4918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN

Feeder No / Name : 202 / 11 KV DEULGAON SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886	.1715	.2829	.3018	.2641	.1886
2	.1698	.1886	.1715	.2829	.3395	.2641	.2263
3	.1886	.2263	.1715	.3018	.415	.2829	.2641
4	.1886	.2641	.1886	.3395	.4904	.2641	.3018
5	.2263	.3018	.2058	.3395	.5658	.4527	.3395
6	.2829	.3584	.3086	.7167	.679	.7545	.3961
7	.3584	.3772	.3944	.6224	.7167	.7167	.5847
8	.3961	.4527	.4115	.4715	.5093	.5281	.6602
9	.3772	.3395	.3086	.4527	.3961	.4527	.3018
10	.2641	.2401	.2058	.3961	.4338	.3961	.2263
11	.1886	.1029	.1372	.3584	.3772	.3961	.132
12	.132	.0514		.2829	.3961	.3772	.132
13	.1509	.0514	.1509	.2829	.3961	.3961	.132
14	.1698	.0514	.1132	.2829	.3395	.4527	.132
15	.1509	.0857	.132	.3018	.3395	.415	.132
16	.1886	.12	.1509	.3018	.3206	.3772	.132
17	.2075	.2743	.1509	.1886	.1886	.1698	.1509
18	.3018	.3086	.2075	.2263	.2641	.2641	.2641
19	.4527	.4115	.4904	.4715	.4715	.4527	.3961
20	.4715	.463	.5847	.547	.547	.5093	.4715
21	.415	.3944	.4527	.4338	.3961	.4527	.4338
22	.3395	.3086	.3772	.3584	.3395	.3584	.3772
23	.1698	.1715	.3395	.3018	.3018	.1886	.2641
24	.1509	.1698	.1715	.3018	.2641	.2829	.1886
Max	.4715	.463	.5847	.7167	.7167	.7545	.6602
Min	.132	.0514	.1132	.1886	.1886	.1698	.132
Avg	.2546	.2459	.2607	.3686	.4079	.3945	.2845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN

Feeder No / Name : 204 / 11 KV SYNBACHIWADI SINGLE SINGLE PHASING  
PHAS Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.132	.1029	.0943	.1132	.0943	.0943
2		.1509	.1029	.0943	.1132	.0943	.0943
3		.1509	.1029	.0943	.132	.0943	.1132
4		.1886	.12	.1132	.1698	.1132	.132
5		.2452	.1715	.132	.2075	.1132	.1698
6		.3018	.2401	.2452	.2452	.2075	.2075
7		.3018	.2572	.2641	.3206	.3395	.2641
8		.2452	.2058	.2641	.1886	.3206	.2263
9		.1509	.1715	.1132	.1132	.1132	.2263
10	.0566	.12	.1372	.0943	.1132	.1132	.2641
11	.0377	.1029	.12	.0943	.0754	.1132	.2452
12	.1509	.1029	.1698	.0943	.0566	.1132	.3206
13	.132	.12	.1509	.1132	.0566	.0943	.3018
14	.0943	.1372		.1132	.0754	.0754	.2829
15	.1132	.1029	.1698	.0943	.0754	.0754	.3018
16	.0943	.1029	.1698	.0754	.0754	.0754	.3395
17		.12	.0943	.0943	.0943	.132	.0754
18	.0566	.1543	.1132	.1698	.1132	.1132	.1132
19	.2452	.2058	.2452	.2075	.1698	.1698	.1509
20	.2075	.1715	.1886	.1886	.2263	.2075	.2452
21	.1698	.1372	.1698	.1698	.1698	.1698	.1886
22	.132	.12	.132	.132	.1132	.1132	.132
23	.1132	.12	.1132	.1132	.1132	.1132	.1132
24	.1132	.1132	.1029	.1132	.1132	.0943	.0943
Max	.2452	.3018	.2572	.2641	.3206	.3395	.3395
Min	.0377	.1029	.0943	.0754	.0566	.0754	.0754
Avg	.1220	.1583	.1544	.1368	.1352	.1360	.1957

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN

Feeder No / Name : 205 / 11 KV SONPIRWADI SINGLE SINGLE PHASING  
PHASIN Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1715	.2641	.2452	.2641	.2829
2		.1886	.1715	.2452	.2641	.2641	.2829
3	.2075	.2452	.1886	.3018	.3018	.2829	.3018
4	.2075	.3395	.2058	.3395	.3772	.3395	.3772
5	.2829	.3772	.3086	.5093	.5281	.4527	.5281
6	.415	.5093	.4115	.9054	.7356	.7922	.7922
7	.4527	.5658	.5144	.9242	.9619	.9431	.9054
8	.4904	.6602	.6173	.7922	.8488	.7922	.7356
9	.4904	.5847	.4973	.7922	.6602	.6036	.7733
10	.3206	.2743	.2915	.6224	.5658	.6224	.7167
11	.2263	.1886	.2229	.5281	.6036	.5658	.6979
12	.2075	.1715	.1886	.4715	.5658	.132	.7356
13	.1698	.1543	.1886	.5281	.547	.6224	.7545
14	.1698	.1372	.1509	.6224	.547	.6979	.7922
15	.1698	.1543	.1509	.4338	.415	.6979	.7545
16	.2452	.1715	.1698	.4904	.4715	.6979	.4527
17	.2829	.2229	.2263	.3772	.2829	.1698	.2452
18	.4338	.3772	.2829	.3961	.415	.3018	.3772
19	.6602	.5487	.5658	.6413	.5847	.5847	.5281
20	.6224	.5316	.6413	.5658	.679	.6602	.7167
21	.3961	.4115	.4715	.4715	.4527	.5658	.5658
22	.2829	.3429	.3961	.3395	.3772	.3772	.3772
23	.1698	.1886	.3395	.2452	.3018	.3018	.3772
24	.1886	.1698	.1886	.3018	.2452	.2641	.2829
Max	.6602	.6602	.6413	.9242	.9619	.9431	.9054
Min	.1698	.1372	.1509	.2452	.2452	.132	.2452
Avg	.3166	.321	.3151	.5045	.4990	.4998	.5564



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214423 / 33/11 KV JALGOAN S/STN

Feeder No / Name : 206 / 11 KV JALGAON (KP) SINGLE SINGLE PHASING

PHAS Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2075	.2401	.547	.6036	.5658	.1886
2		.2075	.2401	.5658	.6036	.5658	.2263
3		.2452	.2572	.5281	.679	.5847	.2641
4		.2829	.3086	.5281	.7545	.6036	.3018
5		.3395	.3601	.6602	.8299	.6979	.3395
6		.3961	.4801	.9808	.9808	.9431	.4338
7	.6413	.4904	.5658	.8676	.9431	.9808	.6979
8	.6036	.5847	.6001	.679	.6979	.7545	.679
9	.6979	.5658	.463	.3395	.3961	.3584	.4527
10	.4715	.3086	.3429	.2829	.3018	.3206	.3395
11	.415	.2572	.2743	.3584	.3772	.3772	.3018
12		.2401	.2452	.2452	.3961	.415	.2641
13	.3206	.2401	.1886	.2641	.415	.4338	.2641
14	.3206	.2401	.1886	.2829	.3961	.4715	.2641
15	.3772	.2572	.1886	.2641	.2829	.4715	.2641
16	.3584	.2401	.2075	.3206	.2829	.4904	.2641
17	.4715	.2915		.2452	.2452	.2829	.3018
18	.6224	.5316	.4338	.3584	.3961	.3961	
19	.811	.7545	.8488	.7545	.6602	.679	.5658
20	.8488	.8059	.9054	.8299	.8865	.7733	.7545
21	.7922	.7545	.7545	.7922	.7733	.679	.6602
22	.679	.6344	.679	.6979	.6979	.6413	.5658
23	.2452	.2743	.5658	.6224	.6224	.2263	.2641
24	.2641	.2263	.2572	.5658	.6224	.6036	.1886
Max	.8488	.8059	.9054	.9808	.9808	.9808	.7545
Min	.2263	.2075	.1886	.2452	.2452	.2263	.1886
Avg	.5093	.3907	.4172	.5242	.5769	.5548	.3846

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 201 / 11 KV KARKHANA SINGLE SINGLE PHASING  
PHASING Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.567	.6859	.7167	.7087	.8059	.6979
2	.5847	.5316	.6687	.6979	.7087	.7888	.679
3	.6036	.5316	.6687	.6979	.7087	.8573	.679
4	.6036	.6556	.7716	.6979	.7796	.8916	.6979
5	.8326		.9774	.8676		.9431	.8916
6	1.0974	.9036	1.0974	.8916	1.2048	.9602	1.1145
7	1.2174	1.1517	1.166	1.1145	1.2757	1.3032	1.1317
8	.9774	1.0099	.9602	1.2174	1.4175	1.406	.9088
9	1.0288	.9568	.9945		.7087	.6173	1.2944
10	1.0631	.9922	.9602	.5316	.567	.6173	1.5089
11	.9922	.9259	1.0288	.3366	.5144	.6413	1.5432
12	.7973	.9431	.703	.2126	.4458	.547	1.5775
13	.7442	.8916	.6859	.2303	.4287	.5658	1.5604
14	.7442	.7888	.7733	.2481	.4801	.6224	1.5432
15	.7796	.8573	.8573	.3898	.463	.6413	1.6118
16	.8505	.8916	.4904	.4961	.4973	.6602	1.6461
17	.5138	.5144	.4904	.4784	.4973	.6979	.5144
18	.691	.5487	.5658	.443	.5487	.7167	.6173
19	.7973	.7202	.7545	.7265	.7545	.8402	.7888
20	.8682	.8916	.8745	.7619	.8916	.8402	.8916
21		.8916	.8573		.8573	.8402	.9088
22	.7442	.8573	.8059		.8402	.8402	.8916
23	.5847	.7545	.7167		.823	.6859	.7202
24	.5847	.567	.6859	.7167	.7442	.823	.6979
Max	1.2174	1.1517	1.166	1.2174	1.4175	1.406	1.6461
Min	.5138	.5144	.4904	.2126	.4287	.547	.5144
Avg	.7950	.7975	.8017	.6237	.7333	.7980	1.0465

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 202 / 11 KV SHARADANAGAR SINGLE SINGLE PHASING  
PHAS Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4252	.4115	.7356	.815	.8573	.4715
2	.3961	.4075	.4287	.7167	.815	.823	.4527
3	.415	.4075	.4287	.6979		.8573	.4527
4	.415	.443	.5144	.695	.9036	.8573	.4715
5	.547		.583	.7545	.9745	.8916	.6413
6	.6979	.6733	.6344	.811	.9922	.8916	.7733
7	.8299	.7973	.6859	.9431	1.0277	.9945	.8676
8	.7545	.7442	.6173	1.0288	1.134	1.0974	.7922
9	.7545	.7619	.7545		.691	.5487	1.1488
10		.7796	.9259	.4784	.4784	.4287	1.1888
11	.8682	.7545	.8402	.443	.4115	.4904	1.3717
12	.7265	.7716	.9259	.3721	.4115	.4904	1.3032
13	.7087	.7545	.8916	.3544	.3772	.5093	1.3375
14	.691	.6173	.8573	.3544	.3772	.4904	1.3203
15	.6733	.6516		.3721	.3944	.4904	1.286
16	.6556	.6687	.8573	.3898	.3601	.5093	1.2689
17	.3898	.3772	.4715	.443	.4287	.5093	.4287
18	.4607	.3772	.547	.4075	.4287	.5847	.5144
19	.6201	.5487	.6413	.6556	.6001	.7167	.583
20	.6733	.6001	.6859	.7087	.6687	.6979	.6859
21		.6001	.7167		.6173	.6979	.6687
22	.5138	.5487	.6602		.583	.679	.6173
23	.4252	.4973	.7202		.8916	.5281	.583
24	.3961	.4252	.4115	.6859	.8328	.8573	.4904
Max	.8682	.7973	.9259	1.0288	1.134	1.0974	1.3717
Min	.3898	.3772	.4115	.3544	.3601	.4287	.4287
Avg	.5913	.5927	.6613	.6024	.6615	.6874	.8216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 203 / 11 KV YELEWASTI SINGLE SINGLE PHASING

PHASING Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3721	.4287	.3772	.443	.4287	.4338
2	.3395	.3544	.4115	.3772	.4252	.4287	.415
3	.3395	.3544	.4287	.3584		.463	.415
4	.3395		.5487	.3772	.4784	.5144	.4338
5	.547	.4961	.6687	.4715		.5487	.7167
6	.6859	.7619	.7545	.5658	.691	.583	.7373
7	.8676	.9036	.7545	.7167	.7265	.6859	.7373
8	.703	.6733	.6344	.7356	.7442	.7888	.6979
9	.5847	.4961	.4973		.4607	.4973	.7202
10	.547	.5138	.5487	.3544	.3721	.4115	.823
11		.4458	.583	.3366	.3258	.4527	.823
12	.5316	.4801	.6224	.3189	.3086	.4527	.8059
13	.4252	.463	.5281	.3366	.2743	.3961	.823
14	.4252	.4287	.5658	.3366	.3086	.3961	.823
15	.443	.4458	.5281	.3189	.3086	.4338	.8402
16	.443	.4973	.4904	.3366	.3258	.4715	.823
17	.3721	.4115	.4527	.3721	.4115		.4115
18	.4961	.4115	.4904	.4607	.4115	.5281	.4287
19	.6024	.4973	.5847	.567	.583	.6413	.5144
20	.6379	.583	.6602	.6379	.6516	.6413	.6001
21		.5487	.6413		.6001	.6036	.583
22	.5138	.4973	.5847		.5487	.5658	.5487
23	.3721	.463	.4338		.4458	.4527	.4973
24	.3584	.3721	.4287	.3961	.443	.4287	.4338
Max	.8676	.9036	.7545	.7356	.7442	.7888	.8402
Min	.3395	.3544	.4115	.3189	.2743	.3961	.4115
Avg	.4970	.4987	.5529	.4376	.4676	.5137	.6286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 204 / 11 KV 22 PHATA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.7796	.4801	.2075	.1772	.1715	.7922
2	.3961	.7442	.4801	.2075	.1772	.1715	.7922
3	.3961	.7442	.5144	.2263	.1772	.2572	.7733
4	.415	.7265	.583	.2263	.1949	.3601	.811
5	.5658		.6001	.3395		.4115	.9259
6	.7545	.815	.6516	.4904	.4252	.463	1.0631
7	.8676	.8328	.823	.5093	.4784	.4801	1.0669
8	.8413	.8682	.9259	.3772	.7796	.4287	1.0974
9	.3395	.3189	.2915		1.0277	1.0631	.3018
10	.1886	.2915	.2058	.9922	1.0631	1.166	.1886
11	.1595	.1886	.1543	.9391	1.0974	1.1145	.1715
12	.1417	.1886	.1509	.9036	1.1145	1.0631	.1715
13	.1595	.1715	.1509	.8859	1.0631	1.1145	
14	.1417	.1543	.1509	.9036	1.0631	1.0802	.1543
15	.1417	.1715	.2263	.9214	1.0974	1.0288	.1886
16	.1595	.2401	.2263	.9391	1.0631	1.0631	.2058
17	.2303	.2401	.2641	.2303	.2401	.2452	.2229
18	.3189	.2572	.3018	.2658	.2572	.3206	.2915
19	.3012	.2743	.2641	.2835		.3395	.3086
20	.2835	.2743	.2452	.3012		.3395	.2915
21		.2743	.2452		.2572	.3018	.2743
22	.2303	.2572	.2452		.2401	.2641	.2401
23	.7973	.4801	.2075		.2058	.7545	.823
24	.415	.0709	.4801	.1886	.1772	.1886	.7202
Max	.8676	.8682	.9259	.9922	1.1145	1.166	1.0974
Min	.1417	.0709	.1509	.1886	.1772	.1715	.1543
Avg	.3757	.4071	.3695	.5169	.5894	.5913	.5164

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214425 / 33/11 KV PAHUNEWADI

Feeder No / Name : 205 / 11 KV KHANDAJ AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6201	.4801	.3018	.3012	.2572	1.2146
2	.6979	.567	.4801	.3206	.2835	.2572	1.2289
3	.6979	.5847	.6173	.3206		.2572	1.1431
4	.7167	.6201	.7202	.3206	.3366	.3772	1.2308
5	.8488	.6733	.8402	.4527		.4973	1.4575
6	.9945	.7442	.9259	.6413	.5493	.6173	1.4632
7	1.166	.8859	1.0288	.6036	.6379	.6173	1.6461
8	1.166	.9922	.9945	.4527	.4961	.5487	1.7071
9	.4527	.3898	.3772		1.3643	1.5432	.3772
10	.3018	.3544	.3772	1.134	1.4529	1.7147	.2263
11		.2401	.2401	1.1694	1.5432	1.5242	.2058
12	.2126	.2401	.2263	1.2048	1.4403	1.5242	.2058
13	.1772	.2229	.2263	1.1694	1.3889	1.5851	.2058
14	.1595	.2058	.1886	1.1517	1.4575	1.5851	.1715
15	.2126	.2058	.2263	1.1694	1.4746	1.5851	.2401
16	.2303	.2401	.2263	1.1694	1.5089	1.5851	.2401
17	.3544	.3086	.3018	.3366	.3086	.3018	.3086
18	.443	.3429	.3772	.3721	.3772	.3395	.3086
19	.4607	.4458	.415	.443	.4458	.4527	.4115
20	.4784	.4458	.4527	.4784	.4458	.4338	.4115
21		.4115	.4338		.4115	.415	.4115
22	.3721	.3772	.3772		.3772	.3772	.3772
23	.567	.4801	.3206		.3086	1.1888	1.3032
24	.7167		.4801	.3018	.3012	.2915	1.1584
Max	1.166	.9922	1.0288	1.2048	1.5432	1.7147	1.7071
Min	.1595	.2058	.1886	.3018	.2835	.2572	.1715
Avg	.5441	.4608	.4722	.6757	.7823	.8282	.7356

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.

Feeder No / Name : 201 / 11 KV PARAWADI SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2458	.2915	.1457	.2075	.2075	.2075	.2515
2	.2458	.2915	.1457	.2075	.2075	.2075	.2515
3	.2458	.2915	.1457	.2075	.2075	.2075	.2515
4	.2458	.3077	.1457	.2263	.2641	.2263	.285
5	.2785	.3077	.1457	.3395	.3961	.3584	.3481
6	.3113	.3725	.2429	.6602	.5658	.6413	.5087
7	.3441	.4372	.3077	.6908	.7167	.5975	.6613
8	.3277	.4696	.3077	.547	.547	.5658	.7922
9	.2241	.3961	.2987	.421	.5087	.4508	.415
10		.2241	.168	.3441	.4588	.5243	.2241
11	.132	.168		.3277	.426	.4588	.168
12	.1132	.1494	.2241	.2949	.3932	.4588	.168
13	.0943	.1307	.2241	.2949	.3932	.426	.1307
14	.0943	.1494	.168	.2622	.3605	.426	.112
15	.0754	.1494	.168	.2458	.3277	.4424	.112
16	.1698	.1494	.1494	.2294	.3277	.4424	.112
17	.2263	.2075	.2075	.1698	.1886	.1886	.1494
18	.3584	.2452	.3018	.1886	.3772	.3772	.2241
19	.3206	.547	.4338	.3772	.5281	.5093	.4108
20	.3018	.2829	.5281	.4715	.4715	.4715	.3734
21	.2829	.2263	.3018	.3395	.3395	.2641	.3361
22	.2829	.2641	.2641	.2641	.2641	.2452	.2452
23	.2915	.1457	.2263	.2075	.2075	.2343	.2713
24	.2622	.2915	.1457	.1886	.2075	.2075	.2343
Max	.3584	.547	.5281	.6908	.7167	.6413	.7922
Min	.0754	.1307	.1457	.1698	.1886	.1886	.112
Avg	.2380	.2707	.2346	.3214	.3705	.3808	.2932

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.

Feeder No / Name : 202 / 11 KV KATPHAL SINGLE SINGLE PHASING  
PHASIN Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3772	.3772	.3462	.3887	.4531	.4338
2	.3361	.3772	.3772	.3462	.3887	.4531	.4338
3	.3361	.3772	.3772	.3462	.3887	.4531	.4338
4	.4481	.415	.4715	.3763	.4191	.4687	.5281
5	.5975	.4338	.679	.5079	.4527	.4843	.7282
6	.7842	.9808	1.0185	.6201	.6036	.7122	1.0082
7	.9522	.9242	.9431	.7973	.8718	.9156	1.1016
8	.8589	.811	.8865	.8939	.9665	.9221	.8817
9	.5243	.5281	.5079	.7282	.7545	.7468	.9555
10	.5197	.3441	.5407	.5601	.4668	.5601	1.0082
11	.4578	.3113	.4752	.3361	.3734	.4854	1.0082
12	.3561	.3277	.4915	.3361	.3361	.3547	1.2803
13	.39		.5243	.2987	.2801	.2987	1.2803
14	.407	.3277	.5243	.2987	.2801	.2987	1.3603
15	.3572	.3441	.5735	.2987	.3361	.2987	1.4091
16	.3286	.4096	.6062	.2987	.3361	.3174	1.3123
17	.5281	.3772	.3584	.3772	.4527	.3772	.4108
18	.6224	.4715	.5281	.5281	.547	.5658	.5228
19	.7167	.6224	.7356	.6602	.7733	.7922	.6722
20	.6602	.5658	.811	.8299	.7167	.7545	.7095
21	.5093	.4338	.6224	.5415	.6224	.5281	.7282
22	.415	.3772	.4904	.4854	.4904	.5281	.547
23	.3772	.3772	.3286	.3688	.4641	.4715	.4715
24	.3361	.3772	.3772	.3612	.3887	.4531	.4338
Max	.9522	.9808	1.0185	.8939	.9665	.9221	1.4091
Min	.3286	.3113	.3286	.2987	.2801	.2987	.4108
Avg	.5065	.4735	.5677	.4809	.5041	.5289	.8191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.

Feeder No / Name : 203 / 11 KV SHIRSUPHAL SINGLE SINGLE PHASING  
PHASIN Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1886	.2452	.1457	.1214	.1543	.2263
2	.1867	.1886	.2452	.1457	.1214	.1543	.2263
3	.1867	.1886	.2452	.1457	.1214	.1543	.2263
4	.2987	.1886	.2829	.1457	.1387	.1734	.2829
5	.3361	.1886	.3395	.1886	.156	.1907	.3961
6	.3734	.5847	.5281	.3012	.2534	.2835	.6224
7	.4668	.6036	.547	.3366	.3439	.3292	.5093
8	.4108	.5281	.4338	.3077	.3641	.3366	.4904
9	.1867	.1619	.2294	.3961	.3018	.3772	.3155
10	.1696	.1475	.213	.2614	.2614	.2987	.3277
11	.1357	.1638	.213	.2241	.2054	.2427	.3932
12	.1355	.1638	.213	.1867	.1867	.1867	.3932
13	.1372	.1802	.213	.1867		.1867	.3841
14	.1219	.1638	.213	.1494	.1867	.1867	.4001
15	.1235	.1638	.1475	.1494	.1494	.2054	.4161
16	.1235	.1638	.1543	.1494	.1494	.2241	.3841
17	.1886	.1698	.2263	.1886	.2075	.2263	.2054
18	.3018	.2263	.2075	.2452	.2829	.3772	.3921
19	.3961	.4338	.4527	.2829	.415	.3961	.3921
20	.3772	.415	.3961	.415	.3772	.3772	.3921
21	.3206	.3018	.3018	.3584	.3584	.2452	.3921
22	.2263	.2452	.2263	.2263	.2829	.2641	.2263
23	.1886	.2452	.1372	.124	.1526	.2263	.2263
24	.1867	.1886	.2452	.1457	.1214	.1543	.2263
Max	.4668	.6036	.547	.415	.415	.3961	.6224
Min	.1219	.1475	.1372	.124	.1214	.1543	.2054
Avg	.2402	.2581	.2773	.2253	.2287	.2480	.3519

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214433 / 33/11 KV PARAWADI S/STN.

Feeder No / Name : 204 / 11 KV NIMBODI SINGLE SINGLE PHASING  
PHASING Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.3563	.3239	.2641	.3887	.3206	.4973
2	.3932	.3563	.3239	.2641	.3395	.3206	.4973
3	.3932	.3563	.3239	.2641	.3395	.3206	.4973
4	.3932	.3887	.3239	.3018	.3961	.3584	.547
5	.3932	.421	.3239	.4715	.5847	.6036	.6173
6	.426	.3887	.4534	.6413	.8299	.7842	.7888
7	.4588	.583	.4534	.6602	.8676	.8402	.9945
8	.5243	.4534	.6478	.6348	.7655	.6984	.9614
9	.3734	.5281		.5921	.6154	.6964	.4904
10	.4854	.4108		.5735	.7865	.7865	.3734
11	.3206	.2987	.4108	.5079	.852	.8192	.2987
12	.2452	.2987	.2427	.5243	.8192	.6718	.2614
13	.2452	.2987	.2241	.5735	.8192	.7865	.2614
14	.2263	.2987	.2241	.6226	.8192	.7865	.2614
15	.1698	.2987	.2241	.6554	.8192	.8192	.2614
16	.2641	.2987	.1867	.6062	.7865	.8684	.2614
17	.3772	.3772	.3018	.3018	.3018	.2263	.2427
18	.4527	.3772	.3772	.3018	.4715	.4715	.4481
19	.679	.5281	.679	.5658	.6036	.6036	.6722
20	.5658	.4527	.679	.679	.5658	.5658	.6535
21	.4527	.3772	.4904	.5658	.5281	.4904	.5601
22	.3772	.3772	.3961	.415	.3961	.3961	.415
23	.3239	.3772	.3206	.3772	.3206	.4687	.5535
24	.4096	.3563	.3239	.2829	.3395	.3206	.4515
Max	.679	.583	.679	.679	.8676	.8684	.9945
Min	.1698	.2987	.1867	.2641	.3018	.2263	.2427
Avg	.3893	.3857	.3752	.4853	.5982	.5843	.4945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 201 / 11 KV KAMBALESHWAR SINGLE SINGLE PHASING  
PHAS Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.3582	.2204	.1543	.1526	.1844	.5487
2	.2622	.3582	.2374	.1372	.1526	.2374	.5243
3	.3018	.3582	.2543	.1372	.1696	.2572	.5571
4	.2949	.3582	.2572	.1715	.1696	.3258	.6226
5	.3277	.3761	.2713	.2401	.1696	.3353	.6882
6	.3768	.3856	.2883	.3429	.2374	.3688	.7373
7	.4096	.3856	.373	.3601	.2883	.3772	.7865
8	.4096	.3506	.3391	.2572	.3052	.3086	.7537
9	.2401	.2195	.1696	.4115	.6783	.8059	.1886
10	.1097	.2195	.1017	.4877	.7122	.8817	.1029
11	.1097	.1029	.1029	.5258	.7209	.9012	.112
12	.0914	.1509	.0686	.5731	.7291	.9175	.0754
13	.0914	.1174	.1029	.5609	.7291	.9175	
14	.0914	.1187	.1029	.5434	.7461	.8848	
15	.0914	.1187	.12	.5144	.763	.8684	
16	.0914	.1372	.1372	.5316	.763	.8684	.1867
17	.1097	.1526	.12	.1646	.1715	.1715	.1867
18	.1829	.1865	.2058	.1829	.1867	.2058	.2614
19	.2926	.2883	.2743	.2378	.3052	.2572	.3361
20	.3292	.2883	.3086	.3109	.3429	.3086	.3734
21	.2926	.2713	.2572	.2926	.2883	.2743	.3361
22	.2195	.2572	.2229	.2378	.2883	.2401	.2987
23	.3224	.2374	.1715	.1829	.2204	.5571	.5898
24	.2785	.3582	.2204	.1543	.1526	.1865	.5571
Max	.4096	.3856	.373	.5731	.763	.9175	.7865
Min	.0914	.1029	.0686	.1372	.1526	.1715	.0754
Avg	.2329	.2565	.2053	.3214	.3934	.4851	.4202

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 202 / 11 KV SHIRWALI SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3658	.415	.3932	.5601	.6722	.3772
2	.3429	.3658	.4108	.3353	.5975	.679	.3772
3	.3772	.4024	.4294	.3658	.5975	.6722	.4115
4	.4115	.4755	.5228	.3963	.6348	.6722	.4115
5	.4801	.4755	.5601	.4268	.6722	.6722	.4801
6	.5658	.6219	.5975	.4725	.6722	.6908	.583
7	.6516	.5853	.6535	.503	.7095	.7842	.6173
8	.6173	.6036	.5788	.5182	.6722	.7468	.5487
9	.4268	.4557	.5601	.4115	.4481	.4668	.5243
10	.4877	.4908	.5847	.4115	.4668	.4294	1.065
11	.5373	.5658	.5079		.4108	.4115	1.0852
12	.4477	.5093	.4588		.3772	.4115	1.2136
13	.4477	.5093	.4752	.3841	.3734		1.0513
14	.4298	.5041	.4588	.4024	.3734	.3429	1.0513
15	.4298	.5601	.4588	.4024	.3921	.3429	1.0174
16	.4298	.5601	.4588	.4207	.4108	.3772	.9389
17	.5121	.3961	.3772	.439	.4481	.4115	.3189
18	.5487	.4715	.5487	.4938	.4668	.4801	.5228
19	.6401	.6036	.6001	.6401	.5765	.5658	.6722
20	.6219	.5975	.6173	.6733	.6161	.583	.5975
21	.5853	.5788	.5487	.5853	.5601	.5144	.5601
22	.4755	.547	.4458	.5121	.5415	.4801	.5228
23	.4024	.4527	.3932	.4207	.6161	.4115	.4668
24	.3429	.3658	.3961	.3932	.5228	.6224	.4115
Max	.6516	.6219	.6535	.6733	.7095	.7842	1.2136
Min	.3429	.3658	.3772	.3353	.3734	.3429	.3189
Avg	.4815	.5027	.5024	.4546	.5299	.5409	.6594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 203 / 11 KV BARAVNAGAR SINGLE SINGLE PHASING  
PHASIN Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2195	.2401	.2134	.407	.4458	.2058
2	.2058	.2561	.2743	.2134	.4748	.4458	.2058
3	.2058	.2561	.3086	.2439	.5087	.4917	.2401
4	.2401	.3292	.3561	.2743	.5765	.5256	.3086
5	.3086	.4024	.4115	.3048	.6443	.5316	.4115
6	.5144	.5121	.5487	.3506	.78	.5596	.5316
7	.5658	.5853	.583		.8139	.8648	.5658
8	.5144	.6219	.5144	.7011	.8309	.9259	.4973
9	.4588	.5609	.5144	.3086	.3052	.373	.8453
10	.4572	.631	.6001	.2401	.2713	.2743	.9339
11	.4477	.5316	.5735	.1829	.1017	.2058	.8589
12	.3761	.5487	.5533	.1646	.1696	.2058	1.0852
13	.3582	.5087	.5636	.1463	.1526	.2058	1.1203
14	.3582	.39	.5735	.1463	.1357	.2058	.9831
15	.3582	.4115	.5636	.1646	.1543	.2058	.9496
16	.3761	.463	.4096	.1829	.1886	.2572	.8817
17	.2926	.2743	.2401	.3109	.2883	.3086	.3361
18	.3658	.3052	.3429	.3658	.3944	.3429	.4108
19	.5121	.4115	.4458	.4207	.4287	.4287	.4854
20	.4938	.3772	.4801	.5121	.4409	.4801	.4527
21	.439	.3561	.3258	.439	.3601	.3429	.4108
22	.3841	.3391	.2401	.2926	.3391	.2915	.3018
23	.2507	.2713	.2622	.3506	.4239		.2267
24	.1886	.2195	.2229	.1981	.373	.4115	.2058
Max	.5658	.631	.6001	.7011	.8309	.9259	1.1203
Min	.1886	.2195	.2229	.1463	.1017	.2058	.2058
Avg	.3692	.4076	.4228	.2925	.3985	.4057	.5606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 205 / 11 KV PONDKULE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1463	.1698	.2458	.3155	.3547	.1372
2	.1372	.1646	.1698	.2286	.3506	.3547	.1372
3	.1543	.1646	.2241	.2622	.4527	.3734	.1715
4	.1715	.1829	.2801	.2949	.4481	.3734	.1715
5	.2058	.2195	.2987	.3277	.5228	.3921	.2058
6	.3258	.2743	.3361	.3353	.5975	.4294	.2743
7	.3772	.2926	.3921	.4877	.679	.5975	.2743
8	.2915	.3292	.3395	.5243	.679	.6413	.2572
9	.3605	.333	.4294	.2561	.2263	.2452	.5898
10	.3353	.3506	.4715	.1646	.2054	.1886	.6554
11	.3582	.3921	.3978	.128	.1867	.1543	.6952
12	.3403	.3734	.3605	.1097	.1494	.1543	.6783
13	.3224	.2987	.3932	.1097	.1307	.1029	.6371
14	.3045	.2987	.3932	.1097	.1307	.1029	.6979
15	.2865	.3174	.426	.1463	.1307	.1029	.6443
16	.2865	.3361	.426	.1463	.1307	.1372	.6783
17	.1829	.1867	.1029	.1646	.1886	.1715	.1417
18	.2195	.1509	.1715	.1829	.2241	.2058	.2241
19	.2926	.2614	.2401	.2561	.2641	.2058	.2987
20	.2743	.2452	.2572	.2926	.3361	.2743	.2614
21	.2378	.2241	.2229	.2561	.2263	.2401	.2427
22	.1829		.1715	.2195	.2241	.1715	.2452
23	.1646	.1698	.2622	.2926	.3547	.1543	.1867
24	.1372	.1463	.1509	.2622	.3155	.3361	.1543
Max	.3772	.3921	.4715	.5243	.679	.6413	.6979
Min	.1372	.1463	.1029	.1097	.1307	.1029	.1372
Avg	.2536	.2547	.2953	.2418	.3112	.2693	.3608

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 206 / 11 KV PATILWASTI SINGLE SINGLE PHASING  
PHASIN Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.5373	.4191	.2058	.2012	.2347	.7865
2	.6062	.5609	.4359	.2058	.2374	.2614	.7865
3	.6299	.5609	.4359	.2058	.2683	.285	.8192
4	.6554	.5959	.4527	.2401	.3052	.3185	.8192
5	.6882	.6661	.4578	.2743	.3018	.3521	.852
6	.7209	.7202	.4748	.4115	.3391	.3856	.8848
7	.7865	.7545	.5868	.4801	.3688	.4854	1.0322
8	.8192	.7545	.6203	.3429	.3521	.373	.9995
9	.2743	.2835	.2347	.7701	.8718	1.0227	.2572
10	.2058	.2561	.1696	.8745	.9156	1.1401	.2058
11	.1829	.2241	.1715	.8573	1.0395	1.1142	.1886
12	.1646	.1844	.1372	.8573	1.0059	1.1142	.1886
13	.1646	.1677	.1543	.823	.9724	1.0814	.1829
14	.1646	.1844	.1372	.823	1.0059	1.0486	.1494
15	.1463	.1509	.1372	.823	1.0682	.9831	.1886
16	.1463	.2012	.1543	.823	1.0562	.9831	.2241
17	.1829	.2374	.1372	.2195	.218	.2401	.2614
18	.2561	.1844	.2401	.2561	.2515	.2743	.2926
19	.3841	.3052	.3898	.3109	.3353	.3601	.3734
20	.4024	.285	.3772	.4024	.3353	.4115	.4108
21	.3658		.3429	.3658	.3018	.3086	.3734
22	.2561	.2515	.2743	.2926	.3018	.2743	.3395
23	.4298	.4191	.2229	.2195	.2347	.8192	.78
24	.6226	.5373	.4191	.2058	.2012	.218	.8192
Max	.8192	.7545	.6203	.8745	1.0682	1.1401	1.0322
Min	.1463	.1509	.1372	.2058	.2012	.218	.1494
Avg	.4113	.3923	.3160	.4704	.5204	.5871	.5090

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214441 / 33/11 SANGAVI S/STN

Feeder No / Name : 207 / 11 KV SANGAVI SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.3292	.2075	.2743	.3734	.3921	.4588
2	.1981	.3292	.2263	.2743	.4481	.4338	.4752
3	.2134	.3292	.2452	.3086	.4481	.4668	.5243
4	.2743	.3475	.2801	.3772	.4854	.5601	.5898
5	.3048	.3475	.3547	.4458	.5228	.6161	.6226
6	.3658	.439	.4108	.6859	.6348	.7468	.6882
7	.3048	.439	.4481	.6687	.7095	.7468	.7373
8	.3658	.4024	.4294	.5487	.6908	.6348	.6554
9	.5487	.4572	.5041	.3429	.4108	.5788	.4973
10	.3772	.4938	.4108	.2896	.4294	.6722	.4115
11	.3292	.415	.2401	.3109	.5228	.5571	.3018
12	.2743	.3547	.2058	.2865	.5041	.5571	.2614
13	.2743	.3361	.2058	.3155	.4854	.5243	.2987
14	.2561	.2801	.2743	.3582	.4668	.5487	.2987
15	.2561	.3361	.2743	.3506	.4854	.5243	.3292
16	.2561	.3734	.2743	.3506	.5228	.5243	.3584
17	.439	.4715		.4024	.4715	.426	.4024
18	.5853	.4294	.5487	.439	.5415	.4915	.4481
19	.6584	.5601	.6173	.6584	.5975	.4915	.5228
20	.6401	.5601	.6516	.6767	.6413	.5487	.5975
21	.5487	.5601	.5144	.5487	.5228	.4973	.5658
22	.439	.5281	.4801	.4755	.5041	.463	.5281
23	.3224	.2241	.3601	.3658	.3921	.4752	.5487
24	.1966	.3292	.1886	.2915	.3361	.3547	.4588
Max	.6584	.5601	.6516	.6859	.7095	.7468	.7373
Min	.1829	.2241	.1886	.2743	.3361	.3547	.2614
Avg	.3588	.403	.3631	.4186	.5061	.5347	.4825



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 201 / 11 KV SALOBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6325	.4428	.6325	.0474	.0474	.0633	.8223
2	.6009	.427	.6009	.0474	.0474	.0633	.8223
3	.6009	.427	.6009	.0474	.0474	.0474	.7907
4	.6009	.427	.6009	.0474	.0474	.0474	.7907
5	.5693	.427	.6009	.0633	.0474	.0474	.8223
6	.5693	.4586	.6009	.0633	.0633	.0633	.8381
7	.6325	.5218	.6483	.0633	.0633	.0791	.9014
8	.0474	.6325	.759	.0633	.0474	.0791	.9804
9	.0474	.0474	.0633	.8539	.933	1.1544	.0633
10	.0316	.0474	.0633	.933	1.1069	1.2176	.0474
11	.0474	.0633	.0633	.9488	1.1227	1.2651	.0474
12	.0633	.0633	.0633	.9804	1.1069	1.1702	.0316
13	.0316	.0474	.0791	.9014	1.0753	1.1069	.0633
14	.0316	.0474	.0633	.9646	.9804	1.0595	.0474
15	.0316	.0474	.0633	.9172	.9804	1.012	.0474
16	.0316	.0474	.0474	.9172	.9962	1.0279	.0633
17	.0316	.0474	.0474	.0474	.0316	.0633	.0474
18	.0474	.0474	.0474	.0474	.0474	.0474	.0474
19	.0474	.0633	.0633	.0474	.0474	.0474	.0633
20	.0633	.0633	.0633	.0633	.0633	.0633	.0474
21	.0633	.0633	.0633	.0633	.0633	.0474	.0474
22	.0474	.0633	.0474	.0474	.0633	.0474	.0474
23	.4902	.6325	.0474	.0474	.0633	.8381	1.012
24	.6642	.4902	.6325	.0474	.0474	.0633	.8381
Max	.6642	.6325	.759	.9804	1.1227	1.2651	1.012
Min	.0316	.0474	.0474	.0474	.0316	.0474	.0316
Avg	.2510	.2352	.2734	.3446	.3808	.4467	.3887

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 202 / 11 KV YAMAI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0972	.1134	.7865	.8097	.9503	.1134
2	.081	.0972	.1134	.7701	.8097	.9175	.1134
3	.081	.0972	.1134	.7865	.8097	.9175	.1134
4	.0972	.0972	.1296	.7865	.8421	.9339	.1134
5	.0972	.1134	.1296	.852	.8745	.9503	.1457
6	.1296	.1457	.1457	.9831	.9717	1.0159	.1781
7	.1781	.1619	.1943	1.065	1.1012	1.2125	.1943
8	.1619	.1296	.1619	1.1797	1.166	1.2616	.1943
9	.9069	.8745	1.0202	.0983	.1134	.1311	1.2955
10	.8745	1.004	1.0486	.1296	.1311	.1311	1.587
11	.8745	1.085	1.1142	.1296	.0983	.1296	1.6194
12	.9069	1.085	1.1305	.1296	.0983	.0972	1.668
13	.8907	1.0526	1.065	.0972	.1311	.0972	1.6518
14	.8745	1.0526	1.1142	.0972	.1147	.1134	1.6032
15	.8259	1.0526	1.1469	.0972	.1147	.1134	1.587
16	.8259	1.0202	1.1469	.1134	.1311	.1296	1.5546
17	.0972	.081	.1147	.1134	.1147	.1296	.081
18	.0972	.081	.1147	.1296	.0983	.1134	.081
19	.1134	.1296	.1475	.1619	.1475	.1457	.1134
20	.1457	.1457	.1475	.1781	.1638	.1943	.1457
21	.1457	.1619	.1475	.1619	.1475	.1781	.1457
22	.1296	.1457	.1311	.1457	.1311	.1781	.1457
23	.0972	.1134	.9503	.8097	1.0159	.1457	.1296
24	.081	.0972	.1134	.8684	.8097	.9667	.1296
Max	.9069	1.085	1.1469	1.1797	1.166	1.2616	1.668
Min	.081	.081	.1134	.0972	.0983	.0972	.081
Avg	.3664	.4217	.4898	.4446	.4561	.4647	.6127

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 203 / 11 KV NAGESHWAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.7095	.7468	.6722	.8299	.7468	.7095
2	.6348	.7095	.7842	.6722	.8215	.7468	.7095
3	.6348	.7095	.7842	.7095	.8215	.7095	.6722
4	.6348	.7468	.7842	.6908	.8589	.7095	.7095
5	.6722	.8215	.8589	.8589	.9149	.7842	.7842
6	.9709	.9149	.9709	1.0082	1.0082	.9709	1.0456
7	1.2696	1.1949	1.1949	1.1576	1.1576	1.1389	1.2696
8	1.1949	1.0456	1.0829	1.0829	1.0456	1.0082	1.0829
9	.9709	1.0082	1.0269	.9709	1.0269	.9896	1.0082
10	.8775	.8962	.8402	.9709	.8215	.9522	1.0082
11	.9335	.9335	.8589	.9522	1.0082	.9709	.9522
12	.8962	.8589	.8962	.8962	.9149	.8589	.9522
13	.7842	.8029	.8402	.8215	.8775	.8215	.9335
14	.7468	.8215	.7468	.8215	.8589	.8589	.9149
15	.7282	.8962	.7095	.9149	.8589	.8962	.9335
16	.7468	.9149	.6908	.7842	.9149	1.0082	.9522
17	.8215	.8962	.7842	.9709	.8402	.9709	.9709
18	.7842	.7655	.7468	.8215		.8962	.9335
19	1.0456	.9709	.9709	1.0456	1.0082	1.0456	1.1016
20	1.0456	1.0456	1.0269	1.0829	1.0642	1.0456	1.1016
21	1.0456	1.0456	.9709	1.0456	1.0082	1.0829	1.0456
22	1.0082	.9896	.9709	1.0082	.9709	1.0456	.9896
23	.8215	.8402	.8215	.9335	.8962	.8962	.9522
24	.6722	.7282	.7468	.7282	.8299	.7842	.7842
Max	1.2696	1.1949	1.1949	1.1576	1.1576	1.1389	1.2696
Min	.6348	.7095	.6908	.6722	.8215	.7095	.6722
Avg	.8581	.8861	.8690	.9009	.9286	.9141	.9382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 204 / 11 KV NANDAN EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2641	.3961	.2801	.3018	.3921	.3772
2	.3395	.2641	.3772	.2987	.3018	.3547	.3395
3	.3395	.2641	.3772	.2614	.3018	.3174	.3395
4	.3206	.2641	.3961	.3174	.3018	.3174	.3395
5	.3395	.3018	.3772	.3734	.3395	.2987	.3584
6	.3584	.3584	.3772	.4294	.3772	.3361	.3961
7	.4527	.4527	.2641	.4481	.3772	.3921	.415
8	.4904	.3584	.4715	.4668	.415	.4108	.5093
9	.3206	.3206	.3206	.3174	.3584	.3174	.2829
10	.5847	.415	.5415	.415	.4108	.5975	.5847
11	.6224	.415	.5601	.3961	.6348	.6036	.6413
12	.5658	.3772	.4854	.4715	.6348	.547	.5658
13	.4715	.3584	.4668	.415	.4668	.5281	.5093
14	.4715	.547	.4668	.3772	.5415	.4904	.4715
15	.4527	.3206	.4668	.415	.4108	.4715	.4527
16	.4527	.5093	.4481	.3395	.3921	.4904	.4338
17	.4715	.547	.4854	.415	.4481	.3961	.3772
18	.547	.5093	.5228	.5093	.5041	.5093	.5281
19	.4904	.5658	.4854	.3961	.4854	.5281	.4715
20	.5093	.5281	.5228	.5847	.5975	.5093	.415
21	.5093	.5281	.6161	.415	.5601	.4904	.4527
22	.5093	.5281	.5415	.3018	.5415	.5658	.4527
23	.4338	.4527	.2987	.3018	.5041	.547	.4715
24	.4527	.2829	.415	.2614	.3395	.4294	.415
Max	.6224	.5658	.6161	.5847	.6348	.6036	.6413
Min	.3206	.2641	.2641	.2614	.3018	.2987	.2829
Avg	.4535	.4055	.4450	.3836	.4394	.4517	.4417

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214472 / 33 KV MALEGAON (KH)

Feeder No / Name : 205 / 11 KV NIAM EXPRESS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0566	.0754	.0754	.0754	.0754	.0754
2	.0754	.0566	.0754	.0754	.0754	.0754	.0754
3	.0754	.0566	.0754	.0754	.0754	.0754	.0754
4	.0754	.0566	.0754	.0754	.0754	.0754	.0754
5	.0754	.0566	.0754	.0566	.0566	.0566	.0754
6	.0566	.0566	.0566	.0754	.0566	.0566	.0566
7	.0754	.0566	.0566	.0754	.0566	.0566	.0566
8	.0566	.0566	.0566	.1132	.0566	.0943	.0754
9	.0566	.0566	.0754	.132	.1132	.0943	.1509
10	.132	.1509	.1886	.1698	.1886	.132	.2452
11	.132	.2263	.1698	.1886	.1886	.132	.2263
12	.132	.2075	.1886	.1886	.1886	.132	.2263
13	.1132	.1886	.2263	.1698	.1698	.132	.2075
14	.0943	.1886	.2263	.1886	.1509	.132	.1698
15	.1132	.1886	.2452	.2075	.1509	.132	.2075
16	.1132	.1509	.2263	.1886	.1698	.132	.2075
17	.0943	.1132	.132	.1509	.0943	.1132	.132
18	.0754	.1132	.1132	.0943	.1132	.0754	.0943
19	.0754	.0943	.1509	.0943	.0943	.0943	.1132
20	.0754	.0754	.0943	.0754	.0754	.0754	.132
21	.0754	.0754	.0943	.0754	.0754	.0754	.132
22	.0754	.0566	.0943	.0754	.0754	.0754	.0754
23	.0566	.0754	.0754	.0754	.0754	.0754	.0754
24	.0754	.0566	.0754	.0754	.0754	.0754	.0754
Max	.132	.2263	.2452	.2075	.1886	.132	.2452
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.0856	.1030	.1218	.1155	.1053	.0935	.1265

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 201 / 11 KV SHIRSUPHAL SINGLE SINGLE PHASING  
PHASIN Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1989	.1989	.2204	.12	.1311	.1658	.2515
2	.2012	.2652	.2204	.12	.1326	.1844	.2652
3	.1989	.3315	.2713	.12	.1326	.1823	.2652
4	.2347	.4144	.2883	.12	.1492	.3315	.3391
5	.2486	.5087	.3647	.1886	.1638	.3647	.4527
6	.2984	.5304	.3812	.2743	.213	.4973	.4694
7	.3353	.57	.407	.3086	.3812	.5304	.4807
8	.4527	.5304	.3812	.3772	.3978	.4807	.4475
9	.1677	.1844	.1823	.2743	.4409	.3688	.3222
10	.1326	.1989	.213	.2401	.4409	.3481	.4475
11	.1326	.1966	.1989	.2401	.4239	.3222	.4917
12	.1326	.1865	.1823	.2058	.3978	.3222	.5087
13	.1492	.1823	.1823	.2058	.3856	.3052	.5138
14	.1326	.1696	.1823	.2401	.3315	.3052	.5426
15	.116	.1658	.1823	.2058	.2713	.2374	.5596
16	.116	.1492	.1989	.2058	.2515	.2035	.5596
17	.2035	.2204	.2155	.2229	.2035	.2515	.2374
18	.2035	.2713	.2321	.2915	.3315	.2915	.2543
19	.2035	.3052	.2652	.3258	.431	.3155	.2883
20	.2155	.3113	.2155	.3601	.4239	.3544	.3366
21	.2321	.2883	.1989	.3601	.4298	.3561	.3315
22	.2543	.2713	.1658	.3086	.2984	.3224	.3481
23	.218	.2374	.0995	.12	.1612	.2622	.2622
24	.192	.1989	.1989	.1029	.1326	.1492	.2515
Max	.4527	.57	.407	.3772	.4409	.5304	.5596
Min	.116	.1492	.0995	.1029	.1311	.1492	.2374
Avg	.2071	.2870	.2353	.2308	.2940	.3105	.3845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 202 / 11 KV GADIKHEL SINGLE SINGLE PHASING  
PHASING Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.2652	.218	.0686	.1326	.1017	.3277
2	.1658	.2652	.2347	.0686	.1357	.116	.3391
3	.1677	.2683	.2347	.0686	.1326	.116	.3018
4	.1658	.2652	.218	.0686	.1357	.1658	.3185
5	.2347	.3481	.2486	.1029	.1492	.2035	.3185
6	.2321	.3812	.2984	.12	.1823	.2204	.3481
7	.2984	.3647	.3185	.1886	.2652	.2347	.3647
8	.373	.3315	.3052	.1715	.2486	.2012	.1492
9	.0829	.1326	.0829	.2229	.1844	.2204	.1492
10	.0829	.0995	.0848	.1715	.1658	.2204	.1966
11	.0829	.0995	.0848	.1543	.1492	.2035	.2347
12	.1006	.116	.0838	.12	.1526	.1865	.285
13	.1017	.116	.0671	.1029	.1326	.1696	.3149
14	.0829	.0995	.0671	.0857	.116	.1509	.3353
15	.0848	.0995	.0663	.1029	.0995	.1357	.3521
16	.0995	.0663	.0983	.0857	.0829	.0838	.3688
17	.1509	.0995	.0995	.1029	.116	.1017	.1017
18	.1526	.1823	.1187	.1543	.3761	.1595	.1492
19	.1509	.3045	.1357	.1543	.4024	.2507	.2155
20	.2035	.3224	.1187	.1543	.3841	.3224	.2486
21	.2374	.3045	.1075	.1372	.3582	.3761	.2984
22	.2713	.2865	.1109	.1543	.3224	.3582	.3277
23	.2543	.2543	.0663	.12	.0663	.3041	.3185
24	.2155	.2486	.2486	.0686	.1326	.0829	.3222
Max	.373	.3812	.3185	.2229	.4024	.3761	.3688
Min	.0829	.0663	.0663	.0686	.0663	.0829	.1017
Avg	.1732	.2217	.1549	.1229	.1926	.1952	.2786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 203 / 11 KV ATOLEWASTI SINGLE SINGLE PHASING  
PHASIN Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.1326	.1326	.0857	.116	.0678	.116
2	.1326	.1326	.1357	.0857	.116	.0671	.1187
3	.1326	.1187	.1509	.0857	.116	.0671	.1326
4	.1357	.1357	.1526	.0857	.116	.0838	.1357
5	.1357	.1989	.1658	.0857	.1326	.0848	.1509
6	.0995	.1865	.1823	.1029	.1326	.1017	.1989
7	.1492	.2035	.1823	.12	.1823	.116	.1823
8	.1174	.1492	.1677	.1372	.1357	.0848	.1326
9	.1017	.0829	.1187	.1029	.116	.1357	.2155
10	.1017	.0829	.0829	.1029	.116	.1526	.2818
11	.1006	.0995	.1017	.0857	.0995	.1357	.2652
12	.116	.116	.1357	.0686	.0995	.1357	.2683
13	.1187	.1187	.1006		.0838	.1187	.2883
14	.1017	.116	.0995		.0829	.1187	.3113
15	.1006	.1187	.1187	.0686	.0663	.0848	.3185
16	.1006	.0995	.1174	.0686	.0663	.0838	.2949
17	.0848	.197	.0678	.0857	.0848	.0838	.0503
18	.1006	.2035	.0829	.0857	.1492	.1063	.124
19	.0983	.2204	.1006	.0857	.1658	.1254	.1612
20	.116	.197	.1017	.0857	.1475	.1433	.1254
21	.1254	.2012	.0829	.0857	.1433	.1612	.1254
22	.1341	.1612	.0716	.0686	.1311	.1433	.1433
23	.1147	.1492	.0829	.1029	.0829	.1311	.1448
24	.1326	.1326	.1492	.0857	.116	.0838	.1357
Max	.1492	.2204	.1823	.1372	.1823	.1612	.3185
Min	.0848	.0829	.0678	.0686	.0663	.0671	.0503
Avg	.1160	.1481	.1202	.0896	.1166	.1090	.1842



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 204 / 11 KV PATILWASTI SINGLE SINGLE PHASING  
PHASIN Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0995	.0995	.1187	.1543	.1658	.0995	.116
2	.0829	.1017	.116	.1715	.1658	.116	.116
3	.0819	.116	.116	.1715	.1658	.1823	.1341
4	.1017	.116	.1526	.1543	.1658	.1823	.1526
5	.1326	.116	.1696	.1715	.1989	.2204	.2012
6	.1326	.1989	.2035	.1886	.2321	.2321	.218
7	.1658	.2204	.2155	.2401	.2818	.2486	.2347
8	.1677	.2035	.2204	.2743	.2818	.2155	.2012
9	.1989	.2012	.1802	.1029	.0995	.1341	.3521
10	.1966	.1357	.2035	.0857	.0995	.1341	.4359
11	.1492	.1357	.2204	.0686	.0995	.1357	.427
12	.1492	.1311	.2374	.0686	.0829	.1187	.4887
13	.1492	.1357	.1509	.0686	.0848	.1187	.4586
14	.1326	.116	.1341	.0686	.0829	.1187	.4801
15	.1326	.116	.1677	.0514	.0671	.1017	.5304
16	.1326	.1187	.1357	.0686	.0663	.1017	.547
17	.1075	.1357	.0332	.0686	.0332	.0848	.0716
18	.1433	.1433	.0655	.0686	.0716	.0895	.064
19	.116	.1254	.0655	.1029	.0716	.1075	.0655
20	.1326	.116	.0678	.0857	.1086	.1075	.1063
21	.1433	.116	.0678	.0857	.1267	.1254	.0716
22	.1629	.1326	.0503	.0686	.1326	.1254	.1075
23	.0983	.1187	.1006	.1715	.0995	.0995	.0983
24	.0995	.0829	.1017	.1715	.1658	.0829	.1006
Max	.1989	.2204	.2374	.2743	.2818	.2486	.547
Min	.0819	.0829	.0332	.0514	.0332	.0829	.064
Avg	.1337	.1347	.1373	.1222	.1312	.1368	.2408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 205 / 11 KV TILEKARWASTI SINGLE SINGLE PHASING  
PHAS Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1658	.1357	.0686	.0328	.0335	.4191
2		.1492	.1492	.0686	.0332	.0335	.4024
3		.1492	.1509	.0686	.0497	.0335	.4239
4		.1492	.2012	.0686	.0663	.0335	.4144
5		.1823	.218	.0857	.0829	.0678	.4409
6		.1823	.2347	.0857	.0829	.0678	.4641
7		.1492	.2543	.0686	.0995	.0678	.503
8		.2374	.218	.0857	.0663	.0678	.4359
9		.0332	.0339	.2743	.4409	.5087	.0332
10		.0663	.0503	.3086	.431	.5426	.0335
11		.0663	.0509	.3429	.4475	.57	.0339
12		.0663	.0503	.3429	.4475	.5868	.0335
13	.0339	.0339	.0509	.3601	.431	.5868	.0335
14	.0332	.0339	.0509	.3944	.4475	.6104	.0339
15	.0339	.0332	.0503	.4287	.4641	.6613	.0335
16	.0328	.0339	.0509	.4458	.0332	.7042	.0339
17	.0332	.0358	.0509	.0514		.0671	.0332
18	.0358	.0358	.0537	.0514	.0358	.0716	.0335
19	.0358	.0358	.0983	.0514	.0358	.0724	.0354
20	.0358	.0362	.1326	.0686	.0362	.0678	.0358
21	.0358	.0358	.1357	.0686	.0358	.0724	.0358
22	.0339	.0362	.1075	.0514	.0335	.0709	.0358
23	.1823	.1448	.1017	.0343	.0335	.4607	.4024
24		.1677	.1492	.0686	.0332	.0332	.4359
Max	.1823	.2374	.2543	.4458	.4641	.7042	.503
Min	.0328	.0332	.0339	.0343	.0328	.0332	.0332
Avg	.0479	.0942	.1158	.1643	.1696	.2538	.2009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214491 / 33/11 KV SHIRSUPHAL

Feeder No / Name : 206 / 11KV GARMALA SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.1174	.1187	.2058	.1658	.1658	.1989
2	.1326	.116	.1187	.2058	.1658	.1865	.218
3	.1357	.116	.1492	.2058	.1696	.1823	.2515
4	.1658	.2347	.1696	.2229	.2321	.1865	.3149
5	.1696	.2543	.2012	.2572	.2486	.3018	.3481
6	.1989	.2713	.2155	.3429	.3768	.3052	.3647
7	.1966	.2622	.2347	.4458	.4409	.3185	.3812
8	.2321	.2374	.2035	.2915	.3052	.3018	.3481
9	.1966	.2155	.1187	.1029	.2984	.2543	.1696
10	.1492	.2321	.1526	.1372	.3052	.2713	.1341
11	.1492	.1658	.1357	.1886	.2883	.2713	.1311
12	.1658	.1357	.1526	.1886	.285	.2683	.1509
13	.1696	.1326	.1187	.1715	.2486	.285	.1509
14	.1526	.1357	.1341	.1715	.2374	.2883	.1638
15	.1326	.1492	.1174	.1715	.1989	.2883	.1865
16	.1341	.1526	.1187	.1543	.1658	.3018	.2035
17	.1526	.1417	.1791	.1715	.1658	.1791	.2481
18	.1595	.1646	.1991	.1886	.2033	.1949	.2507
19	.1595	.1791	.2195	.2058	.2328	.2328	.2328
20	.1612	.2012	.2481	.2229	.2865	.2686	.2328
21	.1791	.2149	.2328	.2401	.2294	.3012	.2149
22	.1829	.2149	.2149	.2058	.218	.2507	.2328
23	.1075	.1006	.1966	.1715	.1658	.1475	.2149
24	.1341	.0995	.1006	.2058	.1658	.1658	.1326
Max	.2321	.2713	.2481	.4458	.4409	.3185	.3812
Min	.1075	.0995	.1006	.1029	.1658	.1475	.1311
Avg	.1605	.1769	.1688	.2115	.2417	.2466	.2281

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 201 / 11 KV KARKHEL SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.2134	.3258	.3429	.3429	.4115
2	.1372	.1372	.2134	.3258	.3429	.3429	.4115
3	.1524	.1524	.2134	.3258	.3429	.3429	.4115
4	.2134	.2134	.2286	.3601	.3772	.3772	.463
5	.2439	.2743	.3048	.5487	.4458	.6344	.6516
6	.3658	.3658	.3963	1.0117	.9945	.823	1.0117
7	.442	.4268	.5487	1.0117	1.0631	1.0288	1.0802
8	.3658	.381	.3658	.7373	.823	.7716	.7716
9	.4801	.4801	.4115	.3963	.3048	.3963	.3963
10	.3944	.3944	.3601	.3658	.3658	.3963	.3963
11	.2743	.2743	.2572	.3353	.3353	.381	.381
12	.2229	.2401	.2229	.3048	.3353	.381	.381
13	.2572	.2572	.2058	.2896	.3506	.3658	.4115
14	.2058	.2401	.2058	.3048	.3201	.3963	.4268
15	.1886	.2401	.2229	.2743	.3048	.381	.4115
16	.2743	.2572	.2572	.3048	.3201	.381	.4268
17	.4973	.4973	.2915	.3086	.3086	.3601	.3601
18	.5316	.5316	.4801	.4287	.4458	.6344	.6344
19	.703	.6516	.7202	.6859	.6859	.7888	.7202
20	.6687	.6687	.7373	.7202	.7202	.703	.703
21	.6001	.5316	.4973	.6173	.6173	.6001	.6001
22	.4287	.463	.4458	.463	.4801	.5144	.5144
23	.1524	.1829	.3772	.4115	.3944	.463	.1981
24	.1372	.1524	.1981	.3429	.3772	.3772	.4287
Max	.703	.6687	.7373	1.0117	1.0631	1.0288	1.0802
Min	.1372	.1372	.1981	.2743	.3048	.3429	.1981
Avg	.3364	.3396	.3490	.4667	.4749	.5076	.5251

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 202 / 11 KV KHARADWADI SINGLE SINGLE PHASING  
PHASIN Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1981	.3258	.3086	.3086	.3429
2	.1524	.1524	.2134	.3258	.3086	.3086	.3429
3	.1677	.1677	.2286	.3258	.3086	.3086	.3429
4	.1981	.1981	.2286	.3429	.3086	.3601	.4115
5		.2896	.2896	.5316	.3258	.4973	.5487
6		.3506	.381	.9431	.9431	.703	.8916
7	.0914	.3048	.4115	1.0288	.9774	.9088	.9774
8	.1219	.2896	.3506	.8059	.8402	.8573	.8402
9	.0857	.3772	.6001	.3353	.3353	.3201	.3506
10	.0686	.3429	.3772	.3201	.3506	.3353	.3506
11	.0686	.3086	.2572	.3201	.3353	.3201	.3506
12	.0686	.2743	.0514	.2743	.3506	.3048	.3658
13	.2743	.2743	.0514	.2439	.3658	.2896	.3506
14	.2572	.2572	.2229	.2286	.3353	.3201	.3658
15	.2743	.2572	.2058	.2439	.3048	.3201	.3506
16	.2572	.2572	.2058	.2439	.2591	.3353	.3353
17	.5658	.5658	.2401	.2915	.2915	.3086	.3086
18	.6001	.6001	.4458	.4115	.463	.4458	.4458
19	.823	.7202	.7545	.7202	.7202	.7373	.6344
20	.6344	.703	.7716	.7545	.7545	.6859	.6859
21	.5487	.583	.583	.6001	.6001	.583	.583
22	.3944	.4973	.4458	.4801	.4458	.4801	.4801
23	.1372	.1524	.3601	.3601	.3601	.3944	.1829
24	.1677	.1524	.1524	.3429	.3429	.3258	.3601
Max	.823	.7202	.7716	1.0288	.9774	.9088	.9774
Min	.0686	.1524	.0514	.2286	.2591	.2896	.1829
Avg	.2786	.3428	.3344	.4500	.4557	.4483	.4666

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 203 / 11 KV UNDAWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.1067	.1067	.1067	.1219	.1067	.1219
2	.1067	.1067	.1067	.1067	.1219	.1067	.1219
3	.1067	.1067	.0914	.1067	.1219	.1219	.1219
4	.1372	.1372	.1219	.1372	.1219	.1372	.1524
5	.1829	.1829	.1829	.1829	.1372	.1981	.2134
6	.2439	.2439	.2743	.2439	.2134	.2134	.2591
7	.2896	.2286	.2591	.2591	.2286	.2743	.2439
8	.2286	.1981	.1829	.1981	.1829	.1981	.2134
9	.1981	.1524	.1524	.1524	.1524	.1677	.1677
10	.1372	.1067	.1067	.0914	.1372	.1372	.1372
11	.1219	.0914	.0914	.0762	.1219	.0914	.1067
12	.0914	.061	.0762	.0762	.061	.0762	.0914
13	.0762	.061	.061	.0762	.061	.0762	.0762
14	.0762	.0762	.061	.0762	.061	.0762	.0762
15	.0914	.0762	.061	.0762	.2286	.0762	.0762
16	.0914	.1067	.061	.0762	.061	.0762	.061
17	.1524	.1372	.0762	.0762	.1067	.1067	.1067
18	.1677	.1524	.1067	.1219	.1372	.1372	.1372
19	.2134	.1829	.1677	.1981	.1981	.1981	.1829
20	.1981	.1981	.1981	.2134	.2134	.1981	.1981
21	.1829	.1677	.1829	.1829	.1829	.1677	.1677
22	.1372	.1524	.1524	.1524	.1524	.1524	.1524
23	.12	.1219	.1372	.1219	.1219	.1372	.1372
24	.1067	.1067	.1067	.1219	.1219	.1067	.1219
Max	.2896	.2439	.2743	.2591	.2286	.2743	.2591
Min	.0762	.061	.061	.0762	.061	.0762	.061
Avg	.1485	.1359	.1302	.1346	.1403	.1391	.1435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 204 / 11 KV SONWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.061	.0762	.0762	.0686	.0857
2	.0686	.0686	.061	.0762	.0762	.0686	.0857
3	.0686	.0686	.0762	.0762	.0914	.0857	.0857
4	.0857	.0686	.0762	.0914	.0914	.1029	.1029
5	.1029	.0857	.0762	.1067	.1067	.12	.1543
6	.1372	.12	.1067	.1219	.1524	.1372	.2058
7	.12	.1029	.1677	.1829	.1981	.1886	.2058
8	.12	.1029	.1372	.2134	.2286	.1372	.1715
9	.0914	.0914	.12	.1029	.0857	.1524	.1829
10	.0762	.0762	.0857	.0686	.0857	.2134	.2134
11	.0762	.0914	.0686	.0686	.0686	.1981	.1981
12	.0762	.0914	.0514	.0686	.0514	.1829	.1829
13	.0762	.0762	.0514	.0514	.0514	.1524	.1829
14	.0762	.0762	.0514	.0514	.0514	.1524	.1981
15	.0914	.0914	.0514	.0514	.0686	.1829	.1829
16	.0762	.1067	.0514	.0686	.0686	.1981	.1829
17	.0857	.0857	.0857	.0857	.0686	.0857	.0857
18	.1029	.1029	.0857	.1029	.0686	.12	.12
19	.12	.1029	.12	.12	.12	.1543	.1543
20	.12	.12	.1372	.1372	.1372	.1372	.1372
21	.1029	.1029	.1029	.12	.12	.12	.12
22	.0857	.1029	.1029	.1029	.1029	.1029	.1029
23	.0686	.0762	.0914	.0762	.0857	.1029	.0857
24	.0686	.0686	.0762	.0762	.0762	.0686	.0857
Max	.1372	.12	.1677	.2134	.2286	.2134	.2134
Min	.0686	.0686	.0514	.0514	.0514	.0686	.0857
Avg	.0903	.0895	.0873	.0957	.0972	.1347	.1464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 205 / 11 KV SABALEWADI SINGLE SEPARATED AG FEEDERS HAVING SPECIAL  
PHASIN Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.1372	.3258	.3258	.3086	.3258	.1981
2	.1219	.1219	.3086	.3086	.3086	.3086	.1981
3	.1219	.1219	.3086	.3086	.3086	.3086	.1981
4	.1372	.1372	.2896	.3258	.3086	.3429	.2439
5	.1524	.1524	.3601	.3601	.3429	.3772	.3048
6	.1829	.1829	.4115	.4115	.4287	.3772	.4268
7	.2439	.2591	.3601	.3944	.463	.3944	.7926
8	.1829	.2743	.2915	.3429	.3086	.2915	.8535
9	.2572		.1981	.2743	.4115	.3201	.2058
10	.2229	.2572	.2439	.3353	.5639	.5639	.2229
11	.2058	.2229	.2743	.3963	.5944	.6401	.1886
12	.2058	.1886	.3048	.4877	.6859	.7468	.1543
13	.1372	.1543	.3506	.4877	.7164	.6859	.1372
14	.1886	.1372	.3353		.6859	.5335	.1543
15	.1886	.1543	.3506		.5944	.7164	.1715
16	.2058	.1543	.3353		.5182	.7316	.1886
17	.3086	.3086	.1372		.1372	.1886	.1886
18	.3258	.3258	.1715		.1886	.2229	.2229
19	.3601	.2743	.2229		.2401	.3601	.3772
20	.3429	.2915	.3944		.4458	.4115	.4115
21	.2915	.3258	.3429	.3772	.4115	.3772	.3772
22	.2229	.2572	.3429	.3601	.3772	.3429	.3429
23	.1524	.2058	.3258	.3258	.3429	.1981	.2591
24	.1372	.1524	.3429	.3258	.3086	.3429	.2134
Max	.3601	.3258	.4115	.4877	.7164	.7468	.8535
Min	.1219	.1219	.1372	.2743	.1372	.1886	.1372
Avg	.2091	.2086	.3054	.3616	.4167	.4212	.2930



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214497 / 33 KV UNDAWADI (KP)

Feeder No / Name : 206 / 11 KV JARADWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.061	.0762	.0914	.0686	.0857
2	.0686	.0686	.061	.0762	.0914	.0686	.0686
3	.0686	.0686	.061	.0762	.0914	.0857	.0686
4	.0857	.0857	.0762	.0914	.0914	.1029	.1029
5	.1029	.1029	.1067	.1219	.1067	.1029	.1372
6	.12	.12	.1219	.1524	.1677	.1372	.1715
7	.1543	.1372	.1372	.2439	.2134	.1543	.1715
8	.1372	.1543	.1829	.2896	.2896	.12	.1543
9	.0914	.0914	.0857	.1029	.12	.1677	.1981
10	.1067	.1067	.0857	.0857	.1029	.2286	.2286
11	.0914	.1219	.0686	.0686	.0857	.2286	.2286
12	.061	.1219	.0686	.0686	.0857	.2286	.1829
13	.0762	.0914	.0686	.1029	.0857	.1829	.2134
14	.061	.1067	.0686	.0686	.0857	.1677	.2286
15	.0762	.1067	.0686	.0686	.0857	.1981	.2134
16	.0914	.1219	.0857	.0686	.0686	.2134	.1981
17	.1372	.1372	.0857	.0857	.0857	.0857	.0857
18	.1543	.1372	.1029	.0857	.1029	.12	.12
19	.1543	.1372	.1372	.1029	.1029	.1372	.12
20	.12	.1029	.1543	.12	.12	.12	.12
21	.1029	.1029	.12	.12	.1029	.12	.12
22	.0857	.0857	.1029	.1029	.0857	.1029	.1029
23	.0686	.0762	.0914	.0914	.0857	.0857	.0857
24	.0686	.0686	.061	.0762	.0914	.0857	.0857
Max	.1543	.1543	.1829	.2896	.2896	.2286	.2286
Min	.061	.0686	.061	.0686	.0686	.0686	.0686
Avg	.0980	.1051	.0943	.1061	.1100	.1380	.1455

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049] BU 5860

Substation No/ Name :- 214500 / 33/11 KV MEKHALI

Feeder No / Name : 201 / 11 KV MEKHALI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.4108	.5601	.5144	.5316	.5658	.5487
2	.6348	.4108	.5601	.4973	.5144	.5487	.5144
3	.6722	.4481	.5975	.4801	.5658	.5316	.5487
4	.7095	.4854	.6348	.583	.6687	.6516	.583
5	.7468	.5228	.6722	.679	.6859	.7545	.6173
6	.7842	.5601	.7095	.6859	.7888	.8059	.7202
7	.8402	.5975	.8402	.7202	.7716	.8059	.7888
8	.6722	.6535	.6722	.5658	.6344	.6687	.6173
9	.5601	.5788	.5228	.5144	.5658	.5316	.5487
10	.5228	.5415	.4108	.4801	.4801	.5144	.5601
11	.4854	.4854	.3734	.4458	.4287	.4973	.4668
12	.4294	.4481	.3361	.4115	.4115	.4458	.4481
13	.4108	.3921	.3547	.3601	.3772	.4287	.4108
14	.4294	.4108	.3734	.3601	.3601	.4115	.4108
15	.4854	.4481	.4108	.3944	.3772	.4287	.4294
16	.5601	.4854	.4854	.463	.1372	.4458	.4481
17	.6535	.4668	.5228	.4115	.463	.5144	.5975
18	.7095	.4668	.5601	.5658	.583	.583	.5788
19	.7468	.6722	.5975	.6859	.6687	.6516	.8029
20	.6535	.7095	.6161	.7202	.7716	.6859	.8402
21	.5601	.7468	.6535	.7545	.7202	.7202	.7282
22	.6161	.7282	.6908	.6344	.6859	.7545	.7468
23	.4668	.5975	.6348	.6173	.6516	.6173	.7095
24	.5975	.4108	.5601	.5487	.5658	.6001	.583
Max	.8402	.7468	.8402	.7545	.7888	.8059	.8402
Min	.4108	.3921	.3361	.3601	.1372	.4115	.4108
Avg	.6045	.5282	.5562	.5456	.5587	.5901	.5937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214500 / 33/11 KV MEKHALI

Feeder No / Name : 202 / 11 KV GHADAGEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.8993
Max	.8993
Min	.8993
Avg	.8993

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214500 / 33/11 KV MEKHALI

Feeder No / Name : 203 / 11 KV SONGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3361	1.6804	.1715	.1886	.1886	.4458
2	.3547	.3361	1.6804	.1886	.1715	.2058	.4801
3	.3734	.3734	1.7177	.1715	.2058	.2401	.5144
4	.3921	.4108	1.7551	.2058	.2401	.2743	.5487
5	.4294	.4481	1.7924	.2229	.2572	.3086	.6173
6	.4294	.4854	1.8298	.2572	.2743	.3601	.7202
7	.4294		1.8671	.2743	.2915	.3258	.823
8	.5041	.5228	1.8671	.1886	.2401	.2572	.9945
9	.112	.1867	.168	.5144	.5487	.6859	.1715
10	.112	.1307	.168	.5487	.6516	.8916	.1307
11	.1307	.1307	.1494	.6173	.7202	1.0288	.1307
12	.1307	.1494	.1494	.6173	.7202	.9259	.1307
13	.112	.1307	.1307	.6001	.703	.823	.0934
14	.1307	.112	.1307	.583	.7716	.8916	.0934
15	.1307	.112	.1307	.6001	.823	.9259	.0934
16	.1494	.1307	.1307	.6602	.8059	.9774	.112
17	.168	.1867	.1494	.1715	.1372	.1886	.1494
18	.1867	.1867	.168	.2229	.1715	.2229	.2241
19	.2801	.2241	.1867	.2572	.2058	.2401	.2801
20	.2427	.2427	.2054	.2743	.2743	.2743	.3361
21	.2241	.2427	.2427	.2915	.3086	.3086	.2987
22	.1867	.2614	.2801	.2401	.2572	.2572	.2614
23	.2801	.2987	.2427	.2058	.2229	.3944	.4481
24	.2987	.3361	.3361	.2058	.1886	.2058	.4115
Max	.5041	.5228	1.8671	.6602	.823	1.0288	.9945
Min	.112	.112	.1307	.1715	.1372	.1886	.0934
Avg	.2552	.2598	.7149	.3454	.3908	.4751	.3546

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214500 / 33/11 KV MEKHALI

Feeder No / Name : 204 / 11 KV NIRAWAGAJ GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.1867	.3361	.2401	.3086	.3086	.2743
2	.4108	.1867	.3361	.2401	.2743	.2743	.2572
3	.4481	.2054	.3921	.2572	.3086	.2743	.3086
4	.4854	.2241	.4481	.2743	.3772	.3086	.3772
5	.4854	.2427	.4854	.2915	.4115	.3944	.463
6	.5228	.2801	.5228	.3086	.4801	.4801	.4801
7	.5228	.2987	.4854	.3258	.5144	.5144	.4801
8	.5041	.3547	.4294	.3601	.4115	.3944	.3772
9	.2427	.2801	.2987	.3086	.3086	.3258	.2743
10	.2241	.2614	.1867	.2743	.2572	.2743	.2241
11	.2241	.2241	.2241	.2572	.2229	.2572	.1867
12	.2241	.2241	.2054	.2229	.2058	.2229	.1867
13	.1867	.2241	.2054	.1715	.2058	.2058	.2054
14	.2054	.1494	.2054	.1886	.2058	.2229	.1867
15	.2241	.1867	.2054	.2058	.2229	.2401	.1867
16	.2427	.2054	.2241		.2229	.2401	.2054
17	.2801	.2241	.2427	.2401	.2229	.2401	.2241
18	.3361	.2241	.2614	.3429	.2572	.2743	.2987
19	.4108	.3547	.2987	.463	.2743	.3772	.4108
20	.3734	.3734	.3361	.4801	.3772	.4115	.4294
21	.3734	.3921	.3734	.3944	.4115	.4287	.4108
22	.3361	.3921	.3734	.4115	.3944	.3772	.3921
23	.2801	.3734	.3547	.3772	.3429	.3258	.3734
24	.3361	.1867	.3547	.2401	.3429	.3258	.3086
Max	.5228	.3921	.5228	.4801	.5144	.5144	.4801
Min	.1867	.1494	.1867	.1715	.2058	.2058	.1867
Avg	.3439	.2606	.3244	.2990	.3151	.3208	.3134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214500 / 33/11 KV MEKHALI

Feeder No / Name : 205 / 11 KV ZARGADWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	1.1203	.5601	.2572	.2743	.2915	1.0974
2	.7842	1.1203	.6722	.2572	.2572	.2915	1.2003
3	.8402	1.1576	.8962	.2743	.2743	.3258	1.2689
4	.8962	1.1949	.9335	.2743	.3086	.4115	1.5089
5	.9335	1.2323	1.1576	.2915	.3601	.4287	1.5775
6	.9709	1.2696	1.2696	.3086	.4115	.4973	1.6461
7	1.1016	1.307	1.363	.3772	.4801	.5487	1.7833
8	1.251	1.307	1.587	.3429	.3429	.4287	2.0405
9	.1867	.2054	.2614	1.2346	1.2689	1.6289	.2915
10	.2054	.1867	.2241	1.3032	1.406	1.8176	.2614
11	.2054	.2054	.1867	1.3375	1.6975	2.1776	.2241
12	.1867	.2241	.1867	1.3889	1.8519	2.1948	.2241
13	.1698	.1867	.1867	1.3717	1.8861	2.1948	.1867
14	.1867	.2054	.2054	1.3203	1.7833	2.1262	.1867
15	.1867	.2054	.2054	1.3032	1.6804	2.0919	.1867
16	.1867	.2054	.2054	1.2689	1.4575	2.0233	.1867
17	.2054	.2427	.2241	.1543	.2058	.3086	.2614
18	.1867	.2614	.2427	.2401	.2743	.3944	.2614
19	.1867	.3921	.2801	.3429	.3086	.3772	.4108
20	.1867	.3921	.3361	.3772	.4287	.4115	.4481
21	.2054	.3547	.3547	.3944	.3944	.3429	.3734
22	.1867	.3547	.3734	.3429	.3429	.3086	.3547
23	1.0269	.4108	.3361	.3258	.3258	.8916	1.2136
24	.3734	1.1203	.4481	.2572	.3086	.3086	.9259
Max	1.251	1.307	1.587	1.3889	1.8861	2.1948	2.0405
Min	.1698	.1867	.1867	.1543	.2058	.2915	.1867
Avg	.4816	.6193	.5290	.6394	.7637	.9509	.7550

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214528 / 33/11 KV LONI BHAPKAR SSTN

Feeder No / Name : 201 / 11KV LONI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.2772	.2987	.1966	.2347	.2195	.3547
2	.439	.2587	.2801	.1966	.3018	.2195	.3547
3	.3658	.3109	.2987	.1966	.3018	.2195	.3361
4	.4024	.439	.3174	.2949	.4024	.3292	.4108
5	.4755	.5731	.4481	.3932	.6036	.4656	.5228
6	.5853	.7186	.6348		.6706	.6447	.5975
7	.7499	.6984	.7282	.6718		.8916	.6722
8	.567	.5853	.5788	.5571	.5087	.823	.5788
9	.3224	.4119	.3932	.4024	.3475	.4207	.4287
10	.3045	.3429	.3113	.3658	.3109	.3109	.4748
11		.2883	.2458	.2378	.2561	.3475	.6443
12	.3292	.3052	.2785	.2195	.2743	.2957	.6874
13	.3109	.3391	.3113	.2195	.2507	.2987	.6706
14	.2926	.3391	.3605	.2195	.2218	.2801	.6036
15	.2378	.3521	.3932	.2012	.2402	.2801	.5533
16	.3045	.3258	.3768	.2012	.2686	.2801	.6036
17	.3109		.3174	.2195	.3109	.3361	.3185
18	.3841	.3734	.4294	.2926	.3292	.3921	.4108
19	.5373	.6348	.5415	.567	.5552	.5788	.6348
20	.5373	.6535	.6348	.6219	.6805	.6535	.6535
21	.4755	.5788	.5601	.5487	.6089	.5601	.6722
22	.4024	.4108	.4668	.439	.5304	.5228	.5788
23	.3326	.3361	.2294	.2035	.2561	.4108	.4108
24	.4755	.2926	.2987	.1802	.2012	.2561	.3547
Max	.7499	.7186	.7282	.6718	.6805	.8916	.6874
Min	.2378	.2587	.2294	.1802	.2012	.2195	.3185
Avg	.4166	.4281	.4056	.3324	.3768	.4182	.522

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214528 / 33/11 KV LONI BHAPKAR SSTN

Feeder No / Name : 203 / 11 KV PALSHI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2374	.2402	.2229	.2987	.2561	.2743	.2622
2	.2374	.2402	.2374	.2987	.2561	.2743	.2622
3	.2713	.2772	.2374	.2987	.2561	.2772	.2622
4	.2713	.3326	.2374	.3361	.2926	.3841	.3605
5	.3052	.4024	.2543	.3734	.3658	.5121	.4588
6	.3391	.5121	.2883		.4755	.5731	.5571
7	.39	.4024	.39	.5041	.5853	.4706	.6226
8	.2713	.3841	.39	.2614	.3658	.2743	.5571
9	.2402	.2195	.2614	.373	.3772	.439	.1867
10	.2033	.1867	.1307	.5087	.4458		.1867
11		.1509	.0934	.5426	.1848	.5434	.1494
12	.1663	.132	.0934	.5087		.4938	.112
13	.1478	.1132	.0934	.4239	.2953	.4424	.0934
14	.1494	.1132	.112	.407	.3761	.426	.1132
15	.1307	.132	.1494	.39	.3841	.4096	.1886
16	.1663	.1494	.1307	.3391	.3658	.4588	.132
17	.1663	.112	.1307	.1097	.1109	.1307	.1509
18	.2587	.2614	.2054	.1463	.1478	.2241	.2641
19	.4024	.4481	.3174	.3292	.2561	.5041	.415
20	.4755	.4481	.5041	.4755	.4656	.4668	.4294
21	.3841	.4481	.3768	.439	.4207	.4294	.4294
22	.3142	.3174	.4294	.3658	.3475	.3547	.3734
23	.2402	.2229	.3174	.3292	.2926	.2458	.2035
24	.2035	.2218	.2241	.3174	.2926	.2743	.2622
Max	.4755	.5121	.5041	.5426	.5853	.5731	.6226
Min	.1307	.112	.0934	.1097	.1109	.1307	.0934
Avg	.2596	.2695	.2428	.3642	.3311	.3862	.2930



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214528 / 33/11 KV LONI BHAPKAR SSTN

Feeder No / Name : 204 / 11KV KARHATI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.3511	.3361	.213	.3052	.3841	.3921
2	.1829	.3326	.3547	.213	.373	.3658	.3734
3	.1829	.3881	.3395	.2294	.4409	.3658	.3734
4	.1829	.4435	.3734	.2949	.5426	.4024	.4108
5	.2195	.5853		.3605	.6783	.4887	.4854
6	.2926	.6584	.6722		.78	.5258	.5975
7	.5121	.6036	.6908	.4424	.8817	.823	.6722
8	.4572	.499	.5601	.5571	.8478	.9156	.5788
9	.4119	.394	.3768	.3841	.3841	.4572	.763
10	.4298	.39	.5079	.3292	.3841	.3326	.8139
11		.4191	.3768	.2378	.2957	.2772	.8383
12	.394	.407	.4096	.2378	.2957	.2957	.7712
13	.4477	.407	.426	.2561	.2743	.2801	.9556
14	.3475	.4239	.426	.2561	.3109	.2801	.9054
15	.394	.4359	.4424	.2561	.3109	.2987	.8383
16	.3761	.4668		.2561	.2561	.2987	.8048
17	.3224	.5041	.3174	.2743	.3292	.3361	.2987
18	.3475	.4108	.3921	.3292	.3292	.4108	.3734
19	.5731	.6535		.5487	.6036	.5975	.6348
20	.6268	.6535	.4854	.5121	.6805	.6161	.5975
21	.5487	.5788	.4854	.5121	.5373	.5601	.5601
22	.462	.4668	.4854	.439	.439	.5041	.4854
23	.3881	.3921	.2458	.2374	.3841	.4108	.3734
24	.3292	.3511	.3547	.213	.2374	.4024	.3921
Max	.6268	.6584	.6908	.5571	.8817	.9156	.9556
Min	.1829	.3326	.2458	.213	.2374	.2772	.2987
Avg	.3776	.4673	.4314	.3300	.4542	.4429	.5954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214542 / 33/11 KV BARAV NAGAR

SUBSTATIO

Feeder No / Name : 201 / 11 KV SHIVGIRI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2753	.2515	.2829	.2743	.2926	.3018	.4687
2	.2591	.2347	.2829	.2743	.2743	.3018	.4999
3	.2591	.2347	.3395	.2743	.2926	.3018	.5601
4	.3077	.2374	.3395	.3086	.3292	.3395	.6081
5	.3239	.2713	.3772	.3429	.3841	.3772	.6401
6	.3887	.3467	.4527	.4973	.5121	.4527	.6401
7	.421	.4409	.4527	.4801	.4938	.4904	.703
8	.5182	.502	.3206	.3258	.3841	.3772	.8905
9	.1829	.2054	.4374	.6001	.6154	.7274	.298
10	.132	.1848	.5316	.5506	.7116	.9945	.1829
11	.1132	.1478	.583	.6154	.7655	1.0288	.1829
12	.1663	.1848	.583	.7125	.787	.9602	.1829
13	.1646	.1848	.5658	.6154	.8078	.9088	.1829
14	.1698	.2218	.6173	.6802	.7977	.9431	.1646
15	.1629	.2172	.6173	.6802	.7773	.8592	.1829
16	.181	.1991	.6173	.664	.7727	.8179	.2195
17	.2218	.2172	.1543	.2012	.2279	.2534	.2561
18	.2743	.2534	.2401	.2195	.2012	.3258	.2926
19	.4108	.2829	.3429	.3841	.4108	.4163	.4207
20	.4338	.3584	.4458	.439	.4715	.4706	.4938
21	.3961	.3961	.3772	.4207	.3961	.3982	.439
22	.3206	.3772	.3429	.3658	.3584	.3439	.3475
23	.2572	.3018	.2743	.3292	.3206	.3437	.5344
24	.2753	.2515	.2829	.2743	.2926	.3018	.4374
Max	.5182	.502	.6173	.7125	.8078	1.0288	.8905
Min	.1132	.1478	.1543	.2012	.2012	.2534	.1646
Avg	.2757	.2710	.4109	.4387	.4865	.5432	.4095

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214542 / 33/11 KV BARAV NAGAR

SUBSTATIO

Feeder No / Name : 202 / 11 KV DAM FEEDER( SANGAVI

PANI Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0038	.0152	.0171	.0183	.0038	.0162
2	.0183	.0038	.0152	.0171	.0183	.0038	.0162
3	.0183	.0033	.0152	.0171	.0183	.0038	.0162
4	.0183	.0033	.0152	.0171	.0183	.0035	.0162
5	.0183	.0033	.0305	.0343	.0366	.0254	.0312
6	.0183	.0359	.0617	.0343	.0366	.0486	.0617
7	.0732	.0601	.0617	.0686	.0366	.064	.0617
8	.0732	.068	.0617	.0686	.0732	.0648	.0617
9	.0732	.0617	.0617	.0686	.0732	.0602	.0469
10	.0625	.0617	.0686	.0732	.0513	.0514	.0549
11	.0625	.0617	.0686	.0549	.0507	.0686	.0549
12	.0542	.0463	.0514	.0549	.0617	.0514	.0549
13	.0246	.0463	.0514	.0549	.0601	.0514	.0549
14	.0528	.0463	.0514	.0549	.0616		.0549
15	.0459	.0463	.0514	.0549	.0403	.0463	.0549
16	.0459	.0309	.0514	.0549	.0325	.0463	.0549
17	.0427	.0309	.0343	.0366	.0187	.0305	.0366
18	.0316	.0162	.0343	.0366	.0189	.0312	.0366
19	.0189	.0162	.0171	.0183	.0038	.0162	.0183
20	.0037	.0162	.0171	.0183	.0038	.0162	.0183
21	.0037	.0152	.0171	.0183	.0038	.016	.0183
22	.0037	.0152	.0171	.0183	.0038	.0162	.0183
23	.0038	.0152	.0171	.0183	.0038	.0162	.0183
24	.0183	.0036	.0152	.0171	.0183	.0038	.0162
Max	.0732	.068	.0686	.0732	.0732	.0686	.0617
Min	.0037	.0033	.0152	.0171	.0038	.0035	.0162
Avg	.0335	.0296	.0376	.0386	.0318	.0322	.0372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (R)[049]

BU 5860

Substation No/ Name :- 214542 / 33/11 KV BARAV NAGAR

SUBSTATIO

Feeder No / Name : 203 / 11 KV BHIKOBA NAGAR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.4428	.5281	.3601	.4435	.4527	.8749
2	.503	.4534	.5281	.3601	.4435	.4527	.9374
3	.5197	.4534	.6468	.4115	.462	.4527	.9686
4	.5197	.4915	.7023	.5144	.499	.5281	.9842
5	.57	.5243	.7392	.6001	.6099	.6224	1.0467
6	.6874	.6274	.8131	.7716	.7577	.679	1.0467
7	.8383	.8048	.8131	.7373	.7392	.7356	1.0936
8	.9556	.8962	.6653	.6173	.6468	.6413	1.3904
9	.462	.4527	.7655	1.0631	1.1736	1.3599	.4163
10	.3547	.3881	.8916	1.1233	1.2654	1.7551	.3881
11	.3326	.2772	.9945	1.2574	1.3123	1.7147	.3511
12	.2926	.3326	.9945	1.2742	1.2967	1.7318	.3511
13	.2865	.3326	1.0288	1.0364	1.4198	1.7318	.3326
14	.2587	.3511	1.0288	1.004	1.3889	1.6804	.3326
15	.2926	.3439	.9945	1.0227	1.3889	1.4815	.3326
16	.3326	.362	.9602	1.1065	1.1439	1.4506	.3326
17	.3511	.3982	.3601	.3142	.3511	.3982	.3696
18	.4207	.4525	.3772	.3511	.3801	.5068	.462
19	.5975	.547	.4973	.5729	.5788	.543	.5729
20	.6224	.6224	.6001	.6283	.6036	.6154	.6099
21	.5658	.6413	.5658	.5914	.6036	.5792	.5914
22	.4715	.5658	.5144	.5175	.5658	.5611	.5544
23	.4534	.4904	.4115	.4805	.4904	.6249	.8215
24	.5365	.4586	.4527	.3601	.462	.4527	.8124
<b>Max</b>	<b>.9556</b>	<b>.8962</b>	<b>1.0288</b>	<b>1.2742</b>	<b>1.4198</b>	<b>1.7551</b>	<b>1.3904</b>
<b>Min</b>	<b>.2587</b>	<b>.2772</b>	<b>.3601</b>	<b>.3142</b>	<b>.3511</b>	<b>.3982</b>	<b>.3326</b>
<b>Avg</b>	<b>.4887</b>	<b>.4879</b>	<b>.7031</b>	<b>.7115</b>	<b>.7928</b>	<b>.9063</b>	<b>.6656</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 201 / Paras -MIDC-

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3361	.362	.2667	.2829	.2614	.2829
2	.3206	.3174	.3429	.2667	.2829	.2614	.2829
3	.3206	.3547	.3239	.2667	.2829	.2801	.2641
4	.3395	.3734	.3048	.2858	.3018	.2614	.2641
5	.3395	.4108	.2858	.2858	.3018	.2801	.2452
6	.3584	.3734	.3239	.3048	.3018	.2801	.2452
7	.415	.3361	.3048	.3239	.3206	.2614	.2641
8	.3772	.4108	.3239	.3429	.3772	.2614	.3018
9	.5658	.4668	.3429	.3395	.5281	.3361	.3395
10	.5228	.4763	.3239	.4715	.5228	.415	.4001
11	.6722	.5335	.3239	.5093	.4668	.3772	.4191
12	.5228	.4954	.3429	.5093	.4854	.3961	.4001
13	.5975	.4191	.3429	.3772	.4294	.3395	.381
14	.5601	.5144	.3239	.4527	.4668	.415	.4382
15	.5788	.6287	.3239	.5093	.5041	.3772	.4191
16	.5975	.5716	.3239	.4715	.5228	.4338	.4763
17	.6161	.5144	.3239	.5093	.5415	.415	.4954
18	.5228	.4954	.3429	.5093	.3921	.3772	.4001
19	.4668	.4572	.3429	.4715	.4108	.3772	.3239
20	.4108	.4572	.381	.4904	.3547	.3206	.3239
21	.3734	.4763	.2858	.415	.3361	.3206	.3429
22	.4294	.4572	.2858	.3772	.2987	.3206	.3429
23	.3921	.4001	.2858	.3584	.2801	.3395	.362
24	.3395	.3547	.362	.2858	.3395	.2614	.3206
Max	.6722	.6287	.381	.5093	.5415	.4338	.4954
Min	.3018	.3174	.2858	.2667	.2801	.2614	.2452
Avg	.4559	.4430	.3263	.3917	.3888	.3321	.3473

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 202 / Naka footwear

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8865	.8215	.6097	.5716	.7733	.7842	.7356
2	.8865	.8029	.6668	.5716	.7922	.7655	.7356
3	.8676	.8215	.5716	.5716	.7733	.7655	.7545
4	.8676	.8215	.6097	.6097	.7922	.7655	.7545
5	.8676	.8589	.5335	.6287	.8488	.7468	.7733
6	.8676	.7655	.6668	.6478	.9431	.7468	.7545
7	.9054	.6722	.5716	.6859	.9431	.7468	.7922
8	.9242	.6722	.6097	.724	.9242	.7468	.8676
9	1.0185	.6722	.8192	.7545	1.2449	.8215	.9431
10	1.2696	.724	.8002	.8488	1.4937	.9431	1.0288
11	1.643	1.1622	.7621	.8676	1.7177	1.0751	1.2003
12	1.643	1.3336	.724	1.0185	1.4937	.9808	1.086
13	1.4003	1.0288	.6859	.8488	1.419	.8299	.9907
14	1.2696	.9526	.6668	.8488	1.4937	.9808	1.105
15	1.7924	1.1622	.6478	.8676	1.5684	.9808	1.0479
16	1.5684	1.1431	.6097	1.0374	1.363	.9054	1.4098
17	1.4937	1.1812	.5716	.9431	1.1949	.8299	1.2955
18	1.4003	1.1241	.5335	.9431	.9335	.8299	1.2765
19	1.2323	1.3527		.9054	.8962	.8488	1.2765
20	1.3443	.9907	1.1431	.811	.8402	.8676	1.0669
21	1.0456	.6668	.9907	.811	.8589	.8299	.9526
22	1.0082	.6097	.8764	.7922	.8215	.8299	1.2003
23	.9522	.6097	.724	.7922	.8029	.811	1.1431
24	.9242	.8962	.5716	.6097	.7922	.7842	.7733
<b>Max</b>	<b>1.7924</b>	<b>1.3527</b>	<b>1.1431</b>	<b>1.0374</b>	<b>1.7177</b>	<b>1.0751</b>	<b>1.4098</b>
<b>Min</b>	<b>.8676</b>	<b>.6097</b>	<b>.5335</b>	<b>.5716</b>	<b>.7733</b>	<b>.7468</b>	<b>.7356</b>
<b>Avg</b>	<b>1.1699</b>	<b>.9103</b>	<b>.6942</b>	<b>.7796</b>	<b>1.0719</b>	<b>.8424</b>	<b>.9985</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048]

BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 203 / Ganesh Mandir

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2449	1.0082	1.105	1.105	1.1128	1.0456	1.094
2	1.226	.9709	1.0479	1.1812	1.094	1.0269	1.094
3	1.226	.9522	.9526	1.2193	1.094	1.0082	1.0562
4	1.2826	.9088	1.105	1.3717	1.1128	1.0082	1.0751
5	1.4712	.9709	1.1812	1.5242	1.1317	1.0269	1.1694
6	1.7164	1.587	1.3717	1.7147	1.1883	1.251	1.4712
7	1.8861	1.7177	1.8099	1.7528	1.6598	1.5684	1.8484
8	1.9805	1.7177	1.8099	1.7909	1.8296	1.643	1.7918
9	1.3957	1.3817	1.3527	1.5089	1.5655	1.643	1.4523
10	1.3443	1.3527	1.2955	1.3957	1.419	1.5466	1.4289
11	1.2696	1.2765	1.2193	1.3203	1.3443	1.358	1.3146
12	1.2696	1.2193	1.1812	1.2449	1.419	1.3957	1.3527
13	1.1576	1.1812	1.1431	1.1883	1.2696	1.358	1.2955
14	1.0456	1.105	1.1431	1.2071	1.2696	1.2071	1.2955
15	1.0456	1.086	1.1812	1.1694	1.2696	.415	1.2384
16	1.0829	1.1812	1.2574	1.1694	1.3256	1.4335	1.3146
17	1.1203	1.2765	1.2955	1.3392	1.419	1.5089	1.3336
18	1.6057	1.3336	1.3336	1.4335	1.419	1.5466	1.467
19	1.7551	1.6956	1.7147	1.8861	1.8298	1.905	1.9624
20	1.7924	1.6956	1.7147	1.9239	1.8298	1.8484	2.0005
21	1.5684	1.6575	1.6004	1.6975	1.643	1.6975	1.6194
22	1.419	1.4289	1.4861		1.419	1.5278	1.5623
23	1.2136	1.2574	1.1431	1.3203	1.2136	1.358	1.3717
24	1.2637	1.0829	1.105	1.0479	1.1317	1.0829	1.1317
<b>Max</b>	<b>1.9805</b>	<b>1.7177</b>	<b>1.8099</b>	<b>1.9239</b>	<b>1.8298</b>	<b>1.905</b>	<b>2.0005</b>
<b>Min</b>	<b>1.0456</b>	<b>.9088</b>	<b>.9526</b>	<b>1.0479</b>	<b>1.094</b>	<b>.415</b>	<b>1.0562</b>
<b>Avg</b>	<b>1.3910</b>	<b>1.2935</b>	<b>1.3146</b>	<b>1.4136</b>	<b>1.3754</b>	<b>1.3504</b>	<b>1.4059</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214414 / 33/11 KV MIDC No. I

BARAMATI

Feeder No / Name : 205 / Kalyani Corner

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5415	.4763	.4191	.5847	.5601	.6036
2	.4715	.5415	.4382	.381	.5847	.5601	.6036
3	.4715	.5601	.381	.381	.6036	.5788	.6036
4	.4904	.5788	.4382	.4191	.6036	.5975	.6224
5	.5093	.5788	.4763	.4382	.6036	.5788	.6224
6	.547	.5975	.5335	.4572	.6602	.6161	.6224
7	.6224	.6161	.6287	.4572	.5658	.5975	.6413
8	.9242	1.0456	.9907	.4763	.9054	.6348	.8676
9	.7922	.8962	.9907	.5093	.7922	.5041	.6979
10	.5975	.7621	.9526	.6036	.7468	.5281	.6287
11	.7468	.7811	.8764	.6979	.6908	.547	.7621
12	.7468	.8573	.724	.9431	.8589	.5093	.8764
13	.7468	.6097	.6478	.5281	.7468	.5658	.5716
14	.7468	.8002	.5716	.9431	.9149	.5847	.8764
15	1.0082	.9335	.6097	.9997	1.1203	.5847	1.0288
16	.7282	.6097	.6287	.6979	.7282	.5847	.9145
17	.5228	.5335	.6478	.547	.5228	.4715	.724
18	.5788	.5525	.6668	.5847	.5601	.5658	.6287
19	.5658	.5525	.5716	.5658	.5228	.5658	.6859
20	.4481	.4572	.5335	.415	.5415	.5847	.5144
21	.4854	.4763	.5716	.4715	.6161	.5847	.5716
22	.5041	.4191	.4954	.5093	.5788	.5658	.6287
23	.5415	.4763	.4572	.6224	.5975	.5847	.6668
24	.4904	.5228	.4382	.4191	.6036	.5788	.6224
Max	1.0082	1.0456	.9907	.9997	1.1203	.6348	1.0288
Min	.4481	.4191	.381	.381	.5228	.4715	.5144
Avg	.6157	.6375	.6144	.5619	.6772	.5681	.6911



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214477 / 33/11 kV Textile park

Feeder No / Name : 201 / Geeta textile

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	.1715	.1326	.1334	.1174	.1402	.1227
2	.1227	.1715	.1341	.1334	.1174	.1402	.1227
3	.1227	.1524	.1341	.1334	.1174	.1402	.1227
4	.1227	.1524	.1341	.1334	.1174	.1402	.1227
5	.1227	.1524	.1341	.1334	.1174	.1402	.1227
6	.1402	.1524	.1174	.1334	.1341	.1227	.1402
7	.1402	.1524	.1341	.1524	.1341	.1227	.1227
8	.1402	.1524	.1174	.1524	.1677	.1402	.1402
9	.3944	.1886	.2667	.4382	.3944	.3681	.4031
10	.4801	.1372	.2286	.463	.463	.3772	.4458
11	.583	.2401	.2286	.5144	.463	.3601	.4973
12	.4973	.2743	.2477	.5658	.4458	.3944	.4115
13	.4801	.3086	.1715	.4115	.4115	.2058	.4801
14	.463	.3086	.2667	.6173	.583	.3772	.4801
15	.5487	.2915	.2477	.6344	.6001	.4115	.463
16	.5487	.1715	.2096	.4801	.3772	.463	.463
17	.6859	.3155	.1715	.5316	.5487	.6516	.6173
18	.4572	.156	.2096	.3944	.4557	.4207	.3506
19	.4382	.1357	.1905	.3506	.3506	.3506	.2804
20	.2096	.1341	.1524	.1696	.2103	.1753	.1928
21	.2096	.1341	.1524	.1402	.1928	.1402	.1578
22	.1715	.1341	.1334	.1174	.1578	.1402	.1402
23	.1524	.1341	.1524	.1341	.1402	.1402	.1578
24	.1402	.1715	.1341	.1334	.1341	.1402	.1227
Max	.6859	.3155	.2667	.6344	.6001	.6516	.6173
Min	.1227	.1341	.1174	.1174	.1174	.1227	.1227
Avg	.3123	.1872	.1751	.3001	.2896	.2585	.2783

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214477 / 33/11 kV Textile park

Feeder No / Name : 202 / Dattakrupa Engineering SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1337	.1905	.141	.1524	.1429	.1486	.1337
2	.1337	.1905	.1429	.1524	.1448	.1486	.1337
3	.1337	.1905	.1429	.1524	.1372	.1486	.1337
4	.1337	.1905	.141	.1524	.1391	.1486	.1337
5	.1337	.1905	.1429	.1524	.141	.1486	.1337
6	.1486	.1905	.1486	.1905	.1391	.1635	.1486
7	.1486	.2096	.1429	.2096	.141	.1635	.1486
8	.1486	.2096	.1448	.2096	.1448	.1486	.1635
9	.176	.2201	.1905	.2286	.176	.1486	.1486
10	.2054	.3668	.1905	.2201	.3772	.176	.2641
11	.2347	.3521	.2286	.2347	.3227	.1907	.2787
12	.2347	.3668	.2667	.2641	.2934	.176	.2787
13	.2347	.2641	.2286	.1907	.2347	.1467	.2054
14	.2201	.2934	.1905	.176	.2934	.1467	.2054
15	.2494	.3227	.2286	.1467	.3601	.1614	.2347
16	.2201	.3227	.2477	.132	.3081	.1467	.2201
17	.2286	.2606	.2477	.132	.2201	.176	.176
18	.1905	.1858	.2477	.1635	.1783	.1486	.1635
19	.1715	.1509	.2286	.1429	.1486	.1486	.1635
20	.1905	.1429	.2096	.1429	.1635	.1486	.1486
21	.1905	.1372	.1905	.141	.1635	.1486	.1486
22	.1905	.141	.1715	.1448	.1486	.1486	.1337
23	.1905	.1448	.1715	.1448	.1486	.1337	.1486
24	.1486	.1905	.1429	.1715	.1429	.1486	.1337
Max	.2494	.3668	.2667	.2641	.3772	.1907	.2787
Min	.1337	.1372	.141	.132	.1372	.1337	.1337
Avg	.1829	.2260	.1887	.1728	.2004	.1547	.1742

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 214478 / 33/11 kV MIDC Baramati - II

Feeder No / Name : 201 / Airport

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	1.7147	1.8671	1.3336	1.6194	2.191	2.0957
2	2.2481	1.6004	1.829	1.3717	1.6385	2.21	2.0957
3	2.2481	1.5242	1.7718	1.4098	1.6385	2.0957	2.0576
4	2.191	1.4861	1.7718	1.448	1.6194	2.0957	2.0576
5	2.191	1.4861	1.7147	1.4861	1.6766	2.0195	2.0195
6	2.191	1.448	1.7147	1.5242	1.7147	1.9433	2.0195
7	2.0957	1.448	1.5242	1.6004	1.6766	2.0386	2.1338
8	1.8671	1.4098	1.3527	1.8671	1.8099	2.2291	2.4577
9	2.3624	1.467	1.3908	1.9243	2.1338	2.6673	2.8578
10	2.6673	2.191	1.5242	2.4768	2.4768	2.915	3.0483
11	2.7054	2.2862		2.553	2.6101	2.8959	3.0102
12	2.7054	2.3243		2.2481	2.3815	2.8959	2.934
13	2.7054	2.2862		1.9052	2.191	2.8578	2.572
14	2.6673	2.4768		2.1338	2.7625	2.8578	2.8578
15	2.6292	2.4577		2.2862	2.7244	2.7816	2.934
16	2.6101	2.4577		2.2862	2.8006	2.7054	3.0674
17	2.2862	2.4006		2.2862	2.7244	2.6292	2.8959
18	2.1719	2.4006		2.0005	2.572	2.553	2.5149
19	2.0957	2.1338	1.0288	2.0957	2.2862	2.4387	2.6863
20	1.9814	1.9052	1.0669	1.9624	2.5339	2.2862	2.3624
21	1.9052	1.8671	1.105	1.9052	2.4196	2.2481	2.2862
22	1.9052	1.8671	1.1431	1.829	2.2672	2.21	2.2291
23	1.8671	2.0576	1.2193	1.7147	2.2481	2.1719	2.0957
24	2.2862	1.829	1.8671	1.2765	1.6194	2.0576	2.1338
Max	2.7054	2.4768	1.8671	2.553	2.8006	2.915	3.0674
Min	1.8671	1.4098	1.0288	1.2765	1.6194	1.9433	2.0195
Avg	2.2862	1.9386	1.4932	1.8719	2.1727	2.4164	2.4760

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048]

BU 5851

Substation No/ Name :- 214478 / 33/11 kV MIDC Baramati - II

Feeder No / Name : 202 / Water Supply MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.5716	.4954	.5716	.5716	.4954	.4954
2	.4954	.6097	.4763	.5335	.5716	.5335	.4954
3	.4954	.6097	.4572		.5335	.5335	.5335
4	.5335	.6478	.4572	.4954	.4954	.5144	.4954
5	.5716	.6478	.4763	.5335	.4572	.5525	.4954
6	.6668	.6097	.4954	.5716	.4191	.5716	.5335
7	.7049	.6097	.5144	.6097	.6097	.6287	.6097
8	.6287	.6478	.4763	.6478	.6478	.5906	.743
9	.8383	.6478	.5525	.6859	.9145	.6668	.9335
10	.9526	.9717	.5906	.6668	.9907	.743	1.1241
11	.9907	.9907	.743	.6859	.8573	.7621	.9145
12	.9907	.8383	.7049	.9526	1.0098	.8002	.9717
13	.9907	.9335	.6859	.8573	.7621	.8383	.9335
14	.9526	.9145	.6668	.9335	.8002	.8764	.9526
15	.9145	.8573	.6859	1.0288	.7621	.9145	1.0669
16	.8764	1.0098	.6668	1.105	.7811	.8764	.9335
17	.8383	.9717	.5716	.9335	1.0479	.8764	.9145
18	.8002	1.0098	.4954	.9907	.9526	.9145	.5906
19	.7621	.8383	.5144	.7621	.8383	.8764	.7811
20	.724	.6287	.5335	.6859	.6478	.8192	.6478
21	.6478	.5335	.5335	.6287	.5335	.7621	.5716
22	.6097	.6478	.5335	.6097	.381	.6668	.6668
23	.5716	.6097	.5716	.6097	.5906	.5716	.4954
24	.4763	.5144	.4954	.6097	.5906	.4954	.4763
Max	.9907	1.0098	.743	1.105	1.0479	.9145	1.1241
Min	.4763	.5144	.4572	.4954	.381	.4954	.4763
Avg	.7295	.7446	.5581	.7265	.6986	.7033	.7240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048]

BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 201 / Shriramnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.362	.4191	.4191	.4572	.4572	.4954
2	.381	.362	.3429	.4191	.4191	.4191	.4954
3	.381	.3429	.3429	.4001	.4191	.4001	.4191
4	.381	.362	.4954	.4001	.381	.362	.5335
5	.4382	.4001	.4572	.4382	.4572	.4001	.5716
6	.5525	.5144	.5335	.5525	.5716	.5144	.5906
7	.724	.6859	.6668	.7811	.6859	.5906	.7049
8	.6478	.6478	.6668	.6668	.724	.5716	.6668
9	.5906	.6287	.5906	.6287	.6287	.5716	.6097
10	.5335	.6287	.5716	.6097	.5716	.5525	.5716
11	.5335	.5525	.5716	.6097	.5525	.5525	.6097
12	.5335	.5716	.5525	.5716	.5335	.5525	.5716
13	.5716	.5525	.5525	.5716	.5525	.5525	.6097
14	.5335	.5144	.5335	.5335	.5144	.5144	.5335
15	.4954	.4954	.5335	.5716	.5525	.4954	.5335
16	.4954	.5144	.5335	.5716	.4954	.4572	.6097
17	.5335	.5335	.5335	.6097	.5335	.5144	.6478
18	.5716	.5716	.5716	.6097	.5906	.5525	.6478
19	.7049	.7049	.743	.8002	.743	.6859	.8002
20	.6859	.743	.724	.724	.724	.6859	.724
21	.6097	.6668	.6859	.6478	.6478	.6287	.6859
22	.5716	.6097	.6097	.6097	.6097	.6287	.6478
23	.4572	.5335	.5716	.5335	.5144	.5906	.6097
24	.4191	.4001	.4763	.4572	.4954		
Max	.724	.743	.743	.8002	.743	.6859	.8002
Min	.381	.3429	.3429	.4001	.381	.362	.4191
Avg	.5311	.5374	.5533	.5724	.5573	.5326	.6039

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048]

BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 202 / Desai Estate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6668	.6859	.724	.8002	.7811	.8002
2	.6859	.6478	.6478	.724	.7621	.743	.724
3	.6668	.6478	.6478	.7049	.7621	.743	.6097
4	.6668	.6668	.6097	.7049	.724	.724	.743
5	.724	.6859	.6859	.7621	.8002	.724	.8764
6	.8954	.8383	.8764	.9335	.8764	.8573	.9526
7	1.0098	.9145	.9335	.9907	.9526	.8954	1.0479
8	.9145	.9335	.9145	.8764	.9907	1.0098	.9335
9	.8954	.9145	.8573	.9526	.9145	.9717	.9526
10	.8383	.8573	.8573	.9907	.8764	.9145	.9145
11	.8383	.8002	.8192	.9145	.8573	.8573	.8764
12	.7621	.7621	.7621	.8764	.8192	.8383	.8764
13	.8002	.8002	.7621	.8383	.8573	.8192	.9145
14	.8002	.7621	.743	.8002	.7621	.8002	.8002
15	.724	.743	.7621	.8383	.8383	.7811	.8764
16	.6859	.7621	.7621	.8002	.8192	.8002	.9145
17	.7621	.8192	.8002	.8383	.8573	.8764	.9145
18	.8573	.8383	.7811	.8764	.8573	.8954	.9145
19	1.0479	.9907	1.1431	1.1812	1.1431	1.0479	1.1812
20	1.0098	1.0479	1.105	1.105	1.1241	1.0669	1.1431
21	.9717	1.0098	1.0479	1.0288	1.0288	1.0479	1.105
22	.9145	.9717	.9907	.9907	.9907	1.0098	1.0669
23	.7621	.8954	.8764	.9145	.8954	.9526	.9145
24	.724	.7049	.7621	.7621	.8192	.8192	
Max	1.0479	1.0479	1.1431	1.1812	1.1431	1.0669	1.1812
Min	.6668	.6478	.6097	.7049	.724	.724	.6097
Avg	.8185	.8200	.8264	.8804	.8804	.8740	.9153

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048]

BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 203 / Ashoknagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.362	.4191	.3601	.4191	.4191	.4191
2	.3601	.362	.362	.3601	.381	.4001	.381
3	.3429	.3429	.362	.3429	.381	.381	.3429
4	.3429	.362	.4191	.3429	.381	.4001	.4572
5	.3772	.362	.4572	.3944	.4191	.4382	.4572
6	.4287	.4382	.4954	.4458	.4572	.4572	.4954
7	.5316	.5525	.5525	.4973	.4954	.4954	.5525
8	.5658	.5716	.5716	.4458	.5335	.4763	.5716
9	.5316	.5335	.5906	.463	.5906	.4763	.5525
10	.5716	.5716	.5316	.5716	.6097	.5525	.6478
11	.6097	.6478	.5658	.6859	.5716	.5906	.6859
12	.6859	.6097	.6001	.6478	.5335	.5335	.6859
13	.6859	.6859	.5658	.6478	.6097	.5716	.724
14	.5716	.6097	.5658	.6859	.5716	.5716	.724
15	.5716	.5906	.5487	.6478	.5525	.5525	.6097
16	.6097	.5906	.5316	.6859	.5716	.5525	.7621
17	.6097	.6478	.5658	.724	.5525	.5335	.724
18	.5716	.6097	.583	.6097	.6097	.6287	.6859
19	.7811	.7621	.703	.8383	.8192	.7621	.8764
20	.7621	.743	.6859	.8002	.8002	.8002	.8002
21	.6287	.6859	.6344	.6859	.7049	.6668	.724
22	.5716	.5906	.5316	.6097	.6287	.6097	.6097
23	.4763	.5144	.4458	.5335	.5525	.5716	.5716
24	.3772	.4001	.4572	.3772	.4572	.4954	
Max	.7811	.7621	.703	.8383	.8192	.8002	.8764
Min	.3429	.3429	.362	.3429	.381	.381	.3429
Avg	.5386	.5478	.5311	.5585	.5501	.5390	.6113

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048]

BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 204 / T.C. College

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.8573	.8764	.8573	1.105	1.0288	1.0288
2	.7888	.8383	.8383	.8402	1.0669	.9526	.9145
3	.7716	.8383	.7621	.8402	1.0288	.9717	.8764
4	.7716	.8764	.724	.823	.9907	.9526	1.0669
5	.8573	.9335	.8002	1.046	1.0288	.9526	1.2955
6	1.1317	1.2003	1.0288	1.2003	1.3336	1.2003	1.3336
7	1.3717	1.4861	1.3146	1.3717	1.4861	1.3527	1.4861
8	1.3375	1.3908	1.3908	1.286	1.3717	1.2955	1.467
9	1.2003	1.3336	1.2765	1.2517	1.3527	1.3717	1.3527
10	1.448	1.3146	1.1488	1.4098	1.4289	1.4289	1.4098
11	1.4861	1.3908	1.1145	1.4861	1.3336	1.3908	1.448
12	1.4098	1.2765	1.0802	.1905	1.3908	1.3717	1.4861
13	1.4098	1.2193	1.1831	.2286	1.2765	1.2765	1.4861
14	1.3717	1.2574	1.046	1.5242	1.2574	1.3527	1.448
15	1.3336	1.2574	1.166	1.3717	1.2765	1.2955	1.4098
16	1.2955	1.2765	1.2003	1.448	1.2574	1.2955	1.4861
17	1.3717	1.2193	1.2174	1.5623	1.3527	1.2955	1.5242
18	1.3717	1.3336	1.1488	1.5242	1.5051	1.3908	1.5623
19	1.8099	1.5432	1.5947	1.9052	1.8671	1.6766	2.0195
20	1.6766	1.6004	1.5775	1.9814	1.8099	1.6194	1.8671
21	1.4861	1.4098	1.3889	1.6385	1.5623	1.5432	1.6385
22	1.2193	1.3336	1.3375	1.5242	1.4861	1.5051	.6097
23	.9907	1.1812	1.1317	1.2955	1.2765	1.3717	1.2955
24	.823	.8764	.9526	.8916	1.1431	1.105	
Max	1.8099	1.6004	1.5947	1.9814	1.8671	1.6766	2.0195
Min	.7716	.8383	.724	.1905	.9907	.9526	.6097
Avg	1.2308	1.2185	1.1375	1.2291	1.3328	1.2916	1.3701



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048]

BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 205 / Khandobanagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9907	1.0669	.9945	1.1431	1.1622	1.2193
2	.9088	.9717	1.0288	.9774	1.1431	1.1431	1.0288
3	.8916	.9526	.9145	.9602	1.105	1.105	.9145
4	.8916	.9717	.9717	.9602	1.105	1.1812	1.0669
5	.9945	1.0098	.9145	1.0288	1.105	1.2955	1.2955
6	1.2003	1.2384	.9526	1.2003	1.4098	1.2955	1.448
7	1.4403	1.4861	1.5051	1.4232	1.6004	1.4861	1.6385
8	1.3717	1.5051	1.4098	1.3203	1.5242	1.4289	1.5813
9	1.1831	1.448	1.6004	1.2346	1.448	1.3717	1.3527
10	1.3717	1.3527	1.286	1.4098	1.3527	1.448	1.448
11	1.3336	1.3717	1.2346	1.3717	1.3336	1.5432	1.448
12	1.2955	1.2384	1.1145	1.4098	1.2574	1.4861	1.4098
13	1.2955	1.2574	1.1488	1.3717	1.2955	1.4098	1.448
14	1.2574	1.1812	.7716	1.3336	1.2765	1.3336	1.4098
15	1.2193	1.2955	1.1317	1.3717	1.4098	1.3527	1.448
16	1.2193	1.2955	1.0974	1.4098	1.3908	1.4289	1.4861
17	1.2574	1.3336	1.166	1.448	1.4098	1.448	1.5623
18	1.4289	1.3908	.823	1.4861	1.448	1.4861	1.6766
19	1.6766	1.6575	1.6289	1.9433	1.7909	1.6575	1.9814
20	1.5432	1.6956	1.5432	1.7528	1.7528	1.6575	1.8671
21	1.467	1.5623	1.406	1.6385	1.6004	1.6575	1.7528
22	1.3527	1.467	1.3203	1.6004	1.5242	1.5432	1.7147
23	1.1431	1.2765	1.1831	1.3717	1.2955	1.448	1.5242
24	.9602	1.0098	1.1241	1.0288	1.2003	1.2003	
Max	1.6766	1.6956	1.6289	1.9433	1.7909	1.6575	1.9814
Min	.8916	.9526	.7716	.9602	1.105	1.105	.9145
Avg	1.2346	1.2900	1.1810	1.3353	1.3717	1.3987	1.4662

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048]

BU 5851

Substation No/ Name :- 214506 / 33KV/11 KV Baramati City

Feeder No / Name : 206 / Avchat Estate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9907	1.105	.9602	1.1812	1.2384	1.2193
2	.9088	.9526	1.0669	.9602	1.1431	1.1812	1.1812
3	.8916	.9335	1.0288	.9431	1.1431	1.1431	1.0288
4	.8916	.9717	1.1812	.9431	1.105	1.086	1.2574
5	.9945	.9907	1.2193	.9945	1.1812	1.1622	1.2955
6	1.1317	1.2574	1.2384	1.1488	1.3336	1.2955	1.3336
7	1.3032	1.3527	1.3527	1.3032	1.4861	1.3146	1.4861
8	1.2517	1.3527	1.3527	1.2003	1.3717	.8383	1.3527
9	1.2174	1.3146	1.3717	1.2003	1.3908	1.3336	1.3146
10	1.448	1.5623	1.3717	1.4098	1.6385	1.3527	1.5242
11	1.5623	1.5813	1.3717	1.6004	1.5623	1.4861	1.6004
12	1.6004	1.5432	1.3717	1.7147	1.6004	1.5242	1.7909
13	1.5623	1.5813	1.3889	1.7147	1.5623	1.5051	1.829
14	1.5242	1.5242	1.3032	1.5623	1.5432	1.5051	1.6385
15	1.4861	1.5813	1.3717	1.4861	1.467	1.3527	1.7147
16	1.4861	1.5432	1.3717	1.7147	1.448	1.3527	1.829
17	1.448	1.5813	1.4746	1.7528	1.467	1.4861	1.829
18	1.6004	1.5813	1.4746	1.6385	1.5813	1.5813	1.8671
19	2.0195	2.0195	1.9204	2.2481	2.2862	1.829	2.2862
20	1.9052	2.1719	1.9547	2.21	2.2481	1.9243	2.0957
21	1.6004	1.848	1.6289	1.9052	1.9052	1.848	1.8671
22	1.4289	1.6956	1.4746	1.6385	1.6385	1.6956	1.6385
23	1.1622	1.3527	1.2003	1.4861	1.3908	1.5051	1.4098
24	.9602	1.0288	1.1431	.9945	1.2193	1.3527	
Max	2.0195	2.1719	1.9547	2.2481	2.2862	1.9243	2.2862
Min	.8916	.9335	1.0288	.9431	1.105	.8383	1.0288
Avg	1.3463	1.4297	1.3641	1.4471	1.4956	1.4122	1.5821

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048]

BU 5851

Substation No/ Name :- 217009 / 132/22KV Baramati SS

Feeder No / Name : 304 / 22 KV ANJANGAON AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 217009 / 132/22KV Baramati SS

Feeder No / Name : 307 / 22 KV ANJANGAON GFSS  
Feeder KV- 22 / OUTGOING

GAOTHAN FEEDER

DATE	01-SEP-17
HR	Load (MW)
24	1.9204
Max	1.9204
Min	1.9204
Avg	1.9204

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 218024 / 220 KV BARAMATI

Feeder No / Name : 406 / Spentex  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
15	3.1436
Max	3.1436
Min	3.1436
Avg	3.1436

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 218024 / 220 KV BARAMATI

Feeder No / Name : 407 / SOMA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
15	3.2007
Max	3.2007
Min	3.2007
Avg	3.2007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 218024 / 220 KV BARAMATI

Feeder No / Name : 408 / 33 KV PIAGGIO  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	6.5158
Max	6.5158
Min	6.5158
Avg	6.5158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 218024 / 220 KV BARAMATI

Feeder No / Name : 409 / IMSOFER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	4.5153
Max	4.5153
Min	4.5153
Avg	4.5153



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 218024 / 220 KV BARAMATI

Feeder No / Name : 412 / 33KV G Block Bauli  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
23	.9145
24	.9145
Max	.9145
Min	.9145
Avg	.9145

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 218024 / 220 KV BARAMATI

Feeder No / Name : 702 / BHARAT FORGE  
Feeder KV- 132 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	7.7732
Max	7.7732
Min	7.7732
Avg	7.7732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

BARAMATI (U)[048] BU 5851

Substation No/ Name :- 218024 / 220 KV BARAMATI

Feeder No / Name : 703 / 132KV Dairy Dynamix  
Feeder KV- 132 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	6.6301
Max	6.6301
Min	6.6301
Avg	6.6301

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 212004 / Switching Station Indapur

Feeder No / Name : 202 / 11 KV Kalthan GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 212004 / Switching Station Indapur

Feeder No / Name : 204 / Moremala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	3.8104
Max	3.8104
Min	3.8104
Avg	3.8104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 212004 / Switching Station Indapur

Feeder No / Name : 205 / 11 KV Kandalgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1492	.2896	.1715	.407	.2439	.2572	.2591
2	.1638	.3353	.1543	.373	.2896	.2229	.3048
3	.1943	.3658	.2058	.3768	.3201	.1886	.3658
4		.381	.2572	.4144	.3658	.2229	.3963
5		.4115	.3258	.4458	.3963	.3086	.442
6		.442	.3944	.3887	.4268	.4287	.5639
7		.4268	.463	.4096	.4572	.4973	.4725
8	.1865	.4115	.3944	.4801	.5335	.5144	.4725
9	.1943	.3353	.3429	.431	.442	.5316	.503
10	.3353	.3601	.2743	.407	.442	.4572	
11	.3506	.3258	.3353	.3658	.4268	.4268	
12	.3201	.2915	.3605	.3506	.4801	.3963	.3149
13	.3048	.2572	.4239	.3201	.4287	.3658	
14	.3353	.2401	.373	.3353	.3944	.3201	
15	.3506	.2229	.3887	.3048	.3601	.3048	
16	.3201	.1715	.2949	.2896	.3429	.2743	
17	.3353	.2058	.2591	.3201	.3944	.3353	
18	.3963	.2401	.3772	.3353	.4287	.381	
19	.3658	.2915	.3856	.3048	.4458	.4115	.3932
20	.3353	.3601	.3932	.3658	.4287	.442	.4096
21	.3506	.3258	.4239	.3506	.3944	.3506	.4161
22	.3658	.2572	.426	.3201	.3772	.2743	.4915
23	.3353	.2401	.4096	.2896	.3429	.2591	.4424
24	.1865	.3048	.2229	.4409	.2591	.3086	.2439
Max	.3963	.442	.463	.4801	.5335	.5316	.5639
Min	.1492	.1715	.1543	.2896	.2439	.1886	.2439
Avg	.2938	.3122	.3357	.3678	.3926	.3533	.4057

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 212004 / Switching Station Indapur

Feeder No / Name : 206 / Kalthan Ag

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6401	1.1145	1.9498	.3048	.1543	.3201
2		.6706	1.0117	2.0645	.3353	.12	.3658
3		.6859	.8745	2.0317	.3506	.1886	.3963
4		.7164	.8402	2.2801	.381	.2743	.4115
5		.7468	.9602	2.1956	.3963	.3258	.442
6		.8078	1.0117	1.9433	.4115	.3944	.4877
7		.8383	.9945		.381	.4458	.4572
8		.8688	.9431		.3201	.3944	.442
9		.2591	.2915	1.5729	.9602	1.7318	.4268
10		.3258	.1017	.9555	1.1431	1.5699	.3277
11	.2134	.2915	.1326	.9297	1.2651	1.7223	.3361
12	.2439	.2743	.1457	.9907	1.4575	1.6918	.4144
13	.2591	.2401	.1638	1.0212	1.5604	1.6766	
14	.3201	.1886	.1341	.9907	1.6461	1.6309	.3932
15		.1543	.1134	1.0059	1.4575	1.6461	.431
16		.1715	.0995	.9297	1.5775	1.6004	.3932
17		.12	.1802	.3541	.2572	.2286	.426
18		.1543	.2652	.381	.2915	.2591	.3725
19	.3201	.2572	.3113	.3963	.3429	.2896	.3932
20	.3658	.2915	.3052	.442	.3258	.3201	.4973
21	.3963	.2572	.3222	.381	.3086	.3658	.4641
22	.5639	.2743	.3315	.3353	.2743	.3353	.4961
23	.5792	1.1831	1.6057	.3048	.2401	.3201	1.4091
24		.6097	1.2517	1.587	.2896	.2058	.2743
Max	.5792	1.1831	1.6057	2.2801	1.6461	1.7318	1.4091
Min	.2134	.12	.0995	.3048	.2401	.12	.2743
Avg	.3624	.4595	.5627	1.1383	.6783	.7455	.4512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 201 / Sarate

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.9431	.9431	1.2498	1.3279	1.4575	.9431
2	.8488	.9431	.9431		1.3279	1.4575	.9431
3	.8488	.9431	.9431	1.2498	1.3441	1.4575	.9431
4	1.1317	1.1317			1.4918	1.6194	1.1317
5	1.5089			1.5623	1.6956	1.8442	1.6032
6				1.6766	1.9719	2.1434	
7				2.4006	2.4587	2.6578	
8		1.7147		2.572	2.6825	2.6578	
9	1.6194	1.8204	1.6404	1.5089	1.4146		2.1862
10	1.6804	1.7204		1.1317			2.5101
11	1.5623	1.7004		1.0374			2.4006
12	1.5242	1.7004		.9335			2.4006
13		1.6004		.8402			2.3434
14		1.5023		.8402		1.0374	2.3148
15		1.4661		.8402	1.0269	.9431	2.3148
16	1.3889	1.4661		.9335	1.226	.9431	2.4215
17		1.0269		1.0374	1.226	.6602	.9431
18	1.226	1.226		1.1317		1.6975	1.4146
19	1.6975	1.5089		1.5089		1.7918	1.7918
20	1.5089	1.5089			1.6975	1.6975	1.5089
21	1.3203	1.3203	1.3203	1.5089	1.4146	1.4146	1.3203
22	1.1317	1.1317		1.1317	1.226	1.1317	1.1317
23	.9431	.9431	1.2803	1.3441	1.4575	.9431	.9431
24	.8488	.9431	.9431	1.2803	1.3279	1.4575	.9431
Max	1.6975	1.8204	1.6404	2.572	2.6825	2.6578	2.5101
Min	.8488	.9431	.9431	.8402	1.0269	.6602	.9431
Avg	1.2729	1.3458	1.1448	1.3200	1.5481	1.5270	1.6406



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 202 / Ganeshwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1791	.1753	.7716	.6859	.8916	.1791
2	.1772	.181	.1753		.6859	.8916	.181
3	.1772	.181	.1753	.6687	.6954	.8916	.181
4	.181	.2743	.1753		.7335	.8916	.2829
5	.2801	.2743	.3658	.743	.8916	1.0536	.2829
6	.2801	.3734	.3734	.9374	.9783	1.1431	.2801
7	.3734	.2801	.3734	1.1717	1.3117	1.5023	.3734
8	.3734	.3696	.3734		1.2955	1.5023	.2801
9	1.6604	.9031		.1581	.181	.181	1.247
10	1.6404	1.0669		.1791	.1772	.0829	1.4299
11	1.6204	1.0669		.1772	.1772		1.7747
12	1.5242	1.0669		.1753	.1772		1.8519
13		1.0669		.1715	.1772		1.929
14		.8802		.1715	.1677		1.9814
15		1.0402		.1696	.1677	.1753	1.6204
16	.9288	1.0402		.1677		.1753	1.9814
17	.1391	.1543		.1715	.1658	.1753	.16
18	.1524	.1734		.1715	.1772	.2601	.1619
19	.2686	.1753		.2686	.2715	.3582	.362
20	.2601	.1753			.2715	.3544	.2715
21	.2601	.1677	.2801	.2629	.2715	.3506	.2658
22	.1715	.1658		.1734	.1791	.2601	.1753
23	.1772	.1753	.823	.6954	.8916	.181	.1772
24	.1772	.1791	.1753	.7888	.6859	.8916	.1791
Max	1.6604	1.0669	.823	1.1717	1.3117	1.5023	1.9814
Min	.1391	.1543	.1753	.1581	.1658	.0829	.16
Avg	.5238	.4838	.3151	.4097	.4964	.6107	.7337

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 204 / Bhandgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17
HR	Load (MW)
16	.16
Max	.16
Min	.16
Avg	.16

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 205 / Bhandgaon 2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3944	.3477	
2				.3944	.3477	
3				.3944	.3477	
4				.4734	.3477	
5				.5716	.6687	
6				.743	.7526	
7				.7335	.743	
8				.7335	.743	
9	.4868	.5068				.6259
10	.4001	.5068				.4934
11	.2172	.5068				.423
12	.2763	.5068				.4868
13		.4001				.4801
14		.2477				.4734
15		.2515				.4734
16	.2134	.2515				.4801
17	.2429	.2477	.2382	.3144		.4649
18	.3258	.262	.3934	.4954		.5316
19	.5182	.3801	.5658	.5658		.6478
20	.4334	.3801		.5573		
21	.4001	.3144		.4877		.5744
22	.3144	.3144	.4068	.4201		.4954
23			.3944	.3477		
24					.3477	
Max	.5182	.5068	.5658	.743	.7526	.6478
Min	.2134	.2477	.2382	.3144	.3477	.423
Avg	.3481	.3626	.3997	.5084	.5162	.5116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 206 / Ganeshwadi 2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2601	.2572	.3506	.4572	.4001	.5068	.2572
2	.2601	.2572	.3506		.4001	.5792	.2629
3	.2629	.2572	.3506	.4458	.4058	.5792	.2629
4	.2658	.3544	.3506		.4287	.5792	.2686
5	.3544	.3582	.362	.4458	.5068	.6097	.3582
6	.3582	.3544	.3658	.5468	.5944	.6173	.3658
7	.3658	.362	.3658	.6249	.602	.8002	.2715
8	.3658	.3582	.3658	.5792	.6773	.8002	.2658
9	.6773	.5792		.2315	.2401	.2658	.8802
10	.724	.6097		.2372	.2458	.2572	.9259
11	.6602	.6097		.1543	.2458		1.1069
12	.643	.6097		.1524	.2458		1.0802
13		.6097		.1486	.2458		1.2346
14		.7335		.1505	.2372		1.2346
15		.7907		.1543	.1581	.1619	1.2346
16	.4572	.7907		.16		.2429	1.2193
17	.2058	.1943		.2401	.2343	.3353	.1972
18	.2286	.2315		.3391	.3353	.3353	.2143
19	.3315	.2315		.3467	.3391	.3429	.2429
20	.3125	.2315			.3353	.2458	
21	.3125	.3277	.3658	.3429	.2486	.3277	.2429
22	.3086	.3277		.3277	.2458	.3277	.2458
23	.2543	.3506	.5258	.4115	.5068	.2543	.2486
24	.2601	.2572	.3506	.5258	.4001	.5068	.2572
Max	.724	.7907	.5258	.6249	.6773	.8002	1.2346
Min	.2058	.1943	.3506	.1486	.1581	.1619	.1972
Avg	.3747	.4185	.3731	.3344	.3600	.4338	.5599

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214403 / 33/11KV BAWADA

Feeder No / Name : 207 / Lakhewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8459	.9145	.1753
2		.8459	.9145	.1772
3		.8688	.9145	.1772
4		.9659	.9145	.2686
5		1.0536	1.1336	.3734
6		1.2041	1.326	.4715
7		1.5051	1.5623	.3772
8		1.5051	1.5623	.2801
9		.2715	.1829	1.3032
10		.1791	.1734	1.5051
11		.1791	.1715	1.5051
12		.1791	.1715	1.467
13		.1791	.1696	1.4118
14		.1715	.1677	1.3756
15		.1638	.1677	1.4861
16		.1638	.2486	1.448
17	.1562	.1619	.2401	.1677
18	.2486	.181	.2629	.2601
19	.3582	.2743	.3658	.3658
20		.2743	.362	
21	.2658	.2658	.3582	.2686
22	.1753	.1753	.1734	.1791
23	.8573	.9145	.1772	.1791
24	3.0483	.8459	.9145	.1753
Max	3.0483	1.5051	1.5623	1.5051
Min	.1562	.1619	.1677	.1677
Avg	.7300	.5573	.5646	.6695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214409 / 33 KV PIMPRI BK

Feeder No / Name : 201 / Ganeshwadi Ag Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0762	.0819	.7716	.8383	.9907	
2	.0857	.0762	.0819	.763	.8383	.9907	
3	.0857	.0762	.0819	.7459	.8383	.9907	
4	.0857	.0762	.0819	.7459	.8383	.9907	
5	.0857	.0762	.0819	.7716	.8383	.9907	.0876
6	.0857	.0762	.0819	.7716	.8383	.9907	
7	.0857	.0762	.0819	.8288	1.0059	1.0669	
8	.0857	.0762	.0819	.8573	1.0059	1.0669	.0876
9	1.4918	.7621	.7373	.0914	.0876	.0762	1.4251
10	1.2955	.7621	.8192	.0857	.0762	.0876	1.7147
11	1.2193	.7621	.9012		.0762	.0876	1.8233
12	1.2193	.9012	.9431	.0867	.0762	.0876	1.9433
13		.9012	.9431	.0857	.0762	.0876	1.9433
14	1.0669	.9831	.9431	.0857	.0762		1.989
15		.9012	.9326	.0857	.0762		1.9433
16		.9012	.9431	.0857	.0762	.0876	1.9433
17		.0819	.0914		.0762		
18		.0819		.0876	.0762		
19	.0762	.0819			.0762	.0876	
20		.0819			.0762		
21		.0819			.0762		
22			.0905		.0762	.0876	
23	.0762	.0819	.7716	.9221	.9907	.0876	.0914
24	.0857	.0762	.0819	.7716	.8383	.9907	.0876
Max	1.4918	.9831	.9431	.9221	1.0059	1.0669	1.989
Min	.0762	.0762	.0819	.0857	.0762	.0762	.0876
Avg	.4510	.3501	.4427	.4802	.4145	.5470	1.2566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214409 / 33 KV PIMPRI BK

Feeder No / Name : 202 / Ozare -Pimpri Bk-

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.3658	.5487	1.8861	2.0481	2.0557	
2	.4715	.3163	.5487	1.8861	2.0481	2.0557	
3	.5658	.3658	.5487	1.8233	2.0481	2.0557	
4	.5087	.4525	.543	1.8233	2.0481	2.0557	
5	.5868	.543	.4915	1.95	2.0481	2.0557	.5144
6	.5868	.6268	.543	2.0719	2.2119	2.2138	
7	.5935	.6135	.6335	2.2377	2.5396	2.372	
8	.5087	.543	.724	2.3205	2.4577	2.451	.5935
9	1.8023	1.8004	1.6194	.4572	.4287	.3953	2.6216
10	1.6604	1.8023	1.7814	.0339	.2372	.4287	2.753
11	1.6604	1.8023	1.8842		.2372	.3429	2.8673
12	1.6766	1.7814	2.0576	.2543	.1581	.3429	2.8807
13		2.1052	2.1434	.2543	.1581	.2572	3.0312
14	1.6604	2.13	2.0243	.2543	.1581		2.9959
15		1.9662	2.0243	.2543	.1581		2.9607
16		1.9433	2.0481	.2543	.2372	.3429	2.8902
17		.4858	.3658		.3953		
18		.4915		.5144	.5535		
19	.4744	.4858			.5535	.5144	
20		.4858			.5535		
21		.4858			.4744		
22		.4858	.4525		.3953	.5144	
23	.3163	.5487	1.8023	1.9662	2.0557	.3429	.362
24	.3429	.362	.5487	1.8861	2.0481	2.0557	.3429
Max	1.8023	2.13	2.1434	2.3205	2.5396	2.451	3.0312
Min	.3163	.3163	.3658	.0339	.1581	.2572	.3429
Avg	.8597	.9579	1.1667	1.2293	1.0938	1.2696	2.0678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214409 / 33 KV PIMPRI BK

Feeder No / Name : 203 / LIS -Shriram Lift-

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.0886	.0819	.0629		.0886	
2	.4191	.0886	.0819			.0886	
3	.4191	.0886	.0819	.0914		.0886	
4	.4191	.0886	.0819			.0886	
5	.4191	.0886	.0819	.0924	.0857	.0886	.5144
6	.4191	.0886	.0819	.0914		.0886	
7	.4191	.0886			.0857	.0886	
8	.4191	.0886	.0819	.0914	.0857	.0886	.5144
9	.0857	.0886		.0914	.2572	.3544	
10	.0886	.0886	.0819	.2543	.0886	.4287	
11	.0886	.0886	.0914		.3544	.5144	
12	.0886	.0819		.2543	.0886	.5144	.0905
13		.0819		.2543	.3544	.5087	
14	.0886	.0819		.2543	.443		
15		.0819		.2543	.443		
16		.0819	.0914	.2543	.4287	.5144	.0905
17		.0819			.0886		
18		.0819		.0876	.0886		
19	.0886				.0886	.0876	
20		.0819			.0886		
21		.0819			.0886		
22		.0819	.0914		.0886	.0876	
23	.0886	.0819	.0914	.0857	.0886	.5144	.5144
24	.4191	.0886	.0819	.0914	.1029	.0886	.5144
Max	.4191	.0886	.0914	.2543	.443	.5144	.5144
Min	.0857	.0819	.0819	.0629	.0857	.0876	.0905
Avg	.2743	.0854	.0848	.1541	.1810	.2401	.3731



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214409 / 33 KV PIMPRI BK

Feeder No / Name : 204 / Girvi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.4915	.6554	.2715	.3391	.3277	
2	.6706	.4915	.6554	.2743	.3391	.3277	
3	.6706	.4915	.6554	.2715	.4239	.3277	
4	.6706	.4915	.6554	.362	.5087	.4915	
5	.6706	.4915	.6554	.5487	.5935	.5735	1.2574
6	.7545	.5735	.6554	.8145	.6001	.7373	
7	.8288	.7373	.6554	.724	.7716	.6554	
8	.8288	.8192	.7373	.5487	.6859	.5735	1.6766
9	.6001	.5735	.4096	.9431	1.4251	1.6385	.5144
10	.4096	.4915	.2572	1.1603	1.4746	1.7404	.3658
11	.3277	.4915	.1829		1.6385	1.2574	.181
12	.2458	.4915	.1829	1.2574	1.6385	1.6766	
13		.4915	.1829	1.2574	1.6385	1.6766	
14	.2458	.4915	.1715	1.2574	1.5565		.1829
15		.4915	.1715	1.2574	1.5565		.1829
16		.4915	.1829	1.3413	1.4746	1.6766	.1829
17		.4096	.2743		.3277		
18		.4915		.5144	.4096		
19	.5735	.4915			.4096	.6001	
20		.4915			.4096		
21		.4915			.3277		
22		.4915	.362		.3277	.3429	
23	.4915	.7373	.2715	.3429	.3277	1.1736	1.2003
24	.6706	.4915	.6554	.2715	.3772	.3277	1.1736
Max	.8288	.8192	.7373	1.3413	1.6385	1.7404	1.6766
Min	.2458	.4096	.1715	.2715	.3277	.3277	.181
Avg	.5831	.5291	.4315	.7455	.8159	.8958	.6918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON

Feeder No / Name : 201 / Bhat Nimgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.1619				.2286
2	.6859	.1619				.2286
3	.6859	.1619				.3239
4	.6859	.1619				.3239
5	.6859	.1619				.2429
6	.6859	.1619				.2429
7	.6859	.1715				.2286
8	.7716					.2286
9			.081		.2429	
10					.2286	
11				.081	.2286	
12				.1619	.2286	
13				.1619	.2286	
14					.3048	
15				.1619	.3048	
16				.1619	.2286	
17				.1715		
18				.2429		
23	.1619				.2286	.6783
24	.6859	.1619				.2286
Max	.7716	.1715	.081	.2429	.3048	.6783
Min	.1619	.1619	.081	.081	.2286	.2286
Avg	.6421	.1631	.081	.1633	.2471	.2955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON

Feeder No / Name : 202 / Babhulgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2429	.5087	.8907	.9145	1.1336	.3048
2	.2429	.3239	.5087	.9717	.9145	1.1336	.4572
3	.2572	.4049	.5087	.9717	.9145	1.2955	.4572
4	.2429	.4858	.5087	.9717	.9145	1.4575	.5668
5	.4049	.5668	.5087	.9717	1.0669	1.6194	.5668
6	.4287	.6478	.5087	1.0526	1.448	1.7004	.5335
7	.5668	.6478	.5087	1.2193	1.9814	.8097	.4572
8	.4858	.5668	.5087	1.7814	2.0576	.7287	.4572
9	1.2146	1.1336	1.1869	.3277	.3239	.3239	.6097
10	1.286	1.3565	1.1336	.3429	.2429	.3048	.8478
11	1.2955	1.3565	1.1336	.3429	.2429	.3048	1.6956
12	1.2955	1.3565	1.2146	.3429	.2429	.2286	1.6956
13	1.1336		1.2146	.2572	.2429	.3048	
14	1.0288		1.1469	.1715	.2429	.2286	
15	.8907		1.0526	.1715	.2429	.3239	1.6956
16	.8097	1.1869	1.0526	.1715	.2429	.3048	1.6956
17	.2429		.2429		.2429	.2286	
18	.2429	.1696	.3239	.1715	.2429	.2286	
19	.2429	.1696	.3239	.2572	.3239	.3048	
20	.2429		.3239	.4287	.3239	.3048	
21	.2429		.2429	.3429	.3239	.3239	
22	.2429		.2429	.2572	.2429	.3048	.3391
23	.2429	.3391	.8907	.8383	1.0526	.3239	.3391
24	.2429	.2429	.5087	.8907	.9145	1.1336	.3048
Max	1.2955	1.3565	1.2146	1.7814	2.0576	1.7004	1.6956
Min	.2429	.1696	.2429	.1715	.2429	.2286	.3048
Avg	.5743	.6587	.6794	.6150	.6627	.6398	.7661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON

Feeder No / Name : 203 / Rakhundemala AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1619	.1696	.081	.0857	.081	.3048
2	.1524	.1619	.1696	.081	.0857	.081	.381
3	.1715	.1619	.1696	.081	.0857	.081	.381
4	.1715	.1619	.1696	.0819	.0857	.081	.3239
5	.2286	.1715	.1696	.0819	.0857	.081	.3048
6	.2286	.2429	.1696	.0838	.0857	.081	.3239
7	.2572	.2429	.1696	.081	.0857	.081	.4572
8	.3048	.2429	.1696	.081	.0857	.081	.3239
9	.0857	.081	.0848	.3239	.4287	.4049	.0762
10	.0857	.0848	.0819	.3048	.4049	.381	.0848
11	.0857	.0848	.081	.3048	.4049	.4572	.0848
12	.0857	.0848	.081	.3048	.3239	.381	.0848
13	.0762		.081	.3048	.3239	.4572	
14	.0762		.081	.3048	.3239	.381	
15	.0762		.081	.3048	.3239	.3048	.0848
16	.0762	.0848	.081	.3048	.3239	.3048	.0848
17	.081		.081	.0857	.081	.0762	
18	.081	.0848	.081	.0857	.081	.0762	
19	.081	.0848	.081	.0857	.081	.0762	
20	.081		.081	.0857	.081	.0762	
21	.081		.081	.0857	.081	.0762	
22	.081		.081	.0857	.081	.081	.0848
23	.1619	.1696	.081	.0857	.081	.4049	.3391
24	.1715	.1715	.1696	.081	.0857	.081	.4049
Max	.3048	.2429	.1696	.3239	.4287	.4572	.4572
Min	.0762	.081	.081	.081	.081	.0762	.0762
Avg	.1306	.1458	.1144	.1580	.1748	.1945	.2429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON

Feeder No / Name : 204 / Chandrabhaga AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0162	.0848	.081	.0857	.081	.2286
2	.0857	.081	.0848	.081	.0857	.081	.3048
3	.0857	.081	.0848	.081	.0857	.081	.3239
4	.0857	.0857	.0848	.081	.0857	.081	.4049
5	.0857	.081	.0848	.081	.0857	.081	.381
6	.1715	.081	.0848	.081	.0857	.081	.381
7	.1715	.081	.0848	.081	.0857	.081	.4858
8	.1715	.081	.0848	.081	.0857	.081	.381
9	.0857	.0762	.0848	.1619	.2429	.2429	.0762
10	.0857	.0848	.081	.1524	.2429	.381	.0848
11	.0857	.0848	.081	.1524	.2429	.381	.0848
12	.0857	.0848	.081	.1524	.2429	.3048	.0848
13	.0857		.081	.1524	.2429	.3048	
14	.0857		.081	.1524	.2429	.3048	
15	.0857		.081	.1524	.2429	.381	.0848
16	.0857	.0848	.081		.3239	.381	.0848
17	.081		.081	.0857	.081		
18	.081	.0848	.081	.0857	.081	.1524	
19	.081	.0848	.081	.0857	.081	.1524	
20	.081		.081	.0857	.081	.0762	
21	.081		.081	.0857	.081	.081	
22	.081		.081	.0857	.081		.0848
23	.081	.0848	.081	.0857	.081		.5087
24	.0857	.081	.0848	.081	.0857	.0762	.2286
Max	.1715	.0857	.0848	.1619	.3239	.381	.5087
Min	.081	.0162	.081	.081	.081	.0762	.0762
Avg	.0951	.0787	.0826	.1046	.1401	.1842	.2478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214410 / 33/11KV BHATNIMGAON

Feeder No / Name : 205 / Bhatnimgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.0343
Max	.0343
Min	.0343
Avg	.0343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214426 / 33/11KV KATI S/STN

Feeder No / Name : 201 / kati

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7293	.6464	.4973	.5304	.547	.5304	1.0159
2	.7293	.6464	.4973	.5304	.547	.5304	1.004
3	.779	.6464	.5801	.5801	.547	.5801	1.0486
4	.8288	.7459	.7459	.663	.663	.663	1.0883
5	.9779	.8453	.8619	.9116	.9282	.8122	1.1336
6	1.2266	1.1105	1.0442	1.1603	1.1603	1.094	2.2939
7	1.5083	1.5746	1.2266	1.1603	1.21	1.1768	2.6216
8	1.6078	1.8399	1.2266	1.0774	1.1105	1.0277	2.9492
9	.7865	.7459	1.5893	1.7204	2.1792	2.1862	.7545
10	.5079	.6796	1.6804	1.8138	2.2283	2.5587	.6036
11	.4915	.6299	1.6549	1.6712	2.1956	2.4615	.5197
12	.3768	.547	1.6385	1.8515	2.1605	2.4615	.4862
13			1.4419	2.0485	2.4291	2.3967	.503
14	.4915		1.4746	2.0119	2.4249	2.1538	.4862
15	.3856		1.6385	1.9662	2.4291	2.3644	.4694
16		.547	1.5402	1.9826	2.2939	2.3805	.5365
17	.5365		.567	.503	.6036	.5868	.6036
18	.5868		.6767	.7209	.7865	.8048	.7545
19	.8886		1.0059	1.0562	1.0974	.8551	1.0242
20	.8718		.9145	.9389	.9877	.788	.9511
21	.6539		.7682	.7042	.8048	.6706	.9145
22	.6203		.6516	.6539	.7095	.5868	.7468
23			.5853	.57	.547	1.0202	1.3108
24	.7293	.6371	.4973	.5853	.57	.5304	1.004
Max	1.6078	1.8399	1.6804	2.0485	2.4291	2.5587	2.9492
Min	.3768	.547	.4973	.503	.547	.5304	.4694
Avg	.7769	.8459	1.0419	1.1422	1.2983	1.3009	1.0343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214426 / 33/11KV KATI S/STN

Feeder No / Name : 202 / Reda

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.2984	.5801	.6962	.7956	.8619	.2926
2	.2652	.2984	.5801	.6962	.7956	.8619	.2926
3	.2652	.2984	.663	.7459	.7956	.9116	.2801
4	.3315	.3978	.779	.8288	.9116	1.0277	.3292
5	.4641	.4973	.9282	1.094	1.1603	1.2266	.3734
6	.663	.7625	1.0442	1.4255	1.3592	1.4918	.5228
7	.7459	.7625	1.5415	1.873	2.1382	2.1051	.8048
8	.6133	.6796	1.7238	1.8399	2.2708		.6584
9	1.0322	1.1768	.5853	.4572	.5487	.4862	1.4899
10	1.0486	1.1603	.3658	.3658	.3658	.3688	1.5061
11	1.0322	1.2929	.2561	.2195	.2658		1.7814
12	.9667	1.2597	.2378	.1829	.1991	.2347	1.7004
13	.9503		.2012	.1638	.1867	.218	1.7166
14		.9448	.2195	.1867	.1867	.218	1.5927
15	.4858		.2378	.2012	.1646	.2515	1.5061
16	.6874	1.094	.1829	.2378	.2195	.2683	1.6356
17			.3109	.2683	.3109	.4191	.2515
18	.3688		.4207	.3688	.4572	.4191	.3353
19	.57		.5853	.57	.5788	.4694	.6036
20	.5533		.5487	.5197	.4755	.4359	.5487
21	.3856		.4755	.4024	.439	.3688	.3658
22	.3521		.3658	.3521	.3841	.3353	.3475
23			.7045	.7611	.8619	.3185	.3109
24	.2652	.3018	.5801	.6882	.7935	.8619	.3185
Max	1.0486	1.2929	1.7238	1.873	2.2708	2.1051	1.7814
Min	.2652	.2984	.1829	.1638	.1646	.218	.2515
Avg	.5863	.7483	.5882	.6310	.6944	.6436	.8152



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214426 / 33/11KV KATI S/STN

Feeder No / Name : 203 / Shetphal Haveli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4321	.4268	.2751	.3102	.3185	.3521	.7042
2	.4321	.4268	.286	.3102	.3185	.3521	.6554
3	.463	.4572	.286	.3525	.3185	.4572	.6554
4	.5668	.5312	.4268	.4287	.4344	.6249	.7935
5	.6859	.5992	.6097	.6097	.6097	.7125	1.0883
6	.8779	.6706	.7293	.7956	.6554	.8619	1.749
7	.9922	1.0517	.8048	.852	1.0486	.8619	1.7924
8	1.1934	1.3413	.6706	.6478	.7209	.7682	1.8084
9	.5898	.4999	.9922	1.3535	1.3123	1.4575	.5312
10	.426	.5121	1.2616	1.491	1.6964	1.7004	.3334
11	.4096	.3637	1.4632	1.5074	1.6842	1.7394	.2896
12	.3605	.4012		1.4413	1.6644	1.7236	.282
13	.3277	.3549	1.2163	1.3108	1.6004	1.7236	.2743
14			1.1523	1.2003	1.5061	1.5708	
15	.2858		1.1984	1.2944	1.4746	1.4864	
16	.2401		1.2125	1.2955	1.5729	1.5655	.3467
17	.2858		.2	.2515	.2221	.3702	.3868
18	.3315		.2972	.3591	.4668	.543	.4405
19	.423		.503	.6308	.5335	.6171	.5487
20	.4793		.6584	.5796	.4801	.5144	.5868
21	.3734		.4481	.4134	.4694	.4287	.439
22	.2972		.3909	.3734	.4115	.4001	.3734
23			.285	.3201	.362	.7274	.7655
24	.4321	.4428	.2751	.3102	.3067	.3521	.7116
Max	1.1934	1.3413	1.4632	1.5074	1.6964	1.7394	1.8084
Min	.2401	.3549	.2	.2515	.2221	.3521	.2743
Avg	.4957	.5771	.6801	.7683	.8412	.9130	.7071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214426 / 33/11KV KATI S/STN

Feeder No / Name : 204 / 11 kv Pandharwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.2353	.3429	.4096	.4915	.4475	.2195
2	.1991	.2353	.3429	.4096	.4915	.4475	.2241
3	.2715	.2353	.3429	.4096	.4915	.5304	.1829
4	.3582	.3258	.5083	.4807	.6516	.6859	.2241
5	.4382	.4525	.5792	.5506	.7712	.7888	.3658
6	.5609	.5316	.7167	.7468	.9511	.9492	.4854
7	.5609	.5493	.8413	.9877	1.1218	1.3643	.5853
8	.3637	.3898	.9362	1.1831	1.0923	1.3546	.4572
9	.5735	.7127	.2926	.2743	.2561		.9831
10	.7045	.7122	.2195	.2195	.2561	.2743	1.1142
11	.6882	.7293	.2012	.2012	.1867	.2195	1.0425
12	.639	.6962	.2195	.128	.1829	.2012	1.2616
13	.6062	.6327	.2012	.1646	.1829	.2054	1.2616
14		.6401	.1829	.1829	.1829	.1867	1.1633
15			.1638	.1829	.1463	.2054	1.2289
16	.5304	.583	.1829	.2012	.1646	.2452	1.1683
17	.2452		.2012	.2829	.2195	.3206	.2641
18	.2452		.2743	.2829	.2926	.3395	.2987
19	.3841		.4108	.3326	.3658	.3584	.4207
20	.3292		.3658	.4024	.3658	.3475	.3658
21	.3174		.3292	.3658	.2926	.3109	.3475
22	.2614		.2926	.3174	.2561	.2743	.3109
23			.4096	.4862	.4424	.2241	.2561
24	.1991	.2378	.3429	.4144	.4807	.4475	.2241
Max	.7045	.7293	.9362	1.1831	1.1218	1.3643	1.2616
Min	.1991	.2353	.1638	.128	.1463	.1867	.1829
Avg	.4131	.4937	.3709	.4007	.4307	.4665	.6023

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN

Feeder No / Name : 201 / Loni

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.4801	.4801	.5258	.5138	.463	.9431
2	.6443	.4973	.4973	.5144	.4908	.4458	.9602
3	.6874	.5144	.5144	.6135	.6219	.4801	.9602
4	.78	.5487	.5975	.7011	.6805	.583	1.0288
5	.8619	.6687	.7716	.8764	.7964	.7716	1.153
6	.9496	.9259	.8573	1.0288	.9568	1.0288	1.3748
7	1.0059	1.0288	1.1488	1.1145	1.0387	1.046	1.7772
8	.9831	1.0974	1.0631	.8764	.8596	.9945	1.8652
9	.8453			1.0974	1.2517	1.3765	.8139
10	.6443	.9335	.695	1.0364	1.3717	1.5074	.6859
11		.7716	.5194	.9945	1.2003	1.4746	.6859
12		.6001	.4835	.9496	1.3032	1.6057	.6859
13	.5487		.5258	.9054	1.3203	1.6118	
14	.5144	.6001	.5487	.8785	1.3375	1.6804	.6001
15	.4458	.5144	.5853	.9214	1.3717	1.7436	.6001
16		.5601			1.3717	1.56	.6859
17	.6173	.6001		.9054	.5487	.6036	.7202
18	.6859	.7716	.8413	.8322	.7202	.8145	.8573
19	.7888	.7716	1.0242	.8764	.8573	.8817	.9602
20	.7716	.6859	.9114	.8682	.8916	.8573	.8573
21	.6516	.6001	.7888	.7796	.7202	.7122	.7716
22	.583	.6001	.6859	.591	.6173	.6001	.6344
23	.5144	.4801	.5853	.5249	.5144	.9431	1.1145
24	.631	.4973	.4801	.5144	.4835	.4801	.9431
Max	1.0059	1.0974	1.1488	1.1145	1.3717	1.7436	1.8652
Min	.4458	.4801	.4801	.5144	.4835	.4458	.6001
Avg	.7067	.6704	.6955	.8229	.9100	1.0111	.9426

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN

Feeder No / Name : 202 / Varkute

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.2401	.2401	.3521	.4908	.583	.2401
2	.2715	.2572	.2401	.3521	.4801	.6001	.2401
3	.2896	.2572	.2721	.3521	.5087	.6173	.2561
4	.3224	.2915	.2721	.3841	.6036	.6344	.2881
5	.4298	.3601	.4001	.4001	.8505	.6859	.3681
6	.4784	.5144	.5121	.4641	.9259	.9602	.4801
7	.5373	.5144	.5281	.7522	.9389	1.3032	.5761
8	.4607	.5144	.4641	.8162	1.1163	1.406	.4801
9	.788	.4973	.5601	.3681	.3721	.3681	1.4083
10	.6979	.4801	.5281	.2507	.12	.2721	1.6004
11	.5487	.4801	.5441	.2126	.2401	.2241	1.6004
12	.5144	.4801	.5281	.1772	.2229	.176	1.6004
13	.4287	.4161	.5281	.197	.2229	.176	1.6004
14	.3944	.4001	.5281	.181	.2229	.176	1.6004
15	.3601	.4481	.4481	.1772	.2401	.192	1.6004
16	.3772	.4001	.4161	.1791	.2401	.192	1.6004
17	.2058	.2721	.208	.2172	.3086	.2401	.3201
18	.2915	.3201	.2241	.394	.3429	.3201	.4001
19	.4287	.4001	.3201	.4835	.4458	.4001	.4801
20	.4115	.3201	.3841	.4706	.4115	.4161	.4001
21	.3429	.3201	.3521	.3224	.3429	.3521	.3521
22	.2915	.2721	.2721	.2658	.2915	.2721	.3201
23	.2572	.2241	.3201	.463	.6344	.2401	.2401
24	.2507	.2401	.2401	.3361	.4458	.6001	.2401
Max	.788	.5144	.5601	.8162	1.1163	1.406	1.6004
Min	.2058	.2241	.208	.1772	.12	.176	.2401
Avg	.4017	.3717	.3888	.3570	.4591	.4753	.7622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN

Feeder No / Name : 203 / AGOTI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.3258	.3429	.7545	1.0004	1.0117	.3086
2	.3856	.3258	.4287	.7545	.9503	.9945	.3086
3	.4207	.3429	.4287	.7545	1.0852	1.0288	.3429
4	.4525	.4115	.463	.7716	1.2597	1.0631	.3772
5	.5028	.5144	.6001	.7888	1.3603	1.1317	.463
6	.6173	.6516	.6859	.823	1.6057	1.5089	.5144
7	.7796	.6516	.6001	1.2517	1.6194	1.9547	.5487
8	.6154	.6687	.6344	1.5089	2.0119	2.1948	.5144
9	1.1603	.9602	1.0288	.5144	.4656	.4801	
10	.9724	.8573	1.0631	.362	.3601	.4115	2.4863
11	.8916	.8573	1.1145	.3224	.3086	.3429	2.572
12	.7888	.9431	1.1888	.2865	.2743	.3429	2.6578
13	.7888	.823	1.0631	.2865	.2743	.3429	2.572
14	.7716	.7716	1.0802	.2481	.2915	.3429	2.4863
15	.7545	.7716	1.0974	.2658	.3429	.3772	2.4006
16	.7545	.7716	1.0631	.2507	.3772	.2743	2.3148
17	.3086	.3086	.2743	.3012	.4458	.3258	.3429
18	.2743	.3429	.3772	.2865	.4801		.5144
19	.5487	.4287	.3086		.5487	.3772	.6859
20	.5144	.4287	.583	.5847	.583	.583	.6001
21	.463	.4287	.5144	.5316	.4801	.3429	.5144
22	.3944	.4287	.4287	.4557	.4115	.3429	.4801
23	.3772	.3429	.7373	.9259	1.046	.3429	.4287
24	.3721	.3429	.3429	.7373	.9496	1.0288	.3429
<b>Max</b>	<b>1.1603</b>	<b>.9602</b>	<b>1.1888</b>	<b>1.5089</b>	<b>2.0119</b>	<b>2.1948</b>	<b>2.6578</b>
<b>Min</b>	<b>.2743</b>	<b>.3086</b>	<b>.2743</b>	<b>.2481</b>	<b>.2743</b>	<b>.2743</b>	<b>.3086</b>
<b>Avg</b>	<b>.5943</b>	<b>.5708</b>	<b>.6854</b>	<b>.5986</b>	<b>.7722</b>	<b>.7455</b>	<b>1.0773</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN

Feeder No / Name : 205 / Chandgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.1372	.0686	.0732	.0716	.0857	.4115
2	.3189	.12	.0686	.0732	.0709	.0857	.4115
3	.3467	.1372	.0686	.0732	.0895	.0857	.4207
4	.3856	.1372	.0686	.0732	.1086	.0857	.4298
5	.4119	.1543	.1372	.0914	.124	.1029	.4115
6	.4115	.1886	.1372	.1097	.1267	.1372	.4572
7	.407	.1886	.1715	.128	.1448	.1372	.5087
8	.3086	.2058	.1372	.1097	.1052	.12	.5487
9	.1075	.0857	.0686	.2058	.2743	.4755	
10	.1075	.0686	.0549	.2126	.3086	.5609	.2058
11	.0857	.0686	.0549	.2534	.3429	.6024	.2058
12	.0857	.0686	.0716	.2865	.3429	.6468	.1715
13	.0857	.0747	.0732	.2947	.3429	.6001	.2058
14	.0686	.0686	.0732	.3155	.3429	.583	.2572
15	.0686	.0686	.0732	.2915	.3772	.6443	.2572
16	.0857	.0686	.0732	.3052	.4115	.6371	.2572
17	.0857	.0747	.0732	.1086	.12	.168	.2572
18	.1029	.0343	.0914	.1063	.12	.1867	.2572
19	.0857	.0343	.128	.1254	.1372	.168	.2572
20	.0857	.0343	.1075	.1075	.1372	.1829	.2058
21	.0857	.0343	.1097	.0886	.12	.1829	.2058
22	.0857	.0343	.1097	.0895	.1029	.1829	.1715
23	.1372	.0686	.0732	.0716	.0857	.4115	.4115
24	.3366	.1372	.0686	.0701	.0693	.0857	.4115
Max	.4119	.2058	.1715	.3155	.4115	.6468	.5487
Min	.0686	.0343	.0549	.0701	.0693	.0857	.1715
Avg	.1919	.0955	.0901	.1527	.1865	.2983	.3190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214427 / 33/11 KV LONI(D) S/STN

Feeder No / Name : 402 / 33KV Ananad Techno

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.3601	.3395	.3292	.3801	.3601	.3361
2	.3761	.3601	.3395	.3292	.3258	.3086	.3361
3	.3761	.4115	.3395	.3326	.3189	.3601	.3881
4	.3258	.3601	.3395	.3841	.3801	.4115	.3921
5	.3721	.4115	.1132	.3292	.3801	.4115	.3841
6	.4252	.4115	.1132	.3841	.4298	.4115	.3292
7	.4344	.4115		.3292	.4344	.4115	.3292
8	.3761	.4115	.1132	.3292	.4207	.4115	.3292
9	.3761	.4115	.3395	.3292	.4344	.439	.3841
10	.4344	.4527	.3841	.3801	.3086	.4435	.4527
11	.4115	.4527	.3841	.4298	.3601	.3841	.4527
12	.4115	.4527	.3292	.4344	.3601	.4435	.4527
13	.4115	.4527	.3292	.4298	.3601	.3841	.4527
14	.4115	.4527	.3292	.4344	.3601	.3841	.3395
15	.4115	.4527	.3292	.3761	.3601	.3841	.3395
16	.4115	.4527	.3326	.3801	.3086	.3841	.3395
17	.4115	.4527	.3326	.3761	.4115	.3801	.3395
18	.4115	.4527	.3292	.4252	.4115	.439	.4527
19	.4115	.4527	.3292	.4298	.4115	.3841	.4527
20	.4115	.4527	.3292	.4887	.463	.3841	.3395
21	.3601	.4527	.3326	.4252	.463	.3881	.4527
22	.3601	.4527	.3292	.4887	.4115	.3841	.3395
23	.4115	.4527	.3292	.4835	.4115	.3841	.4527
24	.4344	.4115	.3395	.4435	.4252	.4115	.3292
Max	.4344	.4527	.3841	.4887	.463	.4435	.4527
Min	.3258	.3601	.1132	.3292	.3086	.3086	.3292
Avg	.3999	.4291	.3089	.3959	.3888	.3953	.3832

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S

Feeder No / Name : 201 / kalthan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2987	.3174	.2401	.2347	.2058	.3174
2	.2829	.2987	.3511	.2401	.2683	.2058	.3361
3	.2829	.3142	.3881	.2572	.2683	.2204	.3547
4	.3018	.3511	.4251	.2543	.2683	.2543	.3881
5	.3018	.4435	.4938	.2713	.2683	.2883	.4435
6	.3018	.5853	.4656	.2984	.3018	.3222	.5359
7	.3018	.5304	.4024	.3353	.3018	.4024	.462
8	.4338	.4251		.3688	.3688	.4527	.3511
9	.2683	.2543	.2683	.1867	.2452	.2587	.5658
10		.2926	.2683	.2263	.2054	.112	.7042
11	.2229	.2149	.2683	.2263	.1867	.1307	.6962
12	.2401	.2328	.2652	.1509	.1867	.1663	.7127
13	.2572	.2149	.2683	.1509	.1698	.168	.7209
14	.2058	.2328	.2543	.1698	.1698	.1867	.6962
15	.2035	.2378	.2347	.1698	.168	.1867	.6464
16	.2058	.2328	.2321	.1698	.1698	.168	.6299
17	.2241	.2378	.2926	.2075	.2241	.2054	
18	.2427	.2241	.2743	.3018	.2427	.2801	
19	.3326	.3174	.2561	.3395	.3326	.3511	
20	.3658	.3921	.3881	.3772	.3658	.3696	.4108
21	.3841	.4024	.3475	.3961	.3658	.3696	.3921
22	.3326	.3696	.3292	.3206	.3511	.3511	.3841
23	.3142	.3361	.2957	.2263	.2229	.3361	.3326
24	.3206	.3174	.3174	.2347	.2012	.2229	.3174
Max	.4338	.5853	.4938	.3961	.3688	.4527	.7209
Min	.2035	.2149	.2321	.1509	.168	.112	.3174
Avg	.2882	.3232	.3219	.2550	.2537	.2590	.4951



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S

Feeder No / Name : 202 / kalashi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2801	.2427	.2572	.3353	.4748	.3734
2	.3395	.2987	.2587	.2743	.3353	.4748	.3734
3	.3395	.2987	.3326	.2883	.3353	.4862	.4024
4	.3772	.3326	.3582	.3052	.3688	.503	4.5176
5	.415	.4435	.3856	.3481	.4359	.57	.5121
6	.4527	.5487	.5121	.407	.503	.6539	.6036
7	.6036	.567	.5194	.4807	.5365	.7956	.695
8	.4527	.4805	.394	.5304	.6706	.8288	.567
9	.6706	.4359	.3688	.2987	.3772	.4251	1.0288
10	.4748	.4287	.3391	.2263		.4656	1.291
11	.3391	.3856	.3561	.2263	.3326	.3761	1.3763
12	.2374	.3155	.3429	.2263	.3696	.394	1.4586
13	.3052	.3224	.3185	.2263	.3326	.4298	
14	.3353	.3506	.3018	.2263	.3326	.4656	1.4582
15	.3018	.333	.3052	.1886	.3361	.5121	1.4752
16	.3222	.298	.3086	.1886	.3696	.5121	1.4582
17	.3142	.2561	.2241	.3018	.4435	.4805	.439
18	.3511	.2561	.2743	.3772	.5175	.5487	.5304
19	.3696	.2743	.2957	.4527	.5853	.5853	.7023
20	.3658	.3292	.3881	.415	.5304	.5487	.6401
21	.3142	.3696	.2926	.3772	.4435	.5121	.5914
22	.2957	.2987	.2218	.3772	.4435	.4435	.5544
23	.2614	.2614	.2012	.3353	.407	.3292	.439
24	.3018	.2801	.2561	.2374	.3353	.4527	.3292
Max	.6706	.567	.5194	.5304	.6706	.8288	4.5176
Min	.2374	.2561	.2012	.1886	.3326	.3292	.3292
Avg	.3684	.3519	.3249	.3155	.4207	.5112	.9485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S

Feeder No / Name : 203 / karewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.5365	.5853	.3734	.2452	.3696	1.0288
2	.7377	.5365	.6036	.3174	.2452	.3696	1.0288
3	.7545	.5256	.591	.3142	.2641	.3881	1.0117
4	.7545	.5087	.6089	.2957	.3018	.3881	1.0059
5	.7545	.5087	.6135	.2926	.3395	.4024	1.0227
6	.7545	.5087	.6344	.2957	.3395	.439	.9448
7	.7712	.5967	.6173	.2801	.3395	.4572	1.2239
8	.7377	.5801	.6859	.2427	.3395	.3696	1.326
9	.3395	.3511	.2614	.663	1.0059	1.1401	.439
10		.2427	.2054	.7042	1.0608	1.1603	.2801
11	.2241	.2402	.2218	.7042	1.1271	1.2071	.2801
12	.2772	.2378	.2427	.7209	1.0059	1.2574	.2587
13	.2587	.2378	.2427	.8383	1.094	1.2742	.2801
14	.2957		.2427	.8383	1.1271	1.2742	.2772
15	.2614		.2614	.8383	1.1065	1.2929	.2957
16	.2772		.2614	.8383	1.0898	1.3077	.3109
17	.3142	.3109	.2801	.2452	.3547	.3734	.4066
18	.3511	.3142	.3511	.2452	.3734	.4251	.4251
19	.3511	.2987	.3881	.2641	.4024	.4251	
20	.2614	.4066	.3881	.2641	.3841	.439	.4207
21	.3475	.4207	.3841	.2641	.3658	.4024	.3841
22	.3326	.3881	.4066	.2829	.3881	.3881	.3841
23	.5365	.5853	.3696	.2452	.3511	1.0631	1.0903
24	.7545	.5533	.591	.3658	.2452	.3696	1.0395
Max	.7712	.5967	.6859	.8383	1.1271	1.3077	1.326
Min	.2241	.2378	.2054	.2427	.2452	.3696	.2587
Avg	.4870	.4233	.4183	.4472	.5790	.7076	.6593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214436 / 33/11 KV KALTHAN S/S

Feeder No / Name : 204 / 11Kv Gangawalan

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.2229	.2378	.1867	.1886	.2054	.4733
2	.3688	.2229	.2195	.2054	.2263	.2241	.4733
3	.4024	.2401	.2507	.2054	.2263	.2241	.5083
4	.4359	.2713	.2561	.2218	.2263	.2587	.5144
5	.503	.3222	.298	.2427	.3018	.2957	.5487
6	.5365	.407	.4207	.2987	.3018	.3696	.7042
7	.5365	.4862	.4973	.3547	.3772	.439	.9054
8	.4694	.4807	.5487	.3696	.3772	.3696	.9556
9	.2641	.2772	.2614	.5636	.6706	.8478	.3841
10	.2033	.2587	.3696	.5365	.7042	.9724	.2957
11	.1494	.2378	.1663	.5365	.788	.9724	.2561
12	.1509	.2195	.1646	.5365	.8215	1.0562	.2195
13	.1509	.2195	.168	.503	.7712	1.0395	.2614
14	.1509	.2012	.1509	.503	.7291	1.0059	.1848
15	.1509	.1829	.1494	.4694	.7291	.9724	.1646
16	.1494	.1463	.1478	.4024	.7291	1.0059	.1646
17	.1867	.2012	.1646	.1886	.2241	.1867	.1886
18	.2801	.2218	.2195	.1886	.2957	.2987	.2195
19	.2587	.2772	.3142	.3018	.3326	.3547	.3109
20	.2402	.3326	.2772	.3018	.3142	.3292	.3361
21	.2218	.2614	.2241	.2263	.2772	.2614	.2743
22	.1867	.1867	.1867	.1886	.2402	.1867	.2241
23	.2374	.2218	.168	.1509	.2241	.4801	.5898
24	.3353	.2401	.2378	.168	.1886	.2054	.4908
Max	.5365	.4862	.5487	.5636	.8215	1.0562	.9556
Min	.1494	.1463	.1478	.1509	.1886	.1867	.1646
Avg	.2877	.2641	.2541	.3271	.4277	.5234	.4020

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 201 / Sarati AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.9259	.8383	.0762	.0762	.1829	1.2146
2	.8383	.8916	.8383	.0953	.0762	.1829	1.1336
3	.8383	.8916	.8383	.0953	.0762	.2134	1.1336
4	.8383	.9259	.8383	.0953	.0762	.2743	1.1336
5	.8383	.9259	.884	.1429	.0953	.3048	1.2955
6	.9145	.9259	.9145	.1905	.1429	.3658	1.5384
7	1.0212	1.0288	.9755	.1905	.1905	.3353	1.7814
8	1.0669	1.0631	.9907	.1429	.1524	.3048	1.7814
9	.1981	.2286	.1677	1.0526	1.4575	1.6842	.0953
10		.2286	.0762	1.3765	1.5242	1.7814	.1372
11	.1886	.2591	.0762	1.5384	1.6613	1.9433	.1372
12	.2229		.0762	1.448	1.8595	1.9433	.1372
13	.2058	.2286	.0762	1.5242	1.768	2.0243	.1372
14	.2058		.0762	1.5242	1.768	2.0243	.1524
15	.2058	.1677	.0762	1.5242	1.829	2.0243	.1981
16	.2058	.1829	.0762	1.5242	1.7528	1.9433	.2134
17		.2286	.1429	.0762	.2286	.0857	.2439
18	.2229	.2439	.1429	.1429	.2743	.1429	.3048
19	.3258	.2743	.1429	.1429	.3048	.1905	.3048
20	.2743	.3048	.1905	.2382	.2743	.1905	.3048
21	.2743	.2743	.1905	.1905	.2439	.1429	.2743
22	.2743	.2439	.1143	.1429	.2286	.1429	.2743
23	.9259	.8383	.0762	.1429	.1829	1.2955	1.1888
24	.8383	.9259	.8383	3.0483	.0762	.1829	1.2955
Max	1.0669	1.0631	.9907	3.0483	1.8595	2.0243	1.7814
Min	.1886	.1677	.0762	.0762	.0762	.0857	.0953
Avg	.5347	.5549	.4024	.6944	.6800	.8294	.6838

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 202 / CHAKATI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2401	.2743	.5668	.7287	.8745	.2429
2	.2743	.2401	.3086	.5668	.7287	.8745	.2429
3	.2743	.2743	.2743	.5668	.7287	.8745	.2429
4	.2743	.3086	.2743	.5668	.7287	.9069	.2429
5	.2743	.3429	.2743	.6478	.8097	.9717	.2372
6	.3353	.3772	.3048	.8097	.9717	1.0688	.2429
7	.3353	.3772	.3048	.9717	1.2146	1.3927	.3239
8	.3048	.3086	.3048	.9717	1.2955	1.4575	.2429
9	.6706	.6401	.7316	.2429	.2429		1.2955
10	.7545	.7011	.8097	.2429	.1943		1.8461
11	.7545	.7316	.8097	.1619	.1296		1.8785
12	.7202	.7316	.8907	.1619	.1619	.1619	2.0081
13	.7202	.7316	.8907	.1296	.1296	.1619	1.8138
14	.7202	.7011	.8907	.1296	.1619	.1619	1.8461
15	.6859	.5792	.8907	.1296	.1943	.1619	1.3279
16	.6516	.6706	.8097	.1619	.1943	.1581	1.8138
17	.12	.2134	.2429	.1619	.2267	.2429	.2267
18	.2743	.2439	.3239	.2429	.3239	.2429	.2915
19	.3429	.2743	.3239	.3239	.3563	.4049	.3887
20	.3429	.3048	.4049	.3239	.3563	.3239	.3563
21	.3086	.2743	.3239	.3239	.3563	.3239	.3239
22	.2743	.2743	.2429	.3239	.3563	.3239	.3239
23	.2401	.2743	.5668	.7287	.8421	.2429	.3239
24	.2743	.2401	.2743	.5668	.7287	.8745	.2429
Max	.7545	.7316	.8907	.9717	1.2955	1.4575	2.0081
Min	.12	.2134	.2429	.1296	.1296	.1581	.2267
Avg	.4251	.4190	.4895	.4177	.5067	.5813	.7636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 203 / 11 kV Nirnimgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7545	.6859	.2372	.2372	.2214	1.2651
2	.6859	.7545	.6859	.2372	.2372	.2214	1.186
3	.6859	.7888	.6859	.2372	.2372	.2214	1.186
4	.6859	.7888	.6859	.2372	.2372	.253	1.186
5	.6859	.823	.8383	.3163	.3163	.3479	1.2651
6	.7621	.9602	1.2193	.4744	.3953	.4744	1.5813
7	1.0669	1.2346	1.4022	.4744	.4744	.4744	2.0557
8	1.0974	1.2689	1.448	.3953	.3953	.4111	2.2138
9	.3353	.2743	.2743	1.3441	1.3441		.3163
10	.2401	.5487	.2372	1.4232	1.4548		.2214
11	.1715	.1829	.1581	1.4232	1.5181	1.8976	.1265
12	.1715	.1524	.1581	1.4232	1.6129	1.4232	.1265
13	.1715	.1219	.1581	1.3441	1.5181	2.0557	.1265
14	.1715	.1219	.1581	1.2651	1.4232	2.0557	.0949
15	.1715	.1219	.1581	1.2651		2.0557	.0949
16	.1715	.1524	.1581	1.2651	1.2018	1.9766	.1265
17	.2401	.1829	.2372	.1581	.2214	.1581	.1898
18	.3086	.2134	.2372	.2372	.3163		.2846
19	.4458	.3048	.3163	.3953	.3795	.4744	.3795
20	.4115	.3048	.3953	.4744	.3479	.3953	.3479
21	.3429	.2743	.3163	.3953	.2846	.3163	.3163
22	.3429	.2743	.2372	.3163	.253	.3163	.2846
23	.7545	.6859	.2372	.2372	.2214	1.2651	1.3283
24	.6859	.7545	.7716	.2372	.2372	.2214	1.2651
Max	1.0974	1.2689	1.448	1.4232	1.6129	2.0557	2.2138
Min	.1715	.1219	.1581	.1581	.2214	.1581	.0949
Avg	.4789	.5019	.4942	.6589	.6463	.8208	.7320

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 204 / 11 kV Gondi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.583	.6001	1.4575	1.5432	1.6118	.6602
2	.6001	.583	.6001	1.4575	1.5432	1.6118	.6602
3	.6001	.6173	.6001	1.4575	1.5432	1.6118	.6602
4	.6001	.6516	.6516	1.4575	1.5432	1.6461	.6602
5	.6859	.7202	.7716	1.5432	1.7147	1.7147	.7545
6	.7888	.823	.8573	1.6289	1.8861	1.8861	.8488
7	.9259	.7545	.9945		2.0576	2.1948	1.0374
8	.8573	.7202	.9431	1.8004	2.1052	2.4006	.9431
9	1.4403	1.3032	1.5775	.8488	.3772	.9431	1.9433
10	1.4575	1.3717	1.6289	.7545	.4904	.7545	2.6406
11	1.3717	1.4403	1.7147	.5658	.5658	.6602	2.8978
12		1.4403	1.8004	.5658	.547	.5144	2.8807
13	1.3889	1.4403	1.8004	.6602	.6413	.5658	2.9321
14	1.3889	1.4575	1.749	.6602	.5658	.5658	2.915
15	1.3717	1.5432	1.8004	.6602	.6224	.5658	2.8978
16	1.3375	1.6118	1.8861	.7545	.6979	.5658	2.8978
17		.6344	.7545	.7545	.9242	.8488	.7356
18	.6344	.6859	.8488	.9431	1.1317	.9431	.8676
19	.8573	.8573	.9431	.9431	.9808	1.1317	1.094
20	.7888	.8573	1.1317	.9431	.8676	1.0374	1.1317
21	.703	.8573	.9431	.9431	.9054	.9431	.9054
22	.6859	.7716	.8488	.7545	.9054	.9431	.8299
23	.6173	.6001	1.4575	1.5432	1.5432	.6602	.7167
24	.6001	.583	.6001	3.8104	1.5432	1.5775	.6602
Max	1.4575	1.6118	1.8861	3.8104	2.1052	2.4006	2.9321
Min	.6001	.583	.6001	.5658	.3772	.5144	.6602
Avg	.9228	.9545	1.1460	1.1699	1.1352	1.1624	1.4655

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 205 / 11 kV Sarati Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.1372	.132	.1509	.1402	.1509
2	.1372	.1372	.1372	.132	.1509	.1402	.1509
3	.1372	.2058	.1372	.132	.1509	.1372	.1509
4	.1715	.2743	.1715	.1698	.1509	.1753	.1509
5	.1829	.2743	.2058	.2075	.1698	.2103	.1886
6	.1981	.2915	.2401	.2641	.2263	.2454	.2263
7	.1886	.2743	.2229	.2641	.2829	.2103	.2829
8	.1715	.2229	.2229	.2075	.2641	.1928	.2263
9	.1029	.1067	.1543	.1715	.1372	.1715	.1886
10		.12	.1509	.12	.1132	.1372	.1753
11	.12	.12	.1509	.1029	.0943	.1029	.0876
12	.1372	.1029	.1132	.1029	.0943	.1029	.0876
13	.1029	.0914	.1132	.1372	.0943	.1029	.1227
14	.1029	.0686	.1132	.12	.0754	.1029	.1052
15	.0686	.0905	.1132	.12	.0754	.1029	.1052
16	.0686	.0857	.0943	.1372	.132	.1029	.1052
17	.1029	.1029	.1132	.132	.1227	.132	.1052
18	.12	.1372	.1509	.132	.1753	.1509	.1578
19	.2058	.1715	.1509	.1509	.1753	.2075	.1928
20	.1715	.1734	.2263	.2075	.1753	.1698	.1753
21	.1372	.1372	.1886	.1886	.1578	.1509	.1578
22	.1372	.1372	.1509	.1509	.1402	.1509	.1578
23	.1372	.1372	.132	.1509	.1402	.1886	.1698
24	.1372	.12	.1372	.7716	.1509	.1402	.1509
Max	.2058	.2915	.2401	.7716	.2829	.2454	.2829
Min	.0686	.0686	.0943	.1029	.0754	.1029	.0876
Avg	.1381	.1550	.1553	.1835	.1500	.1529	.1572



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214439 / 33 KV NIR NIMGAON

Feeder No / Name : 206 / 11 kV Bhagatwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.583	.5335	.0953	.0953	.0914	.6668
2	.5335	.583	.5335	.0953	.0953	.0914	.6668
3	.6097	.6516	.5335	.0953	.0953	.0914	.6668
4	.6097	.6859	.5335	.0953	.0953	.1219	.6668
5	.6097	.7202	.6097	.1905	.0953	.1829	.8002
6	.6859	.7545	.6859	.381	.1905	.2743	.9335
7	.7621	.7545	.6859	.2858	.2858	.2134	1.0002
8	.823	.823	.7621	.2858	.1905	.1524	1.0002
9	.1219	.1219	.0914	.6668	.8002		.0953
10	.1029	.1219	.0953		.9145		.061
11	.0686	.1219	.0953	.9335	.945	.9335	.061
12	.0686	.1029	.0953	.9335		.9335	.061
13	.0686	.0914	.0953	.9335	1.0059	.9335	.061
14	.0686	.0914	.0953	.9335	1.1279	.9335	.061
15	.0686	.061	.0953	.9335	1.0669	.9335	.0305
16	.1029	.0914	.0953	.8669	1.0974	.9335	
17	.1029	.0914	.1905	.0953	.0914	.0953	
18	.1029	.0914	.1905	.0953	.1524	.1905	.0914
19	.1715	.0914	.1905	.1905	.2134	.2858	.1829
20	.1715	.1524	.1334	.2858	.1829	.1905	.1829
21	.1372	.1372	.1334	.1905	.1219	.1905	.1524
22	.12	.1219	.1334	.1905	.0914	.1905	.1219
23	.6344	.5335	.0953	.0953	.0914	.6668	.9145
24	.5335	.583	.5335	.0953	.0953	.0914	.6668
Max	.823	.823	.7621	.9335	1.1279	.9335	1.0002
Min	.0686	.061	.0914	.0953	.0914	.0914	.0305
Avg	.3255	.3401	.3015	.3897	.3974	.3964	.4157

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 201 / 11KV PALASDEO AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2572	.2401	.3353	.3429	.3963	.3086
2	.2058	.2572	.2572	.3353	.3086	.3963	.3258
3	.2058	.2572	.2743	.3353	.3429	.3963	.3429
4	.2572	.2572	.2743	.3353	.3601	.3963	.415
5	.3258	.3429	.3772	.381	.3772	.4115	.5316
6	.5144	.4801	.463	.5335	.7202	.7011	.6001
7	.583	.4287	.463	.6249	.8535	.8688	.6344
8	.583	.3429	.3772	.6249	.823		.463
9	.5182	.3429	.3772	.3086	.3086	.2743	.945
10	.3429	.3944		.1372	.2401	.2743	1.0669
11	.3086	.3258	.3506	.1372	.1829	.2401	1.2041
12	.3086	.3258	.3506	.1715	.2401	.2915	1.1736
13	.3086	.2743				.2915	1.1888
14		.3086	.3506			.2743	1.2498
15		.2915	.3658			.2915	1.2193
16	.3429	.2572	.3658			.2743	1.2041
17	.1715	.1715	.1886	.2572	.3258	.3086	.1677
18	.2572	.2801	.2743	.2401	.3086	.3429	.3772
19	.3429	.2743	.3429	.2058	.3772	.3772	.1715
20	.3429	.2743	.3258	.3601	.3772	.3601	.3086
21	.3086	.2572	.3258	.2401	.3429	.3429	.3258
22	.2572	.2401	.2915	.2572	.2915	.3258	.3429
23	.2572	.2401	.3201	.3772	.4115	.2915	.2915
24	.2058	.2572	.2401	.3201	.3772	.4115	.3086
Max	.583	.4801	.463	.6249	.8535	.8688	1.2498
Min	.1715	.1715	.1886	.1372	.1829	.2401	.1677
Avg	.3252	.2974	.3271	.3259	.3956	.3713	.6320

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 202 / 11KV RUI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2572	.4115	.381	.4115	.5335	.4458
2	.2743	.2572	.4115	.381	.4115	.5335	.463
3	.2743	.2572	.4287	.3963	.4287	.5335	.4801
4	.2743	.3086	.4458	.3963	.5144	.5335	.4801
5	.3429	.4287	.5316	.4572	.5487	.5335	.6344
6	.5487	.6859	.6516	.6401	.8573	.7621	.7202
7	.6516	.5144	.6687	.7164	.945	.9907	.7202
8	.5144	.4287		.6097	1.0364	1.0974	.6173
9	.3963	.4287	.6687	.463	.4458	.4458	1.0212
10	.4287		.6859	.4287	.4115	.3944	.9145
11	.3429	.4115	.503			.1715	1.1736
12	.3429	.4115	.4725	.3429	.1715	.2915	1.2193
13	.3429	.3944	.4877	.3086	.2572	.2743	1.326
14			.4572	.2572	.2915	.2401	1.326
15		.3258	.4877	.1715	.3429	.3258	1.1888
16	.1715	.3601	.4877	.1715	.3086	.2743	1.2803
17	.2572	.1715	.1715	.2229		.3429	.2743
18	.3429	.3429	.2743	.3772	.4115	.4458	.3944
19	.3772	.4458	.463	.4115	.463	.463	.4801
20	.3429	.4115	.463	.463	.4287	.4458	.4801
21	.3086	.4115	.4287	.3944	.4287	.4458	.4801
22	.2572	.3772	.4287	.4115	.3772	.463	.4458
23	.2572	.3944	.3963	.4287	.503	.4458	.3944
24	.2572	.2572	.3944	.381	.463	.5182	.4904
Max	.6516	.6859	.6859	.7164	1.0364	1.0974	1.326
Min	.1715	.1715	.1715	.1715	.1715	.1715	.2743
Avg	.3446	.3765	.4704	.4005	.4753	.4794	.7271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 203 / 11KV NHAVI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.3086	.3772	.6001	.5144	.6516	.6687
2	.4572	.3086	.3772	.6001	.5487	.6516	.6859
3	.4572	.3086	.3944	.6001	.5658	.6516	.6859
4	.4572	.3086	.4115	.6001	.3772	.6516	.7202
5	.4572	.3086	.4458	.6001	.6173	.6516	.8745
6	.4877	.3086	.4973	.6173	.6859	.703	.9088
7	.5487	.4287	.583	.6344	.703	.6687	.8993
8	.4572	.5144	.6687	.5144	.5658	.6516	1.0212
9	.4287	.5144	.3429	.6001	.7545	.8916	.4458
10	.4287	.3772	.2401		.8078	.9297	.3429
11		.3944	.2229	.6001	.8383	.8993	
12	.3429			.6001	.945	.9755	
13			.1886	.6001	.9145	.9907	.1886
14		.2743	.1715	.6001	.884	1.0212	.2229
15		.3086	.2058	.6859	.7926	1.0364	.2401
16		.3429	.2229	.5487	.8383	1.0059	.2572
17		.3601	.2915	.4801	.3601	.3601	.3601
18	.5144	.4973	.3772	.4801	.4801	.4801	.5144
19		.5316	.6001	.4973	.6173	.6001	.6344
20	.6001	.5144	.6001	.6001	.6173	.6001	.6001
21	.5144	.5144	.5487	.583	.6001	.583	.6001
22	.4287	.4973	.5316	.583	.5658	.5658	.5487
23	.3429	.3601	.5658	.5487	.5487	.6516	.6097
24	.4572	.3429	.3601	.6001	.5658	.6516	.6516
Max	.6001	.5316	.6687	.6859	.945	1.0364	1.0212
Min	.3429	.2743	.1715	.4801	.3601	.3601	.1886
Avg	.4610	.3920	.4011	.5815	.6545	.7302	.5764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 204 / 11KV KALEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.2058	.2591	.0762	.12	.1067	1.0974
2	.4268	.2058	.2591	.0762	.12	.1067	1.0974
3	.4268	.2058	.2743	.0762	.1029	.1067	1.1126
4	.4268	.2058	.2743	.0762	.1029	.1067	1.1279
5	.4268	.2572	.3201	.0762	.1372	.1067	1.1279
6	.4572	.3086	.3506	.0762	.1372	.1067	1.1431
7	.4572	.3429	.3658	.0762	.1372	.1067	1.2955
8	.4572	.3429	.3963	.1067	.12	.1067	1.387
9	.1543	.0857	.1219	.5316	.8059	1.0669	.0914
10	.0686	.1219	.1372	.6859	.8535	1.2651	.0914
11	.0686		.12	.6859	.823	1.3413	.1067
12	.1029	.0914	.1543	.6859	.9145	1.4327	.1067
13	.1029	.0762	.1715	.6859	.9602	1.4937	.1067
14		.0762	.1543	.7716	1.0059	1.4784	.1067
15		.1067	.1219	.7716	1.0822	1.5089	.1067
16	.1029	.1372	.1372	.7888	1.1279	1.4784	.1524
17	.1029	.1372	.1829	.1886	.1372	.1219	.1981
18	.1029	.1219	.1677	.1715	.1372	.1067	.2134
19	.12	.1219	.1524	.1715	.1715	.1067	
20	.12	.1219	.1524	.1886	.1524	.0914	.1829
21	.12	.1067	.1372	.1543	.1372	.0914	.1524
22	.12	.1219	.1219	.1886	.1067	.0914	.1067
23	.2058	.2439	.1067	.1372	.1067	1.0974	1.0822
24	.4268	.2058	.2439	.0762	.12	.1067	1.0974
Max	.4572	.3429	.3963	.7888	1.1279	1.5089	1.387
Min	.0686	.0762	.1067	.0762	.1029	.0914	.0914
Avg	.2466	.1718	.2035	.3135	.4008	.5722	.5779

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 205 / 11 KV IRRIGATION

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1372	.12	.1372	.3429	.2134	.0857
2	.2401	.1372	.12	.1372	.3258	.2134	.1029
3	.2401	.1372	.1372	.1372	.3258	.2134	.1029
4	.2401	.1372	.1372	.1372	.3772	.2134	.12
5	.2401	.1372	.1715	.1829	.3086	.2286	.1372
6	.2401	.1715	.1886	.2591	.3429	.2439	.1372
7	.2058	.1372	.1543	.3201	.3258	.4268	.1715
8	.1886	.1372	.12	.3658	.3601	.4268	.12
9	.3048	.2058	.2229	.1543	.1372	.1029	.583
10	.2572	.2229	.2401	.1372	.12		.7773
11	.2572	.2058	.2286	.1372	.0914	.1029	.884
12	.2572	.1886	.1829	.1372	.1067	.1372	.9907
13	.2572	.1886	.1981	.1372		.12	1.0212
14		.2229	.2134	.1029		.1029	1.0517
15		.2229	.1981	.1029		.1372	.945
16	.2572	.2229	.1981	.1372		.1372	.9907
17	.1029	.1029	.061	.12		.1543	.1372
18	.1029	.12	.0914	.1372	.1886	.1372	.1886
19	.0857	.1372	.1067	.12	.1829	.12	.1715
20	.0857	.12	.1067	.12	.1829	.12	.1524
21	.0857	.1029	.1067	.12	.1886	.1029	.1524
22	.12	.1029	.1067	.1372	.1372	.1029	.1372
23	.1372	.1029	.1372	.1715	.1829	.0857	.0914
24	.2743	.1372	.1029	.1372	.3944	.1981	.0857
Max	.3048	.2229	.2401	.3658	.3944	.4268	1.0517
Min	.0857	.1029	.061	.1029	.0914	.0857	.0857
Avg	.2009	.1558	.1521	.1577	.2433	.1757	.3891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 206 / 11KV KALEWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2058	.1715	.1886	.2229	.2229
2	.2058	.2058	.2229	.1715	.2401	.2229	.2229
3	.2058	.2058	.2401	.1715	.2401	.2229	.2401
4	.2058	.3086	.2401	.1715	.3429	.2229	.2572
5	.3429	.4287	.3601	.2915	.4287	.463	.4801
6	.5144	.6173	.6173	.4287	.5144	.6001	.5658
7	.6173	.6001	.6516	.6516	.583	.583	.583
8	.6001	.5144	.5316	.4458	.3772	.4801	.4287
9	.463		.3944	.3601	.4115	.3772	.3944
10	.3429	.3772	.2915	.2572	.3086	.3258	.2915
11	.2743	.3429	.2058	.2058	.2401	.2401	.1886
12	.2058	.3429	.2058	.1886	.2058	.2058	.2058
13	.2058	.2915	.1715	.1715	.1715	.2058	
14		.2572	.1543	.1372	.1543	.1886	.1715
15		.2058	.1543	.1372	.1372	.1715	.1715
16	.2058	.2058	.1543	.2058	.2058	.1715	.2229
17	.2572	.2401	.2058	.2401	.2401	.2572	.2572
18	.3429	.2743	.3429	.3429	.3086	.3772	.2915
19	.3772	.2743	.4458	.3601	.4458	.3772	.463
20	.3086	.2572	.4458	.3772	.4287	.3601	.4287
21	.2572	.2572	.3772	.2572	.3429	.3086	.3258
22	.2058	.2401	.2572	.2572	.2572	.2743	.2572
23	.2058	.2058	.1886	.1715	.2058	.2058	.1886
24	.1886	.2058	.2058	.1715	.1715	.2058	.2058
Max	.6173	.6173	.6516	.6516	.583	.6001	.583
Min	.1886	.2058	.1543	.1372	.1372	.1715	.1715
Avg	.3063	.3072	.3029	.2644	.2979	.3029	.3072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 207 / 11KV PALASDEO GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.12	.1029	.1029	.12	.12
2	.1029	.1029	.1372	.1029	.1029	.12	.1372
3	.1029	.1029	.1372	.1029	.12	.12	.1372
4	.1029	.12	.1543	.1029	.1372	.12	.1543
5	.1543	.1372	.1715	.12	.1715	.1543	.1886
6	.1886	.1886	.1886	.1543	.1886	.1886	.2058
7	.2058	.1886	.2229	.1886	.1886	.1886	.2058
8	.1886	.1886	.1715	.1715	.1543	.1543	.1372
9	.1543	.12	.12	.1715	.1543	.1372	.12
10	.1372	.12	.12	.1029	.12	.12	.12
11	.12		.1029	.0857	.1029	.12	.12
12	.1029	.1372	.0857	.0857		.1029	.12
13	.1029	.12	.1029	.0857	.1029	.1029	.1029
14		.12	.0857	.0857	.0857	.0857	.12
15		.12	.0686	.1029	.1029	.1029	.12
16	.1029	.12	.1029			.12	.12
17	.12	.132	.1029	.1372	.1543	.12	.1372
18	.12	.12	.1029	.1372	.1372	.1372	.12
19	.12	.1372	.1372	.1372	.1543	.1372	.1715
20	.1029	.12	.1543	.1543	.1543	.1372	.1715
21	.1029	.1372	.1543	.1372	.1543	.12	.1543
22	.1029	.12	.1543	.1372	.1372	.1372	.1543
23	.1029	.12	.12	.1029	.12	.12	.12
24	.1029	.1029	.12	.1029	.1029	.12	.12
Max	.2058	.1886	.2229	.1886	.1886	.1886	.2058
Min	.1029	.1029	.0686	.0857	.0857	.0857	.1029
Avg	.1247	.1295	.1307	.1223	.1341	.1286	.1407



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 208 / 11KV BANDEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0686	.0914	.1829	.1886	.1981	.0914
2	.0857	.0686	.0914	.1829	.1543	.1981	.0914
3	.0857	.0686	.0914	.1829	.1715	.1981	.0914
4	.0857	.0686	.0914	.1829	.1715	.1981	.0914
5	.0857	.0686	.0914	.1829	.1715	.1981	.0914
6	.0857	.0686	.0914	.1829	.2058	.1981	.0914
7	.0857	.0686	.0762	.1829	.2058	.2591	.0914
8	.0857	.0686	.0762	.1981	.2401	.2286	.1067
9	.2134	.1029	.1219	.0762	.2058	.1067	.381
10	.0857	.0762	.1829	.0857	.1715		.5639
11	.0857	.0762	.2134	.0857	.0762	.061	.6554
12	.0857	.0762	.1677	.0857	.0762	.0914	.6859
13	.0857	.0762	.1677	.0857	.0762	.1219	.7316
14		.0762	.1524	.0857	.1067	.1524	.7773
15		.0914	.1677	.0857	.1067	.1677	.7773
16	.0857	.0914	.1981	.1029	.1524	.1372	.7926
17	.0343	.061	.1372	.1372	.1067	.1829	.1677
18	.0343	.1067	.1067	.1372	.1067	.1524	.1829
19	.0686	.0914	.0762	.1372	.1372	.1372	.2229
20	.0686	.0914	.0762	.1372	.1372	.1219	.2401
21	.0686	.0914	.0762	.12	.1372	.1067	.2401
22	.0686	.0914	.0762	.1543	.1067	.0914	.2401
23	.0686	.0914	.1829	.1715	.2134	.0914	.2058
24	.0857	.0686	.0914	.1829	.1886	.1981	.0914
Max	.2134	.1067	.2134	.1981	.2401	.2591	.7926
Min	.0343	.061	.0762	.0762	.0762	.061	.0914
Avg	.0829	.0795	.1207	.1396	.1506	.1564	.3209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 209 / 11KV DALAJ AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.2572	.1829	.1067	.12	.1372	.442
2	.3658	.2572	.1829	.1067	.12	.1372	.442
3	.3658	.2572	.1981	.1067	.1372	.1372	.4572
4		.2572	.1981	.1067	.12	.1372	.4877
5	.4115	.2572	.2134	.1067	.1029	.1372	.5335
6	.4115	.2743	.2134	.1524	.12	.1372	.5487
7	.4115	.3429	.2591	.1829	.1372	.1372	.6097
8	.4115	.3429	.2591	.1524	.1715	.1829	.6401
9	.12	.0857	.1372	.3963	.3429	.7316	.1829
10	.0857	.061	.0762	.5144	.4801	.9145	.2134
11	.0857	.061	.1067	.5144	.7926	.9907	.1981
12	.0857	.061	.0762	.5144	.7926	.8993	.1981
13	.0857	.0457	.0305	.5144	.7621	.945	
14		.0457	.0762	.5144	.7621	.9907	.1524
15		.0457	.0762	.5144	.7316	.8688	.2058
16	.0514	.061	.0762	.3429	.7011	.9145	.1372
17	.0857	.061	.0762	.2058	.1067	.1067	.1372
18	.0857	.0457	.1067	.1886		.1372	.2401
19	.0857	.061	.1067	.1715	.1219	.1372	.2058
20	.0857	.061	.1067	.1886	.1219	.1067	.1829
21	.0857	.0457	.1067	.1372	.1219	.1067	.1677
22	.0857	.061	.1067	.1543	.1067	.0762	.1219
23	.2572	.1829	.1067	.1372	.1067	.4268	.4268
24	.3353	.2572	.1829	.1067	.12	.1372	.4268
Max	.4115	.3429	.2591	.5144	.7926	.9907	.6401
Min	.0514	.0457	.0305	.1067	.1029	.0762	.1219
Avg	.2078	.1454	.1359	.2557	.3130	.4014	.3199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214448 / 33/11 KV KALEWADI S/STN

Feeder No / Name : 401 / 33 KV VALMONT

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.3086	.3086	.2572	.2058	
2		.2572	.2572	.3086	.2572	.2572	
3		.2058	.2058	.2572	.2058	.2572	
4		.2058	.3086	.2572	.2058	.2058	
5		.2058	.2572	.2058	.2058	.2058	
6		.1543	.1543	.2572	.3086	.2058	.1029
7		.1543		.2058	.3086	.1029	.1029
8		.2572	.2572	.3086	.2572	.1029	.2572
9		.2058	.1543	.2058	.1543	.1029	.2058
10		.3086	.3086	.2058	.2572	.1543	.2058
11		.3601	.2058	3.9095	.2572	.1543	.3086
12		.2058	.2058	.2058	.3086		.3601
13		.2058	.2572	.2572	.2572		.3601
14		.2058	.4115	.2572	.3086		.3601
15		.2572	.2058	.2572	.3086	.1029	.3086
16	.2572	.2572	.2058	.2572	.2572	.1029	.3086
17	.2572	.2058	.3086	.3086	.3086		.3601
18	.1543	.2572	.2058	.2058	.2058		.3086
19	.2572	.3086	.3601	.3086	.3086	.1029	.3601
20	.3086	.3601	.463	.3086	.3086	.1029	.4115
21	.3086	.3601	.4115	.3601	.3601		.3601
22	.2572	.2572	.3086	.3086	.3086		.4115
23	.2058	.2058	.2572	.3086	.2572		.2058
24		.2058	.2572	.2572	.2572	.2058	
Max	.3086	.3601	.463	3.9095	.3601	.2572	.4115
Min	.1543	.1543	.1543	.2058	.1543	.1029	.1029
Avg	.2508	.2422	.2729	.4180	.2679	.1608	.2944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN

Feeder No / Name : 201 / Shirsondi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0335	.0343	.0335	.0335	.1029	.0366
2	.0168	.0335	.0343	.0335	.0335	.1372	.0366
3	.0168	.0335	.0343	.0335	.0335	.12	.0366
4	.0168	.0335	.0343	.0335	.0335	.1372	.0366
5	.0168	.0335	.0343	.0335	.0335	.0857	.0366
6	.0168	.0335	.0343	.0503	.0335	.12	.0549
7	.0335	.0335	.0343	.0671	.0838	.2058	.0549
8	.0335	.0335	.0343	.0671	.1174	.1715	.0549
9	.2347	.0503	.0343	.0335	.0503	.0183	.4755
10	.0732	.0857	.0732	.0366	.1029	.0732	.6859
11	.0732	.0857	.0732	.0366	.0343	.0914	.7545
12	.0732	.1029	.0549	.0366	.0171	.1463	.823
13	.0732	.0857	.0549	.1097	.1029	.1463	.8916
14		.0857	.0732	.1463	.0686	.128	.9259
15		.0686	.0914	.1463	.0514	.1097	.9774
16		.0686	.0732	.1417	.0514	.0914	.9774
17		.0343	.0168	.1097	.0343	.1097	.0671
18		.0343	.0335	.0732	.0171	.1097	.0838
19	.0343	.0343	.0335	.0732	.0686	.0732	.0838
20	.0343	.0343	.0335	.0366	.0514	.0549	.0671
21	.0343	.0343	.0335	.0366	.0343	.0549	.0671
22	.0343	.0343	.0335	.0168	.0857	.0366	.0671
23	.0335	.0343	.0335	.0335	.0343	.0366	.0168
24	.0168	.0335	.0343	.0335	.0335	.0343	.0366
Max	.2347	.1029	.0914	.1463	.1174	.2058	.9774
Min	.0168	.0335	.0168	.0168	.0171	.0183	.0168
Avg	.0465	.0490	.0440	.0605	.0517	.0998	.3062

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN

Feeder No / Name : 202 / padasthal

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.6173	.583	.6344	.7202	.8402	.6767
2	.5658	.5658	.583	.6687	.7716	.8916	.6036
3	.6001	.6001	.6173	.703	.8059	.9945	.6401
4	.6344	.6516	.6516	.7373	.8402	1.0631	.7133
5	.583	.6859	.6859	.7716	.8745	1.0974	.7499
6	.6173	.7373	.703	.8059	.9088	1.1317	.8413
7	.6859	.8059	.7373	.8573	1.046	1.286	.8779
8	.583	.823	.6687	.9774	1.2346	1.2517	.7682
9	.703	.6516	.6859	.4287	.4458	.4755	1.56
10	.5487	.6001	.695	.4024	.4115	.4572	
11	.5853	.583	.6401	.3475	.3429	.3841	
12	.567		.6036	.3292	.3086	.4207	1.989
13	.5487	.5144	.5121	.3109	.3258	.4024	2.0233
14		.5316	.5121	.3109	.3429	.4024	2.1948
15		.5316	.5121	.3292	.3601	.4024	2.2977
16		.5144	.4207	.3475	.3772	.3658	2.1091
17		.3944	.3601	.4024	.6344	.5487	
18		.3944	.3944	.4938	.6516	.695	.4973
19	.703	.463	.583	.5853	.6516	.7682	.5316
20	.6173	.5658	.6001	.6767	.6687	.7682	.5658
21	.583	.5487	.5658	.5487	.6516	.7316	.6001
22	.5144	.5658	.5316	.5658	.6516	.695	.6344
23	.5487	.5487	.6173	.6173	.6344	.695	.6516
24	.4973	.583	.5316	3.0483	.6687	.6687	.7316
Max	.703	.823	.7373	3.0483	1.2346	1.286	2.2977
Min	.4973	.3944	.3601	.3109	.3086	.3658	.4973
Avg	.5904	.5860	.5831	.6625	.6387	.7265	1.0599

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN

Feeder No / Name : 203 / 11kv Ajoti

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.5144	.5144	.3772	.3429	.4115	1.3496
2	.7545	.463	.5487	.4115	.3601	.4287	1.3146
3	.7373	.4973	.6001	.3944	.3772	.4287	1.3847
4	.7888	.5316	.6001	.4287	.3944	.4458	1.5424
5	.8059	.583	.6859	.3944	.4287	.4801	1.6461
6	.7716	.6173	.7202	.3772	.4115	.4973	1.749
7	.823	.6687	.7888	.4458	.2743	.4458	2.0576
8	.703	.6859	.7202	.3429	.3086	.3772	2.1434
9	.4115	.3601	.3086	.8745	1.3889	1.8176	.3841
10		.2915	.2378	1.0517	1.5604	2.0233	.3086
11	.2378	.2572		1.0517	1.4918	2.1948	.2743
12	.2561		.2012	1.046		2.0748	.2572
13	.2195	.2058	.2012	1.0517		2.0576	.2572
14		.2229	.1829	1.0166	1.7147	2.0405	.2572
15		.2229	.1829	1.0692	1.749	1.9719	.2572
16		.2229	.1829	1.1218	1.8004	1.8519	.2743
17		.2743	.2229	.2195	.2572	.2561	
18		.2915	.2743	.2926	.3258		.3601
19	.4458	.3429	.3944	.4024	.3772	.5121	.3772
20	.463	.3772	.4115	.439	.0343	.5121	.3944
21	.4287	.3772	.3772	.4115	.3772	.4572	.4115
22	.3944	.3944	.3944	.3944	.3601	.4024	.4287
23	.4458	.4115	.3601	.3772	.3429	1.3672	1.7364
24		.4801	.3944	.3429	.3601	.3429	1.3717
Max	.823	.6859	.7888	1.1218	1.8004	2.1948	2.1434
Min	.2195	.2058	.1829	.2195	.0343	.2561	.2572
Avg	.5533	.4041	.4133	.5973	.6835	1.0173	.8929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214455 / 33/11 KV SHIRSODI S/STN

Feeder No / Name : 204 / 11kv Malwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.1844	.2572		.1341	.1372	.8059
2	.3521	.1677	.2743		.1509	.1543	.8059
3	.3185	.2012	.2743		.1844	.1543	.8596
4	.3353	.218	.3086		.2012	.1715	.8954
5	.3688	.2347	.3429		.1844	.1886	.9313
6	.3856	.2347	.3429		.218	.2229	.9671
7	.4024	.285	.3601		.1844	.1886	1.1393
8	.4024	.2683	.3258	.1677	.1677	.1715	1.1393
9	.1509	.2401	.1372	.3521	.6706	.9991	.1463
10	.1463	.2229	.1829	.4344	1.0288	1.2269	.1372
11		.2229	.0914	.4572	1.0288	1.0867	.1372
12	.0914	.2058	.0732	.5014	1.0974	1.1393	.1715
13		.1543	.0732	.4835	1.0631	1.1568	.1372
14		.1372	.0732	.4477	1.0631	1.0692	.1372
15	.1097	.1029	.0732	.5014	1.046	1.0867	.1543
16		.1029	.0732	.5373	1.046	1.1393	.1372
17		.12		.1097	.1715	.1097	.1677
18		.1372	.1174	.1463	.1372	.1463	.1844
19		.1543	.1509	.1829	.1543	.1463	.1509
20	.1543	.1715	.1341	.1646	.1543	.1463	.1509
21	.1543	.1715	.1341	.1341	.1372	.1463	.1341
22	.1372	.1715	.1509	.1677	.1372	.1463	.1174
23	.1341	.2058	.1174	.1341	.1715	.8238	.8048
24	.3353	.1509	.2401	2.2862	.1174	.1372	.8596
Max	.4024	.285	.3601	2.2862	1.0974	1.2269	1.1393
Min	.0914	.1029	.0732	.1097	.1174	.1097	.1174
Avg	.2518	.1861	.1873	.4240	.4437	.5040	.4697

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 201 / Kandalgaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0549	.1494	.0857	.061	.0655	.3734
2	.0572	.0564	.1494	.0857	.061	.0655	.3734
3	.0572		.1848	.1029	.0648	.0648	.3429
4	.0572	.0846	.1848	.1029	.0648	.0995	.3429
5	.0869	.0857	.2218	.1029	.0648	.0995	.4108
6	.0892	.1158	.2195	.1029	.0671	.1296	.4481
7	.1189	.1448	.2534	.1372	.0671	.128	.4854
8	.1486	.1486	.2534	.1715	.0671	.0949	.5228
9	.096	.096	.0995	.2241	.1524	.0829	.1715
10	.0533	.0857	.0857	.1448	.2896	.4656	.1715
11	.0503	.0857	.0857	.1486	.3258	.6348	.0857
12	.0472	.1017	.0857	.1174	.3258	.6348	.0857
13	.0564	.1029	.0857	.1158	.3224	.6348	.0857
14	.0572	.1017	.0857		.3189	.5975	.0857
15	.0572	.0857	.0857	.1027	.3189	.5601	.0857
16	.0457	.1006	.0857	.1174	.2896	.5228	.0857
17	.0442	.1387	.1029	.0457	.0686	.1029	
18	.0884	.1387	.1372	.0472	.0686	.1029	
19	.0884	.1372	.1029	.064	.0848	.12	
20	.0663	.1372	.1029	.0427	.0848	.1029	
21	.0442	.1387	.1029	.0442	.0848	.1029	
22	.0518	.1372	.1029	.0457	.0671	.0857	
23	.0526	.1357	.0857	.0457	.0663	.3734	
24	.0572	.0549	.1494	.0857	.061	.0655	.3734
Max	.1486	.1486	.2534	.2241	.3258	.6348	.5228
Min	.0442	.0549	.0857	.0427	.061	.0648	.0857
Avg	.0679	.1074	.1334	.0993	.1436	.2474	.2665



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 202 / Mahadev Nagar

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2743	.3696	.3429	.2286	.3239	.7468
2	.2858	.2743	.3658	.3429	.2286	.3239	.7468
3	.2858		.3658	.3429	.2343	.3239	.7468
4	.2896	.2858	.3658	.3429	.3239	.4001	.9335
5	.362	.3572	.362	.3429	.3239	.4001	.9335
6	.4458	.362	.362	.4287	.3353	.4744	.9335
7	.4458	.4344	.4477	.4287	.3353	.4744	1.0269
8	.4458	.4458	.5373	.3429	.3353	.3953	1.1203
9	.3201	.3201	.3239	.5601	.4572	.3239	.4287
10	.2286	.3353	.2572	.4344	.7164	1.0631	.4287
11	.1772	.3391	.2572	.4458	.8059	1.0269	.3429
12	.1829		.2572	.4401	.7973	1.1203	.3429
13	.2115	.3353	.2572	.4401	.7973	1.1203	.3429
14	.1429	.3315	.1715	.4401	.7888	1.1203	.3429
15	.1429	.2515	.1715	.4401	.7011	1.1203	.3429
16	.1143	.2543	.1715	.3668	.6268	1.1203	.3429
17	.1658	.3429	.2058	.2286	.4191	.3429	
18	.221	.3429	.3429	.2286	.4191	.3429	
19	.221	.3391	.4287	.2763	.4239	.3429	
20	.221	.3391	.4287	.2763	.4191	.3429	
21	.221	.3391	.3429	.2286	.4191	.3429	
22	.2286	.4334	.3429	.1715	.4239	.4287	
23	.2362	.3734	.3429	.1715	.3277	.7468	
24	.2858	.2743	.3696	.3429	.2286	.3239	.7468
Max	.4458	.4458	.5373	.5601	.8059	1.1203	1.1203
Min	.1143	.2515	.1715	.1715	.2286	.3239	.3429
Avg	.2570	.3357	.3270	.3503	.4632	.5977	.6382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 203 / Hingangaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2	.1783	.2683	.2614	.2439		.2572
2	.2	.1783	.2652	.2801	.3048		.2987
3	.2572		.2652	.2801	.3239		.3361
4	.2858	.2572	.2949	.3361	.3563		.3086
5	.3144	.3041	.3277	.3734	.3887		.3429
6	.3185	.3041	.3441	.4108	.4024		.3772
7	.2972	.3185	.3361	.4294	.4694		.3772
8	.2675		.2721	.4481	.503		.2915
9	.3841	.4001	.3801	.2229	.1829	.3544	.7095
10	.2934	.4668	.3361	.1448	.1677	.4607	.8573
11	.2362	.3734	.3734	.1337	.1677	.4294	.8573
12	.2008	.3696		.1174	.1326	.4668	.8573
13	.2256	.3696	.2614	.1174	.1311	.5228	.8573
14	.2143	.3696	.2229	.088	.1311	.5228	.8573
15	.2143	.3361	.2614	.1027	.1326	.5228	.9431
16	.1486	.3361	.2801	.1027		.5228	.9431
17	.1105	.2035	.2401	.1029	.1341	.2401	
18	.1326	.2401	.2572	.1181	.2012	.2915	
19	.1547	.2883	.2572	.1547	.2683	.3258	
20	.1547	.2683	.2572	.1715	.2543	.3086	
21	.1437	.2743	.2401	.1715	.2486	.2915	
22	.1684	.2652	.2401	.1829	.2486	.2743	
23	.1536	.2713	.2614	.1829		.2743	
24	.1974	.1783	.2683	.2614	.2439		.2572
Max	.3841	.4668	.3801	.4481	.503	.5228	.9431
Min	.1105	.1783	.2229	.088	.1311	.2401	.2572
Avg	.2197	.2978	.2831	.2165	.2562	.3872	.5723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 204 / 11 Kv Sardewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2143	.2058	.3391	.6859	.6859	1.0745	.5144
2	.2143	.2058	.3391	.7468	.703	1.086	.5144
3	.2143		.3353	.7468	.8097	1.1765	.5144
4	.2896	.2858	.3353	.7468	.8097	1.1641	.5144
5	.2896	.2858	.3353	.7468	.8192	1.2536	.5144
6	.2972	.2896	.3277	.9335	1.0059	1.3432	.6001
7	.2972	.2972	.3277	.9335	1.0898	1.4175	.6001
8	.2972	.2972	.2429	.9335	1.0898	1.4175	.4287
9	.6401	.5601	.5373	.2572	.3048	1.4175	1.8671
10	.4572	.5544		.2172	.3277		2.2291
11	.4725	.5487	.5601	.2229	.3277		2.2291
12		.5544	.5601	.1448	.2429	.3429	2.572
13	.5001	.5544	.6535	.1467	.2429	.3429	2.572
14		.5487	.7468	.1467	.3277	.3429	2.572
15	.4287	.5544	.7468	.1467	.3277	.3429	2.572
16	.3429	.4668	.7468	.1467	.4096	.5144	2.4006
17	.221	.3429	.6859	.1715	.4915	.4287	
18	.221	.3429	.2572	.2362	.4973	.4801	
19	.221	.3391	.3429	.2858	.2652	.5144	
20	.221	.3353	.3429	.2858		.5144	
21	.221	.3429	.3429	.2286	.4973	.4801	
22	.2286	.3353	.3429	.1715	.4144	.4801	
23	.1772	.3429	.7468	.5144	.985	.5144	
24	.2143	.2058	.3391	.7468	.6859	1.0745	.5144
Max	.6401	.5601	.7468	.9335	1.0898	1.4175	2.572
Min	.1772	.2058	.2429	.1448	.2429	.3429	.4287
Avg	.3037	.3824	.4580	.4393	.5809	.8056	1.3958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214465 / 33 KV KANDALGAON

Feeder No / Name : 205 / Kandalgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0429	.0274	.0514	.0343	.0305	.0339	.0343
2	.0429	.0412	.0509	.0343	.0305	.0343	.0514
3	.0572		.0678	.0514	.0625	.0503	.0514
4	.0714	.0572	.0671	.0514	.081	.0671	.0857
5	.1014	.0857	.1006	.0857	.0972	.0838	.12
6	.104	.0869	.1341	.12	.1174	1.3413	.1372
7	.0594	.1014	.1357	.1372	.1341	.116	.0686
8	.0594	.0892	.0995	.1029	.1174	.0995	.0857
9	.064	.08	.0838	.0857	.0914	.0819	.0857
10	.0457	.1029	.0514	.0724	.0867	.0655	.0514
11		.0686	.0343	.0594	.0514	.0514	.0343
12	.0354	.0678	.0343	.029	.0343	.0343	.0343
13	.0282	.0514	.0343	.0293	.0343	.0343	.0343
14	.0286	.052	.0343	.0293	.0343	.0343	.0343
15	.0286	.052	.0343	.0293	.0339	.0343	.0343
16	.0229	.0514	.0343	.0293	.0339	.0514	.0343
17	.0332	.052	.0343	.0343	.0514	.0514	.0514
18	.0442	.0701	.0514	.0354	.0857	.0514	.0686
19	.0442	.0867	.0686	.0553	.1029	.0857	.0857
20	.0442	.0867	.0857	.0553	.104	.0857	.1029
21	.0332	.0693	.0857	.0457	.0848	.0686	.1029
22	.0343	.052	.0686	.0343	.0509	.0686	.0857
23	.0236	.0514	.0514	.0229	.0503	.0514	.0686
24	.0429	.0274	.0514	.0343	.0305	.0335	.0343
Max	.104	.1029	.1357	.1372	.1341	1.3413	.1372
Min	.0229	.0274	.0343	.0229	.0305	.0335	.0343
Avg	.0475	.0657	.0644	.0541	.0680	.1129	.0657

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214466 / 33/11 KV BIJEWADI

Feeder No / Name : 201 / Bijewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.3429	.5144	.1753	.3772	.3734	.6478
2	.5487	.3429	.5144	.1753	.3772	.3734	.6478
3	.5487	.3429	.5144	.1753	.3772	.3734	.6478
4	.5487	.3429	.5144	.1772	.3772	.3734	.6097
5	.5487	.3429	.4858	.181	.3772	.3734	.7621
6	.5487	.5144	.4858	.2743	.3772	.3734	.9145
7	.5487	.5144	.4858	.2772	.3772	.3734	.9145
8	.543	.5144	.4572	.2715	.3696	.1867	.9145
9	.1848	.1867	.1867	.6097	.905	1.2003	.1867
10	.1886	.1867	.1867	.703	.8573	1.2193	.1867
11	.1867	.1867	.081	.6859	1.2003	1.2193	.16
12	.1867	.1867	.081	.6935	1.286	1.2193	.16
13	.1867	.1867	.081	.6859	1.286	1.3717	.1619
14	.1867	.1867	.081	.6859	1.286	1.3717	.16
15	.1867	.1867	.081	.7888	1.286	1.3717	.16
16	.1867	.1867	.0829	.7716	1.286	1.3717	.1581
17	.1867	.1867	.16	.1886	.1867	.1867	.1638
18	.1867	.1867	.1619	.1886	.1867	.1867	.1658
19	.1867	.1867	.1658	.3772	.3734	.1867	.1677
20	.1867	.3734	.1677	.3772	.3734	.1867	.1753
21	.1867	.3734	.1658	.3772	.3734	.1867	.1772
22	.1867	.1867	.1772	.3772	.3734	.1867	.1772
23	.3429	.5144	.1772	.3772	.3734	.6478	.8916
24	.543	.3429	.5144	.1753	.3772	.3734	.6478
Max	.5487	.5144	.5144	.7888	1.286	1.3717	.9145
Min	.1848	.1867	.081	.1753	.1867	.1867	.1581
Avg	.3282	.2959	.2718	.4071	.6258	.6370	.4149

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214466 / 33/11 KV BIJEWADI

Feeder No / Name : 202 / Gaagargaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0934	.0934	.1162	.1829	.2572	.0934
2	.0943	.0934	.0934	.1181	.1848	.2572	.0934
3	.0943	.0934	.0934	.1181	.1886	.2572	.0934
4	.0943	.0934	.0934	.12	.1886	.2572	.0934
5	.0943	.0934	.0934	.1238	.1829	.2572	.0934
6	.0943	.0934	.0934	.1276	.2715	.2572	.0934
7	.0943	.0934	.0934	.2	.2572	.3429	.0934
8	.0943	.0934	.0934	.1467	.3506	.3429	.0934
9	.4525	.2572	.1715	.0829	.0934	.0934	.4049
10	.362	.2572	.2429	.0791	.0934	.0934	.4572
11	.2572	.1715	.1858	.0943	.0934	.0934	.6173
12	.2572	.1715	.18	.0943	.0857	.0934	.6249
13	.2801	.1715	.1858	.0934	.0934	.0934	.6173
14	.1715	.1715	.1915	.0934	.0934	.0934	.6249
15	.2572	.1715	.1943	.0943	.0934	.0934	.6249
16	.2572	.1619	.1972	.0934	.0934	.0934	.6249
17	.0934	.0934	.0495	.0943	.0934	.0934	.0591
18	.0934	.0934	.061	.0943	.0934	.0934	.0743
19	.0934	.0934	.0638	.0943	.0934	.0934	.0781
20	.0934	.0934	.0638	.0943	.0934	.0934	.0743
21	.0934	.0934	.0619	.0943	.0934	.0934	.0724
22	.0934	.0934	.0533	.0943	.0934	.0934	.0714
23	.0934	.0934	.1124	.2829	.2572	.0934	.0743
24	.0943	.0934	.0934	.1086	.1829	.2572	.0934
Max	.4525	.2572	.2429	.2829	.3506	.3429	.6249
Min	.0934	.0934	.0495	.0791	.0857	.0934	.0591
Avg	.1582	.1262	.1190	.1147	.1478	.1620	.2475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214466 / 33/11 KV BIJEWADI

Feeder No / Name : 203 / Bijawadi GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2801	.3734	.2829	.2829	.2801	.2801
2		.2801	.3734	.2829	.2829	.2801	.2801
3		.2801	.3734	.2829	.2829	.2801	.2801
4		.2801	.3734	.2829	.2829	.2801	.2801
5		.3734	.5601	.3772	.2829	.3734	.3734
6		.4668	.6535	.5601	.3772	.4668	.4668
7		.5601	.6535	.6535	.5658	.5601	.5601
8		.4668	.4668	.5601	.4525	.5601	.4668
9		.2801	.3734	.3772	.362	.4668	.3734
10		.2801	.2801	.2801	.2801	.3734	.3734
11	.1867	.2801	.2829	.2772	.2801	.2801	.2829
12	.1867	.2801	.2829	.181	.1867	.2801	.2829
13	.1867	.2801	.2829	.1848	.1867	.1867	.2829
14	.1867	.2801	.2829	.1867	.1867	.1867	.1886
15	.1867	.2801	.2829	.1867	.1867	.1867	.2829
16	.1867	.3734	.2829	.1867	.1867	.1867	.2829
17	.2801	.3734	.1886	.1867	.2801	.1867	.2829
18	.3734	.3734	.2829	.1886	.3734	.2801	.2829
19	.3734	.4668	.3772	.2829	.3734	.3734	.3772
20	.2801	.4668	.3772	.3772	.3734	.3734	.3772
21	.2801	.4668	.3772	.3772	.3734	.3734	.3772
22	.2801	.4668	.2829	.2829	.2801	.2801	.3772
23	.2801	.3734	.2829	.2829	.2801	.2801	.2829
24		.2801	.3734	.2829	.2829	.2801	.2801
Max	.3734	.5601	.6535	.6535	.5658	.5601	.5601
Min	.1867	.2801	.1886	.181	.1867	.1867	.1886
Avg	.2513	.3579	.3634	.3085	.3034	.3190	.3323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214466 / 33/11 KV BIJEWADI

Feeder No / Name : 204 / PUNKULWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239	.4858	.2429	.2829	.1619	.8907
2		.3734	.4858	.2429	.2829	.1619	.8907
3		.3239	.4858	.2429	.2829	.1619	.8907
4		.4858	.4858	.2429	.2829	.2429	.8907
5		.5668	.6478	.2429	.2829	.2429	.9717
6		.6478	.8002	.3239	.3772	.3239	1.1203
7		.8907	1.2003	.3239	.3772	.4049	1.7004
8		1.1336	1.2955	.2429	.2715	.2429	1.8404
9		.1619	.1619	1.2146	1.6289	1.2955	.1619
10		.1619	.081	1.4575	1.8861	1.5384	.1619
11	.6478	.1619	.081	.9536	1.7004	1.7004	.1619
12	.1619	.1619	.081	.964	1.8623	1.6804	.1619
13	.1619	.1619	.081	1.5775	1.7814	1.6194	.1619
14	.1619	.1619	.081	1.5604	1.7004	1.7004	.1619
15	.1619	.1619	.081	1.647	1.7004	1.7004	.1619
16	.1619	.1619	.081	1.6289	1.7004	1.6804	.1619
17	.1619	.1619	.2429	.1886	.081	.1619	.1619
18	.1619	.1619	.2429	.1886	.1619	.2429	.1619
19	.2429	.1619	.3239	.2829	.1619	.2429	.3239
20	.2429	.2429	.3239	.3772	.2429	.2429	.3239
21	.1619	.2429	.3239	.3772	.2429	.2429	.2429
22	.1619	.1619	.2429	.2829	.2429	.2429	.2429
23	.3239	.4858	.2429	.2829	.1619	.8907	1.1336
24		.3239	.4858	.2429	.2829	.1619	.8907
Max	.6478	1.1336	1.2955	1.647	1.8861	1.7004	1.8404
Min	.1619	.1619	.081	.1886	.081	.1619	.1619
Avg	.2242	.3327	.3769	.6388	.7491	.7203	.5822



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 201 / 11kv Pitkeshwer

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.373	.373		.4904	.57	.2915
2	.3772	.373	.373		.4904	.5765	
3	.415	.373	.373		.547	.57	.2743
4	.4904	.407	.407		.6036	.6104	
5	.5658	.4917	.5087		.7733	.8718	.463
6	.6413	.5868	.6274		.9431	1.1361	.6173
7	.6036	.5197	.5935	.8573	1.4146	1.2887	.6001
8	.4904	.4239	.4409	1.1145	1.4901	1.5261	
9	.5658	.6104	.5967		.4527	.3113	1.286
10	.6036		.6001		.2713	.3052	
11	.5087	.5304			.3052	.1865	
12	.4409	.5636			.2883	.2204	
13		.5801			.2713	.2374	
14	.4694	.5138			.2683	.2713	
15	.4409	.4144			.2883		
16	.4409	.4973			.2883		
17	.2543	.2543			.3185		
18	.3277	.2883			.407		
19	.3637	.407			.503		
20	.426	.39			.5079		
21	.39	.407			.503		
22	.373	.407			.4858		
23	.373	.373	.5144		.5765	.2915	
24	.3772	.373	.373	.5144	.4904	.57	
Max	.6413	.6104	.6274	1.1145	1.4901	1.5261	1.286
Min	.2543	.2543	.373	.5144	.2683	.1865	.2743
Avg	.4485	.4416	.4817	.8287	.5408	.5965	.5887

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 202 / Vyahali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6104	.6274		.5847	.5087	.4287
2	.5658	.6104	.6274		.6036	.5087	
3	.6036	.6104	.6274		.6413	.5087	.5144
4	.6602	.6443	.6443		.7167	.5426	
5	.7733	.763	.7291		.9242	.763	.6001
6	.8865	1.0343	.9835		1.1694	.8478	.7202
7	.8676	1.0513	.8478	.8573	1.6221	1.5091	.9602
8	.679	.6783	.7202	1.3717	1.5844	1.5769	.4801
9	.3961	.6783			.679	.7122	1.286
10	.4904	.7291	.7716		.3561	.3641	
11	.3391	.7625			.407	.3429	
12	.3391	.5801			.373	.3222	
13	.3391	.5138			.39	.3222	
14	.3391	.5636			.4239	.3772	
15	.3391	.547			.4578		
16	.3222	.6001			.4748		
17	.3561	.547			.3561		
18	.5596	.3601			.4239		
19	.6104	.7202			.8139		
20	.78	.7888			.8139		
21	.7042	.7373			.6783		
22	.6443	.6687			.6443		
23	.6104	.6344	.5144		.5087	.3772	
24	.5658	.5898	.6344	.4458	.5847	.4915	
Max	.8865	1.0513	.9835	1.3717	1.6221	1.5769	1.286
Min	.3222	.3601	.5144	.4458	.3561	.3222	.4287
Avg	.5557	.6676	.7025	.8916	.6763	.6297	.7128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 203 / 11KV INDAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3391	.3391	.3772	.3961	.5087	.2743
2	.3395	.3353	.3391	.3601	.3961	.5087	
3	.3961	.3391	.3391	.4115	.4338	.5087	.2572
4	.4715	.373	.373	.463	.4715	.5243	
5	.5281	.4748	.4239	.5144	.547	.6443	.2743
6	.6224	.6104	.5935	.5316	.6979	.6718	.2572
7	.4904	.5426	.5596	.8573	1.1317	1.1797	.2743
8	.4527	.4409	.4409	1.0288	1.1694	1.3565	
9	.4527	.5426	.5636		.3584	.3391	1.2003
10	.5281	.5765	.6001		.2713	.39	
11	.3561	.5138			.3052	.3315	
12	.4409	.4641			.2374	.3222	
13	.4409	.4475			.2543	.3052	
14	.3222	.4144			.2713	.3222	
15	.3052	.4641			.2883		
16	.3391	.4144			.3222		
17	.7712	.2486			.3391		
18	.373				.407		
19	.407	.3812			.4748		
20	.4111	.3978			.4424		
21	.407	.407			.4409		
22	.3561	.39			.39		
23	.3391	.3391	.3772		.5087	.2743	
24	.3395	.3391	.3391	.3772	.3961	.5087	
Max	.7712	.6104	.6001	1.0288	1.1694	1.3565	1.2003
Min	.3052	.2486	.3391	.3601	.2374	.2743	.2572
Avg	.4262	.4259	.4407	.5468	.4563	.5435	.4229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 204 / 11KV Varkute(kh)

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.8215	.9156	.8059	1.0562	.9835	1.2003
2	.9431	.8309	.8817	.8573	1.0562	.9503	
3	.9997	.8309	.8817	.8573	1.094	.9503	1.2346
4		.8648	.9496	.9431	1.1317	.9831	
5		1.0608	1.3226	.9774	1.2826	1.2717	1.3717
6		1.2209	1.7295	.9602	1.4523	1.3904	2.2291
7		1.9669	2.0178	.9431	1.4335	1.2887	3.1722
8		1.8991	1.9725			1.0343	
9	.9997	.8648	.9602		2.3765	2.2043	.9431
10	.8299	.8309	.6344		2.0348	2.7846	
11	.5765	.6952			2.1026	2.7846	
12	.6104	.5935			2.34	2.7018	
13	.6104	.5426			2.13	2.7018	
14	.6443	.5935			2.1534	2.6023	
15	.4917	.5426			2.0348		
16		.6104			1.95		
17		.6274			.6783		
18	.8648	.6952			.8139		
19	.9724	.9156			1.17		
20	1.1305	1.0174			1.1904		
21	1.1191	1.0343			1.1869		
22	1.0852	1.0343			1.0852		
23	.8309	.9665	.8573		.9835	1.2003	
24	.9431	.8309	.9665	.8573	1.0562	.9503	
Max	1.1305	1.9669	2.0178	.9774	2.3765	2.7846	3.1722
Min	.4917	.5426	.6344	.8059	.6783	.9503	.9431
Avg	.8585	.9121	1.1741	.9002	1.4693	1.6739	1.6918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 205 / Nimgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2374	.2743	.2058	.2829	.2374	.2915
2	.2263	.2374	.2572	.2229	.3018	.2294	
3	.2829	.2374	.2572	.2058	.3395	.2374	.2572
4	.3395	.2713	.2743	.2058	.3961	.2713	
5	.3961	.3391	.373		.4527	.3277	
6	.4715	.373	.5316		.4904	.407	.4973
7	.5093	.5256	.4973	.4458	.4904	.4578	.5144
8		.4024	.4115	.3944	.4338	.3932	.463
9		.373	.3601		.3018	.39	.4115
10		.3561	.3772		.373	.3561	
11		.3086			.373	.2743	
12	.3391				.3391	.3086	
13	.3222	.3429			.2713	.2915	
14	.2883	.3086			.2883	.3086	
15	.2713	.3086			.3052		
16	.2883	.2743			.3222		
17	.3222				.2883		
18	.2785	.3944			.3391		
19	.3391	.463			.39		
20	.3561	.3944			.39		
21	.3052	.3561			.3391		
22	.2713	.3429			.2949		
23	.2374	.3086	.2229		.2347		
24	.2263	.2347	.2743	.2058	.2829	.2374	
Max	.5093	.5256	.5316	.4458	.4904	.4578	.5144
Min	.2263	.2347	.2229	.2058	.2347	.2294	.2572
Avg	.3149	.3359	.3426	.2695	.3467	.3152	.4058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 206 / 11 KV Gotondi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7356	.5935	.8478	.4287	.6036	.5765	1.3717
2	.7356	.5935	.8478	.463	.6036	.5571	
3	.7922	.5935	.8478		.6413	.5571	1.406
4	.8299	.6274	.9835	.6859	.7167	.6104	
5	.9242	.7461	1.3226	.7716	.9242	.8139	
6	1.094	.8648	1.6278	.9431	1.0185	.8648	1.6289
7	1.3392	1.0682	1.8313	.8573	1.0185	.8648	2.1434
8	1.5844	.9835	1.7804	.7716	.7733	.78	2.572
9	.7167	.6274	.6687		2.2822	2.6113	.6859
10	.5281		.4973		2.1704	3.103	
11	.3561	1.0343			2.2891	3.0013	
12	.3052	.5144			2.4587	3.0691	
13	.3222	.4973			2.5434	2.967	
14		.5487			2.5774	2.8675	
15	.373	.5144			2.5095		
16	.39	.4973			2.4247		
17	.407	.4458			.4917		
18	.5426	.5144			.5365		
19	.6443	.6687			.8139		
20	.7291	.703			.7537		
21	.5935	.6859			.7122		
22	.4917	.6516			.6443		
23	.5935	.8453	.6001		.5735	1.3717	
24	.7356	.5935	.8478	.6001	.6036	.5765	
Max	1.5844	1.0682	1.8313	.9431	2.5774	3.103	2.572
Min	.3052	.4458	.4973	.4287	.4917	.5571	.6859
Avg	.6854	.6701	1.0586	.6902	1.2785	1.5745	1.6347

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 207 / Fadtare

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0302	.0271	.0203	.0257	.0226	.0197	.0257
2	.0226	.0271	.0203		.0226	.0197	
3	.0226	.0268	.0203	.024	.0226	.0197	
4	.0302	.0262	.0203		.0226	.0197	
5	.0226	.0339	.0203	.024	.0302	.0203	
6	.0302	.0271	.0203		.0226	.0203	.0326
7	.0226	.0262	.0203	.024	.0226	.0197	
8	.0226	.0271	.0271		.0226	.0203	.0206
9	.2641	.1017	.0271	.024	.2641	.2294	.2572
10	.2641	.095	.0274		.2374	.2374	
11	.2204	.1865			.2374	.2035	
12	.2204	.1696			.2374	.2238	
13	.2035	.1696			.2204	.2374	
14	.2035	.217			.2204	.0271	
15	.1865	.1715			.2204		
16	.2035	.1865			.218		
17	.2204	.1696			.0848		
18	.1696	.2306			.2204		
19	.2035	.2577			.2075		
20	.2035	.251			.1802		
21	.2204	.2543			.1357		
22	.218	.251			.1357		
23	.1696	.1763	.0257		.2035	.0206	
24	.2263	.1696	.0203	.0257	.0377	.0197	
Max	.2641	.2577	.0274	.0257	.2641	.2374	.2572
Min	.0226	.0262	.0203	.024	.0226	.0197	.0206
Avg	.1500	.1366	.0225	.0246	.1354	.0849	.0840

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 208 / 11 KV KACHARWADI.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2622	.2883	.3086	.415	.3277	.2915
2	.2452	.2622	.2883	.2915	.4527	.3239	
3	.2829	.2713	.2883	.3086	.547	.3277	.2401
4	.3395	.2949	.0203	.4115	.6036	.3605	
5	.415	.5256	.0203	.5144	.7733	.4588	
6	.6979	.6783	.6274	.6516	.8865	.5935	.3772
7	.6602	.6443	.6104	.9259	1.358	1.1191	.5144
8	.5847	.5256	.4748	.823	1.4335	1.4074	.4115
9	.5847	.5087	.5256		.4527	.4239	.9431
10	.5281	.5596	.583		.2883	.4239	
11	.407	.5256				.1865	
12	.3605	.4239				.2204	
13	.3391	.373			.2683	.2204	
14	.2883	.407			.2713	.2035	
15	.2374	.4239			.2622		
16		.407			.2713		
17	.3222	.2543			.2949		
18	.2883	.2713			.4096		
19	.2883	.5087			.5087		
20	.2883	.4748			.5898		
21	.3052	.4239			.4239		
22	.3353	.3222			.3561		
23	.2713	.2883	.3429		.3277	.2572	
24	.2641	.2622	.2883	.3258	.3772	.3239	
Max	.6979	.6783	.6274	.9259	1.4335	1.4074	.9431
Min	.2374	.2543	.0203	.2915	.2622	.1865	.2401
Avg	.3730	.4125	.3632	.5068	.5260	.4486	.4630



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214468 / 33/11KV Nimgaon Ketki

Feeder No / Name : 401 / 33 KV Sonai

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0936	1.933	1.8484	2.0576	2.2634	1.7295	1.6461
2	2.037	1.8313	1.8484	1.9033	2.2634	1.6787	
3	1.9805	1.8107	1.8484	1.5432		1.6787	1.8004
4	2.037	1.7101	1.8484	1.5947	2.2068	1.6278	
5	2.0936	1.6095	1.8484	2.0062	2.2634	1.6278	1.749
6	2.1502	1.6278	1.7364	2.0576	2.2068	1.5261	1.5947
7	1.9805	1.5261	1.5123	1.9033	2.1502	1.5769	1.3889
8	1.6975	1.3735	1.4563	1.749	1.5844	1.5769	1.3889
9	1.8107	.763	1.6804		1.1317	1.6712	1.6975
10	2.037	1.7804	1.8519		1.17	2.2405	
11	1.8821	1.7924			1.17	2.5206	
12	1.3735	1.5684			1.5769	1.7924	
13	1.4243	1.6804			1.5261	1.5123	
14	1.358	1.5123			1.3735	1.4003	
15	1.6278	1.3226			1.4243		
16	1.6221	1.4563			1.4752		
17	1.6787	1.7364			1.6278		
18	1.7295	1.7364			1.7695		
19	1.6712	1.8484			1.8313		
20	1.7295	1.9605			1.7804		
21	1.8313	1.9605			1.7295		
22	1.9839	1.9044			1.7295		
23	2.0348	1.8484	2.0576		1.7804	1.6461	
24	2.0936	2.0348	1.8484	2.0576	2.2634	1.7804	
Max	2.1502	2.0348	2.0576	2.0576	2.2634	2.5206	1.8004
Min	1.358	.763	1.4563	1.5432	1.1317	1.4003	1.3889
Avg	1.8316	1.6803	1.7821	1.8747	1.7521	1.7241	1.6094

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214502 / 33/11 KV Wadapuri

Feeder No / Name : 201 / 11 KV Vitthalwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.3224	.3761	1.0978	1.2346	1.5261	.5493
2	.2058	.3224	.394	1.1437	1.166	1.5089	.5552
3	.2058	.3077	.4525	1.2616	1.1568	1.576	.5731
4	.2454	.3439	.5068	1.4586	1.3253	1.6244	.6089
5	.3292	.439	.5731	1.5592	1.5384	1.6933	.6516
6	.5121	.8501	.8326	1.6263	1.893	2.0978	.8596
7	.5853	.8869	.9134	2.0748	2.6116	.815	.8589
8	.5194	.8596	.7712	2.3148	2.5034	.7186	.7202
9	.8817	1.4918	1.6108	.5487		.5375	.5959
10	.7682	1.4752	1.6244	.4161	.431	.463	2.4348
11	.6642	1.3923	1.7269	.2949	.3688	.4748	3.3699
12	.9922	1.3916	1.7661	.2429	.3688	.4359	3.4808
13	1.0595	1.3923	1.8004	.2429	.3018	.4475	3.6008
14		1.3748	1.8347	.2429	.3481	.4359	3.6755
15		1.2929	1.893	.2591	.3277	.4024	3.6808
16		1.2574	1.8781	.3077	.3077	.4239	3.6854
17		.3403	.3155	.3222	.4075	.5194	.4115
18		.4163	.3772	.4207	.4163	.6878	.5658
19	1.2971	.4938	.4458	.6653	.6767	.7682	.8059
20	.5194	.6283	.5258	.6838	.6089	.8501	.6706
21	.4887	.5228	.4854	.5487	.5304	.7095	.6344
22	.462	.4854	.463	.4525	.4887	.5975	.6001
23	.3801	.394	1.1065	1.1919	1.5947	.5194	.503
24	.2454	.362	.3761	1.1142	1.2346	1.5947	.5316
Max	1.2971	1.4918	1.893	2.3148	2.6116	2.0978	3.6854
Min	.2058	.3077	.3155	.2429	.3018	.4024	.4115
Avg	.5562	.7935	.9604	.8538	.9496	.8928	1.4427

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214502 / 33/11 KV Wadapuri

Feeder No / Name : 202 / 11 KV Gokhali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4477	.5552	.3605	.2058	.2543	.691
2	.4973	.4477	.5552	.3521	.2058	.2515	.6984
3	.4458	.4706	.5973	.3768	.2103	.285	.7164
4	.4557	.5068	.6154	.4144	.2686	.3315	.7522
5	.5487	.6219	.6805	.4527	.362	.3856	.8326
6	.6219	.7392	.7602	.4801	.4908	.4508	1.0387
7	.7316	.8869	1.0208	.4801	.4557	.443	1.6126
8	.7701	.9671	1.0517	.4801	.4115	.4207	1.749
9	.2883	.3772	.2883	.8573		1.3003	.3506
10	.192	.2883	.2155	.9536	1.1271	1.4746	.2058
11	.1739	.2155	.218	.9175	1.3413	1.56	.2058
12	.192	.2347	.2058	.9069	1.3748	1.643	.2229
13	.1739	.2155	.1886	.9231	1.1065	1.6409	.2229
14		.2347	.1734	.9231	1.2431	1.643	.2427
15		.2321	.1578	.9231	1.2616	1.6263	.2601
16	.2012	.218	.1949	.9231	1.2955	1.5939	.2629
17	.2374	.2507	.2229	.1865	.1772	.3045	.3086
18	.2883	.2715	.2743	.2804	.2896	.3258	.3944
19	.4031	.3475	.2629	.4251	.4024	.3658	.4801
20	.4477	.4251	.2454	.4251	.4435	.4066	.4287
21	.3801	.3921	.2683	.3841	.3475	.3734	.3944
22	.3511	.3547	.333	.3439	.3077	.3547	.3185
23	.5249	.5373	.3155	.2804	.2915	.6626	.823
24	.5083	.4887	.5373	.3768	.2401	.2743	.6733
Max	.7701	.9671	1.0517	.9536	1.3748	1.643	1.749
Min	.1739	.2155	.1578	.1865	.1772	.2515	.2058
Avg	.4067	.4238	.4141	.5595	.6026	.7655	.5786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214502 / 33/11 KV Wadapuri

Feeder No / Name : 203 / 11 KV Wadapuri GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0537	.0537	.0819	.0686	.0509	.0532
2	.0343	.0537	.0716	.0819	.0514	.0503	.0709
3	.0514	.0724	.0724	.0995	.0526	.0503	.0716
4	.0701	.0905	.0905	.1326	.0895	.0838	.0895
5	.128	.128	.1254	.1677	.1267	.1341	.1267
6	.2195	.2402	.1991	.2229	.1928	.1907	.2149
7	.2195	.1991	.2328	.1886	.1928	.1949	.1928
8	.1612	.1791	.1578	.1372	.0857	.1227	.1543
9	.1017	.1372	.1017	.1029	.1029	.104	.1227
10	.096	.1357	.0663	.0693	.0829	.1029	.1029
11	.0633	.0995	.0671	.0819	.0838	.1017	.0671
12	.08	.0671	.0514	.081	.0838	.0671	.0686
13	.0633	.0663	.0686	.0648	.0671	.0663	.0514
14		.0671	.052	.0486	.0497	.0671	.052
15		.0497		.0486	.0492	.0671	.0701
16	.1006	.0671	.0514	.081	.0648	.0848	.0701
17	.1017	.0895	.0838	.1017	.0886	.0895	.1006
18	.1017	.0724	.0838	.0701	.0905	.1086	.12
19	.1227	.0914	.0857	.1478	.128	.128	.1372
20	.1254	.1294	.0876	.1294	.1478	.1478	.1174
21	.1086	.112	.0876	.1097	.1097	.1307	.1006
22	.0934	.0934	.0686	.0905	.0905	.0934	.1006
23	.0724	.0716	.0671	.0701	.0686	.0716	.0838
24	.0526	.0724	.0537	.0819	.0686	.0686	.0532
<b>Max</b>	<b>.2195</b>	<b>.2402</b>	<b>.2328</b>	<b>.2229</b>	<b>.1928</b>	<b>.1949</b>	<b>.2149</b>
<b>Min</b>	<b>.0343</b>	<b>.0497</b>	<b>.0514</b>	<b>.0486</b>	<b>.0492</b>	<b>.0503</b>	<b>.0514</b>
<b>Avg</b>	<b>.1009</b>	<b>.1016</b>	<b>.0904</b>	<b>.1038</b>	<b>.0932</b>	<b>.0990</b>	<b>.0997</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214502 / 33/11 KV Wadapuri

Feeder No / Name : 204 / 11 kV Pingalewasti Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1612	.1612	.3277	.3429	.3052	.1949
2	.12	.1612	.1791	.3812	.3258	.3185	.1949
3	.12	.1448	.181	.4475	.333	.3688	.2149
4	.1402	.1629	.2353	.5658	.4656	.4359	.2507
5	.2195	.3475	.2865	.6344	.5792	.5533	.3258
6	.439	.5544	.5249	.7202	.7888	.6935	.5373
7	.4938	.5611	.5014	.823	1.0867	.9922	.4382
8	.394	.4835	.4382	.9259	1.1488	1.1568	.4115
9	.407	.583	.6274	.2915	.3086	.3467	.7537
10	.3361	.5765	.6299	.2254	.2652	.2572	.9602
11	.3479	.5967	.57	.1475	.1696	.2035	1.0631
12	.3841	.5197	.5658	.1296	.1006	.1677	1.166
13	.3163	.5636	.5144	.1134	.0503	.1326	1.1393
14		.4694	.5548	.1134	.0663	.1174	1.0166
15		.4475	.5316	.1296	.0983	.1341	.929
16	.3018	.4694	.5609	.1457	.1457	.1526	.8328
17	.2035	.197	.1715	.1696	.1772	.197	.1543
18	.2374	.2353	.2058	.1578	.2534	.3439	.2572
19	.3506	.2926	.2401	.3696	.3841	.3841	.3772
20	.3224	.3326	.2279	.3511	.3511	.3696	.3018
21	.2353	.2801	.2601	.2743	.2561	.2987	.2401
22	.2033	.2427	.2454	.2172	.2172	.2241	.2058
23	.181	.1791	.2683	.3155	.3086	.1791	.1677
24	.1402	.181	.1612	.2949	.3429	.3086	.1772
Max	.4938	.5967	.6299	.9259	1.1488	1.1568	1.166
Min	.12	.1448	.1612	.1134	.0503	.1174	.1543
Avg	.2733	.3643	.3684	.3447	.3569	.3600	.5129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214502 / 33/11 KV Wadapuri

Feeder No / Name : 206 / 11 kV Ramwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.6089	.7522	.5304	.4458	.3391	.9391
2	.6001	.5731	.788	.583	.3772	.3353	.9671
3	.583	.5792	.8145	.6036	.3856	.3185	1.0029
4	.5959	.6154	.8688	.6859	.5014	.4475	1.0745
5	.7682	.8962	.9313	.8048	.6878	.6539	1.1584
6	.9877	1.1643	1.267	1.0288	1.0517	1.0749	1.6118
7	1.2437	1.4661	1.576	1.0974	1.1919	1.0985	2.1033
8	1.4685	1.576	1.5775	1.0974	.8573	1.0166	2.1948
9	.8478	.823	.7122	1.406	1.5432	1.8378	.8413
10	.6401	.8309	.5304	1.5775	1.6244	1.9204	.5487
11	.4902	.6962	.4694	1.6057	1.8442	2.0348	.5144
12	.4481		.3772	1.4899	1.9448	1.9784	.583
13	.3795		.4115	1.587	1.6766	1.9393	.631
14		.6371	.4207	1.587	1.7238	1.9784	.5959
15		.5636	.3856	1.5546	1.7532	1.8778	.5609
16	.4359	.503	.4252	1.5223	1.7814	1.7804	.4961
17	.5426	.5014	.5487	.4748	.5316	.6447	.5487
18	.6443	.6516	.5144	.5959	.7783	.8326	.6371
19	.964	.695	.5487	.8871	.9877	.8779	.9259
20	.7701	.7762	.6036	.8871	.8871	.924	.8383
21	.6697	.6348	.583	.7316	.6767	.7842	.6516
22	.6099	.5601	.4801	.6154	.5792	.6722	.5365
23	.6516	.7164	.4115	.5258	.4458	.8954	.9054
24	.6661	.6516	.7522	.4588	.4801	.4115	.9214
Max	1.4685	1.576	1.5775	1.6057	1.9448	2.0348	2.1948
Min	.3795	.5014	.3772	.4588	.3772	.3185	.4961
Avg	.7110	.7600	.6979	.9974	1.0315	1.1114	.9078

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214504 / 33/11 kV Agoti

Feeder No / Name : 201 / 11 KV CHITALKARWADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0171	.0189	.0183	.0914	.0724	.0171
2	.0183	.0171	.0189	.0366	.0732	.0724	.0171
3	.0183	.0171	.0189	.0366	.0732	.0724	.0171
4	.0183	.0171	.0189	.0366	.0914	.0724	.0171
5	.0183	.0343	.0377	.0549	.0732	.0905	.0343
6	.0377	.0514	.0377	.0549	.0732	.0905	.0343
7	.0366	.0514	.0377	.0549	.0732	.181	.0343
8	.0366	.0343	.0189	.0914	.128	.181	.0343
9	.0732	.0343	.0724	.0183	.0183	.0189	.3601
10		.0724	.0914		.0189	.0189	.5716
11	.0857	.0724	.0914		.0189	.0171	.5716
12	.0686	.0543	.1097	.0183	.0189	.0171	.5906
13	.0686	.0543	.0914	.0183	.0189	.0171	.5716
14	.0686	.0362	.0732	.0183	.0189	.0171	.5716
15		.0362	.0914	.0183	.0189	.0171	.5716
16		.0543	.0732	.0183	.0189	.0171	.5716
17	.0343	.0189	.0183	.0183	.0189	.0171	.0191
18	.0343	.0377	.0183	.0183	.0189	.0343	.0191
19	.0343	.0189	.0183	.0183	.0189	.0343	.0381
20	.0343	.0189	.0366	.0366	.0189	.0171	.0381
21	.0343	.0189	.0366	.0366	.0189	.0171	.0381
22	.0343	.0189	.0183	.0366	.0189	.0171	.0191
23	.0343	.0189	.0183	.0732	.0724	.0171	.0191
24	.0183	.0171	.0189	.0183	.0732	.0724	.0171
Max	.0857	.0724	.1097	.0914	.128	.181	.5906
Min	.0183	.0171	.0183	.0183	.0183	.0171	.0171
Avg	.0393	.0343	.0452	.0341	.0453	.0500	.1997

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214504 / 33/11 kV Agoti

Feeder No / Name : 202 / 11 KV LAXMI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0686	.0566	.0549	.128	.1448	.0514
2	.1097	.0686	.0566	.0549	.1646	.1448	.0514
3	.1097	.0686	.0566	.0549	.1463	.1448	.0514
4	.128	.0686	.0566	.0366	.1463	.1448	.0514
5	.128	.0686	.0566	.0549	.128	.1448	.0514
6	.1097	.0686	.0566	.0549	.1463	.1448	.0514
7	.128	.0514	.0566	.0732	.1463	.1629	.0514
8	.1097	.0514	.0377	.0549	.1646	.1629	.0343
9	.2195	.0514	.0362	.0366	.0366	.0566	.3086
10	.0857	.0543	.0366	.0366	.0566	.0566	.5335
11	.0686	.0543	.0366	.0366	.0566	.0343	.5716
12	.0686	.0543	.0366	.0377	.0566	.0343	.5716
13	.0686	.0543	.0366	.0366	.0566	.0343	.6097
14	.0686	.0362	.0366	.0366	.0566	.0343	.6668
15	.0686	.0362	.0366	.0366	.0566	.0514	.724
16	.0686	.0362	.0366	.0366	.0566	.0514	.5716
17	.0857	.0566	.0549	.0366	.0754	.0514	.1905
18	.0686	.0566	.0549	.0549	.0754	.0514	.1905
19	.0686	.0566	.0549	.0732	.0754	.0514	.1905
20	.0686	.0566	.0732	.0732	.0754	.0686	.1905
21	.0686	.0566	.0549	.0914	.0754	.0686	.1905
22	.0686	.0566	.0732	.0914	.0754	.0686	.1905
23	.0686	.0566	.0732	.128	.1267	.0514	.1905
24	.128	.0686	.0566	.0549	.128	.1448	.0514
Max	.2195	.0686	.0732	.128	.1646	.1629	.724
Min	.0686	.0362	.0362	.0366	.0366	.0343	.0343
Avg	.0948	.0565	.0509	.0557	.0963	.0877	.2640



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214504 / 33/11 kV Agoti

Feeder No / Name : 203 / 11 KV TALEMALA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.2058	.181	.2561	.2012	.181	.6859
2	.3292	.1886	.181	.2743	.2012	.181	.6859
3	.3292	.2058	.181	.2926	.1829	.181	.6859
4	.3292	.2058	.181	.3109	.2012	.2172	.6859
5	.3109	.2058	.181	.3292	.2195	.2534	.6859
6	.3475	.2058	.2172	.2195	.2378	.3258	.7716
7	.3475	.2572	.362	.2012	.2743	.2896	.8745
8	.3475	.2915	.3258	.1829	.2263	.2353	.8745
9	.1829	.1715	.1448	.3292	.5121	.6796	.1715
10	.1715	.1753	.128	.3395	.547	.7625	
11	.1715	.1402	.1463	.439	.6464	.8573	
12	.1372	.1578	.128	.4572	.6962	.8573	.1905
13	.1715	.1402	.1463	.4572	.6962	.8573	.1905
14	.1715	.1402	.1646		.7293	.8573	.1905
15	.1372	.1402	.1829		.7127	.9088	.1905
16	.1372	.1402	.1829	.439	.7459	.9088	.1905
17	.1543	.1578	.1829	.5121	.181	.12	.2858
18	.2058	.1928	.2012	.2012	.1991	.1715	.2858
19	.2058	.1991	.1829	.1829	.2172	.1715	.2858
20	.2058	.1991	.2012	.2195	.2172	.1715	.2858
21	.1715	.181	.2012	.2012	.2172	.1543	.2858
22	.1715	.1629	.2012	.2012	.2172	.1543	.1905
23	.1886	.181	.2378	.1829	.1991	.6344	.724
24	.3109	.2058	.181	.2378	.1829	.181	.6859
Max	.3475	.2915	.362	.5121	.7459	.9088	.8745
Min	.1372	.1402	.128	.1829	.181	.12	.1715
Avg	.2311	.1855	.1926	.2939	.3609	.4297	.4593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214504 / 33/11 kV Agoti

Feeder No / Name : 204 / 11 KV GOLEWASTI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1715	.1267	.128	.1097	.1086	.3429
2	.1829	.1715	.1267	.1463	.128	.1086	.3429
3	.2012	.1715	.1267	.1463	.1646	.1086	.3429
4	.2012	.2058	.1448	.1829	.1463	.1267	.3429
5	.2012	.2229	.181	.2012	.1646	.181	.3772
6	.2195	.2229	.2715	.2012	.1829	.2172	.3772
7	.2195	.2229	.2715	.2012	.1886	.1991	.3772
8	.2058	.2229	.2172	.1463	.1646	.2172	.4287
9		.1029	.0905	.1829	.1829	.3429	.1715
10		.1052	.0914	.2012	.2743	.3429	.1524
11	.1372	.0876		.1829	.3086	.4287	.1524
12	.0857	.0876	.0914	.1829	.3429	.4287	.1524
13		.0876	.0732	.1829	.3429	.4287	.1524
14	.0857	.0526	.0914	.1829	.3429	.4287	.1524
15	.1372	.0526	.0732	.1829	.2915	.4287	.1524
16	.1029	.0526	.0366	.1698	.3258	.4287	.1524
17	.1029	.0701	.0732	.1097	.1086	.1715	.1524
18	.0857	.1086	.0914	.128	.1267	.2058	.2286
19	.0857	.1448	.1097	.1463	.181	.2058	.2858
20	.12	.1448	.1463	.128	.181	.2058	.2858
21	.0857	.1267	.128	.1463	.1267	.1715	.2858
22	.12	.1086	.1463	.1097	.1267	.1372	.1905
23	.1372	.1267	.132	.1097	.1086	.2915	.381
24	.1463	.1715	.1267	.1097	.1097	.1086	.3429
Max	.2195	.2229	.2715	.2012	.3429	.4287	.4287
Min	.0857	.0526	.0366	.1097	.1086	.1086	.1524
Avg	.1442	.1351	.1290	.1587	.1971	.2509	.2635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214504 / 33/11 kV Agoti

Feeder No / Name : 205 / 11 KV GUNAWAREWASTI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.1715	.1886	.2012	.3109	.3086	.1715
2	.2378	.1715	.1886	.2012	.3109	.3086	.1715
3	.2195	.1715	.1886	.2195	.3475	.3429	.1715
4	.2195	.2058	.1886	.2195	.3841	.3772	.1715
5	.2561	.2058	.2641	.3109	.3841	.3944	.1715
6	.2743	.2572	.3395	.3292	.4207	.4973	.1715
7	.2926	.2572	.3018	.3475	.4938	.4287	.2058
8	.3292	.2401	.2452	.4207	.5121	.5316	.2058
9	.3475	.2572	.3439	.1829	.1646	.132	.5487
10	.1715	.2572	.2926		.1509	.0754	.724
11	.1715	.3258	.2561		.1132	.0686	.7621
12	.1372	.2915	.2743	.0914	.0754	.0686	.8573
13	.1715	.2743	.2561	.0914	.0754	.0686	.8573
14	.1715	.2401	.2561	.0732	.0943	.0686	.8573
15		.2401	.2561	.0914	.0754	.0686	.8573
16		.2743	.2378	.0732	.0943	.0686	.8573
17	.1372	.12	.1132	.128	.1698	.0857	.1524
18	.2229	.1698	.128	.1463	.1698	.1372	.2096
19	.2229	.2263	.1646	.1646	.2263	.1372	.2858
20	.2058	.2263	.2012	.1829	.2263	.1715	.2858
21	.1715	.2075	.2195	.2012	.2075	.1715	.2858
22	.1715	.2075	.2012	.2012	.2263	.1715	.2096
23	.1543	.1886	.1829	.2743	.3086	.1715	.1905
24	.2195	.1715	.1886	.1829	.2743	.2984	.1715
Max	.3475	.3258	.3439	.4207	.5121	.5316	.8573
Min	.1372	.12	.1132	.0732	.0754	.0686	.1524
Avg	.2148	.2233	.2282	.1970	.2424	.2147	.3980

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214504 / 33/11 kV Agoti

Feeder No / Name : 207 / AGOTHI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0514	.0566	.0549	.0549	.0377	.0514
2	.0549	.0514	.0566	.0549	.0549	.0377	.0686
3	.0549	.0514	.0566	.0732	.0732	.0377	.0686
4	.0732	.0686	.0754	.0732	.0732	.0566	.0857
5	.0732	.0857	.0754	.0914	.0914	.0754	.1029
6	.1097	.0857	.0943	.0914	.0914	.1132	.1029
7	.1097	.0857	.0943	.0914	.0914	.0943	.0686
8	.0914	.0686	.0754	.0914	.0914	.0566	.0686
9	.0732	.0514	.0377	.0549	.0732	.0566	.0514
10		.0754	.0366	.0366	.0566	.0566	.0381
11	.0343	.0377	.0366	.0366	.0189	.0343	.0381
12	.0343	.0377	.0366	.0343	.0377	.0343	.0381
13	.0343	.0377	.0183	.0366	.0189	.0343	.0381
14	.0343	.0377	.0366	.0366	.0189	.0343	.0381
15	.0343	.0377	.0366	.0366	.0189	.0343	.0381
16	.0343	.0377	.0366	.0366	.0377	.0343	.0381
17	.0343	.0189	.0366	.0549	.0377	.0343	.0381
18	.0514	.0377	.0366	.0549	.0377	.0514	.0381
19	.0686	.0566	.0566	.0732	.0377	.0686	.0572
20	.0686	.0566	.0566	.0732	.0566	.0686	.0572
21	.0514	.0566	.0549	.0732	.0566	.0686	.0572
22	.0514	.0566	.0549	.0732	.0566	.0514	.0572
23	.0514	.0566	.0549	.0549	.0377	.0514	.0572
24	.0549	.0514	.0566	.0549	.0366	.0377	.0514
Max	.1097	.0857	.0943	.0914	.0914	.1132	.1029
Min	.0343	.0189	.0183	.0343	.0189	.0343	.0381
Avg	.0580	.0539	.0528	.0601	.0525	.0525	.0562

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION

Feeder No / Name : 201 / 11 KV REDANI AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5658	.6401	.8192	.8192	.9326	.5716
2	.5487	.5487	.6401	.8192	.8192	.9326	.5716
3	.6535	.5487	.6135	.8288	.8288	.9326	.5716
4	.6401	.5487	.6201	.9012	.9831	1.0774	.5716
5	.7545	.6535	.7316	.9945	1.0774	1.1203	.6468
6	.8488	.7545	.823	1.3927	1.326	1.3117	.823
7	.9431	1.0479	.9145	1.6575	1.8842	1.9052	.8059
8	.8488	.8488	.7316	1.6385	1.8623	1.929	.7392
9	.9431	1.0526	.8592	.6668	.6001	.6468	1.3603
10	.7811	1.1336	1.0155	.4525	.5658	.462	1.5813
11	.7907	1.0526	1.0669	.3544	.462	.381	1.5813
12	.7907	.9831	1.0536	.3086	.381	.2858	1.4403
13	.7811	.9717	.9536	.2343	.381	.2858	1.2955
14	.8097	.8097	.9659	.2858	.2858	.2858	1.2803
15	.8097	.7811	1.0269	.2858	.2858	.3696	1.1069
16	.6249	.7287	.9783	.3201	.381	.462	1.1069
17	.4715	.3658	.3086	.3201	.4477	.462	.3734
18	.5601	.4572	.543	.4049	.5544	.5716	.5487
19	.8573	.6335	.7392	.7888	.7392	.6668	.8488
20	.8573	.7316	.7316	.8145	.7316	.6602	.7545
21	.7545	.7316	.6401	.6335	.6268	.5716	.6602
22	.6535	.6201	.6335	.6401	.6468	.5716	.6602
23	.5601	.6401	.8478	.8192	.9326	.5716	.6602
24	.5601	.5601	.6401	.8192	.8192	.9431	.5716
Max	.9431	1.1336	1.0669	1.6575	1.8842	1.929	1.5813
Min	.4715	.3658	.3086	.2343	.2858	.2858	.3734
Avg	.7251	.7404	.7799	.7167	.7684	.7641	.8805

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION

Feeder No / Name : 202 / 11 KV BORATWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.463	.5087	.1715	.1905	.1486	.7811
2	.4687	.4744	.4915	.1696	.1905	.1505	.8192
3	.4744	.4687	.4915	.1696	.1905	.1562	.8002
4	.4801	.4687	.4915	.1658	.2858	.2229	.8002
5	.6602	.5468	.5801	.2486	.381	.2896	.9831
6	.6478	.6249	.6706	.2543	.4763	.3906	1.0402
7	.8097	.8097	.8097	.2486	.381	.2972	1.1203
8	.7907	.8697	.9717	.2858	.2858	.2896	1.2289
9	.1886	.1715	.1619	.9259	1.2955	1.7404	.2172
10		.1753	.0791	1.2498	1.6108	2.2405	.1905
11	.1886	.1753	.0762	1.5023	2.0005	2.1091	
12			.0638	1.448	1.8404	2.0805	
13	.0914	.1829	.0657	1.406	1.6804	2.0309	
14	.0934	.1829	.0695	1.5623	1.5746	2.1548	.0943
15	.0943	.0914	.0695	1.7604	1.6804	1.709	.0943
16	.1886	.0914	.0638	1.6289	1.6575	1.5604	.0934
17	.1886	.1829	.12	.1734	.12	.1448	.1867
18	.2858	.1829	.1543	.1772	.1276	.1562	.1886
19	.381	.2743	.1581	.2715	.1915	.2343	.2829
20	.2858	.2743	.2401	.2286	.2629	.2115	.2858
21	.2829	.2572	.1753	.2343	.2229	.2172	.1886
22	.2801	.1829	.1772	.2343	.2229	.2143	.1886
23	.4572	.5144	.1905	.1905	.1448	.7811	.7716
24	.463	.4572	.5087	.1696	.1905	.1505	.8192
Max	.8097	.8697	.9717	1.7604	2.0005	2.2405	1.2289
Min	.0914	.0914	.0638	.1658	.12	.1448	.0934
Avg	.3756	.3532	.3079	.6199	.7169	.8200	.5321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION

Feeder No / Name : 203 / 11 KV REDANI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1886	.1829	.1886	.1886	.1791	.1867
2	.1867	.1886	.1829	.1886	.1886	.1753	.1867
3	.1867	.1886	.1867	.1867	.2801	.1829	.1867
4	.2801	.2829	.2801	.2829	.2829	.2801	.2801
5	.3772	.3772	.3658	.2829	.3734	.3696	.3734
6	.4715	.4668	.4572	.3772	.4715	.4668	.4668
7	.4715	.4715	.4572	.3772	.4715	.462	.3734
8	.4668	.2829	.3658	.2829	.3772	.3734	.3734
9	.3772	.3658	.2829	.2829	.1886	.2772	.2801
10	.2743	.2743	.2772	.2801	.1848	.1867	.2801
11	.2801	.2743	.1867	.1886	.1791	.1867	
12	.1867	.2743	.1848	.181	.1867	.1867	.1867
13	.1886	.1829	.1848	.181	.1848	.1848	.1867
14	.1886	.2743	.1886	.181	.2801	.1867	.1867
15	.1867	.3772	.1886	.1791	.2801	.1867	.1867
16	.2801	.3658	.1867	.1829	.2772	.1829	.1867
17	.2801	.2743	.2629	.1867	.2801	.2772	.2801
18	.3772	.1886	.2829	.2829	.3696	.2772	.3734
19	.3772	.3772	.3772	.3772	.462	.3734	.3772
20	.2829	.3658	.362	.3734	.3734	.2801	.3772
21	.2829	.2743	.2772	.2829	.3734	.2801	.2801
22	.2801	.2829	.2829	.1886	.2772	.2772	.1867
23	.1867	.2829	.2743	.2743	.1867	.1867	.1867
24	.1886	.1867	.1829	.1886	.1886	.1791	.1867
Max	.4715	.4715	.4572	.3772	.4715	.4668	.4668
Min	.1867	.1829	.1829	.1791	.1791	.1753	.1867
Avg	.2852	.2945	.2692	.2491	.2878	.2583	.2682

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION

Feeder No / Name : 204 / 11 KV Lakhewadi

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6602	.6401	.9602	1.1336	1.4114	.6455
2		.6468	.5853	.9602	1.1336	1.3931	.6455
3		.5944	.6535	.9717	1.1336	1.3656	.6455
4		.7468	.7316	1.0774	1.2289	1.4186	.6521
5		.823	.823	1.2431	1.3108	1.4952	.8402
6		.9335	.9145	1.4251	1.5746	1.6556	1.0311
7		.9335	.9145	1.5927	2.0243	1.8755	.9345
8		.7468	.7973	1.5384	2.1862	2.1965	.8385
9	.9488	1.2146	1.2498	.5544	.6401	.6455	2.0648
10	1.0526	1.2955	1.4232	.443		.5533	2.5101
11	1.1336	1.2955	1.3717	.2629	.3727	.4644	2.8121
12		1.2955	1.2955		.3749	.4611	2.8807
13	1.1336	1.2955	1.2631	.3353	.3688	.3749	2.3482
14	1.0155	1.2498	1.2041	.3315	.3711	.3757	2.7206
15	.9374	1.2955	1.1288	.2429	.3727	.3727	2.6882
16	.8697	1.2955	1.0669	.2401	.4658	.3605	2.5301
17	.3658	.3658	.3125	.3239	.4696	.4658	.4668
18	.5601	.4572	.5316	.4144	.6501	.5516	.5658
19	.7545	.6401	.724	.724	.743	.743	.6535
20	.8488	.7011	.724	.724	.8436	.7407	.8402
21	.7316	.7316	.6401	.6401	.7377	.7453	.7316
22	.6401	.6401	.6335	.5487	.6455	.6435	.7545
23	.6535	.6401	.9717	1.1336	1.3503	.6562	.7545
24		.6401	.6401	4.0085	1.1203	1.4114	.6528
Max	1.1336	1.2955	1.4232	4.0085	2.1862	2.1965	2.8807
Min	.3658	.3658	.3125	.2401	.3688	.3605	.4668
Avg	.8318	.8808	.8850	.8998	.9240	.9324	1.3420



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214505 / 33/11 kV REDANI SUBSTATION

Feeder No / Name : 205 / BHODANI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2972	.301	.3277	.1848	.1829	.188	.3749
2	.301	.3048	.3239	.1848	.1829	.1858	.3387
3	.3048	.3048	.3277	.181	.181	.1839	.3296
4	.3048	.3086	.3239	.1848	.2715	.2766	.4077
5	.3906	.3906	.4096	.2715	.3658	.4611	.5641
6	.4744	.4801	.503	.362	.4525	.5516	.876
7	.4744	.4744	.6478	.5014	.3658	.4615	.9351
8	.5468	.6478	.7287	.362	.2743	.4658	.8676
9	.3734	.3658	.2801	.5401	.7526	.845	.2786
10	.2801	.3658	.2829	.7335	.9064	.92	.2829
11	.1886	.2743	.2829	.6516	.9934	.8802	.2801
12		.2743	.1886	.643	.8865	.824	.2801
13		.2743	.1867	.4934	.9106	.8154	.1829
14		.2658	.1886	.5639	.8345	.824	.1886
15	.1867	.2743	.1886	.4287	.8135	.7682	.1886
16	.1886	.2743	.1867		.745	.6622	.1867
17	.2801	.2743	.1867	.1734	.2849	.1844	.2801
18	.2829	.2743	.2772	.1886	.3757	.2766	.2801
19	.3772	.3658	.3734	.2801	.4706	.3688	.3734
20	.3772	.3658	.3734	.3772	.3768	.3765	.3772
21	.3734	.3658	.2772	.2715	.3749	.2766	.3772
22	.2829	.2743	.2772	.2829	.2824	.2824	.3772
23	.3734	.3239	.1829	.1829	.1844	.3563	.3906
24	.2972	.2972	.3239	.1848	.181	.1882	.3414
Max	.5468	.6478	.7287	.7335	.9934	.92	.9351
Min	.1867	.2658	.1829	.1734	.181	.1839	.1829
Avg	.3312	.3384	.3187	.3577	.4854	.4843	.3900

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214526 / 33 KV Tannu

Feeder No / Name : 201 / Chavanwasti AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.6097	.4049	.2629	.3441	.2715	1.286
2	.8383	.6859	.4049	.2629	.3801	.362	1.2193
3	.7621	.6859	.4525	.2629	.3441	.362	1.2193
4	.9755	.6859	.724	.2629	.3801	.362	1.2955
5	.9755	.6859	.6478	.362	.3239	.4525	1.5432
6	.9755	.6859	.6478	.4525	.3239	.4525	1.448
7	1.0669	.9145	.8402	.4525	.2534	.4287	1.5242
8	1.2308	.8383	.8962	.4557	.362	.3429	1.5242
9	.2105	.3048	.3086	.8097	1.086	1.1431	.3429
10	.2572	.2743	.2427	.9717	1.1336	1.2193	.3258
11	.2572	.2429	.1867	1.1203	1.166	1.2955	.2896
12	.2572	.2429	.1494	.8907	1.2146	1.3717	.2715
13	.2572	.1619	.1867	.9717	1.2631	1.3717	.2172
14		.1638	.2241	1.1317	1.2955	1.3717	.2353
15		.2458	.2241	1.0269	1.3279	1.448	.2353
16	.2572	.2458	.2054	.8097	1.2193	1.448	.3045
17	.3429	.3734	.2801	.2429	.3982	.3429	.394
18	.3429	.3439	.4481	.3239	.362	.4287	.4477
19	.3429	.3439	.4525	.3239	.4525	.4287	.4656
20	.4287	.2896	.4525	.4572	.543	.4287	.4706
21	.4287	.2896	.4163	.2591	.4525	.3429	.4298
22	.2572	.2896	.3801	.2591	.362	.3429	.3582
23	.5335	.4534	.2534	.3658	.2743	1.0669	1.2146
24	.8383	.6097	.4694	.2715	.3239	.2715	1.1431
Max	1.2308	.9145	.8962	1.1317	1.3279	1.448	1.5432
Min	.2105	.1619	.1494	.2429	.2534	.2715	.2172
Avg	.5761	.4445	.4124	.5421	.6494	.7232	.7586

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214526 / 33 KV Tannu

Feeder No / Name : 202 / Tannu Ag1

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0857	.0838	.0747	.2429	.1524	.0857
2	.0934	.0857	.081	.0716	.2429	.1524	.0857
3	.0934	.1715	.081	.0716	.2429	.2286	.0857
4	.0934	.1715	.081	.0886	.2715	.2286	.0857
5	.0934	.1715	.0629	.0876	.2591	.2286	.1715
6	.0934	.1715	.081	.1029	.2926	.2286	.1715
7	.0934	.1715	.1006	.12	.4049	.2572	.1715
8	.0358	.1715	.0543	.1372	.3439	.1524	.0857
9	.4049	.2572	.1029	.1677	.1006	.1715	.2286
10	.381	.2429	.0934	.081	.0895	.1715	.4115
11	.3429	.2172	.112	.0934	.0716	.0857	.4115
12	.3048	.2012	.1494	.081	.0537	.0857	.4801
13	.3048	.2012	.1494	.0838	.0724	.0857	.5487
14	.3429	.1802	.112	.0905	.0724	.0857	.6001
15	.3048	.1086	.0934	.081	.0543	.0857	.6344
16	.3048	.0972	.0934	.081	.0724	.0857	.6299
17	.0857	.0732	.0747	.0819	.0905	.0857	.1254
18	.0857	.0838	.0934	.1134	.0905	.0857	.1791
19	.1715	.0905	.0934		.181	.1715	.2149
20	.1715	.0362	.112		.181	.1715	.2149
21	.1715	.0362	.112		.181	.1715	.181
22	.1715	.0362	.112		.0905	.1715	.1254
23	.0762	.0366	.0724		.1524	.0857	.0895
24	.0934	.0857	.0373	.0701	.1619	.1524	.0857
Max	.4049	.2572	.1494	.1677	.4049	.2572	.6344
Min	.0358	.0362	.0373	.0701	.0537	.0857	.0857
Avg	.1836	.1327	.0933	.0936	.1674	.1492	.2543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214526 / 33 KV Tannu

Feeder No / Name : 203 / Narsinghpur

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2286	.2515	.2686	.2429	.381	.3429
2	.2743	.3429	.2429	.2629	.2743	.381	.4287
3	.2743	.3429	.2743	.2629	.2915	.381	.4287
4	.362	.4287	.4858	.3086	.2915	.4572	.4287
5	.5144	.4287	.4858	.3429	.3048	.4572	.5144
6	.3658	.5144	.4915	.3772		.4572	.5144
7	.5144	.5144	.3734	.4115	.4525	.4572	.5144
8	.4049	.4287	.4359	.3856	.3239	.5144	.4287
9	.2429	.4287	.2614	.2429	.181	.3429	.5144
10	.3048	.3353	.3601	.2429	.2149	.2572	.6371
11	.3429	.3353	.3086	.2429	.2328	.2572	.6796
12	.381	.3239	.2454	.2429	.2149	.1715	.6796
13	.381	.362	.2629		.181	.1715	.6796
14	.3429	.3239	.298	.2429	.181	.1715	.6962
15	.3048	.2915	.298	.2429	.2534	.2572	.7459
16	.3048	.3395	.3801	.1619	.2534	.2572	.7701
17	.2286		.2715	.2429	.3439	.3429	.3224
18	.2572	.2429	.3174	.2267	.362	.3429	.3582
19	.3048	.3506	.3801	.3734	.4525	.3429	.4298
20	.4287	.362	.4525	.5228	.4525	.4287	.4344
21	.3048	.362	.3982	.1943	.362	.4287	.4119
22	.3429	.3506	.362	.2241	.362	.3429	.3761
23	.2572	.2515	.2801	.3734	.2134	.3429	.333
24	.2801	.2572	.2458	.2658	.362	.3048	.3429
Max	.5144	.5144	.4915	.5228	.4525	.5144	.7701
Min	.2286	.2286	.2429	.1619	.181	.1715	.3224
Avg	.3331	.3542	.3401	.2897	.2958	.3437	.5005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214526 / 33 KV Tannu

Feeder No / Name : 204 / Girve2

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4572	.4858	.2149	.2715	.2715	.9145
2	.5144	.5144	.4858	.2149	.2715	.2715	.9145
3	.5144	.5335	.5601	.2149	.2172	.362	.9907
4	.6706	.6001	.4915	.2149	.2241	.362	1.1145
5	.5144	.6001	.5601	.2686	.213	.362	1.2003
6	.6706	.6001	.5601		.2743	.362	1.0669
7	.6036	.6859	.6554	.3856	.1781	.3429	1.2003
8	.5668	.6097	.5788	.3582	.2896	.3429	1.0669
9	.2915	.3048	.2427	.6478	.5573	.9145	.2572
10	.2572	.1867	.1448	.7373	.9012	.9907	.2172
11	.1715	.1677	.1448	.8097	.9175	1.0669	.181
12	.1715	.1619	.1402	.8097	.9831	1.0669	.181
13	.1715	.0648	.1402	.7287	.9145	1.2003	.181
14	.1715	.0648	.1402	.8402	.9145	1.0669	.181
15	.1715	.112	.1402	.6478	.9297	1.2003	.1448
16	.2572	.1006	.1307	.6478	.9145	1.2003	.181
17	.2572	.1457	.1867	.3292	.2172	.2572	.2865
18	.2572	.1457	.2614	.1677	.181	.2572	.3258
19	.2572	.1753	.362		.2715	.2572	.3258
20	.3429	.181	.3439		.2715	.2572	.3258
21	.2572	.181	.2715		.181	.2572	.2591
22	.2572	.1267	.2427		.1715	.2572	.2715
23	.4287	.543	.2801		.2172	.7621	.8288
24	.5144	.4572	.4858	.2103	.1619	.2715	.8383
Max	.6706	.6859	.6554	.8402	.9831	1.2003	1.2003
Min	.1715	.0648	.1307	.1677	.1619	.2572	.1448
Avg	.3669	.3217	.3348	.4693	.4435	.5817	.5606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR

Feeder No / Name : 201 / 11 KV KHADI CRASHER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0667		.0259	.5716	.0667	
2	.0953	.0667		.0259		.0667	
3	.0953	.0667		.0259	.724	.0667	
4		.0667		.0259		.0667	
5	.0953	.0667		.0324	.9526	.0667	
6	.0953	.0667		.0324	.9526	.0667	
7	.0953	.0667		.0324	1.0288	.0667	
8	.0953	.0667		.0324	1.1431	.0667	
9		.0667		.0324	.0953	.0667	
10	.0953	.0667		.0324	.0953	.0667	
11	.0667		.0259		.0667		.0324
12	.0667		.0324	.0953	.0667		.0324
13	.0667		.0324		.0667		.0324
14	.0667		.0324		.0667		.0324
15	.0667		.0324		.0667		.0324
16	.0667		.0324	.0953	.0667		.0324
17	.0667		.0259	.0762	.0667		.0324
18	.0667		.0324	.0762	.0667		.0324
19	.0667		.0194		.0667		.0324
20	.0667		.0194	.0762	.0667		.0324
21	.0667		.0259		.0667		.0324
22	.0667		.0259		.0667		.0324
23	.0667		.0194		.0667		.0324
24	.0953	.0667		.0259	.5716	.0667	
Max	.0953	.0667	.0324	.0953	1.1431	.0667	.0324
Min	.0667	.0667	.0194	.0259	.0667	.0667	.0324
Avg	.0776	.0667	.0274	.0464	.3183	.0667	.0324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR

Feeder No / Name : 202 / 11KV BORATEWADI NHAVI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		.7716	.2743
2			.7716	.2743
3	.4572		.7716	.2743
4	.5335		.8402	.3086
5	.5716		.9088	.3086
6			.9259	.3429
7	.6478		.8745	.3944
8	.724		1.046	.3772
9	.2667	.3429		1.0288
10	.1905		.2229	1.3375
11	.2286	.2229	.2229	1.0364
12	.1905	.2229	.2401	1.2955
13		.2401	.2401	1.3279
14		.2743	.2401	1.3603
15		.2572	.2743	1.3603
16		.2401	.2743	1.4251
17		.2743	.3086	.1943
18	.3048	.2915	.3086	.2915
19		.3086	.3429	.3563
20	.4191	.3429	.3429	.3887
21		.3601	.3429	.2267
22		.3772	.3429	.2267
23		.6173	.3086	.2267
24	.4572		.6859	.2743
Max	.724	.6173	1.046	1.4251
Min	.1905	.2229	.2229	.1943
Avg	.4191	.3123	.5047	.6213

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR

Feeder No / Name : 203 / 11 KV TONTECH FEEDER

SHEDDABLE FEEDER MIDC EQUIVALENT

Feeder KV- 11 / OUTGOING

HAVING WEEKLY STAGGERING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0095	.0191	.0114	.0191	.0229	
2		.0095	.0191	.0114		.0229	
3	.0191	.0095	.0191	.0114	.0191	.0229	
4		.0095	.0191	.0114		.0229	
5	.0191	.0095	.0191	.0114	.0191	.0229	
6	.0191	.0095	.0191	.0114	.0191	.0229	
7	.0191	.0095	.0191	.0114	.0191	.0229	
8	.0191	.0095		.0114	.0191	.0229	
9		.0095		.0114	.0191	.0229	
10	.0191	.0095		.0114	.0191	.0229	
11	.0095	.0191	.0114		.0229		.0114
12	.0095	.0191	.0114	.0381	.0229		.0114
13	.0095	.0191	.0114		.0229		.0114
14	.0095	.0191	.0114		.0229		.0114
15	.0095	.0191	.0114		.0229		.0107
16	.0095	.0191	.0114	.0381	.0229		.0114
17	.0095	.0191	.0114	.0381	.0229		.0114
18	.0095	.0191	.0114	.0381	.0229		.0114
19	.0095	.0191	.0114		.0229		.0114
20	.0095	.0191	.0114	.0381	.0229		.0114
21	.0095	.0191	.0114		.0229		.0114
22	.0095	.0191	.0114		.0229		.0114
23	.0095	.0191	.0114		.0229		.0114
24	.0191	.0095	.0191	.0114	.0191	.0229	
Max	.0191	.0191	.0191	.0381	.0229	.0229	.0114
Min	.0095	.0095	.0114	.0114	.0191	.0229	.0107
Avg	.0132	.0147	.0143	.0197	.0213	.0229	.0113



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR

Feeder No / Name : 204 / 11 KV KAUTHALI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.2743	.2439	.3239	.6478	.4801	.3086
2		.2915	.2439	.3239		.6001	.3086
3	.5716	.2915	.2439	.3239	.7621	.6859	.3086
4		.3429	.2743	.3239		.7545	.3429
5	.5716	.4115	.3772	.3887	.9907	.7888	.4115
6	.6478	.4801	.5144	.5506	.9907	.823	.463
7	.6859	.6173	.6001	.6154	1.0669	.8402	.5316
8	.5716	.5144	.3429	.7773	1.1812	.7716	.5144
9		.4458	.4115	.3887	.4191	.4287	.6859
10	.5144	.4115	.4115	.2267		.2743	.7545
11	.5144	.4115	.3239		.2229	.2572	.5506
12	.583		.3563	.1905	.2058	.2134	.8097
13			.4534		.2229	.2134	.8097
14		.4287	.4534		.2229	.1829	.8097
15		.381	.4534		.2229	.1829	.8097
16			.4534		.1886	.1524	.7773
17			.1619		.2229	.1524	.1619
18	.7716	.4287	.2267	.3048	.3086	.3086	.2915
19		.4115	.421		.4458	.3086	.3887
20	.7888	.4287	.3563	.5716	.463	.3429	.4858
21	.6344	.3772	.3239		.4115	.3772	.3563
22	.4973	.3048	.2915		.3258	.3772	.3239
23	.2572	.2743	.3239		.2915	.3429	.3239
24	.5335	.2743	.2439	.3239	.6478	.3601	.3086
Max	.7888	.6173	.6001	.7773	1.1812	.8402	.8097
Min	.2572	.2743	.1619	.1905	.1886	.1524	.1619
Avg	.5784	.3901	.3544	.4024	.4982	.4258	.4932

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR

Feeder No / Name : 205 / 11 KV MIDC OFFICE

SHEDDABLE FEEDER MIDC EQUIVALENT

Feeder KV- 11 / OUTGOING

HAVING WEEKLY STAGGERING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0229		.0107	.0381	.04	
2		.0229		.0107		.04	
3	.0381	.0229		.0107	.0381	.04	
4	.0381	.0229		.0107		.04	
5		.0229		.0107	.0381	.04	
6	.0381	.0229		.0107	.0381	.04	
7	.0381	.0229		.0107	.0381	.04	
8	.0381	.0229		.0107	.0381	.04	
9		.0229		.0107	.0381	.0857	
10	.0381	.0229		.0107	.0381	.04	
11	.0229		.0107		.0533		.0267
12	.0229		.0107	.0381	.04		.016
13	.0229		.0107		.04		.0267
14	.0229		.0107		.04		.0267
15	.0229		.0107		.04		.0267
16	.0229		.0107	.0381	.0229		.0267
17	.0229		.0107	.0381	.04		.016
18	.0229		.0107	.0381	.04		.016
19	.0229		.0107		.04		.0107
20	.0229		.0107	.0381	.04		.0107
21	.0229		.0107		.04		.0107
22	.0229		.0107		.0229		.0107
23	.0229		.0107		.04		.0107
24	.0381	.0229		.0107	.0381	.04	
Max	.0381	.0229	.0107	.0381	.0533	.0857	.0267
Min	.0229	.0229	.0107	.0107	.0229	.04	.0107
Avg	.0287	.0229	.0107	.0193	.0383	.0442	.0181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214527 / 33/11 KV MIDC, LONI DEOKAR

Feeder No / Name : 206 / 11 KV CMP FEEDER

SHEDDABLE FEEDER MIDC EQUIVALENT

Feeder KV- 11 / OUTGOING

HAVING WEEKLY STAGGERING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2058	.2058	.0057	.1524	.1715	.2058
2		.2058	.2058	.0057		.1543	.2058
3	.2286	.1715	.2058	.0057	.1524	.1372	.2058
4		.1715	.1715	.0057		.2401	.2058
5	.2286	.1543	.1715	.0057	.1905	.2743	.2401
6	.2286	.1715	.1372	.0171	.1905	.3086	.2572
7	.2667	.1715	.1029	.0229	.2667	.3086	.2915
8	.2667	.1715	.0914	.0286	.3048	.3086	.2915
9		.1886	.0914	.0229	.3048	.3086	.2915
10	.2667	.2229	.1067	.0343	.3048	.3258	.2915
11	.2743	.2401	.0171		.3086	.3086	.0457
12	.2743	.2401	.0171	.2667	.2743	.3086	.0457
13	.2743	.2572	.0143		.2915	.3086	.0457
14	.2572	.2572	.0171		.2401	.3086	.0457
15	.2401	.2572	.0171		.2743	.3086	.0343
16	.1886	.2572	.0229	.2667	.2229	.2572	.0343
17	.2058	.2572	.0229	.2286	.2229	.2401	.0343
18	.1715	.2572	.0171	.2286	.2058	.2401	.0286
19	.2058	.2401	.0143		.2229	.2401	.0286
20	.2058	.2401	.0143	.1905	.2401	.2401	.0286
21	.2229	.2401	.0143		.2401	.2401	.0229
22	.2401	.2401	.0143		.2229	.2401	.0229
23	.2058	.2058	.0057		.1372	.2058	.0229
24	.1905	.2058	.2058	.0057	.1524	.1715	.2058
Max	.2743	.2572	.2058	.2667	.3086	.3258	.2915
Min	.1715	.1543	.0057	.0057	.1372	.1372	.0229
Avg	.2302	.2179	.0793	.0838	.2329	.2565	.1305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214537 / 33/11 KV BABHULGAON

Feeder No / Name : 201 / 11 KV BABHULGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.2429	.2926	.2054	.1715	.1715	1.1157
2	.4572	.2429	.3292	.2054	.1715	.1715	1.1157
3	.4877	.2753	.3658	.2241	.1715	.1886	1.0974
4	.5335	.3077	.3475	.2241	.2058	.2058	1.1523
5	.5639	.3887	.3658	.2614	.2401	.2401	1.1523
6	.5792	.3953	.4024	.2926	.2401	.2572	1.1523
7	.6097	.3906	.4755	.1867	.2743	.3086	1.1523
8	.5792	.3437	.4572	.168	.2229	.2572	1.134
9	.1372	.2427	.1463	.3185	.6859	.823	.2195
10	.1029	.2241	.128	.4268	.7373	.8916	.1646
11	.0943	.2195	.0943	.4268	.6706	.9511	.12
12	.0943	.2012	.0943	.4572	.7316	.9877	.1372
13	.0943	.1463	.132	.4725	.7316	1.0242	.1029
14	.0943	.128	.1132	.4725	.7773	1.0608	.1029
15	.0754	.128	.1132	.4572	.7316	1.0791	.1029
16	.1132	.1097	.1132	.4877	.7164	1.0974	.1372
17	.0943	.128	.1132	.0686	.1372	.1646	.1543
18	.1509	.1646	.1698	.1715	.1886	.1646	.1715
19	.2058	.1463	.2241	.2401	.2058	.1829	.2401
20	.2241	.1463	.2241	.2401	.2401	.1829	.2743
21	.1867	.1646	.2054	.2058	.2229	.1829	.2058
22	.1867	.1646	.2054	.1715	.1886	.2012	.1886
23	.2515	.2561	.2054	.1715	.1715	.8779	.8383
24	.4877	.2429	.2926	.2054	.1715	.1715	1.0974
Max	.6097	.3953	.4755	.4877	.7773	1.0974	1.1523
Min	.0754	.1097	.0943	.0686	.1372	.1646	.1029
Avg	.2859	.225	.2338	.2817	.3753	.4935	.5554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214537 / 33/11 KV BABHULGAON

Feeder No / Name : 202 / 11 KV CHINCHMALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.0848	.0549	.0566	.0514	.0514	.3475
2	.2743	.0848	.0732	.0566	.0514	.0514	.3292
3	.2896	.0848	.0914	.0566	.0514	.0514	.3658
4	.3048	.1017	.1097	.0566	.0686	.0686	.3841
5	.3048	.1017	.0914	.0754	.0686	.0857	.3658
6	.3048	.1187	.1097	.0943	.0857	.0857	.3841
7	.3353	.1017	.1097	.0754	.0857	.1029	.3841
8	.3201	.1006	.0914	.0943	.0857	.0686	.3841
9	.0857	.0754	.0732	.0686	.12	.2572	.0732
10	.0514	.0566	.0366	.061	.1372	.2743	.0549
11	.0189	.0732	.0189	.0457	.1372	.2926	.0171
12	.0189		.0189	.0457	.0914	.3109	.0171
13	.0189	.0366	.0189	.0457	.1219	.2926	.0171
14	.0189	.0366	.0189	.0457	.1524	.3109	.0171
15	.0189	.0366	.0189	.0305	.1524	.3109	.0343
16	.0189	.0366	.0189	.0305	.1372	.3292	.0343
17	.0566	.0366	.0189	.0343	.0343	.0366	.0343
18	.0566	.0366	.0377	.0686	.0343	.0366	.0686
19	.0686	.0549	.0566	.0686	.0686	.0549	.0857
20	.0754	.0366	.0754	.0857	.0857	.0732	.1029
21	.0754	.0549	.0754	.0857	.0857	.0732	.0686
22	.0754	.0732	.0754	.0686	.0686	.0732	.0686
23	.0848	.0732	.0754	.0514	.0686	.1829	.381
24	.2896	.0848	.0549	.0754	.0514	.0686	.3475
Max	.3353	.1187	.1097	.0943	.1524	.3292	.3841
Min	.0189	.0366	.0189	.0305	.0343	.0366	.0171
Avg	.1434	.0687	.0593	.0616	.0873	.1476	.1820

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214537 / 33/11 KV BABHULGAON

Feeder No / Name : 203 / 11 KV DEVKARWASTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0754	.1097	.1341	.1715	.1715	.128
2	.1029	.0754	.128	.1341	.1543	.1715	.128
3	.12	.0943	.128	.1341	.1543	.1715	.128
4	.1372	.0943	.1463	.1509	.1543	.1715	.128
5	.1372	.0943	.1463	.1619	.1543	.1886	.128
6	.1372	.1132	.1646	.1619	.1715	.1886	.1463
7	.1372	.0934	.1463	.1509	.1543	.2058	.1463
8	.12	.0943	.1463	.1457	.1715	.2058	.128
9	.1677	.0838	.128	.0905	.0857	.0857	.2378
10	.1677	.0838	.1463	.0514	.0686	.0686	.2926
11	.1357	.0754	.1341	.0514	.0514	.0732	.2439
12	.1526		.1341	.0343		.0549	.3048
13	.1526	.0914	.1174	.0686		.0549	.3048
14	.1187	.0732	.1174	.0686	.0514	.0732	.3963
15	.1017	.0732	.1174	.0686	.0514	.0732	.3658
16	.1017	.0914	.1174	.0514	.0514	.0732	.3506
17	.0566	.0549	.0943	.0686	.0686	.0732	.0686
18	.0754	.0732	.1132	.1029	.0857	.0732	.1029
19	.1029	.1097	.132	.12	.1372	.0914	.1029
20	.1132	.1097	.1307	.1372	.1029	.1097	.1029
21	.0943	.128	.1307	.1372	.12	.1097	.12
22	.0943	.1463	.1494	.12	.12	.128	.1029
23	.0943	.128	.1341	.1715	.1543	.1097	.12
24	.12	.0754	.0914	.1341	.1715	.1715	.1097
Max	.1677	.1463	.1646	.1715	.1715	.2058	.3963
Min	.0566	.0549	.0914	.0343	.0514	.0549	.0686
Avg	.1185	.0927	.1293	.1104	.1185	.1208	.1828

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 214537 / 33/11 KV BABHULGAON

Feeder No / Name : 204 / 11 KV GAIKWADWASTI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1132	.1097	.3563	.4973	.5144	.2012
2	.0857	.132	.1463	.3506	.4801	.5144	.1829
3	.1029	.1509	.1097	.3658	.5144	.5487	.2195
4	.12	.1867	.2012	.4268	.6001	.583	.2195
5	.1543	.2054	.1829	.4572	.6516	.6173	.2195
6	.1886	.2054	.1829	.4877	.6859	.6516	.2378
7	.2229	.1867	.1829	.6097	.703	.7716	.2561
8	.1886	.168	.1646	.6401	.7202	.7888	.2378
9	.4268	.421	.5487	.1448	.1372	.1715	.9511
10	.4268	.4372	.5853	.1029	.12	.12	1.1706
11	.4359	.4755	.4572	.1029	.1372	.1463	.9145
12	.421	.4572	.503	.0857	.12	.1463	.9602
13	.421	.4755	.5335	.0857	.1029	.128	.9907
14	.3018	.4572	.503	.0857	.1029	.128	.9907
15	.3185	.4755	.4877	.0857	.12	.128	.9755
16	.3018	.4572	.4725	.0857	.1029	.1097	.9145
17	.0943	.0914	.1132		.12	.1463	.12
18	.0943	.1097	.1132	.12	.12	.128	.1543
19	.1543	.0914	.1494	.1715	.1543	.1463	.1715
20	.168	.0914	.1494	.1715	.1543	.1463	.1886
21	.1132	.1097	.1494	.1543	.1372	.128	.1543
22	.1132	.1097	.132	.12	.12	.128	.12
23	.1132	.0732	.3563	.4973	.4973	.1829	.1029
24	.0857	.1132	.0732	.3563	.4973	.5144	.2012
Max	.4359	.4755	.5853	.6401	.7202	.7888	1.1706
Min	.0857	.0732	.0732	.0857	.1029	.1097	.1029
Avg	.2141	.2414	.2753	.2637	.3165	.3162	.4523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 217021 / 132/33/11 KV S/STN.INDAPUR

Feeder No / Name : 201 / Indapur

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	2.2624
Max	2.2624
Min	2.2624
Avg	2.2624



Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 217021 / 132/33/11 KV S/STN.INDAPUR

Feeder No / Name : 202 / kandalga on

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	2.2862
Max	2.2862
Min	2.2862
Avg	2.2862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 217021 / 132/33/11 KV S/STN.INDAPUR

Feeder No / Name : 203 / pimpri kh

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 217021 / 132/33/11 KV S/STN.INDAPUR

Feeder No / Name : 204 / kalthan (Indapur Switching NON SHEDDABLE EXPRESS HV FEEDERS  
Inc Feeder KV- 11 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 217046 / 132 KV BAWADA

Feeder No / Name : 405 / 33kv Bhatnimgaon LIS  
Feeder KV- 33 / OUTGOING

SHEDDABLE HV(AGRICULTURE)

DATE	01-SEP-17
HR	Load (MW)
24	2.2862
Max	2.2862
Min	2.2862
Avg	2.2862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 217046 / 132 KV BAWADA

Feeder No / Name : 701 / Nira-Bhima SSKL

Feeder KV- 132 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	2.2634
Max	2.2634
Min	2.2634
Avg	2.2634

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

INDAPUR[052]

BU 5894

Substation No/ Name :- 217046 / 132 KV BAWADA

Feeder No / Name : 702 / Karmyaogi S.S.K.Ltd

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	2.2634
Max	2.2634
Min	2.2634
Avg	2.2634

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 301 / 22KV BHIGWAN AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.2263	.5144	.4801	.6413	.2743
2	.1715	.2058	.2263	.5144	.4801	.6413	.2743
3	.1715	.2058	.2263	.5144	.4801	.6413	.2743
4	.2058	.2401	.2263	.5144	.5487	.7545	.2743
5	.2058	.2401	.2263	.6173	.6173	.9808	.2743
6	.2058	.2743	.2641	.6859	.6516	1.0562	.2743
7	.2058	.2743	.2641	.7202	.9259	.9808	.2743
8	.2058	.2401	.2641	.7202	.9259	.9431	.3086
9	.2743	.4801	.6413	.2058	.2058	.2641	1.0631
10	.2743	.4458		.2058	.2641	.2401	1.3203
11	.2401	.4904	.6516	.2401	.2263	.2058	1.5844
12	.2058	.4527	.6173	.2058	.2641	.1715	2.5118
13	.2058	.4904	.6173	.2058	.2263	.1715	1.9993
14	.2401	.4904	.6173	.2058	.2263	.2401	1.9993
15	.1715	.4904	.5487	.2058	.1886	.2401	2.0748
16	.4458	.5281	.5144	.2058	.2641	.2743	1.9993
17	.2058	.1509	.1715	.2058	.1886	.2401	.2641
18	.2058	.2641	.1372	.2058	.2263	.3086	.3018
19	.2401	.3018	.1715	.2401	.2641	.3086	.2641
20	.2058	.3018	.2058	.2401	.3018	.2401	.2641
21	.2401	.3018	.2401	.2058	.2263	.2743	.2263
22	.2401	.3018	.1715	.1372	.2263	.1715	.2263
23	.2058	.2641	.4801	.7011	.5281	.2743	.2641
24	.1715	.2058	.2641	2.4082	.4801	.6413	1.9814
Max	.4458	.5281	.6516	2.4082	.9259	1.0562	2.5118
Min	.1715	.1509	.1372	.1372	.1886	.1715	.2263
Avg	.2215	.3269	.3467	.4511	.3924	.4544	.8572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 302 / 22KV KHANOTA BHIGWAN SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7449	2.2611	1.3603	1.3603	1.5074	.7773
2	.6478	.7449	.6554	1.3603	1.3603	1.4419	.7773
3	.6478	.8097	.6554	1.3603	1.3603	1.4419	.7773
4	.7125	.8421	.6554	1.3603	1.5546	1.5074	.9069
5	.9069	.9069	.7865	1.6194	1.6194	1.6385	1.0688
6	.9717	1.0688	.9175	1.7166	1.7166	1.9006	1.166
7	.8745	1.0364	1.0159	1.8461	1.9433	2.2283	.9717
8	.8421	.8097	.7209	1.7166	1.8785	2.1628	.8097
9	1.2955	1.3603	1.5074	.583	.6478	.5571	
10	1.2308	1.3279	1.3927	.5506	.4915	.4858	
11		1.2452	1.2631	.4534	.5571	.4858	2.4249
12		1.0814	1.3603	.4534	.1311		2.8182
13	1.1336	1.3443	1.3927		.5243	.583	2.8837
14	1.1336	1.2125	1.3927	.4534	.4588	.5506	2.4905
15	1.0688	1.3108	1.4575	.4534	.4588	.5182	2.6871
16	1.004	1.3108	1.4575	.4858	.4915	.5182	2.6543
17	.583	.5571	.5506	.5506	.5243	.583	.5571
18	.6478	.5898	.6802	.6802	.7209	.7449	.7209
19	.8421	.7865	.8097	1.608	.9175	.8421	.9175
20	.9393	.8848	1.004	1.004	.9503	.9717	.9831
21	.9069	.9175	.8745	.7773	.9503	.8421	.8848
22	.8421	.852	.8421	.8421	.8192	.8097	.7865
23	.7449	.7209	1.3603	1.4251	1.5402	.7773	.7209
24	.6478	.7449	.7209	3.0674	1.3603	1.5074	.7773
Max	1.2955	1.3603	2.2611	3.0674	1.9433	2.2283	2.8837
Min	.583	.5571	.5506	.4534	.1311	.4858	.5571
Avg	.8777	.9671	1.0723	1.1186	1.0141	1.0698	1.3437



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 303 / 22KV BHIGWAN GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3717	1.5684	1.3717	1.4403	1.5684	1.4403
2	1.3717	1.3717	1.4937	1.3717	1.4403	1.5684	1.4403
3	1.3717	1.3717	1.4937	1.3717	1.4403	1.5684	1.4403
4	1.5432	1.5432	1.7177	1.3717	1.6461	1.7177	1.7147
5	1.7147	1.7833	1.7924	1.7147	2.0576	2.1658	2.0576
6	2.0576	2.0576	2.3152	2.0576	2.2291	2.4272	2.2291
7	2.1948	2.2291	2.4646	2.2291	2.2634	2.4272	2.332
8	2.0576	2.0576	1.8671	2.0576	2.0576	2.2405	2.0576
9	1.8861	1.8519	1.7924	1.7833	1.7833	1.9044	1.9204
10	1.7147	1.7147	1.6461	1.6461	3.5848	1.7147	1.8671
11	1.7147	1.7924	1.6461	1.5775	1.7177	1.6461	1.7177
12	1.6461	1.7177	1.6461	1.5775	1.7177	1.6461	
13	1.6461	1.7177	1.5775	1.5432	1.7177	1.6461	1.7177
14	1.5775	1.7177	1.5775	1.5432	1.7177	1.5775	1.7177
15	1.5775	1.7177	1.5775	1.5432	1.643	1.5775	1.7177
16		1.7924	1.5432	1.5432		1.5775	1.643
17	1.5432	1.7924	1.5432	1.5432	1.643	1.5775	1.643
18	1.7833	1.8671	1.5432	1.7147	1.8671	1.7833	1.8671
19	2.0576	2.1658	1.989	2.0576	2.2405	2.0576	2.1658
20	1.989	2.2405	2.0576	1.989	2.0911	2.0576	2.2405
21	1.7833	1.8671	1.7833	1.7147	1.8671	1.7833	2.0165
22	1.7833	1.7177	1.7147	1.5775	1.643	1.6461	1.7924
23	1.5775	1.643	1.5775	1.5089	1.643	1.5089	1.643
24	1.3717	1.5089	1.5684	1.4022	1.4403	1.5684	1.4403
Max	2.1948	2.2405	2.4646	2.2291	3.5848	2.4272	2.332
Min	1.3717	1.3717	1.4937	1.3717	1.4403	1.5089	1.4403
Avg	1.7102	1.7754	1.7290	1.6588	1.8649	1.7898	1.8183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214415 / 33/22 KV BHIGWAN S/STN.

Feeder No / Name : 306 / 22 KV KUMBHARGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.3772	.3658	.1372	.1372	.2195	1.3032
2	.9602	.3772	.3658	.1372	.1372	.2195	1.3032
3	.9602	.3772	.3658	.1372	.1372	.2195	1.3032
4	.9602	.3772	.3658	.1372	.1372	.2561	1.3032
5	.9602	.4115	.4755	.2058	.2058	.2926	1.3717
6	.9602	.4458	.5853	.2058	.2058	.2926	1.406
7	.9602	.4458	.6219	.2401	.2401	.2926	1.6118
8	.9602	.5144	.5853	.2058	.2401	.2561	1.7147
9	.1372	.1372	.2195	.6173	.8916	1.2803	
10	.1372	.1372	.2058	.823	1.2803	1.406	
11	.1372	.1463	.1372	.8573	1.2071	1.4746	
12	.1372	.1463	.1372	.9259	1.4266	1.6461	
13	.1372	.1463	.1372	.8916	1.4998	1.7147	
14	.1372	.1463		.9259	1.5729	1.749	
15	.1372	.1463		.9259	1.4998	1.6461	.2195
16	.2058	.1463		.9259	1.4632	1.8176	.2195
17	.1372	.1463			.2195	.1372	.2195
18	.1372	.2195		.2058	.2195	.2058	
19	.1372	.2195	.1372	.2401	.2561	.2058	.2561
20	.1372	.2195	.1372	.2401	.2195	.1372	.2195
21	.1372	.2195	.1372	.2058	.2195	.1372	.2195
22	.1372	.2195	.1372	.2058	.2195	.1372	.2561
23	.3772	.3658	.1372	.1372	.2195	1.3032	1.4632
24	.9602	.3772	.3658	.1372	.1372	.2195	1.3032
Max	.9602	.5144	.6219	.9259	1.5729	1.8176	1.7147
Min	.1372	.1372	.1372	.1372	.1372	.1372	.2195
Avg	.4587	.2694	.2958	.4205	.5830	.7194	.9231

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 201 / TAWASHI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859				
8		.8745	.8916	.7545	.9774	.9259	.8059
16	.5487	.5487	.4973	.4287	.4287	.463	1.0631
24	.5144	.6001	.6516	.4115	.463	.9088	.8059
Max	.5487	.8745	.8916	.7545	.9774	.9259	1.0631
Min	.5144	.5487	.4973	.4115	.4287	.463	.8059
Avg	.5316	.6744	.6816	.5316	.6230	.7659	.8916

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 202 / SAPKALWADI (THORATWADI SINGLE PHASING  
OLD) Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2058				
8	.3258	.3944	.3429	.4973	.4801	.4115	.3258
16	.2229	.3086	.3086	.12	.12	.12	.5316
24	.1715	.1543	.1715	.2401	.1715	.3258	.2058
Max	.3258	.3944	.3429	.4973	.4801	.4115	.5316
Min	.1715	.1543	.1715	.12	.12	.12	.2058
Avg	.2401	.2858	.2572	.2858	.2572	.2858	.3544

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 203 / 11KV JAMB SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3086				
8	.4973	.5658	.6173	.4287	.5487	.5316	.8402
16	.1543	.2401	.2058	.5487	.7373	.8573	.2058
24	.2401	.2401	.2229	.5335	.3258	.6344	.463
Max	.4973	.5658	.6173	.5487	.7373	.8573	.8402
Min	.1543	.2401	.2058	.4287	.3258	.5316	.2058
Avg	.2972	.3487	.3387	.5036	.5373	.6744	.503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 204 / 11KV UDMAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0514				
8	.0343	.0343	.0514	.0343	.0171	.0514	.0171
16	.0171	.0171	.0171	.0343	.0343	.0343	.0171
24	.0343	.0171	.0343	.0171	.0171	.0343	.0171
Max	.0343	.0343	.0514	.0343	.0343	.0514	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0343	.0171
Avg	.0286	.0228	.0386	.0286	.0228	.04	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 205 / KURAWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144				
8	.8573	.8916	.8916	.9088	.8916	.8745	1.166
16	.3429		.2743	.8573	1.1317	1.286	.3772
24	.4458	.4458	.4458	.6173	.5658	.8573	.6173
Max	.8573	.8916	.8916	.9088	1.1317	1.286	1.166
Min	.3429	.4458	.2743	.6173	.5658	.8573	.3772
Avg	.5487	.6687	.5315	.7945	.8630	1.0059	.7202

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214435 / 33/11 KV GHOLAPWADI

Feeder No / Name : 206 / 11KV THORATWADI (NEW) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.3086				
8	.6344	.5487	.6173	.5316	.5487	.583	.9945
16	.1715	.2572	.2058	.6687	.9259	.9945	.2401
24	.2401	.2229	.2058	.3086	.2915	.4115	.3429
Max	.6344	.5487	.6173	.6687	.9259	.9945	.9945
Min	.1715	.2229	.2058	.3086	.2915	.4115	.2401
Avg	.3487	.3215	.3344	.5030	.5887	.663	.5258



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 201 / 11KV BHAWANINAGAR AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3086	.4458	.5344	.583	.6478	.4115
2	.3944	.3258	.4801	.6154	.6154	.6478	.4115
3	.4115	.3601	.5144	.6478	.6478	.6802	.4115
4	.4458	.4115	.5487	.6964	.664	.7125	.4458
5	.5144	.463	.583	.7287	.6802	.7773	.5144
6	.6173	.5487	.6173	.7935	.6802		.6344
7	.6344	.6859	.703	.8421	.8745	.9393	.6859
8	.5144	.6173	.583	.9717	1.1336	1.166	.5487
9	.7449	.6859	.7611	.4115	.5487	.4801	1.3603
10	.6478	.6964	.7773	.3429	.4527	.3429	1.4575
11	.6154	.7449	.7935	.2743	.3206	.2572	1.587
12	.583	.7773	.8097	.2401	.3018	.2572	1.749
13	.5992	.7935	.7773	.2401	.2172	.2401	1.7004
14	.5506	.7935	.7125	.2401	.2353	.2401	1.6842
15	.5182	.7935	.6802	.2401	.2263	.2915	1.6518
16	.4534	.7773	.7449	.2401	.2263	.2401	1.6194
17		.2915	.2915		.3018	.3429	.3429
18	.3429	.3601	.4973	.4287	.3772	.463	.4115
19	.463	.4287	.5487	.5658	.6036	.5487	.5144
20	.5487	.4973	.5487	.6173	.5068	.5487	.583
21	.5144	.4801	.5658	.4801	.4715	.4801	.5144
22	.3772	.463	.583	.4115	.4715	.4801	.4534
23	.3429	.4458	.5182	.5344	.6478	.4458	.463
24	.3772	.3601	.4115	.4858	.5506	.6478	.4115
Max	.7449	.7935	.8097	.9717	1.1336	1.166	1.749
Min	.3429	.2915	.2915	.2401	.2172	.2401	.3429
Avg	.5038	.5462	.6040	.5036	.5141	.5164	.8570

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 202 / 11KV SHINDEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2229	.3258	.3429	.2753	.3239	.3429
2	.3086	.2229	.4287		.3077	.3563	.3429
3	.3429	.2572	.463	.3725	.3401	.421	.3772
4	.3772	.3086	.4973	.4372	.3725	.4534	.4115
5	.4115	.3944	.5487	.4696	.4049	.4858	.4801
6	.4801	.4801	.583	.4858	.4534		.5144
7	.6516	.6001	.5144	.5182	.6478	.6802	.6173
8	.5182	.4287	.4801	.6154	.8097	.8097	.5144
9	.3239	.2401	.3239	.3772	.4801	.4458	.6859
10	.3239	.2105	.3239	.3086	.3018	.2743	.8259
11	.2267	.1781	.3401	.2058	.2263	.1715	1.004
12	.2429	.1943	.3563	.1372	.1886	.1715	1.0688
13	.1943	.2591	.3725	.1372	.132		1.1174
14	.2105	.2915	.3563	.1372	.1448	.1029	.9717
15	.2267	.2591	.3239	.1543	.1509	.1715	1.0202
16	.1619	.2267	.3725	.1715	.1509	.1715	.9717
17	.3258	.1715	.2229	.2058	.1886	.2743	.1886
18	.3772	.2572	.3429	.4115	.2641	.3772	.3086
19	.4115	.3772	.4801	.5487	.5281	.5144	.3944
20	.4458	.4973	.5487	.6001	.4904	.4458	.5144
21	.3429	.4115	.4458	.5144	.415	.3429	.4458
22	.2743	.3429	.3772	.3772	.3772	.3429	.3086
23	.2572	.3086	.1943	.2267	.3563	.3429	.3086
24	.3086	.2401	.3086	.1943	.2267	.3239	.3429
Max	.6516	.6001	.583	.6154	.8097	.8097	1.1174
Min	.1619	.1715	.1943	.1372	.132	.1029	.1886
Avg	.3355	.3075	.3971	.3456	.3431	.3638	.5866

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 203 / 11KV KAZAD AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.421	.5668	.4696	.5144	.6001	.5658	.583
2	.421	.5992	.502	.4973	.6687	.5658	.583
3	.4534	.6154	.583	.4801	.7888	.6036	.6154
4	.4534	.5992	.6154	.5658	.8402	.6413	.6478
5	.4858	.6316	.664	.6516	.9088	.7545	.6802
6	.5182	.6478	.7125	.7545	.9774		.7935
7	.583	.6802	.8259	.8573	1.0288	1.0751	1.2631
8	.7449	.6478	1.004	.823	.7888	.8299	1.4575
9	.6173	.6687	.6859	.9717	1.1498	1.3603	.6173
10	.4801	.4801	.4458	1.0202	1.0526	1.3927	
11	.3772	.3944	.3772	1.085	1.2955	1.5223	.2743
12	.3429	.3086	.3086	1.1012	1.2955	1.4899	.3086
13	.2743	.3086	.2915	1.0202	1.3603	1.4575	.2743
14	.2915	.2915	.2743	.9717	.1296	1.3279	.2058
15	.2743	.3258	.2915	.9878	1.2955	1.2955	.2401
16	.3772	.3429	.3086	.9878	1.1822	1.1984	.2743
17	.5144	.3772	.3429	.4287	.3772	.4287	.4115
18	.6173	.6001	.5316	.6173	.4527	.6687	.5144
19	.6516	.703	.6859	.7888	.9808	.7545	.703
20	.6859	.7716	.7202	.823	.8676	.7888	.7545
21	.6173	.6687	.6687	.6859	.7545	.6001	.6516
22	.5487	.6173	.6173	.583	.6036	.583	.6173
23	.5658	.4372	.5487	.5487	.6036	.583	.7773
24	.421	.583	.421	.5487	.5316	.5658	.583
Max	.7449	.7716	1.004	1.1012	1.3603	1.5223	1.4575
Min	.2743	.2915	.2743	.4287	.1296	.4287	.2058
Avg	.4891	.5361	.5373	.7631	.8556	.9154	.6013

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 204 / 11KV WADACHA MALA AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.2429	.2105	.3772	.4287	.3772	.3239
2	.1943	.2753	.2429	.3601	.463	.3772	.3239
3	.2105	.3077	.2753	.3944	.5316	.415	.3563
4	.2267	.3239	.3077	.4287	.5658	.4904	.3563
5	.2429	.3563	.3077	.4801	.6001	.5281	.3887
6	.2753	.3887	.3239	.5144	.6344		.4858
7	.3401	.4534	.5668	.6001	.6344	.679	.7611
8	.4372	.5344	.664	.4115	.4458	.4458	.8745
9	.4287	.3258	.3086	.583	.5182	.6478	.3429
10	.3258	.2401	.2229	.6478	.5506	.7773	.2743
11	.2401	.2058	.1886	.7125	.6478	.8583	.1715
12	.2229	.1715	.1543	.7449	.7125	.8259	.1886
13	.1715	.1372	.1372	.5668	.7611	.6964	.1715
14	.1886	.1543	.1715	.4696	.7287	.7287	.12
15	.1715	.1543	.1886	.4858	.7287	.664	.12
16	.2058	.1372	.1543	.5182	.6964	.7287	.1372
17	.3429	.1543	.1543	.1886	.2263	.2743	.1715
18	.3944	.2743	.2915	.3429	.2452	.3258	.2401
19	.4801	.3772	.3772	.4458	.4715	.4287	.3601
20	.5487	.4973		.4973	.6036	.463	.4801
21	.5144	.4287	.4115	.4287	.4904	.4973	.4458
22	.4458	.3429	.3601	.3772	.5281	.4458	.3944
23	.2572	.2267	.4115	.3944	.3772	.3239	.664
24	.1943	.2591	.2105	.3944	.3944	.3772	.3239
Max	.5487	.5344	.664	.7449	.7611	.8583	.8745
Min	.1715	.1372	.1372	.1886	.2263	.2743	.12
Avg	.3023	.2904	.2888	.4735	.5410	.5381	.3532

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214449 / 33/11 KV KAZAD S/STN.

Feeder No / Name : 205 / 11KV LAKADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1715	.2229	.6154	.6964	.7449	.2229
2	.2058	.2058	.2229	.6802	.7125	.7773	.2229
3	.2058	.2229	.2572	.7125	.6802	.8097	.2229
4	.2401	.2572	.2915	.7287	.7125	.8907	.2401
5	.2743	.2743	.2915	.7449	.7287	.9393	.2743
6	.3258	.2915	.3086	.7935	.7773		.3086
7	.3429	.3258	.3601	.8097	.9717	1.0364	.3258
8	.2401	.2915	.3086	1.0364	1.085	1.2146	.2743
9	.6154	.6687	.7287	.2572	.2743	.2229	1.3927
10	.6802	.664	.664	.2229	.2263	.1715	1.9109
11	.7125	.6478	.6964	.1886	.1698	.1543	2.0243
12	.7287	.6478	.7287	.1543	.1509	.1029	2.0729
13	.6964	.6802	.7125	.1372		.1029	2.1052
14	.664	.6478	.7125	.12		.1029	2.0243
15	.6478	.6316	.6478	.1372	.1448	.12	
16	.6316	.5992	.7935	.1543	.132	.1372	1.9919
17		.1886	.1715	.1715	.1886	.2058	.1715
18	.2401	.2401	.2229	.2401	.2452	.2401	.2058
19	.2401	.2743	.2572	.2915	.3772	.2743	.2229
20	.2572	.2915	.2572	.3086	.3395	.2572	.2572
21	.2401	.2572	.2401	.2743	.3206	.2401	.2743
22	.2229	.2401	.2572	.2572	.2829	.2229	.2572
23	.2058	.2229	.5506	.7125	.7449	.2229	.2401
24	.2058	.1886	.2229	.5668	.7125	.7449	.2229
Max	.7287	.6802	.7935	1.0364	1.085	1.2146	2.1052
Min	.2058	.1715	.1715	.12	.132	.1029	.1715
Avg	.3926	.3805	.4220	.4298	.4852	.4320	.7594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 201 / 11KV NIMSAKHAR AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.3572	.6173	.8059	.7049	.8573	.5487
2	.4801	.4144	.6173	.8402	.8288	.8573	.5487
3	.4973	.4001	.6859	.8573	.8288	.8916	.7716
4	.7202	.3525	.8573	.8916	.8288	.9774	.8573
5	.9602	.3525	1.0288	.9259	.9945	1.0802	.9431
6	1.1831	.5639	1.2003	1.406	.9602	1.2689	1.0288
7	1.4232	.5801	1.2003	1.8861	1.2574	2.2805	1.2003
8	1.166	.4801	1.0288	1.9204	1.8233	2.4006	1.0288
9	.823	.9945	1.286	.9602	.503	1.0117	1.2003
10	.7202	1.2003	1.3717			.823	1.1831
11	.8097	1.0288	1.3203			.6859	1.0288
12	.8002	1.2003	1.2346			.6173	
13	.8097	1.2003	1.2689		.7202	.6173	.2401
14	.8097	1.2003	1.3203		.7202	.6173	.2572
15	.663	1.2003	1.2003		.6344	.6173	.2743
16	.6478	1.2003	1.3375		.6687	.6173	.3258
17	.3521	.6173	.4801	.4858	.703	.6173	.2743
18	.4858	.6173	.6859	.4858	.823	.6173	.3086
19	.663	.9602	.8916	.4858	1.1317	.823	.4287
20	.4973	.9602	1.0802	.5801	1.1831	.8916	.4801
21	.4287	.7545	.8916	.4973	.9602	.8916	.4115
22	.3525	.7545	.8059	.4973	.823	.6859	.3601
23	.3525	.6173	.823	.7459	.8573	.5487	.2743
24	.5316	.4001	.6173	.7888	.8288	.8402	.5487
Max	1.4232	1.2003	1.3717	1.9204	1.8233	2.4006	1.2003
Min	.3521	.3525	.4801	.4858	.503	.5487	.2401
Avg	.6955	.7670	.9938	.8859	.8944	.9224	.6314

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 202 / 11KV SARAFWADI 1 AG

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)
15		.5658
16		.7888
17		.3429
18		.463
19		.6001
20		.5487
21		.463
22		.4458
23		.4115
24	.3963	
<b>Max</b>	<b>.3963</b>	<b>.7888</b>
<b>Min</b>	<b>.3963</b>	<b>.3429</b>
<b>Avg</b>	<b>.3963</b>	<b>.5144</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 203 / 11KV KHOROCHI 1 AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.663	.4287	.703	.4801	.6344	.6859
2	.7545	.663	.4287	.7373	.4801	.6344	.6859
3	.7888	.663	.6516	.7716	.4973	.6516	.6859
4	.823	.663	.6859	.8059	.4801	.703	.6859
5	.8573	.663	.7716	.8402	.4001	.7716	.7716
6	.8916	.7287	.8573	.8745	.4641	.8916	.8573
7	.9259	.8192	.8573	.9259	.4801	1.0117	.8573
8	1.166	.8288	1.0288	.7888	.5668		1.286
9	.823	.4049	.6173	1.0631	1.0059	2.1948	.6859
10	.6478	.6859	.5316			2.1434	
11	.4858	.6173	.4801			2.0576	.4115
12	.4049	.6173	.4973				
13	.4049	.4801	.5144		2.0919	2.0576	.4115
14	.4144	.4801	.5144		2.0405	2.0576	.4287
15	.4049		.4458		2.0748	2.1434	.463
16	.4144	.5487	.463		2.1605	2.0576	
17	.3315	.6859	.6001	1.1336	.6516	.6859	.6687
18	.4641	.6859	.7202	1.2146	.7888	.6859	.7545
19	.5801	.823	.8402	1.1603	.8573	.823	.8402
20	.5801	.823	.8402	1.1603	.9945	.8916	.7888
21	.423	.7545	.823	.7468	.8059	.8916	.7202
22	.3525	.7545	.7888	.5801	.7545	.823	.703
23	.6154	.4287	.6859	.5801	.6344	.6859	.5658
24	.6859	.5639	.4287	.6859	.5601	.6516	.6859
Max	1.166	.8288	1.0288	1.2146	2.1605	2.1948	1.286
Min	.3315	.4049	.4287	.5801	.4001	.6344	.4115
Avg	.6233	.6541	.6459	.8689	.9176	1.1886	.6973



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 204 / 11KV EXPRESS MODERN ENGG. NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0166	.0171	.0171	.016	.0076	.0171
2	.0171	.0166	.0171	.0171	.0162	.0076	.0171
3	.0171	.016	.0171	.0171	.0162	.0076	.0171
4	.0171	.0166	.0171	.0171	.016	.0076	.0171
5	.0171	.0162	.0171	.0171	.016	.0076	.0171
6	.0171	.0166	.0171	.0171	.016	.0076	.0171
7	.0171	.0166	.0171	.0171	.0162	.0076	.0171
8	.0171	.0162	.0171	.0171	.0162	.0076	.0171
9	.0543	.0275	.0171	.0171	.0168	.0076	.0171
10	.0308	.0514	.0171	.0298		.0171	.0076
11	.0302	.0171	.0343	.0298		.0171	
12	.0315	.0171	.0514	.0256		.0343	
13	.0298	.0171	.0171	.0282	.0171	.0343	.0076
14	.0166	.0171	.0171	.0249	.0343	.0343	.0076
15	.0298	.0171	.0171	.0249	.0343	.0343	.0343
16	.0315	.0343	.0171	.0268	.0076	.0343	.0152
17	.0308	.0171	.0171	1.2407	.0171	.0171	.0076
18	.016	.0171	.0171	.0238	.0171	.0171	.0076
19	.0162	.0171	.0171	.0166	.0076	.0171	.0076
20	.0141	.0171	.0171	.0166	.0152	.0171	.0171
21	.0141	.0171	.0171	.0166	.0171	.0171	.0171
22	.0141	.0171	.0171	.0166	.0076	.0171	.0171
23	.0162	.0171	.0171	.0166	.0076	.0171	.0076
24	.0171	.0166	.0171	.0171	.016	.0076	.0171
Max	.0543	.0514	.0514	1.2407	.0343	.0343	.0343
Min	.0141	.016	.0171	.0166	.0076	.0076	.0076
Avg	.0221	.0194	.0192	.0712	.0164	.0167	.0148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 205 / 11KV SARAFWADI 2

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3201	.3601	.5658	.6706	.6687	.3429
2	.2743	.3647	.3601	.583	.6706	.6687	.3429
3	.2572	.3647	.3944	.6001	.6706	.6859	.4287
4	.3429	.3647	.4287	.6173	.6706	.7545	.4287
5	.4287	.4973	.5144	.6344	.6706	.8745	.5144
6	.5144	.6464	.6001	.8573	1.0059	.9945	.6001
7	.6173	.4934	.6001	1.0802	1.4083	1.5432	.6173
8	.583	.5304	.4115	1.2517	1.5223	1.6289	.5487
9	.6859	.4934	.7373	.3944	.2915	.463	.8059
10	.5668	.823	.703	.3315		.3086	.703
11	.57	.7373	.6001	.2915		.3429	.6516
12	.5601	.6344	.7545	.2155		.2743	
13	.5668	.583	.8059	.1823	.2401	.2743	.703
14	.5182	.583	.8573	.176	.2058	.2743	.7373
15	.4801	.583	.7716	.176	.2572	.1886	.7716
16	.4801	.6687	.8916	.1844	.2743	.2427	.7545
17	.2984	.3258	.3086	.2012	.3772	.3429	.2229
18	.4144	.3944		.3077	.3944	.463	.3429
19	.4287	.4801	.5658	.4144	.6344	.5144	.5316
20	.423	.4801	.583		.583	.5144	.5144
21	.4641	.4115	.4973	.4144	.5487	.5144	.4458
22	.3812	.4115	.4801	.3647		.3944	.3944
23	.3201	.3601	.5487	.5801	.7202	.3429	.3601
24	.3086	.3315	.3601	.5487	.6478	.6516	.3429
Max	.6859	.823	.8916	1.2517	1.5223	1.6289	.8059
Min	.2572	.3201	.3086	.176	.2058	.1886	.2229
Avg	.4490	.4951	.5711	.4771	.6232	.5802	.5263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214464 / 33 KV NIM SAKHAR

Feeder No / Name : 206 / 11KV KHOROCHI- 2

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4973	.4801	.463	.2429	.3258	.4287
2	.3944	.4973	.4801	.5144	.2429	.3429	.4287
3	.4115	.4973	.6859	.5658	.2881	.3429	.5144
4	.6001	.4858	.7716	.6173	.2915	.3772	.5144
5	.6859	.5801	.8573	.6859	.3185	.4287	.6001
6	.7888	.6964	.9431	.7888	.4049	.5144	.6859
7	.8916	.7373	.9774	.9088	.5506	.5658	.703
8	.9259	.6908	1.0288	.7202	.421	.4115	.6859
9	.6516	.5441	.5144	.8573	.8886	1.3717	
10	.5087	.6001	.4115	.8097		1.6289	.2743
11	.4534	.4458	.3258			1.749	.2058
12	.3563	.4115	.3258	.7935		1.6289	
13	.3239	.3772	.2743	.8097	1.4403	1.6289	.1543
14	.3239	.3772	.2401	.8097	1.6289	1.6289	.1543
15	.3315	.3772	.2572	.8097	1.5947	1.4403	.1543
16	.3647	.3086	.2572	.7935	1.5089	1.3375	.1886
17	.4144	.3944	.3772	.1943	.2915	.3258	.2229
18	.4287	.5487	.5316	.2267	.3944	.3258	.2915
19	.7459	.6516	.703	.3563	.5144	.3944	.463
20	.5639	.6516	.8573	.5138	.5316	.4458	.4801
21	.663	.5316	.6687	.4973	.4973	.4458	.3772
22	.5075	.5316	.5658	.2984	.3772	.2915	.3429
23	.4144	.4801	.463	.2721	.3258	.4287	.4115
24	.4115	.4973	.4801	.3506	.2429	.3258	.4287
Max	.9259	.7373	1.0288	.9088	1.6289	1.749	.703
Min	.3239	.3086	.2401	.1943	.2429	.2915	.1543
Avg	.5239	.5171	.5616	.5938	.6189	.7795	.3959

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 201 / 11KV PILEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1475	.1638	.1638	.1475	.1677
2		.1677	.1475	.1638	.1638	.1475	.1829
3		.2058	.1638	.1966	.1966	.1638	.1981
4	.1311	.2229	.1966	.213	.2294	.1802	.2286
5		.1981	.2458	.2458	.2785	.213	.2591
6		.1981	.3605	.3277	.362	.3277	.3506
7		.2286	.3605	.3768	.3605	.3441	.3353
8		.1677	.3113	.5407	.7373	.9012	.2896
9		.168	.2294	.6554	.9012	1.0059	.2949
10			.1147	.7209		1.1584	.1966
11			.0983	.7537		1.1126	.1311
12			.0983	.7537			.1147
13		.1147	.0983	.7373	.8684	1.1736	.1311
14	.2743	.1475	.0819	.7373	1.0814	1.1126	.1311
15		.1147	.0983	.6882	1.0978	1.0517	.0983
16		.5898	.426	.1311	.1475	.1219	1.5729
17	.1981	.6062	.5079	.1311	.1475	.1219	1.6549
18	.1829	.4915	.5079	.1966	.1802	.2347	1.5729
19	.2134	.5571	.5571	.2622	.2785	.2134	1.2452
20	.1981	.4915	.5407	.2294	.2622	.2286	1.1797
21	.1829	.426	.4915	.1966	.1802	.2134	1.1305
22	.1829	.3605	.4096	.1966	.1638	.1829	1.0978
23		.3441	.3605	.181	.1475	.1524	
24	.1311		.1475	.7926	.1638	.1475	.1677
Max	.2743	.6062	.5571	.7926	1.0978	1.1736	1.6549
Min	.1311	.1147	.0819	.1311	.1475	.1219	.0983
Avg	.1883	.2976	.2792	.3997	.3863	.4633	.5535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 202 / 11KV AKOLE AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3439	.1524	.2652	.168	.1629	.132	.8383
2	.2949	.1677	.2652	.168	.1629	.132	.8535
3	.2949	.1829	.2818	.168	.1629	.132	.8688
4	.3277	.1981	.2949	.1867	.181	.1509	.884
5	.3277	.2439	.3277	.2241	.1991	.1698	.884
6	.426	.3048	.3441	.2614	.2172	.1867	.9145
7	.4588	.3963	.6062	.2427	.2353	.2241	.9907
8	.2195	.1677	.2614	.2241	.2427	.2378	.1829
9	.1524	.1867	.1867	.181	.2241	.1524	.1867
10	.1067	.1494	.1307	.1448		.1372	.1475
11	.1067	.1307		.1448		.1067	.1307
12	.0914	.1867				.0914	.112
13	.0762	.2075		.1448	.0934	.0914	.112
14	.0762	.168		.1448	.0934	.0914	.112
15	.0762	.1867	.1311	.1448	.0934	.0914	.1307
16	.061	.168	.0934	.724	.9762	1.3717	.1307
17	.1067	.1867	.168	.7602	.9877	1.326	.1311
18	.1067	.2241	.168	.905	1.0648	1.2955	.1867
19	.1524	.2427	.2054	.9593	1.1523	1.1584	.1867
20	.1524	.1867	.2054	.8192	1.0883	1.0669	.2241
21	.1372	.1698	.2054	.7865	1.0311	.9907	.1867
22	.1219	.168	.1867	.7209	.9686	.9145	.1867
23		.1494	.1867	.6554	.9061	.8535	
24	.3439	.1524	.2652	.168	.181	.128	.823
Max	.4588	.3963	.6062	.9593	1.1523	1.3717	.9907
Min	.061	.1307	.0934	.1448	.0934	.0914	.112
Avg	.1983	.1949	.2390	.3933	.4964	.4680	.4089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 203 / 11KV KALAS AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1886	.2241	.3932	.426	.4588	.2058
2	.1638	.2075	.2241	.4096	.426	.4588	.2229
3	.2218	.2263	.2641	.4049	.4588	.4588	.2401
4	.2587	.2452	.3018	.426	.4915	.4915	.2572
5	.2896	.3018	.3395	.4752	.5243	.5182	.2915
6	.3326	.3734	.3734	.5243	.7209	.6478	.3429
7	.3326	.3734	.3361	.7537	.8848	.9175	.3429
8	.2896	.2987	.2987	1.0159	1.166	1.1012	.2743
9	.4572	.5571	.5735	.1848	.2241	.2439	1.0814
10	.5144	.5898	.6226	.181		.2439	1.3108
11	.4801	.7209	.6882	.1448		.1829	1.3435
12	.5487	.5243	.6882	.1448		.1829	1.5729
13	.4287	.4588	.639	.1448	.1867	.1524	1.5565
14	.3086	.426	.5735	.1448	.1867	.1524	1.5402
15	.1715	.4588	.5243	.1448	.1867	.1524	1.5402
16		.3932	.5506	.1448	.2241		1.3927
17		.112	.112	.1448	.1494	.1829	.2054
18	.2058	.1867		.1966	.1829	.2035	.2427
19	.2401	.2241	.1494	.3258	.2614	.2439	.2987
20	.2229	.2241	.2801	.2957	.2987	.2743	.3361
21	.2058	.2263	.2241	.2587	.2614	.2743	.2987
22	.2058	.2241	.1867	.2534	.2641	.2439	.2801
23	.1715	.2241	.4481	.4706	.426	.2134	
24	.2033		.2241	.3932	.426	.4588	.2058
Max	.5487	.7209	.6882	1.0159	1.166	1.1012	1.5729
Min	.1638	.112	.112	.1448	.1494	.1524	.2054
Avg	.2926	.3376	.3846	.3323	.3989	.3678	.6688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 204 / 11KV KALAS GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.3772	.3361	.3361	.3258	.3772	.3601
2	.2353	.3961	.3584	.3361	.3258	.415	.3772
3	.3292	.4108	.3772	.3547	.3982	.4527	.3944
4	.3696	.4338	.415	.3734	.4706	.4904	.4801
5	.462	.5093	.4904	.4668	.6154	.5658	.4801
6	.5544	.6535	.6161	.6722	.6653	.6722	.6173
7	.6283	.6722	.6535	.5975	.6838	.6535	.6173
8	.499	.5415	.547	.5228	.5975	.5415	.4572
9	.3944	.4715	.3734	.462	.4338	.4115	.4854
10	.2743	.3547	.3113	.3696		.3772	.3547
11	.2572	.2614	.3547	.2957		.2743	.2801
12	.2229	.2241	.168	.2172		.2229	.2614
13	.2229	.2075	.1494	.2033	.2801	.2229	.2241
14	.2229	.2263	.112	.2218	.2241	.2229	.2241
15	.1543	.2263	.112	.2402	.2614	.2401	.2054
16	.1886	.1698	.1867	.2402	.2614	.2229	.2614
17	.2743	.1867	.2427	.2772	.2987	.2572	.2987
18	.2915	.3018	.3174		.3547	.4024	.3921
19	.4801	.4108	.4294	.4805	.5041	.4287	.4668
20	.4287	.4668	.5228	.4805	.5415	.4801	.5228
21	.3601	.3961	.4668	.462	.4481	.463	.4294
22	.3429	.3584	.3734	.4435	.3961	.4115	.3921
23	.3258	.3547	.3361	.4066	.3734	.3601	
24	.2402		.3395	.3361	.362	.3734	.3429
Max	.6283	.6722	.6535	.6722	.6838	.6722	.6173
Min	.1543	.1698	.112	.2033	.2241	.2229	.2054
Avg	.3333	.3744	.3579	.3824	.4201	.3975	.3880

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 205 / 11KV AKOLE-2 AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.3361	.3277	.2427	.2172	.2263	.7373
2	.3932	.2614	.3277	.2427	.2172	.2263	.7545
3	.3932	.3734	.3277	.2614	.2534	.2452	.7716
4	.4096	.3772	.3441	.2987	.2896	.2641	.7716
5	.4096	.3961	.3605	.3361	.3258	.2987	.7888
6	.4887	.415	.3605	.3734	.362	.3361	.7888
7	.4424	.5228	.4915	.3734	.4163	.3361	1.0288
8	.543	.6062	.6226	.2987	.3361	.3292	1.0669
9	.2286	.2614	.2801	.6516	.6882	.7316	.2987
10	.1829		.2241	.5898		.7468	.1867
11				.5735		.7926	.1307
12				.5735		.884	.112
13		.1494		.6554	.8848	.884	.112
14	.1829	.1494		.6554	.8848	.884	.112
15	.1524	.1867	.1494	.6226	.9175	.884	.112
16		.1867	.1494	.6226	.8097	.9145	.1494
17	.1829	.2241	.2054	.2949	.1867	.1219	.1867
18	.2134	.2241	.3361	.2622	.2195	.2683	.2614
19	.2439	.2614	.3361	.2896	.2614	.2439	.3361
20	.2286	.2614	.3361	.2896	.2987	.2743	.3361
21	.2134	.2641	.2987	.2896	.2614	.1715	.2987
22	.2134	.2614	.2801	.2534	.2641	.2439	.2614
23	.2743	.3277	.2427	.2534	.1867	.6706	
24	.426		.3353	.2427	.2534	.2241	.7202
Max	.543	.6062	.6226	.6554	.9175	.9145	1.0669
Min	.1524	.1494	.1494	.2427	.1867	.1219	.112
Avg	.3108	.3023	.3168	.3978	.4064	.4668	.4488



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 206 / 11KV BORI-BIRANGUDWADI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.3429	.3768	.5243	.5898	.7209	.381
2	.2949	.3429	.3768	.5407	.5898	.7537	.381
3	.2949	.3201	.3932	.5735	.5898	.7865	.3963
4	.3277	.3353	.4096	.6226	.7865	.852	.4115
5	.3605	.3658	.426	.6718	.9831	.9175	.4115
6	.3605	.3658	.4096	.9012	1.4746	1.3599	.4268
7	.3441	.3658	.4096	1.3763	1.7695	1.9334	.4115
8	.5079	.5487	.7701	.3605	.3605	.3932	1.2346
9	.4725	.639	.8848	.2622	.3113	.3201	1.6057
10	.442	.7045	.8684	.2622		.3048	1.8842
11	.442	.639	.7701	.2294		.2134	1.8351
12	.5335	.6554	.6062	.213		.2134	1.5893
13	.4877	.639	.5735	.2294	.2785	.2134	1.5074
14	.4572	.5735	.5735	.2294	.2622	.2134	1.4582
15	.4115	.5079	.5243	.213	.213	.2286	1.3763
16	.2286	.213	.1802	.2622	.2785	.2286	.2458
17	.1981	.213	.2294	.2949	.3277	.2439	.2785
18	.2134	.2458	.2785	.3277	.3277	.3605	.3277
19	.3048	.2949	.3605	.3605	.3932	.381	.3768
20	.3048	.3277	.3932	.4096	.426	.4115	.4096
21	.3201	.3441	.4424	.4525	.4096	.3658	.426
22	.3048	.3932	.426	.3932	.426	.381	.4424
23		.3768	.3932	.3932	.3932	.3963	
24	.3113	.3048	.3768	.5243	.5898	.7209	.381
Max	.5335	.7045	.8848	1.3763	1.7695	1.9334	1.8842
Min	.1981	.213	.1802	.213	.213	.2134	.2458
Avg	.3573	.4191	.4772	.4428	.5610	.5381	.7912

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214479 / 33/11kv kalas sub-station

Feeder No / Name : 207 / 11KV JAYHIND EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1307				
2	.1478		.112				
3			.132				
4			.1132				
5			.1132				
6			.112				
7			.1307				
8			.0747				
9		.1307		.0924	.0492	.1067	.1867
10		.112		.1478		.0914	.1867
11		.0934		.1478		.1372	.168
12		.1307		.1848		.1219	.1494
13		.0943		.1663	.0732	.0762	.168
14		.0943		.1663	.1463	.0914	.1867
15		.1132		.1663	.1307	.1219	.1867
16		.1307		.1848	.112	.1067	.1867
17	.0107	.1307		.1848	.132	.0914	.1494
18		.1307		.1848	.112	.061	.1867
19		.0934		.1848	.112	.061	.1867
20	.0076	.0934		.1848	.0732		.1867
21	.0061	.1132					
22	.0061	.112					
23	.0061	.112					
24			.112				
Max	.1478	.1307	.132	.1848	.1463	.1372	.1867
Min	.0061	.0934	.0747	.0924	.0492	.061	.1494
Avg	.0307	.1123	.1145	.1663	.1045	.0970	.1774

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 201 / 11KV DHEKALEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4557		.7291	.6443		.4908
2		.4908		.78	.7122		.5083
3		.5434		.8309	.7969		.5434
4		.5959		.9156	.8478		.5959
5		.631		1.0174	1.0867		.6485
6	.8413	.6836	.7011	1.17	1.2094	.9665	.7186
7	.8589	.7186	.7362	1.3395	1.262	1.1869	.7888
8	.6836	.7186	.7186	1.3565	1.2971	1.1869	.6661
9	.9326	1.0277	.9665	.5258	.5256	.5083	1.2717
10	.8951	.9835	1.1022	.407	.4207	.3856	1.3226
11	.8987		.9835	.3222	.3681	.3681	1.2717
12	.8648	.8139	.8987	.2543		.3506	1.3226
13	.6104	.7291	.8139	.2374		.333	1.2717
14	.373	.6783	.763	.2374	.3155	.333	1.1869
15	.373	.6613	.0339	.2374	.333	.3155	1.2548
16	.39	.7122	.1526	.3222	.3681	.3155	1.2378
17	.4207	.333	.3681	.3561	.4031	.4908	.4031
18	.5258	.5258	.5258	.4748	.5083	.5609	.4207
19	.631	.6661	.631	.4748	.631	.5959	.631
20	.5258	.6485	.5959	1.3622	.5959	.6135	.6135
21	.5434	.5784	.5609	.4409	.5609	.5609	.5784
22	.5258	.5258	.5258	.4239	.5258	.5434	.5609
23	.4733	.4908	.7122	.5784	.7461	.5083	.5083
24	.4557	.4557	.4733	1.2498	.5959	.7291	.4908
Max	.9326	1.0277	1.1022	1.3622	1.2971	1.1869	1.3226
Min	.373	.333	.0339	.2374	.3155	.3155	.4031
Avg	.6223	.6377	.6454	.6685	.6707	.5712	.8045

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 202 / KRUSHNA MANDIR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943		.0943	.1132		.132
2		.1132		.1132	.1132		.1509
3		.1132		.1132	.132		.1509
4		.1509		.1509	.1698		.1886
5		.1886		.1886	.2075		.1886
6	.2452	.2263	.2452	.2263	.2452	.2641	.2263
7	.2452	.2641	.2829	.2641	.2641	.2829	.2641
8	.2075	.2075	.1886	.2075	.2452	.2263	.2263
9	.1698	.2075	.1886	.2075	.1698	.2075	.1886
10	.1509	.1698	.1509	.1509	.1509	.1886	.1698
11	.132		.1132	.132	.1509	.1698	.132
12	.1132	.132	.132	.132		.1698	.132
13	.0943	.1132	.132	.1132		.1509	.132
14	.1132	.0943	.1132	.0943	.1132	.1509	.132
15	.1132	.0943	.1132	.0943	.132	.1509	.1132
16	.1132	.0943	.0943	.1132	.132	.1509	.132
17	.1698	.1509	.1698	.1132	.1132	.1698	.1698
18	.1698	.1132	.1509	.132	.1698	.1829	.1698
19	.1886	.1509	.1698	.1698	.1886	.2075	.2263
20	.1886	.1698	.1698	.1886	.2075	.2075	.1886
21	.1509	.1698	.1509	.1698	.1698	.1886	.1886
22	.1509	.1698	.132	.1698	.1509	.1698	.1509
23	.0943	.132	.0943	.132	.132	.132	.132
24	.0943	.0943	.0943	.0943	.1132	.132	.132
Max	.2452	.2641	.2829	.2641	.2641	.2829	.2641
Min	.0943	.0943	.0943	.0943	.1132	.132	.1132
Avg	.1529	.1484	.1519	.1485	.1629	.1844	.1674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 203 / 11KV BELWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3812		.2454	.2321		.6962
2		.4144		.2804	.2155		.7459
3		.4641		.2804	.2155		.8122
4		.5138		.333	.2486		.9448
5		.5801		.3856	.2984		1.0774
6	.3812	.6962	.5138	.4382	.3647	.3856	1.326
7	.6464	.8288	.8619	.4733	.3481	.4382	1.5249
8	1.0442	1.1271	1.0774	.3506	.3481	.333	1.4586
9	.2629	.2804	.2804	.9779	1.21	1.5746	.1753
10	.2103	.2279	.1928	1.0692	1.0774	1.9559	.1052
11	.1753		.1753	1.4022	1.5581	2.2045	.0876
12	.1753	.2103	.1578	1.3146		1.8067	.0876
13	.1578	.1753	.0526	1.2269		1.989	.0876
14	.1578	.1753	.0701	1.1393	1.3592	1.9559	.0876
15	.1578	.1753	.1402	1.0692	1.5746	1.8067	.0876
16		.1928	.1753	.964	1.6078	1.7736	.1052
17	.2629	.2103	.1928	.2103	.2279	.2454	.2279
18	.2804	.1928	.2454	.1823	.2454	.2804	.2279
19	.3155	.2454	.3155	.2321	.333	.2804	.298
20	.298	.298	.2804	.2652	.298	.2804	.2804
21	.2804	.298	.2629	.2486	.2804	.2454	.2629
22	.2279	.2629	.2629	.2486	.2629	.2629	.2629
23	.3812	.3812	.2454	.2321	.2454	.6962	.7625
24	.3978	.3812	.3812	.2454	.2321	.2454	.6796
Max	1.0442	1.1271	1.0774	1.4022	1.6078	2.2045	1.5249
Min	.1578	.1753	.0526	.1823	.2155	.2454	.0876
Avg	.3230	.3788	.3097	.5756	.5811	.9874	.5172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 204 / 11KV BORI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1949		.0358	.0358		.4298
2		.2126		.0358	.0358		.443
3		.2303		.0179	.0358		.4607
4		.2303		.0179	.0358		.4607
5		.2658		.0358	.0537		.4961
6	.2126	.2658	.3012	.0537	.0716	.0895	.5316
7	.2303	.2835	.3721	.0537	.0716	.0537	.567
8	.2658	.3012	.3898	.0537	.0895	.0716	.6024
9	.0537	.0537	.0537	.4784	.4784	.691	.0537
10	.0537	.0537	.0537	.5138	.5138	.815	.0537
11	.0537		.0537	.567	.5138	.8682	.0358
12	.0537	.0358	.0354	.6024		.9036	.0358
13		.0358	.0354	.6379		.8682	.0358
14	.0537	.0179	.0358	.6201	.6024	.8682	.0358
15		.0179	.0537	.6379	.691	.8328	.0179
16		.0358	.0537	.6201	.6733	.815	.0179
17		.0358	.0537	.0358	.0537	.0537	.0358
18		.0358	.0537	.0358	.0537	.0537	.0537
19		.0537	.0537	.0537	.0537	.0537	.0537
20		.0716	.591	.0716	.0537	.0537	.0537
21		.0537	.0537	.0537	.0537	.0716	.0537
22	.0537	.0537	.0537	.0537	.0358	.0537	.0537
23	.1949	.2303	.0537	.0537	.0358	.4252	.5316
24	.2126	.1949	.2303	.0549	.0537	.0358	.4252
Max	.2658	.3012	.591	.6379	.691	.9036	.6024
Min	.0537	.0179	.0354	.0179	.0358	.0358	.0179
Avg	.1308	.1289	.1359	.2248	.1953	.4041	.2308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 205 / 11KV SANASAR GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.567		.6036	.5853		.5487
2		.6401		.6401	.5487		.6401
3		.7133		.7133	.567		.695
4		.7865		.7682	.6401		.7499
5		.8962		.8413	.7316		.8962
6	1.2803	.9694	1.1888	.9511	.9511	1.1157	1.0608
7	1.2437	1.0974	1.2437	1.0608	.8962	1.1523	1.2071
8	.9877	1.0425	.8596	.8779	.9145	1.0608	.8596
9	.8779	.8596	.823	.8779	.9145	.9328	.7865
10	.7499	.5853	.6584	.7316	.5853	.7865	.7682
11	.6219		.4572	.567	.695	.6584	.439
12	.5487	.4755	.5316	.5304		.567	.3292
13	.3658	.6036	.4572	.4938		.4572	.4207
14	.4572	.5853	.4938	.4938		.4755	.5487
15		.567	.5121	.5121	.2926	.5487	.5853
16	.4207	.6584	.5121	.4755	.3109	.5487	.6584
17		.6767	.4755	.5853	.3292	.695	.6584
18	.7865	.6219	.5487	.6219	.7499	.7316	.7316
19	.823	.823	.7316	.7316	.9328	.8413	.695
20	.9145	.9145	.695	.8413	1.0059	.9145	.8779
21	.823	.7499	.6767	.823	.7682	.7316	.6767
22	.6219	.7316	.5487	.7682	.7316	.695	.6036
23	.5487	.6036	.6036	.6767	.5121	.5487	.567
24	.5304	.5487	.567	.6036	.6767	.4755	.5487
Max	1.2803	1.0974	1.2437	1.0608	1.0059	1.1523	1.2071
Min	.3658	.4755	.4572	.4755	.2926	.4572	.3292
Avg	.7413	.7268	.6623	.6996	.6828	.7335	.6897

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214487 / 33 KV Sansar

Feeder No / Name : 206 / 11KV CHATRAPATI KARKHANA SINGLE PHASING  
AG Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5316		.8078	.9431		.5316
2		.583		.8383	.9602		.5658
3		.6516		.884	.9945		.6001
4		.7202		.9907	1.0288		.6687
5		.823		1.1279	1.1488		.7716
6	1.046	.9602	1.0288	1.2498	1.286	1.1736	.8745
7	1.2003	1.1488	1.1317	1.3717	1.4746	1.6156	.9945
8	.9259	.9259	.9259	1.4022	1.6461	1.2193	.8745
9	.9755	2.4387	1.1279	.7545	.6249	.8059	1.3565
10	.9602	.9907	1.1584	.5182	.583	.6516	1.7071
11	.9602		1.2346	.4725	.5316	.5316	1.4022
12	1.0364	.8078	1.1736	.4268		.5144	1.768
13	.945	.884	1.1584			.4801	1.89
14	.9297	.8383	1.0974		.583	.4801	1.5089
15	.9145	.884	1.0212		.5487	.4973	1.6461
16	.8993	.945	1.0364	.503	.5658	.4973	1.5546
17	.6001	.6001	.5658	.5792	.6344	.6687	
18	.7373	.6344	.6344	.6249	.7373	.8059	.6859
19	.8573	.7545	.8916	.6401	.9259	.8059	.7888
20	.7716	.8059	.8402	.6859	.8059	.8059	.7202
21	.703	.7373	.7373	.6401	.7373	.7373	.6687
22	.7061	.6859	.6859	.6097	.6516	.7202	.6173
23	.4973	.5487	.7926	.8573	.9145	.5658	.4973
24	.5144	.4973	.5487	.7926	.9259	.945	.5316
Max	1.2003	2.4387	1.2346	1.4022	1.6461	1.6156	1.89
Min	.4973	.4973	.5487	.4268	.5316	.4801	.4973
Avg	.8516	.8433	.9364	.7989	.8751	.7643	1.0098



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 201 / 11KV PIMPALE AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3077	.2591	.2286	.2286	.2058	.6093
2	.3077	.3077	.2753	.2286	.2286	.2058	.6093
3	.3077	.2915	.2753	.2286	.2286	.1886	.6093
4	.3077	.2915	.2915	.2477	.2477	.2229	.7621
5	.3077	.2915	.2915	.3239	.2858	.2915	.6249
6	.3077	.2915	.3239	.4191	.4001	.3772	.6249
7	.3401	.4372	.4049	.4763	.4572	.4115	.8592
8	.4534	.4372	.5182	.4001	.381	.3772	1.085
9	.3048	.2572	.2572	.4001	.6401	.8987	.3222
10		.1543	.2058	.6287	.6249	1.0202	.2204
11	.1905	.1543	.1543	.6478	.7125	1.1336	.1357
12	.1905	.1543	.1715	.6478	.6613	1.166	.1357
13	.1334	.1372	.1715	.5716	.763	1.0936	.1187
14		.1372	.1524	.6287	.8139	1.1336	.12
15		.1372	.1715	.5906	.8139	1.1498	.1357
16	.1457	.12	.1715	.7049	.9393	1.1174	.1187
17	.1905	.1715	.2096		.1357	.2286	.1865
18	.2477	.1715	.2667	.2667	.2401	.2667	.1886
19	.2858	.2229	.3239	.3429	.2915	.3239	.2915
20	.3429	.2572	.381	.3239	.3429	.362	.2743
21	.3048	.2401	.3048	.2858	.2572	.2477	.2572
22	.2667	.2401	.2667	.2667	.2374		.2204
23	.3239	.2429	.2477	.2477	.2204	.2667	.7125
24	.3239	.3239	.2591	.2286	.2286	.2204	.6093
Max	.4534	.4372	.5182	.7049	.9393	1.166	1.085
Min	.1334	.12	.1524	.2286	.1357	.1886	.1187
Avg	.2813	.2407	.2648	.4059	.4325	.5613	.4096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 202 / 11KV LAMJEWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0514	.1334	.1334	.1296	.0953
2	.0572	.0572	.0514	.1334	.1334	.1134	.0953
3	.0572	.0762	.0686	.1334	.1334	.1134	.1143
4	.0572	.0762	.0686	.1334	.1334	.1296	.1334
5	.0762	.0953	.0857	.1524	.1334	.1619	.1524
6	.0953	.1143	.1029	.1524	.1524	.192	.1715
7	.0953	.1524	.12	.2286	.2477	.2915	.2096
8	.1524	.1524	.12	.3048	.362	.2753	.2477
9	.1457	.1457	.1457	.1715	.1524	.1017	.4049
10		.1619	.2105	.1334	.12	.1017	.4858
11	.125	.1457	.1943	.0953	.1029	.0678	.4858
12	.125	.1457	.1905	.1334	.1187	.0678	.5344
13	.1457	.1296	.2286	.1143	.1017	.0953	.5668
14		.1457	.2286	.1524	.1017	.0848	.583
15		.1619	.2096	.1143	.1187	.0848	.6154
16	.0972	.1296	.1905	.1143	.1187	.0678	.583
17	.0762	.0514	.0572	.1143	.1526	.1143	.0848
18	.0953	.0686	.1524	.1143	.12	.1334	.12
19	.0953	.0686		.1334	.1543	.1524	.1543
20	.1143	.1029	.1715	.1524	.1543	.1524	.1543
21	.0953	.0857	.1334	.1524	.1372	.1143	.1372
22	.0572	.0686	.1143	.1334	.1187		.1017
23		.0514	.1334	.1524	.1296	.1143	.1017
24	.0572	.0572	.0514	.1334	.1334	.1296	.0953
Max	.1524	.1619	.2286	.3048	.362	.2915	.6154
Min	.0572	.0514	.0514	.0953	.1017	.0678	.0848
Avg	.0939	.1042	.1339	.1453	.1443	.1300	.2678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 203 / 11KV SHETPHALGADE AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	.12	.1905	.2096	.1943	.1524
2	.1334	.1334	.1372	.1905	.2096	.1943	.1524
3	.1334	.1524	.1543	.1905	.2096	.1781	.1524
4	.1524	.1715	.1715	.1905	.2286	.1943	.1715
5	.1715	.1905	.2058	.2477	.3048	.2267	.1905
6	.2096	.2286	.2401	.3048	.381	.2881	.2477
7	.2667	.3048	.2572	.4572	.5716	.5182	.3429
8	.3048	.2667	.2058	.4382	.5525	.5506	.3048
9	.2105	.2591	.2105	.1905	.2096	.1696	.421
10		.2267	.2915	.1524	.1524	.1696	.7449
11	.2031	.3239	.3077	.1334	.12	.1696	.8745
12	.2105	.3239	.3048	.1143	.1017	.1187	.8745
13	.2187	.3401	.3429	.0953	.1187	.1334	1.0364
14		.2915	.4763	.0953	.1187	.1017	1.004
15		.3077	.4572	.1143	.1187	.1357	1.1174
16	.2105	.2429	.4001	.1334	.1187	.1526	.9555
17	.1715	.12	.0953	.1143	.0848	.1905	.0848
18	.1905	.1543	.1715	.1524	.1029	.2096	.1543
19	.2096	.1715	.2286	.2667	.1715	.2667	.2229
20	.2286	.1715	.2477	.2667	.2058	.2286	.1886
21	.1905	.1543	.2096	.2096	.1715	.1905	.1543
22	.1524	.1543	.1524	.1905	.1526		.1357
23	.1334	.12	.1905	.2286	.1619	.1905	.1187
24	.1334	.1143	.1029	.1905	.2096	.2105	.1524
Max	.3048	.3401	.4763	.4572	.5716	.5506	1.1174
Min	.1334	.1143	.0953	.0953	.0848	.1017	.0848
Avg	.1890	.2099	.2367	.2024	.2078	.2166	.4148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 204 / 11KV SHETPHALGADE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1698	.1715	.1905	.1886	.1715
2	.1715	.1715	.1886	.1715	.1905	.1698	.1715
3	.1715	.1715	.2641	.1524	.1715	.1698	.1905
4	.1905	.1905	.3018	.1905	.1905	.1698	.2286
5	.2667	.2858	.3395	.2667	.3048	.2829	.3429
6	.362	.381	.415	.4763	.4572	.4527	.4382
7	.5144	.5144	.5281	.5335	.5525	.5281	.5335
8	.4763	.4191	.3584	.4572	.381	.4715	.4382
9	.362	.3395	.2641	.3239	.3239	.3018	.3018
10		.2263	.1698	.2286	.2286	.2452	.1886
11	.2096	.132	.1698	.1905	.1886	.1886	.1886
12	.1905	.1509	.1334	.1715	.1357	.1698	.1886
13	.1715	.2075	.1334	.1715	.1526	.1524	.132
14		.132	.1334	.1715	.1357	.1132	.1494
15		.132	.1334	.1334	.1526	.1509	.1698
16	.1296	.1886	.1524	.1715	.1698	.132	.1698
17	.1905	.1886	.1905		.1696	.1905	.2241
18	.2477	.1886	.2858	.2858	.2829	.2667	.2427
19	.381	.2452	.3429	.3429	.3206	.3429	.3206
20	.3429	.3018	.3429	.362	.3584	.362	.3206
21	.2858	.2829	.2667	.3048	.2572	.2858	.2829
22	.1905	.2075	.2286	.2477	.2035	.2096	.2452
23	.1715	.1509	.1905	.2096	.1886	.1905	.1698
24	.1524	.1524	.1698	.1715	.1905	.1886	.1715
Max	.5144	.5144	.5281	.5335	.5525	.5281	.5335
Min	.1296	.132	.1334	.1334	.1357	.1132	.132
Avg	.2538	.2297	.2447	.2568	.2457	.2468	.2492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 205 / 11KV MHASOBACHI WADI AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4954	.4458	.6478	.6478	.5668	.4954
2	.4572	.5335	.4801	.6287	.6287	.5668	.5335
3	.4954	.6097	.583	.6287	.6287	.583	.5716
4	.5716	.6859	.6516	.6478	.6287	.6316	.6668
5	.743	.7621	.7545	.6859	.6287	.6802	.7621
6	.9145	.9907	.9431	.724	.6859	.7202	.9335
7	.9907	1.0479	1.046	.7811	.9335	1.085	1.105
8	1.0098	1.0288	.8573	.9335	.8954	1.085	1.0288
9	.3077	.502	.5992	.5906	.7049	.6274	1.0004
10		.583	.6316	.381	.5144	.4917	1.2631
11	.3906	.6316	.664	.3239	.3391	.407	1.3927
12	.4763	.6154	.7621	.3048	.3561	.2883	1.3603
13	.4858	.4858	.7811	.2477	.3222	.3048	1.4089
14		.5992	.724	.2667	.2543	.3222	1.4413
15		.583	.7049	.2477	.2883	.3052	1.3117
16	.5335	.502	.6859	.2858	.39	.2883	1.3441
17	.5144	.3258		.362	.407	.3239	.3391
18	.5144	.463	.5335	.4572	.5316	.5716	.463
19	.6097	.5487	.6287	.724	.7202	.724	.6344
20	.743	.583	.7811	.724	.7545	.8002	.6344
21	.5525	.4801	.6097	.6097	.5487	.5906	.583
22	.4763	.4287	.5144	.5144	.4409		.5087
23	.4572	.3601	.5906	.7049	.4858	.4572	.4409
24	.4001	.4572	.3772	.6478	.6478	.583	.4572
Max	1.0098	1.0479	1.046	.9335	.9335	1.085	1.4413
Min	.3077	.3258	.3772	.2477	.2543	.2883	.3391
Avg	.5735	.5959	.6674	.5446	.5576	.5654	.8617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214498 / 33/11 KV SHETFALGADE

Feeder No / Name : 206 / 11KV NIRGUDE AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.3048	.2915	.2858	.2477	.1886	.7621
2	.2591	.2753	.3239		.2286	.1715	.6405
3	.2753	.2812	.3563	.2667	.2286	.1715	.6562
4	.2656	.3239	.3887	.2858	.2477	.2058	.8192
5	.2915	.3887	.421	.3048	.2858	.2401	.703
6	.3077	.4372	.4696	.3239	.381	.2713	.7186
7	.3077	.4372	.5344	.4001	.4001	.3772	.9878
8	.4191	.4696	.5344	.4001	.4191	.3258	1.1174
9	.2286	.2572	.3086	.6668	.7316	.8259	.3222
10		.1886	.2572	.6668	.7773	.9717	.3052
11	.1524	.1886	.2058	.7049	.6316	.9878	.2883
12	.1524	.1886	.2477	.7049	.7287	1.0202	.2883
13	.2286	.2058	.2477	.6859	.8259	1.0311	.2543
14		.2229	.3048	.743	.8583	1.1012	.2743
15		.2058	.2858	.743	.7449	1.1822	.2543
16	.2096	.2229	.2667	.743	.7773	1.1336	.2883
17	.2286	.2229		.2667	.2204	.381	.2883
18	.2477	.2229	.2667	.3048	.2401	.4001	.3429
19	.2667	.3086	.2858	.2667	.2915	.4001	.3601
20	.3048	.2915	.3239	.3239	.3086	.4382	.3772
21	.2858	.2572	.3239	.3048	.2915	.3429	.3429
22	.2667	.2743	.3429	.2667	.2713		.3052
23	.2591	.3563	.2858	.2477	.2035	.4763	.6964
24	.2591	.2591	.3725	.2858	.2477	.2035	.6249
Max	.4191	.4696	.5344	.743	.8583	1.1822	1.1174
Min	.1524	.1886	.2058	.2477	.2035	.1715	.2543
Avg	.2607	.2830	.3324	.4432	.4412	.5586	.5007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214530 / 33/11 KV LASURNE

Feeder No / Name : 201 / 11 KV BAJARANGWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0754	.0554	.1875	.2926	.2561	.0554
2	.0732	.0754	.0554	.2214	.2926	.2561	.0554
3	.0732	.0943	.0739	.2214	.2926	.2926	.0739
4	.0732	.0943	.0739	.253	.3292	.3292	.0739
5	.0732	.1132	.0924	.2881	.3658	.3163	.1109
6	.1097	.1132	.1294	.3201	.5693	.3185	.1478
7	.1097	.112	.1097	.5487	.8048	.602	.1294
8	.0732	.0754	.0747	.828	1.0974	.8109	.0739
9	.3612	.3963	.5335	.0566	.0732	.0732	.6859
10	.4988	.4877	.6097	.0366	.0543	.0358	.9556
11	.333	.4572	.5792	.0366	.037	.0537	1.012
12	.3765	.3201	.5201	.0366	.0366	.0716	
13	.3102	.381	.4841	.0366		.0549	
14	.2896	.3506	.4054	.0366	.0549	.0732	.7819
15	.2858	.3048	.4012	.0732	.052	.0549	.9267
16	.2896	.3048	.442	.0366	.052	.0549	.8688
17	.037	.0366	.0526	.0366	.0537	.0724	.0366
18	.0554	.0554	.0554	.0366	.0709	.0732	.0732
19	.0747	.0739	.0754	.0732	.0924	.0732	.1097
20	.0754	.0732	.0754	.0732	.0732	.0914	.0732
21	.0754	.0739	.0754	.0732	.0732	.0914	.0739
22	.0754	.0739	.0754	.0732	.0732	.0732	.0732
23	.0754	.056	.1875	.2926	.2561	.0732	.0732
24	.0732	.0754	.0554	.1875	.2926	.2561	.0554
Max	.4988	.4877	.6097	.828	1.0974	.8109	1.012
Min	.037	.0366	.0526	.0366	.0366	.0358	.0366
Avg	.1644	.1781	.2205	.1693	.2343	.1858	.2964

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214530 / 33/11 KV LASURNE

Feeder No / Name : 202 / 11 KV RAJMUDRA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6874	.7373	.7499	.1886	.1829	.1463	1.1843
2	.8048	.7373	.7343	.2263	.1463	.1478	1.1203
3		.7537	.7499	.2452	.1463	.1463	1.1203
4		.7773	.7811	.2641	.1463	.1829	1.1523
5		.7865	.8124	.3018	.1829	.2561	1.1843
6		.8192	.828	.3395	.2195	.2926	1.3283
7	.8535	.9282	.9998	.3018	.2561	.2195	1.6842
8	.9934	1.2163	1.1405	.2452	.2195	.2195	2.0243
9	.1829	.1886	.128	1.2018	1.5364	1.5954	.1663
10	.1494	.1494	.1294	1.448	1.7166	2.1445	.0732
11	.112	.1294	.112	1.5059	1.7924	2.2775	.1097
12	.0924	.1097	.0732	1.6385	1.7604	2.2283	.0732
13	.0924	.0739	.0914	1.5623		2.1628	.1097
14	.0914	.128	.1097	1.4685	1.6324	2.1862	.1097
15	.1086	.0924	.0724	1.39	1.9109	2.0645	.112
16	.112	.1097	.0724	1.448	1.7924	1.9433	.1097
17	.1494	.1097	.1097	1.4335	.1097	.1294	.1097
18	.1886	.128	.1478	.1097	.1494	.1663	.1829
19	.2263	.1829	.2241	.1829	.2241	.1848	.1829
20	.2263	.2218	.2427	.1829	.2195	.2218	.1829
21	.2075	.2012	.2263	.1829	.2195	.2033	.1829
22	.1886	.1848	.2263	.1829	.2172	.2033	.2195
23	.7287	.7655	.1886	.1829	.1829	1.1843	.9633
24	.8048	.7209	.7499	.1886	.1829	.1829	1.1843
Max	.9934	1.2163	1.1405	1.6385	1.9109	2.2775	2.0243
Min	.0914	.0739	.0724	.1097	.1097	.1294	.0732
Avg	.3500	.4272	.4042	.6842	.6585	.8621	.6196



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214530 / 33/11 KV LASURNE

Feeder No / Name : 203 / 11 KV JACHAK

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2035	.1783	.1132	.1097	.1463	.3795
2	.2561	.2401	.1783	.1132	.1097	.1463	.4111
3	.2561	.2401	.1783	.1132	.1097	.1463	.016
4	.2926	.2347	.208	.132	.1097	.1463	.4744
5	.3292	.3052	.2378	.1509	.1829	.1829	.5218
6	.4024	.3429	.3269	.2641	.2195	.2195	.6325
7	.4687	.5182	.4904	.2641	.2561	.2195	.9172
8	.7316	.6081	.6093	.2263	.1829	.2195	1.1385
9	.1463	.1886	.1478	.6249	.7274	1.0974	.1097
10	.1307	.1294	.1132	.7529	.8962	1.1227	.0732
11	.0747	.0732	.0747	.7529	.9488	1.2651	.0732
12	.0732	.0732	.056	.9145	.9922	1.3599	.0732
13	.0732	.0554	.0732	.695		1.3125	.0732
14	.0732	.0739	.0549	.724	.7499	1.2334	.0732
15	.0724	.1097	.056	.695	.9804	1.1385	.0732
16	.0739	.0732	.0543	.9145	.9374	1.1069	.0732
17	.1086	.1109	.0747	.7819	.1097	.1294	.1097
18	.1509	.1109	.112	.0732	.1478	.1663	.1097
19	.1698	.1463	.1509	.1463	.1509	.1463	.1829
20	.1698	.1646	.1698	.1463	.1886	.1463	.1829
21	.1509	.1478	.1509	.1463	.1463	.1478	.2195
22	.132	.1294	.1509	.1463	.1097	.128	.2195
23	.2012	.1783	.1132	.1097	.1097	.3795	.4214
24	.2195	.2035	.1783	.1132	.1097	.1463	.3795
Max	.7316	.6081	.6093	.9145	.9922	1.3599	1.1385
Min	.0724	.0554	.0543	.0732	.1097	.128	.016
Avg	.2074	.1942	.1724	.3797	.3733	.5189	.2891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214530 / 33/11 KV LASURNE

Feeder No / Name : 204 / 11 KV LASURNE GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.8865	.9335	.9054	.8779	.8413	.9335
2	.8779	.8676	.9335	.9242	.8779	.8413	.9335
3	.9511	.9054	.9522	.9431	.9145	.8779	.9709
4	.9877	.9808	1.0642	.9808	.9511	.8871	1.0829
5	1.0608	1.094	1.2323	1.094	1.0608	.9145	1.251
6	1.1706	1.4712	1.4266	1.4335	1.1706	1.39	1.4969
7	1.0974	1.3817	1.3306	1.3443	1.3169	1.2803	1.2197
8	1.0974	1.1203	1.1273	1.0829	1.0974	1.1706	.9877
9	.9877	1.0349	.9145	.8131	.8413	.9145	.8413
10	.8048	.8686	.724	.7316	.8326	.7964	.5853
11	.7164	.8131	.6805	.6584	.6878	.724	.5487
12	.6089		.5373	.5487	.591	.6697	.6219
13	.543	.6584	.5014	.5121		.5068	
14	.4706	.3696	.5014	.5121	.6024	.5792	.5487
15	.5068	.5853	.5068	.5487	.5792	.6584	.5487
16	.3982	.6219	.5014	.5487	.6089	.695	.5853
17	.6516	.7316	.5792	.7682	.7087	.8326	.7316
18	.7762	.695	.6516	.8048	.7964	.9877	.8048
19	1.1203	.9511	1.0829	1.0974	1.1088	1.0974	1.0974
20	1.0562	1.0719	1.1576	1.1706	1.1706	1.1523	1.0974
21	.9431	1.0242	1.0562	.9877	.9877	1.0608	1.1088
22	.9335	.9795	1.0082	1.0242	.9709	.9877	1.0242
23	.8676	.9149	.9054	.8779	.8413	.9149	.9335
24	.8048	.8676	.8871	.9054	.8779	.8413	.8962
Max	1.1706	1.4712	1.4266	1.4335	1.3169	1.39	1.4969
Min	.3982	.3696	.5014	.5121	.5792	.5068	.5487
Avg	.8447	.9085	.8832	.8841	.8901	.9009	.9065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214530 / 33/11 KV LASURNE

Feeder No / Name : 205 / 11 KV LINGE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.2075	.1848	.8539	.8223	.8901	.2218
2	.1463	.1886	.1848	.8223	.8124	1.1706	.2402
3	.1463	.2263	.1848	.8855	.8749	.9179	.2587
4	.1829	.2263	.2218	.8855	.8398	1.0235	.2587
5	.2195	.2641	.2402	.9282	.9488	1.0936	.2957
6	.2561	.2641	.2587	.9717	1.134	1.2803	.3326
7	.2561	.2263	.2402	1.1843	1.3169	1.4998	.2957
8	.2195	.2263	.2012	1.2308	1.1584	1.2071	.2033
9	.9374	.8539	.8124	.2054	.1829	.2126	1.2029
10	.9488	.9922	.9172	.1463	.1848	.2926	1.1004
11	.9998	.9602	.9172	.1463	.1463	.2378	1.1439
12	.9877	.8962	1.0311	.0754	.1086	.2012	1.4548
13	1.0311	.9762	1.0185	.1097		.2172	1.5074
14	.9061	.9282	.9259	.1097	.124	.197	1.3321
15	.9259	.9122	.9686	.1097	.1267	.181	1.3546
16	.8951	.8642	.9998	.1097	.1829	.2172	1.2742
17	.1086	.0724	.1086	.1463	.1829	.181	.1097
18	.1478	.1097	.128	.1463	.2149	.2172	.1463
19	.2054	.1646	.2054	.1463	.2587	.2353	.2561
20	.2241	.1829	.2614	.2195	.2926	.2534	.2195
21	.2263	.2195	.2263	.1829	.2561	.2534	.2195
22	.1867	.1991	.1886	.1829	.2587	.2353	.1829
23	.1886	.1848	.8539	.7529	.9267	.2218	.1829
24	.1463	.1886	.1848	.8539	.7529	.9267	.2218
Max	1.0311	.9922	1.0311	1.2308	1.3169	1.4998	1.5074
Min	.1086	.0724	.1086	.0754	.1086	.181	.1097
Avg	.4433	.4389	.4777	.4752	.5264	.5568	.5840

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214535 / 33/11 KV SHELGAON

Feeder No / Name : 201 / 11KV KADBANWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.1187	.1526	.3052	.373	.39	.1526
2	.1017	.1187	.1696	.3052	.373	.39	.1526
3	.1187	.1357	.1865	.3052	.39	.4239	.1696
4	.1357	.1357	.1865	.3391	.407	.4239	.1696
5	.1526	.1526	.2035	.3391	.4239	.4578	.2035
6	.1526	.1696	.2035	.373	.4239	.4917	.2204
7	.2035	.2035	.2035	.5765	.7461	.8817	.2204
8	.1696	.1357	.1696	.5935	.6783	.9156	.1696
9	.3052	.1187	.1187	.1017	.1526	.1526	.6274
10	.2543	.1017		.0848	.1017	.1357	.6104
11	.2713	.1017		.0678	.0678	.0848	.5935
12		.0848		.0509	.0678	.0848	.6443
13		.0848		.0678	.0678	.1017	.5426
14		.0678		.0678	.0678	.1017	.4748
15		.1017		.0678	.0678	.1017	.4409
16	.2883	.0678		.0678	.0678	.1017	
17	.1017	.4748		.0678	.0678	.1357	.0848
18	.1017	.5087		.1017	.0678	.1526	.0848
19	.1526	.4748			.1357	.1526	.1357
20	.1526	.407			.1696	.1865	.1357
21	.1357	.373			.1526	.1696	.1357
22	.1187	.3391			.1357	.1696	.1357
23	.1187	.3052			.1357	.1526	.1357
24	.1017	.1187	.3052	.3052	.1357	.1357	.1526
Max	.3052	.5087	.3052	.5935	.7461	.9156	.6443
Min	.1017	.0678	.1187	.0509	.0678	.0848	.0848
Avg	.1619	.2042	.1899	.2204	.2282	.2706	.2780

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214535 / 33/11 KV SHELGAON

Feeder No / Name : 202 / 11KV TELODHA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.5093	.3772	.1509	.1886	.1509	.1886
2	.1886	.5093	.4338	.1509	.2075	.1509	.1886
3	.2075	.4715	.4904	.1698	.2075	.1698	.2075
4	.2075	.4715	.4904	.1886	.2263	.1886	.2075
5	.2263	.547	.547	.2263	.2452	.2263	.2452
6		.6036	.6036	.2641	.2829	.2829	.3018
7		.7922	1.0562	.2829	.2452	.2452	.2452
8		.9431	1.1317	.2075	.2452	.2075	.2075
9		.2263		1.0374	.9431	1.1317	.1509
10	.132	.1698		1.1317	.9242	1.358	.1132
11	.132	.1698		1.0374	1.0562	1.358	.1132
12	.1132	.1509		1.0185	1.094	1.3392	.0943
13	.0943	.1132		1.0185	1.0751	1.358	.0754
14	.0943	.0943		.9054	1.0562	1.3392	.0754
15		.1132		.9619	1.094	1.2449	.0943
16	.132	.1132		.9431	1.1317	1.2637	.0943
17	.6413	.1132		.1132	.1698	.1886	1.0562
18	.679	.1509			.1509	.2263	1.0562
19	.6413	.2075			.1886	.2263	1.1506
20	.6036	.1886			.2263	.2075	1.0374
21	.5658	.1886			.2075	.2075	.9431
22	.5281	.1509			.1886	.2075	.8865
23	.5281	.1509			.1509	.1886	.8299
24	.5281	.5093	.1509	.1509	.1886	.1509	.1886
Max	.679	.9431	1.1317	1.1317	1.1317	1.358	1.1506
Min	.0943	.0943	.1509	.1132	.1509	.1509	.0754
Avg	.3385	.3191	.5868	.5533	.4873	.5674	.4063

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214535 / 33/11 KV SHELGAON

Feeder No / Name : 203 / 11KV NAZARKAR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.1658	.1326	.1326	.1658	.1658	.663
2	.547	.1658	.1658	.1326	.1658	.1658	.6299
3	.5801	.1492	.1989	.1492	.1823	.1658	.663
4	.5801	.1492	.1989	.1658	.1989	.1823	.663
5	.547	.1989	.2155	.1823	.1989	.1989	.663
6	.5304	.2321	.2321	.1989	.2321	.2486	.663
7	.7127	.2321	.2321	.2486	.2155	.2155	.8619
8	.7625	.1658	.1989	.1823	.1823	.1989	.8619
9	.5304	.7293		.1492	.1492	.1658	.1492
10	.1326	.7956		.116	.0995	.1492	.0995
11	.116	.7127		.0995	.0995	.116	.0829
12	.116	.6962		.0995	.0995	.0995	.0829
13	.0995	.7459		.0995	.0995	.0995	.0663
14	.1326	.6962		.0995	.0829	.0995	.0663
15	.0995	.7625		.0995	.0829	.0995	.0829
16	.0829	.663		.0995	.0829	.1658	.0995
17	.116	.0995		1.4918	1.8067	.9945	.0995
18	.116	.0995			1.7238	1.0277	.1326
19	.1823	.1989			1.5581	.8951	.1658
20	.1658	.1658			1.326	.8453	.1658
21	.1658	.1658			1.21	.8288	.1658
22	.1658	.1658			1.1271	.7459	.1492
23	.1658	.1326			1.0277	.6962	.1326
24	.1326	.1658	.1326	.1326	.8288	.9945	.663
Max	.7625	.7956	.2321	1.4918	1.8067	1.0277	.8619
Min	.0829	.0995	.1326	.0995	.0829	.0995	.0663
Avg	.3053	.3523	.1897	.2155	.5394	.3985	.3364

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214535 / 33/11 KV SHELGAON

Feeder No / Name : 205 / 11 KV SHELGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3961	.3772	.4338	.4527	.4338	.4715
2	.4338	.4715	.4338	.4904	.5281	.4904	.4904
3	.4904	.5281	.5093	.5281	.547	.5281	.4904
4	.6602	.6036	.5847	.5847	.6224	.6036	.5281
5	.6602	.6979	.7167	.6602	.6979	.679	.6413
6	.811	.7356	.8676	.7922	.7922	.7922	.8299
7	.8488	.7167		.7545	.8299	.8299	.8299
8	.7545	.6036		.6036	.7545	.7545	.6413
9	.6036	.5281		.4904	.5281	.6602	.5093
10	.4527	.415		.415	.4527	.4715	.415
11	.3961	.3772		.3584	.4527	.4527	.3772
12	.3772	.3772		.3206	.415	.3772	.3395
13	.2829	.3206		.2263	.3584	.2641	.3018
14	.3018	.2452		.2452	.3018	.3018	.2452
15		.3395		.3395	.3395	.3206	.2641
16	.3772	.3018		.3772	.3772	.3772	.3018
17	.3961	.3395		.4527	.4338	.4527	.415
18		.415			.4904	.6224	.4527
19	.7545	.7733			.6413	.6036	.679
20	.6413	.6036			.6036	.6036	.5281
21	.4904	.547			.5658	.6036	.5281
22	.4715	.4904			.4904	.5658	.4904
23	.4338	.4527			.415	.4904	.4527
24	.3772	.3961	.3772	.7469	.4527	.415	.4715
Max	.8488	.7733	.8676	.7922	.8299	.8299	.8299
Min	.2829	.2452	.3772	.2263	.3018	.2641	.2452
Avg	.5178	.4865	.5524	.4900	.5226	.5289	.4873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214535 / 33/11 KV SHELGAON

Feeder No / Name : 206 / 11KV VIRZARA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4001	.4161	.7362	.8802	.9922	.4161
2		.4001	.4641	.7682	.9282	1.0082	.4481
3		.4641	.5121	.7842	.9922	1.0562	.4481
4		.4641	.5441	.8162	1.0402	1.0883	.4641
5		.5441	.5921	.8802	1.1363	1.2003	.5441
6		.6081	.6401	1.1203	1.2803	1.3443	.6401
7		.6401	.6562	1.7924	2.1765	2.4006	.5761
8		.5441	.5761	2.0805	2.4006	2.4326	.4961
9	.5441	1.2803		.3521	.3841	.4001	1.5043
10	.6401	1.2483		.3041	.2881	.3361	1.5684
11	.7042	1.2803		.2561	.2241	.3201	1.5043
12	1.0082	1.2803		.2401	.2561	.2721	1.4883
13	.9602	1.2803		.2241	.2401	.2241	1.5043
14		1.2163		.208	.2241	.2561	1.3283
15		1.1843		.2561	.2401	.2561	1.3923
16		.9602		.2401	.2561	.2561	1.4723
17	.2561	.2881		.2241	.3201	.3201	.3201
18		.3201			.3521	.4641	.3201
19	.4001	.5441			.5121	.4481	.5121
20	.4161	.4801			.4801	.4321	.4641
21	.3361	.4641			.4801	.4481	.4641
22	.4161	.4481			.4801	.4481	.4161
23	.4161	.4481			.9602	.4001	.4161
24		.4001	.4161	.7362	.8642	.9602	.4161
Max	1.0082	1.2803	.6562	2.0805	2.4006	2.4326	1.5684
Min	.2561	.2881	.4161	.208	.2241	.2241	.3201
Avg	.5543	.7162	.5352	.6677	.7248	.7402	.7968



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214536 / 33/11 KV KALAMB

Feeder No / Name : 201 / 11 KV BHORKARWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0554	.0554	.0819	.0829	.0924	.0549
2	.0549	.0549	.0554	.0819	.0838	.0739	.0549
3	.0549	.0554	.0554	.0819	.0848	.0924	.0549
4	.0732	.0739	.0554	.0983	.1006	.1109	.0732
5	.0914	.0914	.0739	.1147	.116	.1294	.0914
6	.0914	.1294	.0924	.1311	.1311	.1663	.128
7	.1097	.1463	.1294	.1475	.1509	.2033	.0914
8	.1097	.1109	.0924	.1147	.1492	.2033	.0914
9	.0983	.1109	.1311	.0554	.0554	.0914	.1174
10	.1341	.0924	.1638	.0549	.0554	.0549	.213
11	.1174	.1109	.1475	.037	.037	.0549	.2622
12	.0983	.1109	.1311	.0366	.0554	.0492	.2683
13	.0678	.1109	.1311	.037	.0554		
14	.0829	.1294	.1311	.0366	.0554	.0549	.2785
15	.0655	.1294	.1147	.0366	.037	.0366	.3018
16	.0663	.1109	.0983	.037	.037	.0366	.2984
17	.0366	.0554	.0366	.0366	.0554	.0549	.0366
18	.0554	.0554	.0549	.0549	.0554	.0732	.0739
19	.0914	.0554	.0914	.0732		.0732	.0914
20	.0732	.0739	.0914	.0914	.0924	.0732	.0739
21	.0732	.0739	.0914	.0739	.0739	.0549	.0739
22	.0554	.0554	.0732	.0732	.0554	.0549	.0732
23	.0554	.0554	.0983	.1006	.0924	.0549	.0554
24	.0549	.0549	.0554	.0819	.0838	.0924	.0549
Max	.1341	.1463	.1638	.1475	.1509	.2033	.3018
Min	.0366	.0549	.0366	.0366	.037	.0366	.0366
Avg	.0778	.0876	.0938	.0737	.0781	.0862	.1266

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214536 / 33/11 KV KALAMB

Feeder No / Name : 202 / 11 KV KALAMB GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1147	.1848	.1663	.1475	.2033	.4251	.3932
2	.1134	.1829	.1663	.1475	.1848	.4251	.3932
3	.1134	.1848	.1663	.1475	.2012	.4435	.3932
4	.1311	.2012	.1848	.1966	.2743	.5175	.4915
5	.1638	.2772	.2218	.2458	.3326	.6099	.5735
6	.2622	.3841	.2957	.3113	.3841	.8316	.7373
7	.3277	.3326	.3881	.2785	.4066	.8501	.7537
8	.2622	.2614	.2957	.2458	.3475	.7762	.7373
9	.1829	.2218	.213	.2012	.2772	.5898	.7392
10	.1478	.1663	.1638	.1848	.2218	.4915	.5975
11		.1848	.1311	.128	.2218	.4588	.5487
12	.1848	.1848	.1638	.2012	.2218	.4588	.5359
13	.1463	.1848	.1638	.1848	.2033		.4755
14	.1478	.1663	.1147	.1829	.1848	.4372	.4668
15	.1109	.1663	.1638	.1646	.1848	.3277	.4572
16	.128	.1663	.1638	.1663	.4805	.421	.4435
17	.1663	.1848	.1966	.1829	.499	.4915	.5304
18	.1848	.2218	.1475	.2218	.5175	.5407	.6099
19	.2743	.2772	.2622	.2926		.6718	.7762
20	.2957	.3142	.3113	.3696	.8131	.6226	.7316
21	.2195	.2587	.2294	.2987	.6653	.5735	.6348
22	.2195	.2402	.2294	.2587	.5359	.5182	.5544
23	.1646	.2033	.1966	.2195	.4805	.4588	.462
24	.1311	.1646	.1848	.1475	.1829	.4435	.3932
Max	.3277	.3841	.3881	.3696	.8131	.8501	.7762
Min	.1109	.1646	.1147	.128	.1829	.3277	.3932
Avg	.1823	.2215	.2050	.2136	.3489	.5385	.5596

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214536 / 33/11 KV KALAMB

Feeder No / Name : 203 / 11 KV RANGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3441	.2785	.3696	.2957	.2743	.2957	.3113
2	.3441	.285	.3696	.2926	.2772	.2957	.3113
3	.3441	.2785	.3696	.2957	.2957	.3142	.3113
4	.4096	.3018	.4435	.3696	.3475	.3326	.3605
5	.4752	.3812	.5175	.4572	.4207	.3881	.426
6	.5243	.4862	.6099	.5304	.499	.5175	.5243
7	.5344	.5735	.7392	.5729	.5304	.499	.6554
8	.4752	.6203	.7577	.499	.5175	.4435	.6718
9	.3658	.3696	.3841	.663	.7947	.6718	.3696
10	.2926	.3326	.2772	.6796	.8501	.6226	.2378
11	.2561	.3326	.2561	.6371	.8501		.2402
12	.2378	.2772	.2561	.6464	.8871	.7537	.2378
13	.2587	.2587	.2218	.57	.8316		.1848
14	.2195	.2402	.2033	.5636	.8131	.7537	.2378
15	.2033	.2402	.1848	.5801	.8131	.5898	.2033
16	.2218	.2402	.2012	.5898	.7947	.5571	.2195
17	.2378	.2587	.2587	.2218	.2957	.3142	.2402
18	.2772	.2772	.2561	.2561	.3142	.3511	.3109
19	.3841	.3326	.3511	.3658		.3841	.3841
20	.3696	.3696	.3881	.4066	.4251	.3696	.3696
21	.3511	.3326	.3511	.3292	.3696	.3511	.3475
22	.3109	.3142	.3511	.3326	.3326	.3142	.3326
23	.2926	.3511	.2957	.2957	.3142	.3113	.3647
24	.2622	.2652	.3696	.2957	.2772	.3142	.3113
Max	.5344	.6203	.7577	.6796	.8871	.7537	.6718
Min	.2033	.2402	.1848	.2218	.2743	.2957	.1848
Avg	.3330	.3332	.3659	.4478	.5272	.4429	.3402

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214536 / 33/11 KV KALAMB

Feeder No / Name : 204 / 11 KV WALCHANDNAGAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3113	.3696	.3696	.3605	.4066	.1848	.1463
2	.3113	.3921	.3511	.3605	.3841	.2033	.1463
3	.3077	.3696	.3696	.3605	.4066	.2218	.1463
4	.3887	.3658	.3881	.4424	.439	.2218	.1829
5	.4752	.5041	.462	.5407	.4805	.2587	.2561
6	.5992	.6468	.5729	.639	.7133	.3511	.3109
7	.7045	.7023	.7207	.6882	.8048	.4435	.3292
8	.583	.6722	.6838	.639	.8501	.5175	.2743
9	.5914	.5729	.4915	.6653	.7207	.2012	.3521
10		.6283	.4534	.5487	.6099	.1646	.4641
11	.5601	.6099	.4424	.499	.5914	.1829	.4359
12	.5359	.5175	.4096	.499	.5175	.128	.431
13	.4294	.499	.426		.5175		.3277
14	.3696	.462	.3768	.4938	.499	.128	.3812
15	.3658	.4435	.3932	.4251		.1097	.3521
16		.462	.5079	.4024	.1294	.128	.2949
17	.4805	.4805	.4372	.4755	.1478	.1646	.1463
18	.5228	.499	.4049	.4805	.1663	.1829	.1663
19	.5729	.5175	.5079	.6161		.2012	.2195
20	.5487	.5729	.5182	.6099	.2218	.2378	.2218
21	.5175	.5359	.502	.5914	.2033	.2195	.2033
22	.439	.5175	.4588	.5415	.1663	.1829	.1829
23	.3881	.4805	.3768	.4481	.2033	.1646	.1463
24	.3441	.3658	.4066	.3605	.4024	.2033	.1463
Max	.7045	.7023	.7207	.6882	.8501	.5175	.4641
Min	.3077	.3658	.3511	.3605	.1294	.1097	.1463
Avg	.4703	.5078	.4596	.5082	.4355	.2175	.261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214536 / 33/11 KV KALAMB

Feeder No / Name : 205 / 11 KV CHHIKHALI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0732	.0554		.1326	.2033	.0732
2	.0549	.0739	.0554		.1341	.1848	.0732
3	.0549	.0732	.0554		.1326	.1848	.0732
4	.0732	.0914	.0554	.1147	.1509	.1848	.0914
5	.0914	.0924	.0739	.1311	.1492	.2033	.1097
6	.1097	.128	.0924	.1475	.2012	.2587	.1463
7	.128	.1294	.0924	.1802	.2622	.3511	.1463
8	.1097	.0914	.0739	.1966	.3149	.3511	.0914
9	.1006	.1109	.1134	.0739	.1109	.0732	.3149
10	.0983	.0924	.1638	.0914	.0554	.0732	.4752
11	.0819	.1109	.1802	.0739	.0554	.0914	.5636
12	.0983	.1109	.213	.0554	.0554	.0732	.4588
13	.0829	.0924	.1966	.0549	.0554		.3978
14	.0819	.1109	.1802	.0554	.0739	.0549	.4694
15	.0671	.1109	.1638	.037	.0554	.0549	.4588
16	.0492	.0924	.1802	.0732	.0554	.0732	.4144
17	.0366	.0554	.0549	.0739	.0739	.0914	.0739
18	.0732	.0554	.0914	.0732	.0739	.0732	.0914
19	.0924	.0739	.0914	.1109		.1097	.0924
20	.0732	.0924	.1097	.1097	.1109	.1097	.0924
21	.0739	.0924	.0914	.0924	.0924	.0914	.0914
22	.0732	.0924	.0914	.0924	.0739	.0914	.0732
23	.0732	.0739	.0983	.1326	.2033	.0732	.0739
24	.0549	.0739	.0739	.0983	.1341	.2218	.0732
Max	.128	.1294	.213	.1966	.3149	.3511	.5636
Min	.0366	.0554	.0549	.037	.0554	.0549	.0732
Avg	.0786	.0914	.1103	.0985	.1199	.1425	.2091

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 214536 / 33/11 KV KALAMB

Feeder No / Name : 206 / 11 KV LALPURI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294	.2321	.3142	.2012	.2033	.2033	.4096
2	.2294	.2347	.3142	.2012	.1829	.2033	.4096
3	.2294	.2294	.3326	.2012	.2033	.2218	.4096
4	.2622	.2515	.3696	.2378	.2587	.2587	.4915
5	.3277	.2984	.4066	.2926	.2926	.3142	.5407
6	.426	.4024	.462	.3475	.3696	.3881	.639
7	.4752	.4191	.6099	.3841	.3696	.3881	.7373
8	.4534	.4475	.5729	.2926	.3109	.3142	.6554
9	.2195	.2218	.2012	.3932	.5914	.6316	.2012
10	.1663	.1663	.1646	.5079	.5175	.6226	.1848
11	.1646	.1478	.1463	.5304	.7023	.7373	.1848
12	.168	.1663	.1463	.4915	.7023	.7537	.1829
13	.1097	.1663	.1109		.6653		.1478
14	.1174	.1478	.1109	.4424		.6882	.1663
15	.1109	.1478	.1097	.4915		.5079	.1463
16	.128	.1294	.1294	.4973	.6468	.5243	.1663
17	.1294	.1478	.1848	.1463	.1848	.2402	.1848
18	.2033	.1663	.1663	.1848	.2033	.2378	.2012
19	.2743	.2218	.2402	.2155		.2772	.2926
20	.2772	.2587	.2772	.3109	.2587	.2957	.3109
21	.2587	.2402	.2957	.2926	.2957	.2772	.2926
22	.2195	.2402	.2587	.2587	.2402	.2402	.2587
23	.2772	.2957	.2195	.2241	.2218	.4096	.4694
24	.2458	.2347	.3326	.2033	.2012	.2218	.4096
Max	.4752	.4475	.6099	.5304	.7023	.7537	.7373
Min	.1097	.1294	.1097	.1463	.1829	.2033	.1463
Avg	.2376	.2339	.2698	.3195	.3630	.3894	.3372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR

Feeder No / Name : 301 / 22KV KALAMB AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.7011
Max	.7011
Min	.7011
Avg	.7011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR

Feeder No / Name : 302 / 22KV Nimgaon (K)

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.7926
Max	.7926
Min	.7926
Avg	.7926



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR

Feeder No / Name : 303 / 22KV BHAVANINAGAR AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR

Feeder No / Name : 304 / 22KV BHIGWAN INDUSTRIAL  
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	.7011
Max	.7011
Min	.7011
Avg	.7011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR

Feeder No / Name : 305 / 22KV WALCHANDNAGAR IND.

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
19	.7011
24	.7011
Max	.7011
Min	.7011
Avg	.7011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR

Feeder No / Name : 306 / SUBSTATION I

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.7926
Max	.7926
Min	.7926
Avg	.7926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR

Feeder No / Name : 308 / 22KV COLONY SUPPLY

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.7926
Max	.7926
Min	.7926
Avg	.7926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 217007 / 132 KV WALCHANDNAGAR

Feeder No / Name : 309 / SUBSTATION II

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.7071
Max	1.7071
Min	1.7071
Avg	1.7071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 218030 / 220/33 KV SUB-STATION

BHIGWAN

Feeder No / Name : 401 / 33KV BHIGWAN

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	4.9966	1.6827	4.8903	5.3109	5.3572	5.9814	5.3572
16	3.0178	3.4082	3.1459	3.6374	4.3261	4.8583	5.9271
24	3.7037	2.9767	3.1493	3.4591	3.4848	3.6408	4.265
Max	4.9966	3.4082	4.8903	5.3109	5.3572	5.9814	5.9271
Min	3.0178	1.6827	3.1459	3.4591	3.4848	3.6408	4.265
Avg	3.9060	2.6892	3.7285	4.1358	4.3894	4.8268	5.1831

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 218030 / 220/33 KV SUB-STATION

BHIGWAN

Feeder No / Name : 402 / WATER WORKS

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 33 / OUTGOING

UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2721	.2721	.543	.2721	.148	.2721	.2761
16	.543	.2721	.2721	.2721	.2761	.2721	.2761
24	.543	.543	.543	.543	.543	.543	.543
Max	.543	.543	.543	.543	.543	.543	.543
Min	.2721	.2721	.2721	.2721	.148	.2721	.2761
Avg	.4527	.3624	.4527	.3624	.3224	.3624	.3651



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 218030 / 220/33 KV SUB-STATION

BHIGWAN

Feeder No / Name : 408 / STATION TRF I

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.0517
Max	1.0517
Min	1.0517
Avg	1.0517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

BARAMATI DIVISION[511]

WALCHANDNAGAR SUB-DN[723] BU 4723

Substation No/ Name :- 218030 / 220/33 KV SUB-STATION

BHIGWAN

Feeder No / Name : 802 / M/S BILT GRAPHIC PAPER NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
PRODUCT Feeder KV- 220 / (CONTINOUS PROCESS)(NO STAGGERING  
OUTGOING

DATE	01-SEP-17
HR	Load (MW)
23	7.0111
24	7.0111
Max	7.0111
Min	7.0111
Avg	7.0111

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 201 / 11 KV CHAKEN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5242	1.6194	1.1488	1.6766		1.5242
2		1.5623	1.5242	1.166	1.7147		1.6004
3		1.5242	1.6194	1.166	1.6766		1.5623
4		1.5623	1.4861	1.1488	1.7147		1.6004
5		1.5242	1.5242	1.1317	1.6385		1.6385
6		1.5242	1.4861	1.1488	1.6766		1.7718
7		1.6004	1.448	1.1488	1.6766		1.7909
8		1.5242	1.2384	1.3032	1.6004	1.5203	1.6385
9		1.6766	1.3717	1.3375		1.448	1.6194
10	1.829	1.6575	1.4746	1.7147	2.2805	2.0767	
11	1.8671	1.9814	1.3546	1.8099	2.2862	2.191	
12	1.9052	2.0767	1.2517	1.7909	1.9814	2.191	
13	1.829	1.6194	1.2174	1.8665	1.9052	1.9624	
14	1.7528	1.7718		1.9044	1.829	1.7528	
15	1.2955	1.8671	.7202	1.9418	1.9814	1.9052	
16	2.0576	2.0005	1.2517	1.9728	1.9814	1.9243	
17	2.0576	2.0386	1.2003	1.9605	1.9052	1.9814	
18	1.9814	1.9052	1.286	1.8625	1.9814	1.9433	
19	1.829	2.1338	1.3889	1.8671	2.21	2.0576	
20	1.6766	1.9052	1.2346	1.7924		1.7528	
21	1.6766	2.1148	1.1831	1.7924		1.6004	
22	1.6766	1.5242	1.1488	1.643		1.6575	
23	1.448	1.5623	1.1317	1.6651		1.7337	
24		1.4861	1.5813	1.1488	1.7147	1.7909	1.5432
Max	2.0576	2.1338	1.6194	1.9728	2.2862	2.191	1.7909
Min	1.2955	1.4861	.7202	1.1317	1.6004	1.448	1.5242
Avg	1.7773	1.7361	1.3366	1.5597	1.8648	1.8523	1.6290

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 202 / 11 KV TASC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.21	2.1338	1.6975	2.21		2.2481
2		2.2481	2.1719	1.7318	2.1338		2.2862
3		2.21	2.0005	1.7147	2.0957		2.2672
4		2.2481	1.9433	1.6804	2.1719		2.3053
5		2.2481	2.2291	1.6632	2.1719		2.2481
6		2.2862	2.191	1.6975	2.1338		2.21
7		2.3624	2.0957	1.7147	2.1338		2.3624
8		2.5149	1.9433	1.989	2.21	2.3529	2.21
9		2.5911	2.0576	2.1948	2.5339	2.5339	2.191
10	2.6673	2.6482	1.9719	2.2634	2.5393	2.4958	
11	2.7054	2.6673	1.8519	2.5206	2.915	2.4577	
12	2.8197	2.6482	1.9547	2.5393	2.5911	2.553	
13	2.7435	2.4577	1.8176	2.5766	2.553	2.6482	
14	2.6673	2.6673		2.4977	2.21	2.7816	
15	2.1338	2.553	1.1317	2.6326	2.2862	2.6673	
16	2.3624	1.3146	1.6289	2.7149	2.2862	2.6863	
17	2.5911	1.6575	1.6804	2.6244	2.2862	2.5911	
18	2.4387	2.572	1.6804	2.4615	2.2862	2.553	
19	2.5149	1.2003	1.8861	2.2405	2.2862	2.6292	
20	2.3624	2.2862	1.7833	2.1658		2.3624	
21	2.4006	2.1338	1.6461	2.1658		2.3624	
22		2.2862	1.6632	2.3152		2.2291	
23	.9145	2.4006	1.6804	2.3152		2.21	
24		1.9052	2.3053	1.6804	2.2862	2.364	2.2862
Max	2.8197	2.6673	2.3053	2.7149	2.915	2.7816	2.3624
Min	.9145	1.2003	1.1317	1.6632	2.0957	2.21	2.191
Avg	2.4094	2.2632	1.8890	2.1582	2.3160	2.4987	2.2615

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 203 / 11 KV ICL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.3243	1.7147	2.5149		1.9052
2			2.2672	1.6804	2.3243		1.9243
3			2.1338	1.6632	2.2862		2.1338
4			2.2862	1.6632	2.3243		2.0957
5			2.1338	1.6804	2.2862		2.1529
6			2.0957	1.7147	1.9052		1.848
7			1.9052	1.9204	1.829		1.6194
8			1.7528	2.2119	1.6766	1.4842	1.7718
9			1.829	2.4006	1.643	1.5684	1.829
10	1.829	2.2481	1.5775	2.332	1.6644	1.6194	
11	1.9052	2.3815	1.6118	2.4615	1.7528	1.6004	
12	1.9052	2.2862	1.5432	2.4356	1.5242	1.6575	
13	1.829	2.1338	1.5089	2.5393	1.5242	1.5623	
14	1.829	2.1338		2.4615	1.5242	1.6766	
15	1.829	2.2862	.7373	2.4646	1.5242	1.7337	
16	1.9052	2.0767	1.6289	2.6139	1.6766	1.7147	
17	1.9052	2.1338	1.5089	2.6139	1.7147	1.5242	
18	1.829	2.0195	1.3717	2.6139	1.829	1.5242	
19	1.829	2.21	1.5089	2.5393	1.5242	1.6004	
20	1.5242	2.2862	1.7147	2.2862		1.6766	
21	1.6766	2.3624	1.9719	2.2862		1.6004	
22	1.829	2.4006	1.8861	2.6673		2.191	
23	2.0576	2.4768	1.869	2.8959		2.0195	
24		2.0576		1.8519	2.6673	1.6804	2.0767
Max	2.0576	2.4768	2.3243	2.8959	2.6673	2.191	2.1529
Min	1.5242	2.0195	.7373	1.6632	1.5242	1.4842	1.6194
Avg	1.8344	2.2329	1.7803	2.2380	1.8858	1.6726	1.9357

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 204 / 11 KV VINAMAX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0572	.0514	.0572		.0572
2			.0572	.0514	.0572		.0572
3			.0572	.0514	.0572		.0572
4			.0572	.0343	.0572		.0572
5			.0572	.0514	.0572		.0572
6			.0381	.0514	.0381		.0572
7			.0381	.0343	.0381		.0381
8			.0381	.0343	.0381	.0362	.0381
9			.0381	.0343	.0373	.0373	.0381
10	.0381	.0381	.0343	.0343	.0358	.0381	
11	.0381	.0381	.0343	.0354	.0381	.0381	
12	.0381	.0381	.0343	.0373	.0381	.0381	
13	.0381	.0381	.0343	.0373	.0381	.0381	
14	.0381	.0381		.0373	.0381	.0381	
15	.0381	.0381	.0343	.0373	.0381	.0381	
16	.0381	.0381	.0343	.0373	.0381	.0381	
17	.0381	.0381	.0343	.0373	.0381	.0381	
18	.0381	.0381	.0343	.0373	.0572	.0381	
19	.0381	.0572	.0514	.0362	.0572		
20	.0572	.0572	.0343	.0572		.0572	
21	.0572	.0572	.0514	.0572		.0572	
22	.0572	.0572	.0514	.0572		.0572	
23	.0572	.0572	.0514	.0572		.0572	
24		.0572	2.3434	.0343	.0572	.0543	.0572
Max	.0572	.0572	2.3434	.0572	.0572	.0572	.0572
Min	.0381	.0381	.0343	.0343	.0358	.0362	.0381
Avg	.0436	.0457	.1433	.0427	.0456	.0437	.0515

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 205 / 11 KV KHADI CRUSHER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.381	.3429	.381		.381
2			.381	.3429	.381		.381
3			.381	.3429	.3429		.381
4			.381	.3429	.3429		.381
5			.381	.4458	.381		.381
6			.4572	.5144	.381		.381
7			.5335	.6344	.4954		.5525
8			.724	1.0288	.9907	1.086	.9907
9			.381	1.2346	.7468	1.2127	1.1622
10	1.7528	1.7147	.4287	1.4403	1.0456	1.6766	
11	1.8671	1.467	.2915	1.4003	1.5242	1.8671	
12	1.9052	1.9814	.3944	1.6244	1.6766	1.3336	
13	1.6004	1.2003	.3601	1.643	1.1431	1.086	
14	.6097	1.5432		1.6804	1.2193	1.0669	
15	.6097	2.4006	.3086	1.9418	1.2193	1.9052	
16	1.1431	2.2862	.3258	1.5203	1.3717	2.21	
17	1.3717	1.448	.3429	.9335	1.5242	1.9052	
18	.4572	.724	.3258	.5975	1.5242	1.9433	
19	.381	.381	.3601	.4207	.381	.381	
20	.3429	.381	.3601	.381		.381	
21	.3429	.381	.3429	.381		.381	
22	.3429	.381	.3429	.381		.381	
23	.3429	.381	.3429	.381		.381	
24		.3429	.381	.3429	.381	.4656	.381
Max	1.9052	2.4006	.724	1.9418	1.6766	2.21	1.1622
Min	.3429	.3429	.2915	.3429	.3429	.381	.381
Avg	.9335	1.1342	.3873	.8458	.8726	1.1567	.5372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214421 / 33/11 KV KURKUMBH

Feeder No / Name : 206 / 11 KV PANDHAREWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.724	.7621	.6859	.8002		.7621
2		.724	.7811	.6859	.7621		.8192
3							.8002
4							.7811
5							.8573
6							1.0479
7							1.3908
8							1.448
9		.8764	.7621	.7888	1.262	1.1203	
10	.5716	.8002	.7202	.7202	1.2323	1.1812	
11	.5335	.6287	.5658	.9335	1.1431	1.2765	
12	.4191	.5906	.6687	.9522	1.105	1.2003	
13	.4382	.5906	.6173	.9134	1.105	1.1622	
14	.4382	.2858		.9145	1.105	1.1812	
15	.381	.3048	.5144	.8962	1.105	1.2193	
16	.381	.5716	.7373	.9593	1.105	1.2384	
17	.4572	.5906	.7202	.9313	1.105	1.2574	
18	.724	.6859	.7373	.9522	1.0479	1.2193	
19	.7811	.8764	.8573	.9671	1.086	1.2955	
20	.8954	.7621	.8573	.9774		1.105	
21	.8764	.8192	.823	.9774		1.0098	
22	.8002	.8383	.7888	.9412		.8573	
23	.724	.7811	.7373	.8962		.8002	
24		.7621	.7621	.6859	.8764	1.0517	.8002
Max	.8954	.8764	.8573	.9774	1.262	1.2955	1.448
Min	.381	.2858	.5144	.6859	.7621	.8002	.7621
Avg	.6015	.6785	.7301	.8766	1.06	1.1360	.9674



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214428 / 33/11 KV PATAS

Feeder No / Name : 201 / 11 KV Patas Gaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.8861
Max	1.8861
Min	1.8861
Avg	1.8861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214428 / 33/11 KV PATAS

Feeder No / Name : 202 / 11 Kv Railway

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801		.3963	.5144	.6668	.4877	.5144
2	.4801		.4725	.5487	.724	.5182	.5716
3	.5144		.4877	.583	.7621	.4572	.6097
4	.5316		.5487	.6173	.8954	.4268	.6668
5	.5658		.5487	.6516	.9526	.4572	.743
6	.583		.5335	.703	1.0098	.6097	.8002
7	.7545		.6401	1.046	1.1431	.9602	.7049
8	.7888		.6401	1.0802	1.3146	1.0669	.6478
9			.5144	.4763	.4801	.5716	.5182
10		.4801	.4801	.4382	.3772	.6859	
11	.3944	.3944	.3429	.381	.3429	.6478	
12	.3429	.3429	.2915	.3239	.3429	.5716	1.768
13	.3601	.3429	.3258	.3239	.3086	.5716	1.9814
14	.3429	.3258	.3429	.3048	.3086	.5906	2.0881
15	.2743	.3086	.3772	.3048	.3429	.5906	1.8595
16	.3258	.3258		.362	.4115	.6097	1.8138
17		.4973	.4115	.4001	.5316	.6478	.4287
18		.4458	.4458	.4572	.5487	.6668	.4801
19	.4287	.5144	.4801	.5335	.6173	.6859	.6344
20	.463	.6001	.583	.5906	.6516	.724	.6001
21	.4458	.583	.5487	.5144	.5144	.6668	.6173
22	.3601	.5487	.4973	.4001	.5144	.5906	.5144
23		.442	.5316	.5525	.5792	.5335	.4973
24	.5144		.3963	.5144	.6287	.4572	.4763
Max	.7888	.6001	.6401	1.0802	1.3146	1.0669	2.0881
Min	.2743	.3086	.2915	.3048	.3086	.4268	.4287
Avg	.4711	.4394	.4712	.5259	.6237	.6165	.888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214428 / 33/11 KV PATAS

Feeder No / Name : 203 / 11 kv Vasunde

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2401	.3258	.2915	.3429	.3429	1.1622
2	.3429	.2401	.3086	.3258	.3048	.3772	1.2193
3	.4287	.2743	.3772	.3772	.4001	.3601	1.2574
4	.5144	.2743	.4115	.4801	.5335	.4115	1.2955
5	.5487	.4115	.4973	.5144	.6478	.5487	1.3336
6	.583	.583	.6859	.583	.8002	.7202	1.3908
7	.6173	.6173	.6173	.583	.7049	.6859	1.5242
8	.463	.4287	.4115	.463	.5906	.5487	1.6385
9	.5144	.4572	.6001	.7621	.7468	1.2384	.3601
10	.381	.3048	.6859	.8954	1.0802	1.3527	.3429
11	.3963	.4572	.7202	.9526	.7926	1.3908	.2229
12	.4115	.4572	.7373	.9717	.7468	1.3717	.2058
13	.381	.442	.6859	.8383	.7316	1.3336	.2058
14	.3658	.4268	.6344	.6097	.7621	1.2955	.2058
15	.381	.4115	.6001	.5335	.7926	1.2384	.2229
16	.4115	.3658	.5658	.4763	.823	1.2193	.2401
17	.4115	.2572	.2572	.3239	.2743	.2858	.2743
18	.463	.3429	.3086	.381	.3086	.3429	.2915
19	.4801	.4287	.4287	.4572	.4801	.5144	.5487
20	.4801	.5316	.5144	.5335	.5487	.6478	.5144
21	.3429	.5144	.4801	.4954	.5144	.6097	.4973
22	.3258	.4115	.4115	.5144	.463	.5525	.4801
23	.2743	.3601	.3429	.4001	.4287	1.0479	.442
24	.2915	.2401	.3429	.3086	.362	.3772	1.1241
Max	.6173	.6173	.7373	.9717	1.0802	1.3908	1.6385
Min	.2743	.2401	.2572	.2915	.2743	.2858	.2058
Avg	.4216	.3949	.4980	.5447	.5908	.7839	.7083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214428 / 33/11 KV PATAS

Feeder No / Name : 204 / 11 KV Kusegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.2439	.4572	.5316	.9526	.6097	.6859
2	.7716	.2591	.442	.583	1.0669	.5792	.8954
3	.8059	.2591	.5335	.6173	1.2193	.5944	1.0288
4	.823	.3048	.6097	.6859	1.3717	.6249	1.6766
5	.8573	.4572	.7316	.823	1.4861	.8535	1.7337
6	.8916	.6401	.8993	.9774	1.5813	1.1736	1.8099
7	1.0288	.6401	1.1431	1.4575	1.7909	1.7833	1.6004
8	1.0631	.6706	1.2193	1.4403	2.0005	1.9357	1.2955
9	.4973	.4973	.6001	.6478	.7545	.5335	1.4937
10	.6516	.3772	.5487	.5716	.5658	.6859	1.5089
11	.5487	.463	.4801	.5144	.5144	.6668	1.1431
12	.5144	.5487	.3429	.4572	.4801	.7049	1.7071
13	.4801	.5144	.3258	.4382	.4973	.6859	1.829
14	.463	.4458	.3086	.4001	.4801	.7049	1.89
15	.3944	.463	.3772	.4001	.5144	.6668	1.8595
16		.4973	.4458	.4382	.5487	.6478	1.7985
17		.4973	.4801	.6478	.5487	.7621	.5658
18			.5144	.8573	.703	.8573	.6173
19			.7716	.9717	1.0288	1.0098	1.0802
20	.9088	1.166	1.0288	1.086	1.2003	1.2574	1.2346
21	.7202	1.0288	.8916	.9526	.8402	1.0288	1.0288
22	.5316	.8745	.823	.8573	.7888	.8764	.8573
23	.3086	.5182	.5658	.724	.7164	.7049	.7202
24	.7202	.2439	.4877	2.4348	.8573	.6401	.6097
Max	1.0631	1.166	1.2193	2.4348	2.0005	1.9357	1.89
Min	.3086	.2439	.3086	.4001	.4801	.5335	.5658
Avg	.6833	.5277	.6262	.8131	.9378	.8578	1.2779

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214428 / 33/11 KV PATAS

Feeder No / Name : 205 / 11Kv kamthekar

SHEDDABLE HV(AGRICULTURE)

L.I.S.(winary) Feeder KV- 11 /  
OUTGOING

DATE	30-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3				.0191
4				.0191
5				.0381
6	.0762		.0191	.0381
7	.0762		.0191	.0381
8	.0762	.0171	.0762	.0191
<b>Max</b>	<b>.0762</b>	<b>.0171</b>	<b>.0762</b>	<b>.0381</b>
<b>Min</b>	<b>.0762</b>	<b>.0171</b>	<b>.0191</b>	<b>.0191</b>
<b>Avg</b>	<b>.0762</b>	<b>.0171</b>	<b>.0381</b>	<b>.0286</b>

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 201 / 11 KV H.Berdi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.8861
Max	1.8861
Min	1.8861
Avg	1.8861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 202 / 11 KV Wadgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.8861
Max	1.8861
Min	1.8861
Avg	1.8861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 203 / 11 KV Pedgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.8861
Max	1.8861
Min	1.8861
Avg	1.8861



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 204 / 11 KV D. Raje AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.8861
Max	1.8861
Min	1.8861
Avg	1.8861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 207 / 11 KV VITTHAL NAGAR AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.037	.0343	.037	.0381	.2507
2	.0381		.037	.0343	.037	.0381	.2507
3							.2507
4							.2507
5							.2507
6							.2507
7							.2507
8							.3224
9			.1543	.1753	.362	.197	
10			.1543	.1753	.362	.3045	
11			.1715	.1753	.3429	.2865	
12			.1543	.1402	.3429	.2507	
13			.1543	.1402	.3239	.2454	
14			.1543	.1402	.3048	.2507	
15			.1543	.1227	.2858	.2507	.0381
16			.1543	.1227	.2667	.3856	.0381
17			.0514	.037	.0381	.037	.0381
18		.0366	.0514	.037	.0381	.037	.0381
19		.0554	.0514	.037	.0381	.037	.0381
20		.0554	.0514	.0554	.0381	.037	.0381
21		.0554	.0343	.0554	.0381	.037	.0381
22		.0554	.0343	.037	.0381	.037	.0381
23		.037	.0343	.037	.0381	.2507	.1715
24			.037	.0343	.0381		.2507
Max	.0381	.0554	.1715	.1753	.362	.3856	.3224
Min	.0381	.0366	.0343	.0343	.037	.037	.0381
Avg	.0381	.0492	.0928	.0884	.1650	.16	.1558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214463 / 33 /11 KV DEULGAON

Feeder No / Name : 208 / 11KV DEULGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4763	.4435	.4031	.4435	.4572	.4805
2		.4763	.4805	.4031	.4805	.4572	.5544
3	.4191	.5144	.5544	.4382	.5544	.5144	.5544
4	.4191	.6668	.6219	.5316	.6283	.5716	.695
5	.4954	.9145	.7682	.8326	.7682	.9335	.8779
6	.6478	1.0288	1.0608	1.0059	1.0608	1.0669	1.0608
7	.7621	.8573	1.0242	.9877	.9694	.9526	.9877
8	.8002	.8383	.8779	.7164	.823	.8192	.6219
9	.7621	.6219	.6201	.5914	.7621	.7023	.5144
10	.6097	.5544	.5316	.5175	.6668	.462	.381
11	.5716	.4805	.4557	.4805	.5716	.4066	.2858
12		.4435	.4031	.3696	.3429	.3696	.3239
13	.4572	.4066	.3856	.3326	.3048	.3326	.2858
14	.4001	1.8111		.2957	.2858	.2957	.2667
15	.3429	.3326	.3294	.3326	.2858	.2957	.3429
16	.2858	.3326	.4207	.3696	.2858	.4066	.4191
17	.4572	.3326	.4075	.3696	.4572	.3326	
18	.4763	.3326	.3506	.4435		.3696	.5335
19	.5335	.6283	.5083	.7023	.5335	.7316	.6478
20	.5525	.6584	.6805	.7023	.6097	.7316	.7621
21	.5525	.6584	.5316	.6283	.5716	.695	.7621
22	.5716	.5487	.4733	.5544	.5716	.5914	.6478
23	.5144	.4435	.4382	.4435	.5335	.4805	.5716
24	.4954		.4435	.4207	.4382		.4805
Max	.8002	1.8111	1.0608	1.0059	1.0608	1.0669	1.0608
Min	.2858	.3326	.3294	.2957	.2858	.2957	.2667
Avg	.5298	.6243	.5570	.5364	.563	.5642	.5677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214523 / 33/11 KV RAWANGAON

SUBSTATION

Feeder No / Name : 201 / 11 KV KHADKI AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3144	.2743	.2673	.3022	.4725	.4725	.125
2	.3144	.2743	.2673	.3254	.4016	.4801	.1265
3	.3144	.281	.2717	.3544	.4201	.5521	.125
4	.3144	.2858	.2835	.4016	.4201	.5761	.128
5	.3096	.2763	.2835	.4252	.4134	.6001	.144
6	.3544	.281	.2835	.4801	.4441	.6121	.1311
7	.3487	.3662	.2835	.5281	.7316	.6361	.128
8	.4068	.4134	.3544	.5975	.6973	.6962	.1235
9	.1581	.1204	.1296	.1204	.128	.1235	.8916
10	.125	.1219	.1219	.1235	.1311	.1265	.9755
11	.128	.125	.1174	.125	.1326	.1235	1.0974
12	.1296	.125	.1219	.1296	.1326	.1219	1.1949
13	.1296	.128	.1235	.1265	.1326	.1097	1.2384
14	.1311	.1036		.125	.1311	.1006	1.3003
15	.1311	.1326		.1219	.1311	.1082	1.3003
16	.1326	.1341			.1311	.1097	1.3003
17	.125	.1326	.125	.1158	.128	.1128	.1467
18	.1143	.1311	.125	.0975	.128	.1204	.1543
19	.1128		.125	.1166	.128	.1235	.1543
20	.1143	.1296	.125	.1372	.1457	.1406	.1543
21	.1128	.128	.1423	.1505	.1457	.1406	.1524
22	.1113		.1423	.1524	.1457	.1423	.1524
23	.2641	.2557	.3022	.4016	.4649	.125	.1265
24	.3144	.2789	.2673	.4012	.4649	.4725	.1265
Max	.4068	.4134	.3544	.5975	.7316	.6962	1.3003
Min	.1113	.1036	.1174	.0975	.128	.1006	.1235
Avg	.2088	.2045	.2030	.2547	.2834	.2886	.4791

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214523 / 33/11 KV RAWANGAON

SUBSTATION

Feeder No / Name : 202 / 11 KV RAWANGAON GAVTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.7468	.7468	.8215	.7762	.8589	.8962
2	.7167	.7733	.7095	.8589	.7947	.8589	.9055
3	.7545	.7655	.6535	.8962	.8029	.9335	.9709
4	.9431	.8589	.6348	.9431	.8962	1.0082	.9997
5	1.1694	1.0924	.9431	1.094	1.1317	1.0829	1.2136
6	1.358	1.6409	1.2637	1.4335	1.5466	1.2449	1.5089
7	1.5466	1.6975	1.5655	1.5466	1.6975	1.6409	1.5466
8	1.3443	1.5278	1.0829	1.5089	1.419	1.4003	1.363
9	1.1203	1.0829		1.1643	1.1389	1.1273	1.0269
10	.8962	.9522	.6653	.7682	.8589	.8871	.823
11	.5729	.8215	.5544	.5487	.5544	.7133	.5487
12		.6908		.4435	.4805	.5853	.5068
13	.4656	.5601	.5121	.4207	.499	.5175	.5487
14	.5014	.4108	.4938	.4066	.5121	.4294	.5487
15	.5138	.4854	.4805	.439	.5487	.4481	.499
16	.5373	.5175	.499	.4755	.5487	.5175	.499
17	.6584	.5121	.5359	.5853	.5729	.6584	.5973
18	.8316		.8501	.7499	.6283	.8413	.7392
19	.9709	.7023	1.1389	.9511	.7095	.9328	.9335
20	1.1317	.8316	.9335	1.0829	.7842	1.0269	1.0456
21	1.1317	1.0269	.8962	1.0456	.8299	1.0082	1.0082
22	.7922		.8589	.7682	.8865	.9522	.9335
23	.7468	.8402	.8215	.7316	.8962	.9145	.7922
24	.7167	.7468	.7842	.8215	.7655	.8589	.8775
<b>Max</b>	<b>1.5466</b>	<b>1.6975</b>	<b>1.5655</b>	<b>1.5466</b>	<b>1.6975</b>	<b>1.6409</b>	<b>1.5466</b>
<b>Min</b>	<b>.4656</b>	<b>.4108</b>	<b>.4805</b>	<b>.4066</b>	<b>.4805</b>	<b>.4294</b>	<b>.499</b>
<b>Avg</b>	<b>.8755</b>	<b>.8766</b>	<b>.8011</b>	<b>.8544</b>	<b>.8450</b>	<b>.8936</b>	<b>.8888</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214523 / 33/11 KV RAWANGAON

SUBSTATION

Feeder No / Name : 203 / 11 KV NANDADEVI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.2801	.2804	.3258	.2926	.3366	1.6712
2	.3189	.2772	.3155	.3224	.2865	.3403	1.6712
3	.3189	.3045	.3506	.3224	.2865	.3403	1.6907
4	.3544	.3045	.3898	.3403	.3012	.3582	1.6876
5	.3544	.3475	.4607	.3403	.3224	.3582	1.7269
6	.3544	.3721	.4961	.3366	.333	.3544	1.7238
7	.3544	.3761	.5316	.3366	.333	.3544	1.6964
8	.3506	.3544	.3224	.3366	.3012	.3544	1.7078
9	.7116	.7522	.8539	1.1248	1.5497	1.7236	.2149
10	.6882	.7682	.9061	1.358	1.6446	1.8564	.1829
11	.5868	.7748	.9602	1.358	1.7394	1.8976	.1463
12	.5858	.7811	.9755	1.358	1.8185	1.9608	.1463
13	.6226	.787	.9659	1.3889	1.7185	1.9766	.1463
14	.6161	.7827	.9957	1.4022	1.5935	1.9841	.1463
15	.6161	.7926	1.0235	1.387	1.4937	1.9925	.1463
16	.5937	.7926	1.0235	1.4198	1.3998	1.9372	.1463
17	.1829	.1753	.168	.1829	.1494	.1772	.2263
18	.2172	.2103	.2402	.2218	.1848	.2195	.2218
19	.2378	.2481	.2926	.2561	.2195	.2561	.2926
20	.2507	.2658	.3109	.2896	.2715	.2507	.3292
21	.3258	.2835	.3292	.3224	.2835	.3258	.2865
22	.3045		.3292	.2926	.2835	.3189	.2865
23	.2743	.2454	.3292	.2987	.3012	1.6057	1.4403
24	.3189	.2587	.2454	.3258	.2957	.3189	1.6741
<b>Max</b>	<b>.7116</b>	<b>.7926</b>	<b>1.0235</b>	<b>1.4198</b>	<b>1.8185</b>	<b>1.9925</b>	<b>1.7269</b>
<b>Min</b>	<b>.1829</b>	<b>.1753</b>	<b>.168</b>	<b>.1829</b>	<b>.1494</b>	<b>.1772</b>	<b>.1463</b>
<b>Avg</b>	<b>.4107</b>	<b>.4580</b>	<b>.5457</b>	<b>.6520</b>	<b>.7251</b>	<b>.8999</b>	<b>.8170</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214523 / 33/11 KV RAWANGAON

SUBSTATION

Feeder No / Name : 204 / 11 KV RAWANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.4475	.4588	.5571	.7293	.7773	.2614
2	.4973	.4424	.4588	.5898	.7209	.8421	.2614
3	.4973	.4807	.7293	.6554	.7537	.9069	.2772
4	.4973	.4807	.7459	.7459	.7625	.9831	.2801
5	.5801	.503	.7712	.7956	.779	1.0159	.2987
6	.5801	.5256	.8139	.8619	.779	1.0978	.3018
7	.6706	.663	.8139	.9614	1.2431	1.1633	.2987
8	.663	.7537	.9831	1.0608	1.3441	1.1683	.0572
9	.2241	.2149	.2241	.2987	.2427	.2241	1.4723
10	.1578	.1791	.1848	.1578	.2033	.1478	1.5023
11	.1357	.1612	.1463	.1402	.1646	.1463	1.5023
12	.1357	.1433	.1417	.1402	.1433	.1463	1.8185
13	.1372	.1433	.1357	.1417	.1433	.1433	1.8185
14	.1372	.1433	.1357	.1402	.1417	.1417	1.8185
15	.1387	.1433	.1341	.1463	.1417	.1417	1.8185
16	.1578	.1433	.1341	.1578	.1417	.1417	1.8185
17	.1949	.181	.1829	.1772	.1463	.1612	.1829
18	.2303	.2195	.2402	.2126	.1663	.2218	.2218
19	.2743	.2218	.2801	.2561	.1848	.2561	.2987
20	.3547	.1867	.2987	.2587	.2241	.2801	.2987
21	.3142	.168	.3361	.2402	.2614	.2957	
22	.2801		.3361	.2195	.2614	.2801	.2241
23	.4096	.426	.4915	.6882	.7537	.2614	.2241
24	.4973	.426	.4424	.5243	.6882	.7449	.2587
<b>Max</b>	<b>.6706</b>	<b>.7537</b>	<b>.9831</b>	<b>1.0608</b>	<b>1.3441</b>	<b>1.1683</b>	<b>1.8185</b>
<b>Min</b>	<b>.1357</b>	<b>.1433</b>	<b>.1341</b>	<b>.1402</b>	<b>.1417</b>	<b>.1417</b>	<b>.0572</b>
<b>Avg</b>	<b>.3443</b>	<b>.3216</b>	<b>.4008</b>	<b>.4220</b>	<b>.4633</b>	<b>.4870</b>	<b>.7528</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214534 / 33/11 kV Malthan Daund

Feeder No / Name : 201 / 11 kV WATLUJ Ag feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.0663	.1086	.0857	.0686	.0671	.2105
2	.2481	.0686	.1086	.1052	.1006	.0671	.1966
3	.1991	.0343	.1097	.104	.0332	.0671	.1677
4	.2149	.0343	.1086	.1052	.0328	.0503	.1526
5	.1227	.0343	.1097	.1052	.0678	.0332	.1949
6	1.0056	.0343	.1075	.1052	.0332	.0332	.208
7	.12	.0347	.0716	.0362	.0514	.0335	.2229
8	.1017	.0347	.0362	.0366	.0335	.0332	.1989
9	.1341	.128		.032	.096	.1638	.0655
10	.0867	.0732	.0914	.125	.1094	.1562	.0503
11	.0777	.0638	.125	.1107	.1372	.1423	.0251
12	.0648	.092	.0667	.096	.132	.16	.0255
13		.1158		.0791	.1429	.1296	.0259
14		.0974	.0743	.0625	.1391	.1677	.0255
15	.12	.104	.104	.0663	.1391	.1907	.0251
16	.1372	.104	.1094	.1063	.1391	.2126	.0248
17	.0655	.0251	.0305	.0351	.0995	.0335	.0244
18	.0686	.0358	.0358	.0362	.0876	.0895	.1109
19	.0857	.037	.0914	.0358	.0905	.0732	.1086
20	.0905	.1478	.0924	.0549	.0747	.112	.1086
21	.1109	.1478	.0934	.0747	.056	.1097	.1097
22	.1109	.1109	.0934	.0943	.0373	.1307	.1109
23	.0995	.1086	.0924	.0848	.1029	.2012	.1715
24	.181	.0655	.1097	1.8861	.1017	.1006	.1823
Max	1.0056	.1478	.125	1.8861	.1429	.2126	.2229
Min	.0648	.0251	.0305	.032	.0328	.0332	.0244
Avg	.1666	.0749	.0896	.1526	.0878	.1066	.1144



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214534 / 33/11 kV Malthan Daund

Feeder No / Name : 202 / 11 kV Rajegaon Ag

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6796	.8688	.6762	.7545	.7042	.6722
2	.7011	.6859	.8688	.6836	.6706	.7377	.6478
3	.788	.6859	.8954	.7011	.7293	.8048	.7459
4	.8505	.6859	.8954	.7802	.7537	.779	.8048
5	.8842	.7202	.9313	.823	.8478	.8288	.964
6	.9945	.7545	.9313	.8573	.8619	.8288	1.1145
7	.9156	.7455	.8413	.905	.8573	.8383	1.0513
8	.8048	.7628	.7202	.8779	.8048	.8619	.9339
9	.6962	.5761		.6958	.6401	.8259	.7773
10	.5182	.6516	.4382	.6481	.4687	.6706	.7811
11	.3887	.6001	.443	.6249	.4572	.6562	.7164
12	.3191	.6201		.6009	.3668	.6325	.6455
13		.5243	.4031	.5312	.2858	.6562	.7074
14		.5609	.3277	.4572	.4172	.6299	.7907
15	.3201	.5316	.3963	.5243	.4868	.583	.7907
16	.3155	.5493	.3906	.5959	.598	.631	.7482
17	.3932	.2347	.2683	.3121	.4973	.2818	.4344
18	.4287	.4344	.3582	.3761	.5258	.3366	.5068
19	.4458	.4435	.5304	.4252	.543	.4706	.5853
20	.4887	.5544	.5914	.4706	.5975	.5914	.6335
21	.499	.5544	.5975	.5914	.6348	.543	.6268
22	.499	.5175	.5415	.5601	.6535	.5175	.5792
23	.4973	.7682	.6401	.6706	.6859	.7293	.7716
24	.5731	.5898	.8145	.6878	.7122	.6706	.6226
Max	.9945	.7682	.9313	.905	.8619	.8619	1.1145
Min	.3155	.2347	.2683	.3121	.2858	.2818	.4344
Avg	.5897	.6013	.6224	.6282	.6188	.6587	.7355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 214534 / 33/11 kV Malthan Daund

Feeder No / Name : 203 / VASANTDADA SUGAR INSTITUTE

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0354	.0343	.0171	.0166	.0335	.0171
4	.0343	.0343	.0173	.0328	.0332	.0166
5	.0343	.0343	.0173	.017	.0332	.0335
6	.0339	.0343	.0175	.0166	.0335	.017
7	.0335	.0347	.0179	.0171	.0332	.0347
8	.0497	.0347	.0181	.0335	.0332	.0171
9	.0328	.032	.0312	.032	.032	.016
10	.0259	.0373	.0309	.0469	.0463	.019
11	.0255	.0362	.0154	.0457	.0463	.019
12	.0259	.0366	.0312	.044	.0312	.0572
13	.0259	.0381	.0154	.0286	.0316	.0572
14	.0259	.019	.0316	.0278	.0328	.0655
15	.0267	.019	.0324	.0278	.0509	
16	.0274	.019	.052	.0278	.0347	.0655
17	.0328	.019	.0514	.0332	.0492	.0655
18	.0343	.0185	.0354	.0351	.0351	
Max	.0497	.0381	.052	.0469	.0509	.0655
Min	.0255	.0185	.0154	.0166	.0312	.016
Avg	.0315	.0301	.0270	.0302	.0369	.0358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 216613 / Aalegaon Substation

Feeder No / Name : 300 / Auxilary

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 216613 / Aalegaon Substation

Feeder No / Name : 301 / 22 Kv Boribel Feeder AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 216613 / Aalegaon Substation

Feeder No / Name : 302 / 22 KV KHANOTA AALEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 216613 / Aalegaon Substation

Feeder No / Name : 303 / 22KV ALEGAON AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 216613 / Aalegaon Substation

Feeder No / Name : 701 / 132 kV Daund Sugar

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 132 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	22.6338
Max	22.6338
Min	22.6338
Avg	22.6338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 300 / Auxilary

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 301 / 22 KV KEDGAON

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	7.5446
Max	7.5446
Min	7.5446
Avg	7.5446

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 302 / 22 KV DAUND

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	7.5446
Max	7.5446
Min	7.5446
Avg	7.5446

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 303 / 22 KV RAILWAY

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
23	3.7723
24	7.5446
Max	7.5446
Min	3.7723
Avg	5.6585

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 304 / 22 KV KURKUMBH  
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 305 / 22 kv Dychem FEEDER  
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 307 / 22KV GIRIM GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	7.5446
Max	7.5446
Min	7.5446
Avg	7.5446

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 308 / 22KV BORAWAKE NAGAR  
GAVTHAN Feeder KV- 22 /  
OUTGOING

GAOTHAN FEEDER

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 309 / 22 KV S R P F

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 310 / Colony

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 217015 / 132KV DAUND

Feeder No / Name : 401 / 33 KV DEULGAON RAJE

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	11.3168
Max	11.3168
Min	11.3168
Avg	11.3168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 218029 / 220 KV KURKUMBH

Feeder No / Name : 400 / Auxilary

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 218029 / 220 KV KURKUMBH

Feeder No / Name : 401 / 33KV OLD Cipla Express

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 218029 / 220 KV KURKUMBH

Feeder No / Name : 402 / 33 KV PEARL EXP

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 218029 / 220 KV KURKUMBH

Feeder No / Name : 403 / 33 KV Kedgaon

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	11.3168
Max	11.3168
Min	11.3168
Avg	11.3168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 218029 / 220 KV KURKUMBH

Feeder No / Name : 405 / 33KV New Cipla Express

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 218029 / 220 KV KURKUMBH

Feeder No / Name : 406 / 33KV Allik Amines Exp. NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 218029 / 220 KV KURKUMBH

Feeder No / Name : 408 / 33 KV UNDAWADI (KP)

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 218029 / 220 KV KURKUMBH

Feeder No / Name : 409 / 33 KV KIRAN SOLAR  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

DOUND[051]

BU 5886

Substation No/ Name :- 218029 / 220 KV KURKUMBH

Feeder No / Name : 803 / 220kv Reliance Feeder  
Feeder KV- 220 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	37.723
Max	37.723
Min	37.723
Avg	37.723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 201 / 11 kv kedgaon feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8326	.6706	.6802	.9774	.9069	.8907	.7888
2	.7964	.6706	.6478	.9774	.8745	.8097	.7888
3		.6859	.5921	1.1946	.8745	.8745	.7888
4		.7316	.6964	1.1584	.8745	.9717	.823
5		.823	.8097	1.2489	.9393	1.1336	.8573
6		.823	.9069	1.267	1.004	1.2631	.9259
7		.9907	1.065	1.3643	1.004	1.2803	.9774
8		.9755	.9069	1.3937	1.004	1.4413	.8402
9		.6859	.6516		.4973	.7716	1.1431
10	.6173	.7202	.7059		.4801	.7373	
11	.6687	.6687	.6878		.4372	.6859	
12	.6516	.6173	.7059			.5658	
13	.6859	.6173	.6335			.6859	1.7013
14			.5973		.5144	.6687	1.7551
15	.6516	.7186	.6154		.5144	.703	1.8229
16	.6344	.6415	.6516		.5487	.7202	1.9366
17	.6516	.6859	.724		.6173	.7202	.8869
18	.7545	.7202	.7602		.6687	.7716	.9593
19		.7716	.7964		.8402	.9945	.9774
20	.8745	.823	.8688		.8402	.8916	1.0317
21	.7373	.8573	.8954		.8059	.8402	1.0136
22	.8059	.8402	.8869		.7545	.8059	.9774
23	.6859	.6802	.9492		.9231	.7888	.905
24	.8326	.6706	.7287	.8954	.9393	.9717	.8059
Max	.8745	.9907	1.065	1.3937	1.004	1.4413	1.9366
Min	.6173	.6173	.5921	.8954	.4372	.5658	.7888
Avg	.7254	.7430	.7568	1.1641	.7665	.8745	1.0813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 202 / 11 kv Dapodi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0317	.9602	1.0867	1.0566	.8421	.8764	1.0212
2	.9774	.9602	.9145	1.086	.8097	.8573	1.0212
3		.9774	.964	1.1222	.7449	.7716	1.0364
4		1.0288	.7621	1.1584	.7888	.6859	1.0669
5		1.2003	.9774	1.086	.6964	.8238	1.1584
6		1.286	1.1043	1.1222	.7202	.9326	1.3413
7		1.4198	1.3375	1.1222	.8059	1.0802	1.4632
8		1.0802	.9431	1.086	.7716	1.0288	1.4022
9		.8421	.8907		1.085	1.2793	.8573
10	.945	.8745	1.1041		1.1336	1.3413	.8596
11	.945		1.0498		1.1822	1.4175	.8326
12	.9145	.8097	.9955		1.1174	1.3565	.8145
13	.884	.7611	.9774		1.1174	1.3108	
14		.7773	.9774		1.166	1.2955	.9412
15	.7316				1.2146	1.2498	.9231
16	.6859	.5668	1.0136		1.2308	1.2193	.8869
17	.6516	.7888	.8507		.6173	.6173	.9774
18	.7888	.9114	.9231		.6859		1.0498
19	.9945	1.0288	.9671		1.0341	1.3203	1.2308
20	1.1317	1.166	1.1222		1.166	1.166	1.2851
21	1.2003	1.1488	1.1765		1.1145	1.286	1.3032
22	1.0974	1.1317	1.1462		1.0288	1.0669	1.3032
23	.9602	1.166	1.267		1.0288	.9907	1.3112
24	1.086	.9774	1.1145	1.2178	.8745	.9431	1.0364
Max	1.2003	1.4198	1.3375	1.2178	1.2308	1.4175	1.4632
Min	.6516	.5668	.7621	1.0566	.6173	.6173	.8145
Avg	.9391	.9938	1.0289	1.1175	.9574	1.0833	1.0923

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 203 / 11 Kv Handalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8869	.5335	.5668	.9465	.8421	.8097	.7716
2	.8869	.5335	.5182	.9955	.8421	.8097	.7716
3		.5487	.4858	.9671	.8421	.8421	.7716
4		.5792	.583	1.0566	.8745	.9717	.7888
5		.6097	.6964	1.0745	.9069	1.0688	.8916
6		.7316	.8097	1.1765	.9393	1.1336	1.0802
7		.9297	.9231	1.2226	1.0688	1.2146	1.0802
8		.884	.8259	1.2308	.8907	1.1984	.9088
9		.7202	.7202		.583	.7202	1.0517
10	.4801	.6836	.5792		.6001	.7716	1.3394
11	.703	.5658	.5068		.5658	.7202	1.3394
12	.6859	.583	.543		.5344	.6687	1.3672
13	.6001	.6001	.6154		.5144	.6516	1.3937
14	.583	.5784	.6401		.5487	.6516	1.3394
15	.5487	.6001	.6878		.583	.7373	1.448
16	.5658	.6836	.7059		.4973	.7888	1.5203
17	.5144	.6859	.7421		.5487	.7888	.7783
18	.6859	.6859	.7602		.6859	.8059	.8145
19	.7888	.7545	.7602		.7716	.9431	.8326
20	.6859	.7164	.7964		.8402	.8916	.8688
21	.6859	.7716	.8326		.8059	.823	.8507
22	.6516	.7373	.8145		.7716	.8573	.8326
23	.5487	.6316	.8417		.8097	.7716	.8869
24	.8688	.5335	.6154	.8328	.8907	.8421	.7888
Max	.8869	.9297	.9231	1.2308	1.0688	1.2146	1.5203
Min	.4801	.5335	.4858	.8328	.4973	.6516	.7716
Avg	.6688	.6617	.6904	1.0559	.7399	.8534	1.0215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 204 / 11 KV KADETHAN

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8869	.7202	.6516	.7964	.6802	.6859	.7316
2	.8688	.7373	.6001	.7783	.6802	.6516	.7316
3		.7545	.5784	.8326	.6478	.6001	.7468
4		.7888	.6516	.9149	.6478	.6344	.7926
5		.8916	.7716	.905	.7716	.6859	.884
6		1.0631	1.0974	.9774	.8817	.8764	1.1431
7		.9602	.9431	1.0679	1.0166	1.0513	1.1888
8		.8402	.8402	1.0317	.9774	.8745	1.0669
9		.6401	.6401		.7611	1.004	.703
10	.6097	.6802	.6878		.7449	1.0212	.6878
11	.5944	.5668	.6878		.7287	.9907	.6878
12		.5506	.6335		.8421	.9602	.6335
13	.4115	.4858	.6516		.8907	.9602	.5792
14	.3963	.4696	.6335		.8583	1.0212	.6154
15	.3963	.5182	.6335		.8421	.9755	.6335
16	.442	.5992	.6335		.8916	.8993	.6697
17	.5487	.5144	.5611		.5784	.583	.7059
18		.5658	.724		.6344	.6173	.724
19	.9431	.6859	.6878		.8648	.9088	.8688
20	.8573	.8059	.8145		.9088	.9088	.905
21	.8402	.8573	.9231		.8573	.823	.9412
22	.7716	.7888	.8869		.7888	.8402	.9774
23	.703	.7202	.8145		.7716	.7773	.9922
24	.8869	.7202	.6859	.7522	.7287	.7373	.7468
Max	.9431	1.0631	1.0974	1.0679	1.0166	1.0513	1.1888
Min	.3963	.4696	.5611	.7522	.5784	.583	.5792
Avg	.6771	.7052	.7264	.8952	.7915	.8370	.8065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 205 / Dairy Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0724	.0457	.061	.0724	.0457	.061	.0457
2	.0724	.0457	.0457	.0709	.061	.0457	.0457
3		.0457	.0305	.0724	.0457	.0305	.061
4		.061	.0305	.0543	.0762	.0457	.061
5		.0457	.0457	.0543	.0457	.061	.061
6		.061	.0305	.0724	.0305	.0457	.061
7		.0457	.0457	.0724	.0305	.061	.0762
8		.0762	.0457	.0724	.0457	.0914	.0914
9		.0914	.061			.1067	.061
10	.0914	.1067	.0895		.061	.1219	.1267
11	.1219	.0914	.0895		.0762	.0762	.1267
12	.0914	.0914	.0905		.1372	.1067	.1267
13	.0914	.0762	.0724		.0762	.0914	.1086
14	.0762	.0914	.0905		.0914	.061	.1086
15	.0762	.0762	.0724		.0762	.1067	.1267
16	.0762	.1067	.0724		.1219	.0914	.1267
17	.0762	.0762	.0905		.1067	.0762	.1086
18	.061		.0905		.1067	.0457	.1086
19	.0457	.061	.0905		.0914	.061	.1267
20	.061	.0762	.0724		.0762	.0762	.1267
21	.0914	.0762	.0724		.0762	.0914	.1267
22	.0762	.0914	.0905		.0914	.0762	.1075
23	.061	.0914	.0905		.0914	.0762	.061
24	.0716	.061	.0762	.0895	.0762	.0762	.061
Max	.1219	.1067	.0905	.0895	.1372	.1219	.1267
Min	.0457	.0457	.0305	.0543	.0305	.0305	.0457
Avg	.0773	.0735	.0686	.0701	.0755	.0743	.0934



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 206 / 22 FATA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.5792	.5668	.8869	.8421	.6478	.5792
2	.7964	.5792	.5344	.8682	.8421	.6154	.6516
3		.5792	.6154	.9036	.8097	.6802	.6687
4		.5944	.6478	.9671	.8097	.7287	.6859
5		.5944	.7287	1.0566	.8421	.8907	.7888
6		.7621	.7773	1.1222	.8583	1.0364	1.0117
7			.8078	1.1694	.8745	1.2186	.9259
8			.9717	1.1946	.8907	1.2955	.7202
9			1.1145		.463	.5658	1.1279
10	.3258	.5658	.543		.4287	.5487	1.4723
11	.2401		.5068		.4115	.5658	1.5769
12		.4115	.5249		.3772	.5658	1.647
13	.6859	.5258	.4706		.4031	.5487	1.5947
14	.6516	.3772	.4477		.4161	.4801	1.6126
15		.3353	.4706			.5144	1.4883
16	.6173	.4557	.5249		.3772	.5658	1.4529
17	.6173	.5258	.5249		.4458	.583	.543
18	.7373	.5316	.543		.4801	.6344	.5792
19	.7716	.6173	.5792		.7362	.6516	.7059
20	.6859	.7202	.6878		.7011	.7545	.8869
21	.7716	.6859	.7421		.6859	.7373	.8145
22	.6859	.6516	.7164		.6173	.7373	.7964
23	.6859	.5992	.8145		.664	.6516	.7202
24	.7421	.5639	.6154	.788	.8907	.6478	.6516
Max	.7964	.7621	1.1145	1.1946	.8907	1.2955	1.647
Min	.2401	.3353	.4477	.788	.3772	.4801	.543
Avg	.6492	.5628	.6448	.9952	.6464	.7027	.9876

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 207 / 11kv Vrundavan City

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17
HR	Load (MW)
21	.1219
22	.1219
23	.1219
Max	.1219
Min	.1219
Avg	.1219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214432 / 33/11 KV KEDGAON S/STN

Feeder No / Name : 208 / SHRI.SWAMI SAMARTH

GAOTHAN FEEDER

GAONTHAN Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	.6401	.7621	1.1584	.9145	.8124	.823
2	.9412	.6401	.6859	1.0679	.7621	.7811	.823
3		.6706	.6097	1.086	.7011	.7621	.8383
4		.6859	.7164	1.1584	.7011	.8535	.884
5		.7468	.8383	1.3756	.823	.9145	.9145
6		.8688	.9145	1.4661	.9145	1.0059	.9907
7			.9755	1.448	1.1279	1.0669	1.1279
8		.6401	1.2803	1.448	1.0669	1.0669	1.1888
9			1.0974		1.0059	1.0059	.9145
10	1.4022	.8535	1.1946		.9755	.9755	1.086
11	1.0974		1.1584		1.0059	.9145	1.1041
12	.884	.823			.9259	.884	1.1222
13	.884	.7621			.8535		1.086
14		.7621	1.2071		.8383	.9145	1.0566
15	.884	.7621	1.0387		.8535	.9297	1.0498
16	.8535	.7621	1.0498		.9145	.945	
17	.8535	.945	1.086		.9145	.9907	1.086
18	.7926	.945	1.2308		.9717	1.0669	1.1222
19	1.1126	1.0974	1.267		1.2193	1.2498	1.4118
20	1.1279	1.3717	1.4661		1.2193	1.2955	1.4842
21	1.0212	1.0669	1.448		1.0974	1.2193	1.448
22	.9297	.9755	1.3611		1.0059	1.0974	1.3611
23	.7011	.7926	1.1104		.8535	.8993	1.1222
24	1.086	.6554	.7621	1.0745	.9145	.8383	.8383
Max	1.4022	1.3717	1.4661	1.4661	1.2193	1.2955	1.4842
Min	.7011	.6401	.6097	1.0679	.7011	.7621	.823
Avg	.9718	.8318	1.0573	1.2537	.9408	.9778	1.0819

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN

Feeder No / Name : 201 / 11 kv Grant Apparel

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0698	2.2361	1.6632	1.3717	1.6004	1.6766	1.6766
2	2.0165	2.2032	1.5655	1.2765	1.6575	1.7147	1.6575
3	1.9418	2.1285	1.4523	1.2003	1.6004	1.7147	1.6575
4	1.7918	2.1691	1.1763	1.2384	1.6194	1.475	1.6385
5	2.037	2.3388	1.094	1.4098	1.5497	1.475	1.6575
6	2.0698	2.3899	.8939	1.5432	1.5339	1.4415	1.6057
7	2.3045	2.6147	.9536	1.5927	1.4563	1.4266	1.5384
8	2.4535	2.5415	1.3643	1.9978	2.3712	1.7737	2.4006
9	2.9944	2.6699	1.3672	2.4387	2.8481	1.8484	2.6886
10	3.0298	2.6749	1.5061	2.7054	2.8753	2.2218	2.9127
11	3.0849	2.6578	1.4327	3.0102	2.7633	2.0725	2.7435
12	2.3339	2.7496	1.1871	2.4768	2.3167	2.1125	2.3045
13	2.3777	2.6791	1.1104	2.8578	2.5766	1.9909	2.5972
14	3.0445	2.6686	1.2548	2.7625	2.8166	1.7741	2.846
15	2.3339	2.7778	1.4969	2.7435	2.6139	2.1807	2.95
16	2.0553	2.7519	1.6118	2.4387	2.5652	2.0538	3.006
17	2.2986	2.7109	1.5592	2.4768	2.4897	2.1658	2.9313
18	2.3228	.6984	1.3432	2.4387	2.32	2.1148	2.4958
19	2.0538	1.9728	1.4299	2.2862	2.3765	2.1338	2.3243
20	1.9753	1.8642	1.0808	1.6956	1.6787	1.6766	1.8671
21	1.9909	1.7924	1.1765	1.9243	1.8671	2.0005	2.1529
22	2.0851		1.1999	1.829	2.1719	1.6766	2.2481
23	2.1216		1.262	2.1148	2.0005	1.8099	2.3243
24	2.0144	2.1253	1.9404	1.0479	1.9433	1.7337	1.7147
Max	3.0849	2.7778	1.9404	3.0102	2.8753	2.2218	3.006
Min	1.7918	.6984	.8939	1.0479	1.4563	1.4266	1.5384
Avg	2.2834	2.3371	1.3384	2.0366	2.1505	1.8443	2.2475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN

Feeder No / Name : 202 / sahajpur GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1109	.0924	.112	.1143	.1143	.0953
2	.0934	.0934	.0943	.0934	.1143	.1143	.0953
3	.0934	.0934	.1132	.1132	.1143	.1143	.0191
4	.132	.132	.1307	.1494	.1524	.1494	.0191
5	.1886	.1698	.181	.1991	.1905	.1867	.0191
6	.2587	.2054	.2454	.2481	.2218	.2218	.0187
7	.2195	.2328	.208	.2481	.2054	.2378	.0181
8	.1433	.1753		.1867	.168	.2054	.0191
9	.1294	.1387	.1267	.1143	.132	.168	.0187
10	.1294	.1029	.1478	.1143	.0934	.112	
11	.0934	.0857	.0934	.0953	.0747	.0934	.1097
12	.0934	.0905	.0732	.0953	.0724	.0754	.1097
13	.0924	.1075	.0724	.0953	.0934	.0724	.1097
14	.0934	.0905	.0732	.0953	.0732	.0732	.1109
15	.0934	.0914	.0617	.0762	.0747	.0739	.0934
16	.0924	.1086	.0886	.0953	.0943	.0934	.0934
17	.1267	.1086	.1063	.0953	.0943	.0934	.112
18	.1463	.1086	.1075	.1143	.0943	.0953	.1334
19	.1448	.1267	.1086	.1524	.1509	.1524	.1524
20	.1463	.1267	.124	.1524	.1509	.1524	.1524
21	.1267	.128	.1267	.1143	.1524	.1143	.1334
22	.128		.1433	.1143	.1143	.1334	.1143
23	.1109		.1463	.1143	.1143	.1143	.1143
24	.1109	.1109	.1109	.1109	.1143	.1143	.1143
Max	.2587	.2328	.2454	.2481	.2218	.2378	.1524
Min	.0924	.0857	.0617	.0762	.0724	.0724	.0181
Avg	.1291	.1245	.1207	.1291	.1240	.1281	.0859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN

Feeder No / Name : 203 / 11 Kv Khamgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6653	.7922	.7842	.823	.9717	1.1431	1.3336
2	.6722	.7922	.7842	.7762	.9717	1.1431	1.3527
3	.6224	.7282	.7356	.7282	1.0288	1.2574	1.3336
4	.679	.8402	.8871	.9425	1.1431	1.2323	1.3717
5	.7762	.8316	1.0425	1.0425	1.2323	1.3443	1.4289
6	.8779	.8688	1.1403	1.086	1.3676	1.386	1.6244
7	.9425	.8688	1.262	1.1946	1.2323	1.5364	1.6289
8	1.0082	.8145	1.0317	1.1203	1.0642	1.5497	1.4861
9	.8505	.8596	.8871	.8764	.9242	1.4003	1.5123
10	.7973	.7602	.8316	.9717	.9149	1.3443	1.6804
11	.7362	.7133	.8402	.9526	.8775	1.4003	1.6461
12	.7282	.7059	.823	.8954	.8869	1.3957	1.701
13	.7133	.7522	.8145	.9717	.9709	1.3756	1.701
14		.7059	.7133	.9717	1.0242	1.2803	1.6263
15			.7682	1.0288	1.0456	1.386	1.643
16	.2218		.8059	1.0288	.9619	1.4003	1.643
17	.6584	.8145	.8871	.9145	1.1317	1.419	1.6244
18	.9522	.9328	.8871	1.086	1.0374	1.4098	1.7528
19	.9979	.9979	.8962	1.2955	1.4523	1.5813	1.8671
20	.9522	1.0974	.9774	1.3146	1.4523	1.4289	1.7718
21	.9979	.9979	.9568	1.2955	1.4289	1.5051	1.7718
22	.9328		.9671	1.1622	1.3717	1.4289	1.6766
23	.9328		.9231	1.0479	1.2574	1.4289	1.5623
24	.7207	.8402	.8316	.8779	.9717	1.1431	1.3717
Max	1.0082	1.0974	1.262	1.3146	1.4523	1.5813	1.8671
Min	.2218	.7059	.7133	.7282	.8775	1.1431	1.3336
Avg	.7925	.8357	.8949	1.0169	1.1134	1.3717	1.5880

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214442 / 33/11 KV SHAJPUR S/STN

Feeder No / Name : 401 / 33kv Shakti Roofing

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.4481	.4481	.3292	.5716	.6287	.743
2	.4481	.3961	.3921	.3326	.5716	.6287	.8002
3	.3395	.3395	.3961	.3361	.5716	.5716	.8573
4	.3395	.3361	.4435	.3881	.6287	.5601	.8573
5	.3881	.2772	.4938	.3841	.6859	.5601	.8573
6	.439	.3801	.543	.3801	.6859	.5544	.8402
7	.6653	.3801	.4938	.3801	.5601	.4938	.543
8	.5601	.4344	.4344	.3361	.5601	.5041	.5144
9	.6099	.5093	.4435	.6859	.679	.7842	.6722
10	1.4969	.6516	.499	.743	.7842	.7842	.9522
11	.7842	.823	.5041	.8002	1.0082	.8402	.7682
12	.7282	.9231		.9145	.8145	.679	.6584
13	.6099	.9134		.8002	.6161	.4887	.6036
14	.6722	.9774		.743	.7682	.6584	.6653
15	.6161	.823	.439	.6859	.7842	.499	.6722
16	.6653	.7059	.2686	.6287	.679	.5041	.6722
17	.4938	.543	.3326	.6287	.6224	.5041	.7282
18	.5601	.4938	.3326	.5716	.6224	.5144	.743
19	.4435	.5544	.3361	.6287	.679	.6287	.743
20	.5041	.5487	.3601	.6287	.4527	.6287	.8002
21	.5544	.5544	.3189	.6287	.6859	.6287	.9145
22	.5487		.3224	.6859	.6859	.6859	.6859
23	.6653		.3801	.5716	.6859	.6859	.743
24	.5544	.6161	.4435	.3841	.5716	.6859	.6859
Max	1.4969	.9774	.543	.9145	1.0082	.8402	.9522
Min	.3395	.2772	.2686	.3292	.4527	.4887	.5144
Avg	.5888	.5740	.4107	.5665	.6656	.6126	.7384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 202 / 11 KV RAHU AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.8848	.9259	.9602	1.1022		.5658
2	1.0117	.9054	.9259	.9431	1.0608		.5658
3	1.046	.9496		.9945	1.0486		.583
4	1.0631	.9945	.9945	.9602			.6173
5	1.1145	1.073	1.1145	1.0288	1.1934		.583
6	1.1831	1.153	1.1831	1.0974	1.2763	1.3546	.6173
7	.6687	.6299	.6687	.6173	.6952	1.1145	1.2517
8	.6001						1.4918
9	.4915			.5256		.5316	1.4746
10	.3647			.3856		.4458	1.5729
11	.3688			.3812		.4115	1.6244
12	.3391	.3086		.3521		.4115	1.6956
13	.3052	.3086		.373		.3772	1.9662
14				.2984		.3258	2.0622
15	.2818	.3086		.2785		.3258	.2949
16	.3018			.3353		.3429	.3481
17	.3768			.3647		.3601	.3768
18	.431	.3429	.4115	.4748		.4801	.4588
19	.4973	.4287	.4801	.5243		.6001	.4588
20	.5138	.4973	.5144			.6001	.4973
21	.5304		.5658			.5658	.5079
22	.5365	.5658	.5658			.583	.4915
23	.9326	.9088	.9259				.5636
24	1.0288	.9116	.9259	.9259	1.065		1.1145
Max	1.1831	1.153	1.1831	1.0974	1.2763	1.3546	2.0622
Min	.2818	.3086	.4115	.2785	.6952	.3258	.2949
Avg	.6529	.6982	.7848	.6222	1.0631	.5519	.9077



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 203 / 11 KV MADHAV NAGAR FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5571	.5487	.5144	.5967		1.3717
2	.5487	.5967	.583	.5487	.5967		1.4403
3	.5487	.663	.583	.5487	.5868		1.4575
4	.6173	.6554	.6859	.6173	.6443		1.5089
5	.6859	.7127	.7716	.6859	.6882		1.6118
6	.7202	.8048	.823	.7888	.779	.7373	1.7661
7	1.1145	1.1768	1.1317	1.2346	1.2125	1.3717	.7202
8	1.0288		1.0802	1.0486			.6173
9	.7537			.8718		1.2346	.5243
10	.7625			.9012		1.1831	.4578
11	.7545			.8684		1.166	.4475
12	.7373	.7545		.852		1.0974	.4096
13	.7293	.823		.8684		1.0802	.4191
14				.8684		1.0631	.431
15	.5197	.6516		.57		1.1831	1.2929
16	.5868	.6859		.6554		1.3717	1.326
17	.6539			.7209		1.5604	1.3904
18	.7545	.6859	.8916	.8192		1.6461	1.3923
19	.8029		.9774	.9012		1.749	1.4091
20	.7956		.9259			1.7147	1.4089
21	.779	.9088	.9945			1.6804	1.4074
22	.8048	.9259	.9774			1.6804	1.3435
23	.4973	.5316	.5316				1.491
24	.4973	.6226	.5144	.5144	.5735	.6001	.6516
Max	1.1145	1.1768	1.1317	1.2346	1.2125	1.749	1.7661
Min	.4973	.5316	.5144	.5144	.5735	.6001	.4096
Avg	.7047	.7348	.8013	.7699	.7097	1.3011	1.0957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 205 / 11 KV TELE WADI FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5243	.4801	.4801	.5243		.6516
2		.5197	.5144	.4801	.5243		.6516
3	.6516	.5735	.5144	.5144	.5243		.6859
4	.7202	.6299	.6859	.583	.5801		.7202
5	.7888	.6882		.6859	.7209		.8573
6	.8745	.8619	.9774	.8745	.8951	.9774	1.1317
7	.8573	1.0227	1.0974	1.0802	1.1022	1.4403	1.2003
8	.823		.9088				.9945
9	.6554			.852			.8192
10	.547			.8192			.6962
11	.4475	.6173		.8288			.6371
12	.5365	.6516		.779		1.4232	.5304
13	.5735			.663		1.5432	.5197
14		.6344		.6371		1.6118	.5079
15	.2683			.2652		.5316	1.6278
16	.3353	.2915		.2713		.583	1.7101
17	.4096			.431		.4115	2.0517
18	.5243		.5144			.7716	2.1365
19	.5868		.583	.6962		.9259	2.2213
20			.6859			.8916	2.1795
21	.547	.5487	.6001			.8573	2.1714
22	.5304	.4973	.5144			.7373	2.1216
23	.4748	.3601	.4801				.5365
24	.5487	.4915	.4801	.463	.4915	.5144	.703
Max	.8745	1.0227	1.0974	1.0802	1.1022	1.6118	2.2213
Min	.2683	.2915	.4801	.2652	.4915	.4115	.5079
Avg	.5850	.5942	.6455	.6336	.6703	.9443	1.1693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 206 / 11 kv SOMESHWAR FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2458	.2572	.2401	.2155		.0857
2	.2743	.2515	.2401	.2229	.2374		.1029
3	.2743	.2294	.2229	.2401	.2486		.1029
4	.2915	.2486	.2572	.2401	.2374		.0857
5	.3086	.2622	.2743	.2572	.2622		.1029
6	.3086	.2713	.3086	.2743	.2818	.4458	.1029
7	.1029	.1638	.1017	.0857	.0838	.0857	.4801
8	.0686						.6516
9	.0655			.0648			.7701
10	.0655			.0655			1.065
11	.0678	.0678		.0497			1.0898
12	.0829			.0503			1.0343
13	.0655	.0678		.0509			1.1603
14		.0678					1.2378
15	.0655	.0678		.0497			.0492
16				.0492			
17	.0838	.0848		.0838			.0497
18	.0848	.0848	.0686	.0663			.0655
19	.1017		.0686	.0655			.0655
20	.1006	.0848	.0857				.0671
21	.0972		.0857				.0663
22		.1017	.0857				.0648
23	.2486	.2401	.2401				.0819
24	.2572	.2187	.2572	.2229	.213		.4115
Max	.3086	.2713	.3086	.2743	.2818	.4458	1.2378
Min	.0655	.0678	.0686	.0492	.0838	.0857	.0492
Avg	.1567	.1623	.1824	.1322	.2225	.2658	.3910

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 207 / 11 Kv Walaki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4239	.4115	.4115	.431		1.4232
2	.4801	.431	.4287	.4458	.4144		1.4575
3	.4801	.4694	.4115	.4458	.4748		1.4575
4	.5144	.4694		.4801	.5087		1.4403
5	.5487	.5087	.5144	.5487	.4807		1.4575
6	.583	.5533	.5658	.583	.5243	.4801	1.4918
7	.6001	.5426	.0532	.583	.6036	.4458	.5487
8	.4801						.4115
9	.3605			.373		.4115	.3277
10	.285			.2984		.3429	.2785
11	.2267	.2229		.2543		.2743	.2883
12	.2374	.2058		.1989		.2401	.2591
13	.1943			.2035		.2401	.1802
14		.2058		.2155		.2572	.1802
15	.6874			.9503		1.5089	.2035
16	.763	.8745		.9831		1.6118	.2458
17	.6554			.9945		1.7147	.2321
18	.4694		1.0288	1.065		1.7147	.3277
19	.3647	.9088	1.1145			1.6632	.3441
20	.3978	.9431	1.0631			1.6461	.3441
21	.39		1.0974			1.6289	.407
22	.3812	.9431	1.0802			1.5947	.4096
23	.39	.4115	.4115				1.4582
24	.4287	.4239	.4287	.3944	.4096	.3772	.4801
Max	.763	.9431	1.1145	1.065	.6036	1.7147	1.4918
Min	.1943	.2058	.0532	.1989	.4096	.2401	.1802
Avg	.4506	.5336	.6623	.5238	.4809	.9501	.6523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 208 / 11 Kv Bafna Express

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0328	.0339	.0514	.0328		.0514
2	.0514	.0332	.0339	.0514	.0339		.0514
3	.0514	.0339	.0339	.0514	.0332		.0514
4	.0514	.0339	.0343	.0514	.0339		.0514
5	.0514	.0332	.0343	.0514	.0339		.0514
6	.0514	.0328	.0339	.0514	.0332	.0339	.0514
7	.0514	.0339	.0339	.0514	.0339	.0339	.0514
8	.0514						.0686
9	.0492			.0492		.0514	.0655
10	.0497	.0686		.0497		.0514	.0678
11	.0492	.0678		.0492		.0514	.0492
12	.0503			.0492		.0514	.0509
13	.0503	.0678		.0655		.0686	.0671
14				.0655		.0686	.0655
15	.0655			.0492		.0514	.0492
16	.0655	.0509		.0492		.0514	.0678
17	.0663			.0492		.0514	.0497
18	.0655	.0339	.0514			.0686	.0497
19	.0492		.0514	.0655		.0686	.0486
20	.0492	.0339	.0514			.0686	.0503
21	.0503		.0514			.0514	.0509
22	.0492	.0339	.0514			.0514	.0328
23	.0324	.0339	.0514				.0328
24	.0514	.0324	.0343	.0514	.0328	.0339	.0514
Max	.0663	.0686	.0514	.0655	.0339	.0686	.0686
Min	.0324	.0324	.0339	.0492	.0328	.0339	.0328
Avg	.0524	.0411	.0415	.0529	.0335	.0534	.0532

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 209 / 11 Kv RAHU GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5735	.5144	.4801	.5304	.5144	.5144
2	.5144	.57	.5144	.5144	.5243	.6001	.5144
3	.4801	.5636	.4973	.5487	.5801	.6516	.5487
4	.5144	.6443	.583	.583	.5571	.6859	.6173
5	.6173	.663		.7888	.6226	.7716	.6859
6	.6859	.7377	.823	.8745	.7209	.8059	.823
7	.7202	.7291	.7888	.7373	.7291	.7545	.8573
8	.6859						.6859
9	.5735			.5735		.6859	
10	.5426	.4239		.5243		.6173	.639
11	.4973			.5426		.5144	.5735
12	.4862	.3944		.5138		.4973	.5571
13	.426			.4144		.4801	.57
14		.3944		.3605		.4458	.4917
15	.3605			.3481		.4115	.4973
16		.3772		.373		.4458	.4748
17	.4641	.3772		.4096		.4458	.4588
18	.4973	.3944	.5487	.4973		.5144	.4424
19	.5243		.5487	.5596		.5487	.5087
20	.547	.5487	.583			.583	.5365
21	.5243		.6173			.583	.5636
22	.5243	.5316	.6173			.583	.5571
23	.5426	.5316	.5144				.5243
24	.5487	.5426	.5144	.4801	.4915	.4801	.5316
Max	.7202	.7377	.823	.8745	.7291	.8059	.8573
Min	.3605	.3772	.4973	.3481	.4915	.4115	.4424
Avg	.5360	.5292	.5896	.5328	.5945	.5736	.5728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 210 / TAKALI BHIMA DAUND AG

SEPARATED AG FEEDERS HAVING SPECIAL

FEEDER Feeder KV- 11 /

DESIGN TRANSFORMER

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.7545	.6859	.4458	.8192	.7716	.5144
2	.8573	.8309	.703	.6859	.8288	.823	.4973
3	.8573	.7865	.7202	.6859	.852	.823	.4973
4	.8402	.8619	.8402	.703	1.0059	.8573	.5144
5	.9431		1.0288	.8573	1.0774	.9945	.583
6	1.1145	.9945	1.0631	.9945	1.2717	1.0802	.6687
7	.583	.5407	.5487	.5487	.4748	.703	1.1488
8	.3944			.3605			1.4575
9	.2458			.3052		.4458	1.491
10	.1943			.1989		.3944	1.5565
11	.1802	.1715				.3772	1.576
12	.1658			.1658		.3772	1.6956
13	.1802	.1526		.1802		.3772	1.8143
14		.1715		.1658		.3772	1.8313
15	.1989			.1475		.3772	.3521
16	.2543					.3772	
17	.2486	.2035		.1802		.3944	.3561
18	.2915	.2035	.2401	.2458		.4458	.3647
19	.3277		.3086	.3647		.5487	.3561
20	.2984	.3052	.3601			.5144	.39
21	.3052		.3258			.463	.431
22	.2785	.2915	.2915			.4458	
23	.6718	.703	.6859				.4144
24	.7888	.7127	.6859	.6344	.8029	.7373	.7202
Max	1.1145	.9945	1.0631	.9945	1.2717	1.0802	1.8313
Min	.1658	.1526	.2401	.1475	.4748	.3772	.3521
Avg	.4801	.5123	.6063	.4372	.8916	.5775	.8741

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214443 / 33/11 KV RAHU S/STN

Feeder No / Name : 401 / Shreenath Mhaskoba Cogen.

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 201 / 11 Kv Pargaon Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.2915	.2172	.2743	.3086	.2229	.4287
2	.181	.3258	.2378	.3086	.3429	.2229	.463
3	.1991	.3601	.2926	.3429	.3772	.2058	.4973
4	.2172	.3944	.3292	.3601	.4115	.2572	.5316
5	.2743	.4287	.3841	.3944	.4458	.2915	.583
6	.3077	.463	.4572	.4115	.463	.3086	.6173
7	.439	.4458	.4458	.4801	.3429	.3258	.5144
8	.2743	.4115	.3429	.4733	.4163	.4115	.5487
9	.2743	.2915	.2915		.2743	.3086	.2229
10	.2229	.2401	.2743			.2058	.2572
11	.2401	.2229	.1886		.2743	.1715	.2229
12	.2058	.2058	.1886		.2378	.2401	.2229
13	.2058	.2229	.1715		.2263	.2743	.2229
14	.2058	.1886	.1886	.2896	.2452	.2401	.2058
15	.1715	.1715	.2058	.2926	.2229	.2572	.2572
16	.2229	.1543	.2229	.2561	.2378	.2743	.2915
17	.2229	.1715	.2401	.2715	.2195	.2915	.3086
18	.3258	.2572	.2572	.3258	.2926	.3772	.3086
19	.3772	.362	.3601	.3601	.4115	.4115	.463
20	.3429	.3658	.3772	.4287	.3944	.3944	.4287
21	.2915	.3109	.3429	.3944	.3601	.3772	.3944
22	.2572	.3292	.3086	.3258	.3258	.3429	.3429
23	.2229	.3109	.2572	.2401	.2401	.3429	.3258
24	.1578	.2572	.2172	.2572	.2743	.2401	.3772
Max	.439	.463	.4572	.4801	.463	.4115	.6173
Min	.1578	.1543	.1715	.2401	.2195	.1715	.2058
Avg	.2501	.2993	.2833	.3414	.3194	.2915	.3765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 202 / 11 KV SHINDEWADI

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4801	.4755	.5144	.5658	.4458	.5144
2	.4207	.5144	.4755	.5658	.5316	.4458	.5316
3	.439	.5487	.4938	.6173	.583	.4973	.5658
4	.4572	.583	.4887	.6687	.6173	.583	.6001
5	.4572	.6173	.5249	.7202	.6001	.6173	.6173
6	.5487	.6687	.631	.7545	.6344	.7202	.6516
7	.8145	.8573	.823	.9602	.8573	.9945	.6687
8	.7888	.823	.8573	.9259	.8145	1.0117	.6344
9	.1715		.2229	.4801	.3439	.3601	.8573
10	.1372		.2229	.4458	.3077	.3429	.9088
11	.1886	.3086	.3086	.3258	.2743	.3429	1.0631
12	.2572	.3429	.2572	.3258	.2829	.3601	1.0802
13	.2229	.3601	.2743	.3258	.2829	.3429	1.0974
14	.1715	.3429	.2572	.3086	.3109	.3258	1.0802
15	.2229	.3086	.3258	.2743	.2561	.3429	1.0631
16	.2743	.3258	.3086	.3086	.2378	.3601	1.0631
17	.2743	.3086	.3772	.2915	.2926	.3944	.3086
18		.3601	.4287	.3944	.3658	.4287	.3772
19	.4458	.4938	.4801	.4458	.4801	.463	.4458
20	.4458	.567	.5316	.4973	.4458	.4287	.4801
21	.4287	.5304	.463	.463	.4287	.4458	.5316
22	.4115	.543	.4287	.463	.4287	.4801	.4973
23	.4287	.5121	.4801	.5144	.5144	.4458	.4458
24	.4207	.4458	.4572	.463	.5316	.4801	.463
Max	.8145	.8573	.8573	.9602	.8573	1.0117	1.0974
Min	.1372	.3086	.2229	.2743	.2378	.3258	.3086
Avg	.3853	.4928	.4414	.5023	.4578	.4858	.6894

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 203 / 11 Kv Nangaon Feeder

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.3544	.3292	.3721	.443	.3012	.6556
2	.3258	.3898	.3155	.4252	.3898	.2835	.691
3	.3292	.4252	.3475	.4784	.4252	.3544	.7087
4	.3658	.4607	.4024	.4961	.4784	.4252	.7442
5	.4344	.4961	.4557	.5316	.5316	.4607	.7619
6	.5121	.5138	.4572	.5493	.6024	.5847	.7619
7	.567	.5847	.5487	.5316	.5138	.5847	.9745
8	.5138	.5487	.463	.6036	.5487	.443	.9774
9	.5493	.583	.6344	.6584	.7682	.8745	.3944
10	.567	.6001	.6516	.695	.7499	.9945	.3429
11	.5493	.5144	.5658	.6878	.7602	1.0288	.2915
12	.5316	.4801	.5316	.6697	.8145	1.046	.2743
13	.4784	.4458	.5316	.7133	.8507	.9602	.2915
14	.4961	.3944	.5144	.6401	.8238	.9602	.2915
15	.4784	.4115	.5316	.6584	.8596	.9431	.3086
16	.4607	.4458	.5144	.6767	.8596	.9259	.3258
17	.2481	.3429	.3429		.4207	.2915	.3772
18	.3544	.3258	.2229	.3544	.2743	.3429	.5144
19	.4252	.4668	.3429	.4252	.4607	.3772	.5144
20	.3898	.4344	.3898	.443	.4252	.4075	.4607
21	.3544	.3475	.3544	.4252	.3721	.3898	.4252
22	.3189	.3658	.3366	.3898	.3366	.3898	.4075
23	.3012	.3982	.3366	.3721	.3366	.6201	.7619
24	.3174	.3366	.3258	.3366	.4075	.3012	.6379
Max	.567	.6001	.6516	.7133	.8596	1.046	.9774
Min	.2481	.3258	.2229	.3366	.2743	.2835	.2743
Avg	.4241	.4444	.4353	.5275	.5605	.5954	.5373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 204 / 11 Kv HATAWALAN GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1744	1.262	1.1871	1.3289	1.5912	1.3535	1.6461
2	1.2003	1.3535	1.2254	1.4632	1.6644	1.4449	1.7375
3	1.3146	1.4449	1.2269	1.5546	1.7375	1.5364	1.7741
4	1.3717	1.5364	1.4899	1.6461	1.7741	1.6278	2.0119
5	1.4918	1.7375	1.6651	1.8107	1.8107	1.8107	2.0485
6	1.7878	1.8839	1.9806	2.1765	1.8656	2.0485	2.1033
7	2.0119	1.8839	1.8347	2.0851	1.9022	2.0485	2.0302
8	1.7375	1.6975	1.6804	1.7833	1.749	1.7741	1.749
9	1.5181	1.6632	1.4232	1.5432	1.3146	1.7318	1.4403
10	1.39	1.3717	1.3032	1.5546	1.2269	1.5775	1.4575
11	1.2803	1.1145	1.2689	1.448	1.2308	1.3889	1.3546
12	1.0425	1.0288	1.2803	1.3535	1.0517	1.3032	1.1145
13	.9511	.9602	1.0288	.9955	.9412	1.0631	1.1317
14		.9431	.9431	1.3169	.9877	1.0288	1.0802
15	.8413	1.0974	1.166	1.3575	.9816	1.2346	1.166
16	1.0608	1.2003	1.2174	1.3352	1.1157	1.3203	1.2174
17	1.2254	1.2003	1.2003		1.1744	1.2689	1.2689
18	1.2986	1.2003	1.1488	1.6651	1.3672	1.3375	1.3717
19	1.4083	1.5604	1.5089	1.8839	1.7193	1.4403	1.5089
20	1.3352	1.5089	1.7375	1.7741	1.6461	1.8473	1.6278
21	1.2803	1.4232	1.6461	1.6461	1.4815	1.6461	1.6095
22	1.2437	1.3672	1.4998	1.4815	1.3352	1.5729	1.5364
23	1.134	1.2346	1.4266	1.4632	1.2803	1.5181	1.4815
24	1.1706	1.1706	1.1393	1.2986	1.5364	1.3169	1.5729
Max	2.0119	1.8839	1.9806	2.1765	1.9022	2.0485	2.1033
Min	.8413	.9431	.9431	.9955	.9412	1.0288	1.0802
Avg	1.3161	1.3685	1.3845	1.5637	1.4369	1.5100	1.5434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 205 / 11 Kv Khutbav GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661	.823	.8326	.8779	.9328	.7865	.7499
2	.6661	.8596	.8145	.8962	.9145	.7499	.7865
3	.7059	.8413	.7888	.9511	.8779	.8779	.8048
4	.7059	.8779	.8063	.9877	.8413	.9511	.823
5	.7059	.9145	.8413	1.0059	.8779	.9694	.8596
6	.8145	.9511	.9991	1.0425	.8962	1.0242	.8962
7	.9816	1.0791	.8916		1.0425	.9694	.8413
8	.7682	1.0631	.9088	.9877	.964	1.0425	.7716
9	.8413	.8059	.7716	.823	.8048	.823	.7716
10	.9694	.8402	.7202	.7964	.6661	.8573	.8916
11	.9145	.7716	.8402	.8413	.6584	.8402	.8059
12	.439	.7545	.7316	.8779	.5792	.7373	
13	.4024	.703	.6516	.8779	.5434	.6859	.6173
14	.2561	.6859	.6001		.5487	.7202	.6516
15	.3292	.6516	.583	.5611	.567	.6516	.6344
16	.3109	.5487	.5487		.5853	.5487	.6173
17	.5853	.5658	.5658	.5973	.6036	.5487	.6516
18	.6584	.3429	.583	.439	.5853	.6859	
19	.7682	.7133	.7545	.8596	.7316	.703	.7716
20	.7316	.7167	.7865	.8413	.7682	.7316	.8048
21	.695	.7167	.7682	.7865	.7865	.7682	.7442
22	.6767	.6584	.7682	.7133	.7316	.7316	.7316
23	.7499	.7682	.8596	.9328	.823	.6767	.6584
24	.6836	.7865	.8596	.823	.9511	.8413	.7133
Max	.9816	1.0791	.9991	1.0425	1.0425	1.0425	.8962
Min	.2561	.3429	.5487	.439	.5434	.5487	.6173
Avg	.6677	.7683	.7615	.8343	.7617	.7884	.7545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 206 / 11 Kv Delwadi Ag

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0857	.0754	.0857	.0514	.0514	.0343
2	.0754	.0857	.0754	.0857	.0686	.0514	.0514
3	.0754	.0686	.0754	.0857	.0686	.0514	.0514
4	.0754	.0857	.0943	.0857	.0686	.0686	.0514
5	.0754	.0686	.0943	.0857	.0857	.0686	.0514
6	.0943	.0857	.1132	.0857	.0857	.0857	.0514
7	.1097	.0686	.1029	.0857	.0857	.1372	.0686
8	.0886	.0686	.1029	.0747	.0943	.12	.0686
9	.0514	.0343	.0343	.0377	.0754	.0514	.1029
10	.0514	.0343	.0343	.0377	.0566	.0343	.1029
11	.0343	.0171	.0343	.0189	.0377	.0171	.1543
12	.0343	.0343	.0343	.0189	.0189	.0171	.2058
13	.0343	.0514	.0171	.0377	.0189	.0171	.2058
14	.0343	.0343	.0171	.0377	.0377	.0171	.2229
15	.0343	.0343	.0171	.0377	.0377	.0343	.2058
16	.0343	.0343	.0171	.0189	.0377	.0343	.2058
17	.0343	.0343	.0343	.0377	.0377	.0343	.0343
18	.0514	.0343	.0514	.0514	.0566	.0514	.0343
19	.0514	.0377	.0514	.0514	.0686	.0514	.0343
20	.0514	.0566	.0514	.0514	.0686	.0171	.0343
21	.0686	.0566	.0514	.0514	.0514	.0514	.0514
22	.0686	.0754	.0514	.0514	.0514	.0514	.0514
23	.0857	.0754	.0857	.0514	.0686	.0514	.0686
24	.0754	.0857	.0754	.0857	.0514	.0686	.0343
Max	.1097	.0857	.1132	.0857	.0943	.1372	.2229
Min	.0343	.0171	.0171	.0189	.0189	.0171	.0343
Avg	.0602	.0561	.0580	.0563	.0576	.0514	.0907

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUNG DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 207 / 11kv Hatawalan AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.3721	.4344	.4075	.3898	.3544	.3544
2	.4525	.3544	.4207	.3898	.3544	.3544	.3189
3	.4525	.3544	.4344	.3544	.3721	.3721	.2835
4	.4572	.3721	.439	.3898	.4075	.3721	.3366
5	.4706	.4075	.439	.4252	.3898	.4075	.3721
6	.4755	.4252	.4572	.4607	.4075	.4252	.3544
7	.4755	.4075	.4115	.443	.4252	.4075	.3544
8	.4252	.4115	.3944	.4344	.439	.4075	.3772
9	.3544	.3429	.3086	.439	.3658	.3429	.4115
10	.3544	.3601	.3429	.4207	.3801	.3429	.5144
11	.3721	.3601	.3086	.4344	.3658	.3258	.4973
12	.3544	.3429	.3544	.4163	.3658	.3429	.5658
13	.3544	.3429	.3258	.4163	.3961	.3258	.5658
14	.3544	.3258	.3258	.3982	.3475	.3086	.5487
15	.3544	.3429	.3429	.4207	.3475	.3258	.5144
16	.3544	.3429	.3429	.4344	.3475	.3258	.5487
17	.3898	.3429	.3601			.4287	.5487
18	.3898	.3601	.3772	.4075	.4024	.4287	.5144
19	.4075		.4115	.4607	.4252	.4115	.5316
20	.3898	.439	.443		.4252	.4784	.5493
21	.4075	.439	.4252	.4252	.4075	.443	.567
22	.4075	.439	.4252	.4075	.4075	.4607	.5316
23	.4075	.439	.4252	.4075	.4075	.3544	.3544
24	.4527	.4075	.439	.4252	.4252	.3898	.3544
Max	.4755	.439	.4572	.4607	.439	.4784	.567
Min	.3544	.3258	.3086	.3544	.3475	.3086	.2835
Avg	.4062	.3796	.3912	.4190	.3914	.3807	.4529

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214444 / 33/11 KV PARGAON S/STN

Feeder No / Name : 401 / 33kv visaka

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5376	.7016	.696	.8148	.7469	.5772	.7469
2	.5715	.6507	.6337	.7809	.7299	.5545	.7016
3	.662	.7752	.6055	.6903	.662	.5149	.7865
4	.7299	.6903	.6111	.7752	.7016	.5036	.662
5	.7865	.7752	.6055	.6451	.7809	.5319	.7073
6	.7618	.8261	.7695	.7469	.7469	.5828	.7356
7	.6055	.6734	.7695	.7413	.7695	.5093	.7695
8	.7526	.7978	.6281	.7167	.5376	.5149	.6337
9	.3338	.6903	.6055	.6111	.4414	.6281	.8544
10	.4697	.6281	.1471	.6168	.4527	.6224	.6847
11	.481	.6903	.1415	.7016	.5432	.5206	.5998
12	.5432	.679	.1924	.6394	.447	.8035	.7016
13	.5149	.6337	.2037	.1867	.3395	.7865	.8092
14	.3225	.7469	.1754	.679	.5816	.5453	.8601
15	.7469	.7413	.6451	.7186	.5601	.4784	.8261
16	.8092	.6903	.6847	.3678	.3791	.4167	.8092
17	.5828	.7809	.5772	.5602	.3678	.6281	.6055
18	.6337	.8035	.4583	.7639	.6847	.8035	.8035
19	.7016	.8488	.4414	.7978	.6337	.7695	.8318
20	.6337	.464	.7978	.6055	.6224	.7299	.8261
21	.7243	.7695	.8374	.5545	.6111	.7016	.8148
22	.6507	.7922	.7582	.4187	.5828	.6564	.7469
23	.7186	.7809	.5772	.7582	.5715	.7243	.713
24		.6734	.7016	.7016	.8035	.5885	.7186
Max	.8092	.8488	.8374	.8148	.8035	.8035	.8601
Min	.3225	.464	.1415	.1867	.3395	.4167	.5998
Avg	.6206	.7210	.5526	.6497	.5957	.6122	.7479



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 201 / 11 Kv Warwand Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5973	.8954	.6348	.6268	.7602	.6805	.7602
2	.6154	.9313	.6348	.6335	.7783	.6805	.7602
3	.6219	.9671	.7095	.6697	.7783	.6984	.7964
4	.7059	1.0745	.7842	.7059	.9412	.8059	.7964
5	.8688	1.1641	.9149	.8238	1.1403	1.0029	1.1584
6	1.1163	1.2536	1.3203	1.262	1.3756	1.1393	1.3575
7	1.3756	1.3969	1.363	1.3032	1.3432	1.3546	1.3213
8	1.086	1.0082	1.0642	1.0631	1.086	1.0288	1.086
9	.7888	.7602	.6859	.8145	.8402	.9955	.7164
10	.7011	.724	.7011	.6516	.7373	.8688	.7164
11	.6135	.6516	.6836	.6516	.6935	.7602	.7343
12	.5731	.6201	.5784	.724	.6415	.6697	.6268
13	.5194	.5316	.5083	.6878	.6135	.6335	.6089
14	.5194	.5194	.5083	.6335	.5609	.5973	.5731
15	.5373	.5014	.5258	.5973	.5083	.5973	.5373
16	.5731	.5316	.4908	.5611	.5258	.5973	.5731
17	.5014	.6201	.5194	.5973	.5731	.5973	.6268
18	.5373	.5792	.5373	.7059	.7164	.6697	.7164
19	.6268	.8871	.7011	.9328	.8939	.905	.8059
20	.8954	.924	.964	.9694	.9671	.9774	.9313
21	.8059	.8775	.9313	.905	.9134	.9231	.9671
22	.788	.8029	.8417	.8596	.8417	.9231	1.0029
23	.7522	.6908	.7522	.7602	.7712	.7602	1.0029
24	.5973	.8775	.6535	.6447	.7602	.6836	.7602
Max	1.3756	1.3969	1.363	1.3032	1.3756	1.3546	1.3575
Min	.5014	.5014	.4908	.5611	.5083	.5973	.5373
Avg	.7216	.8246	.7504	.7827	.8234	.8146	.8307

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 202 / 11 Kv Fargade Mala

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2507	.2667	.2328	.2378	.2328	.4031
2	.2561	.2686	.2667	.2353	.2378	.2328	.4031
3	.2561	.2686	.2667	.2534	.2378	.2507	.4207
4	.2561	.2686	.2858	.2715	.2561	.2865	.4801
5	.2561	.2865	.3239	.3077	.2926	.3045	.4973
6	.3292	.3045	.362	.333	.3475	.298	.5316
7	.3801	.2865	.362	.2915	.3292	.2915	.703
8	.3258	.2058	.3239	.2572	.2743	.2572	.7545
9	.3506	.3258	.3506	.3658	.4458	.463	.1791
10	.3681	.3429	.3856	.2896	.5144	.5487	.1433
11	.3506	.3439	.3856	.3109	.5201	.6001	.1254
12	.3582	.2515	.3506	.3292	.5375	.6687	.1433
13	.3403	.2683	.3506	.3475	.5784	.6516	.1254
14	.3045	.2683	.333	.3658	.5434	.6173	.1254
15	.2865	.285	.3681	.3475	.5258	.6516	.1075
16	.2686	.285	.333	.3475	.4908	.703	.1433
17	.1433	.1143	.1075	.1097	.1433	.1097	.1612
18	.1791	.1715	.1433	.1829	.1791	.1463	.1791
19	.2149	.2858	.2103	.2743	.2454	.2926	.2149
20	.2865	.3048	.2629	.2896	.3045	.2926	.2865
21	.3045	.2858	.2686	.2743	.2865	.3077	.2686
22	.2865	.3048	.2507	.2715	.2686	.2896	.2865
23	.2507	.2858	.2507	.2378	.2454	.4031	.4477
24	.2561	.2507	.2858	.2507	.2378	.2279	.3944
Max	.3801	.3439	.3856	.3658	.5784	.703	.7545
Min	.1433	.1143	.1075	.1097	.1433	.1097	.1075
Avg	.2860	.2714	.2956	.2824	.3450	.3803	.3135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 203 / 11 Kv Punarvasan

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2686	.1852	.2328	.2507	.2507	.128
2	.2561	.2865	.1852	.2353	.2507	.2507	.128
3	.2561	.3045	.1875	.2353	.2534	.2686	.128
4	.2561	.3045	.2031	.2534	.2715	.3045	.1463
5	.2926	.3403	.2187	.2686	.3439	.3403	.1829
6	.3292	.3506	.2785	.3506	.394	.4382	.2195
7	.362	.333	.3725	.4115	.5316	.463	.1829
8	.3801	.3734	.3637	.4287	.5138	.583	.1646
9	.1052	.1307	.1052	.1097	.1029	.128	.5552
10	.0701	.0934	.0701	.0914	.0857	.1097	.7164
11	.0526	.0747	.0526	.0914	.0867	.0914	.8954
12	.0537	.0747	.0526	.0549	.0701	.0732	.8954
13		.0537	.0526	.0549	.0876	.0732	.9134
14	.0716	.0549	.0526	.0549	.0876	.0732	.9313
15	.0895	.0724	.0526	.0549	.1052	.0732	.9671
16	.1075	.0739	.0526	.0732	.0876	.0732	.8954
17	.0895	.0905	.0537	.1097	.0895	.0732	.0895
18	.1254	.0914	.0895	.128	.1075	.1097	.1254
19	.1433	.1509	.1227	.1463	.1402	.1463	.1433
20	.1433	.1509	.1402	.1463	.1612	.1463	.1254
21	.1254	.1307	.1433	.128	.1612	.1463	.1433
22	.1433	.1307	.1254	.128	.1433	.1448	.1612
23	.2149	.1677	.2328	.2561	.2629	.128	.1791
24	.2561	.2686	.1829	.2328	.2534	.2629	.128
Max	.3801	.3734	.3725	.4287	.5316	.583	.9671
Min	.0526	.0537	.0526	.0549	.0701	.0732	.0895
Avg	.1817	.1821	.1490	.1782	.2018	.1980	.3810

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 204 / 11 NARAYAN BET GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	1.0029	.7095	.7701	.8326	.7164	.8326
2	.5853	1.0745	.7095	.7964	.8326	.724	.8413
3	.6036	1.1104	.7545	.8145	.8326	.7522	.8326
4	.6584	1.1462	.8676	.8417	.8688	.8059	.8688
5	.7133	1.1641	1.0185	.985	.9671	.9313	1.1104
6	.7499	1.1999	1.3392	1.2094	1.2357	1.0692	1.2715
7	.7865	1.2536	1.307	1.1145	1.2403	1.1831	1.2357
8	.6584	1.1403	1.1949	1.0288	1.1041	1.1145	1.0566
9	.5959	.9412	.8764	.9774	.8916	.9955	.8059
10	.6135	.8326	.7362	.9328	.8573	.905	.7164
11	.6836	.724	.6836	.8869	.7108	.695	.7343
12	.6268		.6485	.7421	.7108	.7059	.7343
13	.6089		.5434	.7133	.6485	.6516	.7164
14	.8059		.5784	.6767		.6154	.7522
15	.7522	.8059	.631	.695	.7011	.6516	.788
16		.8507	.6485	.7059	.6661	.7059	.8059
17	.8775	.7964	.6447	.7316	.7343	.7973	.8417
18	.9313	.905	.7701	.8688	.8238	.8326	.8954
19	1.0745		1.0517	1.086	.964	1.1222	.9671
20	1.1999	1.1763	1.1043	1.1222	1.0566	1.1584	1.1104
21	1.2536	1.0642	1.0566	.9412	1.0208	1.0498	1.1641
22	.8059	.9335	.985	.8688	.8775	.9412	1.1104
23	.788	.8215	.8954	.8326	.7712	.8326	1.0745
24	.5792	.9671	.7468	.788	.8326	.7186	.8326
Max	1.2536	1.2536	1.3392	1.2094	1.2403	1.1831	1.2715
Min	.5792	.724	.5434	.6767	.6485	.6154	.7164
Avg	.7625	.9955	.8542	.8804	.8774	.8615	.9208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 205 / 11 KV Deulgaon Gada Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0179	.4858	.4477	.5959	.6089	.2561
2	.0377	.0358	.4696	.4525	.5959	.6089	.2561
3	.0377	.0358	.4696	.4706	.5959	.6268	.2561
4	.0366	.0358	.4696	.4656	.6068	.6626	.2534
5	.0377	.0358	.4696	.4835	.6687	.6984	.2743
6	.0366	.0358	.5668	.6135	.7716	1.0867	.2926
7	.0366	.0351	.7773	.9259	1.2003	1.3546	.3292
8	.0189	.0953	.7748	.9602	1.406	1.5261	.2743
9			.1402	.2195	.1886	.2012	1.379
10			.1578	.3109	.2229	.2012	1.7909
11			.1578	.2561	.156	.2012	1.8804
12			.1227	.1829	.156	.1829	1.9163
13			.2279	.1463	.1578	.1646	1.8267
14			.1753	.128		.1646	1.7193
15			.1578	.128	.1402	.1829	1.7013
16		.1524	.3155	.128	.1753	.1829	1.7372
17		.3048	.3582	.2195	.197	.1829	.1791
18		.2667	.2507	.2561	.197	.2012	.2507
19			.2279	.2743	.2454	.2926	.2686
20		.381	.2279	.2743	.2686	.3292	.3045
21		.381	.2353	.2561	.2686	.3077	.3403
22		.2667	.2172	.2534	.2686	.2896	.3045
23		.5376	.4835	.5847	.6135	.2561	.2865
24	.0549	.0179	.5182	.4656	.5658	.6135	.2561
Max	.0566	.5376	.7773	.9602	1.406	1.5261	1.9163
Min	.0189	.0179	.1227	.128	.1402	.1646	.1791
Avg	.0393	.1647	.3524	.3710	.4462	.4636	.7639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 206 / KHOR AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.2149	.1334	.1267	.1463	.1254	.3772
2	.1097	.2149	.1334	.1267	.1463	.1254	.3772
3	.1097	.2149	.1524	.1267	.1463	.1433	.3944
4	.1097	.2507	.1715	.1448	.1646	.1612	.4287
5	.1097	.2686	.2096	.1791	.2195	.2328	.5658
6	.128	.2686	.3239	.2804	.2743	.2454	.7202
7	.1463	.2454	.3048	.2743	.2743	.2743	.9945
8	.1097	.2286	.2286	.2401	.2561	.2401	1.0974
9	.1578	.5144	.6135	.4973	.7373	.703	.1612
10	.1227	.4458	.5959	.7545	.8745	.8745	.1075
11	.0876	.4801	.6661	.6516	.8669	.9945	.0895
12			.6661	.583	.9015	1.0117	.1075
13	.2328		.631	.6001	.9465	.9431	.1254
14	.2686		.5959	.6173	.9465	.8745	.1075
15	.3045	.4475	.6485	.6173	.929	.8573	.0895
16		.431	.6135	.6344	.8589	.8402	.0895
17	.1075	.0953	.0537	.1097	.1075	.128	.0716
18	.181	.1715	.1433	.1829	.1612	.1646	.1791
19	.1991	.2667	.2279	.2378	.2103	.2926	.2149
20	.2172	.2477	.2454	.2378	.2507	.2561	.2507
21	.1433	.1905	.1791	.1991	.197	.2172	.2686
22	.1075	.1524	.1433	.1463	.1612	.181	.2686
23	.1075	.1524	.1433	.1463	.1402	.3856	.7164
24	.1097	.197	.1334	.1254	.1463	.1227	.3772
Max	.3045	.5144	.6661	.7545	.9465	1.0117	1.0974
Min	.0876	.0953	.0537	.1097	.1075	.1227	.0716
Avg	.1491	.2714	.3316	.3267	.4193	.4331	.3408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214482 / 33/11 Kv WARWAND S/STN.

Feeder No / Name : 401 / 33kv mahananda express      NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.0514		
10		.0514		.0537
11		.052		.1075
12	.0566			
13		.0526		
14		.0526		
15		.0526		
19			.0566	
20			.0566	
21			.0566	.0537
22			.0566	
23	.0566			
Max	.0566	.0526	.0566	.1075
Min	.0566	.0514	.0566	.0537
Avg	.0566	.0521	.0566	.0716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214499 / 33/11 KV DAHITANE S/STN.

Feeder No / Name : 201 / 11 KV DEVKARWADI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.7796	.3856	.8859	.8859	1.2136	.4115
2	.8859	.7545	.3856	.9568	.8916	1.2483	.4115
3	.9214	.8322	.4031	.9922	.9465	1.2971	.4115
4	.9568	.8505		1.0387	.9816	1.3321	.4115
5		.8954	.815	1.0745	.9816	1.3672	.4115
6		.9671	.8505	1.1104	1.0277	1.382	.4458
7		.9214	.5258	1.1462	1.2757	1.4175	.4207
8	1.0985	1.0277	.5784	1.0056	1.3466	1.6301	
9	.3121	.2454	.208	.2401	.3155	.2774	1.5775
10		.2294	.2427	.2401	.2804	.2454	1.6655
11		.2454	.2058	.208	.2454	.2454	2.2565
12		.2454	.1715	.208	.2481	.2103	2.2923
13	.2401	.2103	.2103	.1715	.2835	.6588	2.2786
14		.2103	.1753		.2103	.1734	2.3282
15	.2058	.2103	.1387	.1734	.2058	.208	2.3388
16	.2401	.2103	.1734	.1753	.2401	.2103	2.2436
17	.2103	.2103	.2683	.1753	.2774	.2454	
18	.2454	.2804	.3018	.2804	.3121	.2804	.3467
19	.2454	.3189	.3391		.3429	.4207	.3429
20	.2427	.3544	.373	.2103	.3772	.4252	.3772
21	.2774		.4161	.1753	.407	.4207	.4115
22	.2804	.3898	.3814	.3856	.3391	.4207	.4458
23	.6661		.7362	.8764	1.0631	.5721	.421
24		.3898	.8413		1.1317		.5721
Max	1.0985	1.0277	.8505	1.1462	1.3466	1.6301	2.3388
Min	.2058	.2103	.1387	.1715	.2058	.1734	.3429
Avg	.4919	.4899	.3968	.5586	.6090	.6914	1.0374



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214499 / 33/11 KV DAHITANE S/STN.

Feeder No / Name : 202 / 11 KV DAHITANE GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.3898	.3012	.3366	.3544	.3988	.3601
2	.4607	.3814		.3721	.3944	.4334	.3601
3	.4961	.4161	.333	.4075	.4382	.4557	.3772
4	.6024	.443	.3506	.4477	.5258	.4908	.5144
5	.6268	.5373	.567	.5014	.5609	.5083	.5487
6	.6447	.6089	.6201	.5194	.6379	.4961	.6687
7	.6626	.5316	.4908	.5373	.5144	.5316	.6135
8	.4252	.3544	.2629	.3121	.3898	.3721	
9	.3294	.3155	.3641	.2401	.3155	.2774	.298
10	.3439	.2622	.3641	.2229	.2804	.2629	.3012
11	.3077	.2454	.3086	.2254	.2103	.2629	.2507
12	.3584	.2454	.2401	.2427	.2481	.2629	.2507
13	.2743	.2103	.2804	.2572	.2126	.1907	.197
14		.2103	.2454	.2601	.2279	.1907	.2507
15	.1886	.2103	.208	.2427	.2058	.2774	.2481
16	.2401	.2103	.2427	.2629	.1886	.2629	.2454
17	.2454	.2103	.2515	.2629	.208	.2629	
18	.298	.3506	.2683	.298	.2427	.2804	.2947
19	.298	.3898	.2374	.333	.2743	.3856	.3258
20	.2947	.3898	.2543	.333	.3086	.4075	.3258
21	.2774	.3155	.2774	.3506	.2713	.3856	.3601
22	.2629	.3012	.2947	.333	.2883	.3681	.3772
23	.3155		.3155	.333	.3258	.333	.3563
24		.3012	.298		.3601		.3641
Max	.6626	.6089	.6201	.5373	.6379	.5316	.6687
Min	.1886	.2103	.208	.2229	.1886	.1907	.197
Avg	.3806	.3405	.3207	.3318	.3327	.3521	.3586

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214499 / 33/11 KV DAHITANE S/STN.

Feeder No / Name : 203 / 11 KV DAHITANE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0354	.0701	.0532	.0532	.052	.7373
2	.0532	.0347	.0701	.0532	.0514	.052	.7373
3	.0354	.052	.0701	.0532	.0526	.0526	.7373
4	.0354	.0354	.0701	.0537	.0526	.0526	.7373
5	.0358	.0358	.0709	.0537	.0526	.0526	.6859
6	.0358	.0358	.0532	.0537	.0532	.0532	.6687
7	.0358	.0354	.0526	.0537	.0532	.0532	.7011
8		.0354	.0701	.0347	.0532	.0532	
9	.1387	.0876	.0867	.1372	.3506	.4681	
10	.1448	.0082	.104	.1372	.3155	.6135	
11	.1629	.0876	.1029	.1387	.298		
12	.1886	.0876	.12	.156	.3366	.6485	
13	.1715	.0701	.1052	.1715	.3898		
14		.0701	.1227	.1734	.4207	.6762	
15	.1372	.0701	.1387	.1907	.4458	.7628	
16	.1029	.007	.104	.1928	.4115	.8764	
17	.0351	.0701	.0503	.0526	.052	.0701	
18	.0351	.0701	.0503	.0526	.052	.0701	.052
19	.0351	.0354	.0509	.0526	.0514	.0701	.0514
20	.052	.0709	.0678	.0526	.0514	.0709	.0686
21	.052	.0526	.0693	.0701	.0509	.1052	.0857
22	.0526	.0709	.0693	.0701	.0509	.1052	.0857
23	.0526		.0701	.0526	.0514	.0693	.6478
24		.0709	.0701		.0514		.104
Max	.1886	.0876	.1387	.1928	.4458	.8764	.7373
Min	.0351	.007	.0503	.0347	.0509	.052	.0514
Avg	.0783	.0534	.0796	.0917	.1584	.2394	.4357

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214543 / 33/11kv Pimpalgaon

Substation

Feeder No / Name : 201 / 11kv Siddeshwar Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503	.0503	.0914	.0671	.0671	.0762	.0671
2	.0335		.0762	.0671	.0671	.0457	.0838
3	.0335	.0671	.0762	.0503	.0671	.0457	.0838
4	.0335	.0838	.0762	.0503	.0838	.0914	.0671
5	.0671	.1006	.1219	.0503	.1006	.0914	.1006
6	.0671	.1341	.1372	.0671	.1174	.1067	.1174
7	.1006	.1509	.061	.0838	.1509	.1219	.1174
8	.1174	.1174	.0457	.1174	.1006	.1006	.0838
9	.1006	.1067	.1509	.1341	.1067	.2347	.0503
10	.1006	.1067	.1341	.1341	.1372	.2347	.0671
11	.1006	.1067	.1509	.1174	.1219	.2683	.0838
12	.1006	.0762	.1341	.1174	.1372	.3018	.0671
13	.0838	.1067	.1006	.1174	.1524	.3185	.0671
14	.0671	.0914	.1006	.1006	.1524	.3018	.0671
15	.1006	.0762	.0838	.1006	.1677	.2683	.0503
16	.1006	.0762	.1174	.1174	.1677	.3353	.0503
17	.0503	.0457	.0671	.0671	.0457	.0671	.0671
18	.0503	.061	.0671	.0838	.061	.0838	.0671
19	.1006	.0914	.0838	.1006	.0762	.1006	.1006
20	.1006	.0914	.0838	.1006	.0762	.1006	.1067
21	.1006	.0914	.0671	.0838	.0914	.1006	.0914
22	.0838	.0762	.1006	.0838	.0762	.0838	.0914
23	.0838	.0914	.0335	.0838	.0762	.0838	.2743
24	.0503	.0671	.0914	.1006	.0671	.0762	.0671
Max	.1174	.1509	.1509	.1341	.1677	.3353	.2743
Min	.0335	.0457	.0335	.0503	.0457	.0457	.0503
Avg	.0782	.0899	.0939	.0915	.1028	.1516	.0871

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 214543 / 33/11kv Pimpalgaon

Substation

Feeder No / Name : 202 / 11kv Matoba GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9724	.8048	1.0059	1.0395	.9389	.945	1.1904
2	1.0059	.8383	1.0669	1.1065	.9389	.9755	1.2407
3	1.0395	.8718	1.0364	1.1736	.9389	1.0669	1.291
4	1.0898	.9389	1.2193	1.2239	.9724	1.1279	1.358
5	1.1233	1.0395	1.1888	1.291	1.0059	1.2193	1.4083
6	1.1736	1.1736	1.2651	1.358	1.0395	1.2651	1.4754
7	1.3245	1.3077	1.2803	1.4251	1.1065	1.2955	1.4922
8	1.0898	1.1065	.945	1.1904	.8383	1.1736	1.1736
9	.8718	.8535	.9556	.9389	.6706	1.0898	1.1065
10	.7545	.6706		.8718	.5639	1.0395	.9221
11	.7377	.6554	.8383	.8048	.5792	1.0059	
12	.6706	.6249	.8383	.8383	.5792	.9556	.3353
13	.6706	.5944	.9054	.7545	.5487	.9556	
14	.6371	.5944	.8048	.7712	.5639	.9556	1.0059
15	.6371	.6249	.8551	.8383	.5792	.9389	1.0059
16	.6371	.6249	.7209	.7712	.6401	.9221	.9556
17	.5365	.7011	.7545	.7545	.6249	.9892	.9724
18		.7773	.8048	.8383	.7468	1.1233	1.0059
19	1.0898	1.0822	.8551	1.1904	.9297	1.1736	1.2574
20	1.0059	1.0669	.9724	1.1401	1.0212	1.2071	1.2346
21	.9389	.9602	1.073	1.1736	.945	1.1401	1.1126
22	.8718	.945	1.1233	1.1065	.9145	1.1401	1.0822
23	.8383	.884	1.0395	1.0059	.8383	1.0898	.9602
24	.9221	.8048	.9755	.9892	.9724	.884	1.1401
<b>Max</b>	<b>1.3245</b>	<b>1.3077</b>	<b>1.2803</b>	<b>1.4251</b>	<b>1.1065</b>	<b>1.2955</b>	<b>1.4922</b>
<b>Min</b>	<b>.5365</b>	<b>.5944</b>	<b>.7209</b>	<b>.7545</b>	<b>.5487</b>	<b>.884</b>	<b>.3353</b>
<b>Avg</b>	<b>.8973</b>	<b>.8561</b>	<b>.9793</b>	<b>1.0248</b>	<b>.8124</b>	<b>1.0700</b>	<b>1.1239</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 300 / Auxilary Consumption  
Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 301 / 22 KV INDUSTRIAL

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 302 / 22 Kv Pimpalgaon Feeder  
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 303 / 22 kv Bhuleshwar feeder  
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	2.1719
Max	2.1719
Min	2.1719
Avg	2.1719



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 304 / 22 Kv Yawat Feeder

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.2955
Max	1.2955
Min	1.2955
Avg	1.2955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 305 / 22 Kv Supa Feeder

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.7814
Max	1.7814
Min	1.7814
Avg	1.7814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 306 / 22 Kv Rahu Feeder

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 307 / 22 KV DECCAN

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 308 / 22 Kv Trishul

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 309 / 22 KV YAWAT GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.419
Max	1.419
Min	1.419
Avg	1.419

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUNG DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 310 / 22 KV SUPA GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.4858
Max	.4858
Min	.4858
Avg	.4858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 401 / 33 KV PARGAON

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 402 / 33 KV RAHU FEEDER

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	3.858
Max	3.858
Min	3.858
Avg	3.858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUNG DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 403 / 33 KV SAHAJPUR

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 404 / 33 kv MINAKSHI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	2.1862
Max	2.1862
Min	2.1862
Avg	2.1862

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 217013 / YAwat Sub-station

Feeder No / Name : 406 / 33 KV LIEBHERR

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	.4001
Max	.4001
Min	.4001
Avg	.4001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 217045 / 132/33 KV JANAI S/STN

Feeder No / Name : 400 / Auxilary

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217045 / 132/33 KV JANAI S/STN

Feeder No / Name : 401 / Varvanand Stage 1

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.643
Max	.643
Min	.643
Avg	.643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 217045 / 132/33 KV JANAI S/STN

Feeder No / Name : 402 / Janai Stage 2

Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701] BU 4701

Substation No/ Name :- 217045 / 132/33 KV JANAI S/STN

Feeder No / Name : 405 / 33/11 KV Supa S/stn  
Incomer Feeder KV- 33 /  
INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

KEDGAON S/DN.[701]

BU 4701

Substation No/ Name :- 217045 / 132/33 KV JANAI S/STN

Feeder No / Name : 406 / Kedgaon( Warwand)

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 301 / DSM Express

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8299	1.0669	.7545	.8299	1.0185	.7167
2	.679	1.1317	1.0288	.6413	.7545	.9431	.6413
3	.6413	1.1694	.9907	.7167	.679	.8299	.9054
4	.6036	1.0562	.7621	.8676	.6036	.6413	.9808
5	.6413	1.0185	.8002	.7922	.679	.7922	.8299
6	.6413	1.094	.8383	.9431	.7545	.8676	1.0185
7	1.1317	1.0185	.9145	.8299	.8299	.8299	.5281
8	1.1317	.415	.724	.7545	.7922	.679	.415
9	1.2071	.5281	.6478	.7545	.4527	.7922	.7545
10	.9054	.9145	.415	.6859	.2263	.5281	.8764
11	.8676	.4572	.2641	.5658	.0754	.3772	.7621
12	1.1694	.1905	.5281	.8676	.2641	.4527	.7621
13	1.2193	.1905	.6036	.3395	.3772	.5281	.381
14	.5281	1.0288	.1886	.3018	.1132	.3018	1.0669
15	.9808	.381	.3772	.3395	.2263	.4527	1.1812
16	1.0562	.4954	.5658	.7167	.6036	.5658	1.0669
17	.9431	.7621	.679	.8299	.6413	.4904	1.1431
18	1.0185	1.3336	.7922	1.094	.7922	.5281	1.1812
19	.7922	.9907	.4904	1.0185	.9054	.7922	1.2193
20	.415	.9526	.4904	.9431	.6413	1.0562	1.1431
21	.7545	.8383	.6036	.9054	.9808	.9054	.6859
22	1.1317	1.0288	.8676	.9054	1.0185	.6036	.6859
23	1.1694	1.105	.6413	.9808		.2263	1.2193
24	.7545	1.1317	1.0669	.679	.9054	.9431	.5281
<b>Max</b>	<b>1.2193</b>	<b>1.3336</b>	<b>1.0669</b>	<b>1.094</b>	<b>1.0185</b>	<b>1.0562</b>	<b>1.2193</b>
<b>Min</b>	<b>.415</b>	<b>.1905</b>	<b>.1886</b>	<b>.3018</b>	<b>.0754</b>	<b>.2263</b>	<b>.381</b>
<b>Avg</b>	<b>.8807</b>	<b>.8359</b>	<b>.6811</b>	<b>.7595</b>	<b>.6151</b>	<b>.6727</b>	<b>.8622</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 302 / Pepsico Express

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7353	1.6975	1.5242	1.7551	1.8107	1.773	1.6804
2	1.6598	1.8107	1.4861	1.6057	1.7353	1.8861	1.643
3	1.5844	1.7353	1.5242	1.5466	1.6598	1.7353	1.7551
4	1.5089	1.8107	1.5623	1.643	1.8107	1.8484	1.7177
5	1.5466	1.6975	1.5623	1.6804	1.9239	1.6975	1.6057
6	1.5844	1.6598	1.6004	1.5684	1.9616	1.5844	1.7924
7	1.4335	1.7353	1.6766	1.531	2.037	1.7353	1.8671
8	1.8107	1.8107	1.6766	1.7924	1.8861	1.9239	1.9418
9	1.6975	1.4335	1.8671	1.9616	1.9993	1.9239	1.7924
10	1.8107	1.3336	1.7924	1.9791	2.1125	2.0165	1.6766
11	1.6221	1.3336	1.7551	1.9616	2.1125	1.9418	1.5242
12	1.7353	1.3717	1.5684	1.9239	2.1502	1.9791	1.6004
13	1.8861	1.3717	1.8298	1.8484	1.9993	1.9791	1.7528
14	1.773	1.2574	1.8671	1.9993	1.9993	1.9791	1.7909
15	1.6598	1.2574	1.8298	1.8861	1.9993	1.9791	1.7528
16	1.6975	1.4098	1.8298	1.8484	1.9616	1.9044	1.6766
17	1.6221	1.4861	1.7924	1.8861	1.8861	1.8671	1.7528
18	1.6221	1.6004	1.7551	1.8484	1.8484	1.8671	1.7909
19	1.8107	1.5623	1.7551	1.9616	1.9239	1.9418	1.7909
20	1.8861	1.6385	1.8298	1.8861	2.037	1.9418	1.7909
21	1.773	1.6766	1.8298	1.9239	1.9993	1.6804	1.5623
22	1.7353	1.6385	1.7924	1.8861	1.9239	1.7924	1.5242
23	1.6598	1.6385	1.7924	1.9616		1.8298	1.5623
24	1.8107	1.8861	1.6004	1.6804	1.9239	1.9239	1.8298
<b>Max</b>	<b>1.8861</b>	<b>1.8861</b>	<b>1.8671</b>	<b>1.9993</b>	<b>2.1502</b>	<b>2.0165</b>	<b>1.9418</b>
<b>Min</b>	<b>1.4335</b>	<b>1.2574</b>	<b>1.4861</b>	<b>1.531</b>	<b>1.6598</b>	<b>1.5844</b>	<b>1.5242</b>
<b>Avg</b>	<b>1.6944</b>	<b>1.5772</b>	<b>1.7125</b>	<b>1.8152</b>	<b>1.9435</b>	<b>1.8638</b>	<b>1.7156</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 303 / G &amp;F Block MIDC

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.5539	6.4506	7.2398	5.487	4.2676	5.7339	5.1059
2	6.4777	6.262	7.1254	5.2584	4.0009	5.4698	4.9535
3	6.4015	5.8848	6.9349	5.4108	3.9628	5.3727	5.1821
4	6.5539	6.0357	6.6301	5.3346	3.7342	5.6013	5.2965
5	6.8206	6.0585	6.6682	5.5251	4.1533	5.7339	4.9916
6	6.7825	6.1111	6.6682	5.6013	4.382	5.8848	5.2202
7	6.3634	6.3375	6.4015	4.1152	4.5344	5.5076	4.1914
8	7.2779	6.7147	7.1636	4.6868	6.7825	4.4513	4.8773
9	8.4591	7.8841	6.4396	5.1303	7.697	5.9061	5.868
10	7.5446	8.9925	6.9349	5.7156	6.8968	6.211	6.2872
11	7.3922	9.5641	6.4396	5.1821	7.8841	6.7825	5.0297
12	7.4303	8.6877	6.7063	3.8104	7.1674	6.5539	5.2584
13	6.9787	8.5734	6.4396	4.2295	7.2805	6.1347	5.2202
14	8.4122	7.6589	6.4015	4.6487	7.5823	5.7156	5.3727
15	6.0966	7.697	6.0585	4.8011	7.4684	6.0966	5.6775
16	7.62	8.3829	6.6301	4.8011	7.5446	5.8299	5.7156
17	7.0111	8.6115	5.5251	5.1821	7.316	5.7918	6.1728
18	6.1728	7.6208	5.9823	4.5344	7.1254	5.4489	6.4015
19	7.2428	7.9637	5.1059	3.9628	6.677	5.1059	6.211
20	6.6682	7.6589	6.0966	3.5818	6.5158	5.2202	6.5158
21	6.262	7.5446	5.7537	4.1533	6.6392	5.0297	6.7063
22	6.262	7.2779	5.7918	4.382	7.1674	5.3346	6.6682
23	6.1488	7.4303	5.9061	4.1914		5.4489	6.7444
24	6.6015	6.4883	7.2398	5.7918	4.1152	6.0357	5.3346
Max	8.4591	9.5641	7.2398	5.7918	7.8841	6.7825	6.7444
Min	6.0966	5.8848	5.1059	3.5818	3.7342	4.4513	4.1914
Avg	6.8973	7.4121	6.4285	4.8132	6.1259	5.6834	5.6251

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 304 / Wheels India EXPS

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3169	1.1523	1.6385	1.0974	1.4266	1.4198	1.1043
2	1.3443	1.1831	1.6766	1.0425	1.3717	1.3717	1.0517
3	1.3992	1.2357	1.6385	1.1523	1.3169	1.2894	1.166
4	1.4266	1.3336	1.6004	1.07	1.2445	1.1831	1.0623
5	1.3992	1.3169	1.5242	1.1248	1.1736	1.3797	1.1401
6	1.3527	1.3992	1.5623	1.1797	1.1203	1.4937	1.0883
7	1.1523		1.5242	1.0151	1.1469	1.1523	1.1142
8	1.5089	1.07	1.7147	1.3443	1.2071	1.3717	1.1142
9	1.3992	1.078	1.7528	1.1523	1.4266	1.0974	1.0883
10	1.2346	2.4387	1.2346	1.4937	1.4266	1.5028	1.6766
11	1.3992	2.0195	1.2346	1.2003	1.2894	1.1142	1.6766
12	1.0151	1.6004	1.0151	1.1797	1.262	1.3474	1.7147
13	1.6187	1.5242	1.262	1.3169	1.8381	1.2437	1.6766
14	1.5638	2.1338	1.2346	1.3443	1.893	1.0623	1.6385
15	1.6187	2.0576	1.2346	1.701	1.454	1.3474	1.6385
16	1.07	1.9052	1.1248	1.2269	1.0974	1.4769	1.6385
17	1.4266	1.4861	1.5089	1.4266	1.2894	1.1142	1.6385
18	1.1797	1.7528	1.6461	1.3443	1.4815	1.4769	1.6004
19	1.2346	1.7528	1.7558	1.6735	1.3443	1.3992	1.5242
20	1.1248	1.7147	1.3717	1.3527	1.2346	1.1919	1.5623
21	1.0974	1.6385	1.3717	1.307	1.1248	1.2437	1.6004
22	1.07	1.6004	1.2071	1.7284	1.4266	1.3474	1.5242
23	1.5638	1.6385	1.3169	1.5364		1.2696	1.5623
24	1.547	1.3352	1.6766	1.1797	1.4815	1.4266	.9587
<b>Max</b>	<b>1.6187</b>	<b>2.4387</b>	<b>1.7558</b>	<b>1.7284</b>	<b>1.893</b>	<b>1.5028</b>	<b>1.7147</b>
<b>Min</b>	<b>1.0151</b>	<b>1.07</b>	<b>1.0151</b>	<b>1.0151</b>	<b>1.0974</b>	<b>1.0623</b>	<b>.9587</b>
<b>Avg</b>	<b>1.3360</b>	<b>1.5812</b>	<b>1.4511</b>	<b>1.2996</b>	<b>1.3512</b>	<b>1.3051</b>	<b>1.3984</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213332 / 22 KV RANJANGAON SWITCHING

NO1

Feeder No / Name : 305 / 22 KV POLYONE

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 22 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.2263	.1905	.2263			
2	.1509	.1886	.1905	.1886			
3	.1132	.2641	.1905	.1886			
4	.1509	.3018	.1524	.2263			
5	.1886	.2641	.1905	.1886			
6	.1886	.3018	.2286	.1886			
7	.1886	.2263	.2286	.1509			
8	.1886	.1886	.2286	.2263	.2263		.3018
9	.3395	.2263	.2286	.3018	.1509		.2263
10	.3018		.3018	.2641	.2641		.2286
11	.3395	.3048	.3395	.3772	.3018		.2667
12	.3772	.2286	.2263		.3018		.2667
13	.3395	.2667	.1886		.2263		
14	.3395	.2286	.2263		.2263		.2667
15	.3395	.2667	.2641	.1886	.2641		.1905
16	.3018	.3048	.2263	.2263	.2263		.2286
17	.415	.2286	.2263	.1886	.2263		.2286
18	.3772	.3048	.2263	.1886	.1886		.1905
19	.3018	.2667	.2263	.2263	.1886		.2286
20	.2263	.2667	.2263	.2641	.3395		.2286
21	.3018	.2286	.2641	.2263	.2641		.2667
22	.2641	.2286	.2641	.2263	.2641		.2667
23	.3018	.2286	.2263	.2641			.2286
24	.1886	.3018	.2286	.2263	.2263	.1132	
Max	.415	.3048	.3395	.3772	.3395	.1132	.3018
Min	.1132	.1886	.1524	.1509	.1509	.1132	.1905
Avg	.2656	.2540	.2288	.2263	.2428	.1132	.2409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUNG DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II

Feeder No / Name : 301 / Classic auto tube NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2634	2.2634	1.8861	1.8861	2.2634	2.0748	1.6975
2	1.8861	2.452	2.0748	1.8107	1.8861	2.2634	1.8861
3	2.0748	2.2634	1.8861	1.8484	2.0748	1.8861	2.0748
4	1.8861	2.0748	1.8861	1.6975	2.452	2.2634	1.8861
5	1.6975	1.8861	1.8861	1.773	2.2634	1.5089	1.5089
6	1.8861	1.8861	1.8861		2.452	1.8861	1.5089
7	1.5089	1.5089	1.5089	1.6975	1.5089	1.5089	1.3203
8	1.8861	2.0748	1.8861	1.8861	2.0748	2.2634	2.0748
9	2.0748	2.2634	1.8861	1.8861	2.0748	2.0748	1.8861
10	2.0957	2.452	1.8861	2.0748	1.8861	2.2634	1.1317
11	2.0957	1.8861	2.2634	1.5089	2.0748	1.8861	1.5089
12	2.0957	1.1317	1.7147	1.8861	1.8861	1.8861	1.5089
13	1.8861	1.5089	1.8861	1.5089	1.8861	2.0748	1.8861
14	2.2634	2.2634	2.2634	1.3203	1.8861	1.5089	2.452
15	1.1317	.3772	1.5089	.7545	1.6975	1.3203	.3772
16	2.452	1.8861	2.2634	2.2634	1.6975	1.5089	1.5089
17	2.2634	1.8861	2.452	2.452	2.0748	1.5089	1.8861
18	2.2634	1.8861	2.2634	2.452	1.8861	1.3203	2.0748
19	2.0748	2.2634	2.452		2.0748	1.6975	1.8861
20	2.0748	1.8861	2.452		2.2634	1.8861	2.2634
21	2.2634	2.0748	2.2634		2.2634	1.6975	2.452
22		2.2634	2.3388		2.0748	1.5089	2.2634
23		2.0748	1.5089		1.5089	1.6975	1.6975
24	2.2634	2.0748	1.8861	2.037	2.452	1.8861	1.8861
Max	2.452	2.452	2.452	2.452	2.452	2.2634	2.452
Min	1.1317	.3772	1.5089	.7545	1.5089	1.3203	.3772
Avg	2.0176	1.9412	2.0079	1.8191	2.0276	1.8075	1.7761

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II

Feeder No / Name : 302 / Jabil Circuit NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.5089	1.4937	1.0288	.7468	.3734	.3772
2	1.5089	1.5089	1.4937	.9431	.7468	.3734	.3772
3	1.5089	1.1317	1.6804	.9431	.7468	.3734	.3772
4	1.5089	1.1317	1.4937	.9431	.7468	.3734	.3772
5	1.6975	1.5089	1.6804	1.0288	.3734	.3734	.3772
6	1.3203	1.1317	1.4937	1.1317	.3734	.3734	.3772
7	1.5089	1.1317	1.4937	1.1317	.3734	.3734	.5658
8	1.5089	1.1317	1.4937	1.2003	.3734	.3734	.7545
9	1.6975	1.1317	1.6804	1.5089	.3772	.3772	.7545
10	1.5242	1.4937	1.5089	1.6975	.3772	.3772	1.1203
11	1.7147	1.4937	1.5089	1.5089	.3772	.3772	1.4937
12	1.5242	1.4937	1.5089	1.5089	.3772	.1886	1.1203
13	1.1317	1.4937	1.5089	1.5089	.3772		
14	1.5089	1.4937	1.5089	1.5089	.3772		1.4937
15	1.5089	1.4937	1.5089	1.5089	.3772		1.4937
16	1.5089	1.8671	1.6975	1.6975	.3772	.3772	1.1203
17	1.1317	1.4937	1.6975	1.3203	.3772	.3772	1.4937
18	1.5089	1.4937	1.6975	1.1317	.3772	.3772	1.4937
19	1.5089	1.6804	1.6975		.3734		1.5089
20	1.5089	1.4937	1.6975		.3734	.3772	1.5089
21	1.5089	1.4937	1.5844		.3734	.1886	1.5089
22		1.4937	1.5089		.3734	.3772	.7545
23		1.4937	1.5089		.3734	.3772	1.1317
24	1.5089	1.5089	1.4937	1.3203	.7468	.3734	.3772
Max	1.7147	1.8671	1.6975	1.6975	.7468	.3772	1.5089
Min	1.1317	1.1317	1.4937	.9431	.3734	.1886	.3772
Avg	1.4939	1.4291	1.5683	1.2932	.4528	.3566	.9547



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II

Feeder No / Name : 303 / Haier NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 213342 / 22 kV Ranjangaon MIDC SW II

Feeder No / Name : 304 / Starion NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)  
Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.2826	1.1317	1.1694	1.2955	1.2193	.7545
2	1.2449	1.2449	1.2071	1.2071	1.2193	1.1431	.7167
3	1.5089	1.3203	1.1694	1.1317	1.3336	1.0669	.679
4	1.4335	1.1694	1.094	1.1694	1.448	.9907	1.1317
5	1.2071	1.2826	1.0562	1.2826	1.4098	1.0669	1.0562
6	1.358	1.2071	1.2449	1.3203	1.3717	1.1431	1.2826
7	1.4712	1.358	1.1317	1.2826	1.4861	.724	1.2071
8	1.5466	1.4335	1.1317	1.3957	1.6004	.6859	1.2071
9	1.8484	1.7353	1.0185	1.4712	1.6598	.9808	1.1317
10	1.5089	1.4335	1.2826	1.5466	1.7353	.9431	1.358
11	1.7353	1.3203	1.2826	1.6975	1.5089	.7167	1.4335
12	1.5844	1.3203	1.2826	1.5844	1.3957	.7167	1.5089
13	1.5089	1.6221	1.1317	1.6598	1.2071	.7545	1.4335
14	1.6975	1.5844	1.358	1.6975	1.3957	.7922	1.4712
15	.5281	1.6221	1.3957	1.5089	1.358	.6036	1.773
16	1.6975	1.5844	1.4335	1.5089	1.4712	.5281	1.5844
17	1.5844	1.5466	1.3203	1.6221	1.1694	.679	1.3203
18	1.6221	1.6221	1.5089	1.6975	1.2826	.6036	1.358
19	1.5089	1.6975	1.5466		1.2193	.4527	1.4335
20	1.358	1.5089	1.0185		1.1431	.679	1.2826
21	1.2449	1.5466	1.1317		1.0669	.6036	1.2071
22		1.3203	1.1694		1.105	.6413	1.358
23		1.4335	1.0562		1.4861	.7545	1.2826
24	1.2826	1.358	1.2071	1.2071	1.3717	1.3336	.7167
Max	1.8484	1.7353	1.5466	1.6975	1.7353	1.3336	1.773
Min	.5281	1.1694	1.0185	1.1317	1.0669	.4527	.679
Avg	1.4403	1.4398	1.2213	1.4295	1.3642	.8260	1.2370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214333 / 33/11 kv Pabal

Feeder No / Name : 201 / 11 kv Pabal

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668		.5601		.5228
2	.5601	.4668		.5601	.5601	.5601
3		.5415		.5601		.6535
4	.5975	.6535		.7842		.7468
5	.6535	.8402		.8215	.8215	.8402
6		.8775		.8962		.9149
7	.9522	.9335		.9896	1.1576	1.0269
8	.8589	.9335			1.1203	1.2136
9	.5788		.5601	.5601	.4108	
10	.4668		.5228		.4854	
11	.4108		.4481	.4481		
12	.4108		.4294		.4294	
13	.3921		.4294			
14	.3921		.4294	.4294		
15	.4108		.4108			
16	.4668		.4108	.4294	.4294	
17	.5228		.4854		.4668	
18	.5601		.5228		.4854	
19	.5975		.6348	.7095	.5601	
20	.6535		.6722		.5975	
21	.6535		.7095		.6535	
22	.5975				.6535	
23	.5601				.5975	
24	.5601	.5228		.3547	.5601	
Max	.9522	.9335	.7095	.9896	1.1576	1.2136
Min	.3921	.4668	.4108	.3547	.4108	.5228
Avg	.5646	.6929	.5127	.6233	.6243	.8099

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214333 / 33/11 kv Pabal

Feeder No / Name : 202 / 11 kv Dhamari  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6535		1.0829		1.2696
2	.7468	.7282		1.0829	1.1203	1.4003
3		.8402		1.0829		1.4003
4	.8402	1.2696		1.7924		1.587
5	.9522	1.4937		1.8671	1.6057	1.8671
6		1.5684		2.0538		2.0911
7	1.7177	1.4937		2.1658	2.2032	2.5766
8	1.4003	1.4003			2.1285	2.6326
9	1.307		.5228	.4481	.5601	
10	1.307		.4481		.6535	
11	1.4003		.3734	.3734	.5601	
12	.7468		.3696		.3921	
13	.7095				.3734	
14	.6722		.4108	.2987	.3547	
15	.7095		.4108		.3734	
16	.6535		.4108	.2987	.3921	
17	.7468		.4854		.4668	
18	.8215		.5228		.5601	
19	.8402		.8775	.7468	.7468	
20	.7842		1.0829		.8402	
21	.7468		1.1763		.8402	
22	.7468				.8775	
23	.7095				.9335	
24	.7468	.6535		.8775	1.1203	1.1576
Max	1.7177	1.5684	1.1763	2.1658	2.2032	2.6326
Min	.6535	.6535	.3696	.2987	.3547	1.1576
Avg	.9193	1.1223	.5909	1.0901	.8551	1.7758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214333 / 33/11 kv Pabal

Feeder No / Name : 203 / 11 kv Kendur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8402		.6722		.5975
2	.7842	.8402		.6722	.6722	.5975
3		.9149		.6722		.7095
4	.8029	1.1016		.8402		.8402
5	.8402	1.1576		.9335	.0747	1.1016
6		1.2136		1.0082		1.1576
7	1.2323	1.1576		1.1763	.1307	1.1203
8	1.1389	1.1203			.1307	1.0642
9	.6908		.7095		.3734	
10	.5228		.5601		1.1576	
11	.3921		.4481		1.4937	
12	.4108		.3547		1.6057	
13	.3734		.3921		1.6057	
14	.2614		.3921		1.587	
15	.3734		.3921		1.587	
16	.4668		.4294		1.5123	
17	.5601		.4854		.4668	
18	.6535		.6348		.5041	
19	.6722		.7842	.8962	.6535	
20	.7095		.8589	.9335	.7468	
21	.7095		.9149		.7842	
22	.6908				.8402	
23	.7468				.7842	
24	.7842	.7842		.6722	.6722	.6535
Max	1.2323	1.2136	.9149	1.1763	1.6057	1.1576
Min	.2614	.7842	.3547	.6722	.0747	.5975
Avg	.6579	1.0145	.5659	.8477	.8691	.8713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUNG DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214333 / 33/11 kv Pabal

Feeder No / Name : 204 / 11kv Pabal Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.168		.1867		.168
2	.1494	.1494		.1867	.168	.168
3		.2241		.1867		.2241
4	.168	.2614		.2614		.2614
5	.168	.2987		.2987	.2614	.2801
6		.3547		.3361		.3361
7	.3921	.2987		.3734	.4108	.3361
8	.2987	.2801			.3734	.3174
9	.2614		.2241		.3174	
10	.2614		.2054		.2801	
11	.2241		.2054			
12	.2427		.2054		.2054	
13	.2241		.2054		.3361	
14	.1867		.2241		.3734	
15	.2054		.2241		.3361	
16	.2241		.2241		.2614	
17	.2241		.2614		.2614	
18	.2614		.2614		.2241	
19	.2801		.2987	.2801	.2427	
20	.3361		.3361		.2614	
21	.3734		.2987		.2241	
22	.3734				.2241	
23	.2801				.1867	
24	.1494	.2241		.1494	1.8298	.1867
Max	.3921	.3547	.3361	.3734	1.8298	.3361
Min	.1494	.1494	.2054	.1494	.168	.168
Avg	.2516	.2510	.2442	.2510	.3567	.2531

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214514 / 33/22 kV PIMPALE JAGTAP Sub  
StFeeder No / Name : 201 / 11 KV pimple jagtap SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1494	.1494	.1867	.1867	.1867	.1494
2	.1867	.1494	.1494	.1494	.1494	.1867	.1494
3	.1867		.1867	.1867	.1867	.2054	.1867
4	.2241		.1867	.1867	.1867	.2801	.1867
5	.2987		.3361	.3361	.3361	.3361	.3361
6	.4108		.3734	.3734	.4108	.3921	.4481
7	.4108		.3734	.4108	.4108	.4481	.4481
8	.2987		.3734	.3361	.3361	.2987	.3734
9	.4481		.3734	.5975	.5975	.7209	.5975
10	.4024		.3734	.5601	.7095	.7468	1.0642
11	.3688	.3361	.3734	.6348	.6203	.7095	1.0456
12	.3185	.3734	.3361	.6348	.6371	.7095	1.1203
13	.3185	.3734	.3361	.6348	.7042	.7095	1.1576
14	.285	.3361	.3361	.6348	.7042	.6722	1.1949
15	.285		.1867	.6348	.7042	.7095	1.1949
16	.285		.1867	.5975	.7042	.7468	1.1576
17	.1307	.1494	.0934	.1494	.168	.1494	.1494
18	.1867	.2241	.1715	.1494	.168	.1494	.1867
19	.2987	.3361	.2241	.1494	.2427	.1494	.3361
20	.2987	.3361	.3361	.3361	.3361	.3361	.3734
21	.2614	.3734	.3361	.3361	.2987	.3361	.3734
22	.2427	.3361	.3361	.1867	.2614	.3361	.3361
23	.2054	.1867	.1867	.1867	.2241	.1867	
24	.1867	.168	.1867	.1867	.1867	.2054	.1867
Max	.4481	.3734	.3734	.6348	.7095	.7468	1.1949
Min	.1307	.1494	.0934	.1494	.1494	.1494	.1494
Avg	.2810	.2734	.2709	.3656	.3946	.4128	.5544

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699]

BU 4699

Substation No/ Name :- 214514 / 33/22 kV PIMPALE JAGTAP Sub

St

Feeder No / Name : 301 / 22 KV Pimpale Jagtap AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7468	.7468	.7842	.7468	.9709	.6722
2	.7468	.7468	.7468	.8215	.7468	.9709	.7468
3	.7842	.9709	.9709	.8215	.6722	1.0829	.8962
4	.7468	1.1203	1.4937	1.1203	1.1203	1.2696	1.1203
5	.9709	1.419	1.2323	1.7177	1.5684	1.419	1.3443
6	1.4937	1.6057	1.4937	1.419	1.419	1.6057	1.4937
7	1.5684	1.7924	1.419	1.531	1.4937	1.1203	1.4563
8	1.1949	1.4563	1.3443	1.3443	1.3443	.8962	1.307
9	1.7177	1.4419	1.9044	1.9044	2.4646	1.9113	2.9127
10	1.4754	1.3748	1.9791	2.1285	2.6886	2.4272	3.6222
11	1.3748	1.5684	1.6804	1.8671	2.5484	2.3525	3.5475
12	1.1736	.7842	1.643	2.1285	2.4143	3.5475	3.5101
13	1.1065	.7842	.8962	2.0911		2.95	3.7342
14	1.0395	1.0456		2.2405	2.4813	3.0247	3.7715
15				2.2032	2.5484	3.1741	3.7715
16	1.073			1.8671	2.5484	3.1741	3.6969
17	.6348	.5601		.6348	.5601	.5228	.6348
18	.9335	1.1203	1.1203	1.1203	.7468	.7468	.7095
19	1.1576	1.2696	.9335	1.1576	1.0456	1.1203	1.1949
20	1.307	1.1949	1.2696	1.3443	1.419	1.3817	1.4937
21	1.1949	1.1949	1.2696	1.3443	1.3443	1.3443	1.4937
22	1.0456	1.0082	.8215	1.0829	1.1949	1.1949	1.1949
23	.8589	.8962	.8962	1.0456	1.0456		1.0456
24	.7468	.7842	.7468	.8589	.7468	.9709	.9335
<b>Max</b>	<b>1.7177</b>	<b>1.7924</b>	<b>1.9791</b>	<b>2.2405</b>	<b>2.6886</b>	<b>3.5475</b>	<b>3.7715</b>
<b>Min</b>	<b>.6348</b>	<b>.5601</b>	<b>.7468</b>	<b>.6348</b>	<b>.5601</b>	<b>.5228</b>	<b>.6348</b>
<b>Avg</b>	<b>1.0893</b>	<b>1.1312</b>	<b>1.2304</b>	<b>1.4408</b>	<b>1.5178</b>	<b>1.7034</b>	<b>1.9293</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214514 / 33/22 kV PIMPALE JAGTAP Sub  
StFeeder No / Name : 303 / 22 KV Industrial  
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5684	1.358	1.3443	.8962	1.419	1.3957	1.3817
2	1.531	1.3957	1.3817	.8962	1.4937	1.4335	2.1658
3	1.4563	1.4712	1.4937	.8962	1.9044	1.358	1.7924
4	1.4937	1.4335	1.3443	.8962	1.6804	1.3203	1.8671
5	1.531	1.5089	1.1203	1.1949	1.4937	1.2449	1.4937
6	1.6057	1.5844	1.0456	1.1203	1.7177	1.2826	1.419
7	1.419	1.3203	.8962	1.1203	1.7551	.9431	2.0165
8	1.9418	2.037	.8215	1.3443	1.9791	1.5089	1.8671
9	1.9044	1.8671	.5601	1.6804	1.7551	1.8298	
10	1.9418	1.9418	.8962	1.6057	2.0538	1.7177	2.0538
11	2.0538		1.1949	1.6057	2.0165	1.7924	2.2405
12	.7842		1.307	1.4937	1.531	2.0165	1.9044
13	1.643		1.2696	1.531	1.7177	2.1658	1.8671
14	1.6804		1.1203	1.643	1.5684	1.7551	1.9044
15	1.6057		1.1203	1.7177	2.0165	1.1949	1.8298
16	1.531		1.0829	1.7551	1.9044	1.1949	2.3525
17	1.5844	1.9418	1.1203	1.9418	1.8861	1.7177	2.1285
18	1.8484	1.8671	1.0456	1.4937	1.6598	1.7177	1.9044
19	1.9418	1.9044	1.1203	1.643	2.1502	1.8298	1.8298
20	1.8298	1.8671	1.1203	1.7924	1.9993	1.531	1.7177
21	1.7551	1.643	1.0829	1.7551	1.6975	1.531	1.4937
22	1.8671	1.8671	1.0456	1.5684	1.9239	1.6804	1.9044
23	1.7551	1.5684	1.0456	1.5684	1.6975	1.4937	1.4563
24	1.307	1.3957	1.4937	1.0456	1.3443	1.4335	1.307
Max	2.0538	2.037	1.4937	1.9418	2.1502	2.1658	2.3525
Min	.7842	1.3203	.5601	.8962	1.3443	.9431	1.307
Avg	1.6492	1.6651	1.1281	1.4252	1.7652	1.5454	1.8216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699]

BU 4699

Substation No/ Name :- 214541 / 33/11 KV Kanhur Mesai

Feeder No / Name : 201 / 11 KV Khanur AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6283	.6838	.7922	.5914	.8131	.6468
2	.7167	.6468	.6979	.7733	.6036	.8589	.6268
3	.7095	.6584	.703	.8402	.6036	.9709	.6415
4	.7095	.7783	.7712	.8779	.6602	1.094	.7421
5	.7947	1.0164	.905	.9425	.8316	1.1827	1.1389
6	.9979	1.262	.9412	.9412	1.0456	1.4083	1.4335
7	1.1523	1.086	1.2752	1.2803	1.2308	1.5927	1.5364
8	1.0534	.8596	1.0608	1.4299	1.1389	1.6632	1.0719
9	.5175	.5544	.4854	.7023	.362	.6722	1.2483
10	.4805	.4251	.415	.4805	.3544	.5304	1.3904
11	.3395	.3921	.3142	.2507	.2804	.3326	1.358
12	.3361	.2614	.3658	.2481	.2427	.3547	1.326
13	.3142	.3109	.3109	.2172	.2058	.3258	1.3916
14	.3326	.3292	.3439	.2195	.2058	.3582	1.326
15	.3292	.3696	.3582	.1734	.2204	.3856	1.3904
16	.3547	.3921	.3801	.2427	.218	.3258	1.4232
17		.4066	.4294	.2241	.2058	.2774	.4024
18	.7167	.6161	.5658	.3395	.3734	.6348	.5373
19	1.0082	.9997		.6413	.6653	.8316	.815
20	.9431	1.0751	1.1317	.811	1.0608	1.1949	.9465
21	.8865	.9522	.9709	.6838	.9795	.9362	.8669
22	.8215	.8686	.9149	.6099	.9335	.8326	.7545
23	.7133	.7392	.8488	.5975	.7762	.6979	.7059
24	.7095	.6219	.7095	.8029	.5914	.7762	.6908
Max	1.1523	1.262	1.2752	1.4299	1.2308	1.6632	1.5364
Min	.3142	.2614	.3109	.1734	.2058	.2774	.4024
Avg	.6806	.6771	.6775	.6301	.5992	.7938	1.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 214541 / 33/11 KV Kanhur Mesai

Feeder No / Name : 203 / 11 KV Varude AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1294	.1478	.1698	.1698	.2033	.1663
2	.132	.1109	.1509	.1509	.1698	.2241	.1612
3	.1307	.128	.12	.168	.1698	.2614	.1734
4	.1307	.1991	.1578	.1646	.2263	.3206	.2172
5	.2402	.3142	.181	.2033	.2801	.3881	.2801
6	.3142	.4024	.3361	.2353	.4294	.4572	.3206
7	.4207	.4344	.4251	.2926	.4344	.5068	.6219
8	.3326	.3109	.3658	.2715	.3045	.3326	.5729
9	.2218	.2772	.2614	.2772	.3224	.3361	.1907
10	.1848	.2033	.2641	.1848	.3224	.3109	.1187
11	.132	.1867	.1848	.1254	.2103	.2218	.1006
12	.112	.1086	.128	.124	.208	.2427	.0829
13	.1109	.128	.128	.0724	.2229	.2172	.0671
14	.0924	.1097	.1448	.0549	.2229	.2328	.0663
15	.1097	.1294	.1791	.1448	.2374	.2279	.0678
16	.112	.1307	.1629	.1907	.2347	.1886	.0686
17	.0943	.1109	.0934	.056	.1029	.156	.0732
18	.1509	.1867	.1509	.0943	.112	.1494	.1612
19	.3174	.2452	.3174	.3206	.2957	.2957	.2835
20	.3206	.3584	.3395	.3395	.3475	.3921	.298
21	.2452	.2801	.2801	.2614	.2957	.2774	.2454
22	.2054	.2402	.2241	.1848	.2427	.2353	.2058
23	.1646	.1848	.1886	.1867	.1848	.2263	.3077
24	.1307	.128	.168	.168	.1698	.1848	.1867
Max	.4207	.4344	.4251	.3395	.4344	.5068	.6219
Min	.0924	.1086	.0934	.0549	.1029	.1494	.0663
Avg	.1891	.2099	.2125	.1851	.2465	.2745	.2099

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217036 / 132/33/22 KV SANASWADI S/STN

Feeder No / Name : 300 / Auxiliary

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217036 / 132/33/22 KV SANASWADI S/STN

Feeder No / Name : 301 / Sunny Gold

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217036 / 132/33/22 KV SANASWADI S/STN

Feeder No / Name : 302 / TALEGAON SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)
13		3.7723
24	7.5446	
<b>Max</b>	<b>7.5446</b>	<b>3.7723</b>
<b>Min</b>	<b>7.5446</b>	<b>3.7723</b>
<b>Avg</b>	<b>7.5446</b>	<b>3.7723</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217036 / 132/33/22 KV SANASWADI S/STN

Feeder No / Name : 303 / BHANDARI SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 22 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217036 / 132/33/22 KV SANASWADI S/STN

Feeder No / Name : 304 / Kalyani NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217036 / 132/33/22 KV SANASWADI S/STN

Feeder No / Name : 305 / 22kv WESTERN NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217036 / 132/33/22 KV SANASWADI S/STN

Feeder No / Name : 306 / 22 KV IMP NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 22 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217036 / 132/33/22 KV SANASWADI S/STN

Feeder No / Name : 308 / PERNE GAOTHAN GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	7.5446
Max	7.5446
Min	7.5446
Avg	7.5446

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217036 / 132/33/22 KV SANASWADI S/STN

Feeder No / Name : 401 / 33 KV Pimpale Jagtap  
Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217052 / 132 kV Whirlpool

Feeder No / Name : 301 / Kondapuri Industrial  
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217052 / 132 kV Whirlpool

Feeder No / Name : 302 / Ranjangaon Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217052 / 132 kV Whirlpool

Feeder No / Name : 303 / 22 kv LG

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217052 / 132 kV Whirlpool

Feeder No / Name : 304 / 22 KV RANJANGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
21	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217052 / 132 kV Whirlpool

Feeder No / Name : 702 / 132 KV Whirlpool

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	22.6338
Max	22.6338
Min	22.6338
Avg	22.6338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217052 / 132 kV Whirlpool

Feeder No / Name : 703 / M/S. Neosym Industries  
Feeder KV- 132 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	22.6338
Max	22.6338
Min	22.6338
Avg	22.6338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217052 / 132 kV Whirlpool

Feeder No / Name : 704 / M/S. John Deere

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	22.6338
Max	22.6338
Min	22.6338
Avg	22.6338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 217052 / 132 kV Whirlpool

Feeder No / Name : 705 / M/S.Essar Steel

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	22.6338
Max	22.6338
Min	22.6338
Avg	22.6338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 300 / Auxillary II

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 301 / Appolo

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 302 / IBP Shikrapur

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 303 / Mahaganpati

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 304 / Wheel India  
Feeder KV- 22 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 305 / TREDEGAR EXPRESS

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 306 / Varude Ganegaon

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 307 / 22 kV Bombay Dyeing

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 308 / 22 kV Tata Eaton

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 309 / IKEL

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUN D DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 310 / G &amp; F Block

Feeder KV- 22 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 311 / switching sub stn-2  
Feeder KV- 22 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 312 / 22 kv wheels-2

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 313 / 22 kv itc

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 314 / varude gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
21	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 316 / 22 KV JOTUN

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 317 / SCA Hygine

Feeder KV- 22 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.7723
Max	3.7723
Min	3.7723
Avg	3.7723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 703 / 132 kV BEKART 1

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	22.6338
Max	22.6338
Min	22.6338
Avg	22.6338

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 704 / 132 kV BEKART 2

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	22.6338
Max	22.6338
Min	22.6338
Avg	22.6338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 705 / 132 KV Kalyani

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	22.6338
Max	22.6338
Min	22.6338
Avg	22.6338



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 801 / 220 kv Fiat 1

Feeder KV- 220 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	37.723
Max	37.723
Min	37.723
Avg	37.723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIKRAPUR S/DN.[699] BU 4699

Substation No/ Name :- 218031 / 220 KV RANJANGAON

Feeder No / Name : 802 / 220 kV FIAT 2

Feeder KV- 220 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	37.723
Max	37.723
Min	37.723
Avg	37.723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 203 / Junamala

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.3018	.2652	.2622	.2458	.2683	1.1603
2	.2486	.3353	.2652	.2622	.2543	.2683	1.1603
3	.2652	.3688	.2984	.2622	.2743	.285	1.1768
4	.2818	.4024	.3647	.2949	.2915	.3353	1.2431
5	.3149	.4359	.4144	.3277	.3429	.3353	1.2929
6	.3481	.503	.4641	.426	.4801	.4191	1.326
7	.2458	.5365	.3277	.3932	.4239	.4694	1.4918
8	.2652	.3353	.2622	.3277	.3277	.3353	1.7901
9	.7956	.8619	.9175	1.0174	1.0059	1.4586	.2622
10	.7956	.8122	.852	1.1022	1.2071	1.6575	.2294
11	.8288	.7459	.8192	1.153	1.3413	1.5746	.1966
12	.7956	.663	.8192	1.1869	1.4083	1.6575	
13	.7293	.7459	.7865	1.153	1.3413	1.5249	
14	.6962		.7537	1.0974	1.3413	1.4586	
15	.663	.663	.8192	1.1145	1.3748	1.4918	
16		.663	.8848	1.1869	1.4083	1.5912	
17	.3315	.1326	.1638	.1696	.1677	.1326	.2622
18	.2652	.1326	.1966		.2012	.2652	.2622
19	.2652	.2652	.2949		.2515	.2652	.2949
20	.2984	.2652	.2949	.2713	.3353	.2652	.3277
21	.3315	.2652	.2949	.3052	.3018	.2652	.2949
22		.2652	.2949	.2683	.2683	.2652	.2949
23		.2652	.2949	.2743		1.1271	1.4419
24	.2652	.2683	.2652	.2713	.2572	.2683	1.1271
Max	.8288	.8619	.9175	1.1869	1.4083	1.6575	1.7901
Min	.2458	.1326	.1638	.1696	.1677	.1326	.1966
Avg	.4427	.4449	.4756	.5967	.6457	.7494	.8229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 301 / Mandavgaon

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.2683	.2622	.2622	.1966	.2683	.5243
2	.2622	.2683	.2622	.2622	.2058	.2012	.5243
3	.2622	.2683	.2622	.2622	.2374	.2012	.5243
4	.2622	.2683	.2622	.2622	.2743	.2012	
5	.2622	.3353	.2622	.2622	.2743	.2012	.5898
6	.2622	.3353	.2622	.3277	.2743	.2683	.5898
7	.2622	.2683	.2622	.3277	.2743	.2683	.4915
8	.2622	.2683	.2622	.3277	.2743	.2683	.4915
9	.4024	.4915	.4915	.5087	.503	.4588	.2622
10	.503	.5571	.4915	.5087	.5365	.4915	.2622
11	.5365	.5898	.4915	.5087	.5365	.4588	.2622
12	.5365	.5243	.4915	.4748	.5365	.5243	.2622
13	.5365	.5243	.4915	.4748	.5365	.5571	.2622
14	.5365	.4915	.4915	.4748	.503	.5243	.2622
15	.5365	.4915	.4915	.4748	.4694	.5243	.2622
16	.5243	.5243	.4915	.4748	.503	.4915	.2622
17	.2622	.2622	.2622	.1017	.2683	.2622	.2622
18	.2622	.2622	.2622	.2743	.2683	.2622	.2622
19	.2683	.2622	.2622	.2743	.2683	.2652	.2622
20	.2622	.2622	.3277	.3429	.2683	.2622	.3277
21	.2622	.2622	.3277	.3353	.2683	.2622	.3277
22		.2622	.2622	.2743	.2683	.2622	.2622
23		.2622	.2622	.2058		.4915	1.3108
24	.2622	.2683	.2652	.2622	.2058	.2683	.5243
Max	.5365	.5898	.4915	.5087	.5365	.5571	1.3108
Min	.2622	.2622	.2622	.1017	.1966	.2012	.2622
Avg	.3541	.3574	.3442	.3444	.3457	.3435	.4075

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 302 / Babhulsar

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0983	.0983	.0983	.0995	.1029	.1006	.2294
2	.0983	.0983	.0983	.0995	.1029	.1341	.1966
3	.0983	.1006	.0983	.0995	.1029	.1341	.2294
4	.0983	.1006	.1311	.2652	.1029	.1341	.2622
5	.1311	.1006	.1311	.1326	.1029	.1006	.2949
6	.1311	.1006	.1326	.1326	.1029	.1341	.2949
7	.1311	.1006	.1326	.1326	.0671	.1006	.2294
8	.1311	.1006	.1326	.1326	.1029	.1006	.2622
9	.1372	.1966	.2321	.1357	.503	.1966	.0995
10	.3277	.2294	.2652	.1341	.5365	.2294	.0995
11	.3277	.2622	.2652	.1341	.5365	.2294	.0995
12	.426	.2294	.2652	.2058	.5365	.1966	.0995
13	.5243	.2294	.2652	.2058	.5365	.2294	.0995
14	.5243	.2622	.2652	.2058	.5365	.2622	.0995
15	.5243	.2294	.2652	.2058	.503	.2294	.0995
16	.5243	.2294	.2676	.2035	.503	.1966	.0995
17	.0983	.0983	.0995	.2058	.1006	.0983	.0995
18	.0983	.0983	.0995		.1006	.1311	.0995
19	.0983	.0983	.0995	.1029	.1006	.1311	.0995
20	.0983	.1311	.0995	.1017	.1006	.1311	.0995
21	.0983	.1311	.0995	.1029	.1006	.1311	.0995
22		.1311	.0995	.1029	.1006	.0983	.0995
23		.0983	.0995	.1029		.1966	.2652
24	.0983	.0983	.0983	.0995	.1029	.1006	.1966
Max	.5243	.2622	.2676	.2652	.5365	.2622	.2949
Min	.0983	.0983	.0983	.0995	.0671	.0983	.0995
Avg	.2192	.1480	.1600	.1454	.2472	.1553	.1606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 303 / Inamgaon

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.431	.4024	.5243	.4915	.6371	.6036	.2652
2	.3978	.4024	.5571	.4915	.6516	.6706	.2652
3	.4973	.4694	.4973	.4915	.6706	.7377	.2652
4	.4973		.5967	.4915	.6706	.8048	.3315
5	.4973	.5365	.6299	.4915	.7042	.8718	.3315
6		.5365	.4973	.6554		.9389	.3315
7		.5365	.4588	.8192	.8478	1.0059	.3315
8		.5365	.6554	.8192	1.0174	.9389	.3315
9		.2652	.2622	.2683	.2683	.2652	.6554
10		.2652	.2622	.2374	.2683	.2652	2.6216
11		.2652	.2622	.2347	.2683	.2652	2.6216
12			.2622	.2058	.2683	.2652	
13			.2622	.2035	.2683	.2652	2.9492
14	.2652		.2622	.2035	.2683	.2652	
15	.2652		.2622	.2058	.2683	.2652	2.6216
16	.2683		.2622	.2035	.2683	.2652	2.6216
17		.2652	.2622	.1715	.2683	.2622	.2622
18		.2652	.2622	.2713	.2683	.3315	.2622
19		.3315	.2622	.3391	.2683	.3315	.2622
20	.2652	.3315	.2622	.3391	.2683	.3315	.2622
21	.2652	.3315	.2622	.2743	.2683	.3315	.2622
22		.2652	.2622	.2713	.2683	.2652	.2622
23		.3315	.4915	.6783		.2652	.2622
24	.3978	.3353	.4973	.4915	.6859	.6036	.2652
Max	.4973	.5365	.6554	.8192	1.0174	1.0059	2.9492
Min	.2652	.2652	.2622	.1715	.2683	.2622	.2622
Avg	.3680	.3707	.3782	.3896	.4382	.4757	.8475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 304 / GFSS Mandavgan Farata

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.5365	.4435	.5121	.4801	.503	.5544
2	.4066	.6036	.4066	.5175	.4748	.5365	.5914
3	.4435	.6706	.4066	.5544	.5144	.6036	.5914
4		.6036	.4805	.5914	.5426	.6706	.6653
5		.6706	.6653	.6283	.6173	.7377	.7023
6		.6706	.7762	.7023	.7545	.7042	.8353
7	.7392	.7377	.6653	.7392	.6706	.7042	.7207
8	.7318	.6036	.5544	.7842	.6173	.6371	.6912
9	.6283	.6283	.4915	.6036	.5365	.6653	.6722
10	.5175	.5544	.4588	.4748	.4359	.6062	.5975
11	.4066	.5544	.4481	.4024	.3688	.5175	.5175
12	.4066	.4435	.4481	.4115	.3688	.4805	.5228
13	.3696	.4435	.4108	.4115	.3353	.462	.4805
14	.3696	.3696	.4108	.373	.4024	.4694	.4805
15	.2957	.3696	.5601	.373	.4024	.4768	.4435
16	.3326	.377	.4481	.3772	.4359	.4731	.4108
17	.4435	.4435	.4854	.4458	.4024	.5175	.5601
18	.5914	.5544	.5228	.5426	.4359	.6653	.6348
19	.5914	.6283	.5914	.5765	.503	.7762	.6722
20	.6283	.7023	.7023	.6104	.6706	.7577	.7468
21	.6283	.6653	.6722	.5765	.6036	.7244	.7095
22		.5914	.5914	.5426	.5365	.6801	.6283
23		.4066	.5601	.5087		.5175	.4854
24	.3696	.4024	.4066	.4854	.5144	.4694	.5544
Max	.7392	.7377	.7762	.7842	.7545	.7762	.8353
Min	.2957	.3696	.4066	.373	.3353	.462	.4108
Avg	.4898	.5513	.5253	.5310	.5054	.5982	.6029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214450 / 33 KV MANDANGAON FARATA

Feeder No / Name : 305 / Gfss Inamgaon - Babulsar

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9282	1.073	.8288	1.1088	1.0974	1.073	.9282
2	.8848	1.2071	.8192	1.1203	1.0288	1.0059	.8192
3	.8619	1.3413	.9831	1.1576	1.0852	1.2071	.9945
4	.9831	1.4083	1.0608	1.1949	1.1317	1.3413	1.0486
5	1.0486	1.5424	1.1603	1.1949	1.4243	1.4083	1.1469
6	1.1603	1.6095	1.2597	1.7924	1.7635	1.5089	1.2597
7	1.2452	1.6766	1.2567	1.8671	2.0008	1.8442	1.1469
8	1.326	1.3413	1.0974	1.5684	1.4243	1.5424	1.0608
9	1.1142	.9831	.9145	.6783	1.0059	1.1797	1.0456
10	.852	.5304	.8779	.6371	.8383	1.0608	1.0456
11	.6882	.6299	.8215	.6104	.7042	.9945	.9709
12	.6554	.5898	.8215	.5487	.6036	.852	
13		.6554	.8048	.5487	.5365	.7209	.9709
14	.5898	.8131	.8048	.5144	.503	.6299	
15	.4915	.5967	.8589	.5487	.4694	.4973	
16	.6226	.5571	.8962	.5144	.4359	.4588	1.0082
17		.5304	.9709	.6859	.7042	.4915	1.1203
18		.5898	1.0082	1.2346	.8718	.6226	1.2696
19		.663	1.1949	1.3032	1.0059	.7293	1.419
20	.8192	.8192	1.3443	1.3032	1.4083	.8288	1.3443
21	1.2125	.9282	1.2696	1.3032	1.3413	.9282	1.1949
22		.9831	1.1949	1.2346	1.2407	.9831	1.1203
23		.8192	1.1203	1.1317		.8848	1.0456
24	.8288	1.0059	.8192	1.0829	1.0974	1.073	.8192
Max	1.326	1.6766	1.3443	1.8671	2.0008	1.8442	1.419
Min	.4915	.5304	.8048	.5144	.4359	.4588	.8192
Avg	.9062	.9539	1.0079	1.0369	1.0314	.9944	1.0847



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA

Feeder No / Name : 202 / 11 KV Ambale Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4298	.4298	.3761			.5194
2		.4298	.4477	.4119			.4835
3		.4656	.4477	.4477			.4656
4		.4656	.4835	.6089			.4656
5		.5014	.5194	.6805			.4835
6		.5194	.7701	.788			.7522
7		.6805	.7522	.788			.7522
8	.6089	.6626	.6626	.6984			.6805
9	.8417	.7701	.7522	.6447	.9671		.7701
10			.4835	.6089	.7522		.6447
11		.8059	.5014			.7343	.5194
12		.3403	.4656			.3403	.4835
13		.4835	.2865	.591		.8238	.6805
14		.5373	.3224	.394		.591	.6447
15		.5552	.4119	.4477		.6805	.6089
16		.4656		.5731		.7343	.6984
17		.2686		.4835		.4477	.7701
18		.4477	.394			.5373	.7343
19		.5194	.4656	.4835		.5014	.7343
20		.5552	.5731			.6268	.6805
21		.5731	.5373			.6161	.6626
22		.5014	.4656			.7343	.6089
23		.4835	.394			.591	.6268
24	.4656	.4656	.4298	.3582	.4835		.5373
Max	.8417	.8059	.7701	.788	.9671	.8238	.7701
Min	.4656	.2686	.2865	.3582	.4835	.3403	.4656
Avg	.6387	.5186	.4998	.5520	.7343	.6122	.6253

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA

Feeder No / Name : 203 / 11 KV Kolape Wasti Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5373	.5014	.4656			.2686
2		.5373	.5014	.4835			.2507
3		.5731	.4835	.5373			.2507
4		.6089	.4835	.6805			.2686
5		.6805	.5014	.7522			.3045
6		.6805	.6984	.8238			.4477
7		.8596	.8775	1.1104			.394
8	.788	.8775	.8596	1.0745			.2865
9	.2507	.197	.2507	.2328	.2328		1.2894
10			.197	.2328	.197		1.4842
11		.1791	.1612			.197	1.6297
12		.197	.1612			.2149	1.576
13		.197	.1791	.197		.197	1.6297
14		.1612	.1791	.1867		.2149	1.5402
15		.1612	.1612			.197	1.773
16		.1612		.1612		.1791	1.6834
17		.197		.1791		.1791	.2328
18		.2328	.2328			.197	.2686
19		.2865	.2865	.2328		.3361	.3761
20		.3045	.3403			5.9747	.3403
21		.3045	.3045			.3403	.3403
22		.2507	.2507			.3045	.3045
23		.4835	.4656			.2507	.2507
24	.5373	.5731	.5014	.4298	.5552		.2686
Max	.788	.8775	.8775	1.1104	.5552	5.9747	1.773
Min	.2507	.1612	.1612	.1612	.197	.1791	.2328
Avg	.5253	.4018	.3899	.4863	.3283	.6756	.7275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUNG DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA

Feeder No / Name : 301 / Nhavara

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3734	.3734	.4108			.4108
2		.4108	.3361	.3734			.3734
3		.4854	.3734	.4854			.3734
4		.5601	.4108	.5975			.4108
5		.5975	.4481	.7468			.4481
6		.7842	.6348	.7842			.6348
7		.8962	.7842	.8215			.8215
8	.8589	.7095	.6722	.7095			.6348
9	.6722	.6348	.5601	.5975	.5975		.5601
10			.4854	.6348	.5975		.5601
11		.3734	.5228			.5228	.9708
12		.3734	.4481			.4481	.9708
13		.4108	.4108	.4481		.4854	.4854
14		.3361	.4108	.4481		.3734	.5228
15			.4108	.4854		.4108	.5975
16		.4108	.3734	.5228		.4108	.5228
17		.4108	.4481	.4481		.4108	.5975
18			.4481			.4108	.5975
19		.5975	1.2696			.5601	.7468
20		.5601	1.3444			.6722	.7468
21		.4854	.6348			.5975	.6722
22		.4481	.5601			.4854	.5975
23		.4108	.4481			.4108	.5228
24	.4108	.4108	.3734	.4481	.4481		.4108
Max	.8589	.8962	1.3444	.8215	.5975	.6722	.9708
Min	.4108	.3361	.3361	.3734	.4481	.3734	.3734
Avg	.6473	.5086	.5492	.5601	.5477	.4768	.5912

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA

Feeder No / Name : 302 / Nimbone

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0829		1.2696			.2987
2		1.0829		1.2696			.2987
3		1.1203		1.3443			.2987
4		1.1203		1.4937			.4108
5		1.1203		1.7924			.5228
6		1.3817		1.8298			.7095
7		.6348		.6722			2.6139
8	.6348	.5601		.6348			3.8836
9	.5601	.4854		.4854	.5601		4.5931
10			.4854	.4108	.4108		4.369
11			.3361			.3361	8.2152
12			.3734			.3734	9.7088
13			.3361	.3734		.3734	5.0412
14			.2987	.3361		.3734	4.7051
15			.2987	.3361		.3361	.3734
16			.3361	.3734		.2987	.4108
17			.3361	.3734		.3361	.3734
18			.4481			.3361	.5228
19			.6348	.4108		.5228	.7095
20			.6348			.5975	.6348
21			.4481			.5601	.5228
22			.4481			.3734	.5228
23			1.1949			.4108	.4481
24	1.419	1.1203		1.1949	1.531		.3361
Max	1.419	1.3817	1.1949	1.8298	1.531	.5975	9.7088
Min	.5601	.4854	.2987	.3361	.4108	.2987	.2987
Avg	.8713	.9709	.4721	.8589	.8340	.4021	2.1052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUNG DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA

Feeder No / Name : 303 / 22 KV Alegaon AG feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 22 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3361	.4481	.4108			1.9418
2		.3361	.4481	.4481			1.9044
3		.4108	.4481	.5228			1.8671
4		.5228	.4854	.6722			1.9044
5		.6348	.5975	.7468			1.9418
6		.6348	.7842	.7842			2.3152
7		.6348	.8589	.7468			.7468
8	.4854	.5601	.5228	.5975			.5975
9	.4108	.4108	.4108	.5975	.4854		.4108
10			.4108	.4108	.4481		.4108
11		.2987	.3361			.3361	.7468
12		.2987	.2987			.2987	.6722
13		.2614	.2614	.3734		.4108	.3361
14		.2614	.2614	.3734		.3734	.2987
15		.9335	1.1203	1.5684		2.2779	.2987
16		1.0082	1.4563	1.9418		2.4646	.4108
17		1.1949	1.5684	1.9791		3.062	.4108
18		1.0456				3.0994	.5228
19		1.1203	2.9874			2.9127	.6348
20		1.1203	2.9874			2.8006	.7468
21		.9335	1.419			2.3525	.6348
22		.8962	1.2696			2.2032	.5975
23		.4481	.4108			1.9418	1.8671
24	.3361	.3734	.4108	.3734	.4108		1.9418
Max	.4854	1.1949	2.9874	1.9791	.4854	3.0994	2.3152
Min	.3361	.2614	.2614	.3734	.4108	.2987	.2987
Avg	.4108	.6381	.8784	.7842	.4481	1.8872	1.0067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214451 / 33/22/11 KV NHAVARA

Feeder No / Name : 305 / 22 Kv Mallikarjun GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7468	1.0082	.5601			.9709
2		.6722	1.0082	.5975			1.0082
3		.7842	1.0456	.6722			1.0082
4		1.0082	1.0456	.7468			1.0456
5		1.419	1.0829	.8962			1.0829
6		1.643	1.307	.9709			1.4563
7		1.6804	1.6804	1.0456			1.643
8		1.7551	1.4937				1.7924
9	.2987	1.419	1.5684	.8962	.8962		1.643
10			1.4563	.6348			1.531
11		.6348	.5228			1.307	.5601
12		.7095	.4854			1.1576	.5228
13		.8215	.3361	.4108		1.0082	.5601
14		.8215	.3361	.3361		.8962	.5228
15		1.1949	.3361	.2614		.8962	.5228
16		1.1576	.3361	.4108		.8962	.5601
17		1.1949	.3734	.5601		.8589	.6348
18		1.307	.4854			.8962	.6348
19		1.419	.7095			1.3443	.8962
20		1.4563	.7468			1.6804	1.0082
21		1.3443	.7842			1.4937	.8962
22		1.2696	.6722			1.3443	.7468
23		1.0456	.5601			1.0829	.6348
24	.6722	.8215	.9709	.5228	.8589		1.0082
Max	.6722	1.7551	1.6804	1.0456	.8962	1.6804	1.7924
Min	.2987	.6348	.3361	.2614	.8589	.8589	.5228
Avg	.4855	1.1446	.8480	.6348	.8776	1.1432	.9538

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 301 / TAKALI HAJI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5228	.6722	.5975		.7095	.5601
2		.5975	.7468	.6722		.8962	.5601
3		.6722	.7842	.7468		1.0082	.6722
4		.7842	1.0456	.8215		1.1576	.7468
5		.7842	1.307	1.0456		1.419	.8215
6		.9709	1.3817	1.1949		1.5684	.8962
7		.8215	.7095	.9709		.9335	1.0456
8		.7095	.7468	.7468		.7095	1.6057
9		.5975	.6348	.6348		.6722	1.7551
10	.5228	.5601	.4481	.4481	.5228	.5601	1.7924
11	.4481	.3361	.4108	.3734	.4481	.4854	1.6804
12	.3734	.2614	.2987		.3734	.3361	1.8671
13	.3361	.2614	.2614			.3734	1.8671
14	.3361	.2614	.4108		.2614	.3734	1.9791
15	.2987	.3734	.3734		.2987	.4108	.4854
16	.2987	.2241	.3734		.3734	.4481	.4854
17	.2614	.2241	.3734		.4108	.4854	.4108
18	.4108	.4108	.4481		.4481	.4854	.4481
19	.4481	.5601	.6348		.6722	.6722	.7095
20	.6348	.7095	.7095		.7468	.7095	.6348
21	.5975	.5975	.8215		.6348	.5975	.5975
22	.4344	.4854	.5228		.5228	.5228	.5601
23	.5601	.5975	.5228		.5975	.5228	.5228
24		.5228	.5975	.6348		.6348	.5601
Max	.6348	.9709	1.3817	1.1949	.7468	1.5684	1.9791
Min	.2614	.2241	.2614	.3734	.2614	.3361	.4108
Avg	.4258	.5352	.6348	.7406	.4854	.6955	.9693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUNG DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 302 / Kavathe

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3361	.4108	.2614		.2987	
2		.4481	.4481	.2987		.3361	.8962
3		.4854	.5228	.2987		.3734	.9335
4			.5975	.3734		.4481	.9335
5			.5975	.6348		.5975	.8215
6			.8215	.7095		.7095	.8962
7			.9335	.7842		.8215	.7468
8			.8962	.5601			.8215
9			.6722	.3734			.7095
10	.5228		.4854	.4481	.4854	.5228	.5228
11	.3734	.3734	.4108	.3361	.4854	.5228	.5975
12	.3734	.4108	.3361			.3734	.5975
13	.3361	.3734				.4108	.6348
14	.2987	.3734	.4108		.3734	.4481	.6348
15	.4854	.3734	.5601		1.307	1.531	.5601
16	.5228	.6722	.7468		1.531	2.1285	.6348
17	.6348	.5228	.9335		1.7177	2.1658	.5601
18	.6722	.7468	.8589			.8962	.5975
19	.7095	.8589	1.0082		1.2696	1.6804	.7095
20	.7602	.9709	1.0456			1.4937	.6722
21	.5975	.7095	.9709		1.1949	1.2323	.5975
22	.5601	.6348	.7468		1.0456	.8215	.4854
23	.4481	.3734	.4108		.3734	.8215	.7468
24		.3734	.3734	.2614		.2987	.8589
Max	.7602	.9709	1.0456	.7842	1.7177	2.1658	.9335
Min	.2987	.3361	.3361	.2614	.3734	.2987	.4854
Avg	.5211	.5316	.6608	.4450	.9783	.8606	.7030



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 303 / Shastabad

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6722	.7095	.5975		.6348	.7468
2		.7842	.6722	.5601		.6348	.8215
3		1.1576	.7468	.5975		.7095	
4		1.3443	.8215	.6722		1.0082	.9709
5		1.419	1.0456	.8962		.9709	.9709
6		1.531	1.1203	1.0456		1.0456	1.1949
7		1.4937	1.2696	1.2696		2.1658	1.419
8		1.3443	1.3443	1.3443		2.0911	1.2696
9		1.0082	1.1203	1.2696		2.1285	.9709
10	.8589	.7468	.9335	1.1949	1.531	1.9044	.7468
11	.7842	.6722	.8215	1.0082	1.419	1.6057	.5228
12	.7095	.5601	.7468		1.4937	1.4937	.4854
13	.6722		1.0456		1.4937	1.2696	.4481
14	.7095	.3734	.6722		1.531	1.419	.4854
15	.5601	.2987	.3734		.4854	.4481	1.4937
16	.5601	.4481	.4481		.5228	.4481	1.8671
17	.5228	.4481	.5228		.5601	.5975	1.9044
18	.5601	.5601	.5228		.5601	.5228	1.9044
19	.7095	.6348	.8962		1.2696	1.0082	1.8671
20	1.1203	1.0829	1.0829		1.1576	1.0829	1.7551
21	.8962	.9709	.8589		1.0082	.8589	1.6057
22	.7095	.8589	.7095		.8589	.7842	1.4937
23	.5975	.7095	.7095		.6722	.7842	.7095
24		.5975	.7095	.6348		.5975	.7468
Max	1.1203	1.531	1.3443	1.3443	1.531	2.1658	1.9044
Min	.5228	.2987	.3734	.5601	.4854	.4481	.4481
Avg	.7122	.8572	.8293	.9242	1.0402	1.0923	1.1478

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 304 / 22 KV Kawathe Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5228	.5601	.4854		.5975	.7468
2		.6722	.6722	.5228		.5975	.7468
3		.7842	.6722	.5975		.6722	.8589
4		.8589	.7468	.7468		.7095	.8589
5		1.0829	.8215	.8962		.8962	.8589
6		1.1576	1.1203	1.0456		1.1949	1.0082
7		1.1949	1.1576	.5228		1.1576	1.1203
8		1.0829	1.0456	.6348		1.1203	1.0082
9		.9709	1.0082	.6348		1.0456	.9709
10	.7095	.8589	.7842	.7842	.7095	.8215	.7842
11	.5228	.5601	.6722	.7095	.5601	.7468	.6348
12	.3258	.3734	.5975		.4854	.4108	.5601
13	.2614	.2987			.3734	.4108	.4854
14	.2241	.2987	.4108		.3361	.2987	.3734
15	.1867	.3361	.3734		.4854	.3734	.4481
16	.2241	.3734	.3734		.5228	.4108	.5228
17	.3361	.3734	.3734		.4481	.4854	.4481
18	.4108	.4481	.3734		.4481	.5601	.5601
19	.7095	.6348	.7095		.8589	.7842	.8215
20	.9709	.9709			.9709	.9709	.8962
21	.6722	.8215	1.0456		.8589	.7842	.7468
22	.5228	.6348	.6722		.6348	.7095	.5975
23	.4854	.5601	.5601		.5601	.7095	.5975
24		.4481	.5228	.5601		.5601	.6722
Max	.9709	1.1949	1.1576	1.0456	.9709	1.1949	1.1203
Min	.1867	.2987	.3734	.4854	.3361	.2987	.3734
Avg	.4687	.6799	.6942	.6784	.5895	.7095	.7219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 305 / 22 kv industrial feeder

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	30-AUG-17	31-AUG-17	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.0373		.0373	.0724	
8	.0747	.0373	.112	.112	
9	.112	.0747	.1494	.112	.1494
10	.1867	.1867	.1867	.1494	.1867
11		.1867	.1494	.1494	.0747
12	.0373	.1867		.1494	.0747
13		.1867		.1494	.0747
14		.112			
15	.0373	.0747		.0747	
16	.1867	.112			
17	.0373	.112			.112
18	.0373	.112		.0747	
Max	.1867	.1867	.1867	.1494	.1867
Min	.0373	.0373	.0373	.0724	.0747
Avg	.0830	.1256	.1270	.1159	.1120

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 306 / 22 kv Amdabad

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867	.1867	.2241		.1867	.1867
2		.1867	.2241	.2241		.2241	.1867
3		.2241	.2241	.1867		.2241	.2241
4		.2241	.2614	.2241		.2534	.2241
5		.2614	.2614	.2987		.2614	.1867
6		.2987	.2987	.2987		.2987	.2241
7		.3361	.2987	.3361		.4481	.2987
8		.5228	.3361	.3734		.4481	.2614
9			.3361	.3734		.4854	.2614
10	.2987	.2987	.3361	.2987	.4108	.5601	.1867
11	.2241	.2241	.3361	.3361	.4481	.5601	.1867
12		.2241	.2987			.4854	.1494
13		.1867	.2987			.4854	.1494
14		.1494	.2614		.4481	.5601	.1494
15	.112	.112	.112			.1867	.7095
16	.112	.112	.112			.1867	.7468
17	.1494	.112	.112		.1494	.1867	.7468
18	.1494	.112	.1867		.2241	.1867	.7468
19	.1086	.1867	.2241		.2614	.1867	.6722
20	.2614	.2241	.2614		.2614	.2614	.5975
21	.2241	.1867	.2614		.2614	.2241	.5228
22	.1867	.2241	.2241		.2241	.1867	.5228
23	.1867	.1867	.2241			.1867	.1867
24		.1867	.1867	.2241		.1867	.1867
Max	.2987	.5228	.3361	.3734	.4481	.5601	.7468
Min	.1086	.112	.112	.1867	.1494	.1867	.1494
Avg	.1830	.2159	.2443	.2832	.2988	.3108	.3548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214452 / 33KV/22KV MALTHAN

Feeder No / Name : 307 / 22 kv Malthan Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	30-AUG-17	31-AUG-17	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867	.1494		.1867
2		.1867	.1867		.2241
3		.2241	.1867		.2241
4		.2241	.2241		.2241
5		.2987	.2614		.2614
6		.2987	.3361		.2614
7		.3734	.3734		.3361
8		.3361	.3361		.3361
9		.2241	.2241		.2614
10	.1867	.1867	.1867	.2241	.2241
11	.1867	.1867	.1494	.1867	.1867
12	.1494	.1494		.112	.1494
13	.1494	.1494		.112	.1494
14	.112	.112		.0747	.112
15	.112	.112		.112	
16	.112	.112		.112	.1867
17	.112	.112		.112	.1867
18	.1494	.1867		.1494	.2241
19	.2241	.2614		.2241	.2987
20	.2987	.2987		.2614	.2987
21	.2614	.2987		.2241	.2614
22	.2241	.2241		.1867	.2241
23	.1494	.1494		.1867	.1867
24		.1494	3.7723		.1867
Max	.2987	.3734	3.7723	.2614	.3361
Min	.112	.112	.1494	.0747	.112
Avg	.1734	.2101	.5322	.1627	.2257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214461 / 33 KV TAKALI HAJI

Feeder No / Name : 202 / 11 kv Shingawadi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2477	.2641	.2614	.3048	.3206	.2427
2	.2452	.2477	.2641	.2641	.2858	.3395	.2427
3	.2641	.2667	.3018	.2667	.3048	.3395	.2641
4	.2641	.2667	.3018	.2858	.2858	.3584	.2829
5	.2829	.2858	.3395	.2858	.3048	.3772	.3048
6	.2829	.3048	.3395	.3239	.4763	.5658	.3429
7	.3961	.4001	.4527	.6287	.6287	.7545	.415
8	.4527	.4001	.4527	.6036	.6668	.8488	
9	.3239	.2641	.2667	.2858	.3395	.362	
10	.2378	.2452	.1905	.2477	.3206	.3048	
11	.2126	.1886	.1905	.2477	.3206	.2858	.6478
12	.1715	.1886	.1905	.2667	.3395	.3048	.7621
13	.1543	.2075		.381	.3395	.3429	.9526
14	.1715	.2075		.3429	.3395	.3048	.9907
15	.1715	.1886		.3048	.3395	.3429	.9717
16	.1715	.1509		.3239	.3584	.3429	.9717
17	.1905	.1886	.2286	.381	.3961	.4001	.3429
18	.2286	.1886	.2477	.4382	.2829	.3429	.3048
19	.3239	.2829	.2667	.362	.3395	.4001	.4191
20	.2667	.3018	.2667	.3239	.3206	.3048	.3429
21	.2286	.2263	.2667	.3048	.3018	.3239	.2858
22	.2286	.2263	.2667	.2858	.3018	.2858	.3048
23	.2241	.2641	.2667	.3048	.3395	.2218	.2667
24	.2452	.2614	.2641	.2587	.2858	.3206	.2378
Max	.4527	.4001	.4527	.6287	.6668	.8488	.9907
Min	.1543	.1509	.1905	.2477	.2829	.2218	.2378
Avg	.2493	.2500	.2814	.3325	.3551	.3790	.4713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214461 / 33 KV TAKALI HAJI

Feeder No / Name : 204 / 11 kv Temkarwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2667	.2641	.2987	.362	.3772	.3174
2	.3395	.2858	.2641	.3018	.3239	.3772	.3547
3	.3584	.3048	.3018	.2858	.3429	.3429	.415
4	.3584	.3048	.3018	.3048	.362	.5658	.4527
5	.3772	.3239	.3395	.3239	.362	.5658	.5144
6	.3772	.362	.3772	.4191	.5716	.7545	.6097
7	.5658	.6287	.679	.8383	.8002	.8488	.7922
8	.679	.7811	.7545	.9526	1.0479	1.0562	.7655
9	.5335	.5281	.5906	.6287	.6413	.724	.9717
10	.4755	.5093	.4572	.4954	.5658	.6668	1.1241
11	.3012	.4715	.381	.4001	.5658	.6668	1.1431
12	.2915	.415	.3239	.4001	.6036	.5716	1.2003
13	.2572	.3018	.3429	.4001	.5658		1.2384
14	.2572		.3239	.4001	.6036	.5716	1.3336
15	.2572	.3018	.2858	.4001	.6036	.5906	1.3717
16	.2743	.3018	.3239	.4001	.6224	.5906	1.3908
17	.3048	.3018	.3429	.4954	.6413	.5335	.5906
18	.362	.3584	.4191	.5335	.6224	.5525	.6097
19	.4763	.5093	.4572	.6287	.679	.6287	.6668
20	.4763	.4904	.5335	.5716	.6413	.5716	.5525
21	.4382	.4338	.4001	.4954	.5281	.4763	.4954
22	.3429	.3772	.381	.4001	.4338	.4001	.4763
23	.2614	.2641	.3361	.3239	.415	.3696	.4572
24	.3395	.2614	.2641	.3142	.3429	.3772	.3292
Max	.679	.7811	.7545	.9526	1.0479	1.0562	1.3908
Min	.2572	.2614	.2641	.2858	.3239	.3429	.3174
Avg	.3768	.3949	.3936	.4589	.5520	.5730	.7572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214461 / 33 KV TAKALI HAJI

Feeder No / Name : 205 / Sablewadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4382	.415	.4668	.5335	.4527	.4481
2	.5093	.4572	.415	.4715	.5525	.4527	.4481
3	.547	.4763	.4527	.5144	.5716	.4904	.4715
4	.5316	.5144	.5281	.5716	.5525	.4904	.4715
5	.6036	.5525	.6036	.6287	.5716	.5281	.5144
6	.6224	.5906	.6602	.6478	.6478	.5847	.6097
7	.6036	.5144	.6224	.5906	.7049	.6224	.9054
8	.5281	.4954	.4801	.547	.5716	.5093	.8962
9	.5716	.4715	.5906	.5144	.8488	.724	.4382
10	.567	.5093	.5144	.6097	.9431	.8002	.4191
11	.5138	.4338	.5335	.6668	.9431	.7621	.4382
12	.5144	.4527	.5716	.724	.9431	.8192	.4572
13	.463	.4338	.6097	.7049	.9808	.9717	.4954
14	.4801	.4338	.5906	.6859	.8865	.8002	.4954
15	.4458	.4715	.4763	.6859	.8488	.9145	.5335
16	.4973	.4527	.5716	.6097	.8488	.8764	.5525
17	.2667	.2641	.3429	.5144	.3206	.4191	.5335
18	.381	.3395	.362	.381	.3772	.4191	
19	.5335	.4527	.4763	.5144	.4904	.4954	.5525
20	.4954	.4904	.5335	.4763	.4338	.4954	.4954
21	.4191	.4527	.5144	.4572	.4527	.4382	.4572
22	.4572	.4338	.4572	.4572	.4527	.4763	.4191
23	.4294	.415	.4294	.4954	.4527	.4435	.4382
24	.4904	.4294	.415	.462	.5144	.4527	.439
Max	.6224	.5906	.6602	.724	.9808	.9717	.9054
Min	.2667	.2641	.3429	.381	.3206	.4191	.4191
Avg	.4984	.4573	.5069	.5582	.6435	.6016	.5187



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214461 / 33 KV TAKALI HAJI

Feeder No / Name : 206 / Takali Haji

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5716	.6413	.6722	.743	.6001	.9335
2	.6413	.6287	.679	.7167	.7621	.6602	.9709
3	.6413	.6859	.7922	.743	.743	.679	.9808
4	.679	.7621	.8299	.7621	.7621	.7545	1.0374
5	.7922	.8573	.9431	.7811	.7621	.8299	1.086
6	.8865	.9907	1.0185	1.0479	.9526	.9431	1.1812
7	1.1128	1.086	1.1506	1.3146	1.1622	1.1128	1.6409
8	1.1128	1.0669	1.0751	1.105	1.2003	1.0374	1.7364
9	.9526	.8488	.9335	1.0669	1.5466	1.4289	.8573
10	.8413	.811	.9526	1.3527	1.6598	1.6004	.8192
11	.7265	.6036	1.0098	1.3336	1.7918	1.6575	.5716
12	.703	.6036	.9335	1.3146	1.7918	1.7909	.5525
13	.7202	.6602	1.0098	1.2384	1.7918	1.829	.5525
14	.6173	.6224	1.0288	1.2193	1.5278	1.2955	.6859
15	.6001	.6602	.8002	1.2003	1.5089	1.5623	.724
16	.5658	.6602	.8192	1.2003	1.6409	1.5432	.7621
17	.381	.3206	.5335	.5144	.6224	.5716	.7811
18	.5716	.547	.5335	.5525	.6224	.6478	
19	.7811	.7922	.8954	.8764	1.0185	.8002	.9145
20	.7621	.8488	.8764	.7621	.9054	.7811	.9335
21	.6668	.7356	.7049	.7049	.7545	.8002	.8192
22	.6287	.6413	.7049	.6668	.6979	.7811	.7811
23	.5975	.6413	.6348	.7049	.6602	.8686	.8764
24	.6036	.5601	.6413	.6653	.724	.6602	.8596
Max	1.1128	1.086	1.1506	1.3527	1.7918	1.829	1.7364
Min	.381	.3206	.5335	.5144	.6224	.5716	.5525
Avg	.7162	.7169	.8392	.9382	1.0980	1.0515	.9155

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214461 / 33 KV TAKALI HAJI

Feeder No / Name : 207 / 11 Kv Dongargan

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2477	.2641	.2241	.3239	.2829	.2241
2	.2641	.2667	.2641	.2452	.3429	.2829	.2241
3	.2641	.3048	.3018	.2477	.3429	.3018	.2641
4	.3018	.3239	.3018	.2858	.362	.3018	.3018
5	.3395	.362	.3395	.3239	.362	.3206	.3429
6	.3395	.381	.3395	.381	.4763	.415	.4001
7	.415	.4954	.5093	.5716	.5906	.679	.5093
8	.4527	.5335	.547	.6036	.6668	.6413	.4294
9	.3239	.2829	.362	.381	.3584	.381	.6478
10	.2561	.2641	.2858	.2858	.3395	.3239	.743
11	.2126	.2641	.2667	.1905	.2829	.3048	.5716
12	.1543	.2641	.1905	.1905		.2667	.5525
13	.1715		.1905	.2286		.2477	.5525
14	.1372		.1524	.2286		.2667	.8002
15	.1372	.1886	.1715	.2286		.2477	.8764
16	.1372	.1698	.1715	.2667		.2667	.9335
17	.1715	.1886	.1715	.2477	.2641	.2477	.2667
18	.2667	.1886	.2477	.1905	.2452	.3048	.2477
19	.381	.3018	.3429	.2858	.3772	.4001	.381
20	.381	.3584	.3429	.2667	.3395	.381	.362
21	.2858	.2641	.2667	.2477	.2829	.2858	.2858
22	.2286	.2641	.2477	.2286	.2641	.2667	.2667
23	.2286	.2641	.2477	.2667	.3018	.2402	.2286
24	.2452	.2427	.2641	.2218	.3048	.2829	.2427
Max	.4527	.5335	.547	.6036	.6668	.679	.9335
Min	.1372	.1698	.1524	.1905	.2452	.2402	.2241
Avg	.2642	.2919	.2829	.2849	.3594	.3308	.4439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214470 / 33/11KV JAMBUS

Feeder No / Name : 201 / 11 kv jambut

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.197	.1791	.3361	.1646	.2195	.2378	.2686
2	.1791	.1791	.2801	.1646	.2195	.2378	.2686
3	.1991	.1791	.2801	.1848	.2561	.2378	.2896
4	.2012	.1791	.2801	.1867	.3258	.2378	.3258
5	.2012	.1791	.2561	.1905	.3258	.2328	.362
6	.2286	.2328	.2149	.2286	.362	.2507	.499
7	.3239	.2715	.2686	.3395	.4024	.4908	.5914
8	.3292	.2658	.3258	.2534	.3841	.631	.4887
9	.4024	.3155	.2984	.3292	.4458	.4458	.3403
10	.3294	.2534	.2486	.3801	.3391	.333	.3155
11	.3045	.2534	.2622	.2481	.285	.2947	.2515
12	.2507	.3077	.2267		.3018	.2743	.2683
13	.2279	.3121	.2214	.2012	.3018	.1989	.3768
14	.2454	.2321	.2056	.2012	.2439	.218	.3647
15	.2328	.2401	.2429	.2035	.2439	.1989	.3647
16	.208	.2058	.2622	.2103	.2561	.2321	.3978
17	.2641	.2667	.3292	.3429	.2374	.3048	.2641
18	.4572	.3048	.2587	.2715	.2378	.4001	.2829
19	.4382	.4715	.3841	.2801	.3012	.4382	.4527
20		.415	.3881	.2858	.3961	.4382	.415
21	.381	.3734	.4066	.3048	.3961	.4191	.3772
22	.2858	.3361	.3361	.3048	.3961	.3429	.3258
23	.2054	.3429	.1646	.1829	.2378	.2896	.3658
24	.197	.1829	.3734	.1646	.2012	.2378	.2686
Max	.4572	.4715	.4066	.3801	.4458	.631	.5914
Min	.1791	.1791	.1646	.1646	.2012	.1989	.2515
Avg	.2734	.2700	.2854	.2445	.3048	.3176	.3552

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214470 / 33/11KV JAMBUT

Feeder No / Name : 202 / 11 kv fakte

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.3761	.4108	.4207	.4572	.4024	.5014
2	.3582	.3761	.4481	.4207	.5121		.5014
3	.3801	.3761	.4854	.4435	.5487	.4024	.5068
4	.4207	.3761	.5121	.4854	.5853	.5304	.5068
5	.5304	.4656	.5487	.5906	.6154	.5194	.543
6	.6859	.5373	.6268	.7049	.6516	.6805	.6468
7	.7811	.5194	.6447	.7356	.6767	.631	.9425
8	.6036	.5138	.5792	.5249	.4572	.6135	1.1222
9	.4207	.2454	.3315	.439	.6173	.823	.5373
10	.2947	.3439	.3812	.4163	.7122	.964	.4908
11	.2507	.2896	.3113	.4525	.7042	.9362	.4359
12	.2507	.181	.2915	.4409	.7712	.8573	.4191
13	.2454	.2427	.2846	.4527	.7712	.8619	.3277
14	.2454	.2321	.2688	.4191	.7316	.8383	.3315
15	.2328	.2058	.2915	.4409	.7621	.7459	.431
16	.2254	.2401	.2949	.3856	.8002	.779	.431
17	.2452	.2667	.2561	.3048		.362	.4527
18	.362	.3048	.3142	.3258	.2675	.3239	.4527
19	.5335	.4904	.4572	.5228	.4252	.5335	.5847
20	.5144	.4715	.5914	.4763	.4527	.5716	.5658
21	.4954	.4294	.5175	.4572	.4527	.4954	.5847
22	.4001	.4294	.4481	.4763	.4527	.4382	.4525
23	.4001	.381	.4024	.3841	.4024	.4706	.5853
24	.3761	.3841	.3734	.4024	.4024	.4024	.5014
Max	.7811	.5373	.6447	.7356	.8002	.964	1.1222
Min	.2254	.181	.2561	.3048	.2675	.3239	.3277
Avg	.4005	.3616	.4196	.4635	.5752	.6166	.5356

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214470 / 33/11KV JAMBUT

Feeder No / Name : 203 / 11 kv wadner

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.394	.394	.3734	.3109	.4572	.4572	.3224
2	.394	.394	.3734	.3292	.5487	.4572	.3224
3	.3982	.394	.4668	.3361	.7316	.4572	.362
4	.4024	.394	.5487	.3734	.8145	.5304	.3982
5	.439	.4119	.5853	.4001	.8688	.5194	.4706
6	.6478	.5373	.6268	.6287	.905	.6805	.6099
7	.7811	.6805	.6984	.8299	.9593	.8764	.7762
8	.7682	.7442	.724	.8326	1.0242	1.0867	.6154
9	.4938	.4908	.4641	.439	.4801	.3772	.8596
10	.3814	.3982	.3647	.3258	.407	.4207	1.0867
11	.2686	.3258	.2949	.2715	.3521	.3121	1.0395
12	.2507	.2534	.2267	.2035	.3018	.2572	1.0395
13	.2629	.2427	.2056	.1677	.3018	.2321	.9831
14	.2454	.1658	.1898	.1677	.2591	.2347	.9614
15	.2149	.1715	.1619	.1865	.2591	.1989	.779
16	.2254	.2572	.1802	.2279	.2721	.2321	.7956
17	.2641	.2096	.2561	.2477	.373	.2858	.3018
18	.3429	.2667	.3142	.3258	.3269	.3429	.3772
19	.5335	.4904	.439	.4854	.4784	.5335	.5281
20	.4763	.4527	.5359	.4382	.5093	.4954	.5281
21	.4954	.4481	.462	.381	.5093	.4191	.5281
22	.4191	.4668	.4108	.4382	.4715	.4001	.4163
23	.4191	.3239	.3292	.3841	.4572	.362	.3658
24	.394	.4024	.3734	.3109	.3658	.4572	.3582
Max	.7811	.7442	.724	.8326	1.0242	1.0867	1.0867
Min	.2149	.1658	.1619	.1677	.2591	.1989	.3018
Avg	.4130	.3882	.4002	.3767	.5181	.4428	.6177

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214470 / 33/11KV JAMBUT

Feeder No / Name : 204 / 11 KV Gajare Mala  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2785	.2622	.3605	.2105	.3239	.3441	.1966
2	.2949	.2622	.3605	.2105	.3563	.3441	.1966
3	.2949	.2622	.3932	.2429	.4049	.3441	.1966
4	.2949	.2622	.3932	.2591	.4858	.4096	.2267
5	.3401	.2949	.426	.3077	.6401	.4588	.2591
6	.421	.3887	.4858	.3932	.7202	.5898	.3887
7	.583	.421	.5668	.6226	.7907	.7125	.502
8	.5344	.4372	.6062	.6882	.7432	.8097	.4372
9	.3239	.3239	.3563	.3932	.3953	.3725	.192
10	.2785	.2267	.2753	.2267	.3201	.2753	.6081
11	.1844	.1619	.2105	.1943	.2105	.1943	.6882
12	.2012	.1619	.1296	.16	.176	.1619	.7362
13	.1526	.1457	.1134	.1423	.176	.1423	.8162
14	.1357	.1619	.1296	.1581	.1638	.1423	.7842
15	.1187	.1296	.1134	.1265	.1457	.1423	.8802
16	.1509	.1457	.1296	.144	.1457	.1581	.8962
17	.1715	.1619	.1943	.176	.2321	.1966	.2721
18	.2229	.1781	.2753	.2031	.2543	.2622	.2214
19	.3641	.2429	.3077	.3841	.3721	.3239	.3953
20	.3391	.1943	.3113	.3201	.3601	.3605	.3521
21	.285	.1619	.2949	.2267	.2743	.2949	.3041
22	.2486	.1619	.2267	.1943	.2401	.1966	.2401
23	.2743	.2458	.2267	.2915	.3521	.1802	.192
24	.2785	.2652	.3277	.2105	.2915	.3521	.1802
Max	.583	.4372	.6062	.6882	.7907	.8097	.8962
Min	.1187	.1296	.1134	.1265	.1457	.1423	.1802
Avg	.2822	.2358	.3006	.2703	.3573	.3237	.4234

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214470 / 33/11KV JAMBUT

Feeder No / Name : 206 / 11 Kv GurunathNagar  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2458	.2622	.2458	.2591	.1619	.2458	.2294
2	.2458	.2622	.2458	.2753	.1781	.2458	.2294
3	.2622	.2622	.2458	.2753	.1781	.2458	.2458
4	.2622	.2949	.2622	.3077	.1943	.2949	.2591
5	.3077	.3441	.2622	.3401	.176	.3277	.2915
6	.3887	.421	.2591	.426	.16	.4588	.3239
7	.4858	.421	.2591	.4915	.1423	.4534	.4534
8	.421	.421	.2267	.4752	.1265	.4534	.5182
9	.2591	.2915	.1619	.3113	.3637	.4696	.394
10	.1966	.1781	.1781	.2591	.3841	.4372	.192
11	.1509	.1619	.1781	.2915	.3887	.3725	.16
12	.1677	.1296	.1781	.3041	.3201	.3401	.096
13	.1526	.1296	.2267	.3005	.3201	.3795	.096
14	.1357		.1943		.3113	.3795	
15	.1357	.1134	.1781	.2688	.2753	.3005	
16	.1341	.1296	.1943	.2721	.2753	.3163	
17	.1715	.1296	.1296	.16	.2155	.1802	.1898
18	.2229	.1296	.1457	.1562	.2543	.1802	.2372
19	.3814	.1943	.3563	.192	.3898	.3563	.2846
20	.3391	.1619	.426	.16	.3772	.3605	.2401
21	.285	.1619	.3277	.1619	.3429	.3113	.192
22	.2486	.1457	.2753	.1475	.2915	.2785	.208
23	.2743	.1638	.2591	.1296	.2515	.2458	.2401
24	.2622	.2652	.2458	.2591	.1619	.2515	.2458
Max	.4858	.421	.426	.4915	.3898	.4696	.5182
Min	.1341	.1134	.1296	.1296	.1265	.1802	.096
Avg	.2557	.2250	.2359	.2706	.2600	.3285	.2536

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata

Feeder No / Name : 201 / 11 kv Shirasgaon Kata

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	31-AUG-17	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916		.7969		.3734
2	.9431		.8383		.3395
3	1.0288		.9259		.3361
4	1.1145		.9012		.3734
5	1.1145		.9831		.4481
6	1.1317		1.0774		.6722
7	1.1488		1.4255		.6348
8	1.2003		1.4918	1.9433	.4854
9	.4287	.1943	.3547	.2987	
10		.2241	.2427	.2957	
11		.2241		.2587	
12		.1886		.2241	
13		.1886		.2427	1.5432
14		.168		.2218	1.8176
15		.1867		.2263	1.9719
16		.1848		.1867	
17		.1886		.2614	.2058
18		.2241		.2614	.2401
19		.4481		.4481	.3601
20		.5228		.4854	.4115
21		.4294		.4481	.3772
22		.3734		.3921	.3429
23		.7202		.3734	.3429
24	.823		.7202		.3734
Max	1.2003	.7202	1.4918	1.9433	1.9719
Min	.4287	.168	.2427	.1867	.2058
Avg	.9825	.2977	.8871	.4105	.6131



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata

Feeder No / Name : 202 / 11 kv Pimpalsuti

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	31-AUG-17	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.3174		1.3763
2	.3429		.2987		1.4251
3	.3772		.3395		1.4575
4	.4115		.3734		1.5249
5	.4458		.4481		1.5249
6	.4801		.5729		1.4586
7	.5487		.5914		1.7166
8	.4458		.4668	.1619	1.9559
9	.9259	.6401	.9602	1.5261	.2987
10		.8573	1.0174	1.5912	.2614
11		.7291		1.5223	.2058
12		.7202		1.5364	.1715
13		.7042		1.576	.1543
14		.6613		1.5729	.1543
15		.6935		1.5912	.1543
16		.7545		1.5424	.1715
17		.1867		.2241	.2058
18		.2241		.2614	.2572
19		.3772		.3734	.3429
20		.4294		.4108	.4115
21		.3547		.3734	.3772
22		.3547		.3547	.3429
23		.3361		1.0562	1.1145
24	.3429		.3174		1.1498
Max	.9259	.8573	1.0174	1.5912	1.9559
Min	.3429	.1867	.2987	.1619	.1543
Avg	.4664	.5349	.5185	.9797	.7589

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214483 / 33/11 kv Shirasgaon Kata

Feeder No / Name : 203 / 11 kv Shirasgaon Kata Gfss

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	31-AUG-17	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1086		.1109
2		.1267		.1097
3		.128		.1448
4		.1629		.181
5		.2172		.2172
6		.2534		.2534
7		.2507		.2561
8		.2172	.1619	.2195
9	.1619	.1791	.1463	.1463
10	.1478	.181	.1478	.0747
11	.1294		.1478	.1372
12	.1086		.1463	.1029
13	.1097		.1086	.1543
14	.1086		.1109	.1715
15	.0914		.0914	.1715
16	.1086		.1463	.1715
17	.0747		.0747	.1715
18	.1086		.1463	.1715
19	.1463		.1829	.2058
20	.2172		.2172	.2058
21	.181		.181	.2058
22	.1646		.1478	.1715
23	.1463		.1109	.1372
24		.1097		.1109
Max	.2172	.2534	.2172	.2561
Min	.0747	.1086	.0747	.0747
Avg	.1336	.1759	.1418	.1668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214522 / 33/11 KV Nimone Sub station

Feeder No / Name : 201 / 11 KV NIMONE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.132		.1132	.132	.132	
2	.1132	.1509		.1132	.132	.132	
3	.132	.1509		.132	.1509	.1509	
4	.1509	.1886		.1509	.1698	.1886	
5	.1886	.2075		.1886	.2075	.2263	
6	.2452	.2641		.2641	.2452	.2829	
7	.3395	.3018	.2641	.3206	.2829	.3395	.2641
8	.2829	.3206	.2641	.3206	.3206	.3395	.3772
9	.3395	.3018	.3584	.2829	.2452		.3395
10	.2829	.2641	.2641	.2452	.2452		.2641
11	.2075		.1886	.2075	.3206		.2075
12	.1698		.2075	.1698	.2075		.1509
13	.1509		.1886	.132	.2075		.1698
14	.1509		.1509	.132	.1698		.1698
15	.132		.1509	.1509	.1698		.1698
16	.132		.1509	.1509	.1509		.1698
17	.132		.1509	.132	.1509		.1509
18	.1698		.132	.1509	.1509		.1698
19	.2075		.1509	.1886	.2452		.2075
20	.1886		.2263	.2075	.2075		.1886
21	.1509		.2263	.1698	.1886		.1698
22	.132		.1886	.1509	.1886		.1509
23	.132		.1509	.132	.1509		.1509
24	.1132	.132		.1132	.132	.1509	
Max	.3395	.3206	.3584	.3206	.3206	.3395	.3772
Min	.1132	.132	.132	.1132	.132	.132	.1509
Avg	.1815	.2195	.2008	.1800	.1988	.2158	.2042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214522 / 33/11 KV Nimone Sub station

Feeder No / Name : 205 / 11 KV Kurhadwadi AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.1781		.2012	.2591	.3353	
2	.2347	.1781		.2347	.2591	.3353	
3	.2347	.1943		.2347	.2915	.3353	
4	.2683	.2267		.2347	.3277	.4024	
5	.3353	.2622		.3018	.3932	.4694	
6	.3521	.3113		.3688	.5375	.5533	
7	.5197	.4801	.4938	.4527	.6036	.8048	.3734
8	.57	.5365	.6219	.5898	.8122	1.0185	.3361
9	.2641	.2614	.2561	.2452	.2743		.9012
10	.1886	.1867	.2012	.1698	.2075		1.0814
11	.132		.1097	.1132	.1886		1.1142
12	.0754		.0914	.1132	.1509		1.1797
13	.0754		.0732	.0943	.1509		1.1797
14	.0943		.0549	.0943	.132		1.2125
15	.0754		.0732	.0754	.132		1.2125
16	.0754		.0732	.0754			1.2616
17	.1132		.0914	.0943	.132		.1097
18	.1886		.0914	.1886	.1509		.1829
19	.2452		.1463	.3018	.2641		.2195
20	.2641		.1463	.2829	.2641		.2743
21	.1886		.1097	.2263	.2263		.2195
22	.1509		.1097	.1886	.1886		.1829
23	.1619		.1829	.2591	.3856		.1829
24	.2347	.1619		.2195	.2591	.3856	
Max	.57	.5365	.6219	.5898	.8122	1.0185	1.2616
Min	.0754	.1619	.0549	.0754	.132	.3353	.1097
Avg	.2199	.2707	.1721	.2233	.2866	.5155	.6602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214522 / 33/11 KV Nimone Sub station

Feeder No / Name : 206 / 11 KV Pimpachiwadi

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2195		.2195	.2195	.2263	
2	.2195	.2195		.2195	.2195	.2263	
3	.2195	.2561		.2195	.2561	.2641	
4	.2561			.2561	.2926	.3395	
5	.3292	.3658		.3658	.3696	.415	
6	.4207	.4805		.5121	.5041	.4904	
7	.5304	.5228	.5228	.5121	.5228	.5281	1.0814
8	.4938	.4435	.4854	.4938	.462	.4904	1.2742
9	.4161	.4755	.4424	.4694	.5365		.3658
10	.4161	.439	.426	.4359	.6706		.2561
11	.3814		.3277	.373	.6706		.2012
12	.3814		.2294	.407	.6706		.1463
13	.3814		.2294	.407	.6706		.1097
14	.3641		.2458	.4527	.7042		.1463
15	.3467		.2294	.4359	.7377		.1097
16	.3258		.2785	.4694	.7377		.1097
17	.1629		.1646	.1267	.1509		.1463
18	.2641		.1829	.2561	.1886		.1829
19	.4066		.2561	.4435	.3772		.3658
20	.3475		.439	.4251	.3395		.3841
21	.2926		.4024	.3475	.3395		.2926
22	.2195		.2926	.2378	.2641		.2378
23	.2195		.2561	.2195	.2012		.57
24	.2195	.2195		.2195	.2195	.2263	
Max	.5304	.5228	.5228	.5121	.7377	.5281	1.2742
Min	.1629	.2195	.1646	.1267	.1509	.2263	.1097
Avg	.3264	.3642	.3183	.3552	.4302	.3563	.3518

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214532 / 33/11 Ganegaon Dumala

Feeder No / Name : 201 / 11 SANGAMESHWAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1463	.1478	.0366	.1494	
2	.1509	.1463	.1663	.037	.1478	
3	.1494	.1463	.1663	.0362	.1494	
4	.1663	.1663	.1867	.0181	.168	
5	.1663	.1848	.1867	.0187	.1867	
6	.168	.1848	.2075	.0187	.1867	
7	.1867	.2054	.2263	.0189	.2054	
8	.1867	.1848	.1698	.1886	.112	.2452
9	.1494	.1478	.1307	.1494	.1017	.2439
10	.0762	.0554	.128	.112	.0747	.2408
11	.0543	.037	.0914	.0362	.0754	.3086
12	.0732		.0543	.0549	.0724	.2972
13	.052		.0543	.0362		.3239
14	.0526		.0724	.0366	.0678	.3161
15			.0716	.037	.0693	.3395
16	.052		.0716	.056	.0716	.3395
17			.1505	.1858		.1867
18	.1753		.1783	.2172		.1848
19	.1734		.2263	.2743		.1848
20	.1844		.2452	.2267		.1698
21	.1696		.2353	.2401		.1663
22	.1677		.2353	.2214		.1698
23				.12	.0663	.1886
24	.1494	.1463	.1478	.0362	.1494	.1848
Max	.1867	.2054	.2452	.2743	.2054	.3395
Min	.052	.037	.0543	.0181	.0663	.1663
Avg	.1359	.1460	.1544	.1005	.1208	.2406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214532 / 33/11 Ganegaon Dumala

Feeder No / Name : 202 / 11 KV UDANSHAHA BABA AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.128	.1307	.2263	.1494	
2	.1494	.1267	.1494	.2263	.1509	
3	.168	.1463	.1494	.2801	.1509	
4	.168	.1829	.168	.2801	.168	
5	.1848	.2218	.2075	.3018	.2054	
6	.2033	.2427	.2641	.3018	.2427	
7	.2587	.2614	.2641	.3018	.2614	
8	.2218	.2241	.1886	.1698	.2054	.2614
9	.1509	.1562	.2105	.2012		.056
10	.1524	.1543	.2105	.1844	.2561	.0566
11	.1372	.1219	.1943	.1677	.2429	.0566
12	.1341	.1219	.1677	.1658	.2241	.056
13	.0564	.1406	.1505	.1658		.0754
14	.0671	.1406	.1505	.1844	.2267	.0754
15		.1406	.1505	.1677	.2458	.0739
16	.1174	.1486	.1505	.1844	.2949	.0739
17	.1017	.112	.1478	.0543		.3858
18	.1017		.1478	.1097		.4214
19			.1463	.2172		.4161
20			.1478	.2263		.3401
21			.1663	.2427		.3201
22	.1017		.1646	.1509		.3281
23			.2241			.2054
24	.132	.1294	.1307	.2241	.1494	
Max	.2587	.2614	.2641	.3018	.2949	.4214
Min	.0564	.112	.1307	.0543	.1494	.056
Avg	.1441	.1611	.1743	.2059	.2116	.2001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 214532 / 33/11 Ganegaon Dumala

Feeder No / Name : 303 / 11 kv Tandali Ag

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0526	.0377	.0566	.0532	
2	.0566	.052	.0377	.056	.0526	
3	.0566	.0514	.056	.0554	.0351	
4	.056	.0514	.056	.0554	.0351	
5	.056	.052	.056	.0566	.0532	
6	.0554	.0514	.0747	.056	.0532	
7	.0554	.0514	.056	.0566	.0532	
8	.056	.0514	.0373	.1109	.0351	.056
9	.0549	.0526	.0457	.0602	.0537	.0181
10		.0267	.0463	.0457	.0625	.0183
11	.0043	.0133	.0463	.0457	.0633	.0185
12	.0663		.0463	.0305	.064	.0181
13	.0282		.048	.0305		.0183
14	.0171		.048	.0452	.0648	
15			.0472	.0602	.0655	
16			.0472	.0434	.0791	
17			.0271	.0137		.1067
18			.0267	.0137		.1134
19			.0377	.0343		.1094
20			.0566	.0351		.1107
21			.0543	.0514		.108
22			.0543	.0351		.1147
23			.0543			.0366
24	.056	.0526	.0377	.0566	.0532	.0366
Max	.0663	.0526	.0747	.1109	.0791	.1147
Min	.0043	.0133	.0267	.0137	.0351	.0181
Avg	.0482	.0466	.0473	.0480	.0548	.0631



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 300 / Auxilary

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.0362
Max	.0362
Min	.0362
Avg	.0362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 301 / SHIRUR Urban

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.905
Max	.905
Min	.905
Avg	.905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 302 / Shirur Gavthan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.086
Max	1.086
Min	1.086
Avg	1.086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 303 / PABAL

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 304 / KARDA

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.905
Max	.905
Min	.905
Avg	.905

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 305 / MALLIKARJUN

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.724
Max	.724
Min	.724
Avg	.724

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 307 / MANIKCHAND

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	.181
Max	.181
Min	.181
Avg	.181

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 308 / 22 kv Shirur Nagarpalika      NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 22 / OUTGOING      (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	.1867
Max	.1867
Min	.1867
Avg	.1867



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUNG DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 401 / Malthan

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217010 / 132/33/22 KV SHIRUR

Feeder No / Name : 402 / Takli haji

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 300 / Auxiliary

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.0362
Max	.0362
Min	.0362
Avg	.0362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 301 / WADGAON

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.7888
Max	.7888
Min	.7888
Avg	.7888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 302 / NAGARGAON

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 303 / KURULI

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 304 / URJA

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.905
Max	.905
Min	.905
Avg	.905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 305 / Kuruli gfss

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 306 / Nagargaon Gfss

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 307 / 22 KV KURULI INDUSTRIAL

Feeder KV- 22 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 401 / Mandavgaon Farata

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 402 / Nhavara

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	1.8004
Max	1.8004
Min	1.8004
Avg	1.8004

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 403 / 33 Kv Shirasgaonkata

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 217037 / 132KV/33KV/22KV KURALI

Feeder No / Name : 404 / 33 kv Alegaon Paga

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 218038 / 220/132/33 KV KATHAPUR

Feeder No / Name : 401 / Kathapur

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 218038 / 220/132/33 KV KATHAPUR

Feeder No / Name : 402 / NIRGUDSAR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 218038 / 220/132/33 KV KATHAPUR

Feeder No / Name : 403 / RANJANI

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
22	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 218038 / 220/132/33 KV KATHAPUR

Feeder No / Name : 404 / MANCHAR

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 218038 / 220/132/33 KV KATHAPUR

Feeder No / Name : 405 / PETH

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 218038 / 220/132/33 KV KATHAPUR

Feeder No / Name : 406 / M PARGAON

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 218038 / 220/132/33 KV KATHAPUR

Feeder No / Name : 408 / PABAL

Feeder KV- 33 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

DOUND DIVISION[510]

SHIRUR[055]

BU 0833

Substation No/ Name :- 218038 / 220/132/33 KV KATHAPUR

Feeder No / Name : 409 / 33 kv Jambut

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 214484 / 33 KV NIGUDGHAR

Feeder No / Name : 201 / 11 KV SHIRWALI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0236	.0434	.0543	.0349	.0301	.0278
2	.0895	.0236	.0394	.0543	.0232	.0332	.0297
3	.1075	.0236	.0332	.0549	.0232	.0354	.032
4	.1063	.0236	.0366	.0532	.0232	.029	.0274
5	.0886	.0236	.0457	.0514	.0236	.0278	.0244
6	.0886	.0244	.0543	.0514	.0305	.0305	.0301
7	.0709	.0297	.056	.0686	.0309	.0362	.032
8	.1134	.048	.0377	.0671	.0463	.0328	.0492
9	.0838	.048	.0377	.0648	.0469	.0347	.0332
10	.081	.0347	.0377	.061	.0497	.0328	.0309
11	.0663	.0191	.0648	.0394	.0301	.0297	.0301
12	.0602	.0486	.0625	.0377	.029	.0244	.0278
13	.0469	.0617	.061	.0354	.0251	.0282	.0267
14	.0446	.0509	.0457	.0377	.0282	.029	.0389
15	.0503	.0503	.0469	.0377	.0305	.0267	.0251
16	.0446	.0514	.0457	.0267	.0263	.0312	
17	.0343	.0655	.0486	.0406	.029	.0492	
18	.0351	.0701	.0686	.0429	.048	.0497	
19	.056	.0934	.0905	.0678	.0526	.0716	.0678
20	.0686	.1109	.0924	.0876	.0678	.0709	.0886
21	.0686	.1086	.1109	.0678	.0693	.0549	.0724
22	.0474	.0895	.0924	.0587	.0469	.052	.0509
23	.0389	.0678	.0724	.0389	.0332	.0316	.0305
24	.0905	.0244	.0474	.0549	.0354	.0263	.0332
Max	.1134	.1109	.1109	.0876	.0693	.0716	.0886
Min	.0343	.0191	.0332	.0267	.0232	.0244	.0244
Avg	.0697	.0506	.0571	.0523	.0368	.0374	.0385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 214484 / 33 KV NIGUDGHAR

Feeder No / Name : 202 / 11 KV WAGHJAI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.0423	.1132	.0943	.0705	.0739	.0754
2	.1294	.0423	.0995	.0924	.0705	.0754	.0663
3	.128	.0423	.1052	.0924	.0705	.0678	.0709
4	.1294	.0423	.1097	.0924	.0705	.0747	.0739
5	.1294	.0423	.1029	.0914	.0714	.0693	.0686
6	.1463	.044	.1097	.1097	.0892	.0943	.1086
7	.1829	.0762	.12	.1612	.1265	.1509	.1307
8	.1991	.1094	.1663	.1791	.1492	.168	.1387
9	.1991	.1189	.1772	.1791	.1492	.1463	.1463
10	.197	.0335	.1629	.1578	.1107	.1463	.1254
11	.1526	.1417	.1612	.1174	.128	.1372	.0914
12	.1475	.1526	.1595	.1014	.1372	.1214	.0857
13	.1423	.1402	.1526	.1353	.1341	.116	.0846
14	.128	.1387	.1509	.1337	.1187	.1254	.0823
15	.1372	.1029	.1543	.1189	.104	.1174	.0834
16	.1337	.1341	.1543	.1027	.0886	.1387	
17		.1715	.1372	.1448	.0876	.1227	
18	.0366	.1753	.1402	.1581	.1509	.1109	
19	.0819	.1829	.2054	.1696	.2012	.1698	.1562
20	.112	.2427	.2452	.1907	.2218	.1886	.1844
21	.1107	.2218	.2263	.1696	.1698	.1867	.1638
22	.0949	.1829	.1886	.1296	.1311	.1478	.1326
23	.0579	.1478	.1294	.0926	.0934	.0867	.08
24	.1494	.0423	.1267	.112	.0705	.0716	.0716
Max	.1991	.2427	.2452	.1907	.2218	.1886	.1844
Min	.0366	.0335	.0995	.0914	.0705	.0678	.0663
Avg	.1336	.1155	.1499	.1303	.1173	.1212	.1058



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 214484 / 33 KV NIGUDGHAR

Feeder No / Name : 203 / 11 KV Raireshwar

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292		.2427	.3326	.2804	.2401	.2601
2	.2987		.2561	.3292	.2804	.2561	.2801
3	.2926		.2401	.3292	.2804	.2321	.2829
4	.2926		.2347	.3292	.2804	.2587	.2543
5	.3142		.2587	.3258	.2835	.2534	.2743
6	.3982		.3361	.3582	.3658	.4207	.3258
7	.5014		.4656	.5316	.5373	.5853	.5731
8	.6447		.5487	.6089	.6024	.6415	.6733
9	.6154		.6089	.2835	.631	.6762	.6415
10	.5068		.5731	.2835	.5895	.6001	.5596
11	.4908	.1991	.4961	.192	.4807	.5596	.5197
12	.4854	.5784	.4908	.192	.4049	.5658	.503
13	.3982	.5847	.3601		.4409	.4917	.426
14	.362	.5552	.0509	.1802	.39	.5175	.3768
15	.3658	.4784	.3429	.213	.39	.431	
16	.3801	.4887	.3429	.3978	.3521	.4191	
17		.4733	.3086	.4752	.1357	.4748	
18		.543	.3544	.6241	.4287	.5144	
19	.0754	.6348	.5914	.8238	.6036	.724	.7265
20		.7545	.7468	.8413	.9054	.7421	.8326
21		.7356	.7095	.7207	.7421	.7023	.7865
22		.547	.5975	.5487	.5853	.4917	.6516
23		.4294	.4066	.3982	.439	.4075	.4656
24	.3475		.3547	.3696	.3012	.3366	.3326
Max	.6447	.7545	.7468	.8413	.9054	.7421	.8326
Min	.0754	.1991	.0509	.1802	.1357	.2321	.2543
Avg	.3944	.5386	.4132	.4212	.4471	.4809	.4873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 214484 / 33 KV NIGUDGHAR

Feeder No / Name : 205 / Pombardi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0343	.0099				
2	.0857		.0076				
3	.0876	.0343	.0084				
4	.0838	.0343	.0091				
5	.0848	.0343	.0076				
6	.0838	.0343	.0084				
7	.0686	.0343	.0088				
8	.0838	.0343	.0091				
9			.0095	.0509	.0229	.0343	
10			.0141	.0339	.0229	.0503	
11			.0343	.0472	.0156	.0503	
12			.0351	.0465	.028	.0511	
13			.0328	.0465	.0269	.0619	
14			.0486	.0472	.0442	.0511	
15			.0335	.0472	.0419	.048	
16			.0343	.036	.0373	.0511	
23	.0343	.0091					.0244
24	.0671	.0457	.0126				
Max	.0876	.0457	.0486	.0509	.0442	.0619	.0244
Min	.0343	.0091	.0076	.0339	.0156	.0343	.0244
Avg	.0765	.0328	.0190	.0444	.0300	.0498	.0244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 217008 / 132 KV BHATGAR

Feeder No / Name : 301 / 22 KV HIRDOSHI AG  
Feeder KV- 22 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 217008 / 132 KV BHATGAR

Feeder No / Name : 302 / 22 KV VELHA AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	5.6927
Max	5.6927
Min	5.6927
Avg	5.6927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 217008 / 132 KV BHATGAR

Feeder No / Name : 303 / 22 KV BHOR RURAL GAVTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.7545
Max	.7545
Min	.7545
Avg	.7545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 217008 / 132 KV BHATGAR

Feeder No / Name : 304 / 22 KV PASURE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

BHOR[056]

BU 0841

Substation No/ Name :- 217008 / 132 KV BHATGAR

Feeder No / Name : 305 / 22 KV BHOR URBAN GAOTHAN

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
19	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION

Feeder No / Name : 301 / 22KV JEJURI(U) FEEDER

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7468	.8215		.8215	.7842	.8215
2	.7468	.7468	.7468	.7468	.8589	.7842	.8215
3	.7468	.7095	.6722	.7468	.8589	.7842	.8215
4	.7095	.7095	.5975	.7095	.8962	.7842	.8215
5	.7095	.8215	.8215	.7468	.9335	.7842	.8215
6	.9709	.9335	.9709		.9709	.9335	.9709
7	1.2323	1.1203	1.2323	1.307	1.3817	1.1203	1.1203
8	1.1576	1.2696	1.1576	1.1949	1.3817	1.1203	1.1949
9	1.0829	.9709	1.1203	1.1203	1.1576	1.1949	1.1949
10	1.0456	.8962	1.0082	1.0456	1.0829	1.1949	1.1203
11	.8962	.8962	.8962	1.0829	1.0829	1.1949	1.0456
12	.8962	.8962	.8962	1.0456	.9709	1.1203	1.1576
13	.7842	.8215	.6722	.9335	1.0082		1.1203
14	.7095	.8215	.7095	.9335	1.0082		1.1203
15	.6722	.8215	.6722	.9709	1.0456		1.0082
16	.7095	.8215	.8215	.9709	.9709		1.1203
17	.7468	.8215	.8962	.9709	.9709		1.1576
18	.7468	.9709	.9709	1.0082	1.0456		.8962
19	1.2323	1.2696	1.307	1.307	1.2696		1.2696
20	1.2323	1.2696	1.419	1.4563	1.307		1.3443
21	1.1949	1.1949	1.2323	1.307	1.2323		1.1203
22	1.1203		1.1949	1.1949	1.1576		1.0456
23	.8589		.9709	.9335	1.0082		1.0082
24	.8215	.7842			.8215	.8962	.8962
Max	1.2323	1.2696	1.419	1.4563	1.3817	1.1949	1.3443
Min	.6722	.7095	.5975	.7095	.8215	.7842	.8215
Avg	.9071	.9234	.9482	1.0349	1.0518	.9766	1.0425



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION

Feeder No / Name : 305 / 22KV NAZARE GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4572	.4954	.381	.5335	.5335	.4572
2	.381	.381	.5335	.381	.6097	.5335	.4572
3	.381	.381	.5335	.4572	.6859	.4954	.4572
4	.381	.4191	.6097	.4572	.6859	.5335	.5335
5	.381	.6097	.724	.4954	.7621	.6097	.6097
6	.5716	.8002	.9145		.8383	.8764	.6859
7	.6478	.9145	.8764	1.0288	.9145	.9145	.9145
8	.4572	.3429	.6859	.724	.7621	.8002	.724
9	.5335	.3429	.6859	.6478		.7621	.8002
10	.5335	.5335	.4191	.5716	.4572	.7621	.724
11		.5335	.3429	.6478	.7621	.6097	.8002
12	.5716	.6859	.381	.6478	.6859	.5335	.6859
13	.4572	.5335	.381	.6097	.6097		.6097
14	.4954	.6097	.3429	.6859	.6859		.6859
15	.5716	.6097	.381	.6478	.6859		.6859
16	.6097	.5335	.4191	.6859	.5335		.724
17		.4572	.4191	.724	.6478		.6478
18	.6097	.6097	.4954	.6859	.6478		.5335
19	.8002	.8383	.5716	.9526	.9145		.8002
20	.8764	.9145	.8002	1.0288	1.0669		.9526
21	.7621	.7621	.724	.9526	.9145		.8383
22	.6097		.6478	.8383	.7621		.724
23	.5716		.5716	.724	.6478		.6097
24	.3429	.4954		.4572	.5335	.5716	.4572
Max	.8764	.9145	.9145	1.0288	1.0669	.9145	.9526
Min	.3429	.3429	.3429	.381	.4572	.4954	.4572
Avg	.5404	.5802	.5633	.6710	.7107	.6566	.6716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214418 / 33KV/22KV JEJURI SUBSTATION

Feeder No / Name : 306 / 22KV WALHA GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4572	.5716	.4572	.6097	.6097	.4572
2	.4572	.4572	.5335	.4191	.6859	.5716	.4572
3	.4954	.4572	.4572	.4572	.6859	.5335	.4572
4	.4954	.4572	.4954	.4954	.7621	.5335	.4572
5	.5335	.6478	.6097	.5335	.8002	.5716	.5335
6	.7621	.7621	.8383		.8383	.8002	.6859
7	.9526	.8002		.8002	.9907	.9907	.9145
8	.8383	.8002		.6859	.9145	.8764	.9145
9	.724	.7621		.6097	.7621	.7621	.7621
10	.724	.6859		.6097	.8002	.6097	.724
11	.6478	.6859	.6859	.5335	.7621	.6859	.5716
12	.6859	.5335	.5716	.4954	.6859	.6097	.5335
13	.3429	.5335	.5335	.4572	.6478		.5335
14	.3048	.5335	.4572	.4572	.6097		.5716
15	.5335	.5335	.4954	.4572	.5716		.5335
16	.6478	.4572	.5335	.6859	.6097		.6097
17	.6097	.6097	.4572	.724	.6859		.6478
18	.5335	.6859	.6097	.7621	.724		.4572
19	.8764	.8383	.8002	.9526	.9526		.8764
20	.9145	.9145	.8383	.9907	.9907		1.0288
21	.8002	.8002	.724	.9145	.9145		.9145
22	.6859		.6478	.7621	.8002		.8002
23	.5335			.6478	.6859		.724
24	.5716	.4954		.4572	.6097	.6097	.4572
Max	.9526	.9145	.8383	.9907	.9907	.9907	1.0288
Min	.3048	.4572	.4572	.4191	.5716	.5335	.4572
Avg	.6335	.6322	.6033	.6246	.7542	.6742	.6510

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 201 / 11KV KALDARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2743	.1357	.0754	.0724	.0754	.0532
2	.2949	.2743	.1341	.0754	.0724	.0754	.0709
3	.2915	.2713	.1341	.0754	.0724	.0754	.0701
4	.3439	.2743	.1357	.0754	.0905	.0754	.0876
5	.3768	.2743	.1463	.0943	.1052	.0943	.0857
6	.421	.3429			.1543	.1509	.156
7	.583	.4588	.2865	.1509	.1417	.132	.0867
8	.5898	.5079	.3772	.1132	.0943	.0943	.0886
9	.0953		.3856	.8865	.9945	1.2209	
10		.0762	.3812	.8848	1.1568	1.2887	
11		.0762	.4807	.9054	1.1469	1.543	.0566
12	.0943	.0572	.4973	.9835	1.1904	1.543	.0566
13	.1132	.056	.0373	.7956	1.2071	1.6448	
14	.1132	.0572	.0366	1.2039	1.1797	1.5769	.0566
15	.0739	.0572	.0362	1.0682	1.2125	1.6448	.0754
16	.0716	.0572	.0366	1.0227	1.1797	1.5089	.0754
17	.0754	.4115	.0377	.0754	.0754	.0671	.0754
18	.0943	.0857	.0754	.0747	.0754	.0747	.1029
19	.1509	.1372	.132	.1227	.1509	.0914	.1372
20	.1698	.1387	.1509	.1417	.1509		.1372
21	.1509	.1227	.1509	.124	.132	.124	.1372
22	.1132	.1063	.1132	.0895	.0943	.0905	.12
23	.2743	.2035	.1132	.0716	.1509	.0886	.7468
24		.2713		.0754	.0716	.0754	.0709
Max	.5898	.5079	.4973	1.2039	1.2125	1.6448	.7468
Min	.0716	.056	.0362	.0716	.0716	.0671	.0532
Avg	.2293	.1997	.1825	.3994	.4572	.5807	.1213

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 202 / 11 KV PARINCHE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0943	.1097	.1132	.2818	.373	.3605
2	.0381	.0943	.1097	.1132	.2818	.3601	.3441
3	.0381	.0943	.1097	.1132	.2949	.3429	.3241
4	.0381	.0943	.1097	.132	.2984	.3391	.3481
5	.0572	.1132	.1307	.132	.3391	.3277	.3601
6	.1143	.1509	.1886		.5765	.6133	.5138
7	.0762	.1886	.1886	.132	1.0364	1.065	
8	.0572	.132	.1294	.1132	.933	1.0486	
9	.081	.3605	.0924	.0943	.0914	.1132	
10		.3239	.0943	.0754	.0543	.1132	
11		.2949	.0943	.0701	.0754	.0914	.9145
12			.0895	.0716	.0754	.0914	.9602
13			.4111	.0732	.0566		.8535
14			.5624	.0732	.0566	.0914	.823
15		.4049		.0732	.0566	.0934	.8078
16		.3887		.0732	.0566	.1097	.823
17	.0943	.0747	.0754	.0747	.0754	.0914	.0754
18	.0943	.0934	.0754	.0754	.0943	.1097	.0857
19	.1132	.1494	.1509	.1509	.1886	.1097	.1543
20	.1698	.1494	.1509	.1886	.1886	.0914	.1715
21	.1698	.1494	.1509		.1698	.1698	
22	.132	.112	.1509		.1509	.1509	.1715
23	.1132	.0914	.1132		.4748	.3932	.12
24		.1132		.1132	.2818	.3906	.3605
Max	.1698	.4049	.5624	.1886	1.0364	1.065	.9602
Min	.0381	.0747	.0754	.0701	.0543	.0914	.0754
Avg	.0903	.1747	.1566	.1028	.2579	.2904	.4511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 203 / 11KV VEER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0754	.0934	.0943	.6093	.7537	.8421
2	.0762	.0754	.0943	.0943	.5937	.7209	.7773
3	.0762	.0754	.0747	.0943	.5851	.7127	.6802
4	.0762	.0754	.0754	.0943	.5967	.7209	.6802
5	.0953	.1132	.1494	.1132	.6224	.7209	.8421
6	.1524	.1509	.168		.6554	.7293	.9156
7	.1334	.1132	.132	.1509	.9717	.9995	
8	.1143	.0943	.1132	.0754	.9014	1.0486	
9	.7449		.0332	.0566	.0747	.0754	
10		.583	.0354	.0328	1.7364	.0566	
11		.5571			.0566	.0537	1.4632
12		.5506	.0354	.0332	.052	.0537	1.5851
13		.6834	.7362	.0549	.0377	.0543	1.6876
14		.8029	.8745	.0549	.0377	.0549	1.5851
15		.6478		.0366	.0377	.0747	1.5546
16		.639		.0366	.0377	.0943	1.387
17	.0566	.0754	.0377	.0509	.0377	.0566	.0343
18	.0754	.0943	.0377	.0554	.0566	.0566	.0514
19	.132	.132	.1132	.0739	.1132	.132	.1029
20	.132	.1509	.1509	.1698	.1509	.1698	.1543
21	.132	.132	.1509	.1509	.1509	.1698	.1372
22	.132	.1509	.1509	.1509	.1132	.0754	.12
23	.1132	.0934	.132	.7356	.7865	.8848	.1029
24		.0943		.1132	.5851	.7865	.8421
Max	.7449	.8029	.8745	.7356	1.7364	1.0486	1.6876
Min	.0566	.0754	.0332	.0328	.0377	.0537	.0343
Avg	.1461	.2678	.1694	.1147	.4000	.3857	.7773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 204 / 11KV VEER GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2454	.2378	.2378	.2378	.2561	.2743	.3292
2	.2743	.2378	.2378	.2378	.2561	.2743	.3475
3	.2715	.2378	.2561	.2378	.2743	.2743	.3475
4	.2743	.2926	.2743	.2926	.3292	.3109	.3292
5	.4908	.3292	.4755	.3292	.3841	.3841	
6	.5611	.4755	.4755		.5304	.5121	.5487
7	.543	.5487	.567	.5304	.5487	.5487	.3475
8	.421	.4572	.439	.439	.439	.5121	
9	.3681	.3841	.4024	.3841	.4207	.439	
10			.3475	.3841	.4024	.4024	
11		.3292	.2926	.3658	.3841	.3292	.3429
12		.3801	.2926	.3658	.192	.3475	.3258
13		.3544	.2926	.3292	.3292	.3658	.3258
14		.3155	.3109	.3292	.3109	.3475	.3258
15		.3077	.0532	.3292	.3292	.3475	.3258
16		.2622	.0549	.3292	.3292	.3475	.3258
17	.3475	.3109	.3109	.3292	.3109	.3109	.3086
18	.3292	.3475	.3292	.3658	.3292	.3475	.3086
19	.5121	.4755	.4024	.4572	.4572	.4024	.4458
20	.4938	.4572	.5487	.4572	.5304	.4207	.4801
21	.3841	.3841	.4755		.4207	.3658	.3429
22	.3475	.3475	.3475		.3658	.3292	.3429
23	.2378	.2743	.2743		.2926	.2743	.2743
24		.2378		.2378	.2743	.2743	.3475
Max	.5611	.5487	.567	.5304	.5487	.5487	.5487
Min	.2378	.2378	.0532	.2378	.192	.2743	.2743
Avg	.3813	.3472	.3347	.3484	.3624	.3643	.3536

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 205 / 11KV KALDARI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0754	.0732	.0754	.0732	.0747	.0914
2	.0732	.0754	.0724	.0754	.0724	.0747	.0732
3	.0709	.0754	.0724	.0754	.0724	.0754	.0914
4	.1075	.0943	.0724	.0943	.1086	.0934	.1086
5	.181	.112	.2172	.1132	.1372	.1294	.1267
6	.2896	.2561	.2454		.1372	.2614	.2686
7	.2629	.2987	.2686	.2641	.2835	.1829	
8	.2481	.2241	.1612	.2241	.1949	.1886	
9	.2126		.1227	.1867	.1402	.1663	
10		.1267	.1187	.1509	.1174	.1372	
11		.0709	.0886	.0972	.0934	.0876	.0732
12	.0732	.1086	.0838	.0829	.0914	.0876	.0686
13	.0732	.0905	.0983	.0693	.0914	.0701	
14	.0732	.0905	.052	.0532	.0549	.0701	.1029
15	.0732	.0876		.0514	.0566	.0838	.0857
16	.0732	.1029		.0526	.056	.0509	.0857
17	.1097	.128		.081	.0732	.0754	.0857
18	.1463	.128	.0943	.128	.0732	.0995	.0857
19	.2012	.2195	.2263	.2303	.2195	.116	.2058
20	.2195	.2378	.2641	.2195	.2427		.2058
21	.1829	.2012	.2263	.1791	.2054	.2012	.1886
22	.132	.2012	.132	.128	.1294	.1595	.1372
23	.0943	.1097	.0914	.0739	.0943	.1086	.0857
24		.0754		.0754	.0732	.0754	.0732
Max	.2896	.2987	.2686	.2641	.2835	.2614	.2686
Min	.0709	.0709	.052	.0514	.0549	.0509	.0686
Avg	.1423	.1387	.1391	.1209	.1205	.1161	.1181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 206 / 11KV PARINCHE GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1294	.1417	.1829	.1772	.1646	.1867
2	.1629	.1307	.1227	.1886	.1772	.1646	.1848
3	.1646	.1307	.1417	.1829	.1772	.1646	.1829
4	.2172	.1478	.1612	.1829	.197	.1646	.2033
5	.3224	.1829	.1829	.2195	.2195	.2012	.2075
6	.3982	.3475	.3174		.3547	.2772	.3403
7	.4908	.3658	.3881	.3734	.7762	.2926	
8	.543	.7316	.6805	.724	.2896	.7087	
9	.3506		.4706	.6767	.2481	.5487	
10		.5487	.543	.6401	.2126	.543	
11		.3982	.4835	.4558	.2012	.462	.5487
12	.3222	.4481	.439	1.2536	.109	.462	.5144
13	.3222	1.363	.4755	1.0276	.2012	.1949	.583
14		.5258	.4435	1.1462	.2195	.2172	.6173
15		.5258	.4066	.5731	.2195	.2172	.583
16		.2715	.6984	.5609	.2195	.1991	.583
17	.5121	1.0974	.5487	.4207	.1989	.2172	.583
18	.2926	1.1706	.567		.2195	.2204	.5487
19	.2957	1.3534	.3292	.3898	.3292	.3174	.6344
20	.3292	.7499	.4024	.4075	.3475	.2587	.3601
21	.2743	.695	.4024	.3801	.2926		.3258
22	.2195	.573	.2896	.2715	.2378		.2915
23	.1448	.2303	.2378	.1991	.2012	.2054	.2058
24		.128		.1829	.1772	.1646	.1867
Max	.543	1.363	.6984	1.2536	.7762	.7087	.6344
Min	.1448	.128	.1227	.1829	.109	.1646	.1829
Avg	.3070	.5324	.3858	.4836	.2501	.2894	.3935



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 207 / 11KV KAMBALWADI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0754	.0019	.0754	.0019	.0566	.0566
2	.056	.0754	.0019	.0019	.0019	.0566	.0377
3	.056	.0754	.0019	.0076	.0019	.0566	.0566
4	.056	.0754	.0377	.0076	.0019	.0566	.0566
5	.1307	.0754	.0566	.0076	.0754	.0566	.0566
6	.1307	.0754	.0754		.0754	.0566	.0566
7	.1307	.0754	.0754	.0133	.0754	.0566	
8		.0754	.0754	.0133	.1294	.0566	
9	.056		.0754	.0076	.0566	.0566	
10	.0191	.056	.0754	.0076	.0754	.0754	
11		.1307	.0754	.0566	.0754	.0566	.0686
12		.0191	.0754	.0754	.0566	.0566	.0686
13		.0187	.0566	.0754	.0566	.0566	.0686
14		.0191	.0754	.0566	.0566	.0754	.0686
15		.0187	.0566	.0566	.0566	.0754	.0686
16		.0191	.0566	.0566	.0566	.0754	.0686
17	.0191	.0566	.0566	.0566	.0566	.0566	.12
18	.0566	.0566	.0754	.1294	.0566	.0566	.0191
19	.0754	.0566	.0754	.0566	.0566	.0943	.0191
20	.132	.132	.0754	.0566	.0754	.1132	.0686
21	.1307	.0566	.0754	.0566	.0754	.0566	.0686
22	.1307		.0754	.0019	.0754	.0566	.0686
23	.0754	.0019	.0754	.0019	.0566	.0566	.0686
24		.0754		.0019	.0019	.0566	.0566
Max	.132	.132	.0754	.1294	.1294	.1132	.12
Min	.0191	.0019	.0019	.0019	.0019	.0566	.0191
Avg	.0819	.0600	.0601	.0383	.0545	.0637	.0611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214471 / 33/11KV PARINCHE

Feeder No / Name : 209 / 11KV TONDAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.2378	.1814	.0328	.017	.0492	.0358
2	.3812	.2172	.1867	.0328	.017	.0492	.0354
3	.3932	.2054	.2058	.0343	.017	.0486	.0351
4	.4096	.208	.2134	.0335	.017	.0492	.0362
5	.426	.2027	.2286	.0335	.0358	.0655	.0554
6	.4696	.2134	.2439		.0566	.0924	.0549
7	.4696	.2458	.2896	.0655	1.7926	.0914	
8	.4915	.2622	.3241	.056	1.7194	.0686	
9	.0492		.3102	.5898	.7712	1.0486	
10		.0543	.3102	.663	.9054	1.4243	
11		.0486	.3102	.5407	.9878	1.3226	.0343
12		.0325	.5155	.7545	1.1233	1.3226	.0343
13		.0366	.1143	.8817	1.1568	1.3904	.0343
14		.0377	.1189	.8987	1.1904	1.358	.0171
15			.1311	.8478	1.0814	1.3748	.0343
16			.1265	.8478	1.1469	1.3763	.0343
17	.0183	.0362	.0141	.0139	.0309	.0309	.0514
18	.0366	.0543	.0305	.0154	.037	.0156	.0514
19	.0362	.0362	.0335	.0358	.0732	.0526	.0514
20	.0554	.0366	.0514	.0358	.0686	.0532	.0686
21	.0549	.0362	.0509	.0351	.0655	.0701	.0686
22	.0526	.0339	.0343	.0343	.0492	.0526	.0686
23	.2439	.2317	.0358	.0351	.0492	.0543	1.0212
24		.2317		.0335	.0171	.0492	.0358
Max	.4915	.2622	.5155	.8987	1.7926	1.4243	1.0212
Min	.0183	.0325	.0141	.0139	.017	.0156	.0171
Avg	.2485	.1285	.1766	.2848	.5178	.4796	.0929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION

Feeder No / Name : 201 / 11KV PANDESHWAR GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.168	.2075	.2195	.2195	.2427	.2402
2	.2033	.1698	.1867	.2218	.2218	.2452	.2402
3		.2033	.1848	.2614	.2195	.2715	.2054
4		.2801	.2033	.3142	.2772	.2926	.2427
5		.4298	.2801	.3961	.3696	.3734	.2829
6	.6535	.679	.5975	.6602	.6099	.5847	.6036
7	.6722	.6413	.5847	.6535	.5975	.6161	.5415
8	.4854	.4294	.4294	.4024	.4572	.4435	.4435
9	.3467	.2715	.3189	.2353	.3224	.3077	.3658
10	.2454	.1791	.2126	.1772	.2715	.2378	.2353
11		.1417	.181	.1753	.2218	.1612	.2149
12	.1696	.1417	.1478	.1734	.2353	.1612	.1949
13	.1886	.1372	.1629	.1753	.2172	.1612	.1753
14	.1772	.1448	.1595	.1753	.1907	.1629	.1928
15	.1578	.1494	.1417	.1772	.1949	.1791	.1578
16	.1867	.1433	.1629	.1772	.218	.2254	.1734
17	.2328	.1372	.1886	.208	.218	.2058	.2241
18	.3224	.2658	.2835	.362	.3155	.2804	.2772
19	.462	.4435	.4024	.462	.4887	.462	.5601
20	.4481	.5041	.5544	.5544	.5544	.499	.5175
21	.362	.4066	.4435	.4572	.4108	.4668	.4251
22	.2801	.3142	.3326	.3658	.3511	.3326	.3696
23	.2033	.2402	.2772	.2772	.3361	.2614	.2772
24	.181	.1663	.2033	.2378	.2378	.3018	.2402
Max	.6722	.679	.5975	.6602	.6099	.6161	.6036
Min	.1578	.1372	.1417	.1734	.1907	.1612	.1578
Avg	.3081	.2828	.2853	.3133	.3232	.3115	.3084

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION

Feeder No / Name : 202 / 11KV PANDESHWAR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1027	.2107	.176	.1109	.1494	.112	.2743
2	.104	.2134	.1806	.112	.1494	.1132	.2778
3		.2343	.1852	.1307	.1478	.1307	.2343
4		.2818	.2031	.1663	.1867	.168	.2846
5		.3353	.2214	.2054	.2218	.1886	.3201
6	.2804	.3856	.3201	.2641	.2743	.2641	.4111
7	.333	.4359	.4372	.3018	.3361	.3206	.4961
8	.2778	.381	.4144	.2452	.2614	.2452	.4428
9	.1387	.1494	.1494	.4801	.4218	.4801	.1646
10	.112	.1109	.0934	.4744	.4374	.4641	.128
11		.0886	.112	.4938	.4915	.4268	.1109
12		.0914	.0924	.463	.442	.4572	.0914
13		.0732	.112	.4214		.4784	.1402
14		.0732	.0934	.3715	.4064	.4938	.1478
15		.0914	.0934	.301	.4012	.503	.1402
16		.0914	.112	.2229	.4054	.4161	.1402
17	.1478	.1097	.1307	.1086	.081	.1417	.1578
18	.1867	.1307	.1494	.181	.1097	.1463	.2241
19	.2241	.2075	.1867	.2195	.2427	.2614	.3258
20	.2263	.2075	.2263	.2241	.2641	.2614	.2987
21	.1886	.1698	.1867	.1829	.1867	.1867	.2561
22	.1307	.1494	.168	.1848	.1509	.1663	.2218
23	.1981	.1932	.1307	.168	.1307	.253	.3086
24	.0869	.1907	.176	.112	.1478	.132	.2709
Max	.333	.4359	.4372	.4938	.4915	.503	.4961
Min	.0869	.0732	.0924	.1086	.081	.112	.0914
Avg	.1825	.1919	.1813	.2561	.2629	.2838	.2445

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION

Feeder No / Name : 203 / 11KV KOTHALE AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4365	.4572	.3109	.3174	.3582	.7676
2	.4254	.431	.4548	.3142	.3174	.362	.7579
3	.4365	.4458	.4666	.3292	.3142	.3881	.7876
4	.4344	.4515	.4816	.3511	.3734	.4108	.8173
5	.4694	.4725	.5335	.3921	.4108	.4066	.8916
6	.5201	.503	.6173	.4338	.4668	.5041	.9332
7	.6874	.6859	.8065	.4715	.5041	.547	1.3441
8	.6859	.823	.9686	.4251	.4668	.4854	1.4563
9	.2801	.2534	.2218	1.186	1.0364	1.2967	.3292
10	.1991	.2402	.2614	1.2803	1.2809	1.406	.3439
11	.2241	.2195	.2587	1.2346	1.5402	1.5181	.3475
12	.2614	.2378	.2772	1.2346	1.6091	1.5813	.3881
13	.2427	.2743	.2614	1.2498	1.6309	1.6288	.3881
14	.2279	.2561	.2587	1.406	1.5089	1.6604	.4066
15	.2353	.2801	.2561	1.3889	1.5546	1.7236	.3881
16	.2241	.2587	.3174	1.3717	1.4937	1.189	.3511
17	.2172	.2353	.2926	.2658	.3077	.2561	.4024
18	.2172	.2772	.3142	.3258	.3326	.2957	.415
19	.2402	.3174	.3696	.3658	.4108	.3547	.4294
20	.2743	.3361	.4108	.4163	.4294	.3734	.4481
21	.2614	.3174	.3881	.3658	.362	.3696	.4435
22	.2172	.2957	.362	.3658	.3547	.3511	.4294
23	.4199	.4923	.3547	.3326	.3547	.7375	1.0084
24	.4451	.4161	.4512	.3326	.3326	.362	.7977
Max	.6874	.823	.9686	1.406	1.6309	1.7236	1.4563
Min	.1991	.2195	.2218	.2658	.3077	.2561	.3292
Avg	.3448	.3732	.4101	.6729	.7379	.7736	.6280

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214517 / 33/11NAZARE SUB-STATION

Feeder No / Name : 204 / 11KV NAZARE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3185	.3048	.3961	.2353	.1848	.2641	.3948
2	.3286	.3048	.3864	.2402	.1829	.2614	.4001
3		.3125	.3913	.2561	.1867	.2801	.4144
4		.3241	.4064	.2801	.2033	.2829	.4344
5		.3401	.442	.3174	.2614	.2987	.443
6	.3858	.3561	.5401	.3584	.3772	.3584	.4652
7	.4687	.4049	.6327	.3361	.3696	.3584	.6287
8	.4167	.3715	.6874	.3292	.3326	.3109	.8413
9	.1867	.1578	.2126	.7716	.6539	.6836	.197
10	.1928	.1578	.2149	.9259	.7621	.743	.2172
11	.208		.2012	.8916	.7613	.8173	.1991
12	.2103		.1848	.8688	.9762	.8253	.197
13	.2126	.1753	.1646	.7754	.8278	.8288	
14	.197	.1753	.1715	.8177	.719	.743	.2229
15	.1829	.156	.1791	.5563	.6767	.743	.2658
16	.181	.1578	.1907	.4115	.6676	.5681	.208
17	.2012	.1772	.2058	.1791	.1677	.2134	.2743
18	.2172	.197	.2303	.181	.257	.2347	.2865
19	.2218	.2172	.2715	.2743	.2601	.2328	.3734
20	.2402	.2772	.3224	.3142	.3142	.2507	.3292
21	.2427	.2587	.2896	.2926	.2987	.2481	.3292
22	.2195	.2195	.2743	.2926	.2772	.2303	.2926
23	.2824	.4012	.2743	.2772	.2801	.4458	.4607
24	.3384	.2679	.3961	.2561	.2378	.2829	.3948
Max	.4687	.4049	.6874	.9259	.9762	.8288	.8413
Min	.181	.156	.1646	.1791	.1677	.2134	.197
Avg	.2597	.2598	.3194	.4349	.4265	.4377	.3595

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION

Feeder No / Name : 301 / 22 KV NIRA U GFSS

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4854	.5975	.4854	.5601	.5975	.5281
2	.4481	.4854	.5975	.4854	.5601	.5975	.5281
3	.4481	.4481	.5601	.5228	.5228	.5975	.6036
4	.5228	.5228	.5601	.5975	.5975	.5975	.6722
5	.5601	.5601	.6348	.6722	.6722	.6348	.6722
6	.6348	.7842	.7095	.7468	.7095	.6722	.7468
7	.8589	.7842	.8589	.8215	.8215	.8215	.8589
8	.8962	.7842	.8215	.7842	.8962	.5601	.7842
9	.7316	.6348	.7095	.6348	.7468	.7392	.6722
10	.695	.6722	.7095	.6348	.7392	.7762	.6722
11	.6584	.5975	.6722	.5975	.7468	.7392	.6722
12	.5853	.5975	.6348	.6348	.6348	.6653	.6348
13	.6283	.5975	.6348	.5975	.6348	.6283	.6348
14		.5975	.5975	.4854	.5975	.6283	.6348
15	.5914	.5975	.5975	.5601	.5975	.6283	.6348
16	.5975	.6348	.5975	.5975	.5975	.6653	.6348
17	.5975	.6348	.6584	.6348	.6348	.6653	.6348
18	.5975	.5975	.6283	.6348	.5975	.7468	.6722
19	.8589	.8589	.7762	.9335	.7842	.8962	.8589
20	.7842	.8962	.8871	.8962	.8589	.8962	.8962
21	.7468	.8299	.7842	.7842	.7842	.8215	.8962
22	.6722	.7545	.7468	.7095	.7095	.7842	.8215
23	.5975	.6348	.5975	.6348	.6348	.6722	.6722
24	.5228	.5601	.5975	.5601	.5975	.6348	.5975
Max	.8962	.8962	.8871	.9335	.8962	.8962	.8962
Min	.4481	.4481	.5601	.4854	.5228	.5601	.5281
Avg	.6400	.6479	.6737	.6519	.6765	.6944	.6931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION

Feeder No / Name : 302 / 22KV RAKH GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.3734	.3734	
5	.3734	.3734	.3734	.3018	.4108	.3734	.2987
6	.4854	.3734	.5228	.3734	.4854	.4481	.4435
7	.5228	.5228	.5228	.4481	.4854	.4108	.4805
8	.4108	.3361	.3734	.3734	.4108	.3734	.3696
9		.2987	.2987	.2987	.3361	.2957	.2987
10				.2241	.2241		
11				.2218	.1867		
12				.1867	.1867		
13					.2241		
14					.1848		
15				.1867	.2218		
16				.2347	.2241		
17				.2957	.1867		
18	.2987	.2987		.2987	.2172		.3734
19	.2987	.4108	.3734	.4481	.4108	.3734	.4481
20	.4481	.4481	.4481	.4481	.4481	.4481	.4481
21	.3734	.4108	.3734	.3734	.3734	.3734	.3734
22	.2987	.3361	.2987	.3361	.3734	.2987	.3361
23		.2987		.2987			.2987
24				.1029			
Max	.5228	.5228	.5228	.4481	.4854	.4481	.4805
Min	.2987	.2987	.2987	.1029	.1848	.2957	.2987
Avg	.39	.3734	.3983	.3028	.3139	.3768	.3790



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION

Feeder No / Name : 303 / 22KV NIRA (U) AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 22 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3688	.3353	.4024	.3429	2.079	2.0317	
2	.3688	.3353	.4024	.3429	2.0119	1.9662	
3	.3688	.3688	.4024	.4115	2.0119	1.9662	
4	.4024	.3688	.4359	.4748	2.0119	1.9662	
5	.4359	.3688	.4694	.4694	1.9784	1.9334	
6	.503	.4024	.503	.503	1.9784	2.13	
7	.4359	.4359	.4694	.5365	2.3807	2.7199	
8	.4024	.4024	.3353	.4024	2.9508	2.7854	
9	2.3266	2.1795	2.5149	.4024	.3353	.3688	3.0849
10	2.6882		2.8837	.4359	.3688	.3353	3.6549
11	2.915	2.079	3.0849	.4024	.3688	.3391	3.7891
12	2.7206		3.152	.3605	.3018	.373	3.6549
13	2.7854	2.6155	3.1184		.2683		3.8226
14		2.7496	3.1184		.2012		3.6885
15	1.8785	2.5819	2.9843		.2347		3.4202
16	1.9006	2.4478	3.1184		.3353	.4359	4.145
17					.4024	.4694	.3018
18	.2713	.2683	.2713	.3772	.3688	.4694	.3688
19	.3688	.4359	.4409	.4694	.5365	.503	.4694
20	.3688	.4694	.503	.503	.57	.5365	.5365
21	.3688	.4359	.4694	.4694	.5365	.4694	.5365
22	.3688	.4359	.4359	.4359	.503	.4694	.4694
23	.3353	.4024	.4359	2.079	2.13	2.1376	.4694
24	.4024	.3353	.4024	.407	2.079	2.0645	
Max	2.915	2.7496	3.152	2.079	2.9508	2.7854	4.145
Min	.2713	.2683	.2713	.3429	.2012	.3353	.3018
Avg	1.0448	.9740	1.3197	.5171	1.1226	1.2605	2.1608

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION

Feeder No / Name : 304 / 22 KV Mandki Bhairavanth

Expre Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5201	.5258	.5258
2			.4854	.4908	.5258
3			.4854	.4908	.5258
4			.4854	.4908	.5258
5			.5201	.5258	.5201
6			.5201	.5258	.5201
7			.4854	.5258	.5201
8	.3814		.5201	.5258	.5548
9	.4908	.0362	.5201	.5258	.5201
10	.4908	.0351	.5201	.5258	.5201
11	.4908	.0351	.5258	.5201	.5548
12	.4908	.0351	.5258	.5201	.5201
13	.4908	.0351	.5258	.5201	.5201
14		.0351	.5201	.5201	.5601
23		.4854	.5258	.5258	.5201
24			.5201	.5258	.5258
Max	.4908	.4854	.5258	.5258	.5601
Min	.3814	.0351	.4854	.4908	.5201
Avg	.4726	.0996	.5129	.5178	.5287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

NIRA[050]

BU 5878

Substation No/ Name :- 214520 / 33/22 KV NIRA SUBSTATION

Feeder No / Name : 307 / 22KV THOPATEWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2218
2				.1494
3				.1867
4				.1867
5				.2241
6				.2987
7	.2987	.3696	.4024	.3696
8		.2957	.2987	.2987
9		.2957	.3658	.2987
10	.2957	.4024	.4024	.1848
11	.3326		.2987	.3772
12	.4066	.439		.5228
13	.4066			.4481
14		.4024		.4108
15		.2926		.2987
16		.3326	.4755	.5601
17			.2987	.3361
18			.2987	.3361
19			.2987	.2987
20			.3734	.2987
21			.2987	.2987
22			.2987	.2987
23				.1867
24				.1867
Max	.4066	.439	.4755	.5601
Min	.2957	.2926	.2987	.1494
Avg	.3480	.3538	.3425	.3032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 301 / 22 KV PURANDAR AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0983	.0655	.1966		.2846
2	.0754	.0377	.0983	.0655	.1966		.2561
3	.0754	.0377	.0983	.0648	.1966		.2561
4	.0754	.0754	.0983	.0655	.2267		.2881
5	.0754	.0754	.1311	.0983	.2591		.3201
6	.1132	.0754	.1311	.0972	.3163		.3749
7	.1509	.0754	.0972	.0972	.4062		.5487
8	.0754	.1132	.0972	.1296	.506		
9	.2401	.2267	.25	.0754	.0972		.5243
10	.3429	.2267	.2214	.0754	.1311		.6478
11	.3429	.1619	.1898	.0754	.0972	.0648	.6478
12	.3086	.2591	.3086	.0754	.0972	.0972	.5182
13	.3086	.2591	.2846	.0754	.128	.0972	.583
14	.3086		.3479	.0754	.096	.0972	.6478
15	.3429		.3163	.0686	.1296	.1132	.6478
16	.2743	.1029	.3353	.0686		.1341	.679
17	.1029	.1715	.1372	.1029		.1341	.1372
18	.1029	.1029	.1029	.1029		.1341	.1372
19	.1029	.1029	.1029	.1029		.1677	.1029
20	.1029	.1372	.1029	.1417		.1341	.1086
21	.1029	.1029	.0972	.0709		.1677	.1086
22	.0754	.0983	.0983	.2622		.1029	.2321
23	.0754	.0983	.0983	.2267		.3395	.0663
24	.0754	.0754	.0983	.0983	.2214		.3163
Max	.3429	.2591	.3479	.2622	.506	.3395	.679
Min	.0754	.0377	.0972	.0648	.096	.0648	.0663
Avg	.1636	.1223	.1642	.0992	.2064	.1372	.3667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 302 / 22 KV SHIVARI AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2263	.3391	.407	1.6575	.3429	1.6575
2	.3018	.3018	.4024	.4748	1.5424	.3429	1.6575
3	.3018	.3018	.407	.4024	1.5424	.3429	1.6575
4	.3772	.3018	.407	.5087	1.6095	.3429	1.7814
5	.4481	.3772	.503	.5426	1.6385	.3429	1.7814
6	.5975	.5975	.7712	.8048	1.9433	.57	2.1872
7	.7468	.6722	.7712	.8383	2.7206	.5365	2.5
8	.6722	.5975	.6036	.6036	2.8807	.2743	2.4996
9	1.3717	1.0608	1.3108	.4481	.5365	.3353	3.152
10	.9069	1.1603	1.1469	.3772	.4694	.2683	3.3813
11	.9717	1.2452	1.6194	.3018	.4694		3.4145
12	.9717	.852	1.6194	.3772	.4359		2.4577
13	.9717	.9831	1.6385	.3018	.4024		3.1131
14	.9069	1.2452	1.6385	.3018	.4641	.5304	2.4863
15	.8421	1.3108	1.7814	.3429	.4359		3.2769
16	1.0974	1.0688	1.6766	.4115		2.2497	2.8121
17	.4115	.3772	.4458	.3429		2.372	.4161
18	.7545	.4458	.583	.3429		.6371	.5487
19	.5144	.5144	.7545	.4115		.6036	.6173
20	.5144	.6173	.8573	.6516		.6706	.6379
21	.5144	.583	.6859	.5792		.6706	.5487
22	.3772	.5087	.57	.3978		.4458	.6104
23	.2641	.407	.503	1.8107		2.0557	.4748
24	.3018	.2263	.3391	1.3036	1.7695	.3772	1.9662
Max	1.3717	1.3108	1.7814	1.8107	2.8807	2.372	3.4145
Min	.2641	.2263	.3391	.3018	.4024	.2683	.4161
Avg	.6433	.6659	.8906	.5535	1.2824	.7156	1.9015

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 303 / 22 KV KHALAD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.7956	1.0364	.3277	.3018	.2652	.4527
2	.9389	.7956	1.0364	.3239	.3018	.2652	.4024
3	.9389	.7956	.9717	.3239	.3772	.3315	.4024
4	1.0486	.7956	1.0364	.3239	.4527	.3978	.5365
5	1.0486	.7956	1.0364	.3932	.4527	.5304	.5365
6	1.1469	.8288	1.0364	.4915	.4527	.5304	.5365
7	1.3108	1.1469	1.3603	.3887	.5975	.663	.5365
8	1.5546	1.4419	1.5364	.5182	.6036	.5304	.6036
9	.2743	.2591	1.704	1.9433	2.4291	.4858	.3978
10	.2743	.3932	1.6842	2.2024	2.915	.4858	.4973
11	.2743	.2622	1.5729	1.9433	3.2388	.3887	.3978
12	.2743	.2591	1.9433	2.4291	2.8807	2.9447	.3932
13		.2591	1.9433	2.4291	3.0407	3.8744	
14		.2591	1.9433	2.5911	2.8807	4.0619	
15		.3239	1.7814	2.0729	2.8464	3.9533	.4973
16		.4115	1.7071	2.1948		3.5421	.5487
17	.4115	.2743	.4115	.4115		.3932	.5487
18	.4115	.4115	.5487	.4115		.5365	
19	.4115	.4115	.4115	.5487		.5304	.6706
20	.4115	.4115	.5487	.4115		.5304	.7392
21	.4115	.4115	.3887	.4115		.5304	.6859
22	.4527	.3932	.3932	.3932		.6036	.5243
23	.7956	1.1336	.3932	.2622		.6036	2.2672
24	.9945	.7956	1.0364	.3887	.3018	.2652	.4527
Max	1.5546	1.4419	1.9433	2.5911	3.2388	4.0619	2.2672
Min	.2743	.2591	.3887	.2622	.3018	.2652	.3932
Avg	.7190	.5861	1.1442	1.0057	1.5046	1.1352	.6013

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 304 / 22 KV SASWAD U NO 1

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.9335	.9431	.8299	.8589	.8676	.8962
2	.8215	.9335	.8299	.8299	.7842	.8299	.8589
3	.9335	.9335	.8299	.8299	.7842	.8299	.9335
4	1.0456	.9335	.9431	.8299	.8962	.9431	.9335
5	1.1088	.9335	.9431	.9431	.9335	1.1203	.9335
6	1.6461	1.4784	1.4335	1.3203	1.4632	1.307	1.4784
7	1.829	1.6461	1.8107	1.8107	1.6461	1.5684	1.6632
8	1.4632	1.6461	1.5089	1.5089	1.4632	1.5684	1.2936
9	1.267	1.358	1.2936	1.2936	1.3203		1.2071
10	1.1584	1.3203	1.1088	1.1088	1.3203		1.2071
11	1.086	1.1203	1.1088	1.1088	1.1203		1.1203
12	1.086	1.1203	1.1088	1.1088	1.0456	1.4937	1.1203
13	1.086	1.1203	1.1088	1.1088	1.1203	1.1203	1.1203
14	.9774	1.0456	.924	.924	1.0456	1.0456	1.0456
15	.9412	.9709	.9335	1.086	.9709	.961	1.0082
16	.9774	1.0136	.9774	2.0633		1.1203	.9335
17	1.086	1.086	1.086	1.086		1.1203	1.1088
18	1.267	1.3394	1.086	1.1584		1.1203	1.1088
19	1.6289	1.6289	1.5565	1.8099		1.6804	1.6632
20	1.8099	1.8099	1.7375	1.8099		1.6804	1.848
21	1.6289	1.6289	1.5203	1.5203		1.5684	1.4937
22	1.2936	1.5089	1.4335	1.3203		1.307	1.5089
23	1.0349	1.3203	1.1317	1.1317		1.1203	1.2071
24	.9335	.9335	.9431	.9431	.9335	.9709	.9335
Max	1.829	1.8099	1.8107	2.0633	1.6461	1.6804	1.848
Min	.8215	.9335	.8299	.8299	.7842	.8299	.8589
Avg	1.2070	1.2401	1.1792	1.2285	1.1066	1.2068	1.1927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 305 / 22 KV DIWA GOATHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1509	.1886	.1509	.1509	.1509	.1509
2	.1132	.1509	.1886	.1509	.1509	.1509	.1509
3	.1509	.1886	.1886	.1509	.1886	.1509	.1509
4	.1509	.2263	.2263	.1509	.1886	.1886	.1886
5	.1886	.3018	.2263	.1886	.1886	.2263	.1886
6	.3018	.415	.415	.3772	.3018	.3772	.3395
7	.415	.4805	.3772	.415	.3734	.4527	.415
8	.4108	.4066	.3772	.3395	.3018	.415	.3395
9	.2641	.415	.2641	.2641	.3772	.3772	.3018
10	.2263	.3395	.1886	.2263	.3018	.3018	.2641
11	.1886	.3395	.1886	.2263	.1886	.1867	.2641
12	.1509	.2987	.1509		.1886	.1509	.2241
13	.2263	.1867	.1509	.1886	.1867	.112	.1867
14	.1886	.1867	.1509	.1509	.2241	.2614	.2614
15	.1886	.2241	.1509	.1886	.1494	.2263	.1867
16	.1886	.2263	.1509	.1886		.1886	.1886
17	.1886	.2641	.1509	.2263		.2263	.2263
18	.2263	.2641	.1886	.2641		.2263	.2263
19	.3772	.3018	.3018	.3772		.3772	.3395
20	.415	.415	.415	.3772		.4527	.415
21	.3772	.3772	.3772	.415		.3772	.3772
22	.2641	.3395	.3395	.3018		.3018	.3772
23	.2263	.2641	.2641	.1886		.2263	.3018
24	.1132	.1509	.1886	.1886	.1509	.1886	.1886
Max	.415	.4805	.415	.415	.3772	.4527	.415
Min	.1132	.1509	.1509	.1509	.1494	.112	.1509
Avg	.2356	.2881	.2421	.2477	.2257	.2622	.2606



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 306 / 22 KV KHALAD GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.2263	.2263	.2263	.2263	.2641
2	.1886	.1886	.2263	.2263	.2263	.2263	.2641
3	.1886	.2263	.1886		.2641	.2641	.3018
4	.1886	.2641	.1886	.2263	.3018	.3018	.3018
5	.3018	.3018	.2641	.3018	.3018	.3772	.3018
6	.4108	.4527	.5281	.5658	.4481	.5658	.4854
7	.5544	.4904	.6413	.6036	.4854	.7167	.5601
8	.4435	.4527	.4904	.4904	.4108	.5658	.3361
9	.4527	.4527	.3018	.3018	.4527	.415	.415
10	.3395	.3018	.2641	.2641	.3395	.3395	.3018
11	.3018	.2241	.2263	.2263	.3395	.3361	.2241
12	.2641	.2987	.2263	.2641	.2614	.2987	.2614
13	.2641	.2241	.415	.2263	.2614	.2241	.2241
14	.2641	.2614	.4481	.2263	.2263	.2987	.2614
15	.2263	.2614	.4108	.2263	.2987	.3395	.3361
16	.2641	.2641	.3018	.3018		.3772	.2263
17	.2641	.0377	.3018	.3018		.3395	.2263
18	.1509	.3772	.3395	.2641		.2641	.2641
19	.5281	.5281	.4904	.5281		.4904	.415
20	.5658	.6036	.5658	.6036		.6036	.5601
21	.4904	.5281	.5281	.5281		.5281	.4527
22	.3018	.415	.4527	.3772		.3772	.4527
23	.2263	.3018	.3395	.3018		.3018	.3772
24	.1886	.1886	.2263	.2641	.2641	.3018	.2641
Max	.5658	.6036	.6413	.6036	.4854	.7167	.5601
Min	.1509	.0377	.1886	.2263	.2263	.2241	.2241
Avg	.3149	.3264	.358	.3411	.3193	.3783	.3366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 307 / 22 KV SASWAD AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2012	.2835	.0754	.0754	.0754	.0377
2	.2012	.2012	.2804	.0754	.0377	.0754	.0377
3	.1989	.2012	.2804	.0754	.0377	.0754	.0377
4	.1989	.2012	.2743	.0754	.0754	.0754	.0754
5	.1989	.2012	.2743	.1132	.0754	.1132	.0754
6	.2622	.2321	.2774	.1132	.1132	.0754	.1132
7	.2683	.2652	.3429	.1132	.1509	.1132	.1132
8	.3277	.3239	.4115	.1132	.0754	.1509	.1132
9	.1132	.0747	.3277	.4534	.5258	.5258	.0754
10	.0754	.0373	.3605	.4534	.5487	.7545	.0754
11	.0754	.0373	.3932	.583	.503	.6783	.0377
12	.1132	.0373	.4534	.5182	.5304	.6706	.0747
13	.0754	.0373	.3887	.583	.5636	.6554	.0747
14	.0754	.0373	.3887		.5636	.7125	.0747
15	.0754	.7468	.3932	.5182	.5243	.7865	.0747
16	.1132	.0754	.3563	.4858		.7125	.0377
17	.1132	.0754	.1132	.1132		.0754	.0754
18	.0754	.0754	.0754	.1132		.1132	.0377
19	.0754	.0754	.0754	.1132		.1132	.0754
20	.0754	.0754	.1132	.1509		.1132	.0754
21	.1132	.1132	.1132	.1509		.1132	.0754
22	.0377	.0377	.0754	.0754		.0377	.0754
23	.2321	.2804	.0754	.0754		.0377	.4207
24	.2012	.2012	.2804	.0754	.0754	.0754	.0754
Max	.3277	.7468	.4534	.583	.5636	.7865	.4207
Min	.0377	.0373	.0754	.0754	.0377	.0377	.0377
Avg	.1457	.1602	.267	.2268	.2797	.2887	.0850

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 308 / 22 KV PURANDAR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)
1		.2263
2		.1886
3		.1886
4		.2263
5		.2641
6		.3395
7		.3772
8		.2641
9		.3772
10		.3772
11		.2614
12		.2614
13		.2987
14		.2614
15	.4904	.2957
16	.6036	.2263
17	.4904	.2641
18	.679	.3772
19	.7545	.3772
20	.4527	.3772
21	.415	.415
22	.3772	.3772
23	.2641	.3772
24		.2263
Max	.7545	.415
Min	.2641	.1886
Avg	.5030	.3011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 309 / 22 KV SHIVARI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3395	.3018	.3018	.3018	.3018	.3018
2	.2641	.3018	.3018	.2641	.3018	.2641	.3018
3	.3018	.3018	.3018	.2641	.2641	.2641	.3018
4	.3018	.3395	.3395	.2641	.2641	.3018	.3018
5	.3018	.3772	.3772	.3395	.3018	.3018	.3395
6	.3361	.4854	.4527	.415	.415	.3772	.4481
7	.4108	.4854	.5658	.4904	.415	.4904	.4108
8	.3395	.4108	.5281	.4527	.4108	.415	.4108
9	.4904	.679	.3772	.5544	.5658	.6036	.679
10	.679	.679	.415	.7023	.6413	.7545	.8215
11	.7545	.5975	.415	.6653	.7095	.6348	.6722
12	.5658	.5914	.4527	.6653	.5914	.5544	.7468
13	.679	.5544	.3772	.5914	.5544	.4481	.6722
14	.7922	.6283	.415	.7023	.6653	.6348	.6722
15	.679		.4481	.679	.6722		.7468
16	.6413	.679	.4527	.6036		.4854	.5544
17	.5658	.4904	.3395	.5658		.4527	.5228
18	.4904	.3395	.2641	.4527		.4527	.4481
19	.4904	.3772	.415	.6413		.4904	.4481
20	.5658	.4527	.415	.4904		.4904	.5544
21	.4904	.415	.415	.4527		.4527	.4854
22	.4108	.5228	.4527	.4527		.4481	.5658
23	.4108	.3772	.3772	.3772		.415	.4527
24	.2641	.3395	.3772	.3018	.3018	.3395	.3018
Max	.7922	.679	.5658	.7023	.7095	.7545	.8215
Min	.2641	.3018	.2641	.2641	.2641	.2641	.3018
Avg	.4787	.4680	.3991	.4871	.4610	.4510	.5067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 310 / 22 KV SASWAD NO 2

SHEDDABLE URBAN

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.4632	1.6975	1.1317	1.829	.9808	1.1088
2	1.0082	1.4632	1.6975	1.1317	1.4632	.9431	1.1088
3	1.0082	1.4632	1.6975	1.1317	1.4632	.9431	1.2936
4	1.1203	1.6461	1.5089	1.1317	1.5729	1.0185	1.2936
5		1.6461	1.5089	1.3203	1.6461	1.1203	1.4784
6	1.4632	1.9909	1.8861	1.6975	1.829	1.4937	1.4784
7	1.6461	2.0576	2.0748	2.0748	1.829	1.5524	1.6632
8	1.6461	2.0576	1.8861	2.0748	2.0119	1.6632	1.6632
9	2.0576	2.6406	1.6461	2.2291	2.2634	1.8861	2.0748
10	1.9281	2.6139	1.2936	2.4006	2.6139	2.0748	2.0538
11	2.6749	2.8006	1.5364	2.7435	2.9127	2.1658	2.2405
12	2.4691	2.4025	1.1088	2.572	2.8006	1.848	1.8671
13	2.4006	1.6632	1.2936	2.4006		1.1088	1.6804
14	2.4006	1.7741	1.4632	2.572	2.7721	1.2936	1.8671
15	2.4006	2.1437	1.4632	2.572	2.7721	1.307	1.9418
16	2.6406	2.2291	1.3394	2.0271		1.6632	1.848
17	2.4006	2.2977	1.267	2.4006		1.848	1.848
18	2.3529	1.0631	.905	2.4006		1.6804	1.848
19	2.572	1.8099	1.448	2.572		1.848	2.0328
20	2.2291	2.2634	1.6289	2.0576		1.6804	1.848
21	2.332	2.2291	1.6289	2.1262		1.6804	1.6632
22	2.0576	2.2634	1.6975	2.2634		1.4937	1.8861
23	1.9909	2.0748	1.5089	2.0748		1.4784	1.6975
24	1.1088	1.829	1.8861	1.3203	2.0119	1.2323	1.2936
Max	2.6749	2.8006	2.0748	2.7435	2.9127	2.1658	2.2405
Min	1.0082	1.0631	.905	1.1317	1.4632	.9431	1.1088
Avg	1.9573	1.9953	1.5447	2.0178	2.1194	1.5002	1.6991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214424 / 33 KV SASWAD

Feeder No / Name : 311 / 22 KV DIWA AG

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.3018	.3772	.7865	.3772	.6554
2	.2263	.2263	.3018	.3772	.7865	.3772	.663
3	.2263	.3018	.3018	.3772	.7865	.3772	.7293
4	.2987	.3772	.3018	.3772	.7865	.3772	.7865
5	.2987	.3772	.3772	.4527	.7865	.4527	.8192
6	.4481	.4481	.5281	.6036	1.166	.679	1.1012
7	.5975	.5975	.6036	.679	1.9204	.8299	1.4575
8	.5228	.5228	.5658	.6036	2.2138	.7922	1.7284
9	.6478	.7545	.9831	.5975	.5228	.679	1.9204
10	.7011	.8718	1.1336	.5228	.5281	.6036	2.3472
11	.823	.9945	1.2955	.4481	.5228	.5228	2.0119
12	.9259			.4481	.4481	1.0174	2.2939
13	.8421	1.1142	.9717	.4481	.4481	1.4746	1.7238
14	.6478	1.1142	1.4575	.4481	.3734	1.7604	1.989
15	.4858	1.1142	1.2955	.4527	.4481	2.0081	1.9433
16	.5182	.9069	1.1584	.4904		.8215	
17	.3018	.5506	.415	.5281		.4904	.4481
18	.6036	.3772	.4527	.5658		.3429	.4481
19	.679	.4527	.5281	.679		.5601	.5228
20	.679	.6036	.5658	.679		.679	.5228
21	.5281	.5658	.5658	.5658		.5601	.4481
22	.4481	.3772	.4527	.4344		.4481	.4527
23	.4481	.3772	.3772	.8859		.7209	.3772
24	.2263	.2263	.3018	.3772	.8192	.4527	.7209
Max	.9259	1.1142	1.4575	.8859	2.2138	2.0081	2.3472
Min	.2263	.2263	.3018	.3772	.3734	.3429	.3772
Avg	.5146	.5860	.6624	.5174	.8340	.7252	1.1352

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 201 / 11 KV BABAWADI

SINGLE PHASING

SINGLEPHASING Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.168	.2427	.1886	.2263	1.3435	1.6617
2	.2402	.1698	.2427	.2054	.2263	1.3125	1.6108
3	.2427	.1886	.2641	.2263	.2452	1.2654	1.5746
4	.2427	.2054	.2641	.3018	.2641	1.4091	1.6078
5	.2801	.2829	.2801	.3395	.3174	1.4723	1.6549
6	.4066	.3961	.2987	.415	.3881	1.5729	1.6876
7	.4108	.3584	.3142	.3584	.3881	1.6549	2.0729
8	.2957	.3206	.2801	.2987	.4066	1.8187	2.13
9	1.0802	.8905	1.3889	1.2186	1.4232	.2241	.2743
10	1.1469	1.2071	1.5261	1.5364	1.6448	.1823	.2801
11	1.1305	1.0155	1.543	1.6964	1.8233	.2075	.2614
12	1.0978	1.2449	1.6289	1.6804	1.9559	.1886	.2614
13	1.1469	1.0883	1.6448	1.7532	2.0576	.2452	.2427
14	1.1633	1.1248	1.6108	1.7236	2.0056	.2241	.2241
15	1.0322	1.1069	1.56	1.5729	2.0056	.1886	.2614
16	.9503	1.3957	1.4918		2.0576		.2241
17	.2263	.2263	.2452	.1638	.2587	.2054	.2614
18	.2263	.2641	.2241	.2534	.2452	.2427	.2641
19	.3734	.2829	.2641	.2801	.2641	.2801	.2829
20	.3395	.2772	.3734	.3174	.3547	.2987	.3584
21	.2987	.2772	.3206	.2801	.3018	.2987	.2883
22	.2829	.2772	.3174	.2614	.2614	1.0534	.2829
23	.1886	.2614	.2829	.2614	1.2492	1.6975	1.5844
24	.2772	.1886	.2614	.2614	.2614	1.5655	1.7147
Max	1.1633	1.3957	1.6448	1.7532	2.0576	1.8187	2.13
Min	.1886	.168	.2241	.1638	.2263	.1823	.2241
Avg	.5560	.5508	.7029	.6780	.8597	.8240	.8778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 202 / 11 KV MALSHIRAS

SINGLE PHASING

SINGLEPHASING Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.2881	.4908	.6316	.7545	.4696	.3734
2	.3856	.3277	.4973	.6478	.8139	.4534	.3734
3	.3544	.3401	.5087	.7042	.8478	.5138	.3547
4	.3761	.3605	.5765	.8029	.8648	.5407	.3982
5	.3856	.3887	.7042	.8951	.8333	.6539	.5914
6	.4481	.4321	.9431	1.0722	1.0513	.7888	.9593
7	.6952	.6802	1.1317	1.278	1.5581	.8817	.9511
8	.8648	.8848	1.2378	1.4723	1.6575	.6062	.7316
9	.4481	.3361	.4108	.3239	.4294	1.3441	1.5604
10	.3961	.2949	.2987	.3681	.3547	1.5939	1.5775
11	.3772	.3401	.2987	.3113	.3547	1.4419	1.5432
12	.3395	.2785	.2801	.3239	.3361	1.3763	1.4922
13	.3206	.2561	.2801	.3361	.3547	1.3763	1.4752
14	.3206	.2753	.2987	.3725	.3361	1.3117	1.4255
15	.3395	.2591	.3361	.3277	.3547	1.4251	1.4746
16	.3584	.2785	.3881		.3547		1.531
17	.2949	.3277	.3605	.3441	.3881	.3841	.3174
18	.421	.4854	.2591	.4435	.407	.4251	.3734
19	.664	.7282	.5668	.7207	.6154	.6653	.6554
20	.7611	.7842	.7362	.8501	.7701	.7865	.7701
21	.6718	.7023	.6478	.8131	.7209	.7682	.6722
22	.5992	.6283	.5761	.7207	.6401	.6767	.6687
23	.2881	.499	.6401	.7202	.5441	.5914	.5243
24	.4066	.3041	.5014	.6241	.7373	.4915	.462
Max	.8648	.8848	1.2378	1.4723	1.6575	1.5939	1.5775
Min	.2881	.2561	.2591	.3113	.3361	.3841	.3174
Avg	.4548	.4367	.5404	.6567	.6700	.8507	.8857



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 203 / 11 KV RISEPISE SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2713	.3155	.3429	.3982	.2915	.3696
2	.2743	.2915	.3258	.3772	.394	.3086	.3361
3	.2804	.3467	.3475	.4508	.4163	.2713	.3174
4	.3077	.4557	.362	.5028	.4382	.3294	.3511
5	.3224	.5375	.4382	.5784	.4973	.4207	.3696
6	.3429	.5721	.5028	.7122	.6859	.4854	.6838
7	.583	.6068	.6859	.8059	.9116	.5434	.695
8	.583	.6068	.6783	.8764	.7625	.3391	.6653
9	.3326	.2743	.3326	.2543	.2987	.7202	.6859
10	.2829	.2713	.2957	.2279	.3361	.7362	.7468
11	.2641	.2601	.2957	.2543	.3174	.6783	.6516
12	.2452	.208	.2801	.2229	.2987	.6952	.6274
13	.2263	.1734	.2772	.2427	.2987	.7011	.7095
14	.2263	.1907	.2957	.208	.2801	.6859	.6687
15	.2263	.2058	.2772	.2454	.3174	.7011	.6478
16	.2263	.1886	.2772		.3174		.663
17	.2743	.2254	.2035	.2454	.3511	.2572	.2486
18	.2572	.3109	.2572	.2835	.2629	.3174	.2713
19	.3856	.5487	.3429	.5601	.3988	.5175	.3641
20	.4161	.6401	.5201	.7095	.4733	.6401	.4458
21	.3856	.5853	.4854	.5601	.4527	.5853	.4207
22	.3258	.5544	.3988	.5228	.3561	.5487	.3988
23	.298	.333	.39	.4294	.3086	.4755	.333
24	.3326	.2915	.3403	.3641	.4115	.2774	.3881
Max	.583	.6401	.6859	.8764	.9116	.7362	.7468
Min	.2263	.1734	.2035	.208	.2629	.2572	.2486
Avg	.3211	.3729	.3719	.4338	.4160	.5012	.5025

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 204 / 11 KV BHULESHWAR 3 PHASE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.2092	.5175	.4428	.5228	.6327	.8478
2	.499	.2389	.5041	.4696	.5041	.6097	.8139
3	.4854	.3721	.4668	.5304	.5415	.7537	.788
4	.5228	.4024	.5041	.6371	.5914	.9555	.8215
5	.5975	.5729	.6468	.6554	.7023	1.094	.8951
6	1.0164	.6401	1.0164	.8322	.924	1.3108	1.3923
7		.5853	.961	.5841	.8501	1.5402	1.9662
8	.8316	.4755	.5544	.3544	.7392	1.8484	1.9227
9	.6859	.5853	.7716	.873	1.1145	.3521	.462
10	.7373	.5575		1.0155	1.166		.499
11	1.1469	.5719		1.0155	1.2887		.4477
12	.5898	.6308		1.0595	1.3395	.3725	.4435
13	.5571	.6935	1.0288	.9877	1.3717	.2778	.3696
14	.5243	.5144	1.0288	.9907	1.3735	.2366	.3326
15	.4915	.5575	1.0117	.9755	1.3757	.2515	.4435
16	.4424	.7613	1.0174		1.4243		
17	.2281	.2353	.3149	.3982	.5121	.2926	.5228
18	.1337	.5041	.431	.5601	.4359	.3326	.4557
19	.4294	.7164	.5218	.8402	.5376	.695	.57
20	.1749	.961	.6882	1.0164	.6249	.9955	.7865
21	.1974	.8316	.6249	.924	.6133	.823	.6464
22	.1905	.7392	.503	.8316	.5407	.7392	.5243
23	.2058	.6653	.5079	.6468	.6554	.8573	.9061
24	.5544	.2126	5.7507	.4752	.5914	.6554	.8573
Max	1.1469	.961	5.7507	1.0595	1.4243	1.8484	1.9662
Min	.1337	.2092	.3149	.3544	.4359	.2366	.3326
Avg	.5113	.5514	.9225	.7442	.8475	.7441	.7702

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 205 / 11 kV RAJURI SINGLE

SINGLE PHASING

PHASING Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.2623	.3258	.3795	.4115	.3361	.3921
2	.3506	.2846	.3258	.3768	.4344	.3921	.3547
3	.3086	.3125	.3582	.431	.4477	.3772	.3547
4	.3086	.4917	.3681	.4917	.5194	.415	.3696
5	.3429	.5658	.4409	.7602	.5609	.5847	.5914
6		.7468	.6859	.9145	.6859	.7167	.8688
7		.9694	.9431	1.1104	1.094	.811	.8779
8		.8059	.8478	1.1269	1.2012	.679	.6584
9		.6979	.5144	.6602	.5544	.8817	.7716
10		.5415	.3429	.4338	.4668	.8551	.823
11	.3395	.4108	.362	.3772	.4108	.8951	.8573
12	.3772		.3292	.3584	.3395	.9054	.9431
13	.3961	.3174	.3326	.3361	.3174	.9709	.823
14		.2614	.2772	.3361	.2987	.9431	.8402
15	.3395	.2801	.2587	.2957	.3174	.5801	.6859
16	.3018	.2801	.2402		.3361		.7716
17	.4066	.2429	.3292	.3601	.3547	.3326	.3734
18	.5975	.4049	.4854	.4668	.3881	.462	.4344
19	.6908	.695	.679	.7468	.6602	.6468	.679
20	.6602	.8871	.7545	.8962	.7922	.924	.7842
21	.4755	.8131	.7167	.6468	.6535	.7762	.6602
22	.4251	.7207	.5658	.6468	.5658	.6838	.5658
23	.2881	.3582	.431	.3772	.5041	.462	.4338
24	.3506	.2812	.3258	.3681	.3772	.3772	.4066
Max	.6908	.9694	.9431	1.1269	1.2012	.9709	.9431
Min	.2881	.2429	.2402	.2957	.2987	.3326	.3547
Avg	.4065	.5057	.4683	.5608	.5288	.6525	.6384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214437 / 33 KV PISAWARE

Feeder No / Name : 206 / 11 KV Mavadi/Pimpari

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.1629	.2241	.2195	.2614	.3113	.2572
2	.2427	.1791	.2263	.2587	.2427	.3441	.2572
3	.2614	.197	.2452	.2926	.2614	.3315	.2883
4	.2614	.2743	.2452	.3018	.3326	.3521	.3222
5	.3142	.4108	.3361	.3584	.3696	.4409	.3647
6	.499	.5658	.5601	.3772	.5359	.4973	.503
7	.5359	.547	.5359	.4481	.462	.5375	.6226
8	.4066	.415	.3921	.3921	.4066	.547	.5304
9	.3944	.3932	.5316	.4475	.5487	.2957	.2772
10	.3605	.3637	.4801	.4372	.5487	.2957	.2587
11	.3441	.3281	.4287	.431	.5087	.2614	.2427
12	.3277	.4012	.4287	.3932	.4917	.2402	.2241
13	.3113	.3612	.2401	.3978	.4801	.2561	.2427
14	.2949	.3704	.4115	.3681	.4917	.2402	.2614
15	.3113	.3593	.4115	.3401	.4973	.2012	.2801
16	.3605	.4572	.4287		.5087		.2957
17	.2172	.2328	.2126	.1886	.2402	.2561	.2987
18	.3292	.3142	.2743	.2896	.2926	.2614	.2774
19	.4294	.4525	.3881	.3841	.2402	.4294	.3881
20	.2801		.4755	.439	.5041	.4481	.4481
21	.2926	.4108	.4435	.3696	.4435	.4066	.4066
22	.2772	.3361	.3511	.3326	.3921	.3881	.3142
23	.1829	.2614	.2772	.2772	.3475	.2572	.3052
24	.2587	.1791	.2427	.2378	.2587	.2652	.2743
Max	.5359	.5658	.5601	.4481	.5487	.547	.6226
Min	.1829	.1629	.2126	.1886	.2402	.2012	.2241
Avg	.3222	.3467	.3663	.3470	.4028	.3419	.3309

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214540 / 33 KV Bopgaon

Feeder No / Name : 301 / 22 KV Garade Gaothan

GAOTHAN FEEDER

Feeder KV- 22 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	1.0185	1.1317	1.2071	1.1317	1.2449	.9431
2	1.1317	1.0185	1.1317	1.1694	1.1317	1.2071	.9431
3	1.1317	1.0185	1.1317	1.1317	1.094	1.1694	.9431
4	1.094	1.0185	1.5089	1.2071	1.094	1.2071	1.1317
5	1.3203	1.5089	1.8861	1.5466	1.4335	1.4712	1.5089
6	2.1125	1.9993	2.2634	2.2257	2.1502	2.2634	1.8861
7	2.2634	2.1879	2.2634	2.3011	2.452	2.3388	1.8861
8	2.037	1.8861	1.8861	1.8107	2.037	2.0748	1.5089
9	1.8861	1.6975	1.7353	1.6598	1.7353	2.0748	1.3957
10	1.4335	1.8861	1.4712	2.1125	1.6975	1.8861	1.3203
11	1.358	1.5089	1.1694	2.037	1.6598	1.6975	1.2826
12	1.8484	1.5089	1.2071	1.7353	1.4335		1.1317
13	1.4335	1.5089	1.1317	1.6221	1.2449		1.094
14	1.1694	1.1317	.9808	1.1694	1.3203		.9808
15	1.5466	1.1317	1.1317	1.2826	1.1694		.9054
16	1.0562		1.1694	1.358	1.2449	.9431	.9808
17	1.8861	1.3203	1.2449	1.2826		1.1317	1.1317
18	1.5089	1.6975	1.6221	1.5844		1.1317	1.3203
19	1.9616	2.0748	1.9239	1.9993	1.7353	1.8861	1.6598
20	2.037	2.0748	2.1125	2.037	2.3388	1.8861	1.7353
21	1.773	1.8861	1.9616	1.9616	1.9616	1.5089	1.5844
22	1.358	1.5089	1.6598	1.5466	1.6975	1.3203	1.3203
23	1.094	1.1317	1.2826	1.2071	1.3203	.9431	.9808
24	1.1317	1.0562	1.1317	1.2826	1.1694	1.2071	.9431
Max	2.2634	2.1879	2.2634	2.3011	2.452	2.3388	1.8861
Min	1.0562	1.0185	.9808	1.1317	1.094	.9431	.9054
Avg	1.5278	1.5122	1.5058	1.6032	1.5569	1.5297	1.2716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214540 / 33 KV Bopgaon

Feeder No / Name : 302 / 22 KV Kodit Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2561	.3467	.4435	.3018	.415	.1886
2	.3772	.2622	.3467	.4066	.3018	.4527	.1886
3	.4108	.2622	.3467	.3696	.3018	.4527	.1886
4	.3696	.2622	.3467	.4066	.2641	.415	.3018
5	.439	.3429	.4161	.4706	.3395	.5281	.3772
6	.6516	.4557	.4508	.6024	.415	.7545	.4904
7	.7087	.583	.5895	.6516	.5281	.679	.4904
8	.7202	.6859	.6588	.7773	.3395	.5658	.4527
9	.4527	.1886	.2641	.583	.6958	1.2071	.3772
10	.4527	.3395	.3018	.9431	.8421	1.326	.3018
11	.415	.3018	.3772	.7865	.9922	1.1336	.2641
12	.3772	.3018	.2641	.9175	1.1069		.3018
13	.3395	.2641	.2641	.7407	1.1248		.3018
14	.2641	.1886	.3018	.7811	.9374		.415
15	.3018		.2641	.7186	.9998		.2641
16	.3018		.2641	.7922	1.0059	1.2193	.2641
17	.3018	.1886	.2641	.2641	.2641	1.2955	.4527
18	.3395	.3018	.2641	.2641	.2641	.9717	.4527
19	.4527	.3772	.3772	.3772	.3395	.8383	.3395
20	.415	.415	.415	.3772	.415	.3772	.3772
21	.3395	.3772	.3772	.3772	2.037	.3395	.3772
22	.3018	.3018	.3395	.3395	1.9993	.3018	.3395
23	.2915	.3563	.4435	.2641	1.9616	.1886	.6299
24	.415	.3201	.3467	.4024	.2641	.4527	.1886
Max	.7202	.6859	.6588	.9431	2.037	1.326	.6299
Min	.2641	.1886	.2641	.2641	.2641	.1886	.1886
Avg	.4090	.3333	.3596	.5440	.7517	.6957	.3469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SASWAD[047]

BU 5801

Substation No/ Name :- 214540 / 33 KV Bopgaon

Feeder No / Name : 303 / 22 KV Bhiwari Ag

Feeder KV- 22 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3018	.3772	.3395	.4458	.4066	.4557
2	.3395	.3018	.3772	.3395	.4458	.4481	.4557
3	.3395	.3018	.3772	.3395	.4409	.4435	.4908
4	.3772	.3395	.5658	.3395	.3978	.4108	.4908
5	.4527	.5281	.6413	.4527	.5636	.6584	.6379
6	.679	.6413	.679	.6413	.7796	.8238	.7442
7	.7167	.7167	.679	.7167	1.0402	.9816	.815
8	.5658	.6036	.5658	.5658	1.0402	1.0174	.8573
9	.5895	.4915	.5959	.3772	.4904	.415	.9282
10	.6413	.503	.5487	.3018		.3772	1.358
11	.5121	.5087	.5761	.3018	.3018	.3018	
12	.5182	.5121	.4374	.3018	.3395		1.1694
13	.4915	.5182	.2984	.2641	.3018		1.1012
14	.4588	.4938	.373	.3018	.3395		1.0753
15	.4588	.1886	.3772	.2641	.3395		1.0437
16	.3277		.4115	.3018	.3395	.3018	1.1069
17	.3018	.1886	.3395	.3772	.3395	.4527	.3018
18	.3395	.3772	.415	.3395	.3395	.4904	.3395
19	.4904	.5658	.4904	.4904	.5281	.6036	.4904
20	.5658	.5658	.5658	.5658	.6036	.6036	.5281
21	.4527	.4527	.5658	.5281	.5281	.5281	.4904
22	.3772	.415	.4527	.415	.4527	.4527	.415
23	.3395	.3772	.3772	.4527	.4024	.4557	.3395
24	.3395	.3018	.3772	.3395	.4115	.439	.4557
Max	.7167	.7167	.679	.7167	1.0402	1.0174	1.358
Min	.3018	.1886	.2984	.2641	.3018	.3018	.3018
Avg	.4589	.4432	.4777	.4024	.4874	.5306	.6996

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 201 / 11 KV Vadhane AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5182	.6097	.2915	.3391	.3582	1.166
2	.4572	.5335	.6097	.3239	.3149	.3582	1.2308
3	.4725	.5335	.7621	.3563	.2883	.3582	1.2955
4	.6554	.5487	.9145	.3239	.4915	.4119	1.3279
5	.7621	.5944	.9907	.3563	.7122	.6201	1.3603
6	.8383	.6706	1.0669	.421	.7969	.7712	1.4251
7	.9145	.5639	1.1431	.5182	.6783	.6859	1.4575
8	.9907	.8535	1.2193	.5087	.5426	.5258	1.6194
9	.2439	.2286	.2713	1.17	1.2616	1.4575	.3258
10	.2534	.1981	.2374	1.1633	1.2193	1.4899	.2896
11	.2172	.1829	.2204	1.1305	1.2193	1.4575	.2865
12	.1448	.1829	.2035	1.1869	1.2193	1.4251	.2865
13	.1448	.2134	.2374	1.2039	1.2193	1.4899	.2865
14	.181	.2286	.2713	1.3094	1.2193	1.2955	.2865
15	.2172	.2286	.2105	1.2887	1.2193	1.2308	.2629
16	.2353	.2439	.1943	1.2146	1.2193	1.4575	.2279
17	.2353	.2591	.2915	.1865	.2865	.3887	.2715
18	.3258	.2896	.3239	.2949	.3439	.421	.362
19	.4477	.3048	.3887	.5243	.5068	.4534	.5068
20	.5373	.3353	.3239	.5765	.7011	.4858	.6516
21	.4298	.4268	.2915	.6443	.6447	.5182	.5609
22	.3982	.3963	.2591	.4409	.5552	.7042	.5068
23	.4725	.4877	.3239	.3605	.4477	.8097	.7316
24	.4877	.5182	.5487	.3239	.3391	.3761	1.1736
Max	.9907	.8535	1.2193	1.3094	1.2616	1.4899	1.6194
Min	.1448	.1829	.1943	.1865	.2865	.3582	.2279
Avg	.4383	.3975	.4964	.6716	.7411	.8146	.7458



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 202 / 11 KV Supa Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.373	.3801	.4458	.3563	.5087	.4344	.3239
2	.373	.3801	.5087	.3239	.4917	.4344	.2915
3	.3429	.3801	.6173	.2915	.4973	.4344	.3239
4	.3772	.4344	.7888	.2591	.5935	.4887	.3887
5	.4458	.6516	.8573	.3887	.7969	.6268	.4534
6	.5144	.8764	.9496	.4858	.8383	.8413	.8421
7	.9431	.9114	.8916	.8097	.7969	.9465	.9069
8	.8573	.724	.7202	.8309	.7373	.7602	.7449
9	.5316	.4458	.5087	.5256	.6443	.3239	.5373
10	.4525	.3772	.407	.4239	.4525	.3887	.4706
11	.362	.3086	.4239	.3768	.362	.3563	.4298
12	.362	.1543	.2591	.373	.3439	.3239	.3982
13	.362	.3429	.2915	.3768	.3439	.2591	.3582
14	.3439	.3429	.3239	.3149	.362	.1619	.3582
15	.3258	.3258	.3401	.3391	.362	.1943	.3506
16	.3258	.3601	.3563	.3561			.3506
17	.362	.3429	.5182	.4144	.4298	.3563	.3801
18	.5611	.3772	.583	.5243	.4835	.3887	.4344
19	.7602	.39	.8421	.7209	.7602	.4534	.7522
20	.7964	.4973	.3239	.7122	.8596	.4858	.8596
21	.6154	.6516	.3563	.6783	.724	.5182	.724
22	.4344	.5487	.3887	.6443	.5731	.3563	.543
23	.3982	.4801	.421	.6274	.4706	.3887	.4344
24	.4115	.3801	.4115	.3887	.5426	.4344	.3563
Max	.9431	.9114	.9496	.8309	.8596	.9465	.9069
Min	.3258	.1543	.2591	.2591	.3439	.1619	.2915
Avg	.4846	.4610	.5223	.4809	.5641	.4503	.5005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 203 / 11 KV Baburdi Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.125	.1219	.3239	.2984	.2743	.1457
2	.1067	.1219	.1524	.3563	.3391	.2743	.1457
3	.1067	.1219	.1829	.3887	.4239	.2743	.1296
4	.1524	.1406	.2134	.4858	.5087	.3048	.1296
5	.2134	.1875	.2439	.5182	.5935	.381	.1619
6	.2743	.2968	.2743	.5506	.6443	.5792	.1943
7	.3048	.2812	.2896	.7773	1.0513	.9755	.2591
8	.3048	.2187	.2743	.8907	1.1305	1.1584	.1943
9	.381	.3048	.5087	.1658	.1802	.1457	1.0974
10	.2286	.3201	.5256	.1475	.1094	.1296	1.1584
11	.1981	.2743	.6154	.1696	.0937	.0648	1.0974
12	.2439	.3048	.4858	.1638	.0937	.081	1.0669
13	.2439	.3353	.5182	.1134	.0937	.0972	1.0669
14	.2286	.4268	.583	.1017	.0937	.0648	1.0364
15	.2134	.4877	.5344	.1311	.0937	.081	.9145
16	.1829	.7316	.5182	.1526	.0625	.1296	.8535
17	.0781	.1524	.1943	.1696	.125	.1134	.125
18	.1406	.1524	.1619	.1865	.1562	.1296	.1406
19	.2031	.1677	.1943	.213	.2187	.1457	.2187
20	.2187	.1829	.1943	.2374	.2187	.1619	.2343
21	.2031	.1829	.2267	.2374	.1875	.1943	.2031
22	.1562	.1524	.2429	.2155	.1875	.1619	.1875
23	.1406	.1372	.2591	.2713	.2743	.1943	.1875
24	.1219	.125	.1067	.2915	.3052	.2743	.1619
Max	.381	.7316	.6154	.8907	1.1305	1.1584	1.1584
Min	.0781	.1219	.1067	.1017	.0625	.0648	.125
Avg	.1987	.2472	.3176	.3025	.3118	.2663	.4629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 204 / 11 KV Chandugadewadi Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1715	.0914	.0972	.1696	.1619	.1457
2	.0914	.1715	.1067	.1296	.1526	.1619	.1296
3	.0762	.1715	.1219	.1296	.1526	.1619	.1134
4	.061	.1715	.1372	.1134	.1696	.1619	.0972
5	.0762	.1905	.1524	.0972	.1696	.1781	.0972
6	.0914	.2195	.1829	.081	.2155	.2401	.1619
7	.1219	.2012	.1524	.1943	.213	.25	.1943
8	.1219	.1791	.1372	.2374	.2204	.2439	.1619
9	.1372	.1524	.1017	.0848	.0905	.0972	.2343
10	.1134	.1524	.0678	.0655	.0724	.0972	.25
11	.1134	.1524	.0486	.0655	.0724	.0648	.2968
12	.081	.1677	.0648	.0486	.0543	.081	.3048
13	.081	.1677	.081	.0339	.0543	.0972	.3048
14	.081	.1677	.0972	.0509	.0716	.0486	.3048
15	.081	.1829	.081	.0324	.0716	.0648	.3048
16	.0972	.1981	.0648	.0509	.1254	.0648	.3048
17	.0724	.0762	.0972	.0509	.0724	.0648	.0724
18	.1267	.0914	.1134	.1475	.0905	.1311	.0724
19	.181	.0914	.1296	.1802	.1448	.1457	.1448
20	.1991	.1067	.0648	.2035	.2103	.1677	.2172
21	.2172	.1524	.0648	.1966	.181	.1943	.181
22	.181	.1524	.081	.2035	.1448	.1619	.1448
23	.181	.1372	.0972	.1865	.1619	.1619	.1075
24	.1067	.1646	.1372	.0972	.1696	.1619	.1457
Max	.2172	.2195	.1829	.2374	.2204	.25	.3048
Min	.061	.0762	.0486	.0324	.0543	.0486	.0724
Avg	.1159	.1579	.1031	.1158	.1354	.1402	.1872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 205 / 11 KV Supa Ag Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3801	.3887	.2035	.2713	.2172	.7865
2	.3353	.3801	.421	.2374	.2883	.2172	.8097
3	.3048	.3801	.4858	.2713	.2713	.2172	.9069
4	.3353	.4163	.5426	.3052	.3052	.2353	.9393
5	.3658	.4706	.6613	.3315	.3391	.2715	1.004
6	.3963	.4877	.8139	.3521	.407	.4344	1.0364
7	.4572	.6097	.7935	.407	.3932	.5609	1.166
8	.5182	.6097	.852	.3725	.407	.4207	1.2308
9	.2715	.181	.2035	1.0774	.8139	.3239	.2715
10	.1448	.1991	.1638	1.1271	1.0974	1.166	.2353
11	.0905	.181	.1357	1.17	1.2193	1.0364	.2149
12	.0905	.1991	.1147	1.1336	1.2193	1.1336	.181
13	.0905	.2172	.1357	1.1174	1.2193	1.166	.1075
14	.0905	.181	.1475	.9326	1.0974	1.004	.1052
15	.0905	.1629	.1357	.9835	.9755	1.0364	.1075
16	.1086	.1629	.1147	.9717	.9755	1.1336	.1433
17	.1448	.181	.0983	.1526	.2149	.1619	.1791
18	.2172	.2172	.1017	.1966	.2507	.1943	.2715
19	.362	.2353	.3391	.3239	.4344	.2267	.4344
20	.362	.2534	.1357	.3113	.4344	.2429	.3982
21	.2353	.3258	.1526	.3052	.2896	.2591	.3258
22	.2172	.2896	.1696	.2984	.2534	.4858	.2534
23	.362	.3982	.1943	.2883	.2172	.5182	.4877
24	.3963	.362	.3887	.1696	.2883	.2172	.6478
Max	.5182	.6097	.852	1.17	1.2193	1.166	1.2308
Min	.0905	.1629	.0983	.1526	.2149	.1619	.1052
Avg	.2647	.3117	.3204	.5433	.5701	.5367	.5102

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 206 / 11 KV Baburdi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0762	.081	.1357	.0905	.1134
2	.0762	.0953	.0914	.081	.1187	.0905	.1134
3	.0762	.0953	.1219	.0972	.1187	.0905	.0972
4	.0914	.1334	.1372	.1134	.1696	.1086	.0972
5	.1372	.1715	.1524	.1296	.1865	.1629	.1134
6	.1524	.2286	.1829	.1457	.2204	.2454	.1296
7	.1829	.2378	.1524	.1296	.1696	.2103	.1296
8	.1981	.1448	.1219	.1311	.1017	.1629	.0972
9	.1524	.0914	.0509	.0509	.0972	.1296	.0905
10	.0905	.0762	.0497	.0492	.1086	.0648	.0724
11	.0543	.061	.0486	.0509	.0724	.0486	.0905
12	.0362	.0457	.0486	.0339	.0543	.0486	.0526
13	.0362	.0457	.0324	.0497	.0543	.0648	.0526
14	.0362	.0457	.0486	.0332	.0543	.0486	.0526
15	.0543	.0457	.0486	.0324	.0543	.0486	.0543
16	.0543	.061	.0486	.0509	.0537	.0648	.0543
17	.0724	.0762	.0648	.0509	.0905	.0648	.0543
18	.1086	.061	.081	.0848	.1086	.081	.0905
19	.181	.0762	.1006	.1357	.181	.0972	.181
20	.1629	.1219	.081	.1357	.181	.1134	.181
21	.1086	.1372	.0648	.1357	.1448	.1296	.1448
22	.0905	.1067	.0972	.1296	.1075	.1134	.1086
23	.0953	.0914	.081	.1311	.0905	.0648	.0905
24	.0762	.0953	.0914	.081	.1357	.0905	.081
Max	.1981	.2378	.1829	.1457	.2204	.2454	.181
Min	.0362	.0457	.0324	.0324	.0537	.0486	.0526
Avg	.1000	.1017	.0864	.0893	.1171	.1014	.0976

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214422 / 33/11 KV SUPA

Feeder No / Name : 207 / 11 KV Dandwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1463	.12	.5182	.3222	.381	.1619
2	.1372	.1463	.1372	.5506	.3391	.381	.1943
3	.1372	.1524	.1696	.583	.3391	.381	.2267
4	.1543	.1646	.2401	.6154	.5426	.4572	.2591
5	.1715	.2012	.2743	.6478	.7969	.5335	.2915
6	.2058	.2926	.3258	.6802	.8817	.7621	.3239
7	.2572	.2743	.3086	1.0526	1.0513	.9145	.2429
8	.2915	.2353	.3086	1.0978	1.3056	.9602	.2267
9	.6443	.4115	.6613	.1619	.1865	.1457	1.3717
10	.4877	.4409	.7122	.1357	.2172	.1619	1.5242
11	.4115	.4748	.8097	.1187	.2172	.1457	1.7223
12	.381	.5487	.8745	.1187	.2172	.1619	1.7528
13	.381	.583	.8097	.1357	.2172	.1943	1.7528
14	.4572	.5487	.8745	.0995	.2172	.1619	1.768
15	.503	.4801	.9069	.1017		.1457	1.7375
16	.5335	.5144	.8907	.1187			1.6918
17	.1629	.1886	.2267	.1357	.197	.1457	.2534
18	.1991	.1696	.1943	.1823	.1991	.1619	.2715
19	.2353	.1865	.2267	.2294	.2534	.1943	.2896
20	.2353	.2401	.2591	.2543	.298	.2267	.3077
21	.1991	.1886	.2753	.2543	.2896	.2429	.2896
22	.1448	.1696	.2915	.2374	.2534	.1457	.2534
23	.1463	.1543	.4534	.2949	.3658	.1296	.181
24	.1543	.1448	.1372	.4858	.3052	.381	.1457
Max	.6443	.583	.9069	1.0978	1.3056	.9602	1.768
Min	.1372	.1448	.12	.0995	.1865	.1296	.1457
Avg	.2827	.2941	.4370	.3671	.4097	.3268	.7183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 201 / 11 KV Murti single SINGLE PHASING  
phasing Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.431	.2614	.2267	.2987	.5053
2	.3772	.4161	.2614	.2267	.2987	.5053
3	.4115	.4161	.2614	.2267	.2987	.5053
4	.4458	.4755	.2801	.2591	.3361	.535
5	.4801	.5647	.3361	.2949	.4668	.6539
6	.6173	.6836		.2949	.6161	.8619
7	.7888	.7876	.5788	.2949	.5975	1.07
8	.6859	.8025	.4115	.2622	.4481	1.07
9	.2401	.2054		.6859	.8619	.2172
10	.2058	.168	.823	.8431	1.0105	.2195
11		.1494	1.4575	.8215	1.0105	.2534
12	.2401	.1494	1.5775	.8802	.9214	.1303
13		.1307	1.6118	.8716	.8322	.1254
14		.1307	1.6118	.8977	.8619	.1254
15		.1494	1.6289	.9122	.8619	.1448
16		.1494	1.6461	.9242	.8916	.1646
17		.1867	.2401	.1457	.2241	.168
18		.2241	.2743	.1943	.2614	.2218
19		.3361	.3086	.3605	.3361	.4108
20		.4481	.3772	.426	.4481	.3734
21		.3921	.3429	.3725	.4108	.3961
22		.3361	.3086	.3077	.3734	.3734
23	.3429	.2801	.2743	.2753	.535	.5335
24	.4115		.2801	.2591	.3174	.535
Max	.7888	.8025	1.6461	.9242	1.0105	1.07
Min	.2058	.1307	.2401	.1457	.2241	.1254
Avg	.4326	.3484	.6888	.4693	.5633	.4208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 202 / 11 KV Jogwadi single SINGLE PHASING  
Phasing Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.081	.1494	.1189	.1269	.1486	.1307
2	.12	.1134	.1494	.1189	.1286	.1486	.1307
3	.1372	.112	.1494	.1189	.1429	.1486	.1307
4	.2058	.112	.1867	.1337	.1572	.1783	.1494
5	.2743	.1296	.2614	.1783	.1715	.2229	.1867
6	.3429	.1457	.3921		.2027	.2675	.2987
7	.4115	.1619	.3734	.2675	.2027	.3269	.3734
8	.2743	.1638	.2614	.3086	.2641	.3418	.2801
9	.1715	.1692	.1932	.1886	.1134	.168	.3239
10	.2401	.2	.1932	.1715	.1134	.1307	.2949
11		.1572		.1543	.08	.1307	.2439
12	.1372	.2027	.1783	.1372	.08	.112	.3429
13	.1715	.1858	.1783	.12	.08	.112	.4108
14	.1715	.1692	.2012	.12	.096	.1307	.2572
15	.1543	.2	.1783	.1372	.0972	.1494	.2267
16	.1372	.1833	.1486	.12	.096	.1494	.2606
17	.1029		.112	.1372	.1457	.168	.1463
18	.1029	.1457	.1494	.1715	.1296	.2054	.2218
19	.12	.2429	.2241	.1886	.2458	.2241	.3361
20	.1372	.2949	.3174	.2058	.2591	.2987	.2957
21	.1543	.2429	.2801	.1886	.2622	.2801	.2614
22	.1543	.1781	.2075	.1543	.2105	.2241	.2263
23	.1543	.144	.1337	.1543	.141	.168	.1698
24	.12	.128		.1337	.1269	.1635	.1494
Max	.4115	.2949	.3921	.3086	.2641	.3418	.4108
Min	.1029	.081	.112	.1189	.08	.112	.1307
Avg	.1789	.1680	.2099	.1621	.1531	.1916	.2437



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 203 / 11 KV Morgaon single SINGLE PHASING  
Phasing Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.112	.1494	.104	.1429	.1486	.112
2	.0686	.112	.1494	.104	.141	.1486	.112
3	.1372	.112	.1494	.1189	.141	.1486	.112
4	.1715	.1296	.2054	.1189	.1572	.1783	.1307
5	.2058	.1457	.2801	.1486	.2	.208	.168
6	.2743	.1619	.3547		.2286	.2378	.2054
7	.3772	.1802	.3734	.3121	.2317	.4161	.2427
8	.2401	.1802	.2241	.3429	.2787	.4161	.2054
9	.1543	.1974	.208	.1543	.1296	.112	.2968
10	.2058	.3144	.208	.1543	.1457	.112	.3077
11		.2	.1932	.1715	.1457	.112	.2846
12	.2058	.2896	.1783		.128	.0934	.4115
13	.1886	.2572	.208	.1543	.1134	.112	.4115
14	.2058	.2286	.208	.1715	.096	.112	.4054
15	.2058	.2572	.1932	.1372	.1296	.1307	.3765
16	.1715	.2606	.1783	.12	.08	.1494	.3864
17	.1372	.128	.1494	.1543	.1134	.1494	.0732
18	.1372	.1619	.168	.1715	.081	.1494	.1307
19	.1543	.1781	.2427	.2058	.1781	.1867	.2241
20	.1543	.3113	.3174	.2401	.1781	.2614	.2263
21	.1715	.2241	.2614	.2058	.1619	.2054	.1848
22	.1543	.176	.2241	.1715	.128	.1867	.168
23	.1543	.16	.1337	.1543	.1429	.1494	.1494
24	.12	.112		.1189	.1429	.1486	.1307
Max	.3772	.3144	.3734	.3429	.2787	.4161	.4115
Min	.0686	.112	.1337	.104	.08	.0934	.0732
Avg	.1782	.1913	.2155	.1698	.1506	.1780	.2273

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 204 / 11 KV Tardoli single SINGLE PHASING

phasing Feeder KV- 11 /

OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.3239	.3174	.1486	.2286	.1635	.2987
2	.2058	.2881	.3174	.1486	.2256	.1635	.2987
3	.2401	.2561	.3174	.1486	.2256	.1635	.2987
4	.2743	.2591	.4294	.1783	.2572	.2378	.2987
5	.4287	.2915	.5415	.2378	.3475	.2972	.3734
6	.5144	.3077	.6908		.4401	.3715	.5228
7	.6173	.3563	.7095	.4458	.4988	.4904	.6535
8	.5316	.3429	.4668	.4115	.4054	.5647	.4108
9	.1886	.4001	.208	.2743	.421	.2801	.4801
10	.1886	.2679	.2675	.2401	.2753	.2241	.4572
11		.2429	.2378	.1886	.1619	.2241	.4633
12		.1833	.2824	.1715	.2429	.2054	.4108
13	.2058	.2606	.2675	.1543	.192	.2054	.4089
14	.1886	.2429	.2675	.1886	.16	.2054	.3658
15	.1886	.2286	.2526	.1543	.1781	.1867	.362
16	.1715	.2606	.2229	.1715	.1781	.1867	.3906
17	.12	.2429	.2241	.2058	.1781	.2054	
18	.3772	.2429	.2614	.3429	.2105	.2614	.2427
19	.5144	.4049	.4481	.3772	.4424	.4854	.4668
20	.5144	.4915	.5788	.4115	.5079	.5975	.5788
21	.5316	.4752	.5041	.3772	.4752	.5415	.4904
22	.5144	.3725	.3734	.3429	.3768	.4481	.4108
23	.4458	.2753	.1635	.3429	.1692	.3734	.3206
24	.2401	.3401		.1635	.2572	.1783	.3361
Max	.6173	.4915	.7095	.4458	.5079	.5975	.6535
Min	.12	.1833	.1635	.1486	.16	.1635	.2427
Avg	.3367	.3066	.3630	.2533	.2940	.3025	.4061

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 205 / 11 KV Modhave single  
phasing Feeder KV- 11 /  
OUTGOING

SINGLE PHASING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1974	.1486	.2054	.2591	.2241	.1337
2	.1715	.2	.1486	.2054	.2591	.2241	.1337
3	.1715	.2	.1486	.2241	.2561	.2241	.1337
4	.2058	.2	.1932	.2241	.2915	.2614	.1486
5	.2572	.2	.2378	.2614	.3277	.3734	.2378
6	.3258	.2286	.2824		.3441	.4481	.3864
7	.4115	.3185	.2972	.4481	.3605	.3921	.5201
8	.463	.4344	.3418	.4458	.2429	.2987	.4755
9	.2401	.2401	.2241	.2743	.2679	.2824	.2012
10	.1886	.1943	.1867	.3601	.3144	.2675	.1791
11		.1619	.168	.3429	.3001	.3269	.197
12	.2401	.1619	.1494	.3601	.2858	.2972	.197
13	.2401	.1619	.1494	.3772	.2858	.2972	.1753
14	.2743	.1619	.1494	.3429	.2858	.2972	.181
15	.2401	.1619	.1494	.3086	.2679	.2972	.1646
16	.2401	.1781	.168	.3772	.2896	.3121	.1848
17	.2058	.208	.168	.2401	.1781	.1867	.2054
18	.3086	.2591	.1867	.3086	.2105	.2241	.2218
19	.3201	.3441	.2987	.3429	.3441	.3734	.4108
20	.2743	.3768	.4294	.4115	.3932	.4481	.4108
21	.4458	.3441	.3734	.3944	.3401	.3921	.3734
22	.3772	.2915	.3361	.3772	.2591	.1867	.3206
23	.3086	.1619	.2614	.3429	.2267	.1486	.2267
24	.1886	.2256		.2241	.2915	.2241	.1486
Max	.463	.4344	.4294	.4481	.3932	.4481	.5201
Min	.1715	.1619	.1486	.2054	.1781	.1486	.1337
Avg	.2726	.2338	.2259	.3217	.2867	.2920	.2487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214430 / 33/11 KV MURTI

Feeder No / Name : 206 / 11KV Ambi Single Phasing SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401		.2614	.1783	.2858	.208	.2614
2	.2401		.2614	.1783	.2858	.208	.2614
3	.2743		.2614	.1783	.3001	.208	.2614
4	.3086		.3734	.1783	.2858	.2378	.2987
5	.3772		.4294	.208	.3001	.2675	.3734
6	.4458		.5041		.3475	.2675	.4481
7	.5144	.3077	.5228	.3418	.2751	.3269	.5415
8	.4115		.4108	.3601	.3374	.3269	.4108
9	.2058		.2824	.2401	.2429	.2987	.3814
10	.2401		.2675	.2058	.2267	.2801	.3353
11			.2675	.1886	.2267	.2614	.3725
12	.2401		.3361	.1886	.176	.1867	.301
13	.2743	.2286	.2675	.2058	.16	.1494	.3353
14	.2743	.2429	.2526	.2401	.16	.168	.3041
15	.2401	.2429	.2378	.2058	.16	.1867	.2972
16	.2058	.2143	.208	.1886	.1457	.2054	.2932
17	.1886		.2427	.2058	.1457	.2241	.1448
18		.2753	.2801	.2743	.1966	.2801	.2241
19	.3201	.4049	.3734	.3086	.3768		.4854
20		.4534	.4668	.3429	.421	.2987	.5093
21		.4049	.4108	.3429	.4049	.4481	.4715
22		.3401	.2987	.3086	.3239	.3734	.3772
23		.2915	.1932	.3429	.2	.3361	.3395
24	.2572			.1783	.2858	.208	.2987
Max	.5144	.4534	.5228	.3601	.421	.4481	.5415
Min	.1886	.2143	.1932	.1783	.1457	.1494	.1448
Avg	.2921	.3097	.3222	.2431	.2613	.2589	.3470

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 201 / 11 KV Waki single Phasing SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2881	.2427	.2056	.2214	.2427	.3681	.4744
2	.2881	.2427	.208	.2214	.2427	.3681	.4744
3	.2881	.2427	.2561	.253	.2427	.4481	.5376
4	.3201	.2427	.2881	.2846	.2801	.6081	.5376
5	.3361	.3174	.3113	.3005	.3361	.7682	.6009
6	.3361	.3734	.4321	.2846	.4854	.7907	.6483
7	.4481	.5041	.426	.3005	.5041	.8482	.8223
8	.5121	.5788	.3201	.2688	.4854	.8162	.8539
9	.2241	.2241	.4961	.5535	.7282	.2241	.2056
10	.1619	.192	.6348	.664	.7125		.1943
11	.1457	.176	.6535	.6802	.7625		
12	.1619	.176	.4854	.7125	.6964		
13	.1296	.16	.5601	.4534	.6154	.2429	.1943
14	.1134	.16	.5788	.5992	.6964	.2267	.1943
15	.1134	.176	.6535	.4858	.6316	.2105	.1781
16	.1134	.176	.6722	.6316	.6478	.2267	.1943
17	.2054	.16	.1739	.1619	.1619		.2591
18	.2427	.2241	.2214	.2241	.16	.3479	.3921
19	.3547	.3361	.2846	.3361	.3521	.3795	.4108
20	.3734	.3361	.3321	.4294	.3841	.3795	.4294
21	.3361	.2881	.2846	.3734	.3361	.3479	.4108
22	.2614	.2561	.253	.3174	.2881	.2846	.3734
23	.2427	.2241	.2214	.2614	.3681	.4586	.5041
24	.2881	.2427	.208	.2214	.2427	.3681	.4744
Max	.5121	.5788	.6722	.7125	.7625	.8482	.8539
Min	.1134	.16	.1739	.1619	.16	.2105	.1781
Avg	.2619	.2605	.3817	.3850	.4418	.4356	.4257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 202 / 11 KV Hol single Phasing SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315	.3315	.5304	.5967	.5304	.2984	.3315
2	.3315	.3315	.5304	.5967	.5304	.2984	.3315
3	.3315	.3315	.5243	.5967	.5304	.2984	.3315
4	.426	.3647	.6299	.5967	.5304	.3978	.3315
5	.4588	.3978	.5243	.5967	.5967	.4641	.3978
6	.5304	.4641		.7293	.663	.5304	.4641
7	.5304	.5304	.7293	.7956	.8619	.5967	.4641
8	.5967	.5967	.7293	.8619	.8619	.5304	.4641
9	.7293	.5967	.3315	.3315	.3978	.7293	.9282
10	.8619	.663	.2652	.2652	.2652		1.0608
11	.7956	.7956	.1989	.2652	.1989		
12	.8619	.7956		.1989			
13	.663	.7956	.1989	.1989		.9945	1.0608
14	.2984	.8288	.2652	.1989	.2652	1.1271	1.1271
15	.5967	.8453	.2652	.1989	.2652	1.0608	1.1271
16	.5967	.8619	.1989	.1989	.2652	1.0608	1.0608
17	.2652	.2652	.2652	.2652	.2652	.2652	.2652
18	.3315		.2984	.3315	.2652	.3315	.3315
19	.4641	.3978	.3978	.4435	.4641	.3978	.3978
20	.4641	.4641	.4641	.5304	.431	.3978	.5304
21	.4641	.431	.3978	.4973	.4641	.4641	.4973
22	.3978	.3978	.3978	.3978	.3978	.3978	.3978
23	.3315	.5304	.5967	.3315	.3315	.3315	.3978
24	.3277	.3315	.5304	.5967	.5304	.3315	.3315
Max	.8619	.8619	.7293	.8619	.8619	1.1271	1.1271
Min	.2652	.2652	.1989	.1989	.1989	.2652	.2652
Avg	.4994	.5369	.4214	.4425	.4505	.5383	.5741

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 203 / 11 KV SASTEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5243	.5914	.0983	.0648	.0739	1.0486	1.0688
2	.5243	.5975	.0983	.0648	.0739	1.0486	1.1012
3	.5571	.5975	.0983	.0648	.0739	1.1142	1.1336
4	.5898	.5975	.1147	.081	.0739	1.1469	1.1984
5	.6226	.6161	.1147	.081	.1109	1.278	1.2308
6	.5898	.6535	.1147	.0972	.1109	1.3108	1.247
7	.6882	.8131	.0983	.0972	.1109	1.3272	1.4899
8	.7373	.7392	.0819	.0949	.1109	1.3927	1.5384
9	.0655	.1109	.8356	1.1984	1.46	.0819	.081
10	.0617	.0983	1.1088	1.3426	1.5895		.0617
11	.0617	.0983	1.2012	1.3426	1.6204		
12	.0617	.096	1.1088	1.3272	1.4352		
13	.0617	.0983	1.1827	1.1265	1.5432	.0617	.0772
14		.0983	1.2323	1.2654	1.4661	.0772	.0772
15		.1147	1.2567	1.0648	1.5278	.0926	.0772
16	.0617	.112	1.2567	1.1574	1.4969	.0926	.0926
17	.0739	.0819	.081	.0617	.0617	.0926	.0772
18	.0739	.0655	.081	.0739	.0655	.0972	.0924
19	.0739	.0655	.081	.0924	.0819	.0972	.0924
20	.0924	.0655	.081	.0924	.0819	.081	.0924
21	.0739	.0819	.081	.0924	.0983	.081	.0924
22	.0739	.0819	.0648	.0924	.0819	.0648	.0924
23	.5914	.0983	.0648	.0739	1.0159	1.0526	1.1273
24	.5243	.5914	.0983	.0648	.0739	1.0486	1.0526
Max	.7373	.8131	1.2567	1.3426	1.6204	1.3927	1.5384
Min	.0617	.0655	.0648	.0617	.0617	.0617	.0617
Avg	.3084	.2985	.4431	.4631	.6016	.6042	.5997

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 204 / 11KV Chopadaj SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.426	.3696	.2294	.1898	.2957	.5571	.5693
2	.426	.3696	.2294	.1898	.2957	.5571	.5693
3	.4424	.3696	.2622	.1898	.2957	.5571	.6325
4	.4588	.3696	.2949	.2214	.3326	.6226	.6958
5	.5243	.4066	.2949	.253	.4066	.7865	.759
6	.4915	.4805	.4915	.3163	.6283	.852	.7907
7	.5571	.4805	.5571	.3795	.6653	.8848	.8539
8	.6226	.6283	.3932	.4428	.5544	.9831	.8855
9	.426	.3696	.6882	.5376	.961	.426	.3479
10	.2652	.2949	.8131	.759	.8223		.3163
11	.253	.2458	.924	.8855	.7907		
12	.1898	.1966	.961	.8855	.8855		
13	.1581	.1966	.8871	.9488	.9172	.2846	.2214
14	.1898	.1966	.8131	.8855	.9172	.2846	.2214
15	.1581	.213	.8871	.9172	.8855	.253	.2214
16	.1581	.2294	.8131	.6958	.8223	.253	.2846
17	.2218	.2294	.1898	.2214		.2846	.1898
18	.3326	.2622	.2214	.4066	.2294	.3795	.2957
19	.4435	.3932	.2846	.4805	.4588	.4428	.4805
20	.4066	.3605	.3795	.5175	.426	.3795	.4435
21	.3326	.3277	.3479	.4435	.3932	.3795	.4066
22	.2587	.2949	.2214	.3696	.3277	.2846	.3696
23	.3696	.2294	.1898	.3326	.5243	.5693	.7023
24	.426	.3696	.2294	.1898	.2957	.5571	.5693
Max	.6226	.6283	.961	.9488	.961	.9831	.8855
Min	.1581	.1966	.1898	.1898	.2294	.253	.1898
Avg	.3558	.3285	.4835	.4858	.5709	.5037	.4921



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 205 / 11 KV LOKHANDWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.2801	.6733	.4641	.6161	.2126	.1433
2	.2126	.2801	.6733	.4641	.6161	.2126	.1433
3	.2126	.2801	.6733	.4641	.6161	.2126	.1433
4	.3189	.3361	.8505	.4641	.6722	.3189	.2149
5	.5138	.4481		.5304	.7655	.4961	.2149
6	.5847	.6161		.5304	1.0642	.5316	.2865
7	.567	.5228	.4784	.5967	1.307	.5493	.2149
8	.4075	.4481	.567	.663	1.307	.3721	.1433
9	.7796	.7655	.1417	.0663	.2427	1.2226	1.4586
10	.7125	.7442	.1494	.1629	.181		1.6518
11	.7773	.8505					
12	.7773	.8682	.0747				
13	.7611	.8682	.0747			1.587	1.6032
14	.7773	.8505	.0747			1.6842	1.668
15	.7125	.8328	.0747			1.3765	1.668
16	.664	.8328	.0747	.1448	.0724	1.5384	1.6032
17	.168	.0709	.1433	.1448	.1448	.0724	.1448
18	.2427	.1772	.2149	.2241	.1949	.1433	.2054
19	.3361	.3898	.2865	.2987	.3721	.2149	.3921
20	.3734	.3544	.2865	.3696	.3544	.2149	.4108
21	.3174	.3366	.2149	.3361	.3366	.2865	.3734
22	.2987	.2835	.1433	.2987	.2835	.2149	.3174
23	.2801	.4607	.5014	.6161	.2481	.1433	.2801
24	.2126	.2801	.4607	.4641	.6161	.2481	.1433
Max	.7796	.8682	.8505	.663	1.307	1.6842	1.668
Min	.168	.0709	.0747	.0663	.0724	.0724	.1433
Avg	.4675	.5074	.3253	.3844	.5269	.5644	.6102

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214431 / 33/11 KV HOL

Feeder No / Name : 206 / 11 KV Korhale KH single SINGLE PHASING

Phasin Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5376	.5801	.9804	1.0774	1.2597	.5693	.5801
2	.5376	.5801	.9804	1.094	1.2597	.5693	.5801
3	.5376	.5801	1.012	1.1271	1.2597	.5693	.7293
4	.6009	.6299	1.0437	1.21	1.2597	.6009	.7956
5	.759	.7956	1.0911	1.21	.2486	.759	.8951
6	.8697	.9614	1.186	1.2929	.3149	.9282	.9614
7	.8697	1.0277	1.2651	1.326	.3647	1.012	.8951
8	.759	.9116	1.3125	1.3426	.3978	.8223	.8619
9	1.0279	1.3426	.506	.547	.5304	1.8818	2.5526
10	1.0111	1.2967	.431	.4144	.3315		2.6852
11	.9779	1.3125	.3315	.3481	.4144		
12	1.0111	1.3125	.2486	.2984	.3315		
13	1.2431	1.1544	.2486	.2984		2.4366	2.5194
14	1.2929	1.1544		.2984	.3647	2.5194	2.5194
15	1.2763	1.1702		.2652	.3481	2.4697	2.4863
16	1.2266	1.1702	.3647	.3315	.3812	2.5029	2.652
17	.5138	.4428	.4807	.431	.4807	.4475	.4641
18	.6133	.4744	.5636	.5967	.4744	.7293	.5967
19	.8453	.7274	.7293	.6962	.7432	.7956	.6962
20	.7956	.7116	.7956	.7459	.759	.7956	.7127
21	.6796	.6642	.7293	.6962	.6642	.7293	.6962
22	.6133	.6009	.6133	.6133	.6167	.663	.6796
23	.5801	.9488	1.0774	1.326	.5693	.5801	.6464
24	.5376	.5801	.9804	1.0774	1.2597	.5693	.5801
Max	1.2929	1.3426	1.3125	1.3426	1.2597	2.5194	2.6852
Min	.5138	.4428	.2486	.2652	.2486	.4475	.4641
Avg	.8215	.8804	.7714	.7777	.6363	1.0929	1.2175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 201 / 11 KV Karkhana Single SINGLE PHASING  
phasing Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	.3932	.426	.6299	.5898	.6299	.4588
2	.426	.3932	.426	.6464	.5898	.6464	.4588
3	.426	.3932	.4915	.6464	.5898	.663	.4915
4	.426	.4096	.5735	.663	.6226	.6962	.5571
5	.4915	.4588	.6882	.6554	.6718	.7293	.5898
6	.7045	.6554	.7865	.7956	.852	.8619	.7209
7	.9012	.7865	.7209	1.0442	1.0486	1.21	.7209
8	.7373	.6554		1.004	1.0486	1.0774	.6062
9	.8848	.7865	.7956	.4915	.4588	.4588	1.1271
10	.8684	.852	.9945	.3932	.4752	.4588	1.3923
11	.852	.9175	1.0111	.3768	.4424	.4588	1.3923
12	.9012	.9175	1.0898	.4588	.5079	.4915	1.4255
13	.7865	.8848	1.0608	.426	.4915	.4588	1.4255
14	.7865	.852	1.0277	.426		.4588	1.4255
15	.8029	.852	.9831	.5079		.4588	1.3923
16	.7209	.852	1.0277	.4588		.4588	1.3435
17	.4588	.4588	.4807	.4915	.639	.4588	.4807
18	.5243	.4752	.5197	.5243	.5243	.4915	.6133
19	.7701	.7209	.6874	.7209	.7209	.5735	.7042
20	.7537	.7209	.7377	.7209	.7209	.6554	.7127
21	.6554	.6554	.7293	.6554	.6554	.6554	.6962
22	.5898	.7865	.6299	.5898	.5898	.5898	.663
23	.4588	.5079	.6554	.6554	.639	.4915	.5801
24	.4096	.3932	.426	.6299	.6226	.639	.4588
Max	.9012	.9175	1.0898	1.0442	1.0486	1.21	1.4255
Min	.4096	.3932	.426	.3768	.4424	.4588	.4588
Avg	.6561	.6574	.7378	.6088	.6429	.6155	.8515

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 202 / 11 KV Malashi Single SINGLE PHASING

Phasing Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3768	.4588	.4588	.1658	.1638	.2155	.6226
2	.3605	.4424	.4588	.1823	.1475	.213	.6226
3	.3605	.4424	.4588	.1989	.1638	.2294	.6226
4	.3768	.4588	.4915	.2155	.1638	.2622	.6554
5	.4588	.4915	.5079	.2321	.1966	.2818	.6882
6	.5243	.5735	.5243	.2818	.2622	.3277	.7209
7	.5898	.6062	.6062	.2984	.2622	.3647	.852
8	.6226	.6226		.213	.1966	.3315	.852
9	.2622	.1802	.1989	.5898	.8029	.7373	.1658
10	.1638	.1966	.1492	.7209	.852	.6882	.1823
11	.1638	.1638	.1492	.7209	.8684	.6062	.1658
12	.1475	.1638	.1326	.7373	.9175	.9175	.1658
13	.1638	.1638	.1492	.7865	.9012	.9175	.1823
14	.1638	.1638	.1658	.8356	.8684	.9175	.1658
15	.1475	.1638	.1658	.7865	.852	.852	.1509
16	.1638	.1802	.1658	.7537	.9175	.852	.1492
17		.1802	.1823	.1802	.1966	.1966	.1492
18	.2458	.213	.2012	.1966	.2294	.2622	.1658
19	.2949	.3113	.218	.3277	.2622	.2949	.1823
20	.2949	.3277	.2321	.3277	.2949	.3277	.2012
21	.2949	.3113	.2155	.3277	.2785	.3277	.218
22	.2622	.3113	.218	.2622	.2622	.2949	.1966
23	.4588	.4588	.1823	.1966	.213	.6226	.5636
24	.3932	.4588	.4588	.1823	.1638	.1966	.6226
Max	.6226	.6226	.6062	.8356	.9175	.9175	.852
Min	.1475	.1638	.1326	.1658	.1475	.1966	.1492
Avg	.317	.3352	.2909	.405	.4349	.4682	.3860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 203 / 11 KV Murum Single phasing SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.065	.8192	.852	.3978	.3688	.3812	1.3763
2	1.065	.8192	.852	.431	.3521	.3978	1.3763
3	1.0814	.8192	.8848	.4973	.3688	.4578	1.3763
4	1.0814	.852	.9175	.547	.3856	.4641	1.4091
5	1.1142	.9175	.9503	.5636	.4694	.4807	1.4419
6	1.1797	.9831	.9831	.5868	.6036	.5801	1.5074
7	1.3763	1.1797	1.1797	.663	.6706	.6796	1.9006
8	1.5238	1.2452		.5636	.57	.5407	1.8351
9	.4024	.3932	.3315	1.2239	1.6766	1.7859	.3647
10	.3353	.3277	.285	1.6095	1.7436	1.8842	.2984
11	.3018	.3277	.285	1.6095	1.8442	2.0317	.2818
12	.285	.3277	.285	1.6598	1.8351	1.9662	
13	.2683	.2949	.2984	1.6766	1.861	1.9334	
14	.2683	.2949	.285	1.7436	1.8442	1.9006	.7293
15	.2683	.2949	.3113	1.6263	1.8778	1.9006	.2818
16	.285	.3277	.3315	1.8107	1.8778	1.8351	.2155
17	.3353	.3441	.3353	.3353	.3018	.3605	.2321
18	.3856	.3605	.3481	.3521	.3353	.3277	.2652
19	.503	.4915	.4191	.5365	.4862	.3932	.3018
20	.503	.5243	.5138	.57	.57	.4588	.3113
21	.503	.4915	.5304	.5365	.4915	.4588	.3481
22	.4359		.503	.4694	.4359	.426	.2915
23	.9221	.9175	.431	.4024	.4024	1.3763	1.4586
24	1.1142	.852	.852	.3978	.3688	.3932	1.3763
Max	1.5238	1.2452	1.1797	1.8107	1.8778	2.0317	1.9006
Min	.2683	.2949	.285	.3353	.3018	.3277	.2155
Avg	.6918	.6176	.5637	.8671	.9059	.9756	.8627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 204 / 11 KV Shinde Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161	.5041	.426	.5228	.5041	.5138	.6161
2	.5975	.4424	.4854	.5228	.4854	.5304	.6161
3	.6161	.426	.4854	.5041	.4854	.5975	.5601
4	.6161	.426	.4854	.5228	.5041	.6161	.5228
5	.6161	.5041	.4854	.5415	.5041	.5975	.5041
6	.5975	.5041	.4854	.5601	.5041	.547	.5041
7	.6161	.4424	.5228	.2614	.5415	.5636	.6348
8	.5041	.5228		.6348	.5228	.6348	.4854
9	.6348	.6535	.6722	.6161	.5601	.6535	.6535
10	.6348	.6535	.5415	.6722	.6348	.6535	.5801
11	.6535	.6535	.5415	.6535	.6348	.6535	.6722
12	.6161	.6535	.5788	.6535	.6722	.6348	.6722
13	.5975	.6535	.5601	.6348	.6348	.6348	.5636
14	.5788	.6535	.5228	.6348	.6348	.6348	.6348
15	.5041	.6535	.5601	.6722	.6348	.6161	.6161
16	.5041	.6348	.5788	.6348	.5975	.5228	.6348
17	.5228	.5975	.5601	.6348	.6161	.5228	.6535
18	.5041	.5788	.6161	.6348	.6348	.5228	.6348
19	.5228	.5415	.5228	.5601	.5601	.5041	.6348
20	.5041	.5228	.5228	.5601	.5601	.4854	.5788
21	.5041	.5228	.5041	.5041	.5788	.5041	.5601
22	.5228	.5041	.4481	.4854	.6348	.5041	.5415
23	.5041	.5041	.5228	.4854	.6535	.5041	.5228
24	.5975	.5041	.4854	.5415	.5041	.547	.6161
Max	.6535	.6535	.6722	.6722	.6722	.6535	.6722
Min	.5041	.426	.426	.2614	.4854	.4854	.4854
Avg	.5702	.5524	.5267	.5687	.5749	.5708	.5922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 205 / 11KV Wayalpatta single SINGLE PHASING  
phasing Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1638	.1475	.1638	.4096	.4917	.5304	.1638
2	.1638	.1311	.1638	.426	.4752	.547	.1638
3	.1802	.1311	.1966	.426	.4752	.547	.1966
4	.1966	.1638	.2294	.4424	.4915	.5636	.2294
5	.213	.1966	.2622	.4424	.5243	.5967	.2622
6	.3441	.2949	.3277	.4915	.6226	.7956	.2949
7	.3277	.3277	.3605	.6554	.8848	.8907	.3277
8	.2949	.2458		.6964	.852	.9831	.2785
9	.6226	.5243	.5304	.2458	.2458	.213	.5636
10	.6554	.5898	.7293	.2294	.1966	.1966	.7373
11	.5735	.5243	.6874	.1966	.1966	.1802	.9393
12	.6226	.426	.6299	.1475	.1802	.1311	1.1437
13	.5571	.4588	.5801	.1638	.1638	.1475	1.1768
14	.5571	.4915	.6464	.1802	.1638	.1638	1.1105
15	.5571	.4915	.6133		.1638	.1638	1.1271
16	.6226	.5079	.6874			.1638	1.2308
17	.1966	.213	.1658	.1966	.1966	.1638	.1823
18	.213	.213	.2155	.213	.1802	.213	.0215
19	.2785	.2949	.2984	.3277	.2949	.2458	
20	.2785	.2458	.2818	.2785	.2622	.2622	.2984
21	.213	.2294	.2683	.2458	.2294	.3932	.2652
22	.1638	.2294	.2294	.1966	.1802	.2294	.2321
23	.1638	.1638	.431	.5243	.5243	.1638	.1823
24	.1638	.1475	.1638	.426	.4915	.5304	.1638
Max	.6554	.5898	.7293	.6964	.8848	.9831	1.2308
Min	.1638	.1311	.1638	.1475	.1638	.1311	.0215
Avg	.3468	.3079	.3853	.3437	.3690	.3756	.4909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214462 / 33/11 KV MURUM

Feeder No / Name : 206 / Someshwar Engineering  
College Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.0149			.0137	.0196
10	.0217	.018	.0274	.0171	.0229
11	.0183	.0169	.0241	.0171	.0247
12	.0206	.0191	.0257	.0194	.0271
13	.0183	.018	.0229	.0149	.0213
14	.0183	.0169	.0217	.0183	.0226
15	.0194	.0157	.0244		1.1271
16	.0137	.0197	.0229		.0198
19					.3149
<b>Max</b>	<b>.0217</b>	<b>.0197</b>	<b>.0274</b>	<b>.0194</b>	<b>1.1271</b>
<b>Min</b>	<b>.0137</b>	<b>.0157</b>	<b>.0217</b>	<b>.0137</b>	<b>.0196</b>
<b>Avg</b>	<b>.0182</b>	<b>.0178</b>	<b>.0242</b>	<b>.0168</b>	<b>.1778</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 201 / 11 KV Chilaimala Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0339	.381	.3353	.3612	.4012	.0857
2	.0514	.0335	.3763	.3353	.3864	.3814	.0857
3	.0514	.0335	.3715	.3353	.3864	.3864	.0857
4	.0514	.0335	.3864	.3506	.4108	.3961	.0857
5	.0514		.4012	.3658	.4108	.4108	.1029
6	.0514	.0339	.3715	.3963	.4458	.4915	.1075
7	.0686	.0655	.431	.4572	.535	.5407	.0905
8	.0686	.0663	.3765	.503	.5796	.5335	.1086
9	.4572	.3814	.0492	.0492	.0497	.0625	.4877
10	.4694	.442	.0686	.0309	.0301	.0819	.639
11	.4694	.4268	.0469	.0474	.0305	.12	.7133
12	.4694	.4115	.0469	.0633	.0312	.12	.7977
13	.4344	.4064	.0469	.0633	.0328	.12	.7926
14	.4001	.4167	.048	.0791	.0486	.1372	.7926
15	.3715	.381	.08	.0781	.0492	.12	.7526
16	.3572	.4268	.096	.0772	.064	.1029	.7526
17	.0602		.048	.0762	.064	.1174	.1029
18	.0648	.0354	.0625	.08	.048	.1147	.1052
19	.0663	.0716	.0625	.0838	.0492	.1029	.1433
20	.0686	.0709	.048	.0848	.0492	.1029	.1433
21	.0514	.0895	.0469	.0678	.0324	.0857	.128
22	.0514	.0709	.0469	.0514	.032	.0857	.1097
23	.0514	.3715	.3506	.3864	.4064	.0886	.1097
24	.0514	.0339	.3763	.3506	.3567	.4064	.0886
Max	.4694	.442	.431	.503	.5796	.5407	.7977
Min	.0514	.0335	.0469	.0309	.0301	.0625	.0857
Avg	.1808	.1971	.1925	.1978	.2038	.2296	.3088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 202 / 11 KV Wadgaon GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2587	.2772	.2801	.3142	.2987	.3142
2	.2801	.2561	.2614	.2801	.2957	.2957	.3174
3	.2987	.2561	.2801	.2987	.2987	.2865	.3361
4	.3361	.2561	.3361	.3361	.3174	.3224	.3734
5	.3734	.3511	.4108	.3734	.3547	.394	.4108
6	.4854	.4668	.5041	.4854	.4294	.4298	.5041
7	.5601	.5975	.5601	.5975	.5544	.5373	.6161
8	.5175	.5544	.4854	.5359	.499	.5415	.4805
9	.4066	.4207	.3881	.4024	.4344	.4525	.462
10	.3439	.3326	.362	.3366	.3921	.394	.3544
11	.3012	.3326	.2835	.298	.3881	.362	.3012
12	.2804	.2801	.2835	.2947	.3142	.2865	.298
13	.2454	.2801	.2743	.2774	.3174	.3012	.2947
14	.2103	.2926	.2572	.2427	.2686	.3174	.2601
15	.2103		.2804	.2572	.2801	.3012	.2572
16	.2279	.2987	.298	.2572	.2801	.298	.2743
17	.2427	.3361	.2743	.2515	.2829	.3086	.3086
18	.298	.3511	.3155	.3294	.3326	.3429	.3544
19	.4163	.3801	.4163	.4344	.394	.439	.4163
20	.4435	.4163	.4435	.4572	.4435	.4435	.4572
21	.3881	.4108	.4066	.4066	.3582	.3658	.3881
22	.3696	.362	.4066	.4251	.3403	.3658	.3696
23	.3326	.3109	.3174	.3511	.2987	.3511	.3326
24	.2801	.2957	.2801	.2987	.3326	.2987	.3326
Max	.5601	.5975	.5601	.5975	.5544	.5415	.6161
Min	.2103	.2561	.2572	.2427	.2686	.2865	.2572
Avg	.3387	.3521	.3501	.3545	.3551	.3639	.3672

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 203 / 11 KV CHOUDHARWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3258	.3292	.2957	.3224	.3547	.3326
2	.2987	.3224	.2957	.2987	.3258	.3292	.3361
3	.3361	.3224	.2957	.3174	.3258	.3292	.3547
4	.3734	.3582	.3258	.3547	.3841	.3696	.3921
5	.4854	.4344	.4024	.4294	.4572	.4805	.4668
6	.6535	.6468	.7023	.6348	.6099	.6447	.6838
7	.6908	.7316	.7095	.6468	.7316	.6626	.7207
8	.5304	.567	.5601	.5014	.5973	.5601	.567
9	.3841	.4252	.4024	.3944	.443	.4656	.3601
10	.3222	.3547	.4115	.3052	.4854	.4115	.3978
11	.2915	.3326	.3185	.2915		.3772	.3978
12	.2401	.2772	.3185	.2846	.4207	.3185	.3856
13	.2241	.2743	.3277		.3982	.3353	.3315
14		.2896	.1638		.4024	.3018	.2984
15		.3142	.1638		.394	.3185	.2984
16	.2652	.2033	.0663	.3437	.4108	.3401	.3315
17	.3041	.3174	.3681	.4062	.2801	.3353	.4096
18	.3605	.3326	.3681	.4694	.3361	.3812	.4458
19	.4115	.4024	.4961	.5316	.5544	.543	.5014
20	.5014	.5415	.4887	.5373	.5601	.543	.5731
21	.4887	.5121	.4755	.4119	.4656	.5014	.5249
22	.4525	.4481	.394	.4119	.4066	.4298	.4706
23	.4163	.3696	.3109	.394	.3921	.3696	.4344
24	.3142	.362	.3361	.2957	.3582	.3547	.3511
Max	.6908	.7316	.7095	.6468	.7316	.6626	.7207
Min	.2241	.2033	.0663	.2846	.2801	.3018	.2984
Avg	.3929	.3944	.3763	.4074	.4375	.4190	.4319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 204 / 11 KV Wadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1463	.5182	.6081	.6958	.6554	.1867
2	.1509	.1478	.5121	.6154	.6562	.6554	.1886
3	.1509	.1494	.4999	.6478	.6481	.6401	.1886
4	.1886	.1494	.5121	.6478	.6481	.6554	.2241
5	.2263	.168	.5761	.7125	.679	.7209	.2614
6	.2241	.1848	.6401	.7042	.8124	.7042	.2614
7	.2241	.2263	.7042	.8642	.9488	.8855	.2614
8	.1867	.1509	.7865	.9602	.9488	.9175	.2241
9	.759	.5556	.1448	.1448	.1509	.1448	1.0753
10	.8749	.7865	.1448	.2218	.1402	.1463	1.2346
11	.8749	.852	.181	.2218	.1433	.2172	1.4083
12	.8025	.9175	.181	.2218	.2149	.2172	1.2163
13	.8642	.9175	.181	.181	.2172	.2561	1.3283
14	.8642	.9175	.181	.1433	.2126	.2957	1.2651
15	.7407	.9069	.1829	.1448	.2149	.2926	1.3123
16	.7407	.8322	.1829	.1829	.2149	.2926	1.2498
17	.0848	.0724	.1791	.2195	.2149	.2926	.2172
18	.0995		.1829	.2195	.2149	.2561	.2195
19	.1402	.1463	.2218	.2218	.2865	.1848	.2218
20	.1829	.1433	.2241	.2218	.2896	.2241	.2402
21	.1848	.2149	.2241	.2195	.2896	.2241	.2218
22	.1848	.2172	.2241	.1829	.2896	.2241	.2218
23	.1848	.5243	.6249	.6958	.7316	.2241	.1848
24	.1478	.1478	.567	.6401	.6958	.6478	.2241
Max	.8749	.9175	.7865	.9602	.9488	.9175	1.4083
Min	.0848	.0724	.1448	.1433	.1402	.1448	.1848
Avg	.3847	.4119	.3574	.4101	.4399	.4156	.5682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 205 / 11 KV MUDHALE SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.695	.4915	.6661	.7362	.7042	.679
2	.6602	.6878	.4801	.6661	.7362	.6722	.679
3	.6979	.6733	.5304	.6661	.7712	.6401	.7095
4	.7545	.6859	.5761	.7011	.8063	.7125	.7922
5	.9242	.8688	.6882	.8063	.8764	.7865	.9709
6	1.1506	1.1506	.7701	.9465	1.1568	1.0395	1.2637
7	1.2136	1.1389	.9503	1.0974	1.4074	1.3717	1.1203
8	.8775	.9149	.9339	1.1831	1.4413	1.3435	.7655
9	.7888	.823	.4668	.5041	.5228	.5552	1.21
10	.779	.8192	.3361	.3361	.3761	.4294	1.6095
11	.8192	.8192	.3109	.3361	.3258	.3696	1.7436
12	.7773	.8322	.3109	.3142	.2587	.3361	1.5581
13	.7287	.852		.2353	.2587	.3696	1.6712
14	.7373	.852		.2481	.2957	.3326	1.5729
15	.6133	.8642	.3361	.2481	.2926	.3326	1.5729
16	.6133	.8192	.3361	.2686	.1848	.3475	1.4746
17	.4835	.4066	.3109	.3045	.3403	.3658	.362
18	.543	.6348	.4163	.4525	.5487	.5068	.6036
19	.8871	.8962	.7947	.7762	.924	.905	.7468
20	.9054	.924	.9709	.9896	.924	.8962	.8962
21	.8299	.8413	.8686	.8589	.8962	.7842	.8676
22	.7922	.7842	.7842	.7922	.7922	.7842	.8299
23	.7468	.5182	.7011	.7362	.7209	.7095	.7922
24	.6602	.7392	.5079	.7011	.7362	.7209	.7167
Max	1.2136	1.1506	.9709	1.1831	1.4413	1.3717	1.7436
Min	.4835	.4066	.3109	.2353	.1848	.3326	.362
Avg	.7768	.8017	.5851	.6181	.6804	.6673	1.0503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214473 / 33/11 KV WADGAON NIMBALKAR

Feeder No / Name : 206 / 11 KV DAREKAR MALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.6081	.6478	.7125	.8002	.0566
2	.0377	.0377	.5761	.6478	.7449	.7682	.0566
3	.0377	.0377	.5761	.6154	.7362	.7682	.0566
4	.0377	.0566	.6154	.6154	.7682	.8002	.0566
5	.0566	.0566	.6554	.6154	.7682	.8848	.0754
6	.0566	.0754	.6562	.6154	.7842	.8848	.0754
7	.0754	.0754	.664	.664	.8097	.9012	.0754
8	.0754	.0754	.6554	.7042	.8583	.9069	.0566
9	.9339	.8886	.0566	.0566	.0566	.0377	.9831
10	.8539	.8684	.0377	.0377	.0189	.0189	1.1203
11	.8539	.852	.0377	.0377	.0189	.0377	1.1843
12	.8697	.8583	.0377	.0377	.0189	.0377	1.2323
13	.8697	.8192	.0377	.0377	.0189	.0377	1.2323
14	.8539	.8097	.0377	.0377	.0187	.0377	1.2483
15	.8642	.7773	.0377	.0366	.0189	.0377	1.2334
16	.8482	.8356	.0377	.037	.0189	.0377	1.2334
17	.0373	.0189	.0377	.037	.0377	.0566	.0377
18	.0366	.0377	.0566	.0377	.0377	.0566	.0377
19	.037	.0754	.0754	.0566	.0377	.0566	.0566
20	.0566	.0566	.0566	.0566	.0377	.0754	.0566
21	.0566	.0566	.0566	.0754	.0373	.0754	.0566
22	.0566	.0754	.0566	.0754	.0566	.0566	.0566
23	.0566	.6062	.6722	.7287	.852	.0566	.0566
24	.0566	.0566	.6081	.6722	.7287	.852	.0566
Max	.9339	.8886	.6722	.7287	.8583	.9069	1.2483
Min	.0366	.0189	.0377	.0366	.0187	.0189	.0377
Avg	.3232	.3394	.2895	.2993	.3415	.3451	.4330

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 201 / 11 KV Late Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.3086	.4572	.724	.724	.1143
2	.0953	.0953	.3086	.4572	.724	.724	.0953
3	.0953	.0953	.3086	.4572	.724	.724	.0953
4	.1143	.0762	.3086	.4763	.724	.743	.1143
5	.1334	.0762	.3086	.4954	.743	.8573	.1334
6	.1524	.1715	.3601	.5335	.8383	.9717	.1524
7	.1524	.1715	.5316	.6859	1.1431	1.2193	.1715
8	.1334	.1334	.5487	.8002	1.2384	1.1622	.0953
9	.6478	.6097	.0572	.0572	.0572	.0953	1.6575
10	.724	.6097	.0572	.0572	.0572	.0953	1.8861
11	.7621	.6859	.0572	.0381	.0762	.0762	2.0767
12	.8192	.7621	.0572	.0572	.1143	.0953	1.9243
13	.8002	.7621	.0572	.0572	.0572	.0572	2.1529
14	.8002	.7621	.0572	.0572	.0572	.0572	2.0957
15	.7811	.8002	.0572	.0572	.0572	.0572	2.0195
16	.7621	.8002	.0572	.0572	.0572	.0762	1.829
17	.0762	.0762	.0762	.0762	.0762	.0572	.0762
18	.0953	.0686	.0953	.0953	.0762	.0953	.1143
19	.1143	.0857	.1143	.1143	.1143	.1143	.1334
20	.1143	.1372	.1143	.1143	.1143	.1143	.1334
21	.1143	.12	.1143	.1143	.1143	.1143	.1334
22	.1143	.1029	.1143	.1143	.1143	.1143	.1334
23	.0953	.3086	.4382	.7049	.7621	.1143	.1143
24	.0953	.0953	.3086	.4572	.7049	.7621	.1143
Max	.8192	.8002	.5487	.8002	1.2384	1.2193	2.1529
Min	.0762	.0686	.0572	.0381	.0572	.0572	.0762
Avg	.3287	.3209	.2007	.2747	.3945	.3842	.7319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 202 / 11 KV Korhale Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.4763	.1543	.1372	.1372	.1524	.9945
2	.743	.4572	.1543	.1372	.1543	.1334	1.105
3	.743	.4572	.1543	.1372	.1372	.1334	1.105
4	.743	.4572	.1543	.1372	.1543	.1334	.9945
5	.743	.5335	.1715	.1372	.1886	.1905	1.0288
6	.743	.724	.1886	.1886	.1372	.2286	1.0974
7	.8192	.7621	.1886	.1715	.1886	.2096	1.2003
8	.8764	.8383	.0857	.12	.1372	.1334	1.3032
9	.1334	.1143	.8059	1.0288	1.2193	1.3203	.0953
10	.1334	.0953	.7716	1.0631	1.448	1.5089	.0762
11	.1143	.0953	.8916	1.0974	1.5242	1.5775	.1143
12	.1143	.0953	.9602	1.1317	1.5242	1.5775	.0762
13	.0953	.0953		1.2003	1.5242	1.5432	.0953
14	.0953	.0381	.9259	1.166	1.5623	1.5432	.0953
15	.0762	.0381	.9602	1.166	1.5051	1.5432	.0953
16	.0762	.0762	.9259	1.1145	1.448	1.5432	.0953
17	.1334	.0953	.0857	.0686	.0953	.1029	.1143
18	.1524	.1143	.0514	.12	.0953	.1905	.1715
19	.1715	.1715	.0686	.1543	.1715	.1905	.1905
20	.1715	.1715	.1029	.1543	.0953	.1905	.1905
21	.1524	.1524	.1372	.1543	.1715	.1905	.1905
22	.1524	.1715	.1543	.1543	.1715	.1905	.1905
23	.4954	.1715	.1372	.1543	.1715	1.105	1.1812
24	.743	.4763	.1543	.1372	.1372	.1524	.9945
Max	.8764	.8383	.9602	1.2003	1.5623	1.5775	1.3032
Min	.0762	.0381	.0514	.0686	.0953	.1029	.0762
Avg	.3818	.2866	.3645	.4680	.5875	.6577	.5331



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 203 / 11KV Kurnewadi single SINGLE PHASING

Phasing Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4572	.6287	.4801	.5144	.5906	.7545
2	.4954	.4572	.6478	.4801	.5144	.5716	.7545
3	.4954	.4382	.6478	.4801	.5487	.5716	.8383
4	.4954	.4382	.6668	.5144	.5487	.5716	.7545
5	.5716	.5335	.7621	.6859	.6859	.7621	.8573
6	.6478	.6859	.9526	.8916	.8916	.4763	.9259
7	.8002	.7621	.9145	.7202	.8916	1.0669	1.0974
8	.8383	.8383	.6478	.6173	.6516	.724	1.3032
9	.4763	.4191	.6668	1.0288	1.1431	1.0669	.5335
10	.4382	.3429	.8573	1.0288	1.4098	1.3032	.3429
11	.2477	.3048	.8764	1.0974	1.2955	1.406	
12	.2286	.3048	.8573	.8573	1.448	1.3717	
13	.2286	.3048	.9145	1.0288	1.3336	1.3717	.4572
14	.2286	.3429	.8764	.9431	1.3717	1.3032	.4382
15	.2858	.3429	.8383	1.0974	1.3336	1.2003	.4191
16	.3429	.5335	.8383	1.0631	1.2955	1.1317	.4954
17	.4572	.4572	.4191	.4115	.4954	.4954	.4572
18	.5716	.5335	.4954	.6516	.5335	.6859	.6097
19	.7621	.6859	.5716	.583	.8383	.7621	.8002
20	.8383	.8383	.6478	.6859	.8383	.8573	.8192
21	.7621	.8192	.6859	.6516	.7621	.8002	.8383
22	.6478	.7811	.6859	.6344	.6859	.7621	.724
23	.4572	.6478	.6097	.5487	.6478	.7545	.8383
24	.4954	.4572	.6287	.4801	.5144	.6097	.7545
Max	.8383	.8383	.9526	1.0974	1.448	1.406	1.3032
Min	.2286	.3048	.4191	.4115	.4954	.4763	.3429
Avg	.5128	.5303	.7224	.7359	.8831	.8840	.7188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 204 / MATKARWASTI SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5335	.0514	.0762	.0514	.0762	
2	.6478	.5335	.0514	.0762	.0514	.0762	
3	.6478	.5335	.0686	.0762	.0686	.0572	
4	.6478	.5335	.0514	.0953	.0857	.0572	
5	.6478	.5716	.0686	.0953	.1029	.0762	
6	.6478	.724	.0857	.0762	.1029	.1143	
7	.8002	.7811	.1029	.0953	.1029	.1334	
8	.9145	.8383	.0857	.0762	.1029	.0953	
9	.0572	.0953	.8954	1.3032	1.3717	1.5623	
10	.0572	.0572	1.0288	1.3375	1.5623	1.4746	
11	.0572	.0572	1.0288	1.3203	1.7528	1.5432	.0762
12	.0381	.0572	1.0974	1.286	1.8099	1.5775	.0762
13	.0572	.0572	1.0974	1.3546	1.7528	1.5775	.0762
14	.0381	.0381	1.0974	1.3546	1.5242	1.6118	
15	.0381	.0381	1.0974	1.3032	1.4861	1.5432	.0572
16	.0572	.0381	1.0631	1.3032	1.467	1.4746	.0572
17	.0762	.0572	.0686	.0857	.0762	.0762	.0762
18	.0762	.0514	.0762	.0857	.0762	.0762	.0762
19	.0953	.0514	.0762	.0857	.0953	.0762	.0762
20	.0762	.0686	.0953	.0686	.0762	.0953	.0572
21	.0762	.0686	.0953	.0686	.0762	.0762	.0762
22	.0762	.0514	.0762	.0686	.0762	.0762	.0572
23	.5525	.0514	.0762	.0686	.0762		.8573
24	.6097	.5525	.0514	.0762	.0514	.0762	
Max	.9145	.8383	1.0974	1.3546	1.8099	1.6118	.8573
Min	.0381	.0381	.0514	.0686	.0514	.0572	.0572
Avg	.3168	.2683	.3995	.4932	.5833	.5914	.1350

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214496 / 33/11KV Korhale S/Stn.

Feeder No / Name : 205 / 11 KV BAJARANGWADI GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4382	.4458	.4954	.4287	.5144	.5716
2	.4191	.4191	.4458	.4954	.4287	.4954	.5716
3	.4191	.4191	.4458	.4954	.4458	.4954	.5716
4	.4572	.4191	.463	.5716	.463	.5335	.6097
5	.5906	.4954	.583	.7621	.6173	.6478	.7621
6	.8573	.6668	.7716	.8573	.7545	.8764	1.0098
7	.7811	.8192	.7202	.7621	.7716	.8383	.8383
8	.6859	.7049	.6001	.7049	.6516	.724	.6478
9	.4763	.5335	.5716	.5144	.5716	.5906	.5335
10	.4572	.4001	.4001	.4458	.5335	.5335	
11	.4382	.381	.4001	.3944	.4572	.4763	.4763
12	.381	.381	.381	.3772	.4382	.4191	.4763
13	.3429	.362		.3601	.4382	.4382	.4954
14	.3239	.362		.3429	.4001	.4382	.4572
15	.362	.362		.3429	.4572	.4572	.4763
16	.381	.381		.3944	.4954	.4763	.4954
17	.4382	.4572	.5716	.4115	.4763	.5335	.5525
18	.5525	.4458	.6097	.4801	.4954	.5716	.5716
19	.6287	.4973	.6859	.583	.6478	.6859	.6478
20	.5525	.6173	.724	.6173	.6859	.8002	.6287
21	.5144	.5144	.6859	.6173	.6287	.743	.6287
22	.4954	.463	.5716	.4801	.5716	.6478	.5906
23	.4382	.4458	.5144	.4458	.5335	.6287	
24	.4382	.4382	.4458	.4954	.4287	.5144	.5716
Max	.8573	.8192	.7716	.8573	.7716	.8764	1.0098
Min	.3239	.362	.381	.3429	.4001	.4191	.4572
Avg	.4938	.4760	.5519	.5186	.5342	.5867	.5993

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214524 / 33/11 KV Morgaon

Feeder No / Name : 201 / mayureshwar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2058	.2926	.1174	.1219	.1966	.2743
2	.2641	.2058	.2926	.1174	.1219	.1966	.2743
3	.2641	.2058	.3109	.1174	.1219	.213	.2743
4	.2641	.2058	.3109	.1174	.1372	.213	.2915
5	.2829	.2401	.3292	.1219	.1524	.213	.3086
6	.3584	.2743	.3292	.1509	.1524	.213	.3086
7	.3961	.3258	.4024	.1524	.1829	.2294	.3429
8	.3395	.3258	.3292	.1372	.16	.1966	.3258
9	.1341	.1802	.1147	.2229	.2561	.2743	.1829
10	.1219	.1966	.1372	.2401	.3109	.2743	.1829
11	.1524	.1802	.1524	.2401	.2561	.3086	.1829
12	.1524	.1802	.1829	.2743	.2561	.2915	.1829
13	.1524	.1638		.2987	.2561	.2915	.1677
14	.1524	.1638		.2572	.2743	.2743	.1829
15	.1677	.1802	.1829	.2572	.3292	.2915	.1829
16	.1372	.1966	.1524	.2743	.3292	.2572	.1829
17	.2915	.2926	.3086	.2401	.2195	.2915	.2743
18	.3258	.2561	.3086	.3429	.2926	.2743	.3086
19	.3429	.439	.3601	.4458	.4024	.3944	.3601
20	.3601	.439	.4115	.3944	.439	.3944	.4115
21	.3429	.4024	.3772	.3429	.439	.3944	.3601
22	.3086	.3658	.3086	.3258		.3429	.3086
23	.2229	.3658	.1509	.1372	.1802	.2915	.2915
24	.2641	.2058	.2926	.1067	.1219	.1966	.2743
Max	.3961	.439	.4115	.4458	.439	.3944	.4115
Min	.1219	.1638	.1147	.1067	.1219	.1966	.1677
Avg	.2526	.2582	.2744	.2264	.2397	.2714	.2682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214524 / 33/11 KV Morgaon

Feeder No / Name : 202 / RADHAKRISHNA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1715	.128	.061	.0762	.1147	.1543
2	.1698	.1715	.128	.061	.0762	.1147	.1543
3	.1698	.1715	.1829	.061	.0762	.1311	.1543
4	.1698	.1715	.2195	.061	.0914	.1311	.1715
5	.2263	.2058	.2195	.0914	.1067	.1475	.1886
6	.2829	.2401	.2561	.1219	.1067	.1475	.2058
7	.3018	.2743	.2195	.1524	.1219	.1966	.2229
8	.1886	.1543	.128	.1372	.144	.1802	.1372
9	.0671	.0655	.0819	.0686	.1097	.0857	.0914
10	.0762	.1311	.061	.0686	.1097	.0857	.1219
11	.0457	.1311	.061	.0514	.0914	.1029	.1677
12	.061	.0819	.0762	.0686	.128	.1029	.1524
13	.061	.0655	.0762	.056	.0914	.0857	.1219
14	.061	.0819	.0914	.0514	.0732	.0857	.1219
15	.061	.0819	.1067	.0857	.0732	.0857	.1067
16	.0914	.1147	.0914	.1029	.0914	.0857	.1219
17	.1029	.128	.1029	.0857	.1097	.1029	.0857
18	.1372	.128	.1029	.12	.1463	.0857	.1372
19	.2058	.2012	.1715	.1715	.2195	.1886	.1886
20	.2572	.1829	.1715	.1886	.2195	.1886	.2058
21	.2229	.1646	.1715	.1715	.2195	.1886	.1886
22	.1715	.1646	.1543	.1543	.1829	.1715	.1715
23	.1543	.1646	.0671	.0762	.1147	.1543	.1715
24	.168	.1715	.128	.061	.0762	.1147	.1543
Max	.3018	.2743	.2561	.1886	.2195	.1966	.2229
Min	.0457	.0655	.061	.0514	.0732	.0857	.0857
Avg	.1510	.1508	.1332	.0970	.1190	.1283	.1541

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214524 / 33/11 KV Morgaon

Feeder No / Name : 203 / 11 KV MANGOBACHI WADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1029	.1646	.1677	.2286	.3277	.2058
2	.132	.1029	.1646	.1677	.2286	.3277	.2058
3	.132	.1029	.1829	.1677	.2286	.3605	.2058
4	.132	.1029	.2195		.2439	.3605	.2229
5	.1698	.1372	.2195	.2286	.2743	.3932	.2229
6	.2075	.1715	.2378	.2743	.3353	.4096	.2572
7	.2452	.1886	.2195	.3048	.4115	.5407	.2572
8	.1698	.12	.1463	.3201	.4001	.5898	.1372
9	.1844	.1966	.2294	.12	.128	.1543	.4877
10	.1981	.213	.2439	.12	.128	.12	.5487
11	.2134	.213	.2743	.12	.1097	.1372	.6554
12	.2134	.2622	.3048	.1543	.1097	.12	.6097
13	.1677	.2785	.3048	.1494	.1097	.12	.6554
14	.1677	.2622	.2896	.1543	.1097	.12	.6097
15	.1372	.2785	.3048	.1372	.128	.12	.5639
16	.1524	.2622	.3048	.1372	.1463	.1543	.5792
17	.0857	.1097	.1029	.1372	.128	.1543	.0686
18	.1029	.1463	.1029	.1543	.128	.1543	.1029
19	.1029	.2195	.1886	.1886	.2012	.2229	.1886
20	.1372	.2012	.1886	.2058	.2561	.2401	.2401
21	.1372	.2012	.1886	.2058	.2195	.2401	.2229
22	.1372	.1829	.1886	.1886		.2401	.2058
23	.1029	.1829	.2012	.2286	.3277	.2229	.2058
24	.1307	.1029	.1646	.1677	.2286	.3277	.2058
Max	.2452	.2785	.3048	.3201	.4115	.5898	.6554
Min	.0857	.1029	.1029	.12	.1097	.12	.0686
Avg	.1538	.1809	.2140	.1826	.2091	.2566	.3277

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214525 / 33/11 KV Nimbut

Feeder No / Name : 201 / 11 KV Baramati Agro  
Express Fe Feeder KV- 11 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2229	.2229
2	.2058	.2743	.2401	.2058		.2572	.2401
4	.2058	.2401	.2743	.2401			
5						.2401	.2058
6	.2058	.2058	.2229	.2058		.2229	.2058
7						.2743	.2229
8	.2058	.2058	.2058	.2058		.2058	.2572
9						.2401	.2743
10	.2572	.2915	.2743			.2743	.2743
11				.2401	.2572	.2743	.3086
12	.2401	.3086	.2743	.2401	.2743	.2743	.3086
13					.2572	.2572	.3086
14	.2058	.2915	.2915		.2401	.2572	.3086
15					.2401	.2572	.3086
16	.2058	.2743	.3086		.2401	.2572	.2743
17					.2572	.2572	.2743
18	.2401	.2401	.2743		.2572	.2572	.2743
19					.2743	.2572	.2743
20	.2401	.2401	.2743		.2572	.2401	.2743
21					.2229	.2401	.2401
22	.1715	.2058	.2058		.2058	.2229	.2401
23					.2229	.2401	.2058
24	.2058	.2058	.2229	.1715		.2229	.2229
Max	.2572	.3086	.3086	.2401	.2743	.2743	.3086
Min	.1715	.2058	.2058	.1715	.2058	.2058	.2058
Avg	.2158	.2486	.2558	.2156	.2467	.2479	.2603

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214525 / 33/11 KV Nimbut

Feeder No / Name : 202 / 11 KV CHAUDHARWADI AG  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.12	.1372
2	1.3717	1.0631	1.2003	1.2174		.1029	.12
4	1.406	1.0974	1.3203	1.3717			
5						.12	.1372
6	1.4232	1.0974	1.3717	1.4746		.12	.1543
7						.1372	.1543
8	1.4403	1.1317	1.406	1.5432		.1029	.12
9						1.9204	.1029
10	.1029	.1029	.0857			2.0919	.0857
11				1.8519	2.2977	2.0405	.0514
12	.1029	.12	.12	1.8004	2.4006	1.989	.0514
13					2.0919	2.0405	
14	.12	.1029	.1029		1.9204	2.0919	.0514
15					1.9376	2.1605	.0686
16	.1029	.1029	.1029		1.9547	2.1948	.0857
17					.1029	.1029	.0686
18	.0857	.1029	.1029		.0857	.1029	.0857
19					.1029	.12	.0857
20	.12	.1029	.12		.1029	.1029	.0857
21					.1029	.12	.0857
22	.1029	.1029	.1029		.1029	.1029	.0857
23					.1029	.1029	1.2346
24	1.3375	1.0288	1.0288	1.0288		.1029	.12
Max	1.4403	1.1317	1.406	1.8519	2.4006	2.1948	1.2346
Min	.0857	.1029	.0857	1.0288	.0857	.1029	.0514
Avg	.643	.5130	.5887	1.4697	1.0235	.8223	.1510



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214525 / 33/11 KV Nimbut

Feeder No / Name : 203 / 11 KV GADADARWADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.9945	.9259
2	.0514	.0514	.0686	.0514		1.0288	.9602
4	.0514	.0514	.0343	.0686			
5						1.166	1.0802
6	.0514	.0514	.0514	.0514		1.2003	1.0974
7						1.2003	1.1317
8	.0514	.0686	.0686	.0686		1.2689	1.2689
9						.0514	1.406
10	1.2003	1.0288				.0686	1.4232
11				.0514	.0343	.0686	1.4575
12	1.0288	.9259		.0514	.0514	.0686	1.5089
13					.0514	.0514	1.3717
14		.8916			.0514	.0514	1.3375
15					.0514	.0343	1.3032
16		1.166			.0514	.0514	1.3032
17					.0514	.0514	.0514
18	.0686	.0686			.0514	.0686	.0686
19					.0514	.0686	.0686
20	.0686	.0686			.0514	.0686	.0686
21					.0514	.0686	.0686
22	.0343	.1029			.0514	.0686	.0686
23					.9259	.8573	.0686
24	.0514	.0343	.0857	.0343		.9602	.8916
Max	1.2003	1.166	.0857	.0686	.9259	1.2689	1.5089
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0514
Avg	.2658	.3758	.0617	.0539	.1174	.4326	.8605

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214525 / 33/11 KV Nimbut

Feeder No / Name : 204 / 11 KV SORTEWADI AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1543	.1543
2	1.3717	1.0974	1.1317	1.1317		.1372	.1715
4	1.3717	1.1317	1.2003	1.1831			
5						.12	.1372
6	1.3889	1.2003	1.2689	1.286		.1029	.12
7						.12	.1372
8	1.3889	1.2003	1.3717	1.5089		.1029	.12
9						2.1776	.12
10	.1029	.1372	.0514			2.4006	.12
11				1.8004	2.4006	2.4177	.0857
12	.1029	.1372	.0686	1.8004	2.4691	2.4348	.0857
13					2.4006	2.332	.1029
14	.0686	.12	.1029		2.332	2.2119	.1029
15					2.2291	2.0919	.1029
16	.1029	.1029	.1029		2.1262	2.1262	.1029
17					.1372	.12	.0686
18	.0857	.1029			.12	.1372	.1029
19					.1372	.1372	.1029
20	.1372	.1029			.1372	.1543	.1029
21					.1372	.1543	.1029
22	.1029	.1372	.1372		.1543	.1715	.1029
23					.1543	.1543	1.3546
24	1.3375	1.046	1.0631	1.0974		.1372	.1715
Max	1.3889	1.2003	1.3717	1.8004	2.4691	2.4348	1.3546
Min	.0686	.1029	.0514	1.0974	.12	.1029	.0686
Avg	.6302	.543	.6499	1.4011	1.1488	.9135	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 214525 / 33/11 KV Nimbut

Feeder No / Name : 205 / 11 KV NIMBUT AG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6859	.7202
2	.0343	.0514	.0514	.0514		.703	.7373
4	.0343	.0686	.0686	.0343			
5						.7545	.823
6	.0514	.0343	.0343	.0343		.7716	.8402
7						.7888	.8573
8	.0514	.0343	.0343	.0343		.823	.9259
9						.0343	.9945
10	.7888	.7545	.6859			.0343	.9774
11				.0514	.0514	.0343	.9602
12	.823	.7888	.8573	.0343	.0514	.0343	.9602
13					.0514	.0343	.9602
14	.8745	.7545	1.0288		.0514	.0514	.9945
15					.0343	.0514	.9602
16	.823	.8573	1.0288		.0343	.0343	.9259
17					.0343	.0343	.0343
18	.0857	.0514	.0514		.0514	.0514	.0343
19					.0514	.0514	.0343
20	.1029	.0514	.0686		.0514	.0514	.0343
21					.0686	.0514	.0343
22	.0686	.0343	.0686		.0686	.0514	.0343
23					.6001	.6687	.0343
24	.0343	.0686	.0514	.0343		.6344	.703
Max	.8745	.8573	1.0288	.0514	.6001	.823	.9945
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.3144	.2958	.3358	.0392	.0923	.2923	.6173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 217047 / 132KV Someshwar

Feeder No / Name : 401 / 33/11 KV MURUM s/stn  
Incommmer Feeder KV- 33 /  
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	.8145
Max	.8145
Min	.8145
Avg	.8145

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 217047 / 132KV Someshwar

Feeder No / Name : 402 / 33/11 KV HOL substation  
Incom Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	.8688
Max	.8688
Min	.8688
Avg	.8688

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 217047 / 132KV Someshwar

Feeder No / Name : 403 / 33/11 KV Korhale INCOMER      NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING      (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	2.009
Max	2.009
Min	2.009
Avg	2.009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 217047 / 132KV Someshwar

Feeder No / Name : 404 / 33/11 KV Nimbut s/stn I/C NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	.8688
Max	.8688
Min	.8688
Avg	.8688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 217047 / 132KV Someshwar

Feeder No / Name : 405 / 33 KV Nira Substation  
InComer Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	.8145
Max	.8145
Min	.8145
Avg	.8145



Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

BARAMATI ZONE[052]

BARAMATI CIRCLE[511]

SASWAD DIVISION[509]

SOMESHWAR SUB-DN.[722] BU 4722

Substation No/ Name :- 217047 / 132KV Someshwar

Feeder No / Name : 701 / Someshwar SSK Ltd  
Feeder KV- 132 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
24	1.086
Max	1.086
Min	1.086
Avg	1.086